

SITE OBSERVATION REPORT

PROJECT No.: 170381202	CLIENT: 250 Seaport District, LLC c/o The Howard Hughes Corporation	DATE: Saturday, May 14, 2022
PROJECT: 250 Water Street		WEATHER: Overcast, 63.0 – 67.0 °F Wind: ESE @ 1.2 – 2.5 mph
LOCATION: New York, NY		TIME: 7:00 AM – 2:00 PM
BCP SITE ID: C231127		MONITOR: Lexi Haley, Audrey Seery

EQUIPMENT: MiniRAE 3000 PID DustTrak II Jerome J405® Jerome J505® Hand tools Comacchio MC28 Drill Rig CAT 374F Excavator	PRESENT AT SITE: Langan (Environmental) – Lexi Haley, Audrey Seery, Bill Pagano LendLease (Construction Manager) – Marty Cohen Civetta Cousins JV, LLC (CCJV) (Foundation Contractor) – George Washburn	Day 14
--	--	---------------

OBSERVATIONS, DISCUSSIONS, TEST RESULTS, ETC.:

Langan was present to document remediation and construction activities in accordance with the NYSDEC-approved November 2021 Remedial Action Work Plan (RAWP) at the 250 Water Street site (NYSDEC Brownfield Cleanup Program [BCP] Site No. C231127).

Site Activities

- CCJV continued advancing a foundation pile from about 20 feet to 85 feet below grade surface (bgs) in the southwestern portion of the site using a Comacchio MC28 drill rig. Municipally-supplied water was used during drilling activities and recirculated to facilitate installation of the pile and was temporarily containerized in a settling tank. Excess water generated during drilling activities was collected into a temporary sump, lined with polyethylene sheeting, and then pumped into the settling tank.
 - CCJV installed steel reinforcement bars within the pile in preparation for grout placement.
 - CCJV placed grout within the pile for installation of the future pile cap.
- CCJV graded previously imported 2.5-inch virgin stone for maintenance of the tracking pad in the northwestern portion of the site.
- CCJV placed concrete in an about 20-foot-long by 2-foot-wide area along the northern edge of the tracking pad to create an access ramp for vehicular access.

Cc: M. Raygorodetsky, P. McMahon, M. Au	By: Lexi Haley, Audrey Seery
	LANGAN

SITE OBSERVATION REPORT

Material Tracking

- No material was imported to the site.
- No material was exported from the site.

Material Import Summary		
Facility Name	Stone Industries, Inc.	
Location	Haledon, NJ	
Type of Material	2.5-inch Virgin Stone	
Quantities	No. of Loads	Approx. Volume (Tons)
Today	0	0
Total	1	22.79

Material Export Summary		
Facility Name	Allocco Recycling	
Location	Brooklyn, NY	
Type of Material	Construction & Demolition (C&D) Debris	
Quantities	No. of Loads	Approx. Volume (CY)
Today	0	0
Total	1	5

Sampling

- No samples were collected.

Cc:	M. Raygorodetsky, P. McMahon, M. Au	By:	Lexi Haley, Audrey Seery
			LANGAN

SITE OBSERVATION REPORT

CAMP Activities

Langan performed air monitoring at the perimeter of the site at six locations for particulate matter less than 10 microns in diameter (PM10), volatile organic compounds (VOCs), and mercury vapor, during ground-intrusive activities. Fifteen-minute average concentrations of PM10, VOCs and mercury vapor did not exceed the action levels established in the site community air monitoring plan (CAMP) for the duration of work activities. Prior to implementation of ground-intrusive work, background concentrations of mercury vapor and VOCs were recorded using the handheld Jerome® J505 mercury vapor analyzer and the handheld PID, respectively.

- Background concentrations of mercury vapor at each CAMP station ranged from 0.04 $\mu\text{g}/\text{m}^3$ to 0.08 $\mu\text{g}/\text{m}^3$.
- Background concentration of VOCs at each CAMP station were recorded at 0.0 parts per million (ppm).

Daily Average Concentrations

Station ID	Particulate (mg/m^3)	Organic Vapor (ppm)	Mercury Vapor ($\mu\text{g}/\text{m}^3$)
PM-1	0.039	0.0	0.0
PM-2	0.038	0.0	0.0
PM-3	0.031	0.0	0.0
PM-4	0.048	0.0	0.0
PM-5	0.018	0.0	0.1
PM-6	0.041	0.0	0.0

Maximum 15-Minute-Average Concentrations

Station ID	Particulate (mg/m^3)	Organic Vapor (ppm)	Mercury Vapor ($\mu\text{g}/\text{m}^3$)
PM-1	0.088	0.0	0.1
PM-2	0.067	0.3	0.0
PM-3	0.051	0.0	0.0
PM-4	0.076	0.0	0.0
PM-5	0.024	0.0	0.3
PM-6	0.060	0.0	0.0

• mg/m^3 = milligrams per cubic meter • ppm = parts per million • $\mu\text{g}/\text{m}^3$ = micrograms per cubic meter


- Langan used a handheld Jerome® J505 mercury analyzer to monitor ambient air conditions within the work zone and throughout the site. Instantaneous mercury vapor concentrations ranged from 0.00 $\mu\text{g}/\text{m}^3$ to 0.23 $\mu\text{g}/\text{m}^3$.
- Langan used a handheld photoionization detector (PID) to monitor VOC concentrations within the work zone and throughout the site. VOC concentrations were not detected above background concentrations throughout the work day.
- Prior to discontinuing the CAMP at the conclusion of ground-intrusive activities, VOC and mercury vapor concentrations were confirmed to return to background conditions at each perimeter station. CAMP stations were discontinued sequentially from 12:27 pm to 12:45 pm at the conclusion of ground-intrusive activities.
 - Mercury vapor concentrations at each CAMP station ranged from 0.00 $\mu\text{g}/\text{m}^3$ to 0.08 $\mu\text{g}/\text{m}^3$.
 - VOC concentrations at each CAMP station were recorded at 0.2 ppm.

Anticipated Activities

- CCJV will continue installation of foundation piles in the southwest portion of the site.

Cc:	M. Raygorodetsky, P. McMahon, M. Au	By:	Lexi Haley, Audrey Seery
			LANGAN

SITE OBSERVATION REPORT



Legend:

- PM-1 Approximate Location of Air Monitoring Station
- Approximate Work Area
- Approximate Location of Future Pile Cap
- Approximate Location of Foundation Piles In Progress
- Approximate Location of Foundation Piles Completed
- Approximate Location of Settling Tanks
- Approximate Location of Truck Tracking Pad

Notes:

1) Locations of air monitoring stations are approximate.

Cc:	M. Raygorodetsky, P. McMahon, M. Au	By:	Lexi Haley, Audrey Seery
			LANGAN

SITE OBSERVATION REPORT

Select Site Photographs:



Photo 1: View of concrete placed along the northern edge of the tracking pad (facing southwest).




Photo 2: View of CCJV advancing a foundation pile in the southwestern portion of the site (facing northwest).

Cc: M. Raygorodetsky, P. McMahon, M. Au

By: Lexi Haley, Audrey Seery

LANGAN