

DAILY STATUS REPORT

WEATHER	Snow		Rain		Overcast		Partly Cloudy		Bright Sun	X
TEMP.	< 32		32-50		50-70	X	70-85		> 85	

Prepared By:

JESSICA PROSCIA

NYSDEC BCP Project No.	C241199	NYCOER Project No.	17CVCP044Q	DATE:	10/19/2023
Project Name:	148-28 Hillside Avenue				

<u>Consultant:</u> Thomas Brown CA RICH Consultants	<u>Safety Officer:</u> Thomas Brown CA RICH Consultants
<u>General Contractor:</u> Oscar Velasquez, New York Fast General Contracting Corp.	<u>Site Manager/Supervisor:</u> Joseph Valente (3T Construction Inc.)
<u>Personnel Present and Affiliation:</u> -Thomas Brown (CA RICH) -Cesar (New York Fast General Contracting Corp.) -Roberto (New York Fast General Contracting Corp.) -Consallo (New York Fast General Contracting Corp.) - Joseph Valente (3T Construction Inc.) - Ying Yun (3T Construction Inc.) - Jordan (Big Apple Group)	<u>Equipment:</u> - Dusttrack II (upwind and downwind) - PID (upwind and downwind) - Caterpillar 318E Excavator
<p>Work Activities Performed (Since Last Report):</p> <ul style="list-style-type: none"> • Thomas Brown of CA RICH arrived on the site around 7:00 am. • CA RICH was present to document remediation activities and implement Community Air Monitoring Program (CAMP) in accordance with the NYSDEC approved April 2023 Interim Remedial Measure Work Plan (IRM). • CA RICH setup an upwind CAMP station in C1 and a downwind CAMP station in A4. • Four loads of hazardous soil that was stockpiled from the July 2022 NYSDEC Spill 2203747 was removed and sent to Clean Earth North Jersey. • CA RICH representative left the site around 9:00 am. 	
<p>Grids Worked In: A2</p>	
<p>Samples Collected (Since Last Report): None</p>	

Air Monitoring (Since Last Report):

An Upwind PDR station was set up in grid: C1

Odors: None

Maximum VOC level (PPM): 0.0

Pre-start Conditions – PID = 0.2 ppm, Dust = 34 $\mu\text{g}/\text{m}^3$

Maximum Particulate Level Upwind (ug/m^3): 34

No 15min TWA exceedances were identified in the upwind station.

A Downwind PDR station was set up in grid: A4

Odors: None

Maximum VOC level (PPM): 0.0

Pre-start Conditions – PID = 0.0 ppm, Dust = 30 $\mu\text{g}/\text{m}^3$

Maximum Particulate Level Downwind (ug/m^3): 33

No 15min TWA exceedances were identified in the downwind station.

Problems Encountered:

None

Planned Activities for the Next Day/Week:

- Perform community air monitoring using PIDs and dust monitors;
- Underpinning;
- Soil removal to Clean Earth of Carteret;
- Soil removal to the Clean Soil Bank; and
- End-point soil sampling.

Locations of work and quantities of material imported and exported from the Site:

Facility # Name/ location type of waste	Clean Earth of Carteret 24 Middlesex Ave. Carteret, NJ Solid	
Trucks or Cubic Yards	Trucks	Cubic Yards
Today	0	0
Totals	192	3,840

NYC Clean Soil Bank	Receiving Facility: 830 Forbell Street, Brooklyn NY 11208	
Trucks or Cubic Yards	Trucks	Cubic Yards
Today	0	0
Totals	67	1,944

Facility # Name /location Type of waste	Clean Earth of North Jersey Jacobus Avenue Kearny, NY Solid	
Trucks or Cubic Yards	Trucks	Cubic Yards
Today	4	80
Totals	4	80

Site Grid Map




Photo Log

Photo 1 –

View of
trucking out
soil.



Photo 2 –

View of soil
pile being
removed.




Photo 3 –

View of soil pile being removed.



Photo 4 –

View of trucking out soil.



Hillside Avenue

A

B

C

D



1

X Upwind

2

has
Pile




3

4

X Downwind

Approx. Scale (ft):



Date: 10/19/23

Notes:

CA RICH CONSULTANTS

Environmental Specialists Since 1982
17 Dupont Street, Plainview, New York 11803

TITLE:

Daily Report Grid

DATE:

8/25/2023

SCALE:

As Shown

FIGURE:

1

148-28 Hillside Avenue
Jamaica, Queens, NY

DRAWN BY:

T.R.B.

DRAWING NO:

2023-1

APPR. BY:

J.E.P.


Air Monitoring
(Parts Per Million)
Hillside 168 Inc.
148-28 Hillside Avenue
Jamaica, Queens, NY

Date: 10/19/23
Meter Reading: PID (ppm)

TIME	LOCATION					
	A	B	C	D	E	F
7:00						
7:30	0.6	0.0				
8:00	0.0	0.0				
8:30	0.0	0.0				
9:00						
9:30						
10:00						
10:30						
11:00						
11:30						
12:00						
12:30						
13:00						
13:30						
14:00						
14:30						
15:00						
15:30						
16:00						
16:30						
17:00						

Locations:

- A Upwind
- B Downwind
- C
- D
- E
- F



CA RICH Consultants**Community Air Monitoring Program - DUST (PM-10)**

Project: Hillside 168 Inc.
Location: 148-28 Hillside Avenue, Queens NY
Date: 10/19/2023

Upwind Serial Number 8530203032
Downwind Serial Number 8530172012

Upwind		Downwind		Corrected Downwind	Comments
Time	Concentration [ug/m3]	Time	Concentration [ug/m3]	Concentration [ug/m3]	
7:53:29 AM	34	7:57:37 AM	30	-4	
8:08:29 AM	28	8:12:37 AM	33	5	