


	Daily Activity Report					
	Magnolia Gardens					
	39-03 College Point Boulevard, Queens, NY					
	BCP Site No. C241273					
General Site Information						
Date:	Wednesday, July 10, 2024					
Weather:	76-89°F, Mostly Sunny					
Wind Direction/Speed (towards):	S @ 6-12 mph					
AKRF Personnel on Site:	Isabella Legovich					
AKRF Equipment on Site:	Mini RAE 3000 Photoionization Detectors [(PID) x3] and DustTrak Aerosol Monitors (x3)					
Visitors:	None					
Contractor Information						
Subcontractor						
Archstone Builders LLC			General Contractor (GC)			
Capstone Contracting Corp.			Foundation Contractor			
Description and Location of Work Activities Performed						
Contractor cinstalled vapor barrier and rebar, and poured concrete in Grids WC-1/2/6/7/8.						
Contractor installed sub-slab SSDS piping in the central and northern portion of the site, and installed vapor barrier in Grid WC-2.						
Material Disposal Tracking Information						
Destination Facility/Material Type	Daily Trucks	Total Trucks	Daily Approx. Cubic Yds	Total Approx. Cubic Yds	Total Site Loads	Total Approximate Cubic Yards
Clean Earth of North Jersey (CENJ)/(haz lead soil)	0	10	0	200	439	8,780
Clean Earth of North Jersey (CENJ)/(haz TCE soil)	0	6	0	120		
Bayshore Soil Management, LLC (Bayshore)	0	318	0	6,360		
River Front Recycling (C&D)	0	15	0	300		
Clean Earth of Carteret (CEC)	0	90	0	1,800		
Import Material Tracking Information						
Origin Facility	Daily Trucks	Total Trucks	Daily Tonnage	Total Tonnage	Total Site Loads	Total Quantity (tons)
Aero Aggregate	0	2	0	108.8 CY	2 (32 total bags on flatbeds)	108.8 CY
Tilcon, Goshen or West Nyack Quarry	0	24	0	551.55	24	551.55 tons
Vulcan, Wantage or Hamburg Quarry	0	9	0	203.07	9	203.07 tons
CAMP Air Monitoring Results						
CAMP Station	UPWIND			DOWNWIND		
Odors:	None			None		
VOC Action Level Exceedance(s):	None			None		
Particulate Action Level Exceedance(s):	None			None		
Maximum VOC Level (ppm) 15-min avg:	0.0057			0.0000		
Maximum Particulate Level (mg/m³) 15-min avg:	0.0425			0.8199		
CAMP Response Actions: The Downwind CAMP station experienced an elevated particulate reading between 11:12AM and 11:15AM due to a worker knocking over the equipment (not due to site-related activities).						
Additional Information						
Planned Work Activity for Next Day/Week:	Foundation construction to continue. SSDS work to continue.					
Comments:	None					




Soil Waste Classification Grid Plan



- LEGEND**
- PROJECT SITE BOUNDARY
 - WASTE CHARACTERIZATION GRID
 - LOT BOUNDARY AND TAX LOT NUMBER
 - 4973 BLOCK NUMBER
 - EXISTING BUILDING
 - PROPOSED NEW BLDG FOOTPRINT
 - PROPOSED SUNKEN YARD FOOTPRINT
 - 10X10 FEET HOTSPOT
 - LEAD AND TCE HOTSPOT SAMPLE LOCATION
 - WC-2 WASTE CHARACTERIZATION GRID NAME





Site Photographs	
Photograph 1 - Installation of vapor barrier in Grids WC-1/6, facing east.	 <p>July 10, 2024 at 7:18 AM 133-04 39th Ave New York NY 11354 United States</p>
Photograph 2 - Pouring concrete in central portion of site, facing east.	 <p>July 10, 2024 at 8:39 AM 133-04 39th Ave New York NY 11354 United States</p>
Photograph 3 - Installation of GPA and geotextile fabric layer for SSDS.	 <p>July 10, 2024 at 1:56 PM 133-16 39th Ave New York NY 11354 United States</p>