SESI
CONSULTING ENGINEERS

Geotechnical
Environmental
Site Civil

959 Route 46E, Fl 3, Ste 300
Parsippany, NJ 07054
973.808.9050
www.sesi.org

Phase I Environmental Site Assessment

For:

80 Main Street

White Plains, Westchester County, NY

SESI Project No:
12859

Prepared for:

MLK Developers LLC
March 2025

TABLE OF CONTENTS

LIST OF ACRONYMS ..... **i**

1.0 PROJECT SUMMARY **1**

2.0 INTRODUCTION **5**

2.1. PURPOSE 5

2.2. SCOPE OF SERVICES 5

2.3. SIGNIFICANT ASSUMPTIONS 6

2.4. LIMITATIONS/METHODOLOGY/RELIANCE 6

2.5. DISCLAIMER 7

3.0 SUBJECT PROPERTY DESCRIPTION **8**

3.1. LOCATION/STRUCTURES/LEGAL DESCRIPTION 8

3.2. SUBJECT PROPERTY AND VICINITY CHARACTERISTICS 8

3.3. CURRENT USE OF THE PROPERTY 8

3.4. DESCRIPTION OF STRUCTURES, ROADS AND SITE IMPROVEMENTS 9

4.0 SITE BACKGROUND INFORMATION **10**

4.1. TITLE INFORMATION 10

4.2. ENVIRONMENTAL LIENS OR ACTIVITY AND USE LIMITATIONS 10

4.3. SPECIALIZED KNOWLEDGE/OTHER USER PROVIDED INFORMATION 10

4.3.1. INTERVIEWS 10

4.4. COMMONLY KNOWN OR REASONABLY ASCERTAINABLE RECORDS 10

4.5. VALUATION REDUCTION FOR ENVIRONMENTAL ISSUES 10

4.6. OWNER, PROPERTY MANAGER, AND OCCUPANT INFORMATION 11

5.0 RECORDS REVIEW **12**

5.1. STANDARD ENVIRONMENTAL RECORD SOURCES: FEDERAL, CITY, STATE 12

5.1.1. EDR SEARCH 12

5.1.2. ENVIRONMENTAL REPORTS 23

5.1.3. LOCAL, COUNTY, AND STATE INFORMATION REQUESTS 23

5.2. PHYSICAL SETTING SOURCES 24

5.2.1. TOPOGRAPHY 24

5.2.2. SURFACE WATERS AND WETLANDS 24

5.2.3. GEOLOGY AND GROUNDWATER 24

5.3. HISTORICAL USE INFORMATION FOR THE PROPERTY 24

5.3.1. AERIAL PHOTOGRAPHS 25

5.3.2. EDR CITY DIRECTORY ABSTRACT 26

5.3.3. USGS TOPOGRAPHIC MAPS 26
5.3.4. SANBORN FIRE INSURANCE MAPS 27
5.4. ENVIRONMENTAL LIEN AND AUL SEARCH REPORT 29
5.5. ENVIRONMENTAL PERMITS 30
6.0 SITE RECONNAISSANCE 31
6.1. METHODOLOGY AND LIMITING CONDITIONS 31
6.2. SUBJECT PROPERTY OBSERVATIONS 31
6.3. CHEMICAL STORAGE AND USAGE 31
6.4. BULK STORAGE TANKS 31
6.5. SUBJECT PROPERTY WASTE AND WASTEWATER 31
6.6. STAINED SOIL, STAINED PAVEMENT, OR STRESSED VEGETATION 31
6.7. PITS, PONDS, OR LAGOONS 31
6.8. WELLS 31
6.9. FLOOR DRAINS AND SUMPS 32
6.10. PCB-CONTAINING MATERIAL, INCLUDING CAULK 32
6.11. ASBESTOS-CONTAINING MATERIAL 32
6.12. RADON 32
6.13. UNIVERSAL WASTE 32
6.14. LEAD-BASED PAINT 32
6.15. VAPOR INTRUSION 33
7.0 DATA GAPS 34
8.0 FINDINGS 35
9.0 OPINIONS 36
10.0 CONCLUSIONS AND RECOMMENDATIONS 37
11.0 DEVIATIONS 40
12.0 REFERENCES 41
13.0 SIGNATURE OF ENVIRONMENTAL PROFESSIONAL 42

TABLES

TABLE 3.1 ADJACENT PROPERTY USES
TABLE 5.1 PROPERTY LISTINGS
TABLE 5.2 AERIAL PHOTOGRAPHIC REVIEW
TABLE 5.3 TOPOGRAPHIC MAP REVIEW
TABLE 5.4 SANBORN MAP REVIEW

FIGURES

FIGURE 1.1 TAX MAP
FIGURE 1.2 SUBJECT PROPERTY LOCATION MAP
FIGURE 1.3 SUBJECT PROPERTY PLAN
FIGURE 10.1 REC LOCATION PLAN

APPENDICES

APPENDIX A USER QUESTIONNAIRE
APPENDIX B ENVIRONMENTAL RECORD SEARCH RESULTS AND INFORMATION REQUESTS
APPENDIX C ENVIRONMENTAL DATA RESOURCES, INC. REPORTS
APPENDIX D ENVIRONMENTAL REPORTS AND RELEVANT HISTORICAL DOCUMENTS
APPENDIX E SITE PHOTO LOG

LIST OF ACRONYMS

Acronym	Definition
BCP	Brownfield Cleanup Program
ACM	Asbestos-Containing Material
AST	Aboveground Storage Tank
BER	Business Environmental Risk
CREC	Controlled Recognized Environmental Condition
EDR	Environmental Data Resources
ESA	Environmental Site Assessment
HREC	Historical Recognized Environmental Condition
LBP	Lead-based Paint
MSL	Mean Sea Level
PAH	Polycyclic Aromatic Hydrocarbons
PCB	Polychlorinated Biphenyls
PFAS	Per and Polyfluoroalkyl Substances
PFOA	Perfluorooctanoic Acid
PFOS	Perfluorooctanesulfonic Acid
PGWSCO	Protection of Groundwater Soil Cleanup Objective
RAO	Response Action Outcome
REC	Recognized Environmental Conditions
RRSCO	Restricted Residential Use Soil Cleanup Objectives
SESI	SESI Consulting Engineers, DPC
USCO	Unrestricted Use Soil Cleanup Objectives
USEPA	United States Environmental Protection Agency
UST	Underground Storage Tank
VOC	Volatile Organic Compound

1.0 PROJECT SUMMARY

SESI Consulting Engineers (SESI), at the request of MLK Developers LLC (User), has conducted a Phase I Environmental Site Assessment (ESA) for the property located at 80 Main Street, White Plains, New York (herein referred to as the Subject Property). The Subject Property is a 1.1743-acre with the tax designation Section 125.75 Block 4 Lot 2..2. The Subject Property is located in a commercial/residential/government building area and the Subject Property was previously used as a portion of the Galleria Mall. The Subject Property is currently vacant. A tax map is included on **Figure 1.1**. A Subject Property Location Map is included on **Figure 1.2**. A Subject Property Plan is included on **Figure 1.3**.

The Subject Property was developed prior to 1885 based on the Sanborn Fire Insurance Maps and contained the following historic uses (circa 1885-1950) that were noted to be of concern: gas tank, carriage shop (including woodworking), several blacksmiths with painting, marble cutter, cabinet shop, furniture repair,, tailor, several printing shops (one with gas engine), laundry, tailors several paint and oil shops, cobbler, several upholstery shops, and bicycle repair shop. The Galleria Mall was constructed in approximately 1980. The ground floor of the Subject Property was previously improved with a Blink Fitness gym as well as storage rooms, a mechanical room, an electrical room, common spaces for the mall, and a loading dock. The second through fourth floors consisted of retail and common spaces associated with the Galleria Mall.

The Subject Property is presently owned by WP Galleria Realty LP based on publicly available information and the questionnaire provided by the User. The Subject Property is located in a commercial/residential/government area and the Subject Property is part of a vacant mall.

The objective of this ESA is to identify the presence or likely presence, use or release on the Subject Property of hazardous substances or petroleum products as defined in the American Standard of Testing and Materials (ASTM) E1527-21 as a Recognized Environmental Condition (REC). In addition, Business Environmental Risks (BERs), Controlled Recognized Environmental Conditions (CRECs), and Historical Recognized Environmental Conditions (HRECs) were identified, if present.

The following RECs have been identified:

- **REC 1 – Historical Site Usages**: Historic operations circa 1885-1950 at the Subject Property that are considered of concern include: gas tank, carriage shop (including woodworking), several blacksmiths with painting, marble cutter, cabinet shop, furniture repair,, tailor, several printing shops (one with gas engine), laundry, tailors several paint and oil shops, cobbler, several upholstery shops, and bicycle repair shop.. Soil, ground water, and soil vapor sampling conducted during the Phase II ESA identified impacts that appear to be partially attributable to former on-site operations. Additional investigation is required.
- **REC 2 – On-site Contamination:** SESI conducted subsurface soil, soil vapor and groundwater sampling to investigate for the Site historical usages. Analytical results of this investigation identified VOCs were found to exceed the USCOs from grade to 9.5 ft-bgs (SB-21G[9-9.5]). SVOCs (primarily PAHs) were found to exceed the Protection of Groundwater Soil Cleanup Objectives (PGWSCOs), Restricted Residential Soil Cleanup Objectives (RRSCOs) or Unrestricted Use Soil Cleanup Objectives (USCOs) throughout the Site from grade to 6.5 ft-bgs (SB-10G[6-6.5]). Metals were found above the USCOs throughout the Site to depths ranging from grade to 5.5 ft-bgs (SB-7G[5-5.5]). Pesticides were found above the USCOs to 4 ft-bgs at the southern and northern portions of the Site (SB-22 [3.5-4]) and SB-45G [3.5-4]).

- Volatile organic compounds (VOCs), Per and Polyfluoroalkyl Substances (PFAS), polycyclic aromatic hydrocarbons (PAHs), and metals were found in groundwater to exceed the AWQS throughout the Site, likely associated with historical uses, potential USTs, and historic fill contamination.

- Several PHC and chlorinated VOCs were detected in the soil vapor and indoor air samples, which may indicate contamination is present throughout the Site.

- SESI recommends that prior to any development on the Subject Property additional investigation be conducted to delineate the extent of the SVOCs (PAHs), metals, pesticides, and PFAS contamination in soil and to evaluate soil remedial options. The investigation should also delineate the VOC, SVOCs (PAHs), metals, and PFAS contamination in groundwater and evaluate remedial options available to comply with the

AWQS. Finally, a soil vapor intrusion evaluation is recommended to address the potential for soil vapor contamination.

- **REC 3 –Upgradient Concerns**:

  - *50 Court Street BCP Site (C360258)*:
    - Two (2) releases (Spill Nos. 8803673 and 8805571) were identified in connection with the upgradient northern adjacent property located at 180 Main Street (see below). The spills were identified in the EDR LTANKS and NY SPILLS databases and reported to the NYSDEC in 1988. These spills were attributed to the release of undetermined gallons of No. 2 fuel oil from a10,000-gallon UST. These spills are administratively closed with the NYSDEC. However, no closure documentation or testing data was available for review. Subsurface testing has identified impacts to soil exceeding the NYSDEC soil cleanup objectives, impacts to soil vapor exceeding the NYSDOH lower threshold values, and impacts to groundwater exceeding the NYSDEC AWQSs.

  - *180 Main Street Property*:
    - The Site was developed prior to 1885 based on the Sanborn Fire Insurance Maps. Historical land uses included print shops, painting and oil shops, bottling works, plumbing and tin shops, a bowling alley, a fire department and a portion of the Westchester County Courthouse and commercial/residential spaces (circa 1885-1950), followed by the Galleria Mall. The Galleria Mall was constructed in approximately 1980. The Subject property was improved with the Galleria Mall anchor store Abraham and Straus (circa 1980-1995), and then Sterns (circa 1995-1996), and then Macys (circa 1996 to 2023). Two (2) 10,000-gallon fuel oil underground storage tanks (USTs) were closed in place in January 1997 (PBS 3-173665). Two (2) spills had been reported to the NYSDEC in 1988 identified as Spill Nos. 8803673 and 8805571. Both of these spills appear to be related to tank test failures associated with a 10,000-gallon underground storage tank (UST). Subsurface testing has identified impacts to soil exceeding the NYSDEC soil cleanup objectives and impacts to groundwater exceeding the NYSDEC AWQSs.

The following BERs have been identified:

- **BER 1 – Polychlorinated Biphenyl (PCB) Caulk:** A PCB survey was not completed during SESI's walkthrough of the Subject Property. There are likely several areas present that contain caulking. Therefore, a PCB survey is recommended prior to any demolition or redevelopment of the Subject Property.
- **BER 2 – Asbestos-Containing Material (ACM):** An ACM survey was not completed during SESI's walkthrough of the Subject Property. Based on the age of the building, SESI recommends an ACM survey prior to any demolition or redevelopment of the Subject Property.
- **BER 3 – Universal Waste:** There were several pieces of universal waste identified during the walkthrough of the Subject Property; however, a complete survey of this universal waste was not completed. SESI recommends a universal waste survey prior to any demolition or redevelopment of the Subject Property.
- **BER 4 – Lead-Based Paint (LBP):** An LBP survey was not completed during SESI's walkthrough of the Subject Property. Based on the age of the building, SESI recommends an LBP survey prior to any demolition or redevelopment of the Subject Property.
- **BER 5 – Vapor Intrusion:** Data from the Phase II ESA suggests vapor intrusion may be a concern. In particular, one sample location identified benzene and ethylbenzene in both soil gas and indoor air. Therefore, SESI recommends further evaluation of the vapor intrusion pathway at the Subject Property as part of the redevelopment process.

The RECs are discussed further in **Section 10.0 CONCLUSIONS AND RECOMMENDATIONS** of this Report.

2.0 INTRODUCTION

2.1. PURPOSE

The purpose of this study is to determine the RECs at the Subject Property for due diligence purposes related to the potential acquisition of the Subject Property.

SESI has developed this Phase I ESA Report on behalf of the User. It has been developed in substantial conformance with the ASTM's International Standard Practice for Environmental Site Assessments: Phase I Environmental Site Assessment Process E 1527-21. According to ASTM E1527-21, the following conditions were identified during this assessment:

REC – "(1) the presence of hazardous substances or petroleum products in, on, or at the property due to release to the environment; (2) the likely presence of hazardous substances or petroleum products in, on, or at the property due to a release or likely to the environment; or (3) the presence of hazardous substances or petroleum products in, on, or at under conditions that pose a material threat of a future release to the environment. A de minimis condition is not a recognized environmental condition."

CREC – "A recognized environmental condition resulting from a past release of hazardous substances or petroleum products that has been addressed to the satisfaction of the applicable regulatory authority."

HREC – "A past release that has been remediated to below residential standards and given regulatory closure with no use restrictions."

BER – "A risk which can have a material environmental or environmentally-driven impact on the business associated with the current or planned use of commercial real estate and is not an issue required to be investigated under this practice."

2.2. SCOPE OF SERVICES

The scope of this assessment consisted of the following general tasks: a records review; a Site visit; interviews with present and past owners, operators, and occupants to the extent possible; and preparation of this ESA report. Specific tasks that were conducted included the following:

- A review of environmental databases maintained by the United States Environmental Protection Agency (USEPA) and state and local agencies within the minimum search distance. Environmental Data Resources, Inc. (EDR) prepares environmental databases used in these assessments.

- A Site reconnaissance to observe conditions and to assess the Subject Property location with respect to adjoining and surrounding property uses, types of development, topography, natural surface features, roadways, railroad lines and right-of-ways to identify obvious potential environmental conditions on neighboring properties.

Per ASTM E1527-21, questionnaires were provided to the User (Client) and Owner to obtain information related to the Subject Property.

2.3. SIGNIFICANT ASSUMPTIONS

Information obtained by SESI and by third parties is assumed to be accurate and/or true. SESI makes no warranty, either implied or expressed, regarding the accuracy or validity of information supplied by others.

2.4. LIMITATIONS/METHODOLOGY/RELIANCE

This ESA was prepared for the exclusive use of User, its affiliates and lenders. During the assessment, methodologies were used that conform to generally accepted practices for this type of work. The scope and character of the environmental assessment were, in professional judgment, sufficient to justify the stated conclusions, after giving due consideration to the purpose of the investigation, the data reviewed, the background history of the Subject Property as found in historical records, and visual observation of the Subject Property. No other investigation was performed other than that which is expressly noted in this Report.

This ESA was performed in accordance with ASTM E1527-21 and is subject to reasonable limits of time and cost and is intended to reduce but not eliminate uncertainty regarding the potential for RECs in connection with a property. Sampling and laboratory analysis are required to determine if soil, surface water, groundwater, air, and construction materials have been impacted by a contaminant.

The information presented in this ESA was obtained during the Site reconnaissance and from the Client, representatives of the Client, current/former property owner(s) or tenants, Federal, State, County and Local Officials, and available mapped information obtained by SESI. SESI does not certify the accuracy of the information received from outside sources.

This ESA should be used in its entirety. Use of portions of this ESA may nullify the information and/or conclusions of this ESA. Subject property observations discussed herein apply to Subject Property conditions as observed during Site reconnaissance only. The conclusions of this ESA do not apply to conditions that were unavailable for inspection and could not be evaluated.

SESI does not certify that the Subject Property is contaminant free and this ESA does not serve as a warranty. SESI's investigation was performed within the time frame requested by the client.

The activities to conduct this ESA did not include sampling and analyses of soil, surface water, groundwater, air, or construction materials unless expressed otherwise and requested by the client. Formal wetland, asbestos, mold, and/or radon evaluations were not performed and are not within the scope of work for an ESA. If additional services including UST testing, construction materials testing, or environmental sampling (soil, surface water, groundwater, air) is recommended, the results and conclusions for these tests will be provided under separate cover.

2.5. DISCLAIMER

This ESA was prepared by SESI for the sole and exclusive use of User . Nothing under the Agreement between SESI and the User shall be construed to give any rights or benefits to anyone other than the User and SESI, and all duties and responsibilities undertaken pursuant to the Agreement will be for the sole and exclusive benefit of the User and SESI and not for the benefit of any other party. SESI does not intend, without its written consent, for this ESA to be disseminated to anyone other than the User, or to be used or relied upon by anyone other than the User. Use of the ESA by any other person is unauthorized and such use is at their sole risk.

3.0 SUBJECT PROPERTY DESCRIPTION

3.1. LOCATION/STRUCTURES/LEGAL DESCRIPTION

The Subject Property consists of a 1.1743-acre parcel located at 80 Main Street, White Plains, Westchester County, New York. The Subject Property is identified on tax map records as Section 125.75 Block 4 Lot 2..2. A tax map is included on **Figure 1.1.** The Subject Property is located in a commercial/residential/government building area and the Subject Property was previously used as a portion of the Galleria Mall. The Subject Property is currently vacant and no longer contains mall operations. **Figure 1.2** provides a Subject Property Location Map. A Subject Property Plan is shown on **Figure 1.3.**

The Subject Property is proposed to be redeveloped with apartment, retails stores, and associated parking.

The Subject Property is bound to the north by commercial/office/residential, to the south by government/office, to the east by commercial/office/residential/park, and to the west by office/apartments. Adjacent properties are noted on **Table 3.1** below.

Table 3.1—Adjacent Property Uses

Direction	Adjacent Property Use
North	Commercial/Office/Residential
South	Government/Office
East	Commercial/Office/Residential/Park
West	Office/Apartments

3.2. SUBJECT PROPERTY AND VICINITY CHARACTERISTICS

The Subject Property is located in a commercial, office, and residential area. The closest notable surface water body is the Bronx River located approximately 1,400 feet west of the Subject Property.

3.3. CURRENT USE OF THE PROPERTY

The Subject Property is currently a vacant mall . The Subject Property is owned by WP Galleria Realty LP based on publicly available information and the questionnaire provided by the User.

3.4. DESCRIPTION OF STRUCTURES, ROADS AND SITE IMPROVEMENTS

The Subject Property is a rectangle shaped parcel that is 1.1743-acres in size and currently improved with a large structure that was formerly part of the Galleria Mall. The ground floor of the Subject Property was previously improved with a Blink Fitness gym as well as storage rooms, a mechanical room, an electrical room, common spaces for the mall, and a loading dock. The second through fourth floors consisted of retail and common spaces associated with the Galleria Mall.

4.0 SITE BACKGROUND INFORMATION

4.1. TITLE INFORMATION

A chain of title and deed search was not prepared as part of this Phase I ESA. Should this information be provided, SESI reserves the right to include this information at a later date.

4.2. ENVIRONMENTAL LIENS OR ACTIVITY AND USE LIMITATIONS

A lien or activity use limitation search was not conducted as part of this Phase I ESA. Should this information be provided, SESI reserves the right to include this information at a later date.

4.3. SPECIALIZED KNOWLEDGE/OTHER USER PROVIDED INFORMATION

SESI was not provided any historic reports related the Subject Property.

4.3.1. INTERVIEWS

The ESA questionnaire was provided to the User and the response received on March 5, 2025. After review of the document, no new or previously unknown information was identified. A representative directed a tour of the facility. Information obtained from this interview, questionnaire and Subject Property inspection is integrated in this Phase I ESA. A completed User Questionnaire is presented as **Appendix A**.

4.4. COMMONLY KNOWN OR REASONABLY ASCERTAINABLE RECORDS

SESI completed a review of publicly available New York State Department of Environmental Conservation mapping and database systems and the United States Environmental Protection Agency (USEPA) database system as part of this Report to determine the environmental conditions at the Subject Property and adjacent properties. Information requests are presented as **Appendix B**.

4.5. VALUATION REDUCTION FOR ENVIRONMENTAL ISSUES

The Report User indicated no knowledge of any valuation reduction related to environmental concerns.

4.6. OWNER, PROPERTY MANAGER, AND OCCUPANT INFORMATION

The Subject Property parcel is currently owned by WP Galleria Realty LP and is occupied periodically by Homeland Security and the local police department for active shooter drills.

5.0 RECORDS REVIEW

5.1. STANDARD ENVIRONMENTAL RECORD SOURCES: FEDERAL, CITY, STATE

5.1.1. EDR SEARCH

A search of available environmental records was conducted by EDR and reported in the EDR Radius Map Report with GeoCheck. The Report meets the government records search requirements of ASTM Standard of Practice for Environmental Site Assessments, E-1527-21. Search distances are per ASTM standards. A Radius Map Check was performed by EDR and are provided in **Appendix C**. All properties in the search area with environmental records are listed below:

Table 5.1—Property Listings

Environmental Listing	Subject Property	0-1/8 Miles	1/8 - 1/4 Miles	1/4 - 1/2 Miles	1/2-1 Mile
RCRA-LQG	0	1	1	NR	NR
RCRA-SQG	1	3	2	NR	NR
RCRA-VSQG	1	3	5	NR	NR
NY SHWS	0	0	0	1	1
NY LTANKS	1	16	28	130	NR
NY UST	3	15	38	NR	NR
NY AST	0	10	16	NR	NR
NY ENG CONTROLS	0	1	0	1	NR
NY INST CONTROL	0	1	1	1	NR
NY VCP	0	1	0	0	NR
NY BROWNFIELDS	0	2	4	4	NR
NY Spills	1	36	NR	NR	NR
RCRA NonGen / NLR	4	45	44	NR	NR
FUSRAP	0	1	0	0	0
FINDS	7	0	NR	NR	NR
ECHO	6	0	NR	NR	NR
FUELS PROGRAM	0	1	0	NR	NR
UST FINDER RELEASE	0	5	6	13	NR
UST FINDER	0	1	0	NR	NR
E MANIFEST	5	5	5	NR	NR
NY PFAS	0	0	1	NR	NR
NY MANIFEST	4	54	63	NR	NR
PA MANIFEST	0	2	2	NR	NR
NJ MANIFEST	0	19	17	NR	NR
MI MANIFEST	1	0	0	NR	NR
NY COOLING TOWERS	4	0	NR	NR	NR
NY MGP	0	1	0	0	0
EDR MGP	0	1	0	0	0
EDR Hist Auto	0	2	NR	NR	NR
EDR Hist Cleaner	0	5	NR	NR	NR

The EDR Radius Map Report identified operations at the Subject Property in numerous databases. However, the Subject Property address most often referred to the Galleria Mall as a whole and not the particular condominium space being evaluated as part of this Phase I ESA. Therefore, SESI used professional judgement to determine whether the listings were actually on the Subject Property or associated with other areas of the mall as discussed below:

RCRA Small Quantity Generator (RCRA-SQG)

The RCRA-SQG includes a list of facilities that generate more than 100 but less than 1,000 kilograms of hazardous waste per month and accumulates less than 6,000 kilograms of hazardous waste at any time. According to the RCRA-SQG list provided by EDR, there is one (1) RCRA-SQG facility (Picture People The) located on the Subject Property. However, a review of the operation did not identify any environmental release(s) of hazardous materials. Therefore, this listing is not considered a REC.

LTANKS: Leaking Storage Tank Incident Reports

Leaking Storage Tank Incident Reports. These records contain an inventory of reported leaking storage tank incidents reported from 4/1/86 through the most recent update. They can be either leaking underground storage tanks or leaking aboveground storage tanks. The causes of the incidents are tank test failures, tank failures or tank overfills. A review of the database as provided by EDR identified three (3) listings (one [1] for JC Penney Co Inc and two [2] for A&S Store) on the Subject Property, as follows:

- Historic Spill No. 8803673 (July 27, 1988), A&S Store, Galleria Plaza: Test of a 10,000-gallon No. 2 fuel oil tank failed. The noted impacts were to groundwater, and the case was reported as closed by the NYSDEC on June 13, 1991.
- Historic Spill No. 8805571 (September 9, 1988), A&S Store, Galleria Plaza: Test of a 10,000-gallon No. 2 fuel oil tank failed. The noted impacts were to groundwater, and the case was reported as closed by the NYSDEC on June 13, 1991.
- Historic Spill No. 9102767 (June 10, 1991), JC Penny Co Inc, Galleria: 20 gallons of No. 2 fuel oil spilled from a tank overfill. The noted impacts were to concrete/soil, and the case was reported as closed by the NYSDEC on June 13, 1991.

Based on available information, the listings for the A&S Store are associated with the eastern adjoining property at 180 Main Street and are not associated with the subject property. The listing for the JC Penney store is related to the western adjacent BCP Site at 60 Main Street (C360285). The former spills were closed by NYSDEC and were not on-site however they are considered RECs due to their proximity to the Subject Property.

UST: Underground Storage Tank Data

USTs are regulated under Subtitle I of the Resource Conservation and Recovery Act (RCRA) and must be registered with the state department responsible for administering the UST program. Available information varies by state program. A review of the NY UST list provided by EDR identified four (4) listings (J.C. Penney, The Galleria at White Plains, JC Penney, Galleria West Garage 5) on the Subject Property. These listings are further described below:

- PBS No. 3-173665, JC Penny, 100 Main Street: 2x10,000-gallon USTs closed in place, 1x100-gallon UST converted to non-regulated use, and 1x1,000-gallon UST converted to non-regulated use.
- PBS No. 3-492205, The Galleria at White Plains, 100 Main Street: 2x10,000-gallon USTs closed in place (Macy's Store).
- PBS No. 3-600104, JC Penny, 100 Main St: 1x8,000-gallon UST closed in place.
- PBS No. 3-169579, Galleria West Garage 5, Martine Ave & So Lexington Ave: 1x1,000-gallon diesel UST. Installed December 1, 1980. Removed and closed November 1, 1994.

The Galleria at White Plains listing (3-492205) is associated with the eastern adjoining property located at 180 Main Street) Regardless, it is a concern due to the lack of closure documentation and its upgradient location proximal to the Subject Property. Further, the UST listing at Galleria West Garage 5 is likely associated with the southern Galleria Mall parking garage to the south. Both of these listings are a concern due to their lack of closure documentation and location proximal to the Subject Property. The JC Penney listings (3-173655 and 3-600104) are associated with western adjacent pending BCP site and are a concern due to their proximity to the Subject Property.

AST: Petroleum Bulk Storage

Registered Aboveground Storage Tanks. A review of the database as provided by EDR identified the Subject Property as containing one (1) listing (Galleria West Garage 5) in the AST database. This listing is further described below:

- PBS No. 3-169579, Galleria West Garage 5, Martine Ave & So Lexington Ave: 2x300-gallon diesel ASTs (Tank Nos. 32 and 33) administratively closed.

This listing is likely associated with the southern adjacent mall parking garage. Proper closure documentation and current AST status are unknown and is a concern due to its proximity to the Subject Property.

SPILLS: Spills Information Database

Data collected on spills reported to NYSDEC as required by one or more of the following: Article 12 of the Navigation Law, 6 NYCRR Section 613.8 (from PBS regs), or 6 NYCRR Section 595.2 (from CBS regs). It includes spills active as of April 1, 1986, as well as spills occurring since this date. A review of the database as provided by EDR identified the Subject Property under the listings JC Penney Co Inc and White Plains Garage. The spill listings are as follows:

- Historic Spill No. 9102767 (June 10, 1991): 20 gallons of No. 2 fuel oil spilled from a tank overfill. The noted impacts were to concrete/soil, and the case was reported as closed by the NYSDEC on June 13, 1991.
- Historic Spill No. 9110939 (January 22, 1992), White Plains Garage, Main St & Grove St: 1 gallon of No. 2 fuel oil spilled from a vent tank overfill. Speedy Dry was applied. The noted impacts were to soil, and the case was reported as closed by the NYSDEC on January 24, 1992.
- Historic Spill No. 0703055 (June 13, 2007), Galleria Mall, 100 Main Street: An individual dumped out a gallon of gasoline into a storm drain when he could not return it. The spill was closed out by NYSDEC on June 14, 2007.

These off-site spills are a concern due to their proximity to the Subject Property.

Facility Index System/Facility Registry System (FINDS)

The FINDS database provides a list of facilities that maintain or previously maintained environmental permits or are listed under additional EDR report databases. A review of FINDS list provided by EDR identified seven (7) listings for the Subject Property (Picture People, The, Galleria of White Plains, Macy-White Plains Galleria at White Plains, J.C. Penney Co Inc, Macy's White Plains Cogeneration, Expressly Portraits, and CPI Photo Finish). These operations appear to include RCRA-SQG (EPA ID 110004561402), Air Program (EPA ID 110019206599 and 110054890347), RCRA (EPA ID 110016725748, 110009462553, 110004322849 and 110004531374). No violations were reported; therefore, these listings do not constitute a REC.

USEPA Enforcement and Compliance History Online (ECHO)

The ECHO database provides a list of compliance and enforcement information for regulated facilities. A review of the database provided by EDR identified six (6) listings for the Subject Property (The Picture People, Macy-White Plains Galleria at White Plains, J.C. Penney Co Inc, Macy's White Plains Cogeneration, Expressly Portraits, and CPI Photo Finish). No violations were identified with these operations at the Subject Property; therefore, these listings do not constitute a REC.

MANIFEST Sites

MANIFEST Facilities include a list of facilities that have generated hazardous waste or contaminants. A review of the NY MANIFEST list, as provided by EDR, identified four (4) NY MANIFEST facilities (Picture People, The, JC Penney Co Inc, Expressly Portraits and Macy's East #55, Galleria Mall Dental, Lens Crafters #0787, Sears) located on the Subject Property. The Subject Property is also listed as 100 Main Street on the MI MANIFEST database. Based on a review of the available database information, there are manifests that are not associated with documented releases, and therefore they do not constitute a REC.

EDR Hist Cleaner Sites

The EDR Hist Cleaner list provides an inventory of facilities that formerly/historically operated a dry-cleaning business. A review of the EDR Hist Cleaner database, as provided by EDR, has revealed that there are two (2) Hist Cleaner facilities listed on the Subject Property (Bayliss Morris [90 Main St] and Biscardi Frank [102 Main St]). The operations of the drycleaning operations were noted as circa 1969-1975, prior to the construction of the Galleria Mall. While these addresses

were historically located west of the Subject Property along Main Street, they are identified as RECs due to their close location relative to the Subject Property.

The EDR Radius Map Report identified operations at nearby sites in the following listings. For the purposes of this section, distances are measured from the Galleria Mall as a whole, and not from the specific condominium unit that is subject to this report. A discussion of these listing is provided below:

RCRA Large Quantity Generator (RCRA-LQG)

The RCRA-LQG includes a list of facilities that generate over 1,000 kilograms of hazardous waste, or over one (1) kilogram of acutely hazardous waste per month. According to the RCRA-LQG list provided by EDR, there are two (2) RCRA-LQG facilities (Con Edison Manhole 10087 and Con Edison Manhole 467) within approximately 0.25 miles of the Subject Property. However, a review of the facility listings did not identify any releases or violations. Therefore, these listings are not expected to adversely impact the Subject Property.

RCRA Small Quantity Generator (RCRA-SQG)

The RCRA-SQG includes a list of facilities that generate more than 100 but less than 1,000 kilograms of hazardous waste per month and accumulates less than 6,000 kilograms of hazardous waste at any time. According to the RCRA-SQG list provided by EDR, there are six (6) RCRA-SQG facilities within approximately 0.25 miles of the Subject Property. Of these facilities, only one (1) was identified with an associated spill. However, this spill case was closed by the NYSDEC and not associated with the waste generated. Therefore, these listings are not expected to adversely impact the Subject Property.

RCRA Very Small Quantity Generator (RCRA-VSQG)

The RCRA-VSQG includes a list of facilities that generate less than 100 kilograms of hazardous waste, or less than one (1) kilogram of acutely hazardous waste per month. According to the RCRA-VSQG list provided by EDR, there are nine (9) RCRA-VSQG facilities within approximately 0.25 miles of the Subject Property. The facilities had no reported violations, and any listed spills were reported as closed and not associated with the RCRA listing. Therefore, these listings are not expected to adversely impact the Subject Property.

NY State Hazardous Waste Sites (NY SHWS)

NY SHWS is a list of known contaminated sites except those associated with Bureau of Underground Storage Sites (BUST). According to the NY SHWS list provided by EDR, there are two (2) facilities (Automobile Club of New York and Mamaroneck Avenue Dry Cleaners) located within 0.5 miles of the Subject Property. Due to the distance of these facilities and the locations as hydraulically cross gradient or downgradient from the Subject Property, these listings are not expected to adversely impact the Subject Property.

LTANKS: Leaking Storage Tank Incident Reports

Leaking Storage Tank Incident Reports. These records contain an inventory of reported leaking storage tank incidents reported from 4/1/86 through the most recent update. They can be either leaking underground storage tanks or leaking aboveground storage tanks. The causes of the incidents are tank test failures, tank failures or tank overfills. A review of the database as provided by EDR identified 175 listings within 0.5 miles of the Subject Property. However, a review of the listings within 0.125 miles from the Subject Property did not identify any open spills with the NYSDEC. Therefore, these facilities are not expected to adversely impact the Subject Property.

UST: Underground Storage Tank Data

USTs are regulated under Subtitle I of the Resource Conservation and Recovery Act (RCRA) and must be registered with the state department responsible for administering the UST program. Available information varies by state program. A review of the NY UST list provided by EDR identified 57 facilities within 0.25 miles of the Subject Property. No documented releases were reported from the listed USTs within 0.125 miles from the Subject Property. Therefore, these facilities do not constitute a REC.

AST: Petroleum Bulk Storage

Registered Aboveground Storage Tanks. A review of the database as provided by EDR identified 26 facilities within 0.25 miles of the Subject Property. All facilities within 0.125 miles of the Subject Property that contained associated spills or LTANKS listings were reported as closed by the NYSDEC. Therefore, these facilities do not constitute a REC.

Eng Controls: Registry of Engineering Controls

Environmental Remediation sites that have engineering controls in place. A review of the database as provided by EDR identified two (2) facilities (CE-White Plains MGP and Automobile Club of New York) within 0.5 miles of the Subject Property. Both facilities appear to be located hydraulically downgradient from the Subject Property. Therefore, they do not constitute a REC.

Inst Control: Registry of Institutional Controls

Environmental Remediation sites that have institutional controls in place. A review of the database as provided by EDR identified three (3) facilities (CE-White Plains MGP, WP Mall Cleaners and Gas Station Site, and Automobile Club of New York) within 0.5 miles of the Subject Property.
As previously discussed, the CE-White Plains MGP, WP Mall Cleaners and Gas Station Site, and Automobile Club of New York facilities appear to be located hydraulically downgradient from the Subject Property, and therefore they do not constitute a REC. WP Mall Cleaners and Gas Station Site is being cleaned up under the NYSDEC BCP and is not considered a REC.

Voluntary Cleanup Program (VCP) Sites

The VCP listings included Completed Sites, Sites in Progress and Act 2 Non-Use Aquifer Determinations Sites. Formerly known as the Act 2, the Land Recycling Program encourages the voluntary cleanup and reuse of contaminated commercial and industrial sites. A review of NY VCP list provided by EDR identified one (1) facility (CE—White Plains MGP) within 0.125 miles of the subject Site. As previously discussed, the facility appears to be located hydraulically downgradient from the Subject Property, and therefore does not constitute a REC.

Brownfields: Brownfields Site List

A Brownfield is any real property where redevelopment or re-use may be complicated by the presence or potential presence of a hazardous waste, petroleum, pollutant, or contaminant. A review of the database as provided by EDR identified 10 listings within 0.5 miles of the Subject Property. Of the facilities within 0.125 miles and hydraulically upgradient of the Subject Property, two (2) brownfield cleanup program (BCP) facilities were identified as undergoing remediation for groundwater, soil and soil vapor. These facilities are being investigated and remediated under the NYSDEC BCP and therefore do not constitute and REC.

SPILLS: Spills Information Database

Data collected on spills reported to NYSDEC as required by one or more of the following: Article 12 of the Navigation Law, 6 NYCRR Section 613.8 (from PBS regs), or 6 NYCRR Section 595.2 (from CBS regs). It includes spills active as of April 1, 1986, as well as spills occurring since this date. A review of the database as provided by EDR identified 37 facilities within 0.125 miles of the Subject Property. The spills associated with the facilities listed adjacent or hydraulically upgradient of the Subject Property have been closed with the NYSDEC. Therefore, these facilities do not constitute a REC.

RCRA Non-Generators / No Longer Regulated (RCRA NonGen / NLR)

Resource Conservation and Recovery Act Non-Generators (RCRA NonGen) database searches USEPA's comprehensive information system, providing access to data supporting the RCRA of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. The database includes selective information about facilities that generate, transport, store, treat and/ or dispose of hazardous waste as described by RCRA. Non-generators do not presently generate hazardous waste. A review of RCRA NonGen/NLR list provided by EDR identified 93 facilities within 0.25 miles of the Subject Property. Since none of these facilities currently generate hazardous waste, they are not expected to adversely impact the Subject Property.

Formerly Utilized Sites Remedial Action Program (FUSRAP)

Established in 1974, the FUSRAP list includes facilities that required remediation due to radioactive contamination associated with the Manhattan Project and early U.S. Atomic Energy Commission operations. According to the FUSRAP list provided by EDR, there is one (1) FUSRAP facility (Nuclear Development Corp of America Site) located within approximately 0.125 miles of the Subject Property to the southeast. The facility is listed as Nuclear Development Corp. of America, identified as NY.32, and is located at 5 New Street. The facility was reportedly evaluated and eliminated from consideration under FUSRAP in 1987 due to the EPA's determination that it had no authority to perform remedial efforts under FUSRAP. EDR reported that the facility was licensed to handle nuclear materials. The facility is confirmed to have handled radioactive materials, specifically uranium. The listed operations included the performance of experiments involving uranium recovery from scrap material at the facility. No additional information was provided in the listing. Due to undocumented radioactive contamination at this facility, these conditions do not constitute a REC.

Fuels Program: EPA Fuels Program Registered Listing

This listing includes facilities that are registered under the Part 80 (Code of Federal Regulations) EPA Fuels Programs. All companies now are required to submit new and updated registrations. A review of the database as provided by EDR identified one (1) facility (RNG Padd 1) within 0.125 miles of the Subject Property. Since no releases or violations were documented, this facility is not expected to adversely impact the Subject Property.

MANIFEST Sites

MANIFEST Facilities include a list of facilities that have generated hazardous waste or contaminants. A review of the NY, PA, NJ and MI MANIFEST list, as provided by EDR, identified 121 NY MANIFEST, four (4) PA MANIFEST, one (1) MI MANIFEST, and 36 NJ MANIFEST facilities within approximately 0.25 miles of the Subject Property. All associated releases within 0.125 miles hydraulically upgradient of the Subject Property were evaluated and are not expected to adversely impact the Subject Property.

MGP: Manufactured Gas Plants Listing

From the late 1800's to the mid 1900's, hundreds of manufactured gas plants across New York State supplied homes and industry with fuel for heating, cooking, and lighting. Today, the New York State DEC is overseeing the investigation and cleanup of contamination left behind from these plants. A review of the database as provided by EDR identified one (1) facility (CE-White Plains MGP) within 0.125 miles of the Subject Property. As previously discussed, this facility is not expected to adversely impact the Subject Property.

UST Finder Release: UST Finder Releases Database

US EPA's UST Finder data is a national composite of leaking underground storage tanks. This data contains information about, and locations of, leaking underground storage tanks. Data was collected from state sources and standardized into a national profile by EPA's Office of Underground Storage Tanks, Office of Research and Development, and the Association of State and Territorial Solid Waste Management Officials. A review of the database as provided by EDR identified 24 facilities within 0.5 miles of the Subject Property. Based on a review of the available database information, all but one (1) facility (New York Hospital) have documented release events have not occurred at these facilities. Additionally, this one (1) facility is located approximately 0.25

miles topographically downgradient from the Subject Property. Therefore, these facilities are not expected to adversely impact the Subject Property.

UST Finder: UST Finder Database

EPA developed UST Finder, a web map application containing a comprehensive, state-sourced national map of UST and leaking UST (LUST) data. It provides the attributes and locations of active and closed USTs, UST facilities, and LUST sites from states and from Tribal lands and US territories. UST Finder contains information about proximity of UST facilities and LUST sites to: surface and groundwater public drinking water protection areas; estimated number of private domestic wells and number of people living nearby; and flooding and wildfires. A review of the database as provided by EDR identified one (1) listing (New York Power Authority) within 0.125 miles of the Subject Property. Based on a review of the available database information, documented release events status is noted as “no further action”. Therefore, these facilities are not expected to have adversely impacted the Subject Property.

EDR Hist Auto Sites

The EDR Hist Auto list provides an inventory of facilities that formerly operated automotive repair or automotive gas stations. A review of the EDR Hist Auto database, as provided by EDR, has revealed that there are two (2) Hist Auto facilities within approximately 0.125 miles of the subject Site. These facilities are situated either cross gradient or downgradient from the subject with no known releases. Therefore, these facilities are not expected to adversely impact the Subject Property.

EDR Hist Cleaner Sites

The EDR Hist Cleaner list provides an inventory of facilities that formerly/historically operated a dry-cleaning business. A review of the EDR Hist Cleaner database, as provided by EDR, has revealed that there are four (4) Hist Cleaner facilities within approximately 0.125 miles of the Subject Property. Several of these facilities are either downgradient from the Subject Property and no associated releases were identified. The White Plains Mall Cleaners is associated with the facility discussed in the INST CONTROLS database listing above and is not considered an REC.

5.1.2. ENVIRONMENTAL REPORTS

February 2025 *Phase II ESA* by SESI

SESI prepared a Phase II Environmental Site Assessment for the Subject Property in February 2025. The report identified exceedances in the soil, groundwater, and soil vapor reported during the investigation that are likely a result of the Subject Property's historical land use, potential USTs, and the presence of contaminated historic fill (Appendix E).

- VOCs were found to exceed the USCOs on the northern portion of the Site from grade to 9.5 ft-bgs (SB-21G[9-9.5]). SVOCs (primarily PAHs) were found to exceed the PGWSCOs, RRSCOs or USCOs throughout the Site from grade to 6.5 ft-bgs (SB-10G[6-6.5]). Metals were found above the USCOs throughout the Site to depths ranging from grade to 5.5 ft-bgs (SB-7G[5-5.5]). Pesticides were found above the USCOs to 4 ft-bgs at the southern and northern portions of the Site (SB-22 [3.5-4]) and SB-45G [3.5-4]).

- VOCs, PFAS, PAHs, and metals were found in groundwater to exceed the AWQS throughout the Site, likely associated with historical uses, potential USTs, and historic fill contamination.

- Several PHC and chlorinated VOCs were detected in the soil vapor and indoor air samples, which may indicate contamination is present throughout the Site.

SESI recommends that prior to any development on the Subject Property additional investigation be conducted to delineate the extent of the SVOCs (PAHs), metals, pesticides, and PFAS contamination in soil and to evaluate soil remedial options. The investigation should also delineate the VOC, SVOCs (PAHs), metals, and PFAS contamination in groundwater and evaluate remedial options available to comply with the AWQS. Finally, a soil vapor intrusion evaluation is recommended to address the potential for soil vapor contamination.

5.1.3. LOCAL, COUNTY, AND STATE INFORMATION REQUESTS

On March 6, 2025, SESI filed information requests with the NYSDEC, Westchester County Departments of Health, Emergency Services and Environmental Facilities, and White Plains Buildings and Fire Departments for information regarding potential incidents, spills, hazardous material storage/use and UST decommissioning records. Responses received have not provided

any information that will change the findings provided in this report. SESI reserves the right to modify this report should additional information be provided from these requests that warrants a modification.

5.2. PHYSICAL SETTING SOURCES

Sources used to evaluate the physical setting of the property include:

- USGS Topographic Maps;
- Aerial Photographs; and
- Site Reconnaissance.

5.2.1. TOPOGRAPHY

The Subject Property is relatively level with regional topography decreasing to the west. According to the United States Geological Survey (USGS) 2021 Glenville/2019 White Plains, New York 7.5-minute Series topographic map, the Subject Property's topographic elevation is approximately 200 feet above mean sea level (msl). The EDR Topographic Map Report is attached to this Report as **Appendix D**.

5.2.2. SURFACE WATERS AND WETLANDS

The closest open surface water to the Subject Property is the Bronx River located approximately 1,400 feet west of the Subject Property.

5.2.3. GEOLOGY AND GROUNDWATER

As per the USDA National Cooperative Soil Survey (NCSS) map for the area, the soils at the Site are characterized as UoA (Urban Land outwash substratum) urban land which is surface covered by pavement, concrete, buildings, and other structures underlain by disturbed and natural soil material, till substratum, 0 to 3 percent slopes. Based on the results of the Phase II ESA conducted on-site, the elevation of groundwater at the Subject Property is approximately 180-200 feet above mean sea level (AMSL), and groundwater flow direction is expected to be in the western direction.

5.3. HISTORICAL USE INFORMATION FOR THE PROPERTY

Sources used to determine the historical use of the property include:

- Aerial Photographs;
- EDR City Directory Abstract;
- USGS Topographic Maps; and

- Sanborn Fire Insurance Maps.

EDR Reports are attached to this Report as **Appendix D.**

5.3.1. AERIAL PHOTOGRAPHS

Following is a summary of the EDR review of 15 aerial photographs dated 1941, 1949, 1953, 1958, 1962, 1964, 1971, 1974, 1985, 1991, 1994, 2006, 2011, 2015, and 2019.

Table 5.2—Aerial Photographic Review

Year	Quality of Photograph	Observations
1941	Fair	**Site:** The Subject Property is developed with numerous small structures. **Adjacent Parcels:** The adjoining properties are all developed. In general, the surrounding area is densely developed with numerous smaller structures. The Subject Property is bound to the north by a road and another road is present to the east.
1949, 1953	Good (1949, 1953)	**Site:** No discernible changes. **Adjacent Parcels:** No discernible changes.
1958	Fair	**Site:** Several structures in the center and southeast portion of the Subject Property are no longer present and a parking lot is now present. **Adjacent Parcels:** No discernible changes.
1962	Good	**Site:** A structure in the northwest corner is no longer present and the parking lot is expanded in this area. No other discernible changes. **Adjacent Parcels:** No discernible changes in the surrounding properties. Numerous residential structures are now present in the northern portion of the photograph.
1964	Good	**Site:** No discernible changes. **Adjacent Parcels:** No discernible changes.
1971	Good	**Site:** A structure in the southwest corner of the Subject Property is no longer present and the ground appears disturbed. **Adjacent Parcels:** Numerous structures in the adjoining area to the east, south, and southwest are no longer present. A large structure appears under construction to the northeast and further south.
1974	Good	**Site:** There are no structures depicted, and the entire Subject Property appears to be disturbed land. **Adjacent Parcels:** The structure adjoining to the north and further south appear completed. A road now is present

Year	Quality of Photograph	Observations
		adjoining to the east of the Subject Property and further east a building is under construction.
1985, 1991, 1994	Good (1985), Poor (1991), and Fair (1994)	**Site:** The Subject Property is the north-central portion of a large, interconnected building. **Adjacent Parcels:** The properties to the north, east, south, and west are all developed with large structures.
2006, 2011, 2015, 2019	Good	**Site:** No discernible changes. **Adjacent Parcels:** No discernible changes.

5.3.2. EDR CITY DIRECTORY ABSTRACT

SESI obtained historical city directory data from EDR for the Subject Property. SESI reviewed the City Directory listings for the years 1963, 1965, 1972, 1977, 1982, 1987, 1992, 1995, 2000, 2005, 2010, 2014, 2017 and 2020. A copy of the City Directory Abstract is included in **Appendix C**.

The Subject Property is part of a larger shopping mall and determining which leasehold spaces were within the boundaries of condominium Unit A is not possible based on available information. However, historic operations at the shopping mall have included the following: retail, shoe repair, bank, jewelry, cinema, restaurant, gallery, travel agent, radio shack, video store, café, building management offices, leather retailer and department store. These specific historic operations identified in the City Directory do not constitute a REC.

NuWay Cleaners Inc. was identified west of the Subject property at 90 Main Street in the 1963 and 1965 city directories.

5.3.3. USGS TOPOGRAPHIC MAPS

Following is a summary of the EDR review of Topographic Map Reports:

Table 5.3—Topographic Map Review

Source	Year	Minute	Scale
Tarrytown, Stamford	1892, 1893, 1899, 1902	15	62500
White Plains	1932	7.5	24000
White Plains	1938	7.5	31680

Source	Year	Minute	Scale
Glenville, White Plains	1944, 1947, 1957, 1967, 1971,	7.5	24000
White Plains	1979, 1994	7.5	24000
Glenville, White Plains	2013, 2015, 2016, 2018, 2019, 2021	7.5	24000

Based on a review of the EDR Historical Topographic Map Report, the Subject Property is level with an approximate elevation of 200-feet above msl. Topography on-site gently slopes to the west. Regional topography slopes more significantly downward to the west. Similarly, the surrounding properties are relatively level with a general slope to the west with properties to the west across Lexington Avenue displaying greater topographic relief. No wetlands were noted on the maps within or adjacent to the Subject Property; however, a stream was noted running north-south to the west of the Subject Property circa 1892-1902. A review of these maps suggests the Subject Property was developed prior to 1892. No environmental concerns were identified based on a review of the topographic maps.

5.3.4. SANBORN FIRE INSURANCE MAPS

The Subject Property was covered on 19 of the Sanborn maps from 1885, 1889, 1894, 1900, 1905, 1911, 1930, 1942, 1950, 1987, 1989, 1990, 1992, 1993, 1994, 1995, 2002, 2003, and 2004 described below:

Table 5.4—Sanborn Map Review

Year	Quality of Map	Observations
1885	Good	**Subject property:** Historic uses identified include a carriage shop (including blacksmith and woodworking), a second blacksmith (including painting) several stores (including meat, fish, and barbers), a livery building with wagon house, and other structures are identified on the Subject Property. A potential UST is identified in the northeast corner of the Subject Property. A stream is depicted running from the north to south roughly in the middle of the Subject Property. **Adjacent Parcels:** Historic uses include a saloon, dwellings, storage, a drug store, barber, candy store, jeweler, printers, cigar, post office, beer bottling company, a hotel with two USTs depicted, a grocer, and Chinese laundry on the eastern and northern upgradient properties . Railroad Avenue forms the northern border of the Subject

Year	Quality of Map	Observations
		Property and Grove Street forms the eastern border of the Subject property. There are numerous dwellings to the east and south of the Subject Property.
1889, 1894	Good	**Subject property:** The UST is no longer depicted in the northeast corner of the Subject Property. The carriage house is expanded to the south. The carriage shop in the southeast corner is now indicated as occupied by an undertaker and storage. **Adjacent Parcels:** The USTs are no longer depicted at the Cottage Hotel north of the Subject Property. Further east and upgradient a hardware store (with paints and oils) and a tin shop are depicted. A tin smelter is indicated east (and upgradient) across Grove Street. No other significant changes.
1900	Good	**Subject property:** The fish store in the northeast corner of the Subject Property is no longer indicated and the structure is expanded to the south and indicated as the Westchester Co. Reporter with gas engine and printing. The undertaker and storage building occupies a larger footprint and is also indicated as used for furniture repair . **Adjacent Parcels:** No discernible changes.
1905	Good	**Subject property:** The livery structure in the center of the Subject Property has expanded to the south and several structures indicated as carriage houses are now present. The undertaker and furniture business in the southeast corner has expanded with several structures. The printing is now noted as electric. **Adjacent Parcels:** The Chinese laundry is no longer depicted to the north. A structure located south of the southeast corner of the Subject Property is indicated as a hand laundry. No other significant changes.
1911	Good	**Subject property:** Several store fronts along the northern portion of the Subject Property are no longer depicted Emery & Carpenter Livery building is and sausage kitchen are depicted in the northern portion of the Subject Property along with a printing facility. Structures indicated as a laundry, paint and oils, and bicycle repair shop are located along the eastern boundary . **Adjacent Parcels:** The hardware store and tin shop further east are no longer depicted and are now indicated as banks. The dwelling adjoining to the northwest corner of the Subject Property is no longer depicted and several structures are now present.
1930	Good	**Subject property:** The stream is no longer depicted on the Subject Property. The Subject Property has been improved in the south and southwest portions with two

Year	Quality of Map	Observations
		large theaters. While several storefronts remain depicted, their use is no longer indicated except for printing (with electric motors) and paints along the eastern property boundary. **Adjacent Parcels:** Additional development has occurred throughout the surrounding area. The stream is no longer depicted off-site. A large building indicated as a battery and electric service station is depicted east of the southeast corner of the Subject Property and three gasoline USTs are depicted along Grove Street. A large building used for auto washing and greasing is present adjoining to the southwest corner of the Subject Property .
1942	Good	**Subject property:** No significant changes. **Adjacent Parcels:** No discernable changes.
1950	Good	**Subject property:** No significant changes. **Adjacent Parcels:** A large building is now present to the northeast across Grove Street. The northernmost UST depicted within Grove Street (out front of 18-26 Grove Street) is no longer depicted. No other significant changes.
1987	Good	**Subject property:** All previous on-site structures are no longer depicted and the Subject Property is now improved with the Galleria Mall. **Adjacent Parcels:** Significant changes have occurred to the surrounding area. The area to the east, south, and west is now also part of the Galleria Mall. Each of the surrounding properties have been redeveloped. The smaller former structures are no longer depicted and the surrounding parcels are improved with large structures for both commercial and governmental use.
1989, 1990, 1992, 1993, 1994, 1995, 2002, 2003, 2004	Good	**Subject property:** No discernible changes. **Adjacent Parcels:** No discernible changes.

5.4. ENVIRONMENTAL LIEN AND AUL SEARCH REPORT

A lien or activity use limitation search was not conducted as part of this Phase I ESA. Should this information be provided, SESI reserves the right to include this information at a later date.

5.5. ENVIRONMENTAL PERMITS

Review of the EDR Radius Map Report for the Subject Property indicates no environmental permits attributed to the Site. EDR Reports are provided in **Appendix C**.

6.0 SITE RECONNAISSANCE

6.1. METHODOLOGY AND LIMITING CONDITIONS

An environmental professional from SESI, Dafina Djombalic, visited the Subject Property on February 20, 2025, to identify potential RECs. The Subject Property was observed to the extent that it was accessible and not obstructed. An inspection photolog is attached to this Report as **Appendix E.**

6.2. SUBJECT PROPERTY OBSERVATIONS

The Subject Property is improved by a three-story building encompassing two (2) blocks that extends from North Lexington Avenue to Court Street and Main Street to Martine Avenue. The ground floor of the Subject Property was previously improved with a Blink Fitness gym as well as storage rooms, a mechanical room, an electrical room, common spaces for the mall, and a loading dock. The second through fourth floors consisted of retail and common spaces associated with the Galleria Mall.

6.3. CHEMICAL STORAGE AND USAGE

SESI did not observe any chemical storage or usage.

6.4. BULK STORAGE TANKS

SESI personnel did not observe any bulk storage tanks at the Subject Property.

6.5. SUBJECT PROPERTY WASTE AND WASTEWATER

SESI observed some property waste on the Subject Property. This is not considered a REC.

6.6. STAINED SOIL, STAINED PAVEMENT, OR STRESSED VEGETATION

No stained soil, pavement, or stressed vegetation were identified at the Subject Property.

6.7. PITS, PONDS, OR LAGOONS

No pits, ponds, or lagoons were observed on the Subject Property.

6.8. WELLS

SESI did not observe any on-site dry wells, irrigation wells, injection wells, observation wells, monitoring wells, potable water wells, recovery wells, or abandoned wells.

6.9. FLOOR DRAINS AND SUMPS

There were several floor drains that lead to sanitary sewer throughout the Subject Property. There is also no evidence of septic use in the past. There were storm drains in the parking area. The interior floor drains were in the cooking areas and bathrooms primarily. A pit was observed in the northeast corner of the Subject Property; however, no staining or evidence of a release was identified. There was no observable staining in and around these drains or pits.

6.10. PCB-CONTAINING MATERIAL, INCLUDING CAULK

A dry-type transformer was observed in an electrical closet; however, no oil-filled transformers were observed on-site. In addition, there are likely several areas in which caulking is also present; therefore, a survey is recommended for caulking.

6.11. ASBESTOS-CONTAINING MATERIAL

ACM surveying was not included in SESI's scope of work; however, based on the age of the facility, an ACM survey is recommended. SESI recommends an ACM survey prior to redevelopment.

6.12. RADON

Radon surveying was not included in SESI's scope of work; however, based on the age of the facility, a radon survey is recommended. The Subject Property is located in Westchester County which is in EPA Radon Zone 3. This zone contains counties with the "lowest potential; average indoor radon levels may be less than 2 pCi/L (picocuries per liter)." Therefore, radon is not considered a REC.

6.13. UNIVERSAL WASTE

There were several pieces of universal waste throughout the mall in the cleaning areas of each portion of the mall. Therefore, this universal waste should be properly disposed of prior to demolition or redevelopment.

6.14. LEAD-BASED PAINT

LBP surveying was not included in SESI's scope of work; however, based on the age of the facility, an LBP survey is recommended.

6.15. VAPOR INTRUSION

Based on a review of information from the Phase II ESA, vapor intrusion is anticipated to be a concern on the Subject Property.

7.0 DATA GAPS

- Based on a review of the available documentation no significant data gaps have been identified.

8.0 FINDINGS

Based on our investigation, we conclude that there is evidence to indicate areas of potential environmental concern on the Subject Property due to former on-site uses of USTs, former on-site operations, nearby historical cleaners, upgradient historical uses, and current data demonstrating impacts at the Subject Property. See ***Section 10.0 CONCLUSIONS*** of this Report.

9.0 OPINIONS

In our professional judgment, the scope and character of our environmental assessment were sufficient to justify the stated conclusions, after giving due consideration to the purpose of the investigation, the data reviewed, the background history of the Subject Property as found in historical records, and visual observation of the Subject Property.

10.0 CONCLUSIONS AND RECOMMENDATIONS

Based on the investigation, it is concluded that there is evidence to indicate areas of recognized environmental concern on the Subject Property and that additional investigation of these areas is warranted. The conclusions and recommendations in this regard are as follows:

The following RECs have been identified:

- **REC 1 – Historical Site Usages**: Historic operations circa 1885-1950 at the Subject Property that are considered of concern include: gas tank, carriage shop (including woodworking), several blacksmiths with painting, marble cutter, cabinet shop, furniture repair,, tailor, several printing shops (one with gas engine), laundry, tailors several paint and oil shops, cobbler, several upholstery shops, and bicycle repair shop.. Soil, ground water, and soil vapor sampling conducted during the Phase II ESA identified impacts that appear to be partially attributable to former on-site operations. Additional investigation is required.
- **REC 2 – On-site Contamination:** SESI conducted subsurface soil, soil vapor and groundwater sampling to investigate for the Site historical usages. Analytical results of this investigation identified VOCs were found to exceed the USCOs on the Site from grade to 9.5 ft-bgs (SB-21G[9-9.5]). SVOCs (primarily PAHs) were found to exceed the PGWSCOs, RRSCOs or USCOs throughout the Site from grade to 6.5 ft-bgs (SB-10G[6-6.5]). Metals were found above the USCOs throughout the Site to depths ranging from grade to 5.5 ft-bgs (SB-7G[5-5.5]). Pesticides were found above the USCOs to 4 ft-bgs at the southern and northern portions of the Site (SB-22 [3.5-4]) and SB-45G [3.5-4]).

- VOCs, PFAS, PAHs, and metals were found in groundwater to exceed the AWQS throughout the Site, likely associated with historical uses, potential USTs, and historic fill contamination.

- Several PHC and chlorinated VOCs were detected in the soil vapor and indoor air samples, which may indicate contamination is present throughout the Site.

- SESI recommends that prior to any development on the Subject Property additional investigation be conducted to delineate the extent of the SVOCs (PAHs), metals, pesticides, and PFAS contamination in soil and to evaluate soil remedial options. The investigation should also delineate the VOC, SVOCs (PAHs), metals, and PFAS

contamination in groundwater and evaluate remedial options available to comply with the AWQS. Finally, a soil vapor intrusion evaluation is recommended to address the potential for soil vapor contamination.

- **REC 3 –Upgradient Concerns**:

  - *50 Court Street BCP Site (C360258)*:
    - Two (2) releases (Spill Nos. 8803673 and 8805571) were identified in connection with the upgradient northern adjacent property located at 180 Main Street (see below). The spills were identified in the EDR LTANKS and NY SPILLS databases and reported to the NYSDEC in 1988. These spills were attributed to the release of undetermined gallons of No. 2 fuel oil from a10,000-gallon UST. These spills are administratively closed with the NYSDEC. However, no closure documentation or testing data was available for review. Subsurface testing has identified impacts to soil exceeding the NYSDEC soil cleanup objectives, impacts to soil vapor exceeding the NYSDOH lower threshold values, and impacts to groundwater exceeding the NYSDEC AWQSs.

  - *180 Main Street Property*:
    - The Site was developed prior to 1885 based on the Sanborn Fire Insurance Maps. Historical land uses included print shops, painting and oil shops, bottling works, plumbing and tin shops, a bowling alley, a fire department and a portion of the Westchester County Courthouse and commercial/residential spaces (circa 1885-1950), followed by the Galleria Mall. The Galleria Mall was constructed in approximately 1980. The Subject property was improved with the Galleria Mall anchor store Abraham and Straus (circa 1980-1995), and then Sterns (circa 1995-1996), and then Macys (circa 1996 to 2023). Two (2) 10,000-gallon fuel oil underground storage tanks (USTs) were closed in place in January 1997 (PBS 3-173665). Two (2) spills had been reported to the NYSDEC in 1988 identified as Spill Nos. 8803673 and 8805571. Both of these spills appear to be related to tank test failures associated with a 10,000-gallon underground storage tank (UST). Subsurface testing has identified impacts to soil exceeding the NYSDEC soil cleanup objectives and impacts to groundwater exceeding the NYSDEC AWQSs.

The following BERs have been identified:

- **BER 1 – Polychlorinated Biphenyl (PCB) Caulk:** A PCB survey was not completed during SESI's walkthrough of the Subject Property. There are likely several areas present that contain caulking. Therefore, a PCB survey is recommended prior to any demolition or redevelopment of the Subject Property.
- **BER 2 – Asbestos-Containing Material (ACM):** An ACM survey was not completed during SESI's walkthrough of the Subject Property. Based on the age of the building, SESI recommends an ACM survey prior to any demolition or redevelopment of the Subject Property.
- **BER 3 – Universal Waste:** There were several pieces of universal waste identified during the walkthrough of the Subject Property; however, a complete survey of this universal waste was not completed. SESI recommends a universal waste survey prior to any demolition or redevelopment of the Subject Property.
- **BER 4 – Lead-Based Paint (LBP):** An LBP survey was not completed during SESI's walkthrough of the Subject Property. Based on the age of the building, SESI recommends an LBP survey prior to any demolition or redevelopment of the Subject Property.
- **BER 5 – Vapor Intrusion:** Data from the Phase II ESA suggests vapor intrusion may be a concern. In particular, one sample location identified benzene and ethylbenzene in both soil gas and indoor air. Therefore, SESI recommends further evaluation of the vapor intrusion pathway at the Subject Property as part of the redevelopment process.

A figure showing the locations of the RECs identified at this Subject Property is included as **Figure 10.1.**

11.0 DEVIATIONS

This Report was prepared with no significant deviation from ASTM Standard Practice E1527-21.

12.0 REFERENCES

Environmental Data Resources, Inc. – "Certified Sanborn Map Report", Inquiry No. 7906442.3, dated February 24, 2025

Environmental Data Resources, Inc. – "EDR – Historical Topographic Map Report", Inquiry No. 7906442.4, dated February 24, 2025

Environmental Data Resources, Inc. – "The EDR Aerial Photo Decade Package", Inquiry No. 7906442.8, dated February 24, 2025

Environmental Data Resources, Inc. – "The EDR Radius Map Report", Inquiry No. 7906442.2s, dated February 24, 2025

Environmental Data Resources, Inc. – "The EDR – City Directory Abstract", Inquiry No. 76075856.5, dated February 25, 2025

Remedial Investigation Report, WP Mall Cleaners & Gas Station Site, 250 Hamilton Avenue, White Plains, Westchester County, New York, prepared by SESI, March 2023

Phase II ESA, 100 Main Street Unit C, White Plains, New York, prepared by SESI, February 2025

Remedial Investigation/Remedial Measures Workplan, 100 Main Street Unit C, White Plains, New York, prepared by SESI, February 2025

13.0 SIGNATURE OF ENVIRONMENTAL PROFESSIONAL

As required in 40 CFR 312.21(d), this section includes statements made by the environmental professional conducting this assessment.

“I declare that, to the best of my professional knowledge and belief, I meet the definition of Environmental Professional as defined in §312.10 of 40 CFR Part 312.”

“I declare that I have the specific qualifications based on education, training, and experience to assess a property of the nature, history, and setting of the Subject Property.”

“I have developed and performed the ‘all appropriate inquiry’ in conformance with the standards, limitations, and practices set forth in 40 CFR Part 312.”

This Report incorporates the consultant's best professional judgment in conductance of this Phase One Environmental Site Assessment.

SESI CONSULTING ENGINEERS

_____

Steven Gustems, PG
Senior Project Manager
March 6, 2025

Figures



REFERENCE:

CONDITIONS AND BOUNDARY TAKEN FROM TAX MAP FROM WESTCHESTER COUNTY GIS TAX PARCEL WEB VIEWER, DATED 7/10/2025.

LEGEND:

SUBJECT PROPERTY LOCATION

SCALE: 1" = 100'

0 50 100 200 FEET

80 MAIN STREET
WHITE PLAINS, WESTCHESTER COUNTY, NY

TAX MAP

SESI CONSULTING ENGINEERS
GEOTECHNICAL | ENVIRONMENTAL | SITE CIVIL
959 ROUTE 46E, 3RD FLOOR, PARSIPPANY, NJ 07054 PH: 973.808.9050

FIG-1.1	
DRAWN BY:	KBV
CHECKED BY:	CM
SCALE:	AS NOTED
DATE:	10/30/2025
JOB NO.:	12859

Y:\GIS\Project_Numbers\12859\APRX_PROJECT\APRX_Phase1_Prj_No.aprx, 10/30/2025 11:33 AM, Kim Vanderklein, LAYOUT: FIG-1.1



REFERENCE:

UNITED STATES GEOLOGICAL SURVEY (USGS)
WHITE PLAINS, NY USGS QUADRANGLE - 2019

LEGEND:

SUBJECT PROPERTY

SCALE: 1" = 2,000'

0 1,000 2,000 4,000 FEET

80 MAIN STREET
WHITE PLAINS, WESTCHESTER COUNTY, NY

SUBJECT PROPERTY LOCATION MAP

SESI CONSULTING ENGINEERS
GEOTECHNICAL | ENVIRONMENTAL | SITE CIVIL
959 ROUTE 46E, 3RD FLOOR, PARSIPPANY, NJ 07054 PH: 973.808.9050

FIG-1.2	
DRAWN BY:	KBV
CHECKED BY:	CM
SCALE:	AS NOTED
DATE:	6/6/2024
JOB NO:	12859

Y:\GIS\Project_Numbers\12859\APRX_PROJECT\APRX_Phase1_Prj_No.aprx, 6/6/2024 8:55 AM, Kim Vanderklein, LAYOUT: FIG-1.1



REFERENCE:
CONDITIONS AND BOUNDARY TAKEN FROM SURVEY OF PROPERTY PREPARED FOR 80 MAIN STREET, PREPARED BY LINE AND GRADE SURVEYORS D.P.C. DATED OCT 20, 2025.

LEGEND:

SUBJECT PROPERTY LOCATION

SCALE: 1" = 60'

0 30 60 120 FEET

80 MAIN STREET
WHITE PLAINS, WESTCHESTER COUNTY, NY

SUBJECT PROPERTY PLAN

SESI CONSULTING ENGINEERS
GEOTECHNICAL | ENVIRONMENTAL | SITE CIVIL
959 ROUTE 46E, 3RD FLOOR, PARSIPPANY, NJ 07054 PH: 973.808.9050

FIG-1.3	
DRAWN BY:	KBV
CHECKED BY:	CM
SCALE:	AS NOTED
DATE:	11/4/2025
JOB NO.:	12859

Y:\GIS\Project_Numbers\12859\APRX_PROJECT\APRX_Phase1_Prj_No.aprx, 11/4/2025 10:17 AM, Kim Vanderklein, LAYOUT: FIG-1.3



ID	REC / BER
REC 1	HISTORICAL SITE USAGES
REC 2	ON-SITE CONTAMINATION
REC 3	UPGRADIENT CONCERNS
BER 1	POLYCHLORINATED BIPHENYL (PCB) CAULK
BER 2	ASBESTOS-CONTAINING MATERIAL (ACM)
BER 3	UNIVERSAL WASTE
BER 4	LEAD-BASED PAINT (LBP)
BER 5	VAPOR INTRUSION

© SESI CONSULTING ENGINEERS ---- 2026
This Drawing and all information contained here on is proprietary information of SESI CONSULTING ENGINEERS and may not be copied or reproduced, either in whole or in part, by method, without written permission of SESI CONSULTING ENGINEERS.

NYS Education Law

Unauthorized alterations or additions to this plan are a violation of section 7209 (2) of the New York State Education Law. Copies of this map not having the seal of the engineer shall not be valid.

REFERENCE:

VANTOR, NYS OFFICE OF INFORMATION TECHNOLOGYSERVICES - GIS PROGRAM OFFICE, NYS DEPT OF TAXATION AND FINANCE'S OFFICE OF REAL PROPERTY TAX SERVICES

NOTES:
1. BERS ARE NOT PLOTTED.
2. REC-1 AND REC-2 APPLY TO THE SUBJECT PROPERTY.

LEGEND:

- SUBJECT PROPERTY
- BCP BOUNDARY

SCALE: 1" = 100'

0 50 100 200 FEET

dwg by: KBV
chk by: BC
scale: AS NOTED
date: 2/19/2026

SESI CONSULTING ENGINEERS
GEOTECHNICAL | ENVIRONMENTAL | SITE CIVIL
959 route 46e, 3rd floor, parsippany, nj 07054 ph: 973.808.9050

project: 80 MAIN STREET
WHITE PLAINS, WESTCHESTER COUNTY, NY

title: REC/BER LOCATION MAP

job no.: 12859
drawing no: FIG-10.1

Y:\GIS\Project_Numbers\12859\APRX_PROJECT\APRX_Phase1_Prj_No.aprx, 2/19/2026 10:21 AM, Kim VanderKlein, LAYOUT: FIG-10.1

Appendix A:

User Questionnaire

SESI CONSULTING ENGINEERS
GEOTECHNICAL | ENVIRONMENTAL | SITE CIVIL

Principals
Anthony Castillo, PE
Fuad Dahan, PhD, PE, LSRP
Franz W. Laki, PE
John M. Nederfield, PE
Justin M. Protasiewicz, PE
Michael St. Pierre, PE

Phase I Environmental Site Assessment Questionnaire
For ASTM E 1527-21

According to the American Society for Testing and Materials (ASTM) standard practice for environmental site assessments (Designation: E 1527-21) "All Appropriate Inquiry" (AAI) (40 CRF 312.20) standard, the client must provide the following information (if available) to the environmental consultant during a Phase I Environmental Site Assessment. Failure to provide this information could result in a determination that "all appropriate inquiry" is not complete.

Client/Responsible Party Information (person completing this questionnaire) :

Name: _____
Title: _____
Interest to Property: _____
Street Address: _____
City: _____
State: _____
Phone: _____

Property Owner/Tenant Site Information:

Company Name: _____
Description of Operations: _____
Street Address: _____
Township: _____
City: _____
County/State: _____
Size of Property: _____
Block/Lot: _____
Phone: _____
Contact: _____

I, _____, to the best of my knowledge, have truthfully provided the information herein.
(FULL NAME)

_____ _____
SIGNATURE DATE

Identification of the site contact and how the contact can be reached (person who will conduct or conducted the site walk and/or will provide or provided access):

1. ENVIRONMENTAL CLEANUP LIENS/OTHER LIENS

a. Are there any environmental cleanup liens/and or other liens that are filed or recorded against the site in any applicable jurisdiction?

2. ACTIVITY OR USE LIMITATIONS AND WETLANDS

A) Are you aware of any environmental restrictions/limitations to the use of the property? (i.e. Engineering or Institutional Controls)

i) If yes, please explain.

ii) Can you provide any lien or deed restriction paperwork (ie. deed notice or environmental lien)?

B) Is any of the site to your knowledge used as a child-care facility or are plans in place to have a child-care facility on-site?

C) Are there any wetlands or marshlands at the site to your knowledge?

3. COMMONLY KNOW OR REASONABLE ASCERTAINABLE INFORMATION ABOUT THE PROPERTY

A) Do you have any knowledge of the past uses of the property?

i) If so, please explain (dates or tenant contracts should be collected if available for any commercial or industrial uses).

ii) Has the property ever been used for industrial purposes? (ECRA/ISRA applicability).

a. If yes can you provide the NAICS code for the industrial use?

B) Do you know of any Environmental Spills Incident Numbers or Notices of Violation? (i.e., tank removals/Unregulated Heating Oil Tank removals)?

i) If yes, please provide information or available paperwork (ie. former reports or incident numbers)

C) Do you know if the site has been subject to an environmental cleanup or received a NYSDEC No Further Action (NFA) in the past?

D) Do you know of any underground storage tanks (USTs), aboveground storage tanks (ASTs) and/or septic tanks?

E) Do any buildings on the site have a basement or crawlspace?

F) Does the site use/have an incinerator, compactor, or dumpster? (This should include any cooking oil containers or other media.)

G) How is heating and cooling supplied to the site?

a. If by oil, name of usual supplier:

b. If by gas, name of utility company:

c. If by electric, name of utility company:

H) How is water supplied to the site?

a. Local municipal hookup?
    i. If so, name of provider:

b. Potable Well?
    i. If so, well number/designation and location:

I) Is any portion of the site prone to flooding or has had a significant flood?

4. ADJOINING PROPERTIES

A) Have any of the adjoining properties been used for Industrial purposes currently or in the past?

i) If yes, please provide compass direction and name (if known) of the property.

B) Have any of the adjoining properties been used as a gas station, dry cleaner or auto shop currently or in the past?

i) If yes, please provide compass direction and name (if known) of the property.

C) Have any of the adjoining properties been used for commercial purposes currently or in the past?

i) If yes, please provide compass direction and name/ industry (if known) of the property.

D) Have any adjoining properties been used as a high school in currently or in the past?

i) If yes, please provide compass direction and name (if known) of the property.

E) Are any of the adjoining properties currently or in the future (to your knowledge) a child-care facility?

i) If yes, please provide compass direction and name (if known) of the property.

5. ENVIRONMENTAL SITE CONDITIONS

A) Are there any present environmental conditions at the site that may prove an obvious threat to the environment or human health?

B) Do you have any chemical storage areas?

C) Do you have any drum storage areas?

D) Do you have any USTs or ASTs not related to heating?

E) Do you have any of the following at or on the site:

a. On-site dry cleaning or washing machine facilities?

b. Landfills or known fill areas?

c. Machinery or equipment that uses hazardous or petroleum compounds?

d. Dust collectors?

e. Spray booths?

f. Floor drains or sumps?

g. Other machinery or equipment?

7. ADDITIONAL PERTINENT INFORMATION

A) Please provide the reason why the Phase I is required (i.e., sale, purchase, transfer, due diligence, cessation of operation, off-site source of groundwater contamination).

B) Please provide the complete and correct address for the property (any previous surveys maps or any change in tax lot and blocks that are proposed or not yet recorded at the local/county municipality or re- zoning plans):

C) Any additional services or out-of-scope services you wish to be provided in addition to the standard set of services (mold assessment/asbestos assessment/geotechnical/ lead-based paint/indoor or sub-slab air sampling):

D) Please identify all parties to your knowledge who will rely on this ESA? (excluding regulatory agencies)

E) Please provide any former Phase I or Phase II reports, incident reports, NYSDEC Reports, current or former permits for the operation of machinery, tank registration documents, AIRS permits, or other environmental permits.

Appendix B:

Environmental Record Search Results and Information Requests

From: New York DEC FOIL Center
To: Annmarie Yannaco
Subject: FOIL Request :: W143828-030525
Date: Wednesday, March 5, 2025 12:13:40 PM

CAUTION !! This E-Mail originated from outside the organization. Confirm it is from a legitimate E-Mail address. If uncertain - do not click links or open attachments unless you contact the sender and know the content is safe.

Dear Annmarie:

Thank you for your Freedom of Information Law (FOIL) request. Your request has been received and is being processed. Your request was received in this office on 3/5/2025 and given the reference number FOIL #W143828-030525 for tracking purposes. You may expect the Department's response to your request no later than **4/2/2025**.

Record Requested: **Site Address: 100 Main Street, White Plains, NY As part of a Phase I Environmental assessment, SESI requests the following: Documentation of storage tank operation, illegal dumping; hazardous material storage or use; documented release(s), spills or discharges of hazardous chemicals; site inspections, code violations; emergency responses, fires, and environmental reports associated with soil/groundwater investigative sampling.**

You can monitor the progress of your request at the link below and you'll receive an email when your request has been completed. Again, thank you for using the FOIL Center.

Click here to login to the FOIL Center.

New York State Department of Environmental Conservation, Record Access Office

---

Track the issue status and respond at:
https://link.edgepilot.com/s/412820c8/yZIxm16k2k_4IEmFwWU2_w?u=https://newyorkdec.govqa.us/WEBAPP//_rs/RequestEdit.aspx?rid=143828

FREEDOM OF INFORMATION LAW (FOIL) REQUEST FORM

Date:

3/5/2025

This request pertains to records maintained by the (list city department on board):

Fire Bureau

Records Access Officer for above-named city department or board:

Fire Chief

A link to the list of Records Access Officers may be found on the FOIL page of the city website.

Pursuant to New York Freedom of Information Law, I am requesting an opportunity to:

- ☐ Inspect copies of the following records
- ☑ Obtain copies of the following public records

Documents requested:

Site Address: 100 Main Street, White Plains, NY
As part of a Phase I Environmental assessment, SESI requests the following: Documentation of emergency responses and fires.

Be specific. Describe the record with sufficient detail for the public agency to respond.

Requestor's Name:

Annmarie Yannaco

Representing:

SESI Consulting Engineers

Street Address:

959 Route 46E Floor 3, Suite 300

City, State & Zip Code:

Parsippany, NJ 07054

Phone Number:

973 808 9050 ext 280

E-mail:

annmarie.yannaco@sesi.org

Requestor's Signature:

Annmarie Yannaco

AGENCY USE ONLY:

Fees (if applicable):

Please note: There is a photocopying fee of .25 per standard size page, and a $5.00 per page fee for large format plans or maps. Postage fees in the exact amount as levied by the United States Post Office, if mailed.

Date Received:

- [ ] Request Approved
- [ ] Request Denied

FREEDOM OF INFORMATION LAW (FOIL) REQUEST FORM

Date:

3/5/2025

This request pertains to records maintained by the (list city department on board):

Fire Bureau

Records Access Officer for above-named city department or board:

Fire Chief

A link to the list of Records Access Officers may be found on the FOIL page of the city website.

Pursuant to New York Freedom of Information Law, I am requesting an opportunity to:

- ☐ Inspect copies of the following records
- ☑ Obtain copies of the following public records

Documents requested:

Site Address: 100 Main Street, White Plains, NY
As part of a Phase I Environmental assessment, SESI requests the following: Documentation of emergency responses and fires.

Be specific. Describe the record with sufficient detail for the public agency to respond.

Requestor's Name:

Annmarie Yannaco

Representing:

SESI Consulting Engineers

Street Address:

959 Route 46E Floor 3, Suite 300

City, State & Zip Code:

Parsippany, NJ 07054

Phone Number:

973 808 9050 ext 280

E-mail:

annmarie.yannaco@sesi.org

Requestor's Signature:

Annmarie Yannaco

AGENCY USE ONLY:

Fees (if applicable):

Please note: There is a photocopying fee of .25 per standard size page, and a $5.00 per page fee for large format plans or maps. Postage fees in the exact amount as levied by the United States Post Office, if mailed.

Date Received:

- [ ] Request Approved
- [ ] Request Denied

FREEDOM OF INFORMATION LAW (FOIL) REQUEST FORM

Date:

3/5/2025

This request pertains to records maintained by the (list city department on board):

Fire Bureau

Records Access Officer for above-named city department or board:

Fire Chief

A link to the list of Records Access Officers may be found on the FOIL page of the city website.

Pursuant to New York Freedom of Information Law, I am requesting an opportunity to:

- ☐ Inspect copies of the following records
- ☑ Obtain copies of the following public records

Documents requested:

Site Address: 100 Main Street, White Plains, NY
As part of a Phase I Environmental assessment, SESI requests the following: Documentation of emergency responses and fires.

Be specific. Describe the record with sufficient detail for the public agency to respond.

Requestor's Name:

Annmarie Yannaco

Representing:

SESI Consulting Engineers

Street Address:

959 Route 46E Floor 3, Suite 300

City, State & Zip Code:

Parsippany, NJ 07054

Phone Number:

973 808 9050 ext 280

E-mail:

annmarie.yannaco@sesi.org

Requestor's Signature:

Annmarie Yannaco

AGENCY USE ONLY:

Fees (if applicable):

Please note: There is a photocopying fee of .25 per standard size page, and a $5.00 per page fee for large format plans or maps. Postage fees in the exact amount as levied by the United States Post Office, if mailed.

Date Received:

- [ ] Request Approved
- [ ] Request Denied

OFFICE OF THE CITY CLERK
MUNICIPAL BUILDING • 255 MAIN STREET • WHITE PLAINS, NY 10601
(914) 422-1227 • (914) 422-1330 Fax

Jill Iannetta
City Clerk/Registrar

Jennifer Bartolini
Deputy Clerk

March 5, 2025

Annmarie Yannaco
SESI Consulting Engineers
annmarie.yannaco@sesi.org

RE: Request Pursuant to Freedom of Information Law

Dear Annmarie, ,

The City of White Plains, City Clerk's Office is in receipt of your request, addressed to the City Clerk, dated March 5, 2025 and received on same, requesting the following records:

100 Main St., White Plains, NY

I have conducted a search for the requested records and certify that the City Clerk's Office does not possess the requested records.

Please also be advised that the City Clerk's Office does not respond to requests for access to records of other City departments. Any requests to those departments would need to be addressed to them directly.

Sincerely,

Jill Iannetta

Jill Iannetta
City Clerk
Records Access Officer –City Clerk's Office

From: Walsh, Alison
To: Annmarie Yannaco
Subject: Re: FOIL request ATTN: Building Commissioner Damon Amadio
Date: Thursday, March 6, 2025 10:37:07 AM
Attachments: noname
noname
noname
noname
noname
noname
noname
noname
noname
noname

CAUTION !! This E-Mail originated from outside the organization. Confirm it is from a legitimate E-Mail address. If uncertain - do not click links or open attachments unless you contact the sender and know the content is safe.

Hi Annmarie,

There are 8 boxes of files in our records room for the old Galleria site. What is not contained in those boxes will be on our lobby computer. Your FOIL request will involve an exhaustive search of the records.

Please let me know the date and time you would like to visit the Building Department at 70 Church Street to go through everything since I can't pull the files until you arrive due to space constraints in the lobby.

Thanks,
Alison

Alison Walsh
Secretary to the Commissioner
White Plains Building Department
70 Church Street
White Plains, New York 10601
Phone (914) 422-1285
Fax (914) 422-1471

---------- Forwarded message ---------
From: **Annmarie Yannaco** <annmarie.yannaco@sesi.org>
Date: Wed, Mar 5, 2025 at 12:07 PM
Subject: FOIL request ATTN: Building Commissioner Damon Amadio
To: building@whiteplainsny.gov <building@whiteplainsny.gov>

Good afternoon,

Attached please find a FOIL request for the property located at 100 Main Street.

Thank you.

Best,

Annmarie

SESI
CONSULTING ENGINEERS
GEOTECHNICAL
ENVIRONMENTAL
SITE CIVIL

Annmarie Yannaco
Copy Editor
annmarie.yannaco@sesi.org
973-808-9050 Ext 280
862-702-5730
959 Route 46E Floor 3, Suite 300,
Parsippany, NJ 07054

sesi.org

This electronic mail transmission is privileged and confidential and is intended only for the review of the party to whom it is addressed. If you have received this transmission in error, please immediately return it to the sender. Any use, distribution, or forwarding of this e-mail is strictly prohibited. SESI Consulting Engineers will not be responsible for any loss or damage arising in any way from the use of this email. Although this e-mail and any attachments are believed to be free of any virus or other defect that might affect any computer system into which it is received and opened it is the responsibility of the recipient to ensure that it is safe for use.

Appendix C:

Environmental Data Resources, Inc. Reports

100 Main Street

100 Main Street

White Plains, NY 10601

Inquiry Number: 7906442.8

February 24, 2025

The EDR Aerial Photo Decade Package

6 Armstrong Road, 4th floor
Shelton, CT 06484
Toll Free: 800.352.0050
www.edrnet.com

EDR Aerial Photo Decade Package

02/24/25

Site Name:

100 Main Street
100 Main Street
White Plains, NY 10601
EDR Inquiry # 7906442.8

Client Name:

SESI Consulting Engineers
959 Route 46E 3rd Floor
Parsippany, NJ 07054
Contact: Annmarie Yannaco

Environmental Data Resources, Inc. (EDR) Aerial Photo Decade Package is a screening tool designed to assist environmental professionals in evaluating potential liability on a target property resulting from past activities. EDR's professional researchers provide digitally reproduced historical aerial photographs, and when available, provide one photo per decade.

Search Results:

Year	Scale	Details	Source
2019	1"=500'	Flight Year: 2019	USDA/NAIP
2015	1"=500'	Flight Year: 2015	USDA/NAIP
2011	1"=500'	Flight Year: 2011	USDA/NAIP
2006	1"=500'	Flight Year: 2006	USDA/NAIP
1994	1"=500'	Acquisition Date: April 20, 1994	USGS/DOQQ
1991	1"=500'	Flight Date: April 03, 1991	USGS
1985	1"=500'	Flight Date: March 16, 1985	USDA
1974	1"=500'	Flight Date: October 24, 1974	USDA
1971	1"=500'	Flight Date: April 24, 1971	USGS
1964	1"=500'	Flight Date: March 23, 1964	USGS
1962	1"=500'	Flight Date: January 16, 1962	EDR Proprietary Aerial Viewpoint
1958	1"=500'	Flight Date: August 05, 1958	USGS
1953	1"=500'	Flight Date: December 17, 1953	USGS
1949	1"=500'	Flight Date: March 14, 1949	USGS
1941	1"=500'	Flight Date: October 06, 1941	USGS

When delivered electronically by EDR, the aerial photo images included with this report are for ONE TIME USE ONLY. Further reproduction of these aerial photo images is prohibited without permission from EDR. For more information contact your EDR Account Executive.

Disclaimer - Copyright and Trademark Notice

This Report contains certain information obtained from a variety of public and other sources reasonably available to Environmental Data Resources, LLC. It cannot be concluded from this Report that coverage information for the target and surrounding properties does not exist from other sources. This Report is provided on an "AS IS", "AS AVAILABLE" basis. NO WARRANTY EXPRESS OR IMPLIED IS MADE WHATSOEVER IN CONNECTION WITH THIS REPORT. ENVIRONMENTAL DATA RESOURCES, LLC AND ITS SUBSIDIARIES, AFFILIATES AND THIRD PARTY SUPPLIERS DISCLAIM ALL WARRANTIES, OF ANY KIND OR NATURE, EXPRESS OR IMPLIED, ARISING OUT OF OR RELATED TO THIS REPORT OR ANY OF THE DATA AND INFORMATION PROVIDED IN THIS REPORT, INCLUDING WITHOUT LIMITATION, ANY WARRANTIES REGARDING ACCURACY, QUALITY, CORRECTNESS, COMPLETENESS, COMPREHENSIVENESS, SUITABILITY, MERCHANTABILITY, FITNESS FOR A PARTICULAR PURPOSE, TITLE, NON-INFRINGEMENT, MISAPPROPRIATION, OR OTHERWISE. ALL RISK IS ASSUMED BY THE USER. IN NO EVENT SHALL ENVIRONMENTAL DATA RESOURCES, LLC OR ITS SUBSIDIARIES, AFFILIATES OR THIRD PARTY SUPPLIERS BE LIABLE TO ANYONE FOR ANY DIRECT, INCIDENTAL, INDIRECT, SPECIAL, CONSEQUENTIAL OR OTHER DAMAGES OF ANY TYPE OR KIND (INCLUDING BUT NOT LIMITED TO LOSS OF PROFITS, LOSS OF USE, OR LOSS OF DATA), ARISING OUT OF OR IN ANY WAY CONNECTED WITH THIS REPORT OR ANY OF THE DATA AND INFORMATION PROVIDED IN THIS REPORT.

Any analyses, estimates, ratings, environmental risk levels, or risk codes provided in this Report are provided for illustrative purposes only, and are not intended to provide, nor should they be interpreted as providing any facts regarding, or prediction or forecast of, any environmental risk for any property. Only an assessment performed by a qualified environmental professional can provide findings, opinions or conclusions regarding the environmental risk or conditions in, on or at any property.

Copyright 2025 by Environmental Data Resources, Inc. All rights reserved. Reproduction in any media or format, in whole or in part, of any report or map of Environmental Data Resources, Inc., or its affiliates, is prohibited without prior written permission.

EDR and its logos (including Sanborn and Sanborn Map) are trademarks of Environmental Data Resources, LLC or its affiliates. All other trademarks used herein are the property of their respective owners.

INQUIRY #: 7906442.8

YEAR: 2019

= 500'

N

EDR

INQUIRY #: 7906442.8
YEAR: 2015
= 500'
N
EDR

INQUIRY #: 7906442.8

YEAR: 2011

= 500'

N

EDR

INQUIRY #: 7906442.8
YEAR: 2006
= 500'
N
EDR

INQUIRY #: 7906442.8

YEAR: 1994

= 500'

N

EDR



INQUIRY #: 7906442.8

YEAR: 1991

= 500'

N

EDR

INQUIRY #: 7906442.8

YEAR: 1985

= 500'

N

EDR



INQUIRY #: 7906442.8

YEAR: 1974

= 500'

N

EDR

INQUIRY #: 7906442.8
YEAR: 1971
= 500'
N
EDR



INQUIRY #: 7906442.8

YEAR: 1964

= 500'

N

EDR



INQUIRY #: 7906442.8

YEAR: 1962

= 500'

N

EDR

INQUIRY #: 7906442.8

YEAR: 1958

= 500'

N

EDR

INQUIRY #: 7906442.8

YEAR: 1953

= 500'

N

EDR



INQUIRY #: 7906442.8

YEAR: 1949

= 500'

N

EDR

INQUIRY #: 7906442.8

YEAR: 1941

= 500'

N

EDR

100 Main Street
100 Main Street
White Plains, NY 10601

Inquiry Number: 7906442.5
February 25, 2025

The EDR-City Directory Image Report

Environmental Data Resources Inc

6 Armstrong Road
Shelton, CT 06484
800.352.0050
www.edrnet.com

TABLE OF CONTENTS

SECTION

Executive Summary

Findings

City Directory Images

Thank you for your business.
Please contact EDR at 1-800-352-0050
with any questions or comments.

Disclaimer - Copyright and Trademark Notice

This Report contains certain information obtained from a variety of public and other sources reasonably available to Environmental Data Resources, LLC. It cannot be concluded from this Report that coverage information for the target and surrounding properties does not exist from other sources. This Report is provided on an "AS IS", "AS AVAILABLE" basis. **NO WARRANTY EXPRESS OR IMPLIED IS MADE WHATSOEVER IN CONNECTION WITH THIS REPORT. ENVIRONMENTAL DATA RESOURCES, LLC AND ITS SUBSIDIARIES, AFFILIATES AND THIRD PARTY SUPPLIERS DISCLAIM ALL WARRANTIES, OF ANY KIND OR NATURE, EXPRESS OR IMPLIED, ARISING OUT OF OR RELATED TO THIS REPORT OR ANY OF THE DATA AND INFORMATION PROVIDED IN THIS REPORT, INCLUDING WITHOUT LIMITATION, ANY WARRANTIES REGARDING ACCURACY, QUALITY, CORRECTNESS, COMPLETENESS, COMPREHENSIVENESS, SUITABILITY, MERCHANTABILITY, FITNESS FOR A PARTICULAR PURPOSE, TITLE, NON-INFRINGEMENT, MISAPPROPRIATION, OR OTHERWISE. ALL RISK IS ASSUMED BY THE USER. IN NO EVENT SHALL ENVIRONMENTAL DATA RESOURCES, LLC OR ITS SUBSIDIARIES, AFFILIATES OR THIRD PARTY SUPPLIERS BE LIABLE TO ANYONE FOR ANY DIRECT, INCIDENTAL, INDIRECT, SPECIAL, CONSEQUENTIAL OR OTHER DAMAGES OF ANY TYPE OR KIND (INCLUDING BUT NOT LIMITED TO LOSS OF PROFITS, LOSS OF USE, OR LOSS OF DATA), ARISING OUT OF OR IN ANY WAY CONNECTED WITH THIS REPORT OR ANY OF THE DATA AND INFORMATION PROVIDED IN THIS REPORT.** Any analyses, estimates, ratings, environmental risk levels, or risk codes provided in this Report are provided for illustrative purposes only, and are not intended to provide, nor should they be interpreted as providing any facts regarding, or prediction or forecast of, any environmental risk for any property. Only an assessment performed by a qualified environmental professional can provide findings, opinions or conclusions regarding the environmental risk or conditions in, on or at any property.

Copyright 2023 by Environmental Data Resources, LLC. All rights reserved. Reproduction in any media or format, in whole or in part, of any report or map of Environmental Data Resources, LLC, or its affiliates, is prohibited without prior written permission.

EDR and its logos (including Sanborn and Sanborn Map) are trademarks of Environmental Data Resources, LLC or its affiliates. All other trademarks used herein are the property of their respective owners.

EXECUTIVE SUMMARY

DESCRIPTION

Environmental Data Resources, Inc.'s (EDR) City Directory Report is a screening tool designed to assist environmental professionals in evaluating potential liability on a target property resulting from past activities. EDR's City Directory Report includes a search of available business directory data at approximately five year intervals.

RECORD SOURCES

The EDR City Directory Report accesses a variety of business directory sources, including Haines, InfoUSA, Polk, Cole, Bresser, and Stewart. Listings marked as EDR Digital Archive access Cole and InfoUSA records. The various directory sources enhance and complement each other to provide a more thorough and accurate report.

EDR is licensed to reproduce certain City Directory works by the copyright holders of those works. The purchaser of this EDR City Directory Report may include it in report(s) delivered to a customer.

RESEARCH SUMMARY

The following research sources were consulted in the preparation of this report. A check mark indicates where information was identified in the source and provided in this report.

Year	*Target Street*	*Cross Street*	*Source*
2020	☑	☐	EDR Digital Archive
2017	☑	☐	Cole Information
2014	☑	☐	Cole Information
2010	☑	☐	Cole Information
2005	☑	☐	Cole Information
2000	☑	☐	Cole Information
1995	☑	☐	Cole Information
1992	☑	☐	Cole Information
1987	☑	☐	Cole Criss-Cross Directory
1982	☑	☐	Cole Criss-Cross Directory
1977	☑	☐	Cole Criss-Cross Directory
1972	☑	☐	Cole Criss-Cross Directory
1965	☑	☐	Polk's City Directory
1963	☑	☐	Polk's City Directory

FINDINGS

TARGET PROPERTY STREET

100 Main Street
White Plains, NY 10601

Year	*CD Image*	*Source*
MAIN ST		
2020	pg A2	EDR Digital Archive
2017	pg A6	Cole Information
2014	pg A17	Cole Information
2010	pg A28	Cole Information
2005	pg A40	Cole Information
2000	pg A48	Cole Information
1995	pg A63	Cole Information
1992	pg A77	Cole Information
1987	pg A91	Cole Criss-Cross Directory
1987	pg A92	Cole Criss-Cross Directory
1982	pg A93	Cole Criss-Cross Directory
1982	pg A94	Cole Criss-Cross Directory
1977	pg A95	Cole Criss-Cross Directory
1972	pg A96	Cole Criss-Cross Directory
1965	pg A97	Polk's City Directory
1965	pg A98	Polk's City Directory
1963	pg A100	Polk's City Directory
1963	pg A99	Polk's City Directory

FINDINGS

CROSS STREETS

No Cross Streets Identified

City Directory Images

Target Street	Cross Street	Source
✓	-	EDR Digital Archive

MAIN ST 2020

59	WHITE PLAINS PLUMBING & HTG
81	81 MAIN REALTY LLC
	AMINCO RESOURCES
	BOYNTON SALLY J ATY
	BRICCETTI CALHOUN & LAWRENCE
	CALHOUN & LAWRENCE LLP
	CHARTWELL LAW OFFICES LLP
	COMER NEAL S ATY
	EDWARD H ODESSER LLC
	FLEISCHMAN BONNER & ROCCO LLP
	GOLDSCHMIDT & GENOVESE LLP
	GUSRAE KATLAN NESBAUM
	HAROLD SALANT STRASSFIELD
	HARRINGTON OCKO & MONK
	HARRINGTON OCKO & MONK ATTYS
	HEIDELL PITTONI MURPHY-BACH
	HOCHFELDER & ASSOC
	JENKS PROPERTIES LLC
	KINGDOM RIDGE CAPITAL LLC
	L M ZUCKERMAN CO INC
	LAW OFFICES OF DUANE M FIEDLER
	LINCOLN FINANCIAL GROUP
	LNK PARTNERS LLC
	MARSH & WEINGARDEN PLLC
	NEWMARK KNIGHT FRANK
	ODESSER EDWARD H LLC
	ODESSER SCHILLINGER
	PANNONE LOPES DEVEREAUX & WEST
	PERRY LAWRENCE ATY
	PORTFOLIO STRATEGY GROUP LLC
	SCHILLINGER & FINSTERWALD LLP
	SEEGER & SEEGER
	SILVERMAN JOAN S ATY
	STONEBRIDGE PARTNERS
	T WEST HOLDING EQUITIES CORP
	WEININGER WILLIAM ATY
	WEST GROUP LAX PLLC
	ZARIN & STEINMETZ
100	A DOLLAR 143
	AEO FACTORY STORE
	AEROPOSTALE
	ART OF THREADING INC
	AS SEEN ON TV
	AT&T STORE
	BATH & BODY WORKS
	BELTONE AUDIOLOGY HEARING CARE
	BLINK FITNESS
	BOURBON STREET CAFE
	BURGER KING
	CARVEL EXPRESS

Target Street	Cross Street	Source
✓	-	EDR Digital Archive

MAIN ST 2020 (Cont'd)

100	CHAMPS SPORTS
	CHARLEYS PHILLY STEAKS
	CHESTER-MAPLE GARAGE
	CHIC BOUTIQUE
	CHILDREN'S PLACE
	CINNABON
	CLAIRE'S
	COHEN'S FASHION OPTICAL
	CUSTOM T'S INC
	DINCHER STEPHEN M OD
	DUNKIN'
	ECO ATM
	ELECTRIC CHARGING STATION
	FAMOUS FOOTWEAR
	FINISH LINE AT MACY'S
	FOOT LOCKER
	FOOTACTION
	FOREVER 21
	GALLERIA AT WHITE PLAINS
	GALLERIA GARAGE
	GALLERIA MALL DENTAL
	GALLERIA MALL DENTAL PC
	GLORIA'S LLC
	GNC
	GREEN HEALING CTR
	H&M
	HICKORY FARMS
	HOOKS CHARLES
	HOT TOPIC
	INTRIGUE JEWELERS
	JIMMY JAZZ
	JOURNEYS
	KAY JEWELERS
	KEY ME
	KFC
	KIDS FOOT LOCKER
	LENSCRAFTERS
	LEXINGTON-GROVE GARAGE
	LEXINGTON-GROVE GARAGE EAST
	LIDS
	LOLLIPOP TOYS SHOP
	LOUNGE RETAIL GROUP INC
	M & S JEWELERS INC
	MACY'S
	MACY'S BACKSTAGE
	MASTER WOK MWWP
	NAILPORT SPA SALON
	NAILS & MORE BY DAWN
	NEWS CORNER
	OLD NAVY

Target Street	Cross Street	Source
✓	-	EDR Digital Archive

MAIN ST 2020 (Cont'd)

100	OMORFIA ONLINE SHOP INC
	PANICKER RINA KOSHY
	PIERCING PAGODA
	PROFESSIONAL ORTHOPEDIC-SPORTS
	PROFESSIONAL PHYSICAL THERAPY
	RAINBOW
	SAL'S PERFUMES
	SALON AMERICAS INC
	SARKU JAPAN
	SBARRO
	SEARS
	SEARS APPLIANCE REPAIR
	SEARS AUTO CENTER
	SHAPE-UP
	SINGH VIJETA DDS
	SOCK DRAWER
	SPENCER'S
	SUBWAY
	SUNGLASS HUT AT MACY'S
	T-MOBILE
	TATE'S MENSWEAR
	VICTORIA'S SECRET
	ZUMIEZ
110	FRANK'S ON-TIME PAINTING
111	A ELECTRIC INC
	AUTHENTIC WINDOW DESIGN LLC
	DANZIG FISHMAN & DECEA
	DIVERSE IMAGING INC
	HIGH DEFINITION WATER NY CORP
	HUNTINGTON LEARNING CTR
	JEFF STUDER LAWN IRRGTN INC
	LAW OFFICE-MICHAEL CAMPOREAL
	PRIMERICA FINANCIAL SVC
	TRISTATE RESTORATION
123	AFRICAN AMERICAN CHAMBER
	ASSURED PARTNERS
	BRAUNSTEIN & ZUCKERMAN
	CAMILLE'S SIDEWALK CAFE
	DAHAN & NOWICK
	DANMAR INC
	DANZIGER & MARKHOFF
	GORDON STEPHEN G ATY
	HODOGAYA CHEMICAL USA INC
	LOB GAYLE S
	MNG-MY NETWORKING GROUP
	NEIL J BROWN & ASSOC
	NEW YORK POWER AUTHORITY
	RAFFERT & REDLISKY
	SKCG GROUP INC
	THOMAS M BONA PC

Target Street	Cross Street	Source
✓	-	EDR Digital Archive

MAIN ST 2020 (Cont'd)

149 MENDEL OPTICAL
159 GYU-KAKU

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 2017

50

A 24 7 EMERGENCY LOCKSMITH
A KELLY JOSEPH ESQ
A WEST HARRISON 24 7 EMERGENCY LOCKS
ABM JANITORIAL SERVICE
ACORN DERIVATIVES MANAGEMENT CORP
ADVISO GROUP
AFFILIATED PROFESSIONAL SERVICES
AGILE IT
AJT REALTY GROUP
ALCOA
ALERION
ALL FOGEL ESQ
ALTMAN LAW GROUP
ARCHER ASSOCIATES INC
ASF CAPITAL CORP
ASSOCIATES OF WESTPORT
ATLANTIC BENEFITS GROUP
ATLMAN LAW GROUP LLC
BAISYS CONSULTING LLC
BANFIELD THE PET HOSPITAL
BENEFICIAL CREDIT SERVICES
BERMAN EDWARD ESQ
BEVAN RESOURCES
BHARAT DIAMOND COMPANY
BIFROST FUND LP
BLOOMENTHAL & TROW
BLSH INVESTMENT COUNSEL LLC
BOSLEY
BROOKLINE TECHNOLOGIES
BUNGE
CAPITAL CAFE
CHARLES SCHWAB
CICHANOWITZ & CALLAN
CJS SECURITIES
CLASSIC WESTCHESTER INC
CONCEPT CARE INC
COUNTRYWIDE HOME LOANS
CUDDY LAW FIRM
CUSHNER & GARVEY LLP
CWK NETWORK INC
DAIO PAPER USA INC
DANIEL ERSKINE ESQ
DATA REGUS
DAVID I GRAUER
DERICK C JANUARY ATTY
DIAMOND REPORTING INC
DOUBLE BYTES
E C S
ECORE INTL
EG HOLDINGS CORP

50	EUGENE SEKULOW
	EXCELL PRINT & PROMOTIONS
	FEBBRAIO GREG LAW OFFICES
	FINE OLIN & ANDERMAN LLP
	FIRST DARTMOUTH
	FIRST GREAT WEST LIFE & ANNUITY
	FRIEDMAN & FERGUSON
	FUNDEX CAPITAL CORPORATION
	GARVEY TIRELLI & CUSHNER
	GARY GOLDBERG & CO INC
	GENERAL DYNAMICS
	GEORGE KOKKALENIOS ESQ
	GID GLOBAL
	GMAC MORTGAGE
	GOLDBERG WEINBERGER
	GORDON & SILBER PC
	GRAFICO INC CO
	GREENBERG TRAURIG LLP
	GRUBER LEE MD
	HALCOLL CAPITAL MANAGEMENT
	HALYARD ASSET MANAGEMENT LLC
	HIGHENDMENHAIRPRODUCT HIGHENDMENHAIR
	HOSPITAL INSURANCE CO
	HRH CONSTRUCTION LLC
	HUDSON VALLEY INVESTMENT
	ILENE RABINOWITZ MD
	IT MANAGEMENT PARTNERS
	ITEC INC
	J & J REALTY
	JACOBY & MEYERS LAW OFFICES
	JANUARY BRINTON ATTYS
	JEWERLRY JUDGE
	JLL & ASSOCIATES
	JON LEVINE STEVEN ESQ
	JORDAN ENTERPRISES GROUP
	KANTERMAN & TAUB PC
	KEENAN POWERS & ANDREWS
	KEN TUCHMAN & ASSOCIATES
	KEVIN J KITSON ATTY
	KEVIN MATZ & ASSOCIATES PLLC
	KIPNES CROWLEY GROUP
	KRG CAPITAL
	KURZMAN KARELSON & FRANK
	L R BLOCH LAW MITCHELL
	L ROBERT BRINTON ATTY
	LAW OFFICE OF BEVERLY ROGERS LLC
	LAW OFFICE OF DANNA WOOD
	LAW OFFICE OF HERBERT ALDER
	LAW OFFICE OF JOHN SANDLEITNER
	LAW OFFICE OF MARTIN B EPSTEIN

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 2017 (Cont'd)

50

LAW OFFICE OF MARY RIZZO
LAW OFFICE OF NEAL FUTERFAS
LAW OFFICE OF NORMAN ROSNER
LAW OFFICES OF STANLEY MESSINGER
LAWRENCE A GARVEY ATTY
LEGAL & MEDICAL TRANSCRIPTIONS
LEO ZUCKER ATTY
LEVINE & ZELMAN
LEXIEN CONSULTANTS
LISS MICHAEL ATTV
LISS MICHAEL ESQ
MACKCALI
MANPOWER
MANZOS FURNITURE CITY
MARCUS & MILLICHAP
MARKETING BEYOND DESIGN
MARKSTON INTERNATIONL LLC
MARSH & MCLENNAN LLC
MARTONE CAPITAL MGMT
MBS ASSET MANAGEMENT
MBS FINANCIAL GROUP
MEDSOURCE
MERIDIAN VAT RECLAIM
MILESTONE MANAGEMENT
MMR FOOD & DRINK RESEARCH WORLDWID
MONSTER MOVING
MORRIS JAMES ATTV
NATIONAL ECONOMIC RESEARCH ASSOCS
NAVATEL
NEAL FUTERFAS ATTY
NETRADIOLOGY
NJ ATM SERVICES
NORTHEAST REALTY GROUP
NORTHWESTERN MUTUA
NORTHWESTERN MUTUAL FINANCIAL NETWOR
NU ENERGEN
NY COMMERCIAL LENDING
PACIFIC LIFE INSURANCE COMPANY
PACIFIC PARTNERS
PARADISE ROAD
PATRICIA T BISESTO ATTY
PAXTON RESOURCES
PAYTREX
PENSIONS SERVICES OF WESTCHESTER
PHILIP J MESSING CPA
PHOENIX GLOBAL SUPPLY GROUP
PILGRIM ADVISORS
PINO & ASSOCIATES
PIONEER CORP
PROVEN DATA RECOVERY

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 2017 (Cont'd)

50	PULLMAN & COMELY LLC
	RAKOW COMMERCIAL REALTY
	REDAC
	REGUS
	RIORDAN EUGENE ESQ
	SANDRA NUEBARDTS OFFICE
	SAUNDRA NEUBARDT ATTY
	SCB PARTNERS
	SESE NATHANIEL ESQ
	SESTI LAW FIRM PC
	SHIPMAN & GOODWIN
	SINGER NETTER DOWD & BERMAN PLLC
	SOFTWARE BY DESIGN
	SPEISER & HEINZMAN
	SPERRY VAN NESS
	STARFUELS
	STEINBERG & CAVALIERE
	STEINBERG & CAVALIERE LLP
	STRATEGIC INTELLIGENCE
	THE CAMAJ LAW FIRM PC
	THE INGBER LAW FIRM
	THE WOODLARK COMPANIES
	TITLE AMERICA ABSTRACT CORP
	TODD S CUSHNER ATTY
	TOKIWA COSMETICS INC
	TOKYO ZAIRYO CO LTD
	TWO BROTHERS LOCKSMITH
	V HB
	VHB
	WEISSLER RONALD I ESQ
	WESTCHESTER CAPITAL PLANNING
	YAMOUTH VENTURE GROUP
	YESS PROPERTY MGMT
59	WHITE PLAINS PLUMBING & HEATING
81	81 MAIN LLC
	AMINCO RESOURCES INC
	ARONWALD & PYKETT
	BOYNTON SALLY J LLC
	BRICCETTI CALHOUN & LAWRENCE LLP
	CARL BLOOM ASSOCIATES
	CERBONE LAW
	CLINTON W CALHOUN III ATTY
	COTRONEI P CHRISTOPHER
	COTRONEI P CHRISTOPHER ATTORNEY
	CREATIVE TECHNOLOGIES GROUP INC
	DANIEL BEATON ENGR
	DANIEL J PYKETT ATTY
	DAVID CHARNEY FOUNDATION
	DAVID STEINMETZ ATTY
	DEL VECCHIO & PACOR

81

EINHORN YAFFEE PRESCOTT
FAMILY COURT
GARY F LEWIS CPA
GUSRAE KATLAN NESBAUM
HALLORAN & SAGE LLP
HAROLD SALANT STRASSFIELD & SPIELB
HARRINGTON OCKO & MONK
HEIDELL PITTONI MURPHY & BACH LLP
INTERFACET INC
IPN COMMUNICATIONS
JESSICA G GOLDSMITH ESQ
KAMLER LEWIS & NOREMAN LLP KLN
KERRY A LAWRENCE ATTY
KINGDOM RIDGE CAPITAL LLC
KINGDOM RIDGE CAPTIAL
LAUTERBACH GARFINKEL DAMAST & HOLLAN
LAW OFFICES OF MICHELL I WEINGARDEN
LAW OFFICES OF TIMOTHY A GREEN
LEASON ELLIS LLP
LEONARD I SOLELBERG ATT
LNK PARTNERS LLC
MENKENWE INGARDEN
MESSINA & ASSOCS PC
MICHAEL ZARIN ATTY
NEWMARK & CO REAL ESTATE
ODESSER EDWARD H LLC
PANNONE LOPES & DEVEREAUX
PANNONE LOPES DEVEREAUX & WEST LLC
PARELLEL ASSET MANAGEMENT ROBERT
PETER ELLIOT LLC
PHILLIP C LANDRIGAN ATTY
ROBERT E MARTINEZ PLLC
ROBERT FITZGERALD PC
ROTBARD & FILASTRO
SCHILLINGER & FINSTERWALD LLP
SCHWARTZAPFEL LAWYERS PC
SEEGER & SEEGER
SILVERMAN JOAN S ATTORNEY AT LAW
SKY WILBER FOUNDATION
STANLEY A ROSS CPA
THE LAW OFFICE OF ANDREW PATEL
THE LAW OFFICES OF STEPHEN HABER
THE PORTFOLIO STRATEGY GROUP INC
THOMAS M ROACH ATTY
VINCENT L BRICCETTI ATTY
WILLIAM A CERBONE ESQ
WILLIAM A ROSE ARCHT
WILLIAM I ARONWALD ATTY
WILLIAM WEININGER ATTY
YOUNG & BARTLETT LLP

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 2017 (Cont'd)

81	ZARIN & STEINMETZ
100	A DOLLAR
	A PEA IN THE POD
	A&J RELIABLE
	AHK CHARLEYS INC
	ALDO SHOES
	AMERICAN EAGLE OUTFITTERS
	ART OF THREADING INC
	AS SEEN ON TV
	AT&T
	AUNTIE ANNES
	BEAUTY OF ART
	BELTONE
	BLINK FITNESS
	BOURBON STREET CAFE
	BROOKSTONE
	BUCKLE
	BURGER KING
	C & C MARKET RESEARCH
	CHAMPS SPORTS
	CHARLOTTE RUSSE
	CHIC BOUTIQUE
	CINNABON
	COHENS FASHION OPTICAL
	COMMERICA LOCK & KEY SERVICE
	CUSTOM T S INC
	DUNKIN DONUTS
	EXPRESS
	EXPRESS INC
	FAMOUS FOOTWEAR
	FINISH LINE
	FOOT LOCKER
	FOOTACTION USA
	FOREVER 21
	GALLERIA MALL AT WHITE PLAINS
	GALLERIA MALL DENTAL P F C
	GALLERIA NY SUBWAY
	GAMESTOP
	GARAGE
	GARAGE CLOTHING
	GIFTS 4 US
	GLOBAL DEAL
	GLORIAS LLC
	H&M
	HOME SECURITY PLUS
	HOT TOPIC
	ICING BY CLAIRES
	INTRIGUE JEWELERS
	JEWEL HUT
	JIMMY JAZZ

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 2017 (Cont'd)

100
JOURNEYS
KAY JEWELERS
KFC TACO BELL
KIDS FOOT LOCKER
LENSCRAFTERS
LOUNGE RETAIL GROUP INC
LUGGAGE N MORE
M & S FINE JEWELERS
MACYS
MACYS BACKSTAGE
MASSAGE SENSATIONS INC
MASTER WOK MWWP
MICHAEL MATTHEWS JEWELERS
MOTHERHOOD MATERNITY
MY KITCHEN
NAILPORT SPA SALON
NAILS & MORE BY DAWN
NATHANS FAMOUS
NB NET
NEW DEAL LLC
OLD NAVY
ORIENTAL EXPRESS
PACSUN
PAYLESS SHOESOURCE
PERFULANDIA
PIERCING PAGODA
PRINTS PLUS
PROFESSIONAL ORTHOPEDIC & SPORTS PHY
RAINBOW
RIGHT ON
SAL S PERFUMES
SARKU JAPAN
SEARS
SEARS APPLIANCE REPAIR
SEARS PARTS & REPAIR CENTER
SHAPEUP
SIMON PROPERTIES
SIMPLE GREEN NY INC DBA GREEN HEALIN
SOCIAL NY
SOCK DRAWER
SUBWAY
TACO BELL
TATES MENSWEAR
THE CHILDRENS PLACE
THE HAIR DESIGNERS
THE NEWS CORNER
THE WATCH STOP
TMOBILE
TRAFFIC SHOES
TROPICAL SMOOTHIE CAFE

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 2017 (Cont'd)

100	UMBERTOS
	VICTORIAS SECRET
	VICTORIAS SECRET & PINK
	VITAMIN WORLD
	WENDYS
	WHITE PLAINS GALLARIA PARTNERSHIP
	WHITE PLAINS GARAGE DOORS & OPENER
	XXI FOREVER
	ZUMIEZ
110	FRANKS ONTIME PAINTING
111	A ELECTRIC INC
	AMERICA AUTO TECH
	BRAKES CLUTCHES DRIVE
	DANZIG FISHMAN & DECEA
	DENT DOCTOR
	DESIGNERS QUAD GROUP PC
	DOREEN GINIPRO
	DR MELVYN GROVIT
	ENDICOTT UNION INC
	EREZ ZIPORI EREZ
	EXERFIX INC
	HAGISCHI
	HOWARD YUDIN MD
	HUNTINGTON LEARNING CENTER
	J & L REPORTING SVCE
	MESSINA ASSOCIATES
	MR CHIMNEY
	PARATRANSIT MEDICA LLC
	SCHWARTZAPFEL LAWYERS PC
	TRISTATE RESTORATION
	VERIZON
	WHITE PLAINS RUBBER
123	A ADVANCED LOCKSMITH
	ASSURED SKCG INC
	BOROWICK FELDMAN & GRONER PC
	BRAUNSTEIN & ZUCKERMAN
	CAFE 123
	CANTER LAW FIRM PC
	DAHAN & NOWICK
	DANMAR INC
	DANZIGER & MARKHOFF LLP
	EMPIRE STATE DEVELOPMENT
	FEDERAL BAR COUNCIL
	HODOGAYA CHEMICAL CO LTD
	LAWRENCE JAY BRAUNSTEIN ATTY
	LOB GAYLE S CFP FINANCIAL STRATE
	NELSON CANTER ESQ
	NEW YORK POWER AUTHORITY
	NIPPOLY AMERICA CORP
	NOWICK DAHAN

123	RAFFERT & REDLISKY
	SKCG
	SKCG GROUP INC
	STEPHEN G GORDON ATTY
	THE FRUSTUM GROUP INC
	THE PARKER GROUP
	THE VIII MARKETING INC
	THOMAS M BONA ATTY
	VICTORY LOCKSMITH
	WESTCHESTER PHILHARMONIC
165	BLOOMING GLORY HOSPIT
169	ALPHAGRAPHICS
171	VINTAGE BAR & RESTAURANT
175	1 24 HOUR EMERGENCY LOCKSMITH
	175 MAIN ST SUPER INT
	A & A STAFFING HEALTH CARE SERVICES
	A R I
	ALL METRO HEALTH CARE
	ALLAN GREENSTEIN ATTY
	ARENA DEBRA A ATTORNEY
	ARLEN S YALKUT ATTY
	ARROW ONE TAXI CORP
	BARR ASSOCIATES INC
	BARRISTER PROPERTIES LTD
	BAYBERRY PROPERTY MANAGEMENT & LEASI
	CENTRAL TAXI SERVICE CORP
	CENTRALTAXI CENTRALTAXI
	COOPER MARVIN A ATTY
	COURTHOUSE BARBERS SHOP
	DAMORE DELICAFE
	DAVID MILLER KAHN ATTY
	DRS REALTY GROUP LLC
	ELIOT L KAPLAN ESQ
	EXPRESS CONSTRUCTION
	GELLER & RIVERA PC
	GREENSTEIN SOL D
	HAROLD J JOHNSON ATTY
	HIGHLAND APPRAISALS INC
	HOME ROBERT ESQ
	JAMES C KAHN ATTY
	JOHN J MCMAHON ATTORNEY
	JOSEPH A SCUTIERI ATTY
	KAHN & KAHN
	LAW OFFICES OF JOSEPH SCUTIERI
	LLF CONSTRUCTION SERVICES
	M J HYMAN CPA
	MARTIN J ROSEN ATTY
	MARTIN P MANNION ASSOC
	MERCHANT SERVICES
	MURPHY MCPARTLAND & WALSH

175	NEGRO ARTHUR DEL L JR ATTY
	NORTH COURT BLDG
	PAT BONANNO ATTY
	PETER MARASCO AGENCY INC
	PICKELLE PAUL W ATTORNEY AT LAW
	POLICE FRESH AIR FUND
	PROFESSIONAL TOUCH IN
	PROMOTIONAL MAILING SVCES
	Q & A REPORTING SERVICE
	ROBERT HORNE ESQ
	ROBIN REICH ATTY
	ROLAND A BARONI JR LWYR
	ROXANNE BEECHER ATTORNEY AT LAW
	SELBST GROUP INC
	SMART DAILY ADMINSTARTORS
	SOFRITO
	SOL D GREENSTEIN ATTY
	STEADFAST FUNDING LLC
	STEPHEN R LEWIS ATTY
	STEPHENS BARONI REILLY & LEWIS
	STEVEN P KMETZ ATTY
	SUITE 401 MANAGEMENT CO LTD
	THANKACHAN GHEEVARGHESE
	THE COPY HUT
	THOMAS IANNUCCILLI PLLC
	THOMAS J LYNCH ATTY
	TRACKER PRO
	WALTER JAY HIRSCH & CO LLP
	WELCOME NETWORK CORP
	WESTCHESTER LAW JOURNAL
185	KARAMBA CAFE CORP
187	L & C RESTAURANT CORPORATION
189	KRISTOPHER GARAGE DOORS
199	175 MEMORIAL HWY REALTY CORP
	ARNOLD S KRONICK ATTY
	AROW LOCKSMITH & KEYS
	BERLIN PRODUCTIONS
	BRUCE STEVEN PINKER DPM
	CHIROPRACTIC REHAB
	CLEAR BID
	CLEARVIEW COUNSELING GROUP
	DANIEL A KALISH ATTY
	DR DLUCS
	EUGENE J LOMBARDO ICSW
	FIECH PIACENTE & STANO
	GLOBAL FINANCIAL CREDIT LLC
	IPN COMMUNICATIONS
	JOEL SPIVACK MD
	JOS J FIECH C P A
	KALISH DANIEL A ATTORNEY

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 2017 (Cont'd)

199	KELSEY COMPANYNY
	LAW OFFICE OF THOMAS AGOGLIA
	LEHRMAN KRONICK & LEHRMAN LLP
	LISA S GOLDMAN ATTORNEY AT LAW
	MICROCREDITOS DEL PACIFICO
	NORTH AVENUE MARINE REALTY CORP
	PETER STANO CPA
	PHYSICIANS BILLING SERVICE INC
	PREMIER HOME HEALTH
	RAYS COPY SERVICE LLC
	REIGNS CAPITAL
	ROBINOWITZ COHLAN & DUBOW
	ROBINOWITZ COHLAN DUBOW & DOHERTY LL
	RONAI & RONAI LLP
	RTS CAPITAL LLC
	SEHAM SEHAM MELTZ & PETERSON
	SERAFINA WHITE PLAINS
	SUMMIT TRADING
	TOMLIN LAW
	TOWBIN M R REALTY INC
	UNICORN CONTRACTING
	WESTCHESTER FOOTCARE CENTER
	WHITE PLAINS CHILD DAY CARE ASSOC
	WHITE PLAINS PRINTERS S CORP
200	DUTAN, LUIS
	STARBUCKS
	STARBUCKS COFFEE

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 2014

50	ABM JANITORIAL SERVICE
	ADVANTAGE
	ADVISO GROUP
	AJT REALTY GROUP
	ALAN M RUBIN
	ALCOA INCORPORATED
	ALERION
	ALL FOGEL ESQ
	ALTMAN LAW GROUP
	ARGUS INFOR & ADVISORY SVC
	ASF CAPITAL CORPORATION
	ASSOCIATES OF WESTPORT
	ATLANTIC BENEFITS GROUP
	ATLMAN LAW GROUP LLC
	BAISYS CONSULTING LLC
	BENEFICIAL NEW YORK INC
	BHARAT DIAMOND COMPANY
	BIFROST FUND LP
	BISESTO PATRICIA T ATTY
	BLOOMENTHAL & TROW
	BLSH INVESTMENT COUNSEL LLC
	BRAND BRAND NOMBERG & ROSENBAUM LL
	BRINTON JANUARY ATTYS
	BRINTON L ROBERT ATTY
	BROOKLINE TECHNOLOGIES INCORPORATED
	BUNGE
	BUNGE CORP
	CAPITAL CAFE
	CAPITAL MARKET CONSULTING GROUP
	CJS SECURITIES
	CLASSIC WESTCHESTER INCORPORATED
	CONCEPT CARE INCORPORATED
	COPY STOP
	COUNTRYWIDE HOME LOANS
	CUDDY LAW FIRM
	CUSHNER & GARVEY LLP
	CUSHNER TODD S ATTY
	CWK NETWORK INCORPORATED
	DAIO PAPER USA INCORPORATED
	DOUBLE BYTES
	EDWARD BERMAN ESQ
	ERSKINE DANIEL ESQ
	EXCELL PRINT & PROMOTIONS
	FEBBRAIO GREG LAW OFFICES OF
	FINE OLIN & ANDERMAN LLP
	FIRST DARTMOUTH REALTY
	FIRST GREAT WEST LIFE & ANNUITY
	FRANCIS D TERRELL ATTORNEY AT LAW
	FUTERFAS NEAL ATTY
	GARRISON PHILLIPS

50

GARVEY LAWRENCE A ATTY
GARVEY TIRELLI & CUSHNER
GARY GOLDBERG COMPANY INCORPORATED
GENERAL DYNAMICS
GOLDBERG & WEINBERGER
GORDON & SILBER PC
GRAFICA WORLDWIDE
GRAUER DAVID
GREENBERG TRAURIG LLC
HALCOLL CAPITAL MANAGEMENT
HALYARD ASSET MANAGEMENT LLC
HOSPITAL INSURANCE COMPANY
IMG WORLD
ITEC INCORPORATED
J & J REALTY
JANUARY DERICK C ATTY
JEWERLRY JUDGE
JLL & ASSOCIATES
JONES HIRSCH CONNORS & BULL
JORDAN ENTERPRISES GROUP
JOSEPH A KELLY ESQ
KANTERMAN & TAUB PC
KEENAN POWERS & ANDREWS
KEN TUCHMAN & ASSOCIATES
KEVIN MATZ & ASSOCIATES PLLC
KIPNES CROWLEY GROUP
KITSON & KITSON
KITSON KEVIN J ATTY
KOKKALENIOS GEORGE ESQ
KOTAK MAHINDRA INCORPORATED
KURZMAN KARELSON & FRANK
L R BLOCH LAW MITCHELL
LAW OFFICE OF BEVERLY ROGERS LLC
LAW OFFICE OF DANNA WOOD
LAW OFFICE OF HERBERT ADLER
LAW OFFICE OF JOHN SANDLEITNER
LAW OFFICE OF MARTIN B EPSTEIN
LAW OFFICE OF MARY RIZZO
LAW OFFICE OF MERLY E FISHBONE ATTOR
LAW OFFICE OF NEAL FUTERFAS
LAW OFFICE OF NORMAN ROSNER
LAWRENCE D DICKER PC
LEE GRUBER MD
LEGAL & MEDICAL TRANSCRIPTIONS
LENOX PARK LLC
LEXIAN CONSULTANTS
LISS MICHAEL ATTY
MACK CALI REALTY CORPORATION
MANPOWER
MARCUS SEVEN MILLICHAP

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 2014 (Cont'd)

50
MARK STEVENS & COMPANY
MARKETING BEYOND DESIGN
MARKSTON INTERNATIONL LLC
MARSH & MCLENNAN LLC
MARTONE CAPITAL MANAGEMENT
MBS ASSET MANAGEMENT
MBS FINANCIAL GROUP
MEDSOURCE
MERIDIAN VAT RECLAIM
MERYL FISHBONE
MESSING PHILIP J CPA
MICHAEL LISS ESQ
MIESEL, VICTOR
MILESTONE MANAGEMENT
MMR FOOD & DRINK RESEARCH WORLDWID
MORRIS JAMES ATTY
NATHANIEL SESE ESQ
NATIONAL ECONOMIC RESEARCH ASSOCIATE
NAVATEL
NB LISTINGS REFERRAL SERVICE LLC
NERA INCORPORATED
NETRADIOLOGY
NEUBARDT SAUNDRA ATTY
NJ ATM SERVICES
NORTHEAST REALTY GROUP
NORTHWESTERN MUTUA
NORTHWESTERN MUTUAL FINANCIAL NETWOR
NU ENERGEN
NUENERGEN
NY COMMERCIAL LENDING
PACIFIC LIFE INSURANCE COMPANY
PACIFIC PARTNERS
PARADISE ROAD
PAXTON RESOURCES
PENSIONS SERVICES OF WESTCHESTER
PHOENIX GLOBAL SUPPLY GROUP
PILGRIM ADVISORS
PINO & ASSOCIATES
PINO & ASSOCIATES LLC
PODELL SCHWARTZ & BANFIELD
PULLMAN & COMELY LLC
RABINOWITZ ILENE MD
RAKOW COMMERCIAL REALTY
REDAC
REDAC INCORPORATED
RIORDAN EUGENE ESQ
RONALD WEISSLER ESQ
ROYAL ADVISORIES SERVICES
ROYAL PRESS
SANDRA NUEBARDTS OFFICE

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 2014 (Cont'd)

50	SCB PARTNERS INCORPORATED
	SCHNAUFER JOHN C ATTY
	SESTI LAW FIRM PC
	SHIPMAN & GOODWIN
	SINGER NETTER DOWD & BERMAN PLLC
	SMART ENERGY CAPITAL LLC
	SOFTWARE BY DESIGN
	SPEISER & HEINZMAN
	SPERRY VAN NESS
	STARFUELS
	STEINBERG & CAVALIERE
	STEINBERG & CAVALIERE LLP
	STEVEN JON LEVINE ESQ
	STRATEGIC INTELLIGENCE
	THE HEIRSHIP SEARCH COMPANY
	THE INGBER LAW FIRM
	TOKYO ZAIRYO COMPANY LIMITED
	TWO BROTHERS LOCKSMITH
	V HB
	VITTORIA & FORSYTHE & PURDY LLP
	WELLS FARGO HOME MORTGAGE
	WESTCHESTER CAPITAL PLANNING
	WILLIAM V CALLY ESQ
	WOODLARK EQUITY GROUP LLC
	YAMOUTH VENTURE GROUP
	YESS PROPERTY MANAGEMENT
	ZUCKER LEO ATTY
52	SAETHER, T
55	MARTINEZ, ZOILA
59	WHITE PLAINS PLUMBING & HEATING
81	81 MAIN LLC
	AMINCO RESOURCES
	ARONWALD WILLIAM
	BEATON DANIEL ENGR
	BIONDI LAWRENCE
	BOYNTON SALLY J LLC
	BRICCETTI CALHOUN & LAWRENCE LLP
	CARL BLOOM ASSOCIATES
	CERBONE LAW
	COTRONEI P CHRISTOPHER ATTORNEY
	DAVID CHARNEY FOUNDATION
	EINHORN YAFFEE PRESCOTT
	FAMILY COURT
	FIEDLER DUANE M
	FIELDS & ROSEN LWYRS
	FIELDS STEPHEN ATTY
	GOLDBERG MARC STUART
	GOLDSMITH JESSICA G ESQ
	GUSRAE KATLAN NESBAUM
	HALLORAN & SAGE LLP

81

HAROLD SALANT STRASSFIELD & SPIELBER
HARRINGTON OCKO & MONK ATTYS
HEIDELL PITTONI MURPHY & BACH LLP
HOCHFELDER & ASSOCS
HOCHFELDER JOHN M ATTY
INTERFACET INCORPORATED
IPN COMMUNICATIONS
KAMLER LEWIS & NOREMAN LLP KLN
KEEGAN KEEGAN & STRUTT
KEEGAN KEEGAN KEEGAN & STRUTT LLP AT
KINGDOM RIDGE CAPITAL LLC
KINGDOM RIDGE CAPTIAL
LANDAU NASELLA & KLATSKY LLC
LANDRIGAN PHILLIP C ATTY
LAUTERBACH GARFINKEL DAMAST & HOLLAN
LAW OFFICES OF MICHELL I WEINGARDEN
LAW OFFICES OF STEPHEN HABER THE
LAW OFFICES OF TIMOTHY A GREEN
LEASON ELLIS LLP
LEON REIMER & CO PC
LEWIS GARY F CPA
LNK PARTNERS LLC
LOMBARDI MICHAEL J ESQ
MENKENWE INGARDEN
MP STUART GOLDBERG LLC
NEWMARK & CO REAL ESTATE
ODESSER EDWARD H LLC
ODESSER SCHILLINGER & FINSTERWALD LL
PAM LEWIS
PANNONE LOPES & DEVEREAUX
PANNONE LOPES DEVEREAUX & WEST
PARSONT ALFRED ATTY
PETER ELLIOT LLC
PORTFOLIO STRATEGY GROUP INCORPORATE
PYKETT DANIEL J ATTY
ROACH THOMAS M ATTY
ROBERT E MARTINEZ PLLC
ROBERT FITZGERALD PC
ROSE WILLIAM A ARCHT
ROSEN HAROLD ATTY
ROSS STANLEY A CPA
ROTBARD & FILASTRO
ROTBARD ERIC J ATTY
SEEGER & SEEGER
SILVERMAN JOAN S ATTORNEY AT LAW
SKY WILBER FOUNDATION
STEINMETZ DAVID ATTY
STONEBRIDGE PARTNERS INCORPORATED
WEININGER WILLIAM ATTORNEY
WILLIAM WEININGER ATTYS

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 2014 (Cont'd)

81	YOUNG & BARTLETT LLP
	ZARIN & STEINMETZ ATTYS
	ZARIN MICHAEL ATTY
100	A & J RELIABLE
	A DOLLAR
	ABLE BUILDING MAINTENANCE
	AEROPOSTALE
	ALDO SHOES
	AMERICAN EAGLE OUTFITTERS
	ART OF THREADING INCORPORATED
	AS SEEN ON TV
	AT&T
	AT&T MOBILITY
	AUNTIE ANNES
	BATH & BODY WORKS
	BEAUTY OF ART
	BOURBON STREET CAFE
	C & C MARKET RESEARCH
	CHARLEYS FAMOUS INCORPORATED
	CHARLOTTE RUSSE
	CHIC BOUTIQUE
	CINNABONCARVEL
	CLAIRES
	COHENS FASHION OPTICAL
	COMMERICA LOCK & KEY SERVICE
	CUSTOM T S INCORPORATED
	DEB SHOPS
	DEB SHOPS INCORPORATED
	DIAMOND ISLE
	DNS PERFUME INCORPORATED
	DUNKIN DONUTS
	EASTERN ARTS
	ELEGANT PERFUME INCORPORATED
	EXPRESS INCORPORATED
	FAMOUS FOOTWEAR
	FINISH LINE
	FOOT LOCKER
	FOOTACTION USA
	FOREVER 21
	FULLY LOADED
	GALLERIA MALL AT WHITE PLAINS
	GALLERIA MALL DENTAL PFC
	GAMESTOP CORPORATION 1956
	GARAGE CLOTHING
	GIFTS FOUR US INCORPORATED
	H&M
	HOT TOPIC
	ICING BY CLAIRES
	ILS WAYPORT
	INTRIGUE JEWELERS

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 2014 (Cont'd)

100
J T MAGEN
JEWEL HUT
JIMMY JAZZ
JOURNEYS
KFC TACO BELL
KFC TACO BELL WHITE PLAINS
KIDS FOOT LOCKER
LENSCRAFTERS
LIDS
LOUNGE RETAIL GROUP INCORPORATED
MAC MACYS WHITE PLAINS
MACYS WHITE PLAINS GALLERIA
MCDONALDS
MICHAEL MATTHEWS JEWELRY
MOTHERHOOD MATERNITY
MWWP LLC
MY KITCHEN
NAILPORT SPA SALON
NAILS & MORE BY DAWN
NAME ON THE BUCKLE
NATHANS FAMOUS
NEW DEAL LLC
NEW FASHION & MORE
OLD NAVY
ORIENTAL EXPRESS
PACSUN
PAYLESS SHOESOURCE NUMBER 2395
PRINTS PLUS
PROFESSIONAL ORTHOPEDIC & SPORTS PHY
PS FROM AEROPOSTALE
RADIOSHACK
RAINBOW
RAINBOW SHOPS LADIES APPRL
RAINBOW TOO TOYS
RAMEE SUIT WAREHOUSE
SAL S PERFUMES
SARKU JAPAN
SEARS
SEARS HAIR SALON
SHAPEUP
SIMON PROPERTIES
SIMPLE GREEN NY INCORPORATED DBA GRE
SOCIAL NY
SOCK DRAWER
STRIDE RITE
SUBWAY SANDWICHES
TATES MENSWEAR
THATS HOT
THE CHILDRENS PLACE
THE GALLERIA AT WHITE PLAINS

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 2014 (Cont'd)

100	THE HAIR DESIGNERS
	THE NEWS CORNER
	THE SALON AT 100 MAIN
	THE THREADING
	THE WATCH STOP
	TMOBILE
	TMOBILE WHITE PLAINS
	TOTAL QUALITY COMMUNICATIONS II LLC
	TRAFFIC SHOE
	TROPICAL SMOOTHI
	UMBERTOS
	VICTORIAS SECRET
	VZW AT RADIO SHACK 1429 WHITE PLAIN
	WENDYS
	WHITE PLAINS GALLARIA PARTNERSHIP
	YANKEE CANDLE
	ZUMIEZ
110	FRANKS ONTIME PAINTING
111	A ELECTRIC INCORPORATED
	EXER FIX INCORPORATED
	HAYNES, SONIA
	LINGERIE JULIET
	MR CHIMNEY
	NICOLETTI FASHION DESIGN INCORPORATE
	NICOLETTI FASHIONS INCORPORATED
	PELLEGRINO & COMPANY LLP
	SCHWARTZAPFEL LAWYERS PC
119	SILVIA, SILVA
123	BONA THOMAS M ATTY
	BOROWICK FELDMAN & GRONER PC ATTY
	BRAUNSTEIN & ZUCKERMAN
	BRAUNSTEIN LAWRENCE JAY ATTY
	BROWN NEIL J & ASSOC
	CAFE 123
	CANTER GREENMAN ASSOCIATES
	CANTER LAW FIRM PC
	CANTER NELSON ESQ
	CMS BANK
	COMMUNITY MUTUAL SAVINGS BANK
	DANZIGER & MARKHOFF LLP
	DAYTON COREY & DUBEN INC
	EMPIRE STATE DEVELOPMENT
	FEDERAL BAR COUNCIL
	GORDON STEPHEN G ATTY
	HODOGAYA CHEMICAL COMPANY LIMITED
	KELLMAN NANCY D
	LEARY, JOSEPH G
	LOB GAYLE S CFP FINANCIAL STRATEGIES
	NALVEN & SCHROEDER INSURANCE AGENCY
	NEW YORK POWER AUTHORITY

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 2014 (Cont'd)

123	NOWICK DAHAN
	RAFFERT & REDLISKY
	RIDGEVIEW AUTOMOBILE BODY CORPORATIO
	SKCG GROUP INCORPORATED
	SKG SPECIALTY COVERAGES
	STATE OF NEW YORK
	STATE STREET CORP
	THE FRUSTUM GROUP INCORPORATED
	THE PARKER GROUP
	VICTORY LOCKSMITH
	WESTCHESTER PHILHARMONIC
127	QUINN, DONNA L
135	OCCUPANT UNKNOWN,
152	SERVICE, C
165	BLOOMING GLORY HOSPIT
169	AMERICAN EXPRESS
	AMERICAN EXPRESS ONE BUSINESS TRAVEL
171	VINTAGE BAR & RESTAURANT
175	A & A STAFFING HEALTH CARE SERVICES
	A R I
	ATTORNEYAT LAW ROXANNE BEECHER
	BARONI ROLAND A JR LWYR
	BARR ASSOCIATES INCORPORATED
	BARRISTER PROPERTIES LIMITED
	BAYBERRY PROPERTY MANAGEMENT & LEASI
	BLOOMER THOMAS M LAW OFC
	BONANNO PAT ATTY
	BROWN GERALD
	BUDERWITZ JOSEPH M
	CENTRAL TAXI SERVICE CORPORATION
	CLASSIC CLEANING & MAINTENANC
	COOPER MARVIN A ATTY
	COPYHUT THE
	COURTHOUSE BARBERS SHOP
	CRIBARI ARNOLD D ATTY
	DAILY NEWS
	DAMORE DELICAFE
	DELANEY THOMAS F
	DELNEGRO ARTHUR L JR ATTY
	DONOVAN DANL G ATTY
	DRS REALTY GROUP LLC
	ERIOLE LAW FIRM
	EVOLUTION MORTGAGE
	EXPRESS CONSTRUCTION
	FARRELL LYNN P
	FAYER ERIC M
	GELLER & RIVERA PC
	GEORGE WEINBAUM
	GREENSTEIN ALLAN ATTY
	GREENSTEIN SOL D ATTY

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 2014 (Cont'd)

175	HIGHLAND APPRAISALS INCORPORATED
	HYMAN M J CPA
	JOHNSON HAROLD J ATTY
	KAHN DAVID MILLER ATTY
	KAHN JAMES C ATTY
	KAHN KAHN & SCUTIERI ATTYS
	KAPLAN ELIOT L ATTY
	KILLERLANE JAMES J
	KMETZ STEVEN P ATTY
	KURTIS GLEN A
	LAPAGLIA JAMES W
	LAWOFFICES OF JOSEPH SCUTIERI
	LEWIS STEPHEN R ATTY
	LEWIS STEPHEN R LWYR
	LLF CONSTRUCTION SERVICES
	MAIN STREET GROCERY
	MANNION MARTIN P ASSOCIATES
	MCMAHON JOHN J ATTY SMALL C CAP M
	MONTGOMERY J DELANEY
	MURPHY MCPARTLAND & WALSH
	NORTH COURT BUILDING
	NORTH WP DOORS COMPANY
	PETER MARASCO AGENCY INCORPORATED
	POLICE FRESH AIR FUND
	PROMOTIONAL MAILING SERVICES
	Q & A REPORTING SERVICE
	RAPID PHOTO
	RINALDI EDWARD J ATTY
	ROBERT E GIUNTINI
	ROBERT HORNE LAW
	ROSEN MARTIN J PC ATTY
	SCUTIERI JOSEPH A ATTY
	SELBST GROUP INCORPORATED
	SMART DAILY ADMINSTARTORS
	SOFRITO
	SPLENDID TAXI CORPORATION
	STEADFAST FUNDING LLC
	STEPHENS BARONI REILLY & LEWIS LWYRS
	SUITE 401 MANAGEMENT COMPANY LIMITED
	THANKACHAN GHEEVARGHESE
	WALTER JAY HIRSCH & CO LLP
	WESTCHESTER USA TAXI
	WLJ PRINTERS
	YALKUT ARLEN S ATTY
185	KARAMBA CAFE
187	AJ EDIBLES INCORPORATED
189	KRISTOPHER GARAGE DOORS
	TEFFT BUSINESS SCHL
199	175 MEMORIAL HWY REALTY CORPORATION
	ARLENE GORDON OLIVER

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 2014 (Cont'd)

199	AROW LOCKSMITH & KEYS
	BERLIN PRODUCTIONS
	CHIROPRATIC REHABILITATION
	CLEAR BID
	CLEARVIEW COUNSELING GROUP
	GOLDMAN LISA S ATTORNEY AT LAW
	GOLDMAN, LISA
	GOULD RICHARD A
	GRECO ALFRED V
	KALISH DANIEL A
	KALISH DANIEL A ATTY
	KASS ENTERPRISES
	KELSEY COMPANYNY
	KOLAJ, PAUL
	KRONICK ARNOLD S ATTY
	LAW OFFICE OF THOMAS AGOG
	LEHRMAN KRONICK & LEHRMAN LLP
	LEHRMAN STEPHEN J
	LOMBARDO EUGENE J LCSW
	MICROCREDITOS DEL PACIFICO
	NORTH AVENUE MARINE REALTY CORPORATI
	PAUL GARGIULO
	PINKER BRUCE DR
	PINKER BRUCE STEVEN DPM
	PREMIER HOME HEALTH
	PROGRESSIVE FOOT CARE
	PROMOTIONAL MAILING
	RANELLONE, STEVEN
	REIGNS CAPITAL
	ROBINOWITZ COHLAN & DUBOW
	ROBINOWITZ COHLAN DUBOW & DOHERTY LL
	ROBINOWITZ, DUBOW
	RONAI & RONAI ATTYS
	SERAFINA WHITE PLAINS
	SKYLINE TITLE
	THOMAS SOPHY ATTY
	TOWBIN M R REALTY INCORPORATED
	WESTCHESTER FOOTCARE CENTER
	WESTCHESTER LAW JOURNAL
	WHITE PLAINS CHILD DAY CARE ASSOCIAT
	WILLIAM R WEINSTEIN ESQ
200	CARDENAS B AKERY
	DUTAN, LUIS
	STARBUCKS COFFEE
	THOMAS, ROBERTO

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 2010

41	BRESLIN & BRESLIN
45	OCCUPANT UNKNOWN,
50	A7 N CONSULTING
	ABM JANITORIAL SVC
	ACORN DERIVATIVES MANAGEMENT
	ADVANTAGE HUMAN RESOURCING
	ADVISO GROUP LTD
	AFFILIATED PROFESSIONAL SVC
	AJT REALTY GROUP
	ALCOA INC
	ALLSTATE INSURANCE CO
	ALTMAN LAW GROUP
	ARGUS INFOR & ADVISORY SVC
	ARM GROUP INC
	ASSOCIATES OF WESTPORT
	ATLANTIC BENEFITS GROUP
	ATLMAN LAW GROUP LLC
	BADER & BADER LLP
	BAISYS CONSULTING LLC
	BEVAN RESOURCES
	BEVERLY ROGERS LAW OFFICE LLC
	BHARAT DIAMOND CO
	BIFROST FUND LP
	BITTERMAN MAHATME LAW OFC PLLC
	BLOOMENTHAL & TROW
	BLSH INVESTMENT COUNSEL LLC
	BOSLEY
	BRAND BRAND NOMBERGROSENBAUM
	BRINTON & JANUARY
	BUNGE GLOBAL AGRIBUSINESS
	BUNGE LIMITED
	BUNGE LIMITED FINANCE CORPORAT
	CALLY WILLIAM
	CAPITAL CAFE
	CARDINAL RESOURCES INC
	CHRISTOPHER PARRINO LAW OFFICE
	CJS SECURITIES
	CLIVEDEN PIERRE
	COMMONWEALTH LAND TITLE INS CO
	COMPUTER OPTIONS INC
	CONCEPT CARE INC
	CONTINENTAL SECURITIES LLC
	COPY STORE
	CORPORATE TRADE SOLUTIONS INC
	COUNTRYWIDE HOME LOANS
	CWK NETWORK INC
	DAIO PAPER USA INC
	DANIEL MOSES
	DANNA WOOD LAW OFFICE
	DE VITO FELIX

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 2010 (Cont'd)

50

DISERIO MARTIN OCONNOR
DOUBLE BYTES
DREYFUS FOUNDATION
E G HOLDINGS CORP
ENERGY TRADE MANAGEMENT
ERSKINE DANIEL
ETTINGER LAW FIRM
EUGENE RIORDAN ATTORNEY
EXECUTIVE HEALTHSEARCH
EXEPLEX
FIELD JOEL
FIFTY MAIN STREET CORP
FINE OLIN & ANDERMAN LLP
FIRST CHOICE STAFFING INC
FIRST DARTMOUTH REALTY
FIRST GREATWEST LIFE & ANNTY
FOGEL AL
FUNDEX CAPITAL CORP
GARRISON PHILLIPS
GARY GOLDBERG & CO INC
GENERAL DYNAMICS
GID GLOBAL
GORDON & SILBER
GORDON & SILBER PC
GRAUER DAVID I
GREENBERG TRAURIG
GRUBER LEE S MD
H & H METALS
HALCOLL CAPITAL MANAGEMENT
HALO ONE PROPERTIES LLC
HANK ART INC
HANYS INSURANCE CO
HEALTHCARE HR CONSULTING LLC
HEINEKEN USA
HERBERT ADLER LAW OFFICE
HOLOCOM NETWORKS
HOSPITAL INSURANCE CO
HRH CONSTRUCTION
HRHLLC
HUDSON VALLEY INVESTMENT CORP
I T MANAGEMENT PARTNERS
INGBER LAW FIRM
INSITE SEARCH
INTERTEX TRADING CORP
JACKNESS GROUP
JLL ASSOCIATE
JOEL BIEBER CONSULTING LTD
JOHN SANDLEITNER LAW OFFICE
JORDAN ENTERPRISES GROUP
JOSEPH A KELLY ESQ

50

KANTERMAN & TAUB
KANTERMAN OLEARY & SOSCIA
KEN TUCHMAN & ASSOC
KITSON & KITSON
KOKKALENIOS GEORGE
KOTAK MAHINDRA INC
KURZMAN KARELSON & FRANK
LEO ZUCKER LAW OFFICE
LEVINE & ZELMAN
LEXIEN CONSULTANTS
LINDA WOLFSON STAFFING
LISS MICHAEL
MACKCALI REALTY CORP
MAGIC SLIDERS LP
MALEY PHILIP M
MANPOWER
MARKSTON INTERNATIONAL LLC
MARSH & FASTENBURG LLP
MARTIN B EPSTEIN LAW OFFICE
MARTONE CAPITAL MANAGEMENT
MARY RIZZO LAW OFFICE
MBS ASSET MANAGEMENT GROUP
MED SOURCE
MEDICAL HAIR RESTORATION
MEGGITT AIRCRAFT BRAKING SYSTS
MERIDIAN VAT RECLAIM
MESSING PHILIP J CPA
MIGNON FINANCIAL SVC
MILESTONE MANAGEMENT GROUP
MMR FOOD & DRINK RESEARCH
MONROE J KORN LAW OFFICE
MORISON ANSA HOLDEN ASSUNCAO
MORRIS JAMES S
N Y COMMERCIAL LENDING
NATIONAL ECONOMIC RESEARCH
NEAL FUTERFAS LAW OFFICE
NETRADIOLOGY
NETWORK & SOFTWARE SOLUTIONS
NEUBARDT SAUNDRA
NEW ENGLAND FINANCIAL
NORTHEAST REALTY GROUP LLC
NORTHWESTERN MUTUAL FINANCIAL
OLSEN, MICHAEL L
PACIFIC PARTNERS LLC
PARADISE ROAD
PATRICIA SULLIVAN LAW OFFICE
PAXTON RESOURCES
PENSIONS SERVICESWESTCHESTER
PETER NARDONE LAW OFFICE
PILGRIMS ADVISORS

50	PINO & ASSOC
	PODELL SCHWARTZ & BANFIELD
	PRECISION RIBBON TECHNOLOGY
	PREFERRED PENSION CONCEPTS INC
	PUBLISHING SOULTIONS
	PULLMAN & COMLEY LLC
	RAKOW COMMERCIAL REALTY GROUP
	REGUSHQ BUSINESS CTR
	RICHARD RAKOW COML RL EST
	ROBERT ODONNELL LAW OFFICE
	ROK PROMOTIONS
	RONALD KERN & ASSOC
	ROSENBLUM & TANNENBAUM
	ROYAL PRESS
	RPO GROUP INC
	RUBIN ALAN M
	SANDRA NUEBARDTS OFFICE
	SCB PARTNERS INC
	SCOTT FENSTERMAKER LAW OFFICES
	SERAFINN PAT
	SERENITY SERVICES
	SHIPMAN & GOODWIN
	SIGNA
	SLEEP DISORDERS CTRCOLUMBIA
	SOFTWARE BY DESIGN
	SOLD WORLDWIDE
	SPERRY VAN NESS
	SPIRIAN TECHNOLOGY
	STANLEY MESSINGER LAW OFFICES
	STARRETT CORP
	STEINBERG & CAVALIERE
	STORAGE DELUXE
	STRATEGIC INTELLIGENCE
	SUNBELT BUSINESS BROKERS
	TACONIC MORTGAGE CO INC
	TAX & TREASURY SOLUTIONS
	THOMAS F FARLEY PC
	TOKYO ZAIRYO CO LTD
	VISCERAL MEDIA LLC
	VITTORIA & PURDY
	WALLACE & ASSOC PC
	WELLS FARGO FINANCIAL
	WESTCHESTER PROPERTY TAX
	WOODLARK EQUITY GROUP LLC
	YAMOUTH VENTURE GROUP
	YESS PROPERTY MANAGEMENT
52	SAETHER, T
55	MARTINEZ, ZOILA
61	GONZALEZ, EDWIN
76	URRUTIA, ELIAS

80 PORCEL, CELESTE
81 ABRAMS DONNA E
AMINCO RESOURCES
ANDREW G MALONEY & ASSOC
ARONWALD & PYKETT
BARTLETT MC DONOUGH BASTONE
BPP MANAGEMENT LLC
BRICCETTI CALHOUN & LAWRENCE
CARL BLOOM ASSOC
CARTELLI JAMES A
CONTRONEI CHRISTOPHER
COTRONEI P CHRIS
DAVIN MENKEN LAW OFFICE
DUANE M FIEDLER LAW OFFICE
E BABY
EDWARD H ODESSER LLC
ELLIS LEASON LLP
FIEDLER NORMAN D
FIELDS & ASSOC
GOLDFARB & ABRANDT
GOLDSMITH & SOLOFF LLP
HAROLD SALANT STRASSFIELD
HARRINGTON & OCKO
HARRINGTON OCKO & MONK
HEIDELL PITTONI MURPHY & BACH
HP CRITICAL FACILITIES SVC
INTERFACET INC
JOAN S SILVERMAN ATTY AT LAW
JOHN M HOCHFELDER LAW OFFICE
KAMLER LEWIS & NOREMAN
KEEGAN KEEGAN & STRUTT
KEEGAN KEEGAN KEEGAN & STRUTT
KURTZ SANDRA KOSS
LAWRENCE P BIONDI LAW OFFICES
LEE DAVID AUERBACH PC
LEON REIMER & CO PC
LNK PARTNERS LLC
LOMBARDI MICHAEL J
M P STUART GOLDBERG LLC
MARSH & WEINGARDEN PLLC
MARSH LAW FIRM
MENKEN LAW OFFICE PLLC
MESSINA & ASSOC
MICHAEL A RUBIN ATTORNEY
NEWMARK KNIGHT FRANK
ODESSER SCHILLINGER
PORTFOLIO STRATEGY GROUP INC
RENZULLI LAW FIRM LLP
ROACH THOMAS M
ROACH, THOMAS

81 ROBERT E MARTINEZ PLLC
ROSS STANLEY A CPA
ROTBARD & FILASTRO
ROTBARD ERIC J
SALLY J BOYNTON LLC
SEEGER & SEEGER
SILVERMAN & BIKKAL LLP
STONEBRIDGE PARTNERS
TIMOTHY A GREEN LAW OFFICES
WEINIGER WILLIAM
YOUNG & BARTLETT LLP
ZARIN & STEINMETZ

100 A & J RELIABLE
A DOLLAR
AEROPOSTALE
AFRICAN ARTS & CRAFTS
AGAINST ALL ODDS
ALDO
AMERICAN CONNECTIONS LLC
ARJAY TELECOM INC
AS SEEN ON TV
AT&T STORE
AUNTIE ANNES PRETZELS
AUNTIE, A P
BABYFACE STUDIO
BAKERS
BASKINROBBINS
BATH & BODY WORKS
BELLEZA SALON & SHOP
BENCHMARK GOLD
BLOCK, H
BOURBON STREET CAFE
CELNET COMMUNICATIONS
CHARLEYS GRILLED SUBS
CHARLOTTE RUSSE
CHILDRENS PLACE
CINNABON
CLAIRES
COHENS FASHION OPTICAL
DE LANCEY LEATHER
DIAMONDS HALLMARK
DOCTORS OF OPTOMETRY
DUNKIN DONUTS
EASY SPIRIT
ELEGANT PERFUME INC
EPIC
EVAN DESIGNS
FOOT LOCKER
FOOTACTION USA
FOREVER 21

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 2010 (Cont'd)

100
FRIEDMAN MARKETING SVC
FULLY LOADED
GALLERIA ART EXPO INC
GALLERIA MALL DENTAL
GALLERIA MALL DENTAL PC
GATSBY AT THE GALLERIA
GIFTS R US
GNC
H&M
H&R BLOCK
HAIR DESIGNERS
HAIR STYLISTS INC
HICKORY FARMS
HOT TOPIC
ICING BY CLAIRES
INTRIGUE JEWELERS
JEANS EXPRESS WHITE PLAINS
JEWEL HUT
JEWEL, HUT
JOURNEYS
KELLYS FURNITURE & BEDDING
LADY FOOT LOCKER
LANE BRYANT
LANE, BRYANT
LENSCRAFTERS
LEXINGTONGROVE GARAGE EAST
LUGGAGE N MORE
MACYS
MC DONALDS
MICHAEL MATTHEWS JEWELRY
MIRACLEEAR
MOBILETRON LLC
MODERN EDGE
MOTHERHOOD MATERNITY
MY KITCHEN
NAILPORT SPA SALON
NAILS & MORE BY DAWN
NAME ON THE BUCKLE
NEW YORK & CO
NEWS CORNER
NINE WEST OUTLET
OLD NAVY
OVERTHECOUNTER INC
PAC SUN
PAGING CONCEPTS
PARTY BASKET
PAYLESS SHOE SOURCE
PIERCING PAGODA
PILDES OPTICIANS
PRO ACTIV SKIN CARE

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 2010 (Cont'd)

100	RADIO SHACK
	RAINBOW SHOPS
	RICHS WHITE PAGE TEST
	SARKU JAPAN
	SBARRO
	SEARS
	SEARS AUTO CTR
	SIMSEK TOYS
	SOFTWARE ETC
	SPENCER GIFTS
	SPORTS HEAVEN LLC
	SUBWAY
	TATES MENSWEAR
	TEES YOU
	THATS HOT
	THINGS REMEMBERED
	THREADING STATION
	TORRID
	TRADE SECRET
	UBI ACCESSORIES
	UMBERTOS PIZZERIA
	UNDERGROUND STATION
	VALENTI PERFUMERY
	VALENTI, P
	VBI ACCESSORIES
	VICTORIAS SECRET
	VIDEO BUTTON
	WATCH STOP
	WENDYS
	WEST GARAGE
	YANKEE CANDLE CO
	YUM YUM CHICKEN
110	FRANKS ONTIME PAINTING
111	A DIRECT DISH SATELLITE TV
	ADT AUTHORIZED SALES
	INDEPENDENT VENTURE COMM INC
	RICHARD N WOOL LAW OFFICES
117	SHAH, DARSHAN
119	SILVIA, SILVA
123	BERMAN BAVERO FRUCCO & GOUZ
	BIRNBAUM, LINDA D
	BOROWICK, FELDMAN
	BRAUNSTEIN & ZUCKERMAN
	BUXTON, GREGG
	CAFE 120
	CANTER GREENMAN ASSOC LTD
	CANTER LAW FIRM PC
	CFP FINANCIAL STRATEGIES
	CMS BANCORP INC
	COMMUNITY MUTUAL SAVINGS BANK

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 2010 (Cont'd)

123	DANZIGER & MARKHOFF
	FEDERAL BAR COUNCIL
	FIORITO, HELENE
	FMG TECHNOLOGIES
	GORDON STEPHEN G
	GRANONE, VERONICA D
	HELLER, BRENDA L
	HODOGAYA CHEMICAL USA INC
	KELLMAN NANCY D
	KELLMAN, NANCY D
	LPL FINANCIAL SVC
	MISYS INTERNATIONAL BANKING
	NALVEN & SCHROEDER INSURANCE
	NEIL J BROWN & ASSOC
	NEW YORK POWER AUTHORITY
	NIPPOLY AMERICA CORP
	PARKER GROUP INC
	POWER AUTHORITY
	SKCG GROUP INC
	STATE STREET CORP
	STERNBERG KOZERA & CLEICHER
	THOMAS M BONA LAW OFFICE
	THOMAS M BONA PC
	WESTCHESTER PHILHARMONIC
125	OCCUPANT UNKNOWN,
152	SERVICE, C
161	JOHNSON, SCOTT A
169	ALPHA GRAPHICS
	AMERICAN EXPRESS
	MILNE TRAVEL AMERICAN EXPRESS
171	VINTAGE BAR & RESTAURANT
173	HANNOUSH JEWELERS
175	A & A STAFFING HEALTH CARE SVC
	ANDRIOLA ROBIN
	ARI
	BARR ASSOCIATES INC
	BARRISTER PROPERTIES LTD
	BEECHER ROXANNE
	BENEFICIAL NATIONAL LIFE INS
	BLISS EXTERMINATOR CO
	BONA THOMAS M
	BRENDA LEE INC
	BROOKS JILL
	BROWN GERALD
	BUDERWITZ JOSEPH M
	BUSMAN KENNETH
	CENTRAL TAXI SVC CORP
	CLASSIC CLEANING & MAINTENANCE
	COPY HUT
	CORWIN LEONARD S

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 2010 (Cont'd)

175 COURTHOUSE BARBERS SHOP
CRIBARI ARNOLD D
DAMORE DELI CAFE
DAVID L RICH ATTORNEY AT LAW
DEL NEGRO JR ARTHUR L
DRS REALTY GROUP LLC
E ROBERT GIUNTINI PC
EXPRESS CONSTRUCTION CO
FIELDS JULES M
GELLER & RIVERA PC
GLEN A CURTIS PC
GREENSTEIN ALLEN
GREENSTEIN SOL D
HERZFELD ROBERT
HIGHLAND APPRAISALS INC
HORNE ROBERT
IAN D ORR LAW OFFICE
JOHNSON HAROLD J
KAHN JAMES C
KAPLAN ELIOT L
KHAN JAMES C
KILLERLANE JAMES J
KMETZ STEVEN P
LANGUS SANDRA
LEONARD S CORWIN LAW OFFICES
LEWIS PAMELA
LEXUS TITLE INSURANCE LTD
LLF CONSTRUCTION SVC
MARTIN J ROSEN PC
MC MAHON JOHN J
MEAGHER & MEAGHER
MILLER & PLATT
MURPHY MC PARTLAND & WALSH
NORTHCOURT BUILDING
PENICHE TAPAS
PETER MARASCO AGENCY INC
POLICE FRESH AIR FUND
PROMOTIONAL MAILING SVC
Q & A REPORTING SVC
RICE JONATHAN
RINALDI & SMALEC
SIMON CAROL T
SORIANO NICHOLAS M
SOUND SHORE AMBULETTE CORP
STEPHENS BARONI REILLY & LEWIS
STEVENS BARONI REILLY & LEWIS
SUIT 401 MANAGEMENT CO LTD
THOMAS F DELANEY INC
THOMAS M BLOOMER LAW OFFICE
TRACKER PRO

175	WALTER JAY HIRSCH & CO
	WEINBAUM GEORGE
	WESTCHESTER CHILDRENS ASSN
	WESTCHESTER LAW JOURNAL
	WESTCHESTER TAXI CORP
	YALKUT & ISRAEL
	ZERN MARTIN H
185	KARAMBA CAFE
187	BEYOND THE BAGEL
189	CENTER FOR DRIVINGWESTCHESTER
	MAIL BOXES ETC
	MEWS MANAGEMENT ASSOC
199	175 MEMORIAL HWY REALTY CORP
	BBI SYSTEMS
	BLUESTONE REALTY ADVISORS INC
	CENTRAL VOICE OF NEW YORK
	CLEARVIEW COUNSELING GROUP LLP
	DANIEL A KALISH LAW OFFICE
	DAVID S KLAUSNER LAW OFFICE
	FAMIGLIADE BARTOLO LLC
	FIECH PIACENTE & STANO
	FIECH, STANO
	GLM CAPITAL CORP
	GLUCK, GEORGE
	GOLDMAN LISA S
	GOLDMAN, LISA
	GOULD RICHARD A
	GOULD, RICHARD A
	GRASSROOTS TECHNOLOGY ASSOC
	GRECO ALFRED V
	GRECO, ALFRED
	HERITAGE REALTY ADVISORS LLC
	HOROWITZ LAWRENCE S
	ICJ CONSULTANTS
	J J SEDELMAIER PRODUCTIONS INC
	KAPLAN MRD INC
	KOLAJ, PAUL
	LEHRMAN KRONICK & LEHRMAN LLP
	LIBERTY TITLE AGENCY
	LOUIS JAMES G
	LURIA DIGITAL PRODUCTIONS LLC
	M R TOWBIN REALTY INC
	MEGLINO, GARY L
	NORTH AVENUE REALTY INC
	PANASCHE, PRIVEE
	PHILLIPS, STEVEN
	PHYSICIANS BILLING SVC INC
	PINKER BRUCE S DPM
	PINKER, BRUCE
	PREMIER HOME HEALTH

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 2010 (Cont'd)

199	PROGRESSIVE FOOT CARE
	RABINOWITZ, SEYMOUR
	RANELLONE, STEVEN
	RAYS COPY SVC LLC
	ROBINOWITZ COHLAN & DUBOW
	RONAI & RONAI
	SAVILLE, DAVID A
	STEPHEN J LEHRMAN & ASSOC INC
	THOMAS SOPHY
	TOTAL COMMUNICATIONS
	VIA, Q
	WESTCHESTER FOOTCARE CTR
	WHITE PLAINS CHILD DAY CARE
	WILMAR
200	STARBUCKS
	THOMAS, ROBERTO

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 2005

43	PERRY, PATRICIA
50	78 LAFAYETTE AVE MGMT LLC
	9278 MOBILE
	ACORN DERIVATIVES MANAGEMENT CORP
	ADLER HERBERT ESQ
	ADVANTAGE HUMAN RESURFACING
	ADVANTEDGE TELEVISION ADVG
	ADVISO GROUP LTD
	ALLIANCE MARKETING GROUP
	ALTMAN LAW GROUP LLC
	AMALGAMET INC
	AMERICAN GENERAL CORP
	ATLANTIC BENEFITS CO INCNC
	BARR & HAAS LLP
	BENEFICIAL NEW YORK INC
	BERK & CO PUB RELATIONS INC
	BEVAN RESOURCES
	BHARAT DIAMOND CORP
	BISCOTTI & CO
	BISCOTTI & CO INC
	BISHOP SCOTT ATTORNEY AT LAW
	BOSLEY
	BRAIN MORRISSEY CONTRACTING LLC
	BRIDGE FUNDING INC
	BROOKLINE TECHNOLOGIES INC
	BUNGE GLOBAL MARKETS
	BUNGE LTD DE
	BUNGE MANAGEMENT SERVICES INC
	CAPITAL CAFE
	CARIBINER INTERNATIONAL
	CATHY BEVAN CPC
	CENTRAL GLASS INTERNATIONAL INC
	CHARLES & SCHWAB & CO INC
	CHARLES V BORSETTI
	CJS SECURITIES INC
	CLIVEDEN & PIERRE LTD
	COMMONWEALTH LAND TITLE INSURANCE CO
	COMMUNITY MUTAUL SAVINGS BANK
	CONCEPT CARE INC
	CORLETO AND ASSOCIATES PC
	CORONADO OIL & GAS INC
	CORPORATE TRADE SOLUTIONS INC
	CRIS EDWARD JOHNSON
	CRUISE EXPERTS & TOURS INTERNATIONAL
	EFFTING, HELIO J
	ENCORE CREDIT CORP
	F & J DESIGN LLC
	FHC OF NEW YORK INC
	FIRST UNION MORTGAGE
	FOOD LTDCOM

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 2005 (Cont'd)

50
FREDRIC B KATZ ATTY AT
FRIEDMAN & FERGUSON
GORDON & SILBER PC
GRAFICA WORLDWIDE INC
GREAT WEST LIFE
HEINEKEN USA INC
HEINEKIN
HELM ENTERPRISES INC
HOLDINGS LLC
HRH CONSTRUCTION LLC
I NET PUBLISHING SOLUTIONS LLC
IKON OFFICE SOLUTIONS
INDIMET INC
INFORMATION LINKS INC
ITEC INC
JEMS NOBLE CORP
JOEL BIEBER ASSOCIATES INC
KANTERMAN & TAUB PC
KEITH JOHNSON F
KENT HAZZARD JAEGER WILSON
KIESELSTEIN & LEE LLP
KITSON KITSON AND BISESTO
KLK REALTY LLC
LAW OFFICE OF MATTHEW J NOLFO
LAW OFFICES OF JAMES S MORRIS
LEE S GRUBER MD
LIFE SUPPORT INC
LINDA WOLFSON STAFFING
MAGIC SLIDERS LP
MAIN STREET MARKETING LP
MARKSTON INTERNATIONAL LLC
MILESTONE MANAGEMENT GROUP INC
MMR FOOD & DRINK RESEARCH
MONSTER MOVING
MONSTER WORLDWIDE INC
MORRIS JAMES LAW OFFICE
MORRIS, JAMES
MOVING CO
MY IDENTITY LLC
NATIONAL ECONOMIC RESEARCH ASSOCS
NERA
NS RESOURCES INC
OSCAR DYSTEL & PARTNERS INC
PAXTON RESOURCES INC
PHILIP J MESSING CPA
PINO & ASSOCIATES LLP
PODELL SCHWARTZ SCHECHTER
PREUSSAG NORTH AMERICA INC
PRUDENTIAL
RAKOW COMMERCIAL REALTY GROUP

50	REALTY LLC
	REDSTONE AFFILIATES INC
	RUTHERFORD ASSET MANAGEMENT LLC
	SCTY FOR THE SNCTTY OF LIFE CO
	SOLD WORLDWIDE LLC
	SPERRY VAN NESS
	SPOSATO, EILEEN M
	STEINBERG & CAVALIERE LLP
	STONEBRIDGE PARTNERS
	STUKES ATWOOD LLC
	TACONIC MORTGAGE CO INC
	TDC CARRIER SERVICES USA INC
	TELE DANMARK USA INC
	THACHER PROFFIT & WOOD
	THE MEDCENTER AT CLOVER LAKE III LLC
	TITLE AMERICA ABSTRACT CORP
	TKG COMMUNICATION INC
	TOKYO ZAIRYO CO LTD
	TPG SPORTS INC
	TUCHMAN KEN & ASSOCIATES LLC
	UNIVERSITY ANGEL INC
	VANTAS OFFICING SOLUTIONS WORLDWIDE
	VARIABLE ANNUITY LIFE INSURANCE
	VENUE SERVICES INC
	WATER SAFE SOLUTIONS INC
	WELLS FARGO FINANCIAL
	WESTCHESTER CAPITAL PLANNING
	WFC INC
	WHITE PLAINS
58	FINKELSTEIN, ROBERT
79	PRUDENTIAL SOLE
81	ABLE DIGERATIS LTD
	AMERICAN BENEFIT RESOURCES INC
	AMINCO RESOURCES INC
	ARGUS INFO & ADVISORY SERVICES LLC
	ARON WALD & PIKETT
	BOSTAN LLC
	BOYTON & WATER LLP
	BRUCCETTI CALHOUM AND LAWRENCE LLP
	CGJ CONSULTING GROUP INC
	CREATIVE TECHNOLOGIES GROUP
	DIAMONDBACK ENTERTAINMENT LLC
	DINS RESTAURANT INC
	DORFMAN JEROLD
	E Y P MISSION CRITICAL FACILTY INC
	FREEDOM NY INC
	GASH GARY
	GOLDFARB & ABRANDT
	GOLDFARB ABRANDT SALZMAN
	GRACE ASSOCIATES III LLC

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 2005 (Cont'd)

81 HAN BENEFIT ADVANTAGE INC
HARALD SALANT STRASSFIELD & SPIELBER
HARMONAY MARKETING INC
HGH ASSOCS LLC
HISTORY HELPER INC
HOCHFELDER & ASSOCIATES
HOME SOLUTIONS OF WESTCHESTER LLC
INTERFACET INC
INVESTMENT & BENEFIT SERVICE INC
JAMES DIBBINE ATTORNEY AT LAW
JEFFREY SALANT
JERAN REALTY LLC
JOSEPH KOSOFSKY
KEEGAN KEEGAN & STRUTT LLP
KEEGAN LAW FIRM OF ATTORNEYS
LEON REIMER & CO
LITTMAN KROOKS LLP
LOMBARDI MICHAEL J ESQ
MARC STUART GOLDBERG & ASSOCS
MCCOY JR H Y ESQ
MCGOWAN & COUSINS PC
MESSINA AND ASSOCS PC
MICHAEL ZARIN & DAVID STE
MILLENNIUM REALTY ADVENTURES LLC
NEWMARK AND CO REAL ESTATE INC
PETER ELLIOT LLC
PRIMA LUCI
PRINCIPAL
REALTY LLC
SALLY J BOYNTON LLC
SANDRA K KURTZ
SCHILLINGER & FINSTERWALD LLP
SEEGER & SEEGER
STANLEY A ROSS
STATE ASSETS LLC
STECCHINO INC
SUMMIT INTERIORS INC
TAC6 GROUP LLC
TEMPTATIONS ENTERTAINMENT LLC
THE PORTFOLIO STRTGY GROUP INC
TRAUMATIC INJURY EDUCATION FDN INC
YOUNG AND BARTLETT LLP
ZARIN & STEINMETZ
ZUCKER & KWESTEL

100 AMYS HALLMARK
BRADY, LILLIAN R
CHARADE FASHIONS LTD
FOREVER 21
JEANS OF WHITE PLAINS INC
LACHMANN, DORA

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 2005 (Cont'd)

100	LADY FOOT LOCKER
	LANE, BRYANT
	MODERN EDGE AT GALLERIA
	MUSICLAND GROUP
	ORIENTAL FURNITURE
	RADIOSHACK CORP
	THE HAIR STYLIST INC
	THE HOT CORNER
	WALDEN BOOK
111	THE ICING ACCESSORIES
120	CAFE
123	ADVANCED CAREER TECHNOLOGY
	BANK OF NEW YORK
	BEACON ASSOCIATES LLC
	BIRNBAUM, LINDA D
	BNY INFORMATION SERVICES INC
	BONA, THOMAS
	BRAUNSTEIN & ZUCKERMAN
	BRAUNSTEIN, LAWRENCE J
	CANTER LAW FIRM P C
	CANTER LAW FIRM PC
	CENTROPLEX CAFE 123
	DANCER & MARKHAFF
	EISENBERG, LAWRENCE J
	FECKE, HELEN R
	FORMES, FRANK J
	FRUCCO JOHN
	GELFAND, BERTRAM
	GOLDBERGH & SPITZER
	GREENWICH TECHNOLOGY PARTNERS
	HODOGAYA CHEMICAL USA INC
	HONGACH, LINDA M
	INTEGRATED DATA CONSULTING SERVICES
	JANPRES HOLDINGS INC
	JOHN P FREUKO INC
	JOHN, W M
	KELLMAN, NANCY D
	KEMSTAR CORP
	MANCO, LINDA M
	MANHATTAN PROSTHODONTIC ASSOCS PLLC
	NATIONAL PENSION SERVICE INC
	NEW YORK POWER AUTHORITY
	NIPPOLY
	OBARA, TOSHIO
	PARKER GROUP INC
	RONNIE A GOUZ
	STATE NEW YORK DEPARTMENT F
	STERNBERG KOZERA GLEICHER INC
	STERNBERG, KOZERA
	THE WESTCHESTER PHILHARMONIC

123	THOMPSON, RICHARD C
	VOLPE, DOCTOR C
	WILSON, RICHARD B
	WINGING GROUP LLC
134	KELLMAN NANCY D LAW OFFICE
155	GRANITE, T
	MUSICAL ASSOCIATES INC
162	PICKWICK ICE CREAM CO
169	AMERICAN EXPRESS
	NETWORK MGMT SOLUTIONS CORP
171	VINTAGE
173	MAIN WIRELESS AND JEWELRY INC
175	990 ARNOW AVE CORP
	A AND A STAFFING TEMPORARY HEALTH CA
	ABRATOURS INC
	ALL METRO HEALTH CARE
	ALLAN GREENSTEIN ESQ
	ANA STAFFING INC
	ANEW ENTERPRISE REALTY CORP
	BARE FEET ARIES PRODUCT INC
	BARRISTER PROPERTIES LTD
	BUDERWITZ JOSEPH M
	C PENNACCHIA & BROTHER INC
	CENTRAL TAXI SERVICING CORP
	CHAPPAQUA CLOWN CO INC
	COOPER PREP COURSE
	COURTHOUSE BARBERS SHOP
	CRIBARI JR ARNOLD D LAW OFFICE
	DTC BOOKKEEPING SERVICES
	ELIOT L KAPLAN
	GELLER & RIVERA PC
	GLEN A KUTIS PC
	HILL GROUP LLC
	HOLDINGS LLC
	JDV PLUMBING & HEATING INC
	KAHN KAHN & SCUTIERI
	KNUCKLES & KOMOSINSKI PC
	LEE MAGNUS ESQ
	LISS EXTERMINATOR CO
	MADAN & CO
	MOHEGAN 1031 LLC
	MURPHY MCPARTLAND & WALSH
	NORTHCOURT BUILDING
	PARCHMENT INTL REST & CATERING INC
	PICKER REPORTING SERVICE
	POLICE FRESH AIR FUND OF WEST
	PROMOTIONAL MAILING SVCES
	Q & A REPORTING SERVICE
	RAPID PHOTO
	REAL ESTATE IMPROVEMENT CONTRACTORS

175	REILLY AND LEWIS
	RICHARD THOMPSON ESQ
	RINALDI & SMALEC
	SANDY CAT HOLDING CORP
	SELBST GROUP INC
	SELF SERVICE INC
	SHREE GROUP LLC
	SOFTWARE LINK INC
	SORIANO NICHOLAS M
	SPLENDED CORP
	SPLENDID TAXI CORP
	SQUIRE DAY CAMP
	STAUB BERNARD
	STONESHORE CORP
	THE CENTER FOR BEAUTYFULL SKIN INC
	THE CTR FOR BEAUTYFULL SKIN INC
	THE DOCEO GROUP
	THOMAS M BONA
	THOMPSONRICHARDC
	TRACI L COLLINS Q & A REPORTING
	TRAINING DYNAMICS
	TROTTERS TAVERN
	U S A TAXI CORP
	WESTCHESTER DIVERSIFIED REALTY
	WESTCHESTER LAW JOURNAL
	WILLIAM H COPPER ATTORNEY AT LAW PC
183	INNOVATIONS BY OMIGEN
185	KARAMBA CAFE CORP
	LA COLMENA RESTAURANT CORP
189	189 MAIN STREET ASSOCIATES LLC
	189 MAIN STREET ASSOCS LLC
	BROADWAY TAXI
	CENTER FOR DRIVING OF WESTCHESTER
	CRUISE EXPERTS & TOURS
	G & R CHECK CASHING
	LA PETITE PATISSERIE
	MEWS MANAGEMENT ASSOCIATES
199	6485 APT ASSOCS INC
	ADLER BERKEY INC
	AHMAD & THOMAS
	ALL FOR YOU SALON & DAY SPA
	BLUE DONKEY LLC
	BLUESTONE ASSET MANAGEMENT INC
	BLUESTONE REALTY ADVISORS INC
	CITIZENS CMPAGN FATHER TH ENVMT
	COLLECTION ASSOCS
	COMMCORE INC
	DAMSA INC
	EDUTECH
	FAMIGLIA DEBARTOLO OPERATIONS LLC

199 FIECH PIACENTE AND STANO CPA LLP
FIECH, STANO
FOX ADVERTISING SERVICE
GLM CAPITAL CORP
GORDON, DAVID
GOULD, RICHARD A
GREAT WAY CARS INC
HILL, LINDA M
INTERACTIVE INFORMATION INC
INTREPID EQUITY CO
J J SEDELMAIER PRODUCTIONS INC
JACOBY & MEYERS LAW OFFICES
JAMES LOUIS PLLC
KENNELLY, SHARON G
KRONICK, ARNOLD
LEHRMAN & KRONICK
LEHRMAN KRONICK & LEHRMAN
LISA S GOLDMAN
LOUIS, JAMES
LURIA DIGITAL PRODUCTIONS LLC
MARANTIS, ZACHARY
NEWBURGH REALTY ASSOCS LLC
OPERATION PRISON GAP
OVERNIGHT FUNDING INC
PHILLIPS, STEVEN
PIACENTEJOSEPH, A
RANELLONE, STEVEN
REAF INTERNATIONAL CORP
ROBIN JAMES ASSOCS LLC
ROBINOWITZ COHLAN & DUBOW
ROBINOWITZ, COHLAN
RONAI & RONAI LLP
SALEHZADEH INC
SANTORO & SANTORO ATTORNEY AT LAW
SEASONS ASSOCIATES INC
SECURITY SERVICES OF CONN
SOFTLINK INTERNATIONAL PVT LTD
SPIVACK, JOEL
STAAB GARY G
SUBWAY SANDWICHES & SALADS
TOTAL COMMUNICATIONS
TRADITIONAL CONTRACTING CO
TYDREW REAL ESTATE LLC
US SECURITY ASSOCIATES INC
VANESS & MARANTIS
WESTCHESTER CRT SERVCSFX ADVG
WESTCHESTER TAXI CORP

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 2000

34	BABCOCK, L
	CASH, C
44	AYORA, M
49	INFORMATION MATION INFOFONE SERVICES
50	ABELSON & TURNER ATTORNEY
	ACEVEDO, F
	ACTUARIAL CAREERS INCORPORATED
	ADLER HERBERT ATTORNEY
	ADVANTIS RYE WHITE PLAINS
	ALLIANCE BUSINESS CENTERS
	AMSTEL USA
	ANDERBERG EDWARD BROKER
	AQUISITIONS ADVISORY GROUP
	ARM GROUP
	BEISHEIM GEORGE JR ATTORNEY
	BENEFIT TECHNOLOGY INCORPORATED
	BERGLAS LAWRENCE A ATTORNEY
	BERRY GREGORY ATTORNEYS
	BEVAN RESOURCES
	BIEBER JOEL
	BISHOP SCOTT MARSHALL
	BISHOP, SCOTT
	BLASI PETER F ATTORNEY
	BLAUMAN SIMON L ATTORNEY
	BORSETTI CHARLES V ATTORNEY
	BOYLE JAMES
	BROOKLINE TECHNOLOGIES
	BRUNO ERASMO ATTORNEY
	C I SPECIALTY CHEMICALS INCORPORATED
	CABE, BLAUMAN
	CAPITAL CAFE
	CARDINAL RESOURCES INCORPORATED
	CARIBINER COMMUNICATIONS
	CARLUCCI & ASSOCIATES
	CENTRAL GLASS INTERNATIONAL INCORPORATED
	CERVONE JOSEPH CPA
	CHAVES & ASSOCIATE
	CHENEY, ROBERT S
	CHRONOS RICHARDSON INCORPORATED
	CLARKE BENNETT
	CLASSIC WESTCHESTER INCORPORATED
	CLIVEDEN PIERRE
	COHEN MARCIA SMITHEN JD LLM
	COMMONWEALTH LAND TITLE INSURANCE COMPANY
	COMMUNITY MUTUAL SAVINGS BANK
	COMPUTER OPTIONS INCORPORATED
	CONCEPT CARE CORPORATION
	CONROY KATHERINE WILSON LWY
	CONTE ROCCO ATTORNEY
	COPY STOP

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 2000 (Cont'd)

50 CORPORATE ENTERTAINMENT PROMOTIONS
DATALINX CORPORATION
DEAN & SCHNAUFER
DIGITAL TYPEART INCORPORATED
DININ JOHN R ATTORNEY
DOUBLE BYTE INTERNATIONAL
DOYLE DENNIS T ATTORNEY
EDEN STAFFING SVCES
EDP TECHNOLOGIES GROUP INCORPORATED
EDWARDS & EDWARDS
EISENBERG LAWRENCE J
EPOCH TECHNOLOGIES LLC
EPRI
EPSTEIN MARTIN B ATTORNEY
F G H P CAPITAL LIMITED PARTNERSHIP
FAY LAWRENCE F LAWYER
FEBBRAIO GREGG M ATTORNEY
FERGUSON DONALD ATTORNEY
FIELD JOEL ATTORNEY
FISCHER REESE ASSOCIATES INCORPORATED
FOGEL AL ESQ
FREEMAN GREGORY C LAWYER
FRIEDMAN & FERGUSON ATTORNEYS
FUTERFAS NEAL ATTORNEY
GABEL JEFFREY
GLICKSTEIN RICHARD
GLOBALTICKETS
GMG PUBLIC RELATIONS INCORPORATED
GOLDEN STEVEN R ATTORNEY
GORDON & SILBER PC
GRAFICA WORLDWIDE INCORPORATED
GRAUER DAVIDL ATTORNEY
GREER WILLIAM JAMES LAWYER
GRIFFITHS & O'CONNEL SAUNDRA NEUBART EUGENE KAVA
GRUBER LEE MD
HALL, WILLIAM G
HAMILTON DEVELOPMENT
HARRIS, SHERYL
HATA, TAKASHI
HAZZARD ROBERT D LAWYER
HEANEY, EST O
HEDGES J KRISTIN ATTORNEY
HEINEKEN USA INCORPORATED
HEINZMAN JOSEPH C JR ATTORNEY
HORAN & HORAN
HOUSEHOLD FINANCE CORPORATION
HOWARD L MANN
HUDSON FINANCIAL GROUP
IKON DOCUMENT SVCES
INFORMATION LINKS INCORPORATED

50

INTRAVAIA, JUSTIN M
ITOCHU SPECIALTY CHEMICALS INCORPORATED
JACKNESS GROUP THE
JAEGER OTTO C
JARCHO ARTHUR S ATTORNEY
JLL ASSOCIATES LP
JOC RECRUITERS
JONES HIRSCH CONNORS & BULL
KAMOGAWA, H
KASAIJA, ANDREW B
KATZ FREDRIC B ATTORNEY
KAVA EUGENE S
KENT HAZZARD JAEGER FREEMAN GREER & WILSON
KERN RONALD & ASSOCIATES
KESTENBAUM GERSHENOFF CPA
KIESELSTEIN & LEE LLP
KILBOURNE, ANN M
KITSON KEVIN J ATTORNEY
KREISMAN DAVID & ASSOCIATES
LAW OFFICES OF FRANK V MERLINO
LAZARUS WORLD TRADE INCORPORATED
LEGAL & MEDICAL TRANSCRIPTIONS
LEVER DAVID B
LEVINE & ZELMAN ATTORNEYS
LEVITT & QUINN ATTORNEYS
LINDA WOLFSON STAFFING
LISS MICHAEL ATTORNEY
LONGLEY COMMUNICATIONS
LOSCO GROUP INCORPORATED
MADISON MORTGAGE SERVICES
MAIN ST MARKETING LP
MAIN ST PRODCTNS
MAIN STREET MARKETING
MALEY PHILIP M ATTORNEY
MALONEY, ANDREW
MANPOWER WHITE PLAINS
MARSHALL BISHOP SCOTT
MARTIN CLEARWATER & BELL
MBS FINANCIAL GROUP
MCCABE TERRENCE M ATTORNEY
MCGOVERN & DAWSON ATTORNEY
MCGUINNESS EUGENE J ATTORNEY
MESSING PHILIP J CPA
MESSINGER STANLEY ATTORNEY
MORAN & ASSOCIATES
MORRIS JAMES ATTORNEY
N S RESOURCES INCORPORATED
NATIONAL COUNCIL FOR INTERIOR DESIGN QUALITICATION
NATIONAL ECONOMIC RESEARCH ASSOCIATES
NATIONAL SECURITIES INCORPORATED

50

NEDSTAFF SERVICES
NERA INCORPORATED
NEUBARDT SAUNDRA ATTORNEY
NEW ENGLAND FINANCIAL
NORWEST MORTGAGE
ODONNELL ROBERT ATTORNEY
OERTLY, ADAM F
OLESON RICHARD C ATTORNEY
OSCAR DYSTEL & PARTNERS INCORPORATED
OWEN R CHRISTOPHER ATTORNEY
PARK, G
PARTNERSHIP FOR WESTCHESTER
PAXTON RESOURCES INCORPORATED
PEOPLE CARE INCORPORATED
PINO & ASSOCIATES
PLATINUM STEM & PETALS INCORPORATED
PMCC MORTGAGE INCORPORATED
POWER FORCE
PREFERRED PENSION CONCEPTS
PRIME OFFICE SYSTEMS INCORPORATED
PROCESS MANAGEMENT ENTERPRISES
PROVIDENT DISTRIBUTORS INA
PRUDENTIAL SECURITIES INCORPORATED BROKERS & INVESTMENT BANK
PUBLISHING SOLUTIONS
QUINN ANDREW C ATTORNEY
RAKOW RICHARD COMMERCIAL REAL ESTATE
REDAC INCORPORATED
RISK MONITOR INCORPORATED
ROSE JAMES M ATTORNEY
ROSENBLUM & FILAN ATTORNEYS
SAKAI, MAYUMI
SALOMON SMITH BARNEY INCORPORATED LCL BR SALES OFFICES
SCHINAZI, AGATA
SCHNAUFER JOHN C ATTORNEY
SCHWARTZBERG ALBERT
SECO STEEL TRADING INCORPORATED
SENTINEL PROPERTY COMPANY
SILEX WORLD TRADE INCORPORATED
SMITH BARNEY INCORPORATED
SMITH CHARLES J MD
SPECTOR NEIL ATTORNEY
SPEISER & HEINZMAN
SPEISER & HEINZMAN ATTORNEYS
STAUBI PAUL
STEINBERG & CAVALIERE
STIVERS TEMPORARY PERSONNEL INCORPORATED
STONEBRIDGE PARTNERS
TACKMANN, HERBERT W
TARGOFF CHERI K ATTORNEY
TELE DANMARK USA INCORPORATED

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 2000 (Cont'd)

50	THACHER PROFFIT & WOOD
	THE LITHIUM COMPANY LLC
	THE MEYERS GROUP
	TITLE AMERICA ABSTRACT CORPORATION
	TOKYO ZAIRYO COMPANY LIMITED
	TREMONT INSURANCE BROKERS
	TRINGALI JOSEPH JR
	TUNIS BEN COMPANY INCORPORATED
	TURNER SIDNEY ATTORNEY
	TURNER SIDNEY PC ATTORNEY
	UNIVERSAL TEXTILE BROKERS I
	URBAN DENTAL MANAGMNT IPA INCORPORATED
	VANGIFFEN, REITZE
	WATERHOUSE SECURITIES INCORPORATED
	WEATHERSBY GROUP
	WEATHERSBY GROUP THE
	WEINGARDEN MITHCELL I ATTORNEY
	WELBY BRADY & GREENBLATT L L P
	WELBY, BRADY
	WESTCHESTER ASSOCIATION OF WOMEN BUSINESS OWNERS
	WESTCHESTER FINANCIAL CENTER
	WILSON MIZELL JR LAWYER
	WOLFSON STAFFING
	YAMAKAWA CHEMICAL INDUSTRIES
	ZELMAN ELIZABETH ATTORNEY
	ZUCKER JAY B
	ZUCKER LEO ATTORNEY
61	SERCHUK & ZELERMYER
81	ABRAMS DONNA E ATTORNEY
	BAKER LEON C ATTORNEY
	BALABER STRAUSS BARBARA ATT
	BEATON DANIEL ENGR
	BISESTO PATRICIA T ATTORNEY
	BOWLER RICHARD J ATTORNEY
	BOYNTON SALLY J ATTORNEY
	BRADLEY CHARLES A ATTORNEY
	BRESS FRANK A ATTORNEY
	BREWSTER EVANS V ATTORNEY
	BRINTON ROBERT L ATTORNEY
	BROWN IRA L ATTORNEY
	BURCHETTA BROFMAN & HANLEY PC
	BURCHETTA BROFMAN & HANLEY PC LAWYERS
	CAMARDELLA JAMES V ATTORNEY
	CAREER STRATEGIES INTERNATIONAL INCORPORATED
	CARTELLI JAMES A ATTORNEY
	COMER NEAL S
	COSTA JOSEPH S ATTORNEY
	DONOHUE JAMES F ATTORNEY
	DUBAN MICHAEL C
	DUBAN MICHAEL C ATTORNEY

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 2000 (Cont'd)

81

EINHORN YAFFEE PRESCOTT
ELLENBOGEN GOLDSTEIN & GOODMAN ATTORNEYS
EPSTEIN MARTIN B
ERIC J ROTBARD ATTORNEY
FACILITIES MANAGMNT CONSULTANTS
FIRST AMERICAN TITLE INS CO OF NY BRANCH OFFICES
FIRST AMERICAN TITLE INS COMPANY OF NY BRANCH OFFICES
FITZGERALD ROBERT A PC
FREDERICKS ALFRED D ATTORNEY
GASH & GROSSMAN ATTORNEYS
GOLD BARRY S
GOLDBERGER CHARLES A ATTORNEY
GOLDFARB & ABRANDT
GOODMAN STANLEY L ATTORNEY
HAROLD CHRISTOPHER ATTORNEY
HARRINGTON & OCKO ATTORNEYS
HOCHFELDER JOHN M ATTORNEY
JANUARY DERICK C ATTORNEY
KAMLER & LEWIS
KEEGAN KEEGAN & STRUTT LLP
KIRKPATRICK & SILVERBERG LLP ATTORNEYS
KIRKPATRICK JOHN B ATTORNEY
KITTAY DAVID R
KITTAY GOLD & KREBSBACH PC
KITTAY GOLD KREBSBACK PC
KOSOFSKY JOSEPH ATTORNEY
KRAMER MICHAEL A ATTORNEY
KREBSBACH THEODORE A
KROOKS HOWARD S
KURTZ SANDRA KOSS ATTORNEY
LANDRIGAN PHILLIP C ATTORNEY
LANZA DONALD C ATTORNEY
LEWIS GARY F CPA
LEWITTES PAUL M ATTORNEY
LITTMAN KROOKS ROTH & BALL PC
LITTMAN KROOKS ROTH & BALL PC ATTORNEYS
LOMBARDI MICHAEL J ESQ
LUCENO & PISANELLI ATTORNEY
LUNNEY & MURTAGH LLC
MARX PAULL ATTORNEY
MCCOY HAROLD JR ATTORNEY
MCCULLOUGH GOLDBERGER & STAUDT
MCEVOY ANDREW T JR
MITSUBISHI KASEI AMERICAN I
MURTAGH JOHN M JR ATTORNEY
OCKO ROBERT S ATTORNEY
ODESSER EDWARD H
OLMSTEAD GROUP THE LLC
PETER ELLIOT LLC
PISANELLI ANDREW F ATTORNEY

81	RAPOPORT JOHN ATTORNEY
	REIMER LEON & COMPANY PC
	ROACH THOMAS M ATTORNEY
	ROSE WILLIAM A ARCHT
	ROSS STANLEY A CPA
	SALANT JEFFREY R ATTORNEY
	SEEGER WILLIAM E ATTORNEY
	SHABASSON LEONARD
	SHEEHAN JEREMIAH J
	SILVERBERG STEVEN ATTORNEY
	SILVERSTEIN FRANK ATTORNEY
	SOLARSH LAURENCE ATTORNEY
	SPIELBERG LEONARD I ATTORNEY
	STEINMETZ DAVID ATTORNEY
	STEVEN M SILVERBERG
	STRASSFIELD RICHARD J ATTORNEY
	STRUTT BARRY
	WHELAN DAVID J ATTORNEY
	YOUNG FRANCIS X ATTORNEY
	ZARIN & STEINMETZ
	ZARIN & STEINMETZ ATTORNEYS
100	ACCESSORY PLACE
	ACROPOLIS RESTRNT THE
	AFTERTHOUGHTS
	ALDO SHOES
	ANNTAYLOR
	ART EXPO INCORPORATED
	ARTHUR TREACHERS FISH & CHIPS
	ASPASIA AT GALLERIA LIMITED
	ATHLETES FOOT THE
	AUGUST MAX WOMEN
	AUNTIE ANNES
	BALDWIN PIANO & ORGAN CO
	BANG BANG BOUTIQUE
	BELLEZA SALON & SHOP
	BIG EASY CAJUN AT THE GALLE
	BLOCK H & R
	BOMBAY COMPANY THE
	BRUSHSTROKES INCORPORATED
	BUNNIES CHILDREN DEPARTMENT
	CANDIES GALLERIA INCORPORATED
	CASUAL CORNER
	CHARADES
	CHILDRENS PLACE INCORPORATED THE
	CHOWDERS SEA FOOD
	CHRISTMAS SHOPPE & FESTIVE FOODS
	CINNABON WORLD FAMOUS CINNAMON ROLLS
	CLAIRES DIST OFFICE
	COFFEE BEANERY THE
	COMPLETE ATHLETE THE

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 2000 (Cont'd)

100
CONTEMPO CASUALS INCORPORATED
CPI PHOTO FINISH
DETAILS
DIAMONDS HALLMARK
DISNEY STORE THE
EASY SPIRIT STORE 6306
ELEGANCE
EMIGRANT SAVINGS BANK EXEC OFFICES WESTCHESTER OFFICES
ENERGY FASHIONS
FOOT ACTION USA
FOOT FETISH INCORPORATED
FOOT LOCKER
FRANK & CAMILLES
FRIEDMAN MARKETING SERVICES
G & G SHOPS
GALLERIA ART EXPO INCORPORATED
GALLERIA FOOT CARE
GALLERIA FURNITURE
GALLERIA INFORMATION & SECURITY
GALLERIA MALL AT WHITE PLAI
GALLERIA MALL DENTAL
GAP STORE THE
GATSBY AT THE GALLERIA
GIFT SOLUTIONS TOO
GREAT AMERICAN COOKIE COMPANY
GREENJEAS
GYMBOREE THE STORE
HOT WHITE PLAINS COOKIES INCORPORATED
JC PENNEY COMPANY INCORPORATED
JC PENNY OPTICAL
JEANS HALLMARK
JEWEL HUT
JOBEN RALPH LIMITED
JOHN DAVID LIMITED
KAY BEE TOY
KEEP IN TOUCH WIRELESS
KIDS FOOT LOCKER
LANE BRYANT
LECHTERS HOUSEWARES
LENSCRAFTERS
LERNERS
LETS TALK CELLULAR & WIRELESS INCORPORATED
LIDS
LIMITED THE
LIMITED TOO
LOTS TO LOVE
MACYS
MACYS WHITE PLAINS
MAJOR JEWELERS INCORPORATED
MCDONALDS

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 2000 (Cont'd)

100
MOTHERHOOD MATERNITY
MR GREENJEANS RESTRNT
MUGS & KISSES INCORPORATED
MY FAVORITE MUFFIN
N Y YANKEES CLUB HOUSE
NAILS & MORE BY DAWN
NATHANS RESTRNT
NATURAL SCENTS AND MORE
NATURALIZER SHOES
NEW FASHION
OAK TREE
OLD NAVY STORES
OVER THE COUNTER
OVERLAND TRADING COMPANY
PACIFIC SUNWEAR OF CALIFORNIA INCORPORATED
PARADE OF SHOES
PEMCO INCORPORATED
PETITE SOPHISTICATE
PIERCING PAGODA INCORPORATED
PILDES OPTICIANS
PRINTS PLUS
R & R GALLERIA
RANCH 1
RECORD TOWN
ROSE JEWELRY
SAN FRANCISCO MUSIC BOX 36617
SANTA SHOOT
SARKU JAPAN
SBARRO INCORPORATED THE ITALIAN EATERY
SEES CANDIES
SHIFTYS
SILVER & GOLD CONNECTION
SILVER LINING
STEAK ESCAPE
STITCH THIS
SUNCOAST DISTRICT 310
SUNCOAST VIDEOS
SUNGLASS HUT
SWEET FACTORY INCORPORATED
T D S CONSTRUCTION
TAILORS TOUCH
THINGS REMEMBERED
THIS END UP FURNITURE COMPANY
TIE GUYS THE
TOTAL ECLIPSE
TREASURE CHEST CELTIC IMPORTS
TREND SETTERS
TSR WIRELESS
VALENTI PERFUMERY
VICTORIAS SECRET

100 VITAMIN WORKS THE
WATCH STOP THE
WATCH WORLD INCORPORATED
WENDYS
WESTCHESTER EMPLOYMENT NETWORK
WILD PAIR
WILSONS SUEDE & LEATHER INCORPORATED
WORLD OF SCIENCE
ZIA, IQBAL A

123 ADVANCED CAREER TECHNOLOGIES
ADVANCED CAREER TECHNOLOGIES INCORPORATED
BAVERO RONALD J
BERMAN HENRY S
BONA THOMAS M ATTORNEY
BORCK, STUART H
BOROWICK HOWARD R ATTORNEY
BRAUNSTEIN LAWRENCE JAY ATTORNEY
BRAUNSTEIN, L
BRILL, SANDRA A
DAMAST ROBERT ATTORNEY
DANZIGER & MARKHOFF ATTORNEYS
EISENBERG LAWRENCE J ATTORNEY
FRUCCO JOHN ATTORNEY
GELFAND BERTRAM R ATTORNEY
GOLDBERGH & SPITZER
GORDON STEPHEN G ATTORNEY
GOUZ RONNIE A
GRONER WILLIAM H ATTORNEY
HALLER, EVELYN
HAND, EDWARD S
HODOGAYA CHEMICAL COMPANY LIMITED
HYMAN ANDREW A AGENCY INCORPORATED
IMPACT MANAGEMENT GROUP INCORPORATED
KENS CAFETERIA
KPMG PEAT MARWICK
LANGER IRA ATTORNEY
LAWARE, C
LEVINE JOSHUA S ATTORNEY
MADISON PENSION SVCES INCORPORATED
MARKHOFF HARRIS ATTORNEY
MUKUDAI, O
N Y STATE OF POWER AUTHORITY
NATIONAL PENSION CONSULATNTS II INCORPORATED
NEW YORK EMPLOYEE BENEFITS GROUP
NEW YORK POWER AUTHORITY
NEW YORK STATE OF TRANSPORTATION DEPARTMENT OF
OLSEN, WILLIAM R
ONEILL, WILLIAM A
POST, CYNTHIA
RODRIGUEZ, DAMIAN

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 2000 (Cont'd)

123 RUBIN IRWIN ATTORNEY
SHEA, PAUL J
SHERMAN SCOTT M ATTORNEY
SKIDMORE COLLEGE COMPUTER CAREER INSTITUTE
STIVERS TEMPORARY PERSONNEL INCORPORATED
SUNDHEIM STEVEN R ATTORNEY
T P G FINANCIAL SYSTEM INCORPORATED
THOMPSON RICHARD C ATTORNEY
WORBY BOROWICK GRONER ABELE & ACESTE
ZUCKERMAN & BRAUNSTEIN

169 AMERICAN EXPRESS
COMPUTER FACTORY INCORPORATED THE
METRO COMPUTER RENTAL INCORPORATED
THE NEW COMPUTER FACTORY

173 CAMEO CREATIONS

174 TAYLOR MCCULLOUGH GOLDBERGER GEOGHEAGAN & FRIEDMAN ATTORNEYS

175 A & A STAFFING HEALTH CARE SERVICES
A & A STAFFING TEMPORARY PERSONNEL
A M COURT REPORTING
A R I
ABRATOURS INCORPORATED
ASAP REPORTING COMPANY INCORPORATED
BARONI ROLAND A JR LAWYER
BARRISTER PROPERTIES LIMITED
BARRY MCTIERNAN & MOORE LAW
BEECHER ROXANNE ATTORNEY
BENEFICIAL NATIONAL LIFE INS COMPANY
BLASS HAROLD ATTORNEY
BLISS EXTERMINATOR COMPANY
BLISS TERMITE CONTROL DIVISION OF BLISS EXTERMINATOR COMPANY
BONA THOMAS M ATTORNEY
BROOKS JILL L ATTORNEY
BROWN GERALD ATTORNEY
BUDERWITZ JOSEPH M
BUSMAN KENNETH ATTORNEY
CALGER ARTHUR R ATTORNEY
CAPUTO ANTHONY J ATTORNEY
CENTRAL TAXI SERVICE CORPORATION
COOPER MARVIN A ATTORNEY
COOPER PREP COURSE
COOPER WILLIAM H ATTORNEY
COPYHUT THE
CORWIN LEONARD S ATTORNEY
COSSU DENISE M ATTORNEY
COURTHOUSE BARBERS SHOP
CRIBARI & FLETCHER ATTORNEYS
CUNARD JANET E ATTORNEY
DAILY NEWS
DEL NEGRO ARTHUR L JR ATTORNEY
DELANEY THOMAS F LICENSED PRIVATE INVESTIGATOR

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 2000 (Cont'd)

175 DONOVAN DANL G ATTORNEY
DRESCHER ANN MARIE
EMANUEL THEBNER
FARRELL LYNN P
FAYER, ERIC M
FORD EDWARD L ATTORNEY
GILDEA JOHN T ATTORNEY
GOLDMAN MARSHALL S ATTORNEY
GRAYSON RICHARD E ATTORNEY
GREENSTEIN SOL D ATTORNEY
HERZFELD ROBERT ATTORNEY
HIRSCH RESEARCH ASSOCIATES INCORPORATED
HIRSCH WALTER JAY & COMPANY CPAS
HIRSCHFIELD JOSEPH
HOROWITZ NATHAN ATTORNEY
HYMAN M J CPA
ISAAC EVELYN K ATTORNEY
JACOBS GLORIA S ATTORNEY
JACOBY & MEYERS LAW OFFICES
JOHNSON HAROLD J ATTORNEY
KAHN & KAHN ATTORNEYS
KAHN DAVID MILLER ATTORNEY
KALISH DANIEL A ATTORNEY
KAPLAN ELIOT L ATTORNEY
KELLY & KMETZ ATTORNEYS
KELLY REGINA F ATTORNEY
KILLERLANE JAMES J
KMETZ STEVEN P
KOBACK & CHASE ATTORNEYS
LANGUS SANDRA ATTORNEY
LANSDELL PROTECTIVE AGENCY INCORPORATED
LEWIS DAVID G ATTORNEY
LEWIS PAMELA ATTORNEY
LEWIS STEPHEN R ATTORNEY
LEWIS STEPHEN R LAWYER
LICHTENTHAL JOSEPH A ATTORNEY
LICHTER LESTER ATTORNEY
LOBATO LAW OFFICES
LYNCH THOMAS J ATTORNEY
MADAN JAMES R
MAGNUS LEE ATTORNEY
MAIN ST SMOKE SHOP
MANDEL ROBERT ATTORNEY
MANNION MARTIN P ASSOCIATES
MARASCO PETER AGENCY INCORPORATED
MAROCCO FRANK ATTORNEY
MARTIN LAWRENCE N JR ATTORNEY
MCKENNA THOMAS H PC
MCMAHON JOHN J ATTORNEY
MOROSCO & CUNARD ATTORNEYS

175 MURPHY MCPARTLAND & WALSH
NELSON & SMITH ATTORNEY
NORRELL HEALTH CARE INCORPORATED
ORT
PICKELLE PAUL W ATTORNEY
PITTORE & ZERN ATTORNEY
POHS MAX S COMPANY RUBBER PRODS
POLICE FRESH AIR FUND INCORPORATED
PROMOTIONAL MAILING SVCES
Q & A REPORTING SERVICE
RAPID PHOTO
REICH ROBIN ATTORNEY
REILLY GERALD D ATTORNEY
REILLY GERALD D LAWYER
RELLA GERARDA M & ASSOCIATES ATTORNEY
RICE JONATHAN ATTORNEY
RICHARDSON JOHN WOODWARD
RINALDI & SMALEC
RINALDI & SMALEC ATTORNEY
ROSEN MARTIN J PC ATTORNEY
ROSENBERG THOMAS L ATTORNEY
SCUTIERI JOSEPH A ATTORNEY
SMALEC MARK ATTORNEY
SORIANO NICHOLAS M
SPLENDID TAXI CORP
STATE FARM INS COMPANY
STAUB BERNARD CPA
STEPHENS BARONI REILLY & LEWIS ATTORNEY
STEPHENS BARONI REILLY & LEWIS LWYRS
THE COPY HUT
TROTTERS TAVERN
U S A TAXI CORPORATION
VERDES EDW M AND SON INCORPORATED REAL ESTATE
VINK PAUL T ATTORNEY
WATKINS JOHN E JR ATTORNEY
WESTCHESTER LAW JOURNAL
WESTCHESTER SPECIAL SVCES CENTER INCORPORATED
WHITE PLAINS CENTRAL TAXI
WLJ PRINTERS
WOMENS AMERICAN ORT
WOOLEY JOSEPH E ATTORNEY
YALKUT ARLEN S ATTORNEY
ZERN MARTIN H ATTORNEY
183 INNOVATIONS BY OMIGEN
KIM MORRIS HAIRSTYLIST
185 PIZZAWORKS CAFE INCORPORATED
187 MANHATTAN BAGEL
189 ABF DEVELOPMENT COMPANY INCORPORATED
CENTER FOR DRIVING OF WESTCHESTER
G & R CHECK CASHING

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 2000 (Cont'd)

189 LAPETITE PATISSERIE
MUNSON COMPANY THE
STAR TAXI
TEFFT BUSINESS SCHOOL

199 175 MEMORIAL HWY REALTY CORPORATION
A TOUCH OF GOLD
ALAN M DUBOW ATTORNEY
ALWAYS DEPENDABLE SERVICE PROCESS SERVICE
ASCENT COMPUTING GROUP
BENSON SETH LAWYER
BLAH BLAH BLAH
BLUETT RAYMOND E ATTORNEY
BRILL JOSEPH MD
CARUSO SPILLANE CONTRASTANO ULANER PC
CITIZENS CAMPAIGN FOR THE ENVIRONMENT
CLEARVIEW COUNSELING GROUP
COHLAN RICHARD M ATTORNEY
COMMCORE INCORPORATED
D B KELLY ASSOCIATES
DISCIULLO ROBERT J ATTORNEY
E WORKS
FIECH & RESNICK PC CPAS
FORGET ME NOT TRAINING INCORPORATED
FOX ADVERTISING SVCE
FRASCELLA RUSSELL B CPA
G L M MORTGAGE COMPANY
GARGIULO, PAUL
GOLDSTEIN & ASSOCIATES REALTY INCORPORATED
GORDON DAVID ATTORNEY
GOULD RICHARD A
GRASSROOTS TECHNOLOGY ASSOCIATES LIMITED
GREAT WAY CARS INCORPORATED
HAGAN & KENNEDY
HAGAN AND KENNEDY
HOT FREIGHT
ICJ CONSULTANTS
J J SEDELMAIER PRODUCTIONS INCORPORATED
JASNE & MORELL ATTORNEYS
JCB REALTY
KAPLAN MRD INCORPORATED
KRONICK ARNOLD S ATTORNEY
LEHRMAN STEPHEN J
LEHRMAN STEPHEN J & ASSOCIATES INCORPORATED
MCCARTHY PETER J ATTORNEY
MICHAELS, JEROME A
OIL MICHAEL A DDS
PHYSICIANS BILLING SERVICE INCORPORATED
PIACENT JOSEPH A
PIONEER ABSTRACT CORP
PIOVIA SARA ATTORNEY

199 PREMIER HOME HEALTH
PRESENTS OF TASTE
REARDON JUDITH ATTORNEY
RESNICK DAVID CPA
ROBINOWITZ COHLAN & DUBOW ATTORNEYS
SANTORO & SANTORO ATTORNEYS AT LAW
SCANLAN RICHARD S ATTORNEY
SEDELMAIER J J PRODUCTIONS INCORPORATED
SMALL PROPERTY MANAGMENT COMPANY
SMITH RUSSELL ATTORNEY
SPEISER & HEINZMANN
SUBURBAN ST NEWS INCORPORATED
SUBWAY SANDWICHES & SALADS
THOMAS, SOPHY
TOTAL COMMUNICATIONS
TOWBIN REALTY INCORPORATED
WADLER IRWIN M DDS
WESTCHESTER COURT SVCE COMPANY
WESTCHESTER HISPANIC COALITION INCORPORATED
WHALEN & WHALEN
WHITE PLAINS CHILD DAY CARE ASSOCIATES INCORPORATED

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 1995

50	ABELSON & TURNER, ATTY
	ABELSON, RICHARD H, ATTY
	ADIA PERSONNEL SVCES
	ADLER, HERBERT, ATTY
	ADLER, MARVIN
	ADVISO GROUP LTD
	AMERICAN ASSIGNMENT SVCE CORP
	AMOROS & FAVATA, ATTYS
	AMOROS, SCOTT D
	ANDERBERG, EDWARD, BROKER
	BARRETTA RESEARCH SERVICES CORP
	BEISHEIM, GEORGE, JR, ATTY
	BENEDICTINE USA CORP
	BERGLAS LAWRENCE A, ATTORNEY
	BERTOLDI, HENRY
	BEVAN RESOURCES
	BIEBER, JOEL
	BLANCO BAIOCCO PC
	BLASI, PETER F, ATTY
	BOYLE, JAMES
	BSS ASSET MANAGEMENT
	C I SPECIALTY CHEMICALS INC
	CAIVANO, CHRISTOPHER
	CALBY, JOHN
	CARDINAL RESOURCES INC
	CAREER STRATEGIES INTERNATIONAL INC
	CAREER STRATEGY INT'L INC
	CARIBINER GROUP THE
	CARIELLO, WILLIAM J, ATTY
	CARLUCCI & ASSOCS
	CENTER BANK MORTGAGE
	CENTRAL GLASS INTERNATIONAL INC
	CERVONE, JOSEPH, CPA
	CIAMPI, SAM
	CLARKE, BENNETT
	CLASSIC WESTCHESTER INC
	COMMONWEALTH LAND TITLE INSURANCE CO
	CONCEPTS CARE INC
	CONROY, KATHERINE WILSON, LWYR
	CONTE, ROCCO, ATTY
	COPY STOP
	CORTES, ANA
	DATALAN CORP
	DATALINX CORP
	DEAN & SCHNAUFER
	DEAN, JOHN W, ATTY
	DININ, JOHN R, ATTY
	DOHERTY, JACQUELINE
	DONAHUE, MICHAEL
	DOUGLAS, ROSEMARY

50 DOYLE, DENNIS T, ATTY
DRAKE BEAM & MORIN INC
DREYFUS FOUNDATION MAX & VICTORIA
E DP TECHNOLOGIES GROUP INC
EAGLE DIRECT MARKETING INC
EISENBERG LAWRENCE J
EISENBERG, LAWRENCE J, ATTY
EMMET MARVIN & MARTIN
EPSTEIN, MARTIN
F G H P CAPITAL LTD PARTNERSHIP
FAI ENGINEERING GROUP PC
FAVATA, ROBERT, ATTY
FAY, LAWRENCE F, LWYR
FEBBRAIO, GREGG M, ATTY
FEBBRAIO, GREGG M, ATTY-FAX LINE
FEDERAL DEFENDER SVCES UNIT
FENNELL, ALICE
FERGUSON, DONALD, ATTY
FISCHER REESE ASSOCIATES INC
FLICK JOEL J
FLICK, JOEL J, ATTY
FLICK, JOEL JAY, ATTY
FREEMAN, EDWARD J, LWYR
FREEMAN, GREGORY C, LWYR
FRIEDMAN & FERGUSON, ATTYS
FRIEDMAN, BERNARD A, ATTY
GLICKSTEIN, RICHARD
GOOD DAY CAFE
GORDON & SILBER PC
GRAFICA WORLDWIDE INC
GRAUER, DAVID I, ATTY
GREER, WILLIAM JAMES, LWYR
GRIFFITHS & O'CONNEL SAUNDRA NEUBART EUGENE KAVA, ATTYS
HAAG, HAROLD A, LAW OFC
HAIR TECH
HALLIBURTON NUS
HAMILTON CAPITAL PARTNERS
HAMILTON DEVELOPMENT
HAZZARD, ROBERT D, LWYR
HEALTH MONITOR MARKETING
HEDGES, J KRISTIN, ATTY
HITACHI CABLE AMERICA INC
HUDSON FINANCIAL GROUP
INFORMATION LINKS INC
INSLER, SUE
INTERCONEX INC
INTERCONTINENTAL MARINE AGENCIES INC
INTERNATIONAL LEADING BRANDS INC
INTERSEARCH CORPORATION OF NY
ITOCHU SPECIALTY CHEMICALS INC

50 JAEGER, OTTO C
JARCHO, ARTHUR S, ATTY
JLL ASSOCIATES, LP
JONES HIRSCH CONNORS & BULL
KARDEX SYSTEMS INC
KATZ, FREDRIC B, ATTY
KELLAM, WANDA
KELLMAN, ROBERT
KELLY, LORRAINE
KENT HAZZARD JAEGER FREEMAN GREER & WILSON
KESTENBAUM GERSHENOFF, CPA
KNOX LENT & TUCKER INC
LEBEK, ERIK
LEVER, DAVID B
LEVER, DAVID B, ATTY
LEVINE, LINNEA, ATTY
LION CLAIMS MANAGEMENT INC
LOBER, JAMES
LONGLEY COMMUNICATIONS
LOSCO GROUP INC
LUPIE & ZAFRIN ASSOC INC
M BS ASSET MANAGEMENT GROUP
M BS FINANCIAL GROUP
MADA INTERNATIONAL
MADISON MORTGAGE SVCS
MAGIC SLIDERS L P
MAIN STREET MARKETING
MALEY, PHILIP M, ATTY
MANPOWER TEMPORARY SERVICES
MARITIME LOGISTIC SVCES INC
MARTIN I BLAUSTEIN & CO PC
MC GUINNESS, EUGENE J, ATTY
MESSING, PHILIP J, CPA
MESSINGER, STANLEY, ATTY
MIDLER, BRUCE, CPA
MORAN & ASSOCS
MUTUAL INVESTIGATIVE SVCE INC
NATIONAL CORPORATE SCIENCES INC
NATIONAL COUNCIL FOR INTERIOR DESIGN QUALIFICATION
NATIONAL ECONOMIC RESEARCH ASSOCS
NATIONAL PENSION SVCE INC
NERA INC
NEUBARDT SAUNDRA, ATTY
NEUBARDT, SAUNDRA, ATTY
NEVILLE, RICHARD M, ATTY
NEW ENGLAND THE
NEW ISSUES OUTLOOK
NEW SPECTRUM REALTY SERVICES INC
NIPPON ZEON OF AMERICA INC
NOFELT, ULF

50

OLESON, RICHARD C, ATTY
OPEN SOFTWARE SOLUTIONS
OPTIONS MENTAL HEALTH
OSCAR DYSTEL & PARTNERS INC
OWEN, R CHRISTOPHER, ATTY
PAXTON RESOURCES INC
PERFORMANCE RESUMES
PINO & ASSOCIATES
PLATINUM STEM & PETALS INC
POUGHKEEPSIE SAVINGS BANK FSB MORTGAGE CTR
POWER FORCE
PREFERRED PENSION CONCEPTS
PRERAU & TEITELL, ATTYS
PRIME OFFICE SYSTEMS INC
PROCESS MANAGEMENT ENTERPRISES
PROVIDENT DISTRIBUTORS INA
PRUDENTIAL SECURITIES INCORPORATED
PRUDENTIAL SECURITIES INCORPORATED, BROKERS & INVESTMENT BAN
R BIRD & CO
RABON, WILLIS
RIFKIN, ROBERT A, ATTY
ROSENBLUM & FILAN, ATTYS
S M A MANAGEMENT SYSTEMS
SACHTJEN WILBUR M ASSOC INC
SCHNAUFER, JOHN C, ATTY
SECO STEEL TRADING INC
SHARED SYSTEMS INC
SHAVER, ALAN M, ATTY
SILEX WORLD TRADE INC
SMA MANAGEMENT SYSTEMS
SMITH BARNEY INC-LOCAL BRANCH SALES OFFICES-WHITE PLAINS
SMITH, CHARLES J, MD
SPECTOR, NEIL, ATTY
STIVERS TEMPORARY PERSONNEL INC
STONEBRIDGE PARTNERS
TARGOFF, CHERI K, ATTY
TASCOR INC
TEITELL, CONRAD, ATTY
TELECOM DENMARK
TEMPLE, PHILIP T, ATTY
THACHER PROFFIT & WOOD
TITLE AMERICA ABSTRACT CORP
TITLE AMERICA ABSTRACT CORP-FAX LINE
TOKYO ZAIRYO CO LTD
TOTAL ENERGY CORP
TURNER SIDNEY PC, ATTY
TURNER SIDNEY, ATTY
UNIVERSAL COMMUNICATIONS
UNIVERSAL TEXTILE BROKERS INC
WALGREENS HEALTHCARE PLUS INC

50 WATERHOUSE NATIONAL BANK
WATERHOUSE SECURITIES INC
WEBER, RICHARD P, ATTY
WEBER, ROBERT
WEINGARDEN MITHCELL I, ATTY
WELBY, THOMAS H, ATTY
WESTCHESTER FINANCIAL CTR
WILSON, MALCOLM, ATTY
WILSON, MIZELL, JR, LWYR
YAMATANE INTERNATIONAL INC
ZEON MEDICAL CORPORATION
ZUCKER, LEO, ATTY

81 ABRAMS, DONNA E, ATTY
ACKERMAN, PETER B, ATTY
BAKER, LEON C, ATTY
BALABER-STRAUSS, BARBARA, ATTORNEY
BEATON, DANIEL, ENGR
BOWLER, RICHARD J, ATTY
BOYNTON, SALLY J, ATTY
BRADLEY, CHARLES A, ATTY
BRESS, FRANK A, ATTY
BRESS, FRANK, ATTY
BRESS, THOMAS, ATTY
BREWSTER, EVANS V, ATTY
BRINTON & JANUARY, ATTYS
BRINTON, ROBERT L, ATTY
BROWN, IRA L, ATTY
CAMARDELLA, JAMES V, ATTY
CARTELLI, JAMES A, ATTY
COMER BRESS & BOYNTON
COMER BRESS & BOYNTON, ATTY
COMER, NEAL, ATTY
COSTA, JOSEPH S, ATTY
CROCCO, CHARLES A JR, ATTY
DE MAIO, LUIGI P, ATTY
DONOHUE, JAMES F, ATTY
DUBAN, MICHAEL C
DUBAN, MICHAEL C, ATTY
EICON TECHNOLOGY CORP
EINHORN YAFFEE PRESCOTT
ELLENBOGEN GOLDSTEIN & GOODMAN, ATTYS
FACILITIES MANAGMNT CONSULTANTS
FAUST MARILYN S, ATTY
FIRST AMERICAN TITLE INS CO OF NY-BRANCH OFFICES-81 MAIN WHI
FITZGERALD, ROBERT A PC
FREDERICKS, ALFRED D, ATTY
FRIEDMAN, S WILLIAM, ATTY
GASH, GARY, ATTY
GOLD BARRY S
GOLDBERGER, CHAS A, ATTY

81 GOODMAN, STANLEY L, ATTY
HAROLD SALANT STRASSFIELD & SPIELBERG, ATTYS
HAROLD, CHRISTOPHER, ATTY
HARRINGTON, KEVIN J, ATTY
HOCHFELDER & WEININGER, ATTYS
HOCHFELDER, JOHN M, ATTY
JAMES, F DONOHUE, ATTY
JANUARY, DERICK C, ATTY
KAMLER & LEWIS
KEEGAN KEEGAN & ASSOC PC
KEEGAN, JOHN W, ATTY
KITTAY DAVID R
KITTAY DAVID R PC
KITTAY GOLD KREBSBACK PC
KOSOFSKY, JOSEPH, ATTY
KRAMER, MICHAEL A, ATTY
KREBSBACH THEODORE A
KURTZ, SANDRA KOSS, ATTY
LEBENSON ACTUARIAL SVCS INC
LEWIS, GARY F, CPA
LEWITTES, PAUL M, ATTY
LOMBARDI, MICHAEL J ESQ
LUCENO & PISANELLI, ATTY
LUCENO, CHARLES E, ATTY
LUNNEY CROCCO DEMAIO & CAMARDELLA PC
LUNNEY, J ROBERT, ATTY
MCCULLOUGH GOLDBERGER & STAUDT
MCEVOY, ANDREW T, JR
MENNA & FITZGERALD, ATTYS
MENNA, PHILIP F, ATTY
MITSUBISHI KASEI AMERICA INC
MITSUBISHI KASEI AMERICAN INC
MURTAGH, JOHN M JR, ATTY
OCKO, ROBERT S, ATTY
ODESSER EDWARD H
PENTAMEX
PISANELLI, ANDREW F, ATTY
PITEGOFF OCKO & HARRINGTON, ATTYS
PITEGOFF, THOMAS M, ATTY
RAPOPORT, JOHN, ATTY
RESPONSE SYSTEMS PARTNERS INC
RIGIE LAWRENCE, ATTY
ROSE, WILLIAM A, ARCHT
ROSS, STANLEY A, CPA
RUMBOLD & BRESS, ATTY
SALANT, JEFFREY R, ATTY
SAULITIS, ANDREW P, ATTY
SEEGER & SEEGER
SEEGER & SEEGER, ATTYS
SEEGER, ISRAEL G, ATTY

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 1995 (Cont'd)

81 SEEGER, WILLIAM E, ATTY
SERCHUK & ZELERMYER
SILVERSTEIN, FRANK, ATTY
SPIELBERG, LEONARD I, ATTY
STRASSFIELD, RICHARD J, ATTY
VENTECH INTERNATIONAL INC
WEININGER, ROBERT S, ATTY
WHELAN, DAVID J, ATTY
WILLIAM, JOYCE M, ATTY

100 A & S MUSIC & MOVIES
A & S OPTICAL
A & S-ALL INQUIRIES
A & S-FLORAL DEPT
ACCESSORY PLACE
ACROPOLIS RESTRNT
ACROPOLIS RESTRNT THE
AFTERTHOUGHTS
AMERICAN EAGLE OUTFITTERS
ANCHOR SAVINGS BANK FSB-WHITE PLAINS OFFICES-GALLERIA BRANCH
ART EXPO INC
ARTHUR TREACHER'S FISH & CHIPS
ASPASIA AT GALLERIA LTD
ATHLETES FOOT THE
AUGUST MAX WOMEN
AUNTIE ANNE'S
B Y S BRIDAL CO
BARNES & NOBLE BOOKSTORE
BOMBAY CO THE
C P I PHOTO FINISH
CAREN CHARLES
CASUAL CORNER
CHARADE FASHIONS
CHILDREN'S PLACE INC THE
CHOWDERS SEA FOOD
CIGNAL
CINNABON WORLD FAMOUS CINNAMON ROLLS
COBBIE SHOES OF THE GALLERIA
COBBIE SHOP
COFFEE BEANERY THE
COLONY WHITE PLAINS FLORAL DESIGN
COMPLETE ATHLETE THE
CONTEMPO CASUALS INC
D J'S FASHION CENTER FOR MEN
DECOR MARKETING
DESIGNS EXCLUSIVELY LEVI & STRAUSS & CO
DIME SAVINGS BANK F S B
DISNEY STORE THE
E-Z CASUALS
ENERGY FASHIONS
FAMILY PET CENTER

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 1995 (Cont'd)

100
FILENE'S BASEMENT
FOOT LOCKER
GALLERIA ART EXPO INC
GALLERIA INFORMATION & SECURITY
GALLERIA MANAGMNT
GALLERIA OF WHITE PLAINS THE
GALLERIA SECURITY
GAP STORE THE
GATSBY AT THE GALLERIA
GODIVA CHOCOLATIER
GREENJEANS
GYMBOREE-THE STORE
HALLMARK PARTY BASKET
HERMAN'S WORLD OF SPORTING GOODS
HEROES WORLD
HOT WHITE PLAINS COOKIES INC
IDEAL JEWELERS
JEAN'S HALLMARK
JEWEL HUT
JOBEN RALPH LTD
JOHN DAVID LTD
JUST SHIRTS LTD
KAY-BEE TOY & HOBBY SHOP
LANE BRYANT
LEATHER BOUND INC
LECHTERS HOUSEWARES
LERNER'S
LEVI STRAUSS EXCLUSIVE DESIGN
LIMITED THE
MAJOR JEWELERS INC
MC DONALDS
MERRY-GO-ROUND
MR GREENJEANS RESTRNT
MUGS & KISSES INC
MUSICLAND
MY FAVORITE MUFFIN
NATHANS RESTRNT
NATURALIZER SHOES
NINE WEST
OAK TREE
OVER THE COUNTER
OVERLAND TRADING CO
OVERTHECOUNTER INC
PACIFIC SUNWEAR OF CALIFORNIA INC
PANTS PLACE PLUS
PARTY BASKET
PENNEY J C CO INC-PORTRAIT STUDIO
PETITE SOPHISTICATE
PILDES OPTICIANS
PRINTS PLUS

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 1995 (Cont'd)

100 QUINTEX CELLULAR COMMUNICATIONS
R & R GALLERIA
R M HURSH INC
RALPH JOBEN LTD
REVLON INSPIRATIONS
ROSE JEWELRY
SAM GOODY INC
SBARRO INC THE ITALIAN EATERY
SILVER & GOLD CONNECTION
STERNS
STRIDE RITE SHOES
SUNCOAST DISTRICT 310
SUNCOAST MOTION PICTURE CO
SUNCOAST VIDEOS
SUNGLASS HUT
TAILOR'S TOUCH
THINGS REMEMBERED
THIS END UP FURNITURE CO
THOM MCAN SHOE STORE
TREASURE CHEST-CELTIC IMPORTS
TRU-STRIDE SHOE STORE
VALENTI PERFUMERY
VICTORIA'S SECRET
WILD PAIR
WILSON'S SUEDE & LEATHER INC
YOON TRADING CORP

123 BEAR MECHANICAL CO
BOROWICK FELDMAN & GRONER PC, ATTY
BOROWICK, HOWARD R, ATTY
BRAUNSTEIN, LAWRENCE J, ATTY
BRODNICK, ANDREW D, ATTY
DAMAST, ROBERT, ATTY
DANZIGER & MARKHOFF, ATTYS
DANZIGER, JOEL, ATTY
GELFAND, BERTRAM R, ATTY
GRONER, WILLIAM H, ATTY
HODOGAYA CHEMICAL CO LTD
IMPACT MANAGEMENT GROUP INC
KEN'S II CAFETERIA
LANGER, IRA, ATTY
LEVINE, JOSHUA S, ATTY
LONDON & LONDON
LONDON PAUL ESQ
LONDON STEWART
MARKHOFF, HARRIS, ATTY
NEW YORK EMPLOYEE BENEFITS GROUP
NEW YORK POWER AUTHORITY
NYS POWER AUTHORITY-WHITE PLAINSS
R MARK GOODMAN PC
RUBIN, IRWIN, ATTY

123	SHERIDAN, LORETTA A, ATTY AT LAW
	SHERMAN, SCOTT M, ATTY
	STIVERS TEMPORARY PERSONNEL INC
	THOMPSON, RICHARD C, ATTY
	ZUCKERMAN & BRAUNSTEIN, ATTYS
124	BOROWICK, HOWARD R, ATTY
169	AMERICAN EXPRESS-TRAVEL SERVICE OFFICE
	METRO COMPUTER RENTAL INC
	THE NEW COMPUTER FACTORY
171	JON LOUIS SCHOOL OF BEAUTY
173	GELLERMAN, WILLIAM D, OPTMTRST
174	TAYLOR MC CULLOUGH GOLDBERGER GEOGHEAGAN & FRIEDMAN, ATTYS
175	A & A STAFFING HEALTH CARE SERVICES
	A & A STAFFING TEMPORARY PERSONNEL
	A M COURT REPORTING
	A R I
	ABRATOURS INC
	ARONSON ROBERT
	ARONSON ROBERT W, ATTY
	ASAP REPORTING CO INC
	BANNER ABSTRACT CO
	BARONI, ROLAND A, JR, LWYR
	BARRISTER PROPERTIES LTD
	BARRY MCTIERNAN & MOORE, LAWYERS
	BEECHER, ROXANNE, ATTY
	BENEFICIAL NATIONAL LIFE INS CO
	BLASS, HAROLD, ATTY
	BLISS EXTERMINATOR COMPANY-MOUNT VERNON OFFICE
	BLISS EXTERMINATOR COMPANY-NEW ROCHELLE OFFICE
	BLISS EXTERMINATOR COMPANY-PEEKSKILL OFFICE
	BLISS EXTERMINATOR COMPANY-TARRYTOWN OFFICE
	BLISS EXTERMINATOR COMPANY-WHITE PLAINS OFFICE
	BLISS EXTERMINATOR COMPANY-YONKERS OFFICE
	BLISS TERMITE CONTROL DIV OF BLISS EXTERMINATOR COMPANY-MOUN
	BLISS TERMITE CONTROL DIV OF BLISS EXTERMINATOR COMPANY-TARR
	BLISS TERMITE CONTROL DIV OF BLISS EXTERMINATOR COMPANY-WHIT
	BONA, THOMAS M, ATTY
	BROOKS, JILL L, ATTY
	BROWN, GERALD, ATTY
	BUDERWITZ JOSEPH M
	BUSMAN, KENNETH, ATTY
	CALGER, ARTHUR R, ATTY
	CAPUTO, ANTHONY J, ATTY OFC
	CENTRAL TAXI SERVICE CORP
	CHRISS CAREERS LTD
	COOPER, MARVIN A, ATTY
	CORWIN, LEONARD S, ATTY
	COURTHOUSE BARBERS SHOP
	CRIBARI, & FLETCHER, ATTYS
	CRIBARI, ARNOLD D, JR, ATTY

175
CUNARD JANET E, ATTY
DANZIGER, JOYCE, ATTY
DASH TRAVEL & TOURS
DEL NEGRO ARTHUR L, JR, ATTY
DELANEY, THOMAS F, LICENSED PRIVATE INVESTIGATOR
DRESCHER ANN MARIE
DRESDNER, IRWIN, ATTY
EINHORN, SIDNEY, LWYR
EMANUEL, THEBNER
FARRELL LYNN P
FORD, EDWARD L, ATTY
FRIIA, JO ANN, ATTY
GOLDMAN, MARSHALL S, ATTY
GRAYSON, RICHARD E, ATTY
GREENSTEIN, ALLEN, ATTY
GREENSTEIN, SOL D, ATTY
GUIDO & SKWIERSKY, ATTYS
GUIDO, CATHERINE M, ATTY
HERZFELD, ROBERT, ATTY
HIRSCH WALTER JAY & COMPANY, CPAS
HIRSCH, WALTER J, CPA
HIRSCHFIELD, JOS
HOROWITZ, NATHAN, ATTY
HUNT WILDEE CORP
HUNTER, THOMAS G, ATTY
HYMAN, M J, CPA
ISAAC EVELYN K, ATTY
JACOBS, GLORIA S, ATTY
JOHNSON, HAROLD J, ATTY
KAHN & KAHN, ATTYS
KAHN KAHN & SCUTIERI, ATTYS
KAHN, JAMES C, ATTY
KALISH, DANIEL A, ATTY
KAPLAN, ELIOT L, ATTY
KELLY & KMETZ, ATTORNEYS
KELLY, REGINA F, ATTY
KILLERLANE, JAMES J
KOBACK & CHASE, ATTYS
LANGUS, SANDRA, ATTY
LANIGANS
LEWIS, PAMELA, ATTY
LEWIS, STEPHEN R, ATTY
LEWIS, STEPHEN R, LWYR
LICHTENTHAL, JOS A, ATTY
LICHTER, LESTER, ATTY
LOBATO LAW OFFICES
LYNCH, THOMAS J, ATTY
MADAN, JAMES R
MAGNUS, LEE
MANDEL, ROBERT, ATTY

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 1995 (Cont'd)

175

MANNION MARTIN P ASSOCS
MARASCO PETER AGENCY INC
MAROCCO, FRANK, ATTORNEY
MARTIN, LAWRENCE N, JR, ATTY
MCMAHON, JOHN J, ATTY
MEASTER, BARBARA PERDIUE, ATTY
MOROSCO & CUNARD, ATTYS
MOROSCO, B ANTHONY, ATTY
NATL CONF OF CHRISTIANS & JEWS
NORRELL HEALTH CARE INC
NORTHCOURT BLDG
NUIQ SOFTWARE INC
O'BOYLE, J G, INS
ORT
OWL LITIGATION SUPPORT SVCES INC
PERDIUE, BARBARA
PITTORE & ZERN, ATTY
PITTORE, LAWRENCE A, ATTY
POHS MAX S CO, RUBR PRODS
POLICE FRESH AIR FUND INC
PROMOTIONAL MAILING SVCES
Q & A REPORTING SERVICE
RAPID PHOTO
REICH LAWRENCE R
REICH LAWRENCE R PC
REICH REICH & REICH PC
REICH, ROBIN, ATTY
REILLY & LEWIS, ATTY
REILLY, GERALD D, ATTY
REILLY, GERALD D, LWYR
RELLA GERARDA M & ASSOC, ATTY
RELLA GERARDA M, ATTY
RICHARDSON, JOHN WOODWARD
RINALDI & SMALEC, ATTY
RINALDI EDWARD J, ATTY
ROSEN, MARTIN J PC, ATTY
SCUTIERI, JOSEPH A, ATTY
SIRIGNANO, MICHAEL FULLER, ATTY
SKWIERSKY, BARRY J, ATTY
SMALEC & RINALDI
SMALEC MARK, ATTORNEY
SORIANO NICHOLAS M
STAFFING HEALTH CARE SERVICES
STATE FARM INS CO-AGTS
STAUB, BERNARD, CPA
STEPHENS BARONI REILLY & LEWIS, LWYRS
U S A TAXI CORP
VERDES EDW M AND SON INC, RL EST
WATKINS, JOHN E, JR, ATTY
WESTCHESTER LAW JOURNAL

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 1995 (Cont'd)

175	WESTCHESTER SPECIAL SVCES CENTER INC
	WHITE PLAINS CENTRAL TAXI
	WIRTH, JOHN C JR, ATTY
	WLJ PRINTERS
	WOMEN'S AMERICAN ORT
	WOOLEY, JOSEPH E, ATTY
	YALKUT, ARLEN S, ATTY
	ZERN, MARTIN H, ATTY
183	BURTS CUSTOM IMPRINTING
	INNOVATIONS BY OMIGEN
185	ALPHAGRAPHICS PRINTSHOPS OF THE FUTURE
187	MANHATTAN BAGEL
189	ABF DEVELOPMENT CO INC
	CENTER FOR DRIVING OF WESTCHESTER
	EXTENSION TRAVEL AGENCY
	G & R CHECK CASHING
	LA PETITE PATISSERIE
	MUNSON CO THE, SURVYRS
	STAR TAXI
	SUPER TAXI
	WESTERN UNION-TO PICK-UP OR SEND MONEY OR TR-G & R CHECK CAS
199	A TOUCH OF GOLD
	ALAN, M DUBOW, ATTY
	ALVIN PRESS INC
	BAR BUILDING
	BEULAH CLIFF REST
	BLUETT, RAYMOND E, ATTY
	COHLAN, RICHARD M, ATTY
	DISCIULLO, ROBERT J, ATTY
	DUBOW, ALAN M, ATTY
	ESTATES SUPERVISION
	FIECH & RESNICK PC, CPAS
	FIECH, JOS J, CPA
	FOX ADVERTISING SVCE
	GALLAGHER NEWMAN, INS
	GALLAGHER, NEWMAN, INS
	GOULD & WEISSMAN
	GOULD, RICHARD A, ATTY
	GRAY, STANLEY B, ATTY
	GREAT WAY CARS INC
	GREENSTONE, ROBERT FOSTER, ATTY
	HANSBURY, J BRYAN, ATTY
	HECKER, LEONARD D, ATTY
	HEINZMAN JOSEPH C, JR, ATTYS
	HISPANIC COALITION
	HISPANIC COALITION WESTCHESTER
	HOT FREIGHT
	JACOBY & MEYERS LAW OFFICES-LOCAL BRANCH OFFICES-WHITE PLAIN
	JCB REALTY
	JOHNSON, F KEITH, ATTY

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 1995 (Cont'd)

199
KRONICK, ARNOLD S, ATTY
LEHRMAN KRONICK & LEHRMAN
LEHRMAN STEPHEN J & ASSOCIATES INC
LEHRMAN, FREDRIC M
LOGAN, HENRY J, ATTY
MARGER MELTZER & GRAY
MARGER, JEFFREY A, ATTY
MCCARTHY, PETER J, ATTY
MELTZER, ZABATHY E, ATTY
MERRAN, HAROLD, ATTY
ORLOFSKY MANAGMNT CORP
OWL SECURITY & INVESTIGATION SVCES INC
PLACENTE, JOSEPH A
PREMIER TEMPORARY SERVICE INC
REARDON, JUDITH, ATTY
RESNICK, DAVID, CPA
ROBINOWITZ COHLAN & DUBOW, ATTYS
ROBINOWITZ, SEYMOUR, ATTY
S ORLOFSKY
SCANLAN, RICHARD S, ATTY
SEDELMAIER J J PRODUCTIONS INC
SEYMOUR ORLOFSKY INC
SMITH, RUSSELL B, ATTY
SPEISER & HEINZMAN, ATTYS
SPEISER & HEINZMANN
SUBURBAN ST NEWS INC
SUBWAY SANDWICHES & SALADS
SYSTEM MANAGEMENT ARTS
TOUCH OF GOLD
WADLER, IRWIN M DDS PC, OFC
WELLS W WHITFIELD
WESTCHESTER COURT SVCE CO
WESTCHESTER HISPANIC COALITION
WHALEN & WHALEN
WHITFIELD, WARREN WELLS PC

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 1992

50

A D Q INC
ABELSON & ODESSER
ABELSON, RICHARD H
ABELSON, RICHARD H, ATTY
ADVISO GROUP LTD
ALEXIS-GILL ASSOCS
ALLNET COMMUNICATIONS
AMERICAN ASSIGNMENT SVCE CORP
ANDERBERG, EDWARD, BROKER
APPLIED LINGUISTIC THERAPY INST
ART RESOURCE TRADE EXPO
AURNOU, JOEL MARTIN, ATTY
BALINT LAMB & O'NEILL INC
BEECHER SYSTEMS
BELKIN, MARSHALL, ATTY
BELLWEATHER EXPOSITIONS
BENEDICTINE USA CORP
BENEFITS CONSULTING
BEVAN RESOURCES
BRADHURST ASSOC INC
CARIELLO, WILLIAM J, ATTY
CCI TECHNOLOGIES INC
CIAMPI, SAM
CLARKE, BENNETT
CLARKE, LEGAL SVCE PC
COHEN IRENE PERSONNEL INC
COMPUCLEAN INTERNATIONAL
CONNORS, JOHN T, ATTY
CONRAN'S HABITAT
CONTE, ROCCO, ATTY
COPY STOP
DARWIN CAPITAL MANAGMNT INC
DATALAN CORP
DAVIS, WENDELL, JR
DEGROUT CARLUCCI & ASSOCS
DOLLAR DRY DOCK BANK
DOYLE, DENNIS T, ATTY
EAGLE DIRECT MARKETING INC
EISENBERG LAWRENCE J
EMMET MARVIN & MARTIN
ENTWISTLE, DAVID J, ATT
EPSTEIN, MARTIN
FEBBRAIO, GREGG M
FEBBRAIO, GREGG, ATTY
FEBRUARY HOLDING CORP
FEBRYARY HOLDING CORP
FEDERAL DEFENDER SVCES UNIT
FERGUSON, DONALD, ATTY
FIFTY MAIN STREET CORP
FREDA, LEANNE M, ATTY

50

FRIEDMAN & FERGUSON, ATTYS
FRIEDMAN, BERNARD A, ATTY
FUN EXPO
FUNK & TILZER
GEIGER GLENN G CO
GEORGE J MOLLO ASSOC
GOLDEN WEXLER & SARNESE PC
GOOD DAY CAFE
GORDON & SILBER PC
GRAUER, DAVID I, ATTY
GRAY BUNKERING SVCES INC
GREENFIELD EISENBERG STEIN AND SENIOR
GRENDENE OF AMERICA
GRENDHA SHOES
GRIFFITHS & O'CONNELL, ATTYS
GRIFFITHS, DAVID, ATTY
HAAG, HAROLD A, LAW OFC
HAIR TECH
HALE BORENSTEIN LTD
HANIGSBERG STERN & KEISER PC
HARRINGTON SCHOOL OF INSURANCE
HEALTH MONITOR MARKETING
HITACHI CABLE AMERICA INC
INSPECTORATE SAMPLERS & ANYALISTS
INTERCONEX INC
INTERNATIONAL LEADING BRANDS INC
INTERSEARCH CORPORATION OF NY
J M SULLIVAN CO
JAMIESON, LINDA S, ATTY
JARCHO, ARTHUR S, ATTY
JOHNSON CRIS EDWARD, ATTY
JOYCE CO
JOYCE COMPANY
KARDEX SYSTEMS INC
KESTENBAUM GERSHENOFF, CPA
KNOWLEDGE BASED TECHNOLOGIES
KNOX LENT & TUCKER INC
KNOX LENT & TUCKER INC, GENL INS
LEATON & HUPPERLER CO INC
LIBREX COMPUTER SYSTEMS
LOBER, JAMES
LONGLEY COMMUNICATIONS
LOSCO GROUP INC
MADA INTERNATIONAL
MAIN STREET MARKETING
MALEY, PHILIP M, ATTY
MANAGEMENT CONSULTING
MANAGEMENT GRAPHICS
MANPOWER TEMPORARY SERVICES
MARITIME LOGISTIC SVCES INC

50

MARTIN I BLAUSTEIN & CO PC
MATUSOW, NAOMI C, ATTY
MC GUINNESS, EUGENE J, ATTY
MESSING, PHILIP J, CPA
MESSINGER, STANLEY, ATTY
METIER MGMT SYSTEMS INC
METRO COMPUTER RENTAL INC
METROPOLITAN INTERNATIONAL RESOURCES
MICROGRAPHIC TECH CORP
MILLER GRUSKIN ASSOCS
MORAN & ASSOCS
MORIWAKI & MOORE PC
MUTUAL INVESTIGATIVE SVCE INC
NATIONAL CORPORATE SCIENCES INC
NEUBARDT, SAUNDRA, ATTY
NEVILLE, RICHARD M, ATTY
NIPPON ZEON OF AMERICA INC
NORRELL SERVICES
O'NEILL, JOHN I, ATTY
ODESSER, EDWARD H
ODESSER, EDWARD H, ATTY
OKI MICROSYSTEMS
OLESON, RICHARD C, ATTY
OSCAR DYSTEL & PARTNERS INC
OTC AUSTRALIA
OWEN, R CHRISTOPHER, ATTY
PASQUA & ASSOC
PENSION PLAN
PITASSY, RICHARD N, ATTY
PLATINUM STEM & PETALS INC
POWER FORCE
PREFERRED HEALTH STRATEGIES
PRERAU & TEITELL, ATTYS
PRIME OFFICE SYSTEMS INC
PRIVATE BUSINESS EXCHANGE
PRIVATE CAPITAL PARTNERS
PRUDENTIAL SECURITIES INCORPORATED
QUITTMAN, STEPHEN A, PHD
RABON, WILLIS
RANUCCI LINNEA ESQ
REGISTRY FOR NURSES
RESOURCE SCIENCES ASSOCIATES
RIFKIN, ROBERT A, ATTY
ROBERT THOMAS SECURITIES
ROSENBLUM & FILAN, ATTYS
ROSOFF & CARTON PC
ROSOFF, DAVID, ATTY
ROSS, STANLEY A, CPA
ROTH, RONALD, ATTY
SACHTJEN WILBUR M ASSOC INC

50
SARRO, PAULA M
SARRO, PAULA M, ATTY
SEARCH DYNAMICS
SHARP, SAMUEL R, ATTY
SHAVER, ALAN M, ATTY
SMA MANAGEMENT SYSTEMS
SMITH BARNEY HARRIS UPHAM
SMITH BARNEY HARRIS UPHAM & CO INCORPORATED-BRANCH OFFICES
STONEBRIDGE PARTNERS
SYNESIS SYSTEMS
TARGOFF, CHERI K, ATTY
TEITELL, CONRAD, ATTY
TEMPLE, PHILIP T, ATTY
TITLE AMERICA ABSTRACT CORP
TOKYO ZAIRYO CO LTD
TRANSGULF CAPITAL CORP
TUDOR INVESTMENT CORP
TURNER SIDNEY PC, ATTY
VETTER, MATTHEW
WEBER, NEVILLE & SHAVER
WEBER, RICHARD P, ATTY
WEBER, ROBERT
WELBY, THOMAS H, ATTY
WESTCHESTER FINANCIAL CTR
WILLIAM M MERCER INC
XAVIER DEVELOPMENT CORP
XAVIER TRAVEL
XAVIER TRAVEL INC
ZEON MEDICAL CORPORATION
ZUCKER, LEO, ATTY
ZULKOSKI, WALTER, ATTY

81
A N F INC
ABRAMS, DONNA E, ATTY
ACKERMAN, PETER B, ATTY
ALSTHOM TRANSPORTATION
ALTA TECHNOLOGY
AMRAIL INC
ARKIN, MATTHEW D, ATTY
BAKER, LEON C, ATTY
BALABER-STRAUSS, BARBARA, ATTORNEY
BEATON, DANIEL, ENGR
BOWLER, RICHARD J, ATTY
BRADLEY, CHARLES A, ATTY
BRAUNSTEIN, LAWRENCE J, ATTY
BRESS, FRANK A, ATTY
BREWSTER, EVANS V, ATTY
BRINTON & JANUARY, ATTYS
BRINTON, ROBERT L, ATTY
CARTELLI, JAMES A, ATTY
COMER, NEAL, ATTY

81 COSTA, JOSEPH S, ATTY
COTSWOLD MANAGEMENT PARTNERS
DUBAN, MICHAEL C
DUBAN, MICHAEL C, ATTY
ELLENBOGEN GOLDSTEIN & GOODMAN, ATTYS
FACILITIES MANAGMNT CONSULTANTS
FAUST, MARILYN S, ATTY
FIRST AMERICAN TITLE INSURANCE COMPANY OF NEW YORK
FIRST AMERICAN TITLE INSURANCE OF N Y
FISHERMAN, JAY R, ATTY
FREDERICKS, ALFRED D, ATTY
GASH, GARY, ATTY
GOLDBERGER, CHAS A, ATTY
GOODMAN, STANLEY L, ATTY
HAROLD SALANT STRASSFIELD & SPIELBERG, ATTYS
HAROLD, CHRISTOPHER, ATTY
HOCHFELDER & WEININGER, ATTYS
HOCHFELDER, JOHN M, ATTY
INTELLIMED CORP
JANUARY, DERICK C, ATTY
KATZ, RICHARD C, ATTY
KEEGAN KEEGAN & ASSOC PC
KEEGAN, JOHN W, ATTY
KRAMER, MICHAEL A, ATTY
LEBENSON ACTUARIAL SVCS INC
LEWITTES, PAUL M, ATTY
MCCORMICK, ELIZABETH E, ATTY
MCCULLOUGH GOLDBERGER & STAUDT
MCEVOY, ANDREW T, JR
MITSUBISHI KASEI AMERICA INC
MITSUBISHI KASEI AMERICAN INC
PILKINGTON COMMUNICATION SYSTEMS INC
ROSE BEATON & ROSE, ARCHTS & ENGRS
RUMBOLD & BRESS, ATTY
RUMBOLD & BRESS, ATTYS
SALANT, JEFFREY R, ATTY
SERCHUK & ZELERMYER
SILVERBERG, STEVEN M, ATTY
SPIELBERG, LEONARD I, ATTY
STELLATO, ANTHONY
STRASSFIELD, RICHARD J, ATTY
TRANSWAY INTERNATIONAL CORP
WAGNER, MERIKA R, CPA
WEININGER, ROBERT S, ATTY
ZUCKERMAN & BRAUNSTEIN, ATTYS

100 A & S MUSIC & MOVIES
A & S-ALL INQUIRIES
A & S-FLORAL DEPT
A & S-WHITE PLAINS STORE
A I M N Y

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 1992 (Cont'd)

100
ACCESSORY PLACE
ACROPOLIS RESTRNT
ACROPOLIS RESTRNT THE
AD3 JEWELERS
AFTERTHOUGHTS
ANCHOR SAVINGS BANK FSB-WHITE PLAINS OFFICES-GALLERIA BRANCH
ASPASIA AT GALLERIA LTD
ATHLETES FOOT THE
AUGUST MAX WOMEN
BANDER, NORMAN I, DDS
BARNES & NOBLE BOOKSTORES
BOMBAY CO THE
BOUTON'S OF WHITE PLAINS INC
C P I PHOTO FINISH
CAMP BEVERLY HILLS
CAREN, CHARLES
CASUAL CORNER
CHARADE FASHIONS
CHESS KING
CHEZ CHOCOLAT
CHILDREN'S PLACE INC THE
CHOWDERS SEA FOOD
CIGNAL
CINNABON WORLD FAMOUS CINNAMON ROLLS
CLASSY COTTON INC,
COBBIE SHOES OF THE GALLERIA
COBBIE SHOP
CODA
COFFEE BEANERY THE
COMPLETE ATHLETE THE
CONTEMPO CASUALS INC
CRABTREE & EVELYN
D J'S FASHION CENTER FOR MEN
DECOR MARKETING
DESIGNS EXCLUSIVELY LEVI & STRAUSS & CO
EMIGRANT SAVINGS BANK
EXTENSION
FARRINGTON SQ APOTHECARY
FIELD BROTHERS INC
FISHER DEVELOPMENT INC
FOOT LOCKER
FOR LOVERS ONLY
FREE FALL
G & G SHOPS INC
GALLERIA ART EXPO
GALLERIA DENTAL GROUP
GALLERIA INFORMATION & SECURITY
GALLERIA MANAGMNT
GALLERIA OF WHITE PLAINS THE
GALLERIA SECURITY

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 1992 (Cont'd)

100
GAP STORE THE
GARAGE THE
GATSBY CLOTHES INC AT THE GALLERIA
GROSS H L & BROS, JWLRS
GROSS JEWELERS
GYMBOREE-THE STORE
HALLMARK PARTY BASKET
HALLOWEEN HEADQUARTERS
HERMAN'S WORLD OF SPORTING GOODS
HEROES WORLD
IDEAL JEWELERS
J W
JEWEL HUT
JOBEN RALPH LTD
JOHN DAVID LTD
JOYCE-SELBY SHOES
JUST SHIRTS LTD
KAY-BEE TOY & HOBBY SHOP
LANE BRYANT
LE CHATEAU
LEATHER BOUND INC
LECHTERS HOUSEWARES
LERNER'S
LIFETOUCH PORTRAIT STUDIOS INC
LIMITED THE
MAJOR JEWELERS INC
MC DONALDS
MERRY GO ROUND
MOTHERCARE
MR GREENJEANS RESTRNT
MUSICLAND
MY FAVORITE MUFFIN
NATHANS RESTRNT
NATURALIZER SHOES
NATURE PRESERVE
NEENA
NINE WEST
OAK TREE
OOLA CORP
OVER THE COUNTER
OVERLAND TRADING CO
OVERTHECOUNTER INC
PANTS PLACE PLUS
PENNEY J C PORTRAIT STUDIO
PET POURRI
PETITE SOPHISTICATE
PILDES OPTICIANS
PRINTS PLUS
R & R GALLERIA
RALPH JOBEN LTD

100	RAPHAEL CLOTHING
	RAVE
	RESS INSTANT SVCES
	ROSE JEWELRY
	SAM GOODY INC
	SBARRO INC THE ITALIAN EATERY
	SELBY SHOES
	SILVER & GOLD CONNECTION
	SPECIFIC PACIFIC
	STUFF'N TURKEY
	SUNCOAST MOTION PICTURE CO
	SUNGLASS HUT
	T-SHIRTS PLUS
	TACO DON'S
	THINGS REMEMBERED
	THIS END UP FURNITURE CO
	THOM MCAN SHOE STORE
	TIMEMARKET RESEARCH INC
	TREASURE CHEST THE
	TRU-STRIDE SHOE STORE
	VALENTI PERFUMERY
	VICTOR'S COOKIES
	VICTORIA'S SECRET
	WILD PAIR
	WILSON'S SUEDE & LEATHER INC
	YOON TRADING CORP
110	ASSOCIATED DENTAL GROUP
123	A G EDWARDS & SONS INC
	BOYLE, JAMES
	CARDINAL RESOURCES INC
	CENTROPLEX CORP
	COLEMAN, FRANK A
	COLLINS, KEVIN F
	DANZIGER & MARKHOFF, ATTYS
	DANZIGER, JOEL, ATTY
	DERDERIAN, GEORGE M, MAI
	EDWARDS A G & SONS INC
	EURO GLASS GLASREP CORP
	FRIEDMAN, WARREN
	GIULIANO, CAROL
	HANSEN, A A CLIFFORD, ATTY
	HICKEY, MICHAEL J
	IMPACT MANAGEMENT GROUP INC
	LANGER, IRA, ATTY
	LAWLOR, RAYMOND G
	LEVINE, JOSHUA S, ATTY
	LILLING & LILLING
	MAGEE, JAMES A
	MARKHOFF, HARRIS, ATTY
	MARKOFF, HARRIS, ATTY

123 MC LAUGHLIN, JAMES M, JR
NATIONAL ECONOMIC RESEARCH ASSOCIATES
NERA INC
NEW YORK EMPLOYEE BENEFITS GROUP
NEW YORK POWER AUTHORITY
NORTHEAST NETWORKS INC
NYS POWER AUTHORITY-WHITE PLAINS
O'ROURKE, KEVIN G
ODYSSEY MAINTENANCE CORP
PAPPAS COMPANIES
PAPPAS DEVELOPMENT CORP
REYMAN, STUART
ROWE & HANSEN, ATTY
RUBIN, IRWIN, ATTY
SHERMAN, SCOTT M, ATTY
SIMONE O'ROURKE & HICKEY, LAW OFC
STELZER, CITA
STELZER, IRWIN M
STIVERS TEMPORARY PERSONNEL
TECTON GROUP INC
THOMPSON RICHARD C, ESQ
TRIWELL REFINING & MARKETING INC
W P P CORP
ZANABEE'S RESTAURANT
ZULLO, SALLY A

169 AMERICAN EXPRESS-TRAVEL SERVICE OFFICE
THE NEW COMPUTER FACTORY

171 WILFRED BEAUTY ACADEMY

173 GELLERMAN, WILLIAM D, OPTMTRST
MAIN OPTICAL

174 TAYLOR MC CULLOUGH GOLDBERGER GEOGHEAGAN & FRIEDMAN, ATTYS

175 A & A STAFFING HEALTH CARE SERVICES
A & A STAFFING TEMPORARY PERSONNEL
A M COURT REPORTING
ABRATOURS INC
AIRLINE DELIVERY SVCES
BANDON, WILLIAM E, ATTY
BANNER ABSTRACT CO INC
BARONI, ROLAND A, JR, LWYR
BARRETT, MARK G, ATTY
BARRISTER PROPERTIES LTD
BARRY MC TIERNAN & MOORE, LWYRS
BENEFICIAL NATIONAL LIFE INS CO
BLASS, HAROLD, ATTY
BLISS TERMITE CONTROL DIV OF BLISS EXTERMINATOR COMPANY-WHIT
BONA, THOMAS M, ATTY
BROWN, GERALD, ATTY
BUDERWITZ, JOSEPH J, JR, LWYR
BUSMAN, KENNETH, ATTY
CALGER, ARTHUR R, ATTY

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 1992 (Cont'd)

175

CAPUTO, ANTHONY J, ATTY OFC
CENTRAL TAXI SVC CORP
CHRISS CAREERS LTD
COOPER, MARVIN A, ATTY
COURTHOUSE BARBERS SHOP
CRIBARI & FLETCHER, ATTYS
CRIBARI, ARNOLD D, JR, ATTY
CUNARD JANET E, ATTY
D'AMMORA, VICTOR J
DASH TRAVEL & TOURS
DEL NEGRO ARTHUR L, JR, ATTY
DELANEY, THOMAS F, LICENSED PRIVATE INVESTIGATOR
DONOVAN, DANIEL G
DRACHMAN & HELFMAN, ATTYS
DRESCHER ANN MARIE
EINHORN, SIDNEY, LWYR
EMANUEL, THEBNER
ENTREE PERSONNEL SVCES OF WESTCHESTER LTD
ENTREE TEMPORARY SVCES
ENTREE TEMPS
ERRICO, JOS D, ATTY
FAHEY & ISAAC & NEALE, ATTY
FAHEY, WILLIAM, ATTY
FINLEY, JOHN W, JR, ATTY
FORD, EDWARD L, ATTY
FRIIA, JO ANN, ATTY
GEORGE, JOSEPH H
GLADSTONE, DAVID M, ATTY
GOLDMAN, MARSHALL S, ATTY
GREENE, ALISON E, ATTY
GREENSTEIN, ALLEN, ATTY
GREENSTEIN, SOL D, ATTY
GUIDO & SKWIERSKY, ATTYS
GUIDO, CATHERINE M, ATTY
HERRON, CHARLES J, PATENT LAWYERS
HERZFELD, ROBERT, ATTY
HIRSCH, WALTER J, CPA
HIRSH, WALTER JAY, CPA
HODGES, GEORGE S
HOWARD, ROBERT M, LWYR
HUNT WILDEE CORP
HUNTER, THOMAS G, ATTY
HYMAN, M J, CPA
IACONIS, ANTHONY J
ISAAC, EVELYN K, ATTY
JACOBS, GLORIA S, ATTY
JANNACE, JAMES R
JOHNSON, HAROLD, ATTY
KAHN DAVID MILLER & ASSOCS, ATTYS
KAHN, JAMES C, ATTY

175
KAPLAN, ELIOT L, ATTY
KILLERLANE, JAMES J
KOBACK & CHASE, ATTYS
LANGUS, SANDRA, ATTY
LEVINE, LESLIE I, ATTY
LEWIS, DAVID G, ATTY
LEWIS, PAMELA, ATTY
LEWIS, STEPHEN R, ATTY
LICHTENTHAL, JOS A, ATTY
LICHTER, LESTER, ATTY
LYNCH, THOMAS J
LYNCH, THOMAS J, ATTY
MADAN, JAMES R
MANNION MARTIN P ASSOCS
MANNIX, JAS M, JR, ATTY
MARASCO PETER AGENCY INC
MARTIN, LAWRENCE N, JR, ATTY
MASTER MESSENGER INC
MCMAHON, JOHN J, ATTY
MEASTER, BARBARA PERDIUE, ATTY
MOROSCO & CUNARD, ATTYS
MOROSCO, B ANTHONY, ATTY
MRCO CONSTR CORP
MURDOCK, BRIAN S, ATTY
MURPHY PATRICIA A, CPA
NATL CONF OF CHRISTIANS & JEWS
NORRELL HEALTH CARE INC
NORTHCOURT BLDG
NORTHCOURT HOLDING CORP
O'BOYLE, J G, INS
ORT
OWL LITIGATION SUPPORT SVCES INC
PADGETT, FRANCINE R, ATTY
PERDIUE BARBARA E
PITTORE, LAWRENCE A, ATTY
POHS MAX S CO, RUBR PRODS
POLICE FRESH AIR FUND INC
POST REPORTING SVCE
POST, STANLEY C, JR, CT REPRTR
PRUDENTIAL ABSTRACT CO INC
RAGTIME CAFE
RAPAPORT BROTHERS, ATTYS
RAPAPORT M CO INC, RL EST
RAPAPORT, MICHAEL S, ATTY
RAPID PHOTO
REICH, LAWRENCE R PC
REICH, LAWRENCE R, ATTY
REILLY & LEWIS, ATTY
REILLY, GERALD D, ATTY
RICHARDSON, JOHN WOODWARD

175 ROSEN, MARTIN J PC, ATTY
SAMEL, DAVID, ATTY
SIRIGNANO, MICHAEL FULLER, ATTY
SKWIERSKY, BARRY J, ATTY
SMITH, LAWRENCE L T, ATTY
SORIANO NICHOLAS M
STAFFING HEALTH CARE SERVICES
STAFFING TEMPORARY PERSONNEL
STATE FARM INS CO-AGTS
STAUB, BERNARD, CPA
STEPHENS BUDERWITZ & BARONI, LWYRS
STEPHENS, THOMAS J, LWYR
TROETTI J THOMAS, ATTY
U S A TAXI CORP
VERDES EDW M AND SON INC, RL EST
WATKINS, JOHN E, JR, ATTY
WESTCHESTER LAW JOURNAL
WESTCHESTER MULTIPLE LISTING SVCE-HOTLINE
WESTCHESTER SPECIAL SVCES CENTER INC
WESTERN UNION-TO PICK UP OR SEND MONEY TRANS-DASH TRAVEL SVC
WOMEN'S AMERICAN ORT
WOOLEY, JOSEPH E, ATTY
YALKUT, ARLEN S, ATTY
ZERN, MARTIN H, ATTY
176 MARINO CHAMBERS & LOU, ATTYS
183 INNOVATIONS BY OMIGEN HAIR SALON
OMIGEN HAIR SALON
189 ABF DEVELOPMENT CO INC
BONIFAZ, NELLIE
CENTER FOR DRIVING OF WESTCHESTER
G & R CHECK CASHING
LA PETITE PATISSERIE
MAIL BOXES ETC
MORIWAKI & MOORE PC, ATTY'S
MUNSON CO THE, SURVYRS
POST TAXI INC
THE WACKENHUT CORP
WESTERN UNION-TO PICK UP OR SEND MONEY TRANS-WHITE PLAINS SE
199 ALAN, M DUBOW, ATTY
ALVIN PRESS INC
BAR BUILDING
BEISHEIM, GEORGE, JR, ATTY
BEULAH CLIFF REST
BLAKE, DAVID P, CPA
BLASI, PETER F, ATTY
BLUETT, RAYMOND E, POWER LEGAL
BROOKS & O'LOUGHLIN, ATTYS
COHLAN, RICHARD M, ATTY
CONROY, KATHERINE WILSON, LWYR
DIOGUARDI FOR CONGRESS

199 DISCIULLO, ROBERT J, ATTY
DONOHUE & LOCKER, ATTY
DONOHUE, JAMES F, ATTY
ESTATES SUPERVISION
FAY, LAWRENCE F, LWYR
FIECH & RESNICK, CPAS
FIECH, JOS J, CPA
FOX ADVERTISING SVCE
FREEMAN, EDWARD J, LWYR
FREEMAN, GREGORY C, LWYR
GALLAGHER NEWMAN, INS
GALLAGHER, NEWMAN, INS
GOULD & WEISSMAN
GOULD, RICHARD A, ATTY
GRAY, STANLEY B, ATTY
GRAYSON, RICHARD E, ATTY
GREER, WILLIAM JAMES, LWYR
HANSBURY, J BRYAN, ATTY
HAZZARD, ROBERT D, LWYR
HECKER, HYMAN, ATTY
HECKER, LEONARD D, ATTY
HENRY A LEONARD & CO INC
HOWARD GOODMAN INSURANCE
INNCENTIVE PLANNING LTD
JAEGER, OTTO C
JCB REALTY
KALISH, DANIEL A, ATTY
KENT HAZZARD JAEGER FREEMAN GREER & WILSON
KRONICK, ARNOLD S, ATTY
LEHRMAN, FREDRIC M
LEHRMAN, STEPHEN J, ATTY
LOCKER, KINGDON P, ATTY
LOGAN, HENRY J, ATTY
MACHOVER ASSOCS CORP
MARGER MELTZER & GRAY
MARGER, JEFFREY A, ATTY
MCCARTHY, PETER J, ATTY
MELTZER, ZABATHY E, ATTY
MERRAN, HAROLD, ATTY
O'LOUGHLIN, MARK T, ATTY
ORLOFSKY MANAGMNT CORP
OWL SECURITY & INVESTIGATION SVCES INC
PEOPLE FOR DIOGUARDI
PREMIER HEALTH CARE SERVICE
PREMIER PERSONNEL SVCE INC
REARDON, JUDITY, ATTY
REGAL EXEC PLANS LTD
RESNICK, DAVID, CPA
ROBINOWITZ COHLAN & DUBOW, ATTYS
ROBINOWITZ, SEYMOUR, ATTY

Target Street	Cross Street	Source
✓	-	Cole Information

MAIN ST 1992 (Cont'd)

199 S ORLOFSKY
SCANLAN, RICHARD S, ATTY
SEA MANAGMNT CORP
SEDELMAIER J J PRODUCTIONS INC
SEYMOUR ORLOFSKY INC
SMITH, RUSSELL B, ATTY
SUBURBAN ST NEWS INC
SUBWAY SANDWICHES & SALADS
SWEENEY, ANTHONY E, ATTY
WELLS W WHITFIELD
WESTCHESTER COURT SVCE CO
WHELAN, DAVID J, ATTY
WHITFIELD, WARREN WELLS PC
201 WADLER, IRWIN M DDS PC, OFC

Target Street	Cross Street	Source
✔	-	Cole Criss-Cross Directory

MAIN ST 1987



MAIN ST

10606

50 ★ Venex Internatl . . . . H 948-0272
★ Ventrac . . . . . H 948-0551
★ Venture Foods Inc . . H 948-8877
★ Eli Vigliano . . . . . H 682-2006
★ Wstchstr Financial . . 85 948-3233
★ Zobar Management . . 85 761-7663
★ Zobar Mngmnt Corp . . H 761-7663
★ Zoldan Equities . . . . - 761-7663
62 W Taylor . . . . . H 631-6813

10601

81 ★ ABA Technologies . . . 84 682-4980
★ Apex 2 Inc . . . . . - 997-6300
★ L C Baker Aty 85 997-7340
★ D Beaton Engr 85 682-4850
★ Daniel S Berman . . . 85 761-7550
★ Henry S Berman . . . 85 761-7550
★ Milton Berner Aty . . . 761-9500
★ S D Byron Aty 85 761-7550
★ Gerald Cahn Aty . . . 85 761-7550
★ J A Cartelli Aty . . . 85 993-0100
★ Citytrust Spcl Svc . . 85 997-6107
★ The Conroy Co . . . . H 683-8400
★ J S Costa Aty 85 948-4428
★ David A Doern 84 761-4000
★ Ellenbogen&Assoc . . . 85 681-7177
★ P A Feigenbaum Aty . 85 761-7550
★ Fink&Ascs 76 761-7550
★ N A Fredman Aty . . . 85 761-7550
★ S G Fredman Aty . . . 85 761-7550
★ Genrl Elctrc Crdt . . 85 761-9444
★ A R Giodano Aty . . . 85 761-7550
★ Golenbock&Barell . . . 84 761-9500
★ S L Goodman Aty . . . 85 681-7177
★ Intellimed Corp . . . . H 682-7330
★ B M Kauderer Aty . . 85 761-7550
★ J W Keegan Aty . . . 84 949-7227
★ Keegan&Assoc 84 949-7227
★ M E Horelitz Aty . . . 85 761-7550
★ Georgia D Kramr . . . 84 761-9500
★ Lawyer Title 85 682-3900
★ Lebenson Actuarial . . . - 949-4690
★ Jerome T Levy . . . . - 761-7550
★ E E McCormick Aty . . 85 949-7227
★ Mitsubishi Chem . . . 84 761-9450
★ MMA-PCI 85 328-7703
★ Charles J Moos Aty . 85 761-7550
★ Ntl Pension Assoc . . . H 949-4066
★ C M Newman Aty . . . 84 761-7550
★ Perfrmnce Commnctn . 85 328-7700
★ Pripps Inc . . . . . H 683-5566
★ RGB Intl Property . . . 84 683-1418
★ R K Carvill 85 681-0098
★ Realty Decisions . . . 85 949-5552
★ Rose Beaton&Rose . . 85 682-4850
★ W A Rose Engr 85 682-4850
★ W J Rose Jr Archt . . 85 682-4850
★ Rostenberg-Doern . . . 84 761-4000
★ J H Rostenberg 84 761-4000
★ John P Seligman . . . 85 761-7550
★ Barry Singer Aty . . . 85 761-7550
★ Anthony Stellato . . . 85 684-9795
★ TLI Corp 85 946-1141
★ Transway Internat . . . 84 682-7100
★ L W Wagmann Aty . . 84 761-9500
★ Merika R Wagner . . . H 948-7402
★ M Weinberg Aty . . . 85 761-7550
★ Jos.A Weinberger . . 85 761-7550
96 . . . . . NP

19 BROOKFIELD

100 ★ A&S . . . . . - 428-2800
★ A&S . . . . . - 428-2300
★ A&S 85 997-0600
★ Acropolis Restrnt . . . 80 684-8794
★ Acropolis Restrnt . . . 80 328-0313
★ Adler Shoe Shops . . . 80 997-8353
★ Anchor Savings Bnk . . - 682-8080
★ Aspasia At Gallera . . 81 997-8488
★ Athletes Foot 80 761-4440
★ Max August 80 997-7000
★ Australian Opals . . . 83 948-7265
★ Bakers Shoe Store . . 81 997-7787
★ Dr Norman I Bander . . - 428-2052
★ Bank of New York . . . 80 997-8200
★ Barnes&Noble Books . 80 949-1060
★ Bathique 80 682-9418
★ Begg Daigle Inc . . . . H 997-9412
★ Benetton 84 684-0151
★ Benhil Mens Shop . . 80 997-7444
★ Boutons White Pln . . 80 946-8600
★ Butlers Shoe Store . . 83 948-2377
★ CPI Photo Finish . . . H 946-2066
★ Candies Bar 82 683-0965
★ Capezio Shoes 80 997-1150
★ Charles Carem 80 949-1497
★ Casual Corner 80 949-4311
★ Chandlers 80 997-8443
★ Charade Fashions . . . 80 949-5605
★ Chess King 80 684-8322
★ Chez Chocolat 80 997-8191
★ Childrens Place 80 997-8133
★ Chops 80 997-7410
★ Churchs Frd Chicke . . - 946-2307
★ Cignal . . . . . H 682-4113
★ The Clothes Horse . . 82 428-8155
★ Cohens Fashion Opt . . 83 428-0300
★ Colemans Tuxedos . . . 84 328-7241
★ Collectrs Gld Glry . . . H 682-7050
★ Computer Depot Inc . . 85 997-6330
★ Ginny Cotton . . . . . H 681-5147
★ Crab Tree&Evelyn . . . 85 681-0192
★ Creativity 85 684-9211
★ Cristinas 81 684-8510
★ Dj S Fshn For Men . . H 948-7133
★ Daniele Trissi Ltd . . . 80 997-8414
★ Designs Exclusivly . . . 80 997-7010
★ Emigrant Svg Bank . . . 80 948-6262
★ Enclosed Mall Rsrh . . 80 997-7200
★ Engravers Block 80 997-7717
★ Express Ltd . . . . . H 683-5844
★ Farrington Sq Apt . . . 82 681-0340
★ Field Brothers Inc . . . 80 761-8444
★ Jay R Florsheim . . . 81 997-9694
★ Florsheim Shoes . . . 84 997-9694
★ Thayer M Florsheim . . 80 683-9311
★ Fone Gallery Ltd . . . 83 683-6700
★ Foot Locker 84 948-0188
★ For Lovers Only 83 948-2222
★ G&G Shops Inc 80 684-8788
★ Galleria Cinema 80 997-8198
★ Galleria Dental Gr . . . - 428-2052
★ Galleria of Wht Pl . . 80 682-0111
★ The Gap Store 80 997-8118
★ Gatsby Clothers 80 997-8336

© COPYRIGHT INFORMATION ON THIS PAGE
H — New Listing To The Directory - — New Listir

Target Street	Cross Street	Source
✓	-	Cole Criss-Cross Directory

MAIN ST 1987



100 ★ General Nutrition . . . 80 684-8792
★ Genroku Whte Plns . . 81 761-4444
★ Getting Personal . . . 83 428-0476
★ Gilson Uniform Ctr . . 80 997-8340
★ Glass Oven 80 997-8493
★ Golden Egg Roll . . . 80 997-8243
★ Gross Jewelers 80 997-8228
★ H I Gross&Bros 80 997-8228
★ Hallmrk Prty Bskt . . . 80 946-4825
★ Heavenly Heros . . . . H 997-1452
★ Hermans Wld Spt Gd . 80 997-7600
★ Heroes World 80 946-8881
★ Hickory Farms 81 761-0749
★ Hoffritz Cutlery 80 997-7717
★ I-Natural Cosmetcs . . 81 428-9648
★ Ingenuities 83 682-9563
★ Jacobson Bros 81 997-8110
★ Ralph Joben Ltd . . . 81 997-8418
★ Josuedibles Inc . . . . H 993-0481
★ Hoyce-Selby Shoes . . 80 997-0242
★ Just Shirts Ltd 83 946-4102
★ Kappa Sport 84 328-0928
★ Kay-Bee Toy&Hobby . 80 948-6686
★ Kay Jewelers 80 997-8240
★ Kinney Shoe Corp . . . 80 948-2124
★ Koenig Art Emporm . . 82 997-1998
★ La Baguette Gllria . . . H 948-1780
★ Lane Bryant 85 681-0337
★ J P Laurens 80 997-0800
★ Lechateau . . . . . H 761-1751
★ Leather Bound Inc . . 80 997-8111
★ Lechters Housewars . . 80 684-8323
★ Lerners 80 761-6986
★ Liberty Trvl Retl . . . 83 997-7800
★ Lifetouch Portrait . . . 81 761-1265
★ The Limited 80 997-8272
★ Lodge At Harvrd Sq . 80 997-8252
★ Mall Foods Inc 80 949-4434
★ Margaritaville . . . . . H 997-1110
★ McDonalds 85 946-7156
★ Mr Greenjeans Rest . 80 997-8122
★ Mothercare 80 997-0690
★ Musicland 80 997-8344
★ Naturalizer Shoes . . . 80 997-8445
★ Neena 82 997-8331
★ Nine West 84 946-1510
★ Oakleys Amer Rest . . 80 949-2100
★ Over The Counter . . . 80 997-8280
★ Overland Tradng Co . . 82 428-1994
★ Overthecounter Inc . . 80 997-8280
★ Pants Place Plus . . . 80 948-0090
★ Park Lane Hosiery . . 80 997-8363
★ Pasta . . . . . H 993-0835
★ Pastrami Delight . . . 82 428-8788
★ J C Penney Co Inc . . 84 997-1700
★ J C Penney Co Inc . . 84 328-0607
★ J C Penney Co Inc . . 84 328-0919
★ J C Penney Co Inc . . 84 761-1265
★ Pennington Du Cnda . 80 946-5511
★ Pet Pourri 80 997-0255
★ Petite Sophisticte . . . H 946-1144
★ Phone Gallery Ltd . . . 83 683-6700
★ Pildes Opticians 80 997-7416
★ Pipe&Bowl 80 761-0180
★ Pretty Posies Flrs . . . 80 997-8282
★ Quik-Snax Inc 82 946-3676
★ Radio Shack 85 997-7157
★ Radio Shack 85 997-7141
★ Joben Ralph Ltd . . . 81 997-8418
★ Raphael Clothing . . . 81 946-6100
★ Red Cross Shoes . . . 80 997-8110
★ Ress Instant Svcs . . . 85 428-3658
★ S Hecht&Sons Inc . . . H 683-6411
★ Sam Goody Inc 80 997-8383
★ Sbarro 80 997-8474
★ Scandnvn Dsgn&Gly . 80 997-8262
★ Selby Shoes 81 997-0242
★ The Singer Co 81 682-0595
★ Suzette Lingerie . . . 80 997-8355
★ T Shirts Plus Inc . . . 80 761-6613
★ Taco Dons 80 997-8360
★ The Hair Designers . . 85 682-4727
★ Things Remembered . . H 997-0595
★ This End Up Furn . . . 82 761-4308
★ Thom McAn 80 684-8791
★ Thom McAn Store . . . 80 681-0263
★ Tru-Stride Shoe . . . 85 948-0777
★ Unique Boutique . . . 81 997-8100
★ Ups&Downs . . . . . - 946-3192
★ Victorias Secret 85 949-5037
★ Victors Cookies 82 684-8687
★ Video Concepts 84 997-7703
★ Waldenbrooks 82 997-8150
★ Wild Pair 80 997-9680
★ Yoon Trading Corp . . 83 328-9739
110 ★ Assoc Dental Group . . - 428-2052
111 ★ NY Telephone Co . . . 81 682-8960
★ NY Tel Co 81 949-2295
★ NY Tel Co 81 949-8464
★ NY Telephone Co . . . 81 997-7149
★ NY Telephone 81 390-2755
★ NY Telephone Co . . . 81 949-5264
★ NY Tel Co 85 949-6543
114 . . . . . NP

SPRING

123 ★ Richard P Ackerman . 82 948-1556
★ Atlantic Maritime . . . 82 949-4141
★ Bsl Gift Shoppe . . . . H 682-0814
★ The Bank of New Yk . 83 899-6000
★ L L Barnes Lyr 84 949-2700
★ H Barrett'lii Lyr 83 949-2700
★ J Robert Bleakley . . . 82 949-2700
★ Bleakley Platt&Asc . . 82 949-2700
★ Bleakley Schmidt . . . 82 949-2700
★ James Boyle 82 946-2510
★ Centroplex Corp 82 948-6600
★ M A Chambers Aty . . 83 997-1380
★ Churcham Co 80 682-8838
★ Citibank N A 83 332-1700
★ Coronado Oil&Gas . . . 84 946-2510
★ J C Couzens Jr 82 949-2700
★ Danziger&Markhoff . . 82 948-1556
★ Digital Graphic 84 683-5588
★ Euro Glass Glasrep . . 83 683-1390
★ J J Ferghuson Aty . . . H 949-2700
★ Hugh D Fyfe Lyr . . . 82 949-2700
★ J P Glatthaar Aty . . 85 949-2700
★ M Greenspan Lyr . . . 82 684-0600
★ A A C Hansen Aty . . 82 949-4144
★ W F Harrington 82 949-2700
★ W P Harrington 84 949-2700
★ D J Harris Aty 82 949-2700
★ E F Hutton&Co 84 682-3800
★ Danziger Joel Aty . . . 82 948-1556
★ Kidder Peabody&Co . . . 82 948-7300

MAY NOT BE KEY PUNCHED ENTERED INTO A COMPUT
g To The Street ★ — Business Listing CT — Census Trac

Target Street	Cross Street	Source
✔	-	Cole Criss-Cross Directory

MAIN ST 1982

MAIN ST 10606
White Plains PO
1- 56 TZ 92 $D..N 4
57- 317 TZ 93 $E..N 4
318- 399 TZ 94 $D..N 4
400- 448 TZ 88 $D..N 3
480- END TZ 87 $C..M 3
072740
1 CENTRAL AV
1★Bonanza Bus Lines 428-1683
★Contintl Trlwy Bus 949-2342
★Greyhound Bus Line ... 428-1683
★Trailways Bus Sys 949-2342
★White Plains Bus 949-2342
★Whi Plns Bus Ctr 428-1683
1 ORAWAUPUM AV
..... 10601
96 .....NP
19 BROOKFIELD
100★Abraham&Straus .....¤ 428-2800
★Abraham&Straus .....¤ 428-2300
★Abraham&Straus .....¤ 997-0600
★Acropolis Restrnt .....¤ 946-9863
★Acropolis Restrnt .....¤ 948-5623
★Adler Shoe Shops .....¤ 997-8353
★Athleisure .....¤ 997-8266
★Athletes Foot .....– 761-4440
★Max August .....¤ 997-7000
★Baldwin Piano&Orgn ....– 948-7100
★Bank of New York .....– 997-8200
★Barnes&Noble Book ....¤ 949-1060
★Bathique .....¤ 997-9682
★Benhil Mens Shop .....¤ 997-7444
★Boutons White Pln .....¤ 946-8600
★Capezio Shoes .....¤ 997-1150
★Charles Caren .....¤ 949-1497
★Casual Corner .....¤ 949-4311
★Chandlers .....¤ 997-8443
★Charade Fashions .....¤ 949-5605
★Chess King .....¤ 946-9823
★Chez Chocolat .....¤ 997-8191
★Childrens Place .....¤ 997-8133
★Chocolate Chocalat ....¤ 997-7211
★Chops .....¤ 997-7410
★Cinnabar 2000 Hair ....¤ 997-7161
★Cohens Fshn Optici ....¤ 428-0300
★Command Performnce ...¤ 949-5873
★Craft Showcase .....¤ 948-1800
★Daniele Trissi Ltd .....¤ 997-8414
★Designs Exclusivly .....¤ 997-7010
★Eiderdown Shop .....¤ 997-8322
★Emigrant Svg Bank ....¤ 948-6262
★Enclosed Mall Rsrh ....¤ 997-7200
★Engravers Block .....¤ 997-7717
★Evyan Jewelers Ltd ....¤ 997-8100
★Fantasia .....¤ 946-2000
★Field Brothers Inc .....¤ 761-8444
★Florsheim&Assocts .....¤ 946-9874
★Franklin Mint Glry .....¤ 997-8131
★G&G Shops Inc .....¤ 946-9853
★Galleria Cinema .....¤ 997-8198
★Galleria of Wht Pl .....¤ 682-0111
★Galleria Photo Ctr ....¤ 997-0333
★Galleria Singer .....¤ 949-3377
★The Gap Store .....¤ 997-8118
★Gatsby Clothers .....¤ 997-8336
★General Nutrition .....¤ 946-9858
★Teh General Store .....¤ 997-8181
★Gift Box .....¤ 428-7200
★Gilson Uniform Ctr ....¤ 997-8340
★Glass Oven .....¤ 428-8878
★Golden Egg Roll .....¤ 997-8243
★Gross Jewelers .....¤ 997-8228
★H L Gross&Bros .....¤ 997-8228
★Hallmrk Prty Bskt ....¤ 946-4825
★Hermans Wld Spt Gd ...¤ 997-7600
★Hermans Wrld Sprt ....¤ 997-7600
★Heroes World .....¤ 946-8881
★Hoffritz Cutlery .....¤ 997-7717
★Hoyce-Selby Shoes ....¤ 997-0242
★Just Pants .....¤ 428-7469
★Kay-Bee Toy&Hobby ....¤ 948-6686
★Kay Jewelers .....¤ 997-8240
★King Potatoe Rstnt ....¤ 997-8440
★Kinney Shoe Corp .....¤ 948-2277
★Krishna .....¤ 997-8329
★Lady Madonna .....¤ 946-5666
★J B Laurens .....¤ 997-0800
★Leather Bound Inc .....¤ 997-8111
★Lechters Housewars ....¤ 997-7475
★Lerners .....¤ 761-3305
★Liberty Travel .....¤ 997-7800
★The Limited .....¤ 997-8272
★Lodge At Harvrd Sq ...¤ 997-8252
★The Magic Pan .....¤ 997-8144
★Mall Foods Inc .....¤ 949-4434
★Mr Greenjeans Rest ....¤ 997-8122
★Monacos Coll Chowc ...¤ 997-7711
★Mothercare .....¤ 997-0890
★Musicland .....¤ 997-8344
★Naturalizer Shoes .....¤ 946-9824
★Nizza .....¤ 997-8343
★Oakleys Amer Rest ....¤ 949-2100
★Over The Counter .....¤ 997-8280
★Overthecounter Inc ....¤ 997-8280
★Palm Court Restrnt ....¤ 997-8222
★Pants Place Plus .....¤ 946-9854
★Pants Place Plus .....¤ 948-0090
★Papco Apparel Inc .....¤ 997-7410
★Pappagallo Shop .....¤ 761-5250
★Park Lane Hosiery .....¤ 997-8363
★Pennington Du Cnda ...– 946-5511
★Pet Pourri .....¤ 997-0255
★Pet Pourri Photo .....¤ 997-1210
★Photo Ctr Galleria .....¤ 997-0333
★Pildes Opticians .....¤ 997-7416
★Pipe&Bowl Galleria .....¤ 761-5217
★Pretty Posies Firs .....¤ 997-8282
★Printways .....¤ 949-5210
★Proving Ground .....¤ 946-9856
★Radio Shack Tandy ....¤ 997-7141
★Red Cross Shoes .....– 997-8110
★Regal Shoe Shop .....¤ 949-5755
★Sam Goody Inc .....¤ 997-8383
★Sbarro .....¤ 997-8474
★Scandnvn Dsgn&Gly ....¤ 997-8262
★Scholar's Choice .....¤ 997-8350
★Shelby Shoes .....¤ 997-0242
★Spectrum .....¤ 997-8329
★Stride Rite Shoe S ....¤ 948-0777
★Suzette Lingerie .....¤ 997-8355
★T Shirts Plus Inc .....¤ 761-6813
Y NOT BE KEY PUNCHED, ENTERED INTO A COMPUTER OR P
ing to that Street ★ — Business Listing TZ — Trading Zone

Target Street	Cross Street	Source
✓	-	Cole Criss-Cross Directory

MAIN ST 1982

100	★Taco Dons	997-8360
	★Tano Retail Outlet	949-6900
	★Thom McAn	946-9857
	★Ups&Downs	946-9855
	★Uttals Luggage	428-4434
	★Video Concepts	997-7703
	★Waldenbrooks	997-8150
	★White Plns Gift	428-7200
	★White Plns Photo	997-0333
	★Wild Pair	997-9680
	★Windsor Cntrft Jwl	761-0010
111	★S Allan Garge Door	948-5665
	★P Bratti Assoc	761-7244
	Lundberg W Haines	946-6575
	★Lawn Scape America	946-3538
	★Trim-Line Tarrytwn	948-6300
114	NP	
	SPRING	
123	★Wachtel&Assocs	946-0807
154	★Carpenters Locl 53	948-8918
	1 GRAND	
	1 WILLIAM	
169	★Lincoln Lite Wchtr	948-2525
171	★QBI Hair Fashn	948-3700
	★Queens Bty Inst	948-3700
	★Wilfred Academy	948-3700
173	★Dr W D Gellerman	949-7933
	★Main Optical	949-7933

Target Street	Cross Street	Source
✓	-	Cole Criss-Cross Directory

MAIN ST 1977



MAIN ST 10601
White Plains PO

1- 56 TZ 92 SD..N 4
57- 317 TZ 93 SE..N 4
318- 399 TZ 94 SD..N 4
400- 448 TZ 88 SD..N 3
480- END TZ 87 SC..M 3

1 CENTRAL AV
1 ★ Contintl Trlwy Bus 949-2342
★ Greyhound Bus Line 428-1683
★ Trailways Bus Sys 949-2342
★ White Plns Bus Ctr 428-1683

1 ORAWAUPUM AV
96 NP

19 BROOKFIELD
114 NP

SPRING
154 ★ Carpenters Locl 53 948-8918

1 GRAND

1 WILLIAM
166 ★ County Court House
169 ★ Lincoln Lite Wchtr 948-2525
171 ★ Qbi Hair Fashn WH8-3700
★ Queens Bty Inst WH8-3700
★ Wilfred Academy WH8-3700
173 ★ Dr W D Gellerman 949-7933
★ Main Optical 949-7933

Target Street	Cross Street	Source
✓	-	Cole Criss-Cross Directory

MAIN ST 1972



```
MAIN ST                                  10606
.....................................
      WHITE PLAINS PO
...     1-   56 T   92    $D..N 4
...    57-  317 T   93    $D..N 4
...   318-  399 T   94    $D..N 4
...   400-  445 T   88    $D..N 3
...   486-  END T   87    $C..M 3
FT OF*FARKAS&ASSOCTS      -9460995
     *GIRONDO&LEARMONT    ¤9460997
  ..  1 CENTRAL AV          ..
   1 KENNETH COOMBS    0  7610440
     *GREYHOUND BUS LINE   4288787
     *TRAILWAYS BUS SYS    WH96343
     *WHITE PLAINS BUS     9482000
  17*A R STEVENSEEN        RO12000
  29*WILLIAMS HTG ENGRS    WH66655
  45*MAJESTIC GRILL        9489605
  ..  1 ORAWAUPUM           ..
  ..  AV                    ..

      ..................     10601
  81*PHOTGRPHY BY SPNCR    4281380
  96                  NP
  ..  19 BROOKFIELD         ..
  98*REV R W GULLETTE       WH86372
     *MT HOPE AME ZION      9462668
     *MT HOPE AME ZION      9469630
 114                  NP
  ..  SPRING                ..
 117*WHITE PLAINS JUDO     RO19690
 120*WHITE PLAINS URBN     4281300
 149*CALLAN FURN W PLNS    9466838
     *CALLON FURN W PLNS    WH96060
 150*BROADWAY ARPRT SRV    9467555
     *BROADWAY TAXI         9483100
     *CLOVER DO-NUT CORP    WH89392
     *HOUSE TAXI            9467555
 154*CARPENTERS LOCL 53    9488918
     *DOUGLAS SHOES         WH95506
     *FOAM RUBBER CO       -9494384
     *ELI A HOWARD ATTY    -9494384
     *MAIN GRV TOBACCO      9489713
     *RICHMAN SHOES INC     WH95506
     *WHITE PLAINS FURN    -9494384
 155*WCHSTR COTTON STOR    WH93289
 157*PATERSON DECORATRS    9494112
     *PATERSON SILK STRS    9494112
     *H SHAPIRO INS         9494112
     *JACOB SHAPIRO         9494112
 158*KERMAN SHOPS LDS      9498474
```

Target Street	Cross Street	Source
✓	-	Polk's City Directory

MAIN ST 1965

80 White Plains Furniture Mattress Co Inc WH9-4384
Teca Corp mfr electronic equip WH6-4593
81 Feiner David dentist WH8-8072
Apollo Beauty Salon WH8-0568
Shay Dick Shoes WH9-5226
Mutual Readers League of New York RO1-2810
Apartments;
4 Asselin Peter F WH8-0436
5 Vitro Thos
6 Longo Anthony C RO1-0726
7 Ferrando Vincent WH8-2566
8 Irving Everett A WH6-7144
9 Sloane Frank H WH6-5039
10 Saiz Ysidro WH6-0239
11 Spencer Ann V Mrs WH6-2861
12 Marano Isabel Mrs WH6-3963
83 O K Shop women's clo WH9-3628
84 Learners Men's Shop WH6-4528
85 Vogt's Pharmacy Inc WH9-0220
Thomas Ann Mrs WH6-0229
Jorgenson Margrethe I WH8-5112
DeLeo Nicholas J WH9-8897
86 New Franklyn Cotton Shop Inc (br) women's apparel WH8-2943
87 Day Surplus RO1-9537
88 Vacant
89 LeBow Sam Jeweler WH9-3272
90 NuWay Cleaners Inc WH9-2333
91 Silverstein Fred Optom WH9-6001
Lilyan's Hat Shop WH8-3390
rear Haskins Nelson S WH6-8695
Turner Grace WH6-3889
Riddick ChasA WA9-7192
Billie Jervilene Mrs WH6-4612
Sherman Sam WH8-0617
92 Vacant
93 Westchester Beef Co WH6-7161

Target Street	Cross Street	Source
✓	-	Polk's City Directory

MAIN ST 1965

MAIN--Contd
95 Dinten's Specialty Shop women's apparel WH9-6585
Boss Record Shop WH6-0482
96 MtHope AME Zion Ch WH8-6372
96 Bristol Frances WH9-7406
NO. 2 TEXT
Brookfield begins
97 Schirmer's Bakery WH9-1214
Fendler Robt WH9-1214
99 Busy Bee Fruiterers Delicatessen Inc WH9-9577
99 Paloscio Fortunato WH8-2520
Hondtke Roman RO1-4058
101 Amex Post 532 VFW WH8-9695
102 Ray's Emp Agcy WH8-4545
Gellerman Wm D WH9-7933
Fenton Eric WH8-1758
Lexington Woodcraft WH9-2005
103 Lido Pizza restr RO1-9668
104 County Piano Co WH9-4685
105 Vacant store
106 Paterson Silk Stores (whse)
109 Joes Thrift Store RO1-5939
110 Stanton Radio & Elec Co WH9-8070
112 Wynne School of Beauty Culture WH9-6856
112 Daddy Michaels Quarter House restr RO1-3780
Spring crosses
114 Burger John Inc furs WH8-2600
115 Paterson Silk Stores Inc WH9-4112
Phyllis Luncheonette RO1-4599
Spring begins
116 Bowman's Flower Shop WH9-0792
117 School of Self Defense RO1-9690
SYL-Ru Photo Studio WH9-7094
119 SYl-Ru Photo Studio WH9-7094
120 NY State Dept of Mtr Vehicles RO1-4700
121 Richmand Shoes Inc WH9-5506
122 **Dreyer Building**
Strom Office Equip Co Inc WH9-1881
123 D&L Produce Co fruits and vegetables WH6-3446
124 County Trust Co (collection ofc) WH6-4000
125 Sam's Discount Army & Navy Store 948-0423

Target Street	Cross Street	Source
✓	-	Polk's City Directory

MAIN ST 1963

83 O K Shop women's clo WH9-3628
84 Vacant
85 Vogt's Pharmacy Inc WH9-0220
Thomas Ann Mrs WH6-0229
Jorgenson Margrethe I WH8-5112
DeLeo Nicholas J WH9-8897
86 New Franklyn Cotton Shop Inc (br)
women's apparel WH8-2943
87 Kent clns
88 Peter's Luncheonette WH6-9724
89 LeBow Sam Jeweler WH9-3272
90 NuWay Cleaners Inc WH9-2333
91 Silverstein Fred optom WH9-6001
Lilyan's Hat Shop WH8-3390
rear Haskins Nelson S WH6-8685
Turner Grace WH6-3889
Riddick Chas A WA9-7192
Billie Jervilene Mrs WH6-4612
92 Sonotone Corp (White Plains Plant)
hearing aids WH8-4433
93 Westchester Beff Co WH6-7161
95 Dinten's Specialty Shop women's
apparel WH9-6585
Boss Record Shop WH6-0482
96 Mt Hope AME Zion Ch WH8-6372
Gullette Ralph W Rev
Brookfield begins
97 Schirmer's Bakery WH9-1214
Fendler Robt WH9-1214

Target Street	Cross Street	Source
✓	-	Polk's City Directory

MAIN ST 1963

MAIN—Contd
99 Busy Bee Fruiterers Delicatessen Inc WH9-9577
101 Green H L Co Inc (br) dept store WH9-2631
102 Ray's Emp Agcy WH8-4545
Main Optical optom WH9-7933
103 Lido Pizza restr RO1-9660
104 County Piano Co WH9-4685
105 Vacant store
106 Paterson Silk Stores (whse)
109 Champion Furs
110 Stanton Radio & Elec Co WH9-8070
112 Wynne School of Beauty Culture WH9-6856
Babes Auto Stores Inc

Spring crosses

114 Burger John Inc furs WH8-2600
115 Paterson Silk Stores Inc WH9-4112
Phyllis Luncheonette RO1-4599

Spring begins

116 Bowman's Flower Shop WH9-0792
A A A Answering & Office Service Inc WH9-7444
County Signs WH6-6888
Drummond Alonzo J lwyr
Rochester Bldg & Realty Co WH6-3063
Dale Carnegie Courses WH9-1717
County Trust (Loan Collection ofc)

Wall begins

117 Hales Fashions women's clo WH8-9588
119 Syl-Ru Photo Studio
120 NY State Dept of Mtr Vehicles RO1-4700
121 Richmand Shoes Inc WH9-5506
122 **Dreyer Bldg**
Strom Office Equip Co Inc WH9-1881
123 D&L Produce Co fruits and vegetables WH6-3446
125 Spring Wines & Liquors WH9-7004

100 Main Street
100 Main Street
White Plains, NY 10601

Inquiry Number: 7906442.2s
February 24, 2025

The EDR Radius Map™ Report with GeoCheck®

6 Armstrong Road, 4th floor
Shelton, CT 06484
Toll Free: 800.352.0050
www.edrnet.com

TABLE OF CONTENTS

SECTION	PAGE
Executive Summary	ES1
Overview Map	2
Detail Map	3
Map Findings Summary	4
Map Findings	9
Orphan Summary	1598
Government Records Searched/Data Currency Tracking	GR-1

GEOCHECK ADDENDUM

Physical Setting Source Addendum	A-1
Physical Setting Source Summary	A-2
Physical Setting SSURGO Soil Map	A-5
Physical Setting Source Map	A-9
Physical Setting Source Map Findings	A-11
Physical Setting Source Records Searched	PSGR-1

Thank you for your business.
Please contact EDR at 1-800-352-0050
with any questions or comments.

Disclaimer - Copyright and Trademark Notice

This Report contains certain information obtained from a variety of public and other sources reasonably available to Environmental Data Resources, LLC. It cannot be concluded from this Report that coverage information for the target and surrounding properties does not exist from other sources. This Report is provided on an "AS IS", "AS AVAILABLE" basis. **NO WARRANTY EXPRESS OR IMPLIED IS MADE WHATSOEVER IN CONNECTION WITH THIS REPORT. ENVIRONMENTAL DATA RESOURCES, LLC AND ITS SUBSIDIARIES, AFFILIATES AND THIRD PARTY SUPPLIERS DISCLAIM ALL WARRANTIES, OF ANY KIND OR NATURE, EXPRESS OR IMPLIED, ARISING OUT OF OR RELATED TO THIS REPORT OR ANY OF THE DATA AND INFORMATION PROVIDED IN THIS REPORT, INCLUDING WITHOUT LIMITATION, ANY WARRANTIES REGARDING ACCURACY, QUALITY, CORRECTNESS, COMPLETENESS, COMPREHENSIVENESS, SUITABILITY, MERCHANTABILITY, FITNESS FOR A PARTICULAR PURPOSE, TITLE, NON-INFRINGEMENT, MISAPPROPRIATION, OR OTHERWISE. ALL RISK IS ASSUMED BY THE USER. IN NO EVENT SHALL ENVIRONMENTAL DATA RESOURCES, LLC OR ITS SUBSIDIARIES, AFFILIATES OR THIRD PARTY SUPPLIERS BE LIABLE TO ANYONE FOR ANY DIRECT, INCIDENTAL, INDIRECT, SPECIAL, CONSEQUENTIAL OR OTHER DAMAGES OF ANY TYPE OR KIND (INCLUDING BUT NOT LIMITED TO LOSS OF PROFITS, LOSS OF USE, OR LOSS OF DATA) INFORMATION PROVIDED IN THIS REPORT.** Any analyses, estimates, ratings, environmental risk levels, or risk codes provided in this Report are provided for illustrative purposes only, and are not intended to provide, nor should they be interpreted as providing any facts regarding, or prediction or forecast of, any environmental risk for any property. Only an assessment performed by a qualified environmental professional can provide findings, opinions or conclusions regarding the environmental risk or conditions in, on or at any property.

Copyright 2025 by Environmental Data Resources, LLC. All rights reserved. Reproduction in any media or format, in whole or in part, of any report or map of Environmental Data Resources, LLC, or its affiliates, is prohibited without prior written permission.

EDR and its logos (including Sanborn and Sanborn Map) are trademarks of Environmental Data Resources, LLC or its affiliates. All other trademarks used herein are the property of their respective owners.

EXECUTIVE SUMMARY

A search of available environmental records was conducted by Environmental Data Resources, Inc (EDR). The report was designed to assist parties seeking to meet the search requirements of EPA's Standards and Practices for All Appropriate Inquiries (40 CFR Part 312), the ASTM Standard Practice for Environmental Site Assessments (E1527 - 21), the ASTM Standard Practice for Environmental Site Assessments for Forestland or Rural Property (E2247 - 16), the ASTM Standard Practice for Limited Environmental Due Diligence: Transaction Screen Process (E1528 - 22) or custom requirements developed for the evaluation of environmental risk associated with a parcel of real estate.

TARGET PROPERTY INFORMATION

ADDRESS

100 MAIN STREET
WHITE PLAINS, NY 10601

COORDINATES

Latitude (North):	41.0316400 - 41° 1' 53.90''
Longitude (West):	73.7707970 - 73° 46' 14.86''
Universal Tranverse Mercator:	Zone 18
UTM X (Meters):	603332.3
UTM Y (Meters):	4542785.0
Elevation:	197 ft. above sea level

USGS TOPOGRAPHIC MAP ASSOCIATED WITH TARGET PROPERTY

Target Property Map:	14142197 WHITE PLAINS, NY
Version Date:	2019
Northeast Map:	20023960 GLENVILLE, CT
Version Date:	2021

AERIAL PHOTOGRAPHY IN THIS REPORT

Portions of Photo from:	20190811
Source:	USDA

MAPPED SITES SUMMARY

Target Property Address:
100 MAIN STREET
WHITE PLAINS, NY 10601

Click on Map ID to see full detail.

MAP ID	SITE NAME	ADDRESS	DATABASE ACRONYMS	RELATIVE ELEVATION	DIST (ft. & mi.) DIRECTION
A1		100 MAIN ST	MI MANIFEST		TP
A2	MACYS WHITE PLAINS C	100 MAIN ST	FINDS, ECHO		TP
A3	J C PENNEY CO INC	100 MAIN ST	RCRA NonGen / NLR, FINDS, ECHO, E MANIFEST		TP
A4		100 E. MAIN ST	NY COOLING TOWERS		TP
A5	GALLERIA MALL DENTAL	100 MAIN STREET	E MANIFEST		TP
A6	JC PENNEY	100 MAIN ST.	NY UST		TP
A7	SEARS ROEBUCK & CO.	100 MAIN STREET	RCRA-VSQG, E MANIFEST		TP
A8	C P I PHOTO FINISH	100 MAIN ST STE 301	RCRA NonGen / NLR, FINDS, ECHO		TP
A9	PICTURE PEOPLE THE	100 MAIN ST SPACE 32	RCRA-SQG, FINDS, ECHO, NY MANIFEST		TP
A10		100 MAIN STREET	NY COOLING TOWERS		TP
A11		100 MAIN STREET	NY COOLING TOWERS		TP
A12	J.C. PENNEY	100 MAIN ST	NY UST		TP
A13	LENSCRAFTERS #0787	100 MAIN ST	E MANIFEST		TP
A14	J C PENNEY CO INC	100 MAIN ST	NY LTANKS, NY Spills, RCRA NonGen / NLR, NY...		TP
A15		100 E. MAIN ST	NY COOLING TOWERS		TP
A16	GALLERIA OF WHITE PL	100 MAIN STREET	FINDS		TP
A17	SEARS	100 MAIN ST	E MANIFEST		TP
A18	EXPRESSLY PORTRAITS	100 MAIN ST - GALLER	RCRA NonGen / NLR, FINDS, ECHO, NY MANIFEST		TP
A19	MACY'S EAST #55	100 MAIN ST	NY MANIFEST		TP
A20	MACYS - WHITE PLAINS	100 MAIN ST	FINDS, ECHO		TP
A21	THE GALLERIA AT WHIT	100 MAIN STREET	NY UST		TP
A22	BISCARDI FRANK	102 MAIN ST	EDR Hist Cleaner	Higher	1 ft.
A23	BAYLISS MORRIS	90 MAIN ST	EDR Hist Cleaner	Higher	1 ft.
B24	VAULT #0070	MAIN ST & GROVE ST	NY Spills	Lower	15, 0.003, ENE
B25	CON EDISON MANHOLE 9	MAIN ST & MARTIN LUT	RCRA NonGen / NLR	Lower	15, 0.003, ENE
B26	WHITE PLAINS GARAGE	MAIN ST & GROVE ST	NY Spills	Lower	15, 0.003, ENE
A27	NYNEX	111 MAIN ST	UST FINDER RELEASE	Lower	31, 0.006, NNE
A28	NYNEX	111 MAIN ST	NY LTANKS, NY Spills	Lower	31, 0.006, NNE
A29	VERIZON COMMUNICATIO	111 MAIN ST	NY AST, NY AIRS	Lower	31, 0.006, NNE
A30	VERIZON NEW YORK, IN	111 MAIN STREET	NY UST	Lower	31, 0.006, NNE
A31	NYNEX MATERIEL ENTER	111 MAIN ST	RCRA NonGen / NLR, NY MANIFEST	Lower	31, 0.006, NNE
A32	NY TEL	111 EAST MAIN STREET	UST FINDER RELEASE	Lower	31, 0.006, NNE
C33	CON EDISON	81 MAIN ST FRONT OF	RCRA NonGen / NLR, NY MANIFEST, NJ MANIFEST	Higher	33, 0.006, WNW
A34	IN FRONT OF GALERIA	MAIN ST	NY Spills	Lower	42, 0.008, North
B35	A&S STORE	GALLERIA PLAZA	NY LTANKS	Lower	51, 0.010, ENE
B36	A & S STORE	GALLERIA PLAZA	NY LTANKS	Lower	51, 0.010, ENE
C37	CON EDISON MANHOLE:	LEXINGTON AVE & E MA	RCRA-LQG, FINDS, ECHO	Higher	60, 0.011, WNW
C38	CON EDISON MANHOLE:	LEXINGTON AVE & MAIN	RCRA NonGen / NLR, NY MANIFEST	Higher	60, 0.011, WNW
C39	CON EDISON VAULT: 70	MAIN ST & LEXINGTON	RCRA NonGen / NLR, NY MANIFEST	Higher	60, 0.011, WNW

MAPPED SITES SUMMARY

Target Property Address:
100 MAIN STREET
WHITE PLAINS, NY 10601

Click on Map ID to see full detail.

MAP ID	SITE NAME	ADDRESS	DATABASE ACRONYMS	RELATIVE ELEVATION	DIST (ft. & mi.) DIRECTION
C40	CON EDISON	S. LEXINGTON AVE & E	NY MANIFEST	Higher	60, 0.011, WNW
C41	CON EDISON	S LEXINGTON AV & MAI	NY MANIFEST	Higher	60, 0.011, WNW
C42	GATEWAY PLAZA	1 NORTH LEXINGTON AV	NY UST	Higher	81, 0.015, WNW
C43	1 NORTH LEXINGTON AV	1 NORTH LEXINGTON AV	NY LTANKS, NY Spills	Higher	81, 0.015, WNW
C44	GATEWAY CENTER ONE	1 NORTH LEXINGTON AV	NY UST	Higher	81, 0.015, WNW
C45	CUSHMAN & WAKEFIELD	1 N LEXINGTON AVE	PA MANIFEST	Higher	81, 0.015, WNW
C46	RNG PADD 1	1 N LEXINGTON AVE	RCRA-VSQG, FINDS, FUELS PROGRAM, E MANIFEST, NJ...	Higher	81, 0.015, WNW
C47	GATEWAY CENTER ONE	1 NORTH LEXINGTON AV	NY AST	Higher	81, 0.015, WNW
C48	GATEWAY BLDG	1 N LEXINGTON AVE 13	NY MANIFEST	Higher	81, 0.015, WNW
C49	1 NORTH LEXINGTON AV	1 NORTH LEXINGTON AV	UST FINDER RELEASE	Higher	81, 0.015, WNW
C50	HOPE FIRE ENGINE CO.	25 NORTH LEXINGTON A	NY BROWNFIELDS, NY SPDES	Higher	127, 0.024, WNW
B51	MARTIN LUTHER KING &	MAIN STREET	NY Spills	Lower	152, 0.029, ENE
B52	NY POWER AUTH	123 MAIN ST	RCRA NonGen / NLR	Lower	157, 0.030, ENE
B53	ODDESY CORP MAINT DE	123 MAIN STREET	NY LTANKS, NY Spills	Lower	157, 0.030, ENE
B54	NEW YORK POWER AUTHO	123 MAIN STREET	NY UST, NY AST	Lower	157, 0.030, ENE
B55	NEW YORK POWER AUTHO	123 MAIN STREET	UST FINDER	Lower	157, 0.030, ENE
B56	NEW YORK POWER AUTHO	123 MAIN ST	RCRA-VSQG, NY Spills, FINDS, ECHO, E MANIFEST, NY...	Lower	157, 0.030, ENE
D57	CON EDISON SERVICE B	S LEXINGTON AVE & MA	RCRA NonGen / NLR, NY MANIFEST	Higher	185, 0.035, SW
D58	CON EDISON	N LEXINGTON AVE & MA	NJ MANIFEST	Higher	185, 0.035, SW
D59	GALLERIA WEST GARAGE	MARTINE AVE & SO LEX	NY UST	Higher	185, 0.035, SW
D60	GALLERIA WEST GARAGE	MARTINE AVE & SO LEX	NY AST	Higher	185, 0.035, SW
D61	CON EDISON MANHOLE:	MARTINE AVE & S LEXI	RCRA NonGen / NLR, NY MANIFEST	Higher	185, 0.035, SW
D62	CON EDISON	S. LEXINGTON AV & MA	NY MANIFEST	Higher	185, 0.035, SW
D63	CON EDISON	N LEXINGTON AVE & MA	RCRA NonGen / NLR	Higher	185, 0.035, SW
D64	CON EDISON SERVICE B	S LEXINGTON AVE & MA	RCRA NonGen / NLR, NY MANIFEST	Higher	185, 0.035, SW
D65	CON EDISON	N LEXINGTON AVE & MA	NY MANIFEST	Higher	185, 0.035, SW
D66	CON EDISON	MARTINE AVE & LEXING	NY MANIFEST	Higher	185, 0.035, SW
E67	CON EDISON	MARTINE & GROVE ST	NY MANIFEST	Higher	192, 0.036, SE
E68	CON EDISON	MARTINE & GROVE ST	RCRA NonGen / NLR, FINDS, ECHO	Higher	192, 0.036, SE
E69	CON EDISON MANHOLE 9	MARTINE AVE & GROVE	RCRA NonGen / NLR, NY MANIFEST, NJ MANIFEST	Higher	197, 0.037, SE
E70	CON EDISON MANHOLE 9	MARTINE AVE & GROVE	RCRA NonGen / NLR, NY MANIFEST, NJ MANIFEST	Higher	197, 0.037, SE
E71	CON EDISON MANHOLE 9	MARTINE AVE & GROVE	RCRA NonGen / NLR, NY MANIFEST, NJ MANIFEST	Higher	197, 0.037, SE
B72	CON EDISON MANHOLE:	MAIN ST & WILLIAMS S	RCRA NonGen / NLR, NY MANIFEST	Higher	250, 0.047, ENE
B73	CON EDISON	WILLIAMS ST & MAIN S	RCRA NonGen / NLR, NJ MANIFEST	Higher	250, 0.047, ENE
B74	CONSOLIDATED EDISON	WILLIAM ST & MAIN ST	NY MANIFEST	Higher	250, 0.047, ENE
B75	CON EDISON	WILLIAMS ST & MAIN S	RCRA NonGen / NLR	Higher	250, 0.047, ENE
B76	CON EDISON	WILLIAMS ST & MAIN S	NY MANIFEST	Higher	250, 0.047, ENE
B77	CON ED- TM462	WILLIAMS & MAIN ST	NY MANIFEST	Higher	250, 0.047, ENE
B78	2 WILLIAM ST./ 169 M	2 WILLIAM ST./ 169 M	NY UST	Higher	270, 0.051, ENE

MAPPED SITES SUMMARY

Target Property Address:
100 MAIN STREET
WHITE PLAINS, NY 10601

Click on Map ID to see full detail.

MAP ID	SITE NAME	ADDRESS	DATABASE ACRONYMS	RELATIVE ELEVATION	DIST (ft. & mi.) DIRECTION
D79	GRAY PETER	35 MARTINE AVE	EDR Hist Auto	Higher	300, 0.057, SW
F80	CON EDISON	LEXINGTON & HAMILTON	RCRA NonGen / NLR, FINDS, ECHO, NY MANIFEST, NJ...	Higher	308, 0.058, NW
F81	CON EDISON MANHOLE:	HAMILTON AVE & LEXIN	RCRA NonGen / NLR, NY MANIFEST	Higher	308, 0.058, NW
F82	CON EDISON	HAMILTON & N LEXINGT	RCRA NonGen / NLR, NY MANIFEST, NJ MANIFEST	Higher	308, 0.058, NW
G83	GHP HAMILTON AVENUE	170 HAMILTON AVENUE	NY UST	Lower	343, 0.065, NNW
G84	COMMERCIAL	170 HAMILTON AVE	NY Spills	Lower	343, 0.065, NNW
G85	OFFICE BUILDING	170 HAMILTON AVE	NY Spills, NY MANIFEST	Lower	343, 0.065, NNW
H86	CUSHMAN & WAKEFIELD	ONE N LEXINGTON AVE	PA MANIFEST	Higher	361, 0.068, WNW
F87	WHITE PLAINS GENERAL	76 HAMILTON AVE	EDR Hist Auto	Higher	363, 0.069, NW
F88	WHITE PLAINS GENL AU	76 HAMILTON AVE	RCRA NonGen / NLR, FINDS, ECHO	Higher	363, 0.069, NW
I89	MANHOLE #4021	HAMILTON AVE & GROVE	NY Spills	Lower	385, 0.073, NNE
I90	CON EDISON	HAMILTON & MARTIN LU	NY MANIFEST	Lower	385, 0.073, NNE
D91	PUBLIC SAFETY BUILDI	77 SOUTH LEXINGTON A	NY UST	Higher	397, 0.075, SSW
D92	77 SOUTH LEXINGTON A	77 SOUTH LEXINGTON A	NY LTANKS, NY AST	Higher	397, 0.075, SSW
J93	CROSS WESTCHESTER CL	4 MARTINE AVE	EDR Hist Cleaner	Higher	405, 0.077, SW
J94	CROSS WESTCHESTER CL	2A MARTINE AVE	EDR Hist Cleaner	Higher	411, 0.078, SW
K95	VINTAGE RESTAURANT	171-173 MAIN STREET	NY LTANKS	Higher	418, 0.079, ENE
K96	LAST CALL NY INC/DBA	171-173 MAIN STREET	NY UST	Higher	418, 0.079, ENE
G97	WHITE PLAINS HOUSING	33 FISHER AVE	RCRA-SQG, E MANIFEST	Lower	439, 0.083, NNE
K98	WYASSUP-LAUREL GLEN	175 MAIN STREET	NY AST	Higher	451, 0.085, ENE
K99	OFFICE BLDG	175 MAIN ST	NY Spills	Higher	451, 0.085, ENE
K100	DRAIN - COOKING GREA	175 MAIN STREET	NY Spills	Higher	451, 0.085, ENE
K101	WYASSUP-LAUREL GLEN	175 MAIN STREET	NY UST	Higher	451, 0.085, ENE
H102	CON EDISON MANHOLE:	MAIN ST & BANK ST	RCRA NonGen / NLR, NY MANIFEST	Higher	490, 0.093, West
H103	CON EDISON	BANK ST & MAIN ST	RCRA NonGen / NLR, NY MANIFEST, NJ MANIFEST	Higher	490, 0.093, West
L104	APARTMENT	76 SOUTH LEXINGTON A	NY AST, NY Spills	Higher	519, 0.098, SSW
L105	CON EDISON VAULT: 65	76-78 S LEXINGTON AV	RCRA NonGen / NLR	Higher	519, 0.098, SSW
L106	STATION PLAZA	76 SOUTH LEXINGTON A	NY UST	Higher	519, 0.098, SSW
L107	CON EDISON	76-78 S LEXINGTON AV	NY MANIFEST	Higher	519, 0.098, SSW
F108	WHITE PLAINS SUB-STA	2 NEW STREET	NY Spills	Higher	526, 0.100, NW
K109	RESIDENCE	185- 187 MAIN ST	NY LTANKS	Higher	528, 0.100, ENE
M110	CON EDISON	15 BANK ST	NJ MANIFEST	Higher	539, 0.102, West
M111	CON ED	15 BANK ST	NY MANIFEST	Higher	539, 0.102, West
M112	CON EDISON	15 BANK ST	RCRA NonGen / NLR	Higher	539, 0.102, West
F113	CON EDISON MANHOLE 5	LEXINGTON AVE & NEW	RCRA NonGen / NLR	Higher	540, 0.102, NW
F114	CONSOLIKDATED EDISON	NEW ST & LEXINGTON A	NY MANIFEST	Higher	540, 0.102, NW
N115	WHITE PLAINS SUB STA	NEW STREET	NY Spills	Higher	558, 0.106, NNW
O116	MICHAEL E LAND OFFIC	148 MARTINE AVE	NY LTANKS, NY AST, NY Spills	Higher	559, 0.106, ESE
O117	CON EDISON	148 MARTINE AVE	NJ MANIFEST	Higher	559, 0.106, ESE

MAPPED SITES SUMMARY

Target Property Address:
100 MAIN STREET
WHITE PLAINS, NY 10601

Click on Map ID to see full detail.

MAP ID	SITE NAME	ADDRESS	DATABASE ACRONYMS	RELATIVE ELEVATION	DIST (ft. & mi.) DIRECTION
O118	WESTCHESTER CO DPW	148 MARTINE AVE	UST FINDER RELEASE	Higher	559, 0.106, ESE
O119	CON EDISON	148 MARTINE AVE	RCRA NonGen / NLR, FINDS, ECHO	Higher	559, 0.106, ESE
O120	MICHAELIAN OFFICE BU	148 MARTINE AVE	RCRA-SQG, NY MANIFEST	Higher	559, 0.106, ESE
O121	WESTCHESTER COUNTY O	148 MARTINE AVENUE	NY UST	Higher	559, 0.106, ESE
O122	CON ED	148 MARTINE AVE	NY MANIFEST	Higher	559, 0.106, ESE
O123	MICHAELIAN OFFICE BL	148 MARTINE AVE	UST FINDER RELEASE	Higher	559, 0.106, ESE
K124	CONSOLIDATED EDISON	189 MAIN ST	NJ MANIFEST	Higher	564, 0.107, ENE
K125	CAPPELLI ASSOC.	189 MAIN STREET	NY Spills	Higher	564, 0.107, ENE
M126	CON EDISON MANHOLE:	25 BANK ST	RCRA NonGen / NLR, FINDS, ECHO, NY MANIFEST	Higher	568, 0.108, WSW
M127	OUTSIDE DWELLING	25 BANK DRIVE	NY Spills	Higher	568, 0.108, WSW
H128	CON EDISON MANHOLE:	BANK ST & HAMILTON A	RCRA NonGen / NLR, NY MANIFEST	Higher	574, 0.109, WNW
K129	CON EDISON MANHOLE 5	COURT ST & MAIN ST	RCRA NonGen / NLR	Higher	584, 0.111, ENE
K130	CON EDISON	COURT ST & MAIN ST	NY MANIFEST	Higher	584, 0.111, ENE
K131	CON EDISON	MAIN ST & COURT ST	RCRA NonGen / NLR, NY MANIFEST	Higher	584, 0.111, ENE
K132	ROADWAY	MAIN ST & COURT ST	NY Spills	Higher	584, 0.111, ENE
K133	CON EDISON	COURT ST & MAIN ST	NJ MANIFEST	Higher	584, 0.111, ENE
K134	CON EDISON MANHOLE 1	MAIN ST & COURT ST	RCRA NonGen / NLR, NY MANIFEST	Higher	584, 0.111, ENE
K135	CON EDISON MANHOLE 1	COURT ST & MAIN ST	RCRA NonGen / NLR, NY MANIFEST, NJ MANIFEST	Higher	584, 0.111, ENE
K136	CON EDISON	COURT ST & MAIN ST	RCRA NonGen / NLR	Higher	584, 0.111, ENE
K137	CON EDISON SERVICE B	MAIN ST & COURT ST	RCRA NonGen / NLR, NY MANIFEST	Higher	584, 0.111, ENE
K138	CON EDISON	COURT ST & MAIN ST	RCRA NonGen / NLR, FINDS, ECHO	Higher	584, 0.111, ENE
K139	CON EDISON MANHOLE:	MAIN ST & COURT ST	RCRA NonGen / NLR, NY MANIFEST	Higher	584, 0.111, ENE
K140	CON EDISON MANHOLE:	MAIN ST & COURT ST	RCRA NonGen / NLR, NY MANIFEST	Higher	584, 0.111, ENE
K141	CON EDISON	COURT ST & MAIN ST	NY MANIFEST	Higher	584, 0.111, ENE
N142	COMMERICAL BUILDING	10 NEW KING STREET	NY LTANKS	Higher	584, 0.111, NW
N143	DIESEL IN STREAM	10 NEW KING ST	NY Spills	Higher	584, 0.111, NW
O144	VEHICLE #41354	LEXINGTON AVE/ NEW S	NY Spills	Higher	586, 0.111, East
N145	OFFICE BLDG	4 NEW KING ST	NY LTANKS	Higher	587, 0.111, NW
O146	MINSKOFF MANAGEMENT	39-47 COURT STREET	NY Spills	Higher	602, 0.114, East
O147	COURT & MARTINE 2009	39-55 COURT ST / 167	NY AST	Higher	602, 0.114, East
O148	I/F/O THE MELTING PO	35 COURT ST	NY Spills	Higher	602, 0.114, East
K149	CON EDISON SERVICE B	19 COURT ST	NJ MANIFEST	Higher	603, 0.114, East
K150	CON EDISON SERVICE B	19 COURT ST	RCRA NonGen / NLR, NY MANIFEST	Higher	603, 0.114, East
P151	ON STREET	WILLIAMS STREET	NY Spills	Higher	610, 0.116, NNE
K152	SOIL	3 RENAISSANCE SQUARE	NY Spills	Higher	611, 0.116, ENE
O153	CON EDISON	COURT ST & MARTINE A	RCRA NonGen / NLR, FINDS, ECHO	Higher	613, 0.116, East
O154	DPW VEHICLE	COURT ST AND MARTINE	NY Spills	Higher	613, 0.116, East
O155	CON EDISON MANHOLE 9	MARTINE AVE & COURT	RCRA NonGen / NLR, NY MANIFEST, NJ MANIFEST	Higher	613, 0.116, East
O156	CON EDISON	MARTINE AVE & COURT	NY MANIFEST	Higher	613, 0.116, East

MAPPED SITES SUMMARY

Target Property Address:
100 MAIN STREET
WHITE PLAINS, NY 10601

Click on Map ID to see full detail.

MAP ID	SITE NAME	ADDRESS	DATABASE ACRONYMS	RELATIVE ELEVATION	DIST (ft. & mi.) DIRECTION
O157	INTERSECTION OF COUR	COURT ST. & MARITINE	NY LTANKS	Higher	613, 0.116, East
O158	CON EDISON TRANSFORM	MARTINE AVE & COURT	RCRA NonGen / NLR, NY MANIFEST	Higher	613, 0.116, East
O159	CON EDISON	COURT ST & MARTINE A	NY MANIFEST	Higher	613, 0.116, East
O160	CON EDISON	COURT ST & MARTINE A	NJ MANIFEST	Higher	613, 0.116, East
O161	CON EDISON	MARTINE & COURT ST	NY MANIFEST	Higher	613, 0.116, East
O162	CON EDISON	MARTINE AVE & COURT	NY MANIFEST	Higher	613, 0.116, East
O163	THE MICHICALLIAN OFF	MARTINE AVE & COURT	NY LTANKS	Higher	613, 0.116, East
J164	CON EDISON	10 BANK ST & MARTINE	RCRA NonGen / NLR, FINDS, ECHO	Higher	617, 0.117, WSW
O165	WEST HEALTH DEPT	148 MARTINE AVE	NY LTANKS	Higher	619, 0.117, ESE
J166	MARITINE AVE	MARITINE AVE & BANK	NY Spills	Higher	621, 0.118, WSW
N167	CON ED	9 NEW ST	NY Spills	Higher	624, 0.118, NW
N168	TRANSFORMER 7	9 NEW ST - SUBSTATIO	NY Spills	Higher	624, 0.118, NW
N169	WHITE PLAINS MGP SIT	9 NEW STREET AND 12	EDR MGP	Higher	624, 0.118, NW
N170	WHITE PLAINS SUBSTAT	9 NEW ST	NY Spills, NY SPDES	Higher	624, 0.118, NW
N171	WHITE PLAINS SUBSTAT	9 NEW STREET	RCRA-SQG, E MANIFEST	Higher	624, 0.118, NW
N172	CE - WHITE PLAINS MG	9 NEW STREET AND 12	NY ENG CONTROLS, NY INST CONTROL, NY VCP, NY MGP	Higher	624, 0.118, NW
N173	WHITE PLAINS SUB STA	9 NEW STREET	NY Spills	Higher	624, 0.118, NW
N174	CON ED SUBSTATION	9 NEW ST	NY Spills	Higher	624, 0.118, NW
N175	CONSOLIDATED EDISON	9 NEW ST	NY MANIFEST	Higher	624, 0.118, NW
N176	WHITE PLAINS SUB-STA	5 NEW STREET	NY Spills	Higher	626, 0.119, NW
N177	NUCLEAR DEVELOPMENT	5 NEW STREET	FUSRAP	Higher	626, 0.119, NW
N178	COMMERCIAL	3 NEW KING STREET	NY LTANKS	Higher	627, 0.119, NW
N179	COMMERCIAL PROPERTY	1-3 NEW KING ST	NY Spills	Higher	628, 0.119, NW
N180	PBS TTF	1 NEW KING STREET	NY LTANKS	Higher	628, 0.119, NW
Q181		111 MARTIN LUTHER KI	NY AST, NY COOLING TOWERS	Higher	646, 0.122, SE
Q182	WESTCHESTER COUNTY C	111 GROVE ST TOWER	NY UST	Higher	646, 0.122, SE
Q183	CON EDISON	111 MARTIN LUTHER KI	NJ MANIFEST	Higher	646, 0.122, SE
Q184	CON EDISON	111 MARTIN LUTHER KI	RCRA NonGen / NLR	Higher	646, 0.122, SE
Q185	WESTCHESTER COUNTY C	111 MARTIN LUTHER KI	NY UST	Higher	646, 0.122, SE
Q186	WESTCHESTER COUNTY C	111 GROVE ST	RCRA NonGen / NLR, FINDS, ECHO, NY MANIFEST	Higher	646, 0.122, SE
P187	AMERICAN DENTAL OFFI	200 HAMILTON AVENUE	E MANIFEST	Higher	648, 0.123, NE
P188	WHITE PLAINS MALL CL	200 HAMILTON AVE	EDR Hist Cleaner	Higher	648, 0.123, NE
P189	HAMILTON GREEN PHASE	200 HAMILTON AVENUE	NY BROWNFIELDS, NY Spills, NY MANIFEST, NY SPDES	Higher	648, 0.123, NE
Q190	WESTCHESTER COUNTY C	110 DR MARTIN LUTHER	RCRA-VSQG	Higher	650, 0.123, SE
Q191	WESTCHESTER COUNTY C	110 GROVE ST	NY UST	Higher	650, 0.123, SE
K192	CON EDISON MANHOLE 4	199 MAIN ST & MAMARO	RCRA NonGen / NLR, NY MANIFEST, NJ MANIFEST	Higher	661, 0.125, ENE
K193	199 MAIN STREET REAL	199 MAIN STREET	NY UST, NY AST	Higher	661, 0.125, ENE
P194	CON EDISON	HAMILTON AVE & RENNA	NY MANIFEST	Higher	664, 0.126, NE
R195	CON EDISON	10 BANK ST & MARTINE	NJ MANIFEST	Higher	701, 0.133, SW

MAPPED SITES SUMMARY

Target Property Address:
100 MAIN STREET
WHITE PLAINS, NY 10601

Click on Map ID to see full detail.

MAP ID	SITE NAME	ADDRESS	DATABASE ACRONYMS	RELATIVE ELEVATION	DIST (ft. & mi.) DIRECTION
L196	OUR LADY OF MT CARME	92 SOUTH LEXINGTON A	NY UST	Higher	714, 0.135, SSW
L197	OUR LADY OF MOUNT CA	92 SOUTH LEXINGTON A	NY LTANKS	Higher	714, 0.135, SSW
R198	CON EDISON	10 BANK ST	RCRA NonGen / NLR	Higher	748, 0.142, SW
R199	CON EDISON	10 BANK ST	NJ MANIFEST	Higher	748, 0.142, SW
R200	CON ED	10 BANK ST	NY MANIFEST	Higher	748, 0.142, SW
R201	MARUBENI SPECIALTY C	10 BANK ST	RCRA NonGen / NLR, TSCA, FINDS, ECHO, NY MANIFEST	Higher	748, 0.142, SW
R202	CON EDISON	10 BANK ST	NJ MANIFEST	Higher	748, 0.142, SW
R203	CON EDISON	10 BANK ST	RCRA NonGen / NLR	Higher	748, 0.142, SW
P204	WP MALL CLEANERS & G	250 HAMILTON AVENUE	NY INST CONTROL, NY BROWNFIELDS, NY PFAS, NY...	Higher	763, 0.145, NE
P205	RENAISSANCE ENV MANA	250 HAMILTON AVE	RCRA NonGen / NLR, E MANIFEST	Higher	763, 0.145, NE
Q206	CONSOLIDATED EDISON	GROVE & QUERROPAS	NY MANIFEST	Higher	764, 0.145, SSE
Q207	CON EDISON	GROVE ST & QUARROPAS	RCRA NonGen / NLR, NJ MANIFEST	Higher	764, 0.145, SSE
Q208	CON EDISON	QUARROPAS ST & MLK B	NY MANIFEST	Higher	764, 0.145, SSE
Q209	CON EDISON	QUARROPAS ST & MLK B	RCRA NonGen / NLR	Higher	764, 0.145, SSE
Q210	CON EDISON	QUARROPAS ST & MLK B	NJ MANIFEST	Higher	764, 0.145, SSE
O211		85 COURT STREET	NY AST, NY COOLING TOWERS	Higher	773, 0.146, ESE
S212	NYSDEC	GRAND & QUARRAPUS	NY MANIFEST	Higher	777, 0.147, SE
T213	WHITE PLAINS POLICE	279 HAMILTON AVE	RCRA NonGen / NLR, FINDS, ECHO	Higher	779, 0.148, NE
T214	PUBLIC SAFETY BUILDI	279 HAMILTON AVE	NY UST	Higher	779, 0.148, NE
T215	WHITE PLAINS POLICE	279 HAMILTON AVENUE	NY LTANKS, NY MANIFEST	Higher	779, 0.148, NE
T216	FORMER WPPD	279 HAMITON AVE	UST FINDER RELEASE	Higher	779, 0.148, NE
O217	MINSKOFF CORP.	179 MARTINE AVE	NY LTANKS	Higher	781, 0.148, East
U218	SPILL NUMBER 0206130	203 MAIN ST	NY LTANKS	Higher	790, 0.150, ENE
U219	BRIAN HOLDING COMPAN	203 MAIN STREET	NY UST	Higher	790, 0.150, ENE
T220	274 SNK HAMILTON AVE	274 HAMILTON AVENUE	NY UST	Higher	819, 0.155, NE
T221	274 SNK HAMILTON AVE	274 HAMILTON AVENUE	NY AST	Higher	819, 0.155, NE
T222	EXXON, WHITE PLAINS	274 HAMILTON AVE	UST FINDER RELEASE	Higher	819, 0.155, NE
T223	CON EDISON	274 HAMILTON AVE	NY MANIFEST	Higher	819, 0.155, NE
T224	EXXON, WHITE PLAINS	274 HAMILTON AVE	NY LTANKS, NY Spills	Higher	819, 0.155, NE
T225	FORMER WPPD	279 HAMITON AVE	NY LTANKS	Higher	824, 0.156, NE
P226	EXXON DIV OF CFI #70	274 HAMILTON AVE & C	RCRA-VSQG, FINDS, ECHO, NY MANIFEST	Higher	831, 0.157, NE
U227	CELESTILA GROUP	14 MAMARONECK AVE	NY LTANKS, NY Spills	Higher	854, 0.162, East
U228	CALANO & CALANO REAL	14 MAMARONECK AVENUE	NY UST	Higher	854, 0.162, East
U229	WHITE PLAINS TOWN CE	MAMARONECK AVE & MAI	RCRA NonGen / NLR	Higher	871, 0.165, ENE
U230	CVS PHARMACY #4745	24 MAMARONECK AVE	PA MANIFEST	Higher	873, 0.165, East
U231	CVS	24 MAMARONECK AVENUE	RCRA-VSQG, E MANIFEST, NY MANIFEST	Higher	873, 0.165, East
232	WESTCHESTER CO BRONX	1 BRONX ST- LAT 41 1	RCRA NonGen / NLR, FINDS, ECHO, NY MANIFEST	Lower	877, 0.166, West
V233	INNS OF COURT	99 COURT ST	NY LTANKS	Higher	882, 0.167, ESE
V234	THE INNS OF COURT PR	99 COURT ST.	NY UST	Higher	882, 0.167, ESE

MAPPED SITES SUMMARY

Target Property Address:
100 MAIN STREET
WHITE PLAINS, NY 10601

Click on Map ID to see full detail.

MAP ID	SITE NAME	ADDRESS	DATABASE ACRONYMS	RELATIVE ELEVATION	DIST (ft. & mi.) DIRECTION
U235	CON EDISON	MAMARONECK AVE & MAI	RCRA NonGen / NLR, FINDS, ECHO, NY MANIFEST	Higher	884, 0.167, ENE
W236	CONSOLIDATED EDISON	12 WATER ST - MH 561	NY MANIFEST	Lower	885, 0.168, NNW
S237	RECKSON ASSOCIATES	140 GRAND ST	RCRA NonGen / NLR, FINDS, ECHO, NY MANIFEST	Higher	887, 0.168, SE
U238	CON EDISON - MANHOLE	221 MAIN STREET	NJ MANIFEST	Higher	888, 0.168, ENE
U239	CON EDISON MANHOLE:	221 MAIN ST	RCRA-LQG, FINDS, ECHO, NY MANIFEST	Higher	888, 0.168, ENE
U240	221 MAIN STREET	221 MAIN ST	NY BROWNFIELDS, NY Spills	Higher	888, 0.168, ENE
R241	WHITE PLAINS RUBBER	20 BANK ST	RCRA NonGen / NLR, FINDS, ECHO, NY MANIFEST	Higher	902, 0.171, SW
T242	SPRINT WHITE PLAINS	300 HAMILTON AVENUE	NY UST	Higher	905, 0.171, NE
T243	AMCOTT ASSOCIATES	300 HAMILTON AVENUE	NY UST	Higher	905, 0.171, NE
T244	AMCOTT ASSOCIATES	300 HAMILTON AVENUE	NY AST	Higher	905, 0.171, NE
W245	CON EDISON MANHOLE 4	BARKER AVE & GROVE S	RCRA NonGen / NLR, NY MANIFEST	Lower	909, 0.172, North
W246	CONSOLIDATED EDISON	WATER ST & LEXINGTON	NY MANIFEST	Lower	912, 0.173, NNW
W247	CON EDISON	WATER ST & N LEXINGT	NY MANIFEST	Lower	912, 0.173, NNW
W248	CON EDISON MANHOLE 1	WATER ST & N LEXINGT	RCRA NonGen / NLR, NY MANIFEST, NJ MANIFEST	Lower	912, 0.173, NNW
W249	CON EDISON MANHOLE:	WATER ST & LEXINGTON	RCRA NonGen / NLR, NY MANIFEST	Lower	912, 0.173, NNW
W250	CON EDISON	WATER ST & LEXINGTON	RCRA NonGen / NLR, NY MANIFEST, NJ MANIFEST	Lower	912, 0.173, NNW
W251	CON EDISON	WATER ST & N LEXINGT	NY MANIFEST	Lower	912, 0.173, NNW
W252	CON EDISON MANHOLE:	WATER ST & LEXINGTON	RCRA NonGen / NLR, NY MANIFEST	Lower	912, 0.173, NNW
W253	CON EDISON - MANHOLE	WATER ST & LEXINGTON	NY MANIFEST	Lower	912, 0.173, NNW
W254	CON EDISON	WATER ST & LEXINGTON	RCRA NonGen / NLR, NY MANIFEST, NJ MANIFEST	Lower	912, 0.173, NNW
X255	196-200 MARTINE AVEN	196-200 MARTINE AVEN	NY AST	Higher	918, 0.174, East
S256	GRAND REALTY COMPANY	150 GRAND STREET	NY UST	Higher	918, 0.174, SE
S257	150 GRAND STREET OFF	150 GRAND STREET	NY UST	Higher	918, 0.174, SE
S258	OFFICE BLDG BASEMENT	150 GRAND STREET	NY LTANKS	Higher	918, 0.174, SE
X259	EMPLOYMENT BUILDING	48 MAMARONECK AVE.	NY AST, NY Spills	Higher	923, 0.175, East
Y260	EDGAR	1 BARKER AVE	NY LTANKS	Lower	923, 0.175, North
Y261	RESIDENCE	1 BARKER AVENUE	NY UST	Lower	923, 0.175, North
Z262	AHERN PAINTING CONTR	HAMILTON AVE & BRONX	RCRA NonGen / NLR	Lower	925, 0.175, WNW
Z263	AHERN PAINTING CONTR	HAMILTON AVE & BRONX	NY MANIFEST	Lower	925, 0.175, WNW
Z264	CON EDISON MANHOLE	HAMILTON AVE & BRONX	RCRA NonGen / NLR, NJ MANIFEST	Lower	926, 0.175, WNW
W265	PEPE CADILLAC	15 WATER STREET	NY UST	Lower	929, 0.176, NNW
W266	PEPE CADILLAC	15 WATER STREET	NY AST	Lower	929, 0.176, NNW
AA267	CHARLES L. BRIEANT U	300 QUARROPAS STREET	NY UST	Higher	936, 0.177, South
AA268	CHARLES L. BRIEANT U	300 QUARROPAS STREET	NY AST	Higher	936, 0.177, South
AA269	U.S. PROBATION OFFIC	300 QUARROPAS STREET	E MANIFEST	Higher	936, 0.177, South
R270	YOUNG COAL & LUMBER	55 BANK ST - TXI ID#	RCRA NonGen / NLR, FINDS, ECHO	Higher	940, 0.178, SW
R271	HP NORTH TOWER LLC	55 BANK STREET	PA MANIFEST	Higher	940, 0.178, SW
R272	YOUNG COAL & LUMBER	55 BANK STREET	NY BROWNFIELDS, NY MANIFEST	Higher	940, 0.178, SW
S273	COMMERCIAL BUSINESS	158 GRAND STREET	NY LTANKS	Higher	943, 0.179, SE

MAPPED SITES SUMMARY

Target Property Address:
100 MAIN STREET
WHITE PLAINS, NY 10601

Click on Map ID to see full detail.

MAP ID	SITE NAME	ADDRESS	DATABASE ACRONYMS	RELATIVE ELEVATION	DIST (ft. & mi.) DIRECTION
S274	CON EDISON - VAULT 4	161 GRAND ST	NY MANIFEST	Higher	947, 0.179, SE
X275	CON EDISON	240 MARTINE AVE & MA	RCRA NonGen / NLR, FINDS, ECHO, NJ MANIFEST	Higher	948, 0.180, East
AA276	CON EDISON MANHOLE:	QUARROPAS ST & FISCH	RCRA NonGen / NLR, FINDS, ECHO, NY MANIFEST	Higher	951, 0.180, South
AA277	CON EDISON	FISHER CT & QUARROPA	NY MANIFEST	Higher	951, 0.180, South
AA278	CON EDISON SERVICE B	FISHER CT & QUARROPA	RCRA NonGen / NLR, FINDS	Higher	951, 0.180, South
AA279	CON EDISON	QUARROPAS ST & FISHE	NY MANIFEST	Higher	951, 0.180, South
X280	1-HOUR PHOTO FINISH	60B MAMARONECK AVE	RCRA NonGen / NLR, NY MANIFEST	Higher	955, 0.181, East
AB281	55 CHURCH WP LLC	55 CHURCH STREET	NY AST	Higher	964, 0.183, NE
AB282	CENTURYLINK - WHITE	55 CHURCH STREET	NY AST	Higher	964, 0.183, NE
AC283	PEPE MOTORS	50 BANK ST	UST FINDER RELEASE	Higher	977, 0.185, SW
AC284	MERCEDES- BENZ OF WH	50 BANK STREET	NY UST, NY AST	Higher	977, 0.185, SW
AC285	PEPE MOTORS INC	50 BANK ST	RCRA-VSQG, NY LTANKS, FINDS, ECHO, NY MANIFEST	Higher	977, 0.185, SW
S286	170 GRAND STREET ASS	170 GRAND STREET	NY UST, NY AST	Higher	982, 0.186, SE
S287	170 GRAND STREET	170 GRAND STREET	NY LTANKS, NY Spills	Higher	982, 0.186, SE
X288	WESTCHESTER ARTS COU	31 MAMARONECK AVE.	NY UST	Higher	984, 0.186, East
U289	CON EDISON	MAIN ST & CHURCH ST	NJ MANIFEST	Higher	999, 0.189, ENE
U290	CON EDISON	MAIN ST & CHURCH ST	RCRA NonGen / NLR, NY MANIFEST	Higher	999, 0.189, ENE
S291	177 GRAND STREET ASS	177 GRAND ST	RCRA NonGen / NLR, FINDS, ECHO, NY MANIFEST	Higher	999, 0.189, SE
S292	177 GRAND PARTNERS,	177 GRAND STREET	NY UST	Higher	999, 0.189, SE
AD293	MARRIOT INN	5 BARKER AVE	NY LTANKS	Lower	999, 0.189, NNE
AD294	RESIDENCE INN - TTF	5 BARKER AVE	NY LTANKS	Lower	999, 0.189, NNE
AD295	MARIOTT RESIDENCE IN	5 BARKER AVE	UST FINDER RELEASE	Lower	999, 0.189, NNE
X296	76 MAMARONECK AVENUE	76 MAMARONECK AVENUE	NY UST	Higher	1000, 0.189, ESE
U297	RENAISSANCE CORPORAT	235 MAIN STREET	NY UST	Higher	1001, 0.190, ENE
U298	RENAISSANCE CORPORAT	235 MAIN STREET	NY AST	Higher	1001, 0.190, ENE
AE299	SLADER NEIGHBORHOOD	2 FISHER CT	NY LTANKS	Higher	1030, 0.195, SSE
AE300	SLATER NEIGHBORHOOD	2 FISHER COURT	NY UST	Higher	1030, 0.195, SSE
X301	47 MAMARONECK AVENUE	47 MAMARONECK AVENUE	NY UST	Higher	1032, 0.195, East
AF302	CON EDISON	WATER ST & FERRIS AV	NY MANIFEST	Lower	1042, 0.197, NW
AF303	CON EDISON MANHOLE:	WATER ST & FERRIS AV	RCRA NonGen / NLR, NY MANIFEST	Lower	1042, 0.197, NW
AD304	CON EDISON MANHOLE:	BARKER ST & COTTAGE	RCRA NonGen / NLR, NY MANIFEST	Higher	1044, 0.198, NNE
AD305	CON EDISON	COTTAGE PL & BARKER	RCRA-VSQG	Higher	1044, 0.198, NNE
AD306	CON EDISON	COTTAGE PL & BARKER	RCRA NonGen / NLR, FINDS	Higher	1044, 0.198, NNE
AD307	CON EDISON	COTTAGE PL & BARKER	NY MANIFEST	Higher	1044, 0.198, NNE
AE308	CON EDISON	GROVE ST & FISCHER C	NJ MANIFEST	Higher	1051, 0.199, SSE
AE309	CONSOLIDATED EDISON	GROVE & FISHER	NY MANIFEST	Higher	1051, 0.199, SSE
AE310	CON EDISON	GROVE ST & FISCHER C	RCRA NonGen / NLR, FINDS, ECHO	Higher	1051, 0.199, SSE
AE311	CON EDISON SERVICE B	GROVE ST & FISCHER A	RCRA NonGen / NLR, NY MANIFEST	Higher	1051, 0.199, SSE
AB312	HAMILTON MAIN PARKIN	HAMILTON AVE & MAIN	NY LTANKS	Higher	1051, 0.199, ENE

MAPPED SITES SUMMARY

Target Property Address:
100 MAIN STREET
WHITE PLAINS, NY 10601

Click on Map ID to see full detail.

MAP ID	SITE NAME	ADDRESS	DATABASE ACRONYMS	RELATIVE ELEVATION	DIST (ft. & mi.) DIRECTION
AF313	ONE WATER STREET BLA	P/O 1 WATER ST. AND	NY BROWNFIELDS	Lower	1054, 0.200, NW
AG314	CON EDISON	QUARROPAS ST & LEXIN	NY MANIFEST	Higher	1057, 0.200, South
AG315	CON EDISON	S LEXINGTON AVE & QU	RCRA NonGen / NLR, FINDS, ECHO	Higher	1057, 0.200, South
AG316	CON EDISON	S LEXINGTON AVE & QU	NJ MANIFEST	Higher	1057, 0.200, South
AG317	CON EDISON	LEXINGTON AVE & QUAR	NJ MANIFEST	Higher	1057, 0.200, South
AG318	CON EDISON MANHOLE 1	S LEXINGTON AVE & FI	RCRA NonGen / NLR, NY MANIFEST	Higher	1057, 0.200, South
AG319	CON EDISON	LEXINGTON AVE & QUAR	RCRA NonGen / NLR	Higher	1057, 0.200, South
AG320	CON EDISON	QUARRAPUS ST & LEXIN	NY MANIFEST	Higher	1057, 0.200, South
AG321	CON EDISON	LEXINGTON AVE & QUAR	NY MANIFEST	Higher	1057, 0.200, South
AG322	CON EDISON	S LEXINGTON AVE & QU	NY MANIFEST	Higher	1057, 0.200, South
AG323	CON EDISON MANHOLE:	S LEXINGTON AVE & FI	RCRA NonGen / NLR, NY MANIFEST	Higher	1057, 0.200, South
AH324	CON EDISON - TRANSFO	241 MAIN ST	NY MANIFEST	Higher	1079, 0.204, ENE
AG325	WINBROOK APARTMENTS	11 FISHER AVE	RCRA-SQG, E MANIFEST	Higher	1090, 0.206, SSW
AG326	WINBROOK APARTMENTS	11 FISHER AVE	NY MANIFEST	Higher	1090, 0.206, SSW
AI327	CON EDISON TRANSFORM	MITCHELL PL & MAMARO	RCRA NonGen / NLR, NY MANIFEST	Higher	1102, 0.209, ESE
AI328	KIMCO REALTY CORP	100 MAMARONECK AVENU	NY UST	Higher	1103, 0.209, ESE
X329	204 MARTINE ASSOCIAT	204 MARTINE AVE	NY AST	Higher	1104, 0.209, East
AJ330	MCI DBA VERIZON BUSI	95 CHURCH STREET	NY UST	Higher	1105, 0.209, NE
AC331	SMITH'S DAIRY,INC.	61 BANK STREET	NY UST	Higher	1109, 0.210, SW
AG332	WHITE PLAINS HOUSING	33 FISHER AVE	NY AIRS, NY MANIFEST	Higher	1121, 0.212, SSW
AG333	WHITE PLAINS HOUSING	33 FISHER AVE	NY LTANKS, NY Spills	Higher	1121, 0.212, SSW
AJ334	99 CHURCH STREET	99 CHURCH STREET	NY UST	Higher	1130, 0.214, NE
335	BILL'S AUTO REPAIR	1 MAIN ST.	NY UST	Lower	1143, 0.216, West
AI336	110-122 MAMARONECK A	110 MAMARONECK AVENU	NY UST	Higher	1178, 0.223, ESE
AI337	SILVERMAN REALITY	110 MAMARONECK AVE	NY LTANKS	Higher	1178, 0.223, ESE
338	CHURCH	65 FISHER AVE	NY LTANKS, NY Spills	Higher	1183, 0.224, SSW
AG339	124 SOUTH LEXINGTON	124 SOUTH LEXINGTON	NY UST	Lower	1189, 0.225, South
AI340	MITCHELL PLACE ASSOC	10 MITCHELL PLACE	NY LTANKS	Higher	1197, 0.227, ESE
AI341	TEN MITCHELL PLACE	10 MITCHELL PLACE	NY UST	Higher	1197, 0.227, ESE
AG342	126 S. LEXINGTON CED	126 SOUTH LEXINGTON	NY UST	Lower	1210, 0.229, South
AI343	GAS STATION	9 MITCHELL PL	NY LTANKS, NY Spills	Higher	1217, 0.230, ESE
AI344	MITCHELL PLACE GARAG	9 MITCHELL PLACE	NY UST	Higher	1217, 0.230, ESE
AI345	GAS STATION	9 MITCHELL PL	UST FINDER RELEASE	Higher	1217, 0.230, ESE
AI346	DEVON PLAZA REALTY	9 MITCHELL PLACE	NY UST	Higher	1217, 0.230, ESE
AI347	NICKY'S RESTAURANT	107 MAMARONECK AVE	NY LTANKS	Higher	1234, 0.234, ESE
AI348	DEVON PLAZA REALITY	109 MAMARONECK AVE	NY LTANKS, NY AST	Higher	1246, 0.236, ESE
AH349	MUNICIPAL BUILDING	255 MAIN ST	NY UST	Higher	1254, 0.237, ENE
AH350	CITY HALL	255 MAIN ST	UST FINDER RELEASE	Higher	1254, 0.237, ENE
AH351	WHITE PLAINS DEPT OF	255 MAIN ST	RCRA NonGen / NLR, E MANIFEST	Higher	1254, 0.237, ENE

MAPPED SITES SUMMARY

Target Property Address:
100 MAIN STREET
WHITE PLAINS, NY 10601

Click on Map ID to see full detail.

MAP ID	SITE NAME	ADDRESS	DATABASE ACRONYMS	RELATIVE ELEVATION	DIST (ft. & mi.) DIRECTION
AH352	WHITE PLAINS DEPT OF	255 MAIN STREET	NY LTANKS, NY MANIFEST, NY SPDES	Higher	1254, 0.237, ENE
AK353	124 MAMARONECK AVENU	124 MAMARONECK AVENU	NY UST	Higher	1267, 0.240, ESE
AH354	CON EDISON	218 MAIN ST	NY MANIFEST	Higher	1281, 0.243, ENE
AK355	PER-BAR	124 MAMARONECK AVE	NY LTANKS	Higher	1282, 0.243, ESE
AL356	210 MARTINE AVENUE	210 MARTINE AVENUE	NY UST	Higher	1285, 0.243, East
AH357	T S T WHITE PLAINS L	220 MAIN ST	NY Spills, RCRA NonGen / NLR, NY MANIFEST	Higher	1291, 0.245, ENE
AH358	MACY'S	220 MAIN ST	NY UST	Higher	1291, 0.245, ENE
AH359	T S T WHITE PLAINS L	220 MAIN ST	RCRA-VSQG, FINDS, ECHO	Higher	1291, 0.245, ENE
AG360	HYDRAULIC FLUID TO S	134 SOUTH LEXINGTON	NY LTANKS, NY Spills	Higher	1294, 0.245, South
AM361	CON EDISON SERVICE B	BARKER AVE & CHURCH	RCRA NonGen / NLR, NY MANIFEST	Higher	1304, 0.247, NNE
AM362	CON EDISON MANHOLE:	BARKER AVE & CHURCH	RCRA NonGen / NLR, NY MANIFEST	Higher	1304, 0.247, NNE
AN363	CON EDISON	F/O 360 HAMILTON AVE	NY MANIFEST	Higher	1306, 0.247, NE
AN364	A T & T	360 HAMILTON AVE	RCRA-SQG, NY Spills, NY MANIFEST	Higher	1306, 0.247, NE
AN365	RECKSON ASSOCIATES	360 HAMILTON AVE - M	NY Spills, RCRA NonGen / NLR, FINDS, ECHO, NY...	Higher	1306, 0.247, NE
AN366	RECKSON METRO CENTER	360 HAMILTON AVE	NY AST, US AIRS	Higher	1306, 0.247, NE
AK367	CON EDISON	128 MAMARONECK AVE	RCRA NonGen / NLR, FINDS, ECHO	Higher	1315, 0.249, ESE
AK368	CON EDISON	128 MAMARONECK AVE	NY MANIFEST	Higher	1315, 0.249, ESE
AK369	CON EDISON	128 MAMARONECK AVE	NJ MANIFEST	Higher	1315, 0.249, ESE
AO370	WINBROOK HOUSING DEV	223 DR. MARTIN LUTHE	NY UST	Higher	1320, 0.250, SSE
AO371	WINDBROOK HOUSING	223 DR MARTIN LUTHER	NY LTANKS	Higher	1320, 0.250, SSE
AO372	WHITE PLAIN HOUSING	225 GROVE ST	NY LTANKS	Higher	1328, 0.252, SSE
AP373	SPILL NUMBER 8809894	23 MITCHELL PLACE	NY LTANKS	Higher	1367, 0.259, East
AQ374	WESTCHESTER OFFICE B	112 EAST POST ROAD	NY LTANKS	Higher	1367, 0.259, SE
AQ375	COMMERCIAL	130-144 EAST POST RD	NY LTANKS	Higher	1373, 0.260, SE
AR376	WHITE PLAINS HONDA	31 WESTMPORELAND AVE	NY LTANKS	Higher	1382, 0.262, SW
AP377	SPILL NUMBER 9905959	25 MITCHELL PLACE	NY LTANKS	Higher	1390, 0.263, East
AR378	MUNICIPAL GARAGE	111	NY LTANKS	Higher	1396, 0.264, SW
AL379	28 MITCHELL PLACE	28 MITCHELL PLACE	NY LTANKS	Higher	1403, 0.266, East
AS380	FIRE STATION 2		NY LTANKS	Higher	1406, 0.266, NW
AQ381	COACHMAN HOTEL	123 EAST POST ROAD	NY LTANKS	Higher	1407, 0.266, SE
AS382	FIRE STATION # 2 WH	20 FERRIS AVE	UST FINDER RELEASE	Higher	1410, 0.267, NW
AS383	PRIVATE ENTERPRISE	20 FERRIS AVE	NY LTANKS, NY AST, NY Spills	Higher	1410, 0.267, NW
AS384	FIRE STATION # 2	20 FERRIS AVE	UST FINDER RELEASE	Higher	1410, 0.267, NW
AR385	SPILL NUMBER 0108090	31 WESTMORELAND AVE	NY LTANKS, NY Spills	Higher	1411, 0.267, SW
AL386	SPILL NUMBER 0108164	32 MITCHELL PL	NY LTANKS	Higher	1449, 0.274, East
AK387	COMMERCIAL PROERTY	151 EAST POST ROAD	NY LTANKS	Higher	1461, 0.277, ESE
AR388	LEGACY MANAGEMENT	39 WESTMORELAND AVE	NY LTANKS	Higher	1462, 0.277, SW
AR389	COMMERCIAL PROPERTY	39 WESTMORELAND AVE	NY LTANKS, NY Spills	Higher	1462, 0.277, SW
AQ390	REAL ESTATE - TTF	6 CHESTER AVE	NY LTANKS	Higher	1482, 0.281, SE

MAPPED SITES SUMMARY

Target Property Address:
100 MAIN STREET
WHITE PLAINS, NY 10601

Click on Map ID to see full detail.

MAP ID	SITE NAME	ADDRESS	DATABASE ACRONYMS	RELATIVE ELEVATION	DIST (ft. & mi.) DIRECTION
AP391	BARGAM HOME	36-38 MITCHELL PLACE	NY LTANKS	Higher	1497, 0.284, East
AT392	PBS	82 BANK STREET	NY LTANKS, NY Spills	Higher	1504, 0.285, SSW
AU393	HALPERN ENTERPRISES	170 EAST POST ROAD	NY LTANKS	Higher	1511, 0.286, ESE
AK394	OFFICE BLDG	171 EAST POST RD	NY LTANKS	Higher	1512, 0.286, ESE
AQ395	RESIDENTS	8 CHESTER AVE	NY LTANKS	Higher	1522, 0.288, SE
AP396	APARTMENT BLDG	37-43 MITCHELL PL	NY LTANKS	Higher	1526, 0.289, East
AR397	IRVINGTON	IRVINGTON	NY LTANKS	Higher	1532, 0.290, SW
398	VILLANOVA - TTF	144 CHURCH ST	NY LTANKS	Higher	1542, 0.292, NNE
AP399	APARTMENT BUILDING	40 MITCHELL PL	NY LTANKS	Higher	1545, 0.293, East
AN400	AT & T TELEPHONE CO	400 HAMILTON AVENUE	NY LTANKS, NY Spills	Higher	1546, 0.293, NE
401	BROOKFIELD COMMONS P	159 SOUTH LEXINGTON	NY BROWNFIELDS, NY Spills	Higher	1548, 0.293, South
AV402	10 SCHOOL STREET	10 SCHOOL STREET	NY LTANKS	Higher	1576, 0.298, West
AW403	APARTMENT BLDG	40 BARKER AVE	NY LTANKS	Higher	1591, 0.301, NE
AV404	12 HARMON STREET	12 HARMON STREET	NY LTANKS	Higher	1602, 0.303, WNW
AX405	SPILL NUMBER 9904849	45 MITCHELL PLACE	NY LTANKS	Higher	1619, 0.307, East
AX406	APT BUILDING	45 MITCHELL PLACE	NY LTANKS	Higher	1619, 0.307, East
AW407	COMMERCIAL	41 BARKER AVE	NY LTANKS, NY Spills	Higher	1637, 0.310, NE
AY408	STEWARD	165 MAMARONECK AVENU	NY LTANKS	Higher	1650, 0.312, SE
AU409	SPILL NUMBER 9900622	179 EAST COAST RD	NY LTANKS	Higher	1656, 0.314, ESE
AT410	CASTILLO	125-127 FISHER AVE	NY LTANKS	Higher	1673, 0.317, SW
AY411	KEMPLER RESIDENCE	169 MAMARONECK AVE	NY LTANKS	Higher	1681, 0.318, SE
412	BUSINESS	2-4 WASHINGTON AVE	NY LTANKS	Higher	1692, 0.320, West
AY413	JOHN DALE INC	178 MAMORENECK AVE	NY LTANKS	Higher	1693, 0.321, SE
414	APARTMENT BUILDING	193 EAST POST ROAD	NY LTANKS	Higher	1729, 0.327, ESE
AZ415	WHITE PLAINS HOSPITA	DAVIS AVE & EAST POS	NY LTANKS, NY Spills	Higher	1757, 0.333, SSE
AZ416	WHITE PLAINS HOSPITA	EAST NEW YORK POST R	NY LTANKS	Higher	1776, 0.336, South
AZ417	WHITE PLAINS CITGO	34 EAST POST ROAD	UST FINDER RELEASE	Higher	1797, 0.340, South
AZ418	WHITE PLAINS HOSPITA	41 POST RD	NY LTANKS, NY Spills, NY MANIFEST	Higher	1801, 0.341, South
AZ419	WHITE PLAINS HOSPITA	41 EAST POST ROAD	NY LTANKS	Higher	1801, 0.341, South
BA420	CON ED HOLE # TM 251	MARTINE AVE WEST OF	NY LTANKS, NY Spills	Higher	1805, 0.342, East
AV421	N.Y. TELEPHONE	40 WASHINGTON AVE.	NY LTANKS, NY AST, NY Spills	Higher	1812, 0.343, West
AV422	N.Y. TELEPHONE	40 WASHINGTON AVE.	UST FINDER RELEASE	Higher	1812, 0.343, West
BB423	AUTOMOBILE CLUB OF N	101 WESTMORELAND AVE	NY SHWS, NY ENG CONTROLS, NY INST CONTROL, NY...	Higher	1856, 0.352, SW
BC424	LASALLE PARTNERS	1 NORTH BROADWAY	NY LTANKS	Higher	1904, 0.361, ENE
BD425	GREENRIDGE ESTATES	1-13 GREENRIDGE AVE	NY LTANKS	Higher	1904, 0.361, SE
BD426	GREENRIDGE ESTATES C	1-13 GREENRIDGE AVE	NY LTANKS	Higher	1904, 0.361, SE
BE427	OFFICE BLDG - TTF	203 MAMARONECK AVE	NY LTANKS, NY Spills	Higher	1907, 0.361, SE
428	WHITE PLAINS HOSPITA	8 LONGVIEW AVE	NY LTANKS, NY Spills	Higher	1917, 0.363, SSE
429	240 EAST POST RD	240 EAST POST RD	NY LTANKS	Higher	1920, 0.364, ESE

MAPPED SITES SUMMARY

Target Property Address:
100 MAIN STREET
WHITE PLAINS, NY 10601

Click on Map ID to see full detail.

MAP ID	SITE NAME	ADDRESS	DATABASE ACRONYMS	RELATIVE ELEVATION	DIST (ft. & mi.) DIRECTION
BF430	15 NORTH BROADWAY	15 NORTH BROADWAY	NY LTANKS, NY Spills	Higher	1926, 0.365, NE
BC431	ES GORDON	7-11 SOUTH BROADWAY	NY LTANKS	Higher	1935, 0.366, ENE
BG432	SPILL NUMBER 0103645	12 EAST POST RD	NY LTANKS	Higher	1942, 0.368, South
BA433	BART GOLDBERG APT. B	277 MARTINE AVE	NY LTANKS	Higher	1950, 0.369, East
AZ434	HOSPITAL (UNK NAME)	41 EAST COAST ROAD	NY LTANKS	Higher	1961, 0.371, SSE
BH435	VILLE HOME	167 HARDING AVE	NY LTANKS	Higher	1969, 0.373, West
436	GOMES RESIDENCE	140 HARDING AVE	NY LTANKS	Higher	1970, 0.373, West
BI437	WHITE PLAINS HOSPITA	MAPLE AVE	NY LTANKS	Higher	1975, 0.374, ENE
BG438	SPILL NUMBER 8600048	11 EAST POST ROAD	NY LTANKS	Higher	1981, 0.375, South
BG439	GETTY SERVICE STATIO	11 EAST POST ROAD	UST FINDER RELEASE	Higher	1981, 0.375, South
BG440	GETTY GAS #58108	11 EAST POST ROAD	UST FINDER RELEASE	Higher	1981, 0.375, South
BG441	SPILL NUMBER 8600048	11 EAST POST ROAD	UST FINDER RELEASE	Higher	1981, 0.375, South
BG442	GETTY # 58108	11 EAST POST ROAD	UST FINDER RELEASE	Higher	1981, 0.375, South
BG443	GETTY GAS #58108	11 EAST POST ROAD	NY LTANKS	Higher	1981, 0.375, South
BG444	GETTY 58108	11 EAST POST ROAD	UST FINDER RELEASE	Higher	1981, 0.375, South
BG445	GETTY #58108	11 EAST POST ROAD	UST FINDER RELEASE	Higher	1981, 0.375, South
BH446	W2 POLE	155 HARDING AVE	NY LTANKS, NY Spills	Higher	1986, 0.376, West
447	LAZZARO	47 PARK AVE	NY LTANKS	Higher	1988, 0.377, North
BJ448	PDUZZI - TTF	188 CHURCH ST	NY LTANKS	Higher	2008, 0.380, North
BE449	WHITE PLAINS-FIRE HO	MAMARONECK & MAPLE A	NY LTANKS	Higher	2015, 0.382, SE
BE450	WHITE PLAINS DPW	MAPLE & MAMARONECK A	UST FINDER RELEASE	Higher	2015, 0.382, SE
BE451	WHITE PLAINS DPW	MAPLE & MAMARONECK A	NY LTANKS	Higher	2015, 0.382, SE
BB452	SEACON METAL - TTF	7 INTERVALE STREET	NY LTANKS	Higher	2036, 0.386, SW
BK453	35 PARK AVENUE	35 PARK AVENUE	NY LTANKS	Higher	2045, 0.387, North
BA454	SPILL NUMBER 0206553	300 MARTINE AVE	NY LTANKS, NY Spills	Higher	2052, 0.389, East
BG455	SPILL NUMBER 0013009	1 EAST POST RD	NY LTANKS	Higher	2058, 0.390, South
BD456	JOHN LWHITE CONDO	9 GREENRIDGE AVE	NY LTANKS	Higher	2059, 0.390, SE
457	PIRRO, MONSELL REALT	40 WALLER AVE	NY LTANKS	Higher	2076, 0.393, ESE
BL458	APT BUILDING	16 NORTH BROADWAY	NY LTANKS, NY Spills	Higher	2087, 0.395, ENE
BF459	BUILDING	20 NORTH BROADWAY	NY LTANKS, NY Spills	Higher	2088, 0.395, ENE
BL460	CON ED	10 NORTH BROADWAY	NY LTANKS, NY Spills, NY MANIFEST	Higher	2091, 0.396, ENE
BG461	BISCARDI CLEANERS	201 SO. LEXINGTON AV	NY LTANKS, NY Spills, NY DRYCLEANERS	Higher	2095, 0.397, South
BM462	HART RESIDENCE	77 PARK AVE	NY LTANKS	Higher	2101, 0.398, NNW
463	PARKER RES	3 WYANOKE STREET	NY LTANKS	Higher	2101, 0.398, SSW
BC464	PATRIOT MANAGEMENT	2 WESTCHESTER AVE	NY LTANKS, NY Spills	Higher	2108, 0.399, ENE
BM465	GABERIAL	7 FAIRVIEW AVE	NY LTANKS	Higher	2128, 0.403, NNW
BJ466	SPILL NUMBER 0209590	25 PARK AVE	NY LTANKS	Higher	2135, 0.404, North
BN467	WHITE PLAINS PRESBYT	39 NORTH BROADWAY	NY LTANKS	Higher	2139, 0.405, NE
BO468	UNK HOMEOWNER	163 FISHER AVE	NY LTANKS	Higher	2141, 0.405, SW

MAPPED SITES SUMMARY

Target Property Address:
100 MAIN STREET
WHITE PLAINS, NY 10601

Click on Map ID to see full detail.

MAP ID	SITE NAME	ADDRESS	DATABASE ACRONYMS	RELATIVE ELEVATION	DIST (ft. & mi.) DIRECTION
BI469	PATRIOT MANAGEMENT:	12 WESTCHESTER AVE	NY LTANKS, NY Spills	Higher	2154, 0.408, ENE
BP470	AVIS	20 WEST POST RD	UST FINDER RELEASE	Higher	2161, 0.409, South
BP471	AVIS	20 WEST POST RD	NY LTANKS	Higher	2161, 0.409, South
BQ472	PBS TTF	235 MAMARONECK AVE	NY LTANKS, NY Spills	Higher	2176, 0.412, SE
BR473	PRIVATE RES	3 LAKE VIEW DR NORTH	NY LTANKS	Higher	2216, 0.420, NE
BS474	JEFFERSON APTS	64 JEFFERSON AVE	NY LTANKS	Higher	2218, 0.420, West
BN475	@	44 NORTH BROADWAY	NY LTANKS, NY Spills	Higher	2226, 0.422, NE
BK476	SPILL NUMBER 9909558	7 PARK CIRCLE	NY LTANKS	Higher	2227, 0.422, North
BS477	BARILE RESIDENCE	75 JEFFERSON AVE	NY LTANKS	Higher	2239, 0.424, West
478	MITCHELL ESTATE - TT	5 NUTGROVE ST	NY LTANKS	Higher	2241, 0.424, SSW
BS479	SPILL NUMBER 9808775	48 JEFFERSON AVE	NY LTANKS	Higher	2253, 0.427, West
480	RESIDENCE	25 LONGVIEW AVE	NY LTANKS	Higher	2273, 0.430, SSE
BN481	APT. BUILDING	50 NORTH BROADWAY	NY LTANKS, NY Spills	Higher	2279, 0.432, NE
BP482	WHITE PLAINS LINC/ME	25 WEST COAST RD	NY LTANKS	Higher	2280, 0.432, South
BQ483	YMCA OF CENTRAL & NO	250 MAMARONECK AVENU	NY LTANKS, NY CBS, NY BROWNFIELDS, NY Spills, NY...	Higher	2285, 0.433, SE
BQ484	WHITE PLAINS YMCA	250 MAMARONECK AVE	NY LTANKS	Higher	2285, 0.433, SE
485	WHITE PLAINS MED CEN	170 MAPLE AVE	NY LTANKS	Higher	2290, 0.434, South
BR486	BUSINESS	7 LAKE STREET	NY LTANKS, NY Spills	Higher	2319, 0.439, NE
BO487	179 FISHER AVE	179 FISHER AVE	NY LTANKS	Higher	2324, 0.440, SW
488	SPILL NUMBER 8807217	52 NORTH BROADWAY	NY LTANKS	Higher	2350, 0.445, NNE
BT489	CON ED	300 MAIN ST	NY LTANKS, NY MANIFEST	Higher	2367, 0.448, ENE
BU490	ATI	RTE 100 CENTRAL AVE	UST FINDER RELEASE	Lower	2368, 0.448, NW
BU491	NEWMARK AND LEWIS PR	111 S.CENTRAL PARK A	NY LTANKS	Lower	2369, 0.449, NW
492	REAL ESTATE TRANS -	14 JEFFERSON AVE	NY LTANKS	Higher	2373, 0.449, West
BU493	COUNTRY CENTER	CENTRAL AVE	NY LTANKS	Lower	2384, 0.452, NW
494	REALTY TRANSACTION	52 PARK CIRCLE	NY LTANKS	Higher	2411, 0.457, NNW
BT495	RESIDENCE	325 MAIN ST	NY LTANKS	Higher	2416, 0.458, ENE
496	SUBODH DESHMUKH RESI	39 PARKVIEW CT	NY LTANKS	Higher	2422, 0.459, NNE
497	CROWN PLAZA HOTEL	66 HALE AVE	NY LTANKS	Lower	2426, 0.459, East
BV498	FIRE HOUSE # 4	MAPLE AVE & S LEXING	NY LTANKS	Higher	2432, 0.461, South
499	RESIDENCE	84 LINCOLN AVE	NY LTANKS	Higher	2437, 0.462, West
BS500	SMITH - TTF	70 LINCOLN AVE	NY LTANKS	Higher	2454, 0.465, West
BU501	WESTCHESTER COUNTY A	HANGER A	NY LTANKS, NY Spills	Lower	2454, 0.465, NW
BU502	WESTCHESTER COUNTY A	HANGER E - TELLER RO	NY LTANKS	Lower	2454, 0.465, NW
BU503	WESTCHESTER COUNTY A	AVITAT RAMP	NY LTANKS	Lower	2454, 0.465, NW
504	BERTE HOME	3 CHURCH COURT	NY LTANKS	Higher	2464, 0.467, North
BW505	9 LAFAYETTE STREET	9 LAFAYETTE STREET	NY LTANKS	Higher	2471, 0.468, SW
506	YWCA	69 NORTH BROADWAY	NY LTANKS	Higher	2486, 0.471, NNE
507	WHITE PLAINS PROJECT	179 WESTMORELAND AVE	NY LTANKS, NY Spills	Higher	2489, 0.471, SW

MAPPED SITES SUMMARY

Target Property Address:
100 MAIN STREET
WHITE PLAINS, NY 10601

Click on Map ID to see full detail.

MAP ID	SITE NAME	ADDRESS	DATABASE ACRONYMS	RELATIVE ELEVATION	DIST (ft. & mi.) DIRECTION
BW508	PVT DWELLING	195 FISHER AVE	NY LTANKS	Higher	2497, 0.473, SW
509	APARTMENT BLDG	21 GREENRIDGE AVE	NY LTANKS, NY Spills	Higher	2517, 0.477, SSE
510	3-5 FRANKLIN AVE	3-5 FRANKLIN AVE	NY LTANKS, NY Spills	Lower	2533, 0.480, ENE
511	APT BUILDING	16 LAKE STREET	NY LTANKS	Higher	2548, 0.483, NE
512	ROADWAY	285 MAMARONECK AVE	NY LTANKS, NY Spills	Higher	2553, 0.484, SE
513	POST ROAD CORRIDOR -	77 WEST POST ROAD	NY BROWNFIELDS	Higher	2597, 0.492, SSW
BV514	WHITE PLAINS FD STAT	234 SOUTH LEXINGTON	NY LTANKS	Higher	2611, 0.495, South
515	SPILL NUMBER 9812431	88-90 CHATTERTON AVE	NY LTANKS	Higher	2615, 0.495, WNW
BX516	WESTCHESTER SHOPPING	WEST AVE & PAWLING S	NY LTANKS	Lower	2616, 0.495, East
BX517	WHITE PLAINS CHRYSLE	70 WESTCHESTER AVENU	NY BROWNFIELDS, NY Spills, NY PFAS	Lower	2621, 0.496, East
BV518	GREAT GRANT MANOR PR	235 SOUTH LEXINGTON	NY LTANKS	Higher	2640, 0.500, South
519	MAMARONECK AVENUE DR	359-369 MAMARONECK A	NY SHWS, NY Spills	Higher	3169, 0.600, SE

EXECUTIVE SUMMARY

TARGET PROPERTY SEARCH RESULTS

The target property was identified in the following records. For more information on this property see page 9 of the attached EDR Radius Map report:

Site	Database(s)	EPA ID
100 MAIN ST 100 MAIN ST WHITE PLAINS, NY 10601	MI MANIFEST	N/A
MACYS WHITE PLAINS C 100 MAIN ST WHITE PLAINS, NY 10601	FINDS Registry ID:: 110054890347 ECHO Registry ID: 110054890347	N/A
J C PENNEY CO INC 100 MAIN ST WHITE PLAINS, NY 10601	RCRA NonGen / NLR EPA ID:: NYR000120329 FINDS Registry ID:: 110009462553 ECHO Registry ID: 110009462553 E MANIFEST	NYR000120329
100 E. MAIN ST 100 E. MAIN ST WHITE PLAINS, NY 10601	NY COOLING TOWERS	N/A
GALLERIA MALL DENTAL 100 MAIN STREET WHITE PLAINS, NY 10601	E MANIFEST	N/A
JC PENNEY 100 MAIN ST. WHITE PLAINS, NY 10601	NY UST Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024 Status: 4. Closed - in place Id/Status:: 3-600104 Site Status: Unregulated: <1101 gal. PBS	N/A
SEARS ROEBUCK & CO. 100 MAIN STREET WHITE PLAINS, NY 10601	RCRA-VSQG EPA ID:: NY0000923193 E MANIFEST	NY0000923193
C P I PHOTO FINISH 100 MAIN ST STE 301 WHITE PLAINS, NY 10601	RCRA NonGen / NLR EPA ID:: NYR000034082 FINDS	NYR000034082

Registry ID:: 110004531374

ECHO
Registry ID: 110004531374

PICTURE PEOPLE THE
100 MAIN ST SPACE 32
WHITE PLAINS, NY 10603

RCRA-SQG NYR000084806
EPA ID:: NYR000084806

FINDS
Registry ID:: 110004561402

ECHO
Registry ID: 110004561402

NY MANIFEST
EPA ID: NYR000084806

100 MAIN STREET
100 MAIN STREET
WHITE PLAINS, NY 10601

NY COOLING TOWERS N/A

100 MAIN STREET
100 MAIN STREET
WHITE PLAINS, NY 10601

NY COOLING TOWERS N/A

J.C. PENNEY
100 MAIN ST
WHITE PLAINS, NY 10601

NY UST N/A
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024
Status: 4. Closed - in place
Status: 5. Tank converted to Non-Regulated use
Id/Status:: 3-173665
Site Status: Unregulated: <1101 gal. PBS

LENSCRAFTERS #0787
100 MAIN ST
WHITE PLAINS, NY 10601

E MANIFEST N/A

J C PENNEY CO INC
100 MAIN ST
WHITE PLAINS, NY 10601

NY LTANKS NY0000806901
Spill Number/Closed Date: 9102767 / 1991-06-13
Site ID: 137993
Spill Date: 1991-06-10

NY Spills
Spill Number/Closed Date: 0703055 / 2007-06-14
Spill Number/Closed Date: 0211359 / 2005-02-27
Spill Number/Closed Date: 9204133 / 1992-08-04
Spill Number/Closed Date: 0302779 / 2003-06-16
Site ID: 382912
Site ID: 104864
Site ID: 137995
Site ID: 137992
Spill Date: 2007-06-13

	Spill Date: 2003-02-13 Spill Date: 1992-07-10 Spill Date: 2003-06-16 RCRA NonGen / NLR EPA ID:: NY0000806901 NY MANIFEST EPA ID: NY0000806901	
100 E. MAIN ST 100 E. MAIN ST WHITE PLAINS, NY 10601	NY COOLING TOWERS	N/A
GALLERIA OF WHITE PL 100 MAIN STREET WHITE PLAINS, NY 10601	FINDS Registry ID:: 110019206599	N/A
SEARS 100 MAIN ST WHITE PLAINS, NY 10601	E MANIFEST	N/A
EXPRESSLY PORTRAITS 100 MAIN ST - GALLER WHITE PLAINS, NY 10603	RCRA NonGen / NLR EPA ID:: NY0000969121 FINDS Registry ID:: 110004322849 ECHO Registry ID: 110004322849 NY MANIFEST EPA ID: NY0000969121	NY0000969121
MACY'S EAST #55 100 MAIN ST WHITE PLAINS, NY 10601	NY MANIFEST EPA ID: NYR000120329	N/A
MACYS - WHITE PLAINS 100 MAIN ST WHITE PLAINS, NY 10601	FINDS Registry ID:: 110016725748 ECHO Registry ID: 110016725748	N/A
THE GALLERIA AT WHIT 100 MAIN STREET WHITE PLAINS, NY 10601	NY UST Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024 Status: 4. Closed - in place Id/Status:: 3-492205 Site Status: Unregulated: <1101 gal. PBS	N/A

EXECUTIVE SUMMARY

DATABASES WITH NO MAPPED SITES

No mapped sites were found in EDR's search of available ("reasonably ascertainable ") government records either on the target property or within the search radius around the target property for the following databases:

STANDARD ENVIRONMENTAL RECORDS

Lists of Federal NPL (Superfund) sites

NPL ---------- National Priority List
Proposed NPL ---------- Proposed National Priority List Sites
NPL LIENS ---------- Federal Superfund Liens

Lists of Federal Delisted NPL sites

Delisted NPL ---------- National Priority List Deletions

Lists of Federal sites subject to CERCLA removals and CERCLA orders

FEDERAL FACILITY ---------- Federal Facility Site Information listing
SEMS ---------- Superfund Enterprise Management System

Lists of Federal CERCLA sites with NFRAP

SEMS-ARCHIVE ---------- Superfund Enterprise Management System Archive

Lists of Federal RCRA facilities undergoing Corrective Action

CORRACTS ---------- Corrective Action Report

Lists of Federal RCRA TSD facilities

RCRA-TSDF ---------- RCRA - Treatment, Storage and Disposal

Federal institutional controls / engineering controls registries

LUCIS ---------- Land Use Control Information System
US ENG CONTROLS ---------- Engineering Controls Sites List
US INST CONTROLS ---------- Institutional Controls Sites List

Federal ERNS list

ERNS ---------- Emergency Response Notification System

Lists of state and tribal landfills and solid waste disposal facilities

NY SWF/LF ---------- Facility Register

Lists of state and tribal leaking storage tanks

INDIAN LUST ---------- Leaking Underground Storage Tanks on Indian Land

NY HIST LTANKS Listing of Leaking Storage Tanks

Lists of state and tribal registered storage tanks

FEMA UST Underground Storage Tank Listing
NY CBS UST Chemical Bulk Storage Database
NY MOSF UST Major Oil Storage Facilities Database
NY MOSF Major Oil Storage Facility Site Listing
NY CBS AST Chemical Bulk Storage Database
NY MOSF AST Major Oil Storage Facilities Database
INDIAN UST Underground Storage Tanks on Indian Land
NY TANKS Storage Tank Faciliy Listing

State and tribal institutional control / engineering control registries

NY RES DECL Restrictive Declarations Listing

Lists of state and tribal voluntary cleanup sites

INDIAN VCP Voluntary Cleanup Priority Listing

Lists of state and tribal brownfield sites

NY ERP Environmental Restoration Program Listing

ADDITIONAL ENVIRONMENTAL RECORDS

Local Brownfield lists

US BROWNFIELDS A Listing of Brownfields Sites

Local Lists of Landfill / Solid Waste Disposal Sites

NY SWRCY Registered Recycling Facility List
NY SWTIRE Registered Waste Tire Storage & Facility List
INDIAN ODI Report on the Status of Open Dumps on Indian Lands
DEBRIS REGION 9 Torres Martinez Reservation Illegal Dump Site Locations
ODI Open Dump Inventory
IHS OPEN DUMPS Open Dumps on Indian Land

Local Lists of Hazardous waste / Contaminated Sites

US HIST CDL Delisted National Clandestine Laboratory Register
NY DEL SHWS Delisted Registry Sites
US CDL National Clandestine Laboratory Register

Local Lists of Registered Storage Tanks

NY HIST UST Historical Petroleum Bulk Storage Database
NY HIST AST Historical Petroleum Bulk Storage Database

Local Land Records

NY LIENS Spill Liens Information

LIENS 2 ---------- CERCLA Lien Information

Records of Emergency Release Reports

HMIRS ---------- Hazardous Materials Information Reporting System
NY Hist Spills ---------- SPILLS Database
NY SPILLS 90 ---------- SPILLS 90 data from FirstSearch
NY SPILLS 80 ---------- SPILLS 80 data from FirstSearch

Other Ascertainable Records

FUDS ---------- Formerly Used Defense Sites
DOD ---------- Department of Defense Sites
SCRD DRYCLEANERS ---------- State Coalition for Remediation of Drycleaners Listing
US FIN ASSUR ---------- Financial Assurance Information
EPA WATCH LIST ---------- EPA WATCH LIST
2020 COR ACTION ---------- 2020 Corrective Action Program List
TRIS ---------- Toxic Chemical Release Inventory System
SSTS ---------- Section 7 Tracking Systems
ROD ---------- Records Of Decision
RMP ---------- Risk Management Plans
RAATS ---------- RCRA Administrative Action Tracking System
PRP ---------- Potentially Responsible Parties
PADS ---------- PCB Activity Database System
ICIS ---------- Integrated Compliance Information System
FTTS ---------- FIFRA/ TSCA Tracking System - FIFRA (Federal Insecticide, Fungicide, & Rodenticide Act)/TSCA (Toxic Substances Control Act)
MLTS ---------- Material Licensing Tracking System
COAL ASH DOE ---------- Steam-Electric Plant Operation Data
COAL ASH EPA ---------- Coal Combustion Residues Surface Impoundments List
PCB TRANSFORMER ---------- PCB Transformer Registration Database
RADINFO ---------- Radiation Information Database
HIST FTTS ---------- FIFRA/TSCA Tracking System Administrative Case Listing
DOT OPS ---------- Incident and Accident Data
CONSENT ---------- Superfund (CERCLA) Consent Decrees
INDIAN RESERV ---------- Indian Reservations
UMTRA ---------- Uranium Mill Tailings Sites
LEAD SMELTERS ---------- Lead Smelter Sites
US MINES ---------- Mines Master Index File
ABANDONED MINES ---------- Abandoned Mines
MINES MRDS ---------- Mineral Resources Data System
DOCKET HWC ---------- Hazardous Waste Compliance Docket Listing
UXO ---------- Unexploded Ordnance Sites
PFAS NPL ---------- Superfund Sites with PFAS Detections Information
PFAS FEDERAL SITES ---------- Federal Sites PFAS Information
PFAS TRIS ---------- List of PFAS Added to the TRI
PFAS TSCA ---------- PFAS Manufacture and Imports Information
PFAS RCRA MANIFEST ---------- PFAS Transfers Identified In the RCRA Database Listing
PFAS ATSDR ---------- PFAS Contamination Site Location Listing
PFAS WQP ---------- Ambient Environmental Sampling for PFAS
PFAS PROJECT ---------- NORTHEASTERN UNIVERSITY PFAS PROJECT
PFAS NPDES ---------- Clean Water Act Discharge Monitoring Information
PFAS ECHO ---------- Facilities in Industries that May Be Handling PFAS Listing
PFAS ECHO FIRE TRAIN ---------- Facilities in Industries that May Be Handling PFAS Listing
PFAS PT 139 AIRPORT ---------- All Certified Part 139 Airports PFAS Information Listing

AQUEOUS FOAM NRC Aqueous Foam Related Incidents Listing
BIOSOLIDS ICIS-NPDES Biosolids Facility Data
NY COAL ASH Coal Ash Disposal Site Listing
NY E DESIGNATION E DESIGNATION SITE LISTING
NY Financial Assurance Financial Assurance Information Listing
NY HSWDS Hazardous Substance Waste Disposal Site Inventory
NY LEAD Lead-based Paint Testing Results
NY VAPOR REOPENED Vapor Intrusion Legacy Site List
NY UIC Underground Injection Control Wells
NY ILI New York State Inactive Landfill Initiative
NY NYC OER OER Cleanup Sites Listing
NY NYC LAND USE New York City Land Use Information

EDR RECOVERED GOVERNMENT ARCHIVES

Exclusive Recovered Govt. Archives

NY RGA HWS Recovered Government Archive State Hazardous Waste Facilities List
NY RGA LF Recovered Government Archive Solid Waste Facilities List

SURROUNDING SITES: SEARCH RESULTS

Surrounding sites were identified in the following databases.

Elevations have been determined from the USGS Digital Elevation Model and should be evaluated on a relative (not an absolute) basis. Relative elevation information between sites of close proximity should be field verified. Sites with an elevation equal to or higher than the target property have been differentiated below from sites with an elevation lower than the target property.
Page numbers and map identification numbers refer to the EDR Radius Map report where detailed data on individual sites can be reviewed.

Sites listed in ***bold italics*** are in multiple databases.

Unmappable (orphan) sites are not considered in the foregoing analysis.

STANDARD ENVIRONMENTAL RECORDS

Lists of Federal RCRA generators

RCRA-LQG: RCRAInfo is EPA's comprehensive information system, providing access to data supporting the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. The database includes selective information on sites which generate, transport, store, treat and/or dispose of hazardous waste as defined by the Resource Conservation and Recovery Act (RCRA). Large quantity generators (LQGs) generate over 1,000 kilograms (kg) of hazardous waste, or over 1 kg of acutely hazardous waste per month.

A review of the RCRA-LQG list, as provided by EDR, and dated 09/16/2024 has revealed that there are 2 RCRA-LQG sites within approximately 0.25 miles of the target property.

Equal/Higher Elevation	Address	Direction / Distance	Map ID	Page
CON EDISON MANHOLE: EPA ID:: NYP004303764	***LEXINGTON AVE & E MA***	***WNW 0 - 1/8 (0.011 mi.)***	***C37***	***137***
CON EDISON MANHOLE:	***221 MAIN ST***	***ENE 1/8 - 1/4 (0.168 mi.)***	***U239***	***901***

EPA ID:: NYP004308268

RCRA-SQG: RCRAInfo is EPA's comprehensive information system, providing access to data supporting the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. The database includes selective information on sites which generate, transport, store, treat and/or dispose of hazardous waste as defined by the Resource Conservation and Recovery Act (RCRA). Small quantity generators (SQGs) generate between 100 kg and 1,000 kg of hazardous waste per month.

A review of the RCRA-SQG list, as provided by EDR, and dated 09/16/2024 has revealed that there are 5 RCRA-SQG sites within approximately 0.25 miles of the target property.

Equal/Higher Elevation	Address	Direction / Distance	Map ID	Page
MICHAELIAN OFFICE BU EPA ID:: NYD072705213	***148 MARTINE AVE***	***ESE 0 - 1/8 (0.106 mi.)***	***O120***	***374***
WHITE PLAINS SUBSTAT EPA ID:: NYR000023275	***9 NEW STREET***	***NW 0 - 1/8 (0.118 mi.)***	***N171***	***498***
WINBROOK APARTMENTS EPA ID:: NYR000258236	***11 FISHER AVE***	***SSW 1/8 - 1/4 (0.206 mi.)***	***AG325***	***1116***
A T & T EPA ID:: NYD986998060	***360 HAMILTON AVE***	***NE 1/8 - 1/4 (0.247 mi.)***	***AN364***	***1202***

Lower Elevation	Address	Direction / Distance	Map ID	Page
WHITE PLAINS HOUSING EPA ID:: NYR000258293	***33 FISHER AVE***	***NNE 0 - 1/8 (0.083 mi.)***	***G97***	***322***

RCRA-VSQG: RCRAInfo is EPA's comprehensive information system, providing access to data supporting the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. The database includes selective information on sites which generate, transport, store, treat and/or dispose of hazardous waste as defined by the Resource Conservation and Recovery Act (RCRA). Very small quantity generators (VSQGs) generate less than 100 kg of hazardous waste, or less than 1 kg of acutely hazardous waste per month.

A review of the RCRA-VSQG list, as provided by EDR, and dated 09/16/2024 has revealed that there are 8 RCRA-VSQG sites within approximately 0.25 miles of the target property.

Equal/Higher Elevation	Address	Direction / Distance	Map ID	Page
RNG PADD 1 EPA ID:: NYD986984698	***1 N LEXINGTON AVE***	***WNW 0 - 1/8 (0.015 mi.)***	***C46***	***162***
WESTCHESTER COUNTY C EPA ID:: NYR000124206	110 DR MARTIN LUTHER	SE 0 - 1/8 (0.123 mi.)	Q190	570
EXXON DIV OF CFI #70 EPA ID:: NYD013387436	***274 HAMILTON AVE & C***	***NE 1/8 - 1/4 (0.157 mi.)***	***P226***	***832***
CVS EPA ID:: NYR000194852	***24 MAMARONECK AVENUE***	***E 1/8 - 1/4 (0.165 mi.)***	***U231***	***855***
PEPE MOTORS INC EPA ID:: NYD056298037	***50 BANK ST***	***SW 1/8 - 1/4 (0.185 mi.)***	***AC285***	***1031***
CON EDISON	COTTAGE PL & BARKER	NNE 1/8 - 1/4 (0.198 mi.)	AD305	1079

EPA ID:: NYP005249790

T S T WHITE PLAINS L	***220 MAIN ST***	***ENE 1/8 - 1/4 (0.245 mi.)***	***AH359***	***1188***
EPA ID:: NYN008016099				

Lower Elevation	Address	Direction / Distance	Map ID	Page
NEW YORK POWER AUTHO	***123 MAIN ST***	***ENE 0 - 1/8 (0.030 mi.)***	***B56***	***212***
EPA ID:: NYD986982999				

Lists of state- and tribal hazardous waste facilities

NY SHWS: The State Hazardous Waste Sites records are the states' equivalent to CERCLIS. These sites may or may not already be listed on the federal CERCLIS list. Priority sites planned for cleanup using state funds (state equivalent of Superfund) are identified along with sites where cleanup will be paid for by potentially responsible parties. The data come from the Department of Environmental Conservation's Inactive Hazardous waste Disposal Sites in New York State.

A review of the NY SHWS list, as provided by EDR, and dated 11/04/2024 has revealed that there are 2 NY SHWS sites within approximately 1 mile of the target property.

Equal/Higher Elevation	Address	Direction / Distance	Map ID	Page
AUTOMOBILE CLUB OF N	***101 WESTMORELAND AVE***	***SW 1/4 - 1/2 (0.352 mi.)***	***BB423***	***1358***
Site Code: 374633				
MAMARONECK AVENUE DR	***359-369 MAMARONECK A***	***SE 1/2 - 1 (0.600 mi.)***	***519***	***1596***
Site Code: 387008				

Lists of state and tribal leaking storage tanks

NY LTANKS: Leaking Storage Tank Incident Reports. These records contain an inventory of reported leaking storage tank incidents reported from 4/1/86 through the most recent update. They can be either leaking underground storage tanks or leaking aboveground storage tanks. The causes of the incidents are tank test failures, tank failures or tank overfills

A review of the NY LTANKS list, as provided by EDR, and dated 11/03/2024 has revealed that there are 174 NY LTANKS sites within approximately 0.5 miles of the target property.

Equal/Higher Elevation	Address	Direction / Distance	Map ID	Page
1 NORTH LEXINGTON AV	***1 NORTH LEXINGTON AV***	***WNW 0 - 1/8 (0.015 mi.)***	***C43***	***151***
Spill Number/Closed Date: 8908197 / 1990-01-29				
Spill Number/Closed Date: 9000726 / 1991-12-06				
Spill Number/Closed Date: 9108659 / 1991-11-13				
Site ID: 276348				
Site ID: 131721				
Site ID: 255792				
Spill Date: 1989-11-16				
Spill Date: 1990-04-20				
Spill Date: 1991-11-13				
77 SOUTH LEXINGTON A	***77 SOUTH LEXINGTON A***	***SSW 0 - 1/8 (0.075 mi.)***	***D92***	***315***

Spill Number/Closed Date: 0304231 / 2003-07-22
Site ID: 106697
Spill Date: 2003-07-22

VINTAGE RESTAURANT | 171-173 MAIN STREET | ENE 0 - 1/8 (0.079 mi.) | K95 | 318
Spill Number/Closed Date: 0602861 / 2008-09-26
Site ID: 365437
Spill Date: 2006-06-14

RESIDENCE | 185- 187 MAIN ST | ENE 0 - 1/8 (0.100 mi.) | K109 | 345
Spill Number/Closed Date: 9708138 / 1997-11-10
Site ID: 81930
Spill Date: 1997-10-09

MICHAEL E LAND OFFIC | 148 MARTINE AVE | ESE 0 - 1/8 (0.106 mi.) | O116 | 359
Spill Number/Closed Date: 0109874 / 2002-01-14
Spill Number/Closed Date: 0503295 / 2005-09-26
Site ID: 126439
Site ID: 347878
Spill Date: 2002-01-11
Spill Date: 2005-06-17

COMMERICAL BUILDING | 10 NEW KING STREET | NW 0 - 1/8 (0.111 mi.) | N142 | 442
Spill Number/Closed Date: 1006070 / 2010-10-28
Site ID: 439407
Spill Date: 2010-09-01

OFFICE BLDG | 4 NEW KING ST | NW 0 - 1/8 (0.111 mi.) | N145 | 445
Spill Number/Closed Date: 9809692 / 2003-12-05
Site ID: 170684
Spill Date: 1998-11-02

INTERSECTION OF COUR | COURT ST. & MARITINE | E 0 - 1/8 (0.116 mi.) | O157 | 466
Spill Number/Closed Date: 8905963 / 1989-11-29
Site ID: 187446
Spill Date: 1989-09-18

THE MICHICALLIAN OFF | MARTINE AVE & COURT | E 0 - 1/8 (0.116 mi.) | O163 | 476
Spill Number/Closed Date: 9310783 / 1993-11-18
Site ID: 276042
Spill Date: 1993-11-16

WEST HEALTH DEPT | 148 MARTINE AVE | ESE 0 - 1/8 (0.117 mi.) | O165 | 480
Spill Number/Closed Date: 8701223 / 2004-11-06
Site ID: 126440
Spill Date: 1987-05-13

COMMERCIAL | 3 NEW KING STREET | NW 0 - 1/8 (0.119 mi.) | N178 | 543
Spill Number/Closed Date: 1600651 / 2017-04-04
Spill Number/Closed Date: 0806330 / 2010-03-30
Site ID: 525932
Site ID: 403607
Spill Date: 2016-04-19
Spill Date: 2008-09-05

PBS TTF | 1 NEW KING STREET | NW 0 - 1/8 (0.119 mi.) | N180 | 547
Spill Number/Closed Date: 0000953 / 2001-02-07
Site ID: 272947
Spill Date: 2000-04-24

OUR LADY OF MOUNT CA | 92 SOUTH LEXINGTON A | SSW 1/8 - 1/4 (0.135 mi.) | L197 | 584
Spill Number/Closed Date: 1100855 / 2012-01-23

Spill Number/Closed Date: 8703713 / 1987-10-21
Spill Number/Closed Date: 8704169 / 1987-10-21
Site ID: 448286
Site ID: 239739
Site ID: 219315
Spill Date: 2011-04-25
Spill Date: 1987-08-05
Spill Date: 1987-08-20

WHITE PLAINS POLICE	***279 HAMILTON AVENUE***	***NE 1/8 - 1/4 (0.148 mi.)***	***T215***	***810***
Spill Number/Closed Date: 8606771 / 1989-11-29 Site ID: 92789 Spill Date: 1987-02-04				
MINSKOFF CORP.	179 MARTINE AVE	E 1/8 - 1/4 (0.148 mi.)	O217	814
Spill Number/Closed Date: 9201879 / 1992-05-15 Site ID: 217944 Spill Date: 1992-05-15				
SPILL NUMBER 0206130	203 MAIN ST	ENE 1/8 - 1/4 (0.150 mi.)	U218	815
Spill Number/Closed Date: 0206130 / 2003-09-03 Site ID: 176565 Spill Date: 2002-09-12				
EXXON, WHITE PLAINS	***274 HAMILTON AVE***	***NE 1/8 - 1/4 (0.155 mi.)***	***T224***	***826***
Spill Number/Closed Date: 8707486 / 1987-12-18 Site ID: 190041 Spill Date: 1987-12-01				
FORMER WPPD	279 HAMITON AVE	NE 1/8 - 1/4 (0.156 mi.)	T225	831
Spill Number/Closed Date: 0405806 / 2007-07-06 Site ID: 306552 Spill Date: 1987-01-01				
CELESTILA GROUP	***14 MAMARONECK AVE***	***E 1/8 - 1/4 (0.162 mi.)***	***U227***	***841***
Spill Number/Closed Date: 0313324 / 2004-04-22 Spill Number/Closed Date: 9613653 / 1997-03-05 Site ID: 229197 Site ID: 284245 Spill Date: 2004-03-04 Spill Date: 1997-02-20				
INNS OF COURT	99 COURT ST	ESE 1/8 - 1/4 (0.167 mi.)	V233	887
Spill Number/Closed Date: 9606465 / 2006-02-28 Site ID: 204590 Spill Date: 1996-08-20				
OFFICE BLDG BASEMENT	150 GRAND STREET	SE 1/8 - 1/4 (0.174 mi.)	S258	959
Spill Number/Closed Date: 8908740 / 1990-02-07 Site ID: 307349 Spill Date: 1989-12-05				
COMMERCIAL BUSINESS	158 GRAND STREET	SE 1/8 - 1/4 (0.179 mi.)	S273	998
Spill Number/Closed Date: 0506649 / 2006-02-03 Spill Number/Closed Date: 0413115 / 2005-09-07 Site ID: 351900 Site ID: 338963 Spill Date: 2005-08-30 Spill Date: 2005-03-16				
PEPE MOTORS INC	***50 BANK ST***	***SW 1/8 - 1/4 (0.185 mi.)***	***AC285***	***1031***

Spill Number/Closed Date: 9607100 / 1999-04-29
Site ID: 284462
Spill Date: 1996-09-04

170 GRAND STREET ***170 GRAND STREET*** ***SE 1/8 - 1/4 (0.186 mi.)*** ***S287*** ***1047***
Spill Number/Closed Date: 0408227 / 2007-11-28
Site ID: 332894
Spill Date: 2004-10-26

SLADER NEIGHBORHOOD 2 FISHER CT SSE 1/8 - 1/4 (0.195 mi.) AE299 1069
Spill Number/Closed Date: 9810451 / 2003-12-05
Site ID: 214463
Spill Date: 1998-11-18

HAMILTON MAIN PARKIN HAMILTON AVE & MAIN ENE 1/8 - 1/4 (0.199 mi.) AB312 1093
Spill Number/Closed Date: 8707260 / 1989-11-29
Site ID: 286661
Spill Date: 1987-11-23

WHITE PLAINS HOUSING ***33 FISHER AVE*** ***SSW 1/8 - 1/4 (0.212 mi.)*** ***AG333*** ***1129***
Spill Number/Closed Date: 1007861 / 2011-07-05
Site ID: 441310
Spill Date: 2010-10-25

SILVERMAN REALITY 110 MAMARONECK AVE ESE 1/8 - 1/4 (0.223 mi.) AI337 1136
Spill Number/Closed Date: 0011270 / 2003-01-22
Site ID: 308222
Spill Date: 2001-01-16

CHURCH ***65 FISHER AVE*** ***SSW 1/8 - 1/4 (0.224 mi.)*** ***338*** ***1137***
Spill Number/Closed Date: 0509976 / 2006-12-20
Site ID: 355853
Spill Date: 2005-11-21

MITCHELL PLACE ASSOC 10 MITCHELL PLACE ESE 1/8 - 1/4 (0.227 mi.) AI340 1143
Spill Number/Closed Date: 8902485 / 1989-10-02
Site ID: 76057
Spill Date: 1989-06-09

GAS STATION ***9 MITCHELL PL*** ***ESE 1/8 - 1/4 (0.230 mi.)*** ***AI343*** ***1147***
Spill Number/Closed Date: 9710474 / 1998-10-27
Site ID: 199404
Spill Date: 1997-12-12

NICKY'S RESTAURANT 107 MAMARONECK AVE ESE 1/8 - 1/4 (0.234 mi.) AI347 1153
Spill Number/Closed Date: 8900599 / 1989-05-03
Site ID: 239748
Spill Date: 1989-04-19

DEVON PLAZA REALITY ***109 MAMARONECK AVE*** ***ESE 1/8 - 1/4 (0.236 mi.)*** ***AI348*** ***1155***
Spill Number/Closed Date: 9512203 / 1995-12-29
Site ID: 254450
Spill Date: 1995-12-29

WHITE PLAINS DEPT OF ***255 MAIN STREET*** ***ENE 1/8 - 1/4 (0.237 mi.)*** ***AH352*** ***1163***
Spill Number/Closed Date: 8707220 / 1988-03-14
Site ID: 294455
Spill Date: 1987-11-21

PER-BAR 124 MAMARONECK AVE ESE 1/8 - 1/4 (0.243 mi.) AK355 1173
Spill Number/Closed Date: 8802839 / 1989-01-18
Site ID: 116904
Spill Date: 1988-06-29

HYDRAULIC FLUID TO S ***134 SOUTH LEXINGTON*** ***S 1/8 - 1/4 (0.245 mi.)*** ***AG360*** ***1191***

Spill Number/Closed Date: 0008525 / 2001-03-12
Site ID: 218519
Spill Date: 2000-10-20

WINDBROOK HOUSING	223 DR MARTIN LUTHER	SSE 1/8 - 1/4 (0.250 mi.)	AO371	1235
Spill Number/Closed Date: 0207150 / 2002-11-25 Site ID: 243532 Spill Date: 2002-10-10				
WHITE PLAIN HOUSING	225 GROVE ST	SSE 1/4 - 1/2 (0.252 mi.)	AO372	1237
Spill Number/Closed Date: 8904683 / 1992-07-30 Site ID: 293104 Spill Date: 1989-08-10				
SPILL NUMBER 8809894	23 MITCHELL PLACE	E 1/4 - 1/2 (0.259 mi.)	AP373	1238
Spill Number/Closed Date: 8809894 / 1991-12-20 Site ID: 286069 Spill Date: 1989-03-23				
WESTCHESTER OFFICE B	112 EAST POST ROAD	SE 1/4 - 1/2 (0.259 mi.)	AQ374	1240
Spill Number/Closed Date: 9009334 / 1990-12-11 Site ID: 243138 Spill Date: 1990-11-27				
COMMERCIAL	130-144 EAST POST RD	SE 1/4 - 1/2 (0.260 mi.)	AQ375	1241
Spill Number/Closed Date: 0002215 / 2011-02-28 Site ID: 159846 Spill Date: 2000-05-22				
WHITE PLAINS HONDA	31 WESTMPORELAND AVE	SW 1/4 - 1/2 (0.262 mi.)	AR376	1242
Spill Number/Closed Date: 9514655 / 1996-02-15 Site ID: 224484 Spill Date: 1996-02-15				
SPILL NUMBER 9905959	25 MITCHELL PLACE	E 1/4 - 1/2 (0.263 mi.)	AP377	1243
Spill Number/Closed Date: 9905959 / 1999-10-08 Site ID: 111332 Spill Date: 1999-08-17				
MUNICIPAL GARAGE	111	SW 1/4 - 1/2 (0.264 mi.)	AR378	1245
Spill Number/Closed Date: 8808829 / 1991-08-07 Site ID: 129523 Spill Date: 1989-02-10				
28 MITCHELL PLACE	28 MITCHELL PLACE	E 1/4 - 1/2 (0.266 mi.)	AL379	1246
Spill Number/Closed Date: 9903630 / 2001-11-14 Spill Number/Closed Date: 9901259 / 1999-05-13 Site ID: 206823 Site ID: 206822 Spill Date: 1999-06-29 Spill Date: 1999-05-03				
FIRE STATION 2		NW 1/4 - 1/2 (0.266 mi.)	AS380	1248
Spill Number/Closed Date: 8801791 / 1989-01-24 Site ID: 297873 Spill Date: 1988-05-26				
COACHMAN HOTEL	123 EAST POST ROAD	SE 1/4 - 1/2 (0.266 mi.)	AQ381	1250
Spill Number/Closed Date: 9306655 / 1993-09-24 Site ID: 211948 Spill Date: 1993-08-31				
PRIVATE ENTERPRISE	***20 FERRIS AVE***	***NW 1/4 - 1/2 (0.267 mi.)***	***AS383***	***1252***

Spill Number/Closed Date: 0402326 / 2004-06-02
Spill Number/Closed Date: 8800487 / 1989-01-11
Spill Number/Closed Date: 8800670 / 1989-01-11
Site ID: 166779
Site ID: 166780
Site ID: 166781
Spill Date: 2004-06-02
Spill Date: 1988-04-14
Spill Date: 1988-04-21

SPILL NUMBER 0108090 ***31 WESTMORELAND AVE*** ***SW 1/4 - 1/2 (0.267 mi.)*** ***AR385*** ***1258***
Spill Number/Closed Date: 0108090 / 2001-11-08
Spill Number/Closed Date: 0206674 / 2003-02-26
Spill Number/Closed Date: 0010522 / 2001-07-10
Site ID: 110892
Site ID: 110893
Site ID: 68432
Spill Date: 2001-11-08
Spill Date: 2002-09-25
Spill Date: 2000-12-19

SPILL NUMBER 0108164 32 MITCHELL PL E 1/4 - 1/2 (0.274 mi.) AL386 1264
Spill Number/Closed Date: 0108164 / 2002-07-22
Spill Number/Closed Date: 9611678 / 1996-12-24
Spill Number/Closed Date: 9611679 / 1997-11-10
Site ID: 255456
Site ID: 255457
Site ID: 255458
Spill Date: 2001-11-12
Spill Date: 1996-12-24

COMMERCIAL PROERTY 151 EAST POST ROAD ESE 1/4 - 1/2 (0.277 mi.) AK387 1267
Spill Number/Closed Date: 0601015 / 2006-11-03
Site ID: 363155
Spill Date: 2006-04-26

LEGACY MANAGEMENT 39 WESTMORELAND AVE SW 1/4 - 1/2 (0.277 mi.) AR388 1268
Spill Number/Closed Date: 9411636 / 1994-11-30
Site ID: 109654
Spill Date: 1994-11-30

COMMERCIAL PROPERTY ***39 WESTMORELAND AVE*** ***SW 1/4 - 1/2 (0.277 mi.)*** ***AR389*** ***1270***
Spill Number/Closed Date: 0807224 / 2009-01-07
Spill Number/Closed Date: 9411173 / 1995-09-22
Site ID: 404560
Site ID: 221603
Spill Date: 2008-09-26
Spill Date: 1994-11-21

REAL ESTATE - TTF 6 CHESTER AVE SE 1/4 - 1/2 (0.281 mi.) AQ390 1273
Spill Number/Closed Date: 1506711 / 2019-02-08
Site ID: 514142
Spill Date: 2015-09-24

BARGAM HOME 36-38 MITCHELL PLACE E 1/4 - 1/2 (0.284 mi.) AP391 1275
Spill Number/Closed Date: 0505320 / 2005-12-18
Site ID: 350305
Spill Date: 2005-08-01

PBS ***82 BANK STREET*** ***SSW 1/4 - 1/2 (0.285 mi.)*** ***AT392*** ***1276***

Spill Number/Closed Date: 0312286 / 2005-03-27
Site ID: 301757
Spill Date: 2004-02-04

HALPERN ENTERPRISES | 170 EAST POST ROAD | ESE 1/4 - 1/2 (0.286 mi.) | AU393 | 1279
Spill Number/Closed Date: 8804996 / 2005-04-30
Site ID: 154885
Spill Date: 1988-09-08

OFFICE BLDG | 171 EAST POST RD | ESE 1/4 - 1/2 (0.286 mi.) | AK394 | 1280
Spill Number/Closed Date: 9811157 / 2004-03-30
Site ID: 293961
Spill Date: 1998-12-04

RESIDENTS | 8 CHESTER AVE | SE 1/4 - 1/2 (0.288 mi.) | AQ395 | 1282
Spill Number/Closed Date: 9610881 / 2012-04-16
Site ID: 71801
Spill Date: 1996-12-03

APARTMENT BLDG | 37-43 MITCHELL PL | E 1/4 - 1/2 (0.289 mi.) | AP396 | 1283
Spill Number/Closed Date: 0208214 / 2003-04-07
Site ID: 248365
Spill Date: 2002-11-07

IRVINGTON | IRVINGTON | SW 1/4 - 1/2 (0.290 mi.) | AR397 | 1284
Spill Number/Closed Date: 8708811 / 1988-03-03
Site ID: 309074
Spill Date: 1988-01-15

VILLANOVA - TTF | 144 CHURCH ST | NNE 1/4 - 1/2 (0.292 mi.) | 398 | 1286
Spill Number/Closed Date: 1603426 / 2016-09-06
Site ID: 529884
Spill Date: 2016-07-06

APARTMENT BUILDING | 40 MITCHELL PL | E 1/4 - 1/2 (0.293 mi.) | AP399 | 1287
Spill Number/Closed Date: 0304394 / 2003-10-31
Site ID: 151265
Spill Date: 2003-07-25

AT & T TELEPHONE CO | ***400 HAMILTON AVENUE*** | ***NE 1/4 - 1/2 (0.293 mi.)*** | ***AN400*** | ***1288***
Spill Number/Closed Date: 9604857 / 1996-07-22
Site ID: 72317
Spill Date: 1996-07-15

10 SCHOOL STREET | 10 SCHOOL STREET | W 1/4 - 1/2 (0.298 mi.) | AV402 | 1299
Spill Number/Closed Date: 0710736 / 2008-05-01
Site ID: 392081
Spill Date: 2008-01-10

APARTMENT BLDG | 40 BARKER AVE | NE 1/4 - 1/2 (0.301 mi.) | AW403 | 1300
Spill Number/Closed Date: 9713796 / 2001-01-31
Site ID: 271212
Spill Date: 1998-03-12

12 HARMON STREET | 12 HARMON STREET | WNW 1/4 - 1/2 (0.303 mi.) | AV404 | 1302
Spill Number/Closed Date: 0506799 / 2012-08-15
Site ID: 352081
Spill Date: 2005-09-02

SPILL NUMBER 9904849 | 45 MITCHELL PLACE | E 1/4 - 1/2 (0.307 mi.) | AX405 | 1303
Spill Number/Closed Date: 9510979 / 1995-12-12
Spill Number/Closed Date: 9904849 / 2000-01-11
Site ID: 143584

Site ID: 78194
Spill Date: 1995-11-29
Spill Date: 1999-07-23

APT BUILDING	45 MITCHELL PLACE	E 1/4 - 1/2 (0.307 mi.)	AX406	1305
Spill Number/Closed Date: 1212688 / 2020-02-05 Site ID: 475842 Spill Date: 2012-11-27				
COMMERCIAL	***41 BARKER AVE***	***NE 1/4 - 1/2 (0.310 mi.)***	***AW407***	***1308***
Spill Number/Closed Date: 0909513 / 2010-03-04 Site ID: 422220 Spill Date: 2009-11-25				
STEWARD	165 MAMARONECK AVENU	SE 1/4 - 1/2 (0.312 mi.)	AY408	1311
Spill Number/Closed Date: 9701601 / 2005-02-12 Spill Number/Closed Date: 0303361 / 2007-06-22 Site ID: 118993 Site ID: 180689 Spill Date: 1997-05-06 Spill Date: 2003-06-30				
SPILL NUMBER 9900622	179 EAST COAST RD	ESE 1/4 - 1/2 (0.314 mi.)	AU409	1313
Spill Number/Closed Date: 9900622 / 2000-03-24 Site ID: 260731 Spill Date: 1999-04-16				
CASTILLO	125-127 FISHER AVE	SW 1/4 - 1/2 (0.317 mi.)	AT410	1314
Spill Number/Closed Date: 8709424 / 1988-03-11 Site ID: 210582 Spill Date: 1988-02-05				
KEMPLER RESIDENCE	169 MAMARONECK AVE	SE 1/4 - 1/2 (0.318 mi.)	AY411	1315
Spill Number/Closed Date: 0301465 / 2003-08-25 Site ID: 160482 Spill Date: 2003-05-09				
BUSINESS	2-4 WASHINGTON AVE	W 1/4 - 1/2 (0.320 mi.)	412	1317
Spill Number/Closed Date: 0300993 / 2003-06-13 Site ID: 86277 Spill Date: 2003-04-28				
JOHN DALE INC	178 MAMORENECK AVE	SE 1/4 - 1/2 (0.321 mi.)	AY413	1318
Spill Number/Closed Date: 9810809 / 1998-12-01 Site ID: 325049 Spill Date: 1998-11-25				
APARTMENT BUILDING	193 EAST POST ROAD	ESE 1/4 - 1/2 (0.327 mi.)	414	1319
Spill Number/Closed Date: 0310631 / 2005-10-11 Site ID: 158568 Spill Date: 2003-12-15				
WHITE PLAINS HOSPITA	***DAVIS AVE & EAST POS***	***SSE 1/4 - 1/2 (0.333 mi.)***	***AZ415***	***1321***
Spill Number/Closed Date: 9303501 / 1996-06-18 Site ID: 66799 Spill Date: 1993-06-14				
WHITE PLAINS HOSPITA	EAST NEW YORK POST R	S 1/4 - 1/2 (0.336 mi.)	AZ416	1323
Spill Number/Closed Date: 9506062 / 2005-01-02 Site ID: 240948 Spill Date: 1995-08-15				
WHITE PLAINS HOSPITA	***41 POST RD***	***S 1/4 - 1/2 (0.341 mi.)***	***AZ418***	***1325***

Spill Number/Closed Date: 1107393 / 2011-10-31
Site ID: 455090
Spill Date: 2011-09-12

WHITE PLAINS HOSPITA | 41 EAST POST ROAD | S 1/4 - 1/2 (0.341 mi.) | AZ419 | 1343
Spill Number/Closed Date: 9414693 / 1995-02-13
Site ID: 68377
Spill Date: 1995-02-08

CON ED HOLE # TM 251 | ***MARTINE AVE WEST OF*** | ***E 1/4 - 1/2 (0.342 mi.)*** | ***BA420*** | ***1344***
Spill Number/Closed Date: 8806957 / 1989-02-06
Site ID: 172819
Spill Date: 1988-11-21

N.Y. TELEPHONE | ***40 WASHINGTON AVE.*** | ***W 1/4 - 1/2 (0.343 mi.)*** | ***AV421*** | ***1346***
Spill Number/Closed Date: 9110542 / 1992-03-17
Site ID: 329591
Spill Date: 1992-01-08

LASALLE PARTNERS | 1 NORTH BROADWAY | ENE 1/4 - 1/2 (0.361 mi.) | BC424 | 1384
Spill Number/Closed Date: 8807326 / 1989-03-08
Site ID: 245085
Spill Date: 1988-12-05

GREENRIDGE ESTATES | 1-13 GREENRIDGE AVE | SE 1/4 - 1/2 (0.361 mi.) | BD425 | 1385
Spill Number/Closed Date: 0912193 / 2011-12-22
Site ID: 425068
Spill Date: 2010-02-22

GREENRIDGE ESTATES C | 1-13 GREENRIDGE AVE | SE 1/4 - 1/2 (0.361 mi.) | BD426 | 1386
Spill Number/Closed Date: 1910929 / 2022-05-11
Spill Number/Closed Date: 1911181 / 2022-05-11
Spill Number/Closed Date: 1911256 / 2022-05-11
Site ID: 601600
Site ID: 601870
Site ID: 601947
Spill Date: 2020-02-25
Spill Date: 2020-03-04
Spill Date: 2020-03-06

OFFICE BLDG - TTF | ***203 MAMARONECK AVE*** | ***SE 1/4 - 1/2 (0.361 mi.)*** | ***BE427*** | ***1390***
Spill Number/Closed Date: 9710787 / Not Reported
Site ID: 329412
Spill Date: 1997-12-22

WHITE PLAINS HOSPITA | ***8 LONGVIEW AVE*** | ***SSE 1/4 - 1/2 (0.363 mi.)*** | ***428*** | ***1393***
Spill Number/Closed Date: 1007255 / 2017-12-12
Spill Number/Closed Date: 1007877 / 2011-07-05
Spill Number/Closed Date: 0907812 / 2009-11-04
Site ID: 440652
Site ID: 441326
Site ID: 420361
Spill Date: 2010-10-06
Spill Date: 2010-10-25
Spill Date: 2009-10-12

240 EAST POST RD | 240 EAST POST RD | ESE 1/4 - 1/2 (0.364 mi.) | 429 | 1397
Spill Number/Closed Date: 9903233 / 1999-12-15
Site ID: 135983
Spill Date: 1999-06-21

15 NORTH BROADWAY | ***15 NORTH BROADWAY*** | ***NE 1/4 - 1/2 (0.365 mi.)*** | ***BF430*** | ***1398***

Spill Number/Closed Date: 9207265 / 1996-02-01
Site ID: 125976
Spill Date: 1992-09-23

ES GORDON	7-11 SOUTH BROADWAY	ENE 1/4 - 1/2 (0.366 mi.)	BC431	1400
Spill Number/Closed Date: 9303840 / 1994-05-04 Site ID: 86174 Spill Date: 1993-06-24				
SPILL NUMBER 0103645	12 EAST POST RD	S 1/4 - 1/2 (0.368 mi.)	BG432	1402
Spill Number/Closed Date: 0103645 / 2003-12-09 Site ID: 129951 Spill Date: 2001-07-05				
BART GOLDBERG APT. B	277 MARTINE AVE	E 1/4 - 1/2 (0.369 mi.)	BA433	1403
Spill Number/Closed Date: 9008032 / 1990-11-08 Site ID: 255929 Spill Date: 1990-10-22				
HOSPITAL (UNK NAME)	41 EAST COAST ROAD	SSE 1/4 - 1/2 (0.371 mi.)	AZ434	1404
Spill Number/Closed Date: 9806058 / 1998-08-17 Site ID: 191235 Spill Date: 1998-08-14				
VILLE HOME	167 HARDING AVE	W 1/4 - 1/2 (0.373 mi.)	BH435	1406
Spill Number/Closed Date: 0611042 / 2007-03-30 Site ID: 375611 Spill Date: 2007-01-01				
GOMES RESIDENCE	140 HARDING AVE	W 1/4 - 1/2 (0.373 mi.)	436	1407
Spill Number/Closed Date: 1001359 / 2010-07-08 Site ID: 434408 Spill Date: 2010-05-05				
WHITE PLAINS HOSPITA	MAPLE AVE	ENE 1/4 - 1/2 (0.374 mi.)	BI437	1408
Spill Number/Closed Date: 9304740 / 1994-01-06 Site ID: 290020 Spill Date: 1993-07-15				
SPILL NUMBER 8600048	11 EAST POST ROAD	S 1/4 - 1/2 (0.375 mi.)	BG438	1409
Spill Number/Closed Date: 8600048 / 1987-02-24 Site ID: 200602 Spill Date: 1986-04-02				
GETTY GAS #58108	11 EAST POST ROAD	S 1/4 - 1/2 (0.375 mi.)	BG443	1413
Spill Number/Closed Date: 9710611 / 1998-05-08 Spill Number/Closed Date: 0407127 / 2004-09-27 Site ID: 261415 Site ID: 261414 Spill Date: 1997-12-17 Spill Date: 2004-09-27				
W2 POLE	***155 HARDING AVE***	***W 1/4 - 1/2 (0.376 mi.)***	***BH446***	***1417***
Spill Number/Closed Date: 9500861 / 1995-05-24 Site ID: 313435 Spill Date: 1995-04-20				
LAZZARO	47 PARK AVE	N 1/4 - 1/2 (0.377 mi.)	447	1420
Spill Number/Closed Date: 9815351 / 2004-12-07 Site ID: 238028 Spill Date: 1999-03-26				
PDUZZI - TTF	188 CHURCH ST	N 1/4 - 1/2 (0.380 mi.)	BJ448	1421

Spill Number/Closed Date: 9905239 / 2009-12-16
Site ID: 108306
Spill Date: 1999-07-31

WHITE PLAINS-FIRE HO | MAMARONECK & MAPLE A | SE 1/4 - 1/2 (0.382 mi.) | BE449 | 1423
Spill Number/Closed Date: 8707149 / 1989-01-05
Site ID: 311048
Spill Date: 1987-11-19

WHITE PLAINS DPW | MAPLE & MAMARONECK A | SE 1/4 - 1/2 (0.382 mi.) | BE451 | 1425
Spill Number/Closed Date: 9111846 / 1992-03-10
Site ID: 90852
Spill Date: 1992-02-18

SEACON METAL - TTF | 7 INTERVALE STREET | SW 1/4 - 1/2 (0.386 mi.) | BB452 | 1426
Spill Number/Closed Date: 8904791 / 1989-11-30
Site ID: 252170
Spill Date: 1989-08-14

35 PARK AVENUE | 35 PARK AVENUE | N 1/4 - 1/2 (0.387 mi.) | BK453 | 1427
Spill Number/Closed Date: 0303364 / 2010-06-29
Site ID: 272501
Spill Date: 2003-06-30

SPILL NUMBER 0206553 | 300 MARTINE AVE | E 1/4 - 1/2 (0.389 mi.) | BA454 | 1429
Spill Number/Closed Date: 0206553 / 2002-12-13
Site ID: 293177
Spill Date: 2002-09-24

SPILL NUMBER 0013009 | 1 EAST POST RD | S 1/4 - 1/2 (0.390 mi.) | BG455 | 1431
Spill Number/Closed Date: 0013009 / 2001-03-12
Site ID: 156648
Spill Date: 2001-03-12

JOHN LWHITE CONDO | 9 GREENRIDGE AVE | SE 1/4 - 1/2 (0.390 mi.) | BD456 | 1432
Spill Number/Closed Date: 0911533 / 2011-10-28
Site ID: 424347
Spill Date: 2010-01-27

PIRRO, MONSELL REALT | 40 WALLER AVE | ESE 1/4 - 1/2 (0.393 mi.) | 457 | 1434
Spill Number/Closed Date: 8709325 / 1988-02-02
Site ID: 162080
Spill Date: 1988-02-02

APT BUILDING | 16 NORTH BROADWAY | ENE 1/4 - 1/2 (0.395 mi.) | BL458 | 1435
Spill Number/Closed Date: 0701599 / 2007-12-12
Spill Number/Closed Date: 0412306 / 2005-08-27
Site ID: 381144
Site ID: 337751
Spill Date: 2007-05-08
Spill Date: 2005-02-17

BUILDING | 20 NORTH BROADWAY | ENE 1/4 - 1/2 (0.395 mi.) | BF459 | 1439
Spill Number/Closed Date: 0111039 / 2002-03-11
Spill Number/Closed Date: 0800897 / 2008-06-08
Site ID: 84678
Site ID: 396726
Spill Date: 2002-02-20
Spill Date: 2008-04-22

CON ED | 10 NORTH BROADWAY | ENE 1/4 - 1/2 (0.396 mi.) | BL460 | 1444
Spill Number/Closed Date: 0301652 / 2003-12-12

Site ID: 302706
Spill Date: 2003-05-15

BISCARDI CLEANERS	***201 SO. LEXINGTON AV***	***S 1/4 - 1/2 (0.397 mi.)***	***BG461***	***1447***
Spill Number/Closed Date: 0100630 / 2006-05-01 Site ID: 322267 Spill Date: 2001-04-17				
HART RESIDENCE	77 PARK AVE	NNW 1/4 - 1/2 (0.398 mi.)	BM462	1450
Spill Number/Closed Date: 1214615 / 2013-04-22 Site ID: 477863 Spill Date: 2013-01-14				
PARKER RES	3 WYANOKE STREET	SSW 1/4 - 1/2 (0.398 mi.)	463	1451
Spill Number/Closed Date: 0610630 / 2007-02-06 Spill Number/Closed Date: 0607149 / 2007-02-06 Spill Number/Closed Date: 0607758 / 2007-02-06 Site ID: 375107 Site ID: 370661 Site ID: 371575 Spill Date: 2006-12-19 Spill Date: 2006-09-21 Spill Date: 2006-10-07				
PATRIOT MANAGEMENT	***2 WESTCHESTER AVE***	***ENE 1/4 - 1/2 (0.399 mi.)***	***BC464***	***1454***
Spill Number/Closed Date: 8800351 / 2004-05-06 Site ID: 322460 Spill Date: 1988-04-11				
GABERIAL	7 FAIRVIEW AVE	NNW 1/4 - 1/2 (0.403 mi.)	BM465	1457
Spill Number/Closed Date: 0000372 / 2000-10-13 Site ID: 65789 Spill Date: 2000-04-10				
SPILL NUMBER 0209590	25 PARK AVE	N 1/4 - 1/2 (0.404 mi.)	BJ466	1458
Spill Number/Closed Date: 0209590 / 2002-12-18 Site ID: 206038 Spill Date: 2002-12-18				
WHITE PLAINS PRESBYT	39 NORTH BROADWAY	NE 1/4 - 1/2 (0.405 mi.)	BN467	1460
Spill Number/Closed Date: 8705816 / 1988-03-04 Spill Number/Closed Date: 0911530 / 2017-05-11 Site ID: 120033 Site ID: 424343 Spill Date: 1987-10-09 Spill Date: 2010-01-27				
UNK HOMEOWNER	163 FISHER AVE	SW 1/4 - 1/2 (0.405 mi.)	BO468	1462
Spill Number/Closed Date: 1104419 / 2014-11-05 Site ID: 452024 Spill Date: 2011-07-20				
PATRIOT MANAGEMENT:	***12 WESTCHESTER AVE***	***ENE 1/4 - 1/2 (0.408 mi.)***	***BI469***	***1463***
Spill Number/Closed Date: 0900020 / 2015-06-05 Site ID: 411931 Spill Date: 2009-04-01				
AVIS	20 WEST POST RD	S 1/4 - 1/2 (0.409 mi.)	BP471	1467
Spill Number/Closed Date: 8706892 / 1988-07-27 Site ID: 159466 Spill Date: 1987-11-13				
PBS TTF	***235 MAMARONECK AVE***	***SE 1/4 - 1/2 (0.412 mi.)***	***BQ472***	***1469***

Spill Number/Closed Date: 1112859 / 2012-03-30
Spill Number/Closed Date: 0404588 / 2005-01-10
Site ID: 460824
Site ID: 128036
Spill Date: 2012-02-09
Spill Date: 2004-07-28

PRIVATE RES — 3 LAKE VIEW DR NORTH — NE 1/4 - 1/2 (0.420 mi.) — BR473 — 1472
Spill Number/Closed Date: 0406400 / 2004-12-12
Site ID: 284223
Spill Date: 2004-09-10

JEFFERSON APTS — 64 JEFFERSON AVE — W 1/4 - 1/2 (0.420 mi.) — BS474 — 1474
Spill Number/Closed Date: 1215993 / 2014-03-14
Site ID: 479338
Spill Date: 2013-03-01

@ — 44 NORTH BROADWAY — NE 1/4 - 1/2 (0.422 mi.) — BN475 — 1476
Spill Number/Closed Date: 0302230 / 2009-11-05
Site ID: 328668
Spill Date: 2003-06-02

SPILL NUMBER 9909558 — 7 PARK CIRCLE — N 1/4 - 1/2 (0.422 mi.) — BK476 — 1483
Spill Number/Closed Date: 9909558 / 2000-01-12
Site ID: 222795
Spill Date: 1999-11-05

BARILE RESIDENCE — 75 JEFFERSON AVE — W 1/4 - 1/2 (0.424 mi.) — BS477 — 1484
Spill Number/Closed Date: 0514297 / 2006-06-01
Site ID: 360988
Spill Date: 2006-03-14

MITCHELL ESTATE - TT — 5 NUTGROVE ST — SSW 1/4 - 1/2 (0.424 mi.) — 478 — 1486
Spill Number/Closed Date: 1405501 / 2014-11-19
Site ID: 498930
Spill Date: 2014-08-20

SPILL NUMBER 9808775 — 48 JEFFERSON AVE — W 1/4 - 1/2 (0.427 mi.) — BS479 — 1487
Spill Number/Closed Date: 9808775 / 1999-03-16
Site ID: 120913
Spill Date: 1998-10-14

RESIDENCE — 25 LONGVIEW AVE — SSE 1/4 - 1/2 (0.430 mi.) — 480 — 1489
Spill Number/Closed Date: 0413208 / 2005-05-08
Site ID: 339072
Spill Date: 2005-03-18

APT. BUILDING — 50 NORTH BROADWAY — NE 1/4 - 1/2 (0.432 mi.) — BN481 — 1490
Spill Number/Closed Date: 9212081 / 1994-06-29
Site ID: 219739
Spill Date: 1993-01-22

WHITE PLAINS LINC/ME — 25 WEST COAST RD — S 1/4 - 1/2 (0.432 mi.) — BP482 — 1492
Spill Number/Closed Date: 0005954 / 2001-04-24
Site ID: 226425
Spill Date: 2000-08-18

YMCA OF CENTRAL & NO — 250 MAMARONECK AVENU — SE 1/4 - 1/2 (0.433 mi.) — BQ483 — 1493
Spill Number/Closed Date: 9013259 / 2002-03-23
Site ID: 263885
Spill Date: 1991-03-28

WHITE PLAINS YMCA — 250 MAMARONECK AVE — SE 1/4 - 1/2 (0.433 mi.) — BQ484 — 1515

Spill Number/Closed Date: 1410006 / 2015-12-08
Site ID: 503665
Spill Date: 2015-01-12

WHITE PLAINS MED CEN | 170 MAPLE AVE | S 1/4 - 1/2 (0.434 mi.) | 485 | 1516
Spill Number/Closed Date: 0004388 / 2001-06-22
Site ID: 204425
Spill Date: 2000-07-12

BUSINESS | ***7 LAKE STREET*** | ***NE 1/4 - 1/2 (0.439 mi.)*** | ***BR486*** | ***1517***
Spill Number/Closed Date: 0701292 / 2007-09-28
Spill Number/Closed Date: 0604972 / 2006-11-17
Spill Number/Closed Date: 1401610 / 2015-07-17
Spill Number/Closed Date: 0706405 / 2008-07-31
Site ID: 380826
Site ID: 368064
Site ID: 494900
Site ID: 386923
Spill Date: 2007-05-01
Spill Date: 2006-08-01
Spill Date: 2014-05-14
Spill Date: 2007-09-07

179 FISHER AVE | 179 FISHER AVE | SW 1/4 - 1/2 (0.440 mi.) | BO487 | 1523
Spill Number/Closed Date: 0712211 / 2009-08-31
Site ID: 393798
Spill Date: 2008-02-20

SPILL NUMBER 8807217 | 52 NORTH BROADWAY | NNE 1/4 - 1/2 (0.445 mi.) | 488 | 1524
Spill Number/Closed Date: 0509076 / 2006-03-21
Spill Number/Closed Date: 8807217 / 1988-12-02
Site ID: 354798
Site ID: 181366
Spill Date: 2005-10-28
Spill Date: 1988-12-01

CON ED | ***300 MAIN ST*** | ***ENE 1/4 - 1/2 (0.448 mi.)*** | ***BT489*** | ***1527***
Spill Number/Closed Date: 8708398 / 1988-02-17
Spill Number/Closed Date: 9810968 / 2000-02-09
Spill Number/Closed Date: 9209346 / 1993-07-19
Site ID: 76155
Site ID: 76156
Site ID: 153296
Spill Date: 1987-12-30
Spill Date: 1998-12-01
Spill Date: 1992-11-11

REAL ESTATE TRANS - | 14 JEFFERSON AVE | W 1/4 - 1/2 (0.449 mi.) | 492 | 1534
Spill Number/Closed Date: 1309859 / 2014-07-01
Site ID: 490678
Spill Date: 2014-01-10

REALTY TRANSACTION | 52 PARK CIRCLE | NNW 1/4 - 1/2 (0.457 mi.) | 494 | 1536
Spill Number/Closed Date: 0502737 / 2005-07-25
Site ID: 347156
Spill Date: 2005-06-07

RESIDENCE | 325 MAIN ST | ENE 1/4 - 1/2 (0.458 mi.) | BT495 | 1538
Spill Number/Closed Date: 9710553 / 1998-01-09
Site ID: 230651

Spill Date: 1997-12-15

SUBODH DESHMUKH RESI Spill Number/Closed Date: 1001726 / 2010-08-03 Site ID: 434804 Spill Date: 2010-05-13	39 PARKVIEW CT	NNE 1/4 - 1/2 (0.459 mi.)	496	1539
FIRE HOUSE # 4 Spill Number/Closed Date: 8707150 / 1989-01-05 Site ID: 178231 Spill Date: 1987-11-19	MAPLE AVE & S LEXING	S 1/4 - 1/2 (0.461 mi.)	BV498	1542
RESIDENCE Spill Number/Closed Date: 0502066 / 2005-07-17 Spill Number/Closed Date: 0501947 / 2005-07-17 Site ID: 346355 Site ID: 346210 Spill Date: 2005-05-20 Spill Date: 2005-05-18	84 LINCOLN AVE	W 1/4 - 1/2 (0.462 mi.)	499	1543
SMITH - TTF Spill Number/Closed Date: 1309316 / 2014-05-14 Site ID: 490109 Spill Date: 2013-12-20	70 LINCOLN AVE	W 1/4 - 1/2 (0.465 mi.)	BS500	1546
BERTE HOME Spill Number/Closed Date: 0501302 / 2005-06-19 Site ID: 344494 Spill Date: 2005-05-02	3 CHURCH COURT	N 1/4 - 1/2 (0.467 mi.)	504	1554
9 LAFAYETTE STREET Spill Number/Closed Date: 0208594 / 2012-08-13 Site ID: 322970 Spill Date: 2002-11-19	9 LAFAYETTE STREET	SW 1/4 - 1/2 (0.468 mi.)	BW505	1555
YWCA Spill Number/Closed Date: 0207697 / 2003-05-09 Site ID: 63852 Spill Date: 2002-10-24	69 NORTH BROADWAY	NNE 1/4 - 1/2 (0.471 mi.)	506	1557
WHITE PLAINS PROJECT Spill Number/Closed Date: 8800315 / 1988-11-25 Site ID: 317805 Spill Date: 1988-04-08	***179 WESTMORELAND AVE***	***SW 1/4 - 1/2 (0.471 mi.)***	***507***	***1558***
PVT DWELLING Spill Number/Closed Date: 0909891 / 2014-01-16 Site ID: 422623 Spill Date: 2009-12-07	195 FISHER AVE	SW 1/4 - 1/2 (0.473 mi.)	BW508	1561
APARTMENT BLDG Spill Number/Closed Date: 0410525 / 2005-02-24 Site ID: 335499 Spill Date: 2004-12-22	***21 GREENRIDGE AVE***	***SSE 1/4 - 1/2 (0.477 mi.)***	***509***	***1562***
APT BUILDING Spill Number/Closed Date: 2102648 / 2021-09-28 Spill Number/Closed Date: 2103947 / 2024-10-18 Spill Number/Closed Date: 0912833 / 2010-06-23 Site ID: 620396 Site ID: 622740 Site ID: 425742	16 LAKE STREET	NE 1/4 - 1/2 (0.483 mi.)	511	1568

Spill Date: 2021-06-21
Spill Date: 2021-07-26
Spill Date: 2010-03-10

ROADWAY	***285 MAMARONECK AVE***	***SE 1/4 - 1/2 (0.484 mi.)***	***512***	***1572***
Spill Number/Closed Date: 9712450 / 2020-07-10				
Site ID: 85909				
Spill Date: 1998-02-07				
WHITE PLAINS FD STAT	234 SOUTH LEXINGTON	S 1/4 - 1/2 (0.495 mi.)	BV514	1577
Spill Number/Closed Date: 9804511 / 1998-08-12				
Site ID: 320194				
Spill Date: 1998-07-10				
SPILL NUMBER 9812431	88-90 CHATTERTON AVE	WNW 1/4 - 1/2 (0.495 mi.)	515	1578
Spill Number/Closed Date: 9812431 / 1999-02-02				
Site ID: 319434				
Spill Date: 1999-01-07				
GREAT GRANT MANOR PR	235 SOUTH LEXINGTON	S 1/4 - 1/2 (0.500 mi.)	BV518	1591
Spill Number/Closed Date: 0204243 / 2002-11-06				
Spill Number/Closed Date: 0304500 / 2003-10-31				
Spill Number/Closed Date: 9313731 / 1995-01-05				
Spill Number/Closed Date: 9706472 / 1998-02-27				
Site ID: 147077				
Site ID: 147078				
Site ID: 147079				
Site ID: 147080				
Spill Date: 2002-07-23				
Spill Date: 2003-07-29				
Spill Date: 1994-02-22				
Spill Date: 1997-08-28				

Lower Elevation	**Address**	**Direction / Distance**	**Map ID**	**Page**
NYNEX	***111 MAIN ST***	***NNE 0 - 1/8 (0.006 mi.)***	***A28***	***112***
Spill Number/Closed Date: 9314933 / 1995-03-01				
Spill Number/Closed Date: 9609101 / 1999-11-26				
Site ID: 145113				
Site ID: 239422				
Spill Date: 1994-03-21				
Spill Date: 1996-10-21				
A&S STORE	GALLERIA PLAZA	ENE 0 - 1/8 (0.010 mi.)	B35	134
Spill Number/Closed Date: 8805571 / 1989-03-07				
Site ID: 187319				
Spill Date: 1988-09-29				
A & S STORE	GALLERIA PLAZA	ENE 0 - 1/8 (0.010 mi.)	B36	136
Spill Number/Closed Date: 8803673 / 1988-08-09				
Site ID: 187318				
Spill Date: 1988-07-27				
ODDESY CORP MAINT DE	***123 MAIN STREET***	***ENE 0 - 1/8 (0.030 mi.)***	***B53***	***198***
Spill Number/Closed Date: 8907663 / 1991-06-12				
Spill Number/Closed Date: 8906607 / 1991-06-12				
Spill Number/Closed Date: 9910168 / 1999-11-22				
Site ID: 74955				
Site ID: 160999				

Site ID: 161000
Spill Date: 1989-11-01
Spill Date: 1989-10-04
Spill Date: 1999-11-19

EDGAR	1 BARKER AVE	N 1/8 - 1/4 (0.175 mi.)	Y260	963
Spill Number/Closed Date: 9807932 / 1999-11-19				
Site ID: 330854				
Spill Date: 1998-09-29				
MARRIOT INN	5 BARKER AVE	NNE 1/8 - 1/4 (0.189 mi.)	AD293	1061
Spill Number/Closed Date: 0503865 / 2005-10-28				
Spill Number/Closed Date: 1303150 / 2014-02-28				
Site ID: 348566				
Site ID: 483619				
Spill Date: 2005-06-30				
Spill Date: 2013-06-24				
RESIDENCE INN - TTF	5 BARKER AVE	NNE 1/8 - 1/4 (0.189 mi.)	AD294	1064
Spill Number/Closed Date: 1501552 / 2015-07-20				
Site ID: 507776				
Spill Date: 2015-05-12				
NEWMARK AND LEWIS PR	111 S.CENTRAL PARK A	NW 1/4 - 1/2 (0.449 mi.)	BU491	1533
Spill Number/Closed Date: 9000996 / 1990-06-13				
Site ID: 284169				
Spill Date: 1990-04-26				
COUNTRY CENTER	CENTRAL AVE	NW 1/4 - 1/2 (0.452 mi.)	BU493	1535
Spill Number/Closed Date: 8808026 / 1989-02-07				
Site ID: 215666				
Spill Date: 1989-01-06				
CROWN PLAZA HOTEL	66 HALE AVE	E 1/4 - 1/2 (0.459 mi.)	497	1540
Spill Number/Closed Date: 1105926 / 2020-04-30				
Site ID: 453595				
Spill Date: 2011-08-24				
WESTCHESTER COUNTY A	***HANGER A***	***NW 1/4 - 1/2 (0.465 mi.)***	***BU501***	***1547***
Spill Number/Closed Date: 0105432 / 2001-08-20				
Site ID: 212243				
Spill Date: 2001-08-20				
WESTCHESTER COUNTY A	HANGER E - TELLER RO	NW 1/4 - 1/2 (0.465 mi.)	BU502	1551
Spill Number/Closed Date: 0406492 / 2004-09-13				
Site ID: 307691				
Spill Date: 2004-09-12				
WESTCHESTER COUNTY A	AVITAT RAMP	NW 1/4 - 1/2 (0.465 mi.)	BU503	1553
Spill Number/Closed Date: 0106275 / 2001-09-14				
Site ID: 201432				
Spill Date: 2001-09-13				
3-5 FRANKLIN AVE	***3-5 FRANKLIN AVE***	***ENE 1/4 - 1/2 (0.480 mi.)***	***510***	***1564***
Spill Number/Closed Date: 8800464 / 1989-01-11				
Spill Number/Closed Date: 9207566 / 1993-02-05				
Site ID: 161165				
Site ID: 161166				
Spill Date: 1988-04-14				
Spill Date: 1992-09-29				
WESTCHESTER SHOPPING	WEST AVE & PAWLING S	E 1/4 - 1/2 (0.495 mi.)	BX516	1580

Spill Number/Closed Date: 9310531 / 1995-01-20
Site ID: 213450
Spill Date: 1993-09-09

Lists of state and tribal registered storage tanks

NY UST: The Underground Storage Tank database contains registered USTs. USTs are regulated under Subtitle I of the Resource Conservation and Recovery Act (RCRA). The data come from the Department of Environmental Conservation's Petroleum Bulk Storage (PBS) Database

A review of the NY UST list, as provided by EDR, has revealed that there are 53 NY UST sites within approximately 0.25 miles of the target property.

Equal/Higher Elevation	Address	Direction / Distance	Map ID	Page
GATEWAY PLAZA	1 NORTH LEXINGTON AV	WNW 0 - 1/8 (0.015 mi.)	C42	150
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024 Status: 0. Administratively closed Id/Status:: 3-800106 Site Status: Unregulated: <1101 gal. PBS				
GATEWAY CENTER ONE	1 NORTH LEXINGTON AV	WNW 0 - 1/8 (0.015 mi.)	C44	157
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024 Status: 3. Closed - Removed Status: 1. In-Service Status: 4. Closed - in place Id/Status:: 3-496871 Site Status: Active				
GALLERIA WEST GARAGE	MARTINE AVE & SO LEX	SW 0 - 1/8 (0.035 mi.)	D59	240
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024 Status: 3. Closed - Removed Id/Status:: 3-169579 Site Status: Unregulated: <1101 gal. PBS				
2 WILLIAM ST./ 169 M	2 WILLIAM ST./ 169 M	ENE 0 - 1/8 (0.051 mi.)	B78	287
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024 Status: 3a. Closed - Prior to 04/1991 Id/Status:: 3-505153 Site Status: Unregulated: <1101 gal. PBS				
PUBLIC SAFETY BUILDI	77 SOUTH LEXINGTON A	SSW 0 - 1/8 (0.075 mi.)	D91	314
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024 Status: 3. Closed - Removed Id/Status:: 3-601115 Site Status: Active				
LAST CALL NY INC/DBA	171-173 MAIN STREET	ENE 0 - 1/8 (0.079 mi.)	K96	321
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024 Status: 3. Closed - Removed Id/Status:: 3-800096 Site Status: Unregulated: <1101 gal. PBS				
WYASSUP-LAUREL GLEN	175 MAIN STREET	ENE 0 - 1/8 (0.085 mi.)	K101	329
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024 Status: 4. Closed - in place Id/Status:: 3-032433				

Site Status: Active

STATION PLAZA | 76 SOUTH LEXINGTON A | SSW 0 - 1/8 (0.098 mi.) | L106 | 342
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024
Status: 4. Closed - in place
Id/Status:: 3-139637
Site Status: Administratively Closed

WESTCHESTER COUNTY O | 148 MARTINE AVENUE | ESE 0 - 1/8 (0.106 mi.) | O121 | 390
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024
Status: 4. Closed - in place
Status: 0. Administratively closed
Status: 1. In-Service
Status: 3. Closed - Removed
Id/Status:: 3-168777
Site Status: Active

WESTCHESTER COUNTY C | 111 GROVE ST TOWER | SE 0 - 1/8 (0.122 mi.) | Q182 | 550
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024
Status: 0. Administratively closed
Id/Status:: 3-168750
Site Status: Administratively Closed

WESTCHESTER COUNTY C | 111 MARTIN LUTHER KI | SE 0 - 1/8 (0.122 mi.) | Q185 | 554
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024
Status: 1. In-Service
Id/Status:: 3-801217
Site Status: Active

WESTCHESTER COUNTY C | 110 GROVE ST | SE 0 - 1/8 (0.123 mi.) | Q191 | 573
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024
Status: 0. Administratively closed
Id/Status:: 3-168742
Site Status: Administratively Closed

199 MAIN STREET REAL | 199 MAIN STREET | ENE 1/8 - 1/4 (0.125 mi.) | K193 | 579
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024
Status: 4. Closed - in place
Id/Status:: 3-049824
Site Status: Active

OUR LADY OF MT CARME | 92 SOUTH LEXINGTON A | SSW 1/8 - 1/4 (0.135 mi.) | L196 | 583
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024
Status: 3. Closed - Removed
Id/Status:: 3-074462
Site Status: Unregulated

PUBLIC SAFETY BUILDI | 279 HAMILTON AVE | NE 1/8 - 1/4 (0.148 mi.) | T214 | 809
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024
Status: 3a. Closed - Prior to 04/1991
Id/Status:: 3-169528
Site Status: Unregulated: <1101 gal. PBS

BRIAN HOLDING COMPAN | 203 MAIN STREET | ENE 1/8 - 1/4 (0.150 mi.) | U219 | 817
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024
Status: 4. Closed - in place
Id/Status:: 3-049999
Site Status: Unregulated: <1101 gal. PBS

274 SNK HAMILTON AVE | 274 HAMILTON AVENUE | NE 1/8 - 1/4 (0.155 mi.) | T220 | 818
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024

Status: 1. In-Service
Status: 3. Closed - Removed
Status: 0. Administratively closed
Id/Status:: 3-164135
Site Status: Active

CALANO & CALANO REAL | 14 MAMARONECK AVENUE | E 1/8 - 1/4 (0.162 mi.) | U228 | 846
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024
Status: 1. In-Service
Id/Status:: 3-801152
Site Status: Active

THE INNS OF COURT PR | 99 COURT ST. | ESE 1/8 - 1/4 (0.167 mi.) | V234 | 888
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024
Status: 3. Closed - Removed
Id/Status:: 3-601002
Site Status: Unregulated: <1101 gal. PBS

SPRINT WHITE PLAINS | 300 HAMILTON AVENUE | NE 1/8 - 1/4 (0.171 mi.) | T242 | 925
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024
Status: 3. Closed - Removed
Id/Status:: 3-801122
Site Status: Unregulated

AMCOTT ASSOCIATES | 300 HAMILTON AVENUE | NE 1/8 - 1/4 (0.171 mi.) | T243 | 926
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024
Status: 0. Administratively closed
Status: 1. In-Service
Status: 3. Closed - Removed
Id/Status:: 3-259241
Site Status: Active

GRAND REALTY COMPANY | 150 GRAND STREET | SE 1/8 - 1/4 (0.174 mi.) | S256 | 958
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024
Status: 0. Administratively closed
Id/Status:: 3-176885
Site Status: Administratively Closed

150 GRAND STREET OFF | 150 GRAND STREET | SE 1/8 - 1/4 (0.174 mi.) | S257 | 959
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024
Status: 4. Closed - in place
Id/Status:: 3-800119
Site Status: Unregulated

CHARLES L. BRIEANT U | 300 QUARROPAS STREET | S 1/8 - 1/4 (0.177 mi.) | AA267 | 975
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024
Status: 1. In-Service
Id/Status:: 3-801467
Site Status: Active

MERCEDES- BENZ OF WH | 50 BANK STREET | SW 1/8 - 1/4 (0.185 mi.) | AC284 | 1027
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024
Status: 1. In-Service
Status: 3. Closed - Removed
Status: 4. Closed - in place
Status: 0. Administratively closed
Id/Status:: 3-452122
Site Status: Active

170 GRAND STREET ASS | 170 GRAND STREET | SE 1/8 - 1/4 (0.186 mi.) | S286 | 1046
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024

Status: 4. Closed - in place
Id/Status:: 3-800392
Site Status: Active

WESTCHESTER ARTS COU | 31 MAMARONECK AVE. | E 1/8 - 1/4 (0.186 mi.) | X288 | 1050
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024
Status: 3. Closed - Removed
Id/Status:: 3-600118
Site Status: Unregulated: <1101 gal. PBS

177 GRAND PARTNERS, | 177 GRAND STREET | SE 1/8 - 1/4 (0.189 mi.) | S292 | 1061
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024
Status: 1. In-Service
Id/Status:: 3-049816
Site Status: Active

76 MAMARONECK AVENUE | 76 MAMARONECK AVENUE | ESE 1/8 - 1/4 (0.189 mi.) | X296 | 1066
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024
Status: 4. Closed - in place
Status: 3. Closed - Removed
Id/Status:: 3-074659
Site Status: Unregulated

RENAISSANCE CORPORAT | 235 MAIN STREET | ENE 1/8 - 1/4 (0.190 mi.) | U297 | 1067
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024
Status: 4. Closed - in place
Id/Status:: 3-049980
Site Status: Active

SLATER NEIGHBORHOOD | 2 FISHER COURT | SSE 1/8 - 1/4 (0.195 mi.) | AE300 | 1070
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024
Status: 3. Closed - Removed
Id/Status:: 3-169560
Site Status: Unregulated: <1101 gal. PBS

47 MAMARONECK AVENUE | 47 MAMARONECK AVENUE | E 1/8 - 1/4 (0.195 mi.) | X301 | 1071
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024
Status: 4. Closed - in place
Id/Status:: 3-030929
Site Status: Unregulated

KIMCO REALTY CORP | 100 MAMARONECK AVENU | ESE 1/8 - 1/4 (0.209 mi.) | AI328 | 1124
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024
Status: 3. Closed - Removed
Id/Status:: 3-801328
Site Status: Unregulated: <1101 gal. PBS

MCI DBA VERIZON BUSI | 95 CHURCH STREET | NE 1/8 - 1/4 (0.209 mi.) | AJ330 | 1125
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024
Status: 0. Administratively closed
Status: 3. Closed - Removed
Id/Status:: 3-259233
Site Status: Unregulated

SMITH'S DAIRY,INC. | 61 BANK STREET | SW 1/8 - 1/4 (0.210 mi.) | AC331 | 1127
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024
Status: 3. Closed - Removed
Id/Status:: 3-600496
Site Status: Unregulated

99 CHURCH STREET | 99 CHURCH STREET | NE 1/8 - 1/4 (0.214 mi.) | AJ334 | 1133
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024

Status: 3. Closed - Removed
Id/Status:: 3-149071
Site Status: Unregulated: <1101 gal. PBS

110-122 MAMARONECK A | 110 MAMARONECK AVENU | ESE 1/8 - 1/4 (0.223 mi.) | AI336 | 1135
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024
Status: 3. Closed - Removed
Id/Status:: 3-074640
Site Status: Unregulated: <1101 gal. PBS

TEN MITCHELL PLACE | 10 MITCHELL PLACE | ESE 1/8 - 1/4 (0.227 mi.) | AI341 | 1145
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024
Status: 3. Closed - Removed
Id/Status:: 3-492132
Site Status: Unregulated: <1101 gal. PBS

MITCHELL PLACE GARAG | 9 MITCHELL PLACE | ESE 1/8 - 1/4 (0.230 mi.) | AI344 | 1149
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024
Status: 0. Administratively closed
Id/Status:: 3-168998
Site Status: Administratively Closed

DEVON PLAZA REALTY | 9 MITCHELL PLACE | ESE 1/8 - 1/4 (0.230 mi.) | AI346 | 1151
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024
Status: 3. Closed - Removed
Status: 4. Closed - in place
Status: 1. In-Service
Id/Status:: 3-412384
Site Status: Unregulated

MUNICIPAL BUILDING | 255 MAIN ST | ENE 1/8 - 1/4 (0.237 mi.) | AH349 | 1157
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024
Status: 4. Closed - in place
Id/Status:: 3-169552
Site Status: Unregulated: <1101 gal. PBS

124 MAMARONECK AVENU | 124 MAMARONECK AVENU | ESE 1/8 - 1/4 (0.240 mi.) | AK353 | 1170
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024
Status: 0. Administratively closed
Id/Status:: 3-412007
Site Status: Unregulated: <1101 gal. PBS

210 MARTINE AVENUE | 210 MARTINE AVENUE | E 1/8 - 1/4 (0.243 mi.) | AL356 | 1174
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024
Status: 4. Closed - in place
Id/Status:: 3-801056
Site Status: Unregulated

MACY'S | 220 MAIN ST | ENE 1/8 - 1/4 (0.245 mi.) | AH358 | 1187
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024
Status: 3. Closed - Removed
Id/Status:: 3-167029
Site Status: Unregulated: <1101 gal. PBS

WINBROOK HOUSING DEV | 223 DR. MARTIN LUTHE | SSE 1/8 - 1/4 (0.250 mi.) | AO370 | 1234
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024
Status: 1. In-Service
Id/Status:: 3-493597
Site Status: Active

Lower Elevation	Address	Direction / Distance	Map ID	Page

VERIZON NEW YORK, IN | 111 MAIN STREET | NNE 0 - 1/8 (0.006 mi.) | A30 | 118
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024

Status: 3. Closed - Removed
Status: 1. In-Service
Id/Status:: 3-184713
Site Status: Active

NEW YORK POWER AUTHO ***123 MAIN STREET*** ***ENE 0 - 1/8 (0.030 mi.)*** ***B54*** ***202***
Database: UST, Date of Government Version: 09/16/2024
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024
Status: 1. In-Service
Id/Status:: 3-496812
Site Status: Administratively Closed

GHP HAMILTON AVENUE 170 HAMILTON AVENUE NNW 0 - 1/8 (0.065 mi.) G83 301
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024
Status: 1. In-Service
Status: 3. Closed - Removed
Id/Status:: 3-466034
Site Status: Active

RESIDENCE 1 BARKER AVENUE N 1/8 - 1/4 (0.175 mi.) Y261 964
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024
Status: 3. Closed - Removed
Id/Status:: 3-600999
Site Status: Unregulated

PEPE CADILLAC 15 WATER STREET NNW 1/8 - 1/4 (0.176 mi.) W265 972
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024
Status: 1. In-Service
Id/Status:: 3-801848
Site Status: Active

BILL'S AUTO REPAIR 1 MAIN ST. W 1/8 - 1/4 (0.216 mi.) 335 1134
Database: NASSAU CO. UST, Date of Government Version: 11/27/2023
Facility ID: #57036
Facility ID: 057036

124 SOUTH LEXINGTON 124 SOUTH LEXINGTON S 1/8 - 1/4 (0.225 mi.) AG339 1139
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024
Status: 3. Closed - Removed
Status: 1. In-Service
Id/Status:: 3-497231
Site Status: Active

126 S. LEXINGTON CED 126 SOUTH LEXINGTON S 1/8 - 1/4 (0.229 mi.) AG342 1145
Database: WESTCHESTER CO. UST, Date of Government Version: 11/13/2024
Status: 6. Closed - Work Permit Open
Id/Status:: 3-802064
Site Status: Unregulated

NY AST: The Aboveground Storage Tank database contains registered ASTs. The data come from the Department of Environmental Conservation's Petroleum Bulk Storage (PBS) Database.

A review of the NY AST list, as provided by EDR, has revealed that there are 26 NY AST sites within approximately 0.25 miles of the target property.

Equal/Higher Elevation	Address	Direction / Distance	Map ID	Page
GATEWAY CENTER ONE	1 NORTH LEXINGTON AV	WNW 0 - 1/8 (0.015 mi.)	C47	176

Database: WESTCHESTER CO. AST, Date of Government Version: 11/13/2024

Status: 1. In-Service
PBS Number: 3-496871

GALLERIA WEST GARAGE | MARTINE AVE & SO LEX | SW 0 - 1/8 (0.035 mi.) | D60 | 241
Database: WESTCHESTER CO. AST, Date of Government Version: 11/13/2024
Status: 0. Administratively closed
PBS Number: 3-169579

77 SOUTH LEXINGTON A | 77 SOUTH LEXINGTON A | SSW 0 - 1/8 (0.075 mi.) | D92 | 315
Database: WESTCHESTER CO. AST, Date of Government Version: 11/13/2024
Status: 1. In-Service
PBS Number: 3-601115

WYASSUP-LAUREL GLEN | 175 MAIN STREET | ENE 0 - 1/8 (0.085 mi.) | K98 | 326
Database: WESTCHESTER CO. AST, Date of Government Version: 11/13/2024
Status: 1. In-Service
PBS Number: 3-032433

APARTMENT | 76 SOUTH LEXINGTON A | SSW 0 - 1/8 (0.098 mi.) | L104 | 338
Database: WESTCHESTER CO. AST, Date of Government Version: 11/13/2024
Status: 0. Administratively closed
Status: 1. In-Service
PBS Number: 3-139637

MICHAEL E LAND OFFIC | 148 MARTINE AVE | ESE 0 - 1/8 (0.106 mi.) | O116 | 359
Database: WESTCHESTER CO. AST, Date of Government Version: 11/13/2024
Status: 1. In-Service
PBS Number: 3-168777

COURT & MARTINE 2009 | 39-55 COURT ST / 167 | E 0 - 1/8 (0.114 mi.) | O147 | 448
Database: WESTCHESTER CO. AST, Date of Government Version: 11/13/2024
Status: 1. In-Service
PBS Number: 3-177903

Not reported | 111 MARTIN LUTHER KI | SE 0 - 1/8 (0.122 mi.) | Q181 | 548
Database: WESTCHESTER CO. AST, Date of Government Version: 11/13/2024
Status: 1. In-Service
PBS Number: 3-801217

199 MAIN STREET REAL | 199 MAIN STREET | ENE 1/8 - 1/4 (0.125 mi.) | K193 | 579
Database: WESTCHESTER CO. AST, Date of Government Version: 11/13/2024
Status: 1. In-Service
PBS Number: 3-049824

Not reported | 85 COURT STREET | ESE 1/8 - 1/4 (0.146 mi.) | O211 | 803
Database: WESTCHESTER CO. AST, Date of Government Version: 11/13/2024
Status: 1. In-Service
PBS Number: 3-801525

274 SNK HAMILTON AVE | 274 HAMILTON AVENUE | NE 1/8 - 1/4 (0.155 mi.) | T221 | 821
Database: WESTCHESTER CO. AST, Date of Government Version: 11/13/2024
Status: 1. In-Service
Status: 3. Closed - Removed
Status: 3a. Closed - Prior to 04/1991
Status: 0. Administratively closed
PBS Number: 3-164135

AMCOTT ASSOCIATES | 300 HAMILTON AVENUE | NE 1/8 - 1/4 (0.171 mi.) | T244 | 927
Database: WESTCHESTER CO. AST, Date of Government Version: 11/13/2024
Status: 1. In-Service
PBS Number: 3-259241

196-200 MARTINE AVEN | 196-200 MARTINE AVEN | E 1/8 - 1/4 (0.174 mi.) | X255 | 957
Database: WESTCHESTER CO. AST, Date of Government Version: 11/13/2024

Status: 2. Temporarily out of service
PBS Number: 3-802125

EMPLOYMENT BUILDING ***48 MAMARONECK AVE.*** ***E 1/8 - 1/4 (0.175 mi.)*** ***X259*** ***960***
Database: WESTCHESTER CO. AST, Date of Government Version: 11/13/2024
Status: 3. Closed - Removed
PBS Number: 3-074632

CHARLES L. BRIEANT U 300 QUARROPAS STREET S 1/8 - 1/4 (0.177 mi.) AA268 976
Database: WESTCHESTER CO. AST, Date of Government Version: 11/13/2024
Status: 1. In-Service
PBS Number: 3-801467

55 CHURCH WP LLC 55 CHURCH STREET NE 1/8 - 1/4 (0.183 mi.) AB281 1024
Database: WESTCHESTER CO. AST, Date of Government Version: 11/13/2024
Status: 1. In-Service
PBS Number: 3-800303

CENTURYLINK - WHITE 55 CHURCH STREET NE 1/8 - 1/4 (0.183 mi.) AB282 1025
Database: WESTCHESTER CO. AST, Date of Government Version: 11/13/2024
Status: 1. In-Service
PBS Number: 3-800862

MERCEDES- BENZ OF WH ***50 BANK STREET*** ***SW 1/8 - 1/4 (0.185 mi.)*** ***AC284*** ***1027***
Database: WESTCHESTER CO. AST, Date of Government Version: 11/13/2024
Status: 3. Closed - Removed
Status: 1. In-Service
PBS Number: 3-452122

170 GRAND STREET ASS ***170 GRAND STREET*** ***SE 1/8 - 1/4 (0.186 mi.)*** ***S286*** ***1046***
Database: WESTCHESTER CO. AST, Date of Government Version: 11/13/2024
Status: 1. In-Service
PBS Number: 3-800392

RENAISSANCE CORPORAT 235 MAIN STREET ENE 1/8 - 1/4 (0.190 mi.) U298 1068
Database: WESTCHESTER CO. AST, Date of Government Version: 11/13/2024
Status: 1. In-Service
PBS Number: 3-049980

204 MARTINE ASSOCIAT 204 MARTINE AVE E 1/8 - 1/4 (0.209 mi.) X329 1125
Database: WESTCHESTER CO. AST, Date of Government Version: 11/13/2024
Status: 3. Closed - Removed
PBS Number: 3-173398

DEVON PLAZA REALITY ***109 MAMARONECK AVE*** ***ESE 1/8 - 1/4 (0.236 mi.)*** ***AI348*** ***1155***
Database: WESTCHESTER CO. AST, Date of Government Version: 11/13/2024
Status: 1. In-Service
PBS Number: 3-053554

RECKSON METRO CENTER ***360 HAMILTON AVE*** ***NE 1/8 - 1/4 (0.247 mi.)*** ***AN366*** ***1225***
Database: WESTCHESTER CO. AST, Date of Government Version: 11/13/2024
Status: 1. In-Service
PBS Number: 3-177342

Lower Elevation	Address	Direction / Distance	Map ID	Page

VERIZON COMMUNICATIO ***111 MAIN ST*** ***NNE 0 - 1/8 (0.006 mi.)*** ***A29*** ***116***
Database: WESTCHESTER CO. AST, Date of Government Version: 11/13/2024
Status: 1. In-Service
Status: 3. Closed - Removed
PBS Number: 3-184713

NEW YORK POWER AUTHO ***123 MAIN STREET*** ***ENE 0 - 1/8 (0.030 mi.)*** ***B54*** ***202***
Database: AST, Date of Government Version: 09/16/2024
Database: WESTCHESTER CO. AST, Date of Government Version: 11/13/2024

Status: 1. In-Service
PBS Number: 3-496812
Facility Id: 3-602326

PEPE CADILLAC 15 WATER STREET NNW 1/8 - 1/4 (0.176 mi.) W266 973
Database: WESTCHESTER CO. AST, Date of Government Version: 11/13/2024
Status: 1. In-Service
PBS Number: 3-801848

State and tribal institutional control / engineering control registries

NY ENG CONTROLS: Environmental Remediation sites that have engineering controls in place.

A review of the NY ENG CONTROLS list, as provided by EDR, and dated 11/04/2024 has revealed that there are 2 NY ENG CONTROLS sites within approximately 0.5 miles of the target property.

Equal/Higher Elevation	Address	Direction / Distance	Map ID	Page
CE - WHITE PLAINS MG	***9 NEW STREET AND 12***	***NW 0 - 1/8 (0.118 mi.)***	***N172***	***513***
Site Code: 58617				
AUTOMOBILE CLUB OF N	***101 WESTMORELAND AVE***	***SW 1/4 - 1/2 (0.352 mi.)***	***BB423***	***1358***
Site Code: 374633				

Environmental Remediation sites that have institutional controls in place.

A review of the NY INST CONTROL list, as provided by EDR, and dated 11/04/2024 has revealed that there are 3 NY INST CONTROL sites within approximately 0.5 miles of the target property.

Equal/Higher Elevation	Address	Direction / Distance	Map ID	Page
CE - WHITE PLAINS MG	***9 NEW STREET AND 12***	***NW 0 - 1/8 (0.118 mi.)***	***N172***	***513***
Site Code: 58617				
WP MALL CLEANERS & G	***250 HAMILTON AVENUE***	***NE 1/8 - 1/4 (0.145 mi.)***	***P204***	***748***
Site Code: 628108				
AUTOMOBILE CLUB OF N	***101 WESTMORELAND AVE***	***SW 1/4 - 1/2 (0.352 mi.)***	***BB423***	***1358***
Site Code: 374633				

Lists of state and tribal voluntary cleanup sites

NY VCP: Voluntary Cleanup Agreements. The voluntary remedial program uses private monies to get contaminated sites remediated to levels allowing for the sites' productive use. The program covers virtually any kind of site and contamination.

A review of the NY VCP list, as provided by EDR, has revealed that there is 1 NY VCP site within approximately 0.5 miles of the target property.

Equal/Higher Elevation	Address	Direction / Distance	Map ID	Page
CE - WHITE PLAINS MG	***9 NEW STREET AND 12***	***NW 0 - 1/8 (0.118 mi.)***	***N172***	***513***
Database: VCP, Date of Government Version: 11/04/2024				

Site Code: 58617

Lists of state and tribal brownfield sites

NY BROWNFIELDS: Brownfields Site List

A review of the NY BROWNFIELDS list, as provided by EDR, and dated 11/04/2024 has revealed that there are 10 NY BROWNFIELDS sites within approximately 0.5 miles of the target property.

Equal/Higher Elevation	Address	Direction / Distance	Map ID	Page
HOPE FIRE ENGINE CO. Site Code: 622605	***25 NORTH LEXINGTON A***	***WNW 0 - 1/8 (0.024 mi.)***	***C50***	***188***
HAMILTON GREEN PHASE Site Code: 570663	***200 HAMILTON AVENUE***	***NE 0 - 1/8 (0.123 mi.)***	***P189***	***564***
WP MALL CLEANERS & G Site Code: 628108	***250 HAMILTON AVENUE***	***NE 1/8 - 1/4 (0.145 mi.)***	***P204***	***748***
221 MAIN STREET Site Code: 58997	***221 MAIN ST***	***ENE 1/8 - 1/4 (0.168 mi.)***	***U240***	***906***
YOUNG COAL & LUMBER Site Code: 481411	***55 BANK STREET***	***SW 1/8 - 1/4 (0.178 mi.)***	***R272***	***988***
BROOKFIELD COMMONS P Site Code: 656716	***159 SOUTH LEXINGTON***	***S 1/4 - 1/2 (0.293 mi.)***	***401***	***1295***
YMCA OF CENTRAL & NO Site Code: 612426	***250 MAMARONECK AVENU***	***SE 1/4 - 1/2 (0.433 mi.)***	***BQ483***	***1493***
POST ROAD CORRIDOR - Site Code: 544843	77 WEST POST ROAD	SSW 1/4 - 1/2 (0.492 mi.)	513	1575

Lower Elevation	Address	Direction / Distance	Map ID	Page
ONE WATER STREET BLA Site Code: 645014	P/O 1 WATER ST. AND	NW 1/8 - 1/4 (0.200 mi.)	AF313	1095
WHITE PLAINS CHRYSLE Site Code: 613124	***70 WESTCHESTER AVENU***	***E 1/4 - 1/2 (0.496 mi.)***	***BX517***	***1581***

ADDITIONAL ENVIRONMENTAL RECORDS

Records of Emergency Release Reports

NY Spills: Data collected on spills reported to NYSDEC. is required by one or more of the following: Article 12 of the Navigation Law, 6 NYCRR Section 613.8 (from PBS regs), or 6 NYCRR Section 595.2 (from CBS regs). It includes spills active as of April 1, 1986, as well as spills occurring since this date.

A review of the NY Spills list, as provided by EDR, and dated 11/03/2024 has revealed that there are 36 NY Spills sites within approximately 0.125 miles of the target property.

EXECUTIVE SUMMARY

Equal/Higher Elevation	Address	Direction / Distance	Map ID	Page
1 NORTH LEXINGTON AV	***1 NORTH LEXINGTON AV***	***WNW 0 - 1/8 (0.015 mi.)***	***C43***	***151***
Spill Number/Closed Date: 1112860 / 2012-06-06				
Spill Number/Closed Date: 1213498 / 2013-01-08				
Site ID: 460825				
Site ID: 476685				
Spill Date: 2012-02-09				
Spill Date: 2012-12-13				
OFFICE BLDG	175 MAIN ST	ENE 0 - 1/8 (0.085 mi.)	K99	327
Spill Number/Closed Date: 9910497 / 1999-12-02				
Site ID: 83742				
Spill Date: 1999-12-02				
DRAIN - COOKING GREA	175 MAIN STREET	ENE 0 - 1/8 (0.085 mi.)	K100	328
Spill Number/Closed Date: 1511825 / 2016-04-11				
Site ID: 524609				
Spill Date: 2016-03-12				
APARTMENT	***76 SOUTH LEXINGTON A***	***SSW 0 - 1/8 (0.098 mi.)***	***L104***	***338***
Spill Number/Closed Date: 0605116 / 2006-08-03				
Site ID: 368222				
Spill Date: 2006-08-03				
WHITE PLAINS SUB-STA	2 NEW STREET	NW 0 - 1/8 (0.100 mi.)	F108	344
Spill Number/Closed Date: 0104086 / 2001-07-17				
Site ID: 218482				
Spill Date: 2001-07-17				
WHITE PLAINS SUB STA	NEW STREET	NNW 0 - 1/8 (0.106 mi.)	N115	355
Spill Number/Closed Date: 9700350 / 1997-04-07				
Spill Number/Closed Date: 0111787 / 2005-03-06				
Spill Number/Closed Date: 0403778 / 2004-07-09				
Spill Number/Closed Date: 9606340 / 1996-08-16				
Site ID: 152482				
Site ID: 152479				
Site ID: 152480				
Site ID: 152481				
Spill Date: 1997-04-07				
Spill Date: 2002-03-14				
Spill Date: 2004-07-08				
Spill Date: 1996-08-16				
MICHAEL E LAND OFFIC	***148 MARTINE AVE***	***ESE 0 - 1/8 (0.106 mi.)***	***O116***	***359***
Spill Number/Closed Date: 0301426 / 2003-05-08				
Spill Number/Closed Date: 0412020 / 2008-12-18				
Spill Number/Closed Date: 8900947 / 1989-07-25				
Spill Number/Closed Date: 9103040 / 1991-06-18				
Spill Number/Closed Date: 9202919 / 1992-07-13				
Site ID: 214706				
Site ID: 337374				
Site ID: 253231				
Site ID: 126441				
Site ID: 183296				
Spill Date: 2003-05-08				
Spill Date: 2005-02-10				
Spill Date: 1989-05-01				
Spill Date: 1991-06-12				

Spill Date: 1992-06-10

CAPPELLI ASSOC. Spill Number/Closed Date: 0509190 / 2005-11-01 Spill Number/Closed Date: 0601744 / 2008-06-11 Site ID: 354925 Site ID: 364045 Spill Date: 2005-11-01 Spill Date: 2006-05-17	189 MAIN STREET	ENE 0 - 1/8 (0.107 mi.)	K125	397
OUTSIDE DWELLING Spill Number/Closed Date: 0813053 / 2009-03-05 Site ID: 410714 Spill Date: 2009-03-05	25 BANK DRIVE	WSW 0 - 1/8 (0.108 mi.)	M127	403
ROADWAY Spill Number/Closed Date: 0812871 / 2009-02-27 Site ID: 410519 Spill Date: 2009-02-27	MAIN ST & COURT ST	ENE 0 - 1/8 (0.111 mi.)	K132	415
DIESEL IN STREAM Spill Number/Closed Date: 1812048 / 2019-03-07 Site ID: 584004 Spill Date: 2019-03-06	10 NEW KING ST	NW 0 - 1/8 (0.111 mi.)	N143	443
VEHICLE #41354 Spill Number/Closed Date: 0509373 / 2005-11-04 Site ID: 355142 Spill Date: 2005-11-04	LEXINGTON AVE/ NEW S	E 0 - 1/8 (0.111 mi.)	O144	444
MINSKOFF MANAGEMENT Spill Number/Closed Date: 9110040 / 1992-03-10 Site ID: 239414 Spill Date: 1991-12-20	39-47 COURT STREET	E 0 - 1/8 (0.114 mi.)	O146	447
I/F/O THE MELTING PO Spill Number/Closed Date: 1000201 / 2010-04-06 Site ID: 431359 Spill Date: 2010-04-06	35 COURT ST	E 0 - 1/8 (0.114 mi.)	O148	449
ON STREET Spill Number/Closed Date: 0512156 / 2007-05-07 Site ID: 358429 Spill Date: 2006-01-11	WILLIAMS STREET	NNE 0 - 1/8 (0.116 mi.)	P151	454
SOIL Spill Number/Closed Date: 1011749 / 2011-03-31 Site ID: 445639 Spill Date: 2011-02-24	3 RENAISSANCE SQUARE	ENE 0 - 1/8 (0.116 mi.)	K152	455
DPW VEHICLE Spill Number/Closed Date: 1305831 / 2013-10-07 Site ID: 486412 Spill Date: 2013-09-03	COURT ST AND MARTINE	E 0 - 1/8 (0.116 mi.)	O154	459
MARITINE AVE Spill Number/Closed Date: 8607289 / 1989-11-28 Site ID: 297340 Spill Date: 1986-12-01	MARITINE AVE & BANK	WSW 0 - 1/8 (0.118 mi.)	J166	482
CON ED Spill Number/Closed Date: 1500081 / 2015-04-03 Site ID: 506215	9 NEW ST	NW 0 - 1/8 (0.118 mi.)	N167	483

Spill Date: 2015-04-03

TRANSFORMER 7 | 9 NEW ST - SUBSTATIO | NW 0 - 1/8 (0.118 mi.) | N168 | 484
Spill Number/Closed Date: 0300784 / 2003-04-25
Site ID: 227017
Spill Date: 2003-04-22

WHITE PLAINS SUBSTAT | ***9 NEW ST*** | ***NW 0 - 1/8 (0.118 mi.)*** | ***N170*** | ***485***
Spill Number/Closed Date: 0408249 / 2004-10-28
Spill Number/Closed Date: 0511276 / 2005-12-28
Spill Number/Closed Date: 0511486 / 2006-01-04
Spill Number/Closed Date: 0501556 / 2005-05-10
Spill Number/Closed Date: 0607603 / 2006-10-05
**Additional key fields are available in the Map Findings section*
Site ID: 332929
Site ID: 357395
Site ID: 357650
Site ID: 345728
Site ID: 371373
**Additional key fields are available in the Map Findings section*
Spill Date: 2004-10-26
Spill Date: 2005-12-28
Spill Date: 2006-01-04
Spill Date: 2005-05-09
Spill Date: 2006-10-04
**Additional key fields are available in the Map Findings section*

WHITE PLAINS SUB STA | 9 NEW STREET | NW 0 - 1/8 (0.118 mi.) | N173 | 528
Spill Number/Closed Date: 0905920 / 2010-06-24
Site ID: 418215
Spill Date: 2009-08-20

CON ED SUBSTATION | 9 NEW ST | NW 0 - 1/8 (0.118 mi.) | N174 | 529
Spill Number/Closed Date: 2203027 / 2022-07-08
Site ID: 639126
Spill Date: 2022-07-08

WHITE PLAINS SUB-STA | 5 NEW STREET | NW 0 - 1/8 (0.119 mi.) | N176 | 541
Spill Number/Closed Date: 9610321 / 1996-11-22
Spill Number/Closed Date: 0404755 / 2004-08-02
Site ID: 325629
Site ID: 266688
Spill Date: 1996-11-18
Spill Date: 2004-08-01

COMMERCIAL PROPERTY | 1-3 NEW KING ST | NW 0 - 1/8 (0.119 mi.) | N179 | 546
Spill Number/Closed Date: 1604489 / 2017-04-04
Site ID: 530997
Spill Date: 2016-08-03

HAMILTON GREEN PHASE | ***200 HAMILTON AVENUE*** | ***NE 0 - 1/8 (0.123 mi.)*** | ***P189*** | ***564***
Spill Number/Closed Date: 1706297 / 2022-08-12
Site ID: 560605
Spill Date: 2017-09-22

Lower Elevation	Address	Direction / Distance	Map ID	Page

VAULT #0070 | MAIN ST & GROVE ST | ENE 0 - 1/8 (0.003 mi.) | B24 | 107
Spill Number/Closed Date: 9908279 / 1999-10-07

Site ID: 179454 Spill Date: 1999-10-07				
WHITE PLAINS GARAGE Spill Number/Closed Date: 9110939 / 1992-01-24 Site ID: 179453 Spill Date: 1992-01-22	MAIN ST & GROVE ST	ENE 0 - 1/8 (0.003 mi.)	B26	110
NYNEX Spill Number/Closed Date: 9808850 / 1998-10-16 Site ID: 239423 Spill Date: 1998-10-15	***111 MAIN ST***	***NNE 0 - 1/8 (0.006 mi.)***	***A28***	***112***
IN FRONT OF GALERIA Spill Number/Closed Date: 9809244 / 1998-10-23 Site ID: 253722 Spill Date: 1998-10-23	MAIN ST	N 0 - 1/8 (0.008 mi.)	A34	133
MARTIN LUTHER KING & Spill Number/Closed Date: 0101975 / 2001-05-21 Site ID: 326507 Spill Date: 2001-05-21	MAIN STREET	ENE 0 - 1/8 (0.029 mi.)	B51	193
ODDESY CORP MAINT DE Spill Number/Closed Date: 8606381 / 1987-03-16 Site ID: 160998 Spill Date: 1987-01-13	***123 MAIN STREET***	***ENE 0 - 1/8 (0.030 mi.)***	***B53***	***198***
NEW YORK POWER AUTHO Spill Number/Closed Date: 2305237 / 2023-09-18 Site ID: 657171 Spill Date: 2023-09-16	***123 MAIN ST***	***ENE 0 - 1/8 (0.030 mi.)***	***B56***	***212***
COMMERCIAL Spill Number/Closed Date: 1900748 / 2020-01-17 Site ID: 586585 Spill Date: 2019-04-22	170 HAMILTON AVE	NNW 0 - 1/8 (0.065 mi.)	G84	302
OFFICE BUILDING Spill Number/Closed Date: 9601379 / 2000-10-06 Site ID: 125352 Spill Date: 1996-04-26	***170 HAMILTON AVE***	***NNW 0 - 1/8 (0.065 mi.)***	***G85***	***303***
MANHOLE #4021 Spill Number/Closed Date: 0205032 / 2002-08-13 Site ID: 69649 Spill Date: 2002-08-12	HAMILTON AVE & GROVE	NNE 0 - 1/8 (0.073 mi.)	I89	311

Other Ascertainable Records

RCRA NonGen / NLR: RCRAInfo is EPA's comprehensive information system, providing access to data supporting the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. The database includes selective information on sites which generate, transport, store, treat and/or dispose of hazardous waste as defined by the Resource Conservation and Recovery Act (RCRA). Non-Generators do not presently generate hazardous waste.

A review of the RCRA NonGen / NLR list, as provided by EDR, and dated 09/16/2024 has revealed that

there are 89 RCRA NonGen / NLR sites within approximately 0.25 miles of the target property.

Equal/Higher Elevation	Address	Direction / Distance	Map ID	Page
CON EDISON EPA ID:: NYP004212403	***81 MAIN ST FRONT OF***	***WNW 0 - 1/8 (0.006 mi.)***	***C33***	***129***
CON EDISON MANHOLE: EPA ID:: NYP004307484	***LEXINGTON AVE & MAIN***	***WNW 0 - 1/8 (0.011 mi.)***	***C38***	***140***
CON EDISON VAULT: 70 EPA ID:: NYP004371571	***MAIN ST & LEXINGTON***	***WNW 0 - 1/8 (0.011 mi.)***	***C39***	***144***
CON EDISON SERVICE B EPA ID:: NYP004408274	***S LEXINGTON AVE & MA***	***SW 0 - 1/8 (0.035 mi.)***	***D57***	***236***
CON EDISON MANHOLE: EPA ID:: NYP004318374	***MARTINE AVE & S LEXI***	***SW 0 - 1/8 (0.035 mi.)***	***D61***	***242***
CON EDISON EPA ID:: NYP004786067	N LEXINGTON AVE & MA	SW 0 - 1/8 (0.035 mi.)	D63	248
CON EDISON SERVICE B EPA ID:: NYP004408282	***S LEXINGTON AVE & MA***	***SW 0 - 1/8 (0.035 mi.)***	***D64***	***250***
CON EDISON EPA ID:: NYP004398962	***MARTINE & GROVE ST***	***SE 0 - 1/8 (0.036 mi.)***	***E68***	***257***
CON EDISON MANHOLE 9 EPA ID:: NYP004224192	***MARTINE AVE & GROVE***	***SE 0 - 1/8 (0.037 mi.)***	***E69***	***260***
CON EDISON MANHOLE 9 EPA ID:: NYP004224101	***MARTINE AVE & GROVE***	***SE 0 - 1/8 (0.037 mi.)***	***E70***	***264***
CON EDISON MANHOLE 9 EPA ID:: NYP004224465	***MARTINE AVE & GROVE***	***SE 0 - 1/8 (0.037 mi.)***	***E71***	***269***
CON EDISON MANHOLE: EPA ID:: NYP004328050	***MAIN ST & WILLIAMS S***	***ENE 0 - 1/8 (0.047 mi.)***	***B72***	***273***
CON EDISON EPA ID:: NYP004214599	***WILLIAMS ST & MAIN S***	***ENE 0 - 1/8 (0.047 mi.)***	***B73***	***277***
CON EDISON EPA ID:: NYP004846109	WILLIAMS ST & MAIN S	ENE 0 - 1/8 (0.047 mi.)	B75	283
CON EDISON EPA ID:: NYP004210985	***LEXINGTON & HAMILTON***	***NW 0 - 1/8 (0.058 mi.)***	***F80***	***288***
CON EDISON MANHOLE: EPA ID:: NYP004398830	***HAMILTON AVE & LEXIN***	***NW 0 - 1/8 (0.058 mi.)***	***F81***	***293***
CON EDISON EPA ID:: NYP004210852	***HAMILTON & N LEXINGT***	***NW 0 - 1/8 (0.058 mi.)***	***F82***	***296***
WHITE PLAINS GENL AU EPA ID:: NYD013395397	***76 HAMILTON AVE***	***NW 0 - 1/8 (0.069 mi.)***	***F88***	***307***
CON EDISON MANHOLE: EPA ID:: NYP004476107	***MAIN ST & BANK ST***	***W 0 - 1/8 (0.093 mi.)***	***H102***	***330***
CON EDISON EPA ID:: NYP004212643	***BANK ST & MAIN ST***	***W 0 - 1/8 (0.093 mi.)***	***H103***	***333***
CON EDISON VAULT: 65 EPA ID:: NYP004508313	76-78 S LEXINGTON AV	SSW 0 - 1/8 (0.098 mi.)	L105	340
CON EDISON EPA ID:: NYP004812398	15 BANK ST	W 0 - 1/8 (0.102 mi.)	M112	349
CON EDISON MANHOLE 5	LEXINGTON AVE & NEW	NW 0 - 1/8 (0.102 mi.)	F113	351

EPA ID:: NYP004140646				
CON EDISON	***148 MARTINE AVE***	***ESE 0 - 1/8 (0.106 mi.)***	***O119***	***371***
EPA ID:: NYP004785739				
CON EDISON MANHOLE:	***25 BANK ST***	***WSW 0 - 1/8 (0.108 mi.)***	***M126***	***399***
EPA ID:: NYP004306650				
CON EDISON MANHOLE:	***BANK ST & HAMILTON A***	***WNW 0 - 1/8 (0.109 mi.)***	***H128***	***404***
EPA ID:: NYP004476115				
CON EDISON MANHOLE 5	COURT ST & MAIN ST	ENE 0 - 1/8 (0.111 mi.)	K129	408
EPA ID:: NYP004137717				
CON EDISON	***MAIN ST & COURT ST***	***ENE 0 - 1/8 (0.111 mi.)***	***K131***	***412***
EPA ID:: NYP004146833				
CON EDISON MANHOLE 1	***MAIN ST & COURT ST***	***ENE 0 - 1/8 (0.111 mi.)***	***K134***	***418***
EPA ID:: NYP004146551				
CON EDISON MANHOLE 1	***COURT ST & MAIN ST***	***ENE 0 - 1/8 (0.111 mi.)***	***K135***	***421***
EPA ID:: NYP004224754				
CON EDISON	COURT ST & MAIN ST	ENE 0 - 1/8 (0.111 mi.)	K136	426
EPA ID:: NYP004784807				
CON EDISON SERVICE B	***MAIN ST & COURT ST***	***ENE 0 - 1/8 (0.111 mi.)***	***K137***	***428***
EPA ID:: NYP004450573				
CON EDISON	***COURT ST & MAIN ST***	***ENE 0 - 1/8 (0.111 mi.)***	***K138***	***431***
EPA ID:: NYP004350450				
CON EDISON MANHOLE:	***MAIN ST & COURT ST***	***ENE 0 - 1/8 (0.111 mi.)***	***K139***	***434***
EPA ID:: NYP004432753				
CON EDISON MANHOLE:	***MAIN ST & COURT ST***	***ENE 0 - 1/8 (0.111 mi.)***	***K140***	***437***
EPA ID:: NYP004327854				
CON EDISON SERVICE B	***19 COURT ST***	***E 0 - 1/8 (0.114 mi.)***	***K150***	***451***
EPA ID:: NYP004432662				
CON EDISON	***COURT ST & MARTINE A***	***E 0 - 1/8 (0.116 mi.)***	***O153***	***457***
EPA ID:: NYP004784880				
CON EDISON MANHOLE 9	***MARTINE AVE & COURT***	***E 0 - 1/8 (0.116 mi.)***	***O155***	***460***
EPA ID:: NYP004224176				
CON EDISON TRANSFORM	***MARTINE AVE & COURT***	***E 0 - 1/8 (0.116 mi.)***	***O158***	***468***
EPA ID:: NYP004321162				
CON EDISON	***10 BANK ST & MARTINE***	***WSW 0 - 1/8 (0.117 mi.)***	***J164***	***478***
EPA ID:: NYP004776522				
CON EDISON	111 MARTIN LUTHER KI	SE 0 - 1/8 (0.122 mi.)	Q184	552
EPA ID:: NYP004885055				
WESTCHESTER COUNTY C	***111 GROVE ST***	***SE 0 - 1/8 (0.122 mi.)***	***Q186***	***555***
EPA ID:: NYR000028902				
CON EDISON MANHOLE 4	***199 MAIN ST & MAMARO***	***ENE 1/8 - 1/4 (0.125 mi.)***	***K192***	***574***
EPA ID:: NYP004224721				
CON EDISON	10 BANK ST	SW 1/8 - 1/4 (0.142 mi.)	R198	588
EPA ID:: NYP004792248				
MARUBENI SPECIALTY C	***10 BANK ST***	***SW 1/8 - 1/4 (0.142 mi.)***	***R201***	***592***
EPA ID:: NYD987027638				
CON EDISON	10 BANK ST	SW 1/8 - 1/4 (0.142 mi.)	R203	746

EPA ID:: NYP004769600				
RENAISSANCE ENV MANA EPA ID:: NYR000258814	***250 HAMILTON AVE***	***NE 1/8 - 1/4 (0.145 mi.)***	***P205***	***789***
CON EDISON EPA ID:: NYP004213476	***GROVE ST & QUARROPAS***	***SSE 1/8 - 1/4 (0.145 mi.)***	***Q207***	***796***
CON EDISON EPA ID:: NYP004805560	QUARROPAS ST & MLK B	SSE 1/8 - 1/4 (0.145 mi.)	Q209	800
WHITE PLAINS POLICE EPA ID:: NYD986876019	***279 HAMILTON AVE***	***NE 1/8 - 1/4 (0.148 mi.)***	***T213***	***805***
WHITE PLAINS TOWN CE EPA ID:: NYR000062356	MAMARONECK AVE & MAI	ENE 1/8 - 1/4 (0.165 mi.)	U229	847
CON EDISON EPA ID:: NYP004312302	***MAMARONECK AVE & MAI***	***ENE 1/8 - 1/4 (0.167 mi.)***	***U235***	***889***
RECKSON ASSOCIATES EPA ID:: NYR000096263	***140 GRAND ST***	***SE 1/8 - 1/4 (0.168 mi.)***	***S237***	***896***
WHITE PLAINS RUBBER EPA ID:: NYD980648422	***20 BANK ST***	***SW 1/8 - 1/4 (0.171 mi.)***	***R241***	***913***
YOUNG COAL & LUMBER EPA ID:: NYR000222273	***55 BANK ST - TXI ID#***	***SW 1/8 - 1/4 (0.178 mi.)***	***R270***	***978***
CON EDISON EPA ID:: NYP004213484	***240 MARTINE AVE & MA***	***E 1/8 - 1/4 (0.180 mi.)***	***X275***	***1001***
CON EDISON MANHOLE: EPA ID:: NYP004314233	***QUARROPAS ST & FISCH***	***S 1/8 - 1/4 (0.180 mi.)***	***AA276***	***1004***
CON EDISON SERVICE B EPA ID:: NYP004514436	***FISHER CT & QUARROPA***	***S 1/8 - 1/4 (0.180 mi.)***	***AA278***	***1009***
1-HOUR PHOTO FINISH EPA ID:: NYR000035253	***60B MAMARONECK AVE***	***E 1/8 - 1/4 (0.181 mi.)***	***X280***	***1013***
CON EDISON EPA ID:: NYP004161261	***MAIN ST & CHURCH ST***	***ENE 1/8 - 1/4 (0.189 mi.)***	***U290***	***1052***
177 GRAND STREET ASS EPA ID:: NYR000063727	***177 GRAND ST***	***SE 1/8 - 1/4 (0.189 mi.)***	***S291***	***1056***
CON EDISON MANHOLE: EPA ID:: NYP004420485	***BARKER ST & COTTAGE***	***NNE 1/8 - 1/4 (0.198 mi.)***	***AD304***	***1076***
CON EDISON EPA ID:: NYP004485504	***COTTAGE PL & BARKER***	***NNE 1/8 - 1/4 (0.198 mi.)***	***AD306***	***1081***
CON EDISON EPA ID:: NYP004825978	***GROVE ST & FISCHER C***	***SSE 1/8 - 1/4 (0.199 mi.)***	***AE310***	***1088***
CON EDISON SERVICE B EPA ID:: NYP004428926	***GROVE ST & FISCHER A***	***SSE 1/8 - 1/4 (0.199 mi.)***	***AE311***	***1090***
CON EDISON EPA ID:: NYP004749677	***S LEXINGTON AVE & QU***	***S 1/8 - 1/4 (0.200 mi.)***	***AG315***	***1098***
CON EDISON MANHOLE 1 EPA ID:: NYP004140307	***S LEXINGTON AVE & FI***	***S 1/8 - 1/4 (0.200 mi.)***	***AG318***	***1103***
CON EDISON EPA ID:: NYP004764643	LEXINGTON AVE & QUAR	S 1/8 - 1/4 (0.200 mi.)	AG319	1107
CON EDISON MANHOLE:	***S LEXINGTON AVE & FI***	***S 1/8 - 1/4 (0.200 mi.)***	***AG323***	***1112***

EPA ID:: NYP004379814				
CON EDISON TRANSFORM EPA ID:: NYP004475315	***MITCHELL PL & MAMARO***	***ESE 1/8 - 1/4 (0.209 mi.)***	***AI327***	***1121***
WHITE PLAINS DEPT OF EPA ID:: NYN008015984	***255 MAIN ST***	***ENE 1/8 - 1/4 (0.237 mi.)***	***AH351***	***1158***
T S T WHITE PLAINS L EPA ID:: NYR000054361	***220 MAIN ST***	***ENE 1/8 - 1/4 (0.245 mi.)***	***AH357***	***1175***
CON EDISON SERVICE B EPA ID:: NYP004450730	***BARKER AVE & CHURCH***	***NNE 1/8 - 1/4 (0.247 mi.)***	***AM361***	***1194***
CON EDISON MANHOLE: EPA ID:: NYP004365813	***BARKER AVE & CHURCH***	***NNE 1/8 - 1/4 (0.247 mi.)***	***AM362***	***1197***
RECKSON ASSOCIATES EPA ID:: NYR000071779	***360 HAMILTON AVE - M***	***NE 1/8 - 1/4 (0.247 mi.)***	***AN365***	***1216***
CON EDISON EPA ID:: NYP004846877	***128 MAMARONECK AVE***	***ESE 1/8 - 1/4 (0.249 mi.)***	***AK367***	***1229***

Lower Elevation	Address	Direction / Distance	Map ID	Page
CON EDISON MANHOLE 9 EPA ID:: NYP004232856	MAIN ST & MARTIN LUT	ENE 0 - 1/8 (0.003 mi.)	B25	108
NYNEX MATERIEL ENTER EPA ID:: NYD980582480	***111 MAIN ST***	***NNE 0 - 1/8 (0.006 mi.)***	***A31***	***120***
NY POWER AUTH EPA ID:: NYD986983468	123 MAIN ST	ENE 0 - 1/8 (0.030 mi.)	B52	194
WESTCHESTER CO BRONX EPA ID:: NYR000100974	***1 BRONX ST- LAT 41 1***	***W 1/8 - 1/4 (0.166 mi.)***	***232***	***882***
CON EDISON MANHOLE 4 EPA ID:: NYP004146783	***BARKER AVE & GROVE S***	***N 1/8 - 1/4 (0.172 mi.)***	***W245***	***928***
CON EDISON MANHOLE 1 EPA ID:: NYP004220588	***WATER ST & N LEXINGT***	***NNW 1/8 - 1/4 (0.173 mi.)***	***W248***	***935***
CON EDISON MANHOLE: EPA ID:: NYP004303343	***WATER ST & LEXINGTON***	***NNW 1/8 - 1/4 (0.173 mi.)***	***W249***	***939***
CON EDISON EPA ID:: NYP004207167	***WATER ST & LEXINGTON***	***NNW 1/8 - 1/4 (0.173 mi.)***	***W250***	***943***
CON EDISON MANHOLE: EPA ID:: NYP004358081	***WATER ST & LEXINGTON***	***NNW 1/8 - 1/4 (0.173 mi.)***	***W252***	***949***
CON EDISON EPA ID:: NYP004207183	***WATER ST & LEXINGTON***	***NNW 1/8 - 1/4 (0.173 mi.)***	***W254***	***953***
AHERN PAINTING CONTR EPA ID:: NYR000236299	HAMILTON AVE & BRONX	WNW 1/8 - 1/4 (0.175 mi.)	Z262	964
CON EDISON MANHOLE EPA ID:: NYP004214540	***HAMILTON AVE & BRONX***	***WNW 1/8 - 1/4 (0.175 mi.)***	***Z264***	***969***
CON EDISON MANHOLE: EPA ID:: NYP004382602	***WATER ST & FERRIS AV***	***NW 1/8 - 1/4 (0.197 mi.)***	***AF303***	***1073***

EXECUTIVE SUMMARY

FUSRAP: DOE established the Formerly Utilized Sites Remedial Action Program (FUSRAP) in 1974 to remediate sites where radioactive contamination remained from Manhattan Project and early U.S. Atomic Energy Commission (AEC) operations.

A review of the FUSRAP list, as provided by EDR, and dated 03/03/2023 has revealed that there is 1 FUSRAP site within approximately 1 mile of the target property.

Equal/Higher Elevation	Address	Direction / Distance	Map ID	Page
NUCLEAR DEVELOPMENT	5 NEW STREET	NW 0 - 1/8 (0.119 mi.)	N177	543
Site Status: Eliminated from consideration under FUSRAP				
Site ID: NY 32				

FUELS PROGRAM: This listing includes facilities that are registered under the Part 80 (Code of Federal Regulations) EPA Fuels Programs. All companies now are required to submit new and updated registrations.

A review of the FUELS PROGRAM list, as provided by EDR, and dated 11/08/2024 has revealed that there is 1 FUELS PROGRAM site within approximately 0.25 miles of the target property.

Equal/Higher Elevation	Address	Direction / Distance	Map ID	Page
RNG PADD 1	***1 N LEXINGTON AVE***	***WNW 0 - 1/8 (0.015 mi.)***	***C46***	***162***
Company Seq ID: 6523				
Facility ID: 73681				
Facility ID: 73682				
Facility ID: 73683				
Facility ID: 73684				
Facility ID: 73685				

UST FINDER RELEASE: US EPA's UST Finder data is a national composite of leaking underground storage tanks. This data contains information about, and locations of, leaking underground storage tanks. Data was collected from state sources and standardized into a national profile by EPA's Office of Underground Storage Tanks, Office of Research and Development, and the Association of State and Territorial Solid Waste Management Officials.

A review of the UST FINDER RELEASE list, as provided by EDR, and dated 06/08/2023 has revealed that there are 24 UST FINDER RELEASE sites within approximately 0.5 miles of the target property.

Equal/Higher Elevation	Address	Direction / Distance	Map ID	Page
1 NORTH LEXINGTON AV	1 NORTH LEXINGTON AV	WNW 0 - 1/8 (0.015 mi.)	C49	187
WESTCHESTER CO DPW	148 MARTINE AVE	ESE 0 - 1/8 (0.106 mi.)	O118	370
MICHAELIAN OFFICE BL	148 MARTINE AVE	ESE 0 - 1/8 (0.106 mi.)	O123	395
FORMER WPPD	279 HAMITON AVE	NE 1/8 - 1/4 (0.148 mi.)	T216	814
EXXON, WHITE PLAINS	274 HAMILTON AVE	NE 1/8 - 1/4 (0.155 mi.)	T222	823
PEPE MOTORS	50 BANK ST	SW 1/8 - 1/4 (0.185 mi.)	AC283	1026
GAS STATION	9 MITCHELL PL	ESE 1/8 - 1/4 (0.230 mi.)	AI345	1150
CITY HALL	255 MAIN ST	ENE 1/8 - 1/4 (0.237 mi.)	AH350	1158
FIRE STATION # 2 WH	20 FERRIS AVE	NW 1/4 - 1/2 (0.267 mi.)	AS382	1251
FIRE STATION # 2	20 FERRIS AVE	NW 1/4 - 1/2 (0.267 mi.)	AS384	1258
WHITE PLAINS CITGO	34 EAST POST ROAD	S 1/4 - 1/2 (0.340 mi.)	AZ417	1324
N.Y. TELEPHONE	40 WASHINGTON AVE.	W 1/4 - 1/2 (0.343 mi.)	AV422	1358
GETTY SERVICE STATIO	11 EAST POST ROAD	S 1/4 - 1/2 (0.375 mi.)	BG439	1410
GETTY GAS #58108	11 EAST POST ROAD	S 1/4 - 1/2 (0.375 mi.)	BG440	1411
SPILL NUMBER 8600048	11 EAST POST ROAD	S 1/4 - 1/2 (0.375 mi.)	BG441	1412
GETTY # 58108	11 EAST POST ROAD	S 1/4 - 1/2 (0.375 mi.)	BG442	1412

EXECUTIVE SUMMARY

Equal/Higher Elevation	Address	Direction / Distance	Map ID	Page
GETTY 58108	11 EAST POST ROAD	S 1/4 - 1/2 (0.375 mi.)	BG444	1415
GETTY #58108	11 EAST POST ROAD	S 1/4 - 1/2 (0.375 mi.)	BG445	1417
WHITE PLAINS DPW	MAPLE & MAMARONECK A	SE 1/4 - 1/2 (0.382 mi.)	BE450	1424
AVIS	20 WEST POST RD	S 1/4 - 1/2 (0.409 mi.)	BP470	1467

Lower Elevation	Address	Direction / Distance	Map ID	Page
NYNEX	111 MAIN ST	NNE 0 - 1/8 (0.006 mi.)	A27	111
NY TEL	111 EAST MAIN STREET	NNE 0 - 1/8 (0.006 mi.)	A32	128
MARIOTT RESIDENCE IN	5 BARKER AVE	NNE 1/8 - 1/4 (0.189 mi.)	AD295	1065
ATI	RTE 100 CENTRAL AVE	NW 1/4 - 1/2 (0.448 mi.)	BU490	1532

UST FINDER: EPA developed UST Finder, a web map application containing a comprehensive, state-sourced national map of underground storage tank (UST) and leaking UST (LUST) data. It provides the attributes and locations of active and closed USTs, UST facilities, and LUST sites from states and from Tribal lands and US territories . UST Finder contains information about proximity of UST facilities and LUST sites to: surface and groundwater public drinking water protection areas; estimated number of private domestic wells and number of people living nearby; and flooding and wildfires.

A review of the UST FINDER list, as provided by EDR, and dated 06/08/2023 has revealed that there is 1 UST FINDER site within approximately 0.25 miles of the target property.

Lower Elevation	Address	Direction / Distance	Map ID	Page
NEW YORK POWER AUTHO	123 MAIN STREET	ENE 0 - 1/8 (0.030 mi.)	B55	211

E MANIFEST: EPA established a national system for tracking hazardous waste shipments electronically. This system, known as ?e-Manifest,? will modernize the nation?s cradle-to-grave hazardous waste tracking process while saving valuable time, resources, and dollars for industry and states.

A review of the E MANIFEST list, as provided by EDR, and dated 09/16/2024 has revealed that there are 10 E MANIFEST sites within approximately 0.25 miles of the target property.

Equal/Higher Elevation	Address	Direction / Distance	Map ID	Page
RNG PADD 1	***1 N LEXINGTON AVE***	***WNW 0 - 1/8 (0.015 mi.)***	***C46***	***162***
WHITE PLAINS SUBSTAT	***9 NEW STREET***	***NW 0 - 1/8 (0.118 mi.)***	***N171***	***498***
AMERICAN DENTAL OFFI	200 HAMILTON AVENUE	NE 0 - 1/8 (0.123 mi.)	P187	562
RENAISSANCE ENV MANA	***250 HAMILTON AVE***	***NE 1/8 - 1/4 (0.145 mi.)***	***P205***	***789***
CVS	***24 MAMARONECK AVENUE***	***E 1/8 - 1/4 (0.165 mi.)***	***U231***	***855***
U.S. PROBATION OFFIC	300 QUARROPAS STREET	S 1/8 - 1/4 (0.177 mi.)	AA269	977
WINBROOK APARTMENTS	***11 FISHER AVE***	***SSW 1/8 - 1/4 (0.206 mi.)***	***AG325***	***1116***
WHITE PLAINS DEPT OF	***255 MAIN ST***	***ENE 1/8 - 1/4 (0.237 mi.)***	***AH351***	***1158***

Lower Elevation	Address	Direction / Distance	Map ID	Page
NEW YORK POWER AUTHO	***123 MAIN ST***	***ENE 0 - 1/8 (0.030 mi.)***	***B56***	***212***
WHITE PLAINS HOUSING	***33 FISHER AVE***	***NNE 0 - 1/8 (0.083 mi.)***	***G97***	***322***

EXECUTIVE SUMMARY

NY PFAS: DEC surveyed select businesses, fire departments, fire training centers, bulk storage facilities, airports, and Department of Defense (DoD) facilities. The responses to the survey have helped to determine if these entities used or stored materials containing PFOA/PFOS including AFFF and dispersants used in Teflon coating operations. The results of this survey will be updated periodically as additional responses are received..

A review of the NY PFAS list, as provided by EDR, has revealed that there is 1 NY PFAS site within approximately 0.25 miles of the target property.

Equal/Higher Elevation	Address	Direction / Distance	Map ID	Page
WP MALL CLEANERS & G	***250 HAMILTON AVENUE***	***NE 1/8 - 1/4 (0.145 mi.)***	***P204***	***748***
Database: PFAS 3, Date of Government Version: 11/04/2024				

NY MANIFEST: Manifest is a document that lists and tracks hazardous waste from the generator through transporters to a TSD facility.

A review of the NY MANIFEST list, as provided by EDR, and dated 12/31/2019 has revealed that there are 117 NY MANIFEST sites within approximately 0.25 miles of the target property.

Equal/Higher Elevation	Address	Direction / Distance	Map ID	Page
CON EDISON	***81 MAIN ST FRONT OF***	***WNW 0 - 1/8 (0.006 mi.)***	***C33***	***129***
EPA ID: NYP004212403				
CON EDISON MANHOLE:	***LEXINGTON AVE & MAIN***	***WNW 0 - 1/8 (0.011 mi.)***	***C38***	***140***
EPA ID: NYP004307484				
CON EDISON VAULT: 70	***MAIN ST & LEXINGTON***	***WNW 0 - 1/8 (0.011 mi.)***	***C39***	***144***
EPA ID: NYP004371571				
CON EDISON	S. LEXINGTON AVE & E	WNW 0 - 1/8 (0.011 mi.)	C40	147
EPA ID: NYP004303764				
CON EDISON	S LEXINGTON AV & MAI	WNW 0 - 1/8 (0.011 mi.)	C41	148
EPA ID: NYP004707600				
GATEWAY BLDG	1 N LEXINGTON AVE 13	WNW 0 - 1/8 (0.015 mi.)	C48	177
EPA ID: NYD986984698				
CON EDISON SERVICE B	***S LEXINGTON AVE & MA***	***SW 0 - 1/8 (0.035 mi.)***	***D57***	***236***
EPA ID: NYP004408274				
CON EDISON MANHOLE:	***MARTINE AVE & S LEXI***	***SW 0 - 1/8 (0.035 mi.)***	***D61***	***242***
EPA ID: NYP004318374				
CON EDISON	S. LEXINGTON AV & MA	SW 0 - 1/8 (0.035 mi.)	D62	245
EPA ID: NYP004688545				
CON EDISON SERVICE B	***S LEXINGTON AVE & MA***	***SW 0 - 1/8 (0.035 mi.)***	***D64***	***250***
EPA ID: NYP004408282				
CON EDISON	N LEXINGTON AVE & MA	SW 0 - 1/8 (0.035 mi.)	D65	253
EPA ID: NYP004786067				
CON EDISON	MARTINE AVE & LEXING	SW 0 - 1/8 (0.035 mi.)	D66	254
EPA ID: NYP004303145				
CON EDISON	MARTINE & GROVE ST	SE 0 - 1/8 (0.036 mi.)	E67	256
EPA ID: NYP004398962				
CON EDISON MANHOLE 9	***MARTINE AVE & GROVE***	***SE 0 - 1/8 (0.037 mi.)***	***E69***	***260***
EPA ID: NYP004224192				
CON EDISON MANHOLE 9	***MARTINE AVE & GROVE***	***SE 0 - 1/8 (0.037 mi.)***	***E70***	***264***

EPA ID: NYP004224101				
CON EDISON MANHOLE 9 EPA ID: NYP004224465	***MARTINE AVE & GROVE***	***SE 0 - 1/8 (0.037 mi.)***	***E71***	***269***
CON EDISON MANHOLE: EPA ID: NYP004328050	***MAIN ST & WILLIAMS S***	***ENE 0 - 1/8 (0.047 mi.)***	***B72***	***273***
CONSOLIDATED EDISON EPA ID: NYP004227389	WILLIAM ST & MAIN ST	ENE 0 - 1/8 (0.047 mi.)	B74	281
CON EDISON EPA ID: NYP004846109	WILLIAMS ST & MAIN S	ENE 0 - 1/8 (0.047 mi.)	B76	285
CON ED- TM462 EPA ID: NYZ004019766	WILLIAMS & MAIN ST	ENE 0 - 1/8 (0.047 mi.)	B77	286
CON EDISON EPA ID: NYP004210985	***LEXINGTON & HAMILTON***	***NW 0 - 1/8 (0.058 mi.)***	***F80***	***288***
CON EDISON MANHOLE: EPA ID: NYP004398830	***HAMILTON AVE & LEXIN***	***NW 0 - 1/8 (0.058 mi.)***	***F81***	***293***
CON EDISON EPA ID: NYP004210852	***HAMILTON & N LEXINGT***	***NW 0 - 1/8 (0.058 mi.)***	***F82***	***296***
CON EDISON MANHOLE: EPA ID: NYP004476107	***MAIN ST & BANK ST***	***W 0 - 1/8 (0.093 mi.)***	***H102***	***330***
CON EDISON EPA ID: NYP004212643	***BANK ST & MAIN ST***	***W 0 - 1/8 (0.093 mi.)***	***H103***	***333***
CON EDISON EPA ID: NYP004508313	76-78 S LEXINGTON AV	SSW 0 - 1/8 (0.098 mi.)	L107	343
CON ED EPA ID: NYP004812398	15 BANK ST	W 0 - 1/8 (0.102 mi.)	M111	348
CONSOLIKDATED EDISON EPA ID: NYP004139705	NEW ST & LEXINGTON A	NW 0 - 1/8 (0.102 mi.)	F114	353
MICHAELIAN OFFICE BU EPA ID: NYD072705213	***148 MARTINE AVE***	***ESE 0 - 1/8 (0.106 mi.)***	***O120***	***374***
CON ED EPA ID: NYP004785739	148 MARTINE AVE	ESE 0 - 1/8 (0.106 mi.)	O122	393
CON EDISON MANHOLE: EPA ID: NYP004306650	***25 BANK ST***	***WSW 0 - 1/8 (0.108 mi.)***	***M126***	***399***
CON EDISON MANHOLE: EPA ID: NYP004476115	***BANK ST & HAMILTON A***	***WNW 0 - 1/8 (0.109 mi.)***	***H128***	***404***
CON EDISON EPA ID: NYP004384657	COURT ST & MAIN ST	ENE 0 - 1/8 (0.111 mi.)	K130	410
CON EDISON EPA ID: NYP004146833	***MAIN ST & COURT ST***	***ENE 0 - 1/8 (0.111 mi.)***	***K131***	***412***
CON EDISON MANHOLE 1 EPA ID: NYP004146551	***MAIN ST & COURT ST***	***ENE 0 - 1/8 (0.111 mi.)***	***K134***	***418***
CON EDISON MANHOLE 1 EPA ID: NYP004224754	***COURT ST & MAIN ST***	***ENE 0 - 1/8 (0.111 mi.)***	***K135***	***421***
CON EDISON SERVICE B EPA ID: NYP004450573	***MAIN ST & COURT ST***	***ENE 0 - 1/8 (0.111 mi.)***	***K137***	***428***
CON EDISON MANHOLE:	***MAIN ST & COURT ST***	***ENE 0 - 1/8 (0.111 mi.)***	***K139***	***434***

EPA ID: NYP004432753				
CON EDISON MANHOLE: EPA ID: NYP004327854	***MAIN ST & COURT ST***	***ENE 0 - 1/8 (0.111 mi.)***	***K140***	***437***
CON EDISON EPA ID: NYP004784807	COURT ST & MAIN ST	ENE 0 - 1/8 (0.111 mi.)	K141	440
CON EDISON SERVICE B EPA ID: NYP004432662	***19 COURT ST***	***E 0 - 1/8 (0.114 mi.)***	***K150***	***451***
CON EDISON MANHOLE 9 EPA ID: NYP004224176	***MARTINE AVE & COURT***	***E 0 - 1/8 (0.116 mi.)***	***O155***	***460***
CON EDISON EPA ID: NYP004714374	MARTINE AVE & COURT	E 0 - 1/8 (0.116 mi.)	O156	465
CON EDISON TRANSFORM EPA ID: NYP004321162	***MARTINE AVE & COURT***	***E 0 - 1/8 (0.116 mi.)***	***O158***	***468***
CON EDISON EPA ID: NYP004784880	COURT ST & MARTINE A	E 0 - 1/8 (0.116 mi.)	O159	471
CON EDISON EPA ID: NYP004850869	MARTINE & COURT ST	E 0 - 1/8 (0.116 mi.)	O161	474
CON EDISON EPA ID: NYP004714358	MARTINE AVE & COURT	E 0 - 1/8 (0.116 mi.)	O162	475
CONSOLIDATED EDISON EPA ID: NYP004700894 EPA ID: NYR000023275	9 NEW ST	NW 0 - 1/8 (0.118 mi.)	N175	530
WESTCHESTER COUNTY C EPA ID: NYR000028902	***111 GROVE ST***	***SE 0 - 1/8 (0.122 mi.)***	***Q186***	***555***
HAMILTON GREEN PHASE EPA ID: NYP004937316	***200 HAMILTON AVENUE***	***NE 0 - 1/8 (0.123 mi.)***	***P189***	***564***
CON EDISON MANHOLE 4 EPA ID: NYP004224721	***199 MAIN ST & MAMARO***	***ENE 1/8 - 1/4 (0.125 mi.)***	***K192***	***574***
CON EDISON EPA ID: NYP004713814	HAMILTON AVE & RENNA	NE 1/8 - 1/4 (0.126 mi.)	P194	580
CON ED EPA ID: NYP004769600	10 BANK ST	SW 1/8 - 1/4 (0.142 mi.)	R200	591
MARUBENI SPECIALTY C EPA ID: NYP004776522 EPA ID: NYP004792248 EPA ID: NYD987027638	***10 BANK ST***	***SW 1/8 - 1/4 (0.142 mi.)***	***R201***	***592***
WP MALL CLEANERS & G EPA ID: NYR000258814	***250 HAMILTON AVENUE***	***NE 1/8 - 1/4 (0.145 mi.)***	***P204***	***748***
CONSOLIDATED EDISON EPA ID: NYP004227207	GROVE & QUERROPAS	SSE 1/8 - 1/4 (0.145 mi.)	Q206	794
CON EDISON EPA ID: NYP004805560	QUARROPAS ST & MLK B	SSE 1/8 - 1/4 (0.145 mi.)	Q208	799
NYSDEC EPA ID: NYP003600954	GRAND & QUARRAPUS	SE 1/8 - 1/4 (0.147 mi.)	S212	804
WHITE PLAINS POLICE EPA ID: NYP000877423	***279 HAMILTON AVENUE***	***NE 1/8 - 1/4 (0.148 mi.)***	***T215***	***810***
CON EDISON	274 HAMILTON AVE	NE 1/8 - 1/4 (0.155 mi.)	T223	824

EPA ID: NYP004717195				
EXXON DIV OF CFI #70 EPA ID: NYD013387436	***274 HAMILTON AVE & C***	***NE 1/8 - 1/4 (0.157 mi.)***	***P226***	***832***
CVS EPA ID: NYR000194852	***24 MAMARONECK AVENUE***	***E 1/8 - 1/4 (0.165 mi.)***	***U231***	***855***
CON EDISON EPA ID: NYP004312302 EPA ID: NYP004789996	***MAMARONECK AVE & MAI***	***ENE 1/8 - 1/4 (0.167 mi.)***	***U235***	***889***
RECKSON ASSOCIATES EPA ID: NYR000096263	***140 GRAND ST***	***SE 1/8 - 1/4 (0.168 mi.)***	***S237***	***896***
CON EDISON MANHOLE: EPA ID: NYP004308268	***221 MAIN ST***	***ENE 1/8 - 1/4 (0.168 mi.)***	***U239***	***901***
WHITE PLAINS RUBBER EPA ID: NYD980648422	***20 BANK ST***	***SW 1/8 - 1/4 (0.171 mi.)***	***R241***	***913***
YOUNG COAL & LUMBER EPA ID: NYR000222273	***55 BANK STREET***	***SW 1/8 - 1/4 (0.178 mi.)***	***R272***	***988***
CON EDISON - VAULT 4 EPA ID: NYP004983803	161 GRAND ST	SE 1/8 - 1/4 (0.179 mi.)	S274	1000
CON EDISON MANHOLE: EPA ID: NYP004314233	***QUARROPAS ST & FISCH***	***S 1/8 - 1/4 (0.180 mi.)***	***AA276***	***1004***
CON EDISON EPA ID: NYP004514436	FISHER CT & QUARROPA	S 1/8 - 1/4 (0.180 mi.)	AA277	1007
CON EDISON EPA ID: NYP004314833	QUARROPAS ST & FISHE	S 1/8 - 1/4 (0.180 mi.)	AA279	1011
1-HOUR PHOTO FINISH EPA ID: NYR000035253	***60B MAMARONECK AVE***	***E 1/8 - 1/4 (0.181 mi.)***	***X280***	***1013***
PEPE MOTORS INC EPA ID: NYD056298037	***50 BANK ST***	***SW 1/8 - 1/4 (0.185 mi.)***	***AC285***	***1031***
CON EDISON EPA ID: NYP004161261	***MAIN ST & CHURCH ST***	***ENE 1/8 - 1/4 (0.189 mi.)***	***U290***	***1052***
177 GRAND STREET ASS EPA ID: NYR000063727	***177 GRAND ST***	***SE 1/8 - 1/4 (0.189 mi.)***	***S291***	***1056***
CON EDISON MANHOLE: EPA ID: NYP004420485	***BARKER ST & COTTAGE***	***NNE 1/8 - 1/4 (0.198 mi.)***	***AD304***	***1076***
CON EDISON EPA ID: NYP004485504	COTTAGE PL & BARKER	NNE 1/8 - 1/4 (0.198 mi.)	AD307	1084
CONSOLIDATED EDISON EPA ID: NYP004228116	GROVE & FISHER	SSE 1/8 - 1/4 (0.199 mi.)	AE309	1086
CON EDISON SERVICE B EPA ID: NYP004428926	***GROVE ST & FISCHER A***	***SSE 1/8 - 1/4 (0.199 mi.)***	***AE311***	***1090***
CON EDISON EPA ID: NYP004711206	QUARROPAS ST & LEXIN	S 1/8 - 1/4 (0.200 mi.)	AG314	1098
CON EDISON MANHOLE 1 EPA ID: NYP004140307	***S LEXINGTON AVE & FI***	***S 1/8 - 1/4 (0.200 mi.)***	***AG318***	***1103***
CON EDISON EPA ID: NYP000471120	QUARRAPUS ST & LEXIN	S 1/8 - 1/4 (0.200 mi.)	AG320	1109
CON EDISON	LEXINGTON AVE & QUAR	S 1/8 - 1/4 (0.200 mi.)	AG321	1109

EPA ID: NYP004764643				
CON EDISON EPA ID: NYP004749677	S LEXINGTON AVE & QU	S 1/8 - 1/4 (0.200 mi.)	AG322	1111
CON EDISON MANHOLE: EPA ID: NYP004379814	***S LEXINGTON AVE & FI***	***S 1/8 - 1/4 (0.200 mi.)***	***AG323***	***1112***
CON EDISON - TRANSFO EPA ID: NYP005192141	241 MAIN ST	ENE 1/8 - 1/4 (0.204 mi.)	AH324	1115
WINBROOK APARTMENTS EPA ID: NYR000258236	11 FISHER AVE	SSW 1/8 - 1/4 (0.206 mi.)	AG326	1120
CON EDISON TRANSFORM EPA ID: NYP004475315	***MITCHELL PL & MAMARO***	***ESE 1/8 - 1/4 (0.209 mi.)***	***AI327***	***1121***
WHITE PLAINS HOUSING EPA ID: NYR000258293	***33 FISHER AVE***	***SSW 1/8 - 1/4 (0.212 mi.)***	***AG332***	***1128***
WHITE PLAINS DEPT OF EPA ID: NYD000877423 EPA ID: NYN008015984	***255 MAIN STREET***	***ENE 1/8 - 1/4 (0.237 mi.)***	***AH352***	***1163***
CON EDISON EPA ID: NYP004586020	218 MAIN ST	ENE 1/8 - 1/4 (0.243 mi.)	AH354	1170
T S T WHITE PLAINS L EPA ID: NYR000054361	***220 MAIN ST***	***ENE 1/8 - 1/4 (0.245 mi.)***	***AH357***	***1175***
CON EDISON SERVICE B EPA ID: NYP004450730	***BARKER AVE & CHURCH***	***NNE 1/8 - 1/4 (0.247 mi.)***	***AM361***	***1194***
CON EDISON MANHOLE: EPA ID: NYP004365813	***BARKER AVE & CHURCH***	***NNE 1/8 - 1/4 (0.247 mi.)***	***AM362***	***1197***
CON EDISON EPA ID: NYP004763934	F/O 360 HAMILTON AVE	NE 1/8 - 1/4 (0.247 mi.)	AN363	1200
A T & T EPA ID: NYD986998060 EPA ID: NYP005001854	***360 HAMILTON AVE***	***NE 1/8 - 1/4 (0.247 mi.)***	***AN364***	***1202***
RECKSON ASSOCIATES EPA ID: NYR000071779	***360 HAMILTON AVE - M***	***NE 1/8 - 1/4 (0.247 mi.)***	***AN365***	***1216***
CON EDISON EPA ID: NYP004846877	128 MAMARONECK AVE	ESE 1/8 - 1/4 (0.249 mi.)	AK368	1232

Lower Elevation	Address	Direction / Distance	Map ID	Page
NYNEX MATERIEL ENTER EPA ID: NYD980582480	***111 MAIN ST***	***NNE 0 - 1/8 (0.006 mi.)***	***A31***	***120***
NEW YORK POWER AUTHO EPA ID: NYD986982999	***123 MAIN ST***	***ENE 0 - 1/8 (0.030 mi.)***	***B56***	***212***
OFFICE BUILDING EPA ID: NYP004108221	***170 HAMILTON AVE***	***NNW 0 - 1/8 (0.065 mi.)***	***G85***	***303***
CON EDISON EPA ID: NYP004855397	HAMILTON & MARTIN LU	NNE 0 - 1/8 (0.073 mi.)	I90	312
WESTCHESTER CO BRONX EPA ID: NYR000100974	***1 BRONX ST- LAT 41 1***	***W 1/8 - 1/4 (0.166 mi.)***	***232***	***882***
CONSOLIDATED EDISON	12 WATER ST - MH 561	NNW 1/8 - 1/4 (0.168 mi.)	W236	894

EPA ID: NYP004237859				
CON EDISON MANHOLE 4 EPA ID: NYP004146783	***BARKER AVE & GROVE S***	***N 1/8 - 1/4 (0.172 mi.)***	***W245***	***928***
CONSOLIDATED EDISON EPA ID: NYP004229579	WATER ST & LEXINGTON	NNW 1/8 - 1/4 (0.173 mi.)	W246	932
CON EDISON EPA ID: NYP004703617	WATER ST & N LEXINGT	NNW 1/8 - 1/4 (0.173 mi.)	W247	933
CON EDISON MANHOLE 1 EPA ID: NYP004220588	***WATER ST & N LEXINGT***	***NNW 1/8 - 1/4 (0.173 mi.)***	***W248***	***935***
CON EDISON MANHOLE: EPA ID: NYP004303343	***WATER ST & LEXINGTON***	***NNW 1/8 - 1/4 (0.173 mi.)***	***W249***	***939***
CON EDISON EPA ID: NYP004207167	***WATER ST & LEXINGTON***	***NNW 1/8 - 1/4 (0.173 mi.)***	***W250***	***943***
CON EDISON EPA ID: NYP004703427	WATER ST & N LEXINGT	NNW 1/8 - 1/4 (0.173 mi.)	W251	947
CON EDISON MANHOLE: EPA ID: NYP004358081	***WATER ST & LEXINGTON***	***NNW 1/8 - 1/4 (0.173 mi.)***	***W252***	***949***
CON EDISON - MANHOLE EPA ID: NYP004917565	WATER ST & LEXINGTON	NNW 1/8 - 1/4 (0.173 mi.)	W253	952
CON EDISON EPA ID: NYP004207183	***WATER ST & LEXINGTON***	***NNW 1/8 - 1/4 (0.173 mi.)***	***W254***	***953***
AHERN PAINTING CONTR EPA ID: NYR000236299	HAMILTON AVE & BRONX	WNW 1/8 - 1/4 (0.175 mi.)	Z263	967
CON EDISON EPA ID: NYP004384582	WATER ST & FERRIS AV	NW 1/8 - 1/4 (0.197 mi.)	AF302	1071
CON EDISON MANHOLE: EPA ID: NYP004382602	***WATER ST & FERRIS AV***	***NW 1/8 - 1/4 (0.197 mi.)***	***AF303***	***1073***

PA MANIFEST: Hazardous waste manifest information.

A review of the PA MANIFEST list, as provided by EDR, and dated 06/30/2018 has revealed that there are 4 PA MANIFEST sites within approximately 0.25 miles of the target property.

Equal/Higher Elevation	Address	Direction / Distance	Map ID	Page
CUSHMAN & WAKEFIELD Generator EPA Id: NYD986984698	1 N LEXINGTON AVE	WNW 0 - 1/8 (0.015 mi.)	C45	159
CUSHMAN & WAKEFIELD Generator EPA Id: NYD986984698	ONE N LEXINGTON AVE	WNW 0 - 1/8 (0.068 mi.)	H86	306
CVS PHARMACY #4745 Generator EPA Id: NYR000194852	24 MAMARONECK AVE	E 1/8 - 1/4 (0.165 mi.)	U230	850
HP NORTH TOWER LLC Generator EPA Id: NYR000222273	55 BANK STREET	SW 1/8 - 1/4 (0.178 mi.)	R271	984

NJ MANIFEST: Hazardous waste manifest information.

A review of the NJ MANIFEST list, as provided by EDR, and dated 12/31/2018 has revealed that there are 36 NJ MANIFEST sites within approximately 0.25 miles of the target property.

Equal/Higher Elevation	Address	Direction / Distance	Map ID	Page
CON EDISON EPA Id: NYP004212403	***81 MAIN ST FRONT OF***	***WNW 0 - 1/8 (0.006 mi.)***	***C33***	***129***
RNG PADD 1 EPA Id: NYD986984698	***1 N LEXINGTON AVE***	***WNW 0 - 1/8 (0.015 mi.)***	***C46***	***162***
CON EDISON EPA Id: NYP004786067	N LEXINGTON AVE & MA	SW 0 - 1/8 (0.035 mi.)	D58	239
CON EDISON MANHOLE 9 EPA Id: NYP004224192	***MARTINE AVE & GROVE***	***SE 0 - 1/8 (0.037 mi.)***	***E69***	***260***
CON EDISON MANHOLE 9 EPA Id: NYP004224101	***MARTINE AVE & GROVE***	***SE 0 - 1/8 (0.037 mi.)***	***E70***	***264***
CON EDISON MANHOLE 9 EPA Id: NYP004224465	***MARTINE AVE & GROVE***	***SE 0 - 1/8 (0.037 mi.)***	***E71***	***269***
CON EDISON EPA Id: NYP004214599 EPA Id: NYP004846109	***WILLIAMS ST & MAIN S***	***ENE 0 - 1/8 (0.047 mi.)***	***B73***	***277***
CON EDISON EPA Id: NYP004210985	***LEXINGTON & HAMILTON***	***NW 0 - 1/8 (0.058 mi.)***	***F80***	***288***
CON EDISON EPA Id: NYP004210852	***HAMILTON & N LEXINGT***	***NW 0 - 1/8 (0.058 mi.)***	***F82***	***296***
CON EDISON EPA Id: NYP004212643	***BANK ST & MAIN ST***	***W 0 - 1/8 (0.093 mi.)***	***H103***	***333***
CON EDISON EPA Id: NYP004812398	15 BANK ST	W 0 - 1/8 (0.102 mi.)	M110	346
CON EDISON EPA Id: NYP004785739	148 MARTINE AVE	ESE 0 - 1/8 (0.106 mi.)	O117	369
CONSOLIDATED EDISON EPA Id: NYP004144358	189 MAIN ST	ENE 0 - 1/8 (0.107 mi.)	K124	396
CON EDISON EPA Id: NYP004784807	COURT ST & MAIN ST	ENE 0 - 1/8 (0.111 mi.)	K133	416
CON EDISON MANHOLE 1 EPA Id: NYP004224754	***COURT ST & MAIN ST***	***ENE 0 - 1/8 (0.111 mi.)***	***K135***	***421***
CON EDISON SERVICE B EPA Id: NYP004432662	19 COURT ST	E 0 - 1/8 (0.114 mi.)	K149	450
CON EDISON MANHOLE 9 EPA Id: NYP004224176	***MARTINE AVE & COURT***	***E 0 - 1/8 (0.116 mi.)***	***O155***	***460***
CON EDISON EPA Id: NYP004784880	COURT ST & MARTINE A	E 0 - 1/8 (0.116 mi.)	O160	472
CON EDISON EPA Id: NYP004885055	111 MARTIN LUTHER KI	SE 0 - 1/8 (0.122 mi.)	Q183	551
CON EDISON MANHOLE 4 EPA Id: NYP004224721	***199 MAIN ST & MAMARO***	***ENE 1/8 - 1/4 (0.125 mi.)***	***K192***	***574***
CON EDISON	10 BANK ST & MARTINE	SW 1/8 - 1/4 (0.133 mi.)	R195	582

EPA Id: NYP004776522				
CON EDISON EPA Id: NYP004792248	10 BANK ST	SW 1/8 - 1/4 (0.142 mi.)	R199	590
CON EDISON EPA Id: NYP004769600	10 BANK ST	SW 1/8 - 1/4 (0.142 mi.)	R202	745
CON EDISON EPA Id: NYP004213476	***GROVE ST & QUARROPAS***	***SSE 1/8 - 1/4 (0.145 mi.)***	***Q207***	***796***
CON EDISON EPA Id: NYP004805560	QUARROPAS ST & MLK B	SSE 1/8 - 1/4 (0.145 mi.)	Q210	802
CON EDISON - MANHOLE EPA Id: NYP004308268	221 MAIN STREET	ENE 1/8 - 1/4 (0.168 mi.)	U238	900
CON EDISON EPA Id: NYP004213484	***240 MARTINE AVE & MA***	***E 1/8 - 1/4 (0.180 mi.)***	***X275***	***1001***
CON EDISON EPA Id: NYP004161261	MAIN ST & CHURCH ST	ENE 1/8 - 1/4 (0.189 mi.)	U289	1050
CON EDISON EPA Id: NYP004825978	GROVE ST & FISCHER C	SSE 1/8 - 1/4 (0.199 mi.)	AE308	1085
CON EDISON EPA Id: NYP004749677	S LEXINGTON AVE & QU	S 1/8 - 1/4 (0.200 mi.)	AG316	1101
CON EDISON EPA Id: NYP004764643	LEXINGTON AVE & QUAR	S 1/8 - 1/4 (0.200 mi.)	AG317	1102
CON EDISON EPA Id: NYP004846877	128 MAMARONECK AVE	ESE 1/8 - 1/4 (0.249 mi.)	AK369	1233

Lower Elevation	**Address**	**Direction / Distance**	**Map ID**	**Page**
CON EDISON MANHOLE 1 EPA Id: NYP004220588	***WATER ST & N LEXINGT***	***NNW 1/8 - 1/4 (0.173 mi.)***	***W248***	***935***
CON EDISON EPA Id: NYP004207167	***WATER ST & LEXINGTON***	***NNW 1/8 - 1/4 (0.173 mi.)***	***W250***	***943***
CON EDISON EPA Id: NYP004207183	***WATER ST & LEXINGTON***	***NNW 1/8 - 1/4 (0.173 mi.)***	***W254***	***953***
CON EDISON MANHOLE EPA Id: NYP004214540	***HAMILTON AVE & BRONX***	***WNW 1/8 - 1/4 (0.175 mi.)***	***Z264***	***969***

NY MGP: From the late 1800's to the mid 1900's, hundreds of manufactured gas plants across New York State supplied homes and industry with fuel for heating, cooking, and lighting. Today, the New York State DEC is overseeing the investigation and cleanup of contamination left behind from these plants.

A review of the NY MGP list, as provided by EDR, and dated 08/28/2024 has revealed that there is 1 NY MGP site within approximately 1 mile of the target property.

Equal/Higher Elevation	**Address**	**Direction / Distance**	**Map ID**	**Page**
CE - WHITE PLAINS MG	***9 NEW STREET AND 12***	***NW 0 - 1/8 (0.118 mi.)***	***N172***	***513***

EXECUTIVE SUMMARY

EDR HIGH RISK HISTORICAL RECORDS

EDR Exclusive Records

EDR MGP: The EDR Proprietary Manufactured Gas Plant Database includes records of coal gas plants (manufactured gas plants) compiled by EDR's researchers. Manufactured gas sites were used in the United States from the 1800's to 1950's to produce a gas that could be distributed and used as fuel. These plants used whale oil, rosin, coal, or a mixture of coal, oil, and water that also produced a significant amount of waste. Many of the byproducts of the gas production, such as coal tar (oily waste containing volatile and non-volatile chemicals), sludges, oils and other compounds are potentially hazardous to human health and the environment. The byproduct from this process was frequently disposed of directly at the plant site and can remain or spread slowly, serving as a continuous source of soil and groundwater contamination.

A review of the EDR MGP list, as provided by EDR, has revealed that there is 1 EDR MGP site within approximately 1 mile of the target property.

Equal/Higher Elevation	Address	Direction / Distance	Map ID	Page
WHITE PLAINS MGP SIT	9 NEW STREET AND 12	NW 0 - 1/8 (0.118 mi.)	N169	485

EDR Hist Auto: EDR has searched selected national collections of business directories and has collected listings of potential gas station/filling station/service station sites that were available to EDR researchers. EDR's review was limited to those categories of sources that might, in EDR's opinion, include gas station/filling station/service station establishments. The categories reviewed included, but were not limited to gas, gas station, gasoline station, filling station, auto, automobile repair, auto service station, service station, etc. This database falls within a category of information EDR classifies as "High Risk Historical Records", or HRHR. EDR's HRHR effort presents unique and sometimes proprietary data about past sites and operations that typically create environmental concerns, but may not show up in current government records searches.

A review of the EDR Hist Auto list, as provided by EDR, has revealed that there are 2 EDR Hist Auto sites within approximately 0.125 miles of the target property.

Equal/Higher Elevation	Address	Direction / Distance	Map ID	Page
GRAY PETER	35 MARTINE AVE	SW 0 - 1/8 (0.057 mi.)	D79	288
WHITE PLAINS GENERAL	76 HAMILTON AVE	NW 0 - 1/8 (0.069 mi.)	F87	307

EDR Hist Cleaner: EDR has searched selected national collections of business directories and has collected listings of potential dry cleaner sites that were available to EDR researchers. EDR's review was limited to those categories of sources that might, in EDR's opinion, include dry cleaning establishments. The categories reviewed included, but were not limited to dry cleaners, cleaners, laundry, laundromat, cleaning/laundry, wash & dry etc. This database falls within a category of information EDR classifies as "High Risk Historical Records", or HRHR. EDR's HRHR effort presents unique and sometimes proprietary data about past sites and operations that typically create environmental concerns, but may not show up in current government records searches.

A review of the EDR Hist Cleaner list, as provided by EDR, has revealed that there are 5 EDR Hist Cleaner sites within approximately 0.125 miles of the target property.

Equal/Higher Elevation	Address	Direction / Distance	Map ID	Page
BISCARDI FRANK	102 MAIN ST	0 - 1/8 (0.000 mi.)	A22	107
BAYLISS MORRIS	90 MAIN ST	0 - 1/8 (0.000 mi.)	A23	107
CROSS WESTCHESTER CL	4 MARTINE AVE	SW 0 - 1/8 (0.077 mi.)	J93	317

EXECUTIVE SUMMARY

Equal/Higher Elevation	Address	Direction / Distance	Map ID	Page
CROSS WESTCHESTER CL	2A MARTINE AVE	SW 0 - 1/8 (0.078 mi.)	J94	318
WHITE PLAINS MALL CL	200 HAMILTON AVE	NE 0 - 1/8 (0.123 mi.)	P188	564

EXECUTIVE SUMMARY

Due to poor or inadequate address information, the following sites were not mapped. Count: 5 records.

Site Name	Database(s)
MICA PRODUCTS LANDFILL	NY SWF/LF, NY PFAS
WHITE PLAINS FIRE DEPARTMENT DRILL	NY SHWS, NY PFAS
FORECLOSED - TTF	NY LTANKS
FORMER DPW STAGING AREA	NY VCP
FORMER HANGAR B SEPTIC FIELD	NY VCP

OVERVIEW MAP - 7906442.2S



This report includes Interactive Map Layers to display and/or hide map information. The legend includes only those icons for the default map view.

SITE NAME: 100 Main Street ADDRESS: 100 Main Street White Plains NY 10601 LAT/LONG: 41.03164 / 73.770797	CLIENT: SESI Consulting Engineers CONTACT: Annmarie Yannaco INQUIRY #: 7906442.2s DATE: February 24, 2025 1:25 pm

Copyright © 2025 EDR, Inc. © 2015 TomTom Rel. 2015.

DETAIL MAP - 7906442.2S



Target Property

Sites at elevations higher than or equal to the target property

Sites at elevations lower than the target property

Manufactured Gas Plants

Sensitive Receptors

National Priority List Sites

Dept. Defense Sites

Indian Reservations BIA

Pipelines

Special Flood Hazard Area (1%)

0.2% Annual Chance Flood Hazard

National Wetland Inventory

State Wetlands

0 1/16 1/8 1/4 Miles

This report includes Interactive Map Layers to display and/or hide map information. The legend includes only those icons for the default map view.

SITE NAME: 100 Main Street ADDRESS: 100 Main Street White Plains NY 10601 LAT/LONG: 41.03164 / 73.770797	CLIENT: SESI Consulting Engineers CONTACT: Annmarie Yannaco INQUIRY #: 7906442.2s DATE: February 24, 2025 1:41 pm

Copyright © 2025 EDR, Inc. © 2015 TomTom Rel. 2015.

MAP FINDINGS SUMMARY

Database	Search Distance (Miles)	Target Property	< 1/8	1/8 - 1/4	1/4 - 1/2	1/2 - 1	> 1	Total Plotted
STANDARD ENVIRONMENTAL RECORDS								
Lists of Federal NPL (Superfund) sites								
NPL	1.000		0	0	0	0	NR	0
Proposed NPL	1.000		0	0	0	0	NR	0
NPL LIENS	1.000		0	0	0	0	NR	0
Lists of Federal Delisted NPL sites								
Delisted NPL	1.000		0	0	0	0	NR	0
Lists of Federal sites subject to CERCLA removals and CERCLA orders								
FEDERAL FACILITY	0.500		0	0	0	NR	NR	0
SEMS	0.500		0	0	0	NR	NR	0
Lists of Federal CERCLA sites with NFRAP								
SEMS-ARCHIVE	0.500		0	0	0	NR	NR	0
Lists of Federal RCRA facilities undergoing Corrective Action								
CORRACTS	1.000		0	0	0	0	NR	0
Lists of Federal RCRA TSD facilities								
RCRA-TSDF	0.500		0	0	0	NR	NR	0
Lists of Federal RCRA generators								
RCRA-LQG	0.250		1	1	NR	NR	NR	2
RCRA-SQG	0.250	1	3	2	NR	NR	NR	6
RCRA-VSQG	0.250	1	3	5	NR	NR	NR	9
Federal institutional controls / engineering controls registries								
LUCIS	0.500		0	0	0	NR	NR	0
US ENG CONTROLS	0.500		0	0	0	NR	NR	0
US INST CONTROLS	0.500		0	0	0	NR	NR	0
Federal ERNS list								
ERNS	0.001		0	NR	NR	NR	NR	0
Lists of state- and tribal hazardous waste facilities								
NY SHWS	1.000		0	0	1	1	NR	2
Lists of state and tribal landfills and solid waste disposal facilities								
NY SWF/LF	0.500		0	0	0	NR	NR	0
Lists of state and tribal leaking storage tanks								
INDIAN LUST	0.500		0	0	0	NR	NR	0

MAP FINDINGS SUMMARY

Database	Search Distance (Miles)	Target Property	< 1/8	1/8 - 1/4	1/4 - 1/2	1/2 - 1	> 1	Total Plotted
NY LTANKS	0.500	1	16	28	130	NR	NR	175
NY HIST LTANKS	0.500		0	0	0	NR	NR	0
Lists of state and tribal registered storage tanks								
FEMA UST	0.250		0	0	NR	NR	NR	0
NY UST	0.250	3	15	38	NR	NR	NR	56
NY CBS UST	0.250		0	0	NR	NR	NR	0
NY MOSF UST	0.500		0	0	0	NR	NR	0
NY MOSF	0.500		0	0	0	NR	NR	0
NY CBS	0.250		0	0	NR	NR	NR	0
NY AST	0.250		10	16	NR	NR	NR	26
NY CBS AST	0.250		0	0	NR	NR	NR	0
NY MOSF AST	0.500		0	0	0	NR	NR	0
INDIAN UST	0.250		0	0	NR	NR	NR	0
NY TANKS	0.250		0	0	NR	NR	NR	0
State and tribal institutional control / engineering control registries								
NY RES DECL	0.125		0	NR	NR	NR	NR	0
NY ENG CONTROLS	0.500		1	0	1	NR	NR	2
NY INST CONTROL	0.500		1	1	1	NR	NR	3
Lists of state and tribal voluntary cleanup sites								
NY VCP	0.500		1	0	0	NR	NR	1
INDIAN VCP	0.500		0	0	0	NR	NR	0
Lists of state and tribal brownfield sites								
NY BROWNFIELDS	0.500		2	4	4	NR	NR	10
NY ERP	0.500		0	0	0	NR	NR	0
ADDITIONAL ENVIRONMENTAL RECORDS								
Local Brownfield lists								
US BROWNFIELDS	0.500		0	0	0	NR	NR	0
Local Lists of Landfill / Solid Waste Disposal Sites								
NY SWRCY	0.500		0	0	0	NR	NR	0
NY SWTIRE	0.500		0	0	0	NR	NR	0
INDIAN ODI	0.500		0	0	0	NR	NR	0
DEBRIS REGION 9	0.500		0	0	0	NR	NR	0
ODI	0.500		0	0	0	NR	NR	0
IHS OPEN DUMPS	0.500		0	0	0	NR	NR	0
Local Lists of Hazardous waste / Contaminated Sites								
US HIST CDL	0.001		0	NR	NR	NR	NR	0
NY DEL SHWS	1.000		0	0	0	0	NR	0
US CDL	0.001		0	NR	NR	NR	NR	0
Local Lists of Registered Storage Tanks								
NY HIST UST	0.250		0	0	NR	NR	NR	0

MAP FINDINGS SUMMARY

Database	Search Distance (Miles)	Target Property	< 1/8	1/8 - 1/4	1/4 - 1/2	1/2 - 1	> 1	Total Plotted
NY HIST AST	0.001		0	NR	NR	NR	NR	0
Local Land Records								
NY LIENS	0.001		0	NR	NR	NR	NR	0
LIENS 2	0.001		0	NR	NR	NR	NR	0
Records of Emergency Release Reports								
HMIRS	0.001		0	NR	NR	NR	NR	0
NY Spills	0.125	1	36	NR	NR	NR	NR	37
NY Hist Spills	0.125		0	NR	NR	NR	NR	0
NY SPILLS 90	0.125		0	NR	NR	NR	NR	0
NY SPILLS 80	0.125		0	NR	NR	NR	NR	0
Other Ascertainable Records								
RCRA NonGen / NLR	0.250	4	45	44	NR	NR	NR	93
FUDS	1.000		0	0	0	0	NR	0
DOD	1.000		0	0	0	0	NR	0
SCRD DRYCLEANERS	0.500		0	0	0	NR	NR	0
US FIN ASSUR	0.001		0	NR	NR	NR	NR	0
EPA WATCH LIST	0.001		0	NR	NR	NR	NR	0
2020 COR ACTION	0.250		0	0	NR	NR	NR	0
TSCA	0.001		0	NR	NR	NR	NR	0
TRIS	0.001		0	NR	NR	NR	NR	0
SSTS	0.001		0	NR	NR	NR	NR	0
ROD	1.000		0	0	0	0	NR	0
RMP	0.001		0	NR	NR	NR	NR	0
RAATS	0.001		0	NR	NR	NR	NR	0
PRP	0.001		0	NR	NR	NR	NR	0
PADS	0.001		0	NR	NR	NR	NR	0
ICIS	0.001		0	NR	NR	NR	NR	0
FTTS	0.001		0	NR	NR	NR	NR	0
MLTS	0.001		0	NR	NR	NR	NR	0
COAL ASH DOE	0.001		0	NR	NR	NR	NR	0
COAL ASH EPA	0.500		0	0	0	NR	NR	0
PCB TRANSFORMER	0.001		0	NR	NR	NR	NR	0
RADINFO	0.001		0	NR	NR	NR	NR	0
HIST FTTS	0.001		0	NR	NR	NR	NR	0
DOT OPS	0.001		0	NR	NR	NR	NR	0
CONSENT	1.000		0	0	0	0	NR	0
INDIAN RESERV	1.000		0	0	0	0	NR	0
FUSRAP	1.000		1	0	0	0	NR	1
UMTRA	0.500		0	0	0	NR	NR	0
LEAD SMELTERS	0.001		0	NR	NR	NR	NR	0
US AIRS	0.001		0	NR	NR	NR	NR	0
US MINES	0.250		0	0	NR	NR	NR	0
ABANDONED MINES	0.250		0	0	NR	NR	NR	0
MINES MRDS	0.250		0	0	NR	NR	NR	0
FINDS	0.001	7	0	NR	NR	NR	NR	7
DOCKET HWC	0.001		0	NR	NR	NR	NR	0
ECHO	0.001	6	0	NR	NR	NR	NR	6
UXO	1.000		0	0	0	0	NR	0

MAP FINDINGS SUMMARY

Database	Search Distance (Miles)	Target Property	< 1/8	1/8 - 1/4	1/4 - 1/2	1/2 - 1	> 1	Total Plotted
FUELS PROGRAM	0.250		1	0	NR	NR	NR	1
PFAS NPL	0.250		0	0	NR	NR	NR	0
PFAS FEDERAL SITES	0.250		0	0	NR	NR	NR	0
PFAS TRIS	0.250		0	0	NR	NR	NR	0
PFAS TSCA	0.250		0	0	NR	NR	NR	0
PFAS RCRA MANIFEST	0.250		0	0	NR	NR	NR	0
PFAS ATSDR	0.250		0	0	NR	NR	NR	0
PFAS WQP	0.250		0	0	NR	NR	NR	0
PFAS PROJECT	0.250		0	0	NR	NR	NR	0
PFAS NPDES	0.250		0	0	NR	NR	NR	0
PFAS ECHO	0.250		0	0	NR	NR	NR	0
PFAS ECHO FIRE TRAIN	0.250		0	0	NR	NR	NR	0
PFAS PT 139 AIRPORT	0.250		0	0	NR	NR	NR	0
AQUEOUS FOAM NRC	0.250		0	0	NR	NR	NR	0
BIOSOLIDS	0.001		0	NR	NR	NR	NR	0
UST FINDER RELEASE	0.500		5	6	13	NR	NR	24
UST FINDER	0.250		1	0	NR	NR	NR	1
E MANIFEST	0.250	5	5	5	NR	NR	NR	15
NY PFAS	0.250		0	1	NR	NR	NR	1
NY AIRS	0.001		0	NR	NR	NR	NR	0
NY COAL ASH	0.500		0	0	0	NR	NR	0
NY DRYCLEANERS	0.250		0	0	NR	NR	NR	0
NY E DESIGNATION	0.125		0	NR	NR	NR	NR	0
NY Financial Assurance	0.001		0	NR	NR	NR	NR	0
NY HSWDS	0.500		0	0	0	NR	NR	0
NY LEAD	0.001		0	NR	NR	NR	NR	0
NY MANIFEST	0.250	4	54	63	NR	NR	NR	121
PA MANIFEST	0.250		2	2	NR	NR	NR	4
NJ MANIFEST	0.250		19	17	NR	NR	NR	36
MI MANIFEST	0.250	1	0	0	NR	NR	NR	1
NY SPDES	0.001		0	NR	NR	NR	NR	0
NY VAPOR REOPENED	0.500		0	0	0	NR	NR	0
NY UIC	0.001		0	NR	NR	NR	NR	0
NY COOLING TOWERS	0.001	4	0	NR	NR	NR	NR	4
NY ILI	0.500		0	0	0	NR	NR	0
NY NYC OER	1.000		0	0	0	0	NR	0
NY MGP	1.000		1	0	0	0	NR	1
NY NYC LAND USE	0.001		0	NR	NR	NR	NR	0
EDR HIGH RISK HISTORICAL RECORDS								
EDR Exclusive Records								
EDR MGP	1.000		1	0	0	0	NR	1
EDR Hist Auto	0.125		2	NR	NR	NR	NR	2
EDR Hist Cleaner	0.125		5	NR	NR	NR	NR	5
EDR RECOVERED GOVERNMENT ARCHIVES								
Exclusive Recovered Govt. Archives								
NY RGA HWS	0.001		0	NR	NR	NR	NR	0

MAP FINDINGS SUMMARY

Database	Search Distance (Miles)	Target Property	< 1/8	1/8 - 1/4	1/4 - 1/2	1/2 - 1	> 1	Total Plotted
NY RGA LF	0.001		0	NR	NR	NR	NR	0
- Totals --		38	231	233	150	1	0	653

NOTES:

TP = Target Property

NR = Not Requested at this Search Distance

Sites may be listed in more than one database

A1
Target Property **100 MAIN ST**
WHITE PLAINS, NY 10601

MI MANIFEST **S130528816**
N/A

Site 1 of 30 in cluster A

Actual:
197 ft.

MI MANIFEST:

Generator Site ID Manifest:	NYR000120329
Name:	Not reported
Address:	100 MAIN ST
City,State,Zip:	WHITE PLAINS, NY 10601
Manifest Number:	018352509JJK
Manifest Date:	06/27/2018
Transporter Site ID Manifest:	MAD084814136
Transporter Site Legal Name Site Table:	EQ NORTHEAST INC
TSD Site ID Manifest:	MID980991566
TSD Site Legal Name Site Table:	EQ DETROIT INC
Container Number:	Not reported
Container Type:	Not reported
Total Quantity:	25
Unit Of Measure:	P
Waste Number:	D001
Waste Number 2:	D005
Waste Number 3:	D035
Waste Number 4:	Not reported
Waste Number 5:	Not reported
Waste Number 6:	Not reported

Generator Site ID Manifest:	NYR000120329
Name:	Not reported
Address:	100 MAIN ST
City,State,Zip:	WHITE PLAINS, NY 10601
Manifest Number:	018352509JJK
Manifest Date:	06/27/2018
Transporter Site ID Manifest:	MAD084814136
Transporter Site Legal Name Site Table:	EQ NORTHEAST INC
TSD Site ID Manifest:	MID980991566
TSD Site Legal Name Site Table:	EQ DETROIT INC
Container Number:	Not reported
Container Type:	Not reported
Total Quantity:	71
Unit Of Measure:	P
Waste Number:	D001
Waste Number 2:	Not reported
Waste Number 3:	Not reported
Waste Number 4:	Not reported
Waste Number 5:	Not reported
Waste Number 6:	Not reported

A2
Target Property **MACYS WHITE PLAINS COGENERATION**
100 MAIN ST
WHITE PLAINS, NY 10601

FINDS **1016008457**
ECHO **N/A**

Site 2 of 30 in cluster A

Actual:
197 ft.

FINDS:
Registry ID: 110054890347

Click Here for FRS Facility Detail Report:

MACYS WHITE PLAINS COGENERATION (Continued) **1016008457**

Environmental Interest/Information System:
The Air Facility System (AFS) contains compliance and permit data for stationary sources of air pollution regulated by the EPA, state, and local air pollution agencies.
ICIS-Air (AIR) AIR is the modernization of the Air Facility System (AFS) into the Integrated Compliance Information System (ICIS). AIR contains enforcement, compliance, and permit data for stationary sources of air pollution regulated by the EPA, State, and Local air pollution agencies.
The New York Department of Environmental Conservation Facility Information System (FIS) database houses all information about facilities that are regulated or of environmental interest to the state of New York.

Click this hyperlink while viewing on your computer to access additional FINDS: detail in the EDR Site Report.

ECHO:

Envid:	1016008457
Registry ID:	110054890347

DFR URL:

Name:	MACYS WHITE PLAINS COGENERATION
Address:	100 MAIN ST
City,State,Zip:	WHITE PLAINS, NY 10601

A3 **J C PENNEY CO INC** **RCRA NonGen / NLR** **1007112716**
Target **100 MAIN ST** **FINDS** **NYR000120329**
Property **WHITE PLAINS, NY 10601** **ECHO**
E MANIFEST

Site 3 of 30 in cluster A

Actual:
197 ft.

RCRA Listings:

Date Form Received by Agency:	20210804
Handler Name:	Macys - White Plains Galleria At White Plains
Handler Address:	Main St
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYR000120329
Contact Name:	MONICA NG
Contact Address:	WOODBRIDGE CENTER DR
Contact City,State,Zip:	WOODBRIDGE, NJ 07095
Contact Telephone:	Not reported
Contact Fax:	Not reported
Contact Email:	ENVIRONMENTAL@MACYS.COM
Contact Title:	ENVIRONMENTAL SERVICES MANAGER
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R3
Mailing Address:	WOODBRIDGE CENTER DR
Mailing City,State,Zip:	WOODBRIDGE, NJ 07095
Owner Name:	Macys Retail Holdings Llc
Owner Type:	Private

J C PENNEY CO INC (Continued) **1007112716**

Operator Name:	Macys Retail Holdings Llc
Operator Type:	Private
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20210805
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Hazardous Waste Summary:

Waste Code:	D001
Waste Description:	Ignitable Waste

Handler - Owner Operator:

Owner/Operator Indicator:	Operator
Owner/Operator Name:	MACYS RETAIL HOLDINGS INC
Legal Status:	Private
Date Became Current:	19800816
Date Ended Current:	Not reported
Owner/Operator Address:	7 W 7TH ST
Owner/Operator City,State,Zip:	CINCINNATI, OH 45202

J C PENNEY CO INC (Continued) **1007112716**

Owner/Operator Telephone: 513-562-6702
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: ENVIRONMENTAL@MACYS.COM

Owner/Operator Indicator: Owner
Owner/Operator Name: MACYS RETAIL HOLDINGS INC
Legal Status: Private
Date Became Current: 19800816
Date Ended Current: Not reported
Owner/Operator Address: 7 W 7TH ST
Owner/Operator City,State,Zip: CINCINNATI, OH 45202
Owner/Operator Telephone: 513-562-6702
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: ENVIRONMENTAL@MACYS.COM

Owner/Operator Indicator: Owner
Owner/Operator Name: MACYS
Legal Status: Private
Date Became Current: 20021201
Date Ended Current: Not reported
Owner/Operator Address: 100 MAIN ST
Owner/Operator City,State,Zip: WHITE PLAINS, NY 10601
Owner/Operator Telephone: 914-421-4212
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Owner
Owner/Operator Name: MACYS RETAIL HOLDINGS LLC
Legal Status: Private
Date Became Current: 19800816
Date Ended Current: Not reported
Owner/Operator Address: 145 PROGRESS PL
Owner/Operator City,State,Zip: CINCINNATI, OH 45246
Owner/Operator Telephone: Not reported
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: ENVIRONMENTAL@MACYS.COM

Owner/Operator Indicator: Operator
Owner/Operator Name: MACYS EAST
Legal Status: Private
Date Became Current: 20060201
Date Ended Current: Not reported
Owner/Operator Address: Not reported
Owner/Operator City,State,Zip: Not reported
Owner/Operator Telephone: Not reported
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Operator
Owner/Operator Name: MACYS
Legal Status: Private
Date Became Current: 20021201

J C PENNEY CO INC (Continued) **1007112716**

Date Ended Current: Not reported
Owner/Operator Address: 100 MAIN ST
Owner/Operator City,State,Zip: WHITE PLAINS, NY 10601
Owner/Operator Telephone: 914-421-4212
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Owner
Owner/Operator Name: MACYS EAST
Legal Status: Private
Date Became Current: 20060201
Date Ended Current: Not reported
Owner/Operator Address: 7 W 7TH ST
Owner/Operator City,State,Zip: CINCINNATI, OH 45202
Owner/Operator Telephone: Not reported
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Operator
Owner/Operator Name: MACYS RETAIL HOLDINGS LLC
Legal Status: Private
Date Became Current: 19800816
Date Ended Current: Not reported
Owner/Operator Address: 145 PROGRESS PL
Owner/Operator City,State,Zip: CINCINNATI, OH 45246
Owner/Operator Telephone: Not reported
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: ENVIRONMENTAL@MACYS.COM

Historic Generators:
Receive Date: 20070226
Handler Name: MACYS - WHITE PLAINS #30
Federal Waste Generator Description: Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20070226
Handler Name: MACYS - WHITE PLAINS #30
Federal Waste Generator Description: Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No

J C PENNEY CO INC (Continued) **1007112716**

Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20031117
Handler Name: MACYS STORE #30
Federal Waste Generator Description: Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20070227
Handler Name: MACYS - WHITE PLAINS #30
Federal Waste Generator Description: Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20180823
Handler Name: MACYS - WHITE PLAINS GALLERIA AT WHITE PLAINS
Federal Waste Generator Description: Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: No
Electronic Manifest Broker: No

Receive Date: 20210804
Handler Name: MACYS - WHITE PLAINS GALLERIA AT WHITE PLAINS
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: No
Electronic Manifest Broker: No

J C PENNEY CO INC (Continued) **1007112716**

List of NAICS Codes and Descriptions:
NAICS Code: 45211
NAICS Description: Department Stores

NAICS Code: 452210
NAICS Description: Department Stores

Has the Facility Received Notices of Violations:

Found Violation:	No
Agency Which Determined Violation:	Not reported
Violation Short Description:	Not reported
Date Violation was Determined:	Not reported
Actual Return to Compliance Date:	Not reported
Return to Compliance Qualifier:	Not reported
Violation Responsible Agency:	Not reported
Scheduled Compliance Date:	Not reported
Enforcement Identifier:	Not reported
Date of Enforcement Action:	Not reported
Enforcement Responsible Agency:	Not reported
Enforcement Docket Number:	Not reported
Enforcement Attorney:	Not reported
Corrective Action Component:	Not reported
Appeal Initiated Date:	Not reported
Appeal Resolution Date:	Not reported
Disposition Status Date:	Not reported
Disposition Status:	Not reported
Disposition Status Description:	Not reported
Consent/Final Order Sequence Number:	Not reported
Consent/Final Order Respondent Name:	Not reported
Consent/Final Order Lead Agency:	Not reported
Enforcement Type:	Not reported
Enforcement Responsible Person:	Not reported
Enforcement Responsible Sub-Organization:	Not reported
SEP Sequence Number:	Not reported
SEP Expenditure Amount:	Not reported
SEP Scheduled Completion Date:	Not reported
SEP Actual Date:	Not reported
SEP Defaulted Date:	Not reported
SEP Type:	Not reported
SEP Type Description:	Not reported
Proposed Amount:	Not reported
Final Monetary Amount:	Not reported
Paid Amount:	Not reported
Final Count:	Not reported
Final Amount:	Not reported

Evaluation Action Summary:

Evaluation Date:	20110106
Evaluation Responsible Agency:	EPA
Found Violation:	No
Evaluation Type Description:	COMPLIANCE EVALUATION INSPECTION
Evaluation Responsible Person Identifier:	R2STP
Evaluation Responsible Sub-Organization:	RCB
Actual Return to Compliance Date:	Not reported
Scheduled Compliance Date:	Not reported
Date of Request:	Not reported

J C PENNEY CO INC (Continued) **1007112716**

Date Response Received: Not reported
Request Agency: Not reported
Former Citation: Not reported

FINDS:
Registry ID: 110009462553

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:
The Resource Conservation and Recovery Act Information System (RCRAInfo) is EPA's comprehensive information system in support of the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. It tracks many types of information about generators, transporters, treaters, storers, and disposers of hazardous waste.

Click this hyperlink while viewing on your computer to access additional FINDS: detail in the EDR Site Report.

ECHO:
Envid: 1007112716
Registry ID: 110009462553

DFR URL:
Name: J C PENNEY CO INC
Address: 100 MAIN ST
City,State,Zip: WHITE PLAINS, NY 10601

E MANIFEST:
Manifest Tracking Number: 017122288JJK
Last Updated Date: 20191008
Shipped Date: 20190611
Received Date: 20190618
Manifest Status: Corrected
Submission Type: DataImage5Copy
Origin Type: Service
Generator EPA ID: NYR000120329
Generator Name: Macys - White Plains Galleria At White Plains
Generator Location Street Number: Not reported
Generator Location Street 1: 100 MAIN ST
Generator Location Street 2: Not reported
Generator Location City: WHITE PLAINS
Generator Location State: NY
Generator Location Zip: 10601
Generator Mail Street Number: Not reported
Generator Mail Street 1: 7 W 7TH ST ATTN ENV SERVICES
Generator Mail Street 2: MACYS INC
Generator Mail City: CINCINNATI
Generator Mail Zip: 45202
Generator Mail State: OH
Generator Contact Company Name: Not reported
Designated Facility EPA ID: MID980991566
Designated Facility Name: Eq Detroit Inc
Designated Facility Mail Street Number: Not reported
Designated Facility Mail Street 1: Not reported

J C PENNEY CO INC (Continued) **1007112716**

Designated Facility Mail Street 2:	1923 FREDERICK ST
Designated Facility Mail City:	DETROIT
Designated Facility Mail Zip:	48211
Designated Facility Mail State:	MI
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	1923 FREDERICK ST
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	DETROIT
Designated Facility Location Zip:	48211
Designated Facility Location State:	MI
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Manifest Tracking Number:	017122390JJK
Last Updated Date:	20190123
Shipped Date:	20181213
Received Date:	20181217
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	NYR000120329
Generator Name:	Macys - White Plains Galleria At White Plains
Generator Location Street Number:	Not reported
Generator Location Street 1:	100 MAIN ST
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	7 W 7TH ST ATTN ENV SERVICES
Generator Mail Street 2:	MACYS INC
Generator Mail City:	CINCINNATI
Generator Mail Zip:	45202
Generator Mail State:	OH
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	MID980991566
Designated Facility Name:	Eq Detroit Inc
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	1923 FREDERICK ST
Designated Facility Mail City:	DETROIT
Designated Facility Mail Zip:	48211
Designated Facility Mail State:	MI
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	1923 FREDERICK ST
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	DETROIT
Designated Facility Location Zip:	48211
Designated Facility Location State:	MI
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Manifest Tracking Number:	014854876FLE
Last Updated Date:	20200904
Shipped Date:	20200810

J C PENNEY CO INC (Continued) **1007112716**

Received Date:	20200824
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	NYR000120329
Generator Name:	Macys - White Plains Galleria At White Plains
Generator Location Street Number:	100
Generator Location Street 1:	100 MAIN ST
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601
Generator Mail Street Number:	7
Generator Mail Street 1:	W 7TH ST ATTN ENV SERVICES
Generator Mail Street 2:	MACYS INC
Generator Mail City:	CINCINNATI
Generator Mail Zip:	45202
Generator Mail State:	OH
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	PAD010154045
Designated Facility Name:	Envirite Of Pennsylvania Inc
Designated Facility Mail Street Number:	730
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	VOGELSONG RD
Designated Facility Mail City:	YORK
Designated Facility Mail Zip:	17404
Designated Facility Mail State:	PA
Designated Facility Location Street Number:	730
Designated Facility Location Street 1:	VOGELSONG RD
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	YORK
Designated Facility Location Zip:	17404
Designated Facility Location State:	PA
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Manifest Tracking Number:	012589608FLE
Last Updated Date:	20190329
Shipped Date:	20190305
Received Date:	20190314
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	NYR000120329
Generator Name:	Macys - White Plains Galleria At White Plains
Generator Location Street Number:	Not reported
Generator Location Street 1:	100 MAIN ST
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	7 W 7TH ST ATTN ENV SERVICES
Generator Mail Street 2:	MACYS INC
Generator Mail City:	CINCINNATI
Generator Mail Zip:	45202

J C PENNEY CO INC (Continued) **1007112716**

Generator Mail State:	OH
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	MID980991566
Designated Facility Name:	Eq Detroit Inc
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	1923 FREDERICK ST
Designated Facility Mail City:	DETROIT
Designated Facility Mail Zip:	48211
Designated Facility Mail State:	MI
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	1923 FREDERICK ST
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	DETROIT
Designated Facility Location Zip:	48211
Designated Facility Location State:	MI
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Manifest Tracking Number:	012589927FLE
Last Updated Date:	20191125
Shipped Date:	20191112
Received Date:	20191119
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	NYR000120329
Generator Name:	Macys - White Plains Galleria At White Plains
Generator Location Street Number:	Not reported
Generator Location Street 1:	100 MAIN ST
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	7 W 7TH ST ATTN ENV SERVICES
Generator Mail Street 2:	MACYS INC
Generator Mail City:	CINCINNATI
Generator Mail Zip:	45202
Generator Mail State:	OH
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	MID980991566
Designated Facility Name:	Eq Detroit Inc
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	1923 FREDERICK ST
Designated Facility Mail City:	DETROIT
Designated Facility Mail Zip:	48211
Designated Facility Mail State:	MI
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	1923 FREDERICK ST
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	DETROIT
Designated Facility Location Zip:	48211
Designated Facility Location State:	MI
Designated Facility Contact Company Name:	Not reported

J C PENNEY CO INC (Continued) **1007112716**

Manifest Residue Indicator:	N
Rejection Indicator:	N
Manifest Tracking Number:	012590030FLE
Last Updated Date:	20200313
Shipped Date:	20200302
Received Date:	20200306
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	NYR000120329
Generator Name:	Macys - White Plains Galleria At White Plains
Generator Location Street Number:	100
Generator Location Street 1:	100 MAIN ST
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601
Generator Mail Street Number:	7
Generator Mail Street 1:	W 7TH ST ATTN ENV SERVICES
Generator Mail Street 2:	MACYS INC
Generator Mail City:	CINCINNATI
Generator Mail Zip:	45202
Generator Mail State:	OH
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	PAD010154045
Designated Facility Name:	Envirite Of Pennsylvania Inc
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	730 VOGELSONG RD
Designated Facility Mail City:	YORK
Designated Facility Mail Zip:	17404-6707
Designated Facility Mail State:	PA
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	730 VOGELSONG RD
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	YORK
Designated Facility Location Zip:	17404-6707
Designated Facility Location State:	PA
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N
Manifest Tracking Number:	012248323FLE
Last Updated Date:	20200122
Shipped Date:	20200109
Received Date:	20200115
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	NYR000120329
Generator Name:	Macys - White Plains Galleria At White Plains
Generator Location Street Number:	100
Generator Location Street 1:	100 MAIN ST
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY

J C PENNEY CO INC (Continued) **1007112716**

Generator Location Zip:	10601
Generator Mail Street Number:	7
Generator Mail Street 1:	W 7TH ST ATTN ENV SERVICES
Generator Mail Street 2:	MACYS INC
Generator Mail City:	CINCINNATI
Generator Mail Zip:	45202
Generator Mail State:	OH
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	MID980991566
Designated Facility Name:	Eq Detroit Inc
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	1923 FREDERICK ST
Designated Facility Mail City:	DETROIT
Designated Facility Mail Zip:	48211
Designated Facility Mail State:	MI
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	1923 FREDERICK ST
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	DETROIT
Designated Facility Location Zip:	48211
Designated Facility Location State:	MI
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Manifest Tracking Number:	012249448FLE
Last Updated Date:	20191002
Shipped Date:	20190910
Received Date:	20190918
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	NYR000120329
Generator Name:	Macys - White Plains Galleria At White Plains
Generator Location Street Number:	Not reported
Generator Location Street 1:	100 MAIN ST
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	7 W 7TH ST ATTN ENV SERVICES
Generator Mail Street 2:	MACYS INC
Generator Mail City:	CINCINNATI
Generator Mail Zip:	45202
Generator Mail State:	OH
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	MID980991566
Designated Facility Name:	Eq Detroit Inc
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	1923 FREDERICK ST
Designated Facility Mail City:	DETROIT
Designated Facility Mail Zip:	48211
Designated Facility Mail State:	MI
Designated Facility Location Street Number:	Not reported

J C PENNEY CO INC (Continued) **1007112716**

Designated Facility Location Street 1:	1923 FREDERICK ST
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	DETROIT
Designated Facility Location Zip:	48211
Designated Facility Location State:	MI
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Manifest Tracking Number:	012319650FLE
Last Updated Date:	20191022
Shipped Date:	20191002
Received Date:	20191009
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	NYR000120329
Generator Name:	Macys - White Plains Galleria At White Plains
Generator Location Street Number:	Not reported
Generator Location Street 1:	100 MAIN ST
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	7 W 7TH ST ATTN ENV SERVICES
Generator Mail Street 2:	MACYS INC
Generator Mail City:	CINCINNATI
Generator Mail Zip:	45202
Generator Mail State:	OH
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	MID980991566
Designated Facility Name:	Eq Detroit Inc
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	1923 FREDERICK ST
Designated Facility Mail City:	DETROIT
Designated Facility Mail Zip:	48211
Designated Facility Mail State:	MI
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	1923 FREDERICK ST
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	DETROIT
Designated Facility Location Zip:	48211
Designated Facility Location State:	MI
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Manifest Tracking Number:	015741666FLE
Last Updated Date:	20210414
Shipped Date:	20210323
Received Date:	20210406
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	NYR000120329

J C PENNEY CO INC (Continued) **1007112716**

Generator Name:	Macys White Plains Galleria 710030
Generator Location Street Number:	Not reported
Generator Location Street 1:	100 MAIN STREET
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	ATTN: RECEIVING TEAM LEAD
Generator Mail Street 2:	100 MAIN STREET
Generator Mail City:	WHITE PLAINS
Generator Mail Zip:	10601
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	MID980991566
Designated Facility Name:	Eq Detroit, Inc.
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	1923 FREDERICK STREET
Designated Facility Mail City:	DETROIT
Designated Facility Mail Zip:	48211
Designated Facility Mail State:	MI
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	1923 FREDERICK STREET
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	DETROIT
Designated Facility Location Zip:	48211
Designated Facility Location State:	MI
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Manifest Tracking Number:	015741667FLE
Last Updated Date:	20210406
Shipped Date:	20210323
Received Date:	20210330
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	NYR000120329
Generator Name:	Macys White Plains Galleria 710030
Generator Location Street Number:	Not reported
Generator Location Street 1:	100 MAIN STREET
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	ATTN: RECEIVING TEAM LEAD
Generator Mail Street 2:	100 MAIN STREET
Generator Mail City:	WHITE PLAINS
Generator Mail Zip:	10601
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	MID048090633
Designated Facility Name:	Wayne Disposal, Inc. Site #2 Landfill
Designated Facility Mail Street Number:	Not reported

J C PENNEY CO INC (Continued) **1007112716**

Designated Facility Mail Street 1: Not reported
Designated Facility Mail Street 2: 49350 N I-94 SERVICE DRIVE
Designated Facility Mail City: BELLEVILLE
Designated Facility Mail Zip: 48111
Designated Facility Mail State: MI
Designated Facility Location Street Number: Not reported
Designated Facility Location Street 1: 49350 N I-94 SERVICE DRIVE
Designated Facility Location Street 2: Not reported
Designated Facility Location City: BELLEVILLE
Designated Facility Location Zip: 48111
Designated Facility Location State: MI
Designated Facility Contact Company Name: Not reported
Manifest Residue Indicator: N
Rejection Indicator: N

Federal Waste:
Manifest Tracking Number: 017215946JJK
Waste Line Number: 1
Federal Waste Code: D001
Federal Waste: IGNITABLE WASTE

Manifest Tracking Number: 017215946JJK
Waste Line Number: 1
Federal Waste Code: D005
Federal Waste: BARIUM

Manifest Tracking Number: 017215946JJK
Waste Line Number: 1
Federal Waste Code: D035
Federal Waste: METHYL ETHYL KETONE

Manifest Tracking Number: 017215946JJK
Waste Line Number: 2
Federal Waste Code: D001
Federal Waste: IGNITABLE WASTE

State Waste:
Manifest Tracking Number: 017215946JJK
Waste Line Number: 3
State Waste Code Owner: MI
State Waste Code: 029L
State Waste: 029l

Transporter:
Manifest Tracking Number: 017215946JJK
Transporter Line Number: 1
Transporter EPA ID: MAD084814136
Transporter Name: Eq Northeast Inc

Waste Line:
Manifest Tracking Number: 017215946JJK
Waste Line Number: 1
U.S. DOT Hazardous Indicator: Y
U.S. DOT ID Number: UN1950
U.S. DOT Description: Rq, Un1950, Waste, Aerosols, Flammable, 2.1, (D001), Erg#126

J C PENNEY CO INC (Continued) **1007112716**

Non-Hazardous Waste Description:	Not reported
Number of Containers:	1
Container Type Code:	DF
Container Type Description:	Fiberboard or plastic drums, barrels, kegs
Waste Quantity:	3
Quantity Unit of Measure Code:	P
Quantity Unit of Measure Description:	Pounds
Waste Quantity, in Tons:	0.0015
Acute Waste Quantity, in Tons:	0
Non-Acute Waste Quantity, in Tons:	0.0015
Waste Quantity, in Kilograms:	1.360545
Acute Waste Quantity, in Kilograms:	0
Non-Acute Waste Quantity, in Kilorgrams:	1.360545
Management Method Code:	H141
Management Method Description:	STORAGE, BULKING AND/OR TRANSFER OFF SITE
Waste Residue Indicator:	N
Quantity Discrepancy Indicator:	N
Waste Type Discrepancy Indicator:	N
Waste Density:	Not reported
Waste Density Unit of Measure Code:	Not reported
Waste Density Unit of Measure Description:	Not reported
Form Code:	Not reported
Form Code Description:	Not reported
Source Code:	Not reported
Source Code Description:	Not reported
Waste Minimization Code:	Not reported
Waste Minimization Code Description:	Not reported
Consent Number:	Not reported
EPA Waste Indicator:	Y
Manifest Tracking Number:	017215946JJK
Waste Line Number:	2
U.S. DOT Hazardous Indicator:	Y
U.S. DOT ID Number:	UN1993
U.S. DOT Description:	Rq, Un1993, Waste Flammable Liquids, N.O.S. (Acetone, Alcohol), 3, Pgiii, (D001), Erg#128
Non-Hazardous Waste Description:	Not reported
Number of Containers:	1
Container Type Code:	DM
Container Type Description:	Metal drums, barrels, kegs
Waste Quantity:	11
Quantity Unit of Measure Code:	P
Quantity Unit of Measure Description:	Pounds
Waste Quantity, in Tons:	0.0055
Acute Waste Quantity, in Tons:	0
Non-Acute Waste Quantity, in Tons:	0.0055
Waste Quantity, in Kilograms:	4.988665
Acute Waste Quantity, in Kilograms:	0
Non-Acute Waste Quantity, in Kilorgrams:	4.988665
Management Method Code:	H141
Management Method Description:	STORAGE, BULKING AND/OR TRANSFER OFF SITE
Waste Residue Indicator:	N
Quantity Discrepancy Indicator:	N
Waste Type Discrepancy Indicator:	N
Waste Density:	Not reported
Waste Density Unit of Measure Code:	Not reported
Waste Density Unit of Measure Description:	Not reported

J C PENNEY CO INC (Continued) **1007112716**

Form Code:	Not reported
Form Code Description:	Not reported
Source Code:	Not reported
Source Code Description:	Not reported
Waste Minimization Code:	Not reported
Waste Minimization Code Description:	Not reported
Consent Number:	Not reported
EPA Waste Indicator:	Y
Manifest Tracking Number:	017215946JJK
Waste Line Number:	3
U.S. DOT Hazardous Indicator:	N
U.S. DOT ID Number:	Not reported
U.S. DOT Description:	Not reported
Non-Hazardous Waste Description:	Non Hazardous Liquid
Number of Containers:	1
Container Type Code:	CF
Container Type Description:	Fiber or plastic boxes, cartons, cases
Waste Quantity:	41
Quantity Unit of Measure Code:	P
Quantity Unit of Measure Description:	Pounds
Waste Quantity, in Tons:	0.0205
Acute Waste Quantity, in Tons:	0
Non-Acute Waste Quantity, in Tons:	0.0205
Waste Quantity, in Kilograms:	18.594116
Acute Waste Quantity, in Kilograms:	0
Non-Acute Waste Quantity, in Kilorgrams:	18.594116
Management Method Code:	H110
Management Method Description:	STABILIZATION
Waste Residue Indicator:	N
Quantity Discrepancy Indicator:	N
Waste Type Discrepancy Indicator:	N
Waste Density:	Not reported
Waste Density Unit of Measure Code:	Not reported
Waste Density Unit of Measure Description:	Not reported
Form Code:	Not reported
Form Code Description:	Not reported
Source Code:	Not reported
Source Code Description:	Not reported
Waste Minimization Code:	Not reported
Waste Minimization Code Description:	Not reported
Consent Number:	Not reported
EPA Waste Indicator:	N

Click this hyperlink while viewing on your computer to access
2 additional US EManifest: record(s) in the EDR Site Report.

A4 **NY COOLING TOWERS** **S131454376**
Target Property **100 E. MAIN ST** **N/A**
WHITE PLAINS, NY 10601

Site 4 of 30 in cluster A

Actual: 197 ft.

COOLING TOWERS:

Name:	Not reported
Address:	100 E. MAIN ST
City,State,Zip:	WHITE PLAINS, NY 10601
Equipment Unique ID:	6579

(Continued) **S131454376**

Equipment Borough:	Not reported
Intended Use:	Air Conditioning
Manufacturer:	Marley
Model:	Feb-07
Cooling Capacity:	468
Cooling Capacity Unit:	Tonnage
Commissioned Date:	05/07/2007
Inspection Date:	Not reported
Date of Bacteriological Collection:	Not reported
Date of Legionella Collection:	08/27/2015
Last Legionella Result > 1,000 CFU/mL:	lt20
Last Sampled Days:	Not reported
Reg Compliant:	Not reported
Last Update Days:	Not reported
CT Status:	Not reported
Equipment Tower Operation Duration:	Not reported
Latitude:	41.03196
Longitude:	-73.770798

A5 **GALLERIA MALL DENTAL** **E MANIFEST** **1027827824**
Target **100 MAIN STREET** **N/A**
Property **WHITE PLAINS, NY 10601**

Site 5 of 30 in cluster A

Actual: **197 ft.**

E MANIFEST:

Manifest Tracking Number:	021906241JJK
Last Updated Date:	20211118
Shipped Date:	20211005
Received Date:	20211018
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	VSQG
Generator Name:	Galleria Mall Dental
Generator Location Street Number:	Not reported
Generator Location Street 1:	100 MAIN STREET
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	100 MAIN STREET
Generator Mail Street 2:	Not reported
Generator Mail City:	WHITE PLAINS
Generator Mail Zip:	10601
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	NJD002200046
Designated Facility Name:	Cycle Chem, Inc.
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	217 SOUTH FIRST STREET
Designated Facility Mail City:	ELIZABETH
Designated Facility Mail Zip:	07206
Designated Facility Mail State:	NJ
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	217 SOUTH FIRST STREET

GALLERIA MALL DENTAL (Continued) **1027827824**

Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	ELIZABETH
Designated Facility Location Zip:	07206
Designated Facility Location State:	NJ
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Manifest Tracking Number:	021906241JJK
Last Updated Date:	20211118
Shipped Date:	20211005
Received Date:	20211018
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	VSQG
Generator Name:	Galleria Mall Dental
Generator Location Street Number:	Not reported
Generator Location Street 1:	100 MAIN STREET
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	100 MAIN STREET
Generator Mail Street 2:	Not reported
Generator Mail City:	WHITE PLAINS
Generator Mail Zip:	10601
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	NJD002200046
Designated Facility Name:	Cycle Chem, Inc.
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	217 SOUTH FIRST STREET
Designated Facility Mail City:	ELIZABETH
Designated Facility Mail Zip:	07206
Designated Facility Mail State:	NJ
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	217 SOUTH FIRST STREET
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	ELIZABETH
Designated Facility Location Zip:	07206
Designated Facility Location State:	NJ
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Manifest Tracking Number:	021906241JJK
Last Updated Date:	20211118
Shipped Date:	20211005
Received Date:	20211018
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	VSQG
Generator Name:	Galleria Mall Dental

GALLERIA MALL DENTAL (Continued) **1027827824**

Generator Location Street Number:	Not reported
Generator Location Street 1:	100 MAIN STREET
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	100 MAIN STREET
Generator Mail Street 2:	Not reported
Generator Mail City:	WHITE PLAINS
Generator Mail Zip:	10601
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	NJD002200046
Designated Facility Name:	Cycle Chem, Inc.
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	217 SOUTH FIRST STREET
Designated Facility Mail City:	ELIZABETH
Designated Facility Mail Zip:	07206
Designated Facility Mail State:	NJ
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	217 SOUTH FIRST STREET
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	ELIZABETH
Designated Facility Location Zip:	07206
Designated Facility Location State:	NJ
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Manifest Tracking Number:	024744975JJK
Last Updated Date:	20221130
Shipped Date:	20221108
Received Date:	20221115
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	NYVSQG
Generator Name:	Galleria Mall Dental
Generator Location Street Number:	Not reported
Generator Location Street 1:	100 MAIN STREET
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	100 MAIN STREET
Generator Mail Street 2:	Not reported
Generator Mail City:	WHITE PLAINS
Generator Mail Zip:	10601
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	NJD002200046
Designated Facility Name:	Cycle Chem, Inc.
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported

GALLERIA MALL DENTAL (Continued) **1027827824**

Designated Facility Mail Street 2:	217 SOUTH FIRST STREET
Designated Facility Mail City:	ELIZABETH
Designated Facility Mail Zip:	07206
Designated Facility Mail State:	NJ
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	217 SOUTH FIRST STREET
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	ELIZABETH
Designated Facility Location Zip:	07206
Designated Facility Location State:	NJ
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Manifest Tracking Number:	024744975JJK
Last Updated Date:	20221130
Shipped Date:	20221108
Received Date:	20221115
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	NYVSQG
Generator Name:	Galleria Mall Dental
Generator Location Street Number:	Not reported
Generator Location Street 1:	100 MAIN STREET
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	100 MAIN STREET
Generator Mail Street 2:	Not reported
Generator Mail City:	WHITE PLAINS
Generator Mail Zip:	10601
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	NJD002200046
Designated Facility Name:	Cycle Chem, Inc.
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	217 SOUTH FIRST STREET
Designated Facility Mail City:	ELIZABETH
Designated Facility Mail Zip:	07206
Designated Facility Mail State:	NJ
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	217 SOUTH FIRST STREET
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	ELIZABETH
Designated Facility Location Zip:	07206
Designated Facility Location State:	NJ
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Manifest Tracking Number:	024744975JJK
Last Updated Date:	20221130
Shipped Date:	20221108

GALLERIA MALL DENTAL (Continued) **1027827824**

Received Date:	20221115
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	NYVSQG
Generator Name:	Galleria Mall Dental
Generator Location Street Number:	Not reported
Generator Location Street 1:	100 MAIN STREET
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	100 MAIN STREET
Generator Mail Street 2:	Not reported
Generator Mail City:	WHITE PLAINS
Generator Mail Zip:	10601
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	NJD002200046
Designated Facility Name:	Cycle Chem, Inc.
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	217 SOUTH FIRST STREET
Designated Facility Mail City:	ELIZABETH
Designated Facility Mail Zip:	07206
Designated Facility Mail State:	NJ
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	217 SOUTH FIRST STREET
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	ELIZABETH
Designated Facility Location Zip:	07206
Designated Facility Location State:	NJ
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Manifest Tracking Number:	021915992JJK
Last Updated Date:	20201214
Shipped Date:	20201112
Received Date:	20201120
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	VSQG
Generator Name:	Galleria Mall Dental
Generator Location Street Number:	Not reported
Generator Location Street 1:	100 MAIN STREET
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	100 MAIN STREET
Generator Mail Street 2:	Not reported
Generator Mail City:	WHITE PLAINS
Generator Mail Zip:	10601

GALLERIA MALL DENTAL (Continued) **1027827824**

Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	NJD002200046
Designated Facility Name:	Cycle Chem, Inc.
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	217 SOUTH FIRST STREET
Designated Facility Mail City:	ELIZABETH
Designated Facility Mail Zip:	07206
Designated Facility Mail State:	NJ
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	217 SOUTH FIRST STREET
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	ELIZABETH
Designated Facility Location Zip:	07206
Designated Facility Location State:	NJ
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Manifest Tracking Number:	021915992JJK
Last Updated Date:	20201214
Shipped Date:	20201112
Received Date:	20201120
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	VSQG
Generator Name:	Galleria Mall Dental
Generator Location Street Number:	Not reported
Generator Location Street 1:	100 MAIN STREET
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	100 MAIN STREET
Generator Mail Street 2:	Not reported
Generator Mail City:	WHITE PLAINS
Generator Mail Zip:	10601
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	NJD002200046
Designated Facility Name:	Cycle Chem, Inc.
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	217 SOUTH FIRST STREET
Designated Facility Mail City:	ELIZABETH
Designated Facility Mail Zip:	07206
Designated Facility Mail State:	NJ
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	217 SOUTH FIRST STREET
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	ELIZABETH
Designated Facility Location Zip:	07206
Designated Facility Location State:	NJ
Designated Facility Contact Company Name:	Not reported

GALLERIA MALL DENTAL (Continued) **1027827824**

Manifest Residue Indicator:	N
Rejection Indicator:	N
Manifest Tracking Number:	021915992JJK
Last Updated Date:	20201214
Shipped Date:	20201112
Received Date:	20201120
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	VSQG
Generator Name:	Galleria Mall Dental
Generator Location Street Number:	Not reported
Generator Location Street 1:	100 MAIN STREET
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	100 MAIN STREET
Generator Mail Street 2:	Not reported
Generator Mail City:	WHITE PLAINS
Generator Mail Zip:	10601
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	NJD002200046
Designated Facility Name:	Cycle Chem, Inc.
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	217 SOUTH FIRST STREET
Designated Facility Mail City:	ELIZABETH
Designated Facility Mail Zip:	07206
Designated Facility Mail State:	NJ
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	217 SOUTH FIRST STREET
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	ELIZABETH
Designated Facility Location Zip:	07206
Designated Facility Location State:	NJ
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N
Manifest Tracking Number:	025119131JJK
Last Updated Date:	20230418
Shipped Date:	20230328
Received Date:	20230412
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	CESQG
Generator Name:	Galleria Mall Dental
Generator Location Street Number:	Not reported
Generator Location Street 1:	100 MAIN STREET
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY

GALLERIA MALL DENTAL (Continued) **1027827824**

Generator Location Zip:	10601
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	100 MAIN STREET
Generator Mail Street 2:	Not reported
Generator Mail City:	WHITE PLAINS
Generator Mail Zip:	10601
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	RID040098352
Designated Facility Name:	Northland Environmental, Llc
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	275 Allens Avenue
Designated Facility Mail City:	Providence
Designated Facility Mail Zip:	02905
Designated Facility Mail State:	RI
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	275 Allens Avenue
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	Providence
Designated Facility Location Zip:	02905
Designated Facility Location State:	RI
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Manifest Tracking Number:	025119131JJK
Last Updated Date:	20230418
Shipped Date:	20230328
Received Date:	20230412
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	CESQG
Generator Name:	Galleria Mall Dental
Generator Location Street Number:	Not reported
Generator Location Street 1:	100 MAIN STREET
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	100 MAIN STREET
Generator Mail Street 2:	Not reported
Generator Mail City:	WHITE PLAINS
Generator Mail Zip:	10601
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	RID040098352
Designated Facility Name:	Northland Environmental, Llc
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	275 Allens Avenue
Designated Facility Mail City:	Providence
Designated Facility Mail Zip:	02905
Designated Facility Mail State:	RI
Designated Facility Location Street Number:	Not reported

GALLERIA MALL DENTAL (Continued) **1027827824**

Designated Facility Location Street 1: 275 Allens Avenue
Designated Facility Location Street 2: Not reported
Designated Facility Location City: Providence
Designated Facility Location Zip: 02905
Designated Facility Location State: RI
Designated Facility Contact Company Name: Not reported
Manifest Residue Indicator: N
Rejection Indicator: N

Federal Waste:
Manifest Tracking Number: 025119131JJK
Waste Line Number: 1
Federal Waste Code: D011
Federal Waste: SILVER

Transporter:
Manifest Tracking Number: 025119131JJK
Transporter Line Number: 1
Transporter EPA ID: NYR000076513
Transporter Name: Approved Storage & Waste Haul.

Waste Line:
Manifest Tracking Number: 025119131JJK
Waste Line Number: 1
U.S. DOT Hazardous Indicator: Y
U.S. DOT ID Number: NA3082
U.S. DOT Description: Na3082 Hazardous Waste, Liquid, N.O.S. (Silver) Iii 9 D011=1#
Non-Hazardous Waste Description: Not reported
Number of Containers: 4
Container Type Code: DF
Container Type Description: Fiberboard or plastic drums, barrels, kegs
Waste Quantity: 20
Quantity Unit of Measure Code: G
Quantity Unit of Measure Description: Gallons
Waste Quantity, in Tons: 0.083402835
Acute Waste Quantity, in Tons: 0
Non-Acute Waste Quantity, in Tons: 0.083402835
Waste Quantity, in Kilograms: 75.64887
Acute Waste Quantity, in Kilograms: 0
Non-Acute Waste Quantity, in Kilorgrams: 75.64887
Management Method Code: H141
Management Method Description: STORAGE, BULKING AND/OR TRANSFER OFF SITE
Waste Residue Indicator: N
Quantity Discrepancy Indicator: N
Waste Type Discrepancy Indicator: N
Waste Density: Not reported
Waste Density Unit of Measure Code: Not reported
Waste Density Unit of Measure Description: Not reported
Form Code: Not reported
Form Code Description: Not reported
Source Code: Not reported
Source Code Description: Not reported
Waste Minimization Code: Not reported
Waste Minimization Code Description: Not reported
Consent Number: Not reported
EPA Waste Indicator: Y

GALLERIA MALL DENTAL (Continued) **1027827824**

Click this hyperlink while viewing on your computer to access
26 additional US EManifest: record(s) in the EDR Site Report.

A6 **JC PENNEY** **NY UST** **U004440549**
Target **100 MAIN ST.** **N/A**
Property **WHITE PLAINS, NY 10601**

Site 6 of 30 in cluster A

Actual:
197 ft.

WESTCHESTER CO. UST:

Name:	JC PENNEY
Address:	100 MAIN ST.
City,State,Zip:	WHITE PLAINS, NY 10601
Id/Status:	3-600104 / Unregulated: <1101 gal. PBS
Operator Name:	Keith Layman
Owner Name:	Jc Penney
Owner Street:	P.o. Box 659000
Owner Address2:	Not reported
Owner City:	Dallas
Owner State:	TX
Owner Zipcode:	75265-9000
GDS Number:	Not reported
Tank Number:	1
Status:	4. Closed - in place
Capacity:	8000
Product Stored:	Not reported
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	Not reported
Date Perm Closure:	08/25/1999
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	6. Fiberglass reinforced plastic (FRP)
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	3. Aboveground/underground combination
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	6. Wrapped (Piping)
Overfill Prevention:	5. Vent Whistle
Piping Secondary Containment:	Not reported
Spill Prevention:	Not reported
Dispenser:	2. Suction

A7 **SEARS ROEBUCK & CO. 1444/6504/7024** **RCRA-VSQG** **1000981138**
Target **100 MAIN STREET** **E MANIFEST** **NY0000923193**
Property **WHITE PLAINS, NY 10601**

Site 7 of 30 in cluster A

Actual:
197 ft.

RCRA Listings:

Date Form Received by Agency:	20070101
Handler Name:	Sears Roebuck & Co 1444/6504/7024
Handler Address:	Main St
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NY0000923193

SEARS ROEBUCK & CO. 1444/6504/7024 (Continued) **1000981138**

Contact Name:	KATHLEEN M FLAHERTY
Contact Address:	BEVERLY RD A2-238A
Contact City,State,Zip:	HOFFMAN ESTATES, IL 60179
Contact Telephone:	847-286-7199
Contact Fax:	Not reported
Contact Email:	KFLAHER@SEARS.COM
Contact Title:	Not reported
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Conditionally Exempt Small Quantity Generator
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Handler Activities
State District Owner:	Ny
State District:	NYSDEC R3
Mailing Address:	BEVERLY RD A2-238A
Mailing City,State,Zip:	HOFFMAN ESTATES, IL 60179
Owner Name:	Sears Roebuck & Co
Owner Type:	Private
Operator Name:	Sears Roebuck & Co
Operator Type:	Private
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20150414
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No

SEARS ROEBUCK & CO. 1444/6504/7024 (Continued) **1000981138**

Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Biennial: List of Years
Year: 2003

Click Here for Biennial Reporting System Data:

Hazardous Waste Summary:
Waste Code: D001
Waste Description: Ignitable Waste

Waste Code: D002
Waste Description: Corrosive Waste

Waste Code: D018
Waste Description: Benzene

Waste Code: D039
Waste Description: Tetrachloroethylene

Waste Code: D040
Waste Description: Trichloroethylene

Waste Code: X001
Waste Description: Not Defined

Handler - Owner Operator:
Owner/Operator Indicator: Owner
Owner/Operator Name: SEARS ROEBUCK & CO
Legal Status: Private
Date Became Current: 19680501
Date Ended Current: Not reported
Owner/Operator Address: BEVERLY RD A2-238A
Owner/Operator City,State,Zip: HOFFMAN ESTATES, IL 60179
Owner/Operator Telephone: Not reported
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Owner
Owner/Operator Name: SEARS ROEBUCK & CO
Legal Status: Private
Date Became Current: 19680501
Date Ended Current: Not reported
Owner/Operator Address: BEVERLY RD A2-238A
Owner/Operator City,State,Zip: HOFFMAN ESTATES, IL 60179
Owner/Operator Telephone: Not reported
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Operator

SEARS ROEBUCK & CO. 1444/6504/7024 (Continued) **1000981138**

Owner/Operator Name: SEARS ROEBUCK & CO
Legal Status: Private
Date Became Current: 19680501
Date Ended Current: Not reported
Owner/Operator Address: BEVERLY RD A2-238A
Owner/Operator City,State,Zip: HOFFMAN ESTATES, IL 60179
Owner/Operator Telephone: Not reported
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Owner
Owner/Operator Name: METROPOLITAN LIFE
Legal Status: Private
Date Became Current: Not reported
Date Ended Current: Not reported
Owner/Operator Address: ONE MADISON AVE
Owner/Operator City,State,Zip: NEW YORK, NY 10010
Owner/Operator Telephone: 212-555-1212
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Operator
Owner/Operator Name: SEARS ROEBUCK & CO
Legal Status: Private
Date Became Current: 19680501
Date Ended Current: Not reported
Owner/Operator Address: BEVERLY RD A2-238A
Owner/Operator City,State,Zip: HOFFMAN ESTATES, IL 60179
Owner/Operator Telephone: Not reported
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Historic Generators:
Receive Date: 20060101
Handler Name: SEARS ROEBUCK & CO 1444/6504/7024
Federal Waste Generator Description: Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner: Not reported
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20070101
Handler Name: SEARS ROEBUCK & CO 1444/6504/7024
Federal Waste Generator Description: Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No

SEARS ROEBUCK & CO. 1444/6504/7024 (Continued) **1000981138**

Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 19941107
Handler Name: SEARS ROEBUCK & CO 1444
Federal Waste Generator Description: Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20040225
Handler Name: SEARS ROEBUCK & CO 1444/6504/7024
Federal Waste Generator Description: Small Quantity Generator
State District Owner: Not reported
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Code: 45299
NAICS Description: All Other General Merchandise Stores

NAICS Code: 811191
NAICS Description: Automotive Oil Change And Lubrication Shops

NAICS Code: 811411
NAICS Description: Home And Garden Equipment Repair And Maintenance

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

E MANIFEST:
Manifest Tracking Number: 013937874FLE
Last Updated Date: 20210308
Shipped Date: 20210130
Received Date: 20210223

SEARS ROEBUCK & CO. 1444/6504/7024 (Continued) **1000981138**

Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	NY0000923193
Generator Name:	Sears Roebuck & Co. 1444/6504/7024
Generator Location Street Number:	Not reported
Generator Location Street 1:	100 MAIN STREET
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	3333 Beverly Road, A2-238A
Generator Mail Street 2:	Not reported
Generator Mail City:	Hoffman Estates
Generator Mail Zip:	60179
Generator Mail State:	IL
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	VTR000517052
Designated Facility Name:	Enpro Services Of Vermont, Inc.
Designated Facility Mail Street Number:	54
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	AVENUE D
Designated Facility Mail City:	WILLISTON
Designated Facility Mail Zip:	05495
Designated Facility Mail State:	VT
Designated Facility Location Street Number:	54
Designated Facility Location Street 1:	AVENUE D
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	WILLISTON
Designated Facility Location Zip:	05495
Designated Facility Location State:	VT
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Federal Waste:

Manifest Tracking Number:	013937874FLE
Waste Line Number:	1
Federal Waste Code:	D001
Federal Waste:	IGNITABLE WASTE

Manifest Tracking Number:	013937874FLE
Waste Line Number:	1
Federal Waste Code:	D018
Federal Waste:	BENZENE

Manifest Tracking Number:	013937874FLE
Waste Line Number:	1
Federal Waste Code:	U002
Federal Waste:	2-PROPANONE (I) (OR) ACETONE (I)

Manifest Tracking Number:	013937874FLE
Waste Line Number:	1
Federal Waste Code:	U154
Federal Waste:	METHANOL (I) (OR) METHYL ALCOHOL (I)

SEARS ROEBUCK & CO. 1444/6504/7024 (Continued) **1000981138**

Manifest Tracking Number: 013937874FLE
Waste Line Number: 1
Federal Waste Code: U239
Federal Waste: BENZENE, DIMETHYL- (I,T) (OR) XYLENE (I)

Manifest Tracking Number: 013937874FLE
Waste Line Number: 2
Federal Waste Code: D002
Federal Waste: CORROSIVE WASTE

Manifest Tracking Number: 013937874FLE
Waste Line Number: 3
Federal Waste Code: D001
Federal Waste: IGNITABLE WASTE

State Waste:
Manifest Tracking Number: 013937874FLE
Waste Line Number: 1
State Waste Code Owner: NY
State Waste Code: B
State Waste: Incineration, heat recovery, burning. Waste management method code to be used on e-Manifest only

Manifest Tracking Number: 013937874FLE
Waste Line Number: 2
State Waste Code Owner: NY
State Waste Code: T
State Waste: Chemical, physical or biological treatment. Waste management method code to be used on e-Manifest only

Manifest Tracking Number: 013937874FLE
Waste Line Number: 3
State Waste Code Owner: NY
State Waste Code: B
State Waste: Incineration, heat recovery, burning. Waste management method code to be used on e-Manifest only

Transporter:
Manifest Tracking Number: 013937874FLE
Transporter Line Number: 1
Transporter EPA ID: NYD986908085
Transporter Name: Miller Environmental Group Inc

Waste Line:
Manifest Tracking Number: 013937874FLE
Waste Line Number: 1
U.S. DOT Hazardous Indicator: Y
U.S. DOT ID Number: UN1993
U.S. DOT Description: Un1993, Waste Flammable Liquids, N.O.S. (Xylene, Methanol) 3, Pgii
Non-Hazardous Waste Description: Not reported
Number of Containers: 1
Container Type Code: DF
Container Type Description: Fiberboard or plastic drums, barrels, kegs
Waste Quantity: 40
Quantity Unit of Measure Code: P
Quantity Unit of Measure Description: Pounds

SEARS ROEBUCK & CO. 1444/6504/7024 (Continued) **1000981138**

Waste Quantity, in Tons:	0.02
Acute Waste Quantity, in Tons:	0
Non-Acute Waste Quantity, in Tons:	0.02
Waste Quantity, in Kilograms:	18.1406
Acute Waste Quantity, in Kilograms:	0
Non-Acute Waste Quantity, in Kilorgrams:	18.1406
Management Method Code:	H141
Management Method Description:	STORAGE, BULKING AND/OR TRANSFER OFF SITE
Waste Residue Indicator:	N
Quantity Discrepancy Indicator:	N
Waste Type Discrepancy Indicator:	N
Waste Density:	Not reported
Waste Density Unit of Measure Code:	Not reported
Waste Density Unit of Measure Description:	Not reported
Form Code:	Not reported
Form Code Description:	Not reported
Source Code:	Not reported
Source Code Description:	Not reported
Waste Minimization Code:	Not reported
Waste Minimization Code Description:	Not reported
Consent Number:	Not reported
EPA Waste Indicator:	Y

Manifest Tracking Number:	013937874FLE
Waste Line Number:	2
U.S. DOT Hazardous Indicator:	Y
U.S. DOT ID Number:	UN3266
U.S. DOT Description:	Un3266, Waste Corrosive Liquid, Basic, Inorganic, N.O.S. (Ammonium Chloride, Sodium Hypochlorite) 8, Pgii
Non-Hazardous Waste Description:	Not reported
Number of Containers:	1
Container Type Code:	DF
Container Type Description:	Fiberboard or plastic drums, barrels, kegs
Waste Quantity:	30
Quantity Unit of Measure Code:	P
Quantity Unit of Measure Description:	Pounds
Waste Quantity, in Tons:	0.015
Acute Waste Quantity, in Tons:	0
Non-Acute Waste Quantity, in Tons:	0.015
Waste Quantity, in Kilograms:	13.60545
Acute Waste Quantity, in Kilograms:	0
Non-Acute Waste Quantity, in Kilorgrams:	13.60545
Management Method Code:	H141
Management Method Description:	STORAGE, BULKING AND/OR TRANSFER OFF SITE
Waste Residue Indicator:	N
Quantity Discrepancy Indicator:	N
Waste Type Discrepancy Indicator:	N
Waste Density:	Not reported
Waste Density Unit of Measure Code:	Not reported
Waste Density Unit of Measure Description:	Not reported
Form Code:	Not reported
Form Code Description:	Not reported
Source Code:	Not reported
Source Code Description:	Not reported
Waste Minimization Code:	Not reported
Waste Minimization Code Description:	Not reported
Consent Number:	Not reported

SEARS ROEBUCK & CO. 1444/6504/7024 (Continued) **1000981138**

EPA Waste Indicator:	Y
Manifest Tracking Number:	013937874FLE
Waste Line Number:	3
U.S. DOT Hazardous Indicator:	Y
U.S. DOT ID Number:	UN1950
U.S. DOT Description:	Un1950, Waste Aerosols 2.1
Non-Hazardous Waste Description:	Not reported
Number of Containers:	1
Container Type Code:	DM
Container Type Description:	Metal drums, barrels, kegs
Waste Quantity:	160
Quantity Unit of Measure Code:	P
Quantity Unit of Measure Description:	Pounds
Waste Quantity, in Tons:	0.08
Acute Waste Quantity, in Tons:	0
Non-Acute Waste Quantity, in Tons:	0.08
Waste Quantity, in Kilograms:	72.5624
Acute Waste Quantity, in Kilograms:	0
Non-Acute Waste Quantity, in Kilorgrams:	72.5624
Management Method Code:	H141
Management Method Description:	STORAGE, BULKING AND/OR TRANSFER OFF SITE
Waste Residue Indicator:	N
Quantity Discrepancy Indicator:	N
Waste Type Discrepancy Indicator:	N
Waste Density:	Not reported
Waste Density Unit of Measure Code:	Not reported
Waste Density Unit of Measure Description:	Not reported
Form Code:	Not reported
Form Code Description:	Not reported
Source Code:	Not reported
Source Code Description:	Not reported
Waste Minimization Code:	Not reported
Waste Minimization Code Description:	Not reported
Consent Number:	Not reported
EPA Waste Indicator:	Y

A8 **C P I PHOTO FINISH** **RCRA NonGen / NLR** **1001125005**
Target **100 MAIN ST STE 301** **FINDS** **NYR000034082**
Property **WHITE PLAINS, NY 10601** **ECHO**

Site 8 of 30 in cluster A

Actual:
197 ft.

RCRA Listings:

Date Form Received by Agency:	20070101
Handler Name:	C P I Photo Finish
Handler Address:	Main St Ste 301
Handler City,State,Zip:	WHITE PLAINS, NY 10601-2604
EPA ID:	NYR000034082
Contact Name:	Not reported
Contact Address:	WASHINGTON AVE
Contact City,State,Zip:	ST LOUIS, NY 63103
Contact Telephone:	Not reported
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Private

C P I PHOTO FINISH (Continued) **1001125005**

Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R3
Mailing Address:	WASHINGTON AVE
Mailing City,State,Zip:	ST LOUIS, NY 63103
Owner Name:	Fox Photo Inc
Owner Type:	Private
Operator Name:	Fox Photo Inc
Operator Type:	Private
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20150414
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Hazardous Waste Summary:
Waste Code: D000

C P I PHOTO FINISH (Continued) **1001125005**

Waste Description: Not Defined

Waste Code: D011
Waste Description: Silver

Handler - Owner Operator:
Owner/Operator Indicator: Owner
Owner/Operator Name: FOX PHOTO INC
Legal Status: Private
Date Became Current: Not reported
Date Ended Current: Not reported
Owner/Operator Address: 1706 WASHINGTON AVE
Owner/Operator City,State,Zip: ST LOUIS, MO 63103
Owner/Operator Telephone: 313-231-1575
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Operator
Owner/Operator Name: FOX PHOTO INC
Legal Status: Private
Date Became Current: Not reported
Date Ended Current: Not reported
Owner/Operator Address: 1706 WASHINGTON AVE
Owner/Operator City,State,Zip: ST LOUIS, MO 63103
Owner/Operator Telephone: 313-231-1575
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Owner
Owner/Operator Name: FOX PHOTO INC
Legal Status: Private
Date Became Current: Not reported
Date Ended Current: Not reported
Owner/Operator Address: 1706 WASHINGTON AVE
Owner/Operator City,State,Zip: ST LOUIS, MO 63103
Owner/Operator Telephone: 313-231-1575
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Historic Generators:
Receive Date: 19990708
Handler Name: C P I PHOTO FINISH
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

C P I PHOTO FINISH (Continued) **1001125005**

Receive Date: 20060101
Handler Name: C P I PHOTO FINISH
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20070101
Handler Name: C P I PHOTO FINISH
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 19970108
Handler Name: C P I PHOTO FINISH
Federal Waste Generator Description: Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

FINDS:
Registry ID: 110004531374

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:
The Resource Conservation and Recovery Act Information System

C P I PHOTO FINISH (Continued) **1001125005**

(RCRAInfo) is EPA's comprehensive information system in support of the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. It tracks many types of information about generators, transporters, treaters, storers, and disposers of hazardous waste.

Click this hyperlink while viewing on your computer to access additional FINDS: detail in the EDR Site Report.

ECHO:

Envid:	1001125005
Registry ID:	110004531374

DFR URL:

Name:	C P I PHOTO FINISH
Address:	100 MAIN ST STE 301
City,State,Zip:	WHITE PLAINS, NY 10601

A9 **PICTURE PEOPLE THE** **RCRA-SQG** **1001961666**
Target **100 MAIN ST SPACE 329** **FINDS** **NYR000084806**
Property **WHITE PLAINS, NY 10603** **ECHO**
NY MANIFEST

Site 9 of 30 in cluster A

Actual:
197 ft.

RCRA Listings:

Date Form Received by Agency:	20070101
Handler Name:	Picture People The
Handler Address:	Main St Space 329
Handler City,State,Zip:	WHITE PLAINS, NY 10603
EPA ID:	NYR000084806
Contact Name:	SANTA MITCHELL
Contact Address:	MAIN ST SPACE 329
Contact City,State,Zip:	WHITE PLAINS, NY 10603
Contact Telephone:	914-428-2811
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Not reported
Federal Waste Generator Description:	Small Quantity Generator
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Handler Activities
State District Owner:	Ny
State District:	NYSDEC R3
Mailing Address:	MAIN ST SPACE 329
Mailing City,State,Zip:	WHITE PLAINS, NY 10603
Owner Name:	The Picture People
Owner Type:	Private
Operator Name:	The Picture People
Operator Type:	Private
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No

PICTURE PEOPLE THE (Continued) **1001961666**

Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20150414
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Hazardous Waste Summary:

Waste Code:	D000
Waste Description:	Not Defined
Waste Code:	D011
Waste Description:	Silver

Handler - Owner Operator:

Owner/Operator Indicator:	Operator
Owner/Operator Name: THE PICTURE PEOPLE	
Legal Status:	Private
Date Became Current:	20010101
Date Ended Current:	Not reported
Owner/Operator Address:	1157 TRITON DR STE B
Owner/Operator City,State,Zip:	FOSTER CITY, CA 94404
Owner/Operator Telephone:	800-998-3686
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported
Owner/Operator Email:	Not reported

PICTURE PEOPLE THE (Continued) **1001961666**

Owner/Operator Indicator: Owner
Owner/Operator Name: THE PICTURE PEOPLE
Legal Status: Private
Date Became Current: 20010101
Date Ended Current: Not reported
Owner/Operator Address: 1157 TRITON DR STE B
Owner/Operator City,State,Zip: FOSTER CITY, CA 94404
Owner/Operator Telephone: 800-998-3686
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Owner
Owner/Operator Name: THE PICTURE PEOPLE
Legal Status: Private
Date Became Current: Not reported
Date Ended Current: Not reported
Owner/Operator Address: 1157 TRITON DR STE B
Owner/Operator City,State,Zip: FOSTER CITY, CA 94404
Owner/Operator Telephone: 800-998-3686
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Historic Generators:
Receive Date: 20060101
Handler Name: PICTURE PEOPLE THE
Federal Waste Generator Description: Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20070101
Handler Name: PICTURE PEOPLE THE
Federal Waste Generator Description: Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20000216
Handler Name: PICTURE PEOPLE THE
Federal Waste Generator Description: Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No

PICTURE PEOPLE THE (Continued) **1001961666**

Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20001116
Handler Name: PICTURE PEOPLE THE
Federal Waste Generator Description: Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Has the Facility Received Notices of Violations:
Found Violation: Yes
Agency Which Determined Violation: State
Violation Short Description: Generators - General
Date Violation was Determined: 20001208
Actual Return to Compliance Date: 20010711
Return to Compliance Qualifier: Documented
Violation Responsible Agency: State
Scheduled Compliance Date: 20010706
Enforcement Identifier: 001
Date of Enforcement Action: 20010621
Enforcement Responsible Agency: State
Enforcement Docket Number: Not reported
Enforcement Attorney: Not reported
Corrective Action Component: No
Appeal Initiated Date: Not reported
Appeal Resolution Date: Not reported
Disposition Status Date: Not reported
Disposition Status: Not reported
Disposition Status Description: Not reported
Consent/Final Order Sequence Number:Not reported
Consent/Final Order Respondent Name: Not reported
Consent/Final Order Lead Agency: Not reported
Enforcement Type: WRITTEN INFORMAL
Enforcement Responsible Person: NYWME
Enforcement Responsible Sub-Organization: R3
SEP Sequence Number: Not reported
SEP Expenditure Amount: Not reported
SEP Scheduled Completion Date: Not reported
SEP Actual Date: Not reported
SEP Defaulted Date: Not reported
SEP Type: Not reported
SEP Type Description: Not reported

PICTURE PEOPLE THE (Continued) **1001961666**

Proposed Amount: Not reported
Final Monetary Amount: Not reported
Paid Amount: Not reported
Final Count: Not reported
Final Amount: Not reported

Found Violation: Yes
Agency Which Determined Violation: State
Violation Short Description: Generators - General
Date Violation was Determined: 20001208
Actual Return to Compliance Date: 20010711
Return to Compliance Qualifier: Documented
Violation Responsible Agency: State
Scheduled Compliance Date: 20010510
Enforcement Identifier: 001
Date of Enforcement Action: 20010410
Enforcement Responsible Agency: State
Enforcement Docket Number: Not reported
Enforcement Attorney: Not reported
Corrective Action Component: No
Appeal Initiated Date: Not reported
Appeal Resolution Date: Not reported
Disposition Status Date: Not reported
Disposition Status: Not reported
Disposition Status Description: Not reported
Consent/Final Order Sequence Number:Not reported
Consent/Final Order Respondent Name: Not reported
Consent/Final Order Lead Agency: Not reported
Enforcement Type: WRITTEN INFORMAL
Enforcement Responsible Person: NYWME
Enforcement Responsible Sub-Organization: R3
SEP Sequence Number: Not reported
SEP Expenditure Amount: Not reported
SEP Scheduled Completion Date: Not reported
SEP Actual Date: Not reported
SEP Defaulted Date: Not reported
SEP Type: Not reported
SEP Type Description: Not reported
Proposed Amount: Not reported
Final Monetary Amount: Not reported
Paid Amount: Not reported
Final Count: Not reported
Final Amount: Not reported

Evaluation Action Summary:
Evaluation Date: 20001208
Evaluation Responsible Agency: State
Found Violation: Yes
Evaluation Type Description: COMPLIANCE EVALUATION INSPECTION
Evaluation Responsible Person Identifier: NYWME
Evaluation Responsible Sub-Organization: R3
Actual Return to Compliance Date: 20010711
Scheduled Compliance Date: 20010706
Date of Request: Not reported
Date Response Received: Not reported
Request Agency: Not reported
Former Citation: Not reported

PICTURE PEOPLE THE (Continued) **1001961666**

Evaluation Date:	20001208
Evaluation Responsible Agency:	State
Found Violation:	Yes
Evaluation Type Description:	COMPLIANCE EVALUATION INSPECTION
Evaluation Responsible Person Identifier:	NYWME
Evaluation Responsible Sub-Organization:	R3
Actual Return to Compliance Date:	20010711
Scheduled Compliance Date:	20010510
Date of Request:	Not reported
Date Response Received:	Not reported
Request Agency:	Not reported
Former Citation:	Not reported

FINDS:
Registry ID: 110004561402

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:
The Resource Conservation and Recovery Act Information System (RCRAInfo) is EPA's comprehensive information system in support of the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. It tracks many types of information about generators, transporters, treaters, storers, and disposers of hazardous waste.

Click this hyperlink while viewing on your computer to access additional FINDS: detail in the EDR Site Report.

ECHO:

Envid:	1001961666
Registry ID:	110004561402

DFR URL:

Name:	PICTURE PEOPLE THE
Address:	100 MAIN ST SPACE 329
City,State,Zip:	WHITE PLAINS, NY 10603

NY MANIFEST:

EPA ID:	NYR000084806
Country:	USA
Name:	Picture Place-389 Galleria Mall
Address:	100 MAIN ST SPACE 329
Address 2:	GALLERIA MALL
City,State,Zip:	WHITE PLAINS, NY 10603
Zip 4:	Not reported
Location Address 1:	100 MAIN ST
Location Address 2:	Not reported
Location City,State,Zip:	WHITE PLAINS, NY 10603
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Picture Place-389 Galleria Mall
Mailing Contact:	Vernessa Vasquez

PICTURE PEOPLE THE (Continued) **1001961666**

Mailing Address 1: 100 MAIN ST
Mailing Address 2: Not reported
Mailing City,State,Zip: WHITE PLAINS, NY 10603
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: 9144282811

Manifest Data:
Document ID: MAM9991500
Manifest Status: Not reported
Trans1 State ID: NYCR2436
Year: 2001
Trans2 State ID: Not reported
Generator Ship Date: 10/26/2001
Trans1 Recv Date: 10/26/2001
Trans2 Recv Date: Not reported
TSD Site Recv Date: 10/31/2001
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYR000084806
Trans1 EPA ID: SCR000075150
Trans2 EPA ID: Not reported
TSDF ID 1: MAD982755639
TSDF ID 2: Not reported
Manifest Tracking Number: Not reported
Import Indicator: Not reported
Export Indicator: Not reported
Discr Quantity Indicator: Not reported
Discr Type Indicator: Not reported
Discr Residue Indicator: Not reported
Discr Partial Reject Indicator: Not reported
Discr Full Reject Indicator: Not reported
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: Not reported
Waste Code 1: Silver
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 00500
Units: Pounds
Number of Containers: 002
Container Type: Fiberboard or plastic drums, barrels, kegs
Handling Method: Recycle
Specific Gravity: 01.00

Document ID: MAM9811860
Manifest Status: Not reported
Trans1 State ID: Not reported
Year: 2001
Trans2 State ID: Not reported
Generator Ship Date: 07/17/2001
Trans1 Recv Date: 07/17/2001
Trans2 Recv Date: Not reported

PICTURE PEOPLE THE (Continued) **1001961666**

TSD Site Recv Date:	07/23/2001
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000084806
Trans1 EPA ID:	SCR000075150
Trans2 EPA ID:	Not reported
TSDF ID 1:	MAD982755639
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Silver
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00500
Units:	Pounds
Number of Containers:	002
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Recycle
Specific Gravity:	01.00

Document ID:	MAM9814660
Manifest Status:	Not reported
Trans1 State ID:	NYDW9495
Year:	2001
Trans2 State ID:	Not reported
Generator Ship Date:	07/25/2001
Trans1 Recv Date:	07/25/2001
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	08/06/2001
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000084806
Trans1 EPA ID:	SCR000075150
Trans2 EPA ID:	Not reported
TSDF ID 1:	MAD982755639
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported

PICTURE PEOPLE THE (Continued) **1001961666**

Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: Not reported
Waste Code 1: Silver
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 00500
Units: Pounds
Number of Containers: 002
Container Type: Fiberboard or plastic drums, barrels, kegs
Handling Method: Recycle
Specific Gravity: 01.00

Document ID: MAM9893790
Manifest Status: Not reported
Trans1 State ID: 39320JF
Year: 2001
Trans2 State ID: Not reported
Generator Ship Date: 11/07/2001
Trans1 Recv Date: 11/07/2001
Trans2 Recv Date: Not reported
TSD Site Recv Date: 11/14/2001
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYR000084806
Trans1 EPA ID: SCR000075150
Trans2 EPA ID: Not reported
TSDF ID 1: MAD982755639
TSDF ID 2: Not reported
Manifest Tracking Number: Not reported
Import Indicator: Not reported
Export Indicator: Not reported
Discr Quantity Indicator: Not reported
Discr Type Indicator: Not reported
Discr Residue Indicator: Not reported
Discr Partial Reject Indicator: Not reported
Discr Full Reject Indicator: Not reported
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: Not reported
Waste Code 1: Silver
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 00500
Units: Pounds
Number of Containers: 001
Container Type: Fiberboard or plastic drums, barrels, kegs
Handling Method: Recycle
Specific Gravity: 01.00

PICTURE PEOPLE THE (Continued) **1001961666**

Document ID:	MAM9903160
Manifest Status:	Not reported
Trans1 State ID:	NYCR2436
Year:	2001
Trans2 State ID:	T856MWNJ
Generator Ship Date:	09/06/2001
Trans1 Recv Date:	09/06/2001
Trans2 Recv Date:	09/13/2001
TSD Site Recv Date:	09/18/2001
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000084806
Trans1 EPA ID:	SCR000075150
Trans2 EPA ID:	NJD071629976
TSDF ID 1:	MAD982755639
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Silver
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00500
Units:	Pounds
Number of Containers:	002
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Recycle
Specific Gravity:	01.00

Document ID:	MAM9934860
Manifest Status:	Not reported
Trans1 State ID:	NY056343C
Year:	2001
Trans2 State ID:	Not reported
Generator Ship Date:	08/07/2001
Trans1 Recv Date:	08/07/2001
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	08/14/2001
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000084806
Trans1 EPA ID:	SCR000075150
Trans2 EPA ID:	Not reported
TSDF ID 1:	MAD982755639
TSDF ID 2:	Not reported

PICTURE PEOPLE THE (Continued) **1001961666**

Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Silver
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00500
Units:	Pounds
Number of Containers:	002
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Recycle
Specific Gravity:	01.00

Document ID:	MAM9950440
Manifest Status:	Not reported
Trans1 State ID:	NYCR2436
Year:	2001
Trans2 State ID:	Not reported
Generator Ship Date:	10/03/2001
Trans1 Recv Date:	10/03/2001
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	10/10/2001
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000084806
Trans1 EPA ID:	SCR000075150
Trans2 EPA ID:	Not reported
TSDF ID 1:	MAD982755639
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Silver
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported

PICTURE PEOPLE THE (Continued) **1001961666**

Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00500
Units:	Pounds
Number of Containers:	002
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Recycle
Specific Gravity:	01.00
Document ID:	MAM9967130
Manifest Status:	Not reported
Trans1 State ID:	NYCR2436
Year:	2001
Trans2 State ID:	T2L227
Generator Ship Date:	11/15/2001
Trans1 Recv Date:	11/15/2001
Trans2 Recv Date:	11/26/2001
TSD Site Recv Date:	11/30/2001
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000084806
Trans1 EPA ID:	SCR000075150
Trans2 EPA ID:	NJD071629976
TSDF ID 1:	MAD982755639
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Silver
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00250
Units:	Pounds
Number of Containers:	001
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Recycle
Specific Gravity:	01.00
Document ID:	MAM9230490
Manifest Status:	Not reported
Trans1 State ID:	NYCR2436
Year:	2001
Trans2 State ID:	T335LUNJ
Generator Ship Date:	03/02/2001
Trans1 Recv Date:	03/02/2001

PICTURE PEOPLE THE (Continued) **1001961666**

Trans2 Recv Date:	03/04/2001
TSD Site Recv Date:	03/08/2001
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000084806
Trans1 EPA ID:	SCR000075150
Trans2 EPA ID:	SCR000074591
TSDF ID 1:	MAD982755639
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Silver
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00500
Units:	Pounds
Number of Containers:	002
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Recycle
Specific Gravity:	01.00

Document ID:	MAM9236790
Manifest Status:	Not reported
Trans1 State ID:	NYCR2436
Year:	2001
Trans2 State ID:	T335LUNJ
Generator Ship Date:	03/16/2001
Trans1 Recv Date:	03/16/2001
Trans2 Recv Date:	03/19/2001
TSD Site Recv Date:	03/22/2001
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000084806
Trans1 EPA ID:	SCR000075150
Trans2 EPA ID:	SCR000074591
TSDF ID 1:	MAD982755639
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported

PICTURE PEOPLE THE (Continued) **1001961666**

Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Silver
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00500
Units:	Pounds
Number of Containers:	002
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Recycle
Specific Gravity:	01.00

Document ID:	MAM9301290
Manifest Status:	Not reported
Trans1 State ID:	NYCR2436
Year:	2001
Trans2 State ID:	03217
Generator Ship Date:	04/17/2001
Trans1 Recv Date:	04/17/2001
Trans2 Recv Date:	04/24/2001
TSD Site Recv Date:	05/04/2001
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000084806
Trans1 EPA ID:	SCR000075150
Trans2 EPA ID:	NJD071629976
TSDF ID 1:	MAD982755639
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Silver
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00500
Units:	Pounds
Number of Containers:	002
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Recycle

PICTURE PEOPLE THE (Continued) **1001961666**

Specific Gravity: 01.00

Click this hyperlink while viewing on your computer to access
158 additional NY MANIFEST: record(s) in the EDR Site Report.

A10 **NY COOLING TOWERS** **S121991640**
Target Property **100 MAIN STREET** **N/A**
WHITE PLAINS, NY 10601

Site 10 of 30 in cluster A

Actual: 197 ft.

COOLING TOWERS:

Name:	Not reported
Address:	100 MAIN STREET
City,State,Zip:	WHITE PLAINS, NY 10601
Equipment Unique ID:	1916
Equipment Borough:	Not reported
Intended Use:	Air Conditioning
Manufacturer:	Baltimore Air Coil
Model:	3935-2W
Cooling Capacity:	1860
Cooling Capacity Unit:	Tonnage
Commissioned Date:	03/25/1996
Inspection Date:	04/23/2019
Date of Bacteriological Collection:	10/16/2019
Date of Legionella Collection:	08/24/2022
Last Legionella Result > 1,000 CFU/mL:	lt20
Last Sampled Days:	Not reported
Reg Compliant:	Not reported
Last Update Days:	Not reported
CT Status:	Not reported
Equipment Tower Operation Duration:	Not reported
Latitude:	41.03196
Longitude:	-73.770798

A11 **NY COOLING TOWERS** **S121996546**
Target Property **100 MAIN STREET** **N/A**
WHITE PLAINS, NY 10601

Site 11 of 30 in cluster A

Actual: 197 ft.

COOLING TOWERS:

Name:	Not reported
Address:	100 MAIN STREET
City,State,Zip:	WHITE PLAINS, NY 10601
Equipment Unique ID:	7028
Equipment Borough:	Not reported
Intended Use:	Air Conditioning
Manufacturer:	MARLEY
Model:	NC-8307K2bb
Cooling Capacity:	700
Cooling Capacity Unit:	Tonnage
Commissioned Date:	08/05/2008
Inspection Date:	11/13/2020
Date of Bacteriological Collection:	11/13/2020

(Continued) **S121996546**

Date of Legionella Collection:	11/13/2020
Last Legionella Result > 1,000 CFU/mL:	lt20
Last Sampled Days:	Not reported
Reg Compliant:	Not reported
Last Update Days:	Not reported
CT Status:	Not reported
Equipment Tower Operation Duration:	Not reported
Latitude:	41.03196
Longitude:	-73.770798

A12 **J.C. PENNEY** **NY UST** **U004440526**
Target **100 MAIN ST** **N/A**
Property **WHITE PLAINS, NY 10601**

Site 12 of 30 in cluster A

Actual: **197 ft.**

WESTCHESTER CO. UST:

Name:	J.C. PENNEY
Address:	100 MAIN ST
City,State,Zip:	WHITE PLAINS, NY 10601
Id/Status:	3-173665 / Unregulated: <1101 gal. PBS
Operator Name:	Frank Steixner
Owner Name:	Macy's East, Inc.
Owner Street:	151 West 34th Street Room 1206
Owner Address2:	Not reported
Owner City:	New York
Owner State:	NY
Owner Zipcode:	10001
GDS Number:	Not reported
Tank Number:	1
Status:	4. Closed - in place
Capacity:	10000
Product Stored:	Not reported
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	12/01/1979
Date Perm Closure:	01/01/1997
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Secondary Containment:	0. None
Piping Location:	2. Underground/on ground
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Overfill Prevention:	Not reported
Piping Secondary Containment:	Not reported
Spill Prevention:	Not reported
Dispenser:	1. Submersible
Tank Number:	2
Status:	4. Closed - in place
Capacity:	10000
Product Stored:	Not reported
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None

J.C. PENNEY (Continued) **U004440526**

Date Installation:	12/01/1979
Date Perm Closure:	01/01/1997
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Secondary Containment:	0. None
Piping Location:	2. Underground/on ground
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Overfill Prevention:	Not reported
Piping Secondary Containment:	Not reported
Spill Prevention:	Not reported
Dispenser:	1. Submersible

Tank Number:	3
Status:	5. Tank converted to Non-Regulated use
Capacity:	100
Product Stored:	Not reported
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	12/01/1979
Date Perm Closure:	08/01/1996
Tank Location:	Not reported
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	1. Aboveground
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Overfill Prevention:	4. Product Level Gauge (Aboveground Only)
Piping Secondary Containment:	Not reported
Spill Prevention:	Not reported
Dispenser:	2. Suction

Tank Number:	4
Status:	5. Tank converted to Non-Regulated use
Capacity:	1000
Product Stored:	Not reported
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	01/01/1997
Date Perm Closure:	08/01/1996
Tank Location:	Not reported
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Secondary Containment:	Not reported
Piping Location:	1. Aboveground
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Overfill Prevention:	4. Product Level Gauge (Aboveground Only)
Piping Secondary Containment:	Not reported
Spill Prevention:	Not reported

J.C. PENNEY (Continued) **U004440526**

Dispenser: 2. Suction

A13 **LENSCRAFTERS #0787** **E MANIFEST** **1027933703**
Target **100 MAIN ST** **N/A**
Property **WHITE PLAINS, NY 10601**

Site 13 of 30 in cluster A

Actual: **197 ft.**

E MANIFEST:

Manifest Tracking Number:	017397649FLE
Last Updated Date:	20220705
Shipped Date:	20220610
Received Date:	20220628
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	Not reported
Generator Name:	Lenscrafters #0787
Generator Location Street Number:	Not reported
Generator Location Street 1:	100 MAIN ST
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	ATTN: ENVIRONMENTAL HEALTH & SAFETY MGR
Generator Mail Street 2:	100 MAIN ST
Generator Mail City:	WHITE PLAINS
Generator Mail Zip:	10601
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	PAD010154045
Designated Facility Name:	Envirite Of Pennsylvania, Inc.
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	730 VOGELSONG ROAD
Designated Facility Mail City:	YORK
Designated Facility Mail Zip:	17404
Designated Facility Mail State:	PA
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	730 VOGELSONG ROAD
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	YORK
Designated Facility Location Zip:	17404
Designated Facility Location State:	PA
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Manifest Tracking Number:	017765411FLE
Last Updated Date:	20230117
Shipped Date:	20221227
Received Date:	20230110
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	Not reported
Generator Name:	Lenscrafters #0787

LENSCRAFTERS #0787 (Continued) **1027933703**

Generator Location Street Number:	Not reported
Generator Location Street 1:	100 MAIN ST
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	ATTN: ENVIRONMENTAL HEALTH & SAFETY MGR
Generator Mail Street 2:	100 MAIN ST
Generator Mail City:	WHITE PLAINS
Generator Mail Zip:	10601
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	MID980991566
Designated Facility Name:	Eq Detroit, Inc.
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	1923 FREDERICK STREET
Designated Facility Mail City:	DETROIT
Designated Facility Mail Zip:	48211
Designated Facility Mail State:	MI
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	1923 FREDERICK STREET
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	DETROIT
Designated Facility Location Zip:	48211
Designated Facility Location State:	MI
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Federal Waste:

Manifest Tracking Number:	017765411FLE
Waste Line Number:	1
Federal Waste Code:	D001
Federal Waste:	IGNITABLE WASTE

Manifest Tracking Number:	017765411FLE
Waste Line Number:	1
Federal Waste Code:	U002
Federal Waste:	2-PROPANONE (I) (OR) ACETONE (I)

Manifest Tracking Number:	017765411FLE
Waste Line Number:	1
Federal Waste Code:	U140
Federal Waste:	1-PROPANOL, 2-METHYL- (I,T) (OR) ISOBUTYL ALCOHOL (I,T)

Manifest Tracking Number:	017765411FLE
Waste Line Number:	1
Federal Waste Code:	U154
Federal Waste:	METHANOL (I) (OR) METHYL ALCOHOL (I)

State Waste:

Manifest Tracking Number:	017765411FLE
Waste Line Number:	1
State Waste Code Owner:	NY

LENSCRAFTERS #0787 (Continued) **1027933703**

State Waste Code: R
State Waste: Material Recovery of more than 75 percent of the total material. Waste management method code to be used on e-Manifest only

Transporter:
Manifest Tracking Number: 017765411FLE
Transporter Line Number: 1
Transporter EPA ID: MAD084814136
Transporter Name: Eq Northeast, Inc.

Waste Line:
Manifest Tracking Number: 017765411FLE
Waste Line Number: 1
U.S. DOT Hazardous Indicator: Y
U.S. DOT ID Number: UN1993
U.S. DOT Description: Rq, Un1993, Waste, Flammable Liquids, N.O.S. (Isopropyl Alcohol, Acetone), 3, Pgii, Rq: D001, Erg#128
Non-Hazardous Waste Description: Not reported
Number of Containers: 1
Container Type Code: CF
Container Type Description: Fiber or plastic boxes, cartons, cases
Waste Quantity: 7
Quantity Unit of Measure Code: P
Quantity Unit of Measure Description: Pounds
Waste Quantity, in Tons: 0.0035
Acute Waste Quantity, in Tons: 0
Non-Acute Waste Quantity, in Tons: 0.0035
Waste Quantity, in Kilograms: 3.1746051
Acute Waste Quantity, in Kilograms: 0
Non-Acute Waste Quantity, in Kilorgrams: 3.1746051
Management Method Code: H141
Management Method Description: STORAGE, BULKING AND/OR TRANSFER OFF SITE
Waste Residue Indicator: N
Quantity Discrepancy Indicator: N
Waste Type Discrepancy Indicator: N
Waste Density: Not reported
Waste Density Unit of Measure Code: Not reported
Waste Density Unit of Measure Description: Not reported
Form Code: Not reported
Form Code Description: Not reported
Source Code: Not reported
Source Code Description: Not reported
Waste Minimization Code: Not reported
Waste Minimization Code Description: Not reported
Consent Number: Not reported
EPA Waste Indicator: Y

Manifest Tracking Number: 017765411FLE
Waste Line Number: 2
U.S. DOT Hazardous Indicator: N
U.S. DOT ID Number: Not reported
U.S. DOT Description: Not reported
Non-Hazardous Waste Description: Non Hazardous Liquid
Number of Containers: 1
Container Type Code: CF
Container Type Description: Fiber or plastic boxes, cartons, cases

LENSCRAFTERS #0787 (Continued) **1027933703**

Waste Quantity:	19
Quantity Unit of Measure Code:	P
Quantity Unit of Measure Description:	Pounds
Waste Quantity, in Tons:	0.0095
Acute Waste Quantity, in Tons:	0
Non-Acute Waste Quantity, in Tons:	0.0095
Waste Quantity, in Kilograms:	8.616785
Acute Waste Quantity, in Kilograms:	0
Non-Acute Waste Quantity, in Kilorgrams:	8.616785
Management Method Code:	H110
Management Method Description:	STABILIZATION
Waste Residue Indicator:	N
Quantity Discrepancy Indicator:	N
Waste Type Discrepancy Indicator:	N
Waste Density:	Not reported
Waste Density Unit of Measure Code:	Not reported
Waste Density Unit of Measure Description:	Not reported
Form Code:	Not reported
Form Code Description:	Not reported
Source Code:	Not reported
Source Code Description:	Not reported
Waste Minimization Code:	Not reported
Waste Minimization Code Description:	Not reported
Consent Number:	Not reported
EPA Waste Indicator:	N

A14 **J C PENNEY CO INC** **NY LTANKS** **1000912475**
Target **100 MAIN ST** **NY Spills** **NY0000806901**
Property **WHITE PLAINS, NY 10601** **RCRA NonGen / NLR**
NY MANIFEST

Site 14 of 30 in cluster A

Actual:
197 ft.

LTANKS:

Name:	GALLARIA
Address:	100 MAIN STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9102767 / 1991-06-13
Facility ID:	9102767
Site ID:	137993
Spill Date:	1991-06-10
Spill Cause:	Tank Overfill
Spill Source:	Tank Truck
Spill Class:	Not reported
Cleanup Ceased:	1953-06-18
SWIS:	6017
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1991-06-10
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Responsible Party
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1991-06-13
Spill Record Last Update:	1991-07-10

J C PENNEY CO INC (Continued) **1000912475**

Spiller Name:	Not reported
Spiller Company:	CASTLE OIL
Spiller Address:	Not reported
Spiller County:	999
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	118002
Latitude:	41.0319809
Longitude:	-73.7707610
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY
Remarks:	CONTAINED ON SIDEWALK CASTLE OIL TO CLEAN UP

All Materials:

Site ID:	137993
Operable Unit ID:	956636
Operable Unit:	01
Material ID:	425258
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	20.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

SPILLS:

Name:	GALLERIA MALL
Address:	100 MAIN STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0703055 / 2007-06-14
Facility ID:	0703055
Facility Type:	ER
DER Facility ID:	118002
Site ID:	382912
DEC Region:	3
Spill Cause:	Human Error
Spill Class:	C4
SWIS:	6017
Spill Date:	2007-06-13
Investigator:	TDGHIOSA
Referred To:	Not reported
Reported to Dept:	2007-06-14
CID:	444
Water Affected:	Not reported
Spill Source:	Institutional, Educational, Gov., Other
Spill Notifier:	Health Department
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False

J C PENNEY CO INC (Continued) **1000912475**

Remediation Phase:	0
Date Entered In Computer:	2007-06-14
Spill Record Last Update:	2007-06-14
Spiller Name:	DENISE
Spiller Company:	GALLERIA MALL
Spiller Address:	100 MAIN STREET
Spiller Company:	001
Contact Name:	DENISE
Latitude:	41.0315417
Longitude:	-73.7718686
DEC Memo:	7/14/07 WPPD reported that the WPFD recovered the gas. NFA TG
Remarks:	a person dumped out his gas into storm drain when he could not return it: less then 1 gallon

All Materials:

Site ID:	382912
Operable Unit ID:	1140291
Operable Unit:	01
Material ID:	2130355
Material Code:	0009
Material Name:	gasoline
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	GALLERIA MALL
Address:	100 MAIN STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0211359 / 2005-02-27
Facility ID:	0211359
Facility Type:	ER
DER Facility ID:	118002
Site ID:	104864
DEC Region:	3
Spill Cause:	Unknown
Spill Class:	Not reported
SWIS:	6017
Spill Date:	2003-02-13
Investigator:	UNASSIGNED
Referred To:	Not reported
Reported to Dept:	2003-02-13
CID:	297
Water Affected:	Not reported
Spill Source:	Commercial Vehicle
Spill Notifier:	Police Department
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2003-02-13
Spill Record Last Update:	2005-02-27

J C PENNEY CO INC (Continued) **1000912475**

Spiller Name:	Not reported
Spiller Company:	UNKNOWN
Spiller Address:	Not reported
Spiller Company:	001
Contact Name:	D.C. CIOCCA - WPFD
Latitude:	41.0319809
Longitude:	-73.7707610
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was 2/27/05 surface spill from vehicle--close
Remarks:	WHITE PLAINS FD ON SCENE AND THEY NEED A RESPONSE FROM DEC

All Materials:

Site ID:	104864
Operable Unit ID:	864691
Operable Unit:	01
Material ID:	565743
Material Code:	0009
Material Name:	gasoline
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	40.00
Units:	G
Recovered:	.00
Resource Affected:	Sewer
Oxygenate:	Not reported

Name:	J.C.PENNY DEPT. STORE
Address:	100 MAIN STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9204133 / 1992-08-04
Facility ID:	9204133
Facility Type:	ER
DER Facility ID:	118002
Site ID:	137995
DEC Region:	3
Spill Cause:	Unknown
Spill Class:	C3
SWIS:	6017
Spill Date:	1992-07-10
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1992-07-10
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Other
Cleanup Ceased:	1992-08-04
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	1992-07-13
Spill Record Last Update:	1995-05-19
Spiller Name:	Not reported
Spiller Company:	SAME

J C PENNEY CO INC (Continued) **1000912475**

Spiller Address:	Not reported
Spiller Company:	001
Contact Name:	Not reported
Latitude:	41.0319809
Longitude:	-73.7707610
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY
Remarks:	OIL DISCOVERED IN BASEMENT SUMP; SUMP PUMP WAS BROKEN AND TO BE REPAIRED WHEN OIL WAS DISCOVERED LUZON TO VAC SUMP PICK UP AND DISPOSE TODD GHIOSAY NOTIFIED

All Materials:

Site ID:	137995
Operable Unit ID:	967942
Operable Unit:	01
Material ID:	411881
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	100.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	GALLERIA MALL
Address:	100 MAIN STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0302779 / 2003-06-16
Facility ID:	0302779
Facility Type:	ER
DER Facility ID:	118002
Site ID:	137992
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	C4
SWIS:	6017
Spill Date:	2003-06-16
Investigator:	jbodee
Referred To:	Not reported
Reported to Dept:	2003-06-16
CID:	204
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Police Department
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2003-06-16
Spill Record Last Update:	2003-06-18
Spiller Name:	Not reported
Spiller Company:	GALLERIA MALL
Spiller Address:	100 MAIN STREET

J C PENNEY CO INC (Continued) **1000912475**

Spiller Company:	001
Contact Name:	PATRICK MURPHY
Latitude:	41.0319809
Longitude:	-73.7707610
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was O'DEE
Remarks:	SUBJECT STUCK IN ELEVATOR - FIRE DEPARTMENT ON SCENE

All Materials:

Site ID:	137992
Operable Unit ID:	870528
Operable Unit:	01
Material ID:	507231
Material Code:	0010
Material Name:	hydraulic oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	20.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

RCRA Listings:

Date Form Received by Agency:	20070101
Handler Name:	J C Penney Co Inc
Handler Address:	Main St
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NY0000806901
Contact Name:	Not reported
Contact Address:	PO BOX 250
Contact City,State,Zip:	WAYNE, NY 07470
Contact Telephone:	Not reported
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Not reported
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R3
Mailing Address:	PO BOX 250
Mailing City,State,Zip:	WAYNE, NY 07470
Owner Name:	J C Penney Co Inc
Owner Type:	Private
Operator Name:	J C Penney Co Inc
Operator Type:	Private
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No

J C PENNEY CO INC (Continued) **1000912475**

Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20150414
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Hazardous Waste Summary:

Waste Code:	D002
Waste Description:	Corrosive Waste
Waste Code:	NONE
Waste Description:	Not Defined

Handler - Owner Operator:

Owner/Operator Indicator:	Operator
Owner/Operator Name: J C PENNEY CO INC	
Legal Status:	Private
Date Became Current:	Not reported
Date Ended Current:	Not reported
Owner/Operator Address:	PO BOX 1001
Owner/Operator City,State,Zip:	DALLAS, TX 75301-0001
Owner/Operator Telephone:	214-591-1000
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported
Owner/Operator Email:	Not reported

J C PENNEY CO INC (Continued) **1000912475**

Owner/Operator Indicator: Owner
Owner/Operator Name: J C PENNEY CO INC
Legal Status: Private
Date Became Current: Not reported
Date Ended Current: Not reported
Owner/Operator Address: PO BOX 1001
Owner/Operator City,State,Zip: DALLAS, TX 75301-0001
Owner/Operator Telephone: 214-591-1000
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Owner
Owner/Operator Name: J C PENNEY CO INC
Legal Status: Private
Date Became Current: Not reported
Date Ended Current: Not reported
Owner/Operator Address: PO BOX 1001
Owner/Operator City,State,Zip: DALLAS, TX 75301-0001
Owner/Operator Telephone: 214-591-1000
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Historic Generators:
Receive Date: 19950124
Handler Name: J C PENNEY CO INC
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20060101
Handler Name: J C PENNEY CO INC
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20070101
Handler Name: J C PENNEY CO INC
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No

J C PENNEY CO INC (Continued) **1000912475**

Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported
Receive Date:	19940920
Handler Name: J C PENNEY CO INC	
Federal Waste Generator Description:	Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

NY MANIFEST:

EPA ID:	NY0000806901
Country:	USA
Name:	J C Penneys
Address:	100 MAIN ST
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10601
Zip 4:	Not reported
Location Address 1:	100 MAIN ST
Location Address 2:	Not reported
Location City,State,Zip:	WHITE PLAINS, NY 10601
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	J C Penneys
Mailing Contact:	Roy Langbridge
Mailing Address 1:	P O BOX 250 RT 46
Mailing Address 2:	Not reported
Mailing City,State,Zip:	WHITE PLAINS, NY 10601
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	2017851881

J C PENNEY CO INC (Continued) **1000912475**

Manifest Data:

Document ID:	NYB4480794
Manifest Status:	Not reported
Trans1 State ID:	TW56975PA
Year:	1994
Trans2 State ID:	Not reported
Generator Ship Date:	10/26/1994
Trans1 Recv Date:	10/26/1994
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	11/01/1994
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NY0000806901
Trans1 EPA ID:	PAD064035819
Trans2 EPA ID:	Not reported
TSDF ID 1:	NCD980842132
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Ignitable Waste
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00075
Units:	Pounds
Number of Containers:	001
Container Type:	Metal drums, barrels, kegs
Handling Method:	Treat
Specific Gravity:	01.00
Waste Code 7:	Corrosive Waste
Waste Code 8:	Not reported
Waste Code:	Not reported
Waste Code 10:	Not reported
Waste Code 11:	Not reported
Quantity:	00100
Units:	Pounds
Number of Containers:	001
Container Type:	Metal drums, barrels, kegs
Handling Method:	Landfill
Specific Gravity:	01.00

A15
Target Property **100 E. MAIN ST**
WHITE PLAINS, NY 10601

NY COOLING TOWERS **S131454371**
N/A

Site 15 of 30 in cluster A

Actual: 197 ft.

COOLING TOWERS:

Name:	Not reported
Address:	100 E. MAIN ST
City,State,Zip:	WHITE PLAINS, NY 10601
Equipment Unique ID:	6530
Equipment Borough:	Not reported
Intended Use:	Air Conditioning
Manufacturer:	Marley
Model:	NC1211GM
Cooling Capacity:	180
Cooling Capacity Unit:	Tonnage
Commissioned Date:	05/07/2007
Inspection Date:	09/01/2015
Date of Bacteriological Collection:	08/27/2015
Date of Legionella Collection:	08/27/2015
Last Legionella Result > 1,000 CFU/mL:	Not reported
Last Sampled Days:	Not reported
Reg Compliant:	Not reported
Last Update Days:	Not reported
CT Status:	Not reported
Equipment Tower Operation Duration:	Not reported
Latitude:	41.03196
Longitude:	-73.770798

A16
Target Property **GALLERIA OF WHITE PLAINS**
100 MAIN STREET
WHITE PLAINS, NY 10601

FINDS **1007758249**
N/A

Site 16 of 30 in cluster A

Actual: 197 ft.

FINDS:
Registry ID: 110019206599

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:
The New York Department of Environmental Conservation Facility Information System (FIS) database houses all information about facilities that are regulated or of environmental interest to the state of New York.

Click this hyperlink while viewing on your computer to access additional FINDS: detail in the EDR Site Report.

A17 **SEARS** **E MANIFEST** **1027865207**
Target **100 MAIN ST** **N/A**
Property **WHITE PLAINS, NY 10601**

Site 17 of 30 in cluster A

Actual: **197 ft.**

E MANIFEST:

Manifest Tracking Number:	011451870FLE
Last Updated Date:	20180924
Shipped Date:	20180907
Received Date:	20180917
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	CESQG
Generator Name:	Sears
Generator Location Street Number:	Not reported
Generator Location Street 1:	100 MAIN ST
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	3333 Beverly Rd.
Generator Mail Street 2:	Not reported
Generator Mail City:	Hoffman Estates
Generator Mail Zip:	60179
Generator Mail State:	IL
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	RID040098352
Designated Facility Name:	Northland Environmental, Llc
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	275 Allens Avenue
Designated Facility Mail City:	Providence
Designated Facility Mail Zip:	02905
Designated Facility Mail State:	RI
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	275 Allens Avenue
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	Providence
Designated Facility Location Zip:	02905
Designated Facility Location State:	RI
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Manifest Tracking Number:	012473302FLE
Last Updated Date:	20190319
Shipped Date:	20190304
Received Date:	20190305
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	CESQG
Generator Name:	Sears
Generator Location Street Number:	Not reported
Generator Location Street 1:	100 MAIN ST
Generator Location Street 2:	Not reported

SEARS (Continued) **1027865207**

Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	100 Main St
Generator Mail Street 2:	Not reported
Generator Mail City:	White Plains
Generator Mail Zip:	10601
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	RID040098352
Designated Facility Name:	Northland Environmental, Llc
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	275 Allens Avenue
Designated Facility Mail City:	Providence
Designated Facility Mail Zip:	02905
Designated Facility Mail State:	RI
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	275 Allens Avenue
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	Providence
Designated Facility Location Zip:	02905
Designated Facility Location State:	RI
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Manifest Tracking Number:	013351684FLE
Last Updated Date:	20200107
Shipped Date:	20190808
Received Date:	20190815
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	CESQG
Generator Name:	Sears
Generator Location Street Number:	Not reported
Generator Location Street 1:	100 MAIN ST
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	100 Main St
Generator Mail Street 2:	Not reported
Generator Mail City:	White Plains
Generator Mail Zip:	10601
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	RID040098352
Designated Facility Name:	Northland Environmental, Llc
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	275 Allens Avenue
Designated Facility Mail City:	Providence
Designated Facility Mail Zip:	02905

SEARS (Continued) **1027865207**

Designated Facility Mail State:	RI
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	275 Allens Avenue
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	Providence
Designated Facility Location Zip:	02905
Designated Facility Location State:	RI
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Federal Waste:

Manifest Tracking Number:	013351684FLE
Waste Line Number:	1
Federal Waste Code:	D001
Federal Waste:	IGNITABLE WASTE

State Waste:

Manifest Tracking Number:	013351684FLE
Waste Line Number:	2
State Waste Code Owner:	RI
State Waste Code:	R015
State Waste:	Non-hazardous waste, manifest required by receiving state

Transporter:

Manifest Tracking Number:	013351684FLE
Transporter Line Number:	1
Transporter EPA ID:	PAD982661381
Transporter Name:	Republic Environmental Systems Transportation Group Llc

Manifest Tracking Number:	013351684FLE
Transporter Line Number:	2
Transporter EPA ID:	PAD982661381
Transporter Name:	Republic Environmental Systems Transportation Group Llc

Waste Line:

Manifest Tracking Number:	013351684FLE
Waste Line Number:	1
U.S. DOT Hazardous Indicator:	Y
U.S. DOT ID Number:	UN1993
U.S. DOT Description:	Un1993, Waste Flammable Liquids, N.O.S. (Acetone, Alcohols), 3, Pg Ii, Erg#128
Non-Hazardous Waste Description:	Not reported
Number of Containers:	1
Container Type Code:	BA
Container Type Description:	Burlap, cloth, paper, or plastic bags
Waste Quantity:	22
Quantity Unit of Measure Code:	P
Quantity Unit of Measure Description:	Pounds
Waste Quantity, in Tons:	0.011
Acute Waste Quantity, in Tons:	0
Non-Acute Waste Quantity, in Tons:	0.011
Waste Quantity, in Kilograms:	9.97733
Acute Waste Quantity, in Kilograms:	0
Non-Acute Waste Quantity, in Kilorgrams:	9.97733

SEARS (Continued) **1027865207**

Management Method Code:	H141
Management Method Description:	STORAGE, BULKING AND/OR TRANSFER OFF SITE
Waste Residue Indicator:	N
Quantity Discrepancy Indicator:	N
Waste Type Discrepancy Indicator:	N
Waste Density:	Not reported
Waste Density Unit of Measure Code:	Not reported
Waste Density Unit of Measure Description:	Not reported
Form Code:	Not reported
Form Code Description:	Not reported
Source Code:	Not reported
Source Code Description:	Not reported
Waste Minimization Code:	Not reported
Waste Minimization Code Description:	Not reported
Consent Number:	Not reported
EPA Waste Indicator:	Y

Manifest Tracking Number:	013351684FLE
Waste Line Number:	2
U.S. DOT Hazardous Indicator:	N
U.S. DOT ID Number:	Not reported
U.S. DOT Description:	Not reported
Non-Hazardous Waste Description:	Non-Hazardous, Non-Regulated Liquids & Solids
Number of Containers:	1
Container Type Code:	BA
Container Type Description:	Burlap, cloth, paper, or plastic bags
Waste Quantity:	3
Quantity Unit of Measure Code:	P
Quantity Unit of Measure Description:	Pounds
Waste Quantity, in Tons:	0.0015
Acute Waste Quantity, in Tons:	0
Non-Acute Waste Quantity, in Tons:	0.0015
Waste Quantity, in Kilograms:	1.360545
Acute Waste Quantity, in Kilograms:	0
Non-Acute Waste Quantity, in Kilorgrams:	1.360545
Management Method Code:	H141
Management Method Description:	STORAGE, BULKING AND/OR TRANSFER OFF SITE
Waste Residue Indicator:	N
Quantity Discrepancy Indicator:	N
Waste Type Discrepancy Indicator:	N
Waste Density:	Not reported
Waste Density Unit of Measure Code:	Not reported
Waste Density Unit of Measure Description:	Not reported
Form Code:	Not reported
Form Code Description:	Not reported
Source Code:	Not reported
Source Code Description:	Not reported
Waste Minimization Code:	Not reported
Waste Minimization Code Description:	Not reported
Consent Number:	Not reported
EPA Waste Indicator:	N

A18 **EXPRESSLY PORTRAITS** **RCRA NonGen / NLR** **1000981336**
Target **100 MAIN ST - GALLERIA MALL** **FINDS** **NY0000969121**
Property **WHITE PLAINS, NY 10603** **ECHO**
NY MANIFEST

Site 18 of 30 in cluster A

Actual:
197 ft.

RCRA Listings:

Date Form Received by Agency:	20070101
Handler Name:	Expressly Portraits
Handler Address:	Main St - Galleria Mall
Handler City,State,Zip:	WHITE PLAINS, NY 10603
EPA ID:	NY0000969121
Contact Name:	ROGER BLAKE
Contact Address:	TRITON DR - SUITE C
Contact City,State,Zip:	FOSTER CITY, NY 94404
Contact Telephone:	415-578-9291
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Not reported
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R3
Mailing Address:	TRITON DR - SUITE C
Mailing City,State,Zip:	FOSTER CITY, NY 94404
Owner Name:	Expressly Portraits Corp
Owner Type:	Private
Operator Name:	Expressly Portraits Corp
Operator Type:	Private
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No

EXPRESSLY PORTRAITS (Continued) **1000981336**

Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20150414
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Hazardous Waste Summary:

Waste Code:	D011
Waste Description:	Silver

Handler - Owner Operator:

Owner/Operator Indicator:	Owner
Owner/Operator Name:	EXPRESSLY PORTRAITS CORP
Legal Status:	Private
Date Became Current:	Not reported
Date Ended Current:	Not reported
Owner/Operator Address:	1151 TRITON DR - SUITE C
Owner/Operator City,State,Zip:	FOSTER CITY, CA 94404
Owner/Operator Telephone:	415-578-9291
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported
Owner/Operator Email:	Not reported

Owner/Operator Indicator:	Operator
Owner/Operator Name:	EXPRESSLY PORTRAITS CORP
Legal Status:	Private
Date Became Current:	Not reported
Date Ended Current:	Not reported
Owner/Operator Address:	1151 TRITON DR - SUITE C
Owner/Operator City,State,Zip:	FOSTER CITY, CA 94404
Owner/Operator Telephone:	415-578-9291
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported
Owner/Operator Email:	Not reported

Owner/Operator Indicator:	Owner
Owner/Operator Name:	EXPRESSLY PORTRAITS CORP
Legal Status:	Private
Date Became Current:	Not reported
Date Ended Current:	Not reported
Owner/Operator Address:	1151 TRITON DR - SUITE C
Owner/Operator City,State,Zip:	FOSTER CITY, CA 94404
Owner/Operator Telephone:	415-578-9291
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported

EXPRESSLY PORTRAITS (Continued) **1000981336**

Owner/Operator Email: Not reported

Historic Generators:

Receive Date: 20060101
Handler Name: EXPRESSLY PORTRAITS
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20070101
Handler Name: EXPRESSLY PORTRAITS
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 19941208
Handler Name: EXPRESSLY PORTRAITS
Federal Waste Generator Description: Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:

NAICS Codes: No NAICS Codes Found

Has the Facility Received Notices of Violations:

Found Violation: Yes
Agency Which Determined Violation: State
Violation Short Description: Generators - Records/Reporting
Date Violation was Determined: 19970826
Actual Return to Compliance Date: 19971022
Return to Compliance Qualifier: Observed
Violation Responsible Agency: State
Scheduled Compliance Date: 19971001
Enforcement Identifier: 000
Date of Enforcement Action: 19970826

EXPRESSLY PORTRAITS (Continued) **1000981336**

Enforcement Responsible Agency: State
Enforcement Docket Number: Not reported
Enforcement Attorney: NY
Corrective Action Component: No
Appeal Initiated Date: Not reported
Appeal Resolution Date: Not reported
Disposition Status Date: Not reported
Disposition Status: Not reported
Disposition Status Description: Not reported
Consent/Final Order Sequence Number: Not reported
Consent/Final Order Respondent Name: Not reported
Consent/Final Order Lead Agency: Not reported
Enforcement Type: WRITTEN INFORMAL
Enforcement Responsible Person: NYDEC
Enforcement Responsible Sub-Organization: Not reported
SEP Sequence Number: Not reported
SEP Expenditure Amount: Not reported
SEP Scheduled Completion Date: Not reported
SEP Actual Date: Not reported
SEP Defaulted Date: Not reported
SEP Type: Not reported
SEP Type Description: Not reported
Proposed Amount: Not reported
Final Monetary Amount: Not reported
Paid Amount: Not reported
Final Count: Not reported
Final Amount: Not reported

Evaluation Action Summary:
Evaluation Date: 19970301
Evaluation Responsible Agency: State
Found Violation: Yes
Evaluation Type Description: NON-FINANCIAL RECORD REVIEW
Evaluation Responsible Person Identifier: Not reported
Evaluation Responsible Sub-Organization: Not reported
Actual Return to Compliance Date: 19971022
Scheduled Compliance Date: 19971001
Date of Request: Not reported
Date Response Received: Not reported
Request Agency: Not reported
Former Citation: Not reported

FINDS:
Registry ID: 110004322849

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:
The Resource Conservation and Recovery Act Information System (RCRAInfo) is EPA's comprehensive information system in support of the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. It tracks many types of information about generators, transporters, treaters, storers, and disposers of hazardous waste.

EXPRESSLY PORTRAITS (Continued) **1000981336**

Click this hyperlink while viewing on your computer to access additional FINDS: detail in the EDR Site Report.

ECHO:
- Envid: 1000981336
- Registry ID: 110004322849

DFR URL:
- Name: EXPRESSLY PORTRAITS
- Address: 100 MAIN ST - GALLERIA MALL
- City,State,Zip: WHITE PLAINS, NY 10603

NY MANIFEST:
- EPA ID: NY0000969121
- Country: USA
- Name: Expressly Portraits
- Address: 100 MAIN ST - GALLERIA MALL
- Address 2: SPACE 378
- City,State,Zip: WHITE PLAINS, NY 10603
- Zip 4: Not reported
- Location Address 1: 100 MAIN ST
- Location Address 2: Not reported
- Location City,State,Zip: WHITE PLAINS, NY 10603
- Location Zip 4: Not reported
- Facility Status: Not reported
- Total Tanks: Not reported
- Code: BP

Mailing:
- Mailing Name: Expressly Portraits
- Mailing Contact: Frank Gorham
- Mailing Address 1: 100 MAIN ST
- Mailing Address 2: Not reported
- Mailing City,State,Zip: WHITE PLAINS, NY 10603
- Mailing Zip 4: Not reported
- Mailing Country: USA
- Mailing Phone: 0000000000

Manifest Data:
- Document ID: NYC5337707
- Manifest Status: Not reported
- Trans1 State ID: NYDW9495
- Year: 1998
- Trans2 State ID: T422NYNJ
- Generator Ship Date: 10/12/1998
- Trans1 Recv Date: 10/12/1998
- Trans2 Recv Date: 10/15/1998
- TSD Site Recv Date: 10/21/1998
- Part A Recv Date: Not reported
- Part B Recv Date: Not reported
- Generator EPA ID: NY0000969121
- Trans1 EPA ID: ILD984908202
- Trans2 EPA ID: SCD987574647
- TSDF ID 1: SCD077995488
- TSDF ID 2: Not reported
- Manifest Tracking Number: Not reported

EXPRESSLY PORTRAITS (Continued) **1000981336**

Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Silver
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00500
Units:	Pounds
Number of Containers:	002
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Recycle
Specific Gravity:	01.00

Document ID:	CTF0675331
Manifest Status:	Not reported
Trans1 State ID:	NYAV4489
Year:	1997
Trans2 State ID:	Not reported
Generator Ship Date:	07/21/1997
Trans1 Recv Date:	07/21/1997
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	07/24/1997
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NY0000969121
Trans1 EPA ID:	ILD984908202
Trans2 EPA ID:	Not reported
TSDF ID 1:	CTD001156009
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Silver
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported

EXPRESSLY PORTRAITS (Continued) **1000981336**

Waste Code 6:	Not reported
Quantity:	00500
Units:	Pounds
Number of Containers:	002
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Recycle
Specific Gravity:	01.00
Document ID:	CTF0675361
Manifest Status:	Not reported
Trans1 State ID:	ILP39038
Year:	1997
Trans2 State ID:	Not reported
Generator Ship Date:	08/05/1997
Trans1 Recv Date:	08/05/1997
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	08/07/1997
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NY0000969121
Trans1 EPA ID:	ILD984908202
Trans2 EPA ID:	Not reported
TSDF ID 1:	CTD001156009
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Silver
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00500
Units:	Pounds
Number of Containers:	002
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Recycle
Specific Gravity:	01.00
Document ID:	CTF0639832
Manifest Status:	Not reported
Trans1 State ID:	NYDW9495
Year:	1997
Trans2 State ID:	Not reported
Generator Ship Date:	11/12/1997
Trans1 Recv Date:	11/12/1997
Trans2 Recv Date:	Not reported

EXPRESSLY PORTRAITS (Continued) **1000981336**

TSD Site Recv Date:	11/13/1997
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NY0000969121
Trans1 EPA ID:	ILD984908202
Trans2 EPA ID:	Not reported
TSDF ID 1:	CTD001156009
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Silver
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00500
Units:	Pounds
Number of Containers:	002
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Recycle
Specific Gravity:	01.00

Document ID:	CTF0640246
Manifest Status:	Not reported
Trans1 State ID:	NYDW9495
Year:	1997
Trans2 State ID:	Not reported
Generator Ship Date:	12/10/1997
Trans1 Recv Date:	12/10/1997
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	12/11/1997
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NY0000969121
Trans1 EPA ID:	ILD984908202
Trans2 EPA ID:	Not reported
TSDF ID 1:	CTD001156009
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported

EXPRESSLY PORTRAITS (Continued) **1000981336**

Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: Not reported
Waste Code 1: Silver
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 00750
Units: Pounds
Number of Containers: 003
Container Type: Fiberboard or plastic drums, barrels, kegs
Handling Method: Recycle
Specific Gravity: 01.00

Document ID: CTF0642119
Manifest Status: Not reported
Trans1 State ID: NYDW9495
Year: 1997
Trans2 State ID: Not reported
Generator Ship Date: 11/26/1997
Trans1 Recv Date: 11/26/1997
Trans2 Recv Date: Not reported
TSD Site Recv Date: 12/01/1997
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NY0000969121
Trans1 EPA ID: ILD984908202
Trans2 EPA ID: Not reported
TSDF ID 1: CTD001156009
TSDF ID 2: Not reported
Manifest Tracking Number: Not reported
Import Indicator: Not reported
Export Indicator: Not reported
Discr Quantity Indicator: Not reported
Discr Type Indicator: Not reported
Discr Residue Indicator: Not reported
Discr Partial Reject Indicator: Not reported
Discr Full Reject Indicator: Not reported
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: Not reported
Waste Code 1: Silver
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 00500
Units: Pounds
Number of Containers: 002
Container Type: Fiberboard or plastic drums, barrels, kegs
Handling Method: Recycle
Specific Gravity: 01.00

EXPRESSLY PORTRAITS (Continued) **1000981336**

Document ID:	CTF0642264
Manifest Status:	Not reported
Trans1 State ID:	NYDW9495
Year:	1997
Trans2 State ID:	Not reported
Generator Ship Date:	11/19/1997
Trans1 Recv Date:	11/19/1997
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	11/20/1997
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NY0000969121
Trans1 EPA ID:	ILD984908202
Trans2 EPA ID:	Not reported
TSDF ID 1:	CTD001156009
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Silver
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00500
Units:	Pounds
Number of Containers:	002
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Recycle
Specific Gravity:	01.00

Document ID:	CTF0640741
Manifest Status:	Not reported
Trans1 State ID:	NYAV4489
Year:	1997
Trans2 State ID:	Not reported
Generator Ship Date:	10/24/1997
Trans1 Recv Date:	10/24/1997
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	10/27/1997
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NY0000969121
Trans1 EPA ID:	ILD984908202
Trans2 EPA ID:	Not reported
TSDF ID 1:	CTD001156009
TSDF ID 2:	Not reported

EXPRESSLY PORTRAITS (Continued) **1000981336**

Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Silver
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00500
Units:	Pounds
Number of Containers:	002
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Recycle
Specific Gravity:	01.00

Document ID:	CTF0641101
Manifest Status:	Not reported
Trans1 State ID:	NYAV4489
Year:	1997
Trans2 State ID:	Not reported
Generator Ship Date:	10/16/1997
Trans1 Recv Date:	10/16/1997
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	10/20/1997
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NY0000969121
Trans1 EPA ID:	ILD984908202
Trans2 EPA ID:	Not reported
TSDF ID 1:	CTD001156009
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Silver
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported

EXPRESSLY PORTRAITS (Continued) **1000981336**

Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00500
Units:	Pounds
Number of Containers:	002
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Recycle
Specific Gravity:	01.00
Document ID:	CTF0643465
Manifest Status:	Not reported
Trans1 State ID:	NYDW9495
Year:	1997
Trans2 State ID:	Not reported
Generator Ship Date:	10/29/1997
Trans1 Recv Date:	10/29/1997
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	11/03/1997
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NY0000969121
Trans1 EPA ID:	ILD984908202
Trans2 EPA ID:	Not reported
TSDF ID 1:	CTD001156009
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Silver
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00500
Units:	Pounds
Number of Containers:	002
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Recycle
Specific Gravity:	01.00
Document ID:	CTF0643732
Manifest Status:	Not reported
Trans1 State ID:	NYDW9495
Year:	1997
Trans2 State ID:	Not reported
Generator Ship Date:	12/24/1997
Trans1 Recv Date:	12/24/1997

EXPRESSLY PORTRAITS (Continued) **1000981336**

Trans2 Recv Date:	Not reported
TSD Site Recv Date:	12/29/1997
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NY0000969121
Trans1 EPA ID:	ILD984908202
Trans2 EPA ID:	Not reported
TSDF ID 1:	CTD001156009
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Silver
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00500
Units:	Pounds
Number of Containers:	002
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Recycle
Specific Gravity:	01.00

Click this hyperlink while viewing on your computer to access
206 additional NY MANIFEST: record(s) in the EDR Site Report.

A19 **MACY'S EAST #55** **NY MANIFEST** **S117564976**
Target **100 MAIN ST** **N/A**
Property **WHITE PLAINS, NY 10601**

Site 19 of 30 in cluster A

Actual: NY MANIFEST:
197 ft.

EPA ID:	NYR000120329
Country:	USA
Name:	Macy'S East #55
Address:	100 MAIN ST
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10601
Zip 4:	Not reported
Location Address 1:	700 LEE BLVD
Location Address 2:	Not reported
Location City,State,Zip:	YORKTOWN HEIGHTS, NY 10598
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported

MACY'S EAST #55 (Continued) **S117564976**

Code: BP

Mailing:
Mailing Name: Macy'S East #55
Mailing Contact: Maybelle Valentin
Mailing Address 1: 700 LEE BLVD
Mailing Address 2: Not reported
Mailing City,State,Zip: YORKTOWN HEIGHTS, NY 10598
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: 9142433302

Manifest Data:
Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: MAD039322250
Year: 2018
Trans2 State ID: NJD986607380
Generator Ship Date: 08/22/2007
Trans1 Recv Date: 08/22/2007
Trans2 Recv Date: 08/23/2007
TSD Site Recv Date: 08/29/2007
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYR000120329
Trans1 EPA ID: Not reported
Trans2 EPA ID: Not reported
TSDF ID 1: NCD000648451
TSDF ID 2: Not reported
Manifest Tracking Number: 001138884FLE
Import Indicator: N
Export Indicator: N
Discr Quantity Indicator: N
Discr Type Indicator: N
Discr Residue Indicator: N
Discr Partial Reject Indicator: N
Discr Full Reject Indicator: N
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: H141
Waste Code a: Ignitable Waste
Waste Code b: Not reported
Waste Code c: Not reported
Waste Code e: Not reported
Waste Code f: Not reported
Waste Code g: Not reported
Waste Code 1: Not reported
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 88
Units: Pounds
Number of Containers: 1
Container Type: Metal drums, barrels, kegs

MACY'S EAST #55 (Continued) **S117564976**

Handling Method:	Burn
Specific Gravity:	1
Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	MAD039322250
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	12/11/2015
Trans1 Recv Date:	12/11/2015
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	12/23/2015
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000120329
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	ARD069748192
TSDF ID 2:	Not reported
Manifest Tracking Number:	008795587FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H040
Waste Code a:	Ignitable Waste
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	100
Units:	Pounds
Number of Containers:	1
Container Type:	Metal drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	1
Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	MAD039322250
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	12/11/2015
Trans1 Recv Date:	12/11/2015

MACY'S EAST #55 (Continued) **S117564976**

Trans2 Recv Date:	Not reported
TSD Site Recv Date:	12/23/2015
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000120329
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	ARD069748192
TSDF ID 2:	Not reported
Manifest Tracking Number:	008795587FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H040
Waste Code a:	Corrosive Waste
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	120
Units:	Pounds
Number of Containers:	2
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	1
Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	MAD039322250
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	12/11/2015
Trans1 Recv Date:	12/11/2015
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	12/23/2015
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000120329
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	ARD069748192
TSDF ID 2:	Not reported
Manifest Tracking Number:	008795587FLE

MACY'S EAST #55 (Continued) **S117564976**

Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H040
Waste Code a:	Corrosive Waste
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	300
Units:	Pounds
Number of Containers:	1
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	1

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	MAD039322250
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	12/11/2015
Trans1 Recv Date:	12/11/2015
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	12/23/2015
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000120329
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	ARD069748192
TSDF ID 2:	Not reported
Manifest Tracking Number:	008795587FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported

MACY'S EAST #55 (Continued) **S117564976**

MGMT Method Type Code:	H040
Waste Code a:	Corrosive Waste
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	335
Units:	Pounds
Number of Containers:	3
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	1

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	MAD039322250
Year:	2018
Trans2 State ID:	ALD067138891
Generator Ship Date:	12/11/2015
Trans1 Recv Date:	12/11/2015
Trans2 Recv Date:	12/16/2015
TSD Site Recv Date:	12/22/2015
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000120329
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	OHD000816629
TSDF ID 2:	Not reported
Manifest Tracking Number:	008795589FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H141
Waste Code a:	Corrosive Waste
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported

MACY'S EAST #55 (Continued) **S117564976**

Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	130
Units:	Pounds
Number of Containers:	1
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	1

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	MAD039322250
Year:	2018
Trans2 State ID:	MAD039322250
Generator Ship Date:	01/09/2009
Trans1 Recv Date:	01/09/2009
Trans2 Recv Date:	01/12/2009
TSD Site Recv Date:	01/15/2009
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000120329
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	ARD069748192
TSDF ID 2:	Not reported
Manifest Tracking Number:	002277403FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H040
Waste Code a:	Ignitable Waste
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	400
Units:	Pounds
Number of Containers:	2
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	1

MACY'S EAST #55 (Continued) **S117564976**

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	MAD039322250
Year:	2018
Trans2 State ID:	MAD039322250
Generator Ship Date:	12/14/2012
Trans1 Recv Date:	12/14/2012
Trans2 Recv Date:	12/14/2012
TSD Site Recv Date:	01/02/2013
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000120329
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	ARD069748192
TSDF ID 2:	Not reported
Manifest Tracking Number:	005594008FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H040
Waste Code a:	Ignitable Waste
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	300
Units:	Pounds
Number of Containers:	2
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	1

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	MAD039322250
Year:	2018
Trans2 State ID:	NJD071629976
Generator Ship Date:	07/11/2008
Trans1 Recv Date:	07/11/2008
Trans2 Recv Date:	07/11/2008
TSD Site Recv Date:	07/14/2008
Part A Recv Date:	Not reported

MACY'S EAST #55 (Continued) **S117564976**

Part B Recv Date:	Not reported
Generator EPA ID:	NYR000120329
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NCD000648451
TSDF ID 2:	Not reported
Manifest Tracking Number:	002078826FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H141
Waste Code a:	Ignitable Waste
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	95
Units:	Pounds
Number of Containers:	1
Container Type:	Metal drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	1
Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	MAD039322250
Year:	2018
Trans2 State ID:	NJD071629976
Generator Ship Date:	07/11/2008
Trans1 Recv Date:	07/11/2008
Trans2 Recv Date:	07/11/2008
TSD Site Recv Date:	07/14/2008
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000120329
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NCD000648451
TSDF ID 2:	Not reported
Manifest Tracking Number:	002078826FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N

MACY'S EAST #55 (Continued) **S117564976**

Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H141
Waste Code a:	Ignitable Waste
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	190
Units:	Pounds
Number of Containers:	2
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	1

Document ID:	NYC7506448
Manifest Status:	Not reported
Trans1 State ID:	NY41344JF
Year:	2005
Trans2 State ID:	NH334
Generator Ship Date:	03/29/2005
Trans1 Recv Date:	03/29/2005
Trans2 Recv Date:	04/06/2005
TSD Site Recv Date:	04/13/2005
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000120329
Trans1 EPA ID:	TXR000050930
Trans2 EPA ID:	NJD986607380
TSDF ID 1:	KYD053348108
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Ignitable Waste
Waste Code 2:	Not reported

MACY'S EAST #55 (Continued) **S117564976**

Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00600
Units:	Pounds
Number of Containers:	002
Container Type:	Metal drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00

Click this hyperlink while viewing on your computer to access
37 additional NY MANIFEST: record(s) in the EDR Site Report.

A20 **MACYS - WHITE PLAINS GALLERIA AT WHITE PLAINS** **FINDS** **1007217088**
Target **100 MAIN ST** **ECHO** **N/A**
Property **WHITE PLAINS, NY 10601**

Site 20 of 30 in cluster A

Actual:
197 ft.

FINDS:
Registry ID: 110016725748

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:
The Resource Conservation and Recovery Act Information System (RCRAInfo) is EPA's comprehensive information system in support of the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. It tracks many types of information about generators, transporters, treaters, storers, and disposers of hazardous waste.

Click this hyperlink while viewing on your computer to access
additional FINDS: detail in the EDR Site Report.

ECHO:

Envid:	1007217088
Registry ID:	110016725748

DFR URL:

Name:	MACYS - WHITE PLAINS GALLERIA AT WHITE PLAINS
Address:	100 MAIN ST
City,State,Zip:	WHITE PLAINS, NY 10601

A21 **THE GALLERIA AT WHITE PLAINS** **NY UST** **U004441924**
Target **100 MAIN STREET** **N/A**
Property **WHITE PLAINS, NY 10601**

Site 21 of 30 in cluster A

Actual:
197 ft.

WESTCHESTER CO. UST:

Name:	THE GALLERIA AT WHITE PLAINS
Address:	100 MAIN STREET
City,State,Zip:	WHITE PLAINS, NY 10601
Id/Status:	3-492205 / Unregulated: <1101 gal. PBS

THE GALLERIA AT WHITE PLAINS (Continued) **U004441924**

Operator Name:	Cf White Plains Assoc.
Owner Name:	Cf White Plains Assoc.
Owner Street:	100 Main Street
Owner Address2:	Not reported
Owner City:	White Plains
Owner State:	NY
Owner Zipcode:	10601
GDS Number:	Not reported

Tank Number:	1
Status:	4. Closed - in place
Capacity:	10000
Product Stored:	Not reported
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	09/01/1980
Date Perm Closure:	10/03/1998
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	0. No Pipiing
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Overfill Prevention:	Not reported
Piping Secondary Containment:	Not reported
Spill Prevention:	Not reported
Dispenser:	2. Suction

Tank Number:	2
Status:	4. Closed - in place
Capacity:	10000
Product Stored:	Not reported
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	09/01/1980
Date Perm Closure:	10/03/1998
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	0. No Pipiing
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Overfill Prevention:	Not reported
Piping Secondary Containment:	Not reported
Spill Prevention:	Not reported
Dispenser:	2. Suction

A22 **BISCARDI FRANK** **EDR Hist Cleaner** **1019940041**
102 MAIN ST **N/A**
< 1/8 **WHITE PLAINS, NY 10601**
1 ft.

Site 22 of 30 in cluster A

Relative: EDR Hist Cleaner
Higher

Actual:
198 ft.

Year:	Name:	Type:
1971	BISCARDI FRANK	Drycleaning Plants, Except Rugs
1972	BISCARDI FRANK	Drycleaning Plants, Except Rugs
1973	BISCARDI FRANK	Drycleaning Plants, Except Rugs
1974	BISCARDI FRANK	Drycleaning Plants, Except Rugs
1975	BISCARDI FRANK	Drycleaning Plants, Except Rugs

A23 **BAYLISS MORRIS** **EDR Hist Cleaner** **1019935948**
90 MAIN ST **N/A**
< 1/8 **WHITE PLAINS, NY 10601**
1 ft.

Site 23 of 30 in cluster A

Relative: EDR Hist Cleaner
Higher

Actual:
199 ft.

Year:	Name:	Type:
1969	BAYLISS MORRIS	Drycleaning Plants, Except Rugs
1970	BAYLISS MORRIS	Drycleaning Plants, Except Rugs
1971	BAYLISS MORRIS	Drycleaning Plants, Except Rugs

B24 **VAULT #0070** **NY Spills** **S104282831**
ENE **MAIN ST & GROVE ST** **N/A**
< 1/8 **WHITE PLAINS, NY**
0.003 mi.
15 ft.

Site 1 of 18 in cluster B

Relative: SPILLS:
Lower

Actual:
191 ft.

Name:	VAULT #0070
Address:	MAIN ST & GROVE ST
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9908279 / 1999-10-07
Facility ID:	9908279
Facility Type:	ER
DER Facility ID:	150615
Site ID:	179454
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	C4
SWIS:	6017
Spill Date:	1999-10-07
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1999-10-07
CID:	252
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Responsible Party
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported

VAULT #0070 (Continued) **S104282831**

Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	1999-10-07
Spill Record Last Update:	2004-03-17
Spiller Name:	JOE DEVOTI
Spiller Company:	CON ED VAULT #0070
Spiller Address:	MAIN ST & GROVE ST
Spiller Company:	001
Contact Name:	JOE DEVOTI
Latitude:	41.0321060
Longitude:	-73.7697950
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY
Remarks:	WILL FOLLOW UP TOMORROW. CON E D#128310

All Materials:

Site ID:	179454
Operable Unit ID:	1086946
Operable Unit:	01
Material ID:	300955
Material Code:	0020A
Material Name:	transformer oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

B25 **CON EDISON MANHOLE 9763** **RCRA NonGen / NLR** **1014919130**
ENE **MAIN ST & MARTIN LUTHER KING** **NYP004232856**
< 1/8 **WHITE PLAINS, NY 10601**
0.003 mi.
15 ft. **Site 2 of 18 in cluster B**

Relative: **Lower**

Actual: **191 ft.**

RCRA Listings:

Date Form Received by Agency:	20110428
Handler Name:	Con Edison Manhole 9763
Handler Address:	Main St & Martin Luther King
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYP004232856
Contact Name:	GINO FRABASILE
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	914-925-6219
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	SR SPECIALIST
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported

CON EDISON MANHOLE 9763 (Continued) **1014919130**

State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PLAZA RM 828
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20111026
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20110329
Handler Name:	CON EDISON MANHOLE 9763
Federal Waste Generator Description:	Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No

CON EDISON MANHOLE 9763 (Continued) **1014919130**

Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20110428
Handler Name:	CON EDISON MANHOLE 9763
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

List of NAICS Codes and Descriptions:

NAICS Codes:	No NAICS Codes Found

Facility Has Received Notices of Violations:

Violations:	No Violations Found

Evaluation Action Summary:

Evaluations:	No Evaluations Found

B26 **WHITE PLAINS GARAGE** **NY Spills** **S102151755**
ENE **MAIN ST & GROVE ST** **N/A**
< 1/8 **WHITE PLAINS, NY**
0.003 mi.
15 ft. **Site 3 of 18 in cluster B**

Relative: **Lower**
Actual: **191 ft.**

SPILLS:

Name:	WHITE PLAINS GARAGE
Address:	MAIN ST & GROVE ST
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9110939 / 1992-01-24
Facility ID:	9110939
Facility Type:	ER
DER Facility ID:	150615
Site ID:	179453
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	Not reported
SWIS:	6017
Spill Date:	1992-01-22
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1992-01-22
CID:	Not reported
Water Affected:	Not reported

WHITE PLAINS GARAGE (Continued) **S102151755**

Spill Source:	Institutional, Educational, Gov., Other
Spill Notifier:	Other
Cleanup Ceased:	1953-06-18
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	1992-01-24
Spill Record Last Update:	1993-12-09
Spiller Name:	Not reported
Spiller Company:	SAME
Spiller Address:	Not reported
Spiller Company:	999
Contact Name:	Not reported
Latitude:	41.0321060
Longitude:	-73.7697950
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY
Remarks:	PLUGGED VENT TANK OVERFLOWED TO PAVED AREA DRIVER APPLIED SPEEDI-DRY AND WILL DISPOSE

All Materials:

Site ID:	179453
Operable Unit ID:	964739
Operable Unit:	01
Material ID:	416013
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	1.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

A27 **NYNEX** **UST FINDER RELEASE** **1029064367**
NNE **111 MAIN ST** **N/A**
< 1/8 **WHITE PLAINS, NY 0**
0.006 mi.
31 ft. **Site 24 of 30 in cluster A**

Relative:
Lower

Actual:
192 ft.

UST FINDER RELEASE:

Object ID:	262383
Facility ID:	NY196913
Lust ID:	NY9609101
Name:	NYNEX
Address:	111 MAIN ST
City,State,Zip:	WHITE PLAINS, NY 0
Address Match Type:	Not reported
Reported Date:	1996/10/21 15:59:59+00
Status:	No Further Action
Substance:	Not reported
Population within 1500ft:	3317
Domestic Wells within 1500ft:	0
Land Use:	Developed, High Intensity

NYNEX (Continued) **1029064367**

Within SPA:	Yes
SPA PWS Facility ID:	NY7003493_76968
SPA Water Type:	SW - SurRELEASEe Water
SPA Facility Type:	RS - Reservoir
SPA HUC12:	20301020103
Within WHPA:	No
WHPA PWS Facility ID:	Not reported
WHPA Water Type:	Not reported
WHPA Facility Type:	Not reported
WHPA HUC12:	Not reported
Within 100yr Floodplain:	No
Tribe:	Not reported
EPA Region:	2
NFA Letter 1:	Not reported
NFA Letter 2:	Not reported
NFA Letter 3:	Not reported
NFA Letter 4:	Not reported
Closed With Residual Contaminate:	Not reported
Coordinate Source:	State
X Coord:	-73.7703299999999
Y Coord:	41.0321200000001
Latitude:	41.0321199999999
Longitude:	-73.77033

A28 **NYNEX** **NY LTANKS** **S101102877**
NNE **111 MAIN ST** **NY Spills** **N/A**
< 1/8 **WHITE PLAINS, NY**
0.006 mi.
31 ft. **Site 25 of 30 in cluster A**

Relative: **Lower**
Actual: **192 ft.**

LTANKS:

Name:	NY TEL
Address:	111 EAST MAIN STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9314933 / 1995-03-01
Facility ID:	9314933
Site ID:	145113
Spill Date:	1994-03-21
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	C3
Cleanup Ceased:	1995-03-01
SWIS:	6017
Investigator:	WXWADSWO
Referred To:	Not reported
Reported to Dept:	1994-03-21
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	True
Remediation Phase:	0
Date Entered In Computer:	1994-03-22
Spill Record Last Update:	1995-03-09
Spiller Name:	Not reported
Spiller Company:	Not reported

NYNEX (Continued) **S101102877**

Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	123666
Latitude:	41.0321204
Longitude:	-73.7703302
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was WADSWORTH 09/27/95: This is additional information about material spilled from the translation of the old spill file: TANK TEST.
Remarks:	E I R UST 2000

All TTF:

Facility ID:	9314933
Spill Number:	9314933
Spill Tank Test:	1542517
Site ID:	145113
Tank Number:	Not reported
Tank Size:	0
Material:	0008
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	145113
Operable Unit ID:	993211
Operable Unit:	01
Material ID:	386709
Material Code:	0008
Material Name:	diesel
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	Not reported
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

Name:	NYNEX
Address:	111 MAIN ST
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9609101 / 1999-11-26
Facility ID:	9609101
Site ID:	239422
Spill Date:	1996-10-21
Spill Cause:	Tank Failure

NYNEX (Continued) **S101102877**

Spill Source:	Commercial/Industrial
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1996-10-21
CID:	365
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	True
Remediation Phase:	0
Date Entered In Computer:	1996-10-21
Spill Record Last Update:	1999-12-06
Spiller Name:	Not reported
Spiller Company:	NYNEX
Spiller Address:	111 MAIN ST
Spiller County:	001
Spiller Contact:	CALLER
Spiller Phone:	(914) 793-5200
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	196913
Latitude:	41.0321204
Longitude:	-73.7703302
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY 11/26/99 FEBRUARY 1998 TANK CLOSURE REPORT PREPARED BY S&W SERVICES DOCUMENTING TWO 20K DIESEL TANK REMOVALS. HAS BEEN REVIEWED. 524.7 TONS OF CONTAMINATED SOIL REMOVED. NFA
Remarks:	DURING REMOVAL OF TWO TANKS THEY FOUND CONTAMINATED SOIL UNDER THE SECOND TANK

All Materials:

Site ID:	239422
Operable Unit ID:	1040314
Operable Unit:	01
Material ID:	344831
Material Code:	0008
Material Name:	diesel
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

SPILLS:

Name:	BELL ATLANTIC
Address:	111 MAIN ST
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9808850 / 1998-10-16
Facility ID:	9808850

NYNEX (Continued) **S101102877**

Facility Type:	ER
DER Facility ID:	196913
Site ID:	239423
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	C4
SWIS:	6017
Spill Date:	1998-10-15
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1998-10-16
CID:	384
Water Affected:	Not reported
Spill Source:	Institutional, Educational, Gov., Other
Spill Notifier:	Other
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	1998-10-16
Spill Record Last Update:	1998-10-21
Spiller Name:	TOM OBRIEN
Spiller Company:	BELL ATLANTIC
Spiller Address:	111 MAIN ST
Spiller Company:	001
Contact Name:	TOM OBRIEN
Latitude:	41.0321204
Longitude:	-73.7703302
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY
Remarks:	RUPTURE IN THE LINE CAUSED SPILL ON THE 5TH FLOOR OF BLDG. UNSURE IF IT GOT INTO STORM DRAIN.

All Materials:

Site ID:	239423
Operable Unit ID:	1066233
Operable Unit:	01
Material ID:	566481
Material Code:	0028A
Material Name:	ethylene glycol
Case No.:	00107211
Material FA:	Hazardous Material
Quantity:	700.00
Units:	G
Recovered:	700.00
Resource Affected:	Soil
Oxygenate:	Not reported

A29 **VERIZON COMMUNICATIONS - WHITE PLAINS** **NY AST** **S121490362**
NNE **111 MAIN ST** **NY AIRS** **N/A**
< 1/8 **WHITE PLAINS, NY 10601**
0.006 mi.
31 ft. **Site 26 of 30 in cluster A**

Relative:
Lower

Actual:
192 ft.

WESTCHESTER CO. AST:

Name:	VERIZON NEW YORK, INC.
Address:	111 MAIN STREET
City,State,Zip:	WHITE PLAINS, NY 10601
PBS Number:	3-184713
Site Status:	Active
GDS Number:	Not reported
Operator Name:	Verizon New York Inc.
Owner Name:	Verizon New York, Inc.
Owner Street:	140 West Street
Owner Address2:	Not reported
Owner City/State/Zip:	New York, NY 10007
Tank Number:	3
Status:	1. In-Service
Date Installation:	01/01/1972
Capacity:	275
Product Stored:	0008. Diesel
Product Stored Percent:	Not reported
Date Perm Closure:	01/01/1900
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Leak Detection:	1. Electronic Interstitial Monitoring
Tank Secondary Containment:	1. Diking (aboveground only)
Piping Location:	1. Aboveground
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	0. None
Piping Leak Detection:	0. None
Piping Secondary Containment:	0. None
Overfill Prevention:	3. Automatic Shut-off,4. Product Level Gauge (Aboveground Only)
Spill Prevention:	0. None
Dispenser:	2. Suction
Tank Number:	4
Status:	3. Closed - Removed
Date Installation:	01/01/1972
Capacity:	275
Product Stored:	0008. Diesel
Product Stored Percent:	Not reported
Date Perm Closure:	03/30/2016
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Leak Detection:	Not reported
Tank Secondary Containment:	1. Diking (aboveground only)
Piping Location:	1. Aboveground
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	0. None
Piping Leak Detection:	Not reported

VERIZON COMMUNICATIONS - WHITE PLAINS (Continued) **S121490362**

Piping Secondary Containment: Not reported
Overfill Prevention: 3. Automatic Shut-off,4. Product Level Gauge (Aboveground Only)
Spill Prevention: Not reported
Dispenser: 2. Suction

AIRS:
Name: VERIZON COMMUNICATIONS - WHITE PLAINS
Address: 111 MAIN ST
City,State,Zip: WHITE PLAINS, NY 10601
DECID: 3551700274
Process ID: Not reported
Latitude: 41.032618985
Longitude: 73.770618361
FIPS Code: Not reported
Auth Type Code: ASF

Permit Status: Expired
Auth Status Code: Not reported
Emissions: Not reported
Issue date: 09/04/2012
Expired Date: 09/05/2012
Emission Unit date: Not reported
Contamination: Not reported
EPA Control Code: Not reported
Control Eff: Not reported
Unit: Not reported

Permit Status: Expired
Auth Status Code: Not reported
Emissions: Not reported
Issue date: 10/03/2001
Expired Date: 09/04/2012
Emission Unit date: Not reported
Contamination: Not reported
EPA Control Code: Not reported
Control Eff: Not reported
Unit: Not reported

Permit Status: Expired
Auth Status Code: Not reported
Emissions: Not reported
Issue date: 07/01/2009
Expired Date: 09/04/2012
Emission Unit date: Not reported
Contamination: Not reported
EPA Control Code: Not reported
Control Eff: Not reported
Unit: Not reported

Permit Status: Issued
Auth Status Code: 2
Emissions: Not reported
Issue date: 03/02/2016
Expired Date: 03/01/2026
Emission Unit date: Not reported
Contamination: Not reported
EPA Control Code: Not reported

VERIZON COMMUNICATIONS - WHITE PLAINS (Continued) **S121490362**

Control Eff:	Not reported
Unit:	Not reported
Permit Status:	Expired
Auth Status Code:	7
Emissions:	Not reported
Issue date:	09/27/2000
Expired Date:	10/02/2001
Emission Unit date:	Not reported
Contamination:	Not reported
EPA Control Code:	Not reported
Control Eff:	Not reported
Unit:	Not reported
Permit Status:	Expired
Auth Status Code:	7
Emissions:	Not reported
Issue date:	09/04/2012
Expired Date:	03/01/2016
Emission Unit date:	Not reported
Contamination:	Not reported
EPA Control Code:	Not reported
Control Eff:	Not reported
Unit:	Not reported

A30 **VERIZON NEW YORK, INC.** **NY UST** **U004442141**
NNE **111 MAIN STREET** **N/A**
< 1/8 **WHITE PLAINS, NY 10601**
0.006 mi.
31 ft. **Site 27 of 30 in cluster A**

Relative: **Lower**
Actual: **192 ft.**

WESTCHESTER CO. UST:

Name:	VERIZON NEW YORK, INC.
Address:	111 MAIN STREET
City,State,Zip:	WHITE PLAINS, NY 10601
Id/Status:	3-184713 / Active
Operator Name:	Verizon New York Inc.
Owner Name:	Verizon New York, Inc.
Owner Street:	140 West Street
Owner Address2:	Not reported
Owner City:	New York
Owner State:	NY
Owner Zipcode:	10007
GDS Number:	Not reported
Tank Number:	1
Status:	3. Closed - Removed
Capacity:	20000
Product Stored:	0008. Diesel
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	01/01/1972
Date Perm Closure:	10/01/1996
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Secondary Containment:	0. None

VERIZON NEW YORK, INC. (Continued) **U004442141**

Piping Location:	2. Underground/on ground
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Overfill Prevention:	Not reported
Piping Secondary Containment:	Not reported
Spill Prevention:	Not reported
Dispenser:	2. Suction

Tank Number:	2
Status:	3. Closed - Removed
Capacity:	20000
Product Stored:	0008. Diesel
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	01/01/1972
Date Perm Closure:	10/01/1996
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Secondary Containment:	0. None
Piping Location:	2. Underground/on ground
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Overfill Prevention:	Not reported
Piping Secondary Containment:	Not reported
Spill Prevention:	Not reported
Dispenser:	2. Suction

Tank Number:	5
Status:	1. In-Service
Capacity:	20000
Product Stored:	0008. Diesel
Product Stored Percent:	Not reported
Tank Leak Detection:	1. Electronic Interstitial Monitoring
Date Installation:	10/01/1996
Date Perm Closure:	01/01/1900
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	6. Fiberglass reinforced plastic (FRP)
Tank Internal Protection:	0. None
Tank External Protection:	4. Fiberglass
Tank Secondary Containment:	4. Double-Walled (underground only)
Piping Location:	3. Aboveground/Underground Combination
Piping Type:	11. Flexible Piping
Piping External Protection:	5. Jacketed
Overfill Prevention:	2. High Level Alarm
Piping Secondary Containment:	4. Double-Walled (underground only)
Spill Prevention:	1. Catch Basin
Dispenser:	2. Suction

Tank Number:	6
Status:	1. In-Service
Capacity:	20000
Product Stored:	0008. Diesel

VERIZON NEW YORK, INC. (Continued) **U004442141**

Product Stored Percent:	Not reported
Tank Leak Detection:	1. Electronic Interstitial Monitoring
Date Installation:	10/01/1996
Date Perm Closure:	01/01/1900
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	6. Fiberglass reinforced plastic (FRP)
Tank Internal Protection:	0. None
Tank External Protection:	4. Fiberglass
Tank Secondary Containment:	4. Double-Walled (underground only)
Piping Location:	3. Aboveground/Underground Combination
Piping Type:	11. Flexible Piping
Piping External Protection:	5. Jacketed
Overfill Prevention:	2. High Level Alarm
Piping Secondary Containment:	4. Double-Walled (underground only)
Spill Prevention:	1. Catch Basin
Dispenser:	2. Suction

A31 **NYNEX MATERIEL ENTERPRISES CO** **RCRA NonGen / NLR** **1000225769**
NNE **111 MAIN ST** **NY MANIFEST** **NYD980582480**
< 1/8 **WHITE PLAINS, NY 10601**
0.006 mi.
31 ft. **Site 28 of 30 in cluster A**

Relative: **Lower**
Actual: **192 ft.**

RCRA Listings:

Date Form Received by Agency:	20070101
Handler Name:	Nynex Materiel Enterprises Co
Handler Address:	Main St
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYD980582480
Contact Name:	Not reported
Contact Address:	NINTH AVE
Contact City,State,Zip:	NEW YORK, NY 10001
Contact Telephone:	Not reported
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Not reported
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R3
Mailing Address:	NINTH AVE
Mailing City,State,Zip:	NEW YORK, NY 10001
Owner Name:	New York Telephone Co
Owner Type:	Private
Operator Name:	New York Telephone Co
Operator Type:	Private
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No

NYNEX MATERIEL ENTERPRISES CO (Continued) **1000225769**

Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20150414
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Hazardous Waste Summary:

Waste Code:	D000
Waste Description:	Not Defined
Waste Code:	D002
Waste Description:	Corrosive Waste
Waste Code:	D003
Waste Description:	Reactive Waste

Handler - Owner Operator:

Owner/Operator Indicator:	Operator
Owner/Operator Name: NEW YORK TELEPHONE CO	
Legal Status:	Private
Date Became Current:	Not reported
Date Ended Current:	Not reported
Owner/Operator Address:	NOT REQUIRED
Owner/Operator City,State,Zip:	NOT REQUIRED, WY 99999
Owner/Operator Telephone:	212-555-1212
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported

NYNEX MATERIEL ENTERPRISES CO (Continued) **1000225769**

Owner/Operator Email: Not reported

Owner/Operator Indicator: Owner
Owner/Operator Name: NEW YORK TELEPHONE CO
Legal Status: Private
Date Became Current: Not reported
Date Ended Current: Not reported
Owner/Operator Address: NOT REQUIRED
Owner/Operator City,State,Zip: NOT REQUIRED, WY 99999
Owner/Operator Telephone: 212-555-1212
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Owner
Owner/Operator Name: NEW YORK TELEPHONE CO
Legal Status: Private
Date Became Current: Not reported
Date Ended Current: Not reported
Owner/Operator Address: NOT REQUIRED
Owner/Operator City,State,Zip: NOT REQUIRED, WY 99999
Owner/Operator Telephone: 212-555-1212
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Historic Generators:
Receive Date: 19990708
Handler Name: NYNEX MATERIEL ENTERPRISES CO
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20060101
Handler Name: NYNEX MATERIEL ENTERPRISES CO
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20070101
Handler Name: NYNEX MATERIEL ENTERPRISES CO
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny

NYNEX MATERIEL ENTERPRISES CO (Continued) **1000225769**

Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 19810325
Handler Name: NYNEX MATERIEL ENTERPRISES CO
Federal Waste Generator Description: Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

NY MANIFEST:
EPA ID: NYD980582480
Country: USA
Name: New York Telephone Company
Address: 111 MAIN ST
Address 2: Not reported
City,State,Zip: WHITE PLAINS, NY 10601
Zip 4: Not reported
Location Address 1: 111 MAIN STREET
Location Address 2: Not reported
Location City,State,Zip: WHITE PLAINS, NY 10601
Location Zip 4: Not reported
Facility Status: Not reported
Total Tanks: Not reported
Code: BP

Mailing:
Mailing Name: New York Telephone Company
Mailing Contact: New York Telephone Company
Mailing Address 1: 111 MAIN STREET
Mailing Address 2: Not reported
Mailing City,State,Zip: WHITE PLAINS, NY 10601
Mailing Zip 4: Not reported
Mailing Country: USA

NYNEX MATERIEL ENTERPRISES CO (Continued) **1000225769**

Mailing Phone: 0000000000

Manifest Data:
Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: NJD003812047
Year: 2018
Trans2 State ID: Not reported
Generator Ship Date: 10/08/2008
Trans1 Recv Date: 10/08/2008
Trans2 Recv Date: Not reported
TSD Site Recv Date: 10/09/2008
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYD980582480
Trans1 EPA ID: Not reported
Trans2 EPA ID: Not reported
TSDF ID 1: NJD002200046
TSDF ID 2: Not reported
Manifest Tracking Number: 000405185GBF
Import Indicator: N
Export Indicator: N
Discr Quantity Indicator: N
Discr Type Indicator: N
Discr Residue Indicator: N
Discr Partial Reject Indicator: N
Discr Full Reject Indicator: N
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: H061
Waste Code a: Ignitable Waste
Waste Code b: Not reported
Waste Code c: Not reported
Waste Code e: Not reported
Waste Code f: Not reported
Waste Code g: Not reported
Waste Code 1: Not reported
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 700
Units: Pounds
Number of Containers: 1
Container Type: Fiber or plastic boxes, cartons, cases
Handling Method: Burn
Specific Gravity: 1

Document ID: NJA3036538
Manifest Status: Not reported
Trans1 State ID: 17446
Year: 1999
Trans2 State ID: S50060
Generator Ship Date: 08/25/1999
Trans1 Recv Date: 08/25/1999

NYNEX MATERIEL ENTERPRISES CO (Continued) **1000225769**

Trans2 Recv Date:	08/25/1999
TSD Site Recv Date:	09/10/1999
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD980582480
Trans1 EPA ID:	NYD980761191
Trans2 EPA ID:	NYD980761191
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	The Following Spent Halogenated Solvents Used In Degreasing: Tetrachloroethylene, Trichlorethylene, Methylene Chloride, 1,1,1-Trichloroethane, Carbon Tetrachloride And Chlorinated Fluorocarbons; All Spent Solvent Mixtures/Blends Used In Degreasing Containing, Before Use, A Total Of Ten Percent Or More (By Volume) Of One Or More Of The Above Halogenated Solvents Or Those Solvents Listed In F002, F004, And F005; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent Mixtures.
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00095
Units:	Gallons (liquids only)
Number of Containers:	001
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00
Waste Code 7:	The Following Spent Halogenated Solvents Used In Degreasing: Tetrachloroethylene, Trichlorethylene, Methylene Chloride, 1,1,1-Trichloroethane, Carbon Tetrachloride And Chlorinated Fluorocarbons; All Spent Solvent Mixtures/Blends Used In Degreasing Containing, Before Use, A Total Of Ten Percent Or More (By Volume) Of One Or More Of The Above Halogenated Solvents Or Those Solvents Listed In F002, F004, And F005; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent Mixtures.
Waste Code 8:	Not reported
Waste Code:	Not reported
Waste Code 10:	Not reported
Waste Code 11:	Not reported
Quantity:	00055
Units:	Gallons (liquids only)
Number of Containers:	001
Container Type:	Metal drums, barrels, kegs
Handling Method:	Burn

NYNEX MATERIEL ENTERPRISES CO (Continued) **1000225769**

Specific Gravity: 01.00

Document ID: MAF0000280
Manifest Status: Not reported
Trans1 State ID: XR77HC-NJ
Year: 1990
Trans2 State ID: Not reported
Generator Ship Date: 06/04/1990
Trans1 Recv Date: 06/04/1990
Trans2 Recv Date: Not reported
TSD Site Recv Date: 06/06/1990
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYD980582480
Trans1 EPA ID: MAD039322250
Trans2 EPA ID: Not reported
TSDF ID 1: MAD053452637
TSDF ID 2: Not reported
Manifest Tracking Number: Not reported
Import Indicator: Not reported
Export Indicator: Not reported
Discr Quantity Indicator: Not reported
Discr Type Indicator: Not reported
Discr Residue Indicator: Not reported
Discr Partial Reject Indicator: Not reported
Discr Full Reject Indicator: Not reported
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: Not reported
Waste Code 1: B002
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 00417
Units: Kilograms
Number of Containers: 002
Container Type: Metal drums, barrels, kegs
Handling Method: Burn
Specific Gravity: 01.00

Document ID: ARA1613530
Manifest Status: K - Completed after the designated time
Trans1 State ID: U65765
Year: 1987
Trans2 State ID: Not reported
Generator Ship Date: 870622
Trans1 Recv Date: 870622
Trans2 Recv Date: Not reported
TSD Site Recv Date: 870625
Part A Recv Date: 870722
Part B Recv Date: 870709
Generator EPA ID: NYD980582480
Trans1 EPA ID: NYD980769947
Trans2 EPA ID: Not reported

NYNEX MATERIEL ENTERPRISES CO (Continued) **1000225769**

TSDF ID 1:	ARP000404000
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	B007
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00179
Units:	Pounds
Number of Containers:	001
Container Type:	Metal drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	100

Document ID:	NYA1607553
Manifest Status:	K - Completed after the designated time
Trans1 State ID:	NY9875GA
Year:	1985
Trans2 State ID:	Not reported
Generator Ship Date:	850614
Trans1 Recv Date:	850614
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	850614
Part A Recv Date:	850716
Part B Recv Date:	850716
Generator EPA ID:	NYD980582480
Trans1 EPA ID:	NYD980647820
Trans2 EPA ID:	Not reported
TSDF ID 1:	NYD980647820
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	B007
Waste Code 2:	Not reported

NYNEX MATERIEL ENTERPRISES CO (Continued) **1000225769**

Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00220
Units:	Pounds
Number of Containers:	001
Container Type:	Metal drums, barrels, kegs
Handling Method:	Landfill
Specific Gravity:	100

A32 **NY TEL** **UST FINDER RELEASE** **1029058356**
NNE **111 EAST MAIN STREET** **N/A**
< 1/8 **WHITE PLAINS, NY 0**
0.006 mi.
31 ft. **Site 29 of 30 in cluster A**

Relative: **Lower**
Actual: **192 ft.**

UST FINDER RELEASE:

Object ID:	262382
Facility ID:	NY123666
Lust ID:	NY9314933
Name:	NY TEL
Address:	111 EAST MAIN STREET
City,State,Zip:	WHITE PLAINS, NY 0
Address Match Type:	Not reported
Reported Date:	1994/03/21 15:59:59+00
Status:	No Further Action
Substance:	Not reported
Population within 1500ft:	3317
Domestic Wells within 1500ft:	0
Land Use:	Developed, High Intensity
Within SPA:	Yes
SPA PWS Facility ID:	NY7003493_76968
SPA Water Type:	SW - SurRELEASEe Water
SPA Facility Type:	RS - Reservoir
SPA HUC12:	20301020103
Within WHPA:	No
WHPA PWS Facility ID:	Not reported
WHPA Water Type:	Not reported
WHPA Facility Type:	Not reported
WHPA HUC12:	Not reported
Within 100yr Floodplain:	No
Tribe:	Not reported
EPA Region:	2
NFA Letter 1:	Not reported
NFA Letter 2:	Not reported
NFA Letter 3:	Not reported
NFA Letter 4:	Not reported
Closed With Residual Contaminate:	Not reported
Coordinate Source:	State
X Coord:	-73.7703299999999
Y Coord:	41.0321200000001
Latitude:	41.0321199999999
Longitude:	-73.77033

C33 **CON EDISON** **RCRA NonGen / NLR** **1014398867**
WNW **81 MAIN ST FRONT OF** **NY MANIFEST** **NYP004212403**
< 1/8 **WHITE PLAINS, NY 10603** **NJ MANIFEST**
0.006 mi.
33 ft. **Site 1 of 15 in cluster C**

Relative: **Higher**

Actual: **200 ft.**

RCRA Listings:

Date Form Received by Agency:	20200413
Handler Name:	Con Edison
Handler Address:	Main St Front Of
Handler City,State,Zip:	WHITE PLAINS, NY 10603
EPA ID:	NYP004212403
Contact Name:	Not reported
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	Not reported
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	Not reported
Mailing City,State,Zip:	Not reported
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No

CON EDISON (Continued) **1014398867**

Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20200413
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20100729
Handler Name: CON EDISON	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20200413
Handler Name: CON EDISON	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	No
Electronic Manifest Broker:	No

List of NAICS Codes and Descriptions:

NAICS Codes:	No NAICS Codes Found

Facility Has Received Notices of Violations:

Violations:	No Violations Found

Evaluation Action Summary:

Evaluations:	No Evaluations Found

CON EDISON (Continued) **1014398867**

NY MANIFEST:

EPA ID:	NYP004212403
Country:	USA
Name:	Consolidated Edison
Address:	81 MAIN ST FRONT OF
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10603
Zip 4:	Not reported
Location Address 1:	MH10094 - F/O 81 MAIN ST LEXINGTON AVE
Location Address 2:	Not reported
Location City,State,Zip:	WHITE PLAINS, NY
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Consolidated Edison
Mailing Contact:	Thomas Teeling
Mailing Address 1:	4 IRVING PL RM 828
Mailing Address 2:	Not reported
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	2124603770

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	07/29/2010
Trans1 Recv Date:	07/29/2010
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	07/29/2010
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004212403
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	006874670JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	Y
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H111
Waste Code a:	Lead
Waste Code b:	Not reported

CON EDISON (Continued) **1014398867**

Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	100
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

NJ MANIFEST:

EPA ID:	NYP004212403
Name:	CON EDISON
Address:	81 MAIN ST FRONT OF
City,State,Zip:	WHITE PLAINS, NY 10603
County:	Not reported
Mailing Address:	4 IRVING PL, RM 828
Mailing City,State,Zip:	NEW YORK, NY 10003
Telephone:	Not reported
Emergency Telephone:	Not reported
Contact:	DENNIS ROHRER
Comments:	Not reported
SIC Code:	Not reported
County:	NY119
Municipal:	Not reported
Previous EPAID:	Not reported
Generator Flag:	Not reported
Transporter Flag:	Not reported
TSDF Flag:	Not reported
Name Change:	Not reported
Date Change:	Not reported

Manifest Data:

EPA ID:	NYP004212403
Manifest Number:	006874670JJK
Date Shipped:	07/29/2010
TSDF EPA ID:	NJD002200046
Transporter EPA ID:	NYD006982359
Transporter 2 EPA ID:	Not reported
Transporter 3 EPA ID:	Not reported
Transporter 4 EPA ID:	Not reported
Transporter 5 EPA ID:	Not reported
Transporter 6 EPA ID:	Not reported
Transporter 7 EPA ID:	Not reported
Transporter 8 EPA ID:	Not reported
Transporter 9 EPA ID:	Not reported
Transporter 10 EPA ID:	Not reported
Date Trans1 Transported Waste:	07/29/2010
Date Trans2 Transported Waste:	Not reported

CON EDISON (Continued) **1014398867**

Date Trans3 Transported Waste:	Not reported
Date Trans4 Transported Waste:	Not reported
Date Trans5 Transported Waste:	Not reported
Date Trans6 Transported Waste:	Not reported
Date Trans7 Transported Waste:	Not reported
Date Trans8 Transported Waste:	Not reported
Date Trans9 Transported Waste:	Not reported
Date Trans10 Transported Waste:	Not reported
Date TSDF Received Waste:	07/29/2010
TSDF EPA Facility Name:	Not reported
QTY Units:	Not reported
Transporter SEQ ID:	Not reported
Transporter-1 Date:	Not reported
Waste SEQ ID:	Not reported
Waste Type Code 2:	Not reported
Waste Type Code 3:	Not reported
Waste Type Code 4:	Not reported
Waste Type Code 5:	Not reported
Waste Type Code 6:	Not reported
Date Accepted:	Not reported
Manifest Discrepancy Type:	Not reported
Data Entry Number:	Not reported
Was Load Rejected:	N
Reason Load Was Rejected:	Not reported

Waste:

Manifest Year:	Not reported
Waste Code:	D008
Hand Code:	H111
Quantity:	100
Unit:	P

A34 **IN FRONT OF GALERIA MALL** **NY Spills** **S103573377**
North **MAIN ST** **N/A**
< 1/8 **WHITE PLAINS, NY**
0.008 mi.
42 ft. **Site 30 of 30 in cluster A**

Relative: **Lower**
Actual: **194 ft.**

SPILLS:

Name:	IN FRONT OF GALERIA MALL
Address:	MAIN ST
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9809244 / 1998-10-23
Facility ID:	9809244
Facility Type:	ER
DER Facility ID:	277118
Site ID:	253722
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	C4
SWIS:	6000
Spill Date:	1998-10-23
Investigator:	jbodee
Referred To:	Not reported
Reported to Dept:	1998-10-23
CID:	322

IN FRONT OF GALERIA MALL (Continued) **S103573377**

Water Affected:	Not reported
Spill Source:	Commercial Vehicle
Spill Notifier:	Responsible Party
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	1998-10-23
Spill Record Last Update:	2002-07-17
Spiller Name:	RAY PEREIRA
Spiller Company:	LIBERTY LINES TRANSIT
Spiller Address:	475 SAWMILL RIVER RD
Spiller Company:	001
Contact Name:	Not reported
Latitude:	41.0373699
Longitude:	-73.7571500
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was O'DEE
Remarks:	fuel line ruptured on truck - spill cleaned up

All Materials:

Site ID:	253722
Operable Unit ID:	1066518
Operable Unit:	01
Material ID:	316701
Material Code:	0008
Material Name:	diesel
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	2.00
Units:	G
Recovered:	2.00
Resource Affected:	Soil
Oxygenate:	Not reported

B35 **A&S STORE** **NY LTANKS** **S100137114**
ENE **GALLERIA PLAZA** **N/A**
< 1/8 **WHITE PLAINS, NY**
0.010 mi.
51 ft. **Site 4 of 18 in cluster B**

Relative: **Lower**

Actual: **193 ft.**

LTANKS:

Name:	A&S STORE
Address:	GALLERIA PLAZA
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8805571 / 1989-03-07
Facility ID:	8805571
Site ID:	187319
Spill Date:	1988-09-29
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	Not reported
Cleanup Ceased:	1989-03-07
SWIS:	6017
Investigator:	tdghiosa

A&S STORE (Continued) **S100137114**

Referred To:	Not reported
Reported to Dept:	1988-09-29
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1988-10-19
Spill Record Last Update:	1989-03-07
Spiller Name:	Not reported
Spiller Company:	SAME
Spiller Address:	Not reported
Spiller County:	999
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	156504
Latitude:	Not reported
Longitude:	Not reported
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY 03/07/89: TANK WAS RELINED AND PUT BACK INTO SERVIVE. 03/07/89: TANK WAS RELINED AND PUT BACK INTO SERVIVE.
Remarks:	-.068 GPH; NO COMMENTS (RETEST). 10K TANK. PBS #173665

All TTF:

Facility ID:	8805571
Spill Number:	8805571
Spill Tank Test:	1534700
Site ID:	187319
Tank Number:	Not reported
Tank Size:	0
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	187319
Operable Unit ID:	920745
Operable Unit:	01
Material ID:	457473
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00

A&S STORE (Continued) **S100137114**

Units: Not reported
Recovered: .00
Resource Affected: Groundwater
Oxygenate: Not reported

B36 **A & S STORE** **NY LTANKS** **S100136963**
ENE **GALLERIA PLAZA** **N/A**
< 1/8 **WHITE PLAINS, NY**
0.010 mi.
51 ft. **Site 5 of 18 in cluster B**

Relative: **Lower**

Actual: **193 ft.**

LTANKS:

Name:	A & S STORE
Address:	GALLERIA PLAZA
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8803673 / 1988-08-09
Facility ID:	8803673
Site ID:	187318
Spill Date:	1988-07-27
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	Not reported
Cleanup Ceased:	1988-08-09
SWIS:	6017
Investigator:	jeokesso
Referred To:	Not reported
Reported to Dept:	1988-07-27
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2003-12-02
Spill Record Last Update:	2003-12-02
Spiller Name:	Not reported
Spiller Company:	DENNIS MURPHY
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	156504
Latitude:	Not reported
Longitude:	Not reported
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was J OKESSON
Remarks:	10K -.155 PBS TO FOLLOW UP. NFA

All TTF:

Facility ID:	8803673
Spill Number:	8803673
Spill Tank Test:	1534356
Site ID:	187318

A & S STORE (Continued) **S100136963**

Tank Number:	Not reported
Tank Size:	0
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	187318
Operable Unit ID:	918836
Operable Unit:	01
Material ID:	459213
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

C37 **CON EDISON MANHOLE: 10087** **RCRA-LQG** **1016451333**
WNW **LEXINGTON AVE & E MAIN ST S** **FINDS** **NYP004303764**
< 1/8 **WHITE PLAINS, NY 10605** **ECHO**
0.011 mi.
60 ft. **Site 2 of 15 in cluster C**

Relative:
Higher

Actual:
201 ft.

RCRA Listings:

Date Form Received by Agency:	20140327
Handler Name:	Con Edison - Manhole 10087
Handler Address:	S. Lexington Ave &Amp; E. Main
Handler City,State,Zip:	WHITE PLAINS, NY 10605
EPA ID:	NYP004303764
Contact Name:	DENNIS HUACON
Contact Address:	IRVING PLACE, 15TH FL NE
Contact City,State,Zip:	NEW YORK, NY 10003
Contact Telephone:	212-460-2757
Contact Fax:	401-765-1500
Contact Email:	HUACOND@CONED.COM
Contact Title:	ASSOCIATE SCIENTIST
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Large Quantity Generator
Non-Notifier:	Not reported
Biennial Report Cycle:	2013
Accessibility:	Not reported
Active Site Indicator:	Handler Activities
State District Owner:	Ny

CON EDISON MANHOLE: 10087 (Continued) **1016451333**

State District:	NYSDEC R3
Mailing Address:	IRVING PLACE, 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Consolidated Edison Company Of Ny, Inc.
Owner Type:	Private
Operator Name:	Consolidated Edison Company Of Ny, Inc.
Operator Type:	Private
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20150414
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Biennial: List of Years
Year: 2013

Click Here for Biennial Reporting System Data:

Hazardous Waste Summary:
Waste Code: D008
Waste Description: Lead

CON EDISON MANHOLE: 10087 (Continued) **1016451333**

Handler - Owner Operator:
Owner/Operator Indicator: Operator
Owner/Operator Name: CONSOLIDATED EDISON COMPANY OF NY, INC.
Legal Status: Private
Date Became Current: 20130422
Date Ended Current: Not reported
Owner/Operator Address: 4 IRVING PLACE
Owner/Operator City,State,Zip: NEW YORK, NY 10003
Owner/Operator Telephone: Not reported
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Owner
Owner/Operator Name: CONSOLIDATED EDISON COMPANY OF NY, INC.
Legal Status: Private
Date Became Current: 20130422
Date Ended Current: Not reported
Owner/Operator Address: 4 IRVING PLACE
Owner/Operator City,State,Zip: NEW YORK, NY 10003
Owner/Operator Telephone: Not reported
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Historic Generators:
Receive Date: 20140327
Handler Name: CON EDISON - MANHOLE 10087
Federal Waste Generator Description: Large Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20130422
Handler Name: CON EDISON MANHOLE: 10087
Federal Waste Generator Description: Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Code: 221122
NAICS Description: Electric Power Distribution

CON EDISON MANHOLE: 10087 (Continued) **1016451333**

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

FINDS:
Registry ID: 110056329414

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:
The Resource Conservation and Recovery Act Information System (RCRAInfo) is EPA's comprehensive information system in support of the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. It tracks many types of information about generators, transporters, treaters, storers, and disposers of hazardous waste.

Click this hyperlink while viewing on your computer to access additional FINDS: detail in the EDR Site Report.

ECHO:
Envid: 1016451333
Registry ID: 110056329414

DFR URL:
Name: CON EDISON MANHOLE: 10087
Address: LEXINGTON AVE & E MAIN ST S
City,State,Zip: WHITE PLAINS, NY 10605

C38 **CON EDISON MANHOLE: 10087** **RCRA NonGen / NLR** **1016677185**
WNW **LEXINGTON AVE & MAIN ST** **NY MANIFEST** **NYP004307484**
< 1/8 **WHITE PLAINS, NY 10602**
0.011 mi.
60 ft. **Site 3 of 15 in cluster C**

Relative: Higher
Actual: 201 ft.

RCRA Listings:
Date Form Received by Agency: 20130606
Handler Name: Con Edison Manhole: 10087
Handler Address: Lexington Ave & Main St
Handler City,State,Zip: WHITE PLAINS, NY 10602
EPA ID: NYP004307484
Contact Name: GINO FRABASILE
Contact Address: Not reported
Contact City,State,Zip: Not reported
Contact Telephone: 914-925-6219
Contact Fax: Not reported
Contact Email: Not reported
Contact Title: SR SPECIALIST
EPA Region: 02
Land Type: Private
Federal Waste Generator Description: Not a generator, verified
Non-Notifier: Not reported
Biennial Report Cycle: Not reported
Accessibility: Not reported

CON EDISON MANHOLE: 10087 (Continued) **1016677185**

Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	VING PL, RM 828
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20140402
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20130506
Handler Name:	CON EDISON MANHOLE: 10087
Federal Waste Generator Description:	Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner:	Ny

CON EDISON MANHOLE: 10087 (Continued) **1016677185**

Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20130606
Handler Name: CON EDISON MANHOLE: 10087
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

NY MANIFEST:
EPA ID: NYP004307484
Country: USA
Name: Con Edison
Address: LEXINGTON AVE & MAIN ST
Address 2: Not reported
City,State,Zip: WHITE PLAINS, NY 10602
Zip 4: Not reported
Location Address 1: LEXINGTON & MAIN ST
Location Address 2: Not reported
Location City,State,Zip: WHITE PLAINS, NY 10601
Location Zip 4: Not reported
Facility Status: Not reported
Total Tanks: Not reported
Code: BP

Mailing:
Mailing Name: Con Edison
Mailing Contact: Con Edison
Mailing Address 1: 4 IRVING PLACE 15TH FLOOR
Mailing Address 2: Not reported
Mailing City,State,Zip: NEW YORK, NY 10003
Mailing Zip 4: Not reported
Mailing Country: USA

CON EDISON MANHOLE: 10087 (Continued) **1016677185**

Mailing Phone: 2124603770

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	05/06/2013
Trans1 Recv Date:	05/06/2013
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	05/13/2013
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004307484
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	007019085JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	150
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

C39 WNW < 1/8 0.011 mi. 60 ft. **CON EDISON VAULT: 70**
MAIN ST & LEXINGTON AVE
WHITE PLAINS, NY 10601

RCRA NonGen / NLR 1016964217
NY MANIFEST NYP004371571

Site 4 of 15 in cluster C

Relative: Higher

Actual: 201 ft.

RCRA Listings:

Date Form Received by Agency:	20131108
Handler Name:	Con Edison Vault: 70
Handler Address:	Main St & Lexington Ave
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYP004371571
Contact Name:	THOMAS TEELING
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	212-460-3770
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	SENIOR SCIENTIST
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PL, 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No

CON EDISON VAULT: 70 (Continued) **1016964217**

Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20140701
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20131008
Handler Name: CON EDISON VAULT: 70	
Federal Waste Generator Description:	Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20131108
Handler Name: CON EDISON VAULT: 70	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

List of NAICS Codes and Descriptions:

NAICS Codes:	No NAICS Codes Found

Facility Has Received Notices of Violations:

Violations:	No Violations Found

Evaluation Action Summary:

Evaluations:	No Evaluations Found

CON EDISON VAULT: 70 (Continued) **1016964217**

NY MANIFEST:

EPA ID:	NYP004371571
Country:	USA
Name:	Con Edison
Address:	MAIN ST & LEXINGTON AVE
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10601
Zip 4:	Not reported
Location Address 1:	MAIN ST & LEXINGTON
Location Address 2:	VS 70
Location City,State,Zip:	WHITE PLAINS, NY 10601
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Edison
Mailing Contact:	Tom Teeling
Mailing Address 1:	4 IRVING PLACE - 15TH FLOOR
Mailing Address 2:	Not reported
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	2124603770

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	10/08/2013
Trans1 Recv Date:	10/08/2013
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	10/11/2013
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004371571
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	011694634JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported

CON EDISON VAULT: 70 (Continued) **1016964217**

Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	200
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

C40 **CON EDISON** **NY MANIFEST** **S119073608**
WNW **S. LEXINGTON AVE & E. MAIN** **N/A**
< 1/8 **WHITE PLAINS, NY 10605**
0.011 mi.
60 ft. **Site 5 of 15 in cluster C**

Relative:
Higher

Actual:
201 ft.

NY MANIFEST:

EPA ID:	NYP004303764
Country:	USA
Name:	Con Edison
Address:	S. LEXINGTON AVE & E. MAIN
Address 2:	ST
City,State,Zip:	WHITE PLAINS, NY 10605
Zip 4:	Not reported
Location Address 1:	S. LEXINGTON AVE & E. MAIN
Location Address 2:	ST
Location City,State,Zip:	WHITE PLAINS, NY 10605
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Edison
Mailing Contact:	Tom Teeling
Mailing Address 1:	CON EDISON
Mailing Address 2:	Not reported
Mailing City,State,Zip:	NEW YORK, NY 10601
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	2124603770

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NJ0000027193
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	04/22/2013
Trans1 Recv Date:	04/22/2013

CON EDISON (Continued) **S119073608**

Trans2 Recv Date:	Not reported
TSD Site Recv Date:	04/24/2013
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004303764
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	010845209JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	4000
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

C41 **CON EDISON** **NY MANIFEST** **S117538117**
WNW **S LEXINGTON AV & MAIN ST** **N/A**
< 1/8 **WHITE PLAINS, NY 10801**
0.011 mi.
60 ft. **Site 6 of 15 in cluster C**

Relative: NY MANIFEST:
Higher

EPA ID:	NYP004707600
Country:	USA
Name:	Con Edison
Address:	S LEXINGTON AV & MAIN ST
Address 2:	MH10087
City,State,Zip:	WHITE PLAINS, NY 10801
Zip 4:	Not reported
Location Address 1:	S LEXINGTON AV & MAIN ST
Location Address 2:	MH10087
Location City,State,Zip:	WHITE PLAINS, NY 10801

Actual:
201 ft.

CON EDISON (Continued) **S117538117**

Location Zip 4: Not reported
Facility Status: Not reported
Total Tanks: Not reported
Code: BP

Mailing:
Mailing Name: Con Edison
Mailing Contact: Con Edison
Mailing Address 1: 4 IRVING PL
Mailing Address 2: 15TH FL
Mailing City,State,Zip: NEW YORK, NY 10003
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: Not reported

Manifest Data:
Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: NYD006982359
Year: 2018
Trans2 State ID: Not reported
Generator Ship Date: 12/17/2014
Trans1 Recv Date: 12/17/2014
Trans2 Recv Date: Not reported
TSD Site Recv Date: 12/18/2014
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYP004707600
Trans1 EPA ID: Not reported
Trans2 EPA ID: Not reported
TSDF ID 1: NJD002200046
TSDF ID 2: Not reported
Manifest Tracking Number: 013244434JJK
Import Indicator: N
Export Indicator: N
Discr Quantity Indicator: N
Discr Type Indicator: N
Discr Residue Indicator: N
Discr Partial Reject Indicator: N
Discr Full Reject Indicator: N
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: H110
Waste Code a: Lead
Waste Code b: Not reported
Waste Code c: Not reported
Waste Code e: Not reported
Waste Code f: Not reported
Waste Code g: Not reported
Waste Code 1: Not reported
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 100

CON EDISON (Continued) **S117538117**

Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

C42 **GATEWAY PLAZA** **NY UST** **U004440242**
WNW **1 NORTH LEXINGTON AVENUE** **N/A**
< 1/8 **WHITE PLAINS, NY 10601**
0.015 mi.
81 ft. **Site 7 of 15 in cluster C**

Relative:
Higher

Actual:
201 ft.

WESTCHESTER CO. UST:

Name:	GATEWAY PLAZA
Address:	1 NORTH LEXINGTON AVENUE
City,State,Zip:	WHITE PLAINS, NY 10601
Id/Status:	3-800106 / Unregulated: <1101 gal. PBS
Operator Name:	Robert Melly
Owner Name:	Cigna C/o Albert B Ashforth Inc
Owner Street:	1 North Lexington Ave
Owner Address2:	Not reported
Owner City:	White Plains
Owner State:	NY
Owner Zipcode:	10601
GDS Number:	Not reported
Tank Number:	1
Status:	0. Administratively closed
Capacity:	10000
Product Stored:	Not reported
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	11/01/1984
Date Perm Closure:	05/01/2003
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	2. Underground/on ground
Piping Type:	10. Copper
Piping External Protection:	99. Other
Overfill Prevention:	5. Vent Whistle
Piping Secondary Containment:	Not reported
Spill Prevention:	Not reported
Dispenser:	2. Suction

C43 **1 NORTH LEXINGTON AVE** **NY LTANKS** **S100140904**
WNW **1 NORTH LEXINGTON AVE** **NY Spills** **N/A**
< 1/8 **WHITE PLAINS, NY**
0.015 mi.
81 ft. **Site 8 of 15 in cluster C**

Relative:
Higher

Actual:
201 ft.

LTANKS:

Name:	GATEWAY OFFICE BLDG
Address:	1 NORTH LEXINGTON AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8908197 / 1990-01-29
Facility ID:	8908197
Site ID:	276348
Spill Date:	1989-11-16
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	Not reported
Cleanup Ceased:	1990-01-29
SWIS:	6017
Investigator:	wxwadswo
Referred To:	Not reported
Reported to Dept:	1989-11-16
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1989-11-17
Spill Record Last Update:	2005-05-15
Spiller Name:	Not reported
Spiller Company:	SAME
Spiller Address:	Not reported
Spiller County:	999
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	113491
Latitude:	41.0319729
Longitude:	-73.7725456
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was W. WADSWORTH 01/29/90: TANK PASSED RETEST.
Remarks:	WILL PUMP OUT TANK (CAPITAL OIL)

All TTF:

Facility ID:	8908197
Spill Number:	8908197
Spill Tank Test:	1536421
Site ID:	276348
Tank Number:	Not reported
Tank Size:	0
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00

1 NORTH LEXINGTON AVE (Continued) **S100140904**

Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	276348
Operable Unit ID:	933238
Operable Unit:	01
Material ID:	559409
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	Not reported
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

Name:	1 NORTH LEXINGTON AVE
Address:	1 NORTH LEXINGTON AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9000726 / 1991-12-06
Facility ID:	9000726
Site ID:	131721
Spill Date:	1990-04-20
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	Not reported
Cleanup Ceased:	1953-06-18
SWIS:	6017
Investigator:	wxwadswo
Referred To:	Not reported
Reported to Dept:	1990-04-20
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	True
Remediation Phase:	0
Date Entered In Computer:	1990-05-30
Spill Record Last Update:	2005-05-15
Spiller Name:	Not reported
Spiller Company:	WTT CORP.
Spiller Address:	123 MAIN STREET
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	113491
Latitude:	41.0319729

1 NORTH LEXINGTON AVE (Continued) **S100140904**

Longitude:	-73.7725456
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was W. WADSWORTH 09/27/95: This is additional information about material spilled from the translation of the old spill file: TANK TEST.
Remarks:	PETRO-TITE -.344

All TTF:

Facility ID:	9000726
Spill Number:	9000726
Spill Tank Test:	1536975
Site ID:	131721
Tank Number:	Not reported
Tank Size:	0
Material:	0008
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	131721
Operable Unit ID:	940390
Operable Unit:	01
Material ID:	439098
Material Code:	0008
Material Name:	diesel
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	Not reported
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

Name:	GATEWAY BLDG
Address:	1 NORTH LEXINGTON AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9108659 / 1991-11-13
Facility ID:	9108659
Site ID:	255792
Spill Date:	1991-11-13
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	D3
Cleanup Ceased:	1991-11-13
SWIS:	6017
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1991-11-13
CID:	Not reported

1 NORTH LEXINGTON AVE (Continued) **S100140904**

Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1991-11-18
Spill Record Last Update:	2005-05-15
Spiller Name:	Not reported
Spiller Company:	EMERG ENV.
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	113491
Latitude:	41.0319729
Longitude:	-73.7725456
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY 01/31/92: PASSED RETEST. 09/27/95: This is additional information about material spilled from the translation of the old spill file: TANK TEST.
Remarks:	OIL NOTICED IN MANWAY REPAIR AND RETEST HORNER EZ SYSTEM GROSS

All TTF:

Facility ID:	9108659
Spill Number:	9108659
Spill Tank Test:	1539301
Site ID:	255792
Tank Number:	Not reported
Tank Size:	0
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	255792
Operable Unit ID:	962707
Operable Unit:	01
Material ID:	420787
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	Not reported
Recovered:	.00

1 NORTH LEXINGTON AVE (Continued) **S100140904**

Resource Affected: Soil
Oxygenate: Not reported

SPILLS:
Name: GATE WAY PLAZA
Address: 1 NORTH LEXINGTON AVE
City,State,Zip: WHITE PLAINS, NY
Spill Number/Closed Date: 1112860 / 2012-06-06
Facility ID: 1112860
Facility Type: ER
DER Facility ID: 113491
Site ID: 460825
DEC Region: 3
Spill Cause: Unknown
Spill Class: B3
SWIS: 6017
Spill Date: 2012-02-09
Investigator: jbodee
Referred To: Not reported
Reported to Dept: 2012-02-09
CID: Not reported
Water Affected: Not reported
Spill Source: Commercial/Industrial
Spill Notifier: Other
Cleanup Ceased: Not reported
Cleanup Meets Std: False
Last Inspection: Not reported
Recommended Penalty: False
UST Trust: False
Remediation Phase: 0
Date Entered In Computer: 2012-02-09
Spill Record Last Update: 2012-06-06
Spiller Name: Not reported
Spiller Company: GATE WAY PLAZA
Spiller Address: Not reported
Spiller Company: 999
Contact Name: TONY PEPE
Latitude: 41.0322216
Longitude: -73.7732986
DEC Memo: 2/9/12 - Caller removed one 10K UST and one 2K UST. Post excavation sampling results showed
contamination below soil guidance. A TCR will be prepared. Westchester County DOH was notified and
was presented at the tank pull. KAB >>> Lalak, Chris >cjl1@westchestergov.com> 2/9/2012 10:56 AM
>>> John, I am lead on this one pbs tank pull. Chris jod 06/06/2012: Update received from Chris
Lalak of WCDoH PBS: John Please close this spill 1112860 1 North Lex. Ave, WP American pulled two
tanks *DEC requires no further action at this time. jod
Remarks: contamination based on lab results

All Materials:
Site ID: 460825
Operable Unit ID: 1210927
Operable Unit: 01

1 NORTH LEXINGTON AVE (Continued) **S100140904**

Material ID:	2208599
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	G
Recovered:	Not reported
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	GATEWAY BUILDING
Address:	1 NORTH LEXINGTON AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	1213498 / 2013-01-08
Facility ID:	1213498
Facility Type:	ER
DER Facility ID:	113491
Site ID:	476685
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	Not reported
SWIS:	6017
Spill Date:	2012-12-13
Investigator:	TDGHIOSA
Referred To:	Not reported
Reported to Dept:	2012-12-13
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Other
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2012-12-13
Spill Record Last Update:	2013-01-08
Spiller Name:	Not reported
Spiller Company:	PROPERTY OWNER
Spiller Address:	Not reported
Spiller Company:	999
Contact Name:	CHRIS LALAK
Latitude:	41.0322216
Longitude:	-73.7732986
DEC Memo:	12/13/12 Assitant Chief Engineer Joseph Rocuzzo reported that a contractor, DP Wolff (143 Bedford Rd, Katonah) was performing mechanical work and had 50 gallon of oil that needed to be pumped back into the diesel storage tank. They set the house pump on manual and turned on the pump. It was explained that the oil first gets pumped up to the 20th floor day tank and the excess then flows out the daytank return line back to the storage tank. However the daytank emergency vent relief

1 NORTH LEXINGTON AVE (Continued) **S100140904**

valve is lower than the return line, so the oil released from that vent before it could be sent
back to the tank via the return line. The oil drained down the glass curtain wall from the 19th
floor to the 16th floor. Elite Environmental was on site removing oily insulation and cleaning
oiled surfaces. A minor amount of oil escaped the interior of the building thru the glass curtain
and landed on the sidewalk below. Some oil also entered a floor drain next to the day tank. WP
sewer dept personnel reported that oil was observed in the sanitary sewer in the street but not in
the storm drains. WCHD is requiring indoor air sampling before the 4 impacted floors can be
reoccupied. TG

Remarks: interior and exterior to sidewalk - cleanup in progress - spilled 14 thru 17 floor elite environmental on site

All Materials:

Site ID:	476685
Operable Unit ID:	1226510
Operable Unit:	01
Material ID:	2223774
Material Code:	0008
Material Name:	diesel
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	50.00
Units:	G
Recovered:	Not reported
Resource Affected:	Indoor Air, Impervious Surface
Oxygenate:	Not reported

C44 **GATEWAY CENTER ONE** **NY UST** **U003979121**
WNW **1 NORTH LEXINGTON AVENUE** **N/A**
< 1/8 **WHITE PLAINS, NY 10601**
0.015 mi.
81 ft. **Site 9 of 15 in cluster C**

Relative: **Higher**
Actual: **201 ft.**

WESTCHESTER CO. UST:

Name:	GATEWAY CENTER ONE
Address:	1 NORTH LEXINGTON AVENUE
City,State,Zip:	WHITE PLAINS, NY 10601
Id/Status:	3-496871 / Active
Operator Name:	Cushman & Wakefield
Owner Name:	Gateway I Group, Inc.
Owner Street:	1 North Lexington Avenue
Owner Address2:	Not reported
Owner City:	White Plains
Owner State:	NY
Owner Zipcode:	10601
GDS Number:	Not reported
Tank Number:	1
Status:	3. Closed - Removed
Capacity:	10000
Product Stored:	0001. #2 Fuel Oil

GATEWAY CENTER ONE (Continued) **U003979121**

Product Stored Percent:	100
Tank Leak Detection:	0. None
Date Installation:	11/01/1984
Date Perm Closure:	01/24/2012
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Secondary Containment:	0. None
Piping Location:	2. Underground/on ground
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Overfill Prevention:	5. Vent Whistle
Piping Secondary Containment:	Not reported
Spill Prevention:	Not reported
Dispenser:	2. Suction

Tank Number:	10
Status:	1. In-Service
Capacity:	10000
Product Stored:	0001. #2 Fuel Oil
Product Stored Percent:	Not reported
Tank Leak Detection:	1. Electronic Interstitial Monitoring
Date Installation:	02/01/2012
Date Perm Closure:	01/01/1900
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	6. Fiberglass reinforced plastic (FRP)
Tank Internal Protection:	0. None
Tank External Protection:	4. Fiberglass
Tank Secondary Containment:	4. Double-Walled (underground only)
Piping Location:	2. Underground/on Ground
Piping Type:	6. Fiberglass Reinforced Plastic (FRP)
Piping External Protection:	4. Fiberglass
Overfill Prevention:	2. High Level Alarm
Piping Secondary Containment:	4. Double-Walled (underground only)
Spill Prevention:	1. Catch Basin
Dispenser:	2. Suction

Tank Number:	11
Status:	1. In-Service
Capacity:	10000
Product Stored:	0001. #2 Fuel Oil
Product Stored Percent:	Not reported
Tank Leak Detection:	1. Electronic Interstitial Monitoring
Date Installation:	02/01/2012
Date Perm Closure:	01/01/1900
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	6. Fiberglass reinforced plastic (FRP)
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	4. Double-Walled (underground only)
Piping Location:	2. Underground/on Ground
Piping Type:	6. Fiberglass Reinforced Plastic (FRP)
Piping External Protection:	4. Fiberglass
Overfill Prevention:	2. High Level Alarm

GATEWAY CENTER ONE (Continued) **U003979121**

Piping Secondary Containment:	4. Double-Walled (underground only)
Spill Prevention:	1. Catch Basin
Dispenser:	2. Suction

Tank Number:	2
Status:	4. Closed - in place
Capacity:	2000
Product Stored:	0008. Diesel
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	11/01/1984
Date Perm Closure:	11/01/1991
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	0. No Pipiing
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Overfill Prevention:	Not reported
Piping Secondary Containment:	Not reported
Spill Prevention:	Not reported
Dispenser:	2. Suction

C45 **CUSHMAN & WAKEFIELD** **PA MANIFEST** **S118068777**
WNW **1 N LEXINGTON AVE** **N/A**
< 1/8 **WHITE PLAINS, NY 10601**
0.015 mi.
81 ft. **Site 10 of 15 in cluster C**

Relative: **Higher**
Actual: **201 ft.**

PA MANIFEST:

Name:	CUSHMAN & WAKEFIELD
Address:	1 N LEXINGTON AVE
City,State,Zip:	WHITE PLAINS, NY 10601
Year:	2017
Manifest Number:	010443369FLE
Manifest Type:	T
Generator EPA ID:	NYD986984698
Generator Date:	07/13/2017
Mailing Address:	Not reported
Contact Name:	Not reported
Contact Phone:	Not reported
TSD EPA ID:	Not reported
TSD Date:	Not reported
TSD Facility Name:	Cycle Chem Inc
TSD Facility Address:	217 S First St
TSD Facility City:	Elizabeth
TSD Facility State:	NJ
Facility Telephone:	Not reported
Page Number:	1
Line Number:	1
Waste Number:	D001
Container Number:	2
Container Type:	DF
Waste Quantity:	50
Unit:	G

CUSHMAN & WAKEFIELD (Continued) **S118068777**

Handling Code:	Not reported
TSP EPA ID:	NJD002200046
Date TSP Sig:	Not reported
Year:	2014
Manifest Number:	001502315FLE
Manifest Type:	T
Generator EPA ID:	NYD986984698
Generator Date:	03/27/2014
Mailing Address:	Not reported
Contact Name:	Not reported
Contact Phone:	Not reported
TSD EPA ID:	Not reported
TSD Date:	Not reported
TSD Facility Name:	Cycle Chem Inc
TSD Facility Address:	550 Industrial Rd
TSD Facility City:	Lewisberry
TSD Facility State:	PA
Facility Telephone:	Not reported
Page Number:	1
Line Number:	1
Waste Number:	F003
Container Number:	4
Container Type:	DF
Waste Quantity:	180
Unit:	G
Handling Code:	Not reported
TSP EPA ID:	PAD067098822
Date TSP Sig:	Not reported
Year:	2014
Manifest Number:	001502315FLE
Manifest Type:	T
Generator EPA ID:	NYD986984698
Generator Date:	03/27/2014
Mailing Address:	Not reported
Contact Name:	Not reported
Contact Phone:	Not reported
TSD EPA ID:	Not reported
TSD Date:	Not reported
TSD Facility Name:	Cycle Chem Inc
TSD Facility Address:	550 Industrial Rd
TSD Facility City:	Lewisberry
TSD Facility State:	PA
Facility Telephone:	Not reported
Page Number:	1
Line Number:	1
Waste Number:	D001
Container Number:	4
Container Type:	DF
Waste Quantity:	180
Unit:	G
Handling Code:	Not reported
TSP EPA ID:	PAD067098822
Date TSP Sig:	Not reported
Year:	2016

CUSHMAN & WAKEFIELD (Continued) **S118068777**

Manifest Number:	001505886FLE
Manifest Type:	T
Generator EPA ID:	NYD986984698
Generator Date:	01/21/2016
Mailing Address:	Not reported
Contact Name:	Not reported
Contact Phone:	Not reported
TSD EPA ID:	Not reported
TSD Date:	Not reported
TSD Facility Name:	Cycle Chem Inc
TSD Facility Address:	550 Industrial Rd
TSD Facility City:	Lewisberry
TSD Facility State:	PA
Facility Telephone:	Not reported
Page Number:	1
Line Number:	1
Waste Number:	F003
Container Number:	1
Container Type:	DF
Waste Quantity:	55
Unit:	G
Handling Code:	Not reported
TSP EPA ID:	PAD067098822
Date TSP Sig:	Not reported

Year:	2016
Manifest Number:	001505886FLE
Manifest Type:	T
Generator EPA ID:	NYD986984698
Generator Date:	01/21/2016
Mailing Address:	Not reported
Contact Name:	Not reported
Contact Phone:	Not reported
TSD EPA ID:	Not reported
TSD Date:	Not reported
TSD Facility Name:	Cycle Chem Inc
TSD Facility Address:	550 Industrial Rd
TSD Facility City:	Lewisberry
TSD Facility State:	PA
Facility Telephone:	Not reported
Page Number:	1
Line Number:	1
Waste Number:	D001
Container Number:	1
Container Type:	DF
Waste Quantity:	55
Unit:	G
Handling Code:	Not reported
TSP EPA ID:	PAD067098822
Date TSP Sig:	Not reported

C46 **RNG PADD 1** **RCRA-VSQG** **1000705553**
WNW **1 N LEXINGTON AVE** **FINDS** **NYD986984698**
< 1/8 **WHITE PLAINS, NY 10601** **FUELS PROGRAM**
0.015 mi. **E MANIFEST**
81 ft. **Site 11 of 15 in cluster C** **NJ MANIFEST**

Relative: **Higher**
Actual: **201 ft.**

RCRA Listings:

Date Form Received by Agency:	20070101
Handler Name:	Gateway Building
Handler Address:	N Lexington Ave 13th Fl
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYD986984698
Contact Name:	JOE J ROCCUZZO
Contact Address:	N LEXINGTON AVE 13TH FL
Contact City,State,Zip:	WHITE PLAINS, NY 10601
Contact Telephone:	914-683-5331
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Conditionally Exempt Small Quantity Generator
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Handler Activities
State District Owner:	Ny
State District:	NYSDEC R3
Mailing Address:	N LEXINGTON AVE 13TH FL
Mailing City,State,Zip:	WHITE PLAINS, NY 10601
Owner Name:	A T & T
Owner Type:	Private
Operator Name:	C B Richard Ellis
Operator Type:	Private
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No

RNG PADD 1 (Continued) **1000705553**

Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20150414
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Hazardous Waste Summary:

Waste Code:	D002
Waste Description:	Corrosive Waste
Waste Code:	D008
Waste Description:	Lead
Waste Code:	X003
Waste Description:	Not Defined

Handler - Owner Operator:

Owner/Operator Indicator:	Owner
Owner/Operator Name: A T & T	
Legal Status:	Private
Date Became Current:	Not reported
Date Ended Current:	Not reported
Owner/Operator Address:	1 N LEXINGTON AVE
Owner/Operator City,State,Zip:	WHITE PLAINS, NY 10601
Owner/Operator Telephone:	914-397-3519
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported
Owner/Operator Email:	Not reported
Owner/Operator Indicator:	Owner
Owner/Operator Name: A T & T	
Legal Status:	Private
Date Became Current:	Not reported
Date Ended Current:	Not reported
Owner/Operator Address:	1 N LEXINGTON AVE
Owner/Operator City,State,Zip:	WHITE PLAINS, NY 10601
Owner/Operator Telephone:	914-397-3519
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported
Owner/Operator Email:	Not reported
Owner/Operator Indicator:	Operator
Owner/Operator Name: C B RICHARD ELLIS	
Legal Status:	Private
Date Became Current:	20000701

RNG PADD 1 (Continued) **1000705553**

Date Ended Current:	Not reported
Owner/Operator Address:	Not reported
Owner/Operator City,State,Zip:	Not reported
Owner/Operator Telephone:	Not reported
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported
Owner/Operator Email:	Not reported
Owner/Operator Indicator:	Owner
Owner/Operator Name: ALASKA PENSION FUND	
Legal Status:	Private
Date Became Current:	20000701
Date Ended Current:	Not reported
Owner/Operator Address:	Not reported
Owner/Operator City,State,Zip:	Not reported
Owner/Operator Telephone:	Not reported
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported
Owner/Operator Email:	Not reported
Owner/Operator Indicator:	Operator
Owner/Operator Name: C B RICHARD ELLIS	
Legal Status:	Private
Date Became Current:	20000701
Date Ended Current:	Not reported
Owner/Operator Address:	Not reported
Owner/Operator City,State,Zip:	Not reported
Owner/Operator Telephone:	Not reported
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported
Owner/Operator Email:	Not reported

Historic Generators:

Receive Date:	19990708
Handler Name: A T & T	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported
Receive Date:	20060214
Handler Name: GATEWAY BUILDING	
Federal Waste Generator Description:	Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported

RNG PADD 1 (Continued) **1000705553**

Electronic Manifest Broker: Not reported

Receive Date: 20070101
Handler Name: GATEWAY BUILDING
Federal Waste Generator Description: Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 19920103
Handler Name: A T & T
Federal Waste Generator Description: Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20060215
Handler Name: GATEWAY BUILDING
Federal Waste Generator Description: Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Code: 53119
NAICS Description: Lessors Of Other Real Estate Property

Has the Facility Received Notices of Violations:
Found Violation: No
Agency Which Determined Violation: Not reported
Violation Short Description: Not reported
Date Violation was Determined: Not reported
Actual Return to Compliance Date: Not reported
Return to Compliance Qualifier: Not reported
Violation Responsible Agency: Not reported
Scheduled Compliance Date: Not reported
Enforcement Identifier: Not reported

RNG PADD 1 (Continued) **1000705553**

Date of Enforcement Action:	Not reported
Enforcement Responsible Agency:	Not reported
Enforcement Docket Number:	Not reported
Enforcement Attorney:	Not reported
Corrective Action Component:	Not reported
Appeal Initiated Date:	Not reported
Appeal Resolution Date:	Not reported
Disposition Status Date:	Not reported
Disposition Status:	Not reported
Disposition Status Description:	Not reported
Consent/Final Order Sequence Number:	Not reported
Consent/Final Order Respondent Name:	Not reported
Consent/Final Order Lead Agency:	Not reported
Enforcement Type:	Not reported
Enforcement Responsible Person:	Not reported
Enforcement Responsible Sub-Organization:	Not reported
SEP Sequence Number:	Not reported
SEP Expenditure Amount:	Not reported
SEP Scheduled Completion Date:	Not reported
SEP Actual Date:	Not reported
SEP Defaulted Date:	Not reported
SEP Type:	Not reported
SEP Type Description:	Not reported
Proposed Amount:	Not reported
Final Monetary Amount:	Not reported
Paid Amount:	Not reported
Final Count:	Not reported
Final Amount:	Not reported

Evaluation Action Summary:

Evaluation Date:	20120724
Evaluation Responsible Agency:	State
Found Violation:	No
Evaluation Type Description:	COMPLIANCE EVALUATION INSPECTION
Evaluation Responsible Person Identifier:	NYFKY
Evaluation Responsible Sub-Organization:	R3
Actual Return to Compliance Date:	Not reported
Scheduled Compliance Date:	Not reported
Date of Request:	Not reported
Date Response Received:	Not reported
Request Agency:	Not reported
Former Citation:	Not reported

FINDS:

Registry ID: 110071515485

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:

IN ACCORDANCE WITH THE FEDERAL CLEAN AIR ACT (CAA) EPA ESTABLISHES FUEL QUALITY STANDARDS TO HELP PROTECT PUBLIC HEALTH AND THE ENVIRONMENT FROM HARMFUL GAS AND PARTICULATE MATTER EMISSIONS FROM MOTOR VEHICLES AND ENGINES. THE OFFICE OF TRANSPORTATION AND AIR QUALITY (OTAQ) HAS DEVELOPED THE REGISTRATION AND DC FUELS ONLINE APPLICATIONS IMPLEMENTED THROUGH EPA S CENTRAL DATA EXCHANGE (CDX) WHICH PROVIDES ONLINE APPLICATIONS TO ASSIST THE FUEL MANUFACTURING

RNG PADD 1 (Continued) **1000705553**

COMMUNITY WITH REGISTRATION AND COMPLIANCE WITH REPORTING REQUIREMENTS.

Registry ID: 110071515487

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:
IN ACCORDANCE WITH THE FEDERAL CLEAN AIR ACT (CAA) EPA ESTABLISHES FUEL QUALITY STANDARDS TO HELP PROTECT PUBLIC HEALTH AND THE ENVIRONMENT FROM HARMFUL GAS AND PARTICULATE MATTER EMISSIONS FROM MOTOR VEHICLES AND ENGINES. THE OFFICE OF TRANSPORTATION AND AIR QUALITY (OTAQ) HAS DEVELOPED THE REGISTRATION AND DC FUELS ONLINE APPLICATIONS IMPLEMENTED THROUGH EPA S CENTRAL DATA EXCHANGE (CDX) WHICH PROVIDES ONLINE APPLICATIONS TO ASSIST THE FUEL MANUFACTURING COMMUNITY WITH REGISTRATION AND COMPLIANCE WITH REPORTING REQUIREMENTS.

Registry ID: 110071515488

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:
IN ACCORDANCE WITH THE FEDERAL CLEAN AIR ACT (CAA) EPA ESTABLISHES FUEL QUALITY STANDARDS TO HELP PROTECT PUBLIC HEALTH AND THE ENVIRONMENT FROM HARMFUL GAS AND PARTICULATE MATTER EMISSIONS FROM MOTOR VEHICLES AND ENGINES. THE OFFICE OF TRANSPORTATION AND AIR QUALITY (OTAQ) HAS DEVELOPED THE REGISTRATION AND DC FUELS ONLINE APPLICATIONS IMPLEMENTED THROUGH EPA S CENTRAL DATA EXCHANGE (CDX) WHICH PROVIDES ONLINE APPLICATIONS TO ASSIST THE FUEL MANUFACTURING COMMUNITY WITH REGISTRATION AND COMPLIANCE WITH REPORTING REQUIREMENTS.

Registry ID: 110071515489

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:
IN ACCORDANCE WITH THE FEDERAL CLEAN AIR ACT (CAA) EPA ESTABLISHES FUEL QUALITY STANDARDS TO HELP PROTECT PUBLIC HEALTH AND THE ENVIRONMENT FROM HARMFUL GAS AND PARTICULATE MATTER EMISSIONS FROM MOTOR VEHICLES AND ENGINES. THE OFFICE OF TRANSPORTATION AND AIR QUALITY (OTAQ) HAS DEVELOPED THE REGISTRATION AND DC FUELS ONLINE APPLICATIONS IMPLEMENTED THROUGH EPA S CENTRAL DATA EXCHANGE (CDX) WHICH PROVIDES ONLINE APPLICATIONS TO ASSIST THE FUEL MANUFACTURING COMMUNITY WITH REGISTRATION AND COMPLIANCE WITH REPORTING REQUIREMENTS.

Registry ID: 110071515490

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:
IN ACCORDANCE WITH THE FEDERAL CLEAN AIR ACT (CAA) EPA ESTABLISHES FUEL QUALITY STANDARDS TO HELP PROTECT PUBLIC HEALTH AND THE ENVIRONMENT FROM HARMFUL GAS AND PARTICULATE MATTER EMISSIONS FROM MOTOR VEHICLES AND ENGINES. THE OFFICE OF TRANSPORTATION AND AIR QUALITY (OTAQ) HAS DEVELOPED THE REGISTRATION AND DC FUELS ONLINE APPLICATIONS IMPLEMENTED THROUGH EPA S CENTRAL DATA EXCHANGE (CDX) WHICH PROVIDES ONLINE APPLICATIONS TO ASSIST THE FUEL MANUFACTURING COMMUNITY WITH REGISTRATION AND COMPLIANCE WITH REPORTING REQUIREMENTS.

Registry ID: 110071813054

RNG PADD 1 (Continued) **1000705553**

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:
The database that supports the Toxic Substances Control Act (TSCA) of 1976, which provides EPA with authority to require reporting, record-keeping and testing requirements, and restrictions relating to chemical substances and/or mixtures. Certain substances are generally excluded from TSCA, including, among others, food, drugs, cosmetics and pesticides. TSCA addresses the production, importation, use, and disposal of specific chemicals including polychlorinated biphenyls (PCBs), asbestos, radon and lead-based paint.
Registry ID: 110004481864

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:
The Resource Conservation and Recovery Act Information System (RCRAInfo) is EPA's comprehensive information system in support of the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. It tracks many types of information about generators, transporters, treaters, storers, and disposers of hazardous waste.

Click this hyperlink while viewing on your computer to access additional FINDS: detail in the EDR Site Report.

FUELS PROGRAM:

Name:	RNG PADD 1
Address:	1 N LEXINGTON AVE
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10601
Program Type:	Renewable Fuel Standard
Company Seq. ID:	6523
Business Activity:	Renewable Fuel Producer, Renewable Fuels Importer, RNG RIN Separator
Company Name:	Opal Fuels Station Services LLC
Company Address:	One North Lexington Avenue Suite 1450 White Plains, NY 10601
Facility ID:	73681
Facility Type:	Gas/Ethanol
Facility Activity:	Renewable Fuel Importer
Subject to 80.1403:	Not reported
Fuel Only For Off Road:	No
Fuel Created:	Not reported
D Code:	Not reported
OTAQ Program ID:	OTAQREG10177070

Name:	RNG PADD 2
Address:	1 N LEXINGTON AVE
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10601
Program Type:	Renewable Fuel Standard
Company Seq. ID:	6523
Business Activity:	Renewable Fuel Producer, Renewable Fuels Importer, RNG RIN Separator
Company Name:	Opal Fuels Station Services LLC
Company Address:	One North Lexington Avenue Suite 1450 White Plains, NY 10601

RNG PADD 1 (Continued) **1000705553**

Facility ID:	73682
Facility Type:	Gas/Ethanol
Facility Activity:	Renewable Fuel Importer
Subject to 80.1403:	Not reported
Fuel Only For Off Road:	No
Fuel Created:	Not reported
D Code:	Not reported
OTAQ Program ID:	OTAQREG10177072
Name:	RNG PADD 3
Address:	1 N LEXINGTON AVE
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10601
Program Type:	Renewable Fuel Standard
Company Seq. ID:	6523
Business Activity:	Renewable Fuel Producer, Renewable Fuels Importer, RNG RIN Separator
Company Name:	Opal Fuels Station Services LLC
Company Address:	One North Lexington Avenue Suite 1450 White Plains, NY 10601
Facility ID:	73683
Facility Type:	Gas/Ethanol
Facility Activity:	Renewable Fuel Importer
Subject to 80.1403:	Not reported
Fuel Only For Off Road:	No
Fuel Created:	Not reported
D Code:	Not reported
OTAQ Program ID:	OTAQREG10177073
Name:	RNG PADD 5
Address:	1 N LEXINGTON AVE
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10601
Program Type:	Renewable Fuel Standard
Company Seq. ID:	6523
Business Activity:	Renewable Fuel Producer, Renewable Fuels Importer, RNG RIN Separator
Company Name:	Opal Fuels Station Services LLC
Company Address:	One North Lexington Avenue Suite 1450 White Plains, NY 10601
Facility ID:	73684
Facility Type:	Gas/Ethanol
Facility Activity:	Renewable Fuel Importer
Subject to 80.1403:	Not reported
Fuel Only For Off Road:	No
Fuel Created:	Not reported
D Code:	Not reported
OTAQ Program ID:	OTAQREG10177074
Name:	RNG PADD 4
Address:	1 N LEXINGTON AVE
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10601
Program Type:	Renewable Fuel Standard
Company Seq. ID:	6523
Business Activity:	Renewable Fuel Producer, Renewable Fuels Importer, RNG RIN Separator
Company Name:	Opal Fuels Station Services LLC

RNG PADD 1 (Continued) **1000705553**

Company Address:	One North Lexington Avenue Suite 1450 White Plains, NY 10601
Facility ID:	73685
Facility Type:	Gas/Ethanol
Facility Activity:	Renewable Fuel Importer
Subject to 80.1403:	Not reported
Fuel Only For Off Road:	No
Fuel Created:	Not reported
D Code:	Not reported
OTAQ Program ID:	OTAQREG10177075

E MANIFEST:

Manifest Tracking Number:	010459605FLE
Last Updated Date:	20201214
Shipped Date:	20201117
Received Date:	20201124
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	NYD986984698
Generator Name:	Cushman & Wakefield Gateway 1
Generator Location Street Number:	Not reported
Generator Location Street 1:	ONE NORTH LEXINGTON AVE
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	ONE NORTH LEXINGTON AVE
Generator Mail Street 2:	Not reported
Generator Mail City:	WHITE PLAINS
Generator Mail Zip:	10601
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	NJD002200046
Designated Facility Name:	Cycle Chem, Inc.
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	217 SOUTH FIRST STREET
Designated Facility Mail City:	ELIZABETH
Designated Facility Mail Zip:	07206
Designated Facility Mail State:	NJ
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	217 SOUTH FIRST STREET
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	ELIZABETH
Designated Facility Location Zip:	07206
Designated Facility Location State:	NJ
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Federal Waste:

Manifest Tracking Number:	010459605FLE

RNG PADD 1 (Continued) **1000705553**

Waste Line Number: 1
Federal Waste Code: D001
Federal Waste: IGNITABLE WASTE

Manifest Tracking Number: 010459605FLE
Waste Line Number: 1
Federal Waste Code: F003
Federal Waste: THE FOLLOWING SPENT NONHALOGENATED SOLVENTS: XYLENE, ACETONE, ETHYL ACETATE, ETHYL BENZENE, ETHYL ETHER, METHYL ISOBUTYL KETONE, N-BUTYL ALCOHOL, CYCLOHEXANONE, AND METHANOL; ALL SPENT SOLVENT MIXTURES/BLENDS CONTAINING, BEFORE USE, ONLY THE ABOVE SPENT NONHALOGENATED SOLVENTS; AND ALL SPENT SOLVENT MIXTURES/BLENDS CONTAINING, BEFORE USE, ONE OR MORE OF THE ABOVE NONHALOGENATED SOLVENTS, AND A TOTAL OF TEN PERCENT OR MORE (BY VOLUME) OF ONE OR MORE OF THOSE SOLVENTS LISTED IN F001, F002, F004, AND F005; AND STILL BOTTOMS FROM THE RECOVERY OF THESE SPENT SOLVENTS AND SPENT SOLVENT MIXTURES.

Manifest Tracking Number: 010459605FLE
Waste Line Number: 1
Federal Waste Code: F005
Federal Waste: THE FOLLOWING SPENT NONHALOGENATED SOLVENTS: TOLUENE, METHYL ETHYL KETONE, CARBON DISULFIDE, ISOBUTANOL, PYRIDINE, BENZENE, 2-ETHOXYETHANOL, AND 2-NITROPROPANE; ALL SPENT SOLVENT MIXTURES/BLENDS CONTAINING, BEFORE USE, A TOTAL OF TEN PERCENT OR MORE (BY VOLUME) OF ONE OR MORE OF THE ABOVE NONHALOGENATED SOLVENTS OR THOSE SOLVENTS LISTED IN F001, F002, OR F004; AND STILL BOTTOMS FROM THE RECOVERY OF THESE SPENT SOLVENTS AND SPENT SOLVENT MIXTURES.

State Waste:
Manifest Tracking Number: 010459605FLE
Waste Line Number: 1
State Waste Code Owner: NY
State Waste Code: B
State Waste: Incineration, heat recovery, burning. Waste management method code to be used on e-Manifest only

Transporter:
Manifest Tracking Number: 010459605FLE
Transporter Line Number: 1
Transporter EPA ID: NYD980762843
Transporter Name: Waste Oil Solutions, Inc.

Waste Line:
Manifest Tracking Number: 010459605FLE
Waste Line Number: 1
U.S. DOT Hazardous Indicator: Y
U.S. DOT ID Number: UN1263
U.S. DOT Description: Rq, Un1263, Waste Paint Related Material, 3 , Ii
Non-Hazardous Waste Description: Not reported
Number of Containers: 1
Container Type Code: DM
Container Type Description: Metal drums, barrels, kegs
Waste Quantity: 50
Quantity Unit of Measure Code: G
Quantity Unit of Measure Description: Gallons

RNG PADD 1 (Continued) **1000705553**

Waste Quantity, in Tons:	0.20850709
Acute Waste Quantity, in Tons:	0
Non-Acute Waste Quantity, in Tons:	0.20850709
Waste Quantity, in Kilograms:	189.1222
Acute Waste Quantity, in Kilograms:	0
Non-Acute Waste Quantity, in Kilorgrams:	189.1222
Management Method Code:	H061
Management Method Description:	FUEL BLENDING
Waste Residue Indicator:	N
Quantity Discrepancy Indicator:	N
Waste Type Discrepancy Indicator:	N
Waste Density:	Not reported
Waste Density Unit of Measure Code:	Not reported
Waste Density Unit of Measure Description:	Not reported
Form Code:	Not reported
Form Code Description:	Not reported
Source Code:	Not reported
Source Code Description:	Not reported
Waste Minimization Code:	Not reported
Waste Minimization Code Description:	Not reported
Consent Number:	Not reported
EPA Waste Indicator:	Y

NJ MANIFEST:

EPA ID:	NYD986984698
Name:	CB RICHARD ELLIS
Address:	1 NORTH LEXINGTON AVE
City,State,Zip:	WHITE PLAINS, NY 10601
County:	Not reported
Mailing Address:	1 NORTH LEXINGTON AVE
Mailing City,State,Zip:	WHITE PLAINS 10601
Telephone:	9146835331
Emergency Telephone:	Not reported
Contact:	RON PAULSON
Comments:	Not reported
SIC Code:	Not reported
County:	00
Municipal:	00
Previous EPAID:	Not reported
Generator Flag:	X
Transporter Flag:	Not reported
TSDF Flag:	Not reported
Name Change:	Not reported
Date Change:	Not reported

Manifest Data:

EPA ID:	NYD986984698
Manifest Number:	000052581FLE
Date Shipped:	02/09/2007
TSDF EPA ID:	NJD002200046
Transporter EPA ID:	NYD980761191
Transporter 2 EPA ID:	NYD980761191
Transporter 3 EPA ID:	Not reported
Transporter 4 EPA ID:	Not reported
Transporter 5 EPA ID:	Not reported
Transporter 6 EPA ID:	Not reported
Transporter 7 EPA ID:	Not reported

RNG PADD 1 (Continued) **1000705553**

Transporter 8 EPA ID:	Not reported
Transporter 9 EPA ID:	Not reported
Transporter 10 EPA ID:	Not reported
Date Trans1 Transported Waste:	02/09/2007
Date Trans2 Transported Waste:	02/19/2007
Date Trans3 Transported Waste:	Not reported
Date Trans4 Transported Waste:	Not reported
Date Trans5 Transported Waste:	Not reported
Date Trans6 Transported Waste:	Not reported
Date Trans7 Transported Waste:	Not reported
Date Trans8 Transported Waste:	Not reported
Date Trans9 Transported Waste:	Not reported
Date Trans10 Transported Waste:	Not reported
Date TSDF Received Waste:	02/20/2007
TSDF EPA Facility Name:	Not reported
QTY Units:	Not reported
Transporter SEQ ID:	Not reported
Transporter-1 Date:	Not reported
Waste SEQ ID:	Not reported
Waste Type Code 2:	Not reported
Waste Type Code 3:	Not reported
Waste Type Code 4:	Not reported
Waste Type Code 5:	Not reported
Waste Type Code 6:	Not reported
Date Accepted:	Not reported
Manifest Discrepancy Type:	Not reported
Data Entry Number:	Not reported
Was Load Rejected:	N
Reason Load Was Rejected:	Not reported

Waste:

Manifest Year:	Not reported
Waste Code:	D001
Hand Code:	H14
Quantity:	50
Unit:	G

EPA ID:	NYD986984698
Manifest Number:	NJA5288045
Date Shipped:	02/27/2006
TSDF EPA ID:	NJD002200046
Transporter EPA ID:	VTR000500090
Transporter 2 EPA ID:	NYD980761191
Transporter 3 EPA ID:	Not reported
Transporter 4 EPA ID:	Not reported
Transporter 5 EPA ID:	Not reported
Transporter 6 EPA ID:	Not reported
Transporter 7 EPA ID:	Not reported
Transporter 8 EPA ID:	Not reported
Transporter 9 EPA ID:	Not reported
Transporter 10 EPA ID:	Not reported
Date Trans1 Transported Waste:	02/27/2006
Date Trans2 Transported Waste:	03/10/2006
Date Trans3 Transported Waste:	Not reported
Date Trans4 Transported Waste:	Not reported
Date Trans5 Transported Waste:	Not reported
Date Trans6 Transported Waste:	Not reported

RNG PADD 1 (Continued) **1000705553**

Date Trans7 Transported Waste:	Not reported
Date Trans8 Transported Waste:	Not reported
Date Trans9 Transported Waste:	Not reported
Date Trans10 Transported Waste:	Not reported
Date TSDF Received Waste:	03/10/2006
TSDF EPA Facility Name:	Not reported
QTY Units:	Not reported
Transporter SEQ ID:	Not reported
Transporter-1 Date:	Not reported
Waste SEQ ID:	Not reported
Waste Type Code 2:	Not reported
Waste Type Code 3:	Not reported
Waste Type Code 4:	Not reported
Waste Type Code 5:	Not reported
Waste Type Code 6:	Not reported
Date Accepted:	Not reported
Manifest Discrepancy Type:	Not reported
Data Entry Number:	06190621
Was Load Rejected:	N
Reason Load Was Rejected:	Not reported

EPA ID:	NYD986984698
Manifest Number:	001162208FLE
Date Shipped:	10/29/2008
TSDF EPA ID:	NJD002200046
Transporter EPA ID:	NYR000115733
Transporter 2 EPA ID:	NYD980761191
Transporter 3 EPA ID:	Not reported
Transporter 4 EPA ID:	Not reported
Transporter 5 EPA ID:	Not reported
Transporter 6 EPA ID:	Not reported
Transporter 7 EPA ID:	Not reported
Transporter 8 EPA ID:	Not reported
Transporter 9 EPA ID:	Not reported
Transporter 10 EPA ID:	Not reported
Date Trans1 Transported Waste:	10/29/2008
Date Trans2 Transported Waste:	10/29/2008
Date Trans3 Transported Waste:	Not reported
Date Trans4 Transported Waste:	Not reported
Date Trans5 Transported Waste:	Not reported
Date Trans6 Transported Waste:	Not reported
Date Trans7 Transported Waste:	Not reported
Date Trans8 Transported Waste:	Not reported
Date Trans9 Transported Waste:	Not reported
Date Trans10 Transported Waste:	Not reported
Date TSDF Received Waste:	10/29/2008
TSDF EPA Facility Name:	Not reported
QTY Units:	Not reported
Transporter SEQ ID:	Not reported
Transporter-1 Date:	Not reported
Waste SEQ ID:	Not reported
Waste Type Code 2:	Not reported
Waste Type Code 3:	Not reported
Waste Type Code 4:	Not reported
Waste Type Code 5:	Not reported
Waste Type Code 6:	Not reported
Date Accepted:	Not reported

RNG PADD 1 (Continued) **1000705553**

Manifest Discrepancy Type:	Not reported
Data Entry Number:	Not reported
Was Load Rejected:	N
Reason Load Was Rejected:	Not reported

Waste:

Manifest Year:	Not reported
Waste Code:	D001
Hand Code:	H141
Quantity:	47
Unit:	G

EPA ID:	NYD986984698
Manifest Number:	001162134FLE
Date Shipped:	03/24/2008
TSDF EPA ID:	NJD002200046
Transporter EPA ID:	NYR000115733
Transporter 2 EPA ID:	NYD980761191
Transporter 3 EPA ID:	Not reported
Transporter 4 EPA ID:	Not reported
Transporter 5 EPA ID:	Not reported
Transporter 6 EPA ID:	Not reported
Transporter 7 EPA ID:	Not reported
Transporter 8 EPA ID:	Not reported
Transporter 9 EPA ID:	Not reported
Transporter 10 EPA ID:	Not reported
Date Trans1 Transported Waste:	03/24/2008
Date Trans2 Transported Waste:	04/04/2008
Date Trans3 Transported Waste:	Not reported
Date Trans4 Transported Waste:	Not reported
Date Trans5 Transported Waste:	Not reported
Date Trans6 Transported Waste:	Not reported
Date Trans7 Transported Waste:	Not reported
Date Trans8 Transported Waste:	Not reported
Date Trans9 Transported Waste:	Not reported
Date Trans10 Transported Waste:	Not reported
Date TSDF Received Waste:	04/04/2008
TSDF EPA Facility Name:	Not reported
QTY Units:	Not reported
Transporter SEQ ID:	Not reported
Transporter-1 Date:	Not reported
Waste SEQ ID:	Not reported
Waste Type Code 2:	Not reported
Waste Type Code 3:	Not reported
Waste Type Code 4:	Not reported
Waste Type Code 5:	Not reported
Waste Type Code 6:	Not reported
Date Accepted:	Not reported
Manifest Discrepancy Type:	Not reported
Data Entry Number:	Not reported
Was Load Rejected:	N
Reason Load Was Rejected:	Not reported

Waste:

Manifest Year:	Not reported
Waste Code:	D001
Hand Code:	H141

RNG PADD 1 (Continued) **1000705553**

Quantity: 40
Unit: G

C47 **GATEWAY CENTER ONE** **NY AST** **A100379813**
WNW **1 NORTH LEXINGTON AVENUE** **N/A**
< 1/8 **WHITE PLAINS, NY 10601**
0.015 mi.
81 ft. **Site 12 of 15 in cluster C**

Relative: **Higher**
Actual: **201 ft.**

WESTCHESTER CO. AST:

Name:	GATEWAY CENTER ONE
Address:	1 NORTH LEXINGTON AVENUE
City,State,Zip:	WHITE PLAINS, NY 10601
PBS Number:	3-496871
Site Status:	Active
GDS Number:	Not reported
Operator Name:	Cushman & Wakefield
Owner Name:	Gateway I Group, Inc.
Owner Street:	1 North Lexington Avenue
Owner Address2:	Not reported
Owner City/State/Zip:	White Plains, NY 10601
Tank Number:	No. 3
Status:	1. In-Service
Date Installation:	12/01/2008
Capacity:	275
Product Stored:	0001. #2 Fuel Oil
Product Stored Percent:	Not reported
Date Perm Closure:	01/01/1900
Tank Location:	2. Aboveground (contact w/ impervious barrier)
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Leak Detection:	1. Electronic Interstitial Monitoring
Tank Secondary Containment:	1. Diking (aboveground only),9. Modified double-walled (aboveground only)
Piping Location:	1. Aboveground
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	1. Painted/Asphalt Coating
Piping Leak Detection:	0. None
Piping Secondary Containment:	0. None
Overfill Prevention:	3. Automatic Shut-off,4. Product Level Gauge (Aboveground Only)
Spill Prevention:	1. Catch Basin
Dispenser:	2. Suction
Tank Number:	SMBC Tank 1
Status:	1. In-Service
Date Installation:	08/01/2018
Capacity:	150
Product Stored:	0001. #2 Fuel Oil
Product Stored Percent:	Not reported
Date Perm Closure:	01/01/1900
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating

GATEWAY CENTER ONE (Continued) **A100379813**

Tank Leak Detection:	1. Electronic Interstitial Monitoring
Tank Secondary Containment:	12. Double-Walled (AST only)
Piping Location:	1. Aboveground
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	1. Painted/Asphalt Coating
Piping Leak Detection:	0. None
Piping Secondary Containment:	0. None
Overfill Prevention:	3. Automatic Shut-off
Spill Prevention:	1. Catch Basin
Dispenser:	Not reported

Tank Number:	SMBC Tank 2
Status:	1. In-Service
Date Installation:	08/01/2018
Capacity:	150
Product Stored:	0001. #2 Fuel Oil
Product Stored Percent:	Not reported
Date Perm Closure:	01/01/1900
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Leak Detection:	1. Electronic Interstitial Monitoring
Tank Secondary Containment:	12. Double-Walled (AST only)
Piping Location:	1. Aboveground
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	1. Painted/Asphalt Coating
Piping Leak Detection:	0. None
Piping Secondary Containment:	0. None
Overfill Prevention:	3. Automatic Shut-off
Spill Prevention:	1. Catch Basin
Dispenser:	Not reported

C48 **GATEWAY BLDG** **NY MANIFEST** **S117563215**
WNW **1 N LEXINGTON AVE 13TH FL** **N/A**
< 1/8 **WHITE PLAINS, NY 10601**
0.015 mi.
81 ft. **Site 13 of 15 in cluster C**

Relative: **Higher**

Actual: **201 ft.**

NY MANIFEST:

EPA ID:	NYD986984698
Country:	USA
Name:	Gateway Bldg
Address:	1 N LEXINGTON AVE 13TH FL
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10601
Zip 4:	Not reported
Location Address 1:	NORTH LEXINGTON AVE
Location Address 2:	Not reported
Location City,State,Zip:	WHITE PLAINS, NY 10601
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Gateway Bldg

GATEWAY BLDG (Continued) **S117563215**

Mailing Contact: Bill Moser
Mailing Address 1: NORTH LEXINGTON AVE
Mailing Address 2: Not reported
Mailing City,State,Zip: WHITE PLAINS, NY 10601
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: 3159642554

Manifest Data:
Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: NYR000115733
Year: 2018
Trans2 State ID: Not reported
Generator Ship Date: 07/13/2017
Trans1 Recv Date: 07/13/2017
Trans2 Recv Date: Not reported
TSD Site Recv Date: 07/28/2017
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYD986984698
Trans1 EPA ID: Not reported
Trans2 EPA ID: Not reported
TSDF ID 1: NJD002200046
TSDF ID 2: Not reported
Manifest Tracking Number: 010443369FLE
Import Indicator: N
Export Indicator: N
Discr Quantity Indicator: N
Discr Type Indicator: N
Discr Residue Indicator: N
Discr Partial Reject Indicator: N
Discr Full Reject Indicator: N
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: H141
Waste Code a: Ignitable Waste
Waste Code b: Not reported
Waste Code c: Not reported
Waste Code e: Not reported
Waste Code f: Not reported
Waste Code g: Not reported
Waste Code 1: Not reported
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 50
Units: Gallons (liquids only)
Number of Containers: 2
Container Type: Fiberboard or plastic drums, barrels, kegs
Handling Method: Landfill
Specific Gravity: 1

Document ID: Not reported

GATEWAY BLDG (Continued) **S117563215**

Manifest Status:	Not reported
Trans1 State ID:	NYR000115733
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	03/27/2014
Trans1 Recv Date:	03/27/2014
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	04/21/2014
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD986984698
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	PAD067098822
TSDF ID 2:	Not reported
Manifest Tracking Number:	001502315FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H141
Waste Code a:	Ignitable Waste
Waste Code b:	Corrosive Waste
Waste Code c:	The Following Spent Nonhalogenated Solvents: Xylene, Acetone, Ethyl Acetate, Ethyl Benzene, Ethyl Ether, Methyl Isobutyl Ketone, N-Butyl Alcohol, Cyclohexanone, And Methanol; All Spent Solvent Mixtures/Blends Containing, Before Use, Only The Above Spent Nonhalogenated Solvents; And All Spent Solvent Mixtures/Blends Containing, Before Use, One Or More Of The Above Nonhalogenated Solvents, And A Total Of Ten Percent Or More (By Volume) Of One Or More Of Those Solvents Listed In F001, F002, F004, And F005; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent Mixtures.
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	45
Units:	Gallons (liquids only)
Number of Containers:	1
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Landfill
Specific Gravity:	1
Document ID:	Not reported
Manifest Status:	Not reported

GATEWAY BLDG (Continued) **S117563215**

Trans1 State ID:	NYR000115733
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	03/27/2014
Trans1 Recv Date:	03/27/2014
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	04/21/2014
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD986984698
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	PAD067098822
TSDF ID 2:	Not reported
Manifest Tracking Number:	001502315FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H141
Waste Code a:	Not reported
Waste Code b:	Ignitable Waste
Waste Code c:	The Following Spent Nonhalogenated Solvents: Xylene, Acetone, Ethyl Acetate, Ethyl Benzene, Ethyl Ether, Methyl Isobutyl Ketone, N-Butyl Alcohol, Cyclohexanone, And Methanol; All Spent Solvent Mixtures/Blends Containing, Before Use, Only The Above Spent Nonhalogenated Solvents; And All Spent Solvent Mixtures/Blends Containing, Before Use, One Or More Of The Above Nonhalogenated Solvents, And A Total Of Ten Percent Or More (By Volume) Of One Or More Of Those Solvents Listed In F001, F002, F004, And F005; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent Mixtures.
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	135
Units:	Gallons (liquids only)
Number of Containers:	3
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Landfill
Specific Gravity:	1
Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	VTR000500090

GATEWAY BLDG (Continued) **S117563215**

Year:	2018
Trans2 State ID:	NYD980761191
Generator Ship Date:	02/27/2006
Trans1 Recv Date:	02/27/2006
Trans2 Recv Date:	03/10/2006
TSD Site Recv Date:	03/10/2006
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD986984698
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	NJA5288045
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code a:	Ignitable Waste
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	50
Units:	Gallons (liquids only)
Number of Containers:	1
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	1

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYR000115733
Year:	2018
Trans2 State ID:	NYD980761191
Generator Ship Date:	03/24/2008
Trans1 Recv Date:	03/24/2008
Trans2 Recv Date:	04/04/2008
TSD Site Recv Date:	04/04/2008
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD986984698
Trans1 EPA ID:	Not reported

GATEWAY BLDG (Continued) **S117563215**

Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	001162134FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H141
Waste Code a:	Ignitable Waste
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	40
Units:	Gallons (liquids only)
Number of Containers:	1
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	1

Document ID:	PAC3321500
Manifest Status:	Not reported
Trans1 State ID:	Not reported
Year:	1992
Trans2 State ID:	Not reported
Generator Ship Date:	02/27/1992
Trans1 Recv Date:	02/27/1992
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	02/28/1992
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD986984698
Trans1 EPA ID:	GAD064493000
Trans2 EPA ID:	Not reported
TSDF ID 1:	PAD087561015
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported

GATEWAY BLDG (Continued) **S117563215**

Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Corrosive Waste
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00475
Units:	Pounds
Number of Containers:	001
Container Type:	Wooden boxes, cartons, cases
Handling Method:	Treat
Specific Gravity:	01.00

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD980761191
Year:	2018
Trans2 State ID:	NYD980761191
Generator Ship Date:	02/09/2007
Trans1 Recv Date:	02/09/2007
Trans2 Recv Date:	02/19/2007
TSD Site Recv Date:	02/20/2007
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD986984698
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	000052581FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H141
Waste Code a:	Ignitable Waste
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported

GATEWAY BLDG (Continued) **S117563215**

Waste Code 6:	Not reported
Quantity:	50
Units:	Gallons (liquids only)
Number of Containers:	1
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	1
Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	CT5000001495
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	01/26/2018
Trans1 Recv Date:	01/26/2018
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	01/26/2018
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD986984698
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	CT5000001495
TSDF ID 2:	Not reported
Manifest Tracking Number:	014040769JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	Y
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H010
Waste Code a:	Not reported
Waste Code b:	Mercury
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	846
Units:	Pounds
Number of Containers:	2
Container Type:	Metal drums, barrels, kegs
Handling Method:	Recycle
Specific Gravity:	1
Document ID:	Not reported
Manifest Status:	Not reported

GATEWAY BLDG (Continued) **S117563215**

Trans1 State ID:	NYR000115733
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	07/14/2016
Trans1 Recv Date:	07/19/2016
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	08/05/2016
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD986984698
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	VTR000517052
TSDF ID 2:	Not reported
Manifest Tracking Number:	001505910FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H141
Waste Code a:	Ignitable Waste
Waste Code b:	The Following Spent Nonhalogenated Solvents: Xylene, Acetone, Ethyl Acetate, Ethyl Benzene, Ethyl Ether, Methyl Isobutyl Ketone, N-Butyl Alcohol, Cyclohexanone, And Methanol; All Spent Solvent Mixtures/Blends Containing, Before Use, Only The Above Spent Nonhalogenated Solvents; And All Spent Solvent Mixtures/Blends Containing, Before Use, One Or More Of The Above Nonhalogenated Solvents, And A Total Of Ten Percent Or More (By Volume) Of One Or More Of Those Solvents Listed In F001, F002, F004, And F005; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent Mixtures.
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	945
Units:	Pounds
Number of Containers:	2
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Landfill
Specific Gravity:	1
Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYR000115733

GATEWAY BLDG (Continued) **S117563215**

Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	11/23/2011
Trans1 Recv Date:	11/23/2011
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	12/14/2011
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD986984698
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	PAD067098822
TSDF ID 2:	Not reported
Manifest Tracking Number:	001162465FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H141
Waste Code a:	Ignitable Waste
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	300
Units:	Pounds
Number of Containers:	1
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	1

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYR000115733
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	01/21/2016
Trans1 Recv Date:	01/21/2016
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	02/11/2016
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD986984698
Trans1 EPA ID:	Not reported

GATEWAY BLDG (Continued) **S117563215**

Trans2 EPA ID:	Not reported
TSDF ID 1:	PAD067098822
TSDF ID 2:	Not reported
Manifest Tracking Number:	001505886FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H141
Waste Code a:	Ignitable Waste
Waste Code b:	The Following Spent Nonhalogenated Solvents: Xylene, Acetone, Ethyl Acetate, Ethyl Benzene, Ethyl Ether, Methyl Isobutyl Ketone, N-Butyl Alcohol, Cyclohexanone, And Methanol; All Spent Solvent Mixtures/Blends Containing, Before Use, Only The Above Spent Nonhalogenated Solvents; And All Spent Solvent Mixtures/Blends Containing, Before Use, One Or More Of The Above Nonhalogenated Solvents, And A Total Of Ten Percent Or More (By Volume) Of One Or More Of Those Solvents Listed In F001, F002, F004, And F005; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent Mixtures.
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	55
Units:	Gallons (liquids only)
Number of Containers:	1
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Landfill
Specific Gravity:	1

Click this hyperlink while viewing on your computer to access
2 additional NY MANIFEST: record(s) in the EDR Site Report.

C49 **1 NORTH LEXINGTON AVE** **UST FINDER RELEASE** **1029057592**
WNW **1 NORTH LEXINGTON AVE** **N/A**
< 1/8 **WHITE PLAINS, NY 0**
0.015 mi.
81 ft. **Site 14 of 15 in cluster C**

Relative:
Higher

Actual:
201 ft.

UST FINDER RELEASE:

Object ID:	262307
Facility ID:	NY113491
Lust ID:	NY9000726
Name:	1 NORTH LEXINGTON AVE

1 NORTH LEXINGTON AVE (Continued) **1029057592**

Address:	1 NORTH LEXINGTON AVE
City,State,Zip:	WHITE PLAINS, NY 0
Address Match Type:	Not reported
Reported Date:	1990/04/20 15:59:59+00
Status:	No Further Action
Substance:	Not reported
Population within 1500ft:	2172
Domestic Wells within 1500ft:	0
Land Use:	Developed, High Intensity
Within SPA:	Yes
SPA PWS Facility ID:	NY7003493_76968
SPA Water Type:	SW - SurRELEASEe Water
SPA Facility Type:	RS - Reservoir
SPA HUC12:	20301020103
Within WHPA:	No
WHPA PWS Facility ID:	Not reported
WHPA Water Type:	Not reported
WHPA Facility Type:	Not reported
WHPA HUC12:	Not reported
Within 100yr Floodplain:	No
Tribe:	Not reported
EPA Region:	2
NFA Letter 1:	Not reported
NFA Letter 2:	Not reported
NFA Letter 3:	Not reported
NFA Letter 4:	Not reported
Closed With Residual Contaminate:	Not reported
Coordinate Source:	State
X Coord:	-73.77255
Y Coord:	41.0319700000001
Latitude:	41.03197
Longitude:	-73.7725499999999

C50 **HOPE FIRE ENGINE CO. SITE** **NY BROWNFIELDS S127990271**
WNW **25 NORTH LEXINGTON AVENUE** **NY SPDES N/A**
< 1/8 **WHITE PLAINS, NY 10601**
0.024 mi.
127 ft. **Site 15 of 15 in cluster C**

Relative: **Higher**

Actual: **201 ft.**

BROWNFIELDS:

Name:	HOPE FIRE ENGINE CO. SITE
Address:	25 NORTH LEXINGTON AVENUE
City,State,Zip:	WHITE PLAINS, NY 10601
Program:	BCP
Site Code:	622605
Acres:	1.463
HW Code:	C360219
SWIS:	6017
Town:	White Plains (c)
Record Added Date:	07/21/2021
Record Updated Date:	01/03/2023
Update By:	AMSERVIS
Site Description:	Site Location: The site is located at 25 North Lexington Avenue (formerly 50 Hamilton Avenue and a portion of (p/o) 85 North Lexington Avenue), in the City of White Plains, Westchester County, New York, in an area of urban development. The site comprises 1.463 acres located on the west side of North Lexington Avenue, north of Hamilton Avenue and east of Ferris Avenue, and is identified on the

HOPE FIRE ENGINE CO. SITE (Continued) **S127990271**

Westchester County tax maps as a p/o new Tax Parcel Identification No. 125.66 5 2.1 (formerly 125.66 5 2 [lot 2], and p/o 125.66 5 1 [lot 1]). Site Features: The site is currently undergoing construction of a multi use residential/commercial building. The closest water body is the Bronx River, located 0.118 miles west of the site. The site is not located in a flood zone, and no designated wetlands were identified. Current Zoning and Land Use: The site is currently located in the CB 4 District, which allows commercial and some residential uses. The CB 4 designation also permits hotels. The New Street right of way and Terrace Parking Garage are located north of the site. North Lexington Avenue and St. John the Evangelist Roman Catholic Church are located east of the site, across North Lexington Avenue. Hamilton Avenue and multiple commercial buildings border the southern portion of the Site. Ferris Avenue, a Greyhound Bus Station, and the White Plains Metro North Railroad Station are located west of the site. The rail line is located 0.082 miles west of the site. The closest residential area is an apartment building located approximately 0.10 miles from the site to the south southwest. Past Use of the Site: Prior to 1885, the site was utilized as farmland and a freight yard. Between 1885 and 1888, the site was improved with dwellings, a rail line, and several retail establishments. Between 1889 and 1911 the site was further developed as a lumber and coal storage yard, a railroad round house, and a fire station, known as the Hope Fire Engine Co. of White Plains. In 1930, former lot 1 contained an underground storage tank (UST) associated with the fire station. The former lot 2 portion of the site was occupied by two service stations from 1937 through 1961. Railroad operations continued on lot 1 until the mid 1960 s when the site was taken over by urban renewal agencies and the structures on the railroad portion of the lot were razed and a parking lot was constructed. The fire station remained on-site until 1987. All on site buildings were demolished by 1994 and the site was fully developed into a parking lot in 2006. The parking lot was demolished in 2022, in preparation for construction of a multi use residential/commercial building. The long history of fire station use, and the presence of service stations may have contributed to contamination on the site. The presence of the railroad storage yard and lumber yard may have also contributed to contamination at the site. Contaminants associated with railroad operations include residual ash and cinders, chemically treated railroad ties, and petroleum related compounds. Polyaromatic hydrocarbon (PAH) contaminated soils detected on the site may be attributed to the previous railroad storage and lumber yard. Site Geology and Hydrogeology: According to the United States Geological Survey s White Plains, New York 7.5 minute topographic quadrangle (1967), the site is located at an elevation of 200 210 feet above mean sea level (ft amsl). The site is located in a river valley and slopes in the south southwest direction towards the Bronx River. A steep decline is present along the eastern and northern site boundaries. During investigations of the site, groundwater was encountered at depths ranging from approximately five (5) to 30 feet below grade (ft bg). Groundwater flow direction is to the southwest. Based on environmental investigations conducted to date, the subsurface geology generally consists of fill material to 12 ft bg, underlain by native sand deposits consisting of loose to dense sand with varying amounts of silt to depths of 55 to 88 ft bg, followed by gneissic bedrock.

Env Problem: Remediation at the site is complete. Remedial actions have

HOPE FIRE ENGINE CO. SITE (Continued) **S127990271**

	successfully achieved soil cleanup objectives for unrestricted use. Nature and Extent of Contamination: Based on investigations conducted to date, prior to the IRM, the primary contaminants of concern included SVOCs and metals in soil and groundwater, pesticides and PCBs in soil, and volatile organic compounds (VOCs) in soil vapor. Impacts were identified in soil across the site to depths up to 23.5 feet below grade (ft bg). Soil: Following completion of the on-site IRM, all soil above USCOs have been removed and disposed of off-site. Data do not indicate site-related soil impacts have migrated off-site. Groundwater: Post-IRM groundwater sampling has indicated very low concentrations of chloroform (maximum concentration of 8.98 ppb compared to the AWQS of 7 ppb) and secondary naturally occurring metals (iron, magnesium and manganese), as well as low levels of PFOS (maximum concentration of 14.2 ppt) and PFOA (maximum concentration of 35.4 ppt). While the PFOS and PFOA concentrations exceed the 10 ppt Maximum Contaminant Level (MCL) for each compound, they are not indicative of a source area and are expected to be consistent with the concentrations coming onto the site, similar to other sites in the area that also contain no potential source. Additionally, the area is served by municipal water. The IRM is complete and has removed all soil above USCOs, and thus any possible site-related source material that may contribute to groundwater contamination. Data do not indicate site-related groundwater impacts have migrated off-site. Soil Vapor: The complete excavation of soil exceeding USCOs across the entire site as part of the IRM removed any potentially impacted soil in the unsaturated zone and has addressed potential soil vapor intrusion concerns for any future buildings constructed on-site, as well as the potential migration of soil vapor off-site.
Health Problem:	Remedial actions are complete and measures are in place to control the potential for coming in contact with residual contamination remaining at the site.
Dump:	False
Structure:	False
Lagoon:	False
Landfill:	False
Pond:	False
Disp Start:	Not reported
Disp Term:	Not reported
Lat/Long:	Not reported
Dell:	Not reported
Record Add:	2021-11-05 16:48:00
Record Upd:	2022-11-28 13:09:00
Updated By:	GLWHITE
Own Op:	6
Sub Type:	P03
Owner Name:	Ryan Souls
Owner Company:	GS White Plains Owner, LLC
Owner Address:	One Federal Street, Suite 1804
Owner Addr2:	Not reported
Owner City,St,Zip:	Boston, MA 02110
Owner Country:	United States of America
Own Op:	1
Sub Type:	P03
Owner Name:	Ryan Souls
Owner Company:	GS White Plains Owner, LLC
Owner Address:	One Federal Street, Suite 1804
Owner Addr2:	Not reported

HOPE FIRE ENGINE CO. SITE (Continued) **S127990271**

Owner City,St,Zip:	Boston, MA 02110
Owner Country:	United States of America
Own Op:	Document Repository
Sub Type:	NNN
Owner Name:	Not reported
Owner Company:	White Plains Public Library
Owner Address:	100 Martine Avenue
Owner Addr2:	Not reported
Owner City,St,Zip:	White Plains, NY 10601
Owner Country:	United States of America
HW Code:	C360219
Waste Type:	DDT
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360219
Waste Type:	PCB aroclor 1260
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360219
Waste Type:	DDE
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360219
Waste Type:	benzo(k)fluoranthene
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360219
Waste Type:	cadmium
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360219
Waste Type:	barium
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360219
Waste Type:	benzo(a)anthracene
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360219
Waste Type:	nickel
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360219
Waste Type:	indeno(1,2,3-cd)pyrene
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360219
Waste Type:	chrysene
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360219
Waste Type:	zinc
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360219
Waste Type:	copper
Waste Quantity:	UNKNOWN

HOPE FIRE ENGINE CO. SITE (Continued) **S127990271**

Waste Code:	Not reported
HW Code:	C360219
Waste Type:	benzo(a)pyrene
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360219
Waste Type:	PCB aroclor 1242
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360219
Waste Type:	dibenz[a,h]anthracene
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360219
Waste Type:	lead
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360219
Waste Type:	PCB aroclor 1248
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360219
Waste Type:	mercury
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360219
Waste Type:	benzo(b)fluoranthene
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
Crossref ID:	C360219-11-21
Cross Ref Type Code:	23
Cross Ref Type:	Agreement/Consent Order Number
Record Added Date:	2022-11-28 11:47:00
Record Updated:	2022-11-28 11:47:00
Updated By:	GLWHITE

SPDES:

Name:	Gateway Ii
Address:	25 NORTH LEXINGTON AVENUE
City,State,Zip:	WHITE PLAINS, NY 10601
Permit Number:	NYR11K769
State-Region:	3
Expiration Date:	Not reported
Current Major Minor Status:	Not reported
Primary Facility SIC Code:	Not reported
State Water Body Name:	Bronx River
Limit Set Status Flag:	Not reported
Total Actual Average Flow(MGD):	Not reported
Total App Design Flow(MGD):	Not reported
UDF1:	Not reported
Lat/Long:	Not reported
DMR Cognizant Official:	Not reported
UDF2:	Not reported
UDF3:	Not reported
FIPS County Code:	Not reported

HOPE FIRE ENGINE CO. SITE (Continued) **S127990271**

Non-Gov Permit Affiliation Type Desc:	Not reported
Non-Gov Permit Org Formal Name:	Not reported
Non-Gov Permit Street Address:	Not reported
Non-Gov Permit Supplemental Location:	Not reported
Non-Gov Permit City:	Not reported
Non-Gov Permit State Code:	Not reported
Non-Gov Permit Zip Code:	Not reported
Non-Gov Facility Affiliation Type Desc:	Not reported
Non-Gov Facility Org Formal Name:	Not reported
Non-Gov Facility Street Address:	Not reported
Non-Gov Facility Supplemental Location:	Not reported
Non-Gov Facility City:	Not reported
Non-Gov Facility State Code:	Not reported
Non-Gov Facility Zip Code:	Not reported
State Water Body:	Not reported
Region Permit Processed:	Not reported
Dow Discharge Class Code:	Not reported
SPDES Class Description:	Not reported
Affiliation Type Description:	Not reported
Name:	Not reported
Contacts Title:	Not reported
Contacts Email:	Not reported
NOI Submission Date:	Not reported
Facility Type:	Construction Permit - 2003_present

B51 **MARTIN LUTHER KING &** **NY Spills** **S105057532**
ENE **MAIN STREET** **N/A**
< 1/8 **WHITE PLAINS, NY**
0.029 mi.
152 ft. **Site 6 of 18 in cluster B**

Relative: **Lower**

Actual: **195 ft.**

SPILLS:

Name:	MARTIN LUTHER KING &
Address:	MAIN STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0101975 / 2001-05-21
Facility ID:	0101975
Facility Type:	ER
DER Facility ID:	278182
Site ID:	326507
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	C4
SWIS:	6000
Spill Date:	2001-05-21
Investigator:	WXWADSWO
Referred To:	Not reported
Reported to Dept:	2001-05-21
CID:	205
Water Affected:	Not reported
Spill Source:	Commercial Vehicle
Spill Notifier:	Responsible Party
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2001-05-21

MARTIN LUTHER KING & (Continued) **S105057532**

Spill Record Last Update:	2001-06-13
Spiller Name:	TONY DEOLIVIERA
Spiller Company:	LIBERTY LINES TRANSIT
Spiller Address:	475 SAWMILL RIVER RD
Spiller Company:	001
Contact Name:	CALLER
Latitude:	41.0373699
Longitude:	-73.7571500
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was WADSWORTH
Remarks:	HOSE LEAKED. CLEANUP COMPLETED, EXCEPT APPROX 1QT TO STORM DRAIN.

All Materials:

Site ID:	326507
Operable Unit ID:	840783
Operable Unit:	01
Material ID:	537667
Material Code:	0043A
Material Name:	antifreeze
Case No.:	Not reported
Material FA:	Other
Quantity:	3.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

B52 **NY POWER AUTH** **RCRA NonGen / NLR** **1000555801**
ENE **123 MAIN ST** **NYD986983468**
< 1/8 **WHITE PLAINS, NY 10601**
0.030 mi.
157 ft. **Site 7 of 18 in cluster B**

Relative: **Lower**
Actual: **195 ft.**

RCRA Listings:

Date Form Received by Agency:	20070101
Handler Name:	Ny Power Auth
Handler Address:	Main St
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYD986983468
Contact Name:	Not reported
Contact Address:	MAIN ST
Contact City,State,Zip:	WHITE PLAINS, NY 10601
Contact Telephone:	Not reported
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	State
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R3
Mailing Address:	MAIN ST
Mailing City,State,Zip:	WHITE PLAINS, NY 10601

NY POWER AUTH (Continued) **1000555801**

Owner Name:	Ny Power Auth
Owner Type:	State
Operator Name:	Ny Power Auth
Operator Type:	State
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20150414
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Hazardous Waste Summary:

Waste Code:	D001
Waste Description:	Ignitable Waste
Waste Code:	D002
Waste Description:	Corrosive Waste
Waste Code:	D006
Waste Description:	Cadmium
Waste Code:	D008

NY POWER AUTH (Continued) **1000555801**

Waste Description: Lead

Waste Code: NONE
Waste Description: Not Defined

Handler - Owner Operator:
Owner/Operator Indicator: Operator
Owner/Operator Name: NY POWER AUTH
Legal Status: State
Date Became Current: Not reported
Date Ended Current: Not reported
Owner/Operator Address: 123 MAIN ST
Owner/Operator City,State,Zip: WHITE PLAINS, NY 10601
Owner/Operator Telephone: 914-681-6200
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Owner
Owner/Operator Name: NY POWER AUTH
Legal Status: State
Date Became Current: Not reported
Date Ended Current: Not reported
Owner/Operator Address: 123 MAIN ST
Owner/Operator City,State,Zip: WHITE PLAINS, NY 10601
Owner/Operator Telephone: 914-681-6200
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Owner
Owner/Operator Name: NY POWER AUTH
Legal Status: State
Date Became Current: Not reported
Date Ended Current: Not reported
Owner/Operator Address: 123 MAIN ST
Owner/Operator City,State,Zip: WHITE PLAINS, NY 10601
Owner/Operator Telephone: 914-681-6200
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Historic Generators:
Receive Date: 19920302
Handler Name: NY POWER AUTH
Federal Waste Generator Description: Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

NY POWER AUTH (Continued) **1000555801**

Receive Date:	20060101
Handler Name: NY POWER AUTH	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20070101
Handler Name: NY POWER AUTH	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	19911022
Handler Name: NY POWER AUTH	
Federal Waste Generator Description:	Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

B53 **ODDESY CORP MAINT DEPT** **NY LTANKS** **S104278796**
ENE **123 MAIN STREET** **NY Spills** **N/A**
< 1/8 **WHITE PLAINS, NY**
0.030 mi.
157 ft. **Site 8 of 18 in cluster B**

Relative:
Lower

Actual:
195 ft.

LTANKS:

Name:	CENTROPLEX ASSOC.
Address:	123 MAIN STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8907663 / 1991-06-12
Facility ID:	8907663
Site ID:	74955
Spill Date:	1989-11-01
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	Not reported
Cleanup Ceased:	1953-06-18
SWIS:	6017
Investigator:	wxwadswo
Referred To:	Not reported
Reported to Dept:	1989-11-01
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1989-11-09
Spill Record Last Update:	1993-12-09
Spiller Name:	Not reported
Spiller Company:	Not reported
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	70243
Latitude:	41.0321684
Longitude:	-73.7697583
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was W. WADSWORTH
Remarks:	HIRED CASTLE OIL CO. TO PUMP OUT WILL RETEST SPILL # 8906607 IS THE ORIGINAL # GIVEN TO THIS SITE REFER TO 8906607 FOR MORE INFORMATION PASSED RETEST

All TTF:

Facility ID:	8907663
Spill Number:	8907663
Spill Tank Test:	1536349
Site ID:	74955
Tank Number:	Not reported
Tank Size:	0
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported

ODDESY CORP MAINT DEPT (Continued) **S104278796**

Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	74955
Operable Unit ID:	935283
Operable Unit:	01
Material ID:	444449
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	Not reported
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

Name:	ODDESY CORP MAINT DEPT
Address:	123 MAIN STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8906607 / 1991-06-12
Facility ID:	8906607
Site ID:	160999
Spill Date:	1989-10-04
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	D4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1989-10-04
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1989-10-16
Spill Record Last Update:	2003-09-26
Spiller Name:	Not reported
Spiller Company:	ODDESY CORP MAINT DEPT
Spiller Address:	123 MAIN ST
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3

ODDESY CORP MAINT DEPT (Continued) **S104278796**

DER Facility ID:	70243
Latitude:	41.0321684
Longitude:	-73.7697583
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY
Remarks:	PETRO TITE, 10K, -.483 GPH, SYSTEM FAILED W/PLUMBING INCLUDED. WILL E.I.R. NEXT WEEK THEY PLAN TO ISOLATE TANK TO RETEST. PASSED RETEST

All TTF:

Facility ID:	8906607
Spill Number:	8906607
Spill Tank Test:	1536167
Site ID:	160999
Tank Number:	Not reported
Tank Size:	0
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	160999
Operable Unit ID:	931611
Operable Unit:	01
Material ID:	447023
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

Name:	OFFICE BLDG
Address:	123 MAIN STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9910168 / 1999-11-22
Facility ID:	9910168
Site ID:	161000
Spill Date:	1999-11-19
Spill Cause:	Tank Overfill
Spill Source:	Institutional, Educational, Gov., Other
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	PJDECICC
Referred To:	Not reported

ODDESY CORP MAINT DEPT (Continued) **S104278796**

Reported to Dept:	1999-11-22
CID:	323
Water Affected:	Not reported
Spill Notifier:	Affected Persons
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1999-11-22
Spill Record Last Update:	2000-01-26
Spiller Name:	JOHN MORABIDO
Spiller Company:	COMFORCE (CONTRACTOR)
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	JOSEPH DOSSO
Spiller Phone:	(914) 287-3144
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	70243
Latitude:	41.0321684
Longitude:	-73.7697583
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was DECICCO 11/22/99 OVERFOLD VALVE LET GO WHEN TESTING GENERATOR; CONTAINED IN CONCRETE CONTAINMENT. NFA
Remarks:	ON A Y2K GENERATOR ON THE 17TH FLOOR. SPILL WAS CLEANED UP.

All Materials:

Site ID:	161000
Operable Unit ID:	1084933
Operable Unit:	01
Material ID:	555904
Material Code:	0008
Material Name:	diesel
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	42.00
Units:	G
Recovered:	42.00
Resource Affected:	Soil
Oxygenate:	Not reported

SPILLS:

Name:	SHARP
Address:	123 MAIN STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8606381 / 1987-03-16
Facility ID:	8606381
Facility Type:	ER
DER Facility ID:	70243
Site ID:	160998
DEC Region:	3
Spill Cause:	Unknown
Spill Class:	Not reported
SWIS:	6017
Spill Date:	1987-01-13

ODDESY CORP MAINT DEPT (Continued) **S104278796**

Investigator:	PATEL
Referred To:	Not reported
Reported to Dept:	1987-01-13
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Unknown
Spill Notifier:	Affected Persons
Cleanup Ceased:	1987-03-16
Cleanup Meets Std:	True
Last Inspection:	1987-03-16
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	1987-02-09
Spill Record Last Update:	1988-02-24
Spiller Name:	Not reported
Spiller Company:	UNKNOWN
Spiller Address:	Not reported
Spiller Company:	999
Contact Name:	Not reported
Latitude:	41.0321684
Longitude:	-73.7697583
DEC Memo:	Not reported
Remarks:	Not reported

All Materials:

Site ID:	160998
Operable Unit ID:	903964
Operable Unit:	01
Material ID:	475507
Material Code:	0066A
Material Name:	unknown petroleum
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	Not reported
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

B54 **NEW YORK POWER AUTHORITY** **NY UST 1004902218**
ENE **123 MAIN STREET** **NY AST N/A**
< 1/8 **WHITE PLAINS, NY 10601**
0.030 mi.
157 ft. **Site 9 of 18 in cluster B**

Relative: **Lower**

Actual: **195 ft.**

UST:

Name:	NEW YORK POWER AUTHORITY
Address:	123 MAIN STREET
City,State,Zip:	WHITE PLAINS, NY 10601
Id/Status:	3-602326 / Active
Program Type:	PBS
Region:	STATE
DEC Region:	3
Expiration Date:	01/08/2027
UTM X:	603467.93958
UTM Y:	4543136.07179

NEW YORK POWER AUTHORITY (Continued) **1004902218**

Site Type: Apartment Building/Office Building

Affiliation Records:

Site Id: 488037
Affiliation Type: Mail Contact
Company Name: NEW YORK POWER AUTHORITY
Contact Type: VICE PRESIDENT, ENVIRONMENT, HEALTH & SAFETY
Contact Name: JOHN NOLAN
Address1: 123 MAIN STREET
Address2: Not reported
City: WHITE PLAINS
State: NY
Zip Code: 10601
Country Code: 001
Phone: (914) 287-3797
EMail: JOHN.NOLANIII@NYPA.GOV
Fax Number: Not reported
Modified By: SJWALSH
Date Last Modified: 2024-05-10

Site Id: 488037
Affiliation Type: Facility Operator
Company Name: NEW YORK POWER AUTHORITY
Contact Type: Not reported
Contact Name: JOHN NOLAN
Address1: Not reported
Address2: Not reported
City: Not reported
State: NN
Zip Code: Not reported
Country Code: 001
Phone: (914) 287-3797
EMail: Not reported
Fax Number: Not reported
Modified By: BHYUKOWE
Date Last Modified: 2017-01-20

Site Id: 488037
Affiliation Type: Emergency Contact
Company Name: NEW YORK POWER AUTHORITY
Contact Type: Not reported
Contact Name: JOHN NOLAN
Address1: Not reported
Address2: Not reported
City: Not reported
State: NN
Zip Code: Not reported
Country Code: 999
Phone: (914) 260-5193
EMail: Not reported
Fax Number: Not reported
Modified By: BHYUKOWE
Date Last Modified: 2016-10-13

Site Id: 488037
Affiliation Type: Facility Owner
Company Name: NEW YORK POWER AUTHORITY
Contact Type: VICE PRESIDENT, ENVIRONMENT, HEALTH & SAFETY

NEW YORK POWER AUTHORITY (Continued) **1004902218**

Contact Name:	PATRICIA MEEHAN
Address1:	123 MAIN STREET
Address2:	Not reported
City:	WHITE PLAINS
State:	NY
Zip Code:	10601
Country Code:	001
Phone:	(914) 287-3797
EMail:	Not reported
Fax Number:	Not reported
Modified By:	AAVITARI
Date Last Modified:	2020-04-20

Tank Info:

Tank Number:	1
Tank ID:	249946
Tank Status:	In Service
Material Name:	In Service
Capacity Gallons:	2086
Install Date:	12/01/1981
Date Tank Closed:	Not reported
Registered:	True
Tank Location:	Underground
Tank Type:	Equivalent technology
Tightness Test Method:	-
Date Test:	Not reported
Next Test Date:	Not reported
Pipe Model:	Not reported
Modified By:	SJWALSH
Last Modified:	05/14/2024

Equipment Records:

F99 - Pipe External Protection - Other
H05 - Tank Leak Detection - In-Tank System (ATG)
E04 - Piping Secondary Containment - Double walled UG
A00 - Tank Internal Protection - None
B04 - Tank External Protection - Fiberglass
D08 - Pipe Type - Equivalent Technology
I02 - Overfill - High Level Alarm
K01 - Spill Prevention - Catch Basin
L09 - Piping Leak Detection - Exempt Suction Piping
C03 - Pipe Location - Aboveground/Underground Combination
F04 - Pipe External Protection - Fiberglass
G00 - Tank Secondary Containment - None
J02 - Dispenser - Suction Dispenser
L01 - Piping Leak Detection - Interstitial - Electronic Monitoring

Tank Number:	2
Tank ID:	249947
Tank Status:	In Service
Material Name:	In Service
Capacity Gallons:	9410
Install Date:	12/01/1981
Date Tank Closed:	Not reported
Registered:	True

NEW YORK POWER AUTHORITY (Continued) **1004902218**

Tank Location:	Underground
Tank Type:	Equivalent technology
Tightness Test Method:	-
Date Test:	Not reported
Next Test Date:	Not reported
Pipe Model:	Not reported
Modified By:	SJWALSH
Last Modified:	05/14/2024

Equipment Records:

F99 - Pipe External Protection - Other
H05 - Tank Leak Detection - In-Tank System (ATG)
E04 - Piping Secondary Containment - Double walled UG
A00 - Tank Internal Protection - None
B04 - Tank External Protection - Fiberglass
D08 - Pipe Type - Equivalent Technology
I02 - Overfill - High Level Alarm
K01 - Spill Prevention - Catch Basin
L09 - Piping Leak Detection - Exempt Suction Piping
C03 - Pipe Location - Aboveground/Underground Combination
F04 - Pipe External Protection - Fiberglass
G00 - Tank Secondary Containment - None
J02 - Dispenser - Suction Dispenser
L01 - Piping Leak Detection - Interstitial - Electronic Monitoring

WESTCHESTER CO. UST:

Name:	NEW YORK POWER AUTHORITY
Address:	123 MAIN STREET
City,State,Zip:	WHITE PLAINS, NY 10601
Id/Status:	3-496812 / Administratively Closed
Operator Name:	NEW YORK POWER AUTHORITY
Owner Name:	New York Power Authority
Owner Street:	123 Main Street
Owner Address2:	Not reported
Owner City:	White Plains
Owner State:	NY
Owner Zipcode:	10601
GDS Number:	Not reported
Tank Number:	1
Status:	1. In-Service
Capacity:	2086
Product Stored:	0008. Diesel
Product Stored Percent:	Not reported
Tank Leak Detection:	5. In-Tank System (auto tank gauge)
Date Installation:	12/01/1981
Date Perm Closure:	01/01/1900
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	6. Fiberglass reinforced plastic (FRP)
Tank Internal Protection:	0. None
Tank External Protection:	4. Fiberglass
Tank Secondary Containment:	0. None
Piping Location:	3. Aboveground/underground combination
Piping Type:	6. Fiberglass reinforced plastic (FRP)
Piping External Protection:	4. Fiberglass
Overfill Prevention:	2. High Level Alarm
Piping Secondary Containment:	4. Double-Walled (underground only)

NEW YORK POWER AUTHORITY (Continued) **1004902218**

Spill Prevention:	1. Catch Basin
Dispenser:	2. Suction
Tank Number:	2
Status:	1. In-Service
Capacity:	9410
Product Stored:	0001. #2 Fuel Oil
Product Stored Percent:	Not reported
Tank Leak Detection:	5. In-Tank System (auto tank gauge)
Date Installation:	12/01/1981
Date Perm Closure:	01/01/1900
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	6. Fiberglass reinforced plastic (FRP)
Tank Internal Protection:	0. None
Tank External Protection:	4. Fiberglass
Tank Secondary Containment:	0. None
Piping Location:	3. Aboveground/underground combination
Piping Type:	6. Fiberglass reinforced plastic (FRP)
Piping External Protection:	4. Fiberglass
Overfill Prevention:	2. High Level Alarm
Piping Secondary Containment:	4. Double-Walled (underground only)
Spill Prevention:	1. Catch Basin
Dispenser:	2. Suction

AST:

Name:	NEW YORK POWER AUTHORITY
Address:	123 MAIN STREET
City,State,Zip:	WHITE PLAINS, NY 10601
Region:	STATE
DEC Region:	3
Site Status:	Active
Facility Id:	3-602326
Program Type:	PBS
UTM X:	603467.93958
UTM Y:	4543136.07179
Expiration Date:	01/08/2027
Site Type:	Apartment Building/Office Building

Affiliation Records:

Site Id:	488037
Affiliation Type:	Mail Contact
Company Name:	NEW YORK POWER AUTHORITY
Contact Type:	VICE PRESIDENT, ENVIRONMENT, HEALTH & SAFETY
Contact Name:	JOHN NOLAN
Address1:	123 MAIN STREET
Address2:	Not reported
City:	WHITE PLAINS
State:	NY
Zip Code:	10601
Country Code:	001
Phone:	(914) 287-3797
EMail:	JOHN.NOLANIII@NYPA.GOV
Fax Number:	Not reported
Modified By:	SJWALSH
Date Last Modified:	2024-05-10

NEW YORK POWER AUTHORITY (Continued) **1004902218**

Site Id:	488037
Affiliation Type:	Facility Operator
Company Name:	NEW YORK POWER AUTHORITY
Contact Type:	Not reported
Contact Name:	JOHN NOLAN
Address1:	Not reported
Address2:	Not reported
City:	Not reported
State:	NN
Zip Code:	Not reported
Country Code:	001
Phone:	(914) 287-3797
EMail:	Not reported
Fax Number:	Not reported
Modified By:	BHYUKOWE
Date Last Modified:	2017-01-20

Site Id:	488037
Affiliation Type:	Emergency Contact
Company Name:	NEW YORK POWER AUTHORITY
Contact Type:	Not reported
Contact Name:	JOHN NOLAN
Address1:	Not reported
Address2:	Not reported
City:	Not reported
State:	NN
Zip Code:	Not reported
Country Code:	999
Phone:	(914) 260-5193
EMail:	Not reported
Fax Number:	Not reported
Modified By:	BHYUKOWE
Date Last Modified:	2016-10-13

Site Id:	488037
Affiliation Type:	Facility Owner
Company Name:	NEW YORK POWER AUTHORITY
Contact Type:	VICE PRESIDENT, ENVIRONMENT, HEALTH & SAFETY
Contact Name:	PATRICIA MEEHAN
Address1:	123 MAIN STREET
Address2:	Not reported
City:	WHITE PLAINS
State:	NY
Zip Code:	10601
Country Code:	001
Phone:	(914) 287-3797
EMail:	Not reported
Fax Number:	Not reported
Modified By:	AAVITARI
Date Last Modified:	2020-04-20

Tank Info:

Tank Number:	3
Tank Id:	249948

Equipment Records:

NEW YORK POWER AUTHORITY (Continued) **1004902218**

C01 - Pipe Location - Aboveground
H99 - Tank Leak Detection - Other
I04 - Overfill - Product Level Gauge (A/G)
A00 - Tank Internal Protection - None
B01 - Tank External Protection - Painted/Asphalt Coating
D01 - Pipe Type - Steel/Carbon Steel/Iron
E00 - Piping Secondary Containment - None
F01 - Pipe External Protection - Painted/Asphalt Coating
I03 - Overfill - Automatic Shut-Off
K00 - Spill Prevention - None
L99 - Piping Leak Detection - Other
G01 - Tank Secondary Containment - Diking (Aboveground)
H06 - Tank Leak Detection - Impervious Barrier/Concrete Pad (A/G)
J03 - Dispenser - Gravity

Tank Location: Aboveground - on saddles, legs, racks, etc.... Tank bottom is elevated above grade or tank pad, allowing visual inspection.
Tank Type: Steel/Carbon Steel/Iron
Tank Status: In Service
Pipe Model: Not reported
Install Date: 01/01/2000
Capacity Gallons: 30
Tightness Test Method: -
Date Test: Not reported
Next Test Date: Not reported
Date Tank Closed: 12/14/2023
Register: True
Modified By: SJWALSH
Last Modified: 05/14/2024
Material Name: Diesel (E-Gen)

Tank Number: 3A
Tank Id: 302596

Equipment Records:

F00 - Pipe External Protection - None
A00 - Tank Internal Protection - None
B01 - Tank External Protection - Painted/Asphalt Coating
D01 - Pipe Type - Steel/Carbon Steel/Iron
E00 - Piping Secondary Containment - None
H01 - Tank Leak Detection - Interstitial - Electronic Monitoring
I01 - Overfill - Float Vent Valve
I02 - Overfill - High Level Alarm
L99 - Piping Leak Detection - Other
G12 - Tank Secondary Containment - Double-Walled (AG only)
J03 - Dispenser - Gravity
C01 - Pipe Location - Aboveground

Tank Location: Aboveground - on saddles, legs, racks, etc.... Tank bottom is elevated above grade or tank pad, allowing visual inspection.
Tank Type: Steel/Carbon Steel/Iron
Tank Status: In Service
Pipe Model: Not reported
Install Date: 11/18/2023
Capacity Gallons: 175
Tightness Test Method: -
Date Test: Not reported
Next Test Date: Not reported
Date Tank Closed: Not reported

NEW YORK POWER AUTHORITY (Continued) **1004902218**

Register: True
Modified By: SJWALSH
Last Modified: 05/14/2024
Material Name: Diesel (E-Gen)

Tank Number: 4
Tank Id: 249949

Equipment Records:
C01 - Pipe Location - Aboveground
H99 - Tank Leak Detection - Other
I04 - Overfill - Product Level Gauge (A/G)
A00 - Tank Internal Protection - None
B01 - Tank External Protection - Painted/Asphalt Coating
D01 - Pipe Type - Steel/Carbon Steel/Iron
E00 - Piping Secondary Containment - None
F01 - Pipe External Protection - Painted/Asphalt Coating
G09 - Tank Secondary Containment - Modified Double-Walled (Aboveground)
I03 - Overfill - Automatic Shut-Off
K00 - Spill Prevention - None
L99 - Piping Leak Detection - Other
J03 - Dispenser - Gravity

Tank Location: Aboveground - on saddles, legs, racks, etc.... Tank bottom is elevated above grade or tank pad, allowing visual inspection.
Tank Type: Steel/Carbon Steel/Iron
Tank Status: In Service
Pipe Model: Not reported
Install Date: 01/01/2000
Capacity Gallons: 100
Tightness Test Method: -
Date Test: Not reported
Next Test Date: Not reported
Date Tank Closed: Not reported
Register: True
Modified By: SJWALSH
Last Modified: 05/14/2024
Material Name: Diesel (E-Gen)

Tank Number: 5
Tank Id: 286570

Equipment Records:
A00 - Tank Internal Protection - None
B01 - Tank External Protection - Painted/Asphalt Coating
D01 - Pipe Type - Steel/Carbon Steel/Iron
F01 - Pipe External Protection - Painted/Asphalt Coating
G10 - Tank Secondary Containment - Impervious Underlayment
K00 - Spill Prevention - None
H06 - Tank Leak Detection - Impervious Barrier/Concrete Pad (A/G)
L00 - Piping Leak Detection - None
C01 - Pipe Location - Aboveground
E01 - Piping Secondary Containment - Diking (AG only)
I04 - Overfill - Product Level Gauge (A/G)
J00 - Dispenser - None

Tank Location: Aboveground - on saddles, legs, racks, etc.... Tank bottom is elevated

NEW YORK POWER AUTHORITY (Continued) **1004902218**

	above grade or tank pad, allowing visual inspection.
Tank Type:	Steel/Carbon Steel/Iron
Tank Status:	Closed - Removed
Pipe Model:	Not reported
Install Date:	04/04/2020
Capacity Gallons:	150
Tightness Test Method:	-
Date Test:	Not reported
Next Test Date:	Not reported
Date Tank Closed:	05/05/2020
Register:	True
Modified By:	IANEWSON
Last Modified:	10/04/2023
Material Name:	Diesel (E-Gen)

WESTCHESTER CO. AST:

Name:	NEW YORK POWER AUTHORITY
Address:	123 MAIN STREET
City,State,Zip:	WHITE PLAINS, NY 10601
PBS Number:	3-496812
Site Status:	Administratively Closed
GDS Number:	Not reported
Operator Name:	NEW YORK POWER AUTHORITY
Owner Name:	New York Power Authority
Owner Street:	123 Main Street
Owner Address2:	Not reported
Owner City/State/Zip:	White Plains, NY 10601

Tank Number:	3
Status:	1. In-Service
Date Installation:	12/01/1981
Capacity:	30
Product Stored:	0008. Diesel
Product Stored Percent:	0
Date Perm Closure:	01/01/1900
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Leak Detection:	other
Tank Secondary Containment:	1. Diking (aboveground only)
Piping Location:	1. Aboveground
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	1. Painted/Asphalt Coating
Piping Leak Detection:	0. None
Piping Secondary Containment:	0. None
Overfill Prevention:	3. Automatic Shut-off,4. Product Level Gauge (Aboveground Only)
Spill Prevention:	0. None
Dispenser:	2. Suction

Tank Number:	4
Status:	1. In-Service
Date Installation:	01/01/2000
Capacity:	100
Product Stored:	0008. Diesel
Product Stored Percent:	0

NEW YORK POWER AUTHORITY (Continued) **1004902218**

Date Perm Closure:	01/01/1900
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Leak Detection:	other
Tank Secondary Containment:	9. Modified double-walled (aboveground only)
Piping Location:	1. Aboveground
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	1. Painted/Asphalt Coating
Piping Leak Detection:	0. None
Piping Secondary Containment:	0. None
Overfill Prevention:	3. Automatic Shut-off,4. Product Level Gauge (Aboveground Only)
Spill Prevention:	0. None
Dispenser:	2. Suction

B55 **NEW YORK POWER AUTHORITY** **UST FINDER** **1028592447**
ENE **123 MAIN STREET** **N/A**
< 1/8 **WHITE PLAINS, NY 10601**
0.030 mi.
157 ft. **Site 10 of 18 in cluster B**

Relative: **Lower**
Actual: **195 ft.**

UST FINDER:

Object ID:	304402
Facility ID:	NY488037
Name:	NEW YORK POWER AUTHORITY
Address:	123 MAIN STREET
City,State,Zip:	WHITE PLAINS, NY 10601
Address Match Type:	Not reported
Open USTs:	2
Closed USTs:	0
TOS USTs:	0
Population 1500ft:	3581
Private Wells 1500ft:	0
Within 100yr Floodplain:	No
Land Use:	Developed, High Intensity
Within SPA:	Yes
SPA PWS Facility ID:	NY7003493_76968
SPA Water Type:	SW - Surface Water
SPA Facility Type:	RS - Reservoir
SPA HUC12:	020301020103
Within WHPA:	No
WHPA PWS Facility ID:	Not reported
WHPA Water Type:	Not reported
WHPA Facility Type:	Not reported
WHPA HUC12:	Not reported
Facility Status:	Open UST(s)
Date of Last Inspection:	Not reported
EPA Region:	2
Tribe:	Not reported
Coordinate Source:	State
X Coord:	-73.769196
Y Coord:	41.032231
Latitude:	41.032231
Longitude:	-73.769196

UST FINDER:

Object ID:	1291279

NEW YORK POWER AUTHORITY (Continued) **1028592447**

Facility ID:	NY488037
Tank ID:	NY106133
Tank Status:	Open
Installation Date:	1981/12/01 16:00:00+00
Removal Date:	Not reported
Tank Capacity:	9410
Substances:	Not reported
Tank Wall Type:	Not reported

Object ID:	1291280
Facility ID:	NY488037
Tank ID:	NY103396
Tank Status:	Open
Installation Date:	1981/12/01 16:00:00+00
Removal Date:	Not reported
Tank Capacity:	2086
Substances:	Not reported
Tank Wall Type:	Not reported

B56 **NEW YORK POWER AUTHORITY-WHITE PLAINS OFFICE** **RCRA-VSQG** **1004758118**
ENE **123 MAIN ST** **NY Spills** **NYD986982999**
< 1/8 **WHITE PLAINS, NY 10601** **FINDS**
0.030 mi. **ECHO**
157 ft. **Site 11 of 18 in cluster B** **E MANIFEST**
NY MANIFEST

Relative:
Lower

Actual:
195 ft.

RCRA Listings:

Date Form Received by Agency:	20190613
Handler Name:	New York Power Authority-White Plains Office
Handler Address:	Main St
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYD986982999
Contact Name:	BRIAN DORTCH
Contact Address:	MAIN ST
Contact City,State,Zip:	WHITE PLAINS, NY 10601
Contact Telephone:	914-287-3831
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	State
Federal Waste Generator Description:	Conditionally Exempt Small Quantity Generator
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Handler Activities
State District Owner:	Ny
State District:	NYSDEC R3
Mailing Address:	MAIN ST
Mailing City,State,Zip:	WHITE PLAINS, NY 10601
Owner Name:	New York Power Auth
Owner Type:	State
Operator Name:	New York Power Auth
Operator Type:	State
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No

NEW YORK POWER AUTHORITY-WHITE PLAINS OFFICE (Continued) **1004758118**

Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20240102
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Hazardous Waste Summary:

Waste Code:	D001
Waste Description:	Ignitable Waste
Waste Code:	D002
Waste Description:	Corrosive Waste
Waste Code:	D006
Waste Description:	Cadmium
Waste Code:	D008
Waste Description:	Lead

Handler - Owner Operator:

Owner/Operator Indicator:	Operator
Owner/Operator Name:	NEW YORK POWER AUTH
Legal Status:	State

NEW YORK POWER AUTHORITY-WHITE PLAINS OFFICE (Continued) **1004758118**

Date Became Current: Not reported
Date Ended Current: Not reported
Owner/Operator Address: 123 MAIN ST
Owner/Operator City,State,Zip: WHITE PLAINS, NY 10601
Owner/Operator Telephone: 914-681-6200
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Owner
Owner/Operator Name: NEW YORK POWER AUTH
Legal Status: State
Date Became Current: Not reported
Date Ended Current: Not reported
Owner/Operator Address: 123 MAIN ST
Owner/Operator City,State,Zip: WHITE PLAINS, NY 10601
Owner/Operator Telephone: 914-681-6200
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Owner
Owner/Operator Name: NEW YORK POWER AUTH
Legal Status: State
Date Became Current: Not reported
Date Ended Current: Not reported
Owner/Operator Address: 123 MAIN ST
Owner/Operator City,State,Zip: WHITE PLAINS, NY 10601
Owner/Operator Telephone: 914-681-6200
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Owner
Owner/Operator Name: NEW YORK POWER AUTH
Legal Status: State
Date Became Current: Not reported
Date Ended Current: Not reported
Owner/Operator Address: 123 MAIN ST
Owner/Operator City,State,Zip: WHITE PLAINS, NY 10601
Owner/Operator Telephone: 914-681-6200
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Operator
Owner/Operator Name: NEW YORK POWER AUTH
Legal Status: State
Date Became Current: Not reported
Date Ended Current: Not reported
Owner/Operator Address: 123 MAIN ST
Owner/Operator City,State,Zip: WHITE PLAINS, NY 10601
Owner/Operator Telephone: 914-681-6200
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

NEW YORK POWER AUTHORITY-WHITE PLAINS OFFICE (Continued) **1004758118**

Historic Generators:

Receive Date:	20060101
Handler Name:	NEW YORK POWER AUTH
Federal Waste Generator Description:	Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20070101
Handler Name:	NEW YORK POWER AUTH
Federal Waste Generator Description:	Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	19911212
Handler Name:	NEW YORK POWER AUTH
Federal Waste Generator Description:	Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20190613
Handler Name:	NEW YORK POWER AUTHORITY-WHITE PLAINS OFFICE
Federal Waste Generator Description:	Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	No
Electronic Manifest Broker:	No

NEW YORK POWER AUTHORITY-WHITE PLAINS OFFICE (Continued) **1004758118**

Receive Date: 19920227
Handler Name: NEW YORK POWER AUTHORITY
Federal Waste Generator Description: Large Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Code: 2211
NAICS Description: Electric Power Generation, Transmission And Distribution

NAICS Code: 22111
NAICS Description: Electric Power Generation

Has the Facility Received Notices of Violations:
Found Violation: No
Agency Which Determined Violation: Not reported
Violation Short Description: Not reported
Date Violation was Determined: Not reported
Actual Return to Compliance Date: Not reported
Return to Compliance Qualifier: Not reported
Violation Responsible Agency: Not reported
Scheduled Compliance Date: Not reported
Enforcement Identifier: Not reported
Date of Enforcement Action: Not reported
Enforcement Responsible Agency: Not reported
Enforcement Docket Number: Not reported
Enforcement Attorney: Not reported
Corrective Action Component: Not reported
Appeal Initiated Date: Not reported
Appeal Resolution Date: Not reported
Disposition Status Date: Not reported
Disposition Status: Not reported
Disposition Status Description: Not reported
Consent/Final Order Sequence Number: Not reported
Consent/Final Order Respondent Name: Not reported
Consent/Final Order Lead Agency: Not reported
Enforcement Type: Not reported
Enforcement Responsible Person: Not reported
Enforcement Responsible Sub-Organization: Not reported
SEP Sequence Number: Not reported
SEP Expenditure Amount: Not reported
SEP Scheduled Completion Date: Not reported
SEP Actual Date: Not reported
SEP Defaulted Date: Not reported
SEP Type: Not reported
SEP Type Description: Not reported
Proposed Amount: Not reported
Final Monetary Amount: Not reported
Paid Amount: Not reported

NEW YORK POWER AUTHORITY-WHITE PLAINS OFFICE (Continued) **1004758118**

Final Count:	Not reported
Final Amount:	Not reported

Evaluation Action Summary:

Evaluation Date:	20151005
Evaluation Responsible Agency:	State
Found Violation:	No
Evaluation Type Description:	COMPLIANCE EVALUATION INSPECTION
Evaluation Responsible Person Identifier:	NYFKY
Evaluation Responsible Sub-Organization:	R3
Actual Return to Compliance Date:	Not reported
Scheduled Compliance Date:	Not reported
Date of Request:	Not reported
Date Response Received:	Not reported
Request Agency:	Not reported
Former Citation:	Not reported

SPILLS:

Name:	OFFICE BUILDING
Address:	123 MAIN ST
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	2305237 / 2023-09-18
Facility ID:	2305237
Facility Type:	ER
DER Facility ID:	602770
Site ID:	657171
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	C4
SWIS:	6017
Spill Date:	2023-09-16
Investigator:	TDGHIOSA
Referred To:	Not reported
Reported to Dept:	2023-09-18
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Other
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2023-09-18
Spill Record Last Update:	2023-09-18
Spiller Name:	JOHN NOLAN
Spiller Company:	NYPA
Spiller Address:	123 MAIN ST
Spiller Company:	999
Contact Name:	JOHN NOLAN
Latitude:	Not reported
Longitude:	Not reported
DEC Memo:	9/18/2023 NYPA is in process of cutting power to the building. During work they utilized a diesel

NEW YORK POWER AUTHORITY-WHITE PLAINS OFFICE (Continued) **1004758118**

generator. Workers overfilled the generator on Saturday, spilling 20 gallons to floor (work is
happening on 17th floor of the building). Absorbent, pads, and boom were used to contain spill.
Spent materials are drummed up and waiting a bill of ladding for off-site disposal. Nothing escaped
to environment. -ARM 9/18/2023 Update: Cleanup is complete and no oil discharge to the
environmental. NFA. -ARM

Remarks: appx 20 gals released to an interior room with no drain. solono ed valve stuck clean up finished 55 gal drum with sand and product.

All Materials:

Site ID:	657171
Operable Unit ID:	1404075
Operable Unit:	01
Material ID:	2421049
Material Code:	0008
Material Name:	diesel
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	20.00
Units:	G
Recovered:	Not reported
Resource Affected:	Not reported
Oxygenate:	Not reported

FINDS:

Registry ID: 110009481220

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:

The New York Department of Environmental Conservation Facility Information System (FIS) database houses all information about facilities that are regulated or of environmental interest to the state of New York.
The Air Facility System (AFS) contains compliance and permit data for stationary sources of air pollution regulated by the EPA, state, and local air pollution agencies.
ICIS-Air (AIR) AIR is the modernization of the Air Facility System (AFS) into the Integrated Compliance Information System (ICIS). AIR contains enforcement, compliance, and permit data for stationary sources of air pollution regulated by the EPA, State, and Local air pollution agencies.
The Resource Conservation and Recovery Act Information System (RCRAInfo) is EPA's comprehensive information system in support of the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. It tracks many types of information about generators, transporters, treaters, storers, and disposers of hazardous waste.

Registry ID: 110022533775

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:

The National Compliance Database (NCDB) supports implementation of the

NEW YORK POWER AUTHORITY-WHITE PLAINS OFFICE (Continued) **1004758118**

Federal Insecticide, Fungicide, and Rodenticide Act (FIFRA) and the Toxic Substances Control Act (TSCA).
The database that supports the Toxic Substances Control Act (TSCA) of 1976, which provides EPA with authority to require reporting, record-keeping and testing requirements, and restrictions relating to chemical substances and/or mixtures. Certain substances are generally excluded from TSCA, including, among others, food, drugs, cosmetics and pesticides. TSCA addresses the production, importation, use, and disposal of specific chemicals including polychlorinated biphenyls (PCBs), asbestos, radon and lead-based paint.
The Integrated Compliance Information System (ICIS) provides a database that, when complete, will contain integrated enforcement and compliance information across most of EPA's programs. The vision for ICIS is to replace EPA's independent databases that contain enforcement data with a single repository for that information. Currently, ICIS contains all Federal Administrative and Judicial enforcement actions and a subset of the Permit Compliance System (PCS), which supports the National Pollutant Discharge Elimination System (NPDES). This information is maintained in ICIS by EPA in the Regional offices and it at Headquarters. A future release of ICIS will completely replace PCS and will integrate that information with Federal actions already in the system. ICIS also has the capability to track other activities that support compliance and enforcement programs, including incident tracking, compliance assistance, and compliance monitoring.

Click this hyperlink while viewing on your computer to access additional FINDS: detail in the EDR Site Report.

ECHO:

Envid:	1004758118
Registry ID:	110009481220

DFR URL:

Name:	NEW YORK POWER AUTHORITY-WHITE PLAINS OFFICE
Address:	123 MAIN ST
City,State,Zip:	WHITE PLAINS, NY 10601

E MANIFEST:

Manifest Tracking Number:	014476110FLE
Last Updated Date:	20200918
Shipped Date:	20200817
Received Date:	20200829
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	NYD986982999
Generator Name:	New York Power Auth - White Plains Office
Generator Location Street Number:	123
Generator Location Street 1:	123 MAIN ST
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601
Generator Mail Street Number:	123
Generator Mail Street 1:	MAIN ST
Generator Mail Street 2:	WHITE PLAINS HEADQUARTERS

NEW YORK POWER AUTHORITY-WHITE PLAINS OFFICE (Continued) **1004758118**

Generator Mail City:	WHITE PLAINS
Generator Mail Zip:	10601
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	ARD069748192
Designated Facility Name:	Clean Harbors El Dorado Llc
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	309 American Circle
Designated Facility Mail City:	El Dorado
Designated Facility Mail Zip:	71730
Designated Facility Mail State:	AR
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	309 American Circle
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	El Dorado
Designated Facility Location Zip:	71730
Designated Facility Location State:	AR
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Manifest Tracking Number:	016944887FLE
Last Updated Date:	20220225
Shipped Date:	20220131
Received Date:	20220203
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	NYD986982999
Generator Name:	New York Power Authority
Generator Location Street Number:	Not reported
Generator Location Street 1:	123 MAIN STREET
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	123 Main Street
Generator Mail Street 2:	Not reported
Generator Mail City:	White Plains
Generator Mail Zip:	10601
Generator Mail State:	NY
Generator Contact Company Name:	New York Power Authority
Designated Facility EPA ID:	ARD069748192
Designated Facility Name:	Clean Harbors El Dorado Llc
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	309 American Circle
Designated Facility Mail City:	El Dorado
Designated Facility Mail Zip:	71730
Designated Facility Mail State:	AR
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	309 American Circle
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	El Dorado
Designated Facility Location Zip:	71730

NEW YORK POWER AUTHORITY-WHITE PLAINS OFFICE (Continued) **1004758118**

Designated Facility Location State:	AR
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N
Manifest Tracking Number:	013866490FLE
Last Updated Date:	20191111
Shipped Date:	20191011
Received Date:	20191016
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	NYD986982999
Generator Name:	New York Power Authority
Generator Location Street Number:	Not reported
Generator Location Street 1:	123 MAIN STREET
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	123 Main Street
Generator Mail Street 2:	Not reported
Generator Mail City:	White Plains
Generator Mail Zip:	10601
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	ARD069748192
Designated Facility Name:	Clean Harbors El Dorado Llc
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	309 American Circle
Designated Facility Mail City:	El Dorado
Designated Facility Mail Zip:	71730
Designated Facility Mail State:	AR
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	309 American Circle
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	El Dorado
Designated Facility Location Zip:	71730
Designated Facility Location State:	AR
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N
Manifest Tracking Number:	011960399FLE
Last Updated Date:	20181106
Shipped Date:	20180928
Received Date:	20181011
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	NYD986982999
Generator Name:	New York Power Authority
Generator Location Street Number:	Not reported
Generator Location Street 1:	123 MAIN STREET
Generator Location Street 2:	Not reported

NEW YORK POWER AUTHORITY-WHITE PLAINS OFFICE (Continued) **1004758118**

Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	123 Main Street
Generator Mail Street 2:	Not reported
Generator Mail City:	White Plains
Generator Mail Zip:	10601
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	ARD069748192
Designated Facility Name:	Clean Harbors El Dorado Llc
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	309 American Circle
Designated Facility Mail City:	El Dorado
Designated Facility Mail Zip:	71730
Designated Facility Mail State:	AR
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	309 American Circle
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	El Dorado
Designated Facility Location Zip:	71730
Designated Facility Location State:	AR
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Manifest Tracking Number:	018380217FLE
Last Updated Date:	20231122
Shipped Date:	20231018
Received Date:	20231102
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	NYD986982999
Generator Name:	New York Power Authority
Generator Location Street Number:	123
Generator Location Street 1:	123 MAIN STREET
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601
Generator Mail Street Number:	123
Generator Mail Street 1:	Main Street
Generator Mail Street 2:	Not reported
Generator Mail City:	White Plains
Generator Mail Zip:	10601
Generator Mail State:	NY
Generator Contact Company Name:	New York Power Authority
Designated Facility EPA ID:	ARD069748192
Designated Facility Name:	Clean Harbors El Dorado Llc
Designated Facility Mail Street Number:	301
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	309 American Circle
Designated Facility Mail City:	El Dorado
Designated Facility Mail Zip:	71730

NEW YORK POWER AUTHORITY-WHITE PLAINS OFFICE (Continued) **1004758118**

Designated Facility Mail State:	AR
Designated Facility Location Street Number:	309
Designated Facility Location Street 1:	American Circle
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	El Dorado
Designated Facility Location Zip:	71730
Designated Facility Location State:	AR
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Manifest Tracking Number:	015785362FLE
Last Updated Date:	20210719
Shipped Date:	20210621
Received Date:	20210625
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	NYD986982999
Generator Name:	New York Power Authority
Generator Location Street Number:	Not reported
Generator Location Street 1:	123 MAIN STREET
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	123 Main Street
Generator Mail Street 2:	Not reported
Generator Mail City:	White Plains
Generator Mail Zip:	10601
Generator Mail State:	NY
Generator Contact Company Name:	New York Power Authority
Designated Facility EPA ID:	ARD069748192
Designated Facility Name:	Clean Harbors El Dorado Llc
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	309 American Circle
Designated Facility Mail City:	El Dorado
Designated Facility Mail Zip:	71730
Designated Facility Mail State:	AR
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	309 American Circle
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	El Dorado
Designated Facility Location Zip:	71730
Designated Facility Location State:	AR
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Manifest Tracking Number:	013258416FLE
Last Updated Date:	20190507
Shipped Date:	20190408
Received Date:	20190411
Manifest Status:	Signed
Submission Type:	DataImage5Copy

NEW YORK POWER AUTHORITY-WHITE PLAINS OFFICE (Continued) **1004758118**

Origin Type:	Service
Generator EPA ID:	NYD986982999
Generator Name:	New York Power Authority
Generator Location Street Number:	Not reported
Generator Location Street 1:	123 MAIN STREET
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	123 Main Street
Generator Mail Street 2:	Not reported
Generator Mail City:	White Plains
Generator Mail Zip:	10601
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	ARD069748192
Designated Facility Name:	Clean Harbors El Dorado Llc
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	309 American Circle
Designated Facility Mail City:	El Dorado
Designated Facility Mail Zip:	71730
Designated Facility Mail State:	AR
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	309 American Circle
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	El Dorado
Designated Facility Location Zip:	71730
Designated Facility Location State:	AR
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Federal Waste:

Manifest Tracking Number:	013258416FLE
Waste Line Number:	1
Federal Waste Code:	D001
Federal Waste:	IGNITABLE WASTE

Transporter:

Manifest Tracking Number:	013258416FLE
Transporter Line Number:	1
Transporter EPA ID:	MAD039322250
Transporter Name:	Clean Harbors Environmental Services, Inc.

Waste Line:

Manifest Tracking Number:	013258416FLE
Waste Line Number:	1
U.S. DOT Hazardous Indicator:	Y
U.S. DOT ID Number:	UN1950
U.S. DOT Description:	Un1950, Waste Aerosols, Flammable, (Each Not Exceeding 1 L Capacity) (Each Not Exceeding 1 Lcapacity), 2.1, None
Non-Hazardous Waste Description:	Not reported
Number of Containers:	1
Container Type Code:	DF

NEW YORK POWER AUTHORITY-WHITE PLAINS OFFICE (Continued) **1004758118**

Container Type Description:	Fiberboard or plastic drums, barrels, kegs
Waste Quantity:	60
Quantity Unit of Measure Code:	P
Quantity Unit of Measure Description:	Pounds
Waste Quantity, in Tons:	0.03
Acute Waste Quantity, in Tons:	0
Non-Acute Waste Quantity, in Tons:	0.03
Waste Quantity, in Kilograms:	27.2109
Acute Waste Quantity, in Kilograms:	0
Non-Acute Waste Quantity, in Kilorgrams:	27.2109
Management Method Code:	H040
Management Method Description:	INCINERATION
Waste Residue Indicator:	N
Quantity Discrepancy Indicator:	N
Waste Type Discrepancy Indicator:	N
Waste Density:	Not reported
Waste Density Unit of Measure Code:	Not reported
Waste Density Unit of Measure Description:	Not reported
Form Code:	Not reported
Form Code Description:	Not reported
Source Code:	Not reported
Source Code Description:	Not reported
Waste Minimization Code:	Not reported
Waste Minimization Code Description:	Not reported
Consent Number:	Not reported
EPA Waste Indicator:	Y

Manifest Tracking Number:	013258416FLE
Waste Line Number:	2
U.S. DOT Hazardous Indicator:	N
U.S. DOT ID Number:	Not reported
U.S. DOT Description:	Not reported
Non-Hazardous Waste Description:	N/A, NON D.O.T. REGULATED (COOKING GREASE AND WATER), N/A, NONE
Number of Containers:	2
Container Type Code:	DF
Container Type Description:	Fiberboard or plastic drums, barrels, kegs
Waste Quantity:	800
Quantity Unit of Measure Code:	P
Quantity Unit of Measure Description:	Pounds
Waste Quantity, in Tons:	0.4
Acute Waste Quantity, in Tons:	0
Non-Acute Waste Quantity, in Tons:	0.4
Waste Quantity, in Kilograms:	362.812
Acute Waste Quantity, in Kilograms:	0
Non-Acute Waste Quantity, in Kilorgrams:	362.812
Management Method Code:	H040
Management Method Description:	INCINERATION
Waste Residue Indicator:	N
Quantity Discrepancy Indicator:	N
Waste Type Discrepancy Indicator:	N
Waste Density:	Not reported
Waste Density Unit of Measure Code:	Not reported
Waste Density Unit of Measure Description:	Not reported
Form Code:	Not reported
Form Code Description:	Not reported
Source Code:	Not reported
Source Code Description:	Not reported

NEW YORK POWER AUTHORITY-WHITE PLAINS OFFICE (Continued) **1004758118**

Waste Minimization Code:	Not reported
Waste Minimization Code Description:	Not reported
Consent Number:	Not reported
EPA Waste Indicator:	N

NY MANIFEST:

EPA ID:	NYD986982999
Country:	USA
Name:	New York Power Authority
Address:	123 MAIN ST
Address 2:	WHITE PLAINS HEADQUARTERS
City,State,Zip:	WHITE PLAINS, NY 10601
Zip 4:	Not reported
Location Address 1:	123 MAIN STREET
Location Address 2:	Not reported
Location City,State,Zip:	WHITE PLAINS, NY 10601
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	New York Power Authority
Mailing Contact:	Edward Alkiewicz
Mailing Address 1:	123 MAIN STREET
Mailing Address 2:	Not reported
Mailing City,State,Zip:	WHITE PLAINS, NY 10601
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	9142873247

Manifest Data:

Document ID:	NJA2789758
Manifest Status:	Not reported
Trans1 State ID:	Not reported
Year:	1998
Trans2 State ID:	Not reported
Generator Ship Date:	04/07/1998
Trans1 Recv Date:	04/07/1998
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	04/13/1998
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD986982999
Trans1 EPA ID:	SCD987574647
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD053288239
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported

NEW YORK POWER AUTHORITY-WHITE PLAINS OFFICE (Continued) **1004758118**

Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Ignitable Waste
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00150
Units:	Pounds
Number of Containers:	003
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00
Waste Code 7:	X900
Waste Code 8:	Not reported
Waste Code:	Not reported
Waste Code 10:	Not reported
Waste Code 11:	Not reported
Quantity:	00450
Units:	Pounds
Number of Containers:	009
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00

Document ID:	NJA1690459
Manifest Status:	Not reported
Trans1 State ID:	NJDEPS103
Year:	1994
Trans2 State ID:	S03217508
Generator Ship Date:	02/17/1994
Trans1 Recv Date:	02/17/1994
Trans2 Recv Date:	02/17/1994
TSD Site Recv Date:	02/18/1994
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD986982999
Trans1 EPA ID:	DED980918858
Trans2 EPA ID:	NJD071629976
TSDF ID 1:	NJD053288239
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Ignitable Waste
Waste Code 2:	Not reported

NEW YORK POWER AUTHORITY-WHITE PLAINS OFFICE (Continued) **1004758118**

Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	01320
Units:	Pounds
Number of Containers:	003
Container Type:	Metal drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00
Document ID:	NJA1690460
Manifest Status:	Not reported
Trans1 State ID:	NJDEPS103
Year:	1994
Trans2 State ID:	S03217508
Generator Ship Date:	02/17/1994
Trans1 Recv Date:	02/17/1994
Trans2 Recv Date:	02/17/1994
TSD Site Recv Date:	02/18/1994
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD986982999
Trans1 EPA ID:	DED980918858
Trans2 EPA ID:	NJD071629976
TSDF ID 1:	NJD053288239
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Ignitable Waste
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00040
Units:	Pounds
Number of Containers:	001
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00
Waste Code 7:	Ignitable Waste
Waste Code 8:	Not reported
Waste Code:	Not reported
Waste Code 10:	Not reported
Waste Code 11:	Not reported
Quantity:	00026

NEW YORK POWER AUTHORITY-WHITE PLAINS OFFICE (Continued) **1004758118**

Units:	Pounds
Number of Containers:	004
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00
Waste Code 12:	Ignitable Waste
Waste Code 13:	Not reported
Waste Code 14:	Not reported
Waste Code 15:	Not reported
Waste Code 16:	Not reported
Quantity:	00040
Units:	Pounds
Number of Containers:	004
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	MAD039322250
Year:	2018
Trans2 State ID:	MAD039322250
Generator Ship Date:	08/27/2010
Trans1 Recv Date:	08/27/2010
Trans2 Recv Date:	08/30/2010
TSD Site Recv Date:	09/11/2010
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD986982999
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	ARD069748192
TSDF ID 2:	Not reported
Manifest Tracking Number:	003495139FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H141
Waste Code a:	Corrosive Waste
Waste Code b:	Lead
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported

NEW YORK POWER AUTHORITY-WHITE PLAINS OFFICE (Continued) **1004758118**

Quantity: 240
Units: Pounds
Number of Containers: 3
Container Type: Fiberboard or plastic drums, barrels, kegs
Handling Method: Burn
Specific Gravity: 1

Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: MAD039322250
Year: 2018
Trans2 State ID: MAD039322250
Generator Ship Date: 08/27/2010
Trans1 Recv Date: 08/27/2010
Trans2 Recv Date: 08/30/2010
TSD Site Recv Date: 09/11/2010
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYD986982999
Trans1 EPA ID: Not reported
Trans2 EPA ID: Not reported
TSDF ID 1: ARD069748192
TSDF ID 2: Not reported
Manifest Tracking Number: 003495139FLE
Import Indicator: N
Export Indicator: N
Discr Quantity Indicator: N
Discr Type Indicator: N
Discr Residue Indicator: N
Discr Partial Reject Indicator: N
Discr Full Reject Indicator: N
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: H040
Waste Code a: Corrosive Waste
Waste Code b: Lead
Waste Code c: Not reported
Waste Code e: Not reported
Waste Code f: Not reported
Waste Code g: Not reported
Waste Code 1: Not reported
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 40
Units: Pounds
Number of Containers: 2
Container Type: Fiberboard or plastic drums, barrels, kegs
Handling Method: Burn
Specific Gravity: 1

Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: MAD039322250

NEW YORK POWER AUTHORITY-WHITE PLAINS OFFICE (Continued) **1004758118**

Year:	2018
Trans2 State ID:	MAD039322250
Generator Ship Date:	08/27/2010
Trans1 Recv Date:	08/27/2010
Trans2 Recv Date:	08/30/2010
TSD Site Recv Date:	09/11/2010
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD986982999
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	ARD069748192
TSDF ID 2:	Not reported
Manifest Tracking Number:	003495139FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H040
Waste Code a:	Ignitable Waste
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	40
Units:	Pounds
Number of Containers:	1
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	1

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	MAD039322250
Year:	2018
Trans2 State ID:	MAD039322250
Generator Ship Date:	08/27/2010
Trans1 Recv Date:	08/27/2010
Trans2 Recv Date:	08/30/2010
TSD Site Recv Date:	09/11/2010
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD986982999
Trans1 EPA ID:	Not reported

NEW YORK POWER AUTHORITY-WHITE PLAINS OFFICE (Continued) **1004758118**

Trans2 EPA ID:	Not reported
TSDF ID 1:	ARD069748192
TSDF ID 2:	Not reported
Manifest Tracking Number:	003495139FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H040
Waste Code a:	Corrosive Waste
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	2
Units:	Pounds
Number of Containers:	1
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	1

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	MAD039322250
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	03/14/2016
Trans1 Recv Date:	03/14/2016
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	03/26/2016
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD986982999
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	ARD069748192
TSDF ID 2:	Not reported
Manifest Tracking Number:	009569402FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N

NEW YORK POWER AUTHORITY-WHITE PLAINS OFFICE (Continued) **1004758118**

Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H040
Waste Code a:	Ignitable Waste
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	75
Units:	Pounds
Number of Containers:	1
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	1

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	MAD039322250
Year:	2018
Trans2 State ID:	MAD039322250
Generator Ship Date:	07/25/2012
Trans1 Recv Date:	07/25/2012
Trans2 Recv Date:	07/25/2012
TSD Site Recv Date:	08/12/2012
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD986982999
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	ARD069748192
TSDF ID 2:	Not reported
Manifest Tracking Number:	005575948FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H040
Waste Code a:	Ignitable Waste
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported

NEW YORK POWER AUTHORITY-WHITE PLAINS OFFICE (Continued) **1004758118**

Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	80
Units:	Pounds
Number of Containers:	2
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	1
Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	CTD021816889
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	11/03/2014
Trans1 Recv Date:	11/03/2014
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	11/07/2014
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD986982999
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	IND000717959
TSDF ID 2:	Not reported
Manifest Tracking Number:	000500191VES
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H010
Waste Code a:	Corrosive Waste
Waste Code b:	Lead
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	40
Units:	Pounds
Number of Containers:	1

NEW YORK POWER AUTHORITY-WHITE PLAINS OFFICE (Continued) **1004758118**

Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Recycle
Specific Gravity:	1
Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	CTD021816889
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	09/30/2014
Trans1 Recv Date:	09/30/2014
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	10/02/2014
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD986982999
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NYD049836679
TSDF ID 2:	Not reported
Manifest Tracking Number:	002580282GBF
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H135
Waste Code a:	Corrosive Waste
Waste Code b:	Chromium
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	250
Units:	Pounds
Number of Containers:	1
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Treat
Specific Gravity:	1

Click this hyperlink while viewing on your computer to access
55 additional NY MANIFEST: record(s) in the EDR Site Report.

D57 **CON EDISON SERVICE BOX: 1342** **RCRA NonGen / NLR** **1016967206**
SW **S LEXINGTON AVE & MARTINE AVE** **NY MANIFEST** **NYP004408274**
< 1/8 **WHITE PLAINS, NY 10610**
0.035 mi.
185 ft. **Site 1 of 13 in cluster D**

Relative:
Higher

Actual:
201 ft.

RCRA Listings:

Date Form Received by Agency:	20140118
Handler Name:	Con Edison Service Box: 1342
Handler Address:	S Lexington Ave & Martine Ave
Handler City,State,Zip:	WHITE PLAINS, NY 10610
EPA ID:	NYP004408274
Contact Name:	THOMAS TEELING
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	212-460-3770
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	SENIOR SCIENTIST
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PL, 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No

CON EDISON SERVICE BOX: 1342 (Continued) **1016967206**

Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20140701
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20131218
Handler Name: CON EDISON SERVICE BOX:	1342
Federal Waste Generator Description:	Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20140118
Handler Name: CON EDISON SERVICE BOX:	1342
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

List of NAICS Codes and Descriptions:

NAICS Codes:	No NAICS Codes Found

Facility Has Received Notices of Violations:

Violations:	No Violations Found

Evaluation Action Summary:

Evaluations:	No Evaluations Found

CON EDISON SERVICE BOX: 1342 (Continued) **1016967206**

NY MANIFEST:

EPA ID:	NYP004408274
Country:	USA
Name:	Con Edison
Address:	S LEXINGTON AVE & MARTINE AVE
Address 2:	SB 1342
City,State,Zip:	WHITE PLAINS, NY 10610
Zip 4:	Not reported
Location Address 1:	S LEXINGTON AVE & MARTINE AVE
Location Address 2:	SB75789
Location City,State,Zip:	WHITE PLAINS, NY 10705
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Edison
Mailing Contact:	Con Edison
Mailing Address 1:	4 IRVING PLACE
Mailing Address 2:	15TH FL
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	Not reported

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	12/18/2013
Trans1 Recv Date:	12/18/2013
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	12/19/2013
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004408274
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	011695235JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported

CON EDISON SERVICE BOX: 1342 (Continued) **1016967206**

Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	30
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

D58 **CON EDISON** **NJ MANIFEST** **S120672081**
SW **N LEXINGTON AVE & MARTINE AVE** **N/A**
< 1/8 **WHITE PLAINS, NY 10606**
0.035 mi.
185 ft. **Site 2 of 13 in cluster D**

Relative: **Higher**

Actual: **201 ft.**

NJ MANIFEST:

EPA ID:	NYP004786067
Name:	CON EDISON
Address:	N LEXINGTON AVE & MARTINE AVE
City,State,Zip:	WHITE PLAINS, NY 10606
County:	Not reported
Mailing Address:	IRVING PL 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Telephone:	Not reported
Emergency Telephone:	Not reported
Contact:	THOMAS TEELING
Comments:	Not reported
SIC Code:	Not reported
County:	NY119
Municipal:	Not reported
Previous EPAID:	Not reported
Generator Flag:	Not reported
Transporter Flag:	Not reported
TSDF Flag:	Not reported
Name Change:	Not reported
Date Change:	Not reported

Manifest Data:

EPA ID:	NYP004786067
Manifest Number:	014454292JJK
Date Shipped:	5/24/2015
TSDF EPA ID:	NJD002200046
Transporter EPA ID:	NYD006982359
Transporter 2 EPA ID:	Not reported
Transporter 3 EPA ID:	Not reported
Transporter 4 EPA ID:	Not reported
Transporter 5 EPA ID:	Not reported
Transporter 6 EPA ID:	Not reported
Transporter 7 EPA ID:	Not reported

CON EDISON (Continued) **S120672081**

Transporter 8 EPA ID:	Not reported
Transporter 9 EPA ID:	Not reported
Transporter 10 EPA ID:	Not reported
Date Trans1 Transported Waste:	Not reported
Date Trans2 Transported Waste:	Not reported
Date Trans3 Transported Waste:	Not reported
Date Trans4 Transported Waste:	Not reported
Date Trans5 Transported Waste:	Not reported
Date Trans6 Transported Waste:	Not reported
Date Trans7 Transported Waste:	Not reported
Date Trans8 Transported Waste:	Not reported
Date Trans9 Transported Waste:	Not reported
Date Trans10 Transported Waste:	Not reported
Date TSDF Received Waste:	Not reported
TSDF EPA Facility Name:	Not reported
QTY Units:	Not reported
Transporter SEQ ID:	Not reported
Transporter-1 Date:	Not reported
Waste SEQ ID:	Not reported
Waste Type Code 2:	Not reported
Waste Type Code 3:	Not reported
Waste Type Code 4:	Not reported
Waste Type Code 5:	Not reported
Waste Type Code 6:	Not reported
Date Accepted:	Not reported
Manifest Discrepancy Type:	Not reported
Data Entry Number:	Not reported
Was Load Rejected:	Not reported
Reason Load Was Rejected:	Not reported

D59 **GALLERIA WEST GARAGE 5** **NY UST** **U004440233**
SW **MARTINE AVE & SO LEXINGTON AVE** **N/A**
< 1/8 **WHITE PLAINS, NY 10601**
0.035 mi.
185 ft. **Site 3 of 13 in cluster D**

Relative:
Higher

Actual:
201 ft.

WESTCHESTER CO. UST:

Name:	GALLERIA WEST GARAGE 5
Address:	MARTINE AVE & SO LEXINGTON AVE
City,State,Zip:	WHITE PLAINS, NY 10601
Id/Status:	3-169579 / Unregulated: <1101 gal. PBS
Operator Name:	City Of White Plains
Owner Name:	City Of White Plains
Owner Street:	255 Main St
Owner Address2:	Not reported
Owner City:	White Plains
Owner State:	NY
Owner Zipcode:	10601
GDS Number:	Not reported
Tank Number:	31
Status:	3. Closed - Removed
Capacity:	1000
Product Stored:	0008. Diesel
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	12/01/1980

GALLERIA WEST GARAGE 5 (Continued) **U004440233**

Date Perm Closure:	11/01/1994
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	2. Underground/on ground
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Overfill Prevention:	0. None
Piping Secondary Containment:	Not reported
Spill Prevention:	0. None
Dispenser:	2. Suction

D60 **GALLERIA WEST GARAGE 5** **NY AST** **A100532622**
SW **MARTINE AVE & SO LEXINGTON AVE** **N/A**
< 1/8 **WHITE PLAINS, NY 10601**
0.035 mi.
185 ft. **Site 4 of 13 in cluster D**

Relative: **Higher**
Actual: **201 ft.**

WESTCHESTER CO. AST:

Name:	GALLERIA WEST GARAGE 5
Address:	MARTINE AVE & SO LEXINGTON AVE
City,State,Zip:	WHITE PLAINS, NY 10601
PBS Number:	3-169579
Site Status:	Unregulated: <1101 gal. PBS
GDS Number:	Not reported
Operator Name:	City Of White Plains
Owner Name:	City Of White Plains
Owner Street:	255 Main St
Owner Address2:	Not reported
Owner City/State/Zip:	White Plains, NY 10601
Tank Number:	32
Status:	0. Administratively closed
Date Installation:	12/01/1980
Capacity:	300
Product Stored:	0008. Diesel
Product Stored Percent:	Not reported
Date Perm Closure:	01/01/1900
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Leak Detection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	1. Aboveground
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Piping Leak Detection:	Not reported
Piping Secondary Containment:	Not reported
Overfill Prevention:	0. None
Spill Prevention:	0. None
Dispenser:	3. Gravity
Tank Number:	33
Status:	0. Administratively closed

GALLERIA WEST GARAGE 5 (Continued) **A100532622**

Date Installation:	12/01/1980
Capacity:	300
Product Stored:	0008. Diesel
Product Stored Percent:	Not reported
Date Perm Closure:	01/01/1900
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Leak Detection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	1. Aboveground
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Piping Leak Detection:	Not reported
Piping Secondary Containment:	Not reported
Overfill Prevention:	0. None
Spill Prevention:	0. None
Dispenser:	3. Gravity

D61 **CON EDISON MANHOLE: 9134** **RCRA NonGen / NLR** **1016959956**
SW **MARTINE AVE & S LEXINGTON AVE** **NY MANIFEST** **NYP004318374**
< 1/8 **WHITE PLAINS, NY 10606**
0.035 mi.
185 ft. **Site 5 of 13 in cluster D**

Relative: **Higher**
Actual: **201 ft.**

RCRA Listings:

Date Form Received by Agency:	20130704
Handler Name:	Con Edison Manhole: 9134
Handler Address:	Martine Ave & S Lexington Ave
Handler City,State,Zip:	WHITE PLAINS, NY 10606
EPA ID:	NYP004318374
Contact Name:	DONALD SENNO
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	914-925-6219
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	SR SPECIALIST
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PL, RM 828
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No

CON EDISON MANHOLE: 9134 (Continued) **1016959956**

Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20140701
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20130604
Handler Name: CON EDISON MANHOLE: 9134	
Federal Waste Generator Description:	Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20130704
Handler Name: CON EDISON MANHOLE: 9134	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny

CON EDISON MANHOLE: 9134 (Continued) **1016959956**

Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

List of NAICS Codes and Descriptions:

NAICS Codes:	No NAICS Codes Found

Facility Has Received Notices of Violations:

Violations:	No Violations Found

Evaluation Action Summary:

Evaluations:	No Evaluations Found

NY MANIFEST:

EPA ID:	NYP004318374
Country:	USA
Name:	Con Edison
Address:	MARTINE AVE & S LEXINGTON AVE
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10606
Zip 4:	Not reported
Location Address 1:	MARTINE AVE & S LEXINGTON AVE
Location Address 2:	Not reported
Location City,State,Zip:	WHITE PLAINS, NY 10601
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Edison
Mailing Contact:	Tom Teeling
Mailing Address 1:	4 IRVING PLACE - 15TH FLOOR
Mailing Address 2:	Not reported
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	2124603770

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	06/04/2013
Trans1 Recv Date:	06/04/2013
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	06/10/2013

CON EDISON MANHOLE: 9134 (Continued) **1016959956**

Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004318374
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	007019103JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	200
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

D62 **CON EDISON** **NY MANIFEST** **S117737905**
SW **S. LEXINGTON AV & MARTINE** **N/A**
< 1/8 **WHITE PLAINS, NY 10606**
0.035 mi.
185 ft. **Site 6 of 13 in cluster D**

Relative: NY MANIFEST:
Higher

EPA ID:	NYP004688545
Country:	USA
Name:	Con Edison
Address:	S. LEXINGTON AV & MARTINE
Address 2:	AV
City,State,Zip:	WHITE PLAINS, NY 10606
Zip 4:	Not reported
Location Address 1:	S. LEXINGTON AV & MARTINE
Location Address 2:	AV
Location City,State,Zip:	WHITE PLAINS, NY 10606
Location Zip 4:	Not reported
Facility Status:	Not reported

Actual:
201 ft.

CON EDISON (Continued) **S117737905**

Total Tanks: Not reported
Code: BP

Mailing:
Mailing Name: Con Edison
Mailing Contact: Tom Teeling
Mailing Address 1: 4 IRVING PL 15TH FL
Mailing Address 2: Not reported
Mailing City,State,Zip: NEW YORK, NY 10003
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: 2124603770

Manifest Data:
Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: NJ0000027193
Year: 2018
Trans2 State ID: Not reported
Generator Ship Date: 11/01/2014
Trans1 Recv Date: 11/01/2014
Trans2 Recv Date: Not reported
TSD Site Recv Date: 11/05/2014
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYP004688545
Trans1 EPA ID: Not reported
Trans2 EPA ID: Not reported
TSDF ID 1: NJD002200046
TSDF ID 2: Not reported
Manifest Tracking Number: 012772212JJK
Import Indicator: N
Export Indicator: N
Discr Quantity Indicator: N
Discr Type Indicator: N
Discr Residue Indicator: N
Discr Partial Reject Indicator: N
Discr Full Reject Indicator: N
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: H110
Waste Code a: Not reported
Waste Code b: Not reported
Waste Code c: Not reported
Waste Code e: Lead
Waste Code f: Not reported
Waste Code g: Not reported
Waste Code 1: Not reported
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 3000
Units: Pounds
Number of Containers: 1

CON EDISON (Continued) **S117737905**

Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1
Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NJ0000027193
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	11/01/2014
Trans1 Recv Date:	11/01/2014
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	11/06/2014
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004688545
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	012772217JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Not reported
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Lead
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	200
Units:	Gallons (liquids only)
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

D63 **CON EDISON** **RCRA NonGen / NLR** **1019903475**
SW **N LEXINGTON AVE & MARTINE AVE** **NYP004786067**
< 1/8 **WHITE PLAINS, NY 10606**
0.035 mi.
185 ft. **Site 7 of 13 in cluster D**

Relative: **Higher**
Actual: **201 ft.**

RCRA Listings:

Date Form Received by Agency:	20150524
Handler Name:	Con Edison
Handler Address:	N Lexington Ave & Martine Ave
Handler City,State,Zip:	WHITE PLAINS, NY 10606
EPA ID:	NYP004786067
Contact Name:	THOMAS TEELING
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	212-460-3770
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PL 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No

CON EDISON (Continued) **1019903475**

Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20160909
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20150524
Handler Name: CON EDISON	
Federal Waste Generator Description:	Large Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20150524
Handler Name: CON EDISON	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

List of NAICS Codes and Descriptions:

NAICS Codes:	No NAICS Codes Found

Facility Has Received Notices of Violations:

Violations:	No Violations Found

Evaluation Action Summary:

Evaluations:	No Evaluations Found

D64
SW
< 1/8
0.035 mi.
185 ft.

CON EDISON SERVICE BOX: 10084
S LEXINGTON AVE & MARTINE AVE
WHITE PLAINS, NY 10603

Site 8 of 13 in cluster D

RCRA NonGen / NLR **1016967207**
NY MANIFEST **NYP004408282**

Relative:
Higher

Actual:
201 ft.

RCRA Listings:

Date Form Received by Agency:	20140118
Handler Name:	Con Edison Service Box: 10084
Handler Address:	S Lexington Ave & Martine Ave
Handler City,State,Zip:	WHITE PLAINS, NY 10603
EPA ID:	NYP004408282
Contact Name:	THOMAS TEELING
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	212-460-3770
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	SENIOR SCIENTIST
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PL, 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No

CON EDISON SERVICE BOX: 10084 (Continued) **1016967207**

Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20140701
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20131218
Handler Name: CON EDISON SERVICE BOX:	10084
Federal Waste Generator Description:	Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20140118
Handler Name: CON EDISON SERVICE BOX:	10084
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

List of NAICS Codes and Descriptions:

NAICS Codes:	No NAICS Codes Found

Facility Has Received Notices of Violations:

Violations:	No Violations Found

Evaluation Action Summary:

Evaluations:	No Evaluations Found

CON EDISON SERVICE BOX: 10084 (Continued) **1016967207**

NY MANIFEST:

EPA ID:	NYP004408282
Country:	USA
Name:	Con Edison
Address:	S LEXINGTON AVE & MARTINE AVE
Address 2:	SB 10084
City,State,Zip:	WHITE PLAINS, NY 10603
Zip 4:	Not reported
Location Address 1:	S LEXINGTON AVE & MARTINE AVE
Location Address 2:	SB75789
Location City,State,Zip:	WHITE PLAINS, NY 10705
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Edison
Mailing Contact:	Con Edison
Mailing Address 1:	4 IRVING PLACE
Mailing Address 2:	15TH FL
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	Not reported

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	12/18/2013
Trans1 Recv Date:	12/18/2013
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	12/19/2013
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004408282
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	011695234JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported

CON EDISON SERVICE BOX: 10084 (Continued) **1016967207**

Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	30
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

D65 **CON EDISON** **NY MANIFEST** **S119075480**
SW **N LEXINGTON AVE & MARTINE AVE** **N/A**
< 1/8 **WHITE PLAINS, NY 10606**
0.035 mi.
185 ft. **Site 9 of 13 in cluster D**

Relative:
Higher

Actual:
201 ft.

NY MANIFEST:

EPA ID:	NYP004786067
Country:	USA
Name:	Con Edison
Address:	N LEXINGTON AVE & MARTINE AVE
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10606
Zip 4:	Not reported
Location Address 1:	MARTINE AVE & LEXINGTON AVE
Location Address 2:	M 9946
Location City,State,Zip:	WHITE PLAINS, NY
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Edison
Mailing Contact:	Dennis Huacon
Mailing Address 1:	4 IRVING PL 15TH FL
Mailing Address 2:	Not reported
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	2124603770

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	05/24/2015
Trans1 Recv Date:	05/24/2015

CON EDISON (Continued) **S119075480**

Trans2 Recv Date:	Not reported
TSD Site Recv Date:	05/26/2015
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004786067
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	014454292JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Not reported
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Lead
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	500
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

D66 **CON EDISON** **NY MANIFEST** **S118090959**
SW **MARTINE AVE & LEXINGTON AVE** **N/A**
< 1/8 **WHITE PLAINS, NY 10605**
0.035 mi.
185 ft. **Site 10 of 13 in cluster D**

Relative: NY MANIFEST:
Higher

EPA ID:	NYP004303145
Country:	USA
Name:	Con Edison
Address:	MARTINE AVE & LEXINGTON AVE
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10605
Zip 4:	Not reported
Location Address 1:	MARTINE AVE & LEXINGTON AV
Location Address 2:	E
Location City,State,Zip:	WHITE PLAINS, NY 10605

Actual:
201 ft.

CON EDISON (Continued) **S118090959**

Location Zip 4: Not reported
Facility Status: Not reported
Total Tanks: Not reported
Code: BP

Mailing:
Mailing Name: Con Edison
Mailing Contact: Tom Teeling
Mailing Address 1: 4 IRVING PLACE - 15TH FLOOR
Mailing Address 2: Not reported
Mailing City,State,Zip: NEW YORK, NY 10003
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: 2124603770

Manifest Data:
Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: NJ0000027193
Year: 2018
Trans2 State ID: Not reported
Generator Ship Date: 04/19/2013
Trans1 Recv Date: 04/19/2013
Trans2 Recv Date: Not reported
TSD Site Recv Date: 04/24/2013
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYP004303145
Trans1 EPA ID: Not reported
Trans2 EPA ID: Not reported
TSDF ID 1: NJD002200046
TSDF ID 2: Not reported
Manifest Tracking Number: 010464294JJK
Import Indicator: N
Export Indicator: N
Discr Quantity Indicator: N
Discr Type Indicator: N
Discr Residue Indicator: N
Discr Partial Reject Indicator: N
Discr Full Reject Indicator: N
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: H110
Waste Code a: Reactive Waste
Waste Code b: Not reported
Waste Code c: Not reported
Waste Code e: Not reported
Waste Code f: Not reported
Waste Code g: Not reported
Waste Code 1: Not reported
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 5000

CON EDISON (Continued) **S118090959**

Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

E67
SE
< 1/8
0.036 mi.
192 ft.

CON EDISON **NY MANIFEST** **S116043535**
MARTINE & GROVE ST **N/A**
WHITE PLAINS, NY 10610

Site 1 of 5 in cluster E

Relative:
Higher

Actual:
198 ft.

NY MANIFEST:

EPA ID:	NYP004398962
Country:	USA
Name:	Con Edison
Address:	MARTINE & GROVE ST
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10610
Zip 4:	Not reported
Location Address 1:	NS MARTIN AVE 85 FT NO GROVE ST
Location Address 2:	MH 9130
Location City,State,Zip:	WHITE PLAINS, NY
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Edison
Mailing Contact:	Con Edison
Mailing Address 1:	4 IRVING PL 15TH FL
Mailing Address 2:	Not reported
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	2124603770

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	12/03/2013
Trans1 Recv Date:	12/03/2013
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	12/04/2013
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004398962
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	011695018JJK
Import Indicator:	N

CON EDISON (Continued) **S116043535**

Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	400
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

E68 **CON EDISON** **RCRA NonGen / NLR** **1018277456**
SE **MARTINE & GROVE ST** **FINDS** **NYP004398962**
< 1/8 **WHITE PLAINS, NY 10610** **ECHO**
0.036 mi.
192 ft. **Site 2 of 5 in cluster E**

Relative: **Higher**
Actual: **198 ft.**

RCRA Listings:

Date Form Received by Agency:	20131203
Handler Name:	Con Edison
Handler Address:	Martine & Grove St
Handler City,State,Zip:	WHITE PLAINS, NY 10610
EPA ID:	NYP004398962
Contact Name:	THOMAS TEELING
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	212-460-3770
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2

CON EDISON (Continued) **1018277456**

Mailing Address:	IRVING PL, 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20160502
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20131203
Handler Name: CON EDISON	
Federal Waste Generator Description:	Large Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No

CON EDISON (Continued) **1018277456**

Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20131203
Handler Name: CON EDISON
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

FINDS:
Registry ID: 110067680290

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:
The Resource Conservation and Recovery Act Information System (RCRAInfo) is EPA's comprehensive information system in support of the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. It tracks many types of information about generators, transporters, treaters, storers, and disposers of hazardous waste.

Click this hyperlink while viewing on your computer to access additional FINDS: detail in the EDR Site Report.

ECHO:
Envid: 1018277456
Registry ID: 110067680290

DFR URL:
Name: CON EDISON
Address: MARTINE & GROVE ST
City,State,Zip: WHITE PLAINS, NY 10610

E69 **CON EDISON MANHOLE 9130** **RCRA NonGen / NLR** **1014918800**
SE **MARTINE AVE & GROVE ST MH 9130** **NY MANIFEST** **NYP004224192**
< 1/8 **WHITE PLAINS, NY 10601** **NJ MANIFEST**
0.037 mi.
197 ft. **Site 3 of 5 in cluster E**

Relative: **Higher**
Actual: **198 ft.**

RCRA Listings:

Date Form Received by Agency:	20110215
Handler Name:	Con Edison Manhole 9130
Handler Address:	Martine Ave & Grove St Mh 9130
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYP004224192
Contact Name:	GINO FRABASILE
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	914-925-6219
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	SR SPECIALIST
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PL RM 828
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No

CON EDISON MANHOLE 9130 (Continued) **1014918800**

Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20110701
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20110116
Handler Name:	CON EDISON MANHOLE 9130
Federal Waste Generator Description:	Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20110215
Handler Name:	CON EDISON MANHOLE 9130
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

List of NAICS Codes and Descriptions:

NAICS Codes:	No NAICS Codes Found

Facility Has Received Notices of Violations:

Violations:	No Violations Found

Evaluation Action Summary:

Evaluations:	No Evaluations Found

CON EDISON MANHOLE 9130 (Continued) **1014918800**

NY MANIFEST:

EPA ID:	NYP004224192
Country:	USA
Name:	Consolidated Edison
Address:	MARTINE AVE & GROVE ST MH 9130
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10601
Zip 4:	Not reported
Location Address 1:	MARTINE AVE BET. GROVE ST & COURT ST
Location Address 2:	Not reported
Location City,State,Zip:	WHITE PLAINS, NY
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Consolidated Edison
Mailing Contact:	Dennis Huacon
Mailing Address 1:	4 IRVING PLACE RM 828
Mailing Address 2:	Not reported
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	2124602757

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	01/16/2011
Trans1 Recv Date:	01/16/2011
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	01/17/2011
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004224192
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	007655817JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	Y
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H111
Waste Code a:	Lead
Waste Code b:	Not reported

CON EDISON MANHOLE 9130 (Continued) **1014918800**

Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	100
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

NJ MANIFEST:

EPA ID:	NYP004224192
Name:	CON EDISON MANHOLE 9130
Address:	MARTINE AVE & GROVE ST MH 9130
City,State,Zip:	WHITE PLAINS, NY 10601
County:	Not reported
Mailing Address:	IRVING PL RM 828
Mailing City,State,Zip:	NEW YORK, NY 10003
Telephone:	Not reported
Emergency Telephone:	Not reported
Contact:	GINO FRABASILE
Comments:	Not reported
SIC Code:	Not reported
County:	NY119
Municipal:	Not reported
Previous EPAID:	Not reported
Generator Flag:	Not reported
Transporter Flag:	Not reported
TSDF Flag:	Not reported
Name Change:	Not reported
Date Change:	Not reported

Manifest Data:

EPA ID:	NYP004224192
Manifest Number:	007655817JJK
Date Shipped:	1/16/2011
TSDF EPA ID:	NJD002200046
Transporter EPA ID:	NYD006982359
Transporter 2 EPA ID:	Not reported
Transporter 3 EPA ID:	Not reported
Transporter 4 EPA ID:	Not reported
Transporter 5 EPA ID:	Not reported
Transporter 6 EPA ID:	Not reported
Transporter 7 EPA ID:	Not reported
Transporter 8 EPA ID:	Not reported
Transporter 9 EPA ID:	Not reported
Transporter 10 EPA ID:	Not reported
Date Trans1 Transported Waste:	Not reported
Date Trans2 Transported Waste:	Not reported

CON EDISON MANHOLE 9130 (Continued) **1014918800**

Date Trans3 Transported Waste:	Not reported
Date Trans4 Transported Waste:	Not reported
Date Trans5 Transported Waste:	Not reported
Date Trans6 Transported Waste:	Not reported
Date Trans7 Transported Waste:	Not reported
Date Trans8 Transported Waste:	Not reported
Date Trans9 Transported Waste:	Not reported
Date Trans10 Transported Waste:	Not reported
Date TSDF Received Waste:	Not reported
TSDF EPA Facility Name:	Not reported
QTY Units:	Not reported
Transporter SEQ ID:	Not reported
Transporter-1 Date:	Not reported
Waste SEQ ID:	Not reported
Waste Type Code 2:	Not reported
Waste Type Code 3:	Not reported
Waste Type Code 4:	Not reported
Waste Type Code 5:	Not reported
Waste Type Code 6:	Not reported
Date Accepted:	Not reported
Manifest Discrepancy Type:	Not reported
Data Entry Number:	Not reported
Was Load Rejected:	Not reported
Reason Load Was Rejected:	Not reported

Waste:

Manifest Year:	Not reported
Waste Code:	D008
Hand Code:	H111
Quantity:	100.00
Unit:	Pounds

E70 **CON EDISON MANHOLE 9128** **RCRA NonGen / NLR** **1014918791**
SE **MARTINE AVE & GROVE ST MH 9128** **NY MANIFEST** **NYP004224101**
< 1/8 **WHITE PLAINS, NY 10601** **NJ MANIFEST**
0.037 mi.
197 ft. **Site 4 of 5 in cluster E**

Relative: **Higher**
Actual: **198 ft.**

RCRA Listings:

Date Form Received by Agency:	20110214
Handler Name:	Con Edison Manhole 9128
Handler Address:	Martine Ave & Grove St Mh 9128
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYP004224101
Contact Name:	GINO FRABASILE
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	914-925-6219
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	SR SPECIALIST
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported

CON EDISON MANHOLE 9128 (Continued) **1014918791**

Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PL RM 828
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20110701
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20110115
Handler Name:	CON EDISON MANHOLE 9128
Federal Waste Generator Description:	Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator

CON EDISON MANHOLE 9128 (Continued) **1014918791**

State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20110214
Handler Name: CON EDISON MANHOLE 9128
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

NY MANIFEST:
EPA ID: NYP004224101
Country: USA
Name: Consolidated Edison
Address: MARTINE AVE & GROVE ST MH 9128
Address 2: Not reported
City,State,Zip: WHITE PLAINS, NY 10601
Zip 4: Not reported
Location Address 1: MARTINE AVE & GRANE ST
Location Address 2: MH 9128
Location City,State,Zip: WHITE PLAINS, NY
Location Zip 4: Not reported
Facility Status: Not reported
Total Tanks: Not reported
Code: BP

Mailing:
Mailing Name: Consolidated Edison
Mailing Contact: Dennis Huacon
Mailing Address 1: 4 IRVING PLACE RM 828
Mailing Address 2: Not reported
Mailing City,State,Zip: NEW YORK, NY 10003
Mailing Zip 4: Not reported

CON EDISON MANHOLE 9128 (Continued) **1014918791**

Mailing Country: USA
Mailing Phone: 2124602757

Manifest Data:
Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: NYD006982359
Year: 2018
Trans2 State ID: Not reported
Generator Ship Date: 01/15/2011
Trans1 Recv Date: 01/15/2011
Trans2 Recv Date: Not reported
TSD Site Recv Date: 01/18/2011
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYP004224101
Trans1 EPA ID: Not reported
Trans2 EPA ID: Not reported
TSDF ID 1: NJD002200046
TSDF ID 2: Not reported
Manifest Tracking Number: 007655565JJK
Import Indicator: N
Export Indicator: N
Discr Quantity Indicator: N
Discr Type Indicator: Y
Discr Residue Indicator: N
Discr Partial Reject Indicator: N
Discr Full Reject Indicator: N
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: H111
Waste Code a: Lead
Waste Code b: Not reported
Waste Code c: Not reported
Waste Code e: Not reported
Waste Code f: Not reported
Waste Code g: Not reported
Waste Code 1: Not reported
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 100
Units: Pounds
Number of Containers: 1
Container Type: Cargo tanks (tank trucks)
Handling Method: Treat
Specific Gravity: 1

NJ MANIFEST:
EPA ID: NYP004224101
Name: CON EDISON MANHOLE 9128
Address: MARTINE AVE & GROVE ST MH 9128

CON EDISON MANHOLE 9128 (Continued) **1014918791**

City,State,Zip:	WHITE PLAINS, NY 10601
County:	Not reported
Mailing Address:	IRVING PL RM 828
Mailing City,State,Zip:	NEW YORK, NY 10003
Telephone:	Not reported
Emergency Telephone:	Not reported
Contact:	GINO FRABASILE
Comments:	Not reported
SIC Code:	Not reported
County:	NY119
Municipal:	Not reported
Previous EPAID:	Not reported
Generator Flag:	Not reported
Transporter Flag:	Not reported
TSDF Flag:	Not reported
Name Change:	Not reported
Date Change:	Not reported

Manifest Data:

EPA ID:	NYP004224101
Manifest Number:	007655565JJK
Date Shipped:	1/15/2011
TSDF EPA ID:	NJD002200046
Transporter EPA ID:	NYD006982359
Transporter 2 EPA ID:	Not reported
Transporter 3 EPA ID:	Not reported
Transporter 4 EPA ID:	Not reported
Transporter 5 EPA ID:	Not reported
Transporter 6 EPA ID:	Not reported
Transporter 7 EPA ID:	Not reported
Transporter 8 EPA ID:	Not reported
Transporter 9 EPA ID:	Not reported
Transporter 10 EPA ID:	Not reported
Date Trans1 Transported Waste:	Not reported
Date Trans2 Transported Waste:	Not reported
Date Trans3 Transported Waste:	Not reported
Date Trans4 Transported Waste:	Not reported
Date Trans5 Transported Waste:	Not reported
Date Trans6 Transported Waste:	Not reported
Date Trans7 Transported Waste:	Not reported
Date Trans8 Transported Waste:	Not reported
Date Trans9 Transported Waste:	Not reported
Date Trans10 Transported Waste:	Not reported
Date TSDF Received Waste:	Not reported
TSDF EPA Facility Name:	Not reported
QTY Units:	Not reported
Transporter SEQ ID:	Not reported
Transporter-1 Date:	Not reported
Waste SEQ ID:	Not reported
Waste Type Code 2:	Not reported
Waste Type Code 3:	Not reported
Waste Type Code 4:	Not reported
Waste Type Code 5:	Not reported
Waste Type Code 6:	Not reported
Date Accepted:	Not reported
Manifest Discrepancy Type:	Not reported
Data Entry Number:	Not reported
Was Load Rejected:	Not reported

CON EDISON MANHOLE 9128 (Continued) **1014918791**

Reason Load Was Rejected: Not reported

Waste:
Manifest Year: Not reported
Waste Code: D008
Hand Code: H111
Quantity: 100.00
Unit: Pounds

E71 **CON EDISON MANHOLE 9772** **RCRA NonGen / NLR** **1014918827**
SE **MARTINE AVE & GROVE ST SE COR** **NY MANIFEST** **NYP004224465**
< 1/8 **WHITE PLAINS, NY 10601** **NJ MANIFEST**
0.037 mi.
197 ft. **Site 5 of 5 in cluster E**

Relative:
Higher

Actual:
198 ft.

RCRA Listings:

Date Form Received by Agency:	20110217
Handler Name:	Con Edison Manhole 9772
Handler Address:	Martine Ave & Grove St Se Cor
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYP004224465
Contact Name:	DOMINIC BIZZARO
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	914-925-6219
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	SR SPECIALIST
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PL RM 828
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No

CON EDISON MANHOLE 9772 (Continued) **1014918827**

Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20110701
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20110118
Handler Name: CON EDISON MANHOLE 9772	
Federal Waste Generator Description:	Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20110217
Handler Name: CON EDISON MANHOLE 9772	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

CON EDISON MANHOLE 9772 (Continued) **1014918827**

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

NY MANIFEST:

EPA ID:	NYP004224465
Country:	USA
Name:	Coned - Mh9772
Address:	MARTINE AVE & GROVE ST SE COR
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10601
Zip 4:	Not reported
Location Address 1:	MARTINE AVE
Location Address 2:	GROVE AVE
Location City,State,Zip:	WHITE PLAINS, NY 10601
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Coned - Mh9772
Mailing Contact:	Coned - Mh9772
Mailing Address 1:	4 IRVING PLACE
Mailing Address 2:	Not reported
Mailing City,State,Zip:	NEW YORK, NY 10004
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	Not reported

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	01/18/2011
Trans1 Recv Date:	01/18/2011
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	01/19/2011
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004224465
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	007655782JJK
Import Indicator:	N

CON EDISON MANHOLE 9772 (Continued) **1014918827**

Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H111
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	500
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

NJ MANIFEST:

EPA ID:	NYP004224465
Name:	CON EDISON MANHOLE 9772
Address:	MARTINE AVE & GROVE ST SE COR
City,State,Zip:	WHITE PLAINS, NY 10601
County:	Not reported
Mailing Address:	IRVING PL RM 828
Mailing City,State,Zip:	NEW YORK, NY 10003
Telephone:	Not reported
Emergency Telephone:	Not reported
Contact:	DOMINIC BIZZARO
Comments:	Not reported
SIC Code:	Not reported
County:	NY119
Municipal:	Not reported
Previous EPAID:	Not reported
Generator Flag:	Not reported
Transporter Flag:	Not reported
TSDF Flag:	Not reported
Name Change:	Not reported
Date Change:	Not reported

Manifest Data:

EPA ID:	NYP004224465
Manifest Number:	007655782JJK
Date Shipped:	1/18/2011
TSDF EPA ID:	NJD002200046

CON EDISON MANHOLE 9772 (Continued) **1014918827**

Transporter EPA ID:	NYD006982359
Transporter 2 EPA ID:	Not reported
Transporter 3 EPA ID:	Not reported
Transporter 4 EPA ID:	Not reported
Transporter 5 EPA ID:	Not reported
Transporter 6 EPA ID:	Not reported
Transporter 7 EPA ID:	Not reported
Transporter 8 EPA ID:	Not reported
Transporter 9 EPA ID:	Not reported
Transporter 10 EPA ID:	Not reported
Date Trans1 Transported Waste:	Not reported
Date Trans2 Transported Waste:	Not reported
Date Trans3 Transported Waste:	Not reported
Date Trans4 Transported Waste:	Not reported
Date Trans5 Transported Waste:	Not reported
Date Trans6 Transported Waste:	Not reported
Date Trans7 Transported Waste:	Not reported
Date Trans8 Transported Waste:	Not reported
Date Trans9 Transported Waste:	Not reported
Date Trans10 Transported Waste:	Not reported
Date TSDF Received Waste:	Not reported
TSDF EPA Facility Name:	Not reported
QTY Units:	Not reported
Transporter SEQ ID:	Not reported
Transporter-1 Date:	Not reported
Waste SEQ ID:	Not reported
Waste Type Code 2:	Not reported
Waste Type Code 3:	Not reported
Waste Type Code 4:	Not reported
Waste Type Code 5:	Not reported
Waste Type Code 6:	Not reported
Date Accepted:	Not reported
Manifest Discrepancy Type:	Not reported
Data Entry Number:	Not reported
Was Load Rejected:	Not reported
Reason Load Was Rejected:	Not reported

Waste:

Manifest Year:	Not reported
Waste Code:	D008
Hand Code:	H111
Quantity:	500.00
Unit:	Pounds

B72 **CON EDISON MANHOLE: 10233** **RCRA NonGen / NLR** **1016960696**
ENE **MAIN ST & WILLIAMS ST** **NY MANIFEST** **NYP004328050**
< 1/8 **WHITE PLAINS, NY 10607**
0.047 mi.
250 ft. **Site 12 of 18 in cluster B**

Relative:
Higher

Actual:
199 ft.

RCRA Listings:

Date Form Received by Agency:	20130811
Handler Name:	Con Edison Manhole: 10233
Handler Address:	Main St & Williams St
Handler City,State,Zip:	WHITE PLAINS, NY 10607
EPA ID:	NYP004328050

CON EDISON MANHOLE: 10233 (Continued) **1016960696**

Contact Name:	DOMINIC BIZZARO
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	914-925-6219
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	SR SPECIALIST
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PL, RM 828
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20140701
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No

CON EDISON MANHOLE: 10233 (Continued) **1016960696**

Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20130711
Handler Name:	CON EDISON MANHOLE: 10233
Federal Waste Generator Description:	Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20130811
Handler Name:	CON EDISON MANHOLE: 10233
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

List of NAICS Codes and Descriptions:

NAICS Codes:	No NAICS Codes Found

Facility Has Received Notices of Violations:

Violations:	No Violations Found

Evaluation Action Summary:

Evaluations:	No Evaluations Found

NY MANIFEST:

EPA ID:	NYP004328050
Country:	USA
Name:	Con Edison
Address:	MAIN ST & WILLIAMS ST
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10607
Zip 4:	Not reported
Location Address 1:	MAIN ST & WILLIAMS ST
Location Address 2:	MH # 10233

CON EDISON MANHOLE: 10233 (Continued) **1016960696**

Location City,State,Zip: WHITE PLAINS, NY 10607
Location Zip 4: Not reported
Facility Status: Not reported
Total Tanks: Not reported
Code: BP

Mailing:
Mailing Name: Con Edison
Mailing Contact: Tom Teeling
Mailing Address 1: 4 IRVING PLACE 15TH FLOOR
Mailing Address 2: Not reported
Mailing City,State,Zip: NEW YORK, NY 10003
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: 2124603770

Manifest Data:
Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: NYD006982359
Year: 2018
Trans2 State ID: Not reported
Generator Ship Date: 07/11/2013
Trans1 Recv Date: 07/11/2013
Trans2 Recv Date: Not reported
TSD Site Recv Date: 07/17/2013
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYP004328050
Trans1 EPA ID: Not reported
Trans2 EPA ID: Not reported
TSDF ID 1: NJD002200046
TSDF ID 2: Not reported
Manifest Tracking Number: 011695885JJK
Import Indicator: N
Export Indicator: N
Discr Quantity Indicator: N
Discr Type Indicator: N
Discr Residue Indicator: N
Discr Partial Reject Indicator: N
Discr Full Reject Indicator: N
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: H110
Waste Code a: Lead
Waste Code b: Not reported
Waste Code c: Not reported
Waste Code e: Not reported
Waste Code f: Not reported
Waste Code g: Not reported
Waste Code 1: Not reported
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported

CON EDISON MANHOLE: 10233 (Continued) **1016960696**

Quantity:	300
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

B73 **CON EDISON** **RCRA NonGen / NLR** **1014399082**
ENE **WILLIAMS ST & MAIN ST** **NJ MANIFEST** **NYP004214599**
< 1/8 **WHITE PLAINS, NY 10601**
0.047 mi.
250 ft. **Site 13 of 18 in cluster B**

Relative: **Higher**
Actual: **199 ft.**

RCRA Listings:

Date Form Received by Agency:	20200413
Handler Name:	Con Edison
Handler Address:	Williams St & Main St
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYP004214599
Contact Name:	Not reported
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	Not reported
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	Not reported
Mailing City,State,Zip:	Not reported
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N

CON EDISON (Continued) **1014399082**

Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20200413
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20100831
Handler Name: CON EDISON	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20200413
Handler Name: CON EDISON	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	No
Electronic Manifest Broker:	No

List of NAICS Codes and Descriptions:

NAICS Codes:	No NAICS Codes Found

CON EDISON (Continued) **1014399082**

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

NJ MANIFEST:

EPA ID:	NYP004214599
Name:	CON EDISON
Address:	WILLIAMS ST & MAIN ST
City,State,Zip:	WHITE PLAINS, NY 10601
County:	Not reported
Mailing Address:	4 IRVING PL, RM 828
Mailing City,State,Zip:	NEW YORK, NY 10003
Telephone:	Not reported
Emergency Telephone:	Not reported
Contact:	DOMINIC BIZZARO
Comments:	Not reported
SIC Code:	Not reported
County:	NY119
Municipal:	Not reported
Previous EPAID:	Not reported
Generator Flag:	Not reported
Transporter Flag:	Not reported
TSDF Flag:	Not reported
Name Change:	Not reported
Date Change:	Not reported

Manifest Data:

EPA ID:	NYP004214599
Manifest Number:	001086109GBF
Date Shipped:	08/31/2010
TSDF EPA ID:	NJD002200046
Transporter EPA ID:	NYD006982359
Transporter 2 EPA ID:	Not reported
Transporter 3 EPA ID:	Not reported
Transporter 4 EPA ID:	Not reported
Transporter 5 EPA ID:	Not reported
Transporter 6 EPA ID:	Not reported
Transporter 7 EPA ID:	Not reported
Transporter 8 EPA ID:	Not reported
Transporter 9 EPA ID:	Not reported
Transporter 10 EPA ID:	Not reported
Date Trans1 Transported Waste:	08/31/2010
Date Trans2 Transported Waste:	Not reported
Date Trans3 Transported Waste:	Not reported
Date Trans4 Transported Waste:	Not reported
Date Trans5 Transported Waste:	Not reported
Date Trans6 Transported Waste:	Not reported
Date Trans7 Transported Waste:	Not reported
Date Trans8 Transported Waste:	Not reported
Date Trans9 Transported Waste:	Not reported
Date Trans10 Transported Waste:	Not reported
Date TSDF Received Waste:	09/02/2010
TSDF EPA Facility Name:	Not reported

CON EDISON (Continued) **1014399082**

QTY Units: Not reported
Transporter SEQ ID: Not reported
Transporter-1 Date: Not reported
Waste SEQ ID: Not reported
Waste Type Code 2: Not reported
Waste Type Code 3: Not reported
Waste Type Code 4: Not reported
Waste Type Code 5: Not reported
Waste Type Code 6: Not reported
Date Accepted: Not reported
Manifest Discrepancy Type: Not reported
Data Entry Number: Not reported
Was Load Rejected: N
Reason Load Was Rejected: Not reported

Waste:
Manifest Year: Not reported
Waste Code: D008
Hand Code: H111
Quantity: 200
Unit: P

EPA ID: NYP004846109
Name: CON EDISON
Address: WILLIAMS ST & MAIN ST
City,State,Zip: WHITE PLAINS, NY 10601
County: Not reported
Mailing Address: IRVING PL 15TH FL NE
Mailing City,State,Zip: NEW YORK, NY 10003
Telephone: Not reported
Emergency Telephone: Not reported
Contact: THOMAS TEELING
Comments: Not reported
SIC Code: Not reported
County: NY119
Municipal: Not reported
Previous EPAID: Not reported
Generator Flag: Not reported
Transporter Flag: Not reported
TSDF Flag: Not reported
Name Change: Not reported
Date Change: Not reported

Manifest Data:
EPA ID: NYP004846109
Manifest Number: 014460337JJK
Date Shipped: 9/30/2015
TSDF EPA ID: NJD002200046
Transporter EPA ID: NYD006982359
Transporter 2 EPA ID: Not reported
Transporter 3 EPA ID: Not reported
Transporter 4 EPA ID: Not reported
Transporter 5 EPA ID: Not reported
Transporter 6 EPA ID: Not reported
Transporter 7 EPA ID: Not reported
Transporter 8 EPA ID: Not reported

CON EDISON (Continued) **1014399082**

Transporter 9 EPA ID:	Not reported
Transporter 10 EPA ID:	Not reported
Date Trans1 Transported Waste:	Not reported
Date Trans2 Transported Waste:	Not reported
Date Trans3 Transported Waste:	Not reported
Date Trans4 Transported Waste:	Not reported
Date Trans5 Transported Waste:	Not reported
Date Trans6 Transported Waste:	Not reported
Date Trans7 Transported Waste:	Not reported
Date Trans8 Transported Waste:	Not reported
Date Trans9 Transported Waste:	Not reported
Date Trans10 Transported Waste:	Not reported
Date TSDF Received Waste:	Not reported
TSDF EPA Facility Name:	Not reported
QTY Units:	Not reported
Transporter SEQ ID:	Not reported
Transporter-1 Date:	Not reported
Waste SEQ ID:	Not reported
Waste Type Code 2:	Not reported
Waste Type Code 3:	Not reported
Waste Type Code 4:	Not reported
Waste Type Code 5:	Not reported
Waste Type Code 6:	Not reported
Date Accepted:	Not reported
Manifest Discrepancy Type:	Not reported
Data Entry Number:	Not reported
Was Load Rejected:	Not reported
Reason Load Was Rejected:	Not reported

B74 **CONSOLIDATED EDISON** **NY MANIFEST** **S110823807**
ENE **WILLIAM ST & MAIN ST** **N/A**
< 1/8 **WHITE PLAINS, NY 10602**
0.047 mi.
250 ft. **Site 14 of 18 in cluster B**

Relative:
Higher

Actual:
199 ft.

NY MANIFEST:

EPA ID:	NYP004227389
Country:	USA
Name:	Consolidated Edison
Address:	WILLIAM ST & MAIN ST
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10602
Zip 4:	Not reported
Location Address 1:	WILLIAM ST & MAIN ST
Location Address 2:	Not reported
Location City,State,Zip:	WHITE PLAINS, NY 10602
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Consolidated Edison
Mailing Contact:	Tom Teeling
Mailing Address 1:	4 IRVING PLACE RM 828
Mailing Address 2:	Not reported
Mailing City,State,Zip:	NEW YORK, NY 10003

CONSOLIDATED EDISON (Continued) **S110823807**

Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: 2124603770

Manifest Data:
Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: NYD006982359
Year: 2018
Trans2 State ID: Not reported
Generator Ship Date: 02/09/2011
Trans1 Recv Date: 02/09/2011
Trans2 Recv Date: Not reported
TSD Site Recv Date: 02/10/2011
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYP004227389
Trans1 EPA ID: Not reported
Trans2 EPA ID: Not reported
TSDF ID 1: NJD002200046
TSDF ID 2: Not reported
Manifest Tracking Number: 007655507JJK
Import Indicator: N
Export Indicator: N
Discr Quantity Indicator: N
Discr Type Indicator: Y
Discr Residue Indicator: N
Discr Partial Reject Indicator: N
Discr Full Reject Indicator: N
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: H111
Waste Code a: Lead
Waste Code b: Not reported
Waste Code c: Not reported
Waste Code e: Not reported
Waste Code f: Not reported
Waste Code g: Not reported
Waste Code 1: Not reported
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 400
Units: Pounds
Number of Containers: 1
Container Type: Cargo tanks (tank trucks)
Handling Method: Treat
Specific Gravity: 1

B75 **CON EDISON** **RCRA NonGen / NLR** **1019908455**
ENE **WILLIAMS ST & MAIN ST** **NYP004846109**
< 1/8 **WHITE PLAINS, NY 10601**
0.047 mi.
250 ft. **Site 15 of 18 in cluster B**

Relative: **Higher**
Actual: **199 ft.**

RCRA Listings:

Date Form Received by Agency:	20150930
Handler Name:	Con Edison
Handler Address:	Williams St & Main St
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYP004846109
Contact Name:	THOMAS TEELING
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	212-460-3770
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PL 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No

CON EDISON (Continued) **1019908455**

Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20160909
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20150930
Handler Name: CON EDISON	
Federal Waste Generator Description:	Large Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20150930
Handler Name: CON EDISON	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

List of NAICS Codes and Descriptions:

NAICS Codes:	No NAICS Codes Found

Facility Has Received Notices of Violations:

Violations:	No Violations Found

Evaluation Action Summary:

Evaluations:	No Evaluations Found

B76 **CON EDISON** **NY MANIFEST** **S118463067**
ENE **WILLIAMS ST & MAIN ST** **N/A**
< 1/8 **WHITE PLAINS, NY 10601**
0.047 mi.
250 ft. **Site 16 of 18 in cluster B**

Relative:
Higher

Actual:
199 ft.

NY MANIFEST:

EPA ID:	NYP004846109
Country:	USA
Name:	Con Edison
Address:	WILLIAMS ST & MAIN ST
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10601
Zip 4:	Not reported
Location Address 1:	WILLIAMS ST & MAIN ST
Location Address 2:	TM 5567
Location City,State,Zip:	WHITE PLAINS, NY
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Edison
Mailing Contact:	Dennis Huacon
Mailing Address 1:	4 IRVING PL 15TH FL
Mailing Address 2:	Not reported
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	2124603770

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	09/30/2015
Trans1 Recv Date:	09/30/2015
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	10/05/2015
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004846109
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	014460337JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported

CON EDISON (Continued) **S118463067**

Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	600
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

B77 **CON ED- TM462** **NY MANIFEST** **S109064656**
ENE **WILLIAMS & MAIN ST** **N/A**
< 1/8 **WHITE PLAINS, NY 10601**
0.047 mi.
250 ft. **Site 17 of 18 in cluster B**

Relative: **Higher**
Actual: **199 ft.**

NY MANIFEST:

EPA ID:	NYZ004019766
Country:	USA
Name:	Con Ed- Tm462
Address:	WILLIAMS & MAIN ST
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10601
Zip 4:	0000
Location Address 1:	WILLIAMS & MAIN ST
Location Address 2:	Not reported
Location City,State,Zip:	WHITE PLAINS, NY 10601
Location Zip 4:	0000
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Ed- Tm462
Mailing Contact:	Not reported
Mailing Address 1:	Not reported
Mailing Address 2:	Not reported
Mailing City,State,Zip:	Not reported
Mailing Zip 4:	Not reported
Mailing Country:	Not reported
Mailing Phone:	Not reported

B78 **2 WILLIAM ST./ 169 MAIN ST.** **NY UST** **U004439155**
ENE **2 WILLIAM ST./ 169 MAIN ST.** **N/A**
< 1/8 **WHITE PLAINS, NY 10601**
0.051 mi.
270 ft. **Site 18 of 18 in cluster B**

Relative:
Higher

Actual:
200 ft.

WESTCHESTER CO. UST:

Name:	2 WILLIAM ST./ 169 MAIN ST.
Address:	2 WILLIAM ST./ 169 MAIN ST.
City,State,Zip:	WHITE PLAINS, NY 10601
Id/Status:	3-505153 / Unregulated: <1101 gal. PBS
Operator Name:	Bill Wafford
Owner Name:	Main And William Associates
Owner Street:	Suite 102,80 Business Park Dr.
Owner Address2:	Not reported
Owner City:	Armonk
Owner State:	NY
Owner Zipcode:	10504
GDS Number:	Not reported
Tank Number:	001
Status:	3a. Closed - Prior to 04/1991
Capacity:	2000
Product Stored:	Not reported
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	01/01/1900
Date Perm Closure:	01/01/1900
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	Not reported
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Overfill Prevention:	Not reported
Piping Secondary Containment:	Not reported
Spill Prevention:	Not reported
Dispenser:	2. Suction
Tank Number:	002
Status:	3a. Closed - Prior to 04/1991
Capacity:	2500
Product Stored:	9999. Other
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	01/01/1900
Date Perm Closure:	01/01/1900
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	Not reported
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Overfill Prevention:	0. None

2 WILLIAM ST./ 169 MAIN ST. (Continued) **U004439155**

Piping Secondary Containment: Not reported
Spill Prevention: 0. None
Dispenser: 2. Suction

D79 **GRAY PETER** **EDR Hist Auto** **1020322946**
SW **35 MARTINE AVE** **N/A**
< 1/8 **WHITE PLAINS, NY 10602**
0.057 mi.
300 ft. **Site 11 of 13 in cluster D**

Relative: EDR Hist Auto
Higher

Actual: **202 ft.**

Year:	Name:	Type:
1969	GRAY PETER	Gasoline Service Stations
1970	GRAY PETER	Gasoline Service Stations

F80 **CON EDISON** **RCRA NonGen / NLR** **1014398735**
NW **LEXINGTON & HAMILTON AVE** **FINDS** **NYP004210985**
< 1/8 **WHITE PLAINS, NY 10605** **ECHO**
0.058 mi. **NY MANIFEST**
308 ft. **Site 1 of 8 in cluster F** **NJ MANIFEST**

Relative: RCRA Listings:
Higher

Actual: **201 ft.**

Date Form Received by Agency:	20200413
Handler Name:	Con Edison
Handler Address:	Lexington & Hamilton Ave
Handler City,State,Zip:	WHITE PLAINS, NY 10605
EPA ID:	NYP004210985
Contact Name:	Not reported
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	Not reported
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	Not reported
Mailing City,State,Zip:	Not reported
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No

CON EDISON (Continued) **1014398735**

Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20200413
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20100708
Handler Name: CON EDISON	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20200413
Handler Name: CON EDISON	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No

CON EDISON (Continued) **1014398735**

Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: No
Electronic Manifest Broker: No

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

FINDS:
Registry ID: 110042420074

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:
The Resource Conservation and Recovery Act Information System (RCRAInfo) is EPA's comprehensive information system in support of the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. It tracks many types of information about generators, transporters, treaters, storers, and disposers of hazardous waste.

Click this hyperlink while viewing on your computer to access additional FINDS: detail in the EDR Site Report.

ECHO:
Envid: 1014398735
Registry ID: 110042420074

DFR URL:
Name: CON EDISON
Address: LEXINGTON & HAMILTON AVE
City,State,Zip: WHITE PLAINS, NY 10605

NY MANIFEST:
EPA ID: NYP004210985
Country: USA
Name: Consolidated Edison
Address: LEXINGTON & HAMILTON AVE
Address 2: MH 10101
City,State,Zip: WHITE PLAINS, NY 10605
Zip 4: Not reported
Location Address 1: MH202 SWC S FULTON AVE & E 3RD ST
Location Address 2: Not reported
Location City,State,Zip: MOUNT VERNON, NY
Location Zip 4: Not reported
Facility Status: Not reported
Total Tanks: Not reported
Code: BP

CON EDISON (Continued) **1014398735**

Mailing:
- Mailing Name: Consolidated Edison
- Mailing Contact: Thomas Teeling
- Mailing Address 1: 4 IRVING PL RM 828
- Mailing Address 2: Not reported
- Mailing City,State,Zip: NEW YORK, NY 10003
- Mailing Zip 4: Not reported
- Mailing Country: USA
- Mailing Phone: 2124603770

Manifest Data:
- Document ID: Not reported
- Manifest Status: Not reported
- Trans1 State ID: NYD006982359
- Year: 2018
- Trans2 State ID: Not reported
- Generator Ship Date: 07/08/2010
- Trans1 Recv Date: 07/08/2010
- Trans2 Recv Date: Not reported
- TSD Site Recv Date: 07/12/2010
- Part A Recv Date: Not reported
- Part B Recv Date: Not reported
- Generator EPA ID: NYP004210985
- Trans1 EPA ID: Not reported
- Trans2 EPA ID: Not reported
- TSDF ID 1: NJD002200046
- TSDF ID 2: Not reported
- Manifest Tracking Number: 003533275JJK
- Import Indicator: N
- Export Indicator: N
- Discr Quantity Indicator: N
- Discr Type Indicator: Y
- Discr Residue Indicator: N
- Discr Partial Reject Indicator: N
- Discr Full Reject Indicator: N
- Manifest Ref Number: Not reported
- Alt Facility RCRA ID: Not reported
- Alt Facility Sign Date: Not reported
- MGMT Method Type Code: H111
- Waste Code a: Lead
- Waste Code b: Not reported
- Waste Code c: Not reported
- Waste Code e: Not reported
- Waste Code f: Not reported
- Waste Code g: Not reported
- Waste Code 1: Not reported
- Waste Code 2: Not reported
- Waste Code 3: Not reported
- Waste Code 4: Not reported
- Waste Code 5: Not reported
- Waste Code 6: Not reported
- Quantity: 80
- Units: Pounds
- Number of Containers: 1
- Container Type: Cargo tanks (tank trucks)
- Handling Method: Treat

CON EDISON (Continued) **1014398735**

Specific Gravity: 1

NJ MANIFEST:

EPA ID:	NYP004210985
Name:	CON EDISON
Address:	LEXINGTON & HAMILTON AVE
City,State,Zip:	WHITE PLAINS, NY 10605
County:	Not reported
Mailing Address:	4 IRVING PL, RM 828
Mailing City,State,Zip:	NEW YORK, NY 10003
Telephone:	Not reported
Emergency Telephone:	Not reported
Contact:	DAVID DUKE
Comments:	Not reported
SIC Code:	Not reported
County:	NY119
Municipal:	Not reported
Previous EPAID:	Not reported
Generator Flag:	Not reported
Transporter Flag:	Not reported
TSDF Flag:	Not reported
Name Change:	Not reported
Date Change:	Not reported

Manifest Data:

EPA ID:	NYP004210985
Manifest Number:	003533275JJK
Date Shipped:	07/08/2010
TSDF EPA ID:	NJD002200046
Transporter EPA ID:	NYD006982359
Transporter 2 EPA ID:	Not reported
Transporter 3 EPA ID:	Not reported
Transporter 4 EPA ID:	Not reported
Transporter 5 EPA ID:	Not reported
Transporter 6 EPA ID:	Not reported
Transporter 7 EPA ID:	Not reported
Transporter 8 EPA ID:	Not reported
Transporter 9 EPA ID:	Not reported
Transporter 10 EPA ID:	Not reported
Date Trans1 Transported Waste:	07/08/2010
Date Trans2 Transported Waste:	Not reported
Date Trans3 Transported Waste:	Not reported
Date Trans4 Transported Waste:	Not reported
Date Trans5 Transported Waste:	Not reported
Date Trans6 Transported Waste:	Not reported
Date Trans7 Transported Waste:	Not reported
Date Trans8 Transported Waste:	Not reported
Date Trans9 Transported Waste:	Not reported
Date Trans10 Transported Waste:	Not reported
Date TSDF Received Waste:	07/12/2010
TSDF EPA Facility Name:	Not reported
QTY Units:	Not reported
Transporter SEQ ID:	Not reported
Transporter-1 Date:	Not reported
Waste SEQ ID:	Not reported
Waste Type Code 2:	Not reported

CON EDISON (Continued) **1014398735**

Waste Type Code 3:	Not reported
Waste Type Code 4:	Not reported
Waste Type Code 5:	Not reported
Waste Type Code 6:	Not reported
Date Accepted:	Not reported
Manifest Discrepancy Type:	Not reported
Data Entry Number:	Not reported
Was Load Rejected:	N
Reason Load Was Rejected:	Not reported

Waste:

Manifest Year:	Not reported
Waste Code:	D008
Hand Code:	H111
Quantity:	80
Unit:	P

F81 **CON EDISON MANHOLE: 8307** **RCRA NonGen / NLR** **1016967051**
NW **HAMILTON AVE & LEXINGTON AVE** **NY MANIFEST** **NYP004398830**
< 1/8 **WHITE PLAINS, NY 10602**
0.058 mi.
308 ft. **Site 2 of 8 in cluster F**

Relative: **Higher**
Actual: **201 ft.**

RCRA Listings:

Date Form Received by Agency:	20131228
Handler Name:	Con Edison Manhole: 8307
Handler Address:	Hamilton Ave & Lexington Ave
Handler City,State,Zip:	WHITE PLAINS, NY 10602
EPA ID:	NYP004398830
Contact Name:	THOMAS TEELING
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	212-460-3770
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	SENIOR SCIENTIST
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PL, 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No

CON EDISON MANHOLE: 8307 (Continued) **1016967051**

Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20140701
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20131128
Handler Name: CON EDISON MANHOLE: 8307	
Federal Waste Generator Description:	Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20131228
Handler Name: CON EDISON MANHOLE: 8307	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No

CON EDISON MANHOLE: 8307 (Continued) **1016967051**

Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

List of NAICS Codes and Descriptions:

NAICS Codes:	No NAICS Codes Found

Facility Has Received Notices of Violations:

Violations:	No Violations Found

Evaluation Action Summary:

Evaluations:	No Evaluations Found

NY MANIFEST:

EPA ID:	NYP004398830
Country:	USA
Name:	Con Edison
Address:	HAMILTON AVE & LEXINGTON AVE
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10602
Zip 4:	Not reported
Location Address 1:	HAMILTON AVE 66 FT WO LEXINGTON
Location Address 2:	MH 8307
Location City,State,Zip:	WHITE PLAINS, NY
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Edison
Mailing Contact:	Con Edison
Mailing Address 1:	4 IRVING PL 15TH FL
Mailing Address 2:	Not reported
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	2124603770

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	11/28/2013
Trans1 Recv Date:	11/28/2013
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	12/04/2013
Part A Recv Date:	Not reported

CON EDISON MANHOLE: 8307 (Continued) **1016967051**

Part B Recv Date:	Not reported
Generator EPA ID:	NYP004398830
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	011695017JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	200
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

F82 **CON EDISON** **RCRA NonGen / NLR** **1014398724**
NW **HAMILTON & N LEXINGTON AVE** **NY MANIFEST** **NYP004210852**
< 1/8 **WHITE PLAINS, NY 10605** **NJ MANIFEST**
0.058 mi.
308 ft. **Site 3 of 8 in cluster F**

Relative: RCRA Listings:
Higher

Actual: Date Form Received by Agency:	20200413
201 ft. Handler Name:	Con Edison
Handler Address:	Hamilton & N Lexington Ave
Handler City,State,Zip:	WHITE PLAINS, NY 10605
EPA ID:	NYP004210852
Contact Name:	Not reported
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	Not reported
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02

CON EDISON (Continued) **1014398724**

Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	Not reported
Mailing City,State,Zip:	Not reported
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20200413
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

CON EDISON (Continued) **1014398724**

Historic Generators:
Receive Date: 20100707
Handler Name: CON EDISON
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20200413
Handler Name: CON EDISON
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: No
Electronic Manifest Broker: No

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

NY MANIFEST:
EPA ID: NYP004210852
Country: USA
Name: Consolidated Edison
Address: HAMILTON & N LEXINGTON AVE
Address 2: Not reported
City,State,Zip: WHITE PLAINS, NY 10605
Zip 4: Not reported
Location Address 1: MH8306 - HAMILTON AVE W/O LEXINGTON
Location Address 2: Not reported
Location City,State,Zip: WHITE PLAINS, NY
Location Zip 4: Not reported
Facility Status: Not reported
Total Tanks: Not reported
Code: BP

Mailing:
Mailing Name: Consolidated Edison

CON EDISON (Continued) **1014398724**

Mailing Contact: Thomas Teeling
Mailing Address 1: 4 IRVING PL RM 828
Mailing Address 2: Not reported
Mailing City,State,Zip: NEW YORK, NY 10003
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: 2124603770

Manifest Data:
Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: NYD006982359
Year: 2018
Trans2 State ID: Not reported
Generator Ship Date: 07/07/2010
Trans1 Recv Date: 07/07/2010
Trans2 Recv Date: Not reported
TSD Site Recv Date: 07/08/2010
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYP004210852
Trans1 EPA ID: Not reported
Trans2 EPA ID: Not reported
TSDF ID 1: NJD002200046
TSDF ID 2: Not reported
Manifest Tracking Number: 003533258JJK
Import Indicator: N
Export Indicator: N
Discr Quantity Indicator: N
Discr Type Indicator: Y
Discr Residue Indicator: N
Discr Partial Reject Indicator: N
Discr Full Reject Indicator: N
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: H111
Waste Code a: Lead
Waste Code b: Not reported
Waste Code c: Not reported
Waste Code e: Not reported
Waste Code f: Not reported
Waste Code g: Not reported
Waste Code 1: Not reported
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 250
Units: Pounds
Number of Containers: 1
Container Type: Cargo tanks (tank trucks)
Handling Method: Treat
Specific Gravity: 1

CON EDISON (Continued) **1014398724**

NJ MANIFEST:

EPA ID:	NYP004210852
Name:	CON EDISON
Address:	HAMILTON & N LEXINGTON AVE
City,State,Zip:	WHITE PLAINS, NY 10605
County:	Not reported
Mailing Address:	4 IRVING PL, RM 828
Mailing City,State,Zip:	NEW YORK, NY 10003
Telephone:	Not reported
Emergency Telephone:	Not reported
Contact:	DAVID DUKE
Comments:	Not reported
SIC Code:	Not reported
County:	NY119
Municipal:	Not reported
Previous EPAID:	Not reported
Generator Flag:	Not reported
Transporter Flag:	Not reported
TSDF Flag:	Not reported
Name Change:	Not reported
Date Change:	Not reported

Manifest Data:

EPA ID:	NYP004210852
Manifest Number:	003533258JJK
Date Shipped:	07/07/2010
TSDF EPA ID:	NJD002200046
Transporter EPA ID:	NYD006982359
Transporter 2 EPA ID:	Not reported
Transporter 3 EPA ID:	Not reported
Transporter 4 EPA ID:	Not reported
Transporter 5 EPA ID:	Not reported
Transporter 6 EPA ID:	Not reported
Transporter 7 EPA ID:	Not reported
Transporter 8 EPA ID:	Not reported
Transporter 9 EPA ID:	Not reported
Transporter 10 EPA ID:	Not reported
Date Trans1 Transported Waste:	07/07/2010
Date Trans2 Transported Waste:	Not reported
Date Trans3 Transported Waste:	Not reported
Date Trans4 Transported Waste:	Not reported
Date Trans5 Transported Waste:	Not reported
Date Trans6 Transported Waste:	Not reported
Date Trans7 Transported Waste:	Not reported
Date Trans8 Transported Waste:	Not reported
Date Trans9 Transported Waste:	Not reported
Date Trans10 Transported Waste:	Not reported
Date TSDF Received Waste:	07/08/2010
TSDF EPA Facility Name:	Not reported
QTY Units:	Not reported
Transporter SEQ ID:	Not reported
Transporter-1 Date:	Not reported
Waste SEQ ID:	Not reported
Waste Type Code 2:	Not reported
Waste Type Code 3:	Not reported
Waste Type Code 4:	Not reported
Waste Type Code 5:	Not reported

CON EDISON (Continued) **1014398724**

Waste Type Code 6:	Not reported
Date Accepted:	Not reported
Manifest Discrepancy Type:	Not reported
Data Entry Number:	Not reported
Was Load Rejected:	N
Reason Load Was Rejected:	Not reported

Waste:

Manifest Year:	Not reported
Waste Code:	D008
Hand Code:	H111
Quantity:	250
Unit:	P

G83 **GHP HAMILTON AVENUE** **NY UST** **U004176517**
NNW **170 HAMILTON AVENUE** **N/A**
< 1/8 **WHITE PLAINS, NY 10601**
0.065 mi.
343 ft. **Site 1 of 4 in cluster G**

Relative: **Lower**
Actual: **194 ft.**

WESTCHESTER CO. UST:

Name:	GHP HAMILTON AVENUE
Address:	170 HAMILTON AVENUE
City,State,Zip:	WHITE PLAINS, NY 10601
Id/Status:	3-466034 / Active
Operator Name:	GHP Hamilton Ave. GHP Office
Owner Name:	GHP Hamilton, LLC
Owner Street:	4 West Red Oak Lane
Owner Address2:	Suite 200
Owner City:	White Plains
Owner State:	NY
Owner Zipcode:	10604
GDS Number:	Not reported
Tank Number:	002
Status:	1. In-Service
Capacity:	10000
Product Stored:	0001. #2 Fuel Oil
Product Stored Percent:	Not reported
Tank Leak Detection:	1. Electronic Interstitial Monitoring
Date Installation:	11/18/2019
Date Perm Closure:	01/01/1900
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	10. Urethane clad steel
Tank Internal Protection:	Not reported
Tank External Protection:	5. Jacketed,9. Urethane
Tank Secondary Containment:	4. Double-Walled (underground only),HIGHLAND TITAN
Piping Location:	2. Underground/on Ground
Piping Type:	11. Flexible Piping
Piping External Protection:	9. Urethane
Overfill Prevention:	2. High Level Alarm
Piping Secondary Containment:	4. Double-Walled (underground only)
Spill Prevention:	1. Catch Basin
Dispenser:	Not reported

GHP HAMILTON AVENUE (Continued) **U004176517**

Tank Number:	3-466034
Status:	3. Closed - Removed
Capacity:	10000
Product Stored:	0001. #2 Fuel Oil
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	03/01/1979
Date Perm Closure:	04/23/2019
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	1. Epoxy liner
Tank External Protection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	2. Underground/on Ground
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	6. Wrapped (Piping)
Overfill Prevention:	5. Vent Whistle
Piping Secondary Containment:	0. None
Spill Prevention:	0. None
Dispenser:	2. Suction

G84 **COMMERCIAL** **NY Spills** **S123663079**
NNW **170 HAMILTON AVE** **N/A**
< 1/8 **WHITE PLAINS, NY**
0.065 mi.
343 ft. **Site 2 of 4 in cluster G**

Relative: **Lower**
Actual: **194 ft.**

SPILLS:

Name:	COMMERCIAL
Address:	170 HAMILTON AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	1900748 / 2020-01-17
Facility ID:	1900748
Facility Type:	ER
DER Facility ID:	108424
Site ID:	586585
DEC Region:	3
Spill Cause:	Unknown
Spill Class:	C4
SWIS:	6017
Spill Date:	2019-04-22
Investigator:	TDGHIOSA
Referred To:	Not reported
Reported to Dept:	2019-04-22
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Other
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2019-04-22
Spill Record Last Update:	2020-01-17
Spiller Name:	ROBERT MCNAMARA
Spiller Company:	GHP HAMILTON AVENUE

COMMERCIAL (Continued) **S123663079**

Spiller Address:	170 HAMILTON AVE
Spiller Company:	999
Contact Name:	GHP ROB
Latitude:	Not reported
Longitude:	Not reported
DEC Memo:	4/22/19 Northeastern Env. was removing 10,000 gallon UST, have uncovered tank, and soil is visually contaminated. Tank will be removed completely tomorrow, and WCHD will be on site at that time for inspection. No waterways involved, and property on municipal water. ga 4/23/19 Spoke to property owner - sending draft guidance by e-mail. ga 01/15/2020 Northeast Environmental reported that they excavated and removed one 10,000 gallon tank along with 192.69 tons of contaminated soil. Post excavation soil sample results were below DEC soil guidance values. NFA. TG
Remarks:	in the process of removing a 10000 gallon tank, unknown of material, clean up pending

All Materials:

Site ID:	586585
Operable Unit ID:	1334266
Operable Unit:	01
Material ID:	2343569
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported
Resource Affected:	Soil
Oxygenate:	Not reported

G85 **OFFICE BUILDING** **NY Spills** **S102241491**
NNW **170 HAMILTON AVE** **NY MANIFEST** **N/A**
< 1/8 **WHITE PLAINS, NY**
0.065 mi.
343 ft. **Site 3 of 4 in cluster G**

Relative: **Lower**
Actual: **194 ft.**

SPILLS:

Name:	OFFICE BUILDING
Address:	170 HAMILTON AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9601379 / 2000-10-06
Facility ID:	9601379
Facility Type:	ER
DER Facility ID:	108424
Site ID:	125352
DEC Region:	3
Spill Cause:	Unknown
Spill Class:	C5
SWIS:	6017
Spill Date:	1996-04-26
Investigator:	tdghiosa
Referred To:	Not reported

OFFICE BUILDING (Continued) **S102241491**

Reported to Dept:	1996-04-26
CID:	323
Water Affected:	Not reported
Spill Source:	Unknown
Spill Notifier:	Other
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	1996-04-26
Spill Record Last Update:	2000-10-16
Spiller Name:	UNKNOWN
Spiller Company:	UNKNOWN
Spiller Address:	Not reported
Spiller Company:	001
Contact Name:	ANTHONY LONGHITANO
Latitude:	41.0330836
Longitude:	-73.7702647
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY 10/06/2000 LETTER SENT TO ELMENDORF ENVIRONMENTAL BY T. GHIOSAY; SPILL NUMBER IS CLOSED BUT SOME CONTAMINATION REMAINS WHICH MAY HAVE TO BE ADDRESSED AT A LATER TIME.
Remarks:	CONTAMINATED GROUND WATER FOUND. DEC INVESTIGATING AT THIS TIME.

All Materials:

Site ID:	125352
Operable Unit ID:	1029030
Operable Unit:	01
Material ID:	351186
Material Code:	0009
Material Name:	gasoline
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

NY MANIFEST:

EPA ID:	NYP004108221
Country:	USA
Name:	Consolidated Edison
Address:	170 HAMILTON AVE
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY
Zip 4:	Not reported
Location Address 1:	170 HAMILTON AVE
Location Address 2:	Not reported
Location City,State,Zip:	WHITE PLAINS, NY
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported

OFFICE BUILDING (Continued) **S102241491**

Code: BP

Mailing:
Mailing Name: Consolidated Edison
Mailing Contact: Franklin Murray
Mailing Address 1: 4 IRVING PLACE RM 828
Mailing Address 2: Not reported
Mailing City,State,Zip: NEW YORK, NY 10003
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: 2124602808

Manifest Data:
Document ID: NYE1279746
Manifest Status: Not reported
Trans1 State ID: 46274JM
Year: 2003
Trans2 State ID: Not reported
Generator Ship Date: 03/05/2003
Trans1 Recv Date: 03/05/2003
Trans2 Recv Date: Not reported
TSD Site Recv Date: 03/06/2003
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYP004108221
Trans1 EPA ID: NYD006982359
Trans2 EPA ID: Not reported
TSDF ID 1: NYD077444263
TSDF ID 2: Not reported
Manifest Tracking Number: Not reported
Import Indicator: Not reported
Export Indicator: Not reported
Discr Quantity Indicator: Not reported
Discr Type Indicator: Not reported
Discr Residue Indicator: Not reported
Discr Partial Reject Indicator: Not reported
Discr Full Reject Indicator: Not reported
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: Not reported
Waste Code 1: B007
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 00200
Units: Kilograms
Number of Containers: 002
Container Type: Metal drums, barrels, kegs
Handling Method: Landfill
Specific Gravity: 01.00

Document ID: NYE1298214
Manifest Status: Not reported
Trans1 State ID: 46690JM

OFFICE BUILDING (Continued) **S102241491**

Year:	2003
Trans2 State ID:	Not reported
Generator Ship Date:	02/28/2003
Trans1 Recv Date:	02/28/2003
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	03/03/2003
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004108221
Trans1 EPA ID:	NYD006982359
Trans2 EPA ID:	Not reported
TSDF ID 1:	NYD077444263
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Cadmium
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00259
Units:	Kilograms
Number of Containers:	003
Container Type:	Metal drums, barrels, kegs
Handling Method:	Landfill
Specific Gravity:	01.00

H86 **CUSHMAN & WAKEFIELD** **PA MANIFEST** **S112069200**
WNW **ONE N LEXINGTON AVE** **N/A**
< 1/8 **WHITE PLAINS, NY 10601**
0.068 mi.
361 ft. **Site 1 of 4 in cluster H**

Relative:
Higher

Actual:
201 ft.

PA MANIFEST:

Name:	CUSHMAN & WAKEFIELD
Address:	ONE N LEXINGTON AVE
City,State,Zip:	WHITE PLAINS, NY 10601
Year:	2011
Manifest Number:	001162465FLE
Manifest Type:	T
Generator EPA ID:	NYD986984698
Generator Date:	11/23/2011
Mailing Address:	Not reported
Contact Name:	Not reported
Contact Phone:	Not reported
TSD EPA ID:	PAD067098822

CUSHMAN & WAKEFIELD (Continued) **S112069200**

TSD Date:	Not reported
TSD Facility Name:	CYCLE CHEM INC
TSD Facility Address:	550 INDUSTRIAL DRIVE
TSD Facility City:	LEWISBERRY
TSD Facility State:	PA
Facility Telephone:	Not reported
Page Number:	1
Line Number:	1
Waste Number:	D001
Container Number:	1
Container Type:	DF
Waste Quantity:	300
Unit:	P
Handling Code:	Not reported
TSP EPA ID:	Not reported
Date TSP Sig:	Not reported

F87 **WHITE PLAINS GENERAL AUTO RPS*** **EDR Hist Auto** **1021082368**
NW **76 HAMILTON AVE** **N/A**
< 1/8 **WHITE PLAINS, NY 10601**
0.069 mi.
363 ft. **Site 4 of 8 in cluster F**

Relative: EDR Hist Auto
Higher

Actual:
201 ft.

Year:	Name:	Type:
1969	WHITE PLAINS GENERAL AUTO RPS*	General Automotive Repair Shops
1970	WHITE PLAINS GENERAL AUTO RPS*	General Automotive Repair Shops
1971	WHITE PLAINS GENERAL AUTO RPS*	General Automotive Repair Shops
1972	WHITE PLAINS GENERAL AUTO RPS*	General Automotive Repair Shops
1973	WHITE PLAINS GENERAL AUTO RPS*	General Automotive Repair Shops
1974	WHITE PLAINS GENERAL AUTO RPS*	General Automotive Repair Shops
1975	WHITE PLAINS GENERAL AUTO RPS*	General Automotive Repair Shops
1976	WHITE PLAINS GENERAL AUTO RPS*	General Automotive Repair Shops
1977	WHITE PLAINS GENERAL AUTO RPS*	General Automotive Repair Shops
1978	WHITE PLAINS GENERAL AUTO RPS*	General Automotive Repair Shops
1979	WHITE PLAINS GENERAL AUTO RPS*	General Automotive Repair Shops
1980	WHITE PLAINS GENERAL AUTO RPS*	General Automotive Repair Shops
1982	WHITE PLAINS GENERAL AUTO RPS*	General Automotive Repair Shops
1983	WHITE PLAINS GENERAL AUTO RPS*	General Automotive Repair Shops
1985	WHITE PLAINS GENERAL AUTO RPS*	General Automotive Repair Shops

---

F88 **WHITE PLAINS GENL AUTO REP INC** **RCRA NonGen / NLR** **1000397517**
NW **76 HAMILTON AVE** **FINDS** **NYD013395397**
< 1/8 **WHITE PLAINS, NY 10601** **ECHO**
0.069 mi.
363 ft. **Site 5 of 8 in cluster F**

Relative: RCRA Listings:
Higher

Actual:
201 ft.

Date Form Received by Agency:	20070101
Handler Name:	White Plains Genl Auto Rep Inc
Handler Address:	Hamilton Ave
Handler City,State,Zip:	WHITE PLAINS, NY 10601-1702
EPA ID:	NYD013395397
Contact Name:	Not reported
Contact Address:	HAMILTON AVE

WHITE PLAINS GENL AUTO REP INC (Continued) **1000397517**

Contact City,State,Zip:	WHITE PLAINS, NY 10601
Contact Telephone:	Not reported
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Not reported
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R3
Mailing Address:	HAMILTON AVE
Mailing City,State,Zip:	WHITE PLAINS, NY 10601
Owner Name:	Sun Oil Company Of Pennsylvania
Owner Type:	Private
Operator Name:	Sun Oil Company Of Pennsylvania
Operator Type:	Private
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20150414
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No

WHITE PLAINS GENL AUTO REP INC (Continued) **1000397517**

Recycler Activity Without Storage: No
Manifest Broker: No
Sub-Part P Indicator: No

Hazardous Waste Summary:
Waste Code: D000
Waste Description: Not Defined

Waste Code: D001
Waste Description: Ignitable Waste

Handler - Owner Operator:
Owner/Operator Indicator: Owner
Owner/Operator Name: SUN OIL COMPANY OF PENNSYLVANIA
Legal Status: Private
Date Became Current: Not reported
Date Ended Current: Not reported
Owner/Operator Address: NOT REQUIRED
Owner/Operator City,State,Zip: NOT REQUIRED, WY 99999
Owner/Operator Telephone: 212-555-1212
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Owner
Owner/Operator Name: SUN OIL COMPANY OF PENNSYLVANIA
Legal Status: Private
Date Became Current: Not reported
Date Ended Current: Not reported
Owner/Operator Address: NOT REQUIRED
Owner/Operator City,State,Zip: NOT REQUIRED, WY 99999
Owner/Operator Telephone: 212-555-1212
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Operator
Owner/Operator Name: SUN OIL COMPANY OF PENNSYLVANIA
Legal Status: Private
Date Became Current: Not reported
Date Ended Current: Not reported
Owner/Operator Address: NOT REQUIRED
Owner/Operator City,State,Zip: NOT REQUIRED, WY 99999
Owner/Operator Telephone: 212-555-1212
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Historic Generators:
Receive Date: 19990708
Handler Name: WHITE PLAINS GENL AUTO REP INC
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No

WHITE PLAINS GENL AUTO REP INC (Continued) **1000397517**

Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20060101
Handler Name: WHITE PLAINS GENL AUTO REP INC
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20070101
Handler Name: WHITE PLAINS GENL AUTO REP INC
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 19800818
Handler Name: WHITE PLAINS GENL AUTO REP INC
Federal Waste Generator Description: Large Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

WHITE PLAINS GENL AUTO REP INC (Continued) **1000397517**

FINDS:
Registry ID: 110004348411

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:
The Resource Conservation and Recovery Act Information System (RCRAInfo) is EPA's comprehensive information system in support of the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. It tracks many types of information about generators, transporters, treaters, storers, and disposers of hazardous waste.

Click this hyperlink while viewing on your computer to access additional FINDS: detail in the EDR Site Report.

ECHO:
Envid: 1000397517
Registry ID: 110004348411

DFR URL:
Name: WHITE PLAINS GENL AUTO REP INC
Address: 76 HAMILTON AVE
City,State,Zip: WHITE PLAINS, NY 10601

I89 **MANHOLE #4021** **NY Spills** **S106006516**
NNE **HAMILTON AVE & GROVE ST** **N/A**
< 1/8 **WHITE PLAINS, NY**
0.073 mi.
385 ft. **Site 1 of 2 in cluster I**

Relative: SPILLS:
Lower
Name: MANHOLE #4021
Actual: Address: HAMILTON AVE & GROVE ST
187 ft. City,State,Zip: WHITE PLAINS, NY
Spill Number/Closed Date: 0205032 / 2002-08-13
Facility ID: 0205032
Facility Type: ER
DER Facility ID: 66203
Site ID: 69649
DEC Region: 3
Spill Cause: Equipment Failure
Spill Class: C4
SWIS: 6017
Spill Date: 2002-08-12
Investigator: jbodee
Referred To: Not reported
Reported to Dept: 2002-08-13
CID: 201
Water Affected: Not reported
Spill Source: Commercial/Industrial
Spill Notifier: Responsible Party
Cleanup Ceased: Not reported
Cleanup Meets Std: True
Last Inspection: Not reported
Recommended Penalty: False
UST Trust: False
Remediation Phase: 0

MANHOLE #4021 (Continued) **S106006516**

Date Entered In Computer:	2002-08-13
Spill Record Last Update:	2002-10-30
Spiller Name:	CALLER
Spiller Company:	CON ED
Spiller Address:	4 IRVING PL
Spiller Company:	001
Contact Name:	CALLER
Latitude:	41.0330830
Longitude:	-73.7701890
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was O'DEE
Remarks:	4 OZ OF PRODUCT @ 30014 PARTS/MIL. CLEAN UP WILL BEGIN THE MORNING. CON ED #144499.

All Materials:

Site ID:	69649
Operable Unit ID:	857795
Operable Unit:	01
Material ID:	552589
Material Code:	0541A
Material Name:	dielectric fluid
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	1.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

I90 **CON EDISON** **NY MANIFEST** **S118463677**
NNE **HAMILTON & MARTIN LUTHER KING** **N/A**
< 1/8 **WHITE PLAINS, NY 10601**
0.073 mi.
385 ft. **Site 2 of 2 in cluster I**

Relative:
Lower

Actual:
187 ft.

NY MANIFEST:

EPA ID:	NYP004855397
Country:	USA
Name:	Con Edison
Address:	HAMILTON & MARTIN LUTHER KING
Address 2:	SB 8320
City,State,Zip:	WHITE PLAINS, NY 10601
Zip 4:	Not reported
Location Address 1:	HAMILTON & MARTIN LUTHER KING
Location Address 2:	SB 8320
Location City,State,Zip:	WHITE PLAINS, NY 10601
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Edison
Mailing Contact:	Dennis Huacon
Mailing Address 1:	4 IRVING PL 15TH FL
Mailing Address 2:	Not reported
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported

CON EDISON (Continued) **S118463677**

Mailing Country: USA
Mailing Phone: 2124603770

Manifest Data:
Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: NYD006982359
Year: 2018
Trans2 State ID: Not reported
Generator Ship Date: 10/19/2015
Trans1 Recv Date: 10/19/2015
Trans2 Recv Date: Not reported
TSD Site Recv Date: 10/26/2015
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYP004855397
Trans1 EPA ID: Not reported
Trans2 EPA ID: Not reported
TSDF ID 1: NJD002200046
TSDF ID 2: Not reported
Manifest Tracking Number: 013245105JJK
Import Indicator: N
Export Indicator: N
Discr Quantity Indicator: N
Discr Type Indicator: N
Discr Residue Indicator: N
Discr Partial Reject Indicator: N
Discr Full Reject Indicator: N
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: H110
Waste Code a: Lead
Waste Code b: Not reported
Waste Code c: Not reported
Waste Code e: Not reported
Waste Code f: Not reported
Waste Code g: Not reported
Waste Code 1: Not reported
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 20
Units: Pounds
Number of Containers: 1
Container Type: Cargo tanks (tank trucks)
Handling Method: Treat
Specific Gravity: 1

D91 **PUBLIC SAFETY BUILDING** **NY UST** **U004441391**
SSW **77 SOUTH LEXINGTON AVENUE** **N/A**
< 1/8 **WHITE PLAINS, NY 10601**
0.075 mi.
397 ft. **Site 12 of 13 in cluster D**

Relative:
Higher

Actual:
201 ft.

WESTCHESTER CO. UST:

Name:	PUBLIC SAFETY BUILDING
Address:	77 SOUTH LEXINGTON AVENUE
City,State,Zip:	WHITE PLAINS, NY 10601
Id/Status:	3-601115 / Active
Operator Name:	City Of White Plains
Owner Name:	City Of White Plains
Owner Street:	255 Main Street
Owner Address2:	Not reported
Owner City:	White Plains
Owner State:	NY
Owner Zipcode:	10601
GDS Number:	3551700345
Tank Number:	38
Status:	3. Closed - Removed
Capacity:	2385
Product Stored:	0009. Gasoline
Product Stored Percent:	Not reported
Tank Leak Detection:	5. In-Tank System (auto tank gauge)
Date Installation:	02/01/1990
Date Perm Closure:	01/01/1900
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	6. Fiberglass reinforced plastic (FRP)
Tank Internal Protection:	3. Fiberglass liner (FRP)
Tank External Protection:	4. Fiberglass
Tank Secondary Containment:	4. Double-Walled (underground only)
Piping Location:	2. Underground/on ground
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	Not reported
Overfill Prevention:	2. High Level Alarm
Piping Secondary Containment:	Not reported
Spill Prevention:	1. Catch Basin
Dispenser:	2. Suction
Tank Number:	39
Status:	3. Closed - Removed
Capacity:	2000
Product Stored:	0008. Diesel
Product Stored Percent:	Not reported
Tank Leak Detection:	5. In-Tank System (auto tank gauge)
Date Installation:	02/01/1990
Date Perm Closure:	01/01/1900
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	6. Fiberglass reinforced plastic (FRP)
Tank Internal Protection:	3. Fiberglass liner (FRP)
Tank External Protection:	4. Fiberglass
Tank Secondary Containment:	4. Double-Walled (underground only)
Piping Location:	2. Underground/on ground
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	Not reported
Overfill Prevention:	2. High Level Alarm

PUBLIC SAFETY BUILDING (Continued) **U004441391**

Piping Secondary Containment: Not reported
Spill Prevention: 1. Catch Basin
Dispenser: 2. Suction

D92 **77 SOUTH LEXINGTON AVE** **NY LTANKS** **S105999444**
SSW **77 SOUTH LEXINGTON AVE** **NY AST** **N/A**
< 1/8 **WHITE PLAINS, NY**
0.075 mi.
397 ft. **Site 13 of 13 in cluster D**

Relative:
Higher

Actual:
201 ft.

LTANKS:
Name: 77 SOUTH LEXINGTON AVE
Address: 77 SOUTH LEXINGTON AVE
City,State,Zip: WHITE PLAINS, NY
Spill Number/Closed Date: 0304231 / 2003-07-22
Facility ID: 0304231
Site ID: 106697
Spill Date: 2003-07-22
Spill Cause: Tank Overfill
Spill Source: Passenger Vehicle
Spill Class: D4
Cleanup Ceased: Not reported
SWIS: 6017
Investigator: jbodee
Referred To: Not reported
Reported to Dept: 2003-07-22
CID: 216
Water Affected: Not reported
Spill Notifier: Other
Last Inspection: Not reported
Recommended Penalty: False
Meets Standard: True
UST Involvement: False
Remediation Phase: 0
Date Entered In Computer: 2003-07-22
Spill Record Last Update: 2003-07-25
Spiller Name: Not reported
Spiller Company: MARCOS RAMOS
Spiller Address: Not reported
Spiller County: 001
Spiller Contact: LINDA RICCO
Spiller Phone: (718) 383-1400
Spiller Extention: Not reported
DEC Region: 3
DER Facility ID: 93920
Latitude: 41.0295878
Longitude: -73.7718880
DEC Memo: Prior to Sept, 2004 data translation this spill Lead_DEC Field was O'DEE
Remarks: SPILL AT POLICE STATION OVER FILL SPIL IS CLEANED UP

All Materials:
Site ID: 106697
Operable Unit ID: 871118
Operable Unit: 01
Material ID: 505088
Material Code: 0009
Material Name: gasoline

77 SOUTH LEXINGTON AVE (Continued) **S105999444**

Case No.:	Not reported
Material FA:	Petroleum
Quantity:	1.00
Units:	G
Recovered:	1.00
Resource Affected:	Soil
Oxygenate:	Not reported

WESTCHESTER CO. AST:

Name:	PUBLIC SAFETY BUILDING
Address:	77 SOUTH LEXINGTON AVENUE
City,State,Zip:	WHITE PLAINS, NY 10601
PBS Number:	3-601115
Site Status:	Active
GDS Number:	3551700345
Operator Name:	City Of White Plains
Owner Name:	City Of White Plains
Owner Street:	255 Main Street
Owner Address2:	Not reported
Owner City/State/Zip:	White Plains, NY 10601

Tank Number:	38A
Status:	1. In-Service
Date Installation:	01/01/2011
Capacity:	3000
Product Stored:	0009. Gasoline
Product Stored Percent:	0
Date Perm Closure:	01/01/1900
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	5. Steel tank in concrete
Tank Internal Protection:	0. None
Tank External Protection:	concrete
Tank Leak Detection:	1. Electronic Interstitial Monitoring,5. In-Tank System (auto tank gauge)
Tank Secondary Containment:	9. Modified double-walled (aboveground only)
Piping Location:	1. Aboveground
Piping Type:	3. Stainless steel alloy
Piping External Protection:	0. None
Piping Leak Detection:	0. None
Piping Secondary Containment:	0. None
Overfill Prevention:	2. High Level Alarm,3. Automatic Shut-off
Spill Prevention:	1. Catch Basin
Dispenser:	1. Submersible

Tank Number:	38B
Status:	1. In-Service
Date Installation:	01/01/2011
Capacity:	1000
Product Stored:	0009. Gasoline
Product Stored Percent:	85
Date Perm Closure:	01/01/1900
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	5. Steel tank in concrete
Tank Internal Protection:	0. None
Tank External Protection:	concrete
Tank Leak Detection:	1. Electronic Interstitial Monitoring,5. In-Tank System (auto tank gauge)

77 SOUTH LEXINGTON AVE (Continued) **S105999444**

Tank Secondary Containment:	9. Modified double-walled (aboveground only)
Piping Location:	1. Aboveground
Piping Type:	3. Stainless Steel Alloy
Piping External Protection:	0. None
Piping Leak Detection:	0. None
Piping Secondary Containment:	0. None
Overfill Prevention:	2. High Level Alarm
Spill Prevention:	1. Catch Basin
Dispenser:	1. Submersible

Tank Number:	40
Status:	1. In-Service
Date Installation:	01/01/2011
Capacity:	500
Product Stored:	0008. Diesel
Product Stored Percent:	100
Date Perm Closure:	01/01/1900
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	5. Steel tank in concrete
Tank Internal Protection:	0. None
Tank External Protection:	concrete
Tank Leak Detection:	2. Manual Interstitial Monitoring,6. Impervious Barrier/Concrete Pad (Aboveground Only)
Tank Secondary Containment:	9. Modified double-walled (aboveground only)
Piping Location:	1. Aboveground
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Piping Leak Detection:	9. Exempt suction piping
Piping Secondary Containment:	0. None
Overfill Prevention:	4. Product Level Gauge (Aboveground Only),5. Vent Whistle
Spill Prevention:	1. Catch Basin
Dispenser:	2. Suction

J93 **CROSS WESTCHESTER CLEANERS** **EDR Hist Cleaner** **1019965443**
SW **4 MARTINE AVE** **N/A**
< 1/8 **WHITE PLAINS, NY 10606**
0.077 mi.
405 ft. **Site 1 of 4 in cluster J**

Relative: EDR Hist Cleaner
Higher

Actual:
203 ft.

Year:	Name:	Type:
1991	CROSS WESTCHESTER CLEANERS	Drycleaning Plants, Except Rugs, NEC
1992	CROSS WESTCHESTER CLEANERS	Drycleaning Plants, Except Rugs, NEC
1993	CROSS WESTCHESTER CLEANERS	Drycleaning Plants, Except Rugs, NEC
1994	CROSS WESTCHESTER CLEANERS	Drycleaning Plants, Except Rugs, NEC
1995	CROSS WESTCHESTER CLEANERS	Drycleaning Plants, Except Rugs, NEC
1996	CROSS WESTCHESTER CLEANERS	Drycleaning Plants, Except Rugs, NEC
1997	CROSS WESTCHESTER CLEANERS	Drycleaning Plants, Except Rugs, NEC
1998	CROSS WESTCHESTER CLEANERS	Drycleaning Plants, Except Rugs, NEC
1999	CROSS WESTCHESTER CLEANERS	Drycleaning Plants, Except Rugs, NEC

J94 **CROSS WESTCHESTER CLEANERS** **EDR Hist Cleaner** **1019965439**
SW **2A MARTINE AVE** **N/A**
< 1/8 **WHITE PLAINS, NY 10606**
0.078 mi.
411 ft. **Site 2 of 4 in cluster J**

Relative: EDR Hist Cleaner
Higher

Actual: Year: Name: Type:
203 ft. 2000 CROSS WESTCHESTER CLEANERS Drycleaning Plants, Except Rugs, NEC

K95 **VINTAGE RESTAURANT** **NY LTANKS** **S108059295**
ENE **171-173 MAIN STREET** **N/A**
< 1/8 **WHITE PLAINS, NY**
0.079 mi.
418 ft. **Site 1 of 27 in cluster K**

Relative: LTANKS:
Higher

Actual:
205 ft.

Name:	VINTAGE RESTAURANT
Address:	171-173 MAIN STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0602861 / 2008-09-26
Facility ID:	0602861
Site ID:	365437
Spill Date:	2006-06-14
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	TDGHIOSA
Referred To:	Not reported
Reported to Dept:	2006-06-14
CID:	444
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2006-06-14
Spill Record Last Update:	2008-09-26
Spiller Name:	FREDERICK SASSE
Spiller Company:	SINGER TRUST C/O GEORGE A BOWNMAN INC
Spiller Address:	36 W 44TH ST. SUIT 810
Spiller County:	001
Spiller Contact:	MIKE
Spiller Phone:	(516) 924-3824
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	315576
Latitude:	41.0323340
Longitude:	-73.7683627
DEC Memo:	6/14/06 Pro Test on site to test the 1500 gallon tank as ordered by the DEC. Tester couldn't get vacuum on the tank. Andre from ProTest said the cement on top of the tank needs to be removed to expose all of the bungs and piping. Once that is performed, then the tank can be isolated and tested. Visual observation revealed that the steel on the top of the tank was very heavily corroded. TG 06/29/06 AM -

VINTAGE RESTAURANT (Continued) **S108059295**

ProTest back on site retesting the lines and the tank. Andre reported that the vent line and the remote fill line both failed the test. The tank failed to hold a vacuum therefore, it also failed. Andre recommending unearthing the manway and checking that for a definitive answer on the tank failure. However this can't be accomplished until a refrigeration compressor is moved which will require a refrigeration mechanic. TG 06/29/06 John Leddy from ProTest officially reported that the tank failed and that the tank has lost two inches of oil since the 14th and the tank is not being used. Recommending emptying the tank to their client. TG 07/05/06 Joe Ostrosky from Petroleum Tank Cleaners (PTC) reported that PTC was hired to remove the oil from the tank. The tank has been emptied, cut open and cleaned. TG 11/15/06 New England Tank Services has completed the removal of the tank, allowing for an inspection. Substantial corrosion and numerous holes were observed. A letter was sent to the management company requiring the installation of two monitoring wells. 03/12/07 Monitoring well installation report submitted by JM Associates who were subcontracted by Fleet Environmental. No free product was detected in the wells. TG 07/30/07 New England Tank Services reported that they removed the tank along with 2.64 tons of petroleum contaminated soil. TG

Remarks: Not reported

All TTF:

Facility ID:	0602861
Spill Number:	0602861
Spill Tank Test:	1550055
Site ID:	365437
Tank Number:	1
Tank Size:	1500
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Watchdog
Last Modified Date:	Not reported

All Materials:

Site ID:	365437
Operable Unit ID:	1123455
Operable Unit:	01
Material ID:	2112912
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

VINTAGE RESTAURANT (Continued) **S108059295**

Name:	VINTAGE RESTAURANT
Address:	171-173 MAIN STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0602861 / 2008-09-26
Facility ID:	0602861
Site ID:	365437
Spill Date:	2006-06-14
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	TDGHIOSA
Referred To:	Not reported
Reported to Dept:	2006-06-14
CID:	444
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2006-06-14
Spill Record Last Update:	2008-09-26
Spiller Name:	JOHN HAMILTON
Spiller Company:	SINGER TRUSTEE
Spiller Address:	Not reported
Spiller County:	999
Spiller Contact:	MIKE
Spiller Phone:	(516) 924-3824
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	315576
Latitude:	41.0323340
Longitude:	-73.7683627
DEC Memo:	6/14/06 Pro Test on site to test the 1500 gallon tank as ordered by the DEC. Tester couldn't get vacuum on the tank. Andre from ProTest said the cement on top of the tank needs to be removed to expose all of the bungs and piping. Once that is performed, then the tank can be isolated and tested. Visual observation revealed that the steel on the top of the tank was very heavily corroded. TG 06/29/06 AM - ProTest back on site retesting the lines and the tank. Andre reported that the vent line and the remote fill line both failed the test. The tank failed to hold a vacuum therefore, it also failed. Andre recommending unearthing the manway and checking that for a definitive answer on the tank failure. However this can't be accomplished until a refrigeration compressor is moved which will require a refrigeration mechanic. TG 06/29/06 John Leddy from ProTest officially reported that the tank failed and that the tank has lost two inches of oil since the 14th and the tank is not being used. Recommending emptying the tank to their client. TG 07/05/06 Joe Ostrosky from Petroleum Tank Cleaners (PTC) reported that PTC was hired to remove the oil from the tank. The tank has been emptied, cut open and cleaned. TG 11/15/06 New England Tank Services has completed the removal of the tank, allowing for an inspection. Substantial corrosion and numerous holes were observed. A letter was sent to the

VINTAGE RESTAURANT (Continued) **S108059295**

management company requiring the installation of two monitoring wells. 03/12/07 Monitoring well installation report submitted by JM Associates who were subcontracted by Fleet Environmental. No free product was detected in the wells. TG 07/30/07 New England Tank Services reported that they removed the tank along with 2.64 tons of petroleum contaminated soil. TG

Remarks: Not reported

All TTF:

Facility ID:	0602861
Spill Number:	0602861
Spill Tank Test:	1550055
Site ID:	365437
Tank Number:	1
Tank Size:	1500
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Watchdog
Last Modified Date:	Not reported

All Materials:

Site ID:	365437
Operable Unit ID:	1123455
Operable Unit:	01
Material ID:	2112912
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

K96 **LAST CALL NY INC/DBA - VINTAGE BAR** **NY UST** **U004440727**
ENE **171-173 MAIN STREET** **N/A**
< 1/8 **WHITE PLAINS, NY 10543**
0.079 mi.
418 ft. **Site 2 of 27 in cluster K**

Relative: **Higher**
Actual: **205 ft.**

WESTCHESTER CO. UST:

Name:	LAST CALL NY INC/DBA - VINTAGE BAR
Address:	171-173 MAIN STREET
City,State,Zip:	WHITE PLAINS, NY 10543
Id/Status:	3-800096 / Unregulated: <1101 gal. PBS
Operator Name:	Decklin Farrell
Owner Name:	The Singer Trust c/o George A Bowman Inc.
Owner Street:	36 West 44th Street
Owner Address2:	Not reported

LAST CALL NY INC/DBA - VINTAGE BAR (Continued) **U004440727**

Owner City:	New York
Owner State:	NY
Owner Zipcode:	10036
GDS Number:	Not reported
Tank Number:	001
Status:	3. Closed - Removed
Capacity:	1500
Product Stored:	Not reported
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	Not reported
Date Perm Closure:	10/12/2006
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	99. Other
Piping Location:	1. Aboveground
Piping Type:	10. Copper
Piping External Protection:	0. None
Overfill Prevention:	5. Vent Whistle
Piping Secondary Containment:	Not reported
Spill Prevention:	Not reported
Dispenser:	2. Suction

G97 **WHITE PLAINS HOUSING AUTHORITY - WINBROOK APARTMEN** **RCRA-SQG** **1027473851**
NNE **33 FISHER AVE** **E MANIFEST** **NYR000258293**
< 1/8 **WHITE PLAINS, NY 10601**
0.083 mi.
439 ft. **Site 4 of 4 in cluster G**

Relative: **Lower**
Actual: **186 ft.**

RCRA Listings:

Date Form Received by Agency:	20221020
Handler Name:	White Plains Housing Authority - Winbrook Apartments
Handler Address:	Fisher Ave
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYR000258293
Contact Name:	TEDDIE L HENDERSON
Contact Address:	DR MARTIN LUTHER KING JR BLVD
Contact City,State,Zip:	WHITE PLAINS, NY 10601
Contact Telephone:	914-949-6462 x1015
Contact Fax:	914-949-8211
Contact Email:	THENDERSON@WPHANY.COM
Contact Title:	SECRETARY
EPA Region:	02
Land Type:	Federal
Federal Waste Generator Description:	Small Quantity Generator
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Handler Activities
State District Owner:	Ny
State District:	NYSDEC R3
Mailing Address:	DR MARTIN LUTHER KING JR BLVD
Mailing City,State,Zip:	WHITE PLAINS, NY 10601
Owner Name:	White Plains Housing Authority
Owner Type:	Federal

WHITE PLAINS HOUSING AUTHORITY - WINBROOK APARTMENTS (Continued) **1027473851**

Operator Name:	White Plains Housing Authority
Operator Type:	Federal
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	The land is federally-owned, The site is federally-owned, The site is federally-operated
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20221020
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Hazardous Waste Summary:

Waste Code:	D008
Waste Description:	Lead

Handler - Owner Operator:

Owner/Operator Indicator:	Operator
Owner/Operator Name:	WHITE PLAINS HOUSING AUTHORITY
Legal Status:	Federal
Date Became Current:	19490101
Date Ended Current:	Not reported
Owner/Operator Address:	223 DR MARTIN LUTHER KING JR BLVD

WHITE PLAINS HOUSING AUTHORITY - WINBROOK APARTMENTS (Continued) **1027473851**

Owner/Operator City,State,Zip: WHITE PLAINS, NY 10601
Owner/Operator Telephone: 914-949-6462
Owner/Operator Telephone Ext: 1015
Owner/Operator Fax: Not reported
Owner/Operator Email: THENDERSON@WPHANY.COM

Owner/Operator Indicator: Owner
Owner/Operator Name: WHITE PLAINS HOUSING AUTHORITY
Legal Status: Federal
Date Became Current: 19490101
Date Ended Current: Not reported
Owner/Operator Address: 223 DR MARTIN LUTHER KING JR BLVD
Owner/Operator City,State,Zip: WHITE PLAINS, NY 10601
Owner/Operator Telephone: 914-949-6462
Owner/Operator Telephone Ext: 1015
Owner/Operator Fax: Not reported
Owner/Operator Email: THENDERSON@WPHANY.COM

Historic Generators:
Receive Date: 20221020
Handler Name: WHITE PLAINS HOUSING AUTHORITY - WINBROOK APARTMENTS
Federal Waste Generator Description: Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: No
Electronic Manifest Broker: No

List of NAICS Codes and Descriptions:
NAICS Code: 562910
NAICS Description: Remediation Services

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

E MANIFEST:
Manifest Tracking Number: 019942408JJK
Last Updated Date: 20240112
Shipped Date: 20230908
Received Date: 20231106
Manifest Status: Corrected
Submission Type: DataImage5Copy
Origin Type: Service
Generator EPA ID: NYR000258293
Generator Name: White Plains Housing Authority
Generator Location Street Number: 33
Generator Location Street 1: 33 DR MARTIN LUTHER KING JR BLVD

WHITE PLAINS HOUSING AUTHORITY - WINBROOK APARTMENTS (Continued) **1027473851**

Generator Location Street 2:	Not reported
Generator Location City:	WHTE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601
Generator Mail Street Number:	223
Generator Mail Street 1:	33 DR MARTIN LUTHER KING JR BLVD
Generator Mail Street 2:	Not reported
Generator Mail City:	WHTE PLAINS
Generator Mail Zip:	10601
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	NJD002200046
Designated Facility Name:	Cycle Chem, Inc.
Designated Facility Mail Street Number:	217
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	SOUTH FIRST STREET
Designated Facility Mail City:	ELIZABETH
Designated Facility Mail Zip:	07206
Designated Facility Mail State:	NJ
Designated Facility Location Street Number:	217
Designated Facility Location Street 1:	SOUTH FIRST STREET
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	ELIZABETH
Designated Facility Location Zip:	07206
Designated Facility Location State:	NJ
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Transporter:

Manifest Tracking Number:	019942408JJK
Transporter Line Number:	1
Transporter EPA ID:	NYD986988645
Transporter Name:	Tristate Transfer Inc
Manifest Tracking Number:	019942408JJK
Transporter Line Number:	2
Transporter EPA ID:	NJD003812047
Transporter Name:	Acv Environmental Service Inc.

Waste Line:

Manifest Tracking Number:	019942408JJK
Waste Line Number:	1
U.S. DOT Hazardous Indicator:	Y
U.S. DOT ID Number:	NA3077
U.S. DOT Description:	Na3077, Rq Na3077 Hazardous Waste Solid Nos (Lead) 9 Iii, 9, Pgiii, Lead
Non-Hazardous Waste Description:	Not reported
Number of Containers:	1
Container Type Code:	DM
Container Type Description:	Metal drums, barrels, kegs
Waste Quantity:	300
Quantity Unit of Measure Code:	P
Quantity Unit of Measure Description:	Pounds
Waste Quantity, in Tons:	0.15
Acute Waste Quantity, in Tons:	0

WHITE PLAINS HOUSING AUTHORITY - WINBROOK APARTMENTS (Continued) **1027473851**

Non-Acute Waste Quantity, in Tons:	0.15
Waste Quantity, in Kilograms:	136.0545
Acute Waste Quantity, in Kilograms:	0
Non-Acute Waste Quantity, in Kilorgrams:	136.0545
Management Method Code:	H110
Management Method Description:	STABILIZATION
Waste Residue Indicator:	N
Quantity Discrepancy Indicator:	N
Waste Type Discrepancy Indicator:	N
Waste Density:	Not reported
Waste Density Unit of Measure Code:	Not reported
Waste Density Unit of Measure Description:	Not reported
Form Code:	Not reported
Form Code Description:	Not reported
Source Code:	Not reported
Source Code Description:	Not reported
Waste Minimization Code:	Not reported
Waste Minimization Code Description:	Not reported
Consent Number:	Not reported
EPA Waste Indicator:	Y

K98 **WYASSUP-LAUREL GLEN CORP.** **NY AST** **U004177669**
ENE **175 MAIN STREET** **N/A**
< 1/8 **WHITE PLAINS, NY 10601**
0.085 mi.
451 ft. **Site 3 of 27 in cluster K**

Relative:
Higher

Actual:
206 ft.

WESTCHESTER CO. AST:

Name:	WYASSUP-LAUREL GLEN CORP.
Address:	175 MAIN STREET
City,State,Zip:	WHITE PLAINS, NY 10601
PBS Number:	3-032433
Site Status:	Active
GDS Number:	Not reported
Operator Name:	David Perez
Owner Name:	Wyassup-Laurel Glen Corp.
Owner Street:	866 Lexington Avenue
Owner Address2:	2nd Floor
Owner City/State/Zip:	New York, NY 10065
Tank Number:	002
Status:	1. In-Service
Date Installation:	03/01/2000
Capacity:	5000
Product Stored:	0001. #2 Fuel Oil
Product Stored Percent:	Not reported
Date Perm Closure:	01/01/1900
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Leak Detection:	6. Impervious Barrier/Concrete Pad (Aboveground Only)
Tank Secondary Containment:	2. Vault (w/ access)
Piping Location:	1. Aboveground
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	0. None
Piping Leak Detection:	0. None
Piping Secondary Containment:	0. None

WYASSUP-LAUREL GLEN CORP. (Continued) **U004177669**

Overfill Prevention: 4. Product Level Gauge (Aboveground Only),5. Vent Whistle
Spill Prevention: Not reported
Dispenser: 2. Suction

K99 **OFFICE BLDG** **NY Spills** **S104508595**
ENE **175 MAIN ST** **N/A**
< 1/8 **WHITE PLAINS, NY**
0.085 mi.
451 ft. **Site 4 of 27 in cluster K**

Relative:
Higher

Actual:
206 ft.

SPILLS:
Name: OFFICE BLDG
Address: 175 MAIN ST
City,State,Zip: WHITE PLAINS, NY
Spill Number/Closed Date: 9910497 / 1999-12-02
Facility ID: 9910497
Facility Type: ER
DER Facility ID: 77041
Site ID: 83742
DEC Region: 3
Spill Cause: Unknown
Spill Class: C4
SWIS: 6017
Spill Date: 1999-12-02
Investigator: tdghiosa
Referred To: Not reported
Reported to Dept: 1999-12-02
CID: 371
Water Affected: Not reported
Spill Source: Commercial/Industrial
Spill Notifier: Citizen
Cleanup Ceased: Not reported
Cleanup Meets Std: True
Last Inspection: Not reported
Recommended Penalty: False
UST Trust: False
Remediation Phase: 0
Date Entered In Computer: 1999-12-02
Spill Record Last Update: 2000-01-26
Spiller Name: Not reported
Spiller Company: CONSTRUCTION CREW
Spiller Address: Not reported
Spiller Company: 999
Contact Name: Not reported
Latitude: 41.0323155
Longitude: -73.7683519
DEC Memo: Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY 12/02/99 CALLED TELEPHONE NUMBER ON SHEET-NO JOHN VEGA. SITE INSPECTED BY T. GHIOSAY-NO SPILL. NFA
Remarks: WORKS AGROSS THE STREET FROM THE BLDG, SAW PEOPLE WALKING AROUND BLDG AND THERE IS AN OIL-TYPE PRODUCT ALL OVER THE GROUND.

All Materials:
Site ID: 83742
Operable Unit ID: 1089187
Operable Unit: 01
Material ID: 295979

OFFICE BLDG (Continued) **S104508595**

Material Code:	0066A
Material Name:	unknown petroleum
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

K100 **DRAIN - COOKING GREASE** **NY Spills** **S118636741**
ENE **175 MAIN STREET** **N/A**
< 1/8 **WHITE PLAINS, NY**
0.085 mi.
451 ft. **Site 5 of 27 in cluster K**

Relative: SPILLS:
Higher

Actual: Name:	DRAIN - COOKING GREASE
206 ft. Address:	175 MAIN STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	1511825 / 2016-04-11
Facility ID:	1511825
Facility Type:	ER
DER Facility ID:	478849
Site ID:	524609
DEC Region:	3
Spill Cause:	Deliberate
Spill Class:	C3
SWIS:	6017
Spill Date:	2016-03-12
Investigator:	JBODEE
Referred To:	WCDOH
Reported to Dept:	2016-03-12
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Other
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2016-03-12
Spill Record Last Update:	2016-04-11
Spiller Name:	PAUL
Spiller Company:	SOFRITO
Spiller Address:	175 MAIN STREET
Spiller Company:	999
Contact Name:	PAUL
Latitude:	Not reported
Longitude:	Not reported
DEC Memo:	3-12-16 Spoke with Paul. He says that he witnessed a deliberate dumping down the storm sewer of several oversize buckets. These buckets contained what appeared to be some sort of grease. Location is behind the Galleria Mall on William Street which is off of Main St.

DRAIN - COOKING GREASE (Continued) **S118636741**

This is a municipal lot. He
sent 2 pictures which will be decdoc'd. jm 3/22/16: Photos taken by the Caller were sent to DEC and
entered into DecDocs. jod 4/11/16: Forwarded to County Health department. No other action taken. jod
Not reported
Remarks: business dumping what looks like grease down the drain looking for call back Has pictures

All Materials:
Site ID: 524609
Operable Unit ID: 1273571
Operable Unit: 01
Material ID: 2278007
Material Code: 9999
Material Name: other - grease
Case No.: Not reported
Material FA: Other
Quantity: Not reported
Units: Not reported
Recovered: Not reported
Resource Affected: Not reported
Oxygenate: Not reported

K101 **WYASSUP-LAUREL GLEN CORP.** **NY UST** **U004333699**
ENE **175 MAIN STREET** **N/A**
< 1/8 **WHITE PLAINS, NY 10601**
0.085 mi.
451 ft. **Site 6 of 27 in cluster K**

Relative: **Higher**
Actual: **206 ft.**

WESTCHESTER CO. UST:
Name: WYASSUP-LAUREL GLEN CORP.
Address: 175 MAIN STREET
City,State,Zip: WHITE PLAINS, NY 10601
Id/Status: 3-032433 / Active
Operator Name: David Perez
Owner Name: Wyassup-Laurel Glen Corp.
Owner Street: 866 Lexington Avenue
Owner Address2: 2nd Floor
Owner City: New York
Owner State: NY
Owner Zipcode: 10065
GDS Number: Not reported

Tank Number: 1
Status: 4. Closed - in place
Capacity: 10000
Product Stored: Not reported
Product Stored Percent: Not reported
Tank Leak Detection: 0. None
Date Installation: Not reported
Date Perm Closure: 02/24/2000
Tank Location: 6. Underground, vaulted, with access
Tank Type: 1. Steel/Carbon steel/Iron
Tank Internal Protection: 0. None
Tank External Protection: 0. None
Tank Secondary Containment: Not reported

WYASSUP-LAUREL GLEN CORP. (Continued) **U004333699**

Piping Location:	0. No Pipiing
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Overfill Prevention:	Not reported
Piping Secondary Containment:	Not reported
Spill Prevention:	Not reported
Dispenser:	2. Suction

H102 **CON EDISON MANHOLE: 9927** **RCRA NonGen / NLR** **1016973802**
West **MAIN ST & BANK ST** **NY MANIFEST** **NYP004476107**
< 1/8 **WHITE PLAINS, NY 10606**
0.093 mi.
490 ft. **Site 2 of 4 in cluster H**

Relative: **Higher**
Actual: **200 ft.**

RCRA Listings:

Date Form Received by Agency:	20140423
Handler Name:	Con Edison Manhole: 9927
Handler Address:	Main St & Bank St
Handler City,State,Zip:	WHITE PLAINS, NY 10606
EPA ID:	NYP004476107
Contact Name:	THOMAS TEELING
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	212-460-3770
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	SENIOR SCIENTIST
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PL, 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N

CON EDISON MANHOLE: 9927 (Continued) **1016973802**

Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20141014
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20140323
Handler Name: CON EDISON MANHOLE: 9927	
Federal Waste Generator Description:	Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20140423
Handler Name: CON EDISON MANHOLE: 9927	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

List of NAICS Codes and Descriptions:

NAICS Codes:	No NAICS Codes Found

CON EDISON MANHOLE: 9927 (Continued) **1016973802**

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

NY MANIFEST:

EPA ID:	NYP004476107
Country:	USA
Name:	Con Edison
Address:	MAIN ST & BANK ST
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10606
Zip 4:	Not reported
Location Address 1:	BANK & S/O MAIN ST
Location Address 2:	SB67702
Location City,State,Zip:	WHITE PLAINS, NY 10801
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Edison
Mailing Contact:	Con Edison
Mailing Address 1:	4 IRVING ST
Mailing Address 2:	15TH ST
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	Not reported

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	03/23/2014
Trans1 Recv Date:	03/23/2014
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	03/24/2014
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004476107
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	012772702JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N

CON EDISON MANHOLE: 9927 (Continued) **1016973802**

Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	100
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

H103 **CON EDISON** **RCRA NonGen / NLR** **1014398891**
West **BANK ST & MAIN ST** **NY MANIFEST** **NYP004212643**
< 1/8 **WHITE PLAINS, NY 10606** **NJ MANIFEST**
0.093 mi.
490 ft. **Site 3 of 4 in cluster H**

Relative: **Higher**
Actual: **200 ft.**

RCRA Listings:

Date Form Received by Agency:	20200413
Handler Name:	Con Edison
Handler Address:	Bank St & Main St
Handler City,State,Zip:	WHITE PLAINS, NY 10606
EPA ID:	NYP004212643
Contact Name:	Not reported
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	Not reported
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	Not reported
Mailing City,State,Zip:	Not reported
Owner Name:	Not reported
Owner Type:	Not reported

CON EDISON (Continued) **1014398891**

Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20200413
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20100803
Handler Name: CON EDISON	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

CON EDISON (Continued) **1014398891**

Receive Date:	20200413
Handler Name: CON EDISON	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	No
Electronic Manifest Broker:	No

List of NAICS Codes and Descriptions:

NAICS Codes:	No NAICS Codes Found

Facility Has Received Notices of Violations:

Violations:	No Violations Found

Evaluation Action Summary:

Evaluations:	No Evaluations Found

NY MANIFEST:

EPA ID:	NYP004212643
Country:	USA
Name:	Consolidated Edison
Address:	BANK ST & MAIN ST
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10606
Zip 4:	Not reported
Location Address 1:	MAIN & BANK
Location Address 2:	Not reported
Location City,State,Zip:	WHITE PLAINS, NY 10602
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Consolidated Edison
Mailing Contact:	Tom Teeling
Mailing Address 1:	4 IRVING PLACE RM 828
Mailing Address 2:	Not reported
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	2124603770

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported

CON EDISON (Continued) **1014398891**

Generator Ship Date:	08/03/2010
Trans1 Recv Date:	08/03/2010
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	08/03/2010
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004212643
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	001086060GBF
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	Y
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H111
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	100
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

NJ MANIFEST:

EPA ID:	NYP004212643
Name:	CON EDISON
Address:	BANK ST & MAIN ST
City,State,Zip:	WHITE PLAINS, NY 10606
County:	Not reported
Mailing Address:	4 IRVING PL, RM 828
Mailing City,State,Zip:	NEW YORK, NY 10003
Telephone:	Not reported
Emergency Telephone:	Not reported
Contact:	DENNIS ROHRER
Comments:	Not reported
SIC Code:	Not reported
County:	NY119

CON EDISON (Continued) **1014398891**

Municipal:	Not reported
Previous EPAID:	Not reported
Generator Flag:	Not reported
Transporter Flag:	Not reported
TSDF Flag:	Not reported
Name Change:	Not reported
Date Change:	Not reported

Manifest Data:

EPA ID:	NYP004212643
Manifest Number:	001086060GBF
Date Shipped:	08/03/2010
TSDF EPA ID:	NJD002200046
Transporter EPA ID:	NYD006982359
Transporter 2 EPA ID:	Not reported
Transporter 3 EPA ID:	Not reported
Transporter 4 EPA ID:	Not reported
Transporter 5 EPA ID:	Not reported
Transporter 6 EPA ID:	Not reported
Transporter 7 EPA ID:	Not reported
Transporter 8 EPA ID:	Not reported
Transporter 9 EPA ID:	Not reported
Transporter 10 EPA ID:	Not reported
Date Trans1 Transported Waste:	08/03/2010
Date Trans2 Transported Waste:	Not reported
Date Trans3 Transported Waste:	Not reported
Date Trans4 Transported Waste:	Not reported
Date Trans5 Transported Waste:	Not reported
Date Trans6 Transported Waste:	Not reported
Date Trans7 Transported Waste:	Not reported
Date Trans8 Transported Waste:	Not reported
Date Trans9 Transported Waste:	Not reported
Date Trans10 Transported Waste:	Not reported
Date TSDF Received Waste:	08/03/2010
TSDF EPA Facility Name:	Not reported
QTY Units:	Not reported
Transporter SEQ ID:	Not reported
Transporter-1 Date:	Not reported
Waste SEQ ID:	Not reported
Waste Type Code 2:	Not reported
Waste Type Code 3:	Not reported
Waste Type Code 4:	Not reported
Waste Type Code 5:	Not reported
Waste Type Code 6:	Not reported
Date Accepted:	Not reported
Manifest Discrepancy Type:	Not reported
Data Entry Number:	Not reported
Was Load Rejected:	N
Reason Load Was Rejected:	Not reported

Waste:

Manifest Year:	Not reported
Waste Code:	D008
Hand Code:	H111
Quantity:	100
Unit:	P

L104 **APARTMENT** **NY AST** **S108129595**
SSW **76 SOUTH LEXINGTON AVE** **NY Spills** **N/A**
< 1/8 **WHITE PLAINS, NY**
0.098 mi.
519 ft. **Site 1 of 6 in cluster L**

Relative:
Higher

Actual:
201 ft.

WESTCHESTER CO. AST:

Name:	STATION PLAZA
Address:	76 SOUTH LEXINGTON AVENUE
City,State,Zip:	WHITE PLAINS, NY 10606
PBS Number:	3-139637
Site Status:	Administratively Closed
GDS Number:	Not reported
Operator Name:	Resident Supt.
Owner Name:	Station Plaza Housing Co. Mgmt Corp.
Owner Street:	5 West Main Street
Owner Address2:	Not reported
Owner City/State/Zip:	Elmsford, NY 10523
Tank Number:	DF1
Status:	0. Administratively closed
Date Installation:	06/01/1998
Capacity:	330
Product Stored:	0008. Diesel
Product Stored Percent:	Not reported
Date Perm Closure:	01/01/1900
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Leak Detection:	6. Impervious Barrier/Concrete Pad (Aboveground Only)
Tank Secondary Containment:	10. Impervious Underlayment (AST Only)
Piping Location:	1. Aboveground
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	0. None
Piping Leak Detection:	Not reported
Piping Secondary Containment:	Not reported
Overfill Prevention:	2. High Level Alarm
Spill Prevention:	1. Catch Basin
Dispenser:	2. Suction
Tank Number:	DT2
Status:	1. In-Service
Date Installation:	06/01/1998
Capacity:	25
Product Stored:	0008. Diesel
Product Stored Percent:	Not reported
Date Perm Closure:	01/01/1900
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Leak Detection:	5. In-Tank System (auto tank gauge)
Tank Secondary Containment:	1. Diking (aboveground only)
Piping Location:	1. Aboveground
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Piping Leak Detection:	Not reported

APARTMENT (Continued) **S108129595**

Piping Secondary Containment: Not reported
Overfill Prevention: 2. High Level Alarm,3. Automatic Shut-off
Spill Prevention: Not reported
Dispenser: 2. Suction

SPILLS:
Name: APARTMENT
Address: 76 SOUTH LEXINGTON AVE
City,State,Zip: WHITE PLAINS, NY
Spill Number/Closed Date: 0605116 / 2006-08-03
Facility ID: 0605116
Facility Type: ER
DER Facility ID: 318165
Site ID: 368222
DEC Region: 3
Spill Cause: Equipment Failure
Spill Class: C3
SWIS: 6017
Spill Date: 2006-08-03
Investigator: JYMCCART
Referred To: Not reported
Reported to Dept: 2006-08-03
CID: 444
Water Affected: Not reported
Spill Source: Private Dwelling
Spill Notifier: Responsible Party
Cleanup Ceased: Not reported
Cleanup Meets Std: True
Last Inspection: Not reported
Recommended Penalty: False
UST Trust: False
Remediation Phase: 0
Date Entered In Computer: 2006-08-03
Spill Record Last Update: 2006-08-31
Spiller Name: ED ALLEN
Spiller Company: APRTNMENT
Spiller Address: 76 SOUTH LEXINGTON AVE
Spiller Company: 001
Contact Name: ED ALLEN
Latitude: 41.0294816
Longitude: -73.7725786
DEC Memo: 08/04/06: Spoke with Frank @ Robinson. They are completing clean up.
NFA
Remarks: THE FILL LINE PIECE WAS STRIPPED AND THE HOSE COULD NOT STAY ON AND SPRAYED , IN PROCESS OF CLEANING UP

All Materials:
Site ID: 368222
Operable Unit ID: 1126113
Operable Unit: 01
Material ID: 2115638
Material Code: 0001A
Material Name: #2 fuel oil
Case No.: Not reported
Material FA: Petroleum
Quantity: 2.00
Units: G

APARTMENT (Continued) **S108129595**

Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

L105 **CON EDISON VAULT: 6599** **RCRA NonGen / NLR** **1017773053**
SSW **76-78 S LEXINGTON AVE & FISCHER AVE** **NYP004508313**
< 1/8 **WHITE PLAINS, NY 10603**
0.098 mi.
519 ft. **Site 2 of 6 in cluster L**

Relative: **Higher**
Actual: **201 ft.**

RCRA Listings:

Date Form Received by Agency:	20140522
Handler Name:	Con Edison Vault: 6599
Handler Address:	S Lexington Ave & Fischer Ave
Handler City,State,Zip:	WHITE PLAINS, NY 10603
EPA ID:	NYP004508313
Contact Name:	THOMAS TEELING
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	212-460-3770
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	SENIOR SCIENTIST
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PL, 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline

CON EDISON VAULT: 6599 (Continued) **1017773053**

202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20150211
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20140422
Handler Name: CON EDISON	
Federal Waste Generator Description:	Large Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20140422
Handler Name: CON EDISON	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20140522
Handler Name: CON EDISON VAULT: 6599	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No

CON EDISON VAULT: 6599 (Continued) **1017773053**

Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

L106 **STATION PLAZA** **NY UST** **U004441804**
SSW **76 SOUTH LEXINGTON AVENUE** **N/A**
< 1/8 **WHITE PLAINS, NY 10606**
0.098 mi.
519 ft. **Site 3 of 6 in cluster L**

Relative: **Higher**
Actual: **201 ft.**

WESTCHESTER CO. UST:
Name: STATION PLAZA
Address: 76 SOUTH LEXINGTON AVENUE
City,State,Zip: WHITE PLAINS, NY 10606
Id/Status: 3-139637 / Administratively Closed
Operator Name: Resident Supt.
Owner Name: Station Plaza Housing Co. Mgmt Corp.
Owner Street: 5 West Main Street
Owner Address2: Not reported
Owner City: Elmsford
Owner State: NY
Owner Zipcode: 10523
GDS Number: Not reported

Tank Number: F01
Status: 4. Closed - in place
Capacity: 25000
Product Stored: 0001. #2 Fuel Oil
Product Stored Percent: Not reported
Tank Leak Detection: 0. None
Date Installation: 12/01/1976
Date Perm Closure: 05/08/2012
Tank Location: 5. Underground including vaulted with no access for inspection
Tank Type: 1. Steel/Carbon steel/Iron
Tank Internal Protection: 1. Epoxy liner
Tank External Protection: 1. Painted/Asphalt Coating
Tank Secondary Containment: 0. None
Piping Location: 2. Underground/on ground
Piping Type: 1. Steel/Carbon/ steel/iron
Piping External Protection: 0. None
Overfill Prevention: Not reported
Piping Secondary Containment: Not reported
Spill Prevention: 1. Catch Basin
Dispenser: 2. Suction

L107 **CON EDISON** **NY MANIFEST** **S117058697**
SSW **76-78 S LEXINGTON AVE & FISCHE** **N/A**
< 1/8 **WHITE PLAINS, NY 10603**
0.098 mi.
519 ft. **Site 4 of 6 in cluster L**

Relative:
Higher

Actual:
201 ft.

NY MANIFEST:

EPA ID:	NYP004508313
Country:	USA
Name:	Con Edison
Address:	76-78 S LEXINGTON AVE & FISCHE
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10603
Zip 4:	Not reported
Location Address 1:	F/O 76-78 S LEXINGTON AVE
Location Address 2:	VS6599
Location City,State,Zip:	WHITE PLAINS, NY 10801
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Edison
Mailing Contact:	Con Edison
Mailing Address 1:	4 IRVING PL
Mailing Address 2:	15TH ST
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	Not reported

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	04/22/2014
Trans1 Recv Date:	04/22/2014
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	04/23/2014
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004508313
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	012770975JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported

CON EDISON (Continued) **S117058697**

Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	150
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

F108 **WHITE PLAINS SUB-STATION** **NY Spills** **S105140759**
NW **2 NEW STREET** **N/A**
< 1/8 **WHITE PLAINS, NY**
0.100 mi.
526 ft. **Site 6 of 8 in cluster F**

Relative: **Higher**

Actual: **200 ft.**

SPILLS:

Name:	WHITE PLAINS SUB-STATION
Address:	2 NEW STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0104086 / 2001-07-17
Facility ID:	0104086
Facility Type:	ER
DER Facility ID:	180742
Site ID:	218482
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	C4
SWIS:	6017
Spill Date:	2001-07-17
Investigator:	mbmastro
Referred To:	Not reported
Reported to Dept:	2001-07-17
CID:	266
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Responsible Party
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2001-07-17
Spill Record Last Update:	2001-08-07
Spiller Name:	Not reported

WHITE PLAINS SUB-STATION (Continued) **S105140759**

Spiller Company:	CON EDISON
Spiller Address:	4 IRVING PLACE
Spiller Company:	001
Contact Name:	Not reported
Latitude:	41.0400799
Longitude:	-73.7983400
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was MASTRO
Remarks:	2 OUNCES OF CABLE OIL LEAKED FROM FEEDER END. ONTO CONCRETE BASEMENT FLOOR. TO BE CLEANED UP AND REPAIRED. CON EDISON REFERENCE NUMBER 138292.

All Materials:

Site ID:	218482
Operable Unit ID:	842602
Operable Unit:	01
Material ID:	532592
Material Code:	0020B
Material Name:	cable oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	1.00
Units:	G
Recovered:	1.00
Resource Affected:	Soil
Oxygenate:	Not reported

K109 **RESIDENCE** **NY LTANKS** **S102660217**
ENE **185- 187 MAIN ST** **N/A**
< 1/8 **WHITE PLAINS, NY**
0.100 mi.
528 ft. **Site 7 of 27 in cluster K**

Relative: **Higher**
Actual: **207 ft.**

LTANKS:

Name:	RESIDENCE
Address:	185- 187 MAIN ST
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9708138 / 1997-11-10
Facility ID:	9708138
Site ID:	81930
Spill Date:	1997-10-09
Spill Cause:	Tank Failure
Spill Source:	Private Dwelling
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1997-10-10
CID:	369
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0

RESIDENCE (Continued) **S102660217**

Date Entered In Computer:	1997-10-10
Spill Record Last Update:	1998-01-29
Spiller Name:	STANLEY DRUCKER
Spiller Company:	Not reported
Spiller Address:	185- 187 MAIN ST
Spiller County:	001
Spiller Contact:	STANLEY DRUCKER
Spiller Phone:	(914) 937-7307
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	75659
Latitude:	41.0323577
Longitude:	-73.7680894
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY 10/10/97 SOIL TO BE STOCKPILED & DISPOSED; 10/13/97 LUZON TANK REMOVAL IN DOWNTOWN WHITE PLAINS; TANK LOCATED IN BUCK U/G VAULTED, UNDER THE SIDEWALK; ALL CONTAMINATION MATERIAL REMOVED;
Remarks:	contaminated soil uncovered during tank removal. tanks in u/g vault filled with dirt-about 4 yards worth.

All Materials:

Site ID:	81930
Operable Unit ID:	1051362
Operable Unit:	01
Material ID:	330125
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

M110 **CON EDISON** **NJ MANIFEST** **S120674410**
West **15 BANK ST** **N/A**
< 1/8 **WHITE PLAINS, NY 10601**
0.102 mi.
539 ft. **Site 1 of 5 in cluster M**

Relative:
Higher

Actual:
200 ft.

NJ MANIFEST:

EPA ID:	NYP004812398
Name:	CON EDISON
Address:	15 BANK ST
City,State,Zip:	WHITE PLAINS, NY 10601
County:	Not reported
Mailing Address:	IRVING PL 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Telephone:	Not reported
Emergency Telephone:	Not reported
Contact:	THOMAS TEELING
Comments:	Not reported
SIC Code:	Not reported
County:	NY119
Municipal:	Not reported
Previous EPAID:	Not reported

CON EDISON (Continued) **S120674410**

Generator Flag:	Not reported
Transporter Flag:	Not reported
TSDF Flag:	Not reported
Name Change:	Not reported
Date Change:	Not reported

Manifest Data:

EPA ID:	NYP004812398
Manifest Number:	014472072JJK
Date Shipped:	7/24/2015
TSDF EPA ID:	NJD002200046
Transporter EPA ID:	NYD006982359
Transporter 2 EPA ID:	Not reported
Transporter 3 EPA ID:	Not reported
Transporter 4 EPA ID:	Not reported
Transporter 5 EPA ID:	Not reported
Transporter 6 EPA ID:	Not reported
Transporter 7 EPA ID:	Not reported
Transporter 8 EPA ID:	Not reported
Transporter 9 EPA ID:	Not reported
Transporter 10 EPA ID:	Not reported
Date Trans1 Transported Waste:	Not reported
Date Trans2 Transported Waste:	Not reported
Date Trans3 Transported Waste:	Not reported
Date Trans4 Transported Waste:	Not reported
Date Trans5 Transported Waste:	Not reported
Date Trans6 Transported Waste:	Not reported
Date Trans7 Transported Waste:	Not reported
Date Trans8 Transported Waste:	Not reported
Date Trans9 Transported Waste:	Not reported
Date Trans10 Transported Waste:	Not reported
Date TSDF Received Waste:	Not reported
TSDF EPA Facility Name:	Not reported
QTY Units:	Not reported
Transporter SEQ ID:	Not reported
Transporter-1 Date:	Not reported
Waste SEQ ID:	Not reported
Waste Type Code 2:	Not reported
Waste Type Code 3:	Not reported
Waste Type Code 4:	Not reported
Waste Type Code 5:	Not reported
Waste Type Code 6:	Not reported
Date Accepted:	Not reported
Manifest Discrepancy Type:	Not reported
Data Entry Number:	Not reported
Was Load Rejected:	Not reported
Reason Load Was Rejected:	Not reported

M111 **CON ED** **NY MANIFEST** **S118258236**
West **15 BANK ST** **N/A**
< 1/8 **WHITE PLAINS, NY 10601**
0.102 mi.
539 ft. **Site 2 of 5 in cluster M**

Relative:
Higher

Actual:
200 ft.

NY MANIFEST:

EPA ID:	NYP004812398
Country:	USA
Name:	Con Ed
Address:	15 BANK ST
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10601
Zip 4:	Not reported
Location Address 1:	15 BANK ST
Location Address 2:	V 56
Location City,State,Zip:	WHITE PLAINS, NY 10606
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Ed
Mailing Contact:	Tom Teeling
Mailing Address 1:	4 IRVING PLACE - 15TH FLOOR
Mailing Address 2:	Not reported
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	2124603770

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	07/24/2015
Trans1 Recv Date:	07/24/2015
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	07/28/2015
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004812398
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	014472072JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported

CON ED (Continued) **S118258236**

Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	100
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

M112 **CON EDISON** **RCRA NonGen / NLR** **1019905680**
West **15 BANK ST** **NYP004812398**
< 1/8 **WHITE PLAINS, NY 10601**
0.102 mi.
539 ft. **Site 3 of 5 in cluster M**

Relative: **Higher**

Actual: **200 ft.**

RCRA Listings:

Date Form Received by Agency:	20150724
Handler Name:	Con Edison
Handler Address:	Bank St
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYP004812398
Contact Name:	THOMAS TEELING
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	212-460-3770
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PL 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No

CON EDISON (Continued) **1019905680**

Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20160909
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20150724
Handler Name: CON EDISON	
Federal Waste Generator Description:	Large Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20150724
Handler Name: CON EDISON	
Federal Waste Generator Description:	Not a generator, verified

CON EDISON (Continued) **1019905680**

State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

F113 **CON EDISON MANHOLE 5562** **RCRA NonGen / NLR** **1010326336**
NW **LEXINGTON AVE & NEW ST** **NYP004140646**
< 1/8 **WHITE PLAINS, NY 10601**
0.102 mi.
540 ft. **Site 7 of 8 in cluster F**

Relative: **Higher**
Actual: **201 ft.**

RCRA Listings:
Date Form Received by Agency: 20060830
Handler Name: Con Edison Manhole 5562
Handler Address: Lexington Ave & New St
Handler City,State,Zip: WHITE PLAINS, NY 10601
EPA ID: NYP004140646
Contact Name: ARTHUR HUDMAN
Contact Address: 4 IRVING PL, RM 828
Contact City,State,Zip: NEW YORK, NY 10003
Contact Telephone: 212-580-8383
Contact Fax: Not reported
Contact Email: Not reported
Contact Title: Not reported
EPA Region: 02
Land Type: Not reported
Federal Waste Generator Description: Not a generator, verified
Non-Notifier: Not reported
Biennial Report Cycle: Not reported
Accessibility: Not reported
Active Site Indicator: Not reported
State District Owner: Ny
State District: NYSDEC R3
Mailing Address: 4 IRVING PL, RM 828
Mailing City,State,Zip: NEW YORK, NY 10003
Owner Name: Not reported
Owner Type: Not reported
Operator Name: Not reported
Operator Type: Not reported
Short-Term Generator Activity: No
Importer Activity: No

CON EDISON MANHOLE 5562 (Continued) **1010326336**

Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20150414
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20060828
Handler Name: CON EDISON	
Federal Waste Generator Description:	Not reported
State District Owner:	Not reported
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20060829
Handler Name: CON EDISON	
Federal Waste Generator Description:	Not a generator, verified

CON EDISON MANHOLE 5562 (Continued) **1010326336**

State District Owner: Not reported
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20060830
Handler Name: CON EDISON MANHOLE 5562
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

F114 **CONSOLIKDATED EDISON** **NY MANIFEST** **S108933464**
NW **NEW ST & LEXINGTON AVE** **N/A**
< 1/8 **WHITE PLAINS, NY 10602**
0.102 mi.
540 ft. **Site 8 of 8 in cluster F**

Relative:
Higher

Actual:
201 ft.

NY MANIFEST:
EPA ID: NYP004139705
Country: USA
Name: Consolikdated Edison
Address: NEW ST & LEXINGTON AVE
Address 2: Not reported
City,State,Zip: WHITE PLAINS, NY 10602
Zip 4: Not reported
Location Address 1: NEW ST & LEXINGTON AVE
Location Address 2: Not reported
Location City,State,Zip: WHITE PLAINS, NY 10602
Location Zip 4: Not reported
Facility Status: Not reported
Total Tanks: Not reported
Code: BP

Mailing:
Mailing Name: Consolikdated Edison

CONSOLIKDATED EDISON (Continued) **S108933464**

Mailing Contact: Franklin Murray
Mailing Address 1: 4 IRVING PLACE RM 828
Mailing Address 2: Not reported
Mailing City,State,Zip: NEW YORK, NY 10003
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: 2124602808

Manifest Data:
Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: NYD006982359
Year: 2018
Trans2 State ID: Not reported
Generator Ship Date: 01/30/2006
Trans1 Recv Date: 01/30/2006
Trans2 Recv Date: Not reported
TSD Site Recv Date: 01/31/2006
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYP004139705
Trans1 EPA ID: Not reported
Trans2 EPA ID: Not reported
TSDF ID 1: NYD077444263
TSDF ID 2: Not reported
Manifest Tracking Number: NYE1540467
Import Indicator: N
Export Indicator: N
Discr Quantity Indicator: N
Discr Type Indicator: N
Discr Residue Indicator: N
Discr Partial Reject Indicator: N
Discr Full Reject Indicator: N
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: Not reported
Waste Code a: B007
Waste Code b: Not reported
Waste Code c: Not reported
Waste Code e: Not reported
Waste Code f: Not reported
Waste Code g: Not reported
Waste Code 1: Not reported
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 50
Units: Kilograms
Number of Containers: 1
Container Type: Metal drums, barrels, kegs
Handling Method: Landfill
Specific Gravity: 1

Document ID: Not reported

CONSOLIKDATED EDISON (Continued) **S108933464**

Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	02/08/2006
Trans1 Recv Date:	02/08/2006
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	02/09/2006
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004139705
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NYD077444263
TSDF ID 2:	Not reported
Manifest Tracking Number:	NYE1606869
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code a:	B007
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	50
Units:	Kilograms
Number of Containers:	1
Container Type:	Metal drums, barrels, kegs
Handling Method:	Landfill
Specific Gravity:	1

N115 **WHITE PLAINS SUB STATION** **NY Spills** **S102402262**
NNW **NEW STREET** **N/A**
< 1/8 **WHITE PLAINS, NY**
0.106 mi.
558 ft. **Site 1 of 18 in cluster N**

Relative: SPILLS:
Higher

Name:	WHITE PLAINS SUBSTATION
Address:	NEW STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9700350 / 1997-04-07

Actual:
199 ft.

WHITE PLAINS SUB STATION (Continued) **S102402262**

Facility ID:	9700350
Facility Type:	ER
DER Facility ID:	301371
Site ID:	152482
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	C4
SWIS:	6017
Spill Date:	1997-04-07
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1997-04-07
CID:	211
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Responsible Party
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	1997-04-07
Spill Record Last Update:	1997-04-17
Spiller Name:	Not reported
Spiller Company:	CON ED
Spiller Address:	4 IRVING PLACE
Spiller Company:	001
Contact Name:	LISA PRIMEGGIA
Latitude:	41.0428099
Longitude:	-73.8092300
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY
Remarks:	FLANGE ON TRANSFORMER #5 LEAKED CAUSING 1 QT OF PRODUCT TO SPILL NO CLEAN UP
Name:	WHITE PLAINS SUB STATION
Address:	NEW STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0111787 / 2005-03-06
Facility ID:	0111787
Facility Type:	ER
DER Facility ID:	301371
Site ID:	152479
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	C4
SWIS:	6017
Spill Date:	2002-03-14
Investigator:	TDGHIOSA
Referred To:	Not reported
Reported to Dept:	2002-03-14
CID:	257
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Responsible Party
Cleanup Ceased:	Not reported

WHITE PLAINS SUB STATION (Continued) **S102402262**

Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2002-03-14
Spill Record Last Update:	2021-07-06
Spiller Name:	KEVIN MCARDLE
Spiller Company:	CON ED
Spiller Address:	4 IRVING PLACE
Spiller Company:	001
Contact Name:	CHARLIE MCCARTHY
Latitude:	41.0428099
Longitude:	-73.8092300
DEC Memo:	3/6/5 leak from bushing cleaned up--close jh
Remarks:	leak from bushing on transformer #6 - pads put done ref #141788

All Materials:

Site ID:	152479
Operable Unit ID:	848727
Operable Unit:	01
Material ID:	525806
Material Code:	0541A
Material Name:	dielectric fluid
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	2.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	MANHOLE 5618
Address:	NEW STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0403778 / 2004-07-09
Facility ID:	0403778
Facility Type:	ER
DER Facility ID:	301371
Site ID:	152480
DEC Region:	3
Spill Cause:	Unknown
Spill Class:	C4
SWIS:	6017
Spill Date:	2004-07-08
Investigator:	DVWEHRFR
Referred To:	Not reported
Reported to Dept:	2004-07-09
CID:	73
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Responsible Party
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False

WHITE PLAINS SUB STATION (Continued) **S102402262**

Remediation Phase: 0
Date Entered In Computer: 2004-07-09
Spill Record Last Update: 2004-07-13
Spiller Name: Not reported
Spiller Company: Not reported
Spiller Address: Not reported
Spiller Company: 001
Contact Name: ERT DESK
Latitude: 41.0428099
Longitude: -73.8092300
DEC Memo: Prior to Sept, 2004 data translation this spill Lead_DEC Field was WEHRFRITZ
Remarks: 1/2 GAL OF UNKNOWN OIL IN MANHOLE. NO TO ALL 5 QUESTIONS. CON ED REF #154256

All Materials:
Site ID: 152480
Operable Unit ID: 887032
Operable Unit: 01
Material ID: 491338
Material Code: 0066A
Material Name: unknown petroleum
Case No.: Not reported
Material FA: Petroleum
Quantity: .00
Units: G
Recovered: .00
Resource Affected: Sewer
Oxygenate: Not reported

Name: CON ED
Address: NEW STREET
City,State,Zip: WHITE PLAINS, NY
Spill Number/Closed Date: 9606340 / 1996-08-16
Facility ID: 9606340
Facility Type: ER
DER Facility ID: 301371
Site ID: 152481
DEC Region: 3
Spill Cause: Equipment Failure
Spill Class: C4
SWIS: 6017
Spill Date: 1996-08-16
Investigator: tdghiosa
Referred To: Not reported
Reported to Dept: 1996-08-16
CID: 257
Water Affected: Not reported
Spill Source: Commercial/Industrial
Spill Notifier: Responsible Party
Cleanup Ceased: Not reported
Cleanup Meets Std: True
Last Inspection: Not reported
Recommended Penalty: False
UST Trust: False
Remediation Phase: 0
Date Entered In Computer: 1996-08-16

WHITE PLAINS SUB STATION (Continued) **S102402262**

Spill Record Last Update:	1996-10-04
Spiller Name:	MR DELAHOZ
Spiller Company:	CON ED
Spiller Address:	NEW ST
Spiller Company:	001
Contact Name:	MR DELAHOZ
Latitude:	41.0428099
Longitude:	-73.8092300
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY
Remarks:	spilled onto blue stone celanup crew on the way

All Materials:

Site ID:	152481
Operable Unit ID:	1034134
Operable Unit:	01
Material ID:	345601
Material Code:	0020A
Material Name:	transformer oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	1.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

O116 **MICHAEL E LAND OFFICE BLD** **NY LTANKS** **S102151229**
ESE **148 MARTINE AVE** **NY AST** **N/A**
< 1/8 **WHITE PLAINS, NY** **NY Spills**
0.106 mi.
559 ft. **Site 1 of 26 in cluster O**

Relative:
Higher

Actual:
221 ft.

LTANKS:

Name:	WESTCHESTER CO DPW
Address:	148 MARTINE AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0109874 / 2002-01-14
Facility ID:	0109874
Site ID:	126439
Spill Date:	2002-01-11
Spill Cause:	Tank Test Failure
Spill Source:	Institutional, Educational, Gov., Other
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6018
Investigator:	jbodee
Referred To:	WCDOH
Reported to Dept:	2002-01-12
CID:	281
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	True
Remediation Phase:	0

MICHAEL E LAND OFFICE BLD (Continued) **S102151229**

Date Entered In Computer:	2002-01-12
Spill Record Last Update:	2024-10-30
Spiller Name:	SAME
Spiller Company:	WESTCHESTER CO DPW
Spiller Address:	SAME
Spiller County:	001
Spiller Contact:	MIKE CIRCOSTA
Spiller Phone:	(914) 995-3905
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	304255
Latitude:	41.0310551
Longitude:	-73.7675783
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was O'DEE
Remarks:	LINE TEST FAILURE AT ABOVE LOCATION. SOME MATERIAL DID LEAK AND WAS RECOVERED IN CONTAINMENT AREA. LINE TO BE REPLACED.

All TTF:

Facility ID:	0109874
Spill Number:	0109874
Spill Tank Test:	1526811
Site ID:	126439
Tank Number:	5
Tank Size:	3000
Material:	0009
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	01
Test Method 2:	Petro-Tite/Petro Comp
Leak Rate:	.10
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	126439
Operable Unit ID:	848218
Operable Unit:	01
Material ID:	552679
Material Code:	0009
Material Name:	gasoline
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	MICHAEL E LAND OFFICE BLD
Address:	148 MARTINE AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0503295 / 2005-09-26

MICHAEL E LAND OFFICE BLD (Continued) **S102151229**

Facility ID:	0503295
Site ID:	347878
Spill Date:	2005-06-17
Spill Cause:	Tank Test Failure
Spill Source:	Institutional, Educational, Gov., Other
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	JBODee
Referred To:	WCDOH
Reported to Dept:	2005-06-17
CID:	407
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2005-06-17
Spill Record Last Update:	2024-10-30
Spiller Name:	LOU MASTRO
Spiller Company:	MICHAEL E LAND OFFICE BLD
Spiller Address:	148 MARTINE AVE
Spiller County:	001
Spiller Contact:	LOU MASTRO
Spiller Phone:	(845) 565-9600
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	153551
Latitude:	41.0310510
Longitude:	-73.7675670
DEC Memo:	09/26/05: Letter to J. Varmon, County of Westchester DPW, from C. Lalak, WCDOH, dated 13Sep2005. Spill closure report, reporting requirement and as-built plans received. Department still needs a copy of the passing tightness test. Submit results asap. No further remdiation required regarding this spill number.
Remarks:	Located on the court st side of the building.

All TTF:

Facility ID:	0503295
Spill Number:	0503295
Spill Tank Test:	2516696
Site ID:	347878
Tank Number:	5OR6
Tank Size:	3000
Material:	0009
EPA UST:	True
UST:	True
Cause:	00
Source:	99
Test Method:	34
Test Method 2:	EZY 3 Locator Plus
Leak Rate:	Not reported
Gross Fail:	Not reported
Modified By:	JBODEE
Last Modified Date:	Not reported

MICHAEL E LAND OFFICE BLD (Continued) **S102151229**

All Materials:

Site ID:	347878
Operable Unit ID:	1105557
Operable Unit:	01
Material ID:	1521369
Material Code:	0009
Material Name:	gasoline
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	G
Recovered:	Not reported
Resource Affected:	Soil
Oxygenate:	Not reported

WESTCHESTER CO. AST:

Name:	WESTCHESTER COUNTY OFFICE BUILDING
Address:	148 MARTINE AVENUE
City,State,Zip:	WHITE PLAINS, NY 10601
PBS Number:	3-168777
Site Status:	Active
GDS Number:	3550000034
Operator Name:	Westchester County DPW Operations
Owner Name:	Westchester County DPW
Owner Street:	148 Martine Avenue
Owner Address2:	Not reported
Owner City/State/Zip:	White Plains, NY 10601
Tank Number:	001
Status:	1. In-Service
Date Installation:	01/01/1998
Capacity:	25
Product Stored:	0008. Diesel
Product Stored Percent:	Not reported
Date Perm Closure:	01/01/1900
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Leak Detection:	0. None
Tank Secondary Containment:	room acts as secondary containment
Piping Location:	1. Aboveground
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	1. Painted/Asphalt Coating
Piping Leak Detection:	0. None
Piping Secondary Containment:	0. None
Overfill Prevention:	2. High Level Alarm,3. Automatic Shut-off
Spill Prevention:	Not reported
Dispenser:	2. Suction
Tank Number:	010
Status:	1. In-Service
Date Installation:	03/01/2005
Capacity:	2000

MICHAEL E LAND OFFICE BLD (Continued) **S102151229**

Product Stored:	0008. Diesel
Product Stored Percent:	Not reported
Date Perm Closure:	01/01/1900
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Leak Detection:	0. None
Tank Secondary Containment:	1. Diking (aboveground only),10. Impervious Underlayment (AST Only)
Piping Location:	1. Aboveground
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	1. Painted/Asphalt Coating
Piping Leak Detection:	0. None
Piping Secondary Containment:	0. None
Overfill Prevention:	2. High Level Alarm,4. Product Level Gauge (Aboveground Only)
Spill Prevention:	1. Catch Basin
Dispenser:	2. Suction

Tank Number:	10
Status:	1. In-Service
Date Installation:	07/01/2001
Capacity:	300
Product Stored:	0008. Diesel
Product Stored Percent:	Not reported
Date Perm Closure:	01/01/1900
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Leak Detection:	0. None
Tank Secondary Containment:	9. Modified double-walled (aboveground only)
Piping Location:	1. Aboveground
Piping Type:	99. Other
Piping External Protection:	1. Painted/Asphalt Coating
Piping Leak Detection:	Not reported
Piping Secondary Containment:	Not reported
Overfill Prevention:	4. Product Level Gauge (Aboveground Only)
Spill Prevention:	1. Catch Basin
Dispenser:	2. Suction

Tank Number:	11
Status:	1. In-Service
Date Installation:	07/01/2008
Capacity:	336
Product Stored:	0008. Diesel
Product Stored Percent:	Not reported
Date Perm Closure:	01/01/1900
Tank Location:	2. Aboveground (contact w/ impervious barrier)
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating,LOCATION: 85 COURT ST
Tank Leak Detection:	6. Impervious Barrier/Concrete Pad (Aboveground Only)
Tank Secondary Containment:	GENERATOR BELLY TANK
Piping Location:	0. No Piping
Piping Type:	Not reported

MICHAEL E LAND OFFICE BLD (Continued) **S102151229**

Piping External Protection:	Not reported
Piping Leak Detection:	Not reported
Piping Secondary Containment:	Not reported
Overfill Prevention:	4. Product Level Gauge (Aboveground Only)
Spill Prevention:	0. None
Dispenser:	Not reported

SPILLS:

Name:	MICHILIN MOTOR POOL
Address:	148 MARTINE AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0301426 / 2003-05-08
Facility ID:	0301426
Facility Type:	ER
DER Facility ID:	153551
Site ID:	214706
DEC Region:	3
Spill Cause:	Human Error
Spill Class:	C4
SWIS:	6017
Spill Date:	2003-05-08
Investigator:	VPMCCABE
Referred To:	Not reported
Reported to Dept:	2003-05-08
CID:	270
Water Affected:	Not reported
Spill Source:	Non Major Facility > 1,100 gal
Spill Notifier:	Affected Persons
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2003-05-08
Spill Record Last Update:	2024-10-30
Spiller Name:	CALLER
Spiller Company:	KENN ORICCHIO
Spiller Address:	500 KINGSLAND
Spiller Company:	001
Contact Name:	Not reported
Latitude:	41.0310551
Longitude:	-73.7675783
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was MCCABE
Remarks:	DRIVER OVERFILLED TANK. ALL CLEANED UP

All Materials:

Site ID:	214706
Operable Unit ID:	867817
Operable Unit:	01
Material ID:	505918
Material Code:	0009
Material Name:	gasoline
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	5.00

MICHAEL E LAND OFFICE BLD (Continued) **S102151229**

Units:	G
Recovered:	5.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	COUNTY OF WESTCHESTER DGS
Address:	148 MARTINE AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0412020 / 2008-12-18
Facility ID:	0412020
Facility Type:	ER
DER Facility ID:	153551
Site ID:	337374
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	C3
SWIS:	6017
Spill Date:	2005-02-10
Investigator:	jbodee
Referred To:	Not reported
Reported to Dept:	2005-02-10
CID:	409
Water Affected:	Not reported
Spill Source:	Unknown
Spill Notifier:	Responsible Party
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2005-02-10
Spill Record Last Update:	2024-10-30
Spiller Name:	UNKNOWN
Spiller Company:	MODEL PERTROLEUM
Spiller Address:	UNKNOWN
Spiller Company:	001
Contact Name:	EDDIE
Latitude:	41.0310510
Longitude:	-73.7675670
DEC Memo:	2/17/05: Letter to John Varmon, Westchester DPW from Karen Magnuson, WCDOH dated 11Feb2005. Details work required. First report due 15Mar2005. 2/17/05: Letter to Al Cirino, Model Transportation, Inc from Karen Magnuson, WCDOH dated 11Feb2005. Tanks must be tightness tested by 18Feb2005. Details work required. First report due 15Mar2005.
Remarks:	CLEAN UP IS IN PROCESS AND MANAGEMENT ON THE WAY TO LOOK AT LOCATION. LOCATED IN A PAVED PARKING LOT.

All Materials:

Site ID:	337374
Operable Unit ID:	1099339
Operable Unit:	01
Material ID:	579677
Material Code:	0009
Material Name:	gasoline

MICHAEL E LAND OFFICE BLD (Continued) **S102151229**

Case No.:	Not reported
Material FA:	Petroleum
Quantity:	15.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	SPILL NUMBER 8900947
Address:	148 MARTINE AVENUE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8900947 / 1989-07-25
Facility ID:	8900947
Facility Type:	ER
DER Facility ID:	207447
Site ID:	253231
DEC Region:	3
Spill Cause:	Unknown
Spill Class:	C3
SWIS:	6017
Spill Date:	1989-05-01
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1989-05-01
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Unknown
Spill Notifier:	Responsible Party
Cleanup Ceased:	1989-07-25
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	1989-05-05
Spill Record Last Update:	2024-10-30
Spiller Name:	Not reported
Spiller Company:	RAD OIL COMPANY
Spiller Address:	Not reported
Spiller Company:	001
Contact Name:	Not reported
Latitude:	41.0310551
Longitude:	-73.7675783
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was TODD GHIOSAY / / : SPILL CLEANED UP BY SPILLER N.F.A. / / : SPILL CLEANED UP BY SPILLER N.F.A. 11/29/95: This is additional information about material spilled from the translation of the old spill file: NO LEAD.
Remarks:	DISCOVERED AFTER FUEL OIL DELIVERY. SOME ON CONCRETE AND SOME INTO CATCH BASIN. BOARD OF HEALTH ON SCENE. RAD OIL CONTRACTED WITH TYREE CO. CLEANUP TO BE DONE BY TYREE

All Materials:

Site ID:	253231
Operable Unit ID:	927505
Operable Unit:	01

MICHAEL E LAND OFFICE BLD (Continued) **S102151229**

Material ID:	452264
Material Code:	0009
Material Name:	gasoline
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	15.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	MICHAELIAN OFFICE BLDG
Address:	148 MARTINE AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9103040 / 1991-06-18
Facility ID:	9103040
Facility Type:	ER
DER Facility ID:	304255
Site ID:	126441
DEC Region:	3
Spill Cause:	Housekeeping
Spill Class:	C3
SWIS:	6018
Spill Date:	1991-06-12
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1991-06-12
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Institutional, Educational, Gov., Other
Spill Notifier:	Citizen
Cleanup Ceased:	1953-06-18
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	True
Remediation Phase:	0
Date Entered In Computer:	1991-06-18
Spill Record Last Update:	2024-10-30
Spiller Name:	Not reported
Spiller Company:	SAME
Spiller Address:	Not reported
Spiller Company:	001
Contact Name:	Not reported
Latitude:	41.0310551
Longitude:	-73.7675783
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY
Remarks:	FOUND CONTAMINATION WHILE REMOVING TANKS ARBEN CORP. IS PULLING THE TANKS STOCKPILE OF SOIL IS NOT TO DEC REQUIREMENTS LAURI TAYLOR INSTRUCTED THEM TO STOCKPILE ON PLASTIC SOIL STOCKPILE TO BE REMOVED

All TTF:

Facility ID:	9103040
Spill Number:	9103040
Spill Tank Test:	1538674
Site ID:	126441

MICHAEL E LAND OFFICE BLD (Continued) **S102151229**

Tank Number:	Not reported
Tank Size:	0
Material:	0009
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	126441
Operable Unit ID:	957062
Operable Unit:	01
Material ID:	425507
Material Code:	0009
Material Name:	gasoline
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	G
Recovered:	Not reported
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	CITY OF WHITE PLAINS
Address:	148 MARTINE AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9202919 / 1992-07-13
Facility ID:	9202919
Facility Type:	ER
DER Facility ID:	153551
Site ID:	183296
DEC Region:	3
Spill Cause:	Human Error
Spill Class:	B3
SWIS:	6017
Spill Date:	1992-06-10
Investigator:	TDGHIOSA
Referred To:	WESTCHESTER CNTY HEALTH D
Reported to Dept:	1992-06-10
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Tank Truck
Spill Notifier:	Responsible Party
Cleanup Ceased:	1992-07-13
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	1992-06-11

MICHAEL E LAND OFFICE BLD (Continued) **S102151229**

Spill Record Last Update:	2024-10-30
Spiller Name:	Not reported
Spiller Company:	IS. TRANSPORTATION
Spiller Address:	Not reported
Spiller Company:	001
Contact Name:	Not reported
Latitude:	41.0310551
Longitude:	-73.7675783
DEC Memo:	Not reported
Remarks:	SPILL CONTAINED ON PAVEMENT MOST EVAPORATED SPEEDI-DRI WAS APPLIED AND F.D. WASHED AREA MARINE POLLUTION CONTROL ON WAY TO VAC OUT STORM DRAIN VICKI WCHD ON SCENE

All Materials:

Site ID:	183296
Operable Unit ID:	970249
Operable Unit:	01
Material ID:	554262
Material Code:	0009
Material Name:	gasoline
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	23.00
Units:	G
Recovered:	Not reported
Resource Affected:	Surface Water, Sewer
Oxygenate:	Not reported

O117 **CON EDISON** **NJ MANIFEST** **S120672054**
ESE **148 MARTINE AVE** **N/A**
< 1/8 **WHITE PLAINS, NY 10601**
0.106 mi.
559 ft. **Site 2 of 26 in cluster O**

Relative:
Higher

Actual:
221 ft.

NJ MANIFEST:

EPA ID:	NYP004785739
Name:	CON EDISON
Address:	148 MARTINE AVE
City,State,Zip:	WHITE PLAINS, NY 10601
County:	Not reported
Mailing Address:	IRVING PL 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Telephone:	Not reported
Emergency Telephone:	Not reported
Contact:	THOMAS TEELING
Comments:	Not reported
SIC Code:	Not reported
County:	NY119
Municipal:	Not reported
Previous EPAID:	Not reported
Generator Flag:	Not reported
Transporter Flag:	Not reported
TSDF Flag:	Not reported
Name Change:	Not reported
Date Change:	Not reported

Manifest Data:

EPA ID:	NYP004785739

CON EDISON (Continued) **S120672054**

Manifest Number:	014454293JJK
Date Shipped:	5/22/2015
TSDF EPA ID:	NJD002200046
Transporter EPA ID:	NYD006982359
Transporter 2 EPA ID:	Not reported
Transporter 3 EPA ID:	Not reported
Transporter 4 EPA ID:	Not reported
Transporter 5 EPA ID:	Not reported
Transporter 6 EPA ID:	Not reported
Transporter 7 EPA ID:	Not reported
Transporter 8 EPA ID:	Not reported
Transporter 9 EPA ID:	Not reported
Transporter 10 EPA ID:	Not reported
Date Trans1 Transported Waste:	Not reported
Date Trans2 Transported Waste:	Not reported
Date Trans3 Transported Waste:	Not reported
Date Trans4 Transported Waste:	Not reported
Date Trans5 Transported Waste:	Not reported
Date Trans6 Transported Waste:	Not reported
Date Trans7 Transported Waste:	Not reported
Date Trans8 Transported Waste:	Not reported
Date Trans9 Transported Waste:	Not reported
Date Trans10 Transported Waste:	Not reported
Date TSDF Received Waste:	Not reported
TSDF EPA Facility Name:	Not reported
QTY Units:	Not reported
Transporter SEQ ID:	Not reported
Transporter-1 Date:	Not reported
Waste SEQ ID:	Not reported
Waste Type Code 2:	Not reported
Waste Type Code 3:	Not reported
Waste Type Code 4:	Not reported
Waste Type Code 5:	Not reported
Waste Type Code 6:	Not reported
Date Accepted:	Not reported
Manifest Discrepancy Type:	Not reported
Data Entry Number:	Not reported
Was Load Rejected:	Not reported
Reason Load Was Rejected:	Not reported

O118 **WESTCHESTER CO DPW** **UST FINDER RELEASE** **1029072846**
ESE **148 MARTINE AVE** **N/A**
< 1/8 **WHITE PLAINS, NY 0**
0.106 mi.
559 ft. **Site 3 of 26 in cluster O**

Relative: **Higher**
Actual: **221 ft.**

UST FINDER RELEASE:

Object ID:	262467
Facility ID:	NY304255
Lust ID:	NY109874
Name:	WESTCHESTER CO DPW
Address:	148 MARTINE AVE
City,State,Zip:	WHITE PLAINS, NY 0
Address Match Type:	Not reported
Reported Date:	2002/01/11 15:59:59+00
Status:	No Further Action
Substance:	Not reported

WESTCHESTER CO DPW (Continued) **1029072846**

Population within 1500ft:	4081
Domestic Wells within 1500ft:	0
Land Use:	Developed, High Intensity
Within SPA:	Yes
SPA PWS Facility ID:	NY7003493_76968
SPA Water Type:	SW - SurRELEASEe Water
SPA Facility Type:	RS - Reservoir
SPA HUC12:	20301020103
Within WHPA:	No
WHPA PWS Facility ID:	Not reported
WHPA Water Type:	Not reported
WHPA Facility Type:	Not reported
WHPA HUC12:	Not reported
Within 100yr Floodplain:	No
Tribe:	Not reported
EPA Region:	2
NFA Letter 1:	Not reported
NFA Letter 2:	Not reported
NFA Letter 3:	Not reported
NFA Letter 4:	Not reported
Closed With Residual Contaminate:	Not reported
Coordinate Source:	State
X Coord:	-73.76758
Y Coord:	41.03106
Latitude:	41.0310599999999
Longitude:	-73.7675799999999

O119 **CON EDISON** **RCRA NonGen / NLR** **1019903452**
ESE **148 MARTINE AVE** **FINDS** **NYP004785739**
< 1/8 **WHITE PLAINS, NY 10601** **ECHO**
0.106 mi.
559 ft. **Site 4 of 26 in cluster O**

Relative: **Higher**

Actual: **221 ft.**

RCRA Listings:

Date Form Received by Agency:	20150522
Handler Name:	Con Edison
Handler Address:	Martine Ave
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYP004785739
Contact Name:	THOMAS TEELING
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	212-460-3770
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PL 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported

CON EDISON (Continued) **1019903452**

Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20160909
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20150522
Handler Name: CON EDISON	
Federal Waste Generator Description:	Large Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported

CON EDISON (Continued) **1019903452**

Electronic Manifest Broker: Not reported

Receive Date: 20150522
Handler Name: CON EDISON
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

FINDS:
Registry ID: 110069663126

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:
The Resource Conservation and Recovery Act Information System (RCRAInfo) is EPA's comprehensive information system in support of the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. It tracks many types of information about generators, transporters, treaters, storers, and disposers of hazardous waste.

Click this hyperlink while viewing on your computer to access additional FINDS: detail in the EDR Site Report.

ECHO:
Envid: 1019903452
Registry ID: 110069663126

DFR URL:
Name: CON EDISON
Address: 148 MARTINE AVE
City,State,Zip: WHITE PLAINS, NY 10601

O120 **MICHAELIAN OFFICE BUILDING PARKING GARAGE** **RCRA-SQG** **1000396564**
ESE **148 MARTINE AVE** **NY MANIFEST** **NYD072705213**
< 1/8 **WHITE PLAINS, NY 10601**
0.106 mi.
559 ft. **Site 5 of 26 in cluster O**

Relative:
Higher

Actual:
221 ft.

RCRA Listings:

Date Form Received by Agency:	20191206
Handler Name:	Michaelian Office Building Parking Garage
Handler Address:	Martine Ave
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYD072705213
Contact Name:	JEFFREY A DEAN
Contact Address:	MARTINE AVE
Contact City,State,Zip:	WHITE PLAINS, NY 10601
Contact Telephone:	914-995-3361
Contact Fax:	Not reported
Contact Email:	JADC@WESTCHESTERGOV.COM
Contact Title:	SENIOR ENGINEER (CIVIL)
EPA Region:	02
Land Type:	County
Federal Waste Generator Description:	Small Quantity Generator
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Handler Activities
State District Owner:	Ny
State District:	NYSDEC R3
Mailing Address:	MARTINE AVE
Mailing City,State,Zip:	WHITE PLAINS, NY 10601
Owner Name:	Westchester County
Owner Type:	Private
Operator Name:	Westchester County
Operator Type:	Private
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No

MICHAELIAN OFFICE BUILDING PARKING GARAGE (Continued) **1000396564**

Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20200122
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Hazardous Waste Summary:

Waste Code:	D001
Waste Description:	Ignitable Waste
Waste Code:	D008
Waste Description:	Lead

Handler - Owner Operator:

Owner/Operator Indicator:	Operator
Owner/Operator Name: WESTCHESTER COUNTY	
Legal Status:	Private
Date Became Current:	Not reported
Date Ended Current:	Not reported
Owner/Operator Address:	NOT REQUIRED
Owner/Operator City,State,Zip:	NOT REQUIRED, WY 99999
Owner/Operator Telephone:	212-555-1212
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported
Owner/Operator Email:	Not reported
Owner/Operator Indicator:	Owner
Owner/Operator Name: WESTCHESTER COUNTY	
Legal Status:	Private
Date Became Current:	Not reported
Date Ended Current:	Not reported
Owner/Operator Address:	NOT REQUIRED
Owner/Operator City,State,Zip:	NOT REQUIRED, WY 99999
Owner/Operator Telephone:	212-555-1212
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported
Owner/Operator Email:	Not reported
Owner/Operator Indicator:	Operator
Owner/Operator Name: WESTCHESTER COUNTY	
Legal Status:	Private
Date Became Current:	19720426
Date Ended Current:	Not reported
Owner/Operator Address:	148 MARTINE AVE
Owner/Operator City,State,Zip:	WHITE PLAINS, NY 10601

MICHAELIAN OFFICE BUILDING PARKING GARAGE (Continued) **1000396564**

Owner/Operator Telephone: Not reported
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Owner
Owner/Operator Name: WESTCHESTER COUNTY
Legal Status: Private
Date Became Current: Not reported
Date Ended Current: Not reported
Owner/Operator Address: NOT REQUIRED
Owner/Operator City,State,Zip: NOT REQUIRED, WY 99999
Owner/Operator Telephone: 212-555-1212
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Owner
Owner/Operator Name: WESTCHESTER COUNTY
Legal Status: Private
Date Became Current: 19720426
Date Ended Current: Not reported
Owner/Operator Address: 148 MARTINE AVE
Owner/Operator City,State,Zip: WHITE PLAINS, NY 10601
Owner/Operator Telephone: Not reported
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Historic Generators:
Receive Date: 19990708
Handler Name: WESTCHESTER COUNTY OFFICE BLDG
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20060101
Handler Name: WESTCHESTER COUNTY OFFICE BLDG
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20070101

MICHAELIAN OFFICE BUILDING PARKING GARAGE (Continued) **1000396564**

Handler Name: WESTCHESTER COUNTY OFFICE BLDG
Federal Waste Generator Description: Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 19890314
Handler Name: WESTCHESTER COUNTY OFFICE BLDG
Federal Waste Generator Description: Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20191206
Handler Name: MICHAELIAN OFFICE BUILDING PARKING GARAGE
Federal Waste Generator Description: Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: No
Electronic Manifest Broker: No

List of NAICS Codes and Descriptions:
NAICS Code: 236220
NAICS Description: Commercial And Institutional Building Construction

Has the Facility Received Notices of Violations:
Found Violation: No
Agency Which Determined Violation: Not reported
Violation Short Description: Not reported
Date Violation was Determined: Not reported
Actual Return to Compliance Date: Not reported
Return to Compliance Qualifier: Not reported
Violation Responsible Agency: Not reported
Scheduled Compliance Date: Not reported
Enforcement Identifier: Not reported
Date of Enforcement Action: Not reported
Enforcement Responsible Agency: Not reported
Enforcement Docket Number: Not reported

MICHAELIAN OFFICE BUILDING PARKING GARAGE (Continued) **1000396564**

Enforcement Attorney: Not reported
Corrective Action Component: Not reported
Appeal Initiated Date: Not reported
Appeal Resolution Date: Not reported
Disposition Status Date: Not reported
Disposition Status: Not reported
Disposition Status Description: Not reported
Consent/Final Order Sequence Number: Not reported
Consent/Final Order Respondent Name: Not reported
Consent/Final Order Lead Agency: Not reported
Enforcement Type: Not reported
Enforcement Responsible Person: Not reported
Enforcement Responsible Sub-Organization: Not reported
SEP Sequence Number: Not reported
SEP Expenditure Amount: Not reported
SEP Scheduled Completion Date: Not reported
SEP Actual Date: Not reported
SEP Defaulted Date: Not reported
SEP Type: Not reported
SEP Type Description: Not reported
Proposed Amount: Not reported
Final Monetary Amount: Not reported
Paid Amount: Not reported
Final Count: Not reported
Final Amount: Not reported

Found Violation: No
Agency Which Determined Violation: Not reported
Violation Short Description: Not reported
Date Violation was Determined: Not reported
Actual Return to Compliance Date: Not reported
Return to Compliance Qualifier: Not reported
Violation Responsible Agency: Not reported
Scheduled Compliance Date: Not reported
Enforcement Identifier: Not reported
Date of Enforcement Action: Not reported
Enforcement Responsible Agency: Not reported
Enforcement Docket Number: Not reported
Enforcement Attorney: Not reported
Corrective Action Component: Not reported
Appeal Initiated Date: Not reported
Appeal Resolution Date: Not reported
Disposition Status Date: Not reported
Disposition Status: Not reported
Disposition Status Description: Not reported
Consent/Final Order Sequence Number: Not reported
Consent/Final Order Respondent Name: Not reported
Consent/Final Order Lead Agency: Not reported
Enforcement Type: Not reported
Enforcement Responsible Person: Not reported
Enforcement Responsible Sub-Organization: Not reported
SEP Sequence Number: Not reported
SEP Expenditure Amount: Not reported
SEP Scheduled Completion Date: Not reported
SEP Actual Date: Not reported
SEP Defaulted Date: Not reported
SEP Type: Not reported

MICHAELIAN OFFICE BUILDING PARKING GARAGE (Continued) **1000396564**

SEP Type Description: Not reported
Proposed Amount: Not reported
Final Monetary Amount: Not reported
Paid Amount: Not reported
Final Count: Not reported
Final Amount: Not reported

Found Violation: Yes
Agency Which Determined Violation: State
Violation Short Description: Generators - General
Date Violation was Determined: 19890331
Actual Return to Compliance Date: 19901018
Return to Compliance Qualifier: Observed
Violation Responsible Agency: State
Scheduled Compliance Date: Not reported
Enforcement Identifier: 001
Date of Enforcement Action: 19901018
Enforcement Responsible Agency: State
Enforcement Docket Number: Not reported
Enforcement Attorney: Not reported
Corrective Action Component: No
Appeal Initiated Date: Not reported
Appeal Resolution Date: Not reported
Disposition Status Date: Not reported
Disposition Status: Not reported
Disposition Status Description: Not reported
Consent/Final Order Sequence Number: Not reported
Consent/Final Order Respondent Name: Not reported
Consent/Final Order Lead Agency: Not reported
Enforcement Type: FINAL 3008(A) COMPLIANCE ORDER
Enforcement Responsible Person: NYDEC
Enforcement Responsible Sub-Organization: Not reported
SEP Sequence Number: Not reported
SEP Expenditure Amount: Not reported
SEP Scheduled Completion Date: Not reported
SEP Actual Date: Not reported
SEP Defaulted Date: Not reported
SEP Type: Not reported
SEP Type Description: Not reported
Proposed Amount: Not reported
Final Monetary Amount: 25000
Paid Amount: 25000
Final Count: 1
Final Amount: 25000

Evaluation Action Summary:
Evaluation Date: 19990809
Evaluation Responsible Agency: EPA
Found Violation: No
Evaluation Type Description: NON-FINANCIAL RECORD REVIEW
Evaluation Responsible Person Identifier: R2BG
Evaluation Responsible Sub-Organization: RCB
Actual Return to Compliance Date: Not reported
Scheduled Compliance Date: Not reported
Date of Request: Not reported
Date Response Received: Not reported
Request Agency: Not reported

MICHAELIAN OFFICE BUILDING PARKING GARAGE (Continued) **1000396564**

Former Citation:	Not reported
Evaluation Date:	19990805
Evaluation Responsible Agency:	EPA
Found Violation:	No
Evaluation Type Description:	COMPLIANCE EVALUATION INSPECTION
Evaluation Responsible Person Identifier:	R2BG
Evaluation Responsible Sub-Organization:	RCB
Actual Return to Compliance Date:	Not reported
Scheduled Compliance Date:	Not reported
Date of Request:	Not reported
Date Response Received:	Not reported
Request Agency:	Not reported
Former Citation:	Not reported
Evaluation Date:	19890331
Evaluation Responsible Agency:	State
Found Violation:	Yes
Evaluation Type Description:	FOCUSED COMPLIANCE INSPECTION
Evaluation Responsible Person Identifier:	NYDEC
Evaluation Responsible Sub-Organization:	Not reported
Actual Return to Compliance Date:	19901018
Scheduled Compliance Date:	Not reported
Date of Request:	Not reported
Date Response Received:	Not reported
Request Agency:	Not reported
Former Citation:	Not reported

NY MANIFEST:

EPA ID:	NYD072705213
Country:	USA
Name:	Westchester City Office Bldg
Address:	148 MARTINE AVE
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10601
Zip 4:	Not reported
Location Address 1:	148 MARTINE AVE
Location Address 2:	Not reported
Location City,State,Zip:	WHITE PLAINS, NY 10601
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Westchester City Office Bldg
Mailing Contact:	Westchester City Office Bldg
Mailing Address 1:	19 BRODHURST AVE
Mailing Address 2:	Not reported
Mailing City,State,Zip:	HAWTHORNE, NY 10532
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	9145932305

Manifest Data:

Document ID:	NJA1218523

MICHAELIAN OFFICE BUILDING PARKING GARAGE (Continued) **1000396564**

Manifest Status:	Not reported
Trans1 State ID:	NJDEPS869
Year:	1991
Trans2 State ID:	Not reported
Generator Ship Date:	06/05/1991
Trans1 Recv Date:	06/05/1991
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	06/06/1991
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD072705213
Trans1 EPA ID:	ILD051060408
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002182897
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Ignitable Waste
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00500
Units:	Pounds
Number of Containers:	003
Container Type:	Metal drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD049178296
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	04/02/2009
Trans1 Recv Date:	04/02/2009
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	04/06/2009
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD072705213
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	OHD083377010
TSDF ID 2:	Not reported
Manifest Tracking Number:	004853999JJK

MICHAELIAN OFFICE BUILDING PARKING GARAGE (Continued) **1000396564**

Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H141
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	150
Units:	Pounds
Number of Containers:	1
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Landfill
Specific Gravity:	1

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NJR000003749
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	03/08/2010
Trans1 Recv Date:	03/08/2010
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	03/08/2010
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD072705213
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD991291105
TSDF ID 2:	Not reported
Manifest Tracking Number:	005972801JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported

MICHAELIAN OFFICE BUILDING PARKING GARAGE (Continued) **1000396564**

MGMT Method Type Code:	H111
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	150
Units:	Pounds
Number of Containers:	2
Container Type:	Metal drums, barrels, kegs
Handling Method:	Treat
Specific Gravity:	1

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	PAR000501577
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	06/16/2006
Trans1 Recv Date:	06/16/2006
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	06/19/2006
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD072705213
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	PAD067098822
TSDF ID 2:	Not reported
Manifest Tracking Number:	PAH0192647
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code a:	Chromium
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported

MICHAELIAN OFFICE BUILDING PARKING GARAGE (Continued) **1000396564**

Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	85
Units:	Pounds
Number of Containers:	1
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Landfill
Specific Gravity:	1

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	PAR000501577
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	06/16/2006
Trans1 Recv Date:	06/16/2006
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	06/19/2006
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD072705213
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	PAD067098822
TSDF ID 2:	Not reported
Manifest Tracking Number:	PAH0192647
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code a:	Cyclohexanone (I)
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	10
Units:	Pounds
Number of Containers:	1
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Landfill
Specific Gravity:	1

MICHAELIAN OFFICE BUILDING PARKING GARAGE (Continued) **1000396564**

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	PAR000501577
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	06/16/2006
Trans1 Recv Date:	06/16/2006
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	06/19/2006
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD072705213
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	PAD067098822
TSDF ID 2:	Not reported
Manifest Tracking Number:	PAH0192647
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code a:	Corrosive Waste
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	30
Units:	Pounds
Number of Containers:	1
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Landfill
Specific Gravity:	1

Document ID:	NJA1046861
Manifest Status:	Not reported
Trans1 State ID:	NJDEPS869
Year:	1991
Trans2 State ID:	Not reported
Generator Ship Date:	03/27/1991
Trans1 Recv Date:	03/27/1991
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	03/28/1991
Part A Recv Date:	Not reported

MICHAELIAN OFFICE BUILDING PARKING GARAGE (Continued) **1000396564**

Part B Recv Date:	Not reported
Generator EPA ID:	NYD072705213
Trans1 EPA ID:	ILD051060408
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002182897
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Ignitable Waste
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	05039
Units:	Pounds
Number of Containers:	011
Container Type:	Metal drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00

Document ID:	NJA1046867
Manifest Status:	Not reported
Trans1 State ID:	NJDEPS869
Year:	1991
Trans2 State ID:	Not reported
Generator Ship Date:	03/28/1991
Trans1 Recv Date:	03/28/1991
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	04/02/1991
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD072705213
Trans1 EPA ID:	ILD051060408
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002182897
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported

MICHAELIAN OFFICE BUILDING PARKING GARAGE (Continued) **1000396564**

Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Ignitable Waste
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	02290
Units:	Pounds
Number of Containers:	005
Container Type:	Metal drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00

Document ID:	NJA3239540
Manifest Status:	Not reported
Trans1 State ID:	S5811
Year:	2001
Trans2 State ID:	Not reported
Generator Ship Date:	11/20/2001
Trans1 Recv Date:	11/20/2001
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	11/20/2001
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD072705213
Trans1 EPA ID:	NJ0000027193
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Corrosive Waste
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00001
Units:	Cubic Yards
Number of Containers:	001
Container Type:	Fiber or plastic boxes, cartons, cases
Handling Method:	Treat
Specific Gravity:	01.00
Waste Code 7:	Corrosive Waste
Waste Code 8:	Not reported

MICHAELIAN OFFICE BUILDING PARKING GARAGE (Continued) **1000396564**

Waste Code:	Not reported
Waste Code 10:	Not reported
Waste Code 11:	Not reported
Quantity:	00004
Units:	Cubic Yards
Number of Containers:	001
Container Type:	Fiber or plastic boxes, cartons, cases
Handling Method:	Treat
Specific Gravity:	01.00
Waste Code 12:	Ignitable Waste
Waste Code 13:	Not reported
Waste Code 14:	Not reported
Waste Code 15:	Not reported
Waste Code 16:	Not reported
Quantity:	00055
Units:	Gallons (liquids only)
Number of Containers:	001
Container Type:	Metal drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00

Document ID:	NYB2641158
Manifest Status:	Not reported
Trans1 State ID:	HL4120
Year:	1991
Trans2 State ID:	Not reported
Generator Ship Date:	09/26/1991
Trans1 Recv Date:	09/26/1991
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	09/26/1991
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD072705213
Trans1 EPA ID:	NYD082785429
Trans2 EPA ID:	Not reported
TSDF ID 1:	NYD082785429
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Ignitable Waste
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00040
Units:	Gallons (liquids only)

MICHAELIAN OFFICE BUILDING PARKING GARAGE (Continued) **1000396564**

Number of Containers: 001
Container Type: Metal drums, barrels, kegs
Handling Method: Treat
Specific Gravity: 01.00

Document ID: NYG2329092
Manifest Status: Not reported
Trans1 State ID: 0440408ME
Year: 1999
Trans2 State ID: 0440486ME
Generator Ship Date: 11/23/1999
Trans1 Recv Date: 11/23/1999
Trans2 Recv Date: 11/29/1999
TSD Site Recv Date: 11/29/1999
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYD072705213
Trans1 EPA ID: NJD054126164
Trans2 EPA ID: NJD054126164
TSDF ID 1: NYD049836679
TSDF ID 2: Not reported
Manifest Tracking Number: Not reported
Import Indicator: Not reported
Export Indicator: Not reported
Discr Quantity Indicator: Not reported
Discr Type Indicator: Not reported
Discr Residue Indicator: Not reported
Discr Partial Reject Indicator: Not reported
Discr Full Reject Indicator: Not reported
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: Not reported
Waste Code 1: Lead
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 02620
Units: Pounds
Number of Containers: 001
Container Type: Metal boxes, cartons, cases (including roll-offs)
Handling Method: Landfill
Specific Gravity: 01.00

Click this hyperlink while viewing on your computer to access
6 additional NY MANIFEST: record(s) in the EDR Site Report.

O121 **WESTCHESTER COUNTY OFFICE BUILDING** **NY UST** **U004442265**
ESE **148 MARTINE AVENUE** **N/A**
< 1/8 **WHITE PLAINS, NY 10601**
0.106 mi.
559 ft. **Site 6 of 26 in cluster O**

Relative:
Higher

Actual:
221 ft.

WESTCHESTER CO. UST:

Name:	WESTCHESTER COUNTY OFFICE BUILDING
Address:	148 MARTINE AVENUE
City,State,Zip:	WHITE PLAINS, NY 10601
Id/Status:	3-168777 / Active
Operator Name:	Westchester County DPW Operations
Owner Name:	Westchester County DPW
Owner Street:	148 Martine Avenue
Owner Address2:	Not reported
Owner City:	White Plains
Owner State:	NY
Owner Zipcode:	10601
GDS Number:	3550000034
Tank Number:	008
Status:	4. Closed - in place
Capacity:	1500
Product Stored:	9999. Other
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	01/01/1972
Date Perm Closure:	12/10/2002
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	Not reported
Tank Internal Protection:	1. Epoxy liner
Tank External Protection:	1. Painted/Asphalt Coating
Tank Secondary Containment:	0. None
Piping Location:	0. No Pipiing
Piping Type:	0. No Pippping
Piping External Protection:	0. None
Overfill Prevention:	0. None
Piping Secondary Containment:	Not reported
Spill Prevention:	0. None
Dispenser:	0. None
Tank Number:	009
Status:	0. Administratively closed
Capacity:	30000
Product Stored:	Not reported
Product Stored Percent:	Not reported
Tank Leak Detection:	Not reported
Date Installation:	10/01/2003
Date Perm Closure:	11/01/2004
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	6. Fiberglass reinforced plastic (FRP)
Tank Internal Protection:	3. Fiberglass liner (FRP)
Tank External Protection:	Not reported
Tank Secondary Containment:	4. Double-Walled (underground only)
Piping Location:	3. Aboveground/underground combination
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	1. Painted/Asphalt Coating
Overfill Prevention:	2. High Level Alarm

WESTCHESTER COUNTY OFFICE BUILDING (Continued) **U004442265**

Piping Secondary Containment: Not reported
Spill Prevention: Not reported
Dispenser: 3. Gravity

Tank Number: 1
Status: 1. In-Service
Capacity: 3000
Product Stored: 0008. Diesel
Product Stored Percent: Not reported
Tank Leak Detection: 1. Electronic Interstitial Monitoring
Date Installation: 01/01/1998
Date Perm Closure: 01/01/1900
Tank Location: 5. Underground including vaulted with no access for inspection
Tank Type: 4. Fiberglass coated steel
Tank Internal Protection: 0. None
Tank External Protection: 4. Fiberglass
Tank Secondary Containment: 4. Double-Walled (underground only)
Piping Location: 2. Underground/on Ground
Piping Type: 8. Equivalent Technology
Piping External Protection: 99. Other
Overfill Prevention: 2. High Level Alarm,3. Automatic Shut-off
Piping Secondary Containment: 4. Double-Walled (underground only)
Spill Prevention: 1. Catch Basin
Dispenser: 2. Suction

Tank Number: 2
Status: 3. Closed - Removed
Capacity: 25000
Product Stored: Not reported
Product Stored Percent: Not reported
Tank Leak Detection: 0. None
Date Installation: 01/01/1998
Date Perm Closure: 06/04/2004
Tank Location: 5. Underground including vaulted with no access for inspection
Tank Type: 1. Steel/Carbon steel/Iron
Tank Internal Protection: 0. None
Tank External Protection: 1. Painted/Asphalt Coating
Tank Secondary Containment: 0. None
Piping Location: 2. Underground/on ground
Piping Type: 1. Steel/Carbon/ steel/iron
Piping External Protection: 1. Painted/Asphalt Coating
Overfill Prevention: Not reported
Piping Secondary Containment: Not reported
Spill Prevention: Not reported
Dispenser: 2. Suction

Tank Number: 3
Status: 0. Administratively closed
Capacity: 5000
Product Stored: 0008. Diesel
Product Stored Percent: Not reported
Tank Leak Detection: 0. None
Date Installation: 01/01/1998
Date Perm Closure: 11/01/2004

WESTCHESTER COUNTY OFFICE BUILDING (Continued) **U004442265**

Tank Location:	Not reported
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Secondary Containment:	Not reported
Piping Location:	2. Underground/on ground
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	1. Painted/Asphalt Coating
Overfill Prevention:	Not reported
Piping Secondary Containment:	Not reported
Spill Prevention:	Not reported
Dispenser:	2. Suction

Tank Number:	4
Status:	0. Administratively closed
Capacity:	10000
Product Stored:	Not reported
Product Stored Percent:	Not reported
Tank Leak Detection:	Not reported
Date Installation:	01/01/1998
Date Perm Closure:	11/01/2004
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	4. Fiberglass coated steel
Tank Internal Protection:	0. None
Tank External Protection:	4. Fiberglass
Tank Secondary Containment:	4. Double-Walled (underground only)
Piping Location:	2. Underground/on ground
Piping Type:	99. Other
Piping External Protection:	99. Other
Overfill Prevention:	2. High Level Alarm,3. Automatic Shut-off
Piping Secondary Containment:	Not reported
Spill Prevention:	Not reported
Dispenser:	2. Suction

Tank Number:	5
Status:	1. In-Service
Capacity:	3000
Product Stored:	2712. Gasoline/Ethanol
Product Stored Percent:	Not reported
Tank Leak Detection:	1. Electronic Interstitial Monitoring,5. In-Tank System (auto tank gauge)
Date Installation:	04/01/1991
Date Perm Closure:	01/01/1900
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	4. Fiberglass coated steel
Tank Internal Protection:	0. None
Tank External Protection:	2. Original sacrificial anode,4. Fiberglass
Tank Secondary Containment:	4. Double-Walled (underground only)
Piping Location:	2. Underground/on Ground
Piping Type:	99. Other
Piping External Protection:	4. Fiberglass
Overfill Prevention:	2. High Level Alarm,3. Automatic Shut-off
Piping Secondary Containment:	4. Double-Walled (underground only)
Spill Prevention:	1. Catch Basin
Dispenser:	2. Suction

WESTCHESTER COUNTY OFFICE BUILDING (Continued) **U004442265**

Tank Number:	6
Status:	1. In-Service
Capacity:	3000
Product Stored:	2712. Gasoline/Ethanol
Product Stored Percent:	Not reported
Tank Leak Detection:	1. Electronic Interstitial Monitoring,5. In-Tank System (auto tank gauge)
Date Installation:	04/01/1991
Date Perm Closure:	01/01/1900
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	4. Fiberglass coated steel
Tank Internal Protection:	0. None
Tank External Protection:	2. Original sacrificial anode,4. Fiberglass
Tank Secondary Containment:	4. Double-Walled (underground only)
Piping Location:	2. Underground/on Ground
Piping Type:	99. Other
Piping External Protection:	4. Fiberglass
Overfill Prevention:	2. High Level Alarm
Piping Secondary Containment:	4. Double-Walled (underground only)
Spill Prevention:	1. Catch Basin
Dispenser:	2. Suction

Tank Number:	7
Status:	0. Administratively closed
Capacity:	6000
Product Stored:	Not reported
Product Stored Percent:	Not reported
Tank Leak Detection:	Not reported
Date Installation:	09/01/1993
Date Perm Closure:	05/12/2005
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	4. Fiberglass coated steel
Tank Internal Protection:	0. None
Tank External Protection:	4. Fiberglass
Tank Secondary Containment:	4. Double-Walled (underground only)
Piping Location:	2. Underground/on ground
Piping Type:	Not reported
Piping External Protection:	99. Other
Overfill Prevention:	2. High Level Alarm,3. Automatic Shut-off
Piping Secondary Containment:	Not reported
Spill Prevention:	Not reported
Dispenser:	2. Suction

O122 **CON ED** **NY MANIFEST** **S118090928**
ESE **148 MARTINE AVE** **N/A**
< 1/8 **WHITE PLAINS, NY 10601**
0.106 mi.
559 ft. **Site 7 of 26 in cluster O**

Relative: **Higher**

Actual: **221 ft.**

NY MANIFEST:

EPA ID:	NYP004785739
Country:	USA
Name:	Con Ed
Address:	148 MARTINE AVE
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10601
Zip 4:	Not reported
Location Address 1:	148 MARTINE AVE

CON ED (Continued) **S118090928**

Location Address 2: MH 5823
Location City,State,Zip: WHITE PLAINS, NY 10601
Location Zip 4: Not reported
Facility Status: Not reported
Total Tanks: Not reported
Code: BP

Mailing:
Mailing Name: Con Ed
Mailing Contact: Tom Teeling
Mailing Address 1: 4 IRVING PLACE - 15TH FLOOR
Mailing Address 2: Not reported
Mailing City,State,Zip: NEW YORK, NY 10003
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: 2124603770

Manifest Data:
Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: NYD006982359
Year: 2018
Trans2 State ID: Not reported
Generator Ship Date: 05/22/2015
Trans1 Recv Date: 05/22/2015
Trans2 Recv Date: Not reported
TSD Site Recv Date: 05/26/2015
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYP004785739
Trans1 EPA ID: Not reported
Trans2 EPA ID: Not reported
TSDF ID 1: NJD002200046
TSDF ID 2: Not reported
Manifest Tracking Number: 014454293JJK
Import Indicator: N
Export Indicator: N
Discr Quantity Indicator: N
Discr Type Indicator: N
Discr Residue Indicator: N
Discr Partial Reject Indicator: N
Discr Full Reject Indicator: N
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: H110
Waste Code a: Not reported
Waste Code b: Not reported
Waste Code c: Not reported
Waste Code e: Lead
Waste Code f: Not reported
Waste Code g: Not reported
Waste Code 1: Not reported
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported

CON ED (Continued) **S118090928**

Waste Code 6:	Not reported
Quantity:	200
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

O123 **MICHAELIAN OFFICE BLDG** **UST FINDER RELEASE** **1029072845**
ESE **148 MARTINE AVE** **N/A**
< 1/8 **WHITE PLAINS, NY 0**
0.106 mi.
559 ft. **Site 8 of 26 in cluster O**

Relative:
Higher

Actual:
221 ft.

UST FINDER RELEASE:

Object ID:	262466
Facility ID:	NY304255
Lust ID:	NY9103040
Name:	MICHAELIAN OFFICE BLDG
Address:	148 MARTINE AVE
City,State,Zip:	WHITE PLAINS, NY 0
Address Match Type:	Not reported
Reported Date:	1991/06/12 15:59:59+00
Status:	No Further Action
Substance:	Not reported
Population within 1500ft:	4081
Domestic Wells within 1500ft:	0
Land Use:	Developed, High Intensity
Within SPA:	Yes
SPA PWS Facility ID:	NY7003493_76968
SPA Water Type:	SW - SurRELEASEe Water
SPA Facility Type:	RS - Reservoir
SPA HUC12:	20301020103
Within WHPA:	No
WHPA PWS Facility ID:	Not reported
WHPA Water Type:	Not reported
WHPA Facility Type:	Not reported
WHPA HUC12:	Not reported
Within 100yr Floodplain:	No
Tribe:	Not reported
EPA Region:	2
NFA Letter 1:	Not reported
NFA Letter 2:	Not reported
NFA Letter 3:	Not reported
NFA Letter 4:	Not reported
Closed With Residual Contaminate:	Not reported
Coordinate Source:	State
X Coord:	-73.76758
Y Coord:	41.03106
Latitude:	41.0310599999999
Longitude:	-73.7675799999999

K124 **CONSOLIDATED EDISON CO OF NY** **NJ MANIFEST** **S108170363**
ENE **189 MAIN ST** **N/A**
< 1/8 **WHITEPLAINS, NY 10601**
0.107 mi.
564 ft. **Site 8 of 27 in cluster K**

Relative:
Higher

Actual:
208 ft.

NJ MANIFEST:

EPA ID:	NYP004144358
Name:	CONSOLIDATED EDISON CO OF NY
Address:	189 MAIN ST
City,State,Zip:	WHITEPLAINS, NY 10601
County:	Not reported
Mailing Address:	31-01 20TH AVE
Mailing City,State,Zip:	ASTORIA 11105
Telephone:	7182044151
Emergency Telephone:	Not reported
Contact:	DONNA COVENTRY
Comments:	Not reported
SIC Code:	Not reported
County:	00
Municipal:	00
Previous EPAID:	Not reported
Generator Flag:	X
Transporter Flag:	Not reported
TSDF Flag:	Not reported
Name Change:	Not reported
Date Change:	Not reported

Manifest Data:

EPA ID:	NYP004144358
Manifest Number:	NJA5239251
Date Shipped:	08/06/2006
TSDF EPA ID:	NJD991291105
Transporter EPA ID:	NJD003812047
Transporter 2 EPA ID:	Not reported
Transporter 3 EPA ID:	Not reported
Transporter 4 EPA ID:	Not reported
Transporter 5 EPA ID:	Not reported
Transporter 6 EPA ID:	Not reported
Transporter 7 EPA ID:	Not reported
Transporter 8 EPA ID:	Not reported
Transporter 9 EPA ID:	Not reported
Transporter 10 EPA ID:	Not reported
Date Trans1 Transported Waste:	08/06/2006
Date Trans2 Transported Waste:	Not reported
Date Trans3 Transported Waste:	Not reported
Date Trans4 Transported Waste:	Not reported
Date Trans5 Transported Waste:	Not reported
Date Trans6 Transported Waste:	Not reported
Date Trans7 Transported Waste:	Not reported
Date Trans8 Transported Waste:	Not reported
Date Trans9 Transported Waste:	Not reported
Date Trans10 Transported Waste:	Not reported
Date TSDF Received Waste:	08/09/2006
TSDF EPA Facility Name:	Not reported
QTY Units:	Not reported
Transporter SEQ ID:	Not reported
Transporter-1 Date:	Not reported
Waste SEQ ID:	Not reported
Waste Type Code 2:	Not reported

CONSOLIDATED EDISON CO OF NY (Continued) **S108170363**

Waste Type Code 3:	Not reported
Waste Type Code 4:	Not reported
Waste Type Code 5:	Not reported
Waste Type Code 6:	Not reported
Date Accepted:	Not reported
Manifest Discrepancy Type:	Not reported
Data Entry Number:	09200621
Was Load Rejected:	N
Reason Load Was Rejected:	Not reported

K125 **CAPPELLI ASSOC.** **NY Spills** **S107416552**
ENE **189 MAIN STREET** **N/A**
< 1/8 **WHITE PLAINS, NY**
0.107 mi.
564 ft. **Site 9 of 27 in cluster K**

Relative: **Higher**
Actual: **208 ft.**

SPILLS:

Name:	CAPPELLI ASSOC.
Address:	189 MAIN STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0509190 / 2005-11-01
Facility ID:	0509190
Facility Type:	ER
DER Facility ID:	314244
Site ID:	354925
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	C4
SWIS:	6017
Spill Date:	2005-11-01
Investigator:	KABROWNE
Referred To:	Not reported
Reported to Dept:	2005-11-01
CID:	27
Water Affected:	Not reported
Spill Source:	Commercial Vehicle
Spill Notifier:	Other
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2005-11-01
Spill Record Last Update:	2005-11-14
Spiller Name:	FRANK FERRARO
Spiller Company:	ROBISON OIL
Spiller Address:	500 EXECUTIVE BLVD
Spiller Company:	001
Contact Name:	Not reported
Latitude:	41.0323640
Longitude:	-73.7679820
DEC Memo:	No storm drains impacted. Cleaned up. NFA.
Remarks:	Caller reports a leak from their delivery truck. There was a hole in the hose. White Plains FD is on the scene. Callers company will be sending a cleanup crew. Spill is on the street in front of the business.

CAPPELLI ASSOC. (Continued) **S107416552**

All Materials:

Site ID:	354925
Operable Unit ID:	1112311
Operable Unit:	01
Material ID:	2102353
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	MANHOLE # 10236
Address:	189 MAIN STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0601744 / 2008-06-11
Facility ID:	0601744
Facility Type:	ER
DER Facility ID:	314244
Site ID:	364045
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	C3
SWIS:	6017
Spill Date:	2006-05-17
Investigator:	TDGHIOSA
Referred To:	Not reported
Reported to Dept:	2006-05-17
CID:	444
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Affected Persons
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2006-05-17
Spill Record Last Update:	2008-06-11
Spiller Name:	JOHN MANFREDI
Spiller Company:	CAPELLI ENTERPRISES
Spiller Address:	189 MAIN STREET
Spiller Company:	999
Contact Name:	ERT DESK’
Latitude:	41.0325617
Longitude:	-73.7679586
DEC Memo:	05/17/06 Met with Con ED rep Tim Riley who explained that the impacted manhole conatined about and inch of fuel oil floating on several hundred gallons of water. A sample was taken and results rec’d later indicate that material was similar to a light fuel oil. A curbside fill line for 189 Main

CAPPELLI ASSOC. (Continued) **S107416552**

Street is one possible source. Requested that when the manhole is safe for entry that Con Ed
personnel attempt to determine where the furl is entering the structure. TG 07/21/06 JM Associates
coordinated the testing of the remote fill and vent lines servicing 189 Main Street and both of
those lines failed. The remote fill was excavated and petroleum impacted soil was present beneath
the line. Local WP building Dept work permit prohibited complete removal of the line, so
remediation will continue when the building is demolished. TG 06/10/08 Closure report submitted by
JM Associates. 13.32 tons of PCS removed. No post excavation sample results were taken. TG

Remarks: UNKNOWN DOING LAB RESULTS: CONED # 200085

All Materials:

Site ID:	364045
Operable Unit ID:	1122096
Operable Unit:	01
Material ID:	2111583
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	G
Recovered:	.00
Resource Affected:	Soil, Sewer, Utility
Oxygenate:	Not reported

M126 **CON EDISON MANHOLE: 9908** **RCRA NonGen / NLR** **1016451570**
WSW **25 BANK ST** **FINDS** **NYP004306650**
< 1/8 **WHITE PLAINS, NY 10602** **ECHO**
0.108 mi. **NY MANIFEST**
568 ft. **Site 4 of 5 in cluster M**

Relative: Higher
Actual: 201 ft.

RCRA Listings:

Date Form Received by Agency:	20190503
Handler Name:	Con Edison Manhole: 9908
Handler Address:	Bank St
Handler City,State,Zip:	WHITE PLAINS, NY 10602
EPA ID:	NYP004306650
Contact Name:	Not reported
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	Not reported
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported

CON EDISON MANHOLE: 9908 (Continued) **1016451570**

State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	Not reported
Mailing City,State,Zip:	Not reported
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20190503
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20130501
Handler Name:	CON EDISON MANHOLE: 9908
Federal Waste Generator Description:	Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No

CON EDISON MANHOLE: 9908 (Continued) **1016451570**

Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20190503
Handler Name:	CON EDISON MANHOLE: 9908
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	No
Electronic Manifest Broker:	No

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

FINDS:
Registry ID: 110056327425

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:
The Resource Conservation and Recovery Act Information System (RCRAInfo) is EPA's comprehensive information system in support of the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. It tracks many types of information about generators, transporters, treaters, storers, and disposers of hazardous waste.

Click this hyperlink while viewing on your computer to access additional FINDS: detail in the EDR Site Report.

ECHO:

Envid:	1016451570
Registry ID:	110056327425

DFR URL:

Name:	CON EDISON MANHOLE: 9908
Address:	25 BANK ST
City,State,Zip:	WHITE PLAINS, NY 10602

CON EDISON MANHOLE: 9908 (Continued) **1016451570**

NY MANIFEST:

EPA ID:	NYP004306650
Country:	USA
Name:	Con Edison
Address:	25 BANK ST
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10602
Zip 4:	Not reported
Location Address 1:	25 BANK ST & MARITINE AVE
Location Address 2:	Not reported
Location City,State,Zip:	WHITE PLAINS, NY 10606
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Edison
Mailing Contact:	Con Edison
Mailing Address 1:	4 IRVING PLACE 15TH FLOOR
Mailing Address 2:	Not reported
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	2124603770

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	05/01/2013
Trans1 Recv Date:	05/01/2013
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	05/07/2013
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004306650
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	007019045JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported

CON EDISON MANHOLE: 9908 (Continued) **1016451570**

Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	50
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

M127 **OUTSIDE DWELLING** **NY Spills** **S109415945**
WSW **25 BANK DRIVE** **N/A**
< 1/8 **WHITE PLAINS, NY**
0.108 mi.
568 ft. **Site 5 of 5 in cluster M**

Relative:
Higher

Actual:
201 ft.

SPILLS:

Name:	OUTSIDE DWELLING
Address:	25 BANK DRIVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0813053 / 2009-03-05
Facility ID:	0813053
Facility Type:	ER
DER Facility ID:	359954
Site ID:	410714
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	C4
SWIS:	6017
Spill Date:	2009-03-05
Investigator:	mbmastro
Referred To:	Not reported
Reported to Dept:	2009-03-05
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Private Dwelling
Spill Notifier:	Local Agency
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2009-03-05
Spill Record Last Update:	2009-03-05
Spiller Name:	Not reported
Spiller Company:	EQUIPMENT FAILURE
Spiller Address:	Not reported
Spiller Company:	999
Contact Name:	ERT

OUTSIDE DWELLING (Continued) **S109415945**

Latitude:	41.0304719
Longitude:	-73.7742064
DEC Memo:	03/05/09 Will do clean up, nfa...mm
Remarks:	Asphalt has been cleaned up.Man hole clean up in progress.

All Materials:

Site ID:	410714
Operable Unit ID:	1167191
Operable Unit:	01
Material ID:	2158730
Material Code:	0010
Material Name:	hydraulic oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.11
Units:	G
Recovered:	Not reported
Resource Affected:	Not reported
Oxygenate:	Not reported

H128 **CON EDISON MANHOLE: 9937** **RCRA NonGen / NLR** **1016973803**
WNW **BANK ST & HAMILTON AVE** **NY MANIFEST** **NYP004476115**
< 1/8 **WHITE PLAINS, NY 10606**
0.109 mi.
574 ft. **Site 4 of 4 in cluster H**

Relative:
Higher

Actual:
201 ft.

RCRA Listings:

Date Form Received by Agency:	20140423
Handler Name:	Con Edison Manhole: 9937
Handler Address:	Bank St & Hamilton Ave
Handler City,State,Zip:	WHITE PLAINS, NY 10606
EPA ID:	NYP004476115
Contact Name:	THOMAS TEELING
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	212-460-3770
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	SENIOR SCIENTIST
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PL, 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No

CON EDISON MANHOLE: 9937 (Continued) **1016973803**

Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20141014
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20140323
Handler Name: CON EDISON MANHOLE: 9937	
Federal Waste Generator Description:	Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20140423
Handler Name: CON EDISON MANHOLE: 9937	
Federal Waste Generator Description:	Not a generator, verified

CON EDISON MANHOLE: 9937 (Continued) **1016973803**

State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

List of NAICS Codes and Descriptions:

NAICS Codes:	No NAICS Codes Found

Facility Has Received Notices of Violations:

Violations:	No Violations Found

Evaluation Action Summary:

Evaluations:	No Evaluations Found

NY MANIFEST:

EPA ID:	NYP004476115
Country:	USA
Name:	Con Edison
Address:	BANK ST & HAMILTON AVE
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10606
Zip 4:	Not reported
Location Address 1:	MAIN BANKS ST
Location Address 2:	SB67702
Location City,State,Zip:	WHITE PLAINS, NY 11801
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Edison
Mailing Contact:	Con Edison
Mailing Address 1:	4 IRVING ST
Mailing Address 2:	15TH ST
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	Not reported

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	03/23/2014
Trans1 Recv Date:	03/23/2014
Trans2 Recv Date:	Not reported

CON EDISON MANHOLE: 9937 (Continued) **1016973803**

TSD Site Recv Date:	03/24/2014
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004476115
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	012354004JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	500
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1
Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	03/23/2014
Trans1 Recv Date:	03/23/2014
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	03/24/2014
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004476115
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	012772703JJK
Import Indicator:	N

CON EDISON MANHOLE: 9937 (Continued) **1016973803**

Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	600
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

K129 **CON EDISON MANHOLE 5622** **RCRA NonGen / NLR** **1009218109**
ENE **COURT ST & MAIN ST** **NYP004137717**
< 1/8 **WHITE PLAINS, NY 10601**
0.111 mi.
584 ft. **Site 10 of 27 in cluster K**

Relative: **Higher**
Actual: **208 ft.**

RCRA Listings:

Date Form Received by Agency:	20051125
Handler Name:	Con Edison Manhole 5622
Handler Address:	Court St & Main St
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYP004137717
Contact Name:	ANTONIO DELGADO
Contact Address:	4 IRVING PL, RM 828
Contact City,State,Zip:	NEW YORK, NY 10003
Contact Telephone:	718-204-4201
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Not reported
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R3

CON EDISON MANHOLE 5622 (Continued) **1009218109**

Mailing Address:	4 IRVING PL, RM 828
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20150414
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20051123
Handler Name: CON EDISON	
Federal Waste Generator Description:	Not reported
State District Owner:	Not reported
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No

CON EDISON MANHOLE 5622 (Continued) **1009218109**

Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20051124
Handler Name: CON EDISON	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Not reported
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20051125
Handler Name: CON EDISON MANHOLE 5622	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

K130 **CON EDISON** **NY MANIFEST** **S116042143**
ENE **COURT ST & MAIN ST** **N/A**
< 1/8 **WHITE PLAINS, NY 10701**
0.111 mi.
584 ft. **Site 11 of 27 in cluster K**

Relative: **Higher**
Actual: **208 ft.**

NY MANIFEST:

EPA ID:	NYP004384657
Country:	USA
Name:	Con Edison
Address:	COURT ST & MAIN ST
Address 2:	TM3256
City,State,Zip:	WHITE PLAINS, NY 10701
Zip 4:	Not reported
Location Address 1:	COURT ST & MAIN ST

CON EDISON (Continued) **S116042143**

Location Address 2: TM3256
Location City,State,Zip: WHITE PLAINS, NY 10701
Location Zip 4: Not reported
Facility Status: Not reported
Total Tanks: Not reported
Code: BP

Mailing:
Mailing Name: Con Edison
Mailing Contact: Con Edison
Mailing Address 1: 4 IRVING PLACE
Mailing Address 2: 15TH FL
Mailing City,State,Zip: NEW YORK, NY 10003
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: Not reported

Manifest Data:
Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: NYD006982359
Year: 2018
Trans2 State ID: Not reported
Generator Ship Date: 11/03/2013
Trans1 Recv Date: 11/03/2013
Trans2 Recv Date: Not reported
TSD Site Recv Date: 11/06/2013
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYP004384657
Trans1 EPA ID: Not reported
Trans2 EPA ID: Not reported
TSDF ID 1: NJD002200046
TSDF ID 2: Not reported
Manifest Tracking Number: 011695080JJK
Import Indicator: N
Export Indicator: N
Discr Quantity Indicator: N
Discr Type Indicator: N
Discr Residue Indicator: N
Discr Partial Reject Indicator: N
Discr Full Reject Indicator: N
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: H110
Waste Code a: Lead
Waste Code b: Not reported
Waste Code c: Not reported
Waste Code e: Not reported
Waste Code f: Not reported
Waste Code g: Not reported
Waste Code 1: Not reported
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported

CON EDISON (Continued) **S116042143**

Waste Code 6:	Not reported
Quantity:	150
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

K131 **CON EDISON** **RCRA NonGen / NLR** **1010327472**
ENE **MAIN ST & COURT ST** **NY MANIFEST** **NYP004146833**
< 1/8 **WHITE PLAINS, NY 10601**
0.111 mi.
584 ft. **Site 12 of 27 in cluster K**

Relative: **Higher**

Actual: **208 ft.**

RCRA Listings:

Date Form Received by Agency:	20070111
Handler Name:	Con Edison
Handler Address:	Main St & Court St
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYP004146833
Contact Name:	ANTONIO DELGADO
Contact Address:	4 IRVING PL, RM 828
Contact City,State,Zip:	NEW YORK, NY 10003
Contact Telephone:	718-204-4201
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Not reported
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R3
Mailing Address:	4 IRVING PL, RM 828
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported

CON EDISON (Continued) **1010327472**

Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20150414
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20070109
Handler Name: CON EDISON	
Federal Waste Generator Description:	Not reported
State District Owner:	Not reported
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20070110
Handler Name: CON EDISON	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Not reported
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20070111
Handler Name: CON EDISON	
Federal Waste Generator Description:	Not a generator, verified

CON EDISON (Continued) **1010327472**

State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

NY MANIFEST:
EPA ID: NYP004146833
Country: USA
Name: Consolidated Edison
Address: MAIN ST & COURT ST
Address 2: Not reported
City,State,Zip: WHITE PLAINS, NY 10601
Zip 4: Not reported
Location Address 1: MAIN STREET & COURT STREET
Location Address 2: Not reported
Location City,State,Zip: WHITE PLAINS, NY 10602
Location Zip 4: Not reported
Facility Status: Not reported
Total Tanks: Not reported
Code: BP

Mailing:
Mailing Name: Consolidated Edison
Mailing Contact: Franklin Murray
Mailing Address 1: 4 IRVING PLACE RM 828
Mailing Address 2: Not reported
Mailing City,State,Zip: NEW YORK, NY 10003
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: 2124602808

Manifest Data:
Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: NYD006982359
Year: 2018
Trans2 State ID: Not reported
Generator Ship Date: 11/28/2006
Trans1 Recv Date: 11/28/2006
Trans2 Recv Date: Not reported

CON EDISON (Continued) **1010327472**

TSD Site Recv Date:	11/29/2006
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004146833
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NYD000705939
TSDF ID 2:	Not reported
Manifest Tracking Number:	000328925FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H135
Waste Code a:	Benzene
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	285
Units:	Gallons (liquids only)
Number of Containers:	7
Container Type:	Metal drums, barrels, kegs
Handling Method:	Treat
Specific Gravity:	1

K132 **ROADWAY** **NY Spills** **S109415778**
ENE **MAIN ST & COURT ST** **N/A**
< 1/8 **WHITE PLAINS, NY**
0.111 mi.
584 ft. **Site 13 of 27 in cluster K**

Relative:
Higher

Actual:
208 ft.

SPILLS:

Name:	ROADWAY
Address:	MAIN ST & COURT ST
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0812871 / 2009-02-27
Facility ID:	0812871
Facility Type:	ER
DER Facility ID:	359765
Site ID:	410519
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	D4

ROADWAY (Continued) **S109415778**

SWIS:	6017
Spill Date:	2009-02-27
Investigator:	jbodee
Referred To:	Not reported
Reported to Dept:	2009-02-27
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Commercial Vehicle
Spill Notifier:	Responsible Party
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2009-02-27
Spill Record Last Update:	2009-04-04
Spiller Name:	SEAMUS ROCHE
Spiller Company:	LIBERT LINES TRANSIT BUS # 457
Spiller Address:	MAIN ST & COURT ST
Spiller Company:	999
Contact Name:	SEAMUS ROCHE
Latitude:	41.0323670
Longitude:	-73.7677499
DEC Memo:	SPILLER HIRED 3D ENV. FOR CLEANUP OF ROADWAY. CONFIRMED WITH 3D ENV. NFA DT
Remarks:	Caller states a tranmission failure caised oil to spill onto blacktop. Cleanup is ongoing.

All Materials:

Site ID:	410519
Operable Unit ID:	1167002
Operable Unit:	01
Material ID:	2158524
Material Code:	0021
Material Name:	transmission fluid
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	5.00
Units:	G
Recovered:	Not reported
Resource Affected:	Not reported
Oxygenate:	Not reported

K133 **CON EDISON** **NJ MANIFEST** **S120671973**
ENE **COURT ST & MAIN ST** **N/A**
< 1/8 **WHITE PLAINS, NY 10601**
0.111 mi.
584 ft. **Site 14 of 27 in cluster K**

Relative: **Higher**
Actual: **208 ft.**

NJ MANIFEST:

EPA ID:	NYP004784807
Name:	CON EDISON
Address:	COURT ST & MAIN ST
City,State,Zip:	WHITE PLAINS, NY 10601
County:	Not reported
Mailing Address:	IRVING PL 15TH FL NE

CON EDISON (Continued) **S120671973**

Mailing City,State,Zip:	NEW YORK, NY 10003
Telephone:	Not reported
Emergency Telephone:	Not reported
Contact:	THOMAS TEELING
Comments:	Not reported
SIC Code:	Not reported
County:	NY119
Municipal:	Not reported
Previous EPAID:	Not reported
Generator Flag:	Not reported
Transporter Flag:	Not reported
TSDF Flag:	Not reported
Name Change:	Not reported
Date Change:	Not reported

Manifest Data:

EPA ID:	NYP004784807
Manifest Number:	014467522JJK
Date Shipped:	5/20/2015
TSDF EPA ID:	NJD002200046
Transporter EPA ID:	NYD006982359
Transporter 2 EPA ID:	Not reported
Transporter 3 EPA ID:	Not reported
Transporter 4 EPA ID:	Not reported
Transporter 5 EPA ID:	Not reported
Transporter 6 EPA ID:	Not reported
Transporter 7 EPA ID:	Not reported
Transporter 8 EPA ID:	Not reported
Transporter 9 EPA ID:	Not reported
Transporter 10 EPA ID:	Not reported
Date Trans1 Transported Waste:	Not reported
Date Trans2 Transported Waste:	Not reported
Date Trans3 Transported Waste:	Not reported
Date Trans4 Transported Waste:	Not reported
Date Trans5 Transported Waste:	Not reported
Date Trans6 Transported Waste:	Not reported
Date Trans7 Transported Waste:	Not reported
Date Trans8 Transported Waste:	Not reported
Date Trans9 Transported Waste:	Not reported
Date Trans10 Transported Waste:	Not reported
Date TSDF Received Waste:	Not reported
TSDF EPA Facility Name:	Not reported
QTY Units:	Not reported
Transporter SEQ ID:	Not reported
Transporter-1 Date:	Not reported
Waste SEQ ID:	Not reported
Waste Type Code 2:	Not reported
Waste Type Code 3:	Not reported
Waste Type Code 4:	Not reported
Waste Type Code 5:	Not reported
Waste Type Code 6:	Not reported
Date Accepted:	Not reported
Manifest Discrepancy Type:	Not reported
Data Entry Number:	Not reported
Was Load Rejected:	Not reported
Reason Load Was Rejected:	Not reported

K134 **CON EDISON MANHOLE 10236** **RCRA NonGen / NLR** **1010327416**
ENE **MAIN ST & COURT ST** **NY MANIFEST** **NYP004146551**
< 1/8 **WHITE PLAINS, NY 10606**
0.111 mi.
584 ft. **Site 15 of 27 in cluster K**

Relative: **Higher**

Actual: **208 ft.**

RCRA Listings:

Date Form Received by Agency:	20070111
Handler Name:	Con Edison Manhole 10236
Handler Address:	Main St & Court St
Handler City,State,Zip:	WHITE PLAINS, NY 10606
EPA ID:	NYP004146551
Contact Name:	STEVEN MARTIS
Contact Address:	4 IRVING PL, RM 828
Contact City,State,Zip:	NEW YORK, NY 10003
Contact Telephone:	212-580-8383
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Not reported
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R3
Mailing Address:	4 IRVING PL, RM 828
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No

CON EDISON MANHOLE 10236 (Continued) **1010327416**

Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20150414
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20070109
Handler Name: CON EDISON	
Federal Waste Generator Description:	Not reported
State District Owner:	Not reported
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20070110
Handler Name: CON EDISON	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Not reported
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20070111
Handler Name: CON EDISON MANHOLE 10236	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

CON EDISON MANHOLE 10236 (Continued) **1010327416**

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

NY MANIFEST:

EPA ID:	NYP004146551
Country:	USA
Name:	Consolidated Edison
Address:	MAIN ST & COURT ST
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10606
Zip 4:	Not reported
Location Address 1:	MAIN STREET
Location Address 2:	Not reported
Location City,State,Zip:	WHITE PLAINS, NY 10602
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Consolidated Edison
Mailing Contact:	Franklin Murray
Mailing Address 1:	4 IRVING PLACE RM 828
Mailing Address 2:	Not reported
Mailing City,State,Zip:	NEW YORK, NC 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	2124602808

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NJ0000027193
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	11/09/2006
Trans1 Recv Date:	11/09/2006
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	11/10/2006
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004146551
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	001030647JJK
Import Indicator:	N

CON EDISON MANHOLE 10236 (Continued) **1010327416**

Export Indicator:	N
Discr Quantity Indicator:	Y
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H141
Waste Code a:	Ignitable Waste
Waste Code b:	Benzene
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	170
Units:	Gallons (liquids only)
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

K135 **CON EDISON MANHOLE 10236** **RCRA NonGen / NLR** **1014918856**
ENE **COURT ST & MAIN ST** **NY MANIFEST** **NYP004224754**
< 1/8 **WHITE PLAINS, NY 10601** **NJ MANIFEST**
0.111 mi.
584 ft. **Site 16 of 27 in cluster K**

Relative: **Higher**

Actual: **208 ft.**

RCRA Listings:

Date Form Received by Agency:	20110218
Handler Name:	Con Edison Manhole 10236
Handler Address:	Court St & Main St
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYP004224754
Contact Name:	DOMINIC BIZZARO
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	914-925-6219
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	SR SPECIALIST
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2

CON EDISON MANHOLE 10236 (Continued) **1014918856**

Mailing Address:	IRVING PL RM 828
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20110701
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20110119
Handler Name:	CON EDISON MANHOLE 10236
Federal Waste Generator Description:	Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No

CON EDISON MANHOLE 10236 (Continued) **1014918856**

Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20110218
Handler Name: CON EDISON MANHOLE 10236
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

NY MANIFEST:
EPA ID: NYP004224754
Country: USA
Name: Coned - Mh10236
Address: COURT ST & MAIN ST
Address 2: Not reported
City,State,Zip: WHITE PLAINS, NY 10601
Zip 4: Not reported
Location Address 1: COURT ST
Location Address 2: MAIN ST
Location City,State,Zip: WHITE PLAINS, NY 10601
Location Zip 4: Not reported
Facility Status: Not reported
Total Tanks: Not reported
Code: BP

Mailing:
Mailing Name: Coned - Mh10236
Mailing Contact: Coned - Mh10236
Mailing Address 1: 4 IRVING PLACE
Mailing Address 2: Not reported
Mailing City,State,Zip: NEW YORK, NY 10004
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: Not reported

CON EDISON MANHOLE 10236 (Continued) **1014918856**

Manifest Data:
- Document ID: Not reported
- Manifest Status: Not reported
- Trans1 State ID: NYD006982359
- Year: 2018
- Trans2 State ID: Not reported
- Generator Ship Date: 01/19/2011
- Trans1 Recv Date: 01/19/2011
- Trans2 Recv Date: Not reported
- TSD Site Recv Date: 01/20/2011
- Part A Recv Date: Not reported
- Part B Recv Date: Not reported
- Generator EPA ID: NYP004224754
- Trans1 EPA ID: Not reported
- Trans2 EPA ID: Not reported
- TSDF ID 1: NJD002200046
- TSDF ID 2: Not reported
- Manifest Tracking Number: 007655841JJK
- Import Indicator: N
- Export Indicator: N
- Discr Quantity Indicator: N
- Discr Type Indicator: N
- Discr Residue Indicator: N
- Discr Partial Reject Indicator: N
- Discr Full Reject Indicator: N
- Manifest Ref Number: Not reported
- Alt Facility RCRA ID: Not reported
- Alt Facility Sign Date: Not reported
- MGMT Method Type Code: H111
- Waste Code a: Lead
- Waste Code b: Not reported
- Waste Code c: Not reported
- Waste Code e: Not reported
- Waste Code f: Not reported
- Waste Code g: Not reported
- Waste Code 1: Not reported
- Waste Code 2: Not reported
- Waste Code 3: Not reported
- Waste Code 4: Not reported
- Waste Code 5: Not reported
- Waste Code 6: Not reported
- Quantity: 100
- Units: Pounds
- Number of Containers: 1
- Container Type: Cargo tanks (tank trucks)
- Handling Method: Treat
- Specific Gravity: 1

NJ MANIFEST:
- EPA ID: NYP004224754
- Name: CON EDISON MANHOLE 10236
- Address: COURT ST & MAIN ST
- City,State,Zip: WHITE PLAINS, NY 10601
- County: Not reported
- Mailing Address: IRVING PL RM 828

CON EDISON MANHOLE 10236 (Continued) **1014918856**

Mailing City,State,Zip:	NEW YORK, NY 10003
Telephone:	Not reported
Emergency Telephone:	Not reported
Contact:	DOMINIC BIZZARO
Comments:	Not reported
SIC Code:	Not reported
County:	NY119
Municipal:	Not reported
Previous EPAID:	Not reported
Generator Flag:	Not reported
Transporter Flag:	Not reported
TSDF Flag:	Not reported
Name Change:	Not reported
Date Change:	Not reported

Manifest Data:

EPA ID:	NYP004224754
Manifest Number:	007655841JJK
Date Shipped:	1/19/2011
TSDF EPA ID:	NJD002200046
Transporter EPA ID:	NYD006982359
Transporter 2 EPA ID:	Not reported
Transporter 3 EPA ID:	Not reported
Transporter 4 EPA ID:	Not reported
Transporter 5 EPA ID:	Not reported
Transporter 6 EPA ID:	Not reported
Transporter 7 EPA ID:	Not reported
Transporter 8 EPA ID:	Not reported
Transporter 9 EPA ID:	Not reported
Transporter 10 EPA ID:	Not reported
Date Trans1 Transported Waste:	Not reported
Date Trans2 Transported Waste:	Not reported
Date Trans3 Transported Waste:	Not reported
Date Trans4 Transported Waste:	Not reported
Date Trans5 Transported Waste:	Not reported
Date Trans6 Transported Waste:	Not reported
Date Trans7 Transported Waste:	Not reported
Date Trans8 Transported Waste:	Not reported
Date Trans9 Transported Waste:	Not reported
Date Trans10 Transported Waste:	Not reported
Date TSDF Received Waste:	Not reported
TSDF EPA Facility Name:	Not reported
QTY Units:	Not reported
Transporter SEQ ID:	Not reported
Transporter-1 Date:	Not reported
Waste SEQ ID:	Not reported
Waste Type Code 2:	Not reported
Waste Type Code 3:	Not reported
Waste Type Code 4:	Not reported
Waste Type Code 5:	Not reported
Waste Type Code 6:	Not reported
Date Accepted:	Not reported
Manifest Discrepancy Type:	Not reported
Data Entry Number:	Not reported
Was Load Rejected:	Not reported
Reason Load Was Rejected:	Not reported

Waste:

CON EDISON MANHOLE 10236 (Continued) **1014918856**

Manifest Year:	Not reported
Waste Code:	D008
Hand Code:	H111
Quantity:	100.00
Unit:	Pounds

K136 **CON EDISON** **RCRA NonGen / NLR** **1019903377**
ENE **COURT ST & MAIN ST** **NYP004784807**
< 1/8 **WHITE PLAINS, NY 10601**
0.111 mi.
584 ft. **Site 17 of 27 in cluster K**

Relative: **Higher**
Actual: **208 ft.**

RCRA Listings:

Date Form Received by Agency:	20150520
Handler Name:	Con Edison
Handler Address:	Court St & Main St
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYP004784807
Contact Name:	THOMAS TEELING
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	212-460-3770
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PL 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N

CON EDISON (Continued) **1019903377**

Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20160909
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20150520
Handler Name: CON EDISON	
Federal Waste Generator Description:	Large Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20150520
Handler Name: CON EDISON	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

List of NAICS Codes and Descriptions:

NAICS Codes:	No NAICS Codes Found

CON EDISON (Continued) **1019903377**

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

K137 **CON EDISON SERVICE BOX: 12498** **RCRA NonGen / NLR** **1016971319**
ENE **MAIN ST & COURT ST** **NY MANIFEST** **NYP004450573**
< 1/8 **WHITE PLAINS, NY 10607**
0.111 mi.
584 ft. **Site 18 of 27 in cluster K**

Relative: **Higher**
Actual: **208 ft.**

RCRA Listings:

Date Form Received by Agency:	20140324
Handler Name:	Con Edison Service Box: 12498
Handler Address:	Main St & Court St
Handler City,State,Zip:	WHITE PLAINS, NY 10607
EPA ID:	NYP004450573
Contact Name:	THOMAS TEELING
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	212-460-3770
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	SENIOR SCIENTIST
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PL, 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N

CON EDISON SERVICE BOX: 12498 (Continued) **1016971319**

Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20141014
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20140224
Handler Name: CON EDISON SERVICE BOX:	12498
Federal Waste Generator Description:	Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20140324
Handler Name: CON EDISON SERVICE BOX:	12498
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

List of NAICS Codes and Descriptions:

NAICS Codes:	No NAICS Codes Found

CON EDISON SERVICE BOX: 12498 (Continued) **1016971319**

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

NY MANIFEST:

EPA ID:	NYP004450573
Country:	USA
Name:	Con Edison
Address:	MAIN ST & COURT ST
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10607
Zip 4:	Not reported
Location Address 1:	MAIN ST & LOVET ST
Location Address 2:	Not reported
Location City,State,Zip:	WHITE PLAINS, NY 10801
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Edison
Mailing Contact:	Con Edision
Mailing Address 1:	4 IRVING PL
Mailing Address 2:	15TH FL
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	Not reported

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	02/24/2014
Trans1 Recv Date:	02/24/2014
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	02/25/2014
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004450573
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	012772727JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N

CON EDISON SERVICE BOX: 12498 (Continued) **1016971319**

Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	20
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

K138 **CON EDISON** **RCRA NonGen / NLR** **1016962067**
ENE **COURT ST & MAIN ST** **FINDS** **NYP004350450**
< 1/8 **WHITE PLAINS, NY 10601** **ECHO**
0.111 mi.
584 ft. **Site 19 of 27 in cluster K**

Relative: **Higher**
Actual: **208 ft.**

RCRA Listings:

Date Form Received by Agency:	20130923
Handler Name:	Con Edison Transformer Manhole: 3256
Handler Address:	Court St & Main St
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYP004350450
Contact Name:	DENNIS ROHRER
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	914-925-6219
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	SR SPECIALIST
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PL, RM 828
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported

CON EDISON (Continued) **1016962067**

Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20140701
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20130823
Handler Name:	CON EDISON TRANSFORMER MANHOLE: 3256
Federal Waste Generator Description:	Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported

CON EDISON (Continued) **1016962067**

Electronic Manifest Broker: Not reported

Receive Date: 20130923
Handler Name: CON EDISON TRANSFORMER MANHOLE: 3256
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

FINDS:
Registry ID: 110069657829

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:
The Resource Conservation and Recovery Act Information System (RCRAInfo) is EPA's comprehensive information system in support of the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. It tracks many types of information about generators, transporters, treaters, storers, and disposers of hazardous waste.

Click this hyperlink while viewing on your computer to access additional FINDS: detail in the EDR Site Report.

ECHO:
Envid: 1016962067
Registry ID: 110069657829

DFR URL:
Name: CON EDISON
Address: COURT ST & MAIN ST
City,State,Zip: WHITE PLAINS, NY 10601

K139 **CON EDISON MANHOLE: 5622** **RCRA NonGen / NLR** **1016969602**
ENE **MAIN ST & COURT ST** **NY MANIFEST** **NYP004432753**
< 1/8 **WHITE PLAINS, NY 10602**
0.111 mi.
584 ft. **Site 20 of 27 in cluster K**

Relative: **Higher**
Actual: **208 ft.**

RCRA Listings:

Date Form Received by Agency:	20140303
Handler Name:	Con Edison Manhole: 5622
Handler Address:	Main St & Court St
Handler City,State,Zip:	WHITE PLAINS, NY 10602
EPA ID:	NYP004432753
Contact Name:	THOMAS TEELING
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	212-460-3770
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	SENIOR SCIENTIST
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PL, 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No

CON EDISON MANHOLE: 5622 (Continued) **1016969602**

Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20141014
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20140203
Handler Name: CON EDISON MANHOLE: 5622	
Federal Waste Generator Description:	Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20140303
Handler Name: CON EDISON MANHOLE: 5622	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

List of NAICS Codes and Descriptions:

NAICS Codes:	No NAICS Codes Found

Facility Has Received Notices of Violations:

Violations:	No Violations Found

Evaluation Action Summary:

Evaluations:	No Evaluations Found

CON EDISON MANHOLE: 5622 (Continued) **1016969602**

NY MANIFEST:

EPA ID:	NYP004432753
Country:	USA
Name:	Con Edison
Address:	MAIN ST & COURT ST
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10602
Zip 4:	Not reported
Location Address 1:	COURT ST & MAIN ST
Location Address 2:	Not reported
Location City,State,Zip:	WHITE PLAINS, NY 10602
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Edison
Mailing Contact:	Con Edison
Mailing Address 1:	4 IRVING PLACE
Mailing Address 2:	15TH FL
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	Not reported

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	02/03/2014
Trans1 Recv Date:	02/03/2014
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	02/04/2014
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004432753
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	011692714JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported

CON EDISON MANHOLE: 5622 (Continued) **1016969602**

Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	300
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

K140 **CON EDISON MANHOLE: 10235** **RCRA NonGen / NLR** **1016960682**
ENE **MAIN ST & COURT ST** **NY MANIFEST** **NYP004327854**
< 1/8 **WHITE PLAINS, NY 10610**
0.111 mi.
584 ft. **Site 21 of 27 in cluster K**

Relative: **Higher**
Actual: **208 ft.**

RCRA Listings:

Date Form Received by Agency:	20130811
Handler Name:	Con Edison Manhole: 10235
Handler Address:	Main St & Court St
Handler City,State,Zip:	WHITE PLAINS, NY 10610
EPA ID:	NYP004327854
Contact Name:	DOMINIC BIZZARO
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	914-925-6219
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	SR SPECIALIST
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PL, RM 828
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No

CON EDISON MANHOLE: 10235 (Continued) **1016960682**

Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20140701
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20130711
Handler Name: CON EDISON MANHOLE: 10235	
Federal Waste Generator Description:	Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20130811
Handler Name: CON EDISON MANHOLE: 10235	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No

CON EDISON MANHOLE: 10235 (Continued) **1016960682**

Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

NY MANIFEST:
EPA ID: NYP004327854
Country: USA
Name: Con Edison
Address: MAIN ST & COURT ST
Address 2: Not reported
City,State,Zip: WHITE PLAINS, NY 10610
Zip 4: Not reported
Location Address 1: MAIN ST & COURT ST
Location Address 2: MH #10235
Location City,State,Zip: WHITE PLAINS, NY 10601
Location Zip 4: Not reported
Facility Status: Not reported
Total Tanks: Not reported
Code: BP

Mailing:
Mailing Name: Con Edison
Mailing Contact: Con Edison
Mailing Address 1: 4 IRVING PLACE 15TH FLOOR
Mailing Address 2: Not reported
Mailing City,State,Zip: NEW YORK, NY 10003
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: 2124603770

Manifest Data:
Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: NYD006982359
Year: 2018
Trans2 State ID: Not reported
Generator Ship Date: 07/11/2013
Trans1 Recv Date: 07/11/2013
Trans2 Recv Date: Not reported
TSD Site Recv Date: 07/17/2013
Part A Recv Date: Not reported
Part B Recv Date: Not reported

CON EDISON MANHOLE: 10235 (Continued) **1016960682**

Generator EPA ID:	NYP004327854
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	011695970JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	150
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

K141 **CON EDISON** **NY MANIFEST** **S118090838**
ENE **COURT ST & MAIN ST** **N/A**
< 1/8 **WHITE PLAINS, NY 10601**
0.111 mi.
584 ft. **Site 22 of 27 in cluster K**

Relative: **Higher**
Actual: **208 ft.**

NY MANIFEST:

EPA ID:	NYP004784807
Country:	USA
Name:	Con Edison
Address:	COURT ST & MAIN ST
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10601
Zip 4:	Not reported
Location Address 1:	COURT ST & MAIN ST
Location Address 2:	MH 5622
Location City,State,Zip:	WHITE PLAINS, NY 10601
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

CON EDISON (Continued) **S118090838**

Mailing:
- Mailing Name: Con Edison
- Mailing Contact: Dennis Huacon
- Mailing Address 1: 4 IRVING PL 15TH FL
- Mailing Address 2: Not reported
- Mailing City,State,Zip: NEW YORK, NY 10003
- Mailing Zip 4: Not reported
- Mailing Country: USA
- Mailing Phone: 2124603770

Manifest Data:
- Document ID: Not reported
- Manifest Status: Not reported
- Trans1 State ID: NYD006982359
- Year: 2018
- Trans2 State ID: Not reported
- Generator Ship Date: 05/20/2015
- Trans1 Recv Date: 05/20/2015
- Trans2 Recv Date: Not reported
- TSD Site Recv Date: 05/26/2015
- Part A Recv Date: Not reported
- Part B Recv Date: Not reported
- Generator EPA ID: NYP004784807
- Trans1 EPA ID: Not reported
- Trans2 EPA ID: Not reported
- TSDF ID 1: NJD002200046
- TSDF ID 2: Not reported
- Manifest Tracking Number: 014467522JJK
- Import Indicator: N
- Export Indicator: N
- Discr Quantity Indicator: Y
- Discr Type Indicator: N
- Discr Residue Indicator: N
- Discr Partial Reject Indicator: N
- Discr Full Reject Indicator: N
- Manifest Ref Number: Not reported
- Alt Facility RCRA ID: Not reported
- Alt Facility Sign Date: Not reported
- MGMT Method Type Code: H141
- Waste Code a: Lead
- Waste Code b: Not reported
- Waste Code c: Not reported
- Waste Code e: Not reported
- Waste Code f: B002
- Waste Code g: Not reported
- Waste Code 1: Not reported
- Waste Code 2: Not reported
- Waste Code 3: Not reported
- Waste Code 4: Not reported
- Waste Code 5: Not reported
- Waste Code 6: Not reported
- Quantity: 835
- Units: Kilograms
- Number of Containers: 1
- Container Type: Cargo tanks (tank trucks)
- Handling Method: Treat

CON EDISON (Continued) **S118090838**

Specific Gravity: 1

N142 **COMMERICAL BUILDING** **NY LTANKS** **S118953530**
NW **10 NEW KING STREET** **N/A**
< 1/8 **WHITE PLAINS, NY**
0.111 mi.
584 ft. **Site 2 of 18 in cluster N**

Relative:
Higher

Actual:
201 ft.

LTANKS:

Name:	COMMERICAL BUILDING
Address:	10 NEW KING STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	1006070 / 2010-10-28
Facility ID:	1006070
Site ID:	439407
Spill Date:	2010-09-01
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	JKOMARA
Referred To:	Not reported
Reported to Dept:	2010-09-01
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2010-09-01
Spill Record Last Update:	2010-10-28
Spiller Name:	KAREN GOMEZ
Spiller Company:	BENEROFE GROUP
Spiller Address:	10 NEW KING STREET
Spiller County:	999
Spiller Contact:	KAREN GOMEZ
Spiller Phone:	(914) 681-5100
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	394398
Latitude:	41.0333203
Longitude:	-73.7743564
DEC Memo:	9-1-10 Spoke with Bob. He says the leak appears to be very minor. They will uncover tank and investigate cause of tank test failure - then repair and retest. This is a 10k UST. 10/28/10 Pased Retest 9/24/10 NFA JO'M
Remarks:	The tank is located underground and failed the tank test. Benerofe group is the responsible party.

All Materials:

Site ID:	439407
Operable Unit ID:	1190052
Operable Unit:	01
Material ID:	2185019

COMMERICAL BUILDING (Continued) **S118953530**

Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported
Resource Affected:	Not reported
Oxygenate:	Not reported

N143 **DIESEL IN STREAM** **NY Spills** **S123661649**
NW **10 NEW KING ST** **N/A**
< 1/8 **WHITE PLAINS, NY**
0.111 mi.
584 ft. **Site 3 of 18 in cluster N**

Relative: **Higher**
Actual: **201 ft.**

SPILLS:

Name:	DIESEL IN STREAM
Address:	10 NEW KING ST
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	1812048 / 2019-03-07
Facility ID:	1812048
Facility Type:	ER
DER Facility ID:	536447
Site ID:	584004
DEC Region:	3
Spill Cause:	Unknown
Spill Class:	C6
SWIS:	6038
Spill Date:	2019-03-06
Investigator:	JBODEE
Referred To:	NYC DEP
Reported to Dept:	2019-03-06
CID:	Not reported
Water Affected:	NEARBY STREAM
Spill Source:	Unknown
Spill Notifier:	Local Agency
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	2019-03-07
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2019-03-06
Spill Record Last Update:	2019-03-13
Spiller Name:	UNKNOWN
Spiller Company:	Unknown Vehicle
Spiller Address:	Not reported
Spiller Company:	999
Contact Name:	RICHARD BARRETT
Latitude:	Not reported
Longitude:	Not reported
DEC Memo:	3/6/19 Spoke to the caller, who confirmed that this was related to an earlier report of petroleum in a stream. O'Dee had spoken with them earlier, and said he would try to meet DEP on site to investigate and determine a possible source. dw 3/07/19: DEC inspected

DIESEL IN STREAM (Continued) **S123661649**

the location with DEP
HazMat. Strong diesel odors noted in a catch basin at the southeast corner of the parking lot for
office building at 10 New King Street. There is a petroleum stain on the grate over the catch
basin. Upgradient catch basins are clean. Some sheen noted in the impacted catch basin. Impacted
basin discharges to a nearby stream. Diesel odors, sheen, and some emulsified product noted at the
outfall. DEP has deployed boom which is picking up very little petroleum. It appears this spill is
the result of a diesel fuel leak - most likely from a delivery truck - and the spill occurred some
time ago. The diesel is weathered and breaking apart. DEP will continue to monitor and replace
booms if necessary. No recoverable product. jod

Remarks: SOIL SAMPLES DISCOVERED CONTAMINATION 3/07/19: Update from Regional Office: Actual report to Central Office Hotline was for petroleum odors noted while DEP was taking water samples. The caller did not report soil samples. jod

All Materials:

Site ID:	584004
Operable Unit ID:	1331673
Operable Unit:	01
Material ID:	2340888
Material Code:	0008
Material Name:	diesel
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported
Resource Affected:	Surface Water
Oxygenate:	Not reported

O144 **VEHICLE #41354** **NY Spills** **S107416673**
East **LEXINGTON AVE/ NEW ST** **N/A**
< 1/8 **WHITE PLAINS, NY**
0.111 mi.
586 ft. **Site 9 of 26 in cluster O**

Relative: **Higher**
Actual: **214 ft.**

SPILLS:

Name:	VEHICLE #41354
Address:	LEXINGTON AVE/ NEW ST
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0509373 / 2005-11-04
Facility ID:	0509373
Facility Type:	ER
DER Facility ID:	305139
Site ID:	355142
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	C4
SWIS:	6017
Spill Date:	2005-11-04
Investigator:	JBODee

VEHICLE #41354 (Continued) **S107416673**

Referred To:	Not reported
Reported to Dept:	2005-11-04
CID:	408
Water Affected:	Not reported
Spill Source:	Commercial Vehicle
Spill Notifier:	Responsible Party
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2005-11-04
Spill Record Last Update:	2005-11-14
Spiller Name:	ERT DESK
Spiller Company:	CON EDISON
Spiller Address:	4 IRVING PLACE
Spiller Company:	999
Contact Name:	ERT DESK’
Latitude:	41.0317400
Longitude:	-73.7675900
DEC Memo:	NFA.
Remarks:	PRODUCT WAS 1/2 QUART. CON ED #161795

All Materials:

Site ID:	355142
Operable Unit ID:	1112512
Operable Unit:	01
Material ID:	2102553
Material Code:	0015
Material Name:	motor oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

N145 **OFFICE BLDG** **NY LTANKS** **S103558242**
NW **4 NEW KING ST** **N/A**
< 1/8 **WHITE PLAINS, NY**
0.111 mi.
587 ft. **Site 4 of 18 in cluster N**

Relative: **Higher**
Actual: **201 ft.**

LTANKS:

Name:	OFFICE BLDG
Address:	4 NEW KING ST
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9809692 / 2003-12-05
Facility ID:	9809692
Site ID:	170684
Spill Date:	1998-11-02
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	B3
Cleanup Ceased:	Not reported

OFFICE BLDG (Continued) **S103558242**

SWIS:	6017
Investigator:	WCHD
Referred To:	Westchester Cnty Health Dept
Reported to Dept:	1998-11-02
CID:	211
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1998-11-02
Spill Record Last Update:	2003-12-05
Spiller Name:	Not reported
Spiller Company:	OFFICE BLDG
Spiller Address:	4 NEW KING ST
Spiller County:	001
Spiller Contact:	TOM CAFFERTY
Spiller Phone:	(914) 697-7654
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	143629
Latitude:	41.0775668
Longitude:	-73.7127611
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was WCHD - MCDONALD 12/05/03 CLOSED BY BARBARA McDONALD OF WCHD. TANK REMOVED JANUARY OF 1999.
Remarks:	REOMMEND UNCOVER TANK - ISOLATE FOR RETEST

All TTF:

Facility ID:	9809692
Spill Number:	9809692
Spill Tank Test:	1546478
Site ID:	170684
Tank Number:	1
Tank Size:	2000
Material:	0002
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	.00
Gross Fail:	F
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	170684
Operable Unit ID:	1066903
Operable Unit:	01
Material ID:	313593
Material Code:	0002A
Material Name:	#4 fuel oil
Case No.:	Not reported

OFFICE BLDG (Continued) **S103558242**

Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

O146 **MINSKOFF MANAGEMENT** **NY Spills** **S102151723**
East **39-47 COURT STREET** **N/A**
< 1/8 **WHITE PLAINS, NY**
0.114 mi.
602 ft. **Site 10 of 26 in cluster O**

Relative:
Higher

Actual:
216 ft.

SPILLS:

Name:	MINSKOFF MANAGEMENT
Address:	39-47 COURT STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9110040 / 1992-03-10
Facility ID:	9110040
Facility Type:	ER
DER Facility ID:	196905
Site ID:	239414
DEC Region:	3
Spill Cause:	Unknown
Spill Class:	Not reported
SWIS:	6017
Spill Date:	1991-12-20
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1991-12-20
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Private Dwelling
Spill Notifier:	Fire Department
Cleanup Ceased:	1992-01-08
Cleanup Meets Std:	True
Last Inspection:	1992-01-08
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	1992-01-07
Spill Record Last Update:	1992-03-10
Spiller Name:	Not reported
Spiller Company:	Not reported
Spiller Address:	Not reported
Spiller Company:	001
Contact Name:	Not reported
Latitude:	41.0315862
Longitude:	-73.7675447
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY
Remarks:	APPRX. 1 OF PRODUCT IN BASEMENT CONCRETE FLOOR FIRE DEPT. RESPONDED TO COMPLAINT OF ODORS CARLOS WCHD WILL TRY TO GET SOMEONE FROM WCHD TO INSPECT APPEARS TO BE VERY LARGE OVERFILL

All Materials:

Site ID:	239414

MINSKOFF MANAGEMENT (Continued) **S102151723**

Operable Unit ID:	960055
Operable Unit:	01
Material ID:	418614
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	Not reported
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

O147 **COURT & MARTINE 2009 LLC** **NY AST** **A100412049**
East **39-55 COURT ST / 167-183 MARTINE AVE.** **N/A**
< 1/8 **WHITE PLAINS, NY 10601**
0.114 mi.
602 ft. **Site 11 of 26 in cluster O**

Relative: WESTCHESTER CO. AST:
Higher

Name:	COURT & MARTINE 2009 LLC
Address:	39-55 COURT ST / 167-183 MARTINE AVE.
City,State,Zip:	WHITE PLAINS, NY 10601
PBS Number:	3-177903
Site Status:	Active
GDS Number:	Not reported
Operator Name:	Michael Pilla
Owner Name:	Court & Martine 2009 LLC
Owner Street:	39-55 Court St / 167-183 Martine Avenue
Owner Address2:	Not reported
Owner City/State/Zip:	White Plains, NY 10601
Tank Number:	003
Status:	1. In-Service
Date Installation:	03/01/1991
Capacity:	2000
Product Stored:	0001. #2 Fuel Oil
Product Stored Percent:	Not reported
Date Perm Closure:	06/01/1994
Tank Location:	6. Aboveground in subterranean vault with access for inspections
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Leak Detection:	0. None
Tank Secondary Containment:	2. Vault (w/ access)
Piping Location:	3. Aboveground/Underground Combination
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	1. Painted/Asphalt Coating
Piping Leak Detection:	0. None
Piping Secondary Containment:	0. None
Overfill Prevention:	4. Product Level Gauge (Aboveground Only),5. Vent Whistle
Spill Prevention:	0. None
Dispenser:	2. Suction

Actual:
216 ft.

O148 **I/F/O THE MELTING POT** **NY Spills** **S110307755**
East **35 COURT ST** **N/A**
< 1/8 **WHITE PLAINS, NY**
0.114 mi.
602 ft. **Site 12 of 26 in cluster O**

Relative:
Higher

Actual:
215 ft.

SPILLS:

Name:	I/F/O THE MELTING POT
Address:	35 COURT ST
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	1000201 / 2010-04-06
Facility ID:	1000201
Facility Type:	ER
DER Facility ID:	380329
Site ID:	431359
DEC Region:	3
Spill Cause:	Deliberate
Spill Class:	E5
SWIS:	6017
Spill Date:	2010-04-06
Investigator:	kabrowne
Referred To:	Not reported
Reported to Dept:	2010-04-06
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Health Department
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	Not reported
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2010-04-06
Spill Record Last Update:	2010-04-06
Spiller Name:	DENIS HEINZGER
Spiller Company:	THE MELTING POT
Spiller Address:	35 COURT ST
Spiller Company:	999
Contact Name:	DENIS HEINZGER
Latitude:	41.0316663
Longitude:	-73.7675167
DEC Memo:	4/6/10 - A juvenile caused the spil. Nonpetroleum spill. Spill being overseen by Westchester County DOH. No spill. NFA. KAB
Remarks:	DUE TO CONTAINERS FALLING OVER ON THE CURB ABOUT 50 GALLONS SPILLED TO THE STREET AND A STORM DRAIN. CLEAN UP PENDING.

All Materials:

Site ID:	431359
Operable Unit ID:	1182813
Operable Unit:	01
Material ID:	2177016
Material Code:	0046A
Material Name:	cooking grease
Case No.:	Not reported
Material FA:	Other
Quantity:	50.00
Units:	G
Recovered:	50.00

I/F/O THE MELTING POT (Continued) **S110307755**

Resource Affected: Sewer, Impervious Surface
Oxygenate: Not reported

K149 **CON EDISON SERVICE BOX: 464** **NJ MANIFEST** **S120666081**
East **19 COURT ST** **N/A**
< 1/8 **WHITE PLAINS, NY 10602**
0.114 mi.
603 ft. **Site 23 of 27 in cluster K**

Relative:
Higher

Actual:
211 ft.

NJ MANIFEST:

EPA ID:	NYP004432662
Name:	CON EDISON SERVICE BOX: 464
Address:	19 COURT ST
City,State,Zip:	WHITE PLAINS, NY 10602
County:	Not reported
Mailing Address:	VING PL, 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Telephone:	Not reported
Emergency Telephone:	Not reported
Contact:	THOMAS TEELING
Comments:	Not reported
SIC Code:	Not reported
County:	NY119
Municipal:	Not reported
Previous EPAID:	Not reported
Generator Flag:	Not reported
Transporter Flag:	Not reported
TSDF Flag:	Not reported
Name Change:	Not reported
Date Change:	Not reported

Manifest Data:

EPA ID:	NYP004432662
Manifest Number:	015319726JJK
Date Shipped:	2/29/2016
TSDF EPA ID:	NJD002200046
Transporter EPA ID:	NYD006982359
Transporter 2 EPA ID:	Not reported
Transporter 3 EPA ID:	Not reported
Transporter 4 EPA ID:	Not reported
Transporter 5 EPA ID:	Not reported
Transporter 6 EPA ID:	Not reported
Transporter 7 EPA ID:	Not reported
Transporter 8 EPA ID:	Not reported
Transporter 9 EPA ID:	Not reported
Transporter 10 EPA ID:	Not reported
Date Trans1 Transported Waste:	Not reported
Date Trans2 Transported Waste:	Not reported
Date Trans3 Transported Waste:	Not reported
Date Trans4 Transported Waste:	Not reported
Date Trans5 Transported Waste:	Not reported
Date Trans6 Transported Waste:	Not reported
Date Trans7 Transported Waste:	Not reported
Date Trans8 Transported Waste:	Not reported
Date Trans9 Transported Waste:	Not reported
Date Trans10 Transported Waste:	Not reported
Date TSDF Received Waste:	Not reported

CON EDISON SERVICE BOX: 464 (Continued) **S120666081**

TSDF EPA Facility Name:	Not reported
QTY Units:	Not reported
Transporter SEQ ID:	Not reported
Transporter-1 Date:	Not reported
Waste SEQ ID:	Not reported
Waste Type Code 2:	Not reported
Waste Type Code 3:	Not reported
Waste Type Code 4:	Not reported
Waste Type Code 5:	Not reported
Waste Type Code 6:	Not reported
Date Accepted:	Not reported
Manifest Discrepancy Type:	Not reported
Data Entry Number:	Not reported
Was Load Rejected:	Not reported
Reason Load Was Rejected:	Not reported

K150 **CON EDISON SERVICE BOX: 464** **RCRA NonGen / NLR** **1016969593**
East **19 COURT ST** **NY MANIFEST** **NYP004432662**
< 1/8 **WHITE PLAINS, NY 10602**
0.114 mi.
603 ft. **Site 24 of 27 in cluster K**

Relative: **Higher**
Actual: **211 ft.**

RCRA Listings:

Date Form Received by Agency:	20140303
Handler Name:	Con Edison Service Box: 464
Handler Address:	Court St
Handler City,State,Zip:	WHITE PLAINS, NY 10602
EPA ID:	NYP004432662
Contact Name:	THOMAS TEELING
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	212-460-3770
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	SENIOR SCIENTIST
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PL, 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No

CON EDISON SERVICE BOX: 464 (Continued) **1016969593**

Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20141014
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20140203
Handler Name: CON EDISON SERVICE BOX:	464
Federal Waste Generator Description:	Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20140303
Handler Name: CON EDISON SERVICE BOX:	464
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No

CON EDISON SERVICE BOX: 464 (Continued) **1016969593**

Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

NY MANIFEST:
EPA ID: NYP004432662
Country: USA
Name: Con Edison
Address: 19 COURT ST
Address 2: Not reported
City,State,Zip: WHITE PLAINS, NY 10602
Zip 4: Not reported
Location Address 1: S/O 19 COURT ST
Location Address 2: Not reported
Location City,State,Zip: WHITE PLAINS, NY 10602
Location Zip 4: Not reported
Facility Status: Not reported
Total Tanks: Not reported
Code: BP

Mailing:
Mailing Name: Con Edison
Mailing Contact: Con Edison
Mailing Address 1: 4 IRVING PLACE
Mailing Address 2: 15TH FL
Mailing City,State,Zip: NEW YORK, NY 10003
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: Not reported

Manifest Data:
Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: NYD006982359
Year: 2018
Trans2 State ID: Not reported
Generator Ship Date: 02/03/2014
Trans1 Recv Date: 02/03/2014
Trans2 Recv Date: Not reported
TSD Site Recv Date: 02/04/2014
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYP004432662

CON EDISON SERVICE BOX: 464 (Continued) **1016969593**

Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	011692715JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	30
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

P151 **ON STREET** **NY Spills** **S107522214**
NNE **WILLIAMS STREET** **N/A**
< 1/8 **WHITE PLAINS, NY**
0.116 mi.
610 ft. **Site 1 of 8 in cluster P**

Relative: **Higher**
Actual: **198 ft.**

SPILLS:

Name:	ON STREET
Address:	WILLIAMS STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0512156 / 2007-05-07
Facility ID:	0512156
Facility Type:	ER
DER Facility ID:	308439
Site ID:	358429
DEC Region:	3
Spill Cause:	Other
Spill Class:	B1
SWIS:	6017
Spill Date:	2006-01-11
Investigator:	TDGHIOSA
Referred To:	Not reported

ON STREET (Continued) **S107522214**

Reported to Dept:	2006-01-20
CID:	444
Water Affected:	Not reported
Spill Source:	Institutional, Educational, Gov., Other
Spill Notifier:	Other
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2006-01-20
Spill Record Last Update:	2007-05-07
Spiller Name:	JOHN MANFREDIE
Spiller Company:	ON STREET
Spiller Address:	WILLIAMS STREET
Spiller Company:	001
Contact Name:	JOHN MANFREDIE
Latitude:	41.0336650
Longitude:	-73.7691750
DEC Memo:	04/27/07 Reprot issued by JM Associates documenting the work perrformed to install a new sanitary sewer on Williams street. The sewer was installed 10 feet below street level. No PCS was encountered during the installation. NFA TG
Remarks:	DURING DIGGING ON ISTE FOUND CONTAMINATED SOIL, THE STREET IS OWNED BY THE NY POWER AUTHORITY, BUT NOT THERE RESPONSIBILITY: UNSURE WHERE SPILL CAME FROM:

All Materials:

Site ID:	358429
Operable Unit ID:	1115672
Operable Unit:	01
Material ID:	2105759
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

K152 **SOIL** **NY Spills** **S110768383**
ENE **3 RENAISSANCE SQUARE** **N/A**
< 1/8 **WHITE PLAINS, NY**
0.116 mi.
611 ft. **Site 25 of 27 in cluster K**

Relative: **Higher**
Actual: **210 ft.**

SPILLS:

Name:	SOIL
Address:	3 RENAISSANCE SQUARE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	1011749 / 2011-03-31
Facility ID:	1011749
Facility Type:	ER

SOIL (Continued) **S110768383**

DER Facility ID:	400485
Site ID:	445639
DEC Region:	3
Spill Cause:	Human Error
Spill Class:	B1
SWIS:	6017
Spill Date:	2011-02-24
Investigator:	kabrowne
Referred To:	Not reported
Reported to Dept:	2011-02-24
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Other
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2011-02-24
Spill Record Last Update:	2011-03-31
Spiller Name:	Not reported
Spiller Company:	RITZ CARLTON
Spiller Address:	Not reported
Spiller Company:	999
Contact Name:	PATRICK BECCARIA
Latitude:	41.0327326
Longitude:	-73.7677534
DEC Memo:	2/24/11 - Left a message with Caller to return phone call. C. Lalak & C. Torres, Westchester County DOH, will conduct an inspection and report back to DEC. KAB 3/31/11 AS per WCDOH spill CLeanup finished NFA JO'M
Remarks:	Caller advised approximately 80 gallons of diesel spilled. Clean up is in process.

All Materials:

Site ID:	445639
Operable Unit ID:	1196021
Operable Unit:	01
Material ID:	2192206
Material Code:	0008
Material Name:	diesel
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	80.00
Units:	G
Recovered:	Not reported
Resource Affected:	Soil
Oxygenate:	Not reported

O153 **CON EDISON** **RCRA NonGen / NLR** **1019903384**
East **COURT ST & MARTINE AVE** **FINDS** **NYP004784880**
< 1/8 **WHITE PLAINS, NY 10601** **ECHO**
0.116 mi.
613 ft. **Site 13 of 26 in cluster O**

Relative: **Higher**
Actual: **220 ft.**

RCRA Listings:

Date Form Received by Agency:	20150520
Handler Name:	Con Edison
Handler Address:	Court St & Martine Ave
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYP004784880
Contact Name:	THOMAS TEELING
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	212-460-3770
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PL 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No

CON EDISON (Continued) **1019903384**

Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20160909
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20150520
Handler Name: CON EDISON	
Federal Waste Generator Description:	Large Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20150520
Handler Name: CON EDISON	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

List of NAICS Codes and Descriptions:

NAICS Codes:	No NAICS Codes Found

Facility Has Received Notices of Violations:

Violations:	No Violations Found

Evaluation Action Summary:

Evaluations:	No Evaluations Found

CON EDISON (Continued) **1019903384**

FINDS:
Registry ID: 110069657892

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:
The Resource Conservation and Recovery Act Information System (RCRAInfo) is EPA's comprehensive information system in support of the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. It tracks many types of information about generators, transporters, treaters, storers, and disposers of hazardous waste.

Click this hyperlink while viewing on your computer to access additional FINDS: detail in the EDR Site Report.

ECHO:
Envid: 1019903384
Registry ID: 110069657892

DFR URL:
Name: CON EDISON
Address: COURT ST & MARTINE AVE
City,State,Zip: WHITE PLAINS, NY 10601

O154 **DPW VEHICLE** **NY Spills** **S113915643**
East **COURT ST AND MARTINE AVE** **N/A**
< 1/8 **WHITE PLAINS, NY**
0.116 mi.
613 ft. **Site 14 of 26 in cluster O**

Relative:
Higher

Actual:
220 ft.

SPILLS:
Name: DPW VEHICLE
Address: COURT ST AND MARTINE AVE
City,State,Zip: WHITE PLAINS, NY
Spill Number/Closed Date: 1305831 / 2013-10-07
Facility ID: 1305831
Facility Type: ER
DER Facility ID: 441527
Site ID: 486412
DEC Region: 3
Spill Cause: Equipment Failure
Spill Class: B3
SWIS: 6017
Spill Date: 2013-09-03
Investigator: JBODEE
Referred To: Not reported
Reported to Dept: 2013-09-03
CID: Not reported
Water Affected: Not reported
Spill Source: Commercial Vehicle
Spill Notifier: Responsible Party
Cleanup Ceased: Not reported
Cleanup Meets Std: False
Last Inspection: Not reported
Recommended Penalty: False
UST Trust: False
Remediation Phase: 0

DPW VEHICLE (Continued) **S113915643**

Date Entered In Computer:	2013-09-03
Spill Record Last Update:	2013-10-07
Spiller Name:	BILL MCMAHON
Spiller Company:	WHITE PLAINS DPW
Spiller Address:	Not reported
Spiller Company:	999
Contact Name:	BILL MCMAHON
Latitude:	41.0311499
Longitude:	-73.7674469
DEC Memo:	9-3-13: J.O'Dee call to V.Mc./Dspt.: John in contact with BILL MCMAHON/DPW. DPW responding and may be hairing Tri.St. J.O'Dee handling. 9/04/13: Bill McMahon from DPW called me directly when the spill occured yesterday. At first he stated fluid had entered a catch basin and they were calling Tri-State. He also stated that there was a multi-vehicle traffic accident as a result of this spill, a car reportedly slid through a traffic light. Bill called back later and stated that no material had entered the catch basin and DPW was completing the clean up themselves. I called back this morning and left a message asking him for an update. jod 10/07/13: Tri-State was contacted but never hired to perform any work. White Plains DPW reports the clean up was completed and no drains were impacted. No disposal documentation was provided. jod
Remarks:	spill to roadway and catch basin/clean up underway

All Materials:

Site ID:	486412
Operable Unit ID:	1236058
Operable Unit:	01
Material ID:	2235359
Material Code:	0010
Material Name:	hydraulic oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	20.00
Units:	G
Recovered:	Not reported
Resource Affected:	Sewer
Oxygenate:	Not reported

O155 **CON EDISON MANHOLE 932** **RCRA NonGen / NLR** **1014918798**
East **MARTINE AVE & COURT ST** **NY MANIFEST** **NYP004224176**
< 1/8 **WHITE PLAINS, NY 10605** **NJ MANIFEST**
0.116 mi.
613 ft. **Site 15 of 26 in cluster O**

Relative:
Higher

Actual:
220 ft.

RCRA Listings:

Date Form Received by Agency:	20110215
Handler Name:	Con Edison Manhole 932
Handler Address:	Martine Ave & Court St
Handler City,State,Zip:	WHITE PLAINS, NY 10605
EPA ID:	NYP004224176
Contact Name:	DENNIS ROHRER
Contact Address:	Not reported

CON EDISON MANHOLE 932 (Continued) **1014918798**

Contact City,State,Zip:	Not reported
Contact Telephone:	914-925-6219
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	SR SPECIALIST
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PL RM 828
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20110701
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No

CON EDISON MANHOLE 932 (Continued) **1014918798**

Recycler Activity Without Storage: No
Manifest Broker: No
Sub-Part P Indicator: No

Historic Generators:
Receive Date: 20110116
Handler Name: CON EDISON MANHOLE 932
Federal Waste Generator Description: Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20110215
Handler Name: CON EDISON MANHOLE 932
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

NY MANIFEST:
EPA ID: NYP004224176
Country: USA
Name: Consolidated Edison
Address: MARTINE AVE & COURT ST
Address 2: Not reported
City,State,Zip: WHITE PLAINS, NY 10605
Zip 4: Not reported
Location Address 1: MAINTIME & COURT ST
Location Address 2: MH 9132
Location City,State,Zip: WHITE PLAINS, NY
Location Zip 4: Not reported

CON EDISON MANHOLE 932 (Continued) **1014918798**

Facility Status: Not reported
Total Tanks: Not reported
Code: BP

Mailing:
Mailing Name: Consolidated Edison
Mailing Contact: Dennis Huacon
Mailing Address 1: 4 IRVING PLACE RM 828
Mailing Address 2: Not reported
Mailing City,State,Zip: NEW YORK, NY 10003
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: 2124602757

Manifest Data:
Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: NYD006982359
Year: 2018
Trans2 State ID: Not reported
Generator Ship Date: 01/16/2011
Trans1 Recv Date: 01/16/2011
Trans2 Recv Date: Not reported
TSD Site Recv Date: 01/18/2011
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYP004224176
Trans1 EPA ID: Not reported
Trans2 EPA ID: Not reported
TSDF ID 1: NJD002200046
TSDF ID 2: Not reported
Manifest Tracking Number: 007655566JJK
Import Indicator: N
Export Indicator: N
Discr Quantity Indicator: N
Discr Type Indicator: Y
Discr Residue Indicator: N
Discr Partial Reject Indicator: N
Discr Full Reject Indicator: N
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: H111
Waste Code a: Lead
Waste Code b: Not reported
Waste Code c: Not reported
Waste Code e: Not reported
Waste Code f: Not reported
Waste Code g: Not reported
Waste Code 1: Not reported
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 100
Units: Pounds

CON EDISON MANHOLE 932 (Continued) **1014918798**

Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

NJ MANIFEST:

EPA ID:	NYP004224176
Name:	CON EDISON MANHOLE 932
Address:	MARTINE AVE & COURT ST
City,State,Zip:	WHITE PLAINS, NY 10605
County:	Not reported
Mailing Address:	IRVING PL RM 828
Mailing City,State,Zip:	NEW YORK, NY 10003
Telephone:	Not reported
Emergency Telephone:	Not reported
Contact:	DENNIS ROHRER
Comments:	Not reported
SIC Code:	Not reported
County:	NY119
Municipal:	Not reported
Previous EPAID:	Not reported
Generator Flag:	Not reported
Transporter Flag:	Not reported
TSDF Flag:	Not reported
Name Change:	Not reported
Date Change:	Not reported

Manifest Data:

EPA ID:	NYP004224176
Manifest Number:	007655566JJK
Date Shipped:	1/16/2011
TSDF EPA ID:	NJD002200046
Transporter EPA ID:	NYD006982359
Transporter 2 EPA ID:	Not reported
Transporter 3 EPA ID:	Not reported
Transporter 4 EPA ID:	Not reported
Transporter 5 EPA ID:	Not reported
Transporter 6 EPA ID:	Not reported
Transporter 7 EPA ID:	Not reported
Transporter 8 EPA ID:	Not reported
Transporter 9 EPA ID:	Not reported
Transporter 10 EPA ID:	Not reported
Date Trans1 Transported Waste:	Not reported
Date Trans2 Transported Waste:	Not reported
Date Trans3 Transported Waste:	Not reported
Date Trans4 Transported Waste:	Not reported
Date Trans5 Transported Waste:	Not reported
Date Trans6 Transported Waste:	Not reported
Date Trans7 Transported Waste:	Not reported
Date Trans8 Transported Waste:	Not reported
Date Trans9 Transported Waste:	Not reported
Date Trans10 Transported Waste:	Not reported
Date TSDF Received Waste:	Not reported
TSDF EPA Facility Name:	Not reported
QTY Units:	Not reported
Transporter SEQ ID:	Not reported

CON EDISON MANHOLE 932 (Continued) **1014918798**

Transporter-1 Date:	Not reported
Waste SEQ ID:	Not reported
Waste Type Code 2:	Not reported
Waste Type Code 3:	Not reported
Waste Type Code 4:	Not reported
Waste Type Code 5:	Not reported
Waste Type Code 6:	Not reported
Date Accepted:	Not reported
Manifest Discrepancy Type:	Not reported
Data Entry Number:	Not reported
Was Load Rejected:	Not reported
Reason Load Was Rejected:	Not reported

Waste:

Manifest Year:	Not reported
Waste Code:	D008
Hand Code:	H111
Quantity:	100.00
Unit:	Pounds

O156 **CON EDISON** **NY MANIFEST** **S117738399**
East **MARTINE AVE & COURT ST** **N/A**
< 1/8 **WHITE PLAINS, NY 10801**
0.116 mi.
613 ft. **Site 16 of 26 in cluster O**

Relative:
Higher

Actual:
220 ft.

NY MANIFEST:

EPA ID:	NYP004714374
Country:	USA
Name:	Con Edison
Address:	MARTINE AVE & COURT ST
Address 2:	MH7098
City,State,Zip:	WHITE PLAINS, NY 10801
Zip 4:	Not reported
Location Address 1:	MARTINE AVE & COURT ST
Location Address 2:	MH7098
Location City,State,Zip:	WHITE PLAINS, NY 10801
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Edison
Mailing Contact:	Con Edison
Mailing Address 1:	4 IRVING PL
Mailing Address 2:	15TH FL
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	Not reported

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359

CON EDISON (Continued) **S117738399**

Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	01/13/2015
Trans1 Recv Date:	01/13/2015
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	01/19/2015
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004714374
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	012774706JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	25
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

O157 **INTERSECTION OF COURT ST.** **NY LTANKS** **S102674960**
East **COURT ST. & MARITINE AVE.** **N/A**
< 1/8 **WHITE PLAINS, NY**
0.116 mi.
613 ft. **Site 17 of 26 in cluster O**

Relative: LTANKS:
Higher

Name:	INTERSECTION OF COURT ST.
Address:	COURT ST. & MARITINE AVE.
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8905963 / 1989-11-29
Facility ID:	8905963
Site ID:	187446

Actual:
220 ft.

INTERSECTION OF COURT ST. (Continued) **S102674960**

Spill Date:	1989-09-18
Spill Cause:	Tank Overfill
Spill Source:	Tank Truck
Spill Class:	Not reported
Cleanup Ceased:	1989-11-29
SWIS:	6017
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1989-09-18
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Fire Department
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1989-09-21
Spill Record Last Update:	1989-11-29
Spiller Name:	Not reported
Spiller Company:	RAD OIL
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	156611
Latitude:	41.0311499
Longitude:	-73.7674469
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was TODD GHIOSAY
Remarks:	TANK TRUCK WAS OVERFILLED. WHITE PLAINS P.D. & F.D. ON SCENE.

All Materials:

Site ID:	187446
Operable Unit ID:	931170
Operable Unit:	01
Material ID:	446358
Material Code:	0009
Material Name:	gasoline
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	25.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

O158 **CON EDISON TRANSFORMER MANHOLE: 5706** **RCRA NonGen / NLR** **1016960251**
East **MARTINE AVE & COURT** **NY MANIFEST** **NYP004321162**
< 1/8 **WHITE PLAINS, NY 10601**
0.116 mi.
613 ft. **Site 18 of 26 in cluster O**

Relative:
Higher

Actual:
220 ft.

RCRA Listings:

Date Form Received by Agency:	20130717
Handler Name:	Con Edison Transformer Manhole: 5706
Handler Address:	Martine Ave & Court
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYP004321162
Contact Name:	DOMINIC BIZZARO
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	914-925-6219
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	SR SPECIALIST
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PL, RM 828
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No

CON EDISON TRANSFORMER MANHOLE: 5706 (Continued) **1016960251**

Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20140701
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20130617
Handler Name:	CON EDISON TRANSFORMER MANHOLE: 5706
Federal Waste Generator Description:	Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20130717
Handler Name:	CON EDISON TRANSFORMER MANHOLE: 5706
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

List of NAICS Codes and Descriptions:

NAICS Codes:	No NAICS Codes Found

Facility Has Received Notices of Violations:

Violations:	No Violations Found

Evaluation Action Summary:

Evaluations:	No Evaluations Found

CON EDISON TRANSFORMER MANHOLE: 5706 (Continued) **1016960251**

NY MANIFEST:

EPA ID:	NYP004321162
Country:	USA
Name:	Con Edison
Address:	MARTINE AVE & COURT
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10601
Zip 4:	Not reported
Location Address 1:	MARTINE AVE & SO COURT ST
Location Address 2:	MH 2706
Location City,State,Zip:	WHITE PLAINS, NY 10601
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Edison
Mailing Contact:	Con Edison
Mailing Address 1:	4 IRVING PLACE 15TH FLOOR
Mailing Address 2:	Not reported
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	2124603770

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	NYD006982359
Generator Ship Date:	06/17/2013
Trans1 Recv Date:	06/17/2013
Trans2 Recv Date:	06/18/2013
TSD Site Recv Date:	06/18/2013
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004321162
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	011693084JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported

CON EDISON TRANSFORMER MANHOLE: 5706 (Continued) **1016960251**

Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	300
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

O159 **CON EDISON** **NY MANIFEST** **S119075420**
East **COURT ST & MARTINE AVE** **N/A**
< 1/8 **WHITE PLAINS, NY 10601**
0.116 mi.
613 ft. **Site 19 of 26 in cluster O**

Relative: **Higher**

Actual: **220 ft.**

NY MANIFEST:

EPA ID:	NYP004784880
Country:	USA
Name:	Con Edison
Address:	COURT ST & MARTINE AVE
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10601
Zip 4:	Not reported
Location Address 1:	E SIDE COURT ST & MARTINE
Location Address 2:	MH 12496
Location City,State,Zip:	WHITE PLAINS, NY 10601
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Edison
Mailing Contact:	Dennis Huacon
Mailing Address 1:	4 IRVING PL 15TH FL
Mailing Address 2:	Not reported
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	2124603770

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	05/20/2015
Trans1 Recv Date:	05/20/2015

CON EDISON (Continued) **S119075420**

Trans2 Recv Date:	Not reported
TSD Site Recv Date:	05/26/2015
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004784880
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	014467523JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	Y
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	1834
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

O160 **CON EDISON** **NJ MANIFEST** **S120671981**
East **COURT ST & MARTINE AVE** **N/A**
< 1/8 **WHITE PLAINS, NY 10601**
0.116 mi.
613 ft. **Site 20 of 26 in cluster O**

Relative: NJ MANIFEST:
Higher

Actual: EPA ID:	NYP004784880
220 ft. Name:	CON EDISON
Address:	COURT ST & MARTINE AVE
City,State,Zip:	WHITE PLAINS, NY 10601
County:	Not reported
Mailing Address:	IRVING PL 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Telephone:	Not reported
Emergency Telephone:	Not reported
Contact:	THOMAS TEELING

CON EDISON (Continued) **S120671981**

Comments:	Not reported
SIC Code:	Not reported
County:	NY119
Municipal:	Not reported
Previous EPAID:	Not reported
Generator Flag:	Not reported
Transporter Flag:	Not reported
TSDF Flag:	Not reported
Name Change:	Not reported
Date Change:	Not reported

Manifest Data:

EPA ID:	NYP004784880
Manifest Number:	014467523JJK
Date Shipped:	5/20/2015
TSDF EPA ID:	NJD002200046
Transporter EPA ID:	NYD006982359
Transporter 2 EPA ID:	Not reported
Transporter 3 EPA ID:	Not reported
Transporter 4 EPA ID:	Not reported
Transporter 5 EPA ID:	Not reported
Transporter 6 EPA ID:	Not reported
Transporter 7 EPA ID:	Not reported
Transporter 8 EPA ID:	Not reported
Transporter 9 EPA ID:	Not reported
Transporter 10 EPA ID:	Not reported
Date Trans1 Transported Waste:	Not reported
Date Trans2 Transported Waste:	Not reported
Date Trans3 Transported Waste:	Not reported
Date Trans4 Transported Waste:	Not reported
Date Trans5 Transported Waste:	Not reported
Date Trans6 Transported Waste:	Not reported
Date Trans7 Transported Waste:	Not reported
Date Trans8 Transported Waste:	Not reported
Date Trans9 Transported Waste:	Not reported
Date Trans10 Transported Waste:	Not reported
Date TSDF Received Waste:	Not reported
TSDF EPA Facility Name:	Not reported
QTY Units:	Not reported
Transporter SEQ ID:	Not reported
Transporter-1 Date:	Not reported
Waste SEQ ID:	Not reported
Waste Type Code 2:	Not reported
Waste Type Code 3:	Not reported
Waste Type Code 4:	Not reported
Waste Type Code 5:	Not reported
Waste Type Code 6:	Not reported
Date Accepted:	Not reported
Manifest Discrepancy Type:	Not reported
Data Entry Number:	Not reported
Was Load Rejected:	Not reported
Reason Load Was Rejected:	Not reported

O161 **CON EDISON** **NY MANIFEST** **S118463400**
East **MARTINE & COURT ST** **N/A**
< 1/8 **WHITE PLAINS, NY**
0.116 mi.
613 ft. **Site 21 of 26 in cluster O**

Relative:
Higher

Actual:
220 ft.

NY MANIFEST:

EPA ID:	NYP004850869
Country:	USA
Name:	Con Edison
Address:	MARTINE & COURT ST
Address 2:	TM 5706
City,State,Zip:	WHITE PLAINS, NY
Zip 4:	Not reported
Location Address 1:	MARTINE & COURT ST
Location Address 2:	TM 5706
Location City,State,Zip:	WHITE PLAINS, NY
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Edison
Mailing Contact:	Dennis Huacon
Mailing Address 1:	4 IRVING PL 15TH FL
Mailing Address 2:	Not reported
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	2124603770

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	10/09/2015
Trans1 Recv Date:	10/09/2015
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	10/14/2015
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004850869
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	013245137JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported

CON EDISON (Continued) **S118463400**

Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	100
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

O162 **CON EDISON** **NY MANIFEST** **S117738397**
East **MARTINE AVE & COURT ST** **N/A**
< 1/8 **WHITE PLAINS, NY 10801**
0.116 mi.
613 ft. **Site 22 of 26 in cluster O**

Relative: **Higher**

Actual: **220 ft.**

NY MANIFEST:

EPA ID:	NYP004714358
Country:	USA
Name:	Con Edison
Address:	MARTINE AVE & COURT ST
Address 2:	VS4250
City,State,Zip:	WHITE PLAINS, NY 10801
Zip 4:	Not reported
Location Address 1:	MARTINE AVE & COURT ST
Location Address 2:	VS4250
Location City,State,Zip:	WHITE PLAINS, NY 10801
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Edison
Mailing Contact:	Con Edison
Mailing Address 1:	4 IRVING PL
Mailing Address 2:	15TH FL
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	Not reported

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359

CON EDISON (Continued) **S117738397**

Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	01/13/2015
Trans1 Recv Date:	01/13/2015
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	01/19/2015
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004714358
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	012774710JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	50
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

O163 **THE MICHICALLIAN OFFICE** **NY LTANKS** **S100782193**
East **MARTINE AVE & COURT ST** **N/A**
< 1/8 **WHITE PLAINS, NY**
0.116 mi.
613 ft. **Site 23 of 26 in cluster O**

Relative: **Higher**
Actual: **220 ft.**

LTANKS:

Name:	THE MICHICALLIAN OFFICE
Address:	MARTINE AVE & COURT ST
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9310783 / 1993-11-18
Facility ID:	9310783
Site ID:	276042

THE MICHICALLIAN OFFICE (Continued) **S100782193**

Spill Date:	1993-11-16
Spill Cause:	Tank Failure
Spill Source:	Commercial/Industrial
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1993-12-06
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	1993-11-16
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1994-01-03
Spill Record Last Update:	1997-07-29
Spiller Name:	Not reported
Spiller Company:	W.C. DPW
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	224426
Latitude:	41.0311499
Longitude:	-73.7674469
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY 11/16/93 DEC ON SITE TO DETERMINE CONTAMINATION; 11/18/93 REMOVAL OF 77.98 TONS OF SOIL;
Remarks:	DISCOVERED OIL IN TANK PULL FAXED TO TODD GHIOSAY

All Materials:

Site ID:	276042
Operable Unit ID:	989528
Operable Unit:	01
Material ID:	389858
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	L
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

J164 **CON EDISON** **RCRA NonGen / NLR** **1019902675**
WSW **10 BANK ST & MARTINE AVE** **FINDS** **NYP004776522**
< 1/8 **WHITE PLAINS, NY 10606** **ECHO**
0.117 mi.
617 ft. **Site 3 of 4 in cluster J**

Relative: **Higher**

Actual: **201 ft.**

RCRA Listings:

Date Form Received by Agency:	20150430
Handler Name:	Con Edison
Handler Address:	Bank St & Martine Ave
Handler City,State,Zip:	WHITE PLAINS, NY 10606
EPA ID:	NYP004776522
Contact Name:	THOMAS TEELING
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	212-460-3770
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PL 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No

CON EDISON (Continued) **1019902675**

Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20160909
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20150430
Handler Name: CON EDISON	
Federal Waste Generator Description:	Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20150430
Handler Name: CON EDISON	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

List of NAICS Codes and Descriptions:

NAICS Codes:	No NAICS Codes Found

Facility Has Received Notices of Violations:

Violations:	No Violations Found

Evaluation Action Summary:

Evaluations:	No Evaluations Found

CON EDISON (Continued) **1019902675**

FINDS:
Registry ID: 110069691541

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:
The Resource Conservation and Recovery Act Information System (RCRAInfo) is EPA's comprehensive information system in support of the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. It tracks many types of information about generators, transporters, treaters, storers, and disposers of hazardous waste.

Click this hyperlink while viewing on your computer to access additional FINDS: detail in the EDR Site Report.

ECHO:
Envid: 1019902675
Registry ID: 110069691541

DFR URL:
Name: CON EDISON
Address: 10 BANK ST & MARTINE AVE
City,State,Zip: WHITE PLAINS, NY 10606

O165 **WEST HEALTH DEPT** **NY LTANKS** **S106703105**
ESE **148 MARTINE AVE** **N/A**
< 1/8 **YONKERS, NY**
0.117 mi.
619 ft. **Site 24 of 26 in cluster O**

Relative:
Higher

Actual:
225 ft.

LTANKS:

Name:	WEST HEALTH DEPT
Address:	148 MARTINE AVE
City,State,Zip:	YONKERS, NY
Spill Number/Closed Date:	8701223 / 2004-11-06
Facility ID:	8701223
Site ID:	126440
Spill Date:	1987-05-13
Spill Cause:	Tank Test Failure
Spill Source:	Institutional, Educational, Gov., Other
Spill Class:	C5
Cleanup Ceased:	Not reported
SWIS:	6018
Investigator:	WXWADSWO
Referred To:	Not reported
Reported to Dept:	1987-05-13
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1987-11-25
Spill Record Last Update:	2004-11-05
Spiller Name:	Not reported

WEST HEALTH DEPT (Continued) **S106703105**

Spiller Company:	TOM ZIMINSKY
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	109305
Latitude:	Not reported
Longitude:	Not reported
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was WADSWORTH
Remarks:	TANK TESTED. WILL HAVE TO PLACE MONTORING WELLS.

All TTF:

Facility ID:	8701223
Spill Number:	8701223
Spill Tank Test:	1530809
Site ID:	126440
Tank Number:	Not reported
Tank Size:	0
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	126440
Operable Unit ID:	907699
Operable Unit:	01
Material ID:	471174
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	L
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

J166 **MARITINE AVE** **NY Spills** **S129116193**
WSW **MARITINE AVE & BANK ST** **N/A**
< 1/8 **WHITE PLAINS, NY**
0.118 mi.
621 ft. **Site 4 of 4 in cluster J**

Relative:
Higher

Actual:
201 ft.

SPILLS:

Name:	MARITINE AVE
Address:	MARITINE AVE & BANK ST
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8607289 / 1989-11-28
Facility ID:	8607289
Facility Type:	ER
DER Facility ID:	240580
Site ID:	297340
DEC Region:	3
Spill Cause:	Unknown
Spill Class:	B3
SWIS:	6017
Spill Date:	1986-12-01
Investigator:	dxtraver
Referred To:	Not reported
Reported to Dept:	1987-03-02
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Private Dwelling
Spill Notifier:	Local Agency
Cleanup Ceased:	1989-11-28
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	1987-03-13
Spill Record Last Update:	2022-09-09
Spiller Name:	Not reported
Spiller Company:	UNKNOWN
Spiller Address:	Not reported
Spiller Company:	999
Contact Name:	Not reported
Latitude:	41.0304359
Longitude:	-73.7741490
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was TRAVER
Remarks:	SOIL SAMPLES SHOWED PETROLEUM CONTAMINATION

All Materials:

Site ID:	297340
Operable Unit ID:	903920
Operable Unit:	01
Material ID:	472804
Material Code:	0009
Material Name:	gasoline
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	G
Recovered:	Not reported
Resource Affected:	Soil
Oxygenate:	Not reported

N167 **CON ED** **NY Spills** **S117851796**
NW **9 NEW ST** **N/A**
< 1/8 **WHITE PLAINS, NY**
0.118 mi.
624 ft. **Site 5 of 18 in cluster N**

Relative:
Higher

Actual:
201 ft.

SPILLS:

Name:	CON ED
Address:	9 NEW ST
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	1500081 / 2015-04-03
Facility ID:	1500081
Facility Type:	ER
DER Facility ID:	461005
Site ID:	506215
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	C3
SWIS:	6017
Spill Date:	2015-04-03
Investigator:	VPMCCABE
Referred To:	Not reported
Reported to Dept:	2015-04-03
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Commercial Vehicle
Spill Notifier:	Responsible Party
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2015-04-03
Spill Record Last Update:	2015-04-03
Spiller Name:	ERT
Spiller Company:	CON ED
Spiller Address:	9 NEW ST
Spiller Company:	999
Contact Name:	ERT
Latitude:	Not reported
Longitude:	Not reported
DEC Memo:	4-3-15: V.Mc. call to ERT: Vender filling generator on site, spilled aprx. 10 gal. to concrete pad and blue stone. Clean up onging at this time. NFA.
Remarks:	loss to pavement and soil, c/u in progress

All Materials:

Site ID:	506215
Operable Unit ID:	1255544
Operable Unit:	01
Material ID:	2258304
Material Code:	0008
Material Name:	diesel
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	10.00
Units:	G
Recovered:	Not reported
Resource Affected:	Not reported

CON ED (Continued) **S117851796**

Oxygenate: Not reported

N168 **TRANSFORMER 7** **NY Spills** **S106013380**
NW **9 NEW ST - SUBSTATION** **N/A**
< 1/8 **WHITE PLAINS, NY**
0.118 mi.
624 ft. **Site 6 of 18 in cluster N**

Relative: **Higher**

Actual: **201 ft.**

SPILLS:

Name:	TRANSFORMER 7
Address:	9 NEW ST - SUBSTATION
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0300784 / 2003-04-25
Facility ID:	0300784
Facility Type:	ER
DER Facility ID:	187381
Site ID:	227017
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	C4
SWIS:	6017
Spill Date:	2003-04-22
Investigator:	jbodee
Referred To:	Not reported
Reported to Dept:	2003-04-22
CID:	195
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Responsible Party
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2003-04-22
Spill Record Last Update:	2003-04-25
Spiller Name:	Not reported
Spiller Company:	CON EDISON
Spiller Address:	4 IRVING PLACE
Spiller Company:	001
Contact Name:	LARRY COSTA
Latitude:	41.0400799
Longitude:	-73.7983400
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was O'DEE
Remarks:	NON PCP OIL - 1/2 OUNCE - LEAKED FROM RADITOR FIN ONTO BLUE STONE - CLEAN UP PENDING REPAIR - CON ED SPILL 148026. ALSO 1 OUNCE OF FLUID SPILLED FROM DRAIN PLUG OF ANOTHER FIN, ALSO ON BLUE STONE.

All Materials:

Site ID:	227017
Operable Unit ID:	868920
Operable Unit:	01
Material ID:	508855
Material Code:	0541A
Material Name:	dielectric fluid

TRANSFORMER 7 (Continued) **S106013380**

Case No.:	Not reported
Material FA:	Petroleum
Quantity:	1.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

N169 **WHITE PLAINS MGP SITE** **EDR MGP** **1008408071**
NW **9 NEW STREET AND 12 WATER STREET** **N/A**
< 1/8 **WHITE PLAINS, NY 10601**
0.118 mi.
624 ft. **Site 7 of 18 in cluster N**

Relative: EDR MGP:
Higher
Actual: No additional information available
201 ft.

N170 **WHITE PLAINS SUBSTATION** **NY Spills** **S102240780**
NW **9 NEW ST** **NY SPDES** **N/A**
< 1/8 **WHITE PLAINS, NY 10601**
0.118 mi.
624 ft. **Site 8 of 18 in cluster N**

Relative: SPILLS:
Higher

Name:	TRANSFORMER #2
Address:	9 NEW STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0408249 / 2004-10-28
Facility ID:	0408249
Facility Type:	ER
DER Facility ID:	95370
Site ID:	332929
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	C4
SWIS:	6017
Spill Date:	2004-10-26
Investigator:	JBODee
Referred To:	Not reported
Reported to Dept:	2004-10-26
CID:	407
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Responsible Party
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2004-10-26
Spill Record Last Update:	2004-12-22
Spiller Name:	ERT DESK

WHITE PLAINS SUBSTATION (Continued) **S102240780**

Spiller Company: Con Ed
Spiller Address: Not reported
Spiller Company: 001
Contact Name: ERT DESK
Latitude: 41.0338517
Longitude: -73.7719186
DEC Memo: 26-OCT-2004 13:24:00 Start (Incident First Discovered): Transformer # 2 ~ 1 Ounce of Transf. oil on soil Brief Description: 155977 Spill - Dielectric, Transformer Incident ID: Incident Type: 26-OCT-2004 13:34:00 First Reported: White Plains S/S 9 New St. White Plains, NY. Location: No. of Injuries: 26-OCT-2004 14:14:00 First Reported to CIG: Resolved (administrative closure): Cleanup Completed/Stopped: Immediate Abatement/Containment Actions: N Preliminary - Cleanup Pending Report Type: Incident Status: 4 Rev. #: 511 Theo Fremd White Plains Substation Substation Operations Administrative Site: Responsible Operation: 1 Amount % Contnd % Cleaned % Recycld Soil/Bluestone Environmental Medium Impacted OZ UOM OIL AND GREASE Substance, Material Property Duration Hours (discovery to closure): Any Outside Impact: 26-Oct. 2004 13:45 hrs. Central S/S Sr. S/S Operator M. Gonzalez # 81900 reported that while doing an inspection at the station she discovered ~ 1 ounce of transf. oil from a guage on transf. # 2 to bluestone. There was/is no smoke, fire or injuries involved. There was/is no sewers, waterways or private property affected. M. Gonzalez # 81900 wrapped the affected guage with pads to prevent further leakage. This incident will be updated by Central S/S EH&S Sr. Specialist C. Little # 96080. R. Browne # 21646 ========== Detailed Description:
Remarks: Amount: 1 Ounce. Transformer involved, spilled on bluestone.

All Materials:
Site ID: 332929
Operable Unit ID: 1095129
Operable Unit: 01
Material ID: 575253
Material Code: 0541A
Material Name: dielectric fluid
Case No.: Not reported
Material FA: Petroleum
Quantity: .00
Units: G
Recovered: .00
Resource Affected: Soil
Oxygenate: Not reported

Name: VEHICLE # 60775
Address: 9 NEW STREET
City,State,Zip: WHITE PLAINS, NY
Spill Number/Closed Date: 0511276 / 2005-12-28

WHITE PLAINS SUBSTATION (Continued) **S102240780**

Facility ID:	0511276
Facility Type:	ER
DER Facility ID:	95370
Site ID:	357395
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	C4
SWIS:	6017
Spill Date:	2005-12-28
Investigator:	VPMCCABE
Referred To:	Not reported
Reported to Dept:	2005-12-28
CID:	408
Water Affected:	Not reported
Spill Source:	Commercial Vehicle
Spill Notifier:	Responsible Party
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	Not reported
UST Trust:	Not reported
Remediation Phase:	0
Date Entered In Computer:	2005-12-28
Spill Record Last Update:	2006-01-06
Spiller Name:	Not reported
Spiller Company:	CON EDISON 162367
Spiller Address:	4 IRVING PLACE
Spiller Company:	001
Contact Name:	ERT DESK’
Latitude:	41.0317400
Longitude:	-73.7675900
DEC Memo:	- NFA -
Remarks:	FROM A PULLING CABLE TRUCK. HAS BEEN CONTAINED AND CLEAN UP IS IN PROGRESS. PRODUCT IS ON ASPHALT AND SOIL. CON ED # 162367. NO TO 5 QUESTIONS

All Materials:

Site ID:	357395
Operable Unit ID:	1114669
Operable Unit:	01
Material ID:	2104737
Material Code:	0010
Material Name:	hydraulic oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	17.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	CON ED
Address:	9 NEW STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0511486 / 2006-01-04
Facility ID:	0511486
Facility Type:	ER

WHITE PLAINS SUBSTATION (Continued) **S102240780**

DER Facility ID:	95370
Site ID:	357650
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	C4
SWIS:	6017
Spill Date:	2006-01-04
Investigator:	JBODee
Referred To:	Not reported
Reported to Dept:	2006-01-04
CID:	408
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Responsible Party
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	Not reported
UST Trust:	Not reported
Remediation Phase:	0
Date Entered In Computer:	2006-01-04
Spill Record Last Update:	2006-01-09
Spiller Name:	ERT DESK
Spiller Company:	CON EDISON
Spiller Address:	4 IRVING PLACE
Spiller Company:	999
Contact Name:	ERT DESK'
Latitude:	41.0338517
Longitude:	-73.7719186
DEC Memo:	AS STATED, WAITING FOR CLEAN UP CREW.
Remarks:	16 OUNZES. HAS NOT BEEN CLEANED UP, PENDING AVAILABLE CREW. UNKNOWN IS PCB OR NOT, PENDING LAB RESULTS. CON ED # 162420

All Materials:

Site ID:	357650
Operable Unit ID:	1114926
Operable Unit:	01
Material ID:	2104983
Material Code:	0541A
Material Name:	dielectric fluid
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	WHITE PLAINS SUB
Address:	9 NEW STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0501556 / 2005-05-10
Facility ID:	0501556
Facility Type:	ER
DER Facility ID:	95370
Site ID:	345728
DEC Region:	3

WHITE PLAINS SUBSTATION (Continued) **S102240780**

Spill Cause:	Equipment Failure
Spill Class:	C4
SWIS:	6017
Spill Date:	2005-05-09
Investigator:	TDGHIOSA
Referred To:	Not reported
Reported to Dept:	2005-05-09
CID:	444
Water Affected:	Not reported
Spill Source:	Commercial Vehicle
Spill Notifier:	Responsible Party
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2005-05-09
Spill Record Last Update:	2005-05-10
Spiller Name:	Not reported
Spiller Company:	MANLIFT
Spiller Address:	Not reported
Spiller Company:	001
Contact Name:	ERT DESK
Latitude:	41.0338517
Longitude:	-73.7719186
DEC Memo:	Environmental Detailed Incident Report E2MIS 09-MAY-2005 15:07:51 Page 1 of 3 09-MAY-2005 09:45:00 Start (Incident First Discovered): Rental Manlift- 1qt of hydraulic fluid from leaking piston on soil and bluestone Brief Description: 158467 Spill - Hydraulic Fluid Incident ID: Incident Type: 09-MAY-2005 09:50:00 First Reported: Rental Manlift-9 New Street, White Plains, NY Location: No. of Injuries: 09-MAY-2005 10:12:00 First Reported to CIG: Resolved (administrative closure): 09-MAY-2005 10:22:00 Cleanup Completed/Stopped: Immediate Abatement/Containment Actions: N Preliminary - Cleanup Complete Report Type: Incident Status: 6 Rev. #: 511 Theo Fremd White Plains Substation Substation Operations Administrative Site: Responsible Operation: 1 Amount Soil/Bluestone/Grass Environmental Medium Impacted QT UOM HYDRAULIC FLUID Substance, Material Property Duration Hours (discovery to closure): Any Outside Impact: 09-May-2005 10:04 Chief Const. Insp P. Luzzi 64900 reported while inspecting the station discovered 1 quart of hydraulic fluid leaked on soil and bluestone from a piston of a Rental Manlift in the station. No smoke or fire is/was involved. No sewers, waterways, or private property affected. The spill is contained, cleanup is in progress, and the rental company is being contacted for repair of the equipment. D. Rohrer 12788 ==========

WHITE PLAINS SUBSTATION (Continued) **S102240780**

09-May-2005 10:26 Chief Const. Insp P. Luzzi 64900 reported that Snr Substa Oper R. Detz 19835 and
himself completed cleanup of the spill removing the affected area of soil and bluestone generating
3/4 of a 55 gallon drum of non-hazardous waste. The waste is being stored in the proper temporary
storage area and the manlift has engineering controls in place and the repair is pending the rental
company. D. Rohrer 12788
========== Detailed
Description: Environmental Detailed Incident Report E2MIS 09-MAY-2005 15:07:51 Page 2 of 3
Correction Actions Due Date Completion Date Emp Comment Assigned to (last name) Date/Time Comment
Commitment Made Date/Time Completion Due Date Completion Date Comitment Description Regulatory Body
Involved Items Item Type Finder Control Center Operator Shift Supervisor Email Notification CIG
Operator Called Cleanup Person Cleanup Person Involved Roles E E E E E E E (347) 203-2707 (914)
925-6219 (914) 925-6221 (914) 422-8173 (212) 580-6763 (347) 203-2707 (914) 949-3356 Emp Phone #
LUZZI ROHRER BULAN LITTLE MCGUIRE LUZZI DETZ Last Name Equipment - Vehicle / Truck / Lift Causes N
P Rental Equipment which leaked Comments Equipment Name Tag # Opn CE Environmental Affairs ERT CE
VP Responsible Operation New York, State Department of Environmental Conservation Westchester
County, Department of Health Notifications 09-MAY-2005 10:15:00 09-MAY-2005 10:25:00 09-MAY-2005
10:18:00 09-MAY-2005 10:20:00 Date/Time 05-01556 Agency Asgnd. # MCGUIRE MCGUIRE MCGUIRE MCGUIRE
Employee Reporting (last name) 05/09/2005 Effective date ERT Initial Incident Review Comments
Description A.Delgado Expire date Event Property Test Results Environmental Detailed Incident
Report E2MIS 09-MAY-2005 15:07:51 Page 3 of 3 Sample Id Parameter Type Parameter Description
Numeric Result Unit Collect Date Result Date Comments

Remarks: 1 QUART OF OIL: MANLIFT LEAKED, CONTAINED, ON SOIL AND BLU STONE: NO TO 5 QUESTIONS: CONED # 158467

All Materials:

Site ID:	345728
Operable Unit ID:	1103445
Operable Unit:	01
Material ID:	583655
Material Code:	0010
Material Name:	hydraulic oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

WHITE PLAINS SUBSTATION (Continued) **S102240780**

Name:	WHITE PLAINS SUB
Address:	9 NEW STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0607603 / 2006-10-05
Facility ID:	0607603
Facility Type:	ER
DER Facility ID:	95370
Site ID:	371373
DEC Region:	3
Spill Cause:	Other
Spill Class:	C4
SWIS:	6017
Spill Date:	2006-10-04
Investigator:	JBODee
Referred To:	Not reported
Reported to Dept:	2006-10-04
CID:	444
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Responsible Party
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2006-10-04
Spill Record Last Update:	2006-10-13
Spiller Name:	ERTS
Spiller Company:	WHITE PLAINS SUB
Spiller Address:	9 NEW STREET
Spiller Company:	001
Contact Name:	ERTS
Latitude:	41.0338517
Longitude:	-73.7719186
DEC Memo:	Not reported
Remarks:	NO T O 4 QUESTIONS: ON SOIL: CREW ENROUTE TO CLEAN UP AND CONED # 202761

All Materials:

Site ID:	371373
Operable Unit ID:	1129140
Operable Unit:	01
Material ID:	2118804
Material Code:	0020A
Material Name:	transformer oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	WHITE PLAINS SUB STATION TRANSFORMER #2
Address:	9 NEW STREET
City,State,Zip:	WHITE PLAINS, NY

WHITE PLAINS SUBSTATION (Continued) **S102240780**

Spill Number/Closed Date:	0905919 / 2010-08-27
Facility ID:	0905919
Facility Type:	ER
DER Facility ID:	95370
Site ID:	418214
DEC Region:	3
Spill Cause:	Unknown
Spill Class:	C4
SWIS:	6017
Spill Date:	2009-08-20
Investigator:	TDGHIOSA
Referred To:	Not reported
Reported to Dept:	2009-08-20
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Responsible Party
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2009-08-20
Spill Record Last Update:	2010-08-27
Spiller Name:	Not reported
Spiller Company:	CON EDISON
Spiller Address:	Not reported
Spiller Company:	999
Contact Name:	NIEL
Latitude:	41.0338517
Longitude:	-73.7719186
DEC Memo:	8/21/09 - 1 pint of unknown oil was found staining the blue stone from the transformer. Transformer located within substation yard. KAB 08/27/2010 See eDocs for Con Ed report detailing cleanup and closure DMP
Remarks:	1652 The caller advised dispatch no water ways have been affected. The clean up is pending. Unknown oil and cause of the spill.

All Materials:

Site ID:	418214
Operable Unit ID:	1174400
Operable Unit:	01
Material ID:	2166733
Material Code:	0066A
Material Name:	unknown petroleum
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported
Resource Affected:	Not reported
Oxygenate:	Not reported

Name:	WHITE PLAINS SUB STATION TRANSFORMER #3
Address:	9 NEW STREET

WHITE PLAINS SUBSTATION (Continued) **S102240780**

City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0905921 / 2010-08-27
Facility ID:	0905921
Facility Type:	ER
DER Facility ID:	95370
Site ID:	418216
DEC Region:	3
Spill Cause:	Unknown
Spill Class:	C4
SWIS:	6017
Spill Date:	2009-08-20
Investigator:	TDGHIOSA
Referred To:	Not reported
Reported to Dept:	2009-08-20
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Responsible Party
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2009-08-20
Spill Record Last Update:	2010-08-27
Spiller Name:	Not reported
Spiller Company:	NATIONAL GRID
Spiller Address:	Not reported
Spiller Company:	999
Contact Name:	NIEL
Latitude:	41.0338517
Longitude:	-73.7719186
DEC Memo:	8/21/09 - 1 pint of unknown oil was found staining the blue stone from the transformer. Transformer located within substation yard. KAB 08/27/2010 See eDocs for Con Ed report detailing cleanup and closure DMP
Remarks:	1659 The caller advised dispatch the spill amount is two pints of unknown oil. Unknown cause. No water ways affected. The spill is contained.

All Materials:

Site ID:	418216
Operable Unit ID:	1174402
Operable Unit:	01
Material ID:	2166735
Material Code:	0066A
Material Name:	unknown petroleum
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported
Resource Affected:	Not reported
Oxygenate:	Not reported

WHITE PLAINS SUBSTATION (Continued) **S102240780**

Name:	WHITE PLAINS SUBSTATION
Address:	9 NEW STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0012709 / 2001-02-28
Facility ID:	0012709
Facility Type:	ER
DER Facility ID:	95370
Site ID:	108530
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	C4
SWIS:	6017
Spill Date:	2001-02-28
Investigator:	rdbendel
Referred To:	Not reported
Reported to Dept:	2001-02-28
CID:	282
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Responsible Party
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2001-02-28
Spill Record Last Update:	2001-03-19
Spiller Name:	CALLER
Spiller Company:	CON ED
Spiller Address:	4 IRVING PLACE
Spiller Company:	001
Contact Name:	SEAN MCKEEVER
Latitude:	41.0400799
Longitude:	-73.7983400
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was BENDELL
Remarks:	CAPACITOR ON THE FEEDER 8W50 FAILED THE SPILL WILL BE CLEANED UP.

All Materials:

Site ID:	108530
Operable Unit ID:	834674
Operable Unit:	01
Material ID:	542970
Material Code:	0541A
Material Name:	dielectric fluid
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	2.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	WHITE PLAINS SUBSTATION
Address:	9 NEW STREET
City,State,Zip:	WHITE PLAINS, NY

WHITE PLAINS SUBSTATION (Continued) **S102240780**

Spill Number/Closed Date:	0305783 / 2003-08-30
Facility ID:	0305783
Facility Type:	ER
DER Facility ID:	95370
Site ID:	108531
DEC Region:	3
Spill Cause:	Unknown
Spill Class:	C4
SWIS:	6017
Spill Date:	2003-08-30
Investigator:	jbodee
Referred To:	Not reported
Reported to Dept:	2003-08-30
CID:	204
Water Affected:	Not reported
Spill Source:	Unknown
Spill Notifier:	Local Agency
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2003-08-30
Spill Record Last Update:	2003-09-04
Spiller Name:	Not reported
Spiller Company:	UNKNOWN
Spiller Address:	Not reported
Spiller Company:	999
Contact Name:	PAUL DIDONATO
Latitude:	41.0400799
Longitude:	-73.7983400
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was O'DEE
Remarks:	1 OUNCE ON CONCRETE

All Materials:

Site ID:	108531
Operable Unit ID:	874232
Operable Unit:	01
Material ID:	503023
Material Code:	0066A
Material Name:	unknown petroleum
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	1.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	CON ED SUBSTAION
Address:	9 NEW STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0402585 / 2004-06-09
Facility ID:	0402585
Facility Type:	ER

WHITE PLAINS SUBSTATION (Continued) **S102240780**

DER Facility ID:	95370
Site ID:	108532
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	C4
SWIS:	6017
Spill Date:	2004-06-09
Investigator:	mbmastro
Referred To:	Not reported
Reported to Dept:	2004-06-09
CID:	444
Water Affected:	Not reported
Spill Source:	Institutional, Educational, Gov., Other
Spill Notifier:	Other
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2004-06-09
Spill Record Last Update:	2004-06-10
Spiller Name:	ERT DESK
Spiller Company:	CON ED SUBSTAION
Spiller Address:	9 NEW STREET
Spiller Company:	001
Contact Name:	ERT DESK
Latitude:	41.0400799
Longitude:	-73.7983400
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was MASTRO
Remarks:	CONSTRUCTION CO. PULLING OUT CABLE, RIPPED CONCRETE AND WENT TO BLUE STONE, NO SMOKE FIRE OR WATERWAYS: IT WAS SEALED SO THEY SAY IT WAS EQUIPMENT FAILURE:

All Materials:

Site ID:	108532
Operable Unit ID:	886285
Operable Unit:	01
Material ID:	490200
Material Code:	0017A
Material Name:	PCB oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	WHITE PLAINS SUBSTATION
Address:	9 NEW STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0402605 / 2004-06-09
Facility ID:	0402605
Facility Type:	ER
DER Facility ID:	95370

WHITE PLAINS SUBSTATION (Continued) **S102240780**

Site ID:	108533
DEC Region:	3
Spill Cause:	Unknown
Spill Class:	C4
SWIS:	6017
Spill Date:	2004-06-09
Investigator:	mbmastro
Referred To:	Not reported
Reported to Dept:	2004-06-09
CID:	403
Water Affected:	Not reported
Spill Source:	Commercial Vehicle
Spill Notifier:	Other
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2004-06-09
Spill Record Last Update:	2004-06-10
Spiller Name:	ERT DESK
Spiller Company:	WHITE PLAINS SUBSTATION
Spiller Address:	9 NEW STREET
Spiller Company:	001
Contact Name:	ERT DESK
Latitude:	41.0400799
Longitude:	-73.7983400
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was MASTRO
Remarks:	6 ounces of hydraulic oil was spilled from a contractors truck.spill has been cleaned up,spilled onto bluestone and soil.no smoke,fire,sewers,or waterways affected

All Materials:

Site ID:	108533
Operable Unit ID:	886294
Operable Unit:	01
Material ID:	490222
Material Code:	0010
Material Name:	hydraulic oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Click this hyperlink while viewing on your computer to access
51 additional NY SPILL: record(s) in the EDR Site Report.

SPDES:

Name:	White Plains Substation
Address:	9 NEW ST

WHITE PLAINS SUBSTATION (Continued) **S102240780**

City,State,Zip:	WHITE PLAINS, NY 10601
Permit Number:	NY0265039
State-Region:	NY-2
Expiration Date:	Not reported
Current Major Minor Status:	Not reported
Primary Facility SIC Code:	Not reported
State Water Body Name:	Not reported
Limit Set Status Flag:	Not reported
Total Actual Average Flow(MGD):	Not reported
Total App Design Flow(MGD):	0.0019
UDF1:	Not reported
Lat/Long:	41.033843936 / 73.772296712
DMR Cognizant Official:	JOSEPH SUSCO
UDF2:	Not reported
UDF3:	Not reported
FIPS County Code:	Not reported
Non-Gov Permit Affiliation Type Desc:	Private
Non-Gov Permit Org Formal Name:	CONSOLIDATED EDISON COMPANY OF NEW YORK, INC.
Non-Gov Permit Street Address:	4 IRVING PL
Non-Gov Permit Supplemental Location:	Not reported
Non-Gov Permit City:	NEW YORK
Non-Gov Permit State Code:	NY
Non-Gov Permit Zip Code:	10003
Non-Gov Facility Affiliation Type Desc:	Not reported
Non-Gov Facility Org Formal Name:	Not reported
Non-Gov Facility Street Address:	Not reported
Non-Gov Facility Supplemental Location:	Not reported
Non-Gov Facility City:	Not reported
Non-Gov Facility State Code:	Not reported
Non-Gov Facility Zip Code:	Not reported
State Water Body:	Not reported
Region Permit Processed:	Not reported
Dow Discharge Class Code:	Not reported
SPDES Class Description:	Not reported
Affiliation Type Description:	Not reported
Name:	Not reported
Contacts Title:	Not reported
Contacts Email:	Not reported
NOI Submission Date:	Not reported
Facility Type:	Not reported

N171 **WHITE PLAINS SUBSTATION** **RCRA-SQG** **1001113337**
NW **9 NEW STREET** **E MANIFEST** **NYR000023275**
< 1/8 **WHITE PLAINS, NY 10601**
0.118 mi.
624 ft. **Site 9 of 18 in cluster N**

Relative: **Higher**
Actual: **201 ft.**

RCRA Listings:

Date Form Received by Agency:	20070101
Handler Name:	Con Edison - White Plains Substation
Handler Address:	New St
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYR000023275
Contact Name:	FRANKLIN MURRAY
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	212-460-2808
Contact Fax:	Not reported

WHITE PLAINS SUBSTATION (Continued) **1001113337**

Contact Email:	MURRAYFR@CONED.COM
Contact Title:	Not reported
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Small Quantity Generator
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Handler Activities
State District Owner:	Ny
State District:	NYSDEC R3
Mailing Address:	IRVING PLACE
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Consolidated Edison Company Of Ny, Inc.
Owner Type:	Private
Operator Name:	Consolidated Edison Company Of Ny, Inc.
Operator Type:	Private
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20230511
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

WHITE PLAINS SUBSTATION (Continued) **1001113337**

Biennial: List of Years
Year: 2005

Click Here for Biennial Reporting System Data:
Year: 2003

Click Here for Biennial Reporting System Data:
Year: 2001

Click Here for Biennial Reporting System Data:

Hazardous Waste Summary:
Waste Code: D001
Waste Description: Ignitable Waste

Waste Code: D002
Waste Description: Corrosive Waste

Waste Code: D006
Waste Description: Cadmium

Waste Code: D007
Waste Description: Chromium

Waste Code: D008
Waste Description: Lead

Waste Code: F003
Waste Description: The Following Spent Nonhalogenated Solvents: Xylene, Acetone, Ethyl Acetate, Ethyl Benzene, Ethyl Ether, Methyl Isobutyl Ketone, N-Butyl Alcohol, Cyclohexanone, And Methanol; All Spent Solvent Mixtures/Blends Containing, Before Use, Only The Above Spent Nonhalogenated Solvents; And All Spent Solvent Mixtures/Blends Containing, Before Use, One Or More Of The Above Nonhalogenated Solvents, And A Total Of Ten Percent Or More (By Volume) Of One Or More Of Those Solvents Listed In F001, F002, F004, And F005; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent Mixtures.

Waste Code: X002
Waste Description: Not Defined

Handler - Owner Operator:
Owner/Operator Indicator: Owner
Owner/Operator Name: CONSOLIDATED EDISON COMPANY OF NY, INC.
Legal Status: Private
Date Became Current: 20020101
Date Ended Current: Not reported
Owner/Operator Address: 4 IRVING PLACE
Owner/Operator City,State,Zip: NEW YORK, NY 10003
Owner/Operator Telephone: Not reported
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Operator

WHITE PLAINS SUBSTATION (Continued) **1001113337**

Owner/Operator Name: CONSOLIDATED EDISON COMPANY OF NY, INC.
Legal Status: Private
Date Became Current: 20020101
Date Ended Current: Not reported
Owner/Operator Address: 4 IRVING PLACE
Owner/Operator City,State,Zip: NEW YORK, NY 10003
Owner/Operator Telephone: Not reported
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Operator
Owner/Operator Name: CONSOLIDATED EDISON COMPANY OF NY, INC.
Legal Status: Private
Date Became Current: 20020101
Date Ended Current: Not reported
Owner/Operator Address: 4 IRVING PLACE
Owner/Operator City,State,Zip: NEW YORK, NY 10003
Owner/Operator Telephone: Not reported
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Operator
Owner/Operator Name: CONSOLIDATED EDISON COMPANY OF NY, INC.
Legal Status: Private
Date Became Current: 19250101
Date Ended Current: Not reported
Owner/Operator Address: 4 IRVING PLACE
Owner/Operator City,State,Zip: NEW YORK, NY 10003
Owner/Operator Telephone: Not reported
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Owner
Owner/Operator Name: CONSOLIDATED EDISON COMPANY OF NY, INC.
Legal Status: Private
Date Became Current: 19250101
Date Ended Current: Not reported
Owner/Operator Address: 4 IRVING PLACE
Owner/Operator City,State,Zip: NEW YORK, NY 10003
Owner/Operator Telephone: Not reported
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Owner
Owner/Operator Name: CONSOLIDATED EDISON CO OF NEW YORK INC
Legal Status: Private
Date Became Current: Not reported
Date Ended Current: Not reported
Owner/Operator Address: 4 IRVING PL ROOM 306S
Owner/Operator City,State,Zip: NEW YORK, NY 10003
Owner/Operator Telephone: 212-460-3968
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported

WHITE PLAINS SUBSTATION (Continued) **1001113337**

Owner/Operator Email: Not reported

Owner/Operator Indicator: Owner
Owner/Operator Name: CONSOLIDATED EDISON COMPANY OF NY, INC.
Legal Status: Private
Date Became Current: 19250101
Date Ended Current: Not reported
Owner/Operator Address: 4 IRVING PLACE
Owner/Operator City,State,Zip: NEW YORK, NY 10003
Owner/Operator Telephone: Not reported
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Historic Generators:
Receive Date: 19990714
Handler Name: CON EDISON - WHITE PLAINS SUBSTATION
Federal Waste Generator Description: Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20060220
Handler Name: CON EDISON - WHITE PLAINS SUBSTATION
Federal Waste Generator Description: Small Quantity Generator
State District Owner: Not reported
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20070101
Handler Name: CON EDISON - WHITE PLAINS SUBSTATION
Federal Waste Generator Description: Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: Not reported
Recognized Trader Exporter: Not reported
Spent Lead Acid Battery Importer: Not reported
Spent Lead Acid Battery Exporter: Not reported
Current Record: Yes
Non Storage Recycler Activity: No
Electronic Manifest Broker: No

Receive Date: 19960502
Handler Name: CON EDISON - WHITE PLAINS SUBSTATION
Federal Waste Generator Description: Large Quantity Generator

WHITE PLAINS SUBSTATION (Continued) **1001113337**

State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20020531
Handler Name: CON EDISION - WHITE PLAINS SUBSTATION
Federal Waste Generator Description: Large Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20040225
Handler Name: CON EDISON - WHITE PLAINS SUBSTATION
Federal Waste Generator Description: Large Quantity Generator
State District Owner: Not reported
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20060221
Handler Name: CON EDISON - WHITE PLAINS SUBSTATION
Federal Waste Generator Description: Large Quantity Generator
State District Owner: Not reported
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Code: 221122
NAICS Description: Electric Power Distribution

Facility Has Received Notices of Violations:
Violations: No Violations Found

WHITE PLAINS SUBSTATION (Continued) **1001113337**

Evaluation Action Summary:
Evaluations: No Evaluations Found

E MANIFEST:

Manifest Tracking Number:	012340997FLE
Last Updated Date:	20210924
Shipped Date:	20210910
Received Date:	20210913
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	NYD000706234
Generator Name:	Consolidated Edison-Deliveries
Generator Location Street Number:	Not reported
Generator Location Street 1:	31-01 20TH AVENUE
Generator Location Street 2:	Not reported
Generator Location City:	LONG ISLAND CITY
Generator Location State:	NY
Generator Location Zip:	11105
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	31-01 20th Avenue
Generator Mail Street 2:	Not reported
Generator Mail City:	Long Island City
Generator Mail Zip:	11105
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	NYD077444263
Designated Facility Name:	Triumvirate Environmental (Nyc), Llc
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	42-14 19th Avenue
Designated Facility Mail City:	Astoria
Designated Facility Mail Zip:	11105
Designated Facility Mail State:	NY
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	42-14 19th Avenue
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	Astoria
Designated Facility Location Zip:	11105
Designated Facility Location State:	NY
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Manifest Tracking Number:	012341010FLE
Last Updated Date:	20221004
Shipped Date:	20220915
Received Date:	20220916
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	NYD000706234
Generator Name:	Consolidated Edison-Deliveries
Generator Location Street Number:	Not reported
Generator Location Street 1:	31-01 20TH AVENUE

WHITE PLAINS SUBSTATION (Continued) **1001113337**

Generator Location Street 2:	Not reported
Generator Location City:	LONG ISLAND CITY
Generator Location State:	NY
Generator Location Zip:	11105
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	31-01 20th Avenue
Generator Mail Street 2:	Not reported
Generator Mail City:	Long Island City
Generator Mail Zip:	11105
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	NYD077444263
Designated Facility Name:	Triumvirate Environmental (Nyc), Llc
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	42-14 19th Avenue
Designated Facility Mail City:	Astoria
Designated Facility Mail Zip:	11105
Designated Facility Mail State:	NY
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	42-14 19th Avenue
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	Astoria
Designated Facility Location Zip:	11105
Designated Facility Location State:	NY
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Manifest Tracking Number:	012341018FLE
Last Updated Date:	20221116
Shipped Date:	20221021
Received Date:	20221024
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	NYD000706234
Generator Name:	Consolidated Edison-Deliveries
Generator Location Street Number:	Not reported
Generator Location Street 1:	31-01 20TH AVENUE
Generator Location Street 2:	Not reported
Generator Location City:	LONG ISLAND CITY
Generator Location State:	NY
Generator Location Zip:	11105
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	31-01 20th Avenue
Generator Mail Street 2:	Not reported
Generator Mail City:	Long Island City
Generator Mail Zip:	11105
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	NYD077444263
Designated Facility Name:	Triumvirate Environmental (Nyc), Llc
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	42-14 19th Avenue
Designated Facility Mail City:	Astoria

WHITE PLAINS SUBSTATION (Continued) **1001113337**

Designated Facility Mail Zip:	11105
Designated Facility Mail State:	NY
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	42-14 19th Avenue
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	Astoria
Designated Facility Location Zip:	11105
Designated Facility Location State:	NY
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Manifest Tracking Number:	012341043FLE
Last Updated Date:	20221214
Shipped Date:	20221128
Received Date:	20221129
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	NYD000706234
Generator Name:	Consolidated Edison-Deliveries
Generator Location Street Number:	Not reported
Generator Location Street 1:	31-01 20TH AVENUE
Generator Location Street 2:	Not reported
Generator Location City:	LONG ISLAND CITY
Generator Location State:	NY
Generator Location Zip:	11105
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	31-01 20th Avenue
Generator Mail Street 2:	Not reported
Generator Mail City:	Long Island City
Generator Mail Zip:	11105
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	NYD077444263
Designated Facility Name:	Triumvirate Environmental (Nyc), Llc
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	42-14 19th Avenue
Designated Facility Mail City:	Astoria
Designated Facility Mail Zip:	11105
Designated Facility Mail State:	NY
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	42-14 19th Avenue
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	Astoria
Designated Facility Location Zip:	11105
Designated Facility Location State:	NY
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Manifest Tracking Number:	012341053FLE
Last Updated Date:	20230113
Shipped Date:	20221221
Received Date:	20221222
Manifest Status:	Signed

WHITE PLAINS SUBSTATION (Continued) **1001113337**

Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	NYD000706234
Generator Name:	Consolidated Edison-Deliveries
Generator Location Street Number:	Not reported
Generator Location Street 1:	31-01 20TH AVENUE
Generator Location Street 2:	Not reported
Generator Location City:	LONG ISLAND CITY
Generator Location State:	NY
Generator Location Zip:	11105
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	31-01 20th Avenue
Generator Mail Street 2:	Not reported
Generator Mail City:	Long Island City
Generator Mail Zip:	11105
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	NYD077444263
Designated Facility Name:	Triumvirate Environmental (Nyc), Llc
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	42-14 19th Avenue
Designated Facility Mail City:	Astoria
Designated Facility Mail Zip:	11105
Designated Facility Mail State:	NY
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	42-14 19th Avenue
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	Astoria
Designated Facility Location Zip:	11105
Designated Facility Location State:	NY
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Manifest Tracking Number:	012341064FLE
Last Updated Date:	20230124
Shipped Date:	20230103
Received Date:	20230105
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	NYD00706234
Generator Name:	Consolidated Edison-Deliveries
Generator Location Street Number:	Not reported
Generator Location Street 1:	31-01 20TH AVENUE
Generator Location Street 2:	Not reported
Generator Location City:	LONG ISLAND CITY
Generator Location State:	NY
Generator Location Zip:	11105
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	31-01 20th Avenue
Generator Mail Street 2:	Not reported
Generator Mail City:	Long Island City
Generator Mail Zip:	11105
Generator Mail State:	NY
Generator Contact Company Name:	Not reported

WHITE PLAINS SUBSTATION (Continued) **1001113337**

Designated Facility EPA ID:	NYD077444263
Designated Facility Name:	Triumvirate Environmental (Nyc), Llc
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	42-14 19th Avenue
Designated Facility Mail City:	Astoria
Designated Facility Mail Zip:	11105
Designated Facility Mail State:	NY
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	42-14 19th Avenue
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	Astoria
Designated Facility Location Zip:	11105
Designated Facility Location State:	NY
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Manifest Tracking Number:	012341086FLE
Last Updated Date:	20230317
Shipped Date:	20230224
Received Date:	20230227
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	NYD000706234
Generator Name:	Consolidated Edison-Deliveries
Generator Location Street Number:	Not reported
Generator Location Street 1:	31-01 20TH AVENUE
Generator Location Street 2:	Not reported
Generator Location City:	LONG ISLAND CITY
Generator Location State:	NY
Generator Location Zip:	11105
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	31-01 20th Avenue
Generator Mail Street 2:	Not reported
Generator Mail City:	Long Island City
Generator Mail Zip:	11105
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	NYD077444263
Designated Facility Name:	Triumvirate Environmental (Nyc), Llc
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	42-14 19th Avenue
Designated Facility Mail City:	Astoria
Designated Facility Mail Zip:	11105
Designated Facility Mail State:	NY
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	42-14 19th Avenue
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	Astoria
Designated Facility Location Zip:	11105
Designated Facility Location State:	NY
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

WHITE PLAINS SUBSTATION (Continued) **1001113337**

Manifest Tracking Number:	012341087FLE
Last Updated Date:	20230317
Shipped Date:	20230224
Received Date:	20230227
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	NYD000706234
Generator Name:	Consolidated Edison-Deliveries
Generator Location Street Number:	Not reported
Generator Location Street 1:	31-01 20TH AVENUE
Generator Location Street 2:	Not reported
Generator Location City:	LONG ISLAND CITY
Generator Location State:	NY
Generator Location Zip:	11105
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	31-01 20th Avenue
Generator Mail Street 2:	Not reported
Generator Mail City:	Long Island City
Generator Mail Zip:	11105
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	NYD077444263
Designated Facility Name:	Triumvirate Environmental (Nyc), Llc
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	42-14 19th Avenue
Designated Facility Mail City:	Astoria
Designated Facility Mail Zip:	11105
Designated Facility Mail State:	NY
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	42-14 19th Avenue
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	Astoria
Designated Facility Location Zip:	11105
Designated Facility Location State:	NY
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Manifest Tracking Number:	012341098FLE
Last Updated Date:	20230421
Shipped Date:	20230331
Received Date:	20230403
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	NYD000706234
Generator Name:	Consolidated Edison-Deliveries
Generator Location Street Number:	Not reported
Generator Location Street 1:	31-01 20TH AVENUE
Generator Location Street 2:	Not reported
Generator Location City:	LONG ISLAND CITY
Generator Location State:	NY
Generator Location Zip:	11105
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	31-01 20th Avenue

WHITE PLAINS SUBSTATION (Continued) **1001113337**

Generator Mail Street 2:	Not reported
Generator Mail City:	Long Island City
Generator Mail Zip:	11105
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	NYD077444263
Designated Facility Name:	Triumvirate Environmental (Nyc), Llc
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	42-14 19th Avenue
Designated Facility Mail City:	Astoria
Designated Facility Mail Zip:	11105
Designated Facility Mail State:	NY
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	42-14 19th Avenue
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	Astoria
Designated Facility Location Zip:	11105
Designated Facility Location State:	NY
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Manifest Tracking Number:	012341111FLE
Last Updated Date:	20211101
Shipped Date:	20211012
Received Date:	20211013
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	NYD000706234
Generator Name:	Consolidated Edison-Deliveries
Generator Location Street Number:	Not reported
Generator Location Street 1:	31-01 20TH AVENUE
Generator Location Street 2:	Not reported
Generator Location City:	LONG ISLAND CITY
Generator Location State:	NY
Generator Location Zip:	11105
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	31-01 20th Avenue
Generator Mail Street 2:	Not reported
Generator Mail City:	Long Island City
Generator Mail Zip:	11105
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	NYD077444263
Designated Facility Name:	Triumvirate Environmental (Nyc), Llc
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	42-14 19th Avenue
Designated Facility Mail City:	Astoria
Designated Facility Mail Zip:	11105
Designated Facility Mail State:	NY
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	42-14 19th Avenue
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	Astoria

WHITE PLAINS SUBSTATION (Continued) **1001113337**

Designated Facility Location Zip:	11105
Designated Facility Location State:	NY
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N
Manifest Tracking Number:	012341120FLE
Last Updated Date:	20211201
Shipped Date:	20211116
Received Date:	20211118
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	NYD000706234
Generator Name:	Consolidated Edison-Deliveries
Generator Location Street Number:	Not reported
Generator Location Street 1:	31-01 20TH AVENUE
Generator Location Street 2:	Not reported
Generator Location City:	LONG ISLAND CITY
Generator Location State:	NY
Generator Location Zip:	11105
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	31-01 20th Avenue
Generator Mail Street 2:	Not reported
Generator Mail City:	Long Island City
Generator Mail Zip:	11105
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	NYD077444263
Designated Facility Name:	Triumvirate Environmental (Nyc), Llc
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	42-14 19th Avenue
Designated Facility Mail City:	Astoria
Designated Facility Mail Zip:	11105
Designated Facility Mail State:	NY
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	42-14 19th Avenue
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	Astoria
Designated Facility Location Zip:	11105
Designated Facility Location State:	NY
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Federal Waste:

Manifest Tracking Number:	012341136FLE
Waste Line Number:	1
Federal Waste Code:	D001
Federal Waste:	IGNITABLE WASTE
Manifest Tracking Number:	012341136FLE
Waste Line Number:	1
Federal Waste Code:	D018
Federal Waste:	BENZENE

WHITE PLAINS SUBSTATION (Continued) **1001113337**

State Waste:
- Manifest Tracking Number: 012341136FLE
- Waste Line Number: 1
- State Waste Code Owner: NY
- State Waste Code: B
- State Waste: Incineration, heat recovery, burning. Waste management method code to be used on e-Manifest only

Transporter:
- Manifest Tracking Number: 012341136FLE
- Transporter Line Number: 1
- Transporter EPA ID: NYD006982359
- Transporter Name: Consolidated Edison-Transporter

Waste Line:
- Manifest Tracking Number: 012341136FLE
- Waste Line Number: 1
- U.S. DOT Hazardous Indicator: Y
- U.S. DOT ID Number: UN3175
- U.S. DOT Description: Un3175, Waste Solids Containing Flammable Liquid, N.O.S. ((Filters, Benzene)), 4.1, Ii Rq: (Benzene)
- Non-Hazardous Waste Description: Not reported
- Number of Containers: 1
- Container Type Code: DM
- Container Type Description: Metal drums, barrels, kegs
- Waste Quantity: 178
- Quantity Unit of Measure Code: P
- Quantity Unit of Measure Description: Pounds
- Waste Quantity, in Tons: 0.089
- Acute Waste Quantity, in Tons: 0
- Non-Acute Waste Quantity, in Tons: 0.089
- Waste Quantity, in Kilograms: 80.72568
- Acute Waste Quantity, in Kilograms: 0
- Non-Acute Waste Quantity, in Kilorgrams: 80.72568
- Management Method Code: H141
- Management Method Description: STORAGE, BULKING AND/OR TRANSFER OFF SITE
- Waste Residue Indicator: N
- Quantity Discrepancy Indicator: N
- Waste Type Discrepancy Indicator: N
- Waste Density: Not reported
- Waste Density Unit of Measure Code: Not reported
- Waste Density Unit of Measure Description: Not reported
- Form Code: Not reported
- Form Code Description: Not reported
- Source Code: Not reported
- Source Code Description: Not reported
- Waste Minimization Code: Not reported
- Waste Minimization Code Description: Not reported
- Consent Number: Not reported
- EPA Waste Indicator: Y

Click this hyperlink while viewing on your computer to access
1022 additional US EManifest: record(s) in the EDR Site Report.

N172 **CE - WHITE PLAINS MGP** **NY ENG CONTROLS** **S106906513**
NW **9 NEW STREET AND 12 WATER STREET** **NY INST CONTROL** **N/A**
< 1/8 **WHITE PLAINS, NY 10601** **NY VCP**
0.118 mi. **NY MGP**
624 ft. **Site 10 of 18 in cluster N**

Relative:
Higher

Actual:
201 ft.

ENG CONTROLS:

Name:	CE - WHITE PLAINS MGP
Address:	9 NEW STREET AND 12 WATER STREET
City,State,Zip:	WHITE PLAINS, NY 10601-
Site Code:	58617
HW Code:	V00438
Control Code:	15
Control Type:	ENG
Date Record Added:	06/19/2008
Date Rec Updated:	07/30/2024
Updated By:	GLWHITE
Site Description:	Site Location and Features: The site is located near the edge of downtown in the City of White Plains, Westchester County. The address of the central portion of the site is 12 Water Street. The site is split into two operable units, OU1 and OU2; OU2, with the 12 Water Street address, is situated north of OU1. The main site feature of OU1 includes a Consolidated Edison Company of New York, Inc (Con Edison) electric distribution substation, as well as off-site areas to the south, which currently include the YMCA of Central and Northern Westchester and Saint John the Evangelist Roman Catholic Church (St. John s Property). OU2 site features include a commercial office building, which currently houses a banking institution, a security guard company and an attorney s office, and tenant parking area. The site and the St. John s Property are dissected by New Street (a dead end); together, they are bounded to the north by Water Street, Hamilton Avenue to the South, North Lexington Avenue to the west, and to the east by a parking area and office building located over the former road-bed of a de-mapped public thoroughfare formerly known as Spring Street. Current Zoning: The site is currently zoned CB-4, for commercial use. Historical Uses: Beginning in the mid-1800s, a former manufactured gas plant (MGP) operated by Con Edison predecessor companies spanned both OU1 and OU2. MGP operations reportedly ceased in 1930. OU1 includes the Southern Relief Holder of the MGP site and the St. John s Property. The Holder was removed by a 2004-2005 Interim Remedial Measure (IRM). There is no record of any MGP activity on the St. John s Property, but some MGP tar is present deep underground. Operable Unit 2 addresses the remainder of the MGP site, located on the Water Street portion of the site. A Site Management Plan and monitoring plan are in place for the site, including the St. John’s Property. Site Geology and Hydrogeology: The stratigraphy of the site can be divided into four geologic units: fill, fine to medium sand, glacial till, and bedrock. Fill ranges in thickness from 3.5 to 9 feet and is underlain by up to 77 feet of sand. Glacial till, while discontinuous across the site, ranges up to 15 feet thick. Bedrock, consisting of Manhattan Schist, was observed at highly variable depths, ranging from 8 to 84 feet below grade (ft bg). Depth to groundwater ranges from 7 to 12 ft bg in the northern portion of the site to 22 to 29 ft bg in the southern portion, apparently corresponding with the increasing depth to bedrock, with flow to the south and west.
Env Problem:	Nature and Extent of contamination: The principal contaminant of concern at the site is MGP related coal tar and associated petroleum contamination. Coal tar contains various volatile organic compounds

CE - WHITE PLAINS MGP (Continued) **S106906513**

(VOCs), primarily benzene, toluene, ethylbenzenes, and xylenes (collectively known as BTEX). A family of compounds referred to as polycyclic aromatic hydrocarbons (PAHs) are also associated with MGP coal tar. Coal tar, a non-aqueous phase liquid (NAPL), is present in the subsurface of the plant site (OU2) in the proximity of historic MGP structures. This contamination appears to have migrated south, west and vertically down from these structures, impacting deep (e.g. 36 to 60 feet below ground surface) groundwater south of the building on the St. John s property. Site-related contamination was not detected in sub-slab soil vapor samples from directly beneath the basement slab of the building or the indoor air samples. The relief gas holder foundation, which is part of OU1, was heavily contaminated with MGP tar, and was removed through an excavation interim remedial measure (IRM) in 2004-5. In addition to the excavation, a NAPL cutoff wall and NAPL recovery wells were installed. Coal tar is present under much of the parking area at 12 Water Street (OU2). The remediation in this area was completed in June 2010 via in-situ solidification and a low-permeability cap, as described in the 2012 Final Engineering Report. Operation and monitoring of the coal tar recovery well networks is ongoing. Residual contamination in the soil and groundwater is being managed under a Declaration of Covenants and Restrictions and a Site Management Plan.

Health Problem:	Not reported
Dump:	False
Structure:	False
Lagoon:	False
Landfill:	False
Pond:	False
Disp Start:	Not reported
Disp Term:	Not reported
Lat/Long:	Not reported
Dell:	Not reported
Record Add:	2012-10-18 16:09:00
Record Upd:	2012-10-18 16:09:00
Updated By:	ldennist
Own Op:	1
Sub Type:	ZZZ
Owner Name:	9 NEW STREET PROP
Owner Company:	CONSOLIDATED EDISON COMPANY OF NY IN
Owner Address:	4 IRVING PLACE
Owner Addr2:	Not reported
Owner City,St,Zip:	NEW YORK, NY 10003
Owner Country:	United States of America
Own Op:	6
Sub Type:	03
Owner Name:	Yelena Skorobogatov
Owner Company:	CONSOLIDATED EDISON COMPANY OF NY IN
Owner Address:	31-01 20TH AVE
Owner Addr2:	Not reported
Owner City,St,Zip:	LONG ISLAND CITY, NY 11105
Owner Country:	United States of America
Own Op:	1
Sub Type:	ZZZ
Owner Name:	12 WATER ST PRO C/O CB RIC.ELLIS INC
Owner Company:	PRINCIPAL MUTUAL LIFE INSURANCE CO
Owner Address:	177 BROAD ST.
Owner Addr2:	Not reported

CE - WHITE PLAINS MGP (Continued) **S106906513**

Owner City,St,Zip: STAMFORD, CT 06901
Owner Country: United States of America
HW Code: V00438
Waste Type: COAL TAR
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: V00438
Waste Type: COAL TAR
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: V00438
Waste Type: COAL TAR
Waste Quantity: UNKNOWN
Waste Code: Not reported
Crossref ID: Not reported
Cross Ref Type Code: Not reported
Cross Ref Type: Not reported
Record Added Date: Not reported
Record Updated: Not reported
Updated By: Not reported

INST CONTROL:
Name: CE - WHITE PLAINS MGP
Address: 9 NEW STREET AND 12 WATER STREET
City,State,Zip: WHITE PLAINS, NY 10601-
Site Code: 58617
Control Name: Ground Water Use Restriction
HW Code: V00438
Control Code: 08
Control Type: INST
Dt record added: 06/19/2008
Dt rec updated: 07/30/2024
Updated By: GLWHITE
Site Code: 58617
Site Description: Site Location and Features: The site is located near the edge of downtown in the City of White Plains, Westchester County. The address of the central portion of the site is 12 Water Street. The site is split into two operable units, OU1 and OU2; OU2, with the 12 Water Street address, is situated north of OU1. The main site feature of OU1 includes a Consolidated Edison Company of New York, Inc (Con Edison) electric distribution substation, as well as off-site areas to the south, which currently include the YMCA of Central and Northern Westchester and Saint John the Evangelist Roman Catholic Church (St. John s Property). OU2 site features include a commercial office building, which currently houses a banking institution, a security guard company and an attorney s office, and tenant parking area. The site and the St. John s Property are dissected by New Street (a dead end); together, they are bounded to the north by Water Street, Hamilton Avenue to the South, North Lexington Avenue to the west, and to the east by a parking area and office building located over the former road-bed of a de-mapped public thoroughfare formerly known as Spring Street. Current Zoning: The site is currently zoned CB-4, for commercial use. Historical Uses: Beginning in the mid-1800s, a former manufactured gas plant (MGP) operated by Con Edison predecessor companies spanned both OU1 and OU2. MGP operations reportedly ceased in 1930. OU1 includes the Southern Relief Holder of the MGP site and the St. John s Property. The Holder was removed by a

CE - WHITE PLAINS MGP (Continued) **S106906513**

2004-2005 Interim Remedial Measure (IRM). There is no record of any MGP activity on the St. John s Property, but some MGP tar is present deep underground. Operable Unit 2 addresses the remainder of the MGP site, located on the Water Street portion of the site. A Site Management Plan and monitoring plan are in place for the site, including the St. John's Property. Site Geology and Hydrogeology: The stratigraphy of the site can be divided into four geologic units: fill, fine to medium sand, glacial till, and bedrock. Fill ranges in thickness from 3.5 to 9 feet and is underlain by up to 77 feet of sand. Glacial till, while discontinuous across the site, ranges up to 15 feet thick. Bedrock, consisting of Manhattan Schist, was observed at highly variable depths, ranging from 8 to 84 feet below grade (ft bg). Depth to groundwater ranges from 7 to 12 ft bg in the northern portion of the site to 22 to 29 ft bg in the southern portion, apparently corresponding with the increasing depth to bedrock, with flow to the south and west.

Env Problem: Nature and Extent of contamination: The principal contaminant of concern at the site is MGP related coal tar and associated petroleum contamination. Coal tar contains various volatile organic compounds (VOCs), primarily benzene, toluene, ethylbenzenes, and xylenes (collectively known as BTEX). A family of compounds referred to as polycyclic aromatic hydrocarbons (PAHs) are also associated with MGP coal tar. Coal tar, a non-aqueous phase liquid (NAPL), is present in the subsurface of the plant site (OU2) in the proximity of historic MGP structures. This contamination appears to have migrated south, west and vertically down from these structures, impacting deep (e.g. 36 to 60 feet below ground surface) groundwater south of the building on the St. John s property. Site-related contamination was not detected in sub-slab soil vapor samples from directly beneath the basement slab of the building or the indoor air samples. The relief gas holder foundation, which is part of OU1, was heavily contaminated with MGP tar, and was removed through an excavation interim remedial measure (IRM) in 2004-5. In addition to the excavation, a NAPL cutoff wall and NAPL recovery wells were installed. Coal tar is present under much of the parking area at 12 Water Street (OU2). The remediation in this area was completed in June 2010 via in-situ solidification and a low-permeability cap, as described in the 2012 Final Engineering Report. Operation and monitoring of the coal tar recovery well networks is ongoing. Residual contamination in the soil and groundwater is being managed under a Declaration of Covenants and Restrictions and a Site Management Plan.

Health Problem: Not reported
Dump: False
Structure: False
Lagoon: False
Landfill: False
Pond: False
Disp Start: Not reported
Disp Term: Not reported
Lat/Long: Not reported
Dell: Not reported
Record Add: 2012-10-18 16:09:00
Record Upd: 2012-10-18 16:09:00
Updated By: ldennist
Own Op: 1
Sub Type: ZZZ
Owner Name: 9 NEW STREET PROP

CE - WHITE PLAINS MGP (Continued) **S106906513**

Owner Company: CONSOLIDATED EDISON COMPANY OF NY IN
Owner Address: 4 IRVING PLACE
Owner Addr2: Not reported
Owner City,St,Zip: NEW YORK, NY 10003
Owner Country: United States of America
Own Op: 6
Sub Type: 03
Owner Name: Yelena Skorobogatov
Owner Company: CONSOLIDATED EDISON COMPANY OF NY IN
Owner Address: 31-01 20TH AVE
Owner Addr2: Not reported
Owner City,St,Zip: LONG ISLAND CITY, NY 11105
Owner Country: United States of America
Own Op: 1
Sub Type: ZZZ
Owner Name: 12 WATER ST PRO C/O CB RIC.ELLIS INC
Owner Company: PRINCIPAL MUTUAL LIFE INSURANCE CO
Owner Address: 177 BROAD ST.
Owner Addr2: Not reported
Owner City,St,Zip: STAMFORD, CT 06901
Owner Country: United States of America
HW Code: V00438
Waste Type: COAL TAR
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: V00438
Waste Type: COAL TAR
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: V00438
Waste Type: COAL TAR
Waste Quantity: UNKNOWN
Waste Code: Not reported
Crossref ID: Not reported
Cross Ref Type Code: Not reported
Cross Ref Type: Not reported
Record Added Date: Not reported
Record Updated: Not reported
Updated By: Not reported

Name: CE - WHITE PLAINS MGP
Address: 9 NEW STREET AND 12 WATER STREET
City,State,Zip: WHITE PLAINS, NY 10601-
Site Code: 58617
Control Name: Landuse Restriction
HW Code: V00438
Control Code: 25
Control Type: INST
Dt record added: 06/19/2008
Dt rec updated: 07/30/2024
Updated By: GLWHITE
Site Code: 58617
Site Description: Site Location and Features: The site is located near the edge of downtown in the City of White Plains, Westchester County. The address of the central portion of the site is 12 Water Street. The site is split into two operable units, OU1 and OU2; OU2, with the 12 Water Street address, is situated north of OU1. The main site feature of

CE - WHITE PLAINS MGP (Continued) **S106906513**

OU1 includes a Consolidated Edison Company of New York, Inc (Con Edison) electric distribution substation, as well as off-site areas to the south, which currently include the YMCA of Central and Northern Westchester and Saint John the Evangelist Roman Catholic Church (St. John s Property). OU2 site features include a commercial office building, which currently houses a banking institution, a security guard company and an attorney s office, and tenant parking area. The site and the St. John s Property are dissected by New Street (a dead end); together, they are bounded to the north by Water Street, Hamilton Avenue to the South, North Lexington Avenue to the west, and to the east by a parking area and office building located over the former road-bed of a de-mapped public thoroughfare formerly known as Spring Street. Current Zoning: The site is currently zoned CB-4, for commercial use. Historical Uses: Beginning in the mid-1800s, a former manufactured gas plant (MGP) operated by Con Edison predecessor companies spanned both OU1 and OU2. MGP operations reportedly ceased in 1930. OU1 includes the Southern Relief Holder of the MGP site and the St. John s Property. The Holder was removed by a 2004-2005 Interim Remedial Measure (IRM). There is no record of any MGP activity on the St. John s Property, but some MGP tar is present deep underground. Operable Unit 2 addresses the remainder of the MGP site, located on the Water Street portion of the site. A Site Management Plan and monitoring plan are in place for the site, including the St. John's Property. Site Geology and Hydrogeology: The stratigraphy of the site can be divided into four geologic units: fill, fine to medium sand, glacial till, and bedrock. Fill ranges in thickness from 3.5 to 9 feet and is underlain by up to 77 feet of sand. Glacial till, while discontinuous across the site, ranges up to 15 feet thick. Bedrock, consisting of Manhattan Schist, was observed at highly variable depths, ranging from 8 to 84 feet below grade (ft bg). Depth to groundwater ranges from 7 to 12 ft bg in the northern portion of the site to 22 to 29 ft bg in the southern portion, apparently corresponding with the increasing depth to bedrock, with flow to the south and west.

Env Problem: Nature and Extent of contamination: The principal contaminant of concern at the site is MGP related coal tar and associated petroleum contamination. Coal tar contains various volatile organic compounds (VOCs), primarily benzene, toluene, ethylbenzenes, and xylenes (collectively known as BTEX). A family of compounds referred to as polycyclic aromatic hydrocarbons (PAHs) are also associated with MGP coal tar. Coal tar, a non-aqueous phase liquid (NAPL), is present in the subsurface of the plant site (OU2) in the proximity of historic MGP structures. This contamination appears to have migrated south, west and vertically down from these structures, impacting deep (e.g. 36 to 60 feet below ground surface) groundwater south of the building on the St. John s property. Site-related contamination was not detected in sub-slab soil vapor samples from directly beneath the basement slab of the building or the indoor air samples. The relief gas holder foundation, which is part of OU1, was heavily contaminated with MGP tar, and was removed through an excavation interim remedial measure (IRM) in 2004-5. In addition to the excavation, a NAPL cutoff wall and NAPL recovery wells were installed. Coal tar is present under much of the parking area at 12 Water Street (OU2). The remediation in this area was completed in June 2010 via in-situ solidification and a low-permeability cap, as described in the 2012 Final Engineering Report. Operation and monitoring of the coal tar recovery well networks is ongoing. Residual contamination in the soil

CE - WHITE PLAINS MGP (Continued) **S106906513**

and groundwater is being managed under a Declaration of Covenants and Restrictions and a Site Management Plan.

Health Problem: Not reported
Dump: False
Structure: False
Lagoon: False
Landfill: False
Pond: False
Disp Start: Not reported
Disp Term: Not reported
Lat/Long: Not reported
Dell: Not reported
Record Add: 2012-10-18 16:09:00
Record Upd: 2012-10-18 16:09:00
Updated By: ldennist
Own Op: 1
Sub Type: ZZZ
Owner Name: 9 NEW STREET PROP
Owner Company: CONSOLIDATED EDISON COMPANY OF NY IN
Owner Address: 4 IRVING PLACE
Owner Addr2: Not reported
Owner City,St,Zip: NEW YORK, NY 10003
Owner Country: United States of America
Own Op: 6
Sub Type: 03
Owner Name: Yelena Skorobogatov
Owner Company: CONSOLIDATED EDISON COMPANY OF NY IN
Owner Address: 31-01 20TH AVE
Owner Addr2: Not reported
Owner City,St,Zip: LONG ISLAND CITY, NY 11105
Owner Country: United States of America
Own Op: 1
Sub Type: ZZZ
Owner Name: 12 WATER ST PRO C/O CB RIC.ELLIS INC
Owner Company: PRINCIPAL MUTUAL LIFE INSURANCE CO
Owner Address: 177 BROAD ST.
Owner Addr2: Not reported
Owner City,St,Zip: STAMFORD, CT 06901
Owner Country: United States of America
HW Code: V00438
Waste Type: COAL TAR
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: V00438
Waste Type: COAL TAR
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: V00438
Waste Type: COAL TAR
Waste Quantity: UNKNOWN
Waste Code: Not reported
Crossref ID: Not reported
Cross Ref Type Code: Not reported
Cross Ref Type: Not reported
Record Added Date: Not reported
Record Updated: Not reported
Updated By: Not reported

CE - WHITE PLAINS MGP (Continued) **S106906513**

Name:	CE - WHITE PLAINS MGP
Address:	9 NEW STREET AND 12 WATER STREET
City,State,Zip:	WHITE PLAINS, NY 10601-
Site Code:	58617
Control Name:	Soil Management Plan
HW Code:	V00438
Control Code:	14
Control Type:	INST
Dt record added:	06/19/2008
Dt rec updated:	07/30/2024
Updated By:	GLWHITE
Site Code:	58617
Site Description:	Site Location and Features: The site is located near the edge of downtown in the City of White Plains, Westchester County. The address of the central portion of the site is 12 Water Street. The site is split into two operable units, OU1 and OU2; OU2, with the 12 Water Street address, is situated north of OU1. The main site feature of OU1 includes a Consolidated Edison Company of New York, Inc (Con Edison) electric distribution substation, as well as off-site areas to the south, which currently include the YMCA of Central and Northern Westchester and Saint John the Evangelist Roman Catholic Church (St. John s Property). OU2 site features include a commercial office building, which currently houses a banking institution, a security guard company and an attorney s office, and tenant parking area. The site and the St. John s Property are dissected by New Street (a dead end); together, they are bounded to the north by Water Street, Hamilton Avenue to the South, North Lexington Avenue to the west, and to the east by a parking area and office building located over the former road-bed of a de-mapped public thoroughfare formerly known as Spring Street. Current Zoning: The site is currently zoned CB-4, for commercial use. Historical Uses: Beginning in the mid-1800s, a former manufactured gas plant (MGP) operated by Con Edison predecessor companies spanned both OU1 and OU2. MGP operations reportedly ceased in 1930. OU1 includes the Southern Relief Holder of the MGP site and the St. John s Property. The Holder was removed by a 2004-2005 Interim Remedial Measure (IRM). There is no record of any MGP activity on the St. John s Property, but some MGP tar is present deep underground. Operable Unit 2 addresses the remainder of the MGP site, located on the Water Street portion of the site. A Site Management Plan and monitoring plan are in place for the site, including the St. John’s Property. Site Geology and Hydrogeology: The stratigraphy of the site can be divided into four geologic units: fill, fine to medium sand, glacial till, and bedrock. Fill ranges in thickness from 3.5 to 9 feet and is underlain by up to 77 feet of sand. Glacial till, while discontinuous across the site, ranges up to 15 feet thick. Bedrock, consisting of Manhattan Schist, was observed at highly variable depths, ranging from 8 to 84 feet below grade (ft bg). Depth to groundwater ranges from 7 to 12 ft bg in the northern portion of the site to 22 to 29 ft bg in the southern portion, apparently corresponding with the increasing depth to bedrock, with flow to the south and west.
Env Problem:	Nature and Extent of contamination: The principal contaminant of concern at the site is MGP related coal tar and associated petroleum contamination. Coal tar contains various volatile organic compounds (VOCs), primarily benzene, toluene, ethylbenzenes, and xylenes (collectively known as BTEX). A family of compounds referred to as polycyclic aromatic hydrocarbons (PAHs) are also associated with MGP

CE - WHITE PLAINS MGP (Continued) **S106906513**

coal tar. Coal tar, a non-aqueous phase liquid (NAPL), is present in the subsurface of the plant site (OU2) in the proximity of historic MGP structures. This contamination appears to have migrated south, west and vertically down from these structures, impacting deep (e.g. 36 to 60 feet below ground surface) groundwater south of the building on the St. John s property. Site-related contamination was not detected in sub-slab soil vapor samples from directly beneath the basement slab of the building or the indoor air samples. The relief gas holder foundation, which is part of OU1, was heavily contaminated with MGP tar, and was removed through an excavation interim remedial measure (IRM) in 2004-5. In addition to the excavation, a NAPL cutoff wall and NAPL recovery wells were installed. Coal tar is present under much of the parking area at 12 Water Street (OU2). The remediation in this area was completed in June 2010 via in-situ solidification and a low-permeability cap, as described in the 2012 Final Engineering Report. Operation and monitoring of the coal tar recovery well networks is ongoing. Residual contamination in the soil and groundwater is being managed under a Declaration of Covenants and Restrictions and a Site Management Plan.

Health Problem: Not reported
Dump: False
Structure: False
Lagoon: False
Landfill: False
Pond: False
Disp Start: Not reported
Disp Term: Not reported
Lat/Long: Not reported
Dell: Not reported
Record Add: 2012-10-18 16:09:00
Record Upd: 2012-10-18 16:09:00
Updated By: ldennist
Own Op: 1
Sub Type: ZZZ
Owner Name: 9 NEW STREET PROP
Owner Company: CONSOLIDATED EDISON COMPANY OF NY IN
Owner Address: 4 IRVING PLACE
Owner Addr2: Not reported
Owner City,St,Zip: NEW YORK, NY 10003
Owner Country: United States of America
Own Op: 6
Sub Type: 03
Owner Name: Yelena Skorobogatov
Owner Company: CONSOLIDATED EDISON COMPANY OF NY IN
Owner Address: 31-01 20TH AVE
Owner Addr2: Not reported
Owner City,St,Zip: LONG ISLAND CITY, NY 11105
Owner Country: United States of America
Own Op: 1
Sub Type: ZZZ
Owner Name: 12 WATER ST PRO C/O CB RIC.ELLIS INC
Owner Company: PRINCIPAL MUTUAL LIFE INSURANCE CO
Owner Address: 177 BROAD ST.
Owner Addr2: Not reported
Owner City,St,Zip: STAMFORD, CT 06901
Owner Country: United States of America
HW Code: V00438

CE - WHITE PLAINS MGP (Continued) **S106906513**

Waste Type: COAL TAR
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: V00438
Waste Type: COAL TAR
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: V00438
Waste Type: COAL TAR
Waste Quantity: UNKNOWN
Waste Code: Not reported
Crossref ID: Not reported
Cross Ref Type Code: Not reported
Cross Ref Type: Not reported
Record Added Date: Not reported
Record Updated: Not reported
Updated By: Not reported

Name: CE - WHITE PLAINS MGP
Address: 9 NEW STREET AND 12 WATER STREET
City,State,Zip: WHITE PLAINS, NY 10601-
Site Code: 58617
Control Name: Deed Restriction
HW Code: V00438
Control Code: A
Control Type: INST
Dt record added: 06/19/2008
Dt rec updated: 07/30/2024
Updated By: GLWHITE
Site Code: 58617
Site Description: Site Location and Features: The site is located near the edge of downtown in the City of White Plains, Westchester County. The address of the central portion of the site is 12 Water Street. The site is split into two operable units, OU1 and OU2; OU2, with the 12 Water Street address, is situated north of OU1. The main site feature of OU1 includes a Consolidated Edison Company of New York, Inc (Con Edison) electric distribution substation, as well as off-site areas to the south, which currently include the YMCA of Central and Northern Westchester and Saint John the Evangelist Roman Catholic Church (St. John s Property). OU2 site features include a commercial office building, which currently houses a banking institution, a security guard company and an attorney s office, and tenant parking area. The site and the St. John s Property are dissected by New Street (a dead end); together, they are bounded to the north by Water Street, Hamilton Avenue to the South, North Lexington Avenue to the west, and to the east by a parking area and office building located over the former road-bed of a de-mapped public thoroughfare formerly known as Spring Street. Current Zoning: The site is currently zoned CB-4, for commercial use. Historical Uses: Beginning in the mid-1800s, a former manufactured gas plant (MGP) operated by Con Edison predecessor companies spanned both OU1 and OU2. MGP operations reportedly ceased in 1930. OU1 includes the Southern Relief Holder of the MGP site and the St. John s Property. The Holder was removed by a 2004-2005 Interim Remedial Measure (IRM). There is no record of any MGP activity on the St. John s Property, but some MGP tar is present deep underground. Operable Unit 2 addresses the remainder of the MGP site, located on the Water Street portion of the site. A Site

CE - WHITE PLAINS MGP (Continued) **S106906513**

Management Plan and monitoring plan are in place for the site, including the St. John's Property. Site Geology and Hydrogeology: The stratigraphy of the site can be divided into four geologic units: fill, fine to medium sand, glacial till, and bedrock. Fill ranges in thickness from 3.5 to 9 feet and is underlain by up to 77 feet of sand. Glacial till, while discontinuous across the site, ranges up to 15 feet thick. Bedrock, consisting of Manhattan Schist, was observed at highly variable depths, ranging from 8 to 84 feet below grade (ft bg). Depth to groundwater ranges from 7 to 12 ft bg in the northern portion of the site to 22 to 29 ft bg in the southern portion, apparently corresponding with the increasing depth to bedrock, with flow to the south and west.

Env Problem: Nature and Extent of contamination: The principal contaminant of concern at the site is MGP related coal tar and associated petroleum contamination. Coal tar contains various volatile organic compounds (VOCs), primarily benzene, toluene, ethylbenzenes, and xylenes (collectively known as BTEX). A family of compounds referred to as polycyclic aromatic hydrocarbons (PAHs) are also associated with MGP coal tar. Coal tar, a non-aqueous phase liquid (NAPL), is present in the subsurface of the plant site (OU2) in the proximity of historic MGP structures. This contamination appears to have migrated south, west and vertically down from these structures, impacting deep (e.g. 36 to 60 feet below ground surface) groundwater south of the building on the St. John s property. Site-related contamination was not detected in sub-slab soil vapor samples from directly beneath the basement slab of the building or the indoor air samples. The relief gas holder foundation, which is part of OU1, was heavily contaminated with MGP tar, and was removed through an excavation interim remedial measure (IRM) in 2004-5. In addition to the excavation, a NAPL cutoff wall and NAPL recovery wells were installed. Coal tar is present under much of the parking area at 12 Water Street (OU2). The remediation in this area was completed in June 2010 via in-situ solidification and a low-permeability cap, as described in the 2012 Final Engineering Report. Operation and monitoring of the coal tar recovery well networks is ongoing. Residual contamination in the soil and groundwater is being managed under a Declaration of Covenants and Restrictions and a Site Management Plan.

Health Problem: Not reported
Dump: False
Structure: False
Lagoon: False
Landfill: False
Pond: False
Disp Start: Not reported
Disp Term: Not reported
Lat/Long: Not reported
Dell: Not reported
Record Add: 2012-10-18 16:09:00
Record Upd: 2012-10-18 16:09:00
Updated By: ldennist
Own Op: 1
Sub Type: ZZZ
Owner Name: 9 NEW STREET PROP
Owner Company: CONSOLIDATED EDISON COMPANY OF NY IN
Owner Address: 4 IRVING PLACE
Owner Addr2: Not reported
Owner City,St,Zip: NEW YORK, NY 10003

CE - WHITE PLAINS MGP (Continued) **S106906513**

Owner Country: United States of America
Own Op: 6
Sub Type: 03
Owner Name: Yelena Skorobogatov
Owner Company: CONSOLIDATED EDISON COMPANY OF NY IN
Owner Address: 31-01 20TH AVE
Owner Addr2: Not reported
Owner City,St,Zip: LONG ISLAND CITY, NY 11105
Owner Country: United States of America
Own Op: 1
Sub Type: ZZZ
Owner Name: 12 WATER ST PRO C/O CB RIC.ELLIS INC
Owner Company: PRINCIPAL MUTUAL LIFE INSURANCE CO
Owner Address: 177 BROAD ST.
Owner Addr2: Not reported
Owner City,St,Zip: STAMFORD, CT 06901
Owner Country: United States of America
HW Code: V00438
Waste Type: COAL TAR
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: V00438
Waste Type: COAL TAR
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: V00438
Waste Type: COAL TAR
Waste Quantity: UNKNOWN
Waste Code: Not reported
Crossref ID: Not reported
Cross Ref Type Code: Not reported
Cross Ref Type: Not reported
Record Added Date: Not reported
Record Updated: Not reported
Updated By: Not reported

VCP:
Name: CE - WHITE PLAINS MGP
Address: 9 NEW STREET AND 12 WATER STREET
City,State,Zip: WHITE PLAINS, NY 10601-
Program Type: VCP
Site Code: 58617
HW Code: V00438
Site Class: C
SWIS: 6017
Region: 3
Town: White Plains (c)
Acres: Not reported
Date Record Added: 02/22/2001
Date Record Updated: 08/07/2024
Updated By: KATHOMPS
Site Description: Site Location and Features: The site is located near the edge of downtown in the City of White Plains, Westchester County. The address of the central portion of the site is 12 Water Street. The site is split into two operable units, OU1 and OU2; OU2, with the 12 Water Street address, is situated north of OU1. The main site feature of OU1 includes a Consolidated Edison Company of New York, Inc (Con

CE - WHITE PLAINS MGP (Continued) **S106906513**

Edison) electric distribution substation, as well as off-site areas to the south, which currently include the YMCA of Central and Northern Westchester and Saint John the Evangelist Roman Catholic Church (St. John s Property). OU2 site features include a commercial office building, which currently houses a banking institution, a security guard company and an attorney s office, and tenant parking area. The site and the St. John s Property are dissected by New Street (a dead end); together, they are bounded to the north by Water Street, Hamilton Avenue to the South, North Lexington Avenue to the west, and to the east by a parking area and office building located over the former road-bed of a de-mapped public thoroughfare formerly known as Spring Street. Current Zoning: The site is currently zoned CB-4, for commercial use. Historical Uses: Beginning in the mid-1800s, a former manufactured gas plant (MGP) operated by Con Edison predecessor companies spanned both OU1 and OU2. MGP operations reportedly ceased in 1930. OU1 includes the Southern Relief Holder of the MGP site and the St. John s Property. The Holder was removed by a 2004-2005 Interim Remedial Measure (IRM). There is no record of any MGP activity on the St. John s Property, but some MGP tar is present deep underground. Operable Unit 2 addresses the remainder of the MGP site, located on the Water Street portion of the site. A Site Management Plan and monitoring plan are in place for the site, including the St. John's Property. Site Geology and Hydrogeology: The stratigraphy of the site can be divided into four geologic units: fill, fine to medium sand, glacial till, and bedrock. Fill ranges in thickness from 3.5 to 9 feet and is underlain by up to 77 feet of sand. Glacial till, while discontinuous across the site, ranges up to 15 feet thick. Bedrock, consisting of Manhattan Schist, was observed at highly variable depths, ranging from 8 to 84 feet below grade (ft bg). Depth to groundwater ranges from 7 to 12 ft bg in the northern portion of the site to 22 to 29 ft bg in the southern portion, apparently corresponding with the increasing depth to bedrock, with flow to the south and west.

Env Problem: Nature and Extent of contamination: The principal contaminant of concern at the site is MGP related coal tar and associated petroleum contamination. Coal tar contains various volatile organic compounds (VOCs), primarily benzene, toluene, ethylbenzenes, and xylenes (collectively known as BTEX). A family of compounds referred to as polycyclic aromatic hydrocarbons (PAHs) are also associated with MGP coal tar. Coal tar, a non-aqueous phase liquid (NAPL), is present in the subsurface of the plant site (OU2) in the proximity of historic MGP structures. This contamination appears to have migrated south, west and vertically down from these structures, impacting deep (e.g. 36 to 60 feet below ground surface) groundwater south of the building on the St. John s property. Site-related contamination was not detected in sub-slab soil vapor samples from directly beneath the basement slab of the building or the indoor air samples. The relief gas holder foundation, which is part of OU1, was heavily contaminated with MGP tar, and was removed through an excavation interim remedial measure (IRM) in 2004-5. In addition to the excavation, a NAPL cutoff wall and NAPL recovery wells were installed. Coal tar is present under much of the parking area at 12 Water Street (OU2). The remediation in this area was completed in June 2010 via in-situ solidification and a low-permeability cap, as described in the 2012 Final Engineering Report. Operation and monitoring of the coal tar recovery well networks is ongoing. Residual contamination in the soil and groundwater is being managed under a Declaration of Covenants and

CE - WHITE PLAINS MGP (Continued) **S106906513**

	Restrictions and a Site Management Plan.
Health Problem:	Not reported
Dump:	False
Structure:	False
Lagoon:	False
Landfill:	False
Pond:	False
Disp Start:	Not reported
Disp Term:	Not reported
Lat/Long:	Not reported
Dell:	Not reported
Record Add:	2012-10-18 16:09:00
Record Upd:	2012-10-18 16:09:00
Updated By:	ldennist
Own Op:	1
Sub Type:	ZZZ
Owner Name:	9 NEW STREET PROP
Owner Company:	CONSOLIDATED EDISON COMPANY OF NY IN
Owner Address:	4 IRVING PLACE
Owner Addr2:	Not reported
Owner City,St,Zip:	NEW YORK, NY 10003
Owner Country:	United States of America
Own Op:	6
Sub Type:	03
Owner Name:	Yelena Skorobogatov
Owner Company:	CONSOLIDATED EDISON COMPANY OF NY IN
Owner Address:	31-01 20TH AVE
Owner Addr2:	Not reported
Owner City,St,Zip:	LONG ISLAND CITY, NY 11105
Owner Country:	United States of America
Own Op:	1
Sub Type:	ZZZ
Owner Name:	12 WATER ST PRO C/O CB RIC.ELLIS INC
Owner Company:	PRINCIPAL MUTUAL LIFE INSURANCE CO
Owner Address:	177 BROAD ST.
Owner Addr2:	Not reported
Owner City,St,Zip:	STAMFORD, CT 06901
Owner Country:	United States of America
HW Code:	V00438
Waste Type:	COAL TAR
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	V00438
Waste Type:	COAL TAR
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	V00438
Waste Type:	COAL TAR
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
Crossref ID:	Not reported
Cross Ref Type Code:	Not reported
Cross Ref Type:	Not reported
Record Added Date:	Not reported
Record Updated:	Not reported
Updated By:	Not reported

CE - WHITE PLAINS MGP (Continued) **S106906513**

MGP:

Site ID:	Not reported
Name:	CE - WHITE PLAINS MGP
Address:	9 NEW STREET AND 12 WATER STREET
City,State,Zip:	WHITE PLAINS, NY 10601-
Region:	3
Class:	Completed: The classification used for sites where the Department has determined that remediation has been satisfactorily completed under a remedial program (i. e., State Superfund, Brownfield Cleanup Program, Environmental Restoration Program, Voluntary Cleanup Program, and RCRA Corrective Action Program). State Superfund (Registry) sites must have completed all active operation, maintenance, or monitoring requirements before they can be delisted and made class C. Non-registry sites may be made a class C after successful completion of all required construction or after a no further action remedy has been selected by the Department. These sites will be issued a Certificate of Completion (COC), but may still require ongoing maintenance and periodic certification of institutional/engineering controls (IC/ECs).
Swis Code:	6017
Town:	White Plains (c)
Disp Start:	Not reported
Disp Term:	Not reported
Acres:	Not reported
Fuse:	Industrial
Description:	Site Location and Features: The site is located near the edge of downtown in the City of White Plains, Westchester County. The address of the central portion of the site is 12 Water Street. The site is split into two operable units, OU1 and OU2; OU2, with the 12 Water Street address, is situated north of OU1. The main site feature of OU1 includes a Consolidated Edison Company of New York, Inc (Con Edison) electric distribution substation, as well as off-site areas to the south, which currently include the YMCA of Central and Northern Westchester and Saint John the Evangelist Roman Catholic Church (St. John?s Property). OU2 site features include a commercial office building, which currently houses a banking institution, a security guard company and an attorney?s office, and tenant parking area. The site and the St. John?s Property are dissected by New Street (a dead end); together, they are bounded to the north by Water Street, Hamilton Avenue to the South, North Lexington Avenue to the west, and to the east by a parking area and office building located over the former road-bed of a de-mapped public thoroughfare formerly known as Spring Street. Current Zoning: The site is currently zoned CB-4, for commercial use. Historical Uses: Beginning in the mid-1800s, a former manufactured gas plant (MGP) operated by Con Edison predecessor companies spanned both OU1 and OU2. MGP operations reportedly ceased in 1930. OU1 includes the Southern Relief Holder of the MGP site and the St. John?s Property. The Holder was removed by a 2004-2005 Interim Remedial Measure (IRM). There is no record of any MGP activity on the St. John?s Property, but some MGP tar is present deep underground. Operable Unit 2 addresses the remainder of the MGP site, located on the Water Street portion of the site. A Site Management Plan and monitoring plan are in place for the site, including the St. John’s Property. Site Geology and Hydrogeology: The stratigraphy of the site can be divided into four geologic units: fill, fine to medium sand, glacial till, and bedrock. Fill ranges in thickness from 3.5 to 9 feet and is underlain by up to 77 feet of

CE - WHITE PLAINS MGP (Continued) **S106906513**

sand. Glacial till, while discontinuous across the site, ranges up to 15 feet thick. Bedrock, consisting of Manhattan Schist, was observed at highly variable depths, ranging from 8 to 84 feet below grade (ft bg). Depth to groundwater ranges from 7 to 12 ft bg in the northern portion of the site to 22 to 29 ft bg in the southern portion, apparently corresponding with the increasing depth to bedrock, with flow to the south and west.

Assess Env: Nature and Extent of contamination: The principal contaminant of concern at the site is MGP related coal tar and associated petroleum contamination. Coal tar contains various volatile organic compounds (VOCs), primarily benzene, toluene, ethylbenzenes, and xylenes (collectively known as BTEX). A family of compounds referred to as polycyclic aromatic hydrocarbons (PAHs) are also associated with MGP coal tar. Coal tar, a non-aqueous phase liquid (NAPL), is present in the subsurface of the plant site (OU2) in the proximity of historic MGP structures. This contamination appears to have migrated south, west and vertically down from these structures, impacting deep (e.g. 36 to 60 feet below ground surface) groundwater south of the building on the St. John?s property. Site-related contamination was not detected in sub-slab soil vapor samples from directly beneath the basement slab of the building or the indoor air samples. The relief gas holder foundation, which is part of OU1, was heavily contaminated with MGP tar, and was removed through an excavation interim remedial measure (IRM) in 2004-5. In addition to the excavation, a NAPL cutoff wall and NAPL recovery wells were installed. Coal tar is present under much of the parking area at 12 Water Street (OU2). The remediation in this area was completed in June 2010 via in-situ solidification and a low-permeability cap, as described in the 2012 Final Engineering Report. Operation and monitoring of the coal tar recovery well networks is ongoing. Residual contamination in the soil and groundwater is being managed under a Declaration of Covenants and Restrictions and a Site Management Plan.

Assess Doh: Not reported
Latitude: 41.03392292
Longitude: -73.77223618

N173 **WHITE PLAINS SUB STATION TRANSORMER #1** **NY Spills** **S109828911**
NW **9 NEW STREET** **N/A**
< 1/8 **WHITE PALINS, NY**
0.118 mi.
624 ft. **Site 11 of 18 in cluster N**

Relative:
Higher

Actual:
201 ft.

SPILLS:

Name:	WHITE PLAINS SUB STATION TRANSORMER #1
Address:	9 NEW STREET
City,State,Zip:	WHITE PALINS, NY
Spill Number/Closed Date:	0905920 / 2010-06-24
Facility ID:	0905920
Facility Type:	ER
DER Facility ID:	367331
Site ID:	418215
DEC Region:	3
Spill Cause:	Unknown
Spill Class:	C4
SWIS:	6017
Spill Date:	2009-08-20
Investigator:	TDGHIOSA
Referred To:	Not reported

WHITE PLAINS SUB STATION TRANSORMER #1 (Continued) **S109828911**

Reported to Dept:	2009-08-20
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Responsible Party
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2009-08-20
Spill Record Last Update:	2010-06-24
Spiller Name:	Not reported
Spiller Company:	NATIONAL GRID
Spiller Address:	Not reported
Spiller Company:	999
Contact Name:	NIEL
Latitude:	41.0338517
Longitude:	-73.7719186
DEC Memo:	8/21/09 - 1 pint of unknown oil was found staining the blue stone from the transformer. Transformer located within substation yard. KAB 6/24/10 NFA JO'M
Remarks:	1656 The caller advised dispatch the spill amount and cause is unknown. No water ways affected. Clean up is pending at this time.

All Materials:

Site ID:	418215
Operable Unit ID:	1174401
Operable Unit:	01
Material ID:	2166734
Material Code:	0066A
Material Name:	unknown petroleum
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported
Resource Affected:	Not reported
Oxygenate:	Not reported

N174 **CON ED SUBSTATION** **NY Spills** **S128912768**
NW **9 NEW ST** **N/A**
< 1/8 **WHITE PLAINS, NY**
0.118 mi.
624 ft. **Site 12 of 18 in cluster N**

Relative: Higher
Actual: 201 ft.

SPILLS:

Name:	CON ED SUBSTATION
Address:	9 NEW ST
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	2203027 / 2022-07-08
Facility ID:	2203027
Facility Type:	ER
DER Facility ID:	461005
Site ID:	639126
DEC Region:	3

CON ED SUBSTATION (Continued) **S128912768**

Spill Cause:	Equipment Failure
Spill Class:	C4
SWIS:	6017
Spill Date:	2022-07-08
Investigator:	EXTYRELL
Referred To:	Not reported
Reported to Dept:	2022-07-08
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Other
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2022-07-08
Spill Record Last Update:	2022-07-08
Spiller Name:	Not reported
Spiller Company:	CON ED
Spiller Address:	Not reported
Spiller Company:	999
Contact Name:	DENNIS
Latitude:	Not reported
Longitude:	Not reported
DEC Memo:	7/8/22 5 ounces leaked from feeder pipe onto concrete. Fully cleaned up. NFA. EKT
Remarks:	5 ounces from pipe, repairs pending. On Con Ed property *Update* Con Ed called back and is reporting no spill for this location

All Materials:

Site ID:	639126
Operable Unit ID:	1386178
Operable Unit:	01
Material ID:	2400929
Material Code:	0541A
Material Name:	dielectric fluid
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported
Resource Affected:	Not reported
Oxygenate:	Not reported

N175 **CONSOLIDATED EDISON** **NY MANIFEST** **S117537516**
NW **9 NEW ST** **N/A**
< 1/8 **WHITE PLAINS, NY 10601**
0.118 mi.
624 ft. **Site 13 of 18 in cluster N**

Relative:
Higher

Actual:
201 ft.

NY MANIFEST:

EPA ID:	NYP004700894
Country:	USA
Name:	Con Edison
Address:	9 NEW ST

CONSOLIDATED EDISON (Continued) **S117537516**

Address 2: MH186
City,State,Zip: WHITE PLAINS, NY 10801
Zip 4: Not reported
Location Address 1: 9 NEW ST
Location Address 2: MH186
Location City,State,Zip: WHITE PLAINS, NY 10801
Location Zip 4: Not reported
Facility Status: Not reported
Total Tanks: Not reported
Code: BP

Mailing:
Mailing Name: Con Edison
Mailing Contact: Con Edison
Mailing Address 1: 4 IRVING PL
Mailing Address 2: 15TH FL
Mailing City,State,Zip: NEW YORK, NY 10003
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: Not reported

Manifest Data:
Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: NYD006982359
Year: 2018
Trans2 State ID: Not reported
Generator Ship Date: 12/01/2014
Trans1 Recv Date: 12/01/2014
Trans2 Recv Date: Not reported
TSD Site Recv Date: 12/02/2014
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYP004700894
Trans1 EPA ID: Not reported
Trans2 EPA ID: Not reported
TSDF ID 1: NJD002200046
TSDF ID 2: Not reported
Manifest Tracking Number: 012773417JJK
Import Indicator: N
Export Indicator: N
Discr Quantity Indicator: N
Discr Type Indicator: N
Discr Residue Indicator: N
Discr Partial Reject Indicator: N
Discr Full Reject Indicator: N
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: H110
Waste Code a: Lead
Waste Code b: Not reported
Waste Code c: Not reported
Waste Code e: Not reported
Waste Code f: Not reported
Waste Code g: Not reported
Waste Code 1: Not reported

CONSOLIDATED EDISON (Continued) **S117537516**

Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	50
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

EPA ID:	NYR000023275
Country:	USA
Name:	Consolidated Edison
Address:	9 NEW ST
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10601
Zip 4:	Not reported
Location Address 1:	9 9 NEW STREET
Location Address 2:	Not reported
Location City,State,Zip:	WHITE PLAINS, NY 10601
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Consolidated Edison
Mailing Contact:	Franklin Murray
Mailing Address 1:	4 IRVING PLACE RM 828
Mailing Address 2:	Not reported
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	2124602808

Manifest Data:

Document ID:	NYE0522513
Manifest Status:	Not reported
Trans1 State ID:	74791AV
Year:	2001
Trans2 State ID:	Not reported
Generator Ship Date:	07/20/2001
Trans1 Recv Date:	07/20/2001
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	07/23/2001
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000023275
Trans1 EPA ID:	NYD006982359
Trans2 EPA ID:	Not reported
TSDF ID 1:	NYD980593636
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported

CONSOLIDATED EDISON (Continued) **S117537516**

Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	B007
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00004
Units:	Kilograms
Number of Containers:	001
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Landfill
Specific Gravity:	01.00

Document ID:	NYE0441333
Manifest Status:	Not reported
Trans1 State ID:	80680AE
Year:	2000
Trans2 State ID:	Not reported
Generator Ship Date:	01/07/2000
Trans1 Recv Date:	01/07/2000
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	01/10/2000
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000023275
Trans1 EPA ID:	NYD006982359
Trans2 EPA ID:	Not reported
TSDF ID 1:	NYD077444263
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Mercury
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported

CONSOLIDATED EDISON (Continued) **S117537516**

Quantity:	00010
Units:	Pounds
Number of Containers:	001
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Recycle
Specific Gravity:	01.00
Document ID:	NYE0515007
Manifest Status:	Not reported
Trans1 State ID:	28190AV
Year:	2002
Trans2 State ID:	43056AV
Generator Ship Date:	02/04/2002
Trans1 Recv Date:	02/04/2002
Trans2 Recv Date:	02/05/2002
TSD Site Recv Date:	02/06/2002
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000023275
Trans1 EPA ID:	NYD006982359
Trans2 EPA ID:	NYD006982359
TSDF ID 1:	NYD077444263
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Mercury
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00010
Units:	Pounds
Number of Containers:	001
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Recycle
Specific Gravity:	01.00
Document ID:	NJA4087850
Manifest Status:	Not reported
Trans1 State ID:	S8424
Year:	2002
Trans2 State ID:	Not reported
Generator Ship Date:	02/14/2002
Trans1 Recv Date:	02/14/2002
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	02/14/2002

CONSOLIDATED EDISON (Continued) **S117537516**

Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000023275
Trans1 EPA ID:	NYD046765574
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD991291105
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Lead
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	38780
Units:	Pounds
Number of Containers:	001
Container Type:	Metal boxes, cartons, cases (including roll-offs)
Handling Method:	Treat
Specific Gravity:	01.00

Document ID:	NYE0126336
Manifest Status:	Not reported
Trans1 State ID:	43056AN
Year:	1998
Trans2 State ID:	Not reported
Generator Ship Date:	07/09/1998
Trans1 Recv Date:	07/09/1998
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	07/10/1998
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000023275
Trans1 EPA ID:	NYD006982359
Trans2 EPA ID:	Not reported
TSDF ID 1:	NYD077444263
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported

CONSOLIDATED EDISON (Continued) **S117537516**

Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Lead
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00400
Units:	Kilograms
Number of Containers:	004
Container Type:	Metal drums, barrels, kegs
Handling Method:	Landfill
Specific Gravity:	01.00

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	06/17/2009
Trans1 Recv Date:	06/17/2009
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	06/18/2009
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000023275
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NYD077444263
TSDF ID 2:	Not reported
Manifest Tracking Number:	001433344FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H141
Waste Code a:	B007
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	50

CONSOLIDATED EDISON (Continued) **S117537516**

Units:	Kilograms
Number of Containers:	1
Container Type:	Metal drums, barrels, kegs
Handling Method:	Landfill
Specific Gravity:	1
Document ID:	NYE0293477
Manifest Status:	Not reported
Trans1 State ID:	80303AB
Year:	1999
Trans2 State ID:	Not reported
Generator Ship Date:	04/16/1999
Trans1 Recv Date:	04/16/1999
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	04/19/1999
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000023275
Trans1 EPA ID:	NYD006982359
Trans2 EPA ID:	Not reported
TSDF ID 1:	NYD077444263
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	B008
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00100
Units:	Kilograms
Number of Containers:	001
Container Type:	Metal drums, barrels, kegs
Handling Method:	Landfill
Specific Gravity:	01.00
Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	10/22/2009
Trans1 Recv Date:	10/22/2009
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	10/23/2009
Part A Recv Date:	Not reported

CONSOLIDATED EDISON (Continued) **S117537516**

Part B Recv Date:	Not reported
Generator EPA ID:	NYR000023275
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NYD980593636
TSDF ID 2:	Not reported
Manifest Tracking Number:	001440917FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H141
Waste Code a:	Lead
Waste Code b:	B007
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	25
Units:	Kilograms
Number of Containers:	1
Container Type:	Metal drums, barrels, kegs
Handling Method:	Landfill
Specific Gravity:	1
Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	MAC300016672
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	07/03/2018
Trans1 Recv Date:	07/03/2018
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	07/06/2018
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000023275
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NYD077444263
TSDF ID 2:	Not reported
Manifest Tracking Number:	012167411FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N

CONSOLIDATED EDISON (Continued) **S117537516**

Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H141
Waste Code a:	Corrosive Waste
Waste Code b:	Lead
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	1600
Units:	Pounds
Number of Containers:	2
Container Type:	Metal drums, barrels, kegs
Handling Method:	Treat
Specific Gravity:	1
Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	07/14/2008
Trans1 Recv Date:	07/14/2008
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	07/15/2008
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000023275
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NYD077444263
TSDF ID 2:	Not reported
Manifest Tracking Number:	001451258FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H141
Waste Code a:	Cadmium
Waste Code b:	Chromium

CONSOLIDATED EDISON (Continued) **S117537516**

Waste Code c:	Lead
Waste Code e:	B007
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	180
Units:	Kilograms
Number of Containers:	3
Container Type:	Metal drums, barrels, kegs
Handling Method:	Landfill
Specific Gravity:	1

Document ID:	NYE0375287
Manifest Status:	Not reported
Trans1 State ID:	80336AB
Year:	1999
Trans2 State ID:	Not reported
Generator Ship Date:	01/30/1999
Trans1 Recv Date:	01/30/1999
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	02/01/1999
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000023275
Trans1 EPA ID:	NYD006982359
Trans2 EPA ID:	Not reported
TSDF ID 1:	NYD077444263
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Lead
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00100
Units:	Kilograms
Number of Containers:	001
Container Type:	Metal drums, barrels, kegs
Handling Method:	Landfill
Specific Gravity:	01.00

CONSOLIDATED EDISON (Continued) **S117537516**

Click this hyperlink while viewing on your computer to access
57 additional NY MANIFEST: record(s) in the EDR Site Report.

N176 **WHITE PLAINS SUB-STATION** **NY Spills** **S102446986**
NW **5 NEW STREET** **N/A**
< 1/8 **WHITE PLAINS, NY**
0.119 mi.
626 ft. **Site 14 of 18 in cluster N**

Relative:
Higher

Actual:
201 ft.

SPILLS:

Name:	WHITE PLAINS SUB-STATION
Address:	5 NEW STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9610321 / 1996-11-22
Facility ID:	9610321
Facility Type:	ER
DER Facility ID:	262292
Site ID:	325629
DEC Region:	3
Spill Cause:	Unknown
Spill Class:	C3
SWIS:	6017
Spill Date:	1996-11-18
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1996-11-18
CID:	266
Water Affected:	Not reported
Spill Source:	Unknown
Spill Notifier:	Affected Persons
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	1996-11-18
Spill Record Last Update:	1996-12-16
Spiller Name:	Not reported
Spiller Company:	UNKNOWN
Spiller Address:	Not reported
Spiller Company:	999
Contact Name:	Not reported
Latitude:	41.0400799
Longitude:	-73.7983400
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY 11/22/96 I RECHECKED ALL THE STORM DRAINS, NO LIQUID IN ANY OF THEM; THERE WERE SEVERAL CON ED VAULTS; THE STREET IS ONLY 50 YARDS LONG WITH A SCHOOL ON OTHER SIDE OF STREET
Remarks:	SHEEN FOUND IN STORM DRAIN NEAR DRIVEWAY. CLEANED UP.

All Materials:

Site ID:	325629
Operable Unit ID:	1041897
Operable Unit:	01
Material ID:	342532

WHITE PLAINS SUB-STATION (Continued) **S102446986**

Material Code:	0066A
Material Name:	unknown petroleum
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Surface Water
Oxygenate:	Not reported

Name:	WHITE PLAINS SUBSTATION
Address:	5 NEW STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0404755 / 2004-08-02
Facility ID:	0404755
Facility Type:	ER
DER Facility ID:	262292
Site ID:	266688
DEC Region:	3
Spill Cause:	Human Error
Spill Class:	C4
SWIS:	6017
Spill Date:	2004-08-01
Investigator:	kabrowne
Referred To:	Not reported
Reported to Dept:	2004-08-01
CID:	64
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Other
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2004-08-01
Spill Record Last Update:	2004-08-30
Spiller Name:	ERT DESK
Spiller Company:	CON EDISON
Spiller Address:	4 IRVING PLACE
Spiller Company:	999
Contact Name:	ERT DESK
Latitude:	41.0334216
Longitude:	-73.7745553
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was BROWNE
Remarks:	a drum was knocked over spilling 1 pint of dielectric fluid on the ground. Clean up is complete as of 1015 hrs. non-pcb oil.

All Materials:

Site ID:	266688
Operable Unit ID:	888136
Operable Unit:	01
Material ID:	488736
Material Code:	0541A
Material Name:	dielectric fluid

WHITE PLAINS SUB-STATION (Continued) **S102446986**

Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	L
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

N177 **NUCLEAR DEVELOPMENT CORP OF AMERICA SITE** **FUSRAP** **1016603375**
NW **5 NEW STREET** **N/A**
< 1/8 **WHITE PLAINS, NY**
0.119 mi.
626 ft. **Site 15 of 18 in cluster N**

Relative:
Higher

Actual:
201 ft.

FUSRAP:

Site Name:	NUCLEAR DEVELOPMENT CORP OF AMERICA SITE
Site Id:	NY 32
Site Status:	Eliminated from consideration under FUSRAP
Designated Name:	Not Designated
Alternate Name:	Nuclear Development Corp of America - NY 32
Location Street Address:	5 NEW STREET
Location City:	WHITE PLAINS
Location State:	NY
Location County:	Not reported
Site Oprerations:	Conducted experiments involving uranium recovery from scrap.
Site Disposition:	Eliminated - No Authority - Facility was licensed to handle nuclear materials
Radioactice Materials Handled:	Yes
Primary Radioactivce Materials Handled:	Uranium
Radiological Survey(S):	None Indicated
LM Site:	Not reported
Considered Name:	Nuclear Development Corp. of America
Site Summary:	Not reported

Website URL:

N178 **COMMERCIAL** **NY LTANKS** **S109208790**
NW **3 NEW KING STREET** **N/A**
< 1/8 **WHITE PLAINS, NY 10603**
0.119 mi.
627 ft. **Site 16 of 18 in cluster N**

Relative:
Higher

Actual:
201 ft.

LTANKS:

Name:	COMMERCIAL
Address:	3 NEW KING STREET
City,State,Zip:	WHITE PLAINS, NY 10603
Spill Number/Closed Date:	1600651 / 2017-04-04
Facility ID:	1600651
Site ID:	525932
Spill Date:	2016-04-19
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6038

COMMERCIAL (Continued) **S109208790**

Investigator:	RDBENDEL
Referred To:	Not reported
Reported to Dept:	2016-04-19
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2016-04-19
Spill Record Last Update:	2023-06-14
Spiller Name:	TOM FITSGIBBONS
Spiller Company:	LORDAE PROPERTIES
Spiller Address:	Not reported
Spiller County:	999
Spiller Contact:	DAVE GASTLE
Spiller Phone:	(631) 321-4670
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	480144
Latitude:	Not reported
Longitude:	Not reported
DEC Memo:	4-19-16 Called and spoke with Dave and then left message for Tom to return call to dispatch desk. Two USTs were tested - 550 passed, 2k failed (small dry leak?). Toms email is tom@lordae.com. jm Recv'd callback from Tom Fitzsimmons. They have been in touch with Envirostar about removing both tanks and will proceed in this direction. PBS #3-800342 jm
Remarks:	Failed Tank Test.

All Materials:

Site ID:	525932
Operable Unit ID:	1274876
Operable Unit:	01
Material ID:	2279538
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported
Resource Affected:	Not reported
Oxygenate:	Not reported

Site ID:	525932
Operable Unit ID:	1274876
Operable Unit:	01
Material ID:	2279539
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported

COMMERCIAL (Continued) **S109208790**

Resource Affected:	Not reported
Oxygenate:	Not reported
Name:	3 NEW KING ST
Address:	3 NEW KING STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0806330 / 2010-03-30
Facility ID:	0806330
Site ID:	403607
Spill Date:	2008-09-05
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6038
Investigator:	jbodee
Referred To:	WCDOH PBS
Reported to Dept:	2008-09-05
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2008-09-05
Spill Record Last Update:	2023-06-14
Spiller Name:	Not reported
Spiller Company:	JAM NEW KING HOLDING CORP
Spiller Address:	4 NEW KING ST
Spiller County:	999
Spiller Contact:	ALBERT LOPEZ
Spiller Phone:	(631) 321-4670
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	352839
Latitude:	41.0334185
Longitude:	-73.7746267
DEC Memo:	9/5/08: caller imformed owner about retest, etc.. awaiting answer...ra Unregistered PBS facility. jod 11/12/08: Passing retest on 9/26/08 after tightening fitting at boiler and repairing petrometer. NFA jod 3/30/10: As per Wayne Schneider: 0806330: 3 New king St, White Plains- passed retest after boiler fittings and petrometer were replaced NFA again! jod
Remarks:	Above company did a dry tank test and had a failure on the tank, but no product was lost.

All Materials:

Site ID:	403607
Operable Unit ID:	1160299
Operable Unit:	01
Material ID:	2151464
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum

COMMERCIAL (Continued) **S109208790**

Quantity: Not reported
Units: Not reported
Recovered: Not reported
Resource Affected: Not reported
Oxygenate: Not reported

N179 **COMMERCIAL PROPERTY** **NY Spills** **S118707282**
NW **1-3 NEW KING ST** **N/A**
< 1/8 **WHITE PLAINS, NY**
0.119 mi.
628 ft. **Site 17 of 18 in cluster N**

Relative: **Higher**

Actual: **201 ft.**

SPILLS:

Name:	COMMERCIAL PROPERTY
Address:	1-3 NEW KING ST
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	1604489 / 2017-04-04
Facility ID:	1604489
Facility Type:	ER
DER Facility ID:	485064
Site ID:	530997
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	C3
SWIS:	6038
Spill Date:	2016-08-03
Investigator:	RDBENDEL
Referred To:	Not reported
Reported to Dept:	2016-08-03
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Other
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2016-08-03
Spill Record Last Update:	2023-06-14
Spiller Name:	LINA DISAVINO
Spiller Company:	NEW KING STREET LLC
Spiller Address:	1-3 NEW KING ST
Spiller Company:	999
Contact Name:	LINA DISAVINO
Latitude:	Not reported
Longitude:	Not reported
DEC Memo:	8-3-16 Spoke with Lina. They pulled a 2k today in the rear of the bldg. and are removing a 550 tomorrow. WHDOH was on site this afternoon. PBS # is 3-800342 jm 4-4-17, email from county , NFA1600651 and 1604489 New King Street LLC 1-3 New King Street White Plains NY PBS# 3-800342 requesting NFA based on the attached closure report. The 2 spills are related, tightness test failure (1600651) and tank removal (1604489) associated with tank #1 a

COMMERCIAL PROPERTY (Continued) **S118707282**

Remarks:	2000g UST which contained #2 heating oil. Sample results below NYSDEC guidelines. NFA RDB tank removal, c/u pending

All TTF:

Facility ID:	1604489
Spill Number:	1604489
Spill Tank Test:	2500368
Site ID:	530997
Tank Number:	UST
Tank Size:	2000
Material:	0001
EPA UST:	False
UST:	True
Cause:	00
Source:	00
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	Not reported
Gross Fail:	Not reported
Modified By:	JBODEE
Last Modified Date:	Not reported

All Materials:

Site ID:	530997
Operable Unit ID:	1279784
Operable Unit:	01
Material ID:	2284872
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported
Resource Affected:	Not reported
Oxygenate:	Not reported

N180 **PBS TTF** **NY LTANKS** **S104621025**
NW **1 NEW KING STREET** **N/A**
< 1/8 **WHITE PLAINS, NY**
0.119 mi.
628 ft. **Site 18 of 18 in cluster N**

Relative:
Higher

Actual:
201 ft.

LTANKS:

Name:	PBS TTF
Address:	1 NEW KING STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0000953 / 2001-02-07
Facility ID:	0000953
Site ID:	272947
Spill Date:	2000-04-24
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6038

PBS TTF (Continued) **S104621025**

Investigator:	JBODEE
Referred To:	WESTCHESTER CNTY HEALTH DEPT
Reported to Dept:	2000-04-24
CID:	396
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2000-04-24
Spill Record Last Update:	2023-06-14
Spiller Name:	Not reported
Spiller Company:	SAME
Spiller Address:	Not reported
Spiller County:	999
Spiller Contact:	KAREN
Spiller Phone:	(914) 681-5100
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	222123
Latitude:	41.0773700
Longitude:	-73.7128840
DEC Memo:	Not reported
Remarks:	tank test failure will retest later

All Materials:

Site ID:	272947
Operable Unit ID:	822651
Operable Unit:	01
Material ID:	289183
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	G
Recovered:	Not reported
Resource Affected:	Soil
Oxygenate:	Not reported

Q181 **NY AST** **S121995578**
SE **111 MARTIN LUTHER KING JR. BLVD** **NY COOLING TOWERS** **N/A**
< 1/8 **WHITE PLAINS, NY 10601**
0.122 mi.
646 ft. **Site 1 of 13 in cluster Q**

Relative: **Higher**
Actual: **199 ft.**

WESTCHESTER CO. AST:

Name:	WESTCHESTER COUNTY COURTHOUSE
Address:	111 MARTIN LUTHER KING JR. BLVD.
City,State,Zip:	WHITE PLAINS, NY 10601
PBS Number:	3-801217
Site Status:	Active
GDS Number:	Not reported
Operator Name:	David Fazio
Owner Name:	Westchester County DPW

(Continued) **S121995578**

Owner Street:	148 Martine Avenue
Owner Address2:	Not reported
Owner City/State/Zip:	White Plains, NY 10601
Tank Number:	003
Status:	1. In-Service
Date Installation:	01/01/2006
Capacity:	25
Product Stored:	0008. Diesel
Product Stored Percent:	Not reported
Date Perm Closure:	01/01/1900
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Leak Detection:	5. In-Tank System (auto tank gauge)
Tank Secondary Containment:	Not reported
Piping Location:	1. Aboveground
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	0. None
Piping Leak Detection:	Not reported
Piping Secondary Containment:	Not reported
Overfill Prevention:	2. High Level Alarm,4. Product Level Gauge (Aboveground Only)
Spill Prevention:	Not reported
Dispenser:	2. Suction
Tank Number:	12
Status:	1. In-Service
Date Installation:	06/02/2002
Capacity:	60
Product Stored:	0008. Diesel
Product Stored Percent:	Not reported
Date Perm Closure:	01/01/1900
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Leak Detection:	6. Impervious Barrier/Concrete Pad (Aboveground Only)
Tank Secondary Containment:	1. Diking (aboveground only),10. Impervious Underlayment (AST Only)
Piping Location:	1. Aboveground
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	0. None
Piping Leak Detection:	Not reported
Piping Secondary Containment:	Not reported
Overfill Prevention:	2. High Level Alarm,4. Product Level Gauge (Aboveground Only)
Spill Prevention:	DAY TANK
Dispenser:	2. Suction
Tank Number:	3
Status:	1. In-Service
Date Installation:	01/01/1998
Capacity:	2000
Product Stored:	0008. Diesel
Product Stored Percent:	Not reported
Date Perm Closure:	01/01/1900

(Continued) **S121995578**

Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Leak Detection:	0. None
Tank Secondary Containment:	Not reported
Piping Location:	2. Underground/on Ground
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	1. Painted/Asphalt Coating
Piping Leak Detection:	Not reported
Piping Secondary Containment:	Not reported
Overfill Prevention:	4. Product Level Gauge (Aboveground Only)
Spill Prevention:	Not reported
Dispenser:	2. Suction

COOLING TOWERS:

Name:	Not reported
Address:	111 MARTIN LUTHER KING JR. BLVD
City,State,Zip:	WHITE PLAINS, NY 10601
Equipment Unique ID:	6028
Equipment Borough:	Not reported
Intended Use:	Air Conditioning
Manufacturer:	BAC
Model:	3752A-3
Cooling Capacity:	2730
Cooling Capacity Unit:	Tonnage
Commissioned Date:	09/01/2003
Inspection Date:	03/23/2022
Date of Bacteriological Collection:	06/28/2022
Date of Legionella Collection:	04/04/2024
Last Legionella Result > 1,000 CFU/mL:	lt20
Last Sampled Days:	Not reported
Reg Compliant:	Not reported
Last Update Days:	Not reported
CT Status:	Not reported
Equipment Tower Operation Duration:	Not reported
Latitude:	41.029629
Longitude:	-73.76899

Q182 **WESTCHESTER COUNTY COURTHOUSE** **NY UST** **U004442258**
SE **111 GROVE ST TOWER** **N/A**
< 1/8 **WHITE PLAINS, NY 10601**
0.122 mi.
646 ft. **Site 2 of 13 in cluster Q**

Relative:
Higher

Actual:
199 ft.

WESTCHESTER CO. UST:

Name:	WESTCHESTER COUNTY COURTHOUSE
Address:	111 GROVE ST TOWER
City,State,Zip:	WHITE PLAINS, NY 10601
Id/Status:	3-168750 / Administratively Closed
Operator Name:	Garrett Profft
Owner Name:	County of Westchester
Owner Street:	148 Martine Ave
Owner Address2:	Not reported
Owner City:	White Plains
Owner State:	NY
Owner Zipcode:	10601

WESTCHESTER COUNTY COURTHOUSE (Continued) **U004442258**

GDS Number:	Not reported
Tank Number:	3
Status:	0. Administratively closed
Capacity:	5000
Product Stored:	0008. Diesel
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	12/01/1973
Date Perm Closure:	12/26/2001
Tank Location:	Not reported
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	Not reported
Piping Location:	Not reported
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Overfill Prevention:	Not reported
Piping Secondary Containment:	Not reported
Spill Prevention:	Not reported
Dispenser:	2. Suction

Q183 **CON EDISON** **NJ MANIFEST** **S120678603**
SE **111 MARTIN LUTHER KING JR BLVD** **N/A**
< 1/8 **WHITE PLAINS, NY 10601**
0.122 mi.
646 ft. **Site 3 of 13 in cluster Q**

Relative: **Higher**
Actual: **199 ft.**

NJ MANIFEST:

EPA ID:	NYP004885055
Name:	CON EDISON
Address:	111 MARTIN LUTHER KING JR BLVD
City,State,Zip:	WHITE PLAINS, NY 10601
County:	Not reported
Mailing Address:	IRVING PL 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Telephone:	Not reported
Emergency Telephone:	Not reported
Contact:	THOMAS TEELING
Comments:	Not reported
SIC Code:	Not reported
County:	NY119
Municipal:	Not reported
Previous EPAID:	Not reported
Generator Flag:	Not reported
Transporter Flag:	Not reported
TSDF Flag:	Not reported
Name Change:	Not reported
Date Change:	Not reported

Manifest Data:

EPA ID:	NYP004885055
Manifest Number:	015323084JJK
Date Shipped:	12/30/2015
TSDF EPA ID:	NJD002200046
Transporter EPA ID:	NYD006982359
Transporter 2 EPA ID:	Not reported

CON EDISON (Continued) **S120678603**

Transporter 3 EPA ID:	Not reported
Transporter 4 EPA ID:	Not reported
Transporter 5 EPA ID:	Not reported
Transporter 6 EPA ID:	Not reported
Transporter 7 EPA ID:	Not reported
Transporter 8 EPA ID:	Not reported
Transporter 9 EPA ID:	Not reported
Transporter 10 EPA ID:	Not reported
Date Trans1 Transported Waste:	Not reported
Date Trans2 Transported Waste:	Not reported
Date Trans3 Transported Waste:	Not reported
Date Trans4 Transported Waste:	Not reported
Date Trans5 Transported Waste:	Not reported
Date Trans6 Transported Waste:	Not reported
Date Trans7 Transported Waste:	Not reported
Date Trans8 Transported Waste:	Not reported
Date Trans9 Transported Waste:	Not reported
Date Trans10 Transported Waste:	Not reported
Date TSDF Received Waste:	Not reported
TSDF EPA Facility Name:	Not reported
QTY Units:	Not reported
Transporter SEQ ID:	Not reported
Transporter-1 Date:	Not reported
Waste SEQ ID:	Not reported
Waste Type Code 2:	Not reported
Waste Type Code 3:	Not reported
Waste Type Code 4:	Not reported
Waste Type Code 5:	Not reported
Waste Type Code 6:	Not reported
Date Accepted:	Not reported
Manifest Discrepancy Type:	Not reported
Data Entry Number:	Not reported
Was Load Rejected:	Not reported
Reason Load Was Rejected:	Not reported

Q184 **CON EDISON** **RCRA NonGen / NLR** **1019909457**
SE **111 MARTIN LUTHER KING JR BLVD** **NYP004885055**
< 1/8 **WHITE PLAINS, NY 10601**
0.122 mi.
646 ft. **Site 4 of 13 in cluster Q**

Relative: **Higher**

Actual: **199 ft.**

RCRA Listings:

Date Form Received by Agency:	20151230
Handler Name:	Con Edison
Handler Address:	Martin Luther King Jr Blvd
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYP004885055
Contact Name:	THOMAS TEELING
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	212-460-3770
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified

CON EDISON (Continued) **1019909457**

Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PL 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20160909
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20151230
Handler Name:	CON EDISON

CON EDISON (Continued) **1019909457**

Federal Waste Generator Description:	Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20151230
Handler Name: CON EDISON	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

Q185 **WESTCHESTER COUNTY COURTHOUSE** **NY UST** **U004442259**
SE **111 MARTIN LUTHER KING JR. BLVD.** **N/A**
< 1/8 **WHITE PLAINS, NY 10601**
0.122 mi.
646 ft. **Site 5 of 13 in cluster Q**

Relative: **Higher**
Actual: **199 ft.**

WESTCHESTER CO. UST:

Name:	WESTCHESTER COUNTY COURTHOUSE
Address:	111 MARTIN LUTHER KING JR. BLVD.
City,State,Zip:	WHITE PLAINS, NY 10601
Id/Status:	3-801217 / Active
Operator Name:	David Fazio
Owner Name:	Westchester County DPW
Owner Street:	148 Martine Avenue
Owner Address2:	Not reported
Owner City:	White Plains
Owner State:	NY
Owner Zipcode:	10601
GDS Number:	Not reported
Tank Number:	009
Status:	1. In-Service

WESTCHESTER COUNTY COURTHOUSE (Continued) **U004442259**

Capacity:	30000
Product Stored:	0001. #2 Fuel Oil
Product Stored Percent:	Not reported
Tank Leak Detection:	1. Electronic Interstitial Monitoring
Date Installation:	10/01/2003
Date Perm Closure:	01/01/1900
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	6. Fiberglass reinforced plastic (FRP)
Tank Internal Protection:	3. Fiberglass liner (FRP)
Tank External Protection:	4. Fiberglass
Tank Secondary Containment:	4. Double-Walled (underground only)
Piping Location:	3. Aboveground/Underground Combination
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	5. Jacketed
Overfill Prevention:	2. High Level Alarm
Piping Secondary Containment:	4. Double-Walled (underground only)
Spill Prevention:	1. Catch Basin
Dispenser:	3. Gravity

Q186 **WESTCHESTER COUNTY COURTHOUSE** **RCRA NonGen / NLR** **1001119601**
SE **111 GROVE ST** **FINDS** **NYR000028902**
< 1/8 **WHITE PLAINS, NY 10601** **ECHO**
0.122 mi. **NY MANIFEST**
646 ft. **Site 6 of 13 in cluster Q**

Relative: **Higher**
Actual: **199 ft.**

RCRA Listings:

Date Form Received by Agency:	20070101
Handler Name:	Westchester County Courthouse
Handler Address:	Grove St
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYR000028902
Contact Name:	Not reported
Contact Address:	GROVE ST
Contact City,State,Zip:	WHITE PLAINS, NY 10601
Contact Telephone:	Not reported
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	County
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R3
Mailing Address:	GROVE ST
Mailing City,State,Zip:	WHITE PLAINS, NY 10601
Owner Name:	Westchester County
Owner Type:	County
Operator Name:	Westchester County
Operator Type:	County
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No

WESTCHESTER COUNTY COURTHOUSE (Continued) **1001119601**

Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20150414
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Hazardous Waste Summary:

Waste Code:	D000
Waste Description:	Not Defined
Waste Code:	D008
Waste Description:	Lead
Waste Code:	D009
Waste Description:	Mercury

Handler - Owner Operator:

Owner/Operator Indicator:	Operator
Owner/Operator Name: WESTCHESTER COUNTY	
Legal Status:	County
Date Became Current:	Not reported
Date Ended Current:	Not reported
Owner/Operator Address:	148 MARTINE AVE
Owner/Operator City,State,Zip:	WHITE PLAINS, NY 10601
Owner/Operator Telephone:	914-285-2559

WESTCHESTER COUNTY COURTHOUSE (Continued) **1001119601**

Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Owner
Owner/Operator Name: WESTCHESTER COUNTY
Legal Status: County
Date Became Current: Not reported
Date Ended Current: Not reported
Owner/Operator Address: 148 MARTINE AVE
Owner/Operator City,State,Zip: WHITE PLAINS, NY 10601
Owner/Operator Telephone: 914-285-2559
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Owner
Owner/Operator Name: WESTCHESTER COUNTY
Legal Status: County
Date Became Current: Not reported
Date Ended Current: Not reported
Owner/Operator Address: 148 MARTINE AVE
Owner/Operator City,State,Zip: WHITE PLAINS, NY 10601
Owner/Operator Telephone: 914-285-2559
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Historic Generators:
Receive Date: 19990708
Handler Name: WESTCHESTER COUNTY COURTHOUSE
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20060101
Handler Name: WESTCHESTER COUNTY COURTHOUSE
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20070101
Handler Name: WESTCHESTER COUNTY COURTHOUSE

WESTCHESTER COUNTY COURTHOUSE (Continued) **1001119601**

Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	19960906
Handler Name:	WESTCHESTER COUNTY COURTHOUSE
Federal Waste Generator Description:	Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

FINDS:
Registry ID: 110004528182

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:
The Resource Conservation and Recovery Act Information System (RCRAInfo) is EPA's comprehensive information system in support of the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. It tracks many types of information about generators, transporters, treaters, storers, and disposers of hazardous waste.

Click this hyperlink while viewing on your computer to access additional FINDS: detail in the EDR Site Report.

ECHO:
Envid: 1001119601
Registry ID: 110004528182

DFR URL:
Name: WESTCHESTER COUNTY COURTHOUSE

WESTCHESTER COUNTY COURTHOUSE (Continued) **1001119601**

Address: 111 GROVE ST
City,State,Zip: WHITE PLAINS, NY 10601

NY MANIFEST:
EPA ID: NYR000028902
Country: USA
Name: Westchester County Courthouse
Address: 111 GROVE ST
Address 2: Not reported
City,State,Zip: WHITE PLAINS, NY 10601
Zip 4: Not reported
Location Address 1: 111 GROVE STREET
Location Address 2: Not reported
Location City,State,Zip: WHITE PLAINS, NY 10601
Location Zip 4: Not reported
Facility Status: Not reported
Total Tanks: Not reported
Code: BP

Mailing:
Mailing Name: Westchester County Courthouse
Mailing Contact: John Blake/Randi Smith
Mailing Address 1: 123 MAIN STREET
Mailing Address 2: Not reported
Mailing City,State,Zip: WHITE PLAINS, NY 10601
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: 9146816384

Manifest Data:
Document ID: NYB8450235
Manifest Status: Not reported
Trans1 State ID: MA102
Year: 1997
Trans2 State ID: Not reported
Generator Ship Date: 05/07/1997
Trans1 Recv Date: 05/07/1997
Trans2 Recv Date: Not reported
TSD Site Recv Date: 05/12/1997
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYR000028902
Trans1 EPA ID: MA5000002394
Trans2 EPA ID: Not reported
TSDF ID 1: AZ0000337360
TSDF ID 2: Not reported
Manifest Tracking Number: Not reported
Import Indicator: Not reported
Export Indicator: Not reported
Discr Quantity Indicator: Not reported
Discr Type Indicator: Not reported
Discr Residue Indicator: Not reported
Discr Partial Reject Indicator: Not reported
Discr Full Reject Indicator: Not reported
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported

WESTCHESTER COUNTY COURTHOUSE (Continued) **1001119601**

MGMT Method Type Code:	Not reported
Waste Code 1:	Mercury
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00855
Units:	Pounds
Number of Containers:	011
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Recycle
Specific Gravity:	01.00
Waste Code 7:	Mercury
Waste Code 8:	Not reported
Waste Code:	Not reported
Waste Code 10:	Not reported
Waste Code 11:	Not reported
Quantity:	00170
Units:	Pounds
Number of Containers:	015
Container Type:	Fiber or plastic boxes, cartons, cases
Handling Method:	Recycle
Specific Gravity:	01.00

Document ID:	NYB8593956
Manifest Status:	Not reported
Trans1 State ID:	PTH7946
Year:	1997
Trans2 State ID:	Not reported
Generator Ship Date:	01/22/1997
Trans1 Recv Date:	01/22/1997
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	01/27/1997
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000028902
Trans1 EPA ID:	MA5000002394
Trans2 EPA ID:	Not reported
TSDF ID 1:	AZ0000337360
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Mercury
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported

WESTCHESTER COUNTY COURTHOUSE (Continued) **1001119601**

Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	01900
Units:	Pounds
Number of Containers:	019
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Recycle
Specific Gravity:	01.00
Document ID:	NYB8032266
Manifest Status:	Not reported
Trans1 State ID:	PTH7945
Year:	1996
Trans2 State ID:	Not reported
Generator Ship Date:	09/25/1996
Trans1 Recv Date:	09/25/1996
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	10/07/1996
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000028902
Trans1 EPA ID:	MA5000002394
Trans2 EPA ID:	Not reported
TSDF ID 1:	AZ0000337360
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Mercury
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	01100
Units:	Pounds
Number of Containers:	011
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Recycle
Specific Gravity:	01.00

P187
NE
< 1/8
0.123 mi.
648 ft.

AMERICAN DENTAL OFFICES #5
200 HAMILTON AVENUE
WHITE PLAINS, NY 10601

Site 2 of 8 in cluster P

E MANIFEST | **1027792507** | **N/A**

Relative:
Higher

Actual:
201 ft.

E MANIFEST:

Manifest Tracking Number:	019977263JJK
Last Updated Date:	20200107
Shipped Date:	20190801
Received Date:	20190820
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	CESQG
Generator Name:	American Dental Offices #5
Generator Location Street Number:	Not reported
Generator Location Street 1:	200 HAMILTON AVENUE
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	200 HAMILTON AVENUE
Generator Mail Street 2:	Not reported
Generator Mail City:	WHITE PLAINS
Generator Mail Zip:	10601
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	RID040098352
Designated Facility Name:	Northland Environmental, Llc
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	275 Allens Avenue
Designated Facility Mail City:	Providence
Designated Facility Mail Zip:	02905
Designated Facility Mail State:	RI
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	275 Allens Avenue
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	Providence
Designated Facility Location Zip:	02905
Designated Facility Location State:	RI
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Manifest Tracking Number:	018668533JJK
Last Updated Date:	20190213
Shipped Date:	20181205
Received Date:	20181228
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	CESQG
Generator Name:	American Dental Offices #5
Generator Location Street Number:	Not reported
Generator Location Street 1:	200 HAMILTON AVENUE
Generator Location Street 2:	Not reported

AMERICAN DENTAL OFFICES #5 (Continued) **1027792507**

Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	200 HAMILTON AVENUE
Generator Mail Street 2:	Not reported
Generator Mail City:	WHITE PLAINS
Generator Mail Zip:	10601
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	RID040098352
Designated Facility Name:	Northland Environmental, Llc
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	275 Allens Avenue
Designated Facility Mail City:	Providence
Designated Facility Mail Zip:	02905
Designated Facility Mail State:	RI
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	275 Allens Avenue
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	Providence
Designated Facility Location Zip:	02905
Designated Facility Location State:	RI
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Federal Waste:

Manifest Tracking Number:	018668533JJK
Waste Line Number:	1
Federal Waste Code:	D011
Federal Waste:	SILVER

Transporter:

Manifest Tracking Number:	018668533JJK
Transporter Line Number:	1
Transporter EPA ID:	NYR000076513
Transporter Name:	Approved Storage & Waste Haul.
Manifest Tracking Number:	018668533JJK
Transporter Line Number:	2
Transporter EPA ID:	PAD982661381
Transporter Name:	Republic Environmental Systems Transportation Group Llc

Waste Line:

Manifest Tracking Number:	018668533JJK
Waste Line Number:	1
U.S. DOT Hazardous Indicator:	Y
U.S. DOT ID Number:	NA3082
U.S. DOT Description:	Na3082 Hazardous Waste, Liquid, N.O.S. (Silver) Iii 9 D011=5
Non-Hazardous Waste Description:	Not reported
Number of Containers:	4
Container Type Code:	DF
Container Type Description:	Fiberboard or plastic drums, barrels, kegs
Waste Quantity:	20

AMERICAN DENTAL OFFICES #5 (Continued) **1027792507**

Quantity Unit of Measure Code:	G
Quantity Unit of Measure Description:	Gallons
Waste Quantity, in Tons:	0.083402835
Acute Waste Quantity, in Tons:	0
Non-Acute Waste Quantity, in Tons:	0.083402835
Waste Quantity, in Kilograms:	75.64887
Acute Waste Quantity, in Kilograms:	0
Non-Acute Waste Quantity, in Kilorgrams:	75.64887
Management Method Code:	H141
Management Method Description:	STORAGE, BULKING AND/OR TRANSFER OFF SITE
Waste Residue Indicator:	N
Quantity Discrepancy Indicator:	N
Waste Type Discrepancy Indicator:	N
Waste Density:	Not reported
Waste Density Unit of Measure Code:	Not reported
Waste Density Unit of Measure Description:	Not reported
Form Code:	Not reported
Form Code Description:	Not reported
Source Code:	Not reported
Source Code Description:	Not reported
Waste Minimization Code:	Not reported
Waste Minimization Code Description:	Not reported
Consent Number:	Not reported
EPA Waste Indicator:	Y

P188 **WHITE PLAINS MALL CLEANERS** **EDR Hist Cleaner** **1020120254**
NE **200 HAMILTON AVE** **N/A**
< 1/8 **WHITE PLAINS, NY 10601**
0.123 mi.
648 ft. **Site 3 of 8 in cluster P**

Relative: EDR Hist Cleaner
Higher

Actual:
201 ft.

Year:	Name:	Type:
1996	WHTIE PLAINS MALL CLEANERS	Drycleaning Plants, Except Rugs
1997	WHTIE PLAINS MALL CLEANERS	Drycleaning Plants, Except Rugs
1998	WHITE PLAINS MALL CLEANERS	Drycleaning Plants, Except Rugs
1999	WHITE PLAINS MALL CLEANERS	Drycleaning Plants, Except Rugs
2000	WHITE PLAINS MALL CLEANERS	Drycleaning Plants, Except Rugs
2001	WHITE PLAINS MALL CLEANERS	Drycleaning Plants, Except Rugs
2002	WHITE PLAINS MALL CLEANERS	Drycleaning Plants, Except Rugs
2003	WHITE PLAINS MALL CLEANERS	Drycleaning Plants, Except Rugs

---

P189 **HAMILTON GREEN PHASE 1** **NY BROWNFIELDS** **S120958439**
NE **200 HAMILTON AVENUE** **NY Spills** **N/A**
< 1/8 **WHITE PLAINS, NY 10601** **NY MANIFEST**
0.123 mi. **NY SPDES**
648 ft. **Site 4 of 8 in cluster P**

Relative: BROWNFIELDS:
Higher

Actual:
201 ft.

Name:	HAMILTON GREEN
Address:	200 HAMILTON AVENUE
City,State,Zip:	WHITE PLAINS, NY 10601
Program:	BCP
Site Code:	570663
Acres:	1.940

HAMILTON GREEN PHASE 1 (Continued) **S120958439**

HW Code: C360177
SWIS: 6017
Town: White Plains (c)
Record Added Date: 05/22/2018
Record Updated Date: 06/20/2023
Update By: KATHOMPS
Site Description: Site Location: The 1.94-acre site is located at 200 Hamilton Avenue, White Plains, Westchester County. The site is located on tax lot 125.67-5-1.2. The site is a portion of the two-story White Plains Mall, located in a mixed-use commercial and residential neighborhood. Barker Avenue, a restaurant, and a hotel are located north of the site. Cottage Place, a parking lot, a condominium building, and Berkley College student dormitories are located east of the site. Hamilton Avenue and a New York Power Authority Building are located south of the site. The remaining portion of the White Plains Mall and mall parking lot are located east of the site. Site Features: The majority of the site is improved with the White Plains Mall, which is vacant. The remainder of the White Plains Mall and associated parking area is present on the eastern adjacent BCP Site C360221 on tax lot 125.67-5-1.1. The site is located approximately 0.35 miles from the Bronx River. It is not located in a flood zone. Current Zoning and Land Use: The site is located in a Transit Development District (TD-1). The surrounding properties include residential and commercial use. Past Use and Investigation of the Site: The site was developed with several small buildings, including dwellings and garages, prior to 1894. Between 1892 and 1902, a tributary to the Bronx River was visible on maps of the site, suggesting the area may have been elevated from its original topographic level. By 1930 multiple businesses operated on-site, including a gypsum partitions business, an electric motors building, a paint store, a plumbing shop and a candy manufacturer. The candy manufacturer, along with a gasoline station located in the south-eastern portion of the site, are estimated to have been on-site from the 1930 s through the 1970 s. By 1987, all on-site buildings were demolished and replaced by the White Plains Mall. A dry-cleaning facility is listed as a White Plains Mall occupant in 2010 and 2011. Use of the site as a candy manufacturer, gasoline station and dry-cleaning operations may have contributed to site contamination. Geophysical investigations conducted to date have not indicated any underground storage tanks exist on-site. Spill Number 17-06297 was reported September 28, 2017, based on evidence of petroleum contamination in soil and groundwater. In addition, contaminants of concern have been identified in soil vapor. Site Geology and Hydrogeology: Based on the United States Geological Survey and Westchester County Geographic Information System, the site lies at elevations ranging from 185 to 200 feet above the National Geodetic Vertical Datum of 1983. Regional topography slopes downward to the west. Groundwaters flows in the southwesterly direction. Groundwater depths range from approximately 9.58 to 23. feet below grade (ft bg). Deeper groundwater depths were found in the eastern portion of the site. The soils at the site are characterized as Uf (Urban Land) which is covered by pavement, concrete, buildings, and other structures. A fill stratum is encountered from grade to depths of 12 ft bg. The fill layer consists of sand, silt, gravel, organics (wood/grass), brick, asphalt, and rubber. A layer of clay and silt were encountered beneath the fill between 7 and 13 ft bg. Sand is present in the layer of clay and silt, but content varied across the site. Between approximately 13 and 25.5 ft bg, a sand layer was

HAMILTON GREEN PHASE 1 (Continued) **S120958439**

encountered. The sand stratum consisted of brown, medium to coarse sand, little to some silt, and trace amounts of gravel. During geophysical investigations of the site, bedrock was encountered from approximately 13 to 37 ft bg. The depth of bedrock corresponded to the approximate elevations of the site.

Env Problem: Environmental investigations have identified metals, semi-volatile organic compounds (SVOCs), and volatile organic compounds (VOCs), in site soils; VOCs, including methyl-tert-butyl-ether (MTBE) in site groundwater; and VOCs in soil gas at the site. Soil: Soil borings have been advanced to a maximum depth of 11 ft bg. The maximum photoionization detector reading to date as been as high as 1,370 parts per million (ppm). Soil impacts include VOCs (chlorinated and petroleum-related compounds), SVOCs (polyaromatic hydrocarbons [PAHs]), and metals (chromium, lead, mercury, and zinc). Investigation into the nature and extent of soil contamination is on-going. Groundwater: Petroleum-related VOCs, including benzene, toluene, ethylbenzene and xylenes, collectively referred to as BTEX, were detected at concentrations above New York State Ambient Water Quality Standards. MTBE, which was added to gasoline in New York from 1979 until 2004, was also detected, which suggests an off-site source has contributed to the groundwater plume, since the on-site gas station closed prior to 1970. Investigation into the nature and extent of groundwater contamination is on-going. Soil Vapor: Sampling of sub-slab soil vapor points has indicated elevated concentrations of VOCs, including trichloroethylene and methylene chloride, within the footprint of the proposed redevelopment area. Investigation into the nature and extent of soil vapor impacts is on-going.

Health Problem: Information submitted with the BCP application regarding the conditions at the site are currently under review and will be revised as additional information becomes available.

Dump: False
Structure: False
Lagoon: False
Landfill: False
Pond: False
Disp Start: Not reported
Disp Term: Not reported
Lat/Long: Not reported
Dell: Not reported
Record Add: 2018-08-02 15:32:00
Record Upd: 2022-03-03 17:39:00
Updated By: JEBROWN
Own Op: 6
Sub Type: P03
Owner Name: Kenneth D. Narva
Owner Company: S-WD/WP LLC
Owner Address: c/o Law Office of Denise D’Ambrosio
Owner Addr2: 202 Mamaroneck Ave., Suite 601
Owner City,St,Zip: White Plains, NY 10601
Owner Country: United States of America
Own Op: Document Repository
Sub Type: NNN
Owner Name: Brian Kenney
Owner Company: White Plains Public Library
Owner Address: 100 Martine Avenue
Owner Addr2: Not reported
Owner City,St,Zip: White Plains, NY 10601

HAMILTON GREEN PHASE 1 (Continued) **S120958439**

Owner Country:	United States of America
Own Op:	4
Sub Type:	NNN
Owner Name:	White Plains Mall/ Parking Lot
Owner Company:	White Plains Mall/ Parking Lot
Owner Address:	200 Hamilton Avenue
Owner Addr2:	Not reported
Owner City,St,Zip:	White Plains, NY 10601
Owner Country:	United States of America
Own Op:	1
Sub Type:	P03
Owner Name:	c/o the Cappelli Organization
Owner Company:	S-WD/WP LLC
Owner Address:	Attn: Bruce Berg
Owner Addr2:	5 RENAISSANCE SQUARE, 42ND FLOOR
Owner City,St,Zip:	White Plains, NY 10601
Owner Country:	United States of America
HW Code:	Not reported
Waste Type:	Not reported
Waste Quantity:	Not reported
Waste Code:	Not reported
Crossref ID:	1706297
Cross Ref Type Code:	01
Cross Ref Type:	Spill No.
Record Added Date:	2022-05-03 14:02:00
Record Updated:	2022-05-03 14:02:00
Updated By:	GLWHITE

SPILLS:

Name:	SOUTHEAST SIDE OF PROPERTY
Address:	200 HAMILTON AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	1706297 / 2022-08-12
Facility ID:	1706297
Facility Type:	ER
DER Facility ID:	514102
Site ID:	560605
DEC Region:	3
Spill Cause:	Unknown
Spill Class:	A1
SWIS:	6017
Spill Date:	2017-09-22
Investigator:	TDGHIOSA
Referred To:	Not reported
Reported to Dept:	2017-09-28
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Other
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2017-09-28
Spill Record Last Update:	2022-08-12

HAMILTON GREEN PHASE 1 (Continued) **S120958439**

Spiller Name:	Not reported
Spiller Company:	UNKNOWN
Spiller Address:	Not reported
Spiller Company:	999
Contact Name:	BECKY
Latitude:	Not reported
Longitude:	Not reported
DEC Memo:	9/28/17 AKRF was performing Phase II, noticed some sites where soil seemed odiferous and possibly contaminated. Took soil and gw samples, soil samples came back below CP-51. GW samples came back high in MTBE, benzene, and toluene in 3 areas. Site used to be old shopping mall. AKRF states that there was a gas station at site in 1970's, and there is currently a gas station across the road from the site. Will send in copy of soil and gw analysis. ga 10/05/17 Becky called and said the report will be completed soon and she expects to submit it in a week or two. TG 12/21/17 AKRF submitted a Phase II Investigation Report (See report in DecDocs.) TG 05/03/22 Greta White emailed the following, Good afternoon, Todd, This spill is to be administratively closed as it will be rolled into the BCP under site C360221 WP Mall Cleaners & Gas Station. The BCP Agreement was executed on April 22. I have added a cross reference in the spill file to this BCP site, as well as the adjoining site, C360177 Hamilton Green. At one time the Hamilton Green site (C360177) included the land that is now part of both the C360177 and C360221 sites (until the owner terminated the BCA, split the site and sold half). The owners of the Hamilton Green site (they submitted a new BCP application at the end of last year) and the WP Mall site both agree that the spill number can be assigned to the WP Mall side of the site C360221. Both sites intend on excavating all material above USCOs and applying a product like OCR to the excavation for groundwater remediation, and testing for future soil vapor intrusion. Please let me know if you require any further information from me in order to close this spill. Thank you, Greta Greta White, P.G. Assistant Geologist, Division of Environmental Remediation New York State Department of Environmental Conservation 625 Broadway, Albany, New York 12233-7014 P: (518) 402-2029 - F: (518) 402-9679 - greta.white@dec.ny.gov
	Not reported
Remarks:	historic spill, found last week after samples were taken, just ground water impacted, clean up is pending

All Materials:

Site ID:	560605
Operable Unit ID:	1308600
Operable Unit:	01
Material ID:	2315602
Material Code:	0009
Material Name:	gasoline

HAMILTON GREEN PHASE 1 (Continued) **S120958439**

Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported
Resource Affected:	Groundwater
Oxygenate:	Not reported

NY MANIFEST:

EPA ID:	NYP004937316
Country:	USA
Name:	Con Edison - Vault 9075
Address:	200 HAMILTON AVE & COTTAGE PL
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10601
Zip 4:	Not reported
Location Address 1:	200 HAMILTON AVE & COTTAGE PL
Location Address 2:	Not reported
Location City,State,Zip:	WHITE PLAINS, NY 10601
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Edison - Vault 9075
Mailing Contact:	Con Edison
Mailing Address 1:	4 IRVING PL 15TH FL NE
Mailing Address 2:	Not reported
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	Not reported

SPDES:

Name:	Hamilton Green Phase 1
Address:	200 HAMILTON AVENUE
City,State,Zip:	WHITE PLAINS, NY 10601
Permit Number:	NYR11M557
State-Region:	3
Expiration Date:	Not reported
Current Major Minor Status:	Not reported
Primary Facility SIC Code:	Not reported
State Water Body Name:	Bronx River
Limit Set Status Flag:	Not reported
Total Actual Average Flow(MGD):	Not reported
Total App Design Flow(MGD):	Not reported
UDF1:	Not reported
Lat/Long:	Not reported
DMR Cognizant Official:	Not reported
UDF2:	Not reported
UDF3:	Not reported
FIPS County Code:	Not reported

HAMILTON GREEN PHASE 1 (Continued) **S120958439**

Non-Gov Permit Affiliation Type Desc:	Not reported
Non-Gov Permit Org Formal Name:	Not reported
Non-Gov Permit Street Address:	Not reported
Non-Gov Permit Supplemental Location:	Not reported
Non-Gov Permit City:	Not reported
Non-Gov Permit State Code:	Not reported
Non-Gov Permit Zip Code:	Not reported
Non-Gov Facility Affiliation Type Desc:	Not reported
Non-Gov Facility Org Formal Name:	Not reported
Non-Gov Facility Street Address:	Not reported
Non-Gov Facility Supplemental Location:	Not reported
Non-Gov Facility City:	Not reported
Non-Gov Facility State Code:	Not reported
Non-Gov Facility Zip Code:	Not reported
State Water Body:	Not reported
Region Permit Processed:	Not reported
Dow Discharge Class Code:	Not reported
SPDES Class Description:	Not reported
Affiliation Type Description:	Not reported
Name:	Not reported
Contacts Title:	Not reported
Contacts Email:	Not reported
NOI Submission Date:	Not reported
Facility Type:	Construction Permit - 2003_present

Q190 **WESTCHESTER COUNTY COURT HOUSE** **RCRA-VSQG** **1007371355**
SE **110 DR MARTIN LUTHER KING JR BLVD** **NYR000124206**
< 1/8 **WHITE PLAINS, NY 10601**
0.123 mi.
650 ft. **Site 7 of 13 in cluster Q**

Relative: **Higher**
Actual: **203 ft.**

RCRA Listings:

Date Form Received by Agency:	20070101
Handler Name:	Westchester County Court House
Handler Address:	Dr Martin Luther King Jr Blvd
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYR000124206
Contact Name:	DAVID W LOMASNEY
Contact Address:	DR MARTIN LUTHER KING JR BLVD
Contact City,State,Zip:	WHITE PLAINS, NY 10601
Contact Telephone:	914-946-9681
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	County
Federal Waste Generator Description:	Conditionally Exempt Small Quantity Generator
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Handler Activities
State District Owner:	Ny
State District:	NYSDEC R3
Mailing Address:	DR MARTIN LUTHER KING JR BLVD
Mailing City,State,Zip:	WHITE PLAINS, NY 10601
Owner Name:	No Name Found
Owner Type:	County
Operator Name:	No Name Found
Operator Type:	County

WESTCHESTER COUNTY COURT HOUSE (Continued) **1007371355**

Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20150414
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Hazardous Waste Summary:

Waste Code:	D007
Waste Description:	Chromium

Handler - Owner Operator:

Owner/Operator Indicator:	Operator
Owner/Operator Name: DON MACDONALD DPW	
Legal Status:	County
Date Became Current:	20040421
Date Ended Current:	Not reported
Owner/Operator Address:	Not reported
Owner/Operator City,State,Zip:	Not reported
Owner/Operator Telephone:	Not reported
Owner/Operator Telephone Ext:	Not reported

WESTCHESTER COUNTY COURT HOUSE (Continued) **1007371355**

Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Operator
Owner/Operator Name: NO NAME FOUND
Legal Status: County
Date Became Current: 20040421
Date Ended Current: Not reported
Owner/Operator Address: Not reported
Owner/Operator City,State,Zip: Not reported
Owner/Operator Telephone: Not reported
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Owner
Owner/Operator Name: WESTCHESTER COUNTY
Legal Status: County
Date Became Current: 20040421
Date Ended Current: Not reported
Owner/Operator Address: Not reported
Owner/Operator City,State,Zip: Not reported
Owner/Operator Telephone: Not reported
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Owner
Owner/Operator Name: NO NAME FOUND
Legal Status: County
Date Became Current: 20040421
Date Ended Current: Not reported
Owner/Operator Address: Not reported
Owner/Operator City,State,Zip: Not reported
Owner/Operator Telephone: Not reported
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Historic Generators:
Receive Date: 20060101
Handler Name: WESTCHESTER COUNTY COURT HOUSE
Federal Waste Generator Description: Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20070101
Handler Name: WESTCHESTER COUNTY COURT HOUSE
Federal Waste Generator Description: Very Small Quantity Generator (formerly Conditionally-Exempt Small

WESTCHESTER COUNTY COURT HOUSE (Continued) **1007371355**

	Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20040430
Handler Name:	WESTCHESTER COUNTY COURT HOUSE
Federal Waste Generator Description:	Large Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

List of NAICS Codes and Descriptions:

NAICS Code:	92211
NAICS Description:	Courts

Facility Has Received Notices of Violations:

Violations:	No Violations Found

Evaluation Action Summary:

Evaluations:	No Evaluations Found

Q191 **WESTCHESTER COUNTY COURTHOUSE** **NY UST** **U004442257**
SE **110 GROVE ST** **N/A**
< 1/8 **WHITE PLAINS, NY 10601**
0.123 mi.
650 ft. **Site 8 of 13 in cluster Q**

Relative: **Higher**
Actual: **203 ft.**

WESTCHESTER CO. UST:

Name:	WESTCHESTER COUNTY COURTHOUSE
Address:	110 GROVE ST
City,State,Zip:	WHITE PLAINS, NY 10601
Id/Status:	3-168742 / Administratively Closed
Operator Name:	Garrett Profft
Owner Name:	County of Westchester
Owner Street:	Michaelian Office Bldg
Owner Address2:	Not reported
Owner City:	White Plains
Owner State:	NY
Owner Zipcode:	10601
GDS Number:	Not reported
Tank Number:	2

WESTCHESTER COUNTY COURTHOUSE (Continued) **U004442257**

Status:	0. Administratively closed
Capacity:	25000
Product Stored:	Not reported
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	12/01/1973
Date Perm Closure:	12/26/2001
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	Not reported
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Overfill Prevention:	Not reported
Piping Secondary Containment:	Not reported
Spill Prevention:	Not reported
Dispenser:	2. Suction

K192 **CON EDISON MANHOLE 466** **RCRA NonGen / NLR** **1014918853**
ENE **199 MAIN ST & MAMARONECK AVE** **NY MANIFEST** **NYP004224721**
1/8-1/4 **WHITE PLAINS, NY 10601** **NJ MANIFEST**
0.125 mi.
661 ft. **Site 26 of 27 in cluster K**

Relative: **Higher**
Actual: **209 ft.**

RCRA Listings:

Date Form Received by Agency:	20110218
Handler Name:	Con Edison Manhole 466
Handler Address:	Main St & Mamaroneck Ave
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYP004224721
Contact Name:	DOMINIC BIZZARO
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	914-925-6219
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	SR SPECIALIST
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PL RM 828
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No

CON EDISON MANHOLE 466 (Continued) **1014918853**

Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20110701
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20110119
Handler Name: CON EDISON MANHOLE 466	
Federal Waste Generator Description:	Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20110218
Handler Name: CON EDISON MANHOLE 466	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny

CON EDISON MANHOLE 466 (Continued) **1014918853**

Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

NY MANIFEST:

EPA ID:	NYP004224721
Country:	USA
Name:	Coned - Mh466
Address:	199 MAIN ST & MAMARONECK AVE
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10601
Zip 4:	Not reported
Location Address 1:	MAIN ST
Location Address 2:	MAMARONECK AVE
Location City,State,Zip:	WHITE PLAINS, NY 10601
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Coned - Mh466
Mailing Contact:	Coned - Mh466
Mailing Address 1:	4 IRVING PLACE
Mailing Address 2:	Not reported
Mailing City,State,Zip:	NEW YORK, NY 10004
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	Not reported

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	01/19/2011
Trans1 Recv Date:	01/19/2011
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	01/20/2011

CON EDISON MANHOLE 466 (Continued) **1014918853**

Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004224721
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	007655840JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H111
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	50
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

NJ MANIFEST:

EPA ID:	NYP004224721
Name:	CON EDISON MANHOLE 466
Address:	199 MAIN ST & MAMARONECK AVE
City,State,Zip:	WHITE PLAINS, NY 10601
County:	Not reported
Mailing Address:	IRVING PL RM 828
Mailing City,State,Zip:	NEW YORK, NY 10003
Telephone:	Not reported
Emergency Telephone:	Not reported
Contact:	DOMINIC BIZZARO
Comments:	Not reported
SIC Code:	Not reported
County:	NY119
Municipal:	Not reported
Previous EPAID:	Not reported
Generator Flag:	Not reported
Transporter Flag:	Not reported

CON EDISON MANHOLE 466 (Continued) **1014918853**

TSDF Flag:	Not reported
Name Change:	Not reported
Date Change:	Not reported

Manifest Data:

EPA ID:	NYP004224721
Manifest Number:	007655840JJK
Date Shipped:	1/19/2011
TSDF EPA ID:	NJD002200046
Transporter EPA ID:	NYD006982359
Transporter 2 EPA ID:	Not reported
Transporter 3 EPA ID:	Not reported
Transporter 4 EPA ID:	Not reported
Transporter 5 EPA ID:	Not reported
Transporter 6 EPA ID:	Not reported
Transporter 7 EPA ID:	Not reported
Transporter 8 EPA ID:	Not reported
Transporter 9 EPA ID:	Not reported
Transporter 10 EPA ID:	Not reported
Date Trans1 Transported Waste:	Not reported
Date Trans2 Transported Waste:	Not reported
Date Trans3 Transported Waste:	Not reported
Date Trans4 Transported Waste:	Not reported
Date Trans5 Transported Waste:	Not reported
Date Trans6 Transported Waste:	Not reported
Date Trans7 Transported Waste:	Not reported
Date Trans8 Transported Waste:	Not reported
Date Trans9 Transported Waste:	Not reported
Date Trans10 Transported Waste:	Not reported
Date TSDF Received Waste:	Not reported
TSDF EPA Facility Name:	Not reported
QTY Units:	Not reported
Transporter SEQ ID:	Not reported
Transporter-1 Date:	Not reported
Waste SEQ ID:	Not reported
Waste Type Code 2:	Not reported
Waste Type Code 3:	Not reported
Waste Type Code 4:	Not reported
Waste Type Code 5:	Not reported
Waste Type Code 6:	Not reported
Date Accepted:	Not reported
Manifest Discrepancy Type:	Not reported
Data Entry Number:	Not reported
Was Load Rejected:	Not reported
Reason Load Was Rejected:	Not reported

Waste:

Manifest Year:	Not reported
Waste Code:	D008
Hand Code:	H111
Quantity:	50.00
Unit:	Pounds

K193 **199 MAIN STREET REALTY CORP.** **NY UST** **U004175928**
ENE **199 MAIN STREET** **NY AST** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.125 mi.
661 ft. **Site 27 of 27 in cluster K**

Relative:
Higher

Actual:
209 ft.

WESTCHESTER CO. UST:

Name:	199 MAIN STREET REALTY CORP.
Address:	199 MAIN STREET
City,State,Zip:	WHITE PLAINS, NY 10601
Id/Status:	3-049824 / Active
Operator Name:	Frank Longhitano
Owner Name:	199 Main Street Realty Corp.
Owner Street:	P.O. Box 8197
Owner Address2:	Not reported
Owner City:	White Plains
Owner State:	NY
Owner Zipcode:	10601
GDS Number:	Not reported
Tank Number:	199
Status:	4. Closed - in place
Capacity:	5000
Product Stored:	Not reported
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	Not reported
Date Perm Closure:	11/01/1994
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	0. No Pipiing
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Overfill Prevention:	0. None
Piping Secondary Containment:	Not reported
Spill Prevention:	0. None
Dispenser:	2. Suction
Tank Number:	201
Status:	4. Closed - in place
Capacity:	5000
Product Stored:	Not reported
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	Not reported
Date Perm Closure:	08/01/1994
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	0. No Pipiing
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Overfill Prevention:	0. None

199 MAIN STREET REALTY CORP. (Continued) **U004175928**

Piping Secondary Containment: Not reported
Spill Prevention: 0. None
Dispenser: 2. Suction

WESTCHESTER CO. AST:
Name: 199 MAIN STREET REALTY CORP.
Address: 199 MAIN STREET
City,State,Zip: WHITE PLAINS, NY 10601
PBS Number: 3-049824
Site Status: Active
GDS Number: Not reported
Operator Name: Frank Longhitano
Owner Name: 199 Main Street Realty Corp.
Owner Street: P.O. Box 8197
Owner Address2: Not reported
Owner City/State/Zip: White Plains, NY 10601

Tank Number: 202
Status: 1. In-Service
Date Installation: 11/01/1994
Capacity: 5000
Product Stored: 0001. #2 Fuel Oil
Product Stored Percent: Not reported
Date Perm Closure: 01/01/1900
Tank Location: 3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type: 1. Steel/Carbon steel/Iron
Tank Internal Protection: 0. None
Tank External Protection: 1. Painted/Asphalt Coating
Tank Leak Detection: 6. Impervious Barrier/Concrete Pad (Aboveground Only)
Tank Secondary Containment: 2. Vault (w/ access),10. Impervious Underlayment (AST Only)
Piping Location: 1. Aboveground
Piping Type: 1. Steel/Carbon/ Steel/Iron
Piping External Protection: 0. None
Piping Leak Detection: Not reported
Piping Secondary Containment: Not reported
Overfill Prevention: 4. Product Level Gauge (Aboveground Only),5. Vent Whistle
Spill Prevention: 1. Catch Basin
Dispenser: 2. Suction

P194 **CON EDISON** **NY MANIFEST** **S117738350**
NE **HAMILTON AVE & RENNAISANCE** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10801**
0.126 mi.
664 ft. **Site 5 of 8 in cluster P**

Relative: **Higher**
Actual: **207 ft.**

NY MANIFEST:
EPA ID: NYP004713814
Country: USA
Name: Con Edison
Address: HAMILTON AVE & RENNAISANCE
Address 2: MH8323
City,State,Zip: WHITE PLAINS, NY 10801
Zip 4: Not reported
Location Address 1: HAMILTON AVE & RENNAISANCE
Location Address 2: MH8323
Location City,State,Zip: WHITE PLAINS, NY 10801
Location Zip 4: Not reported

CON EDISON (Continued) **S117738350**

Facility Status: Not reported
Total Tanks: Not reported
Code: BP

Mailing:
Mailing Name: Con Edison
Mailing Contact: Con Edison
Mailing Address 1: 4 IRVING PL
Mailing Address 2: 15TH FL
Mailing City,State,Zip: NEW YORK, NY 10003
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: Not reported

Manifest Data:
Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: NYD006982359
Year: 2018
Trans2 State ID: Not reported
Generator Ship Date: 01/11/2015
Trans1 Recv Date: 01/11/2015
Trans2 Recv Date: Not reported
TSD Site Recv Date: 01/13/2015
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYP004713814
Trans1 EPA ID: Not reported
Trans2 EPA ID: Not reported
TSDF ID 1: NJD002200046
TSDF ID 2: Not reported
Manifest Tracking Number: 013244426JJK
Import Indicator: N
Export Indicator: N
Discr Quantity Indicator: N
Discr Type Indicator: N
Discr Residue Indicator: N
Discr Partial Reject Indicator: N
Discr Full Reject Indicator: N
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: H110
Waste Code a: Lead
Waste Code b: Not reported
Waste Code c: Not reported
Waste Code e: Not reported
Waste Code f: Not reported
Waste Code g: Not reported
Waste Code 1: Not reported
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 50
Units: Pounds

CON EDISON (Continued) **S117738350**

Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

R195 **CON EDISON** **NJ MANIFEST** **S120671233**
SW **10 BANK ST & MARTINE AVE** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10606**
0.133 mi.
701 ft. **Site 1 of 11 in cluster R**

Relative:
Higher

Actual:
203 ft.

NJ MANIFEST:

EPA ID:	NYP004776522
Name:	CON EDISON
Address:	10 BANK ST & MARTINE AVE
City,State,Zip:	WHITE PLAINS, NY 10606
County:	Not reported
Mailing Address:	IRVING PL 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Telephone:	Not reported
Emergency Telephone:	Not reported
Contact:	THOMAS TEELING
Comments:	Not reported
SIC Code:	Not reported
County:	NY119
Municipal:	Not reported
Previous EPAID:	Not reported
Generator Flag:	Not reported
Transporter Flag:	Not reported
TSDF Flag:	Not reported
Name Change:	Not reported
Date Change:	Not reported

Manifest Data:

EPA ID:	NYP004776522
Manifest Number:	014454051JJK
Date Shipped:	4/30/2015
TSDF EPA ID:	NJD002200046
Transporter EPA ID:	NYD006982359
Transporter 2 EPA ID:	Not reported
Transporter 3 EPA ID:	Not reported
Transporter 4 EPA ID:	Not reported
Transporter 5 EPA ID:	Not reported
Transporter 6 EPA ID:	Not reported
Transporter 7 EPA ID:	Not reported
Transporter 8 EPA ID:	Not reported
Transporter 9 EPA ID:	Not reported
Transporter 10 EPA ID:	Not reported
Date Trans1 Transported Waste:	Not reported
Date Trans2 Transported Waste:	Not reported
Date Trans3 Transported Waste:	Not reported
Date Trans4 Transported Waste:	Not reported
Date Trans5 Transported Waste:	Not reported
Date Trans6 Transported Waste:	Not reported
Date Trans7 Transported Waste:	Not reported
Date Trans8 Transported Waste:	Not reported
Date Trans9 Transported Waste:	Not reported

CON EDISON (Continued) **S120671233**

Date Trans10 Transported Waste:	Not reported
Date TSDF Received Waste:	Not reported
TSDF EPA Facility Name:	Not reported
QTY Units:	Not reported
Transporter SEQ ID:	Not reported
Transporter-1 Date:	Not reported
Waste SEQ ID:	Not reported
Waste Type Code 2:	Not reported
Waste Type Code 3:	Not reported
Waste Type Code 4:	Not reported
Waste Type Code 5:	Not reported
Waste Type Code 6:	Not reported
Date Accepted:	Not reported
Manifest Discrepancy Type:	Not reported
Data Entry Number:	Not reported
Was Load Rejected:	Not reported
Reason Load Was Rejected:	Not reported

L196 **OUR LADY OF MT CARMEL CHURCH** **NY UST** **U004441216**
SSW **92 SOUTH LEXINGTON AVENUE** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10606**
0.135 mi.
714 ft. **Site 5 of 6 in cluster L**

Relative: **Higher**

Actual: **200 ft.**

WESTCHESTER CO. UST:

Name:	OUR LADY OF MT CARMEL CHURCH
Address:	92 SOUTH LEXINGTON AVENUE
City,State,Zip:	WHITE PLAINS, NY 10606
Id/Status:	3-074462 / Unregulated
Operator Name:	Rev. Albert Azrak
Owner Name:	Archdioese Of New York
Owner Street:	1011 First Avenue
Owner Address2:	Not reported
Owner City:	New York
Owner State:	NY
Owner Zipcode:	10022
GDS Number:	Not reported
Tank Number:	1
Status:	3. Closed - Removed
Capacity:	10000
Product Stored:	0001. #2 Fuel Oil
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	12/01/1966
Date Perm Closure:	08/26/2011
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	3. Fiberglass liner (FRP)
Tank External Protection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	2. Underground/on ground
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Overfill Prevention:	0. None
Piping Secondary Containment:	Not reported
Spill Prevention:	0. None

OUR LADY OF MT CARMEL CHURCH (Continued) **U004441216**

Dispenser: 2. Suction

L197
SSW
1/8-1/4
0.135 mi.
714 ft.

OUR LADY OF MOUNT CARMEL
92 SOUTH LEXINGTON AVE
WHITE PLAINS, NY

NY LTANKS **S100139372**
N/A

Site 6 of 6 in cluster L

Relative:
Higher

Actual:
200 ft.

LTANKS:

Name:	MT CARMEL
Address:	92 SOUTH LEXINGTON AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	1100855 / 2012-01-23
Facility ID:	1100855
Site ID:	448286
Spill Date:	2011-04-25
Spill Cause:	Tank Test Failure
Spill Source:	Institutional, Educational, Gov., Other
Spill Class:	B3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	jbodee
Referred To:	Not reported
Reported to Dept:	2011-04-25
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2011-04-25
Spill Record Last Update:	2012-01-23
Spiller Name:	Not reported
Spiller Company:	OUR LADY OF MT CARMEL
Spiller Address:	Not reported
Spiller County:	999
Spiller Contact:	KATHY MORGAN
Spiller Phone:	(845) 855-3970
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	181357
Latitude:	41.0290017
Longitude:	-73.7723686
DEC Memo:	4/25/11: This is a 10K heating oil UST, estimated to be at least 60 years old. Thank was re-lined in 1980. WCDOH has required yearly testing of this tank - Kathy Morgan from US Tank Tech reports their company tested the tank every December from 2002 up until 2008. She does not know if anyone else tested it from Dec 08 until now. jod >>> Schneider, Wayne >wts1@westchestergov.com> 1/20/2012 3:52 PM >>> 1100855: 92 South Lexington Ave, White Plains- tank removed. Endpoint samples below cp-51 1/23/12: DEC requires no further action at this time. jod
Remarks:	1235 THE CALLER ADVISED DISPATCH THE TANK TEST FAILED. THE CALLER IS REQUESTING SPILLS TO CALL BACK. (PBS 3-074462), 10,000 GALLON TANK

All Materials:

OUR LADY OF MOUNT CARMEL (Continued) **S100139372**

Site ID:	448286
Operable Unit ID:	1198525
Operable Unit:	01
Material ID:	2194807
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported
Resource Affected:	Not reported
Oxygenate:	Not reported

Name:	OUR LADY OF MT CARMEL CHURCH
Address:	92 SOUTH LEXINGTON AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8703713 / 1987-10-21
Facility ID:	8703713
Site ID:	239739
Spill Date:	1987-08-05
Spill Cause:	Tank Test Failure
Spill Source:	Institutional, Educational, Gov., Other
Spill Class:	Not reported
Cleanup Ceased:	1987-10-21
SWIS:	6017
Investigator:	PATEL
Referred To:	Not reported
Reported to Dept:	1987-08-05
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1987-08-14
Spill Record Last Update:	2005-05-15
Spiller Name:	Not reported
Spiller Company:	NYS ARCHDIOCES
Spiller Address:	SAME
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	181357
Latitude:	41.0290340
Longitude:	-73.7719410
DEC Memo:	Not reported
Remarks:	TTTF 10K -.1100GPH

All TTF:

Facility ID:	8703713
Spill Number:	8703713
Spill Tank Test:	1531288

OUR LADY OF MOUNT CARMEL (Continued) **S100139372**

Site ID:	239739
Tank Number:	Not reported
Tank Size:	0
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	239739
Operable Unit ID:	910351
Operable Unit:	01
Material ID:	469939
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	Not reported
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

Name:	OUR LADY OF MOUNT CARMEL
Address:	92 SOUTH LEXINGTON AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8704169 / 1987-10-21
Facility ID:	8704169
Site ID:	219315
Spill Date:	1987-08-20
Spill Cause:	Tank Test Failure
Spill Source:	Institutional, Educational, Gov., Other
Spill Class:	Not reported
Cleanup Ceased:	1987-10-21
SWIS:	6017
Investigator:	PATEL
Referred To:	Not reported
Reported to Dept:	1987-08-20
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1987-09-25
Spill Record Last Update:	2005-05-15
Spiller Name:	Not reported

OUR LADY OF MOUNT CARMEL (Continued) **S100139372**

Spiller Company:	SAME
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	181357
Latitude:	41.0290480
Longitude:	-73.7719456
DEC Memo:	Not reported
Remarks:	1OK SYSTEM- -.1091 GPH. TO BE EMPTIED AND CLEANED. CONTACT:FATHER RIBEZZI

All TTF:

Facility ID:	8704169
Spill Number:	8704169
Spill Tank Test:	1531431
Site ID:	219315
Tank Number:	Not reported
Tank Size:	0
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	219315
Operable Unit ID:	908038
Operable Unit:	01
Material ID:	466817
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	Not reported
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

R198 **CON EDISON** **RCRA NonGen / NLR** **1019903978**
SW **10 BANK ST** **NYP004792248**
1/8-1/4 **WHITE PLAINS, NY 10606**
0.142 mi.
748 ft. **Site 2 of 11 in cluster R**

Relative: **Higher**

Actual: **202 ft.**

RCRA Listings:

Date Form Received by Agency:	20150610
Handler Name:	Con Edison
Handler Address:	Bank St
Handler City,State,Zip:	WHITE PLAINS, NY 10606
EPA ID:	NYP004792248
Contact Name:	THOMAS TEELING
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	212-460-3770
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PL 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No

CON EDISON (Continued) **1019903978**

Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20160909
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20150610
Handler Name: CON EDISON	
Federal Waste Generator Description:	Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20150610
Handler Name: CON EDISON	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

List of NAICS Codes and Descriptions:

NAICS Codes:	No NAICS Codes Found

Facility Has Received Notices of Violations:

Violations:	No Violations Found

Evaluation Action Summary:

Evaluations:	No Evaluations Found

R199 **CON EDISON** **NJ MANIFEST** **S120672618**
SW **10 BANK ST** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10606**
0.142 mi.
748 ft. **Site 3 of 11 in cluster R**

Relative:
Higher

Actual:
202 ft.

NJ MANIFEST:

EPA ID:	NYP004792248
Name:	CON EDISON
Address:	10 BANK ST
City,State,Zip:	WHITE PLAINS, NY 10606
County:	Not reported
Mailing Address:	IRVING PL 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Telephone:	Not reported
Emergency Telephone:	Not reported
Contact:	THOMAS TEELING
Comments:	Not reported
SIC Code:	Not reported
County:	NY119
Municipal:	Not reported
Previous EPAID:	Not reported
Generator Flag:	Not reported
Transporter Flag:	Not reported
TSDF Flag:	Not reported
Name Change:	Not reported
Date Change:	Not reported

Manifest Data:

EPA ID:	NYP004792248
Manifest Number:	014473098JJK
Date Shipped:	6/10/2015
TSDF EPA ID:	NJD002200046
Transporter EPA ID:	NYD006982359
Transporter 2 EPA ID:	Not reported
Transporter 3 EPA ID:	Not reported
Transporter 4 EPA ID:	Not reported
Transporter 5 EPA ID:	Not reported
Transporter 6 EPA ID:	Not reported
Transporter 7 EPA ID:	Not reported
Transporter 8 EPA ID:	Not reported
Transporter 9 EPA ID:	Not reported
Transporter 10 EPA ID:	Not reported
Date Trans1 Transported Waste:	Not reported
Date Trans2 Transported Waste:	Not reported
Date Trans3 Transported Waste:	Not reported
Date Trans4 Transported Waste:	Not reported
Date Trans5 Transported Waste:	Not reported
Date Trans6 Transported Waste:	Not reported
Date Trans7 Transported Waste:	Not reported
Date Trans8 Transported Waste:	Not reported
Date Trans9 Transported Waste:	Not reported
Date Trans10 Transported Waste:	Not reported
Date TSDF Received Waste:	Not reported
TSDF EPA Facility Name:	Not reported
QTY Units:	Not reported
Transporter SEQ ID:	Not reported
Transporter-1 Date:	Not reported
Waste SEQ ID:	Not reported
Waste Type Code 2:	Not reported

CON EDISON (Continued) **S120672618**

Waste Type Code 3:	Not reported
Waste Type Code 4:	Not reported
Waste Type Code 5:	Not reported
Waste Type Code 6:	Not reported
Date Accepted:	Not reported
Manifest Discrepancy Type:	Not reported
Data Entry Number:	Not reported
Was Load Rejected:	Not reported
Reason Load Was Rejected:	Not reported

R200 **CON ED** **NY MANIFEST** **S118089358**
SW **10 BANK ST** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10606**
0.142 mi.
748 ft. **Site 4 of 11 in cluster R**

Relative: **Higher**
Actual: **202 ft.**

NY MANIFEST:

EPA ID:	NYP004769600
Country:	USA
Name:	Con Ed
Address:	10 BANK ST
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10606
Zip 4:	Not reported
Location Address 1:	10 BANK ST / TRAVERS ST
Location Address 2:	SB 9907
Location City,State,Zip:	WHITE PLAINS, NY 10606
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Ed
Mailing Contact:	Tom Teeling
Mailing Address 1:	4 IRVING PLACE - 15TH FLOOR
Mailing Address 2:	Not reported
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	2124603770

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	04/16/2015
Trans1 Recv Date:	04/16/2015
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	04/22/2015
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004769600
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported

CON ED (Continued) **S118089358**

TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	014085133JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	50
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

R201 **MARUBENI SPECIALTY CHEMICALS INC** **RCRA NonGen / NLR** **1000911942**
SW **10 BANK ST** **TSCA** **NYD987027638**
1/8-1/4 **WHITE PLAINS, NY 10606** **FINDS**
0.142 mi. **ECHO**
748 ft. **Site 5 of 11 in cluster R** **NY MANIFEST**

Relative: **Higher**

Actual: **202 ft.**

RCRA Listings:

Date Form Received by Agency:	20070101
Handler Name:	Marubeni Specialty Chemicals Inc
Handler Address:	Bank St
Handler City,State,Zip:	WHITE PLAINS, NY 10606
EPA ID:	NYD987027638
Contact Name:	HIROSHI YOSHIHARA
Contact Address:	BANK ST
Contact City,State,Zip:	WHITE PLAINS, NY 10606
Contact Telephone:	914-428-8900
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R3
Mailing Address:	BANK ST
Mailing City,State,Zip:	WHITE PLAINS, NY 10606
Owner Name:	Homart Development Co
Owner Type:	Private
Operator Name:	Homart Development Co
Operator Type:	Private
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20150414
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Hazardous Waste Summary:

Waste Code:	D001
Waste Description:	Ignitable Waste
Waste Code:	D002

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Waste Description: Corrosive Waste

Waste Code: U201
Waste Description: 1,3-Benzenediol (Or) Resorcinol

Waste Code: U328
Waste Description: Benzenamine, 2-Methyl- (Or) O-Toluidine

Handler - Owner Operator:
Owner/Operator Indicator: Operator
Owner/Operator Name: HOMART DEVELOPMENT CO
Legal Status: Private
Date Became Current: Not reported
Date Ended Current: Not reported
Owner/Operator Address: 10 BANK ST
Owner/Operator City,State,Zip: WHITE PLAINS, NY 10606
Owner/Operator Telephone: 914-761-1030
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Owner
Owner/Operator Name: HOMART DEVELOPMENT CO
Legal Status: Private
Date Became Current: Not reported
Date Ended Current: Not reported
Owner/Operator Address: 10 BANK ST
Owner/Operator City,State,Zip: WHITE PLAINS, NY 10606
Owner/Operator Telephone: 914-761-1030
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Owner
Owner/Operator Name: HOMART DEVELOPMENT CO
Legal Status: Private
Date Became Current: Not reported
Date Ended Current: Not reported
Owner/Operator Address: 10 BANK ST
Owner/Operator City,State,Zip: WHITE PLAINS, NY 10606
Owner/Operator Telephone: 914-761-1030
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Historic Generators:
Receive Date: 20060101
Handler Name: MARUBENI SPECIALTY CHEMICALS INC
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20070101
Handler Name: MARUBENI SPECIALTY CHEMICALS INC
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 19940701
Handler Name: MARUBENI SPECIALTY CHEMICALS INC
Federal Waste Generator Description: Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Has the Facility Received Notices of Violations:
Found Violation: No
Agency Which Determined Violation: Not reported
Violation Short Description: Not reported
Date Violation was Determined: Not reported
Actual Return to Compliance Date: Not reported
Return to Compliance Qualifier: Not reported
Violation Responsible Agency: Not reported
Scheduled Compliance Date: Not reported
Enforcement Identifier: Not reported
Date of Enforcement Action: Not reported
Enforcement Responsible Agency: Not reported
Enforcement Docket Number: Not reported
Enforcement Attorney: Not reported
Corrective Action Component: Not reported
Appeal Initiated Date: Not reported
Appeal Resolution Date: Not reported
Disposition Status Date: Not reported
Disposition Status: Not reported
Disposition Status Description: Not reported
Consent/Final Order Sequence Number:Not reported
Consent/Final Order Respondent Name: Not reported
Consent/Final Order Lead Agency: Not reported
Enforcement Type: Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Enforcement Responsible Person:	Not reported
Enforcement Responsible Sub-Organization:	Not reported
SEP Sequence Number:	Not reported
SEP Expenditure Amount:	Not reported
SEP Scheduled Completion Date:	Not reported
SEP Actual Date:	Not reported
SEP Defaulted Date:	Not reported
SEP Type:	Not reported
SEP Type Description:	Not reported
Proposed Amount:	Not reported
Final Monetary Amount:	Not reported
Paid Amount:	Not reported
Final Count:	Not reported
Final Amount:	Not reported

Evaluation Action Summary:

Evaluation Date:	20010925
Evaluation Responsible Agency:	EPA
Found Violation:	No
Evaluation Type Description:	COMPLIANCE EVALUATION INSPECTION
Evaluation Responsible Person Identifier:	R2RV
Evaluation Responsible Sub-Organization:	RCB
Actual Return to Compliance Date:	Not reported
Scheduled Compliance Date:	Not reported
Date of Request:	Not reported
Date Response Received:	Not reported
Request Agency:	Not reported
Former Citation:	Not reported

TSCA:

Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK STREET
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	Not reported
Facility ID:	Not reported

TSCA 2016-2019:

Chemical ID Number:	100-51-6
Case Number:	100516
Chemical Name:	Benzenemethanol
Activity:	Import
Number of Workers:	10 - 24
Max Concentration:	90% +
Chemical Recycled:	NKRA
Physical Forms:	Liquid
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 740
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Marubeni America Corporation
Domestic pc address line1:	375 Lexington Ave.
Domestic pc address line2:	Not reported
Domestic pc city:	New York
Domestic pc county / parish:	New York

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Domestic pc state:	NY
Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633
Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610
Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	0
2019 import pv:	757721
2019 pv:	757721
2018 pv:	4121630
2017 pv:	2913758
2016 pv:	122488
2019 nationally aggregated pv:	10,000,000 - <50,000,000 lb
2018 nationally aggregated pv:	10,000,000 - <50,000,000 lb
2017 nationally aggregated pv:	10,000,000 - <50,000,000 lb
2016 nationally aggregated pv:	10,000,000 - <50,000,000 lb
Imported chem never at site:	Yes
2019 v used on-site:	Not reported
2019 v exported:	0
Pct byp code:	B1
Percent byproduct:	0 percent by weight
Workers code:	W2
Max conc code:	M5
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported
Max Concentration:	Not reported
Number of Workers:	Not reported
Chemical Name:	Benzenemethanol
Chemical ID:	100-51-6
C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported
C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Not reported
C / c pv pct:	Not reported
C / c max conc code:	Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Comm workers code: Not reported

2016-2019 Industrial:

Type Process Use:	Processing-incorporation into formulation, mixture, or reaction product
Sector:	Other (requires additional information)
Function Category:	Solvent
Number of Sites:	< 10
Number of Workers:	10 - 24
Chemical Name:	Benzenemethanol
Chemical ID:	100-51-6
Case Number:	100516
Ind type code:	PF
Ind sect code:	IS48
Ind sector other desc:	Used to produce paint stripping solvents.
Ind fc code:	F075
Ind funct cat other desc:	Not reported
Ind pv pct:	100
Ind sites code:	S1
Ind workers code:	W2

Chemical ID Number:	10101-50-5
Case Number:	10101505
Chemical Name:	Permanganic acid (HMnO4), sodium salt
Activity:	Import
Number of Workers:	25 - 49
Max Concentration:	30% - < 60%
Chemical Recycled:	No
Physical Forms:	Liquid
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 740
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Marubeni America Corporation
Domestic pc address line1:	375 Lexington Ave.
Domestic pc address line2:	Not reported
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633
Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	0
2019 import pv:	41976
2019 pv:	41976
2018 pv:	302623
2017 pv:	86275
2016 pv:	129132
2019 nationally aggregated pv:	1,000,000 lb - <20,000,000 lb
2018 nationally aggregated pv:	1,000,000 lb - <20,000,000 lb
2017 nationally aggregated pv:	1,000,000 lb - <20,000,000 lb
2016 nationally aggregated pv:	1,000,000 lb - <20,000,000 lb
Imported chem never at site:	Yes
2019 v used on-site:	Not reported
2019 v exported:	0
Pct byp code:	B1
Percent byproduct:	0 percent by weight
Workers code:	W3
Max conc code:	M3
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported
Max Concentration:	Not reported
Number of Workers:	Not reported
Chemical Name:	Permanganic acid (HMnO4), sodium salt
Chemical ID:	10101-50-5
C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported
C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Not reported
C / c pv pct:	Not reported
C / c max conc code:	Not reported
Comm workers code:	Not reported

2016-2019 Industrial:

Type Process Use:	Processing as a reactant
Sector:	Utilities
Function Category:	Deodorizer
Number of Sites:	10 - 24
Number of Workers:	25 - 49
Chemical Name:	Permanganic acid (HMnO4), sodium salt
Chemical ID:	10101-50-5
Case Number:	10101505
Ind type code:	PC
Ind sect code:	IS4
Ind sector other desc:	Not reported
Ind fc code:	F042

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Ind funct cat other desc:	Not reported
Ind pv pct:	100
Ind sites code:	S2
Ind workers code:	W3

Chemical ID Number:	104-66-5
Case Number:	104665
Chemical Name:	Benzene, 1,1'-[1,2-ethanediylbis(oxy)]bis-
Activity:	Import
Number of Workers:	1000 - 9999
Max Concentration:	90% +
Chemical Recycled:	NKRA
Physical Forms:	Dry Powder
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 740
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Marubeni America Corporation
Domestic pc address line1:	375 Lexington Ave.
Domestic pc address line2:	Not reported
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633
Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610
Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	0
2019 import pv:	88294
2019 pv:	88294
2018 pv:	282850
2017 pv:	198414
2016 pv:	2205
2019 nationally aggregated pv:	88294
2018 nationally aggregated pv:	282850
2017 nationally aggregated pv:	198414
2016 nationally aggregated pv:	180226

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Imported chem never at site:	Yes
2019 v used on-site:	Not reported
2019 v exported:	0
Pct byp code:	B1
Percent byproduct:	0 percent by weight
Workers code:	W7
Max conc code:	M5
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported
Max Concentration:	Not reported
Number of Workers:	Not reported
Chemical Name:	Benzene, 1,1'-[1,2-ethanediylbis(oxy)]bis-
Chemical ID:	104-66-5
C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported
C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Not reported
C / c pv pct:	Not reported
C / c max conc code:	Not reported
Comm workers code:	Not reported

2016-2019 Industrial:

Type Process Use:	Processing-incorporation into article
Sector:	Paper Manufacturing
Function Category:	Other
Number of Sites:	< 10
Number of Workers:	1000 - 9999
Chemical Name:	Benzene, 1,1'-[1,2-ethanediylbis(oxy)]bis-
Chemical ID:	104-66-5
Case Number:	104665
Ind type code:	PA
Ind sect code:	IS9
Ind sector other desc:	Not reported
Ind fc code:	F999
Ind funct cat other desc:	Sensitizer for thermal paper.
Ind pv pct:	100
Ind sites code:	S1
Ind workers code:	W7

Chemical ID Number:	1071-93-8
Case Number:	1071938
Chemical Name:	Hexanedioic acid, 1,6-dihydrazide
Activity:	Import
Number of Workers:	< 10
Max Concentration:	90% +
Chemical Recycled:	NKRA
Physical Forms:	Liquid
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Site Address 2:	SUITE 740
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Marubeni America Corporation
Domestic pc address line1:	375 Lexington Ave.
Domestic pc address line2:	Not reported
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633
Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610
Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	0
2019 import pv:	100529
2019 pv:	100529
2018 pv:	0
2017 pv:	0
2016 pv:	0
2019 nationally aggregated pv:	500,000 - <1,000,000 lb
2018 nationally aggregated pv:	500,000 - <1,000,000 lb
2017 nationally aggregated pv:	1,000,000 - <10,000,000 lb
2016 nationally aggregated pv:	500,000 - <1,000,000 lb
Imported chem never at site:	Yes
2019 v used on-site:	Not reported
2019 v exported:	0
Pct byp code:	B1
Percent byproduct:	0 percent by weight
Workers code:	W1
Max conc code:	M5
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported
Max Concentration:	Not reported
Number of Workers:	Not reported
Chemical Name:	Hexanedioic acid, 1,6-dihydrazide

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Chemical ID:	1071-93-8
C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported
C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Not reported
C / c pv pct:	Not reported
C / c max conc code:	Not reported
Comm workers code:	Not reported

2016-2019 Industrial:

Type Process Use:	Processing-incorporation into formulation, mixture, or reaction product
Sector:	Plastics Product Manufacturing
Function Category:	Plasticizer
Number of Sites:	< 10
Number of Workers:	< 10
Chemical Name:	Hexanedioic acid, 1,6-dihydrazide
Chemical ID:	1071-93-8
Case Number:	1071938
Ind type code:	PF
Ind sect code:	IS35
Ind sector other desc:	Not reported
Ind fc code:	F052
Ind funct cat other desc:	Not reported
Ind pv pct:	100
Ind sites code:	S1
Ind workers code:	W1

Chemical ID Number:	107-98-2
Case Number:	107982
Chemical Name:	2-Propanol, 1-methoxy-
Activity:	Not reported
Number of Workers:	Not reported
Max Concentration:	Not reported
Chemical Recycled:	Not reported
Physical Forms:	Not reported
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 740
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Marubeni America Corporation
Domestic pc address line1:	375 Lexington Ave.
Domestic pc address line2:	Not reported
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633
Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610
Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	0
2019 import pv:	0
2019 pv:	0
2018 pv:	4734
2017 pv:	25020
2016 pv:	7363
2019 nationally aggregated pv:	100,000,000 - <250,000,000 lb
2018 nationally aggregated pv:	100,000,000 - <250,000,000 lb
2017 nationally aggregated pv:	100,000,000 - <250,000,000 lb
2016 nationally aggregated pv:	100,000,000 - <250,000,000 lb
Imported chem never at site:	Not reported
2019 v used on-site:	Not reported
2019 v exported:	Not reported
Pct byp code:	Not reported
Percent byproduct:	Not reported
Workers code:	Not reported
Max conc code:	Not reported
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported
Max Concentration:	Not reported
Number of Workers:	Not reported
Chemical Name:	2-Propanol, 1-methoxy-
Chemical ID:	107-98-2
C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported
C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Not reported
C / c pv pct:	Not reported
C / c max conc code:	Not reported
Comm workers code:	Not reported

2016-2019 Industrial:

Type Process Use:	Not reported
Sector:	Not reported
Function Category:	Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Number of Sites:	Not reported
Number of Workers:	Not reported
Chemical Name:	2-Propanol, 1-methoxy-
Chemical ID:	107-98-2
Case Number:	107982
Ind type code:	Not reported
Ind sect code:	Not reported
Ind sector other desc:	Not reported
Ind fc code:	Not reported
Ind funct cat other desc:	Not reported
Ind pv pct:	Not reported
Ind sites code:	Not reported
Ind workers code:	Not reported

Chemical ID Number:	108-30-5
Case Number:	108305
Chemical Name:	2,5-Furandione, dihydro-
Activity:	Import
Number of Workers:	Not Known or Reasonably Ascertainable
Max Concentration:	90% +
Chemical Recycled:	NKRA
Physical Forms:	Dry Powder
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 740
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Marubeni America Corporation
Domestic pc address line1:	375 Lexington Ave.
Domestic pc address line2:	Not reported
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633
Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610
Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	0

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

2019 import pv:	67240
2019 pv:	67240
2018 pv:	67494
2017 pv:	187190
2016 pv:	72882
2019 nationally aggregated pv:	100,000 - <500,000 lb
2018 nationally aggregated pv:	100,000 - <500,000 lb
2017 nationally aggregated pv:	500,000 - <1,000,000 lb
2016 nationally aggregated pv:	100,000 - <500,000 lb
Imported chem never at site:	Yes
2019 v used on-site:	Not reported
2019 v exported:	0
Pct byp code:	B1
Percent byproduct:	0 percent by weight
Workers code:	NKRA
Max conc code:	M5
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported
Max Concentration:	Not reported
Number of Workers:	Not reported
Chemical Name:	2,5-Furandione, dihydro-
Chemical ID:	108-30-5
C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported
C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Not reported
C / c pv pct:	Not reported
C / c max conc code:	Not reported
Comm workers code:	Not reported

2016-2019 Industrial:

Type Process Use:	Processing-incorporation into formulation, mixture, or reaction product
Sector:	Food, beverage, and tobacco product manufacturing
Function Category:	Flavoring and nutrient
Number of Sites:	< 10
Number of Workers:	< 10
Chemical Name:	2,5-Furandione, dihydro-
Chemical ID:	108-30-5
Case Number:	108305
Ind type code:	PF
Ind sect code:	IS6
Ind sector other desc:	Not reported
Ind fc code:	F088
Ind funct cat other desc:	Not reported
Ind pv pct:	100
Ind sites code:	S1
Ind workers code:	W1

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Chemical ID Number:	108-31-6
Case Number:	108316
Chemical Name:	2,5-Furandione
Activity:	Not reported
Number of Workers:	Not reported
Max Concentration:	Not reported
Chemical Recycled:	Not reported
Physical Forms:	Not reported
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 740
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Marubeni America Corporation
Domestic pc address line1:	375 Lexington Ave.
Domestic pc address line2:	Not reported
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633
Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610
Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	Not reported
2019 import pv:	Not reported
2019 pv:	Not reported
2018 pv:	45415
2017 pv:	0
2016 pv:	0
2019 nationally aggregated pv:	500,000,000 - <750,000,000 lb
2018 nationally aggregated pv:	500,000,000 - <750,000,000 lb
2017 nationally aggregated pv:	500,000,000 - <750,000,000 lb
2016 nationally aggregated pv:	500,000,000 - <750,000,000 lb
Imported chem never at site:	Not reported
2019 v used on-site:	Not reported
2019 v exported:	Not reported
Pct byp code:	Not reported
Percent byproduct:	Not reported
Workers code:	Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Max conc code:	Not reported
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported
Max Concentration:	Not reported
Number of Workers:	Not reported
Chemical Name:	2,5-Furandione
Chemical ID:	108-31-6
C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported
C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Not reported
C / c pv pct:	Not reported
C / c max conc code:	Not reported
Comm workers code:	Not reported

2016-2019 Industrial:

Type Process Use:	Not reported
Sector:	Not reported
Function Category:	Not reported
Number of Sites:	Not reported
Number of Workers:	Not reported
Chemical Name:	2,5-Furandione
Chemical ID:	108-31-6
Case Number:	108316
Ind type code:	Not reported
Ind sect code:	Not reported
Ind sector other desc:	Not reported
Ind fc code:	Not reported
Ind funct cat other desc:	Not reported
Ind pv pct:	Not reported
Ind sites code:	Not reported
Ind workers code:	Not reported

Chemical ID Number:	108-78-1
Case Number:	108781
Chemical Name:	1,3,5-Triazine-2,4,6-triamine
Activity:	Import
Number of Workers:	25 - 49
Max Concentration:	90% +
Chemical Recycled:	NKRA
Physical Forms:	Dry Powder
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 740
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Marubeni America Corporation
Domestic pc address line1:	375 Lexington Ave.

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Domestic pc address line2:	Not reported
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633
Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610
Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	0
2019 import pv:	1256622
2019 pv:	1256622
2018 pv:	806075
2017 pv:	5206782
2016 pv:	4885793
2019 nationally aggregated pv:	100,000,000 - <250,000,000 lb
2018 nationally aggregated pv:	100,000,000 - <250,000,000 lb
2017 nationally aggregated pv:	100,000,000 - <250,000,000 lb
2016 nationally aggregated pv:	100,000,000 - <250,000,000 lb
Imported chem never at site:	Yes
2019 v used on-site:	Not reported
2019 v exported:	0
Pct byp code:	B1
Percent byproduct:	0 percent by weight
Workers code:	W3
Max conc code:	M5
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported
Max Concentration:	Not reported
Number of Workers:	Not reported
Chemical Name:	1,3,5-Triazine-2,4,6-triamine
Chemical ID:	108-78-1
C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported
C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Cons or comm use:	Not reported
C / c pv pct:	Not reported
C / c max conc code:	Not reported
Comm workers code:	Not reported

2016-2019 Industrial:

Type Process Use:	Processing-incorporation into article
Sector:	Plastics Material and Resin Manufacturing
Function Category:	Adhesives and sealant chemicals
Number of Sites:	10 - 24
Number of Workers:	25 - 49
Chemical Name:	1,3,5-Triazine-2,4,6-triamine
Chemical ID:	108-78-1
Case Number:	108781
Ind type code:	PA
Ind sect code:	IS22
Ind sector other desc:	Not reported
Ind fc code:	U002
Ind funct cat other desc:	Not reported
Ind pv pct:	100
Ind sites code:	S2
Ind workers code:	W3

Chemical ID Number:	108-88-3
Case Number:	108883
Chemical Name:	Benzene, methyl-
Activity:	Import
Number of Workers:	25 - 49
Max Concentration:	1% - < 30%
Chemical Recycled:	NKRA
Physical Forms:	Liquid
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 740
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Marubeni America Corporation
Domestic pc address line1:	375 Lexington Ave.
Domestic pc address line2:	Not reported
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610
Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	0
2019 import pv:	16785
2019 pv:	16785
2018 pv:	29941
2017 pv:	29280
2016 pv:	35730
2019 nationally aggregated pv:	20,000,000,000 - <30,000,000,000 lb
2018 nationally aggregated pv:	20,000,000,000 - <30,000,000,000 lb
2017 nationally aggregated pv:	20,000,000,000 - <30,000,000,000 lb
2016 nationally aggregated pv:	20,000,000,000 - <30,000,000,000 lb
Imported chem never at site:	Yes
2019 v used on-site:	Not reported
2019 v exported:	0
Pct byp code:	B1
Percent byproduct:	0 percent by weight
Workers code:	W3
Max conc code:	M2
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported
Max Concentration:	Not reported
Number of Workers:	Not reported
Chemical Name:	Benzene, methyl-
Chemical ID:	108-88-3
C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported
C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Not reported
C / c pv pct:	Not reported
C / c max conc code:	Not reported
Comm workers code:	Not reported

2016-2019 Industrial:

Type Process Use:	Processing-incorporation into formulation, mixture, or reaction product
Sector:	Electrical Equipment, Appliance, and Component Manufacturing
Function Category:	Other (specify)
Number of Sites:	< 10
Number of Workers:	25 - 49
Chemical Name:	Benzene, methyl-
Chemical ID:	108-88-3
Case Number:	108883
Ind type code:	PF

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Ind sect code:	IS42
Ind sector other desc:	Not reported
Ind fc code:	U999
Ind funct cat other desc:	Anti-moisture and dust coating
Ind pv pct:	100
Ind sites code:	S1
Ind workers code:	W3

Chemical ID Number:	109-66-0
Case Number:	109660
Chemical Name:	Pentane
Activity:	Not reported
Number of Workers:	Not reported
Max Concentration:	Not reported
Chemical Recycled:	Not reported
Physical Forms:	Not reported
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 740
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Marubeni America Corporation
Domestic pc address line1:	375 Lexington Ave.
Domestic pc address line2:	Not reported
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633
Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610
Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	Not reported
2019 import pv:	Not reported
2019 pv:	Not reported
2018 pv:	0
2017 pv:	0
2016 pv:	57099
2019 nationally aggregated pv:	1,000,000,000 - <5,000,000,000 lb

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

2018 nationally aggregated pv:	1,000,000,000 - <5,000,000,000 lb
2017 nationally aggregated pv:	1,000,000,000 - <5,000,000,000 lb
2016 nationally aggregated pv:	1,000,000,000 - <5,000,000,000 lb
Imported chem never at site:	Not reported
2019 v used on-site:	Not reported
2019 v exported:	Not reported
Pct byp code:	Not reported
Percent byproduct:	Not reported
Workers code:	Not reported
Max conc code:	Not reported
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported
Max Concentration:	Not reported
Number of Workers:	Not reported
Chemical Name:	Pentane
Chemical ID:	109-66-0
C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported
C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Not reported
C / c pv pct:	Not reported
C / c max conc code:	Not reported
Comm workers code:	Not reported

2016-2019 Industrial:

Type Process Use:	Not reported
Sector:	Not reported
Function Category:	Not reported
Number of Sites:	Not reported
Number of Workers:	Not reported
Chemical Name:	Pentane
Chemical ID:	109-66-0
Case Number:	109660
Ind type code:	Not reported
Ind sect code:	Not reported
Ind sector other desc:	Not reported
Ind fc code:	Not reported
Ind funct cat other desc:	Not reported
Ind pv pct:	Not reported
Ind sites code:	Not reported
Ind workers code:	Not reported

Chemical ID Number:	11070-44-3
Case Number:	11070443
Chemical Name:	1,3-Isobenzofurandione, tetrahydromethyl-
Activity:	Import
Number of Workers:	10 - 24
Max Concentration:	30% - < 60%
Chemical Recycled:	NKRA

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Physical Forms:	Liquid
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 740
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Marubeni America Corporation
Domestic pc address line1:	375 Lexington Ave.
Domestic pc address line2:	Not reported
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633
Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610
Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	0
2019 import pv:	19400
2019 pv:	19400
2018 pv:	25221
2017 pv:	19400
2016 pv:	13580
2019 nationally aggregated pv:	100,000 - <500,000 lb
2018 nationally aggregated pv:	100,000 - <500,000 lb
2017 nationally aggregated pv:	100,000 - <500,000 lb
2016 nationally aggregated pv:	100,000 - <500,000 lb
Imported chem never at site:	Yes
2019 v used on-site:	Not reported
2019 v exported:	0
Pct byp code:	B1
Percent byproduct:	0 percent by weight
Workers code:	W2
Max conc code:	M3
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Max Concentration:	Not reported
Number of Workers:	Not reported
Chemical Name:	1,3-Isobenzofurandione, tetrahydromethyl-
Chemical ID:	11070-44-3
C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported
C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Not reported
C / c pv pct:	Not reported
C / c max conc code:	Not reported
Comm workers code:	Not reported

2016-2019 Industrial:

Type Process Use:	Processing-incorporation into formulation, mixture, or reaction product
Sector:	All Other Chemical Product and Preparation Manufacturing
Function Category:	Fillers
Number of Sites:	< 10
Number of Workers:	10 - 24
Chemical Name:	1,3-Isobenzofurandione, tetrahydromethyl-
Chemical ID:	11070-44-3
Case Number:	11070443
Ind type code:	PF
Ind sect code:	IS34
Ind sector other desc:	Not reported
Ind fc code:	U009
Ind funct cat other desc:	Not reported
Ind pv pct:	100
Ind sites code:	S1
Ind workers code:	W2

Chemical ID Number:	128-44-9
Case Number:	128449
Chemical Name:	1,2-Benzisothiazol-3(2H)-one, 1,1-dioxide, sodium salt (1:1)
Activity:	Import
Number of Workers:	< 10
Max Concentration:	90% +
Chemical Recycled:	NKRA
Physical Forms:	Dry Powder
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 740
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Marubeni America Corporation
Domestic pc address line1:	375 Lexington Ave.
Domestic pc address line2:	Not reported
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633
Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610
Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	0
2019 import pv:	44092
2019 pv:	44092
2018 pv:	88537
2017 pv:	94793
2016 pv:	89771
2019 nationally aggregated pv:	100,000 - <500,000 lb
2018 nationally aggregated pv:	100,000 - <500,000 lb
2017 nationally aggregated pv:	100,000 - <500,000 lb
2016 nationally aggregated pv:	100,000 - <500,000 lb
Imported chem never at site:	Yes
2019 v used on-site:	Not reported
2019 v exported:	0
Pct byp code:	B1
Percent byproduct:	0 percent by weight
Workers code:	W1
Max conc code:	M5
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported
Max Concentration:	Not reported
Number of Workers:	Not reported
Chemical Name:	1,2-Benzisothiazol-3(2H)-one, 1,1-dioxide, sodium salt (1:1)
Chemical ID:	128-44-9
C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported
C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Not reported
C / c pv pct:	Not reported
C / c max conc code:	Not reported
Comm workers code:	Not reported

2016-2019 Industrial:

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Type Process Use:	Processing-incorporation into formulation, mixture, or reaction product
Sector:	Food, beverage, and tobacco product manufacturing
Function Category:	Flavoring and nutrient
Number of Sites:	< 10
Number of Workers:	< 10
Chemical Name:	1,2-Benzisothiazol-3(2H)-one, 1,1-dioxide, sodium salt (1:1)
Chemical ID:	128-44-9
Case Number:	128449
Ind type code:	PF
Ind sect code:	IS6
Ind sector other desc:	Not reported
Ind fc code:	F088
Ind funct cat other desc:	Not reported
Ind pv pct:	100
Ind sites code:	S1
Ind workers code:	W1

Chemical ID Number:	1344-00-9
Case Number:	1344009
Chemical Name:	Silicic acid, aluminum sodium salt
Activity:	Import
Number of Workers:	25 - 49
Max Concentration:	90% +
Chemical Recycled:	No
Physical Forms:	Dry Powder
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 740
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Marubeni America Corporation
Domestic pc address line1:	375 Lexington Ave.
Domestic pc address line2:	Not reported
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633
Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610
Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	0
2019 import pv:	7353
2019 pv:	7353
2018 pv:	11031
2017 pv:	6429
2016 pv:	3837
2019 nationally aggregated pv:	10,000,000 - <50,000,000 lb
2018 nationally aggregated pv:	10,000,000 - <50,000,000 lb
2017 nationally aggregated pv:	10,000,000 - <50,000,000 lb
2016 nationally aggregated pv:	10,000,000 - <50,000,000 lb
Imported chem never at site:	Yes
2019 v used on-site:	Not reported
2019 v exported:	0
Pct byp code:	B1
Percent byproduct:	0 percent by weight
Workers code:	W3
Max conc code:	M5
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported
Max Concentration:	Not reported
Number of Workers:	Not reported
Chemical Name:	Silicic acid, aluminum sodium salt
Chemical ID:	1344-00-9
C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported
C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Not reported
C / c pv pct:	Not reported
C / c max conc code:	Not reported
Comm workers code:	Not reported

2016-2019 Industrial:

Type Process Use:	Processing as a reactant
Sector:	Utilities
Function Category:	Oxidizing agent
Number of Sites:	10 - 24
Number of Workers:	25 - 49
Chemical Name:	Silicic acid, aluminum sodium salt
Chemical ID:	1344-00-9
Case Number:	1344009
Ind type code:	PC
Ind sect code:	IS4
Ind sector other desc:	Not reported
Ind fc code:	F044
Ind funct cat other desc:	Not reported
Ind pv pct:	100
Ind sites code:	S2

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Ind workers code:	W3
Chemical ID Number:	13463-67-7
Case Number:	13463677
Chemical Name:	Titanium oxide (TiO2)
Activity:	Not reported
Number of Workers:	Not reported
Max Concentration:	Not reported
Chemical Recycled:	Not reported
Physical Forms:	Not reported
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 740
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Marubeni America Corporation
Domestic pc address line1:	375 Lexington Ave.
Domestic pc address line2:	Not reported
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633
Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610
Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	Not reported
2019 import pv:	Not reported
2019 pv:	Not reported
2018 pv:	0
2017 pv:	0
2016 pv:	31377
2019 nationally aggregated pv:	1,000,000,000 - <5,000,000,000 lb
2018 nationally aggregated pv:	1,000,000,000 - <5,000,000,000 lb
2017 nationally aggregated pv:	1,000,000,000 - <5,000,000,000 lb
2016 nationally aggregated pv:	1,000,000,000 - <5,000,000,000 lb
Imported chem never at site:	Not reported
2019 v used on-site:	Not reported
2019 v exported:	Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Pct byp code:	Not reported
Percent byproduct:	Not reported
Workers code:	Not reported
Max conc code:	Not reported
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported
Max Concentration:	Not reported
Number of Workers:	Not reported
Chemical Name:	Titanium oxide (TiO2)
Chemical ID:	13463-67-7
C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported
C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Not reported
C / c pv pct:	Not reported
C / c max conc code:	Not reported
Comm workers code:	Not reported

2016-2019 Industrial:

Type Process Use:	Not reported
Sector:	Not reported
Function Category:	Not reported
Number of Sites:	Not reported
Number of Workers:	Not reported
Chemical Name:	Titanium oxide (TiO2)
Chemical ID:	13463-67-7
Case Number:	13463677
Ind type code:	Not reported
Ind sect code:	Not reported
Ind sector other desc:	Not reported
Ind fc code:	Not reported
Ind funct cat other desc:	Not reported
Ind pv pct:	Not reported
Ind sites code:	Not reported
Ind workers code:	Not reported

Chemical ID Number:	142-82-5
Case Number:	142825
Chemical Name:	Heptane
Activity:	Not reported
Number of Workers:	Not reported
Max Concentration:	Not reported
Chemical Recycled:	Not reported
Physical Forms:	Not reported
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 740
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Chemical ID type:	CASRN
Domestic parent company name:	Marubeni America Corporation
Domestic pc address line1:	375 Lexington Ave.
Domestic pc address line2:	Not reported
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633
Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610
Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	Not reported
2019 import pv:	Not reported
2019 pv:	Not reported
2018 pv:	0
2017 pv:	0
2016 pv:	27337
2019 nationally aggregated pv:	100,000,000 - <250,000,000 lb
2018 nationally aggregated pv:	50,000,000 - <100,000,000 lb
2017 nationally aggregated pv:	50,000,000 - <100,000,000 lb
2016 nationally aggregated pv:	50,000,000 - <100,000,000 lb
Imported chem never at site:	Not reported
2019 v used on-site:	Not reported
2019 v exported:	Not reported
Pct byp code:	Not reported
Percent byproduct:	Not reported
Workers code:	Not reported
Max conc code:	Not reported
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported
Max Concentration:	Not reported
Number of Workers:	Not reported
Chemical Name:	Heptane
Chemical ID:	142-82-5
C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Not reported
C / c pv pct:	Not reported
C / c max conc code:	Not reported
Comm workers code:	Not reported

2016-2019 Industrial:

Type Process Use:	Not reported
Sector:	Not reported
Function Category:	Not reported
Number of Sites:	Not reported
Number of Workers:	Not reported
Chemical Name:	Heptane
Chemical ID:	142-82-5
Case Number:	142825
Ind type code:	Not reported
Ind sect code:	Not reported
Ind sector other desc:	Not reported
Ind fc code:	Not reported
Ind funct cat other desc:	Not reported
Ind pv pct:	Not reported
Ind sites code:	Not reported
Ind workers code:	Not reported

Chemical ID Number:	143-07-7
Case Number:	143077
Chemical Name:	Dodecanoic acid
Activity:	Import
Number of Workers:	< 10
Max Concentration:	90% +
Chemical Recycled:	NKRA
Physical Forms:	Dry Powder
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 740
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Marubeni America Corporation
Domestic pc address line1:	375 Lexington Ave.
Domestic pc address line2:	Not reported
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633
Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610
Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	0
2019 import pv:	5796369
2019 pv:	5796369
2018 pv:	0
2017 pv:	0
2016 pv:	0
2019 nationally aggregated pv:	10,000,000 - <50,000,000 lb
2018 nationally aggregated pv:	1,000,000 - <10,000,000 lb
2017 nationally aggregated pv:	1,000,000 - <10,000,000 lb
2016 nationally aggregated pv:	1,000,000 - <10,000,000 lb
Imported chem never at site:	Yes
2019 v used on-site:	Not reported
2019 v exported:	0
Pct byp code:	B1
Percent byproduct:	0 percent by weight
Workers code:	W1
Max conc code:	M5
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported
Max Concentration:	Not reported
Number of Workers:	Not reported
Chemical Name:	Dodecanoic acid
Chemical ID:	143-07-7
C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported
C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Not reported
C / c pv pct:	Not reported
C / c max conc code:	Not reported
Comm workers code:	Not reported

2016-2019 Industrial:

Type Process Use:	Processing-incorporation into formulation, mixture, or reaction product
Sector:	Other (requires additional information)
Function Category:	Other (specify)
Number of Sites:	< 10
Number of Workers:	< 10
Chemical Name:	Dodecanoic acid

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Chemical ID:	143-07-7
Case Number:	143077
Ind type code:	PF
Ind sect code:	IS48
Ind sector other desc:	This substance is used in the production of hand cream.
Ind fc code:	U999
Ind funct cat other desc:	This product is used in the production of hand cream.
Ind pv pct:	100
Ind sites code:	S1
Ind workers code:	W1

Chemical ID Number:	144-55-8
Case Number:	144558
Chemical Name:	Carbonic acid sodium salt (1:1)
Activity:	Not reported
Number of Workers:	50 - 99
Max Concentration:	1% - < 30%
Chemical Recycled:	No
Physical Forms:	Dry Powder
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 740
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Marubeni America Corporation
Domestic pc address line1:	375 Lexington Ave.
Domestic pc address line2:	Not reported
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633
Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610
Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	0
2019 import pv:	0
2019 pv:	0
2018 pv:	0

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

2017 pv:	92637
2016 pv:	0
2019 nationally aggregated pv:	750,000,000 - <1,000,000,000 lb
2018 nationally aggregated pv:	750,000,000 - <1,000,000,000 lb
2017 nationally aggregated pv:	750,000,000 - <1,000,000,000 lb
2016 nationally aggregated pv:	750,000,000 - <1,000,000,000 lb
Imported chem never at site:	Not reported
2019 v used on-site:	Not reported
2019 v exported:	Not reported
Pct byp code:	B1
Percent byproduct:	0 percent by weight
Workers code:	W4
Max conc code:	M2
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported
Max Concentration:	Not reported
Number of Workers:	Not reported
Chemical Name:	Carbonic acid sodium salt (1:1)
Chemical ID:	144-55-8
C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported
C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Not reported
C / c pv pct:	Not reported
C / c max conc code:	Not reported
Comm workers code:	Not reported

2016-2019 Industrial:

Type Process Use:	Processing as a reactant
Sector:	Plastics Product Manufacturing
Function Category:	Propellants and blowing agents
Number of Sites:	< 10
Number of Workers:	50 - 99
Chemical Name:	Carbonic acid sodium salt (1:1)
Chemical ID:	144-55-8
Case Number:	144558
Ind type code:	PC
Ind sect code:	IS35
Ind sector other desc:	Not reported
Ind fc code:	U027
Ind funct cat other desc:	Not reported
Ind pv pct:	10
Ind sites code:	S1
Ind workers code:	W4

Chemical ID Number:	14807-96-6
Case Number:	14807966
Chemical Name:	Talc (Mg3H2(SiO3)4)
Activity:	Import

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Number of Workers:	50 - 99
Max Concentration:	90% +
Chemical Recycled:	NKRA
Physical Forms:	Not reported
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 740
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Marubeni America Corporation
Domestic pc address line1:	375 Lexington Ave.
Domestic pc address line2:	Not reported
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633
Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610
Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	0
2019 import pv:	69831
2019 pv:	69831
2018 pv:	293653
2017 pv:	391940
2016 pv:	530839
2019 nationally aggregated pv:	50,000,000 - <100,000,000 lb
2018 nationally aggregated pv:	50,000,000 - <100,000,000 lb
2017 nationally aggregated pv:	50,000,000 - <100,000,000 lb
2016 nationally aggregated pv:	100,000,000 - <250,000,000 lb
Imported chem never at site:	Yes
2019 v used on-site:	Not reported
2019 v exported:	0
Pct byp code:	B1
Percent byproduct:	0 percent by weight
Workers code:	W4
Max conc code:	M5
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported
Max Concentration:	Not reported
Number of Workers:	Not reported
Chemical Name:	Talc (Mg3H2(SiO3)4)
Chemical ID:	14807-96-6
C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported
C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Not reported
C / c pv pct:	Not reported
C / c max conc code:	Not reported
Comm workers code:	Not reported

2016-2019 Industrial:

Type Process Use:	Processing-incorporation into article
Sector:	Plastics Product Manufacturing
Function Category:	Dusting agent
Number of Sites:	< 10
Number of Workers:	50 - 99
Chemical Name:	Talc (Mg3H2(SiO3)4)
Chemical ID:	14807-96-6
Case Number:	14807966
Ind type code:	PA
Ind sect code:	IS35
Ind sector other desc:	Not reported
Ind fc code:	F014
Ind funct cat other desc:	Not reported
Ind pv pct:	100
Ind sites code:	S1
Ind workers code:	W4

Chemical ID Number:	14808-60-7
Case Number:	14808607
Chemical Name:	Quartz (SiO2)
Activity:	Import
Number of Workers:	10 - 24
Max Concentration:	30% - < 60%
Chemical Recycled:	NKRA
Physical Forms:	Pellets or Large Crystals
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 740
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Marubeni America Corporation
Domestic pc address line1:	375 Lexington Ave.
Domestic pc address line2:	Not reported
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633
Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610
Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	0
2019 import pv:	354941
2019 pv:	354941
2018 pv:	432102
2017 pv:	593037
2016 pv:	577605
2019 nationally aggregated pv:	750,000,000 - <1,000,000,000 lb
2018 nationally aggregated pv:	1,000,000,000 - <5,000,000,000 lb
2017 nationally aggregated pv:	750,000,000 - <1,000,000,000 lb
2016 nationally aggregated pv:	750,000,000 - <1,000,000,000 lb
Imported chem never at site:	Yes
2019 v used on-site:	Not reported
2019 v exported:	0
Pct byp code:	B1
Percent byproduct:	0 percent by weight
Workers code:	W2
Max conc code:	M3
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported
Max Concentration:	Not reported
Number of Workers:	Not reported
Chemical Name:	Quartz (SiO2)
Chemical ID:	14808-60-7
C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported
C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Not reported
C / c pv pct:	Not reported
C / c max conc code:	Not reported
Comm workers code:	Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

2016-2019 Industrial:

Type Process Use:	Processing-incorporation into formulation, mixture, or reaction product
Sector:	All Other Chemical Product and Preparation Manufacturing
Function Category:	Fillers
Number of Sites:	< 10
Number of Workers:	10 - 24
Chemical Name:	Quartz (SiO2)
Chemical ID:	14808-60-7
Case Number:	14808607
Ind type code:	PF
Ind sect code:	IS34
Ind sector other desc:	Not reported
Ind fc code:	U009
Ind funct cat other desc:	Not reported
Ind pv pct:	100
Ind sites code:	S1
Ind workers code:	W2

Chemical ID Number:	1552-42-7
Case Number:	1552427
Chemical Name:	1(3H)-Isobenzofuranone, 6-(dimethylamino)-3,3-bis[4-(dimethylamino)phenyl]-
Activity:	Import
Number of Workers:	1000 - 9999
Max Concentration:	90% +
Chemical Recycled:	NKRA
Physical Forms:	Dry Powder
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 740
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Marubeni America Corporation
Domestic pc address line1:	375 Lexington Ave.
Domestic pc address line2:	Not reported
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633
Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610
Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	0
2019 import pv:	122355
2019 pv:	122355
2018 pv:	388010
2017 pv:	182982
2016 pv:	23148
2019 nationally aggregated pv:	<1,000,000 lb
2018 nationally aggregated pv:	<1,000,000 lb
2017 nationally aggregated pv:	<1,000,000 lb
2016 nationally aggregated pv:	<1,000,000 lb
Imported chem never at site:	Yes
2019 v used on-site:	Not reported
2019 v exported:	0
Pct byp code:	B1
Percent byproduct:	0 percent by weight
Workers code:	W7
Max conc code:	M5
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported
Max Concentration:	Not reported
Number of Workers:	Not reported
Chemical Name:	1(3H)-Isobenzofuranone, 6-(dimethylamino)-3,3-bis[4-(dimethylamino)phenyl]-
Chemical ID:	1552-42-7
C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported
C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Not reported
C / c pv pct:	Not reported
C / c max conc code:	Not reported
Comm workers code:	Not reported

2016-2019 Industrial:

Type Process Use:	Processing-incorporation into article
Sector:	Paper Manufacturing
Function Category:	Dye
Number of Sites:	< 10
Number of Workers:	1000 - 9999
Chemical Name:	1(3H)-Isobenzofuranone, 6-(dimethylamino)-3,3-bis[4-(dimethylamino)phenyl]-
Chemical ID:	1552-42-7
Case Number:	1552427
Ind type code:	PA
Ind sect code:	IS9
Ind sector other desc:	Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Ind fc code:	F019
Ind funct cat other desc:	Not reported
Ind pv pct:	100
Ind sites code:	S1
Ind workers code:	W7

Chemical ID Number:	161074-93-7
Case Number:	161074937
Chemical Name:	D-Glucopyranose, oligomeric, 2-ethylhexyl glycosides
Activity:	Import
Number of Workers:	10 - 24
Max Concentration:	60% - < 90%
Chemical Recycled:	NKRA
Physical Forms:	Other Solid
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 740
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Marubeni America Corporation
Domestic pc address line1:	375 Lexington Ave.
Domestic pc address line2:	Not reported
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633
Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610
Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	0
2019 import pv:	136420
2019 pv:	136420
2018 pv:	436024
2017 pv:	377836
2016 pv:	303885
2019 nationally aggregated pv:	136420
2018 nationally aggregated pv:	436024
2017 nationally aggregated pv:	377836

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

2016 nationally aggregated pv:	303885
Imported chem never at site:	Yes
2019 v used on-site:	Not reported
2019 v exported:	0
Pct byp code:	B1
Percent byproduct:	0 percent by weight
Workers code:	W2
Max conc code:	M4
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported
Max Concentration:	Not reported
Number of Workers:	Not reported
Chemical Name:	D-Glucopyranose, oligomeric, 2-ethylhexyl glycosides
Chemical ID:	161074-93-7
C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported
C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Not reported
C / c pv pct:	Not reported
C / c max conc code:	Not reported
Comm workers code:	Not reported

2016-2019 Industrial:

Type Process Use:	Processing-incorporation into formulation, mixture, or reaction product
Sector:	Soap, Cleaning Compound, and Toilet Preparation Manufacturing
Function Category:	Cleaning agent
Number of Sites:	< 10
Number of Workers:	10 - 24
Chemical Name:	D-Glucopyranose, oligomeric, 2-ethylhexyl glycosides
Chemical ID:	161074-93-7
Case Number:	161074937
Ind type code:	PF
Ind sect code:	IS29
Ind sector other desc:	Not reported
Ind fc code:	F073
Ind funct cat other desc:	Not reported
Ind pv pct:	100
Ind sites code:	S1
Ind workers code:	W2

Chemical ID Number:	21645-51-2
Case Number:	21645512
Chemical Name:	Aluminum hydroxide (Al(OH)3)
Activity:	Import
Number of Workers:	1000 - 9999
Max Concentration:	90% +
Chemical Recycled:	NKRA
Physical Forms:	Dry Powder

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 740
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Marubeni America Corporation
Domestic pc address line1:	375 Lexington Ave.
Domestic pc address line2:	Not reported
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633
Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610
Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	0
2019 import pv:	88184
2019 pv:	88184
2018 pv:	158731
2017 pv:	135451
2016 pv:	101588
2019 nationally aggregated pv:	1,000,000,000 - <5,000,000,000 lb
2018 nationally aggregated pv:	1,000,000,000 - <5,000,000,000 lb
2017 nationally aggregated pv:	1,000,000,000 - <5,000,000,000 lb
2016 nationally aggregated pv:	1,000,000,000 - <5,000,000,000 lb
Imported chem never at site:	Yes
2019 v used on-site:	Not reported
2019 v exported:	0
Pct byp code:	B1
Percent byproduct:	0 percent by weight
Workers code:	W7
Max conc code:	M5
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported
Max Concentration:	Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Number of Workers:	Not reported
Chemical Name:	Aluminum hydroxide (Al(OH)3)
Chemical ID:	21645-51-2
C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported
C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Not reported
C / c pv pct:	Not reported
C / c max conc code:	Not reported
Comm workers code:	Not reported

2016-2019 Industrial:

Type Process Use:	Processing-incorporation into article
Sector:	Paper Manufacturing
Function Category:	Filler
Number of Sites:	< 10
Number of Workers:	1000 - 9999
Chemical Name:	Aluminum hydroxide (Al(OH)3)
Chemical ID:	21645-51-2
Case Number:	21645512
Ind type code:	PA
Ind sect code:	IS9
Ind sector other desc:	Not reported
Ind fc code:	F022
Ind funct cat other desc:	Not reported
Ind pv pct:	100
Ind sites code:	S1
Ind workers code:	W7

Chemical ID Number:	25134-21-8
Case Number:	25134218
Chemical Name:	4,7-Methanoisobenzofuran-1,3-dione, 3a,4,7,7a-tetrahydromethyl-, (3aR,4S,7R,7aS)-rel-
Activity:	Import
Number of Workers:	10 - 24
Max Concentration:	90% +
Chemical Recycled:	NKRA
Physical Forms:	Liquid
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 740
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Marubeni America Corporation
Domestic pc address line1:	375 Lexington Ave.
Domestic pc address line2:	Not reported
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633
Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610
Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	0
2019 import pv:	1345937
2019 pv:	1345937
2018 pv:	2041782
2017 pv:	1639150
2016 pv:	761456
2019 nationally aggregated pv:	1410153
2018 nationally aggregated pv:	2301186
2017 nationally aggregated pv:	1790145
2016 nationally aggregated pv:	804137
Imported chem never at site:	Yes
2019 v used on-site:	Not reported
2019 v exported:	0
Pct byp code:	B1
Percent byproduct:	0 percent by weight
Workers code:	W2
Max conc code:	M5
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported
Max Concentration:	Not reported
Number of Workers:	Not reported
Chemical Name:	4,7-Methanoisobenzofuran-1,3-dione, 3a,4,7,7a-tetrahydromethyl-, (3aR,4S,7R,7aS)-rel-
Chemical ID:	25134-21-8
C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported
C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Not reported
C / c pv pct:	Not reported
C / c max conc code:	Not reported
Comm workers code:	Not reported

2016-2019 Industrial:

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Type Process Use:	Processing-incorporation into formulation, mixture, or reaction product
Sector:	All Other Chemical Product and Preparation Manufacturing
Function Category:	Fillers
Number of Sites:	< 10
Number of Workers:	10 - 24
Chemical Name:	4,7-Methanoisobenzofuran-1,3-dione, 3a,4,7,7a-tetrahydromethyl-, (3aR,4S,7R,7aS)-rel-
Chemical ID:	25134-21-8
Case Number:	25134218
Ind type code:	PF
Ind sect code:	IS34
Ind sector other desc:	Not reported
Ind fc code:	U009
Ind funct cat other desc:	Not reported
Ind pv pct:	100
Ind sites code:	S1
Ind workers code:	W2

Chemical ID Number:	27176-87-0
Case Number:	27176870
Chemical Name:	Benzenesulfonic acid, dodecyl-
Activity:	Import
Number of Workers:	25 - 49
Max Concentration:	60% - < 90%
Chemical Recycled:	NKRA
Physical Forms:	Other Solid
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 740
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Marubeni America Corporation
Domestic pc address line1:	375 Lexington Ave.
Domestic pc address line2:	Not reported
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633
Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610
Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers
Site naics activity 1:	Import

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	0
2019 import pv:	613549
2019 pv:	613549
2018 pv:	1581259
2017 pv:	329822
2016 pv:	124090
2019 nationally aggregated pv:	1,000,000 - <10,000,000 lb
2018 nationally aggregated pv:	10,000,000 - <50,000,000 lb
2017 nationally aggregated pv:	1,000,000 - <10,000,000 lb
2016 nationally aggregated pv:	1,000,000 - <10,000,000 lb
Imported chem never at site:	Yes
2019 v used on-site:	Not reported
2019 v exported:	0
Pct byp code:	B3
Percent byproduct:	At least 50 percent but less than 100 percent
Workers code:	W3
Max conc code:	M4
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported
Max Concentration:	Not reported
Number of Workers:	Not reported
Chemical Name:	Benzenesulfonic acid, dodecyl-
Chemical ID:	27176-87-0
C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported
C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Not reported
C / c pv pct:	Not reported
C / c max conc code:	Not reported
Comm workers code:	Not reported

2016-2019 Industrial:

Type Process Use:	Processing-incorporation into formulation, mixture, or reaction product
Sector:	Soap, Cleaning Compound, and Toilet Preparation Manufacturing
Function Category:	Cleaning agent
Number of Sites:	< 10
Number of Workers:	10 - 24
Chemical Name:	Benzenesulfonic acid, dodecyl-
Chemical ID:	27176-87-0
Case Number:	27176870
Ind type code:	PF
Ind sect code:	IS29
Ind sector other desc:	Not reported
Ind fc code:	F073
Ind funct cat other desc:	Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Ind pv pct:	100
Ind sites code:	S1
Ind workers code:	W2
Chemical ID Number:	41481-66-7
Case Number:	41481667
Chemical Name:	Phenol, 4,4'-sulfonylbis[2-(2-propen-1-yl)-
Activity:	Import
Number of Workers:	1000 - 9999
Max Concentration:	90% +
Chemical Recycled:	NKRA
Physical Forms:	Dry Powder
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 740
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Marubeni America Corporation
Domestic pc address line1:	375 Lexington Ave.
Domestic pc address line2:	Not reported
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633
Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610
Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	0
2019 import pv:	1644764
2019 pv:	1644764
2018 pv:	1296305
2017 pv:	1633256
2016 pv:	1491588
2019 nationally aggregated pv:	1,000,000 lb - <20,000,000 lb
2018 nationally aggregated pv:	1,000,000 lb - <20,000,000 lb
2017 nationally aggregated pv:	1,000,000 lb - <20,000,000 lb
2016 nationally aggregated pv:	1,000,000 lb - <20,000,000 lb
Imported chem never at site:	Yes

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

2019 v used on-site:	Not reported
2019 v exported:	0
Pct byp code:	B1
Percent byproduct:	0 percent by weight
Workers code:	W7
Max conc code:	M5
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported
Max Concentration:	Not reported
Number of Workers:	Not reported
Chemical Name:	Phenol, 4,4'-sulfonylbis[2-(2-propen-1-yl)-
Chemical ID:	41481-66-7
C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported
C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Not reported
C / c pv pct:	Not reported
C / c max conc code:	Not reported
Comm workers code:	Not reported

2016-2019 Industrial:

Type Process Use:	Processing-incorporation into article
Sector:	Paper Manufacturing
Function Category:	Other
Number of Sites:	< 10
Number of Workers:	1000 - 9999
Chemical Name:	Phenol, 4,4'-sulfonylbis[2-(2-propen-1-yl)-
Chemical ID:	41481-66-7
Case Number:	41481667
Ind type code:	PA
Ind sect code:	IS9
Ind sector other desc:	Not reported
Ind fc code:	F999
Ind funct cat other desc:	Developer for thermal paper.
Ind pv pct:	100
Ind sites code:	S1
Ind workers code:	W7

Chemical ID Number:	532-32-1
Case Number:	532321
Chemical Name:	Benzoic acid, sodium salt (1:1)
Activity:	Import
Number of Workers:	< 10
Max Concentration:	90% +
Chemical Recycled:	NKRA
Physical Forms:	Dry Powder
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 740

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Marubeni America Corporation
Domestic pc address line1:	375 Lexington Ave.
Domestic pc address line2:	Not reported
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633
Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610
Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	0
2019 import pv:	44092
2019 pv:	44092
2018 pv:	100001
2017 pv:	0
2016 pv:	0
2019 nationally aggregated pv:	20,000,000 lb - <100,000,000 lb
2018 nationally aggregated pv:	20,000,000 lb - <100,000,000 lb
2017 nationally aggregated pv:	20,000,000 lb - <100,000,000 lb
2016 nationally aggregated pv:	20,000,000 lb - <100,000,000 lb
Imported chem never at site:	Yes
2019 v used on-site:	Not reported
2019 v exported:	0
Pct byp code:	B1
Percent byproduct:	0 percent by weight
Workers code:	W1
Max conc code:	M5
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported
Max Concentration:	Not reported
Number of Workers:	Not reported
Chemical Name:	Benzoic acid, sodium salt (1:1)
Chemical ID:	532-32-1

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported
C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Not reported
C / c pv pct:	Not reported
C / c max conc code:	Not reported
Comm workers code:	Not reported

2016-2019 Industrial:

Type Process Use:	Processing-incorporation into formulation, mixture, or reaction product
Sector:	Food, beverage, and tobacco product manufacturing
Function Category:	Preservative
Number of Sites:	< 10
Number of Workers:	< 10
Chemical Name:	Benzoic acid, sodium salt (1:1)
Chemical ID:	532-32-1
Case Number:	532321
Ind type code:	PF
Ind sect code:	IS6
Ind sector other desc:	Not reported
Ind fc code:	F109
Ind funct cat other desc:	Not reported
Ind pv pct:	100
Ind sites code:	S1
Ind workers code:	W1

Chemical ID Number:	557-04-0
Case Number:	557040
Chemical Name:	Octadecanoic acid, magnesium salt (2:1)
Activity:	Not reported
Number of Workers:	Not reported
Max Concentration:	Not reported
Chemical Recycled:	Not reported
Physical Forms:	Not reported
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 740
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Marubeni America Corporation
Domestic pc address line1:	375 Lexington Ave.
Domestic pc address line2:	Not reported
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633
Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610
Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	Not reported
2019 import pv:	Not reported
2019 pv:	Not reported
2018 pv:	0
2017 pv:	0
2016 pv:	97124
2019 nationally aggregated pv:	1,000,000 - <10,000,000 lb
2018 nationally aggregated pv:	1,000,000 - <10,000,000 lb
2017 nationally aggregated pv:	1,000,000 - <10,000,000 lb
2016 nationally aggregated pv:	1,000,000 - <10,000,000 lb
Imported chem never at site:	Not reported
2019 v used on-site:	Not reported
2019 v exported:	Not reported
Pct byp code:	Not reported
Percent byproduct:	Not reported
Workers code:	Not reported
Max conc code:	Not reported
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported
Max Concentration:	Not reported
Number of Workers:	Not reported
Chemical Name:	Octadecanoic acid, magnesium salt (2:1)
Chemical ID:	557-04-0
C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported
C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Not reported
C / c pv pct:	Not reported
C / c max conc code:	Not reported
Comm workers code:	Not reported

2016-2019 Industrial:

Type Process Use:	Not reported
Sector:	Not reported
Function Category:	Not reported
Number of Sites:	Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Number of Workers:	Not reported
Chemical Name:	Octadecanoic acid, magnesium salt (2:1)
Chemical ID:	557-04-0
Case Number:	557040
Ind type code:	Not reported
Ind sect code:	Not reported
Ind sector other desc:	Not reported
Ind fc code:	Not reported
Ind funct cat other desc:	Not reported
Ind pv pct:	Not reported
Ind sites code:	Not reported
Ind workers code:	Not reported

Chemical ID Number:	56-40-6
Case Number:	56406
Chemical Name:	Glycine
Activity:	Not reported
Number of Workers:	Not reported
Max Concentration:	Not reported
Chemical Recycled:	Not reported
Physical Forms:	Not reported
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 740
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Marubeni America Corporation
Domestic pc address line1:	375 Lexington Ave.
Domestic pc address line2:	Not reported
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633
Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610
Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	Not reported
2019 import pv:	Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

2019 pv:	Not reported
2018 pv:	0
2017 pv:	1187521
2016 pv:	3246644
2019 nationally aggregated pv:	10,000,000 - <50,000,000 lb
2018 nationally aggregated pv:	10,000,000 - <50,000,000 lb
2017 nationally aggregated pv:	10,000,000 - <50,000,000 lb
2016 nationally aggregated pv:	10,000,000 - <50,000,000 lb
Imported chem never at site:	Not reported
2019 v used on-site:	Not reported
2019 v exported:	Not reported
Pct byp code:	Not reported
Percent byproduct:	Not reported
Workers code:	Not reported
Max conc code:	Not reported
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported
Max Concentration:	Not reported
Number of Workers:	Not reported
Chemical Name:	Glycine
Chemical ID:	56-40-6
C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported
C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Not reported
C / c pv pct:	Not reported
C / c max conc code:	Not reported
Comm workers code:	Not reported

2016-2019 Industrial:

Type Process Use:	Not reported
Sector:	Not reported
Function Category:	Not reported
Number of Sites:	Not reported
Number of Workers:	Not reported
Chemical Name:	Glycine
Chemical ID:	56-40-6
Case Number:	56406
Ind type code:	Not reported
Ind sect code:	Not reported
Ind sector other desc:	Not reported
Ind fc code:	Not reported
Ind funct cat other desc:	Not reported
Ind pv pct:	Not reported
Ind sites code:	Not reported
Ind workers code:	Not reported

Chemical ID Number:	56-81-5
Case Number:	56815

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Chemical Name:	1,2,3-Propanetriol
Activity:	Import
Number of Workers:	10 - 24
Max Concentration:	90% +
Chemical Recycled:	NKRA
Physical Forms:	Not reported
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 740
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Marubeni America Corporation
Domestic pc address line1:	375 Lexington Ave.
Domestic pc address line2:	Not reported
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633
Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610
Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	0
2019 import pv:	44092
2019 pv:	44092
2018 pv:	132276
2017 pv:	0
2016 pv:	0
2019 nationally aggregated pv:	1,000,000,000 - <5,000,000,000 lb
2018 nationally aggregated pv:	1,000,000,000 - <5,000,000,000 lb
2017 nationally aggregated pv:	1,000,000,000 - <5,000,000,000 lb
2016 nationally aggregated pv:	1,000,000,000 - <5,000,000,000 lb
Imported chem never at site:	Yes
2019 v used on-site:	Not reported
2019 v exported:	0
Pct byp code:	B1
Percent byproduct:	0 percent by weight
Workers code:	W2
Max conc code:	M5
Joint fc code:	Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Joint function category: Not reported
Joint funct cat other desc: Not reported

2016-2019 Consumer:
Product Category: Not reported
Children Products: Not reported
Max Concentration: Not reported
Number of Workers: Not reported
Chemical Name: 1,2,3-Propanetriol
Chemical ID: 56-81-5
C / c prod cat code: Not reported
Cons / comm prod cat other desc: Not reported
C / c fc code: Not reported
Cons / comm function category: Not reported
Cons / comm funct cat other desc: Not reported
Cons or comm use: Not reported
C / c pv pct: Not reported
C / c max conc code: Not reported
Comm workers code: Not reported

2016-2019 Industrial:
Type Process Use: Processing-incorporation into formulation, mixture, or reaction product
Sector: Food, beverage, and tobacco product manufacturing
Function Category: Other (specify)
Number of Sites: < 10
Number of Workers: 10 - 24
Chemical Name: 1,2,3-Propanetriol
Chemical ID: 56-81-5
Case Number: 56815
Ind type code: PF
Ind sect code: IS6
Ind sector other desc: Not reported
Ind fc code: U999
Ind funct cat other desc: Used to produce vape flavoring
Ind pv pct: 100
Ind sites code: S1
Ind workers code: W2

Chemical ID Number: 57-10-3
Case Number: 57103
Chemical Name: Hexadecanoic acid
Activity: Import
Number of Workers: 10 - 24
Max Concentration: 90% +
Chemical Recycled: NKRA
Physical Forms: Other Solid
Site Name: MARUBENI SPECIALTY CHEMICALS INC.
Site Address: 10 BANK ST
Site Address 2: SUITE 740
Site City,State,Zip: WHITE PLAINS, NY 10606
Site County: WESTCHESTER COUNTY
Chemical ID type: CASRN
Domestic parent company name: Marubeni America Corporation
Domestic pc address line1: 375 Lexington Ave.
Domestic pc address line2: Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633
Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610
Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	0
2019 import pv:	5367853
2019 pv:	5367853
2018 pv:	1216719
2017 pv:	0
2016 pv:	0
2019 nationally aggregated pv:	100,000,000 lb - <1,000,000,000 lb
2018 nationally aggregated pv:	100,000,000 lb - <1,000,000,000 lb
2017 nationally aggregated pv:	100,000,000 lb - <1,000,000,000 lb
2016 nationally aggregated pv:	100,000,000 lb - <1,000,000,000 lb
Imported chem never at site:	Yes
2019 v used on-site:	Not reported
2019 v exported:	0
Pct byp code:	B1
Percent byproduct:	0 percent by weight
Workers code:	W2
Max conc code:	M5
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported
Max Concentration:	Not reported
Number of Workers:	Not reported
Chemical Name:	Hexadecanoic acid
Chemical ID:	57-10-3
C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported
C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

C / c pv pct:	Not reported
C / c max conc code:	Not reported
Comm workers code:	Not reported

2016-2019 Industrial:

Type Process Use:	Processing-incorporation into formulation, mixture, or reaction product
Sector:	Food, beverage, and tobacco product manufacturing
Function Category:	Other
Number of Sites:	< 10
Number of Workers:	10 - 24
Chemical Name:	Hexadecanoic acid
Chemical ID:	57-10-3
Case Number:	57103
Ind type code:	PF
Ind sect code:	IS6
Ind sector other desc:	Not reported
Ind fc code:	F999
Ind funct cat other desc:	Used in the production of feed supplements for cows.
Ind pv pct:	100
Ind sites code:	S1
Ind workers code:	W2

Chemical ID Number:	57-11-4
Case Number:	57114
Chemical Name:	Octadecanoic acid
Activity:	Not reported
Number of Workers:	Not reported
Max Concentration:	Not reported
Chemical Recycled:	Not reported
Physical Forms:	Not reported
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 740
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Marubeni America Corporation
Domestic pc address line1:	375 Lexington Ave.
Domestic pc address line2:	Not reported
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610
Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	Not reported
2019 import pv:	Not reported
2019 pv:	Not reported
2018 pv:	882316
2017 pv:	9458
2016 pv:	0
2019 nationally aggregated pv:	250,000,000 - <500,000,000 lb
2018 nationally aggregated pv:	500,000,000 - <750,000,000 lb
2017 nationally aggregated pv:	500,000,000 - <750,000,000 lb
2016 nationally aggregated pv:	500,000,000 - <750,000,000 lb
Imported chem never at site:	Not reported
2019 v used on-site:	Not reported
2019 v exported:	Not reported
Pct byp code:	Not reported
Percent byproduct:	Not reported
Workers code:	Not reported
Max conc code:	Not reported
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported
Max Concentration:	Not reported
Number of Workers:	Not reported
Chemical Name:	Octadecanoic acid
Chemical ID:	57-11-4
C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported
C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Not reported
C / c pv pct:	Not reported
C / c max conc code:	Not reported
Comm workers code:	Not reported

2016-2019 Industrial:

Type Process Use:	Not reported
Sector:	Not reported
Function Category:	Not reported
Number of Sites:	Not reported
Number of Workers:	Not reported
Chemical Name:	Octadecanoic acid
Chemical ID:	57-11-4
Case Number:	57114
Ind type code:	Not reported
Ind sect code:	Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Ind sector other desc:	Not reported
Ind fc code:	Not reported
Ind funct cat other desc:	Not reported
Ind pv pct:	Not reported
Ind sites code:	Not reported
Ind workers code:	Not reported

Chemical ID Number:	60-00-4
Case Number:	60004
Chemical Name:	Glycine, N,N'-1,2-ethanediylbis[N-(carboxymethyl)-
Activity:	Not reported
Number of Workers:	100 - 499
Max Concentration:	90% +
Chemical Recycled:	No
Physical Forms:	Not reported
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 740
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Marubeni America Corporation
Domestic pc address line1:	375 Lexington Ave.
Domestic pc address line2:	Not reported
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633
Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610
Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	0
2019 import pv:	0
2019 pv:	0
2018 pv:	0
2017 pv:	79630
2016 pv:	39815
2019 nationally aggregated pv:	10,000,000 - <50,000,000 lb
2018 nationally aggregated pv:	50,000,000 - <100,000,000 lb

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

2017 nationally aggregated pv:	50,000,000 - <100,000,000 lb
2016 nationally aggregated pv:	10,000,000 - <50,000,000 lb
Imported chem never at site:	Not reported
2019 v used on-site:	Not reported
2019 v exported:	Not reported
Pct byp code:	B1
Percent byproduct:	0 percent by weight
Workers code:	W5
Max conc code:	M5
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported
Max Concentration:	Not reported
Number of Workers:	Not reported
Chemical Name:	Glycine, N,N'-1,2-ethanediylbis[N-(carboxymethyl)-
Chemical ID:	60-00-4
C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported
C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Not reported
C / c pv pct:	Not reported
C / c max conc code:	Not reported
Comm workers code:	Not reported

2016-2019 Industrial:

Type Process Use:	Processing as a reactant
Sector:	Agriculture, Forestry, Fishing and Hunting
Function Category:	Chelating agent
Number of Sites:	< 10
Number of Workers:	100 - 499
Chemical Name:	Glycine, N,N'-1,2-ethanediylbis[N-(carboxymethyl)-
Chemical ID:	60-00-4
Case Number:	60004
Ind type code:	PC
Ind sect code:	IS1
Ind sector other desc:	Not reported
Ind fc code:	F062
Ind funct cat other desc:	Not reported
Ind pv pct:	100
Ind sites code:	S1
Ind workers code:	W5

Chemical ID Number:	65-85-0
Case Number:	65850
Chemical Name:	Benzoic acid
Activity:	Not reported
Number of Workers:	Not reported
Max Concentration:	Not reported
Chemical Recycled:	Not reported
Physical Forms:	Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 740
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Marubeni America Corporation
Domestic pc address line1:	375 Lexington Ave.
Domestic pc address line2:	Not reported
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633
Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610
Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	Not reported
2019 import pv:	Not reported
2019 pv:	Not reported
2018 pv:	219702
2017 pv:	73334
2016 pv:	75556
2019 nationally aggregated pv:	100,000,000 lb - <1,000,000,000 lb
2018 nationally aggregated pv:	100,000,000 lb - <1,000,000,000 lb
2017 nationally aggregated pv:	100,000,000 lb - <1,000,000,000 lb
2016 nationally aggregated pv:	100,000,000 lb - <1,000,000,000 lb
Imported chem never at site:	Not reported
2019 v used on-site:	Not reported
2019 v exported:	Not reported
Pct byp code:	Not reported
Percent byproduct:	Not reported
Workers code:	Not reported
Max conc code:	Not reported
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported
Max Concentration:	Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Number of Workers:	Not reported
Chemical Name:	Benzoic acid
Chemical ID:	65-85-0
C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported
C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Not reported
C / c pv pct:	Not reported
C / c max conc code:	Not reported
Comm workers code:	Not reported

2016-2019 Industrial:

Type Process Use:	Not reported
Sector:	Not reported
Function Category:	Not reported
Number of Sites:	Not reported
Number of Workers:	Not reported
Chemical Name:	Benzoic acid
Chemical ID:	65-85-0
Case Number:	65850
Ind type code:	Not reported
Ind sect code:	Not reported
Ind sector other desc:	Not reported
Ind fc code:	Not reported
Ind funct cat other desc:	Not reported
Ind pv pct:	Not reported
Ind sites code:	Not reported
Ind workers code:	Not reported

Chemical ID Number:	65997-17-3
Case Number:	65997173
Chemical Name:	Glass, oxide, chemicals
Activity:	Import
Number of Workers:	50 - 99
Max Concentration:	90% +
Chemical Recycled:	NKRA
Physical Forms:	Not reported
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 740
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Marubeni America Corporation
Domestic pc address line1:	375 Lexington Ave.
Domestic pc address line2:	Not reported
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633
Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610
Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	0
2019 import pv:	145480
2019 pv:	145480
2018 pv:	611778
2017 pv:	816541
2016 pv:	1105914
2019 nationally aggregated pv:	5,000,000,000 - <10,000,000,000 lb
2018 nationally aggregated pv:	5,000,000,000 - <10,000,000,000 lb
2017 nationally aggregated pv:	5,000,000,000 - <10,000,000,000 lb
2016 nationally aggregated pv:	5,000,000,000 - <10,000,000,000 lb
Imported chem never at site:	Yes
2019 v used on-site:	Not reported
2019 v exported:	0
Pct byp code:	B1
Percent byproduct:	0 percent by weight
Workers code:	W4
Max conc code:	M5
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported
Max Concentration:	Not reported
Number of Workers:	Not reported
Chemical Name:	Glass, oxide, chemicals
Chemical ID:	65997-17-3
C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported
C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Not reported
C / c pv pct:	Not reported
C / c max conc code:	Not reported
Comm workers code:	Not reported

2016-2019 Industrial:

Type Process Use:	Processing-incorporation into article
Sector:	Plastics Product Manufacturing

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Function Category:	Monomers
Number of Sites:	< 10
Number of Workers:	50 - 99
Chemical Name:	Glass, oxide, chemicals
Chemical ID:	65997-17-3
Case Number:	65997173
Ind type code:	PA
Ind sect code:	IS35
Ind sector other desc:	Not reported
Ind fc code:	F038
Ind funct cat other desc:	Not reported
Ind pv pct:	0
Ind sites code:	S1
Ind workers code:	W4

Chemical ID Number:	67-56-1
Case Number:	67561
Chemical Name:	Methanol
Activity:	Not reported
Number of Workers:	Not reported
Max Concentration:	Not reported
Chemical Recycled:	Not reported
Physical Forms:	Not reported
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 740
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Marubeni America Corporation
Domestic pc address line1:	375 Lexington Ave.
Domestic pc address line2:	Not reported
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633
Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610
Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

2019 domestic pv:	Not reported
2019 import pv:	Not reported
2019 pv:	Not reported
2018 pv:	0
2017 pv:	0
2016 pv:	67038
2019 nationally aggregated pv:	10,000,000,000 - <20,000,000,000 lb
2018 nationally aggregated pv:	10,000,000,000 - <20,000,000,000 lb
2017 nationally aggregated pv:	10,000,000,000 - <20,000,000,000 lb
2016 nationally aggregated pv:	10,000,000,000 - <20,000,000,000 lb
Imported chem never at site:	Not reported
2019 v used on-site:	Not reported
2019 v exported:	Not reported
Pct byp code:	Not reported
Percent byproduct:	Not reported
Workers code:	Not reported
Max conc code:	Not reported
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported
Max Concentration:	Not reported
Number of Workers:	Not reported
Chemical Name:	Methanol
Chemical ID:	67-56-1
C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported
C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Not reported
C / c pv pct:	Not reported
C / c max conc code:	Not reported
Comm workers code:	Not reported

2016-2019 Industrial:

Type Process Use:	Not reported
Sector:	Not reported
Function Category:	Not reported
Number of Sites:	Not reported
Number of Workers:	Not reported
Chemical Name:	Methanol
Chemical ID:	67-56-1
Case Number:	67561
Ind type code:	Not reported
Ind sect code:	Not reported
Ind sector other desc:	Not reported
Ind fc code:	Not reported
Ind funct cat other desc:	Not reported
Ind pv pct:	Not reported
Ind sites code:	Not reported
Ind workers code:	Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Chemical ID Number:	68439-57-6
Case Number:	68439576
Chemical Name:	Sulfonic acids, C14-16-alkane hydroxy and C14-16-alkene, sodium salts
Activity:	Import
Number of Workers:	25 - 49
Max Concentration:	90% +
Chemical Recycled:	NKRA
Physical Forms:	Liquid
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 740
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Marubeni America Corporation
Domestic pc address line1:	375 Lexington Ave.
Domestic pc address line2:	Not reported
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633
Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610
Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	0
2019 import pv:	117461
2019 pv:	117461
2018 pv:	190463
2017 pv:	0
2016 pv:	0
2019 nationally aggregated pv:	50,000,000 - <100,000,000 lb
2018 nationally aggregated pv:	50,000,000 - <100,000,000 lb
2017 nationally aggregated pv:	50,000,000 - <100,000,000 lb
2016 nationally aggregated pv:	50,000,000 - <100,000,000 lb
Imported chem never at site:	Yes
2019 v used on-site:	Not reported
2019 v exported:	0
Pct byp code:	B1
Percent byproduct:	0 percent by weight
Workers code:	W3

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Max conc code:	M5
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported
Max Concentration:	Not reported
Number of Workers:	Not reported
Chemical Name:	Sulfonic acids, C14-16-alkane hydroxy and C14-16-alkene, sodium salts
Chemical ID:	68439-57-6
C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported
C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Not reported
C / c pv pct:	Not reported
C / c max conc code:	Not reported
Comm workers code:	Not reported

2016-2019 Industrial:

Type Process Use:	Processing-incorporation into formulation, mixture, or reaction product
Sector:	Soap, Cleaning Compound, and Toilet Preparation Manufacturing
Function Category:	Surfactant (surface active agent)
Number of Sites:	< 10
Number of Workers:	25 - 49
Chemical Name:	Sulfonic acids, C14-16-alkane hydroxy and C14-16-alkene, sodium salts
Chemical ID:	68439-57-6
Case Number:	68439576
Ind type code:	PF
Ind sect code:	IS29
Ind sector other desc:	Not reported
Ind fc code:	F076
Ind funct cat other desc:	Not reported
Ind pv pct:	100
Ind sites code:	S1
Ind workers code:	W3

Chemical ID Number:	68586-19-6
Case Number:	68586196
Chemical Name:	2-Propenoic acid, 2-methyl-, 2-[(3a,4,7,7a,?,?-hexahydro-4,7-methano-1H-indenyl)oxy]ethyl ester
Activity:	Import
Number of Workers:	10 - 24
Max Concentration:	1% - < 30%
Chemical Recycled:	NKRA
Physical Forms:	Liquid
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 740
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Domestic parent company name:	Marubeni America Corporation
Domestic pc address line1:	375 Lexington Ave.
Domestic pc address line2:	Not reported
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633
Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610
Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	0
2019 import pv:	31431
2019 pv:	31431
2018 pv:	36186
2017 pv:	24286
2016 pv:	5410
2019 nationally aggregated pv:	<1,000,000 lb
2018 nationally aggregated pv:	<1,000,000 lb
2017 nationally aggregated pv:	<1,000,000 lb
2016 nationally aggregated pv:	<1,000,000 lb
Imported chem never at site:	Yes
2019 v used on-site:	Not reported
2019 v exported:	0
Pct byp code:	B1
Percent byproduct:	0 percent by weight
Workers code:	W2
Max conc code:	M2
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported
Max Concentration:	Not reported
Number of Workers:	Not reported
Chemical Name:	2-Propenoic acid, 2-methyl-, 2-[(3a,4,7,7a,?,?-hexahydro-4,7-methano-1H-indenyl)oxy]ethyl ester
Chemical ID:	68586-19-6
C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Not reported
C / c pv pct:	Not reported
C / c max conc code:	Not reported
Comm workers code:	Not reported

2016-2019 Industrial:

Type Process Use:	Processing as a reactant
Sector:	Adhesive Manufacturing
Function Category:	Intermediates
Number of Sites:	< 10
Number of Workers:	10 - 24
Chemical Name:	2-Propenoic acid, 2-methyl-, 2-[(3a,4,7,7a,?,?-hexahydro-4,7-methano-1H-indenyl)oxy]ethyl ester
Chemical ID:	68586-19-6
Case Number:	68586196
Ind type code:	PC
Ind sect code:	IS28
Ind sector other desc:	Not reported
Ind fc code:	U015
Ind funct cat other desc:	Not reported
Ind pv pct:	100
Ind sites code:	S1
Ind workers code:	W2

Chemical ID Number:	6915-15-7
Case Number:	6915157
Chemical Name:	Butanedioic acid, 2-hydroxy-
Activity:	Not reported
Number of Workers:	Not reported
Max Concentration:	Not reported
Chemical Recycled:	Not reported
Physical Forms:	Not reported
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 740
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Marubeni America Corporation
Domestic pc address line1:	375 Lexington Ave.
Domestic pc address line2:	Not reported
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633
Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610
Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	Not reported
2019 import pv:	Not reported
2019 pv:	Not reported
2018 pv:	0
2017 pv:	86888
2016 pv:	0
2019 nationally aggregated pv:	1,000,000 lb - <20,000,000 lb
2018 nationally aggregated pv:	1,000,000 lb - <20,000,000 lb
2017 nationally aggregated pv:	1,000,000 lb - <20,000,000 lb
2016 nationally aggregated pv:	1,000,000 lb - <20,000,000 lb
Imported chem never at site:	Not reported
2019 v used on-site:	Not reported
2019 v exported:	Not reported
Pct byp code:	Not reported
Percent byproduct:	Not reported
Workers code:	Not reported
Max conc code:	Not reported
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported
Max Concentration:	Not reported
Number of Workers:	Not reported
Chemical Name:	Butanedioic acid, 2-hydroxy-
Chemical ID:	6915-15-7
C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported
C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Not reported
C / c pv pct:	Not reported
C / c max conc code:	Not reported
Comm workers code:	Not reported

2016-2019 Industrial:

Type Process Use:	Not reported
Sector:	Not reported
Function Category:	Not reported
Number of Sites:	Not reported
Number of Workers:	Not reported
Chemical Name:	Butanedioic acid, 2-hydroxy-

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Chemical ID:	6915-15-7
Case Number:	6915157
Ind type code:	Not reported
Ind sect code:	Not reported
Ind sector other desc:	Not reported
Ind fc code:	Not reported
Ind funct cat other desc:	Not reported
Ind pv pct:	Not reported
Ind sites code:	Not reported
Ind workers code:	Not reported

Chemical ID Number:	7631-86-9
Case Number:	7631869
Chemical Name:	Silica
Activity:	Import
Number of Workers:	1000 - 9999
Max Concentration:	90% +
Chemical Recycled:	NKRA
Physical Forms:	Dry Powder
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 740
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Marubeni America Corporation
Domestic pc address line1:	375 Lexington Ave.
Domestic pc address line2:	Not reported
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633
Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610
Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	0
2019 import pv:	635868
2019 pv:	635868
2018 pv:	593079

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

2017 pv:	656309
2016 pv:	719912
2019 nationally aggregated pv:	1,000,000,000 - <5,000,000,000 lb
2018 nationally aggregated pv:	1,000,000,000 - <5,000,000,000 lb
2017 nationally aggregated pv:	1,000,000,000 - <5,000,000,000 lb
2016 nationally aggregated pv:	1,000,000,000 - <5,000,000,000 lb
Imported chem never at site:	Yes
2019 v used on-site:	Not reported
2019 v exported:	0
Pct byp code:	B1
Percent byproduct:	0 percent by weight
Workers code:	W7
Max conc code:	M5
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported
Max Concentration:	Not reported
Number of Workers:	Not reported
Chemical Name:	Silica
Chemical ID:	7631-86-9
C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported
C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Not reported
C / c pv pct:	Not reported
C / c max conc code:	Not reported
Comm workers code:	Not reported

2016-2019 Industrial:

Type Process Use:	Processing-incorporation into article
Sector:	Paper Manufacturing
Function Category:	Filler
Number of Sites:	< 10
Number of Workers:	1000 - 9999
Chemical Name:	Silica
Chemical ID:	7631-86-9
Case Number:	7631869
Ind type code:	PA
Ind sect code:	IS9
Ind sector other desc:	Not reported
Ind fc code:	F022
Ind funct cat other desc:	Not reported
Ind pv pct:	100
Ind sites code:	S1
Ind workers code:	W7

Chemical ID Number:	7664-93-9
Case Number:	7664939
Chemical Name:	Sulfuric acid
Activity:	Import

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Number of Workers:	25 - 49
Max Concentration:	90% +
Chemical Recycled:	NKRA
Physical Forms:	Not reported
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 740
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Marubeni America Corporation
Domestic pc address line1:	375 Lexington Ave.
Domestic pc address line2:	Not reported
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633
Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610
Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	0
2019 import pv:	25565
2019 pv:	25565
2018 pv:	65886
2017 pv:	0
2016 pv:	0
2019 nationally aggregated pv:	70,000,000,000 - <80,000,000,000 lb
2018 nationally aggregated pv:	70,000,000,000 - <80,000,000,000 lb
2017 nationally aggregated pv:	70,000,000,000 - <80,000,000,000 lb
2016 nationally aggregated pv:	70,000,000,000 - <80,000,000,000 lb
Imported chem never at site:	Yes
2019 v used on-site:	Not reported
2019 v exported:	0
Pct byp code:	B1
Percent byproduct:	0 percent by weight
Workers code:	W3
Max conc code:	M5
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported
Max Concentration:	Not reported
Number of Workers:	Not reported
Chemical Name:	Sulfuric acid
Chemical ID:	7664-93-9
C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported
C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Not reported
C / c pv pct:	Not reported
C / c max conc code:	Not reported
Comm workers code:	Not reported

2016-2019 Industrial:

Type Process Use:	Processing-incorporation into formulation, mixture, or reaction product
Sector:	Soap, Cleaning Compound, and Toilet Preparation Manufacturing
Function Category:	Cleaning agent
Number of Sites:	< 10
Number of Workers:	25 - 49
Chemical Name:	Sulfuric acid
Chemical ID:	7664-93-9
Case Number:	7664939
Ind type code:	PF
Ind sect code:	IS29
Ind sector other desc:	Not reported
Ind fc code:	F073
Ind funct cat other desc:	Not reported
Ind pv pct:	100
Ind sites code:	S1
Ind workers code:	W3

Chemical ID Number:	7722-64-7
Case Number:	7722647
Chemical Name:	Permanganic acid (HMnO4), potassium salt (1:1)
Activity:	Import
Number of Workers:	25 - 49
Max Concentration:	90% +
Chemical Recycled:	No
Physical Forms:	Dry Powder
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 740
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Marubeni America Corporation
Domestic pc address line1:	375 Lexington Ave.
Domestic pc address line2:	Not reported
Domestic pc city:	New York
Domestic pc county / parish:	New York

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Domestic pc state:	NY
Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633
Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610
Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	0
2019 import pv:	237733
2019 pv:	237733
2018 pv:	356668
2017 pv:	207874
2016 pv:	124067
2019 nationally aggregated pv:	25123301
2018 nationally aggregated pv:	20,000,000 lb - <100,000,000 lb
2017 nationally aggregated pv:	20,000,000 lb - <100,000,000 lb
2016 nationally aggregated pv:	20,000,000 lb - <100,000,000 lb
Imported chem never at site:	Yes
2019 v used on-site:	Not reported
2019 v exported:	0
Pct byp code:	B1
Percent byproduct:	0 percent by weight
Workers code:	W3
Max conc code:	M5
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported
Max Concentration:	Not reported
Number of Workers:	Not reported
Chemical Name:	Permanganic acid (HMnO4), potassium salt (1:1)
Chemical ID:	7722-64-7
C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported
C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Not reported
C / c pv pct:	Not reported
C / c max conc code:	Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Comm workers code: Not reported

2016-2019 Industrial:
Type Process Use: Processing as a reactant
Sector: Utilities
Function Category: Oxidizing agent
Number of Sites: 10 - 24
Number of Workers: 25 - 49
Chemical Name: Permanganic acid (HMnO4), potassium salt (1:1)
Chemical ID: 7722-64-7
Case Number: 7722647
Ind type code: PC
Ind sect code: IS4
Ind sector other desc: Not reported
Ind fc code: F044
Ind funct cat other desc: Not reported
Ind pv pct: 100
Ind sites code: S2
Ind workers code: W3

Chemical ID Number: 7757-82-6
Case Number: 7757826
Chemical Name: Sulfuric acid sodium salt (1:2)
Activity: Import
Number of Workers: 25 - 49
Max Concentration: 90% +
Chemical Recycled: NKRA
Physical Forms: Liquid
Site Name: MARUBENI SPECIALTY CHEMICALS INC.
Site Address: 10 BANK ST
Site Address 2: SUITE 740
Site City,State,Zip: WHITE PLAINS, NY 10606
Site County: WESTCHESTER COUNTY
Chemical ID type: CASRN
Domestic parent company name: Marubeni America Corporation
Domestic pc address line1: 375 Lexington Ave.
Domestic pc address line2: Not reported
Domestic pc city: New York
Domestic pc county / parish: New York
Domestic pc state: NY
Domestic pc postal code: 10017
Domestic pc dun and bradstreet number: 00-167-0876
Foreign parent company name: Not reported
Foreign pc address line1: Not reported
Foreign pc address line2: Not reported
Foreign pc city: Not reported
Foreign pc county / parish: Not reported
Foreign pc postal code: Not reported
Foreign pc country code: Not reported
Foreign pc dun and bradstreet number: Not reported
Site latitude: 41.029764
Site longitude: -73.773964
Site dun and bradstreet number: 78-727-6633
Epa-tsca program id: TSCA4463
Epa facility registry id: 110004500610
Site naics code 1: 424690 Other Chemical And Allied Products Merchant Wholesalers

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	0
2019 import pv:	170319
2019 pv:	170319
2018 pv:	276172
2017 pv:	0
2016 pv:	0
2019 nationally aggregated pv:	750,000,000 - <1,000,000,000 lb
2018 nationally aggregated pv:	500,000,000 - <750,000,000 lb
2017 nationally aggregated pv:	500,000,000 - <750,000,000 lb
2016 nationally aggregated pv:	750,000,000 - <1,000,000,000 lb
Imported chem never at site:	Yes
2019 v used on-site:	Not reported
2019 v exported:	0
Pct byp code:	B1
Percent byproduct:	0 percent by weight
Workers code:	W3
Max conc code:	M5
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported
Max Concentration:	Not reported
Number of Workers:	Not reported
Chemical Name:	Sulfuric acid sodium salt (1:2)
Chemical ID:	7757-82-6
C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported
C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Not reported
C / c pv pct:	Not reported
C / c max conc code:	Not reported
Comm workers code:	Not reported

2016-2019 Industrial:

Type Process Use:	Processing-incorporation into formulation, mixture, or reaction product
Sector:	Soap, Cleaning Compound, and Toilet Preparation Manufacturing
Function Category:	Surfactant (surface active agent)
Number of Sites:	< 10
Number of Workers:	25 - 49
Chemical Name:	Sulfuric acid sodium salt (1:2)
Chemical ID:	7757-82-6
Case Number:	7757826
Ind type code:	PF
Ind sect code:	IS29
Ind sector other desc:	Not reported
Ind fc code:	F076

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Ind funct cat other desc:	Not reported
Ind pv pct:	100
Ind sites code:	S1
Ind workers code:	W3

Chemical ID Number:	77-92-9
Case Number:	77929
Chemical Name:	1,2,3-Propanetricarboxylic acid, 2-hydroxy-
Activity:	Not reported
Number of Workers:	Not reported
Max Concentration:	Not reported
Chemical Recycled:	Not reported
Physical Forms:	Not reported
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 740
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Marubeni America Corporation
Domestic pc address line1:	375 Lexington Ave.
Domestic pc address line2:	Not reported
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633
Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610
Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	Not reported
2019 import pv:	Not reported
2019 pv:	Not reported
2018 pv:	0
2017 pv:	129306
2016 pv:	129306
2019 nationally aggregated pv:	100,000,000 - <250,000,000 lb
2018 nationally aggregated pv:	250,000,000 - <500,000,000 lb
2017 nationally aggregated pv:	250,000,000 - <500,000,000 lb
2016 nationally aggregated pv:	250,000,000 - <500,000,000 lb

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Imported chem never at site:	Not reported
2019 v used on-site:	Not reported
2019 v exported:	Not reported
Pct byp code:	Not reported
Percent byproduct:	Not reported
Workers code:	Not reported
Max conc code:	Not reported
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported
Max Concentration:	Not reported
Number of Workers:	Not reported
Chemical Name:	1,2,3-Propanetricarboxylic acid, 2-hydroxy-
Chemical ID:	77-92-9
C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported
C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Not reported
C / c pv pct:	Not reported
C / c max conc code:	Not reported
Comm workers code:	Not reported

2016-2019 Industrial:

Type Process Use:	Not reported
Sector:	Not reported
Function Category:	Not reported
Number of Sites:	Not reported
Number of Workers:	Not reported
Chemical Name:	1,2,3-Propanetricarboxylic acid, 2-hydroxy-
Chemical ID:	77-92-9
Case Number:	77929
Ind type code:	Not reported
Ind sect code:	Not reported
Ind sector other desc:	Not reported
Ind fc code:	Not reported
Ind funct cat other desc:	Not reported
Ind pv pct:	Not reported
Ind sites code:	Not reported
Ind workers code:	Not reported

Chemical ID Number:	80-09-1
Case Number:	80091
Chemical Name:	Phenol, 4,4’-sulfonylbis-
Activity:	Import
Number of Workers:	1000 - 9999
Max Concentration:	90% +
Chemical Recycled:	NKRA
Physical Forms:	Dry Powder
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Site Address 2:	SUITE 740
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Marubeni America Corporation
Domestic pc address line1:	375 Lexington Ave.
Domestic pc address line2:	Not reported
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633
Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610
Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	0
2019 import pv:	1596748
2019 pv:	1596748
2018 pv:	1910848
2017 pv:	781707
2016 pv:	321470
2019 nationally aggregated pv:	1,000,000 - <10,000,000 lb
2018 nationally aggregated pv:	1,000,000 - <10,000,000 lb
2017 nationally aggregated pv:	1,000,000 - <10,000,000 lb
2016 nationally aggregated pv:	1,000,000 - <10,000,000 lb
Imported chem never at site:	Yes
2019 v used on-site:	Not reported
2019 v exported:	0
Pct byp code:	B1
Percent byproduct:	0 percent by weight
Workers code:	W7
Max conc code:	M5
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported
Max Concentration:	Not reported
Number of Workers:	Not reported
Chemical Name:	Phenol, 4,4’-sulfonylbis-

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Chemical ID:	80-09-1
C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported
C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Not reported
C / c pv pct:	Not reported
C / c max conc code:	Not reported
Comm workers code:	Not reported

2016-2019 Industrial:

Type Process Use:	Processing-incorporation into article
Sector:	Paper Manufacturing
Function Category:	Other
Number of Sites:	< 10
Number of Workers:	1000 - 9999
Chemical Name:	Phenol, 4,4’-sulfonylbis-
Chemical ID:	80-09-1
Case Number:	80091
Ind type code:	PA
Ind sect code:	IS9
Ind sector other desc:	Not reported
Ind fc code:	F999
Ind funct cat other desc:	Developer for thermal paper.
Ind pv pct:	100
Ind sites code:	S1
Ind workers code:	W7

Chemical ID Number:	826-62-0
Case Number:	826620
Chemical Name:	4,7-Methanoisobenzofuran-1,3-dione, 3a,4,7,7a-tetrahydro-
Activity:	Import
Number of Workers:	10 - 24
Max Concentration:	90% +
Chemical Recycled:	NKRA
Physical Forms:	Liquid
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 740
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Marubeni America Corporation
Domestic pc address line1:	375 Lexington Ave.
Domestic pc address line2:	Not reported
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633
Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610
Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	0
2019 import pv:	336484
2019 pv:	336484
2018 pv:	510445
2017 pv:	409787
2016 pv:	190364
2019 nationally aggregated pv:	1,000,000 - <10,000,000 lb
2018 nationally aggregated pv:	1,000,000 - <10,000,000 lb
2017 nationally aggregated pv:	1,000,000 - <10,000,000 lb
2016 nationally aggregated pv:	1,000,000 lb - <20,000,000 lb
Imported chem never at site:	Yes
2019 v used on-site:	Not reported
2019 v exported:	0
Pct byp code:	B1
Percent byproduct:	0 percent by weight
Workers code:	W2
Max conc code:	M5
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported
Max Concentration:	Not reported
Number of Workers:	Not reported
Chemical Name:	4,7-Methanoisobenzofuran-1,3-dione, 3a,4,7,7a-tetrahydro-
Chemical ID:	826-62-0
C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported
C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Not reported
C / c pv pct:	Not reported
C / c max conc code:	Not reported
Comm workers code:	Not reported

2016-2019 Industrial:

Type Process Use:	Processing-incorporation into formulation, mixture, or reaction product
Sector:	All Other Chemical Product and Preparation Manufacturing
Function Category:	Fillers

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Number of Sites:	< 10
Number of Workers:	10 - 24
Chemical Name:	4,7-Methanoisobenzofuran-1,3-dione, 3a,4,7,7a-tetrahydro-
Chemical ID:	826-62-0
Case Number:	826620
Ind type code:	PF
Ind sect code:	IS34
Ind sector other desc:	Not reported
Ind fc code:	U009
Ind funct cat other desc:	Not reported
Ind pv pct:	100
Ind sites code:	S1
Ind workers code:	W2

Chemical ID Number:	89331-94-2
Case Number:	89331942
Chemical Name:	Spiro[isobenzofuran-1(3H),9'-[9H]xanthen]-3-one, 6'-(dibutylamino)-3'-methyl-2'-(phenylamino)-
Activity:	Import
Number of Workers:	1000 - 9999
Max Concentration:	90% +
Chemical Recycled:	NKRA
Physical Forms:	Dry Powder
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 740
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Marubeni America Corporation
Domestic pc address line1:	375 Lexington Ave.
Domestic pc address line2:	Not reported
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10017
Domestic pc dun and bradstreet number:	00-167-0876
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029764
Site longitude:	-73.773964
Site dun and bradstreet number:	78-727-6633
Epa-tsca program id:	TSCA4463
Epa facility registry id:	110004500610
Site naics code 1:	424690 Other Chemical And Allied Products Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

2019 domestic pv:	0
2019 import pv:	220460
2019 pv:	220460
2018 pv:	262372
2017 pv:	0
2016 pv:	0
2019 nationally aggregated pv:	1,000,000 - <10,000,000 lb
2018 nationally aggregated pv:	1,000,000 - <10,000,000 lb
2017 nationally aggregated pv:	1,000,000 - <10,000,000 lb
2016 nationally aggregated pv:	1,000,000 - <10,000,000 lb
Imported chem never at site:	Yes
2019 v used on-site:	Not reported
2019 v exported:	0
Pct byp code:	B1
Percent byproduct:	0 percent by weight
Workers code:	W7
Max conc code:	M5
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Not reported
Children Products:	Not reported
Max Concentration:	Not reported
Number of Workers:	Not reported
Chemical Name:	Spiro[isobenzofuran-1(3H),9'-[9H]xanthen]-3-one, 6'-(dibutylamino)-3'-methyl-2'-(phenylamino)-
Chemical ID:	89331-94-2
C / c prod cat code:	Not reported
Cons / comm prod cat other desc:	Not reported
C / c fc code:	Not reported
Cons / comm function category:	Not reported
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Not reported
C / c pv pct:	Not reported
C / c max conc code:	Not reported
Comm workers code:	Not reported

2016-2019 Industrial:

Type Process Use:	Processing-incorporation into article
Sector:	Paper Manufacturing
Function Category:	Dye
Number of Sites:	< 10
Number of Workers:	1000 - 9999
Chemical Name:	Spiro[isobenzofuran-1(3H),9'-[9H]xanthen]-3-one, 6'-(dibutylamino)-3'-methyl-2'-(phenylamino)-
Chemical ID:	89331-94-2
Case Number:	89331942
Ind type code:	PA
Ind sect code:	IS9
Ind sector other desc:	Not reported
Ind fc code:	F019
Ind funct cat other desc:	Not reported
Ind pv pct:	100
Ind sites code:	S1
Ind workers code:	W7

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Chemical ID Number:	11097-59-9
Case Number:	11097599
Chemical Name:	Aluminate (Al(OH)63-), (OC-6-11)-, magnesium carbonate hydroxide (2:6:1:4)
Activity:	Import
Number of Workers:	< 10
Max Concentration:	90% +
Chemical Recycled:	Yes
Physical Forms:	Dry Powder
Site Name:	MITSUI PLASTICS, INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 1010
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Mitsui & Co. (U.S.A.), Inc.
Domestic pc address line1:	10 Bank Street
Domestic pc address line2:	200 Park Avenue
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10166
Domestic pc dun and bradstreet number:	00-166-4523
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029815
Site longitude:	-73.773963
Site dun and bradstreet number:	19-536-4260
Epa-tsca program id:	TSCA10057515
Epa facility registry id:	110070864473
Site naics code 1:	424610 Plastics Materials And Basic Forms And Shapes Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	0
2019 import pv:	90168
2019 pv:	90168
2018 pv:	173479
2017 pv:	435833
2016 pv:	1081488
2019 nationally aggregated pv:	10,000,000 - <50,000,000 lb
2018 nationally aggregated pv:	10,000,000 - <50,000,000 lb
2017 nationally aggregated pv:	10,000,000 - <50,000,000 lb
2016 nationally aggregated pv:	10,000,000 - <50,000,000 lb
Imported chem never at site:	Yes
2019 v used on-site:	Not reported
2019 v exported:	1367
Pct byp code:	NKRA

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Percent byproduct:	Not Known or Reasonably Ascertainable
Workers code:	W1
Max conc code:	M5
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Food Packaging
Children Products:	100
Max Concentration:	Not Known or Reasonably Ascertainable
Number of Workers:	Not Known or Reasonably Ascertainable
Chemical Name:	Aluminate (Al(OH)63-), (OC-6-11)-, magnesium carbonate hydroxide (2:6:1:4)
Chemical ID:	11097-59-9
C / c prod cat code:	C301
Cons / comm prod cat other desc:	Not reported
C / c fc code:	U007
Cons / comm function category:	Corrosion inhibitors and anti-scaling agents
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Commercial
C / c pv pct:	No
C / c max conc code:	NKRA
Comm workers code:	NKRA

2016-2019 Industrial:

Type Process Use:	Processing-incorporation into formulation, mixture, or reaction product
Sector:	Plastics Material and Resin Manufacturing
Function Category:	Corrosion inhibitors and anti-scaling agents
Number of Sites:	100 - 249
Number of Workers:	Not Known or Reasonably Ascertainable
Chemical Name:	Aluminate (Al(OH)63-), (OC-6-11)-, magnesium carbonate hydroxide (2:6:1:4)
Chemical ID:	11097-59-9
Case Number:	11097599
Ind type code:	PF
Ind sect code:	IS22
Ind sector other desc:	Not reported
Ind fc code:	U007
Ind funct cat other desc:	Not reported
Ind pv pct:	100
Ind sites code:	S4
Ind workers code:	NKRA

Chemical ID Number:	1309-42-8
Case Number:	1309428
Chemical Name:	Magnesium hydroxide (Mg(OH)2)
Activity:	Not reported
Number of Workers:	Not reported
Max Concentration:	Not reported
Chemical Recycled:	Not reported
Physical Forms:	Not reported
Site Name:	MITSUI PLASTICS, INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 1010

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Mitsui & Co. (U.S.A.), Inc.
Domestic pc address line1:	10 Bank Street
Domestic pc address line2:	200 Park Avenue
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10166
Domestic pc dun and bradstreet number:	00-166-4523
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029815
Site longitude:	-73.773963
Site dun and bradstreet number:	19-536-4260
Epa-tsca program id:	TSCA10057515
Epa facility registry id:	110070864473
Site naics code 1:	424610 Plastics Materials And Basic Forms And Shapes Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	Not reported
2019 import pv:	Not reported
2019 pv:	Not reported
2018 pv:	0
2017 pv:	42328
2016 pv:	383159
2019 nationally aggregated pv:	500,000,000 - <750,000,000 lb
2018 nationally aggregated pv:	500,000,000 - <750,000,000 lb
2017 nationally aggregated pv:	500,000,000 - <750,000,000 lb
2016 nationally aggregated pv:	500,000,000 - <750,000,000 lb
Imported chem never at site:	Not reported
2019 v used on-site:	Not reported
2019 v exported:	Not reported
Pct byp code:	Not reported
Percent byproduct:	Not reported
Workers code:	Not reported
Max conc code:	Not reported
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Electrical and Electronic Products
Children Products:	100
Max Concentration:	Not Known or Reasonably Ascertainable
Number of Workers:	Not Known or Reasonably Ascertainable
Chemical Name:	Magnesium hydroxide (Mg(OH)2)

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Chemical ID:	1309-42-8
C / c prod cat code:	C205
Cons / comm prod cat other desc:	Not reported
C / c fc code:	U011
Cons / comm function category:	Flame retardants
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Commercial
C / c pv pct:	No
C / c max conc code:	NKRA
Comm workers code:	NKRA

2016-2019 Industrial:

Type Process Use:	Processing-incorporation into formulation, mixture, or reaction product
Sector:	All Other Basic Inorganic Chemical Manufacturing
Function Category:	Flame retardants
Number of Sites:	< 10
Number of Workers:	Not Known or Reasonably Ascertainable
Chemical Name:	Magnesium hydroxide (Mg(OH)2)
Chemical ID:	1309-42-8
Case Number:	1309428
Ind type code:	PF
Ind sect code:	IS19
Ind sector other desc:	Not reported
Ind fc code:	U011
Ind funct cat other desc:	Not reported
Ind pv pct:	100
Ind sites code:	S1
Ind workers code:	NKRA

Chemical ID Number:	1344-01-0
Case Number:	1344010
Chemical Name:	Silicic acid, aluminum calcium sodium salt
Activity:	Not reported
Number of Workers:	Not reported
Max Concentration:	Not reported
Chemical Recycled:	Not reported
Physical Forms:	Not reported
Site Name:	MITSUI PLASTICS, INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 1010
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Mitsui & Co. (U.S.A.), Inc.
Domestic pc address line1:	10 Bank Street
Domestic pc address line2:	200 Park Avenue
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10166
Domestic pc dun and bradstreet number:	00-166-4523
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029815
Site longitude:	-73.773963
Site dun and bradstreet number:	19-536-4260
Epa-tsca program id:	TSCA10057515
Epa facility registry id:	110070864473
Site naics code 1:	424610 Plastics Materials And Basic Forms And Shapes Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	Not reported
2019 import pv:	Not reported
2019 pv:	Not reported
2018 pv:	0
2017 pv:	1763680
2016 pv:	0
2019 nationally aggregated pv:	213846
2018 nationally aggregated pv:	141094
2017 nationally aggregated pv:	1834227
2016 nationally aggregated pv:	0
Imported chem never at site:	Not reported
2019 v used on-site:	Not reported
2019 v exported:	Not reported
Pct byp code:	Not reported
Percent byproduct:	Not reported
Workers code:	Not reported
Max conc code:	Not reported
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Food Packaging
Children Products:	100
Max Concentration:	Not Known or Reasonably Ascertainable
Number of Workers:	Not Known or Reasonably Ascertainable
Chemical Name:	Silicic acid, aluminum calcium sodium salt
Chemical ID:	1344-01-0
C / c prod cat code:	C301
Cons / comm prod cat other desc:	Not reported
C / c fc code:	U023
Cons / comm function category:	Plating agents and surface treating agents
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Commercial
C / c pv pct:	No
C / c max conc code:	NKRA
Comm workers code:	NKRA

2016-2019 Industrial:

Type Process Use:	Processing-incorporation into formulation, mixture, or reaction product

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Sector:	Miscellaneous Manufacturing
Function Category:	Plating agents and surface treating agents
Number of Sites:	< 10
Number of Workers:	Not Known or Reasonably Ascertainable
Chemical Name:	Silicic acid, aluminum calcium sodium salt
Chemical ID:	1344-01-0
Case Number:	1344010
Ind type code:	PF
Ind sect code:	IS45
Ind sector other desc:	Not reported
Ind fc code:	U023
Ind funct cat other desc:	Not reported
Ind pv pct:	100
Ind sites code:	S1
Ind workers code:	NKRA

Chemical ID Number:	65997-17-3
Case Number:	65997173
Chemical Name:	Glass, oxide, chemicals
Activity:	Import
Number of Workers:	< 10
Max Concentration:	Not Known or Reasonably Ascertainable
Chemical Recycled:	No
Physical Forms:	Other Solid
Site Name:	MITSUI PLASTICS, INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 1010
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Mitsui & Co. (U.S.A.), Inc.
Domestic pc address line1:	10 Bank Street
Domestic pc address line2:	200 Park Avenue
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10166
Domestic pc dun and bradstreet number:	00-166-4523
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029815
Site longitude:	-73.773963
Site dun and bradstreet number:	19-536-4260
Epa-tsca program id:	TSCA10057515
Epa facility registry id:	110070864473
Site naics code 1:	424610 Plastics Materials And Basic Forms And Shapes Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	0
2019 import pv:	39682
2019 pv:	39682
2018 pv:	116843
2017 pv:	155865
2016 pv:	0
2019 nationally aggregated pv:	5,000,000,000 - <10,000,000,000 lb
2018 nationally aggregated pv:	5,000,000,000 - <10,000,000,000 lb
2017 nationally aggregated pv:	5,000,000,000 - <10,000,000,000 lb
2016 nationally aggregated pv:	5,000,000,000 - <10,000,000,000 lb
Imported chem never at site:	Yes
2019 v used on-site:	Not reported
2019 v exported:	0
Pct byp code:	NKRA
Percent byproduct:	Not Known or Reasonably Ascertainable
Workers code:	W1
Max conc code:	NKRA
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Plastic and Rubber Products not covered elsewhere
Children Products:	100
Max Concentration:	Not Known or Reasonably Ascertainable
Number of Workers:	Not Known or Reasonably Ascertainable
Chemical Name:	Glass, oxide, chemicals
Chemical ID:	65997-17-3
C / c prod cat code:	C303
Cons / comm prod cat other desc:	Not reported
C / c fc code:	U009
Cons / comm function category:	Fillers
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Commercial
C / c pv pct:	No
C / c max conc code:	NKRA
Comm workers code:	NKRA

2016-2019 Industrial:

Type Process Use:	Processing-incorporation into formulation, mixture, or reaction product
Sector:	Plastics Material and Resin Manufacturing
Function Category:	Fillers
Number of Sites:	< 10
Number of Workers:	Not Known or Reasonably Ascertainable
Chemical Name:	Glass, oxide, chemicals
Chemical ID:	65997-17-3
Case Number:	65997173
Ind type code:	PF
Ind sect code:	IS22
Ind sector other desc:	Not reported
Ind fc code:	U009
Ind funct cat other desc:	Not reported
Ind pv pct:	100
Ind sites code:	S1

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Ind workers code:	NKRA
Chemical ID Number:	7553-56-2
Case Number:	7553562
Chemical Name:	Iodine
Activity:	Import
Number of Workers:	< 10
Max Concentration:	Not Known or Reasonably Ascertainable
Chemical Recycled:	Yes
Physical Forms:	Pellets or Large Crystals
Site Name:	MITSUI PLASTICS, INC.
Site Address:	10 BANK ST
Site Address 2:	SUITE 1010
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER COUNTY
Chemical ID type:	CASRN
Domestic parent company name:	Mitsui & Co. (U.S.A.), Inc.
Domestic pc address line1:	10 Bank Street
Domestic pc address line2:	200 Park Avenue
Domestic pc city:	New York
Domestic pc county / parish:	New York
Domestic pc state:	NY
Domestic pc postal code:	10166
Domestic pc dun and bradstreet number:	00-166-4523
Foreign parent company name:	Not reported
Foreign pc address line1:	Not reported
Foreign pc address line2:	Not reported
Foreign pc city:	Not reported
Foreign pc county / parish:	Not reported
Foreign pc postal code:	Not reported
Foreign pc country code:	Not reported
Foreign pc dun and bradstreet number:	Not reported
Site latitude:	41.029815
Site longitude:	-73.773963
Site dun and bradstreet number:	19-536-4260
Epa-tsca program id:	TSCA10057515
Epa facility registry id:	110070864473
Site naics code 1:	424610 Plastics Materials And Basic Forms And Shapes Merchant Wholesalers
Site naics activity 1:	Import
Site naics code 2:	Not reported
Site naics activity 2:	Not reported
Site naics code 3:	Not reported
Site naics activity 3:	Not reported
2019 domestic pv:	0
2019 import pv:	868619
2019 pv:	868619
2018 pv:	1225758
2017 pv:	1183876
2016 pv:	1029548
2019 nationally aggregated pv:	1,000,000 - <10,000,000 lb
2018 nationally aggregated pv:	10,000,000 - <50,000,000 lb
2017 nationally aggregated pv:	1,000,000 - <10,000,000 lb
2016 nationally aggregated pv:	1,000,000 - <10,000,000 lb
Imported chem never at site:	Yes
2019 v used on-site:	Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

2019 v exported:	0
Pct byp code:	NKRA
Percent byproduct:	Not Known or Reasonably Ascertainable
Workers code:	W1
Max conc code:	NKRA
Joint fc code:	Not reported
Joint function category:	Not reported
Joint funct cat other desc:	Not reported

2016-2019 Consumer:

Product Category:	Paints and Coatings
Children Products:	30
Max Concentration:	Not Known or Reasonably Ascertainable
Number of Workers:	Not Known or Reasonably Ascertainable
Chemical Name:	Iodine
Chemical ID:	7553-56-2
C / c prod cat code:	C202
Cons / comm prod cat other desc:	Not reported
C / c fc code:	U019
Cons / comm function category:	Oxidizing/reducing agents
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Commercial
C / c pv pct:	No
C / c max conc code:	NKRA
Comm workers code:	NKRA

Product Category:	Agricultural Products (non-pesticidal)
Children Products:	70
Max Concentration:	Not Known or Reasonably Ascertainable
Number of Workers:	Not Known or Reasonably Ascertainable
Chemical Name:	Iodine
Chemical ID:	7553-56-2
C / c prod cat code:	C406
Cons / comm prod cat other desc:	Not reported
C / c fc code:	U004
Cons / comm function category:	Agricultural chemicals (non-pesticidal)
Cons / comm funct cat other desc:	Not reported
Cons or comm use:	Commercial
C / c pv pct:	No
C / c max conc code:	NKRA
Comm workers code:	NKRA

2016-2019 Industrial:

Type Process Use:	Processing-incorporation into formulation, mixture, or reaction product
Sector:	Miscellaneous Manufacturing
Function Category:	Agricultural chemicals (non-pesticidal)
Number of Sites:	< 10
Number of Workers:	Not Known or Reasonably Ascertainable
Chemical Name:	Iodine
Chemical ID:	7553-56-2
Case Number:	7553562
Ind type code:	PF
Ind sect code:	IS45
Ind sector other desc:	Not reported
Ind fc code:	U004
Ind funct cat other desc:	Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Ind pv pct:	100
Ind sites code:	S1
Ind workers code:	NKRA

TSCA 2012-2015:

Consolidated ID:	905649
Chemical ID Number:	21645-51-2
Stripped Chemical ID NUmber:	21645512
Chemical Name:	Aluminum hydroxide (Al(OH)3)
Activity:	Imported
DOM MFG LB:	0
Imported LB:	42549
Dom Import:	42549
Imported Never at Site:	YES
Volume Used:	0
Volume Exported:	0
Number of Workers:	Not known or reasonably ascertainable
Max Concentration:	Not known or reasonably ascertainable
Chemical Recycled:	NKRA
Physical Forms:	DryPowder
PPV 2014:	200768
PPV 2013:	63065
PPV 2012:	0
Parent Company Name:	MARUBENI AMERICA CORPORATION
Parent Address:	375 Lexington Ave.
Parent Supplemental Address:	Not reported
Parent City:	New York
Parent County:	New York
Parent State:	NY
Parent Zip:	10017
Submitter First Name:	Pedro
Submitter Middle Initial:	Not reported
Submitter Last Name:	Jativa
Submitter Suffix:	Not reported
Submitter Title:	Mr
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Supplemental Address:	Not reported
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER
NAT AGG PVV 2015:	1,000,000,000 - <5,000,000,000 lbs
NAT AGG PVV 2014:	1,000,000,000 - <5,000,000,000 lbs
NAT AGG PVV 2013:	1,000,000,000 - <5,000,000,000 lbs
NAT AGG PVV 2012:	1,000,000,000 - <5,000,000,000 lbs

2012-2015 Consumer:

Consolidated ID:	905649
Product Category:	Paper products
Cons Comm Option:	Both
Children Products:	No
Percent Product Volume:	100
Max Concentration:	Not known or reasonably ascertainable
Number of Workers:	Not known or reasonably ascertainable

2012-2015 Industrial:

Consolidated ID:	905649

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Type Process Use:	Processing incorporation into formulation, mixture, or reaction product
Sector:	Paper manufacturing
Function Category:	Fillers
Percent Product Volume:	100
Number of Sites:	Not known or reasonably ascertainable
Number of Workers:	Not known or reasonably ascertainable

Consolidated ID:	905648
Chemical ID Number:	1314-13-2
Stripped Chemical ID NUmber:	1314132
Chemical Name:	Zinc oxide (ZnO)
Activity:	Imported
DOM MFG LB:	0
Imported LB:	212382
Dom Import:	212382
Imported Never at Site:	YES
Volume Used:	0
Volume Exported:	0
Number of Workers:	Not known or reasonably ascertainable
Max Concentration:	Not known or reasonably ascertainable
Chemical Recycled:	NKRA
Physical Forms:	DryPowder
PPV 2014:	84216
PPV 2013:	0
PPV 2012:	0
Parent Company Name:	MARUBENI AMERICA CORPORATION
Parent Address:	375 Lexington Ave.
Parent Supplemental Address:	Not reported
Parent City:	New York
Parent County:	New York
Parent State:	NY
Parent Zip:	10017
Submitter First Name:	Pedro
Submitter Middle Initial:	Not reported
Submitter Last Name:	Jativa
Submitter Suffix:	Not reported
Submitter Title:	Mr
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Supplemental Address:	Not reported
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER
NAT AGG PVV 2015:	500,000,000 - <750,000,000 lbs
NAT AGG PVV 2014:	500,000,000 - <750,000,000 lbs
NAT AGG PVV 2013:	500,000,000 - <750,000,000 lbs
NAT AGG PVV 2012:	500,000,000 - <750,000,000 lbs

2012-2015 Consumer:

Consolidated ID:	905648
Product Category:	Not known or reasonably ascertainable
Cons Comm Option:	NKRA
Children Products:	NKRA
Percent Product Volume:	0
Max Concentration:	Not known or reasonably ascertainable
Number of Workers:	Not known or reasonably ascertainable

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

2012-2015 Industrial:

Consolidated ID:	905648
Type Process Use:	Not known or reasonably ascertainable
Sector:	Not known or reasonably ascertainable
Function Category:	Not known or reasonably ascertainable
Percent Product Volume:	NKRA
Number of Sites:	Not known or reasonably ascertainable
Number of Workers:	Not known or reasonably ascertainable

Consolidated ID:	905644
Chemical ID Number:	57-13-6
Stripped Chemical ID NUmber:	57136
Chemical Name:	Urea
Activity:	Imported
DOM MFG LB:	0
Imported LB:	143997
Dom Import:	143997
Imported Never at Site:	YES
Volume Used:	0
Volume Exported:	0
Number of Workers:	Not known or reasonably ascertainable
Max Concentration:	Not known or reasonably ascertainable
Chemical Recycled:	NKRA
Physical Forms:	PelletsLargeCrystals
PPV 2014:	251995
PPV 2013:	108000
PPV 2012:	107998
Parent Company Name:	MARUBENI AMERICA CORPORATION
Parent Address:	375 Lexington Ave.
Parent Supplemental Address:	Not reported
Parent City:	New York
Parent County:	New York
Parent State:	NY
Parent Zip:	10017
Submitter First Name:	Pedro
Submitter Middle Initial:	Not reported
Submitter Last Name:	Jativa
Submitter Suffix:	Not reported
Submitter Title:	Mr
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Supplemental Address:	Not reported
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER
NAT AGG PVV 2015:	20,000,000,000 - <30,000,000,000 lbs
NAT AGG PVV 2014:	20,000,000,000 - <30,000,000,000 lbs
NAT AGG PVV 2013:	20,000,000,000 - <30,000,000,000 lbs
NAT AGG PVV 2012:	20,000,000,000 - <30,000,000,000 lbs

2012-2015 Consumer:

Consolidated ID:	905644
Product Category:	Not known or reasonably ascertainable
Cons Comm Option:	NKRA
Children Products:	NKRA
Percent Product Volume:	0
Max Concentration:	Not known or reasonably ascertainable

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Number of Workers: Not known or reasonably ascertainable

2012-2015 Industrial:
Consolidated ID: 905644
Type Process Use: Use non-incorporative activities
Sector: Agriculture, forestry, fishing and hunting
Function Category: Agricultural chemicals (non-pesticidal)
Percent Product Volume: 100
Number of Sites: Not known or reasonably ascertainable
Number of Workers: Not known or reasonably ascertainable

Consolidated ID: 905645
Chemical ID Number: 41481-66-7
Stripped Chemical ID NUmber: 41481667
Chemical Name: Phenol, 4,4'-sulfonylbis[2-(2-propen-1-yl)-
Activity: Imported
DOM MFG LB: 0
Imported LB: 724645
Dom Import: 724645
Imported Never at Site: YES
Volume Used: 0
Volume Exported: 0
Number of Workers: Not known or reasonably ascertainable
Max Concentration: Not known or reasonably ascertainable
Chemical Recycled: NKRA
Physical Forms: DryPowder
PPV 2014: 2776939
PPV 2013: 2711914
PPV 2012: 0
Parent Company Name: MARUBENI AMERICA CORPORATION
Parent Address: 375 Lexington Ave.
Parent Supplemental Address: Not reported
Parent City: New York
Parent County: New York
Parent State: NY
Parent Zip: 10017
Submitter First Name: Pedro
Submitter Middle Initial: Not reported
Submitter Last Name: Jativa
Submitter Suffix: Not reported
Submitter Title: Mr
Site Name: MARUBENI SPECIALTY CHEMICALS INC.
Site Address: 10 BANK ST
Site Supplemental Address: Not reported
Site City,State,Zip: WHITE PLAINS, NY 10606
Site County: WESTCHESTER
NAT AGG PVV 2015: <1,000,000 lbs
NAT AGG PVV 2014: 1,000,000 - <20,000,000 lbs
NAT AGG PVV 2013: 1,000,000 - <20,000,000 lbs
NAT AGG PVV 2012: <1,000,000 lbs

2012-2015 Consumer:
Consolidated ID: 905645
Product Category: Paper products
Cons Comm Option: Both
Children Products: No

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Percent Product Volume:	100
Max Concentration:	Not known or reasonably ascertainable
Number of Workers:	Not known or reasonably ascertainable

2012-2015 Industrial:

Consolidated ID:	905645
Type Process Use:	Processing incorporation into formulation, mixture, or reaction product
Sector:	Paper manufacturing
Function Category:	Processing aids, not otherwise listed
Percent Product Volume:	100
Number of Sites:	Not known or reasonably ascertainable
Number of Workers:	Not known or reasonably ascertainable

Consolidated ID:	905647
Chemical ID Number:	14808-60-7
Stripped Chemical ID NUmber:	14808607
Chemical Name:	Quartz (SiO2)
Activity:	Imported
DOM MFG LB:	0
Imported LB:	226000
Dom Import:	226000
Imported Never at Site:	YES
Volume Used:	0
Volume Exported:	0
Number of Workers:	Fewer than 10 workers
Max Concentration:	Less than 1% by weight
Chemical Recycled:	NKRA
Physical Forms:	DryPowder
PPV 2014:	847998
PPV 2013:	486000
PPV 2012:	461998
Parent Company Name:	MARUBENI AMERICA CORPORATION
Parent Address:	375 Lexington Ave.
Parent Supplemental Address:	Not reported
Parent City:	New York
Parent County:	New York
Parent State:	NY
Parent Zip:	10017
Submitter First Name:	Pedro
Submitter Middle Initial:	Not reported
Submitter Last Name:	Jativa
Submitter Suffix:	Not reported
Submitter Title:	Mr
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Supplemental Address:	Not reported
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER
NAT AGG PVV 2015:	100,000,000 - <250,000,000 lbs
NAT AGG PVV 2014:	100,000,000 - <250,000,000 lbs
NAT AGG PVV 2013:	100,000,000 - <250,000,000 lbs
NAT AGG PVV 2012:	100,000,000 - <250,000,000 lbs

2012-2015 Consumer:

Consolidated ID:	905647

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Product Category:	Paints and coatings
Cons Comm Option:	Commercial
Children Products:	No
Percent Product Volume:	100
Max Concentration:	Not known or reasonably ascertainable
Number of Workers:	Not known or reasonably ascertainable

2012-2015 Industrial:

Consolidated ID:	905647
Type Process Use:	Processing incorporation into formulation, mixture, or reaction product
Sector:	All other chemical product and preparation manufacturing
Function Category:	Fillers
Percent Product Volume:	100
Number of Sites:	Not known or reasonably ascertainable
Number of Workers:	Not known or reasonably ascertainable

Consolidated ID:	905643
Chemical ID Number:	7631-86-9
Stripped Chemical ID NUmber:	7631869
Chemical Name:	Silica
Activity:	Imported
DOM MFG LB:	0
Imported LB:	325953
Dom Import:	325953
Imported Never at Site:	YES
Volume Used:	0
Volume Exported:	0
Number of Workers:	Not known or reasonably ascertainable
Max Concentration:	Not known or reasonably ascertainable
Chemical Recycled:	NKRA
Physical Forms:	DryPowder
PPV 2014:	1036414
PPV 2013:	550273
PPV 2012:	0
Parent Company Name:	MARUBENI AMERICA CORPORATION
Parent Address:	375 Lexington Ave.
Parent Supplemental Address:	Not reported
Parent City:	New York
Parent County:	New York
Parent State:	NY
Parent Zip:	10017
Submitter First Name:	Pedro
Submitter Middle Initial:	Not reported
Submitter Last Name:	Jativa
Submitter Suffix:	Not reported
Submitter Title:	Mr
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Supplemental Address:	Not reported
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER
NAT AGG PVV 2015:	10,000,000,000 - <20,000,000,000 lbs
NAT AGG PVV 2014:	1,000,000,000 - <5,000,000,000 lbs
NAT AGG PVV 2013:	1,000,000,000 - <5,000,000,000 lbs
NAT AGG PVV 2012:	1,000,000,000 - <5,000,000,000 lbs

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

2012-2015 Consumer:

Consolidated ID:	905643
Product Category:	Paper products
Cons Comm Option:	Commercial
Children Products:	No
Percent Product Volume:	100
Max Concentration:	Not known or reasonably ascertainable
Number of Workers:	Not known or reasonably ascertainable

2012-2015 Industrial:

Consolidated ID:	905643
Type Process Use:	Processing incorporation into formulation, mixture, or reaction product
Sector:	Paper manufacturing
Function Category:	Fillers
Percent Product Volume:	100
Number of Sites:	Not known or reasonably ascertainable
Number of Workers:	Not known or reasonably ascertainable

Consolidated ID:	905646
Chemical ID Number:	826-62-0
Stripped Chemical ID NUmber:	826620
Chemical Name:	4,7-Methanoisobenzofuran-1,3-dione, 3a,4,7,7a-tetrahydro-
Activity:	Imported
DOM MFG LB:	0
Imported LB:	745095
Dom Import:	745095
Imported Never at Site:	YES
Volume Used:	0
Volume Exported:	0
Number of Workers:	Not known or reasonably ascertainable
Max Concentration:	Not known or reasonably ascertainable
Chemical Recycled:	NKRA
Physical Forms:	Liquid
PPV 2014:	2702538
PPV 2013:	1165539
PPV 2012:	1210116
Parent Company Name:	MARUBENI AMERICA CORPORATION
Parent Address:	375 Lexington Ave.
Parent Supplemental Address:	Not reported
Parent City:	New York
Parent County:	New York
Parent State:	NY
Parent Zip:	10017
Submitter First Name:	Pedro
Submitter Middle Initial:	Not reported
Submitter Last Name:	Jativa
Submitter Suffix:	Not reported
Submitter Title:	Mr
Site Name:	MARUBENI SPECIALTY CHEMICALS INC.
Site Address:	10 BANK ST
Site Supplemental Address:	Not reported
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER
NAT AGG PVV 2015:	1,000,000 - <10,000,000 lbs

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

NAT AGG PVV 2014:	1,000,000 - <20,000,000 lbs
NAT AGG PVV 2013:	1,000,000 - <10,000,000 lbs
NAT AGG PVV 2012:	1,000,000 - <20,000,000 lbs

2012-2015 Consumer:

Consolidated ID:	905646
Product Category:	Paints and coatings
Cons Comm Option:	Commercial
Children Products:	No
Percent Product Volume:	100
Max Concentration:	Not known or reasonably ascertainable
Number of Workers:	Not known or reasonably ascertainable

2012-2015 Industrial:

Consolidated ID:	905646
Type Process Use:	Processing incorporation into formulation, mixture, or reaction product
Sector:	All other chemical product and preparation manufacturing
Function Category:	Paint additives and coating additives not described by other categories
Percent Product Volume:	100
Number of Sites:	Not known or reasonably ascertainable
Number of Workers:	Not known or reasonably ascertainable

TSCA 2012:

Chemical ID Number:	101-68-8
Stripped Chemical ID Number:	101688
Number ID Code:	CASRN
Chemical Name:	Benzene, 1,1’-methylenebis[4-isocyanato-
Activity:	Import
Domestic MFG LB:	0
Imported LB:	5000
Imported Never at Site:	NO
Volume Used:	5000
Volume Exported:	0
Number of Workers:	1000 - 9999
Max Concentration:	90% +
Chemical Recycled:	NO
Physical Forms:	Liquid
Past Product Volume:	44000
Parent Company Name:	MARUBENI AMERICA CORP
Parent Address:	10 Bank Street
Parent Supplemental Address:	Suite 740
Parent City,State,Zip:	White Plains, NY 10606
Parent County:	Westchester
Submitter First Name:	Paul
Submitter Middle Initial:	J
Submitter Last Name:	Guerne
Submitter Suffix:	Jr
Submitter Title:	Mr
Site Name:	MARUBENI SPECIALTY CHEMICALS INC
Site Address:	10 BANK ST
Site Supplemental Address:	Not reported
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

2012 Industrial:

Chemical Report ID:	618431
Type Process Use:	Processing as a reactant
Sector:	Construction
Function Category:	Adhesives and sealant chemicals
Industrial Percent Product Volume:	100
Number of Sites:	25 - 49
Industrial Number of Workers:	< 10
Chemical ID Number:	103-11-7
Stripped Chemical ID Number:	103117
Number ID Code:	CASRN
Chemical Name:	2-Propenoic acid, 2-ethylhexyl ester
Activity:	Import
Domestic MFG LB:	0
Imported LB:	5000
Imported Never at Site:	NO
Volume Used:	5000
Volume Exported:	0
Number of Workers:	100 - 499
Max Concentration:	90% +
Chemical Recycled:	NO
Physical Forms:	Liquid
Past Product Volume:	132000
Parent Company Name:	MARUBENI AMERICA CORP
Parent Address:	10 Bank Street
Parent Supplemental Address:	Suite 740
Parent City,State,Zip:	White Plains, NY 10606
Parent County:	Westchester
Submitter First Name:	Paul
Submitter Middle Initial:	J
Submitter Last Name:	Guerne
Submitter Suffix:	Jr
Submitter Title:	Mr
Site Name:	MARUBENI SPECIALTY CHEMICALS INC
Site Address:	10 BANK ST
Site Supplemental Address:	Not reported
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER

2012 Industrial:

Chemical Report ID:	618457
Type Process Use:	Processing as a reactant
Sector:	Paint and Coating Manufacturing
Function Category:	Adhesives and sealant chemicals
Industrial Percent Product Volume:	100
Number of Sites:	10 - 24
Industrial Number of Workers:	< 10
Chemical ID Number:	107568-10-5
Stripped Chemical ID Number:	107568105
Number ID Code:	CASRN
Chemical Name:	2-Propene-1-sulfonic acid, sodium salt (1:1), polymer with ethenol and ethenyl acetate
Activity:	Import

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Domestic MFG LB:	0
Imported LB:	53000
Imported Never at Site:	NO
Volume Used:	53000
Volume Exported:	0
Number of Workers:	100 - 499
Max Concentration:	90% +
Chemical Recycled:	NO
Physical Forms:	DryPowder
Past Product Volume:	42000
Parent Company Name:	MARUBENI AMERICA CORP
Parent Address:	10 Bank Street
Parent Supplemental Address:	Suite 740
Parent City,State,Zip:	White Plains, NY 10606
Parent County:	Westchester
Submitter First Name:	Paul
Submitter Middle Initial:	J
Submitter Last Name:	Guerne
Submitter Suffix:	Jr
Submitter Title:	Mr
Site Name:	MARUBENI SPECIALTY CHEMICALS INC
Site Address:	10 BANK ST
Site Supplemental Address:	Not reported
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER

2012 Industrial:

Chemical Report ID:	618795
Type Process Use:	Processing-incorporation into formulation, mixture, or reaction product
Sector:	Paper Manufacturing
Function Category:	Not Known or Reasonably Ascertainable
Industrial Percent Product Volume:	100
Number of Sites:	50 - 99
Industrial Number of Workers:	< 10

Chemical ID Number:	11070-44-3
Stripped Chemical ID Number:	11070443
Number ID Code:	CASRN
Chemical Name:	1,3-Isobenzofurandione, tetrahydromethyl-
Activity:	Import
Domestic MFG LB:	Withheld
Imported LB:	Withheld
Imported Never at Site:	YES
Volume Used:	N/A
Volume Exported:	0
Number of Workers:	< 10
Max Concentration:	90% +
Chemical Recycled:	NO
Physical Forms:	Liquid
Past Product Volume:	295120
Parent Company Name:	MARUBENI AMERICA CORP
Parent Address:	10 Bank Street
Parent Supplemental Address:	Suite 740
Parent City,State,Zip:	White Plains, NY 10606
Parent County:	Westchester
Submitter First Name:	Paul

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Submitter Middle Initial:	J
Submitter Last Name:	Guerne
Submitter Suffix:	Jr
Submitter Title:	Mr
Site Name:	MARUBENI SPECIALTY CHEMICALS INC
Site Address:	10 BANK ST
Site Supplemental Address:	Not reported
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER

2012 Consumer:

Chemical Report ID:	618522
Product Category:	Electrical and Electronic Products
Consumer Comm Option:	Both
Children Products:	No
Consumer Percent Product Volume:	100
Consumer Max Concentration:	30% - < 60%
Consumer Number of Workers:	50 - 99

2012 Industrial:

Chemical Report ID:	618522
Type Process Use:	Processing-incorporation into formulation, mixture, or reaction product
Sector:	Custom Compounding of Purchased Resins
Function Category:	Other (specify)
Industrial Percent Product Volume:	100
Number of Sites:	50 - 99
Industrial Number of Workers:	< 10

Chemical ID Number:	115001-58-6
Stripped Chemical ID Number:	115001586
Number ID Code:	CASRN
Chemical Name:	Acetic acid ethenyl ester, homopolymer, hydrolyzed, reaction products with 4-methylene-2-oxetanone
Activity:	Import
Domestic MFG LB:	0
Imported LB:	282000
Imported Never at Site:	NO
Volume Used:	282000
Volume Exported:	0
Number of Workers:	100 - 499
Max Concentration:	90% +
Chemical Recycled:	NO
Physical Forms:	DryPowder
Past Product Volume:	290000
Parent Company Name:	MARUBENI AMERICA CORP
Parent Address:	10 Bank Street
Parent Supplemental Address:	Suite 740
Parent City,State,Zip:	White Plains, NY 10606
Parent County:	Westchester
Submitter First Name:	Paul
Submitter Middle Initial:	J
Submitter Last Name:	Guerne
Submitter Suffix:	Jr
Submitter Title:	Mr
Site Name:	MARUBENI SPECIALTY CHEMICALS INC

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Site Address: 10 BANK ST
Site Supplemental Address: Not reported
Site City,State,Zip: WHITE PLAINS, NY 10606
Site County: WESTCHESTER

2012 Industrial:
Chemical Report ID: 618808
Type Process Use: Processing-incorporation into formulation, mixture, or reaction product
Sector: Paper Manufacturing
Function Category: Not Known or Reasonably Ascertainable
Industrial Percent Product Volume: 100
Number of Sites: 50 - 99
Industrial Number of Workers: < 10

Chemical ID Number: 127-09-3
Stripped Chemical ID Number: 127093
Number ID Code: CASRN
Chemical Name: Acetic acid, sodium salt (1:1)
Activity: Import
Domestic MFG LB: 0
Imported LB: 48000
Imported Never at Site: NO
Volume Used: 48000
Volume Exported: 0
Number of Workers: 100 - 499
Max Concentration: 90% +
Chemical Recycled: NO
Physical Forms: Unknown
Past Product Volume: 52000
Parent Company Name: MARUBENI AMERICA CORP
Parent Address: 10 Bank Street
Parent Supplemental Address: Suite 740
Parent City,State,Zip: White Plains, NY 10606
Parent County: Westchester
Submitter First Name: Paul
Submitter Middle Initial: J
Submitter Last Name: Guerne
Submitter Suffix: Jr
Submitter Title: Mr
Site Name: MARUBENI SPECIALTY CHEMICALS INC
Site Address: 10 BANK ST
Site Supplemental Address: Not reported
Site City,State,Zip: WHITE PLAINS, NY 10606
Site County: WESTCHESTER

2012 Industrial:
Chemical Report ID: 618444
Type Process Use: Not Known or Reasonably Ascertainable
Sector: Not Known or Reasonably Ascertainable
Function Category: Not Known or Reasonably Ascertainable
Industrial Percent Product Volume: 100
Number of Sites: Not Known or Reasonably Ascertainable
Industrial Number of Workers: Not Known or Reasonably Ascertainable

Chemical ID Number: 137091-12-4

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Stripped Chemical ID Number:	137091124
Number ID Code:	CASRN
Chemical Name:	Acetic acid ethenyl ester, polymer with ethenol and .alpha.-2-propenyl-.omega.-h ydroxypoly(oxy-1,2-ethanediyl)
Activity:	Import
Domestic MFG LB:	0
Imported LB:	5000
Imported Never at Site:	NO
Volume Used:	5000
Volume Exported:	0
Number of Workers:	100 - 499
Max Concentration:	90% +
Chemical Recycled:	NO
Physical Forms:	DryPowder
Past Product Volume:	35000
Parent Company Name:	MARUBENI AMERICA CORP
Parent Address:	10 Bank Street
Parent Supplemental Address:	Suite 740
Parent City,State,Zip:	White Plains, NY 10606
Parent County:	Westchester
Submitter First Name:	Paul
Submitter Middle Initial:	J
Submitter Last Name:	Guerne
Submitter Suffix:	Jr
Submitter Title:	Mr
Site Name:	MARUBENI SPECIALTY CHEMICALS INC
Site Address:	10 BANK ST
Site Supplemental Address:	Not reported
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER

2012 Industrial:

Chemical Report ID:	618821
Type Process Use:	Processing-incorporation into formulation, mixture, or reaction product
Sector:	Paper Manufacturing
Function Category:	Abrasives
Industrial Percent Product Volume:	100
Number of Sites:	100 - 499
Industrial Number of Workers:	< 10

Chemical ID Number:	139871-83-3
Stripped Chemical ID Number:	139871833
Number ID Code:	CASRN
Chemical Name:	2-Butenedioic acid (2Z)-, polymer with ethenol and ethenyl acetate, sodium salt
Activity:	Import
Domestic MFG LB:	0
Imported LB:	1232000
Imported Never at Site:	NO
Volume Used:	1232000
Volume Exported:	0
Number of Workers:	100 - 499
Max Concentration:	90% +
Chemical Recycled:	NO
Physical Forms:	DryPowder
Past Product Volume:	1707000

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Parent Company Name:	MARUBENI AMERICA CORP
Parent Address:	10 Bank Street
Parent Supplemental Address:	Suite 740
Parent City,State,Zip:	White Plains, NY 10606
Parent County:	Westchester
Submitter First Name:	Paul
Submitter Middle Initial:	J
Submitter Last Name:	Guerne
Submitter Suffix:	Jr
Submitter Title:	Mr
Site Name:	MARUBENI SPECIALTY CHEMICALS INC
Site Address:	10 BANK ST
Site Supplemental Address:	Not reported
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER

2012 Industrial:

Chemical Report ID:	618834
Type Process Use:	Processing-incorporation into formulation, mixture, or reaction product
Sector:	Paper Manufacturing
Function Category:	Abrasives
Industrial Percent Product Volume:	100
Number of Sites:	100 - 499
Industrial Number of Workers:	< 10

Chemical ID Number:	14808-60-7
Stripped Chemical ID Number:	14808607
Number ID Code:	CASRN
Chemical Name:	Quartz (SiO2)
Activity:	Import
Domestic MFG LB:	0
Imported LB:	440000
Imported Never at Site:	YES
Volume Used:	N/A
Volume Exported:	0
Number of Workers:	< 10
Max Concentration:	90% +
Chemical Recycled:	NO
Physical Forms:	DryPowder
Past Product Volume:	396000
Parent Company Name:	MARUBENI AMERICA CORP
Parent Address:	10 Bank Street
Parent Supplemental Address:	Suite 740
Parent City,State,Zip:	White Plains, NY 10606
Parent County:	Westchester
Submitter First Name:	Paul
Submitter Middle Initial:	J
Submitter Last Name:	Guerne
Submitter Suffix:	Jr
Submitter Title:	Mr
Site Name:	MARUBENI SPECIALTY CHEMICALS INC
Site Address:	10 BANK ST
Site Supplemental Address:	Not reported
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

2012 Consumer:

Chemical Report ID:	618542
Product Category:	Electrical and Electronic Products
Consumer Comm Option:	Both
Children Products:	No
Consumer Percent Product Volume:	100
Consumer Max Concentration:	30% - < 60%
Consumer Number of Workers:	10 - 24

2012 Industrial:

Chemical Report ID:	618542
Type Process Use:	Processing-incorporation into formulation, mixture, or reaction product
Sector:	Plastics Material and Resin Manufacturing
Function Category:	Fillers
Industrial Percent Product Volume:	100
Number of Sites:	10 - 24
Industrial Number of Workers:	< 10

Chemical ID Number:	1552-42-7
Stripped Chemical ID Number:	1552427
Number ID Code:	CASRN
Chemical Name:	1(3H)-Isobenzofuranone, 6-(dimethylamino)-3,3-bis[4-(dimethylamino)phenyl]-
Activity:	Import
Domestic MFG LB:	0
Imported LB:	89000
Imported Never at Site:	NO
Volume Used:	89000
Volume Exported:	0
Number of Workers:	100 - 499
Max Concentration:	90% +
Chemical Recycled:	NO
Physical Forms:	DryPowder
Past Product Volume:	0
Parent Company Name:	MARUBENI AMERICA CORP
Parent Address:	10 Bank Street
Parent Supplemental Address:	Suite 740
Parent City,State,Zip:	White Plains, NY 10606
Parent County:	Westchester
Submitter First Name:	Paul
Submitter Middle Initial:	J
Submitter Last Name:	Guerne
Submitter Suffix:	Jr
Submitter Title:	Mr
Site Name:	MARUBENI SPECIALTY CHEMICALS INC
Site Address:	10 BANK ST
Site Supplemental Address:	Not reported
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER

2012 Industrial:

Chemical Report ID:	618470
Type Process Use:	Processing as a reactant
Sector:	Paper Manufacturing
Function Category:	Paint additives and coating additives not described by other

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

categories
Industrial Percent Product Volume: 100
Number of Sites: 100 - 499
Industrial Number of Workers: < 10

Chemical ID Number: 24993-04-2
Stripped Chemical ID Number: 24993042
Number ID Code: CASRN
Chemical Name: Hexanedioic acid, polymer with hexahydro-2H-azepin-2-one and 1,6-hexanediamine
Activity: Import
Domestic MFG LB: 0
Imported LB: 79708
Imported Never at Site: YES
Volume Used: N/A
Volume Exported: 0
Number of Workers: Not Known or Reasonably Ascertainable
Max Concentration: 90% +
Chemical Recycled: NKRA
Physical Forms: PelletsLargeCrystals
Past Product Volume: 173912
Parent Company Name: MARUBENI AMERICA CORP
Parent Address: 10 Bank Street
Parent Supplemental Address: Suite 740
Parent City,State,Zip: White Plains, NY 10606
Parent County: Westchester
Submitter First Name: Paul
Submitter Middle Initial: J
Submitter Last Name: Guerne
Submitter Suffix: Jr
Submitter Title: Mr
Site Name: MARUBENI SPECIALTY CHEMICALS INC
Site Address: 10 BANK ST
Site Supplemental Address: Not reported
Site City,State,Zip: WHITE PLAINS, NY 10606
Site County: WESTCHESTER

2012 Consumer:
Chemical Report ID: 618562
Product Category: Other (specify)
Consumer Comm Option: Commercial
Children Products: No
Consumer Percent Product Volume: 100
Consumer Max Concentration: Not Known or Reasonably Ascertainable
Consumer Number of Workers: Not Known or Reasonably Ascertainable

2012 Industrial:
Chemical Report ID: 618562
Type Process Use: Processing-incorporation into article
Sector: Plastics Material and Resin Manufacturing
Function Category: Not Known or Reasonably Ascertainable
Industrial Percent Product Volume: 100
Number of Sites: Not Known or Reasonably Ascertainable
Industrial Number of Workers: < 10

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Chemical ID Number:	25038-36-2
Stripped Chemical ID Number:	25038362
Number ID Code:	CASRN
Chemical Name:	Bicyclo[2.2.1]hept-2-ene, 5-ethylidene-, polymer with ethene and 1-propene
Activity:	Import
Domestic MFG LB:	0
Imported LB:	176370
Imported Never at Site:	YES
Volume Used:	N/A
Volume Exported:	0
Number of Workers:	Not Known or Reasonably Ascertainable
Max Concentration:	90% +
Chemical Recycled:	NO
Physical Forms:	DryPowder
Past Product Volume:	0
Parent Company Name:	MARUBENI AMERICA CORP
Parent Address:	10 Bank Street
Parent Supplemental Address:	Suite 740
Parent City,State,Zip:	White Plains, NY 10606
Parent County:	Westchester
Submitter First Name:	Paul
Submitter Middle Initial:	J
Submitter Last Name:	Guerne
Submitter Suffix:	Jr
Submitter Title:	Mr
Site Name:	MARUBENI SPECIALTY CHEMICALS INC
Site Address:	10 BANK ST
Site Supplemental Address:	Not reported
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER

2012 Consumer:

Chemical Report ID:	618602
Product Category:	Plastic and Rubber Products not covered elsewhere
Consumer Comm Option:	Commercial
Children Products:	No
Consumer Percent Product Volume:	100
Consumer Max Concentration:	90% +
Consumer Number of Workers:	Not Known or Reasonably Ascertainable

2012 Industrial:

Chemical Report ID:	618602
Type Process Use:	Processing-incorporation into formulation, mixture, or reaction product
Sector:	Plastics Material and Resin Manufacturing
Function Category:	Plasticizers
Industrial Percent Product Volume:	100
Number of Sites:	Not Known or Reasonably Ascertainable
Industrial Number of Workers:	< 10

Chemical ID Number:	25038-54-4
Stripped Chemical ID Number:	25038544
Number ID Code:	CASRN
Chemical Name:	Poly[imino(1-oxo-1,6-hexanediyl)]
Activity:	Import

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Domestic MFG LB:	0
Imported LB:	129967
Imported Never at Site:	YES
Volume Used:	N/A
Volume Exported:	0
Number of Workers:	Not Known or Reasonably Ascertainable
Max Concentration:	90% +
Chemical Recycled:	NKRA
Physical Forms:	OtherSolid
Past Product Volume:	141958
Parent Company Name:	MARUBENI AMERICA CORP
Parent Address:	10 Bank Street
Parent Supplemental Address:	Suite 740
Parent City,State,Zip:	White Plains, NY 10606
Parent County:	Westchester
Submitter First Name:	Paul
Submitter Middle Initial:	J
Submitter Last Name:	Guerne
Submitter Suffix:	Jr
Submitter Title:	Mr
Site Name:	MARUBENI SPECIALTY CHEMICALS INC
Site Address:	10 BANK ST
Site Supplemental Address:	Not reported
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER

2012 Consumer:

Chemical Report ID:	618622
Product Category:	Food Packaging
Consumer Comm Option:	Both
Children Products:	Not Known or Reasonably Ascertainable
Consumer Percent Product Volume:	100
Consumer Max Concentration:	90% +
Consumer Number of Workers:	Not Known or Reasonably Ascertainable

2012 Industrial:

Chemical Report ID:	618622
Type Process Use:	Processing-incorporation into article
Sector:	Plastics Product Manufacturing
Function Category:	Not Known or Reasonably Ascertainable
Industrial Percent Product Volume:	100
Number of Sites:	Not Known or Reasonably Ascertainable
Industrial Number of Workers:	Not Known or Reasonably Ascertainable

Chemical ID Number:	25038-59-9
Stripped Chemical ID Number:	25038599
Number ID Code:	CASRN
Chemical Name:	Poly(oxy-1,2-ethanediyloxycarbonyl-1,4-p henylenecarbonyl)
Activity:	Import
Domestic MFG LB:	0
Imported LB:	188231
Imported Never at Site:	YES
Volume Used:	N/A
Volume Exported:	0
Number of Workers:	Not Known or Reasonably Ascertainable
Max Concentration:	Not Known or Reasonably Ascertainable

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Chemical Recycled:	NKRA
Physical Forms:	OtherSolid
Past Product Volume:	86272
Parent Company Name:	MARUBENI AMERICA CORP
Parent Address:	10 Bank Street
Parent Supplemental Address:	Suite 740
Parent City,State,Zip:	White Plains, NY 10606
Parent County:	Westchester
Submitter First Name:	Paul
Submitter Middle Initial:	J
Submitter Last Name:	Guerne
Submitter Suffix:	Jr
Submitter Title:	Mr
Site Name:	MARUBENI SPECIALTY CHEMICALS INC
Site Address:	10 BANK ST
Site Supplemental Address:	Not reported
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER

2012 Consumer:

Chemical Report ID:	618642
Product Category:	Food Packaging
Consumer Comm Option:	Both
Children Products:	Not Known or Reasonably Ascertainable
Consumer Percent Product Volume:	100
Consumer Max Concentration:	90% +
Consumer Number of Workers:	Not Known or Reasonably Ascertainable

2012 Industrial:

Chemical Report ID:	618642
Type Process Use:	Processing-incorporation into article
Sector:	Plastics Product Manufacturing
Function Category:	Not Known or Reasonably Ascertainable
Industrial Percent Product Volume:	100
Number of Sites:	Not Known or Reasonably Ascertainable
Industrial Number of Workers:	Not Known or Reasonably Ascertainable

Chemical ID Number:	25134-21-8
Stripped Chemical ID Number:	25134218
Number ID Code:	CASRN
Chemical Name:	4,7-Methanoisobenzofuran-1,3-dione, 3a,4,7,7a-tetrahydromethyl-, (3aR,4S,7R,7aS)-rel-
Activity:	Import
Domestic MFG LB:	0
Imported LB:	784080
Imported Never at Site:	YES
Volume Used:	N/A
Volume Exported:	0
Number of Workers:	< 10
Max Concentration:	90% +
Chemical Recycled:	NO
Physical Forms:	Liquid
Past Product Volume:	609840
Parent Company Name:	MARUBENI AMERICA CORP
Parent Address:	10 Bank Street
Parent Supplemental Address:	Suite 740

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Parent City,State,Zip:	White Plains, NY 10606
Parent County:	Westchester
Submitter First Name:	Paul
Submitter Middle Initial:	J
Submitter Last Name:	Guerne
Submitter Suffix:	Jr
Submitter Title:	Mr
Site Name:	MARUBENI SPECIALTY CHEMICALS INC
Site Address:	10 BANK ST
Site Supplemental Address:	Not reported
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER

2012 Consumer:

Chemical Report ID:	618662
Product Category:	Electrical and Electronic Products
Consumer Comm Option:	Commercial
Children Products:	No
Consumer Percent Product Volume:	100
Consumer Max Concentration:	30% - < 60%
Consumer Number of Workers:	10 - 24

2012 Industrial:

Chemical Report ID:	618662
Type Process Use:	Processing-incorporation into formulation, mixture, or reaction product
Sector:	Plastics Material and Resin Manufacturing
Function Category:	Other (specify)
Industrial Percent Product Volume:	100
Number of Sites:	10 - 24
Industrial Number of Workers:	< 10

Chemical ID Number:	25213-24-5
Stripped Chemical ID Number:	25213245
Number ID Code:	CASRN
Chemical Name:	Acetic acid ethenyl ester, polymer with ethenol
Activity:	Import
Domestic MFG LB:	0
Imported LB:	2035000
Imported Never at Site:	NO
Volume Used:	2035000
Volume Exported:	0
Number of Workers:	500 - 999
Max Concentration:	90% +
Chemical Recycled:	NO
Physical Forms:	DryPowder
Past Product Volume:	1250000
Parent Company Name:	MARUBENI AMERICA CORP
Parent Address:	10 Bank Street
Parent Supplemental Address:	Suite 740
Parent City,State,Zip:	White Plains, NY 10606
Parent County:	Westchester
Submitter First Name:	Paul
Submitter Middle Initial:	J
Submitter Last Name:	Guerne
Submitter Suffix:	Jr

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Submitter Title:	Mr
Site Name:	MARUBENI SPECIALTY CHEMICALS INC
Site Address:	10 BANK ST
Site Supplemental Address:	Not reported
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER

2012 Industrial:

Chemical Report ID:	618682
Type Process Use:	Processing-incorporation into article
Sector:	Pharmaceutical and Medicine Manufacturing
Function Category:	Not Known or Reasonably Ascertainable
Industrial Percent Product Volume:	15
Number of Sites:	50 - 99
Industrial Number of Workers:	< 10

Chemical Report ID:	618682
Type Process Use:	Processing-incorporation into formulation, mixture, or reaction product
Sector:	Paper Manufacturing
Function Category:	Surface active agents
Industrial Percent Product Volume:	15
Number of Sites:	50 - 99
Industrial Number of Workers:	< 10

Chemical Report ID:	618682
Type Process Use:	Processing as a reactant
Sector:	Plastics Material and Resin Manufacturing
Function Category:	Process regulators
Industrial Percent Product Volume:	70
Number of Sites:	100 - 499
Industrial Number of Workers:	< 10

Chemical ID Number:	25895-47-0
Stripped Chemical ID Number:	25895470
Number ID Code:	CASRN
Chemical Name:	1-Butene, polymer with ethene and 1-propene
Activity:	Import
Domestic MFG LB:	0
Imported LB:	4715240
Imported Never at Site:	YES
Volume Used:	N/A
Volume Exported:	0
Number of Workers:	Not Known or Reasonably Ascertainable
Max Concentration:	90% +
Chemical Recycled:	NKRA
Physical Forms:	PelletsLargeCrystals
Past Product Volume:	4866703
Parent Company Name:	MARUBENI AMERICA CORP
Parent Address:	10 Bank Street
Parent Supplemental Address:	Suite 740
Parent City,State,Zip:	White Plains, NY 10606
Parent County:	Westchester
Submitter First Name:	Paul
Submitter Middle Initial:	J
Submitter Last Name:	Guerne
Submitter Suffix:	Jr

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Submitter Title:	Mr
Site Name:	MARUBENI SPECIALTY CHEMICALS INC
Site Address:	10 BANK ST
Site Supplemental Address:	Not reported
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER

2012 Consumer:

Chemical Report ID:	618709
Product Category:	Food Packaging
Consumer Comm Option:	Both
Children Products:	Not Known or Reasonably Ascertainable
Consumer Percent Product Volume:	100
Consumer Max Concentration:	90% +
Consumer Number of Workers:	Not Known or Reasonably Ascertainable

2012 Industrial:

Chemical Report ID:	618709
Type Process Use:	Processing-incorporation into article
Sector:	Plastics Product Manufacturing
Function Category:	Not Known or Reasonably Ascertainable
Industrial Percent Product Volume:	100
Number of Sites:	Not Known or Reasonably Ascertainable
Industrial Number of Workers:	Not Known or Reasonably Ascertainable

Chemical ID Number:	25971-63-5
Stripped Chemical ID Number:	25971635
Number ID Code:	CASRN
Chemical Name:	Carbonic dichloride, polymer with 4,4’-(1-methylethylidene)bis[phenol]
Activity:	Import
Domestic MFG LB:	0
Imported LB:	139436
Imported Never at Site:	YES
Volume Used:	N/A
Volume Exported:	0
Number of Workers:	Not Known or Reasonably Ascertainable
Max Concentration:	90% +
Chemical Recycled:	NKRA
Physical Forms:	PelletsLargeCrystals
Past Product Volume:	361582
Parent Company Name:	MARUBENI AMERICA CORP
Parent Address:	10 Bank Street
Parent Supplemental Address:	Suite 740
Parent City,State,Zip:	White Plains, NY 10606
Parent County:	Westchester
Submitter First Name:	Paul
Submitter Middle Initial:	J
Submitter Last Name:	Guerne
Submitter Suffix:	Jr
Submitter Title:	Mr
Site Name:	MARUBENI SPECIALTY CHEMICALS INC
Site Address:	10 BANK ST
Site Supplemental Address:	Not reported
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

2012 Consumer:

Chemical Report ID:	618729
Product Category:	Not Known or Reasonably Ascertainable
Consumer Comm Option:	Commercial
Children Products:	No
Consumer Percent Product Volume:	100
Consumer Max Concentration:	90% +
Consumer Number of Workers:	Not Known or Reasonably Ascertainable

2012 Industrial:

Chemical Report ID:	618729
Type Process Use:	Processing-incorporation into article
Sector:	Plastics Product Manufacturing
Function Category:	Not Known or Reasonably Ascertainable
Industrial Percent Product Volume:	100
Number of Sites:	Not Known or Reasonably Ascertainable
Industrial Number of Workers:	Not Known or Reasonably Ascertainable

Chemical ID Number:	26221-27-2
Stripped Chemical ID Number:	26221272
Number ID Code:	CASRN
Chemical Name:	Acetic acid ethenyl ester, polymer with ethene and ethenol
Activity:	Import
Domestic MFG LB:	0
Imported LB:	28000
Imported Never at Site:	NO
Volume Used:	28000
Volume Exported:	0
Number of Workers:	100 - 499
Max Concentration:	90% +
Chemical Recycled:	NO
Physical Forms:	DryPowder
Past Product Volume:	345000
Parent Company Name:	MARUBENI AMERICA CORP
Parent Address:	10 Bank Street
Parent Supplemental Address:	Suite 740
Parent City,State,Zip:	White Plains, NY 10606
Parent County:	Westchester
Submitter First Name:	Paul
Submitter Middle Initial:	J
Submitter Last Name:	Guerne
Submitter Suffix:	Jr
Submitter Title:	Mr
Site Name:	MARUBENI SPECIALTY CHEMICALS INC
Site Address:	10 BANK ST
Site Supplemental Address:	Not reported
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER

2012 Industrial:

Chemical Report ID:	618749
Type Process Use:	Processing-incorporation into formulation, mixture, or reaction product
Sector:	Plastics Material and Resin Manufacturing
Function Category:	Not Known or Reasonably Ascertainable
Industrial Percent Product Volume:	100

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Number of Sites:	50 - 99
Industrial Number of Workers:	< 10
Chemical ID Number:	30050-69-2
Stripped Chemical ID Number:	30050692
Number ID Code:	CASRN
Chemical Name:	2-Propenoic acid, 2-methyl-, methyl ester, polymer with ethenylbenzene and (1-methylethenyl)benzene
Activity:	Import
Domestic MFG LB:	0
Imported LB:	59400
Imported Never at Site:	YES
Volume Used:	N/A
Volume Exported:	0
Number of Workers:	< 10
Max Concentration:	90% +
Chemical Recycled:	NO
Physical Forms:	OtherSolid
Past Product Volume:	8800
Parent Company Name:	MARUBENI AMERICA CORP
Parent Address:	10 Bank Street
Parent Supplemental Address:	Suite 740
Parent City,State,Zip:	White Plains, NY 10606
Parent County:	Westchester
Submitter First Name:	Paul
Submitter Middle Initial:	J
Submitter Last Name:	Guerne
Submitter Suffix:	Jr
Submitter Title:	Mr
Site Name:	MARUBENI SPECIALTY CHEMICALS INC
Site Address:	10 BANK ST
Site Supplemental Address:	Not reported
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER

2012 Consumer:

Chemical Report ID:	618582
Product Category:	Plastic and Rubber Products not covered elsewhere
Consumer Comm Option:	Commercial
Children Products:	No
Consumer Percent Product Volume:	100
Consumer Max Concentration:	90% +
Consumer Number of Workers:	< 10

2012 Industrial:

Chemical Report ID:	618582
Type Process Use:	Processing-incorporation into article
Sector:	Plastics Material and Resin Manufacturing
Function Category:	Not Known or Reasonably Ascertainable
Industrial Percent Product Volume:	100
Number of Sites:	< 10
Industrial Number of Workers:	< 10
Chemical ID Number:	41481-66-7
Stripped Chemical ID Number:	41481667

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Number ID Code:	CASRN
Chemical Name:	Phenol, 4,4'-sulfonylbis[2-(2-propen-1-yl)-
Activity:	Import
Domestic MFG LB:	0
Imported LB:	1621000
Imported Never at Site:	NO
Volume Used:	1621000
Volume Exported:	0
Number of Workers:	100 - 499
Max Concentration:	90% +
Chemical Recycled:	NO
Physical Forms:	DryPowder
Past Product Volume:	1408000
Parent Company Name:	MARUBENI AMERICA CORP
Parent Address:	10 Bank Street
Parent Supplemental Address:	Suite 740
Parent City,State,Zip:	White Plains, NY 10606
Parent County:	Westchester
Submitter First Name:	Paul
Submitter Middle Initial:	J
Submitter Last Name:	Guerne
Submitter Suffix:	Jr
Submitter Title:	Mr
Site Name:	MARUBENI SPECIALTY CHEMICALS INC
Site Address:	10 BANK ST
Site Supplemental Address:	Not reported
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER

2012 Industrial:

Chemical Report ID:	618762
Type Process Use:	Processing-incorporation into formulation, mixture, or reaction product
Sector:	Paper Manufacturing
Function Category:	Photosensitive chemicals
Industrial Percent Product Volume:	100
Number of Sites:	100 - 499
Industrial Number of Workers:	< 10

Chemical ID Number:	56-40-6
Stripped Chemical ID Number:	56406
Number ID Code:	CASRN
Chemical Name:	Glycine
Activity:	Import
Domestic MFG LB:	Withheld
Imported LB:	Withheld
Imported Never at Site:	NO
Volume Used:	33000
Volume Exported:	0
Number of Workers:	100 - 499
Max Concentration:	90% +
Chemical Recycled:	NO
Physical Forms:	DryPowder
Past Product Volume:	0
Parent Company Name:	MARUBENI AMERICA CORP
Parent Address:	10 Bank Street
Parent Supplemental Address:	Suite 740

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Parent City,State,Zip:	White Plains, NY 10606
Parent County:	Westchester
Submitter First Name:	Paul
Submitter Middle Initial:	J
Submitter Last Name:	Guerne
Submitter Suffix:	Jr
Submitter Title:	Mr
Site Name:	MARUBENI SPECIALTY CHEMICALS INC
Site Address:	10 BANK ST
Site Supplemental Address:	Not reported
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER

2012 Industrial:

Chemical Report ID:	618340
Type Process Use:	Processing-incorporation into formulation, mixture, or reaction product
Sector:	Food, beverage, and tobacco product manufacturing
Function Category:	Not Known or Reasonably Ascertainable
Industrial Percent Product Volume:	100
Number of Sites:	50 - 99
Industrial Number of Workers:	< 10

Chemical ID Number:	57-13-6
Stripped Chemical ID Number:	57136
Number ID Code:	CASRN
Chemical Name:	Urea
Activity:	Import
Domestic MFG LB:	0
Imported LB:	100000
Imported Never at Site:	YES
Volume Used:	N/A
Volume Exported:	0
Number of Workers:	100 - 499
Max Concentration:	90% +
Chemical Recycled:	NO
Physical Forms:	PelletsLargeCrystals
Past Product Volume:	300000000
Parent Company Name:	MARUBENI AMERICA CORP
Parent Address:	10 Bank Street
Parent Supplemental Address:	Suite 740
Parent City,State,Zip:	White Plains, NY 10606
Parent County:	Westchester
Submitter First Name:	Paul
Submitter Middle Initial:	J
Submitter Last Name:	Guerne
Submitter Suffix:	Jr
Submitter Title:	Mr
Site Name:	MARUBENI SPECIALTY CHEMICALS INC
Site Address:	10 BANK ST
Site Supplemental Address:	Not reported
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER

2012 Consumer:

Chemical Report ID:	618353
Product Category:	Agricultural Products (non-pesticidal)

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Consumer Comm Option:	Commercial
Children Products:	No
Consumer Percent Product Volume:	80
Consumer Max Concentration:	90% +
Consumer Number of Workers:	100 - 499

2012 Industrial:

Chemical Report ID:	618353
Type Process Use:	Processing-incorporation into formulation, mixture, or reaction product
Sector:	Agriculture, Forestry, Fishing and Hunting
Function Category:	Agricultural chemicals (non-pesticidal)
Industrial Percent Product Volume:	100
Number of Sites:	50 - 99
Industrial Number of Workers:	< 10

Chemical ID Number:	66070-58-4
Stripped Chemical ID Number:	66070584
Number ID Code:	CASRN
Chemical Name:	Benzene, ethenyl-, polymer with 1,3-butadiene, hydrogenated
Activity:	Import
Domestic MFG LB:	0
Imported LB:	1440486
Imported Never at Site:	YES
Volume Used:	N/A
Volume Exported:	0
Number of Workers:	Not Known or Reasonably Ascertainable
Max Concentration:	90% +
Chemical Recycled:	NO
Physical Forms:	PelletsLargeCrystals
Past Product Volume:	1036722
Parent Company Name:	MARUBENI AMERICA CORP
Parent Address:	10 Bank Street
Parent Supplemental Address:	Suite 740
Parent City,State,Zip:	White Plains, NY 10606
Parent County:	Westchester
Submitter First Name:	Paul
Submitter Middle Initial:	J
Submitter Last Name:	Guerne
Submitter Suffix:	Jr
Submitter Title:	Mr
Site Name:	MARUBENI SPECIALTY CHEMICALS INC
Site Address:	10 BANK ST
Site Supplemental Address:	Not reported
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER

2012 Consumer:

Chemical Report ID:	618775
Product Category:	Plastic and Rubber Products not covered elsewhere
Consumer Comm Option:	Commercial
Children Products:	No
Consumer Percent Product Volume:	100
Consumer Max Concentration:	90% +
Consumer Number of Workers:	Not Known or Reasonably Ascertainable

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

2012 Industrial:

Chemical Report ID:	618775
Type Process Use:	Processing-incorporation into formulation, mixture, or reaction product
Sector:	Plastics Material and Resin Manufacturing
Function Category:	Processing aids, not otherwise listed
Industrial Percent Product Volume:	100
Number of Sites:	Not Known or Reasonably Ascertainable
Industrial Number of Workers:	< 10

Chemical ID Number:	67-56-1
Stripped Chemical ID Number:	67561
Number ID Code:	CASRN
Chemical Name:	Methanol
Activity:	Import
Domestic MFG LB:	0
Imported LB:	178000
Imported Never at Site:	NO
Volume Used:	178000
Volume Exported:	0
Number of Workers:	500 - 999
Max Concentration:	90% +
Chemical Recycled:	NO
Physical Forms:	Unknown
Past Product Volume:	165000
Parent Company Name:	MARUBENI AMERICA CORP
Parent Address:	10 Bank Street
Parent Supplemental Address:	Suite 740
Parent City,State,Zip:	White Plains, NY 10606
Parent County:	Westchester
Submitter First Name:	Paul
Submitter Middle Initial:	J
Submitter Last Name:	Guerne
Submitter Suffix:	Jr
Submitter Title:	Mr
Site Name:	MARUBENI SPECIALTY CHEMICALS INC
Site Address:	10 BANK ST
Site Supplemental Address:	Not reported
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER

Chemical ID Number:	7631-86-9
Stripped Chemical ID Number:	7631869
Number ID Code:	CASRN
Chemical Name:	Silica
Activity:	Import
Domestic MFG LB:	0
Imported LB:	612000
Imported Never at Site:	NO
Volume Used:	612000
Volume Exported:	0
Number of Workers:	100 - 499
Max Concentration:	90% +
Chemical Recycled:	NO
Physical Forms:	DryPowder
Past Product Volume:	528000

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Parent Company Name:	MARUBENI AMERICA CORP
Parent Address:	10 Bank Street
Parent Supplemental Address:	Suite 740
Parent City,State,Zip:	White Plains, NY 10606
Parent County:	Westchester
Submitter First Name:	Paul
Submitter Middle Initial:	J
Submitter Last Name:	Guerne
Submitter Suffix:	Jr
Submitter Title:	Mr
Site Name:	MARUBENI SPECIALTY CHEMICALS INC
Site Address:	10 BANK ST
Site Supplemental Address:	Not reported
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER

2012 Industrial:

Chemical Report ID:	618483
Type Process Use:	Processing-incorporation into article
Sector:	Paper Manufacturing
Function Category:	Fillers
Industrial Percent Product Volume:	100
Number of Sites:	100 - 499
Industrial Number of Workers:	< 10

Chemical ID Number:	79-20-9
Stripped Chemical ID Number:	79209
Number ID Code:	CASRN
Chemical Name:	Acetic acid, methyl ester
Activity:	Import
Domestic MFG LB:	0
Imported LB:	70000
Imported Never at Site:	NO
Volume Used:	70000
Volume Exported:	0
Number of Workers:	100 - 499
Max Concentration:	90% +
Chemical Recycled:	NO
Physical Forms:	Unknown
Past Product Volume:	65000
Parent Company Name:	MARUBENI AMERICA CORP
Parent Address:	10 Bank Street
Parent Supplemental Address:	Suite 740
Parent City,State,Zip:	White Plains, NY 10606
Parent County:	Westchester
Submitter First Name:	Paul
Submitter Middle Initial:	J
Submitter Last Name:	Guerne
Submitter Suffix:	Jr
Submitter Title:	Mr
Site Name:	MARUBENI SPECIALTY CHEMICALS INC
Site Address:	10 BANK ST
Site Supplemental Address:	Not reported
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER

Chemical ID Number:	8006-54-0

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Stripped Chemical ID Number:	8006540
Number ID Code:	CASRN
Chemical Name:	Lanolin
Activity:	Import
Domestic MFG LB:	Withheld
Imported LB:	Withheld
Imported Never at Site:	NO
Volume Used:	35000
Volume Exported:	0
Number of Workers:	50 - 99
Max Concentration:	90% +
Chemical Recycled:	NO
Physical Forms:	Liquid
Past Product Volume:	266000
Parent Company Name:	MARUBENI AMERICA CORP
Parent Address:	10 Bank Street
Parent Supplemental Address:	Suite 740
Parent City,State,Zip:	White Plains, NY 10606
Parent County:	Westchester
Submitter First Name:	Paul
Submitter Middle Initial:	J
Submitter Last Name:	Guerne
Submitter Suffix:	Jr
Submitter Title:	Mr
Site Name:	MARUBENI SPECIALTY CHEMICALS INC
Site Address:	10 BANK ST
Site Supplemental Address:	Not reported
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER

2012 Industrial:

Chemical Report ID:	618496
Type Process Use:	Processing-incorporation into formulation, mixture, or reaction product
Sector:	Soap, Cleaning Compound, and Toilet Preparation Manufacturing
Function Category:	Viscosity adjustors
Industrial Percent Product Volume:	100
Number of Sites:	10 - 24
Industrial Number of Workers:	< 10

Chemical ID Number:	80-09-1
Stripped Chemical ID Number:	80091
Number ID Code:	CASRN
Chemical Name:	Phenol, 4,4’-sulfonylbis-
Activity:	Import
Domestic MFG LB:	0
Imported LB:	2812000
Imported Never at Site:	NO
Volume Used:	2812000
Volume Exported:	0
Number of Workers:	100 - 499
Max Concentration:	90% +
Chemical Recycled:	NO
Physical Forms:	DryPowder
Past Product Volume:	2614000
Parent Company Name:	MARUBENI AMERICA CORP
Parent Address:	10 Bank Street

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Parent Supplemental Address:	Suite 740
Parent City,State,Zip:	White Plains, NY 10606
Parent County:	Westchester
Submitter First Name:	Paul
Submitter Middle Initial:	J
Submitter Last Name:	Guerne
Submitter Suffix:	Jr
Submitter Title:	Mr
Site Name:	MARUBENI SPECIALTY CHEMICALS INC
Site Address:	10 BANK ST
Site Supplemental Address:	Not reported
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER

2012 Industrial:

Chemical Report ID:	618385
Type Process Use:	Processing-incorporation into formulation, mixture, or reaction product
Sector:	Paper Manufacturing
Function Category:	Finishing agents
Industrial Percent Product Volume:	100
Number of Sites:	100 - 499
Industrial Number of Workers:	< 10
Chemical ID Number:	80-43-3
Stripped Chemical ID Number:	80433
Number ID Code:	CASRN
Chemical Name:	Peroxide, bis(1-methyl-1-phenylethyl)
Activity:	Import
Domestic MFG LB:	0
Imported LB:	69854
Imported Never at Site:	YES
Volume Used:	N/A
Volume Exported:	0
Number of Workers:	< 10
Max Concentration:	90% +
Chemical Recycled:	NO
Physical Forms:	OtherSolid
Past Product Volume:	174636
Parent Company Name:	MARUBENI AMERICA CORP
Parent Address:	10 Bank Street
Parent Supplemental Address:	Suite 740
Parent City,State,Zip:	White Plains, NY 10606
Parent County:	Westchester
Submitter First Name:	Paul
Submitter Middle Initial:	J
Submitter Last Name:	Guerne
Submitter Suffix:	Jr
Submitter Title:	Mr
Site Name:	MARUBENI SPECIALTY CHEMICALS INC
Site Address:	10 BANK ST
Site Supplemental Address:	Not reported
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER

2012 Consumer:

Chemical Report ID:	618398

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Product Category:	Electrical and Electronic Products
Consumer Comm Option:	Commercial
Children Products:	No
Consumer Percent Product Volume:	100
Consumer Max Concentration:	30% - < 60%
Consumer Number of Workers:	100 - 499

2012 Industrial:

Chemical Report ID:	618398
Type Process Use:	Processing-incorporation into formulation, mixture, or reaction product
Sector:	Electrical Equipment, Appliance, and Component Manufacturing
Function Category:	Other (specify)
Industrial Percent Product Volume:	100
Number of Sites:	50 - 99
Industrial Number of Workers:	< 10

Chemical ID Number:	80-62-6
Stripped Chemical ID Number:	80626
Number ID Code:	CASRN
Chemical Name:	2-Propenoic acid, 2-methyl-, methyl ester
Activity:	Import
Domestic MFG LB:	0
Imported LB:	88000
Imported Never at Site:	NO
Volume Used:	88000
Volume Exported:	0
Number of Workers:	100 - 499
Max Concentration:	90% +
Chemical Recycled:	NO
Physical Forms:	Liquid
Past Product Volume:	90000
Parent Company Name:	MARUBENI AMERICA CORP
Parent Address:	10 Bank Street
Parent Supplemental Address:	Suite 740
Parent City,State,Zip:	White Plains, NY 10606
Parent County:	Westchester
Submitter First Name:	Paul
Submitter Middle Initial:	J
Submitter Last Name:	Guerne
Submitter Suffix:	Jr
Submitter Title:	Mr
Site Name:	MARUBENI SPECIALTY CHEMICALS INC
Site Address:	10 BANK ST
Site Supplemental Address:	Not reported
Site City,State,Zip:	WHITE PLAINS, NY 10606
Site County:	WESTCHESTER

2012 Industrial:

Chemical Report ID:	618418
Type Process Use:	Processing as a reactant
Sector:	Paint and Coating Manufacturing
Function Category:	Paint additives and coating additives not described by other categories
Industrial Percent Product Volume:	100
Number of Sites:	10 - 24

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Industrial Number of Workers: < 10

Chemical ID Number: 9003-22-9
Stripped Chemical ID Number: 9003229
Number ID Code: CASRN
Chemical Name: Acetic acid ethenyl ester, polymer with chloroethene
Activity: Import
Domestic MFG LB: 0
Imported LB: 88000
Imported Never at Site: NO
Volume Used: 88000
Volume Exported: 0
Number of Workers: 50 - 99
Max Concentration: 90% +
Chemical Recycled: NO
Physical Forms: PelletsLargeCrystals
Past Product Volume: 0
Parent Company Name: MARUBENI AMERICA CORP
Parent Address: 10 Bank Street
Parent Supplemental Address: Suite 740
Parent City,State,Zip: White Plains, NY 10606
Parent County: Westchester
Submitter First Name: Paul
Submitter Middle Initial: J
Submitter Last Name: Guerne
Submitter Suffix: Jr
Submitter Title: Mr
Site Name: MARUBENI SPECIALTY CHEMICALS INC
Site Address: 10 BANK ST
Site Supplemental Address: Not reported
Site City,State,Zip: WHITE PLAINS, NY 10606
Site County: WESTCHESTER

2012 Industrial:
Chemical Report ID: 618509
Type Process Use: Processing-incorporation into formulation, mixture, or reaction product
Sector: Adhesive Manufacturing
Function Category: Adhesives and sealant chemicals
Industrial Percent Product Volume: 100
Number of Sites: 25 - 49
Industrial Number of Workers: < 10

TSCA 1986-2002:
Manufacturer/Importer Status: Import
CBIMFIM: No
Company Name: MARUBENI SPECIALTY CHEMICALS, INC.
TSCA Name: MARUBENI SPECIALTY CHEMICALS INC.
Facility Address: 10 BANK STREET
Facility Address 2: SUITE 740
Facility City,State,Zip: WHITE PLAINS, NY 10606
Case Number: 78784
Chemical Name: Butane, 2-methyl-

1986-2002 Chemical:
Case Number: 78-78-4

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Preferred CA Index Name:	Butane, 2-methyl-
Submitter Name:	Not reported
Chemical Substance Definition:	Not reported
Former Case Number:	68923-44-4; 92046-46-3
Molecular Formula:	C5H12
UVCB Flag:	Not reported
EPA Inventory Flag:	Not reported

1986-2002 CUSAGG:

Case Number:	78784
Range 86:	> 1B
Range 90:	> 1B
Range 94:	> 1B
Range 98:	> 1B
Range 02:	> 1B
Chemical Name:	Butane, 2-methyl-

Manufacturer/Importer Status:	Import
CBIMFIM:	No
Company Name:	MARUBENI SPECIALTY CHEMICALS, INC.
TSCA Name:	MARUBENI SPECIALTY CHEMICALS INC.
Facility Address:	10 BANK STREET
Facility Address 2:	SUITE 740
Facility City,State,Zip:	WHITE PLAINS, NY 10606
Case Number:	109660
Chemical Name:	Pentane

1986-2002 Chemical:

Case Number:	109-66-0
Preferred CA Index Name:	Pentane
Submitter Name:	Not reported
Chemical Substance Definition:	Not reported
Former Case Number:	8031-35-4
Molecular Formula:	C5H12
UVCB Flag:	Not reported
EPA Inventory Flag:	T

1986-2002 CUSAGG:

Case Number:	109660
Range 86:	> 1B
Range 90:	> 1B
Range 94:	> 1B
Range 98:	> 1B
Range 02:	> 1B
Chemical Name:	Pentane

Manufacturer/Importer Status:	Import
CBIMFIM:	No
Company Name:	MARUBENI SPECIALTY CHEMICALS, INC.
TSCA Name:	MARUBENI SPECIALTY CHEMICALS INC.
Facility Address:	10 BANK STREET
Facility Address 2:	SUITE 740
Facility City,State,Zip:	WHITE PLAINS, NY 10606
Case Number:	826620
Chemical Name:	4,7-Methanoisobenzofuran-1,3-dione, 3a,4,7,7a-tetrahydro-

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

1986-2002 Chemical:
Case Number: 826-62-0
Preferred CA Index Name: 4,7-Methanoisobenzofuran-1,3-dione, 3a,4,7,7a-tetrahydro-
Submitter Name: Not reported
Chemical Substance Definition: Not reported
Former Case Number: 66075-60-3
Molecular Formula: C9H8O3
UVCB Flag: Not reported
EPA Inventory Flag: Not reported

1986-2002 CUSAGG:
Case Number: 826620
Range 86: No Reports
Range 90: 10K - 500K
Range 94: No Reports
Range 98: 10K - 500K
Range 02: 10K - 500K
Chemical Name: 4,7-Methanoisobenzofuran-1,3-dione, 3a,4,7,7a-tetrahydro-

Manufacturer/Importer Status: Import
CBIMFIM: No
Company Name: MARUBENI SPECIALTY CHEMICALS, INC.
TSCA Name: MARUBENI SPECIALTY CHEMICALS INC.
Facility Address: 10 BANK STREET
Facility Address 2: SUITE 740
Facility City,State,Zip: WHITE PLAINS, NY 10606
Case Number: 89797024
Chemical Name: Pyridinium, 1,1'-[(4-sulfo-1,3-phenylene)bis[imino[6-[[3-(acetylamino)-4-[(4,8-disulfo-2-naphthalenyl)azo]phenyl]amino]-1,3,5-triazine-4,2-diyl]]]bis[3-carboxy-, dihydroxide, pentasodium salt

1986-2002 Chemical:
Case Number: 89797-02-4
Preferred CA Index Name: Pyridinium, 1,1'-[(4-sulfo-1,3-phenylene)bis[imino[6-[[3-(acetylamino)-4-[2-(4,8-disulfo-2-naphthalenyl)diazenyl]phenyl]amino]-1,3,5-triazine-4,2-diyl]]]bis[3-carboxy-, hydroxide, sodium salt (1:2:5)
Submitter Name: Not reported
Chemical Substance Definition: Not reported
Former Case Number: Not reported
Molecular Formula: C60H46N18O21S5.2HO.5Na
UVCB Flag: Not reported
EPA Inventory Flag: P

Manufacturer/Importer Status: Import
CBIMFIM: No
Company Name: MARUBENI SPECIALTY CHEMICALS, INC.
TSCA Name: MARUBENI SPECIALTY CHEMICALS INC.
Facility Address: 10 BANK STREET
Facility Address 2: SUITE 740
Facility City,State,Zip: WHITE PLAINS, NY 10606
Case Number: 89797013
Chemical Name: Cuprate(4-), [3-carboxy-1-[4-[[3-[[[(2-carboxy-5-sulfophenyl)azo]phenylmethyl]azo]-

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

2-hydroxy-5-sulfophenyl]amino]-6-[(2-chloro-5-sulfophenyl)amino]-1,3,5
-triazin-2-yl]pyridiniumato(7-)]-, trisodiu

1986-2002 Chemical:
Case Number: 89797-01-3
Preferred CA Index Name: Cuprate(4-), [3-carboxy-1-[4-[[3-[2-[[2-[2-(carboxy-.kappa.O)-5-sulfophenyl]diazeny l-.kappa.N2]phenylmethyl]diazenyl-.kappa.N1]-2-(hydroxy-.kappa.O)-5-su lfophenyl]amino]-6-[(2-chloro-5-sulfophenyl)amino]-1,3,5-triazin-2-yl] pyridiniumato(7-)]-, sodium
Submitter Name: Not reported
Chemical Substance Definition: Not reported
Former Case Number: 97553-91-8; 131257-18-6
Molecular Formula: C35H19ClCuN10O14S3.H.3Na
UVCB Flag: Not reported
EPA Inventory Flag: P

1986-2002 CUSAGG:
Case Number: 89797013
Range 86: No Reports
Range 90: No Reports
Range 94: 10K - 500K
Range 98: No Reports
Range 02: 10K - 500K
Chemical Name: Cuprate(4-), [3-carboxy-1-[4-[[3-[[[[2-(carboxy-.kappa.O)-5-sulfophenyl]azo-.kappa. N2]phenylmethyl]azo-.kappa.N1]-2-(hydroxy-.kappa.O)-5-sulfophenyl]amin o]-6-[(2-chloro-5-sulfophenyl)amino]-1,3,5-tria

Manufacturer/Importer Status: Import
CBIMFIM: No
Company Name: MARUBENI SPECIALTY CHEMICALS, INC.
TSCA Name: MARUBENI SPECIALTY CHEMICALS INC.
Facility Address: 10 BANK STREET
Facility Address 2: SUITE 740
Facility City,State,Zip: WHITE PLAINS, NY 10606
Case Number: 56815
Chemical Name: 1,2,3-Propanetriol

1986-2002 Chemical:
Case Number: 56-81-5
Preferred CA Index Name: 1,2,3-Propanetriol
Submitter Name: Glycerin
Chemical Substance Definition: Not reported
Former Case Number: 8013-25-0; 29796-42-7; 30049-52-6; 37228-54-9; 75398-78-6; 78630-16-7
Molecular Formula: C3H8O3
UVCB Flag: Not reported
EPA Inventory Flag: Not reported

1986-2002 CUSAGG:
Case Number: 56815
Range 86: >100M - 500M
Range 90: >500M - 1B
Range 94: >100M - 500M
Range 98: >100M - 500M
Range 02: >100M - 500M

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Chemical Name: 1,2,3-Propanetriol

Manufacturer/Importer Status: Import
CBIMFIM: No
Company Name: MARUBENI SPECIALTY CHEMICALS, INC.
TSCA Name: MARUBENI SPECIALTY CHEMICALS INC.
Facility Address: 10 BANK STREET
Facility Address 2: SUITE 740
Facility City,State,Zip: WHITE PLAINS, NY 10606
Case Number: 124072
Chemical Name: Octanoic acid

1986-2002 Chemical:
Case Number: 124-07-2
Preferred CA Index Name: Octanoic acid
Submitter Name: Not reported
Chemical Substance Definition: Not reported
Former Case Number: Not reported
Molecular Formula: C8H16O2
UVCB Flag: Not reported
EPA Inventory Flag: Not reported

1986-2002 CUSAGG:
Case Number: 124072
Range 86: >10M - 50M
Range 90: >1M - 10M
Range 94: >1M - 10M
Range 98: >10M - 50M
Range 02: >1M - 10M
Chemical Name: Octanoic acid

Manufacturer/Importer Status: Import
CBIMFIM: No
Company Name: MARUBENI SPECIALTY CHEMICALS, INC.
TSCA Name: MARUBENI SPECIALTY CHEMICALS INC.
Facility Address: 10 BANK STREET
Facility Address 2: SUITE 740
Facility City,State,Zip: WHITE PLAINS, NY 10606
Case Number: 86422619
Chemical Name: Pyridinium, 1,1'-[1,2-ethenediylbis[(3-sulfo-4,1-phenylene)imino[6-[[3-(acetylamino)-4-[(4,8-disulfo-2-naphthalenyl)azo]phenyl]amino]-1,3,5-triazine-4,2-diyl]]]bis[3-carboxy-, dihydroxide, hexasod

1986-2002 Chemical:
Case Number: 86422-61-9
Preferred CA Index Name: Pyridinium, 1,1'-[1,2-ethenediylbis[(3-sulfo-4,1-phenylene)imino[6-[[3-(acetylamino)-4-[2-(4,8-disulfo-2-naphthalenyl)diazenyl]phenyl]amino]-1,3,5-triazine-4,2-diyl]]]bis[3-carboxy-, hydroxide, sodium salt (1:2:6)
Submitter Name: Not reported
Chemical Substance Definition: Not reported
Former Case Number: 89797-04-6
Molecular Formula: C68H52N18O24S6.2HO.6Na
UVCB Flag: Not reported
EPA Inventory Flag: P

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

1986-2002 CUSAGG:
Case Number: 86422619
Range 86: No Reports
Range 90: No Reports
Range 94: 10K - 500K
Range 98: No Reports
Range 02: 10K - 500K
Chemical Name: Pyridinium, 1,1'-[1,2-ethenediylbis[(3-sulfo-4,1-phenylene)imino[6-[[3-(acetylamino)-4-[(4,8-disulfo-2-naphthalenyl)azo]phenyl]amino]-1,3,5-triazine-4,2-diyl]]]bis[3-carboxy-, dihydroxide, hexasodium

Manufacturer/Importer Status: Import
CBIMFIM: No
Company Name: MARUBENI SPECIALTY CHEMICALS, INC.
TSCA Name: MARUBENI SPECIALTY CHEMICALS INC.
Facility Address: 10 BANK STREET
Facility Address 2: SUITE 740
Facility City,State,Zip: WHITE PLAINS, NY 10606
Case Number: 89797013
Chemical Name: X2- alpha- 3-4-(3-carboxypyridinio)-6-(2-chloro-5-sulfoanilino)-1,3,5-triazin-2-ylamino -2-hydroxy-5-sulfophenylazo benzylidene hydrazino -4-sulfobenzoato-(0,0')(5-) copper (ii) acid trisodium salt

1986-2002 Chemical:
Case Number: 89797-01-3
Preferred CA Index Name: Cuprate(4-), [3-carboxy-1-[4-[[3-[2-[[2-[2-(carboxy-.kappa.O)-5-sulfophenyl]diazenyl-.kappa.N2]phenylmethyl]diazenyl-.kappa.N1]-2-(hydroxy-.kappa.O)-5-sulfophenyl]amino]-6-[(2-chloro-5-sulfophenyl)amino]-1,3,5-triazin-2-yl]pyridiniumato(7-)]-, sodium
Submitter Name: Not reported
Chemical Substance Definition: Not reported
Former Case Number: 97553-91-8; 131257-18-6
Molecular Formula: C35H19ClCuN10O14S3.H.3Na
UVCB Flag: Not reported
EPA Inventory Flag: P

1986-2002 CUSAGG:
Case Number: 89797013
Range 86: No Reports
Range 90: No Reports
Range 94: 10K - 500K
Range 98: No Reports
Range 02: 10K - 500K
Chemical Name: Cuprate(4-), [3-carboxy-1-[4-[[3-[[[[2-(carboxy-.kappa.O)-5-sulfophenyl]azo-.kappa.N2]phenylmethyl]azo-.kappa.N1]-2-(hydroxy-.kappa.O)-5-sulfophenyl]amino]-6-[(2-chloro-5-sulfophenyl)amino]-1,3,5-tria

Manufacturer/Importer Status: Import
CBIMFIM: No
Company Name: MARUBENI SPECIALTY CHEMICALS, INC.
TSCA Name: MARUBENI SPECIALTY CHEMICALS INC.

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Facility Address: 10 BANK STREET
Facility Address 2: SUITE 740
Facility City,State,Zip: WHITE PLAINS, NY 10606
Case Number: 89797035
Chemical Name: Pyridinium, 1,1'-[(1-amino-8-hydroxy-3,6-disulfo-2,7-naphthalenediyl)bis[azo(4-sulfo-3,1-phenylene)imino[6-[(4-chloro-3-sulfophenyl)amino]-1,3,5-triazine-4,2-diyl]]]bis[3-carboxy-, dihydroxide, he

1986-2002 Chemical:
Case Number: 89797-03-5
Preferred CA Index Name: Pyridinium, 1,1'-[(1-amino-8-hydroxy-3,6-disulfo-2,7-naphthalenediyl)bis[2,1-diazenediyl(4-sulfo-3,1-phenylene)imino[6-[(4-chloro-3-sulfophenyl)amino]-1,3,5-triazine-4,2-diyl]]]bis[3-carboxy-, hydroxide, sodium salt (1:2:6)
Submitter Name: Not reported
Chemical Substance Definition: Not reported
Former Case Number: Not reported
Molecular Formula: C52H37Cl2N17O23S6.2HO.6Na
UVCB Flag: Not reported
EPA Inventory Flag: P

1986-2002 CUSAGG:
Case Number: 89797035
Range 86: No Reports
Range 90: No Reports
Range 94: No Reports
Range 98: No Reports
Range 02: 10K - 500K
Chemical Name: Pyridinium, 1,1'-[(1-amino-8-hydroxy-3,6-disulfo-2,7-naphthalenediyl)bis[azo(4-sulfo-3,1-phenylene)imino[6-[(4-chloro-3-sulfophenyl)amino]-1,3,5-triazine-4,2-diyl]]]bis[3-carboxy-, dihydroxide, hexaso

Manufacturer/Importer Status: Import
CBIMFIM: No
Company Name: MARUBENI SPECIALTY CHEMICALS, INC.
TSCA Name: MARUBENI SPECIALTY CHEMICALS INC.
Facility Address: 10 BANK STREET
Facility Address 2: SUITE 740
Facility City,State,Zip: WHITE PLAINS, NY 10606
Case Number: 544638
Chemical Name: Tetradecanoic acid

1986-2002 Chemical:
Case Number: 544-63-8
Preferred CA Index Name: Tetradecanoic acid
Submitter Name: Not reported
Chemical Substance Definition: Not reported
Former Case Number: 45184-05-2
Molecular Formula: C14H28O2
UVCB Flag: Not reported
EPA Inventory Flag: Not reported

1986-2002 CUSAGG:

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Case Number: 544638
Range 86: >1M - 10M
Range 90: >1M - 10M
Range 94: >10M - 50M
Range 98: >10M - 50M
Range 02: >1M - 10M
Chemical Name: Tetradecanoic acid

Manufacturer/Importer Status: Import
CBIMFIM: No
Company Name: MARUBENI SPECIALTY CHEMICALS, INC.
TSCA Name: MARUBENI SPECIALTY CHEMICALS INC.
Facility Address: 10 BANK STREET
Facility Address 2: SUITE 740
Facility City,State,Zip: WHITE PLAINS, NY 10606
Case Number: 40220084
Chemical Name: 2-Propenoic acid, (2,4,6-trioxo-1,3,5-triazine-1,3,5(2H,4H,6H)-triyl)tri-2,1-ethanediyl ester

1986-2002 Chemical:
Case Number: 40220-08-4
Preferred CA Index Name: 2-Propenoic acid, 1,1',1''-[(2,4,6-trioxo-1,3,5-triazine-1,3,5(2H,4H,6H)-triyl)tri-2,1-ethanediyl] ester
Submitter Name: Not reported
Chemical Substance Definition: Not reported
Former Case Number: 76364-14-2; 98940-65-9; 112385-00-9; 115753-22-5; 116107-64-3; 182077-88-9
Molecular Formula: C18H21N3O9
UVCB Flag: Not reported
EPA Inventory Flag: P

1986-2002 CUSAGG:
Case Number: 40220084
Range 86: No Reports
Range 90: No Reports
Range 94: 10K - 500K
Range 98: 10K - 500K
Range 02: >500K - 1M
Chemical Name: 2-Propenoic acid, (2,4,6-trioxo-1,3,5-triazine-1,3,5(2H,4H,6H)-triyl)tri-2,1-ethanediyl ester

Manufacturer/Importer Status: Import
CBIMFIM: No
Company Name: MARUBENI SPECIALTY CHEMICALS, INC.
TSCA Name: MARUBENI SPECIALTY CHEMICALS INC.
Facility Address: 10 BANK STREET
Facility Address 2: SUITE 740
Facility City,State,Zip: WHITE PLAINS, NY 10606
Case Number: 104825
Chemical Name: Benzene, 1-(chloromethyl)-4-methyl-

1986-2002 Chemical:
Case Number: 104-82-5

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Preferred CA Index Name: Benzene, 1-(chloromethyl)-4-methyl-
Submitter Name: Not reported
Chemical Substance Definition: Not reported
Former Case Number: Not reported
Molecular Formula: C8H9Cl
UVCB Flag: Not reported
EPA Inventory Flag: Not reported

1986-2002 CUSAGG:
Case Number: 104825
Range 86: No Reports
Range 90: 10K - 500K
Range 94: No Reports
Range 98: 10K - 500K
Range 02: 10K - 500K
Chemical Name: Benzene, 1-(chloromethyl)-4-methyl-

Manufacturer/Importer Status: Import
CBIMFIM: No
Company Name: MARUBENI SPECIALTY CHEMICALS, INC.
TSCA Name: MARUBENI SPECIALTY CHEMICALS INC.
Facility Address: 10 BANK STREET
Facility Address 2: SUITE 740
Facility City,State,Zip: WHITE PLAINS, NY 10606
Case Number: 25134218
Chemical Name: 4,7-Methanoisobenzofuran-1,3-dione, 3a,4,7,7a-tetrahydromethyl-, (3aR,4S,7R,7aS)-rel-

1986-2002 Chemical:
Case Number: 25134-21-8
Preferred CA Index Name: 4,7-Methanoisobenzofuran-1,3-dione, 3a,4,7,7a-tetrahydromethyl-, (3aR,4S,7R,7aS)-rel-
Submitter Name: Methendic anhydride; Methyl-1,2,3,6-tetrahydro-3,6-endomethylenephthalic anhydride; Methyl-tetrahydro-3,6-endomethylenephthalic anhydride
Chemical Substance Definition: Not reported
Former Case Number: 9087-28-9; 25338-60-7; 84135-87-5; 415690-66-3
Molecular Formula: C10H10O3
UVCB Flag: Not reported
EPA Inventory Flag: Not reported

1986-2002 CUSAGG:
Case Number: 25134218
Range 86: >500K - 1M
Range 90: >1M - 10M
Range 94: >500K - 1M
Range 98: >1M - 10M
Range 02: 10K - 500K
Chemical Name: 4,7-Methanoisobenzofuran-1,3-dione, 3a,4,7,7a-tetrahydromethyl-, (3aR,4S,7R,7aS)-rel-

Manufacturer/Importer Status: Import
CBIMFIM: No
Company Name: MARUBENI SPECIALTY CHEMICALS, INC.
TSCA Name: MARUBENI SPECIALTY CHEMICALS INC.

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Facility Address:	10 BANK STREET
Facility Address 2:	SUITE 740
Facility City,State,Zip:	WHITE PLAINS, NY 10606
Case Number:	1302789
Chemical Name:	Bentonite

1986-2002 Chemical:

Case Number:	1302-78-9
Preferred CA Index Name:	Bentonite
Submitter Name:	Not reported
Chemical Substance Definition:	A colloidal clay. Consists primarily of montmorillonite.
Former Case Number:	10043-07-9; 11004-12-9; 12198-92-4; 12199-69-8; 37320-72-2; 52623-66-2; 115628-71-2; 135945-01-6; 850872-77-4
Molecular Formula:	Unspecified
UVCB Flag:	UVCB
EPA Inventory Flag:	Not reported

1986-2002 CUSAGG:

Case Number:	1302789
Range 86:	10K - 500K
Range 90:	No Reports
Range 94:	10K - 500K
Range 98:	10K - 500K
Range 02:	10K - 500K
Chemical Name:	Bentonite

Manufacturer/Importer Status:	Import
CBIMFIM:	No
Company Name:	MARUBENI SPECIALTY CHEMICALS, INC.
TSCA Name:	MARUBENI SPECIALTY CHEMICALS INC.
Facility Address:	10 BANK STREET
Facility Address 2:	SUITE 740
Facility City,State,Zip:	WHITE PLAINS, NY 10606
Case Number:	107568105
Chemical Name:	2-Propene-1-sulfonic acid, sodium salt, polymer with ethenol and ethenyl acetate

1986-2002 Chemical:

Case Number:	107568-10-5
Preferred CA Index Name:	2-Propene-1-sulfonic acid, sodium salt (1:1), polymer with ethenol and ethenyl acetate
Submitter Name:	Not reported
Chemical Substance Definition:	Not reported
Former Case Number:	Not reported
Molecular Formula:	(C4H6O2.C3H6O3S.C2H4O.Na)x
UVCB Flag:	Not reported
EPA Inventory Flag:	P; XU

1986-2002 CUSAGG:

Case Number:	107568105
Range 86:	No Reports
Range 90:	No Reports
Range 94:	No Reports
Range 98:	10K - 500K
Range 02:	No Reports
Chemical Name:	2-Propene-1-sulfonic acid, sodium salt, polymer with ethenol and

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

ethenyl acetate

Manufacturer/Importer Status: Import
CBIMFIM: No
Company Name: MARUBENI SPECIALTY CHEMICALS, INC.
TSCA Name: MARUBENI SPECIALTY CHEMICALS INC.
Facility Address: 10 BANK STREET
Facility Address 2: SUITE 740
Facility City,State,Zip: WHITE PLAINS, NY 10606
Case Number: 115001586
Chemical Name: Acetic acid ethenyl ester, homopolymer, hydrolyzed, reaction products with 4-methylene-2-oxetanone

1986-2002 Chemical:
Case Number: 115001-58-6
Preferred CA Index Name: Acetic acid ethenyl ester, homopolymer, hydrolyzed, reaction products with 4-methylene-2-oxetanone
Submitter Name: Not reported
Chemical Substance Definition: Not reported
Former Case Number: Not reported
Molecular Formula: C4H6O2.C4H4O2
UVCB Flag: UVCB
EPA Inventory Flag: N; P; XU

1986-2002 CUSAGG:
Case Number: 115001586
Range 86: No Reports
Range 90: No Reports
Range 94: No Reports
Range 98: 10K - 500K
Range 02: No Reports
Chemical Name: Acetic acid ethenyl ester, homopolymer, hydrolyzed, reaction products with 4-methylene-2-oxetanone

Manufacturer/Importer Status: Import
CBIMFIM: No
Company Name: MARUBENI SPECIALTY CHEMICALS, INC.
TSCA Name: MARUBENI SPECIALTY CHEMICALS INC.
Facility Address: 10 BANK STREET
Facility Address 2: SUITE 740
Facility City,State,Zip: WHITE PLAINS, NY 10606
Case Number: 334485
Chemical Name: Decanoic acid

1986-2002 Chemical:
Case Number: 334-48-5
Preferred CA Index Name: Decanoic acid
Submitter Name: Not reported
Chemical Substance Definition: Not reported
Former Case Number: Not reported
Molecular Formula: C10H20O2
UVCB Flag: Not reported
EPA Inventory Flag: Not reported

1986-2002 CUSAGG:

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Case Number:	334485
Range 86:	>1M - 10M
Range 90:	>1M - 10M
Range 94:	>1M - 10M
Range 98:	>10M - 50M
Range 02:	10K - 500K
Chemical Name:	Decanoic acid
Manufacturer/Importer Status:	Import
CBIMFIM:	No
Company Name:	MARUBENI SPECIALTY CHEMICALS INC.
TSCA Name:	MARUBENI SPECIALTY CHEMICALS INC.
Facility Address:	10 BANK STREET
Facility Address 2:	SUITE 740
Facility City,State,Zip:	WHITE PLAINS, NY 10606
Case Number:	132983381
Chemical Name:	Benzene, ethenyl-, polymer with 1,3-butadiene and 2-methyl-1,3-butadiene, hydrogenated

1986-2002 Chemical:

Case Number:	132983-38-1
Preferred CA Index Name:	Benzene, ethenyl-, polymer with 1,3-butadiene and 2-methyl-1,3-butadiene, hydrogenated
Submitter Name:	Not reported
Chemical Substance Definition:	Not reported
Former Case Number:	180254-53-9
Molecular Formula:	Unspecified
UVCB Flag:	UVCB
EPA Inventory Flag:	XU; Y1

1986-2002 CUSAGG:

Case Number:	132983381
Range 86:	No Reports
Range 90:	No Reports
Range 94:	No Reports
Range 98:	10K - 500K
Range 02:	No Reports
Chemical Name:	Benzene, ethenyl-, polymer with 1,3-butadiene and 2-methyl-1,3-butadiene, hydrogenated
Manufacturer/Importer Status:	Import
CBIMFIM:	No
Company Name:	MARUBENI SPECIALTY CHEMICALS, INC.
TSCA Name:	MARUBENI SPECIALTY CHEMICALS INC.
Facility Address:	10 BANK STREET
Facility Address 2:	SUITE 740
Facility City,State,Zip:	WHITE PLAINS, NY 10606
Case Number:	86422608
Chemical Name:	Pyridinium, 1,1'-[1,4-phenylenebis[imino[6-[[8-hydroxy-3,6-disulfo-7-[(2-sulfophenyl)azo]-1-naphthalenyl]amino]-1,3,5-triazine-4,2-diyl]]]bis[3-carboxy-, dihydroxide, hexasodium salt

1986-2002 Chemical:

Case Number:	86422-60-8
Preferred CA Index Name:	Pyridinium,

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

1,1'-[1,4-phenylenebis[imino[6-[[8-hydroxy-3,6-disulfo-7-[2-(2-sulfoph
enyl)diazenyl]-1-naphthalenyl]amino]-1,3,5-triazine-4,2-diyl]]]bis[3-c
arboxy-, hydroxide, sodium salt (1:2:6)

Submitter Name: Not reported
Chemical Substance Definition: Not reported
Former Case Number: Not reported
Molecular Formula: C56H40N16O24S6.2HO.6Na
UVCB Flag: Not reported
EPA Inventory Flag: P

1986-2002 CUSAGG:
Case Number: 86422608
Range 86: No Reports
Range 90: 10K - 500K
Range 94: 10K - 500K
Range 98: 10K - 500K
Range 02: 10K - 500K
Chemical Name: Pyridinium,
1,1'-[1,4-phenylenebis[imino[6-[[8-hydroxy-3,6-disulfo-7-[(2-sulfophen
yl)azo]-1-naphthalenyl]amino]-1,3,5-triazine-4,2-diyl]]]bis[3-carboxy-
, dihydroxide, hexasodium salt

Manufacturer/Importer Status: Import
CBIMFIM: No
Company Name: MARUBENI SPECIALTY CHEMICALS, INC.
TSCA Name: MARUBENI SPECIALTY CHEMICALS INC.
Facility Address: 10 BANK STREET
Facility Address 2: SUITE 740
Facility City,State,Zip: WHITE PLAINS, NY 10606
Case Number: 41481667
Chemical Name: Phenol, 4,4'-sulfonylbis[2-(2-propenyl)-

1986-2002 Chemical:
Case Number: 41481-66-7
Preferred CA Index Name: Phenol, 4,4'-sulfonylbis[2-(2-propen-1-yl)-
Submitter Name: Not reported
Chemical Substance Definition: Not reported
Former Case Number: 118731-67-2
Molecular Formula: C18H18O4S
UVCB Flag: Not reported
EPA Inventory Flag: P

1986-2002 CUSAGG:
Case Number: 41481667
Range 86: No Reports
Range 90: No Reports
Range 94: No Reports
Range 98: 10K - 500K
Range 02: 10K - 500K
Chemical Name: Phenol, 4,4'-sulfonylbis[2-(2-propenyl)-

Manufacturer/Importer Status: Import
CBIMFIM: No
Company Name: MARUBENI SPECIALTY CHEMICALS, INC.
TSCA Name: MARUBENI SPECIALTY CHEMICALS INC.

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Facility Address: 10 BANK STREET
Facility Address 2: SUITE 740
Facility City,State,Zip: WHITE PLAINS, NY 10606
Case Number: 629118
Chemical Name: 1,6-Hexanediol

1986-2002 Chemical:
Case Number: 629-11-8
Preferred CA Index Name: 1,6-Hexanediol
Submitter Name: Not reported
Chemical Substance Definition: Not reported
Former Case Number: 140434-69-1
Molecular Formula: C6H14O2
UVCB Flag: Not reported
EPA Inventory Flag: Not reported

1986-2002 CUSAGG:
Case Number: 629118
Range 86: >10M - 50M
Range 90: >1M - 10M
Range 94: >10M - 50M
Range 98: >10M - 50M
Range 02: >10M - 50M
Chemical Name: 1,6-Hexanediol

Manufacturer/Importer Status: Import
CBIMFIM: No
Company Name: MARUBENI SPECIALTY CHEMICALS, INC.
TSCA Name: MARUBENI SPECIALTY CHEMICALS INC.
Facility Address: 10 BANK STREET
Facility Address 2: SUITE 740
Facility City,State,Zip: WHITE PLAINS, NY 10606
Case Number: 11070443
Chemical Name: 1,3-Isobenzofurandione, tetrahydromethyl-

1986-2002 Chemical:
Case Number: 11070-44-3
Preferred CA Index Name: 1,3-Isobenzofurandione, tetrahydromethyl-
Submitter Name: 1,3-Isobenzofurandione, tetrahydromethyl-
Chemical Substance Definition: Not reported
Former Case Number: 74318-12-0; 1027622-42-9
Molecular Formula: C9H10O3
UVCB Flag: Not reported
EPA Inventory Flag: Not reported

1986-2002 CUSAGG:
Case Number: 11070443
Range 86: >1M - 10M
Range 90: >1M - 10M
Range 94: >1M - 10M
Range 98: >1M - 10M
Range 02: >1M - 10M
Chemical Name: 1,3-Isobenzofurandione, tetrahydromethyl-

Manufacturer/Importer Status: Import

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

CBIMFIM: No
Company Name: MARUBENI SPECIALTY CHEMICALS, INC.
TSCA Name: MARUBENI SPECIALTY CHEMICALS INC.
Facility Address: 10 BANK STREET
Facility Address 2: SUITE 740
Facility City,State,Zip: WHITE PLAINS, NY 10606
Case Number: 13463417
Chemical Name: Zinc, bis[1-(hydroxy-.kappa.O)-2(1H)-pyridinethionato-.kappa.S2]-, (T-4)-

1986-2002 Chemical:
Case Number: 13463-41-7
Preferred CA Index Name: Zinc, bis[1-(hydroxy-.kappa.O)-2(1H)-pyridinethionato-.kappa.S2]-, (T-4)-
Submitter Name: Not reported
Chemical Substance Definition: Not reported
Former Case Number: 1192-70-7; 1320-68-9; 3138-01-0; 3590-23-6; 3865-77-8; 14376-32-0; 15686-64-3; 16782-00-6; 17652-47-0; 31089-48-2; 35430-20-7; 39412-61-8; 51148-10-8; 51406-57-6; 55172-61-7; 74261-71-5; 109702-19-4; 118480-78-7; 162400-43-3; 192458-89-2; 208398-70-3
Molecular Formula: C10H8N2O2S2Zn
UVCB Flag: Not reported
EPA Inventory Flag: Not reported

1986-2002 CUSAGG:
Case Number: 13463417
Range 86: No Reports
Range 90: >500K - 1M
Range 94: >1M - 10M
Range 98: >1M - 10M
Range 02: 10K - 500K
Chemical Name: Zinc, bis[1-(hydroxy-.kappa.O)-2(1H)-pyridinethionato-.kappa.S2]-, (T-4)-

FINDS:
Registry ID: 110004500610

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:
The National Compliance Database (NCDB) supports implementation of the Federal Insecticide, Fungicide, and Rodenticide Act (FIFRA) and the Toxic Substances Control Act (TSCA).
The database that supports the Toxic Substances Control Act (TSCA) of 1976, which provides EPA with authority to require reporting, record-keeping and testing requirements, and restrictions relating to chemical substances and/or mixtures. Certain substances are generally excluded from TSCA, including, among others, food, drugs, cosmetics and pesticides. TSCA addresses the production, importation, use, and disposal of specific chemicals including polychlorinated biphenyls (PCBs), asbestos, radon and lead-based paint.
The Integrated Compliance Information System (ICIS) provides a database that, when complete, will contain integrated enforcement and compliance information across most of EPA's programs. The vision for ICIS is to replace EPA's independent databases that contain

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

enforcement data with a single repository for that information. Currently, ICIS contains all Federal Administrative and Judicial enforcement actions and a subset of the Permit Compliance System (PCS), which supports the National Pollutant Discharge Elimination System (NPDES). This information is maintained in ICIS by EPA in the Regional offices and it at Headquarters. A future release of ICIS will completely replace PCS and will integrate that information with Federal actions already in the system. ICIS also has the capability to track other activities that support compliance and enforcement programs, including incident tracking, compliance assistance, and compliance monitoring.
The Resource Conservation and Recovery Act Information System (RCRAInfo) is EPA's comprehensive information system in support of the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. It tracks many types of information about generators, transporters, treaters, storers, and disposers of hazardous waste.

Registry ID: 110070864473

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:
The database that supports the Toxic Substances Control Act (TSCA) of 1976, which provides EPA with authority to require reporting, record-keeping and testing requirements, and restrictions relating to chemical substances and/or mixtures. Certain substances are generally excluded from TSCA, including, among others, food, drugs, cosmetics and pesticides. TSCA addresses the production, importation, use, and disposal of specific chemicals including polychlorinated biphenyls (PCBs), asbestos, radon and lead-based paint.

Click this hyperlink while viewing on your computer to access additional FINDS: detail in the EDR Site Report.

ECHO:

Envid:	1000911942
Registry ID:	110004500610

DFR URL:

Name:	MARUBENI SPECIALTY CHEMICALS INC
Address:	10 BANK ST
City,State,Zip:	WHITE PLAINS, NY 10606

NY MANIFEST:

EPA ID:	NYP004776522
Country:	USA
Name:	Con Edison
Address:	10 BANK ST & MARTINE AVE
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10606
Zip 4:	Not reported
Location Address 1:	F/O 10 BANK & MARTINE AVE
Location Address 2:	MH 9908
Location City,State,Zip:	WHITE PLAINS, NY 10606
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Mailing:
Mailing Name: Con Edison
Mailing Contact: Tom Teeling
Mailing Address 1: 4 IRVING PLACE - 15TH FLOOR
Mailing Address 2: Not reported
Mailing City,State,Zip: NEW YORK, NY 10003
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: Not reported

Manifest Data:
Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: NYD006982359
Year: 2018
Trans2 State ID: Not reported
Generator Ship Date: 04/30/2015
Trans1 Recv Date: 04/30/2015
Trans2 Recv Date: Not reported
TSD Site Recv Date: 04/30/2015
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYP004776522
Trans1 EPA ID: Not reported
Trans2 EPA ID: Not reported
TSDF ID 1: NJD002200046
TSDF ID 2: Not reported
Manifest Tracking Number: 014454051JJK
Import Indicator: N
Export Indicator: N
Discr Quantity Indicator: N
Discr Type Indicator: N
Discr Residue Indicator: N
Discr Partial Reject Indicator: N
Discr Full Reject Indicator: N
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: H110
Waste Code a: Lead
Waste Code b: Not reported
Waste Code c: Not reported
Waste Code e: Not reported
Waste Code f: Not reported
Waste Code g: Not reported
Waste Code 1: Not reported
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 60
Units: Pounds
Number of Containers: 1
Container Type: Cargo tanks (tank trucks)
Handling Method: Treat

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Specific Gravity: 1

EPA ID: NYP004792248
Country: USA
Name: Con Edison
Address: 10 BANK ST
Address 2: Not reported
City,State,Zip: WHITE PLAINS, NY 10606
Zip 4: Not reported
Location Address 1: BANK AVE NO TRAVERSE AVE
Location Address 2: MH 9908
Location City,State,Zip: WHITE PLAINS, NY 10606
Location Zip 4: Not reported
Facility Status: Not reported
Total Tanks: Not reported
Code: BP

Mailing:
Mailing Name: Con Edison
Mailing Contact: Dennis Huacon
Mailing Address 1: 4 IRVING PL 15TH FL
Mailing Address 2: Not reported
Mailing City,State,Zip: NEW YORK, NY 10003
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: 2124603770

Manifest Data:
Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: NYD006982359
Year: 2018
Trans2 State ID: Not reported
Generator Ship Date: 06/10/2015
Trans1 Recv Date: 06/10/2015
Trans2 Recv Date: Not reported
TSD Site Recv Date: 06/11/2015
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYP004792248
Trans1 EPA ID: Not reported
Trans2 EPA ID: Not reported
TSDF ID 1: NJD002200046
TSDF ID 2: Not reported
Manifest Tracking Number: 014473098JJK
Import Indicator: N
Export Indicator: N
Discr Quantity Indicator: N
Discr Type Indicator: N
Discr Residue Indicator: N
Discr Partial Reject Indicator: N
Discr Full Reject Indicator: N
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: H110

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Waste Code a: Not reported
Waste Code b: Not reported
Waste Code c: Not reported
Waste Code e: Lead
Waste Code f: Not reported
Waste Code g: Not reported
Waste Code 1: Not reported
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 175
Units: Pounds
Number of Containers: 1
Container Type: Cargo tanks (tank trucks)
Handling Method: Treat
Specific Gravity: 1

EPA ID: NYD987027638
Country: USA
Name: Marubeni Specialty Chemicals
Address: 10 BANK ST
Address 2: Not reported
City,State,Zip: WHITE PLAINS, NY 10606
Zip 4: Not reported
Location Address 1: 10 BANK ST
Location Address 2: Not reported
Location City,State,Zip: WHITE PLAINS, NY 10606
Location Zip 4: Not reported
Facility Status: Not reported
Total Tanks: Not reported
Code: BP

Mailing:
Mailing Name: Marubeni Specialty Chemicals
Mailing Contact: Ruperto Roman
Mailing Address 1: 10 BANK ST
Mailing Address 2: Not reported
Mailing City,State,Zip: WHITE PLAINS, NY 10606
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: 9144288900

Manifest Data:
Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: MAD039322250
Year: 2018
Trans2 State ID: MAD039322250
Generator Ship Date: 08/22/2013
Trans1 Recv Date: 08/22/2013
Trans2 Recv Date: 08/22/2013
TSD Site Recv Date: 09/10/2013
Part A Recv Date: Not reported
Part B Recv Date: Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Generator EPA ID:	NYD987027638
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	ARD069748192
TSDF ID 2:	Not reported
Manifest Tracking Number:	006548251FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H040
Waste Code a:	Ignitable Waste
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	5
Units:	Pounds
Number of Containers:	1
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	1
Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	MAD039322250
Year:	2018
Trans2 State ID:	MAD039322250
Generator Ship Date:	08/22/2013
Trans1 Recv Date:	08/22/2013
Trans2 Recv Date:	08/22/2013
TSD Site Recv Date:	09/10/2013
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD987027638
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	ARD069748192
TSDF ID 2:	Not reported
Manifest Tracking Number:	006548251FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H040
Waste Code a:	Ignitable Waste
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	5
Units:	Pounds
Number of Containers:	1
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	1
Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	ILD981957236
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	12/31/2008
Trans1 Recv Date:	12/31/2008
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	01/07/2009
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD987027638
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	TXD055135388
TSDF ID 2:	Not reported
Manifest Tracking Number:	005529288JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H141
Waste Code a:	Methyl Ethyl Ketone
Waste Code b:	Ignitable Waste
Waste Code c:	Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	800
Units:	Pounds
Number of Containers:	9
Container Type:	Metal drums, barrels, kegs
Handling Method:	Landfill
Specific Gravity:	1
Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	ILD981957236
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	12/31/2008
Trans1 Recv Date:	12/31/2008
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	01/07/2009
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD987027638
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	TXD055135388
TSDF ID 2:	Not reported
Manifest Tracking Number:	005529288JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H141
Waste Code a:	Methyl Ethyl Ketone
Waste Code b:	Ignitable Waste
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	60

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Units:	Pounds
Number of Containers:	1
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Landfill
Specific Gravity:	1
Document ID:	LAA3275160
Manifest Status:	Not reported
Trans1 State ID:	PA246
Year:	1994
Trans2 State ID:	Not reported
Generator Ship Date:	07/26/1994
Trans1 Recv Date:	07/26/1994
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	08/06/1994
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD987027638
Trans1 EPA ID:	PAD987284171
Trans2 EPA ID:	Not reported
TSDF ID 1:	LAD981057706
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Ignitable Waste
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00250
Units:	Pounds
Number of Containers:	002
Container Type:	Metal drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00
Waste Code 7:	Ignitable Waste
Waste Code 8:	Not reported
Waste Code:	Not reported
Waste Code 10:	Not reported
Waste Code 11:	Not reported
Quantity:	00001
Units:	Pounds
Number of Containers:	001
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Waste Code 12:	Corrosive Waste
Waste Code 13:	Not reported
Waste Code 14:	Not reported
Waste Code 15:	Not reported
Waste Code 16:	Not reported
Quantity:	00008
Units:	Pounds
Number of Containers:	001
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00
Waste Code 17:	Corrosive Waste
Waste Code 18:	Not reported
Waste Code 19:	Not reported
Waste Code 20:	Not reported
Waste Code 21:	Not reported
Quantity:	00015
Units:	Pounds
Number of Containers:	001
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00

Document ID:	LAA3275161
Manifest Status:	Not reported
Trans1 State ID:	PA246
Year:	1994
Trans2 State ID:	Not reported
Generator Ship Date:	07/26/1994
Trans1 Recv Date:	07/26/1994
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	08/06/1994
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD987027638
Trans1 EPA ID:	PAD987284171
Trans2 EPA ID:	Not reported
TSDF ID 1:	LAD981057706
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Ignitable Waste
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Quantity:	00003
Units:	Pounds
Number of Containers:	001
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00
Waste Code 7:	Ignitable Waste
Waste Code 8:	Not reported
Waste Code:	Not reported
Waste Code 10:	Not reported
Waste Code 11:	Not reported
Quantity:	00006
Units:	Pounds
Number of Containers:	001
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00
Waste Code 12:	Benzenamine, 2-Methyl- (Or) O-Toluidine
Waste Code 13:	Not reported
Waste Code 14:	Not reported
Waste Code 15:	Not reported
Waste Code 16:	Not reported
Quantity:	00011
Units:	Pounds
Number of Containers:	001
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00

Document ID:	MAJ5626420
Manifest Status:	Not reported
Trans1 State ID:	MA13273
Year:	1996
Trans2 State ID:	Not reported
Generator Ship Date:	07/02/1996
Trans1 Recv Date:	07/02/1996
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	07/09/1996
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD987027638
Trans1 EPA ID:	MAD039322250
Trans2 EPA ID:	Not reported
TSDF ID 1:	MAD980523203
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Waste Code 1:	Ignitable Waste
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00040
Units:	Pounds
Number of Containers:	002
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00
Waste Code 7:	Ignitable Waste
Waste Code 8:	Not reported
Waste Code:	Not reported
Waste Code 10:	Not reported
Waste Code 11:	Not reported
Quantity:	00005
Units:	Pounds
Number of Containers:	001
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00
Waste Code 12:	Corrosive Waste
Waste Code 13:	Not reported
Waste Code 14:	Not reported
Waste Code 15:	Not reported
Waste Code 16:	Not reported
Quantity:	00005
Units:	Pounds
Number of Containers:	001
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Treat
Specific Gravity:	01.00

Document ID:	ILA7651117
Manifest Status:	Not reported
Trans1 State ID:	2075
Year:	1997
Trans2 State ID:	1478
Generator Ship Date:	11/20/1997
Trans1 Recv Date:	01/01/1900
Trans2 Recv Date:	11/20/1997
TSD Site Recv Date:	12/02/1997
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD987027638
Trans1 EPA ID:	NJD000813477
Trans2 EPA ID:	MAD039322250
TSDF ID 1:	ILD000608471
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Ignitable Waste
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00001
Units:	Pounds
Number of Containers:	001
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00
Waste Code 7:	Ignitable Waste
Waste Code 8:	Not reported
Waste Code:	Not reported
Waste Code 10:	Not reported
Waste Code 11:	Not reported
Quantity:	00070
Units:	Pounds
Number of Containers:	001
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00
Waste Code 12:	Ignitable Waste
Waste Code 13:	Not reported
Waste Code 14:	Not reported
Waste Code 15:	Not reported
Waste Code 16:	Not reported
Quantity:	00040
Units:	Pounds
Number of Containers:	001
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00
Waste Code 17:	Ignitable Waste
Waste Code 18:	Not reported
Waste Code 19:	Not reported
Waste Code 20:	Not reported
Waste Code 21:	Not reported
Quantity:	00100
Units:	Pounds
Number of Containers:	004
Container Type:	Metal drums, barrels, kegs
Handling Method:	Landfill
Specific Gravity:	01.00
Document ID:	ILA7385491
Manifest Status:	Not reported
Trans1 State ID:	1478
Year:	1997
Trans2 State ID:	1431

MARUBENI SPECIALTY CHEMICALS INC (Continued) **1000911942**

Generator Ship Date:	10/16/1997
Trans1 Recv Date:	10/16/1997
Trans2 Recv Date:	10/17/1997
TSD Site Recv Date:	10/30/1997
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD987027638
Trans1 EPA ID:	MAD039322250
Trans2 EPA ID:	OHD009865825
TSDF ID 1:	ILD000608471
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Ignitable Waste
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00001
Units:	Gallons (liquids only)
Number of Containers:	001
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00
Waste Code 7:	Ignitable Waste
Waste Code 8:	Not reported
Waste Code:	Not reported
Waste Code 10:	Not reported
Waste Code 11:	Not reported
Quantity:	00001
Units:	Gallons (liquids only)
Number of Containers:	001
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00

R202 **CON EDISON** **NJ MANIFEST** **S120670623**
SW **10 BANK ST** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10606**
0.142 mi.
748 ft. **Site 6 of 11 in cluster R**

Relative:
Higher

Actual:
202 ft.

NJ MANIFEST:

EPA ID:	NYP004769600
Name:	CON EDISON
Address:	10 BANK ST
City,State,Zip:	WHITE PLAINS, NY 10606
County:	Not reported
Mailing Address:	IRVING PL 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Telephone:	Not reported
Emergency Telephone:	Not reported
Contact:	THOMAS TEELING
Comments:	Not reported
SIC Code:	Not reported
County:	NY119
Municipal:	Not reported
Previous EPAID:	Not reported
Generator Flag:	Not reported
Transporter Flag:	Not reported
TSDF Flag:	Not reported
Name Change:	Not reported
Date Change:	Not reported

Manifest Data:

EPA ID:	NYP004769600
Manifest Number:	014085133JJK
Date Shipped:	4/16/2015
TSDF EPA ID:	NJD002200046
Transporter EPA ID:	NYD006982359
Transporter 2 EPA ID:	Not reported
Transporter 3 EPA ID:	Not reported
Transporter 4 EPA ID:	Not reported
Transporter 5 EPA ID:	Not reported
Transporter 6 EPA ID:	Not reported
Transporter 7 EPA ID:	Not reported
Transporter 8 EPA ID:	Not reported
Transporter 9 EPA ID:	Not reported
Transporter 10 EPA ID:	Not reported
Date Trans1 Transported Waste:	Not reported
Date Trans2 Transported Waste:	Not reported
Date Trans3 Transported Waste:	Not reported
Date Trans4 Transported Waste:	Not reported
Date Trans5 Transported Waste:	Not reported
Date Trans6 Transported Waste:	Not reported
Date Trans7 Transported Waste:	Not reported
Date Trans8 Transported Waste:	Not reported
Date Trans9 Transported Waste:	Not reported
Date Trans10 Transported Waste:	Not reported
Date TSDF Received Waste:	Not reported
TSDF EPA Facility Name:	Not reported
QTY Units:	Not reported
Transporter SEQ ID:	Not reported
Transporter-1 Date:	Not reported
Waste SEQ ID:	Not reported
Waste Type Code 2:	Not reported

CON EDISON (Continued) **S120670623**

Waste Type Code 3:	Not reported
Waste Type Code 4:	Not reported
Waste Type Code 5:	Not reported
Waste Type Code 6:	Not reported
Date Accepted:	Not reported
Manifest Discrepancy Type:	Not reported
Data Entry Number:	Not reported
Was Load Rejected:	Not reported
Reason Load Was Rejected:	Not reported

R203 **CON EDISON** **RCRA NonGen / NLR** **1019902096**
SW **10 BANK ST** **NYP004769600**
1/8-1/4 **WHITE PLAINS, NY 10606**
0.142 mi.
748 ft. **Site 7 of 11 in cluster R**

Relative: **Higher**
Actual: **202 ft.**

RCRA Listings:

Date Form Received by Agency:	20150416
Handler Name:	Con Edison
Handler Address:	Bank St
Handler City,State,Zip:	WHITE PLAINS, NY 10606
EPA ID:	NYP004769600
Contact Name:	THOMAS TEELING
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	212-460-3770
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PL 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No

CON EDISON (Continued) **1019902096**

Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20160909
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20150416
Handler Name: CON EDISON	
Federal Waste Generator Description:	Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20150416
Handler Name: CON EDISON	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

CON EDISON (Continued) **1019902096**

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

P204 **WP MALL CLEANERS & GAS STATION SITE** **NY INST CONTROL** **S128529085**
NE **250 HAMILTON AVENUE** **NY BROWNFIELDS** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601** **NY PFAS**
0.145 mi. **NY MANIFEST**
763 ft. **Site 6 of 8 in cluster P**

Relative:
Higher

Actual:
208 ft.

INST CONTROL:
Name: WP MALL CLEANERS & GAS STATION SITE
Address: 250 HAMILTON AVENUE
City,State,Zip: WHITE PLAINS, NY 10601
Site Code: 628108
Control Name: Monitoring Plan
HW Code: C360221
Control Code: 31
Control Type: INST
Dt record added: 12/18/2023
Dt rec updated: 12/29/2023
Updated By: GLWHITE
Site Code: 628108
Site Description: Site Location: The 1.808-acre site is located at 250 Hamilton Avenue, White Plains, Westchester County. The site is located on tax lot 125.67-5-1..1. The site was most recently a portion of the White Plains Mall and associated parking lot. The site is located in a mixed-use commercial and residential neighborhood. Barker Avenue, a restaurant, and a hotel are located north of the site. Cottage Place, a parking lot, a condominium building, and Berkeley College student dormitories are located east of the site. Hamilton Avenue and a New York Power Authority Building are located south of the site. A Brownfield Cleanup Program site (site no. C360177) abuts the west boundary of the site. The site is located approximately 0.35 miles from the Bronx River. It is not located in a flood zone. Site Features: Currently, a multi-story mixed use building is under construction on the site. Current Zoning and Land Use: The site is located in a Transit Development District (TD-1) and is currently being redeveloped as noted above. The surrounding properties include residential and commercial use. Past Use and Investigation of the Site: The site was developed with dwellings and garages prior to 1911. By 1930, multiple businesses operated on-site, including a gypsum partitions business, an electric motors building, a paint store, a plumbing shop, and a candy manufacturer. The candy manufacturer, along with a gasoline station located in the south-eastern portion of the site, are estimated to have been on-site from the 1930s through the 1970s. By 1987, all on-site buildings were demolished and replaced by a parking lot and eventually a portion of the White Plains Mall. A dry-cleaning facility is listed as a White Plains Mall occupant in 2010 and 2011. Use of the site as a candy

WP MALL CLEANERS & GAS STATION SITE (Continued) **S128529085**

manufacturer, gasoline station and dry-cleaning operations may have contributed to site contamination. Spill Number 17-06297 was reported September 28, 2017, based on evidence of petroleum contamination in soil and groundwater. Site Geology and Hydrogeology: Based on the United States Geological Survey and Westchester County Geographic Information System, the site lies at elevations ranging from 185 to 200 feet above the National Geodetic Vertical Datum of 1983. Regional topography slopes downward to the west. Groundwater flows in the southwesterly direction. Groundwater depths range from approximately 9 to 24 feet below grade (ft bg). Deeper groundwater depths were found in the eastern portion of the site. The soil at the site is characterized as Uf (Urban Land) which is covered by pavement, concrete, buildings, and other structures. A fill stratum is encountered from grade to depths of 12 ft bg. The fill layer consists of sand, silt, gravel, organics (wood/grass), brick, asphalt, and rubber. A layer of clay and silt were encountered beneath the fill between 7 and 13 ft bg. Sand is present in the layer of clay and silt, but content varied across the site. Between approximately 13 and 25.5 ft bg, a sand layer was encountered. The sand stratum consisted of brown, medium to coarse sand, little to some silt, and trace amounts of gravel. During geophysical investigations of the site, bedrock was encountered from approximately 13 to 40 ft bg. The depth of bedrock corresponded to the approximate elevations of the site.

Env Problem: Nature and extent of contamination: Prior to remediation, the primary contaminants of concern included volatile organic compounds (VOCs), metals, and pesticides in soil, VOCs, semi-VOCs (SVOCs), metals and per- and polyfluoroalkyl substances (PFAS) in groundwater, and VOCs in soil vapor. Impacts were identified in soil across the site to depths up to 40 ft bg. Soil: Upon acceptance into the BCP, the primary contaminants of concern in soil were VOCs, SVOCs, metals, and pesticides. Compounds that exceeded their unrestricted use soil cleanup objectives (USCOs) during the remedial investigation (RI) included (maximum concentrations given): ethylbenzene (37.3 part per million [ppm] compared to the USCO of 1 ppm), xylenes (110 ppm compared to the USCO of 0.26 ppm), benzo(a)anthracene (1.5 ppm compared to the USCO of 1 ppm), benzo(a)pyrene (1.63 ppm compared to the USCO of 1 ppm), benzo(b)fluoranthene (2.67 ppm compared to the USCO of 1 ppm), benzo(k)fluoranthene (0.972 ppm compared to the USCO of 0.8 ppm), chrysene (1.68 ppm compared to the USCO of 1 ppm), dibenzo(a,h)anthracene (0.399 ppm compared to the USCO of 0.33 ppm), indeno(1,2,3 c,d)pyrene (1.57 ppm compared to the USCO of 0.5 ppm), arsenic (26.4 ppm compared to the USCO of 13 ppm), barium (1,100 ppm compared to the USCO of 350 ppm), chromium (120 ppm compared to the USCO of 30 ppm), copper (83.9 ppm compared to the USCO of 50 ppm), lead (3,120 ppm compared to the USCO of 63 ppm), manganese (3,320 ppm compared to the USCO of 1,600 ppm), mercury (0.97 ppm compared to the USCO of 0.18 ppm), nickel (75.5 ppm compared to the USCO of 30 ppm), selenium (6.5 ppm compared to the USCO of 3.9 ppm), silver (4.3 ppm compared to the USCO of 2 ppm), zinc (693 ppm compared to the USCO of 109 ppm), dieldrin (0.007 ppm compared to the USCO of 0.005 ppm), 4,4 DDD (0.103 ppm compared to the USCO of 0.0033 ppm), 4,4 DDE (0.0512 ppm compared to 0.0033 ppm), and 4,4 DDT (0.06 ppm compared to the USCO of 0.0033 ppm). Following remediation, all soil above USCOs have been removed and disposed of off-site. A total of 146,398 tons of contaminated soil was excavated and removed from the site. Groundwater: Remedial investigation groundwater sampling, conducted

WP MALL CLEANERS & GAS STATION SITE (Continued) **S128529085**

in November 2022, indicated impacts of VOCs, SVOCs, metals (filtered), and PFAS in exceedance of New York Codes, Rules and Regulations Title 6 (6 NYCRR) and guidance documents found in the Division of Water Technical and Operational Guidance Series (TOGs) Standards, Criteria and Guidance Values (SCGs), including, but not limited to: benzene (3.2 parts per billion [ppb] compared to the SCG of 1 ppb), toluene (18.1 ppb compared to the SCG of 5 ppb), ethylbenzene (632 ppb compared to the SCG of 5 ppb), isopropylbenzene (80.3 ppb compared to the SCG of 5 ppb), xylenes (1,670 ppb compared to the SCG of 5 ppb), benzo(a)anthracene (4.1 ppb compared to the SCG of 0.002 ppb), benzo(a)pyrene (4.4 ppb compared to the SCG of non detect), benzo(b)fluoranthene (5.8 ppb compared to the SCG of 0.002 ppb), benzo (k)fluoranthene (2.3 ppb compared to the SCG of 0.002 ppb), chrysene (3.8 ppb compared to the SCG of 0.002 ppb), ideno(1,2,3 cd)pyrene (0.18 ppb compared to the SCG of 0.002 ppb), indeno(1,2,3 c,d)pyrene (6.2 ppb compared to the SCG of 0.002 ppb), 2,4 dimethylphenol (11.5 ppb compared to the SCG of 1 ppb), pentachlorophenol (5.3 ppb compared to the SCG of 1 ppb), naphthalene (25.1 ppb compared to the SCG of 10 ppb), antimony (41.3 ppb compared to the SCG of 3 ppb), arsenic (44.5 ppb compared to the SCG of 25 ppb), cadmium (45.4 ppb compared to the SCG of 5 ppb), chromium (483 ppb compared to the SCG of 50 ppb), iron (50,700 ppb compared to the SCG of 300 ppb), lead (307 ppb compared to the SCG of 50 ppb), manganese (20,400 ppb compared to the SCG of 300 ppb), selenium (45.3 ppb compared to the SCG of 10 ppb), sodium (1,670,000 ppb compared to the SCG of 20,000 ppb), PFOS (152 parts per trillion [ppt] compared to the SCG of 2.7 ppt) and PFOA (71.2 ppt compared to the SCG of 6.7 ppt). Groundwater samples were collected from three (3) monitoring wells in the southern portion of the site for VOC analysis in April 2023. Those results indicated methyl tert butyl ether (MTBE) concentrations above its SCG (10 ppb), at a maximum concentration of 220 ppb. No other VOCs were detected above SCGs during that sampling event. Groundwater concentrations of VOCs and PFAS remain above SCGs.
Soil Vapor: Prior to remediation, soil vapor samples were collected. No indoor air samples were collected since the on-site building was being demolished. During the Phase II site investigation, trichloroethylene (TCE) was detected in soil vapor at a maximum concentration of 13 micrograms per cubic meter (g/m3). During the remedial investigation, TCE was detected at a maximum concentration of 0.97 g/m3. This compound was not detected in soil or groundwater above its USCO or SCG. Based on the soil vapor results and the intended use, a post remediation soil vapor intrusion evaluation is required. There are no current exposure concerns since there are no buildings on site. The complete excavation of soil in exceedance of USCOs have removed any potentially impacted soil addressing the potential migration of soil vapor off site.

Health Problem: Remedial actions are complete, and measures are in place to control the potential for coming in contact with residual contamination remaining at the site.
Dump: False
Structure: False
Lagoon: False
Landfill: False
Pond: False
Disp Start: Not reported
Disp Term: Not reported
Lat/Long: Not reported

WP MALL CLEANERS & GAS STATION SITE (Continued) **S128529085**

Dell: Not reported
Record Add: 2022-03-03 17:35:00
Record Upd: 2023-08-24 14:14:00
Updated By: GLWHITE
Own Op: 6
Sub Type: P03
Owner Name: Todd Rechler
Owner Company: Hamilton Green I Partners LLC
Owner Address: 625 RXR Plaza
Owner Addr2: Not reported
Owner City,St,Zip: Uniondale, NY 11556
Owner Country: United States of America
Own Op: Document Repository
Sub Type: NNN
Owner Name: Brian Kenney
Owner Company: White Plains Public Library
Owner Address: 100 Martine Avenue
Owner Addr2: Not reported
Owner City,St,Zip: White Plains, NY 10601
Owner Country: United States of America
Own Op: 1
Sub Type: P03
Owner Name: Todd Rechler
Owner Company: Hamilton Green I Partners LLC
Owner Address: 625 RXR Plaza
Owner Addr2: Not reported
Owner City,St,Zip: Uniondale, NY 11556
Owner Country: United States of America
HW Code: C360221
Waste Type: n-propylbenzene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: perfluorooctanoic acid
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: mercury
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: lead
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: benzo(b)fluoranthene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: naphthalene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: zinc
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221

WP MALL CLEANERS & GAS STATION SITE (Continued) **S128529085**

Waste Type: chromium
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: dibenz[a,h]anthracene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: manganese
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: chrysene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: DDT
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: 1,3,5-trimethylbenzene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: isopropylbenzene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: benzene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: selenium
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: DDE
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: perfluorooctane sulfonic acid
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: barium
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: nickel
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: ethylbenzene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: antimony

WP MALL CLEANERS & GAS STATION SITE (Continued) **S128529085**

Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: dieldrin
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: methyl-tert-butyl ether (MTBE)
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: indeno(1,2,3-cd)pyrene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: toluene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: benzo(a)anthracene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: benzo(a)pyrene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: alpha-BHC
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: arsenic
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: pentachlorophenol
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: DDD
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: cadmium
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: xylene (mixed)
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: 1,2,4-trimethylbenzene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: benzo(k)fluoranthene
Waste Quantity: UNKNOWN

WP MALL CLEANERS & GAS STATION SITE (Continued) **S128529085**

Waste Code: Not reported
HW Code: C360221
Waste Type: copper
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: silver
Waste Quantity: UNKNOWN
Waste Code: Not reported
Crossref ID: 632063045
Cross Ref Type Code: 25
Cross Ref Type: County Recording Identifier
Record Added Date: 2023-12-26 10:05:00
Record Updated: 2023-12-26 10:05:00
Updated By: GLWHITE
Crossref ID: 633423096
Cross Ref Type Code: 25
Cross Ref Type: County Recording Identifier
Record Added Date: 2023-12-26 10:06:00
Record Updated: 2023-12-26 10:06:00
Updated By: GLWHITE
Crossref ID: 1706297
Cross Ref Type Code: 01
Cross Ref Type: Spill No.
Record Added Date: 2022-05-03 14:02:00
Record Updated: 2022-05-03 14:02:00
Updated By: GLWHITE
Crossref ID: C360221-03-22
Cross Ref Type Code: 23
Cross Ref Type: Agreement/Consent Order Number
Record Added Date: 2023-12-20 08:21:00
Record Updated: 2023-12-20 08:21:00
Updated By: GLWHITE

Name: WP MALL CLEANERS & GAS STATION SITE
Address: 250 HAMILTON AVENUE
City,State,Zip: WHITE PLAINS, NY 10601
Site Code: 628108
Control Name: IC/EC Plan
HW Code: C360221
Control Code: 34
Control Type: INST
Dt record added: 12/18/2023
Dt rec updated: 12/29/2023
Updated By: GLWHITE
Site Code: 628108
Site Description: Site Location: The 1.808-acre site is located at 250 Hamilton Avenue, White Plains, Westchester County. The site is located on tax lot 125.67-5-1..1. The site was most recently a portion of the White Plains Mall and associated parking lot. The site is located in a mixed-use commercial and residential neighborhood. Barker Avenue, a restaurant, and a hotel are located north of the site. Cottage Place, a parking lot, a condominium building, and Berkeley College student dormitories are located east of the site. Hamilton Avenue and a New York Power Authority Building are located south of the site. A Brownfield Cleanup Program site (site no. C360177) abuts the west boundary of the site. The site is located approximately 0.35 miles

WP MALL CLEANERS & GAS STATION SITE (Continued) **S128529085**

from the Bronx River. It is not located in a flood zone. Site Features: Currently, a multi-story mixed use building is under construction on the site. Current Zoning and Land Use: The site is located in a Transit Development District (TD-1) and is currently being redeveloped as noted above. The surrounding properties include residential and commercial use. Past Use and Investigation of the Site: The site was developed with dwellings and garages prior to 1911. By 1930, multiple businesses operated on-site, including a gypsum partitions business, an electric motors building, a paint store, a plumbing shop, and a candy manufacturer. The candy manufacturer, along with a gasoline station located in the south-eastern portion of the site, are estimated to have been on-site from the 1930s through the 1970s. By 1987, all on-site buildings were demolished and replaced by a parking lot and eventually a portion of the White Plains Mall. A dry-cleaning facility is listed as a White Plains Mall occupant in 2010 and 2011. Use of the site as a candy manufacturer, gasoline station and dry-cleaning operations may have contributed to site contamination. Spill Number 17-06297 was reported September 28, 2017, based on evidence of petroleum contamination in soil and groundwater. Site Geology and Hydrogeology: Based on the United States Geological Survey and Westchester County Geographic Information System, the site lies at elevations ranging from 185 to 200 feet above the National Geodetic Vertical Datum of 1983. Regional topography slopes downward to the west. Groundwater flows in the southwesterly direction. Groundwater depths range from approximately 9 to 24 feet below grade (ft bg). Deeper groundwater depths were found in the eastern portion of the site. The soil at the site is characterized as Uf (Urban Land) which is covered by pavement, concrete, buildings, and other structures. A fill stratum is encountered from grade to depths of 12 ft bg. The fill layer consists of sand, silt, gravel, organics (wood/grass), brick, asphalt, and rubber. A layer of clay and silt were encountered beneath the fill between 7 and 13 ft bg. Sand is present in the layer of clay and silt, but content varied across the site. Between approximately 13 and 25.5 ft bg, a sand layer was encountered. The sand stratum consisted of brown, medium to coarse sand, little to some silt, and trace amounts of gravel. During geophysical investigations of the site, bedrock was encountered from approximately 13 to 40 ft bg. The depth of bedrock corresponded to the approximate elevations of the site.

Env Problem: Nature and extent of contamination: Prior to remediation, the primary contaminants of concern included volatile organic compounds (VOCs), metals, and pesticides in soil, VOCs, semi-VOCs (SVOCs), metals and per- and polyfluoroalkyl substances (PFAS) in groundwater, and VOCs in soil vapor. Impacts were identified in soil across the site to depths up to 40 ft bg. Soil: Upon acceptance into the BCP, the primary contaminants of concern in soil were VOCs, SVOCs, metals, and pesticides. Compounds that exceeded their unrestricted use soil cleanup objectives (USCOs) during the remedial investigation (RI) included (maximum concentrations given): ethylbenzene (37.3 part per million [ppm] compared to the USCO of 1 ppm), xylenes (110 ppm compared to the USCO of 0.26 ppm), benzo(a)anthracene (1.5 ppm compared to the USCO of 1 ppm), benzo(a)pyrene (1.63 ppm compared to the USCO of 1 ppm), benzo(b)fluoranthene (2.67 ppm compared to the USCO of 1 ppm), benzo(k)fluoranthene (0.972 ppm compared to the USCO of 0.8 ppm), chrysene (1.68 ppm compared to the USCO of 1 ppm), dibenzo(a,h)anthracene (0.399 ppm compared to the USCO of 0.33 ppm),

WP MALL CLEANERS & GAS STATION SITE (Continued) **S128529085**

indeno(1,2,3 c,d)pyrene (1.57 ppm compared to the USCO of 0.5 ppm), arsenic (26.4 ppm compared to the USCO of 13 ppm), barium (1,100 ppm compared to the USCO of 350 ppm), chromium (120 ppm compared to the USCO of 30 ppm), copper (83.9 ppm compared to the USCO of 50 ppm), lead (3,120 ppm compared to the USCO of 63 ppm), manganese (3,320 ppm compared to the USCO of 1,600 ppm), mercury (0.97 ppm compared to the USCO of 0.18 ppm), nickel (75.5 ppm compared to the USCO of 30 ppm), selenium (6.5 ppm compared to the USCO of 3.9 ppm), silver (4.3 ppm compared to the USCO of 2 ppm), zinc (693 ppm compared to the USCO of 109 ppm), dieldrin (0.007 ppm compared to the USCO of 0.005 ppm), 4,4 DDD (0.103 ppm compared to the USCO of 0.0033 ppm), 4,4 DDE (0.0512 ppm compared to 0.0033 ppm), and 4,4 DDT (0.06 ppm compared to the USCO of 0.0033 ppm). Following remediation, all soil above USCOs have been removed and disposed of off-site. A total of 146,398 tons of contaminated soil was excavated and removed from the site.
Groundwater: Remedial investigation groundwater sampling, conducted in November 2022, indicated impacts of VOCs, SVOCs, metals (filtered), and PFAS in exceedance of New York Codes, Rules and Regulations Title 6 (6 NYCRR) and guidance documents found in the Division of Water Technical and Operational Guidance Series (TOGs) Standards, Criteria and Guidance Values (SCGs), including, but not limited to: benzene (3.2 parts per billion [ppb] compared to the SCG of 1 ppb), toluene (18.1 ppb compared to the SCG of 5 ppb), ethylbenzene (632 ppb compared to the SCG of 5 ppb), isopropylbenzene (80.3 ppb compared to the SCG of 5 ppb), xylenes (1,670 ppb compared to the SCG of 5 ppb), benzo(a)anthracene (4.1 ppb compared to the SCG of 0.002 ppb), benzo(a)pyrene (4.4 ppb compared to the SCG of non detect), benzo(b)fluoranthene (5.8 ppb compared to the SCG of 0.002 ppb), benzo (k)fluoranthene (2.3 ppb compared to the SCG of 0.002 ppb), chrysene (3.8 ppb compared to the SCG of 0.002 ppb), ideno(1,2,3 cd)pyrene (0.18 ppb compared to the SCG of 0.002 ppb), indeno(1,2,3 c,d)pyrene (6.2 ppb compared to the SCG of 0.002 ppb), 2,4 dimethylphenol (11.5 ppb compared to the SCG of 1 ppb), pentachlorophenol (5.3 ppb compared to the SCG of 1 ppb), naphthalene (25.1 ppb compared to the SCG of 10 ppb), antimony (41.3 ppb compared to the SCG of 3 ppb), arsenic (44.5 ppb compared to the SCG of 25 ppb), cadmium (45.4 ppb compared to the SCG of 5 ppb), chromium (483 ppb compared to the SCG of 50 ppb), iron (50,700 ppb compared to the SCG of 300 ppb), lead (307 ppb compared to the SCG of 50 ppb), manganese (20,400 ppb compared to the SCG of 300 ppb), selenium (45.3 ppb compared to the SCG of 10 ppb), sodium (1,670,000 ppb compared to the SCG of 20,000 ppb), PFOS (152 parts per trillion [ppt] compared to the SCG of 2.7 ppt) and PFOA (71.2 ppt compared to the SCG of 6.7 ppt). Groundwater samples were collected from three (3) monitoring wells in the southern portion of the site for VOC analysis in April 2023. Those results indicated methyl tert butyl ether (MTBE) concentrations above its SCG (10 ppb), at a maximum concentration of 220 ppb. No other VOCs were detected above SCGs during that sampling event. Groundwater concentrations of VOCs and PFAS remain above SCGs.
Soil Vapor: Prior to remediation, soil vapor samples were collected. No indoor air samples were collected since the on-site building was being demolished. During the Phase II site investigation, trichloroethylene (TCE) was detected in soil vapor at a maximum concentration of 13 micrograms per cubic meter (g/m3). During the remedial investigation, TCE was detected at a maximum concentration of 0.97 g/m3. This compound was not detected in soil or groundwater above its USCO or SCG. Based on the soil vapor results and the

WP MALL CLEANERS & GAS STATION SITE (Continued) **S128529085**

	intended use, a post remediation soil vapor intrusion evaluation is required. There are no current exposure concerns since there are no buildings on site. The complete excavation of soil in exceedance of USCOs have removed any potentially impacted soil addressing the potential migration of soil vapor off site.
Health Problem:	Remedial actions are complete, and measures are in place to control the potential for coming in contact with residual contamination remaining at the site.
Dump:	False
Structure:	False
Lagoon:	False
Landfill:	False
Pond:	False
Disp Start:	Not reported
Disp Term:	Not reported
Lat/Long:	Not reported
Dell:	Not reported
Record Add:	2022-03-03 17:35:00
Record Upd:	2023-08-24 14:14:00
Updated By:	GLWHITE
Own Op:	6
Sub Type:	P03
Owner Name:	Todd Rechler
Owner Company:	Hamilton Green I Partners LLC
Owner Address:	625 RXR Plaza
Owner Addr2:	Not reported
Owner City,St,Zip:	Uniondale, NY 11556
Owner Country:	United States of America
Own Op:	Document Repository
Sub Type:	NNN
Owner Name:	Brian Kenney
Owner Company:	White Plains Public Library
Owner Address:	100 Martine Avenue
Owner Addr2:	Not reported
Owner City,St,Zip:	White Plains, NY 10601
Owner Country:	United States of America
Own Op:	1
Sub Type:	P03
Owner Name:	Todd Rechler
Owner Company:	Hamilton Green I Partners LLC
Owner Address:	625 RXR Plaza
Owner Addr2:	Not reported
Owner City,St,Zip:	Uniondale, NY 11556
Owner Country:	United States of America
HW Code:	C360221
Waste Type:	n-propylbenzene
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360221
Waste Type:	perfluorooctanoic acid
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360221
Waste Type:	mercury
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360221

WP MALL CLEANERS & GAS STATION SITE (Continued) **S128529085**

Waste Type: lead
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: benzo(b)fluoranthene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: naphthalene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: zinc
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: chromium
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: dibenz[a,h]anthracene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: manganese
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: chrysene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: DDT
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: 1,3,5-trimethylbenzene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: isopropylbenzene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: benzene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: selenium
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: DDE
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: perfluorooctane sulfonic acid

WP MALL CLEANERS & GAS STATION SITE (Continued) **S128529085**

Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: barium
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: nickel
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: ethylbenzene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: antimony
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: dieldrin
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: methyl-tert-butyl ether (MTBE)
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: indeno(1,2,3-cd)pyrene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: toluene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: benzo(a)anthracene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: benzo(a)pyrene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: alpha-BHC
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: arsenic
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: pentachlorophenol
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: DDD
Waste Quantity: UNKNOWN

WP MALL CLEANERS & GAS STATION SITE (Continued) **S128529085**

Waste Code: Not reported
HW Code: C360221
Waste Type: cadmium
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: xylene (mixed)
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: 1,2,4-trimethylbenzene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: benzo(k)fluoranthene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: copper
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: silver
Waste Quantity: UNKNOWN
Waste Code: Not reported
Crossref ID: 632063045
Cross Ref Type Code: 25
Cross Ref Type: County Recording Identifier
Record Added Date: 2023-12-26 10:05:00
Record Updated: 2023-12-26 10:05:00
Updated By: GLWHITE
Crossref ID: 633423096
Cross Ref Type Code: 25
Cross Ref Type: County Recording Identifier
Record Added Date: 2023-12-26 10:06:00
Record Updated: 2023-12-26 10:06:00
Updated By: GLWHITE
Crossref ID: 1706297
Cross Ref Type Code: 01
Cross Ref Type: Spill No.
Record Added Date: 2022-05-03 14:02:00
Record Updated: 2022-05-03 14:02:00
Updated By: GLWHITE
Crossref ID: C360221-03-22
Cross Ref Type Code: 23
Cross Ref Type: Agreement/Consent Order Number
Record Added Date: 2023-12-20 08:21:00
Record Updated: 2023-12-20 08:21:00
Updated By: GLWHITE

Name: WP MALL CLEANERS & GAS STATION SITE
Address: 250 HAMILTON AVENUE
City,State,Zip: WHITE PLAINS, NY 10601
Site Code: 628108
Control Name: Site Management Plan
HW Code: C360221
Control Code: 32

WP MALL CLEANERS & GAS STATION SITE (Continued) **S128529085**

Control Type: INST
Dt record added: 12/18/2023
Dt rec updated: 12/29/2023
Updated By: GLWHITE
Site Code: 628108
Site Description: Site Location: The 1.808-acre site is located at 250 Hamilton Avenue, White Plains, Westchester County. The site is located on tax lot 125.67-5-1..1. The site was most recently a portion of the White Plains Mall and associated parking lot. The site is located in a mixed-use commercial and residential neighborhood. Barker Avenue, a restaurant, and a hotel are located north of the site. Cottage Place, a parking lot, a condominium building, and Berkeley College student dormitories are located east of the site. Hamilton Avenue and a New York Power Authority Building are located south of the site. A Brownfield Cleanup Program site (site no. C360177) abuts the west boundary of the site. The site is located approximately 0.35 miles from the Bronx River. It is not located in a flood zone. Site Features: Currently, a multi-story mixed use building is under construction on the site. Current Zoning and Land Use: The site is located in a Transit Development District (TD-1) and is currently being redeveloped as noted above. The surrounding properties include residential and commercial use. Past Use and Investigation of the Site: The site was developed with dwellings and garages prior to 1911. By 1930, multiple businesses operated on-site, including a gypsum partitions business, an electric motors building, a paint store, a plumbing shop, and a candy manufacturer. The candy manufacturer, along with a gasoline station located in the south-eastern portion of the site, are estimated to have been on-site from the 1930s through the 1970s. By 1987, all on-site buildings were demolished and replaced by a parking lot and eventually a portion of the White Plains Mall. A dry-cleaning facility is listed as a White Plains Mall occupant in 2010 and 2011. Use of the site as a candy manufacturer, gasoline station and dry-cleaning operations may have contributed to site contamination. Spill Number 17-06297 was reported September 28, 2017, based on evidence of petroleum contamination in soil and groundwater. Site Geology and Hydrogeology: Based on the United States Geological Survey and Westchester County Geographic Information System, the site lies at elevations ranging from 185 to 200 feet above the National Geodetic Vertical Datum of 1983. Regional topography slopes downward to the west. Groundwater flows in the southwesterly direction. Groundwater depths range from approximately 9 to 24 feet below grade (ft bg). Deeper groundwater depths were found in the eastern portion of the site. The soil at the site is characterized as Uf (Urban Land) which is covered by pavement, concrete, buildings, and other structures. A fill stratum is encountered from grade to depths of 12 ft bg. The fill layer consists of sand, silt, gravel, organics (wood/grass), brick, asphalt, and rubber. A layer of clay and silt were encountered beneath the fill between 7 and 13 ft bg. Sand is present in the layer of clay and silt, but content varied across the site. Between approximately 13 and 25.5 ft bg, a sand layer was encountered. The sand stratum consisted of brown, medium to coarse sand, little to some silt, and trace amounts of gravel. During geophysical investigations of the site, bedrock was encountered from approximately 13 to 40 ft bg. The depth of bedrock corresponded to the approximate elevations of the site.
Env Problem: Nature and extent of contamination: Prior to remediation, the primary

WP MALL CLEANERS & GAS STATION SITE (Continued) **S128529085**

contaminants of concern included volatile organic compounds (VOCs), metals, and pesticides in soil, VOCs, semi-VOCs (SVOCs), metals and per- and polyfluoroalkyl substances (PFAS) in groundwater, and VOCs in soil vapor. Impacts were identified in soil across the site to depths up to 40 ft bg. Soil: Upon acceptance into the BCP, the primary contaminants of concern in soil were VOCs, SVOCs, metals, and pesticides. Compounds that exceeded their unrestricted use soil cleanup objectives (USCOs) during the remedial investigation (RI) included (maximum concentrations given): ethylbenzene (37.3 part per million [ppm] compared to the USCO of 1 ppm), xylenes (110 ppm compared to the USCO of 0.26 ppm), benzo(a)anthracene (1.5 ppm compared to the USCO of 1 ppm), benzo(a)pyrene (1.63 ppm compared to the USCO of 1 ppm), benzo(b)fluoranthene (2.67 ppm compared to the USCO of 1 ppm), benzo(k)fluoranthene (0.972 ppm compared to the USCO of 0.8 ppm), chrysene (1.68 ppm compared to the USCO of 1 ppm), dibenzo(a,h)anthracene (0.399 ppm compared to the USCO of 0.33 ppm), indeno(1,2,3 c,d)pyrene (1.57 ppm compared to the USCO of 0.5 ppm), arsenic (26.4 ppm compared to the USCO of 13 ppm), barium (1,100 ppm compared to the USCO of 350 ppm), chromium (120 ppm compared to the USCO of 30 ppm), copper (83.9 ppm compared to the USCO of 50 ppm), lead (3,120 ppm compared to the USCO of 63 ppm), manganese (3,320 ppm compared to the USCO of 1,600 ppm), mercury (0.97 ppm compared to the USCO of 0.18 ppm), nickel (75.5 ppm compared to the USCO of 30 ppm), selenium (6.5 ppm compared to the USCO of 3.9 ppm), silver (4.3 ppm compared to the USCO of 2 ppm), zinc (693 ppm compared to the USCO of 109 ppm), dieldrin (0.007 ppm compared to the USCO of 0.005 ppm), 4,4 DDD (0.103 ppm compared to the USCO of 0.0033 ppm), 4,4 DDE (0.0512 ppm compared to 0.0033 ppm), and 4,4 DDT (0.06 ppm compared to the USCO of 0.0033 ppm). Following remediation, all soil above USCOs have been removed and disposed of off-site. A total of 146,398 tons of contaminated soil was excavated and removed from the site. Groundwater: Remedial investigation groundwater sampling, conducted in November 2022, indicated impacts of VOCs, SVOCs, metals (filtered), and PFAS in exceedance of New York Codes, Rules and Regulations Title 6 (6 NYCRR) and guidance documents found in the Division of Water Technical and Operational Guidance Series (TOGs) Standards, Criteria and Guidance Values (SCGs), including, but not limited to: benzene (3.2 parts per billion [ppb] compared to the SCG of 1 ppb), toluene (18.1 ppb compared to the SCG of 5 ppb), ethylbenzene (632 ppb compared to the SCG of 5 ppb), isopropylbenzene (80.3 ppb compared to the SCG of 5 ppb), xylenes (1,670 ppb compared to the SCG of 5 ppb), benzo(a)anthracene (4.1 ppb compared to the SCG of 0.002 ppb), benzo(a)pyrene (4.4 ppb compared to the SCG of non detect), benzo(b)fluoranthene (5.8 ppb compared to the SCG of 0.002 ppb), benzo (k)fluoranthene (2.3 ppb compared to the SCG of 0.002 ppb), chrysene (3.8 ppb compared to the SCG of 0.002 ppb), ideno(1,2,3 cd)pyrene (0.18 ppb compared to the SCG of 0.002 ppb), indeno(1,2,3 c,d)pyrene (6.2 ppb compared to the SCG of 0.002 ppb), 2,4 dimethylphenol (11.5 ppb compared to the SCG of 1 ppb), pentachlorophenol (5.3 ppb compared to the SCG of 1 ppb), naphthalene (25.1 ppb compared to the SCG of 10 ppb), antimony (41.3 ppb compared to the SCG of 3 ppb), arsenic (44.5 ppb compared to the SCG of 25 ppb), cadmium (45.4 ppb compared to the SCG of 5 ppb), chromium (483 ppb compared to the SCG of 50 ppb), iron (50,700 ppb compared to the SCG of 300 ppb), lead (307 ppb compared to the SCG of 50 ppb), manganese (20,400 ppb compared to the SCG of 300 ppb), selenium (45.3 ppb compared to the SCG of 10 ppb), sodium (1,670,000 ppb compared to

WP MALL CLEANERS & GAS STATION SITE (Continued) **S128529085**

the SCG of 20,000 ppb), PFOS (152 parts per trillion [ppt] compared to the SCG of 2.7 ppt) and PFOA (71.2 ppt compared to the SCG of 6.7 ppt). Groundwater samples were collected from three (3) monitoring wells in the southern portion of the site for VOC analysis in April 2023. Those results indicated methyl tert butyl ether (MTBE) concentrations above its SCG (10 ppb), at a maximum concentration of 220 ppb. No other VOCs were detected above SCGs during that sampling event. Groundwater concentrations of VOCs and PFAS remain above SCGs. Soil Vapor: Prior to remediation, soil vapor samples were collected. No indoor air samples were collected since the on-site building was being demolished. During the Phase II site investigation, trichloroethylene (TCE) was detected in soil vapor at a maximum concentration of 13 micrograms per cubic meter (g/m3). During the remedial investigation, TCE was detected at a maximum concentration of 0.97 g/m3. This compound was not detected in soil or groundwater above its USCO or SCG. Based on the soil vapor results and the intended use, a post remediation soil vapor intrusion evaluation is required. There are no current exposure concerns since there are no buildings on site. The complete excavation of soil in exceedance of USCOs have removed any potentially impacted soil addressing the potential migration of soil vapor off site.

Health Problem: Remedial actions are complete, and measures are in place to control the potential for coming in contact with residual contamination remaining at the site.
Dump: False
Structure: False
Lagoon: False
Landfill: False
Pond: False
Disp Start: Not reported
Disp Term: Not reported
Lat/Long: Not reported
Dell: Not reported
Record Add: 2022-03-03 17:35:00
Record Upd: 2023-08-24 14:14:00
Updated By: GLWHITE
Own Op: 6
Sub Type: P03
Owner Name: Todd Rechler
Owner Company: Hamilton Green I Partners LLC
Owner Address: 625 RXR Plaza
Owner Addr2: Not reported
Owner City,St,Zip: Uniondale, NY 11556
Owner Country: United States of America
Own Op: Document Repository
Sub Type: NNN
Owner Name: Brian Kenney
Owner Company: White Plains Public Library
Owner Address: 100 Martine Avenue
Owner Addr2: Not reported
Owner City,St,Zip: White Plains, NY 10601
Owner Country: United States of America
Own Op: 1
Sub Type: P03
Owner Name: Todd Rechler
Owner Company: Hamilton Green I Partners LLC
Owner Address: 625 RXR Plaza

WP MALL CLEANERS & GAS STATION SITE (Continued) **S128529085**

Owner Addr2: Not reported
Owner City,St,Zip: Uniondale, NY 11556
Owner Country: United States of America
HW Code: C360221
Waste Type: n-propylbenzene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: perfluorooctanoic acid
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: mercury
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: lead
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: benzo(b)fluoranthene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: naphthalene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: zinc
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: chromium
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: dibenz[a,h]anthracene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: manganese
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: chrysene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: DDT
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: 1,3,5-trimethylbenzene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: isopropylbenzene

WP MALL CLEANERS & GAS STATION SITE (Continued) **S128529085**

Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: benzene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: selenium
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: DDE
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: perfluorooctane sulfonic acid
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: barium
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: nickel
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: ethylbenzene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: antimony
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: dieldrin
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: methyl-tert-butyl ether (MTBE)
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: indeno(1,2,3-cd)pyrene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: toluene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: benzo(a)anthracene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: benzo(a)pyrene
Waste Quantity: UNKNOWN

WP MALL CLEANERS & GAS STATION SITE (Continued) **S128529085**

Waste Code: Not reported
HW Code: C360221
Waste Type: alpha-BHC
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: arsenic
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: pentachlorophenol
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: DDD
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: cadmium
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: xylene (mixed)
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: 1,2,4-trimethylbenzene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: benzo(k)fluoranthene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: copper
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: silver
Waste Quantity: UNKNOWN
Waste Code: Not reported
Crossref ID: 632063045
Cross Ref Type Code: 25
Cross Ref Type: County Recording Identifier
Record Added Date: 2023-12-26 10:05:00
Record Updated: 2023-12-26 10:05:00
Updated By: GLWHITE
Crossref ID: 633423096
Cross Ref Type Code: 25
Cross Ref Type: County Recording Identifier
Record Added Date: 2023-12-26 10:06:00
Record Updated: 2023-12-26 10:06:00
Updated By: GLWHITE
Crossref ID: 1706297
Cross Ref Type Code: 01
Cross Ref Type: Spill No.
Record Added Date: 2022-05-03 14:02:00

WP MALL CLEANERS & GAS STATION SITE (Continued) **S128529085**

Record Updated: 2022-05-03 14:02:00
Updated By: GLWHITE
Crossref ID: C360221-03-22
Cross Ref Type Code: 23
Cross Ref Type: Agreement/Consent Order Number
Record Added Date: 2023-12-20 08:21:00
Record Updated: 2023-12-20 08:21:00
Updated By: GLWHITE

Name: WP MALL CLEANERS & GAS STATION SITE
Address: 250 HAMILTON AVENUE
City,State,Zip: WHITE PLAINS, NY 10601
Site Code: 628108
Control Name: Ground Water Use Restriction
HW Code: C360221
Control Code: 08
Control Type: INST
Dt record added: 12/18/2023
Dt rec updated: 12/29/2023
Updated By: GLWHITE
Site Code: 628108
Site Description: Site Location: The 1.808-acre site is located at 250 Hamilton Avenue, White Plains, Westchester County. The site is located on tax lot 125.67-5-1..1. The site was most recently a portion of the White Plains Mall and associated parking lot. The site is located in a mixed-use commercial and residential neighborhood. Barker Avenue, a restaurant, and a hotel are located north of the site. Cottage Place, a parking lot, a condominium building, and Berkeley College student dormitories are located east of the site. Hamilton Avenue and a New York Power Authority Building are located south of the site. A Brownfield Cleanup Program site (site no. C360177) abuts the west boundary of the site. The site is located approximately 0.35 miles from the Bronx River. It is not located in a flood zone. Site Features: Currently, a multi-story mixed use building is under construction on the site. Current Zoning and Land Use: The site is located in a Transit Development District (TD-1) and is currently being redeveloped as noted above. The surrounding properties include residential and commercial use. Past Use and Investigation of the Site: The site was developed with dwellings and garages prior to 1911. By 1930, multiple businesses operated on-site, including a gypsum partitions business, an electric motors building, a paint store, a plumbing shop, and a candy manufacturer. The candy manufacturer, along with a gasoline station located in the south-eastern portion of the site, are estimated to have been on-site from the 1930s through the 1970s. By 1987, all on-site buildings were demolished and replaced by a parking lot and eventually a portion of the White Plains Mall. A dry-cleaning facility is listed as a White Plains Mall occupant in 2010 and 2011. Use of the site as a candy manufacturer, gasoline station and dry-cleaning operations may have contributed to site contamination. Spill Number 17-06297 was reported September 28, 2017, based on evidence of petroleum contamination in soil and groundwater. Site Geology and Hydrogeology: Based on the United States Geological Survey and Westchester County Geographic Information System, the site lies at elevations ranging from 185 to 200 feet above the National Geodetic Vertical Datum of 1983. Regional topography slopes downward to the west. Groundwater flows in the southwesterly direction. Groundwater depths range from approximately

WP MALL CLEANERS & GAS STATION SITE (Continued) **S128529085**

9 to 24 feet below grade (ft bg). Deeper groundwater depths were found in the eastern portion of the site. The soil at the site is characterized as Uf (Urban Land) which is covered by pavement, concrete, buildings, and other structures. A fill stratum is encountered from grade to depths of 12 ft bg. The fill layer consists of sand, silt, gravel, organics (wood/grass), brick, asphalt, and rubber. A layer of clay and silt were encountered beneath the fill between 7 and 13 ft bg. Sand is present in the layer of clay and silt, but content varied across the site. Between approximately 13 and 25.5 ft bg, a sand layer was encountered. The sand stratum consisted of brown, medium to coarse sand, little to some silt, and trace amounts of gravel. During geophysical investigations of the site, bedrock was encountered from approximately 13 to 40 ft bg. The depth of bedrock corresponded to the approximate elevations of the site.

Env Problem: Nature and extent of contamination: Prior to remediation, the primary contaminants of concern included volatile organic compounds (VOCs), metals, and pesticides in soil, VOCs, semi-VOCs (SVOCs), metals and per- and polyfluoroalkyl substances (PFAS) in groundwater, and VOCs in soil vapor. Impacts were identified in soil across the site to depths up to 40 ft bg. Soil: Upon acceptance into the BCP, the primary contaminants of concern in soil were VOCs, SVOCs, metals, and pesticides. Compounds that exceeded their unrestricted use soil cleanup objectives (USCOs) during the remedial investigation (RI) included (maximum concentrations given): ethylbenzene (37.3 part per million [ppm] compared to the USCO of 1 ppm), xylenes (110 ppm compared to the USCO of 0.26 ppm), benzo(a)anthracene (1.5 ppm compared to the USCO of 1 ppm), benzo(a)pyrene (1.63 ppm compared to the USCO of 1 ppm), benzo(b)fluoranthene (2.67 ppm compared to the USCO of 1 ppm), benzo(k)fluoranthene (0.972 ppm compared to the USCO of 0.8 ppm), chrysene (1.68 ppm compared to the USCO of 1 ppm), dibenzo(a,h)anthracene (0.399 ppm compared to the USCO of 0.33 ppm), indeno(1,2,3 c,d)pyrene (1.57 ppm compared to the USCO of 0.5 ppm), arsenic (26.4 ppm compared to the USCO of 13 ppm), barium (1,100 ppm compared to the USCO of 350 ppm), chromium (120 ppm compared to the USCO of 30 ppm), copper (83.9 ppm compared to the USCO of 50 ppm), lead (3,120 ppm compared to the USCO of 63 ppm), manganese (3,320 ppm compared to the USCO of 1,600 ppm), mercury (0.97 ppm compared to the USCO of 0.18 ppm), nickel (75.5 ppm compared to the USCO of 30 ppm), selenium (6.5 ppm compared to the USCO of 3.9 ppm), silver (4.3 ppm compared to the USCO of 2 ppm), zinc (693 ppm compared to the USCO of 109 ppm), dieldrin (0.007 ppm compared to the USCO of 0.005 ppm), 4,4 DDD (0.103 ppm compared to the USCO of 0.0033 ppm), 4,4 DDE (0.0512 ppm compared to 0.0033 ppm), and 4,4 DDT (0.06 ppm compared to the USCO of 0.0033 ppm). Following remediation, all soil above USCOs have been removed and disposed of off-site. A total of 146,398 tons of contaminated soil was excavated and removed from the site. Groundwater: Remedial investigation groundwater sampling, conducted in November 2022, indicated impacts of VOCs, SVOCs, metals (filtered), and PFAS in exceedance of New York Codes, Rules and Regulations Title 6 (6 NYCRR) and guidance documents found in the Division of Water Technical and Operational Guidance Series (TOGs) Standards, Criteria and Guidance Values (SCGs), including, but not limited to: benzene (3.2 parts per billion [ppb] compared to the SCG of 1 ppb), toluene (18.1 ppb compared to the SCG of 5 ppb), ethylbenzene (632 ppb compared to the SCG of 5 ppb), isopropylbenzene (80.3 ppb compared to the SCG of 5 ppb), xylenes (1,670 ppb compared

WP MALL CLEANERS & GAS STATION SITE (Continued) **S128529085**

to the SCG of 5 ppb), benzo(a)anthracene (4.1 ppb compared to the SCG of 0.002 ppb), benzo(a)pyrene (4.4 ppb compared to the SCG of non detect), benzo(b)fluoranthene (5.8 ppb compared to the SCG of 0.002 ppb), benzo (k)fluoranthene (2.3 ppb compared to the SCG of 0.002 ppb), chrysene (3.8 ppb compared to the SCG of 0.002 ppb), ideno(1,2,3 cd)pyrene (0.18 ppb compared to the SCG of 0.002 ppb), indeno(1,2,3 c,d)pyrene (6.2 ppb compared to the SCG of 0.002 ppb), 2,4 dimethylphenol (11.5 ppb compared to the SCG of 1 ppb), pentachlorophenol (5.3 ppb compared to the SCG of 1 ppb), naphthalene (25.1 ppb compared to the SCG of 10 ppb), antimony (41.3 ppb compared to the SCG of 3 ppb), arsenic (44.5 ppb compared to the SCG of 25 ppb), cadmium (45.4 ppb compared to the SCG of 5 ppb), chromium (483 ppb compared to the SCG of 50 ppb), iron (50,700 ppb compared to the SCG of 300 ppb), lead (307 ppb compared to the SCG of 50 ppb), manganese (20,400 ppb compared to the SCG of 300 ppb), selenium (45.3 ppb compared to the SCG of 10 ppb), sodium (1,670,000 ppb compared to the SCG of 20,000 ppb), PFOS (152 parts per trillion [ppt] compared to the SCG of 2.7 ppt) and PFOA (71.2 ppt compared to the SCG of 6.7 ppt). Groundwater samples were collected from three (3) monitoring wells in the southern portion of the site for VOC analysis in April 2023. Those results indicated methyl tert butyl ether (MTBE) concentrations above its SCG (10 ppb), at a maximum concentration of 220 ppb. No other VOCs were detected above SCGs during that sampling event. Groundwater concentrations of VOCs and PFAS remain above SCGs. Soil Vapor: Prior to remediation, soil vapor samples were collected. No indoor air samples were collected since the on-site building was being demolished. During the Phase II site investigation, trichloroethylene (TCE) was detected in soil vapor at a maximum concentration of 13 micrograms per cubic meter (g/m3). During the remedial investigation, TCE was detected at a maximum concentration of 0.97 g/m3. This compound was not detected in soil or groundwater above its USCO or SCG. Based on the soil vapor results and the intended use, a post remediation soil vapor intrusion evaluation is required. There are no current exposure concerns since there are no buildings on site. The complete excavation of soil in exceedance of USCOs have removed any potentially impacted soil addressing the potential migration of soil vapor off site.

Health Problem: Remedial actions are complete, and measures are in place to control the potential for coming in contact with residual contamination remaining at the site.
Dump: False
Structure: False
Lagoon: False
Landfill: False
Pond: False
Disp Start: Not reported
Disp Term: Not reported
Lat/Long: Not reported
Dell: Not reported
Record Add: 2022-03-03 17:35:00
Record Upd: 2023-08-24 14:14:00
Updated By: GLWHITE
Own Op: 6
Sub Type: P03
Owner Name: Todd Rechler
Owner Company: Hamilton Green I Partners LLC
Owner Address: 625 RXR Plaza

WP MALL CLEANERS & GAS STATION SITE (Continued) **S128529085**

Owner Addr2: Not reported
Owner City,St,Zip: Uniondale, NY 11556
Owner Country: United States of America
Own Op: Document Repository
Sub Type: NNN
Owner Name: Brian Kenney
Owner Company: White Plains Public Library
Owner Address: 100 Martine Avenue
Owner Addr2: Not reported
Owner City,St,Zip: White Plains, NY 10601
Owner Country: United States of America
Own Op: 1
Sub Type: P03
Owner Name: Todd Rechler
Owner Company: Hamilton Green I Partners LLC
Owner Address: 625 RXR Plaza
Owner Addr2: Not reported
Owner City,St,Zip: Uniondale, NY 11556
Owner Country: United States of America
HW Code: C360221
Waste Type: n-propylbenzene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: perfluorooctanoic acid
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: mercury
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: lead
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: benzo(b)fluoranthene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: naphthalene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: zinc
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: chromium
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: dibenz[a,h]anthracene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: manganese

WP MALL CLEANERS & GAS STATION SITE (Continued) **S128529085**

Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: chrysene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: DDT
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: 1,3,5-trimethylbenzene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: isopropylbenzene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: benzene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: selenium
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: DDE
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: perfluorooctane sulfonic acid
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: barium
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: nickel
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: ethylbenzene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: antimony
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: dieldrin
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: methyl-tert-butyl ether (MTBE)
Waste Quantity: UNKNOWN

WP MALL CLEANERS & GAS STATION SITE (Continued) **S128529085**

Waste Code: Not reported
HW Code: C360221
Waste Type: indeno(1,2,3-cd)pyrene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: toluene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: benzo(a)anthracene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: benzo(a)pyrene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: alpha-BHC
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: arsenic
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: pentachlorophenol
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: DDD
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: cadmium
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: xylene (mixed)
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: 1,2,4-trimethylbenzene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: benzo(k)fluoranthene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: copper
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: silver
Waste Quantity: UNKNOWN
Waste Code: Not reported

WP MALL CLEANERS & GAS STATION SITE (Continued) **S128529085**

Crossref ID: 632063045
Cross Ref Type Code: 25
Cross Ref Type: County Recording Identifier
Record Added Date: 2023-12-26 10:05:00
Record Updated: 2023-12-26 10:05:00
Updated By: GLWHITE
Crossref ID: 633423096
Cross Ref Type Code: 25
Cross Ref Type: County Recording Identifier
Record Added Date: 2023-12-26 10:06:00
Record Updated: 2023-12-26 10:06:00
Updated By: GLWHITE
Crossref ID: 1706297
Cross Ref Type Code: 01
Cross Ref Type: Spill No.
Record Added Date: 2022-05-03 14:02:00
Record Updated: 2022-05-03 14:02:00
Updated By: GLWHITE
Crossref ID: C360221-03-22
Cross Ref Type Code: 23
Cross Ref Type: Agreement/Consent Order Number
Record Added Date: 2023-12-20 08:21:00
Record Updated: 2023-12-20 08:21:00
Updated By: GLWHITE

Name: WP MALL CLEANERS & GAS STATION SITE
Address: 250 HAMILTON AVENUE
City,State,Zip: WHITE PLAINS, NY 10601
Site Code: 628108
Control Name: Environmental Easement
HW Code: C360221
Control Code: J
Control Type: INST
Dt record added: 12/18/2023
Dt rec updated: 12/29/2023
Updated By: GLWHITE
Site Code: 628108
Site Description: Site Location: The 1.808-acre site is located at 250 Hamilton Avenue, White Plains, Westchester County. The site is located on tax lot 125.67-5-1..1. The site was most recently a portion of the White Plains Mall and associated parking lot. The site is located in a mixed-use commercial and residential neighborhood. Barker Avenue, a restaurant, and a hotel are located north of the site. Cottage Place, a parking lot, a condominium building, and Berkeley College student dormitories are located east of the site. Hamilton Avenue and a New York Power Authority Building are located south of the site. A Brownfield Cleanup Program site (site no. C360177) abuts the west boundary of the site. The site is located approximately 0.35 miles from the Bronx River. It is not located in a flood zone. Site Features: Currently, a multi-story mixed use building is under construction on the site. Current Zoning and Land Use: The site is located in a Transit Development District (TD-1) and is currently being redeveloped as noted above. The surrounding properties include residential and commercial use. Past Use and Investigation of the Site: The site was developed with dwellings and garages prior to 1911. By 1930, multiple businesses operated on-site, including a gypsum partitions business, an electric motors building, a paint

WP MALL CLEANERS & GAS STATION SITE (Continued) **S128529085**

store, a plumbing shop, and a candy manufacturer. The candy manufacturer, along with a gasoline station located in the south-eastern portion of the site, are estimated to have been on-site from the 1930s through the 1970s. By 1987, all on-site buildings were demolished and replaced by a parking lot and eventually a portion of the White Plains Mall. A dry-cleaning facility is listed as a White Plains Mall occupant in 2010 and 2011. Use of the site as a candy manufacturer, gasoline station and dry-cleaning operations may have contributed to site contamination. Spill Number 17-06297 was reported September 28, 2017, based on evidence of petroleum contamination in soil and groundwater. Site Geology and Hydrogeology: Based on the United States Geological Survey and Westchester County Geographic Information System, the site lies at elevations ranging from 185 to 200 feet above the National Geodetic Vertical Datum of 1983. Regional topography slopes downward to the west. Groundwater flows in the southwesterly direction. Groundwater depths range from approximately 9 to 24 feet below grade (ft bg). Deeper groundwater depths were found in the eastern portion of the site. The soil at the site is characterized as Uf (Urban Land) which is covered by pavement, concrete, buildings, and other structures. A fill stratum is encountered from grade to depths of 12 ft bg. The fill layer consists of sand, silt, gravel, organics (wood/grass), brick, asphalt, and rubber. A layer of clay and silt were encountered beneath the fill between 7 and 13 ft bg. Sand is present in the layer of clay and silt, but content varied across the site. Between approximately 13 and 25.5 ft bg, a sand layer was encountered. The sand stratum consisted of brown, medium to coarse sand, little to some silt, and trace amounts of gravel. During geophysical investigations of the site, bedrock was encountered from approximately 13 to 40 ft bg. The depth of bedrock corresponded to the approximate elevations of the site.

Env Problem: Nature and extent of contamination: Prior to remediation, the primary contaminants of concern included volatile organic compounds (VOCs), metals, and pesticides in soil, VOCs, semi-VOCs (SVOCs), metals and per- and polyfluoroalkyl substances (PFAS) in groundwater, and VOCs in soil vapor. Impacts were identified in soil across the site to depths up to 40 ft bg. Soil: Upon acceptance into the BCP, the primary contaminants of concern in soil were VOCs, SVOCs, metals, and pesticides. Compounds that exceeded their unrestricted use soil cleanup objectives (USCOs) during the remedial investigation (RI) included (maximum concentrations given): ethylbenzene (37.3 part per million [ppm] compared to the USCO of 1 ppm), xylenes (110 ppm compared to the USCO of 0.26 ppm), benzo(a)anthracene (1.5 ppm compared to the USCO of 1 ppm), benzo(a)pyrene (1.63 ppm compared to the USCO of 1 ppm), benzo(b)fluoranthene (2.67 ppm compared to the USCO of 1 ppm), benzo(k)fluoranthene (0.972 ppm compared to the USCO of 0.8 ppm), chrysene (1.68 ppm compared to the USCO of 1 ppm), dibenzo(a,h)anthracene (0.399 ppm compared to the USCO of 0.33 ppm), indeno(1,2,3 c,d)pyrene (1.57 ppm compared to the USCO of 0.5 ppm), arsenic (26.4 ppm compared to the USCO of 13 ppm), barium (1,100 ppm compared to the USCO of 350 ppm), chromium (120 ppm compared to the USCO of 30 ppm), copper (83.9 ppm compared to the USCO of 50 ppm), lead (3,120 ppm compared to the USCO of 63 ppm), manganese (3,320 ppm compared to the USCO of 1,600 ppm), mercury (0.97 ppm compared to the USCO of 0.18 ppm), nickel (75.5 ppm compared to the USCO of 30 ppm), selenium (6.5 ppm compared to the USCO of 3.9 ppm), silver (4.3 ppm compared to the USCO of 2 ppm), zinc (693 ppm compared to the USCO of

WP MALL CLEANERS & GAS STATION SITE (Continued) **S128529085**

109 ppm), dieldrin (0.007 ppm compared to the USCO of 0.005 ppm), 4,4 DDD (0.103 ppm compared to the USCO of 0.0033 ppm), 4,4 DDE (0.0512 ppm compared to 0.0033 ppm), and 4,4 DDT (0.06 ppm compared to the USCO of 0.0033 ppm). Following remediation, all soil above USCOs have been removed and disposed of off-site. A total of 146,398 tons of contaminated soil was excavated and removed from the site. Groundwater: Remedial investigation groundwater sampling, conducted in November 2022, indicated impacts of VOCs, SVOCs, metals (filtered), and PFAS in exceedance of New York Codes, Rules and Regulations Title 6 (6 NYCRR) and guidance documents found in the Division of Water Technical and Operational Guidance Series (TOGs) Standards, Criteria and Guidance Values (SCGs), including, but not limited to: benzene (3.2 parts per billion [ppb] compared to the SCG of 1 ppb), toluene (18.1 ppb compared to the SCG of 5 ppb), ethylbenzene (632 ppb compared to the SCG of 5 ppb), isopropylbenzene (80.3 ppb compared to the SCG of 5 ppb), xylenes (1,670 ppb compared to the SCG of 5 ppb), benzo(a)anthracene (4.1 ppb compared to the SCG of 0.002 ppb), benzo(a)pyrene (4.4 ppb compared to the SCG of non detect), benzo(b)fluoranthene (5.8 ppb compared to the SCG of 0.002 ppb), benzo (k)fluoranthene (2.3 ppb compared to the SCG of 0.002 ppb), chrysene (3.8 ppb compared to the SCG of 0.002 ppb), ideno(1,2,3 cd)pyrene (0.18 ppb compared to the SCG of 0.002 ppb), indeno(1,2,3 c,d)pyrene (6.2 ppb compared to the SCG of 0.002 ppb), 2,4 dimethylphenol (11.5 ppb compared to the SCG of 1 ppb), pentachlorophenol (5.3 ppb compared to the SCG of 1 ppb), naphthalene (25.1 ppb compared to the SCG of 10 ppb), antimony (41.3 ppb compared to the SCG of 3 ppb), arsenic (44.5 ppb compared to the SCG of 25 ppb), cadmium (45.4 ppb compared to the SCG of 5 ppb), chromium (483 ppb compared to the SCG of 50 ppb), iron (50,700 ppb compared to the SCG of 300 ppb), lead (307 ppb compared to the SCG of 50 ppb), manganese (20,400 ppb compared to the SCG of 300 ppb), selenium (45.3 ppb compared to the SCG of 10 ppb), sodium (1,670,000 ppb compared to the SCG of 20,000 ppb), PFOS (152 parts per trillion [ppt] compared to the SCG of 2.7 ppt) and PFOA (71.2 ppt compared to the SCG of 6.7 ppt). Groundwater samples were collected from three (3) monitoring wells in the southern portion of the site for VOC analysis in April 2023. Those results indicated methyl tert butyl ether (MTBE) concentrations above its SCG (10 ppb), at a maximum concentration of 220 ppb. No other VOCs were detected above SCGs during that sampling event. Groundwater concentrations of VOCs and PFAS remain above SCGs. Soil Vapor: Prior to remediation, soil vapor samples were collected. No indoor air samples were collected since the on-site building was being demolished. During the Phase II site investigation, trichloroethylene (TCE) was detected in soil vapor at a maximum concentration of 13 micrograms per cubic meter (g/m3). During the remedial investigation, TCE was detected at a maximum concentration of 0.97 g/m3. This compound was not detected in soil or groundwater above its USCO or SCG. Based on the soil vapor results and the intended use, a post remediation soil vapor intrusion evaluation is required. There are no current exposure concerns since there are no buildings on site. The complete excavation of soil in exceedance of USCOs have removed any potentially impacted soil addressing the potential migration of soil vapor off site.

Health Problem: Remedial actions are complete, and measures are in place to control the potential for coming in contact with residual contamination remaining at the site.

Dump: False

WP MALL CLEANERS & GAS STATION SITE (Continued) **S128529085**

Structure: False
Lagoon: False
Landfill: False
Pond: False
Disp Start: Not reported
Disp Term: Not reported
Lat/Long: Not reported
Dell: Not reported
Record Add: 2022-03-03 17:35:00
Record Upd: 2023-08-24 14:14:00
Updated By: GLWHITE
Own Op: 6
Sub Type: P03
Owner Name: Todd Rechler
Owner Company: Hamilton Green I Partners LLC
Owner Address: 625 RXR Plaza
Owner Addr2: Not reported
Owner City,St,Zip: Uniondale, NY 11556
Owner Country: United States of America
Own Op: Document Repository
Sub Type: NNN
Owner Name: Brian Kenney
Owner Company: White Plains Public Library
Owner Address: 100 Martine Avenue
Owner Addr2: Not reported
Owner City,St,Zip: White Plains, NY 10601
Owner Country: United States of America
Own Op: 1
Sub Type: P03
Owner Name: Todd Rechler
Owner Company: Hamilton Green I Partners LLC
Owner Address: 625 RXR Plaza
Owner Addr2: Not reported
Owner City,St,Zip: Uniondale, NY 11556
Owner Country: United States of America
HW Code: C360221
Waste Type: n-propylbenzene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: perfluorooctanoic acid
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: mercury
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: lead
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: benzo(b)fluoranthene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: naphthalene

WP MALL CLEANERS & GAS STATION SITE (Continued) **S128529085**

Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: zinc
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: chromium
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: dibenz[a,h]anthracene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: manganese
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: chrysene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: DDT
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: 1,3,5-trimethylbenzene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: isopropylbenzene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: benzene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: selenium
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: DDE
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: perfluorooctane sulfonic acid
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: barium
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: nickel
Waste Quantity: UNKNOWN

WP MALL CLEANERS & GAS STATION SITE (Continued) **S128529085**

Waste Code: Not reported
HW Code: C360221
Waste Type: ethylbenzene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: antimony
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: dieldrin
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: methyl-tert-butyl ether (MTBE)
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: indeno(1,2,3-cd)pyrene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: toluene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: benzo(a)anthracene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: benzo(a)pyrene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: alpha-BHC
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: arsenic
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: pentachlorophenol
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: DDD
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: cadmium
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: xylene (mixed)
Waste Quantity: UNKNOWN
Waste Code: Not reported

WP MALL CLEANERS & GAS STATION SITE (Continued) **S128529085**

HW Code: C360221
Waste Type: 1,2,4-trimethylbenzene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: benzo(k)fluoranthene
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: copper
Waste Quantity: UNKNOWN
Waste Code: Not reported
HW Code: C360221
Waste Type: silver
Waste Quantity: UNKNOWN
Waste Code: Not reported
Crossref ID: 632063045
Cross Ref Type Code: 25
Cross Ref Type: County Recording Identifier
Record Added Date: 2023-12-26 10:05:00
Record Updated: 2023-12-26 10:05:00
Updated By: GLWHITE
Crossref ID: 633423096
Cross Ref Type Code: 25
Cross Ref Type: County Recording Identifier
Record Added Date: 2023-12-26 10:06:00
Record Updated: 2023-12-26 10:06:00
Updated By: GLWHITE
Crossref ID: 1706297
Cross Ref Type Code: 01
Cross Ref Type: Spill No.
Record Added Date: 2022-05-03 14:02:00
Record Updated: 2022-05-03 14:02:00
Updated By: GLWHITE
Crossref ID: C360221-03-22
Cross Ref Type Code: 23
Cross Ref Type: Agreement/Consent Order Number
Record Added Date: 2023-12-20 08:21:00
Record Updated: 2023-12-20 08:21:00
Updated By: GLWHITE

BROWNFIELDS:

Name:	WP MALL CLEANERS & GAS STATION SITE
Address:	250 HAMILTON AVENUE
City,State,Zip:	WHITE PLAINS, NY 10601
Program:	BCP
Site Code:	628108
Acres:	1.808
HW Code:	C360221
SWIS:	6017
Town:	White Plains (c)
Record Added Date:	11/03/2021
Record Updated Date:	12/29/2023
Update By:	AMSERVIS
Site Description:	Site Location: The 1.808-acre site is located at 250 Hamilton Avenue, White Plains, Westchester County. The site is located on tax lot 125.67-5-1..1. The site was most recently a portion of the White

WP MALL CLEANERS & GAS STATION SITE (Continued) **S128529085**

Plains Mall and associated parking lot. The site is located in a mixed-use commercial and residential neighborhood. Barker Avenue, a restaurant, and a hotel are located north of the site. Cottage Place, a parking lot, a condominium building, and Berkeley College student dormitories are located east of the site. Hamilton Avenue and a New York Power Authority Building are located south of the site. A Brownfield Cleanup Program site (site no. C360177) abuts the west boundary of the site. The site is located approximately 0.35 miles from the Bronx River. It is not located in a flood zone. Site Features: Currently, a multi-story mixed use building is under construction on the site. Current Zoning and Land Use: The site is located in a Transit Development District (TD-1) and is currently being redeveloped as noted above. The surrounding properties include residential and commercial use. Past Use and Investigation of the Site: The site was developed with dwellings and garages prior to 1911. By 1930, multiple businesses operated on-site, including a gypsum partitions business, an electric motors building, a paint store, a plumbing shop, and a candy manufacturer. The candy manufacturer, along with a gasoline station located in the south-eastern portion of the site, are estimated to have been on-site from the 1930s through the 1970s. By 1987, all on-site buildings were demolished and replaced by a parking lot and eventually a portion of the White Plains Mall. A dry-cleaning facility is listed as a White Plains Mall occupant in 2010 and 2011. Use of the site as a candy manufacturer, gasoline station and dry-cleaning operations may have contributed to site contamination. Spill Number 17-06297 was reported September 28, 2017, based on evidence of petroleum contamination in soil and groundwater. Site Geology and Hydrogeology: Based on the United States Geological Survey and Westchester County Geographic Information System, the site lies at elevations ranging from 185 to 200 feet above the National Geodetic Vertical Datum of 1983. Regional topography slopes downward to the west. Groundwater flows in the southwesterly direction. Groundwater depths range from approximately 9 to 24 feet below grade (ft bg). Deeper groundwater depths were found in the eastern portion of the site. The soil at the site is characterized as Uf (Urban Land) which is covered by pavement, concrete, buildings, and other structures. A fill stratum is encountered from grade to depths of 12 ft bg. The fill layer consists of sand, silt, gravel, organics (wood/grass), brick, asphalt, and rubber. A layer of clay and silt were encountered beneath the fill between 7 and 13 ft bg. Sand is present in the layer of clay and silt, but content varied across the site. Between approximately 13 and 25.5 ft bg, a sand layer was encountered. The sand stratum consisted of brown, medium to coarse sand, little to some silt, and trace amounts of gravel. During geophysical investigations of the site, bedrock was encountered from approximately 13 to 40 ft bg. The depth of bedrock corresponded to the approximate elevations of the site.

Env Problem:

Nature and extent of contamination: Prior to remediation, the primary contaminants of concern included volatile organic compounds (VOCs), metals, and pesticides in soil, VOCs, semi-VOCs (SVOCs), metals and per- and polyfluoroalkyl substances (PFAS) in groundwater, and VOCs in soil vapor. Impacts were identified in soil across the site to depths up to 40 ft bg. Soil: Upon acceptance into the BCP, the primary contaminants of concern in soil were VOCs, SVOCs, metals, and pesticides. Compounds that exceeded their unrestricted use soil cleanup objectives (USCOs) during the remedial investigation (RI)

WP MALL CLEANERS & GAS STATION SITE (Continued) **S128529085**

included (maximum concentrations given): ethylbenzene (37.3 part per million [ppm] compared to the USCO of 1 ppm), xylenes (110 ppm compared to the USCO of 0.26 ppm), benzo(a)anthracene (1.5 ppm compared to the USCO of 1 ppm), benzo(a)pyrene (1.63 ppm compared to the USCO of 1 ppm), benzo(b)fluoranthene (2.67 ppm compared to the USCO of 1 ppm), benzo(k)fluoranthene (0.972 ppm compared to the USCO of 0.8 ppm), chrysene (1.68 ppm compared to the USCO of 1 ppm), dibenzo(a,h)anthracene (0.399 ppm compared to the USCO of 0.33 ppm), indeno(1,2,3 c,d)pyrene (1.57 ppm compared to the USCO of 0.5 ppm), arsenic (26.4 ppm compared to the USCO of 13 ppm), barium (1,100 ppm compared to the USCO of 350 ppm), chromium (120 ppm compared to the USCO of 30 ppm), copper (83.9 ppm compared to the USCO of 50 ppm), lead (3,120 ppm compared to the USCO of 63 ppm), manganese (3,320 ppm compared to the USCO of 1,600 ppm), mercury (0.97 ppm compared to the USCO of 0.18 ppm), nickel (75.5 ppm compared to the USCO of 30 ppm), selenium (6.5 ppm compared to the USCO of 3.9 ppm), silver (4.3 ppm compared to the USCO of 2 ppm), zinc (693 ppm compared to the USCO of 109 ppm), dieldrin (0.007 ppm compared to the USCO of 0.005 ppm), 4,4 DDD (0.103 ppm compared to the USCO of 0.0033 ppm), 4,4 DDE (0.0512 ppm compared to 0.0033 ppm), and 4,4 DDT (0.06 ppm compared to the USCO of 0.0033 ppm). Following remediation, all soil above USCOs have been removed and disposed of off-site. A total of 146,398 tons of contaminated soil was excavated and removed from the site.
Groundwater: Remedial investigation groundwater sampling, conducted in November 2022, indicated impacts of VOCs, SVOCs, metals (filtered), and PFAS in exceedance of New York Codes, Rules and Regulations Title 6 (6 NYCRR) and guidance documents found in the Division of Water Technical and Operational Guidance Series (TOGs) Standards, Criteria and Guidance Values (SCGs), including, but not limited to: benzene (3.2 parts per billion [ppb] compared to the SCG of 1 ppb), toluene (18.1 ppb compared to the SCG of 5 ppb), ethylbenzene (632 ppb compared to the SCG of 5 ppb), isopropylbenzene (80.3 ppb compared to the SCG of 5 ppb), xylenes (1,670 ppb compared to the SCG of 5 ppb), benzo(a)anthracene (4.1 ppb compared to the SCG of 0.002 ppb), benzo(a)pyrene (4.4 ppb compared to the SCG of non detect), benzo(b)fluoranthene (5.8 ppb compared to the SCG of 0.002 ppb), benzo (k)fluoranthene (2.3 ppb compared to the SCG of 0.002 ppb), chrysene (3.8 ppb compared to the SCG of 0.002 ppb), ideno(1,2,3 cd)pyrene (0.18 ppb compared to the SCG of 0.002 ppb), indeno(1,2,3 c,d)pyrene (6.2 ppb compared to the SCG of 0.002 ppb), 2,4 dimethylphenol (11.5 ppb compared to the SCG of 1 ppb), pentachlorophenol (5.3 ppb compared to the SCG of 1 ppb), naphthalene (25.1 ppb compared to the SCG of 10 ppb), antimony (41.3 ppb compared to the SCG of 3 ppb), arsenic (44.5 ppb compared to the SCG of 25 ppb), cadmium (45.4 ppb compared to the SCG of 5 ppb), chromium (483 ppb compared to the SCG of 50 ppb), iron (50,700 ppb compared to the SCG of 300 ppb), lead (307 ppb compared to the SCG of 50 ppb), manganese (20,400 ppb compared to the SCG of 300 ppb), selenium (45.3 ppb compared to the SCG of 10 ppb), sodium (1,670,000 ppb compared to the SCG of 20,000 ppb), PFOS (152 parts per trillion [ppt] compared to the SCG of 2.7 ppt) and PFOA (71.2 ppt compared to the SCG of 6.7 ppt). Groundwater samples were collected from three (3) monitoring wells in the southern portion of the site for VOC analysis in April 2023. Those results indicated methyl tert butyl ether (MTBE) concentrations above its SCG (10 ppb), at a maximum concentration of 220 ppb. No other VOCs were detected above SCGs during that sampling event. Groundwater concentrations of VOCs and PFAS remain above SCGs.

WP MALL CLEANERS & GAS STATION SITE (Continued) **S128529085**

	Soil Vapor: Prior to remediation, soil vapor samples were collected. No indoor air samples were collected since the on-site building was being demolished. During the Phase II site investigation, trichloroethylene (TCE) was detected in soil vapor at a maximum concentration of 13 micrograms per cubic meter (g/m3). During the remedial investigation, TCE was detected at a maximum concentration of 0.97 g/m3. This compound was not detected in soil or groundwater above its USCO or SCG. Based on the soil vapor results and the intended use, a post remediation soil vapor intrusion evaluation is required. There are no current exposure concerns since there are no buildings on site. The complete excavation of soil in exceedance of USCOs have removed any potentially impacted soil addressing the potential migration of soil vapor off site.
Health Problem:	Remedial actions are complete, and measures are in place to control the potential for coming in contact with residual contamination remaining at the site.
Dump:	False
Structure:	False
Lagoon:	False
Landfill:	False
Pond:	False
Disp Start:	Not reported
Disp Term:	Not reported
Lat/Long:	Not reported
Dell:	Not reported
Record Add:	2022-03-03 17:35:00
Record Upd:	2023-08-24 14:14:00
Updated By:	GLWHITE
Own Op:	6
Sub Type:	P03
Owner Name:	Todd Rechler
Owner Company:	Hamilton Green I Partners LLC
Owner Address:	625 RXR Plaza
Owner Addr2:	Not reported
Owner City,St,Zip:	Uniondale, NY 11556
Owner Country:	United States of America
Own Op:	Document Repository
Sub Type:	NNN
Owner Name:	Brian Kenney
Owner Company:	White Plains Public Library
Owner Address:	100 Martine Avenue
Owner Addr2:	Not reported
Owner City,St,Zip:	White Plains, NY 10601
Owner Country:	United States of America
Own Op:	1
Sub Type:	P03
Owner Name:	Todd Rechler
Owner Company:	Hamilton Green I Partners LLC
Owner Address:	625 RXR Plaza
Owner Addr2:	Not reported
Owner City,St,Zip:	Uniondale, NY 11556
Owner Country:	United States of America
HW Code:	C360221
Waste Type:	n-propylbenzene
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360221

WP MALL CLEANERS & GAS STATION SITE (Continued) **S128529085**

Waste Type:	perfluorooctanoic acid
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360221
Waste Type:	mercury
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360221
Waste Type:	lead
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360221
Waste Type:	benzo(b)fluoranthene
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360221
Waste Type:	naphthalene
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360221
Waste Type:	zinc
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360221
Waste Type:	chromium
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360221
Waste Type:	dibenz[a,h]anthracene
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360221
Waste Type:	manganese
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360221
Waste Type:	chrysene
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360221
Waste Type:	DDT
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360221
Waste Type:	1,3,5-trimethylbenzene
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360221
Waste Type:	isopropylbenzene
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360221
Waste Type:	benzene
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360221
Waste Type:	selenium

WP MALL CLEANERS & GAS STATION SITE (Continued) **S128529085**

Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360221
Waste Type:	DDE
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360221
Waste Type:	perfluorooctane sulfonic acid
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360221
Waste Type:	barium
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360221
Waste Type:	nickel
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360221
Waste Type:	ethylbenzene
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360221
Waste Type:	antimony
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360221
Waste Type:	dieldrin
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360221
Waste Type:	methyl-tert-butyl ether (MTBE)
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360221
Waste Type:	indeno(1,2,3-cd)pyrene
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360221
Waste Type:	toluene
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360221
Waste Type:	benzo(a)anthracene
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360221
Waste Type:	benzo(a)pyrene
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360221
Waste Type:	alpha-BHC
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360221
Waste Type:	arsenic
Waste Quantity:	UNKNOWN

WP MALL CLEANERS & GAS STATION SITE (Continued) **S128529085**

Waste Code:	Not reported
HW Code:	C360221
Waste Type:	pentachlorophenol
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360221
Waste Type:	DDD
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360221
Waste Type:	cadmium
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360221
Waste Type:	xylene (mixed)
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360221
Waste Type:	1,2,4-trimethylbenzene
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360221
Waste Type:	benzo(k)fluoranthene
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360221
Waste Type:	copper
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360221
Waste Type:	silver
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
Crossref ID:	632063045
Cross Ref Type Code:	25
Cross Ref Type:	County Recording Identifier
Record Added Date:	2023-12-26 10:05:00
Record Updated:	2023-12-26 10:05:00
Updated By:	GLWHITE
Crossref ID:	633423096
Cross Ref Type Code:	25
Cross Ref Type:	County Recording Identifier
Record Added Date:	2023-12-26 10:06:00
Record Updated:	2023-12-26 10:06:00
Updated By:	GLWHITE
Crossref ID:	1706297
Cross Ref Type Code:	01
Cross Ref Type:	Spill No.
Record Added Date:	2022-05-03 14:02:00
Record Updated:	2022-05-03 14:02:00
Updated By:	GLWHITE
Crossref ID:	C360221-03-22
Cross Ref Type Code:	23
Cross Ref Type:	Agreement/Consent Order Number
Record Added Date:	2023-12-20 08:21:00
Record Updated:	2023-12-20 08:21:00
Updated By:	GLWHITE

WP MALL CLEANERS & GAS STATION SITE (Continued) **S128529085**

PFAS 3:

Name:	WP MALL CLEANERS & GAS STATION SITE
Address:	250 HAMILTON AVENUE
City,State,Zip:	WHITE PLAINS, NY 10601
Site Code:	628108
HW Code:	C360221
Program:	BCP
Class Code:	C
Region:	3
Acres:	1.808
Date Record Added:	11/03/2021
Date Record Updated:	12/29/2023
Water Quantity:	UNKNOWN
Updated By:	AMSERVIS
Site Description:	Site Location: The 1.808-acre site is located at 250 Hamilton Avenue, White Plains, Westchester County. The site is located on tax lot 125.67-5-1..1. The site was most recently a portion of the White Plains Mall and associated parking lot. The site is located in a mixed-use commercial and residential neighborhood. Barker Avenue, a restaurant, and a hotel are located north of the site. Cottage Place, a parking lot, a condominium building, and Berkeley College student dormitories are located east of the site. Hamilton Avenue and a New York Power Authority Building are located south of the site. A Brownfield Cleanup Program site (site no. C360177) abuts the west boundary of the site. The site is located approximately 0.35 miles from the Bronx River. It is not located in a flood zone. Site Features: Currently, a multi-story mixed use building is under construction on the site. Current Zoning and Land Use: The site is located in a Transit Development District (TD-1) and is currently being redeveloped as noted above. The surrounding properties include residential and commercial use. Past Use and Investigation of the Site: The site was developed with dwellings and garages prior to 1911. By 1930, multiple businesses operated on-site, including a gypsum partitions business, an electric motors building, a paint store, a plumbing shop, and a candy manufacturer. The candy manufacturer, along with a gasoline station located in the south-eastern portion of the site, are estimated to have been on-site from the 1930s through the 1970s. By 1987, all on-site buildings were demolished and replaced by a parking lot and eventually a portion of the White Plains Mall. A dry-cleaning facility is listed as a White Plains Mall occupant in 2010 and 2011. Use of the site as a candy manufacturer, gasoline station and dry-cleaning operations may have contributed to site contamination. Spill Number 17-06297 was reported September 28, 2017, based on evidence of petroleum contamination in soil and groundwater. Site Geology and Hydrogeology: Based on the United States Geological Survey and Westchester County Geographic Information System, the site lies at elevations ranging from 185 to 200 feet above the National Geodetic Vertical Datum of 1983. Regional topography slopes downward to the west. Groundwater flows in the southwesterly direction. Groundwater depths range from approximately 9 to 24 feet below grade (ft bg). Deeper groundwater depths were found in the eastern portion of the site. The soil at the site is characterized as Uf (Urban Land) which is covered by pavement, concrete, buildings, and other structures. A fill stratum is encountered from grade to depths of 12 ft bg. The fill layer consists of sand, silt, gravel, organics (wood/grass), brick, asphalt, and rubber. A layer of clay and silt were encountered beneath the fill

WP MALL CLEANERS & GAS STATION SITE (Continued) **S128529085**

between 7 and 13 ft bg. Sand is present in the layer of clay and silt, but content varied across the site. Between approximately 13 and 25.5 ft bg, a sand layer was encountered. The sand stratum consisted of brown, medium to coarse sand, little to some silt, and trace amounts of gravel. During geophysical investigations of the site, bedrock was encountered from approximately 13 to 40 ft bg. The depth of bedrock corresponded to the approximate elevations of the site.

Summary: Remedial actions are complete, and measures are in place to control the potential for coming in contact with residual contamination remaining at the site.

Summary: Nature and extent of contamination: Prior to remediation, the primary contaminants of concern included volatile organic compounds (VOCs), metals, and pesticides in soil, VOCs, semi-VOCs (SVOCs), metals and per- and polyfluoroalkyl substances (PFAS) in groundwater, and VOCs in soil vapor. Impacts were identified in soil across the site to depths up to 40 ft bg. Soil: Upon acceptance into the BCP, the primary contaminants of concern in soil were VOCs, SVOCs, metals, and pesticides. Compounds that exceeded their unrestricted use soil cleanup objectives (USCOs) during the remedial investigation (RI) included (maximum concentrations given): ethylbenzene (37.3 part per million [ppm] compared to the USCO of 1 ppm), xylenes (110 ppm compared to the USCO of 0.26 ppm), benzo(a)anthracene (1.5 ppm compared to the USCO of 1 ppm), benzo(a)pyrene (1.63 ppm compared to the USCO of 1 ppm), benzo(b)fluoranthene (2.67 ppm compared to the USCO of 1 ppm), benzo(k)fluoranthene (0.972 ppm compared to the USCO of 0.8 ppm), chrysene (1.68 ppm compared to the USCO of 1 ppm), dibenzo(a,h)anthracene (0.399 ppm compared to the USCO of 0.33 ppm), indeno(1,2,3 c,d)pyrene (1.57 ppm compared to the USCO of 0.5 ppm), arsenic (26.4 ppm compared to the USCO of 13 ppm), barium (1,100 ppm compared to the USCO of 350 ppm), chromium (120 ppm compared to the USCO of 30 ppm), copper (83.9 ppm compared to the USCO of 50 ppm), lead (3,120 ppm compared to the USCO of 63 ppm), manganese (3,320 ppm compared to the USCO of 1,600 ppm), mercury (0.97 ppm compared to the USCO of 0.18 ppm), nickel (75.5 ppm compared to the USCO of 30 ppm), selenium (6.5 ppm compared to the USCO of 3.9 ppm), silver (4.3 ppm compared to the USCO of 2 ppm), zinc (693 ppm compared to the USCO of 109 ppm), dieldrin (0.007 ppm compared to the USCO of 0.005 ppm), 4,4 DDD (0.103 ppm compared to the USCO of 0.0033 ppm), 4,4 DDE (0.0512 ppm compared to 0.0033 ppm), and 4,4 DDT (0.06 ppm compared to the USCO of 0.0033 ppm). Following remediation, all soil above USCOs have been removed and disposed of off-site. A total of 146,398 tons of contaminated soil was excavated and removed from the site. Groundwater: Remedial investigation groundwater sampling, conducted in November 2022, indicated impacts of VOCs, SVOCs, metals (filtered), and PFAS in exceedance of New York Codes, Rules and Regulations Title 6 (6 NYCRR) and guidance documents found in the Division of Water Technical and Operational Guidance Series (TOGs) Standards, Criteria and Guidance Values (SCGs), including, but not limited to: benzene (3.2 parts per billion [ppb] compared to the SCG of 1 ppb), toluene (18.1 ppb compared to the SCG of 5 ppb), ethylbenzene (632 ppb compared to the SCG of 5 ppb), isopropylbenzene (80.3 ppb compared to the SCG of 5 ppb), xylenes (1,670 ppb compared to the SCG of 5 ppb), benzo(a)anthracene (4.1 ppb compared to the SCG of 0.002 ppb), benzo(a)pyrene (4.4 ppb compared to the SCG of non

WP MALL CLEANERS & GAS STATION SITE (Continued) **S128529085**

detect), benzo(b)fluoranthene (5.8 ppb compared to the SCG of 0.002 ppb), benzo (k)fluoranthene (2.3 ppb compared to the SCG of 0.002 ppb), chrysene (3.8 ppb compared to the SCG of 0.002 ppb), ideno(1,2,3 cd)pyrene (0.18 ppb compared to the SCG of 0.002 ppb), indeno(1,2,3 c,d)pyrene (6.2 ppb compared to the SCG of 0.002 ppb), 2,4 dimethylphenol (11.5 ppb compared to the SCG of 1 ppb), pentachlorophenol (5.3 ppb compared to the SCG of 1 ppb), naphthalene (25.1 ppb compared to the SCG of 10 ppb), antimony (41.3 ppb compared to the SCG of 3 ppb), arsenic (44.5 ppb compared to the SCG of 25 ppb), cadmium (45.4 ppb compared to the SCG of 5 ppb), chromium (483 ppb compared to the SCG of 50 ppb), iron (50,700 ppb compared to the SCG of 300 ppb), lead (307 ppb compared to the SCG of 50 ppb), manganese (20,400 ppb compared to the SCG of 300 ppb), selenium (45.3 ppb compared to the SCG of 10 ppb), sodium (1,670,000 ppb compared to the SCG of 20,000 ppb), PFOS (152 parts per trillion [ppt] compared to the SCG of 2.7 ppt) and PFOA (71.2 ppt compared to the SCG of 6.7 ppt). Groundwater samples were collected from three (3) monitoring wells in the southern portion of the site for VOC analysis in April 2023. Those results indicated methyl tert butyl ether (MTBE) concentrations above its SCG (10 ppb), at a maximum concentration of 220 ppb. No other VOCs were detected above SCGs during that sampling event. Groundwater concentrations of VOCs and PFAS remain above SCGs. Soil Vapor: Prior to remediation, soil vapor samples were collected. No indoor air samples were collected since the on-site building was being demolished. During the Phase II site investigation, trichloroethylene (TCE) was detected in soil vapor at a maximum concentration of 13 micrograms per cubic meter (g/m3). During the remedial investigation, TCE was detected at a maximum concentration of 0.97 g/m3. This compound was not detected in soil or groundwater above its USCO or SCG. Based on the soil vapor results and the intended use, a post remediation soil vapor intrusion evaluation is required. There are no current exposure concerns since there are no buildings on site. The complete excavation of soil in exceedance of USCOs have removed any potentially impacted soil addressing the potential migration of soil vapor off site.

Water Type: perfluorooctanoic acid

PFAS 3:
Water Type: perfluorooctane sulfonic acid

NY MANIFEST:
EPA ID: NYR000258814
Country: USA
Name: Renaissance Env Management Llc - Wp Mall Clears & Gas Station Site
Address: 250 HAMILTON AVE
Address 2: Not reported
City,State,Zip: WHITE PLAINS, NY 10601
Zip 4: Not reported
Location Address 1: 250 HAMILTON AVE
Location Address 2: Not reported
Location City,State,Zip: WHITE PLAINS, NY 10601
Location Zip 4: Not reported
Facility Status: Not reported
Total Tanks: Not reported
Code: BP

WP MALL CLEANERS & GAS STATION SITE (Continued) **S128529085**

Mailing:

Mailing Name:	Renaissance Env Management Llc - Wp Mall Clears & Gas Station Site
Mailing Contact:	Kevin Mcmanus
Mailing Address 1:	250 HAMILTON AVE
Mailing Address 2:	Not reported
Mailing City,State,Zip:	WHITE PLAINS, NY 10601
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	9144033568

P205 **RENAISSANCE ENV MANAGEMENT LLC-WP MALL CLEANERS &** **RCRA NonGen / NLR** **1027533033**
NE **250 HAMILTON AVE** **E MANIFEST** **NYR000258814**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.145 mi.
763 ft. **Site 7 of 8 in cluster P**

Relative:
Higher

Actual:
208 ft.

RCRA Listings:

Date Form Received by Agency:	20230508
Handler Name:	Renaissance Env Management Llc-Wp Mall Cleaners & Gas Station Site
Handler Address:	Hamilton Ave
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYR000258814
Contact Name:	KEVIN MCMANUS
Contact Address:	RENAISSANCE SQUARE 4TH FL
Contact City,State,Zip:	WHITE PLAINS, NY 10601
Contact Telephone:	914-403-3568
Contact Fax:	Not reported
Contact Email:	KMCMANUS@ICAPPELLI.COM
Contact Title:	Not reported
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	2022
Accessibility:	Not reported
Active Site Indicator:	Handler Activities
State District Owner:	Ny
State District:	NYSDEC R3
Mailing Address:	HAMILTON AVE
Mailing City,State,Zip:	WHITE PLAINS, NY 10601
Owner Name:	Hamilton Green 1 Partners Llc
Owner Type:	Private
Operator Name:	Renaissance Env Management Llc
Operator Type:	Private
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	Yes
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No

RENAISSANCE ENV MANAGEMENT LLC-WP MALL CLEANERS & GAS STATIO (Continued) **1027533033**

Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20230508
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Hazardous Waste Summary:

Waste Code:	D008
Waste Description:	Lead

Handler - Owner Operator:

Owner/Operator Indicator:	Operator
Owner/Operator Name:	RENAISSANCE ENV MANAGEMENT LLC
Legal Status:	Private
Date Became Current:	20220901
Date Ended Current:	Not reported
Owner/Operator Address:	7 RENAISSANCE SQUARE 4TH FL
Owner/Operator City,State,Zip:	WHITE PLAINS, NY 10601
Owner/Operator Telephone:	914-406-3568
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported
Owner/Operator Email:	KMCMANUS@ICAPPELLI.COM

Owner/Operator Indicator:	Operator
Owner/Operator Name:	RENAISSANCE ENV MANAGEMENT LLC
Legal Status:	Private
Date Became Current:	20220901
Date Ended Current:	Not reported
Owner/Operator Address:	7 RENAISSANCE SQUARE 4TH FL
Owner/Operator City,State,Zip:	WHITE PLAINS, NY 10601
Owner/Operator Telephone:	914-406-3568
Owner/Operator Telephone Ext:	Not reported

RENAISSANCE ENV MANAGEMENT LLC-WP MALL CLEANERS & GAS STATIO (Continued) **1027533033**

Owner/Operator Fax: Not reported
Owner/Operator Email: KMCMANUS@ICAPPELLI.COM

Owner/Operator Indicator: Owner
Owner/Operator Name: HAMILTON GREEN 1 PARTNERS LLC
Legal Status: Private
Date Became Current: 20221101
Date Ended Current: Not reported
Owner/Operator Address: 625 RXR PLAZA
Owner/Operator City,State,Zip: UNIONDALE, NY 11553
Owner/Operator Telephone: 516-506-6600
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: TODD@RXR.COM

Owner/Operator Indicator: Owner
Owner/Operator Name: HAMILTON GREEN 1 PARTNERS LLC
Legal Status: Private
Date Became Current: 20221101
Date Ended Current: Not reported
Owner/Operator Address: 625 RXR PLAZA
Owner/Operator City,State,Zip: UNIONDALE, NY 11553
Owner/Operator Telephone: 516-506-6600
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: TODD@RXR.COM

Historic Generators:
Receive Date: 20230508
Handler Name: RENAISSANCE ENV MANAGEMENT LLC-WP MALL CLEANERS & GAS STATION SITE
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: No
Electronic Manifest Broker: No

Receive Date: 20221129
Handler Name: RENAISSANCE ENV MANAGEMENT LLC-WP MALL CLEANERS & GAS STATION SITE
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: No
Electronic Manifest Broker: No

List of NAICS Codes and Descriptions:
NAICS Code: 531390

RENAISSANCE ENV MANAGEMENT LLC-WP MALL CLEANERS & GAS STATIO (Continued) **1027533033**

NAICS Description: Other Activities Related To Real Estate

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

E MANIFEST:

Manifest Tracking Number:	024689588JJK
Last Updated Date:	20230123
Shipped Date:	20221221
Received Date:	20221221
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	NYR000258814
Generator Name:	Hamilton Green I Partners Llc
Generator Location Street Number:	Not reported
Generator Location Street 1:	250 HAMILTON AVE
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	625 RXR PLAZA
Generator Mail Street 2:	Not reported
Generator Mail City:	UNIONDALE
Generator Mail Zip:	11553
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	NJD002200046
Designated Facility Name:	Cycle Chem, Inc.
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	217 SOUTH FIRST STREET
Designated Facility Mail City:	ELIZABETH
Designated Facility Mail Zip:	07206
Designated Facility Mail State:	NJ
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	217 SOUTH FIRST STREET
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	ELIZABETH
Designated Facility Location Zip:	07206
Designated Facility Location State:	NJ
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Manifest Tracking Number:	024689589JJK
Last Updated Date:	20230105
Shipped Date:	20221221
Received Date:	20221221
Manifest Status:	Signed
Submission Type:	DataImage5Copy

RENAISSANCE ENV MANAGEMENT LLC-WP MALL CLEANERS & GAS STATIO (Continued) **1027533033**

Origin Type:	Service
Generator EPA ID:	NYR000258814
Generator Name:	Hamilton Green I Partners Llc
Generator Location Street Number:	Not reported
Generator Location Street 1:	250 HAMILTON AVE
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	625 RXR PLAZA
Generator Mail Street 2:	Not reported
Generator Mail City:	UNIONDALE
Generator Mail Zip:	11553
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	NJD002200046
Designated Facility Name:	Cycle Chem, Inc.
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	217 SOUTH FIRST STREET
Designated Facility Mail City:	ELIZABETH
Designated Facility Mail Zip:	07206
Designated Facility Mail State:	NJ
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	217 SOUTH FIRST STREET
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	ELIZABETH
Designated Facility Location Zip:	07206
Designated Facility Location State:	NJ
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Federal Waste:

Manifest Tracking Number:	024689589JJK
Waste Line Number:	1
Federal Waste Code:	D008
Federal Waste:	LEAD

State Waste:

Manifest Tracking Number:	024689589JJK
Waste Line Number:	1
State Waste Code Owner:	NY
State Waste Code:	T
State Waste:	Chemical, physical or biological treatment. Waste management method code to be used on e-Manifest only

Transporter:

Manifest Tracking Number:	024689589JJK
Transporter Line Number:	1
Transporter EPA ID:	NJR986659282
Transporter Name:	Di Trucking Llc

Waste Line:

RENAISSANCE ENV MANAGEMENT LLC-WP MALL CLEANERS & GAS STATIO (Continued) 1027533033

Manifest Tracking Number:	024689589JJK
Waste Line Number:	1
U.S. DOT Hazardous Indicator:	Y
U.S. DOT ID Number:	NA3077
U.S. DOT Description:	Rq, Na3077, Hazardous Waste, Solid, N.O.S. (Lead), 9 , Iii
Non-Hazardous Waste Description:	Not reported
Number of Containers:	1
Container Type Code:	DT
Container Type Description:	Dump truck
Waste Quantity:	57800
Quantity Unit of Measure Code:	P
Quantity Unit of Measure Description:	Pounds
Waste Quantity, in Tons:	28.9
Acute Waste Quantity, in Tons:	0
Non-Acute Waste Quantity, in Tons:	28.9
Waste Quantity, in Kilograms:	26213.168
Acute Waste Quantity, in Kilograms:	0
Non-Acute Waste Quantity, in Kilorgrams:	26213.168
Management Method Code:	H110
Management Method Description:	STABILIZATION
Waste Residue Indicator:	N
Quantity Discrepancy Indicator:	N
Waste Type Discrepancy Indicator:	N
Waste Density:	Not reported
Waste Density Unit of Measure Code:	Not reported
Waste Density Unit of Measure Description:	Not reported
Form Code:	Not reported
Form Code Description:	Not reported
Source Code:	Not reported
Source Code Description:	Not reported
Waste Minimization Code:	Not reported
Waste Minimization Code Description:	Not reported
Consent Number:	Not reported
EPA Waste Indicator:	Y

Q206 CONSOLIDATED EDISON NY MANIFEST S110823791
SSE GROVE & QUERROPAS N/A
1/8-1/4 WHITE PLAINS, NY 10602
0.145 mi.
764 ft. Site 9 of 13 in cluster Q

Relative: NY MANIFEST:
Higher

Actual: EPA ID:	NYP004227207
206 ft. Country:	USA
Name:	Consolidated Edison
Address:	GROVE & QUERROPAS
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10602
Zip 4:	Not reported
Location Address 1:	GROVE & QUERROPAS
Location Address 2:	Not reported
Location City,State,Zip:	WHITE PLAINS, NY 10602
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

CONSOLIDATED EDISON (Continued) **S110823791**

Mailing Name: Consolidated Edison
Mailing Contact: Tom Teeling
Mailing Address 1: 4 IRVING PLACE RM 828
Mailing Address 2: Not reported
Mailing City,State,Zip: NEW YORK, NY 10003
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: 2124603770

Manifest Data:
Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: NYD006982359
Year: 2018
Trans2 State ID: Not reported
Generator Ship Date: 02/08/2011
Trans1 Recv Date: 02/08/2011
Trans2 Recv Date: Not reported
TSD Site Recv Date: 02/09/2011
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYP004227207
Trans1 EPA ID: Not reported
Trans2 EPA ID: Not reported
TSDF ID 1: NJD002200046
TSDF ID 2: Not reported
Manifest Tracking Number: 007655773JJK
Import Indicator: N
Export Indicator: N
Discr Quantity Indicator: N
Discr Type Indicator: Y
Discr Residue Indicator: N
Discr Partial Reject Indicator: N
Discr Full Reject Indicator: N
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: H111
Waste Code a: Lead
Waste Code b: Not reported
Waste Code c: Not reported
Waste Code e: Not reported
Waste Code f: Not reported
Waste Code g: Not reported
Waste Code 1: Not reported
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 200
Units: Pounds
Number of Containers: 1
Container Type: Cargo tanks (tank trucks)
Handling Method: Treat
Specific Gravity: 1

Q207 **CON EDISON** **RCRA NonGen / NLR** **1014398972**
SSE **GROVE ST & QUARROPAS ST** **NJ MANIFEST** **NYP004213476**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.145 mi.
764 ft. **Site 10 of 13 in cluster Q**

Relative: **Higher**
Actual: **206 ft.**

RCRA Listings:

Date Form Received by Agency:	20200413
Handler Name:	Con Edison
Handler Address:	Grove St & Quarropas St
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYP004213476
Contact Name:	Not reported
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	Not reported
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	Not reported
Mailing City,State,Zip:	Not reported
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No

CON EDISON (Continued) **1014398972**

Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20200413
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20100813
Handler Name: CON EDISON	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20200413
Handler Name: CON EDISON	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	No
Electronic Manifest Broker:	No

List of NAICS Codes and Descriptions:

NAICS Codes:	No NAICS Codes Found

Facility Has Received Notices of Violations:

Violations:	No Violations Found

Evaluation Action Summary:

Evaluations:	No Evaluations Found

CON EDISON (Continued) **1014398972**

NJ MANIFEST:

EPA ID:	NYP004213476
Name:	CON EDISON
Address:	GROVE ST & QUARROPAS ST
City,State,Zip:	WHITE PLAINS, NY 10601
County:	Not reported
Mailing Address:	4 IRVING PL, RM 828
Mailing City,State,Zip:	NEW YORK, NY 10003
Telephone:	Not reported
Emergency Telephone:	Not reported
Contact:	DONALD SENNO
Comments:	Not reported
SIC Code:	Not reported
County:	NY119
Municipal:	Not reported
Previous EPAID:	Not reported
Generator Flag:	Not reported
Transporter Flag:	Not reported
TSDF Flag:	Not reported
Name Change:	Not reported
Date Change:	Not reported

Manifest Data:

EPA ID:	NYP004213476
Manifest Number:	006874772JJK
Date Shipped:	08/13/2010
TSDF EPA ID:	NJD002200046
Transporter EPA ID:	NJ0000027193
Transporter 2 EPA ID:	Not reported
Transporter 3 EPA ID:	Not reported
Transporter 4 EPA ID:	Not reported
Transporter 5 EPA ID:	Not reported
Transporter 6 EPA ID:	Not reported
Transporter 7 EPA ID:	Not reported
Transporter 8 EPA ID:	Not reported
Transporter 9 EPA ID:	Not reported
Transporter 10 EPA ID:	Not reported
Date Trans1 Transported Waste:	08/13/2010
Date Trans2 Transported Waste:	Not reported
Date Trans3 Transported Waste:	Not reported
Date Trans4 Transported Waste:	Not reported
Date Trans5 Transported Waste:	Not reported
Date Trans6 Transported Waste:	Not reported
Date Trans7 Transported Waste:	Not reported
Date Trans8 Transported Waste:	Not reported
Date Trans9 Transported Waste:	Not reported
Date Trans10 Transported Waste:	Not reported
Date TSDF Received Waste:	08/13/2010
TSDF EPA Facility Name:	Not reported
QTY Units:	Not reported
Transporter SEQ ID:	Not reported
Transporter-1 Date:	Not reported
Waste SEQ ID:	Not reported
Waste Type Code 2:	Not reported
Waste Type Code 3:	Not reported
Waste Type Code 4:	Not reported
Waste Type Code 5:	Not reported

CON EDISON (Continued) **1014398972**

Waste Type Code 6:	Not reported
Date Accepted:	Not reported
Manifest Discrepancy Type:	Not reported
Data Entry Number:	Not reported
Was Load Rejected:	N
Reason Load Was Rejected:	Not reported

Waste:

Manifest Year:	Not reported
Waste Code:	D008
Hand Code:	H111
Quantity:	90
Unit:	G

Q208 **CON EDISON** **NY MANIFEST** **S119076430**
SSE **QUARROPAS ST & MLK BLVD** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.145 mi.
764 ft. **Site 11 of 13 in cluster Q**

Relative:
Higher

Actual:
206 ft.

NY MANIFEST:

EPA ID:	NYP004805560
Country:	USA
Name:	Con Edison
Address:	QUARROPAS ST & MLK BLVD
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10601
Zip 4:	Not reported
Location Address 1:	QUAMOPERS ST W OF GROVE
Location Address 2:	MH 11363
Location City,State,Zip:	WHITE PLAINS, NY
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Edison
Mailing Contact:	Dennis Huacon
Mailing Address 1:	4 IRVING PL 15TH FL
Mailing Address 2:	Not reported
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	2124603770

Q209
SSE
1/8-1/4
0.145 mi.
764 ft.

CON EDISON
QUARROPAS ST & MLK BLVD
WHITE PLAINS, NY 10601

Site 12 of 13 in cluster Q

RCRA NonGen / NLR | **1019905075** | **NYP004805560**

Relative:
Higher

Actual:
206 ft.

RCRA Listings:

Date Form Received by Agency:	20150712
Handler Name:	Con Edison
Handler Address:	Quarropas St & Mlk Blvd
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYP004805560
Contact Name:	THOMAS TEELING
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	212-460-3770
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PL 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No

CON EDISON (Continued) **1019905075**

Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20160909
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20150712
Handler Name: CON EDISON	
Federal Waste Generator Description:	Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20150712
Handler Name: CON EDISON	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

List of NAICS Codes and Descriptions:

NAICS Codes:	No NAICS Codes Found

Facility Has Received Notices of Violations:

Violations:	No Violations Found

Evaluation Action Summary:

Evaluations:	No Evaluations Found

Q210
SSE
1/8-1/4
0.145 mi.
764 ft.

CON EDISON
QUARROPAS ST & MLK BLVD
WHITE PLAINS, NY 10601

Site 13 of 13 in cluster Q

NJ MANIFEST | **S120673776** | **N/A**

Relative:
Higher

Actual:
206 ft.

NJ MANIFEST:

EPA ID:	NYP004805560
Name:	CON EDISON
Address:	QUARROPAS ST & MLK BLVD
City,State,Zip:	WHITE PLAINS, NY 10601
County:	Not reported
Mailing Address:	IRVING PL 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Telephone:	Not reported
Emergency Telephone:	Not reported
Contact:	THOMAS TEELING
Comments:	Not reported
SIC Code:	Not reported
County:	NY119
Municipal:	Not reported
Previous EPAID:	Not reported
Generator Flag:	Not reported
Transporter Flag:	Not reported
TSDF Flag:	Not reported
Name Change:	Not reported
Date Change:	Not reported

Manifest Data:

EPA ID:	NYP004805560
Manifest Number:	014473233JJK
Date Shipped:	7/12/2015
TSDF EPA ID:	NJD002200046
Transporter EPA ID:	NYD006982359
Transporter 2 EPA ID:	Not reported
Transporter 3 EPA ID:	Not reported
Transporter 4 EPA ID:	Not reported
Transporter 5 EPA ID:	Not reported
Transporter 6 EPA ID:	Not reported
Transporter 7 EPA ID:	Not reported
Transporter 8 EPA ID:	Not reported
Transporter 9 EPA ID:	Not reported
Transporter 10 EPA ID:	Not reported
Date Trans1 Transported Waste:	Not reported
Date Trans2 Transported Waste:	Not reported
Date Trans3 Transported Waste:	Not reported
Date Trans4 Transported Waste:	Not reported
Date Trans5 Transported Waste:	Not reported
Date Trans6 Transported Waste:	Not reported
Date Trans7 Transported Waste:	Not reported
Date Trans8 Transported Waste:	Not reported
Date Trans9 Transported Waste:	Not reported
Date Trans10 Transported Waste:	Not reported
Date TSDF Received Waste:	Not reported
TSDF EPA Facility Name:	Not reported
QTY Units:	Not reported
Transporter SEQ ID:	Not reported
Transporter-1 Date:	Not reported
Waste SEQ ID:	Not reported
Waste Type Code 2:	Not reported

CON EDISON (Continued) **S120673776**

Waste Type Code 3:	Not reported
Waste Type Code 4:	Not reported
Waste Type Code 5:	Not reported
Waste Type Code 6:	Not reported
Date Accepted:	Not reported
Manifest Discrepancy Type:	Not reported
Data Entry Number:	Not reported
Was Load Rejected:	Not reported
Reason Load Was Rejected:	Not reported

O211 **NY AST** **S121995547**
ESE **85 COURT STREET** **NY COOLING TOWERS** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.146 mi.
773 ft. **Site 25 of 26 in cluster O**

Relative: **Higher**
Actual: **226 ft.**

WESTCHESTER CO. AST:

Name:	COUNTY OF WESTCHESTER
Address:	85 COURT STREET
City,State,Zip:	WHITE PLAINS, NY 10601
PBS Number:	3-801525
Site Status:	Administratively Closed
GDS Number:	Not reported
Operator Name:	John Varmon
Owner Name:	County of Westchester
Owner Street:	148 Martine Avenue
Owner Address2:	Not reported
Owner City/State/Zip:	White Plains, NY 10601
Tank Number:	11
Status:	1. In-Service
Date Installation:	07/01/2008
Capacity:	336
Product Stored:	0008. Diesel
Product Stored Percent:	Not reported
Date Perm Closure:	01/01/1900
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Leak Detection:	5. In-Tank System (auto tank gauge),GEN BELLY TANK
Tank Secondary Containment:	GEN BELLY TANK
Piping Location:	1. Aboveground
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	Not reported
Piping Leak Detection:	Not reported
Piping Secondary Containment:	Not reported
Overfill Prevention:	2. High Level Alarm,4. Product Level Gauge (Aboveground Only)
Spill Prevention:	0. None
Dispenser:	2. Suction

COOLING TOWERS:

Name:	Not reported
Address:	85 COURT STREET
City,State,Zip:	WHITE PLAINS, NY 10601
Equipment Unique ID:	5994

(Continued) **S121995547**

Equipment Borough:	Not reported
Intended Use:	Air Conditioning
Manufacturer:	BAC
Model:	VTO-78-JMLTX
Cooling Capacity:	200
Cooling Capacity Unit:	Tonnage
Commissioned Date:	09/01/1982
Inspection Date:	03/23/2022
Date of Bacteriological Collection:	06/28/2022
Date of Legionella Collection:	04/29/2024
Last Legionella Result > 1,000 CFU/mL:	lt20
Last Sampled Days:	Not reported
Reg Compliant:	Not reported
Last Update Days:	Not reported
CT Status:	Not reported
Equipment Tower Operation Duration:	Not reported
Latitude:	41.030441
Longitude:	-73.767029

S212 **NYSDEC** **NY MANIFEST** **1009235252**
SE **GRAND & QUARRAPUS** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.147 mi.
777 ft. **Site 1 of 11 in cluster S**

Relative: **Higher**
Actual: **229 ft.**

NY MANIFEST:

EPA ID:	NYP003600954
Country:	USA
Name:	Nysdec
Address:	GRAND & QUARRAPUS
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10601
Zip 4:	Not reported
Location Address 1:	GRAND & QUARRAPUS
Location Address 2:	Not reported
Location City,State,Zip:	WHITE PLAINS, NY 10601
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Nysdec
Mailing Contact:	Robert Smith
Mailing Address 1:	21 S PUTT CORNERS RD
Mailing Address 2:	Not reported
Mailing City,State,Zip:	NEW PALTZ, NY 12561
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	9142555453

Manifest Data:

Document ID:	NYB2077632
Manifest Status:	Not reported
Trans1 State ID:	Not reported
Year:	1991
Trans2 State ID:	Not reported
Generator Ship Date:	03/19/1991

NYSDEC (Continued) **1009235252**

Trans1 Recv Date:	03/19/1991
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	04/02/1991
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP003600954
Trans1 EPA ID:	NYD986908085
Trans2 EPA ID:	Not reported
TSDF ID 1:	NYD082785429
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	The Following Spent Nonhalogenated Solvents: Xylene, Acetone, Ethyl Acetate, Ethyl Benzene, Ethyl Ether, Methyl Isobutyl Ketone, N-Butyl Alcohol, Cyclohexanone, And Methanol; All Spent Solvent Mixtures/Blends Containing, Before Use, Only The Above Spent Nonhalogenated Solvents; And All Spent Solvent Mixtures/Blends Containing, Before Use, One Or More Of The Above Nonhalogenated Solvents, And A Total Of Ten Percent Or More (By Volume) Of One Or More Of Those Solvents Listed In F001, F002, F004, And F005; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent Mixtures.
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00050
Units:	Gallons (liquids only)
Number of Containers:	001
Container Type:	Metal drums, barrels, kegs
Handling Method:	Treat
Specific Gravity:	01.00

T213 **WHITE PLAINS POLICE DEPT** **RCRA NonGen / NLR** **1000397528**
NE **279 HAMILTON AVE** **FINDS** **NYD986876019**
1/8-1/4 **WHITE PLAINS, NY 10601** **ECHO**
0.148 mi.
779 ft. **Site 1 of 13 in cluster T**

Relative: **Higher**
Actual: **210 ft.**

RCRA Listings:

Date Form Received by Agency:	20070101
Handler Name:	White Plains Police Dept
Handler Address:	Hamilton Ave
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYD986876019
Contact Name:	Not reported

WHITE PLAINS POLICE DEPT (Continued) **1000397528**

Contact Address:	HAMILTON AVE
Contact City,State,Zip:	WHITE PLAINS, NY 10601
Contact Telephone:	Not reported
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Not reported
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R3
Mailing Address:	HAMILTON AVE
Mailing City,State,Zip:	WHITE PLAINS, NY 10601
Owner Name:	The City Of White Plains
Owner Type:	Municipal
Operator Name:	The City Of White Plains
Operator Type:	Municipal
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20150414
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No

WHITE PLAINS POLICE DEPT (Continued) **1000397528**

Exporter of Spent Lead Acid Batteries: No
Recycler Activity Without Storage: No
Manifest Broker: No
Sub-Part P Indicator: No

Hazardous Waste Summary:
Waste Code: D001
Waste Description: Ignitable Waste

Waste Code: NONE
Waste Description: Not Defined

Handler - Owner Operator:
Owner/Operator Indicator: Operator
Owner/Operator Name: THE CITY OF WHITE PLAINS
Legal Status: Municipal
Date Became Current: Not reported
Date Ended Current: Not reported
Owner/Operator Address: NOT REQUIRED
Owner/Operator City,State,Zip: NOT REQUIRED, WY 99999
Owner/Operator Telephone: 212-555-1212
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Owner
Owner/Operator Name: THE CITY OF WHITE PLAINS
Legal Status: Municipal
Date Became Current: Not reported
Date Ended Current: Not reported
Owner/Operator Address: NOT REQUIRED
Owner/Operator City,State,Zip: NOT REQUIRED, WY 99999
Owner/Operator Telephone: 212-555-1212
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Owner
Owner/Operator Name: THE CITY OF WHITE PLAINS
Legal Status: Municipal
Date Became Current: Not reported
Date Ended Current: Not reported
Owner/Operator Address: NOT REQUIRED
Owner/Operator City,State,Zip: NOT REQUIRED, WY 99999
Owner/Operator Telephone: 212-555-1212
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Historic Generators:
Receive Date: 19950413
Handler Name: WHITE PLAINS POLICE DEPT
Federal Waste Generator Description: Not reported
State District Owner: Ny
Large Quantity Handler of Universal Waste: No

WHITE PLAINS POLICE DEPT (Continued) **1000397528**

Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20060101
Handler Name: WHITE PLAINS POLICE DEPT
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20070101
Handler Name: WHITE PLAINS POLICE DEPT
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 19881005
Handler Name: WHITE PLAINS POLICE DEPT
Federal Waste Generator Description: Large Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

WHITE PLAINS POLICE DEPT (Continued) **1000397528**

FINDS:
Registry ID: 110004438207

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:
The Resource Conservation and Recovery Act Information System (RCRAInfo) is EPA's comprehensive information system in support of the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. It tracks many types of information about generators, transporters, treaters, storers, and disposers of hazardous waste.

Click this hyperlink while viewing on your computer to access additional FINDS: detail in the EDR Site Report.

ECHO:
Envid: 1000397528
Registry ID: 110004438207

DFR URL:
Name: WHITE PLAINS POLICE DEPT
Address: 279 HAMILTON AVE
City,State,Zip: WHITE PLAINS, NY 10601

T214 **PUBLIC SAFETY BUILDING** **NY UST** **U004441390**
NE **279 HAMILTON AVE** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.148 mi.
779 ft. **Site 2 of 13 in cluster T**

Relative:
Higher

Actual:
210 ft.

WESTCHESTER CO. UST:
Name: PUBLIC SAFETY BUILDING
Address: 279 HAMILTON AVE
City,State,Zip: WHITE PLAINS, NY 10601
Id/Status: 3-169528 / Unregulated: <1101 gal. PBS
Operator Name: City of White Plains
Owner Name: City of White Plains
Owner Street: 255 Main St
Owner Address2: Not reported
Owner City: White Plains
Owner State: NY
Owner Zipcode: 10601
GDS Number: Not reported

Tank Number: 015
Status: 3a. Closed - Prior to 04/1991
Capacity: 3000
Product Stored: Not reported
Product Stored Percent: Not reported
Tank Leak Detection: 0. None
Date Installation: 01/01/1900
Date Perm Closure: 01/01/1900
Tank Location: 5. Underground including vaulted with no access for inspection
Tank Type: 1. Steel/Carbon steel/Iron
Tank Internal Protection: 0. None
Tank External Protection: 0. None
Tank Secondary Containment: 0. None

PUBLIC SAFETY BUILDING (Continued) **U004441390**

Piping Location:	Not reported
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Overfill Prevention:	0. None
Piping Secondary Containment:	Not reported
Spill Prevention:	0. None
Dispenser:	2. Suction

Tank Number:	017
Status:	3a. Closed - Prior to 04/1991
Capacity:	3000
Product Stored:	0009. Gasoline
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	01/01/1900
Date Perm Closure:	01/01/1900
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	Not reported
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Overfill Prevention:	0. None
Piping Secondary Containment:	Not reported
Spill Prevention:	0. None
Dispenser:	2. Suction

T215 **WHITE PLAINS POLICE DEPT** **NY LTANKS S100139018**
NE **279 HAMILTON AVENUE** **NY MANIFEST N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.148 mi.
779 ft. **Site 3 of 13 in cluster T**

Relative:
Higher

Actual:
210 ft.

LTANKS:

Name:	POLICE
Address:	279 HAMILTON
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8606771 / 1989-11-29
Facility ID:	8606771
Site ID:	92789
Spill Date:	1987-02-04
Spill Cause:	Tank Test Failure
Spill Source:	Institutional, Educational, Gov., Other
Spill Class:	C3
Cleanup Ceased:	1989-11-29
SWIS:	6017
Investigator:	PATEL
Referred To:	Not reported
Reported to Dept:	1987-02-04
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	1987-02-17
Recommended Penalty:	False
Meets Standard:	True

WHITE PLAINS POLICE DEPT (Continued) **S100139018**

UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1987-02-09
Spill Record Last Update:	2007-10-25
Spiller Name:	Not reported
Spiller Company:	WPPD
Spiller Address:	SAME
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	83302
Latitude:	41.0338614
Longitude:	-73.7680256
DEC Memo:	There is a 2007 Region 3 signed stipulation agreement for this site which can be found at:
Remarks:	TTTF

All TTF:

Facility ID:	8606771
Spill Number:	8606771
Spill Tank Test:	1530547
Site ID:	92789
Tank Number:	Not reported
Tank Size:	0
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	92789
Operable Unit ID:	903611
Operable Unit:	01
Material ID:	472333
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

WHITE PLAINS POLICE DEPT (Continued) **S100139018**

NY MANIFEST:

EPA ID:	NYP000877423
Country:	USA
Name:	White Plains Police Dept
Address:	279 HAMILTON AVENUE
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10601
Zip 4:	Not reported
Location Address 1:	279 HAMILTON AVENUE
Location Address 2:	Not reported
Location City,State,Zip:	WHITE PLAINS, NY 10601
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	White Plains Police Dept
Mailing Contact:	White Plains Police Dept
Mailing Address 1:	279 HAMILTON AVENUE
Mailing Address 2:	Not reported
Mailing City,State,Zip:	WHITE PLAINS, NY 10601
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	9146824210

Manifest Data:

Document ID:	PAB5063236
Manifest Status:	K - Completed after the designated time
Trans1 State ID:	PA-AH0287
Year:	1988
Trans2 State ID:	PA-AH
Generator Ship Date:	880617
Trans1 Recv Date:	880617
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	880617
Part A Recv Date:	880707
Part B Recv Date:	880728
Generator EPA ID:	NYP000877423
Trans1 EPA ID:	NJD000603563
Trans2 EPA ID:	Not reported
TSDF ID 1:	PAD085690592
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Ignitable Waste
Waste Code 2:	Not reported

WHITE PLAINS POLICE DEPT (Continued) **S100139018**

Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00065
Units:	Gallons (liquids only)
Number of Containers:	002
Container Type:	Metal drums, barrels, kegs
Handling Method:	Treat
Specific Gravity:	100
Document ID:	PAB5062794
Manifest Status:	K - Completed after the designated time
Trans1 State ID:	PA-AH0287
Year:	1988
Trans2 State ID:	PA-AH
Generator Ship Date:	881013
Trans1 Recv Date:	881013
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	881013
Part A Recv Date:	881205
Part B Recv Date:	881220
Generator EPA ID:	NYP000877423
Trans1 EPA ID:	NJD000603563
Trans2 EPA ID:	Not reported
TSDF ID 1:	PAD085690592
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Ignitable Waste
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	04800
Units:	Pounds
Number of Containers:	012
Container Type:	Metal drums, barrels, kegs
Handling Method:	Landfill
Specific Gravity:	100

T216 **FORMER WPPD** **UST FINDER RELEASE** **1029068547**
NE **279 HAMITON AVE** **N/A**
1/8-1/4 **WHITE PLAINS, NY 0**
0.148 mi.
779 ft. **Site 4 of 13 in cluster T**

Relative: **Higher**
Actual: **210 ft.**

UST FINDER RELEASE:

Object ID:	262457
Facility ID:	NY247580
Lust ID:	NY405806
Name:	FORMER WPPD
Address:	279 HAMITON AVE
City,State,Zip:	WHITE PLAINS, NY 0
Address Match Type:	Not reported
Reported Date:	1987/01/01 16:00:00+00
Status:	No Further Action
Substance:	Not reported
Population within 1500ft:	4377
Domestic Wells within 1500ft:	0
Land Use:	Developed, High Intensity
Within SPA:	Yes
SPA PWS Facility ID:	NY7003493_76968
SPA Water Type:	SW - SurRELEASEe Water
SPA Facility Type:	RS - Reservoir
SPA HUC12:	20301020103
Within WHPA:	No
WHPA PWS Facility ID:	Not reported
WHPA Water Type:	Not reported
WHPA Facility Type:	Not reported
WHPA HUC12:	Not reported
Within 100yr Floodplain:	No
Tribe:	Not reported
EPA Region:	2
NFA Letter 1:	Not reported
NFA Letter 2:	Not reported
NFA Letter 3:	Not reported
NFA Letter 4:	Not reported
Closed With Residual Contaminate:	Not reported
Coordinate Source:	State
X Coord:	-73.76802
Y Coord:	41.0338600000001
Latitude:	41.0338599999999
Longitude:	-73.76802

O217 **MINSKOFF CORP.** **NY LTANKS** **S102673852**
East **179 MARTINE AVE** **N/A**
1/8-1/4 **WHITE PLAINS, NY**
0.148 mi.
781 ft. **Site 26 of 26 in cluster O**

Relative: **Higher**
Actual: **217 ft.**

LTANKS:

Name:	MINSKOFF CORP.
Address:	179 MARTINE AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9201879 / 1992-05-15
Facility ID:	9201879
Site ID:	217944
Spill Date:	1992-05-15
Spill Cause:	Tank Overfill
Spill Source:	Tank Truck

MINSKOFF CORP. (Continued) **S102673852**

Spill Class:	C3
Cleanup Ceased:	1992-05-15
SWIS:	6017
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1992-05-15
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Responsible Party
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2003-12-02
Spill Record Last Update:	2003-12-02
Spiller Name:	Not reported
Spiller Company:	ORIG. CONSUMERS
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	180303
Latitude:	41.0313087
Longitude:	-73.7668599
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY
Remarks:	CONTAINED ON CONCRETE FLOOR IN CELLAR SPILLER DOING CLEAN UP

All Materials:

Site ID:	217944
Operable Unit ID:	969292
Operable Unit:	01
Material ID:	413166
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	7.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

U218 **SPILL NUMBER 0206130** **NY LTANKS** **S105996744**
ENE **203 MAIN ST** **N/A**
1/8-1/4 **WHITE PLAINS, NY**
0.150 mi.
790 ft. **Site 1 of 15 in cluster U**

Relative: LTANKS:
Higher

Name:	SPILL NUMBER 0206130
Address:	203 MAIN ST
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0206130 / 2003-09-03

Actual:
211 ft.

SPILL NUMBER 0206130 (Continued) **S105996744**

Facility ID:	0206130
Site ID:	176565
Spill Date:	2002-09-12
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	WCHD
Referred To:	Westchester Cnty Health Dept
Reported to Dept:	2002-09-13
CID:	396
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2002-09-13
Spill Record Last Update:	2003-09-08
Spiller Name:	Not reported
Spiller Company:	SAME
Spiller Address:	Not reported
Spiller County:	999
Spiller Contact:	JOHN JANUS
Spiller Phone:	(914) 760-0257
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	148388
Latitude:	41.0325620
Longitude:	-73.7669792
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was WCHD - SCHNEIDER 09/03/03 TANK CLOSED IN PLACE, VAULT CLEAN.
Remarks:	while doing an inspection of the tank oil was observed leaking back into the empty tank.

All TTF:

Facility ID:	0206130
Spill Number:	0206130
Spill Tank Test:	1527446
Site ID:	176565
Tank Number:	1
Tank Size:	2500
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

SPILL NUMBER 0206130 (Continued) **S105996744**

Site ID:	176565
Operable Unit ID:	857669
Operable Unit:	01
Material ID:	516742
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

U219 **BRIAN HOLDING COMPANY** **NY UST** **U004439578**
ENE **203 MAIN STREET** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.150 mi.
790 ft. **Site 2 of 15 in cluster U**

Relative: WESTCHESTER CO. UST:
Higher

Actual:
211 ft.

Name:	BRIAN HOLDING COMPANY
Address:	203 MAIN STREET
City,State,Zip:	WHITE PLAINS, NY 10601
Id/Status:	3-049999 / Unregulated: <1101 gal. PBS
Operator Name:	John Janis
Owner Name:	Brian Holding Company c/o Stillman Management
Owner Street:	141 Halstead Avenue
Owner Address2:	Not reported
Owner City:	Mamaroneck
Owner State:	NY
Owner Zipcode:	10543
GDS Number:	Not reported
Tank Number:	1
Status:	4. Closed - in place
Capacity:	2500
Product Stored:	Not reported
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	Not reported
Date Perm Closure:	12/10/2002
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	Not reported
Piping Location:	0. No Pipiing
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Overfill Prevention:	Not reported
Piping Secondary Containment:	Not reported
Spill Prevention:	Not reported
Dispenser:	2. Suction

T220 **274 SNK HAMILTON AVENUE, LLC** **NY UST** **U004457012**
NE **274 HAMILTON AVENUE** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.155 mi.
819 ft. **Site 5 of 13 in cluster T**

Relative:
Higher

Actual:
210 ft.

WESTCHESTER CO. UST:

Name:	274 SNK HAMILTON AVENUE, LLC
Address:	274 HAMILTON AVENUE
City,State,Zip:	WHITE PLAINS, NY 10601
Id/Status:	3-164135 / Active
Operator Name:	Syed H. Kirmani
Owner Name:	274 SNK Hamilton Avenue, LLC
Owner Street:	1983 Route 52
Owner Address2:	Not reported
Owner City:	Hopewell Junction
Owner State:	NY
Owner Zipcode:	12533
GDS Number:	3551700304
Tank Number:	01
Status:	1. In-Service
Capacity:	12000
Product Stored:	2712. Gasoline/Ethanol
Product Stored Percent:	10
Tank Leak Detection:	1. Electronic Interstitial Monitoring
Date Installation:	01/01/1989
Date Perm Closure:	01/01/1900
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	6. Fiberglass reinforced plastic (FRP)
Tank Internal Protection:	0. None
Tank External Protection:	4. Fiberglass
Tank Secondary Containment:	4. Double-Walled (underground only)
Piping Location:	2. Underground/on Ground
Piping Type:	6. Fiberglass Reinforced Plastic (FRP)
Piping External Protection:	4. Fiberglass
Overfill Prevention:	3. Automatic Shut-off
Piping Secondary Containment:	4. Double-Walled (underground only)
Spill Prevention:	1. Catch Basin
Dispenser:	1. Submersible
Tank Number:	02
Status:	1. In-Service
Capacity:	10000
Product Stored:	2712. Gasoline/Ethanol
Product Stored Percent:	10
Tank Leak Detection:	1. Electronic Interstitial Monitoring
Date Installation:	01/01/1989
Date Perm Closure:	01/01/1900
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	6. Fiberglass reinforced plastic (FRP)
Tank Internal Protection:	0. None
Tank External Protection:	4. Fiberglass
Tank Secondary Containment:	4. Double-Walled (underground only)
Piping Location:	2. Underground/on Ground
Piping Type:	6. Fiberglass Reinforced Plastic (FRP)
Piping External Protection:	4. Fiberglass
Overfill Prevention:	3. Automatic Shut-off

274 SNK HAMILTON AVENUE, LLC (Continued) **U004457012**

Piping Secondary Containment:	4. Double-Walled (underground only)
Spill Prevention:	1. Catch Basin
Dispenser:	1. Submersible

Tank Number:	03
Status:	1. In-Service
Capacity:	10000
Product Stored:	2712. Gasoline/Ethanol
Product Stored Percent:	10
Tank Leak Detection:	1. Electronic Interstitial Monitoring
Date Installation:	01/01/1989
Date Perm Closure:	01/01/1900
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	6. Fiberglass reinforced plastic (FRP)
Tank Internal Protection:	0. None
Tank External Protection:	4. Fiberglass
Tank Secondary Containment:	4. Double-Walled (underground only)
Piping Location:	2. Underground/on Ground
Piping Type:	6. Fiberglass Reinforced Plastic (FRP)
Piping External Protection:	4. Fiberglass
Overfill Prevention:	3. Automatic Shut-off
Piping Secondary Containment:	4. Double-Walled (underground only)
Spill Prevention:	1. Catch Basin
Dispenser:	1. Submersible

Tank Number:	04
Status:	3. Closed - Removed
Capacity:	550
Product Stored:	Not reported
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	01/01/1989
Date Perm Closure:	09/01/2008
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	6. Fiberglass reinforced plastic (FRP)
Tank Internal Protection:	0. None
Tank External Protection:	4. Fiberglass
Tank Secondary Containment:	0. None
Piping Location:	2. Underground/on ground
Piping Type:	10. Copper
Piping External Protection:	0. None
Overfill Prevention:	Not reported
Piping Secondary Containment:	Not reported
Spill Prevention:	1. Catch Basin
Dispenser:	2. Suction

Tank Number:	1
Status:	0. Administratively closed
Capacity:	67000
Product Stored:	2712. Gasoline/Ethanol
Product Stored Percent:	10
Tank Leak Detection:	1. Electronic Interstitial Monitoring
Date Installation:	01/01/1989
Date Perm Closure:	01/01/1900

274 SNK HAMILTON AVENUE, LLC (Continued) **U004457012**

Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	6. Fiberglass reinforced plastic (FRP)
Tank Internal Protection:	4. Glass liner
Tank External Protection:	4. Fiberglass
Tank Secondary Containment:	4. Double-Walled (underground only)
Piping Location:	2. Underground/on ground
Piping Type:	6. Fiberglass reinforced plastic (FRP)
Piping External Protection:	4. Fiberglass
Overfill Prevention:	1. Float Vent Valve,5. Vent Whistle
Piping Secondary Containment:	4. Double-Walled (underground only)
Spill Prevention:	1. Catch Basin
Dispenser:	1. Submersible

Tank Number:	10
Status:	0. Administratively closed
Capacity:	1000
Product Stored:	9999. Other
Product Stored Percent:	Not reported
Tank Leak Detection:	Not reported
Date Installation:	01/01/1989
Date Perm Closure:	12/01/2001
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	4. Double-Walled (underground only)
Piping Location:	Not reported
Piping Type:	Not reported
Piping External Protection:	0. None
Overfill Prevention:	1. Float Vent Valve
Piping Secondary Containment:	Not reported
Spill Prevention:	Not reported
Dispenser:	2. Suction

Tank Number:	2
Status:	0. Administratively closed
Capacity:	10000
Product Stored:	2712. Gasoline/Ethanol
Product Stored Percent:	10
Tank Leak Detection:	1. Electronic Interstitial Monitoring
Date Installation:	01/01/1989
Date Perm Closure:	01/01/1900
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	6. Fiberglass reinforced plastic (FRP)
Tank Internal Protection:	0. None
Tank External Protection:	4. Fiberglass
Tank Secondary Containment:	4. Double-Walled (underground only)
Piping Location:	2. Underground/on ground
Piping Type:	6. Fiberglass reinforced plastic (FRP)
Piping External Protection:	4. Fiberglass
Overfill Prevention:	1. Float Vent Valve
Piping Secondary Containment:	4. Double-Walled (underground only)
Spill Prevention:	1. Catch Basin
Dispenser:	1. Submersible

274 SNK HAMILTON AVENUE, LLC (Continued) **U004457012**

Tank Number:	3
Status:	0. Administratively closed
Capacity:	10000
Product Stored:	2712. Gasoline/Ethanol
Product Stored Percent:	10
Tank Leak Detection:	1. Electronic Interstitial Monitoring
Date Installation:	01/01/1989
Date Perm Closure:	01/01/1900
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	6. Fiberglass reinforced plastic (FRP)
Tank Internal Protection:	0. None
Tank External Protection:	4. Fiberglass
Tank Secondary Containment:	4. Double-Walled (underground only)
Piping Location:	2. Underground/on ground
Piping Type:	6. Fiberglass reinforced plastic (FRP)
Piping External Protection:	4. Fiberglass
Overfill Prevention:	1. Float Vent Valve
Piping Secondary Containment:	4. Double-Walled (underground only)
Spill Prevention:	1. Catch Basin
Dispenser:	1. Submersible

T221 **274 SNK HAMILTON AVENUE, LLC** **NY AST** **U003949256**
NE **274 HAMILTON AVENUE** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.155 mi.
819 ft. **Site 6 of 13 in cluster T**

Relative:
Higher

Actual:
210 ft.

WESTCHESTER CO. AST:

Name:	274 SNK HAMILTON AVENUE, LLC
Address:	274 HAMILTON AVENUE
City,State,Zip:	WHITE PLAINS, NY 10601
PBS Number:	3-164135
Site Status:	Active
GDS Number:	3551700304
Operator Name:	Syed H. Kirmani
Owner Name:	274 SNK Hamilton Avenue, LLC
Owner Street:	1983 Route 52
Owner Address2:	Not reported
Owner City/State/Zip:	Hopewell Junction, NY 12533
Tank Number:	05
Status:	1. In-Service
Date Installation:	01/01/1997
Capacity:	350
Product Stored:	0022. Waste/Used Oil
Product Stored Percent:	Not reported
Date Perm Closure:	01/01/1900
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Leak Detection:	2. Manual Interstitial Monitoring,6. Impervious Barrier/Concrete Pad (Aboveground Only)
Tank Secondary Containment:	1. Diking (aboveground only),9. Modified double-walled (aboveground only)
Piping Location:	0. No Piping
Piping Type:	0. No Piping
Piping External Protection:	0. None
Piping Leak Detection:	0. None
Piping Secondary Containment:	2. Vault (w/ access)

274 SNK HAMILTON AVENUE, LLC (Continued) **U003949256**

Overfill Prevention:	4. Product Level Gauge (Aboveground Only),HAND FILLED
Spill Prevention:	1. Catch Basin
Dispenser:	0. None

Tank Number:	06
Status:	3. Closed - Removed
Date Installation:	01/01/1997
Capacity:	350
Product Stored:	0022. Waste/Used Oil
Product Stored Percent:	Not reported
Date Perm Closure:	01/01/1900
Tank Location:	1. Aboveground (contact w/ soil)
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Leak Detection:	0. None
Tank Secondary Containment:	9. Modified double-walled (aboveground only)
Piping Location:	0. No Piping
Piping Type:	0. No Piping
Piping External Protection:	0. None
Piping Leak Detection:	0. None
Piping Secondary Containment:	2. Vault (w/ access)
Overfill Prevention:	0. None
Spill Prevention:	0. None
Dispenser:	0. None

Tank Number:	07
Status:	1. In-Service
Date Installation:	09/01/2008
Capacity:	500
Product Stored:	0001. #2 Fuel Oil
Product Stored Percent:	Not reported
Date Perm Closure:	01/01/1900
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Leak Detection:	1. Electronic Interstitial Monitoring,6. Impervious Barrier/Concrete Pad (Aboveground Only)
Tank Secondary Containment:	9. Modified double-walled (aboveground only),10. Impervious Underlayment (AST Only)
Piping Location:	1. Aboveground
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	0. None
Piping Leak Detection:	0. None
Piping Secondary Containment:	0. None
Overfill Prevention:	4. Product Level Gauge (Aboveground Only),5. Vent Whistle
Spill Prevention:	1. Catch Basin
Dispenser:	0. None

Tank Number:	4
Status:	3a. Closed - Prior to 04/1991
Date Installation:	01/01/1989
Capacity:	550
Product Stored:	0003. #6 Fuel Oil
Product Stored Percent:	Not reported

274 SNK HAMILTON AVENUE, LLC (Continued) **U003949256**

Date Perm Closure:	01/01/1900
Tank Location:	4. Aboveground: w/ 10% or more below ground
Tank Type:	5. Steel tank in concrete
Tank Internal Protection:	0. None
Tank External Protection:	4. Impressed Current (no retrofit)
Tank Leak Detection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	0. No Piping
Piping Type:	4. fiberglass coated steel
Piping External Protection:	0. None
Piping Leak Detection:	0. None
Piping Secondary Containment:	0. None
Overfill Prevention:	0. None
Spill Prevention:	0. None
Dispenser:	1. Submersible

Tank Number:	5
Status:	0. Administratively closed
Date Installation:	01/01/1997
Capacity:	350
Product Stored:	Not reported
Product Stored Percent:	Not reported
Date Perm Closure:	01/01/1900
Tank Location:	1. Aboveground (contact w/ soil)
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Leak Detection:	0. None
Tank Secondary Containment:	9. Modified double-walled (aboveground only)
Piping Location:	0. No Piping
Piping Type:	0. No Piping
Piping External Protection:	0. None
Piping Leak Detection:	0. None
Piping Secondary Containment:	2. Vault (w/ access)
Overfill Prevention:	0. None
Spill Prevention:	0. None
Dispenser:	0. None

T222 **EXXON, WHITE PLAINS** **UST FINDER RELEASE** **1029079515**
NE **274 HAMILTON AVE** **N/A**
1/8-1/4 **WHITE PLAINS, NY 0**
0.155 mi.
819 ft. **Site 7 of 13 in cluster T**

Relative:
Higher

Actual:
210 ft.

UST FINDER RELEASE:

Object ID:	262454
Facility ID:	NY93029
Lust ID:	NY8707486
Name:	EXXON, WHITE PLAINS
Address:	274 HAMILTON AVE
City,State,Zip:	WHITE PLAINS, NY 0
Address Match Type:	Not reported
Reported Date:	1987/12/01 16:00:00+00
Status:	No Further Action
Substance:	Not reported
Population within 1500ft:	4338
Domestic Wells within 1500ft:	0

EXXON, WHITE PLAINS (Continued) **1029079515**

Land Use:	Developed, High Intensity
Within SPA:	Yes
SPA PWS Facility ID:	NY7003493_76968
SPA Water Type:	SW - SurRELEASEe Water
SPA Facility Type:	RS - Reservoir
SPA HUC12:	20301020103
Within WHPA:	No
WHPA PWS Facility ID:	Not reported
WHPA Water Type:	Not reported
WHPA Facility Type:	Not reported
WHPA HUC12:	Not reported
Within 100yr Floodplain:	No
Tribe:	Not reported
EPA Region:	2
NFA Letter 1:	Not reported
NFA Letter 2:	Not reported
NFA Letter 3:	Not reported
NFA Letter 4:	Not reported
Closed With Residual Contaminate:	Not reported
Coordinate Source:	State
X Coord:	-73.7680999999999
Y Coord:	41.03396
Latitude:	41.03396
Longitude:	-73.7681

T223 **CON EDISON** **NY MANIFEST** **S117738650**
NE **274 HAMILTON AVE** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.155 mi.
819 ft. **Site 8 of 13 in cluster T**

Relative: **Higher**

Actual: **210 ft.**

NY MANIFEST:

EPA ID:	NYP004717195
Country:	USA
Name:	Con Edison
Address:	274 HAMILTON AVE
Address 2:	TM 4691
City,State,Zip:	WHITE PLAINS, NY 10601
Zip 4:	Not reported
Location Address 1:	274 HAMILTON AVE
Location Address 2:	TM 4691
Location City,State,Zip:	WHITE PLAINS, NY 10601
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Edison
Mailing Contact:	Tom Teeling
Mailing Address 1:	4 IRVING PLACE - 15TH FLOOR
Mailing Address 2:	Not reported
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	Not reported

CON EDISON (Continued) **S117738650**

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	01/21/2015
Trans1 Recv Date:	01/21/2015
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	01/23/2015
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004717195
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	014161949JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	350
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

T224
NE
1/8-1/4
0.155 mi.
819 ft.

EXXON, WHITE PLAINS
274 HAMILTON AVE
WHITE PLAINS, NY

Site 9 of 13 in cluster T

NY LTANKS **S103571230**
NY Spills **N/A**

Relative:
Higher

Actual:
210 ft.

LTANKS:

Name:	EXXON, WHITE PLAINS
Address:	274 HAMILTON AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8707486 / 1987-12-18
Facility ID:	8707486
Site ID:	190041
Spill Date:	1987-12-01
Spill Cause:	Tank Test Failure
Spill Source:	Gasoline Station or other PBS Facility
Spill Class:	D3
Cleanup Ceased:	1987-12-18
SWIS:	6017
Investigator:	jeokesso
Referred To:	Not reported
Reported to Dept:	1987-12-02
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	1987-12-18
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	True
Remediation Phase:	0
Date Entered In Computer:	1987-12-02
Spill Record Last Update:	1988-02-12
Spiller Name:	Not reported
Spiller Company:	EXXON
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	93029
Latitude:	41.0339612
Longitude:	-73.7680952
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was OKESSON / / : 2-9-88 PASSED RET. ON 12-17-87. N.F.A. L.R.
Remarks:	4K TANK SYS. WOULD NOT HOLD COLUMN, TO ESCAVATE & LOCATE LEAK

All TTF:

Facility ID:	8707486
Spill Number:	8707486
Spill Tank Test:	1532487
Site ID:	190041
Tank Number:	Not reported
Tank Size:	0
Material:	0009
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00

EXXON, WHITE PLAINS (Continued) **S103571230**

Test Method 2: Unknown
Leak Rate: .00
Gross Fail: Not reported
Modified By: Spills
Last Modified Date: Not reported

All Materials:
Site ID: 190041
Operable Unit ID: 911639
Operable Unit: 01
Material ID: 466435
Material Code: 0009
Material Name: gasoline
Case No.: Not reported
Material FA: Petroleum
Quantity: .00
Units: Not reported
Recovered: .00
Resource Affected: Groundwater
Oxygenate: Not reported

SPILLS:
Name: EXXON SERVICE STATION
Address: 274 HAMILTON AVE
City,State,Zip: WHITE PLAINS, NY
Spill Number/Closed Date: 9707887 / Not Reported
Facility ID: 9707887
Facility Type: ER
DER Facility ID: 93029
Site ID: 105471
DEC Region: 3
Spill Cause: Other
Spill Class: A3
SWIS: 6017
Spill Date: 1997-10-03
Investigator: MXLENNA
Referred To: Not reported
Reported to Dept: 1997-10-03
CID: 282
Water Affected: Not reported
Spill Source: Gasoline Station or other PBS Facility
Spill Notifier: Other
Cleanup Ceased: Not reported
Cleanup Meets Std: False
Last Inspection: Not reported
Recommended Penalty: False
UST Trust: False
Remediation Phase: 5
Date Entered In Computer: 1997-10-03
Spill Record Last Update: 2023-04-28
Spiller Name: Not reported
Spiller Company: EXXON SERVICE STATION
Spiller Address: SAME
Spiller Company: 001
Contact Name: MICHAEL MEOLA

EXXON, WHITE PLAINS (Continued) **S103571230**

Latitude: 41.0339612
Longitude: -73.7680952
DEC Memo: Prior to Sept, 2004 data translation this spill Lead_DEC Field was HARDY 06/08/98 LETTER SENT DEC REQUIRES SOIL AND INVESTIGATION OF SITE IN 6 MONTHS 02/09/01 LETTER SENT TO EXXONMOBIL BY J. HARDY; ADVISE AS TO THE SIGNIFICANCE OF THE WHITE PLAINS MALL DENIAL OF ACCESS. 03/15/01 LETTER SENT TO EXXONMOBIL BY J. HARDY; SCHEDULE FOR SUBMISSION OF AN INVESTIGATION REPORT BY 4/30/01 IS APPROVED & REQUIRED. Letter to K. Bourque, Groundwater & Env. Svcs. from J. Hardy, dated 6/27/2003. Reduce monitor well sampling to semi-annually, report annually. 09/04/03: Letter to Eric Harvey, Groundwater & Env. Services, Inc from J. Hardy. Reduce monitor well sampling to semi-annually. Report annually. 6/22/09 2008 annual report shows persistent contamination of approximately 5k btex at mw1--sent email to lbg sirecting them to define extent of contamination in that vicinity within 45 days--email is in edocs jh 10/26/09 2009 annual report shows all wells stable (and low)except mw-1 which has gone down to approx 3k btex. 11/10/09 as a result of decrease in mw1 above gave cf option, by email, to start quarterly sampling and reporting instead of investigation at this t ime. In that case we would consider future action based on whether downward trend continues or not. email in edocs jh 4/21/10 jan 10 sampling shows levels approx same as last period jh 11/22/10 Project transferred to Mastro. 5/25/11 BTEX concentrations remain high in MW-1. Will continue to monitor...mm 5/7/12 See quarterly monitoring reports in edocs...mm 02/12/13 A workplan has been developed and approved to investigate the BTEX in MW-1. Four monitoring wells will be installed and soil samples will be collected for lab analysis. 7/2013 Four monitoring wells were installed..mm 3/30/2017 The BTEX concentrations in MW-1 and MW-4 remain high and unchanged. Off site wells are ND. The consultant, LBG, has been asked to develop a RAP...mm 8/01/17 The 2ndQMR report was submitted by LBG. RAP will be proposed by m10/31/17...mm 1-26-21 Received 2Q20 report. Last ISCO event was Nov 2020. Next event scheduled for March 2021. MW4 and MW1 are the most impacted with total VOCs in the ppm range with general increased right after ISCO and a decline in dissolved concentrations. ML 4-15-21 Received 1Q21 report. Last ISCO event was Nov 2020. The next even is scheduled for April 2021. MW4 and MW1 are the most impacted with total VOCs in the ppm range. Total VOCs increased from last quarter. ML 10-7-21 Report reviewed 2 well have BTEX in the 2000-3000ppm range. All wells are upgradient from injection wells. ML 12-30-21 Updated file to add note for report received on 1/26/21 and 4-15-21. ML 1-5-22 Reviewed 2Q21 QMR.

EXXON, WHITE PLAINS (Continued) **S103571230**

Last ISCO event was March
2021. Next event scheduled for July 2021. MW4 and MW1 are the most impacted with total VOCs in the
ppm range with general increased right after ISCO and a decline in dissolved concentrations. ML
2-10-22 Reached out to WPS. Wells are downgradient of the source area and haven't shown to be
effective. Propose an alternative remedial solution by end of 2Q22. ML
5-3-22 Received 1Q22
Monitoring report. No LNAPL detected. Concentrations in MW have increased. Total VOCS are greater
than the 1st round of sampling from 2018. Revised RAP to be sent by 5/31/22. DEC to require
ethanol. ML 6-16-22 Received Addendum to RAWP on 6/8. RAWP addendum reviewed-calls for the
installation of 5 additional injections wells in the area of presumed residual contaminated soil
located around the dispensers. The proposed locations are upgradient or cross gradient from the
current wells. Soil samples will be obtained during the well installation and wells to be screened
from the start of impacts to 5' below the water table. WPS proposed using field observations and
PID readings over 100ppm to determine the location of contamination and proposed the same
groundwater frequency and sampling. Conditional approval grated-conditions are the threshold for
contamination is lowered to 50ppm and ethanol is included in the analysis. ML 9-8-22 RP questioned
request for ethanol and DEC provided a response. Sampling needed for the 1st year only. ML 11-30-22
Received 3Q22 monitoring report. Wells from the June 2022 RAWP addendum were installed in Sept 2022
and the 1st injections to them will be in 4Q22. Last ISCO event was Feb 2022. Summary report of
well installation to be submitted in Dec 2022. No LNAPL observed, MW1 and MW3 are most impacted.
Monitoring to continue. ML 2-15-23 Received Injection well summary report. Five 2 injection wells
were installed upgradient from the previous locations. IW4 borings show PCS is present in the area
of that well. ISCO event conducted. ML 4-28-23 ISCO event conducted in Nov and Dec 2022. MW1 and
MW4 show a slight decrease in total VOCs since the ISCO event. Other wells show an increase in
concentration ;typical of Isco events. Continue per rawp. ML

Remarks: WHILE REMOVING ABANDONED UNDERGROUND 1000 GALLON TANK ELEVATED PID HEAD SPACE READINGS WERE ENCOUNTERED

All Materials:

Site ID:	105471
Operable Unit ID:	1051107
Operable Unit:	01
Material ID:	329872
Material Code:	0009
Material Name:	gasoline
Case No.:	Not reported
Material FA:	Petroleum

EXXON, WHITE PLAINS (Continued) **S103571230**

Quantity:	Not reported
Units:	G
Recovered:	Not reported
Resource Affected:	Soil, Groundwater
Oxygenate:	Not reported

Name:	CUMBERLAND FARMS # 70324
Address:	274 HAMILTON AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0806742 / 2009-02-24
Facility ID:	0806742
Facility Type:	ER
DER Facility ID:	93029
Site ID:	404037
DEC Region:	3
Spill Cause:	Other
Spill Class:	C3
SWIS:	6017
Spill Date:	2008-09-15
Investigator:	TDGHIOSA
Referred To:	WCDOH / PBS 3-164135
Reported to Dept:	2008-09-15
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Gasoline Station or other PBS Facility
Spill Notifier:	Other
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2008-09-15
Spill Record Last Update:	2009-02-24
Spiller Name:	BRAIN HAWE
Spiller Company:	CUMBERLAND FARMS # 70324
Spiller Address:	274 HAMILTON AVE
Spiller Company:	999
Contact Name:	BRAIN HAWE
Latitude:	41.0340617
Longitude:	-73.7683986
DEC Memo:	1K FUEL OIL TANK REMOVAL. NO EVIDENCE OF RELEASE UPON REMOVAL. LAB RESULTS CAME BACK WITH SVOC DETECTION. WILL SUBMIT REPORT. DT 02/2009 UST closure report submitted by Leggette Brashears & Graham. Based on the information contained in that report, no further action required. TG
Remarks:	CALLER STATES THAT THEY WERE REMOVING TANKS AND NOTICED CONTAMINATED SOIL. CALLER STATES THAT LAB RESULTS CONFIRMED CONTAMINATION.

All Materials:

Site ID:	404037
Operable Unit ID:	1160714
Operable Unit:	01
Material ID:	2151889
Material Code:	0066A
Material Name:	unknown petroleum

EXXON, WHITE PLAINS (Continued) **S103571230**

Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

T225 **FORMER WPPD** **NY LTANKS** **S106702646**
NE **279 HAMITON AVE** **N/A**
1/8-1/4 **WHITE PLAINS, NY**
0.156 mi.
824 ft. **Site 10 of 13 in cluster T**

Relative: **Higher**

Actual: **211 ft.**

LTANKS:

Name:	FORMER WPPD
Address:	279 HAMITON AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0405806 / 2007-07-06
Facility ID:	0405806
Site ID:	306552
Spill Date:	1987-01-01
Spill Cause:	Tank Failure
Spill Source:	Commercial/Industrial
Spill Class:	B3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	MXTIPPLE
Referred To:	Not reported
Reported to Dept:	2004-08-27
CID:	407
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	True
Remediation Phase:	0
Date Entered In Computer:	2004-08-27
Spill Record Last Update:	2007-07-06
Spiller Name:	Not reported
Spiller Company:	WHITE PLAINS POLICE DEPT
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	247580
Latitude:	41.0338590
Longitude:	-73.7680160
DEC Memo:	7/6/07 Tipple met with Kahabka and conducted a final inspection of all remaining work as indicated in the STIP. Stip obligations for the installation of engineering controls have been met, continued inspections of those engineering controls to be conducted regularly by the NYPA as per the STIP.
Remarks:	Area is going to be cleaned up.

FORMER WPPD (Continued) **S106702646**

All Materials:

Site ID:	306552
Operable Unit ID:	889358
Operable Unit:	01
Material ID:	486658
Material Code:	0009
Material Name:	gasoline
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	Not reported
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

Site ID:	306552
Operable Unit ID:	889358
Operable Unit:	01
Material ID:	486659
Material Code:	0009
Material Name:	gasoline
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

P226 **EXXON DIV OF CFI #70324** **RCRA-VSQG** **1000244746**
NE **274 HAMILTON AVE & COTTAGE PLACE** **FINDS** **NYD013387436**
1/8-1/4 **WHITE PLAINS, NY 10601** **ECHO**
0.157 mi. **NY MANIFEST**
831 ft. **Site 8 of 8 in cluster P**

Relative: **Higher**
Actual: **210 ft.**

RCRA Listings:

Date Form Received by Agency:	20070101
Handler Name:	Exxon Div Of Cfi #70324
Handler Address:	Hamilton Ave & Cottage Place
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYD013387436
Contact Name:	MAUREEN JERNSTEDT
Contact Address:	DEDHAM ST
Contact City,State,Zip:	CANTON, MA 02021
Contact Telephone:	800-225-9702 x3378
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Conditionally Exempt Small Quantity Generator
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Handler Activities
State District Owner:	Ny

EXXON DIV OF CFI #70324 (Continued) **1000244746**

State District:	NYSDEC R3
Mailing Address:	DEDHAM ST
Mailing City,State,Zip:	CANTON, MA 02021
Owner Name:	Tosco
Owner Type:	Private
Operator Name:	No Name Found
Operator Type:	Private
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20150414
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Hazardous Waste Summary:

Waste Code:	D001
Waste Description:	Ignitable Waste
Waste Code:	D018
Waste Description:	Benzene

EXXON DIV OF CFI #70324 (Continued) **1000244746**

Handler - Owner Operator:

Owner/Operator Indicator:	Owner
Owner/Operator Name: NO NAME FOUND	
Legal Status:	Private
Date Became Current:	20030910
Date Ended Current:	Not reported
Owner/Operator Address:	Not reported
Owner/Operator City,State,Zip:	Not reported
Owner/Operator Telephone:	Not reported
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported
Owner/Operator Email:	Not reported

Owner/Operator Indicator:	Owner
Owner/Operator Name: TOSCO	
Legal Status:	Private
Date Became Current:	Not reported
Date Ended Current:	Not reported
Owner/Operator Address:	PO BOX 52085
Owner/Operator City,State,Zip:	PHOENIX, AZ 85072-2085
Owner/Operator Telephone:	602-728-8000
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported
Owner/Operator Email:	Not reported

Owner/Operator Indicator:	Owner
Owner/Operator Name: TOSCO	
Legal Status:	Private
Date Became Current:	20010101
Date Ended Current:	Not reported
Owner/Operator Address:	PO BOX 52085
Owner/Operator City,State,Zip:	PHOENIX, AZ 85072-2085
Owner/Operator Telephone:	602-728-8000
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported
Owner/Operator Email:	Not reported

Owner/Operator Indicator:	Operator
Owner/Operator Name: NO NAME FOUND	
Legal Status:	Private
Date Became Current:	20030910
Date Ended Current:	Not reported
Owner/Operator Address:	Not reported
Owner/Operator City,State,Zip:	Not reported
Owner/Operator Telephone:	Not reported
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported
Owner/Operator Email:	Not reported

Owner/Operator Indicator:	Owner
Owner/Operator Name: TOSCO	
Legal Status:	Private
Date Became Current:	Not reported
Date Ended Current:	Not reported
Owner/Operator Address:	PO BOX 52085
Owner/Operator City,State,Zip:	PHOENIX, AZ 85072-2085
Owner/Operator Telephone:	602-728-8000

EXXON DIV OF CFI #70324 (Continued) **1000244746**

Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Owner
Owner/Operator Name: CUMBERLAND FARMS INC
Legal Status: Private
Date Became Current: 20030910
Date Ended Current: Not reported
Owner/Operator Address: Not reported
Owner/Operator City,State,Zip: Not reported
Owner/Operator Telephone: Not reported
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Operator
Owner/Operator Name: CUMBERLAND FARMS INC
Legal Status: Private
Date Became Current: 20030910
Date Ended Current: Not reported
Owner/Operator Address: Not reported
Owner/Operator City,State,Zip: Not reported
Owner/Operator Telephone: Not reported
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Historic Generators:
Receive Date: 20060101
Handler Name: EXXON DIV OF CFI #70324
Federal Waste Generator Description: Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20070101
Handler Name: EXXON DIV OF CFI #70324
Federal Waste Generator Description: Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

EXXON DIV OF CFI #70324 (Continued) **1000244746**

Receive Date: 19880722
Handler Name: TOSCO#34748
Federal Waste Generator Description: Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20010808
Handler Name: TOSCO#34748
Federal Waste Generator Description: Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20041006
Handler Name: EXXON DIV OF CFI #70324
Federal Waste Generator Description: Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Code: 44711
NAICS Description: Gasoline Stations With Convenience Stores

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

FINDS:
Registry ID: 110004348386

EXXON DIV OF CFI #70324 (Continued) **1000244746**

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:
The Resource Conservation and Recovery Act Information System (RCRAInfo) is EPA's comprehensive information system in support of the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. It tracks many types of information about generators, transporters, treaters, storers, and disposers of hazardous waste.

Click this hyperlink while viewing on your computer to access additional FINDS: detail in the EDR Site Report.

ECHO:

Envid:	1000244746
Registry ID:	110004348386

DFR URL:

Name:	EXXON DIV OF CFI #70324
Address:	274 HAMILTON AVE & COTTAGE PLACE
City,State,Zip:	WHITE PLAINS, NY 10601

NY MANIFEST:

EPA ID:	NYD013387436
Country:	USA
Name:	Exxon Usa
Address:	274 HAMILTON AVE & COTTAGE PLA
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10601
Zip 4:	Not reported
Location Address 1:	274 HAMILTON AVENUE
Location Address 2:	Not reported
Location City,State,Zip:	WHITE PLAINS, NY 10602
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Exxon Usa
Mailing Contact:	Exxon Usa
Mailing Address 1:	274 HAMILTON AVENUE
Mailing Address 2:	Not reported
Mailing City,State,Zip:	WHITE PLAINS, NY 10602
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	0000000000

Manifest Data:

Document ID:	NYG3870036
Manifest Status:	Not reported
Trans1 State ID:	CA016
Year:	2003
Trans2 State ID:	Not reported
Generator Ship Date:	08/24/2003
Trans1 Recv Date:	08/24/2003
Trans2 Recv Date:	Not reported

EXXON DIV OF CFI #70324 (Continued) **1000244746**

TSD Site Recv Date:	08/26/2003
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD013387436
Trans1 EPA ID:	CAR000118992
Trans2 EPA ID:	Not reported
TSDF ID 1:	CTD002593887
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Ignitable Waste
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00200
Units:	Gallons (liquids only)
Number of Containers:	001
Container Type:	Portable tanks
Handling Method:	Burn
Specific Gravity:	01.00

Document ID:	NYB2443608
Manifest Status:	Not reported
Trans1 State ID:	LL5554
Year:	1991
Trans2 State ID:	Not reported
Generator Ship Date:	08/13/1991
Trans1 Recv Date:	08/13/1991
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	08/13/1991
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD013387436
Trans1 EPA ID:	NYD068011352
Trans2 EPA ID:	Not reported
TSDF ID 1:	NYD082785429
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported

EXXON DIV OF CFI #70324 (Continued) **1000244746**

Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	The Following Spent Halogenated Solvents Used In Degreasing: Tetrachloroethylene, Trichlorethylene, Methylene Chloride, 1,1,1-Trichloroethane, Carbon Tetrachloride And Chlorinated Fluorocarbons; All Spent Solvent Mixtures/Blends Used In Degreasing Containing, Before Use, A Total Of Ten Percent Or More (By Volume) Of One Or More Of The Above Halogenated Solvents Or Those Solvents Listed In F002, F004, And F005; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent Mixtures.
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	01000
Units:	Pounds
Number of Containers:	002
Container Type:	Metal drums, barrels, kegs
Handling Method:	Recycle
Specific Gravity:	01.00

Document ID:	CTF0649619
Manifest Status:	Not reported
Trans1 State ID:	V32578CT
Year:	1998
Trans2 State ID:	Not reported
Generator Ship Date:	02/27/1998
Trans1 Recv Date:	02/27/1998
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	03/02/1998
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD013387436
Trans1 EPA ID:	CTD021816889
Trans2 EPA ID:	Not reported
TSDF ID 1:	CTD021816889
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	The Following Spent Nonhalogenated Solvents: Toluene, Methyl Ethyl Ketone, Carbon Disulfide, Isobutanol, Pyridine, Benzene, 2-Ethoxyethanol, And 2-Nitropropane; All Spent Solvent Mixtures/Blends Containing, Before Use, A Total Of Ten Percent Or More (By Volume) Of One Or More Of The Above Nonhalogenated Solvents Or Those Solvents

EXXON DIV OF CFI #70324 (Continued) **1000244746**

Listed In F001, F002, Or F004; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent Mixtures.

Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 00055
Units: Gallons (liquids only)
Number of Containers: 001
Container Type: Metal drums, barrels, kegs
Handling Method: Treat
Specific Gravity: 01.00

Document ID: NJA2970029
Manifest Status: Not reported
Trans1 State ID: S6993
Year: 1998
Trans2 State ID: Not reported
Generator Ship Date: 07/22/1998
Trans1 Recv Date: 07/22/1998
Trans2 Recv Date: Not reported
TSD Site Recv Date: 07/22/1998
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYD013387436
Trans1 EPA ID: NJD980772768
Trans2 EPA ID: Not reported
TSDF ID 1: NJD991291105
TSDF ID 2: Not reported
Manifest Tracking Number: Not reported
Import Indicator: Not reported
Export Indicator: Not reported
Discr Quantity Indicator: Not reported
Discr Type Indicator: Not reported
Discr Residue Indicator: Not reported
Discr Partial Reject Indicator: Not reported
Discr Full Reject Indicator: Not reported
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: Not reported
Waste Code 1: Benzene
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 00070
Units: Pounds
Number of Containers: 001
Container Type: Metal drums, barrels, kegs
Handling Method: Burn
Specific Gravity: 01.00

Document ID: NYA8043237
Manifest Status: K - Completed after the designated time

EXXON DIV OF CFI #70324 (Continued) **1000244746**

Trans1 State ID:	000000000
Year:	1988
Trans2 State ID:	000000000
Generator Ship Date:	881101
Trans1 Recv Date:	881101
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	881102
Part A Recv Date:	881220
Part B Recv Date:	881118
Generator EPA ID:	NYD013387436
Trans1 EPA ID:	NYD980769947
Trans2 EPA ID:	Not reported
TSDF ID 1:	NYD043815703
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Ignitable Waste
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00450
Units:	Pounds
Number of Containers:	001
Container Type:	Metal drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	100

U227 **CELESTILA GROUP** **NY LTANKS S106385494**
East **14 MAMARONECK AVE** **NY Spills N/A**
1/8-1/4 **WHITE PLAINS, NY**
0.162 mi.
854 ft. **Site 3 of 15 in cluster U**

Relative:
Higher

Actual:
213 ft.

LTANKS:

Name:	CELESTILA GROUP
Address:	14 MAMARONECK AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0313324 / 2004-04-22
Facility ID:	0313324
Site ID:	229197
Spill Date:	2004-03-04
Spill Cause:	Tank Test Failure
Spill Source:	Non Major Facility > 1,100 gal
Spill Class:	C3
Cleanup Ceased:	Not reported

CELESTILA GROUP (Continued) **S106385494**

SWIS:	6017
Investigator:	JBODEE
Referred To:	WESTCHESTER CNTY HEALTH DEPT
Reported to Dept:	2004-03-04
CID:	444
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2004-03-04
Spill Record Last Update:	2024-06-12
Spiller Name:	Not reported
Spiller Company:	CELESTILA GROUP
Spiller Address:	14 MAMARONECK AVE
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	(646) 935-1200
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	188973
Latitude:	41.0321636
Longitude:	-73.7667844
DEC Memo:	04/22/04 TANK PASSED A RETEST ON 3-29-04. jbo
Remarks:	RECOMEND: EXCAVATE, AND RETEST

All TTF:

Facility ID:	0313324
Spill Number:	0313324
Spill Tank Test:	1529019
Site ID:	229197
Tank Number:	1
Tank Size:	3000
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	229197
Operable Unit ID:	880498
Operable Unit:	01
Material ID:	498477
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported

CELESTILA GROUP (Continued) **S106385494**

Units: G
Recovered: Not reported
Resource Affected: Groundwater
Oxygenate: Not reported

Name: OFFICE BUILDING
Address: 14 MAMARONECK AVE
City,State,Zip: WHITE PLAINS, NY
Spill Number/Closed Date: 9613653 / 1997-03-05
Facility ID: 9613653
Site ID: 284245
Spill Date: 1997-02-20
Spill Cause: Tank Test Failure
Spill Source: Commercial/Industrial
Spill Class: C3
Cleanup Ceased: Not reported
SWIS: 6017
Investigator: tdghiosa
Referred To: Not reported
Reported to Dept: 1997-02-20
CID: 257
Water Affected: Not reported
Spill Notifier: Tank Tester
Last Inspection: Not reported
Recommended Penalty: False
Meets Standard: True
UST Involvement: False
Remediation Phase: 0
Date Entered In Computer: 1997-02-20
Spill Record Last Update: 2005-11-08
Spiller Name: KEMPNER CORP
Spiller Company: OFFICE BUILDING
Spiller Address: 14 NANARONNECK AV
Spiller County: 001
Spiller Contact: KEMPNER CORP
Spiller Phone: (914) 946-3030
Spiller Extention: Not reported
DEC Region: 3
DER Facility ID: 188973
Latitude: 41.0321510
Longitude: -73.7667880
DEC Memo: Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY 03/05/1995 TANK PASSED A RETEST ON THIS DATE. NFA
Remarks: Not reported

All Materials:
Site ID: 284245
Operable Unit ID: 1041238
Operable Unit: 01
Material ID: 338758
Material Code: 0001A
Material Name: #2 fuel oil
Case No.: Not reported
Material FA: Petroleum
Quantity: .00
Units: G
Recovered: .00

CELESTILA GROUP (Continued) **S106385494**

Resource Affected: Soil
Oxygenate: Not reported

SPILLS:

Name:	COMMERICAL PBS LINE LEAK
Address:	14 MAMARONECK AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	2009897 / 2023-02-27
Facility ID:	2009897
Facility Type:	ER
DER Facility ID:	188973
Site ID:	616914
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	Not reported
SWIS:	6017
Spill Date:	2021-03-05
Investigator:	TDGHIOSA
Referred To:	Not reported
Reported to Dept:	2021-03-08
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Other
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2021-03-08
Spill Record Last Update:	2023-02-27
Spiller Name:	HIME RRACI
Spiller Company:	ROY PROPERTIES LLC
Spiller Address:	14 MAMARONECK AVE
Spiller Company:	999
Contact Name:	HIME RRACI
Latitude:	Not reported
Longitude:	Not reported
DEC Memo:	3/8/2021 Called back and spoke with Hime who told me that the return line from the boiler to the tank failed a tank test. The tank is a 3,000 gallon UST, however the lines run mostly above ground. There is a small drip in the return line above ground in the maintenance room, it is currently being caught by a funnel and a bucket beneath. Property is on municipal water and sewer. TJP 3/08/21: From Chris Lalak of WCDOH PBS: PBS site 3-801152 14 Mamaroneck Ave, White Plains 3k UST from 1960 Facility is in the midst of a gas conversion. Gas line is not yet active, but expected shortly. New ownership of the building. Oil lines are running into a cast iron secondary containment pipe and oil slowly dripping back into the boiler room, and being collected. Facility told to immediately set up a temp. tank or switch to a temporary line

CELESTILA GROUP (Continued) **S106385494**

and tested the rest of the
system. The location is reportedly on a busy city sidewalk and any
option will be challenging. Mr.
Rraci was calling the city of WP building inspector, to work on the
temp tank/Temp line and the gas
line completion. Owner Rraci Realty, Hime Rraci jod 3-31-21
Discussions w/WCHD (Chris and Natasha)
concerning situation. They report location is an busy intersection and
busy sidewalk. Chris reports
that return line has been disconnected and system converted to a one
line system. Site continues to
operate pending conversion. Based on conversation that this is
violation of regs, Chris is going to
inspect location with owner to see if there is a potential solution.
jc 06-08-21 Update from WCHD:
I met with the owner on site. Very challenging location for a temp
tank (Busy city sidewalk in
Downtown, White Plains). The facility agreed to pump out the tank I am
awaiting confirmation BTR
12-7-21 The copper piping is snaked through an old steel pipe that s
cutoff above the tank. Oil
spilled out of the pipe and contaminated the soil around the tank. ABC
Tank hand excavated 5 drums
of soil and had clean endpoints at the building. Soil Borings did not
encounter contamination and
ranged 10 to 15 below sidewalk. Weathered bedrock at 15 feet bgs on
the street side of the tank.
The building will acquire basement ASTs in the interim, and a plan
will be developed to address the
contamination around the tank. BTR 1/11/22 Email from Chris/WC saying
that owner appears for
hearing today w/no contractor. Owner is waiting for direction from the
State on how to proceed.
Hearing postponed. Chris also emailed Harry, who said report should be
submitted by end of this
week. jc 3/21/22 Jan 18 report from ECMS. Discusses contamination
found during Dec investigation,
temp system install and intent to close 3k UST. jc 10/21/22 Visited
site. Tank cut at half-way
point and top and bottom of tank removed. Sides left intact to support
soil from blowing in.
Contamination found beneath tank. Removed impacted soil up to
elevation of base of footing. Does
not want to excavate deeper as it may compromise structural integrity
of building. Gas and power
lines had to be cut off by Con-Ed the day prior in order to access
tank. Impacted soil moved to one
side of trench. Awaiting k-crete to backfill excavation and then move
impacted soil back to remove
other side. Photos uploaded to D2. BAG 12/30/22 Harry Sudwischer from
Environmental Consulting and
Management Services (ECMS) submitted a UST Closure Report and Spill
closure Request. Full Tank
removal was constrained by nearby gas and electric lines, so some
contaminated soil was left in
place. See report in DecDocs. NFA. TG

Remarks: Tank test failure-leak in return line to boiler.

CELESTILA GROUP (Continued) **S106385494**

All Materials:

Site ID:	616914
Operable Unit ID:	1364046
Operable Unit:	01
Material ID:	2376416
Material Code:	9999
Material Name:	other - tank test failure
Case No.:	Not reported
Material FA:	Other
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported
Resource Affected:	Not reported
Oxygenate:	Not reported

U228 **CALANO & CALANO REALTY CORP.** **NY UST** **U004439653**
East **14 MAMARONECK AVENUE** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.162 mi.
854 ft. **Site 4 of 15 in cluster U**

Relative: **Higher**

Actual: **213 ft.**

WESTCHESTER CO. UST:

Name:	CALANO & CALANO REALTY CORP.
Address:	14 MAMARONECK AVENUE
City,State,Zip:	WHITE PLAINS, NY 10601
Id/Status:	3-801152 / Active
Operator Name:	Michael Calano
Owner Name:	Calano & Calano Realty Corp
Owner Street:	14 Mamaroneck Avenue
Owner Address2:	3rd floor
Owner City:	White Plains
Owner State:	NY
Owner Zipcode:	10601
GDS Number:	Not reported
Tank Number:	1
Status:	1. In-Service
Capacity:	3000
Product Stored:	0001. #2 Fuel Oil
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	01/01/1960
Date Perm Closure:	01/01/1900
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	2. Underground/on Ground
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	0. None
Overfill Prevention:	5. Vent Whistle
Piping Secondary Containment:	0. None
Spill Prevention:	0. None
Dispenser:	2. Suction

U229 **WHITE PLAINS TOWN CENTER** **RCRA NonGen / NLR** **1001233124**
ENE **MAMARONECK AVE & MAIN ST** **NYR000062356**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.165 mi.
871 ft. **Site 5 of 15 in cluster U**

Relative:
Higher

Actual:
213 ft.

RCRA Listings:

Date Form Received by Agency:	20070101
Handler Name:	White Plains Town Center
Handler Address:	Mamaroneck Ave & Main St
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYR000062356
Contact Name:	CHARLES REID
Contact Address:	MAMARONECK AVE & MAIN ST
Contact City,State,Zip:	WHITE PLAINS, NY 10601
Contact Telephone:	212-715-0371
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Not reported
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R3
Mailing Address:	MAMARONECK AVE & MAIN ST
Mailing City,State,Zip:	WHITE PLAINS, NY 10601
Owner Name:	Tst White Plains Llc
Owner Type:	Private
Operator Name:	Tst White Plains Llc
Operator Type:	Private
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No

WHITE PLAINS TOWN CENTER (Continued) **1001233124**

Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20150414
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Handler - Owner Operator:

Owner/Operator Indicator:	Owner
Owner/Operator Name: TST WHITE PLAINS LLC	
Legal Status:	Private
Date Became Current:	Not reported
Date Ended Current:	Not reported
Owner/Operator Address:	520 MADISON AVE
Owner/Operator City,State,Zip:	NEW YORK, NY 10022
Owner/Operator Telephone:	212-715-0371
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported
Owner/Operator Email:	Not reported

Owner/Operator Indicator:	Operator
Owner/Operator Name: TST WHITE PLAINS LLC	
Legal Status:	Private
Date Became Current:	Not reported
Date Ended Current:	Not reported
Owner/Operator Address:	520 MADISON AVE
Owner/Operator City,State,Zip:	NEW YORK, NY 10022
Owner/Operator Telephone:	212-715-0371
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported
Owner/Operator Email:	Not reported

Owner/Operator Indicator:	Owner
Owner/Operator Name: TST WHITE PLAINS LLC	
Legal Status:	Private
Date Became Current:	Not reported
Date Ended Current:	Not reported
Owner/Operator Address:	520 MADISON AVE
Owner/Operator City,State,Zip:	NEW YORK, NY 10022
Owner/Operator Telephone:	212-715-0371
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported
Owner/Operator Email:	Not reported

Historic Generators:

Receive Date:	20060101

WHITE PLAINS TOWN CENTER (Continued) **1001233124**

Handler Name: WHITE PLAINS TOWN CENTER
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20070101
Handler Name: WHITE PLAINS TOWN CENTER
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 19981020
Handler Name: WHITE PLAINS TOWN CENTER
Federal Waste Generator Description: Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

U230 **CVS PHARMACY #4745** **PA MANIFEST** **S118068905**
East **24 MAMARONECK AVE** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.165 mi.
873 ft. **Site 6 of 15 in cluster U**

Relative:
Higher

Actual:
213 ft.

PA MANIFEST:

Name:	CVS PHARMACY #4745
Address:	24 MAMARONECK AVE
City,State,Zip:	WHITE PLAINS, NY 10601
Year:	2015
Manifest Number:	006247110FLE
Manifest Type:	T
Generator EPA ID:	NYR000194852
Generator Date:	01/13/2015
Mailing Address:	Not reported
Contact Name:	Not reported
Contact Phone:	401-765-1500
TSD EPA ID:	Not reported
TSD Date:	Not reported
TSD Facility Name:	Republic Environmental Systems (Pennsylvania) LLC
TSD Facility Address:	2869 Sandstone Dr
TSD Facility City:	Hatfield
TSD Facility State:	PA
Facility Telephone:	Not reported
Page Number:	1
Line Number:	1
Waste Number:	D001
Container Number:	1
Container Type:	BA
Waste Quantity:	9
Unit:	P
Handling Code:	Not reported
TSP EPA ID:	PAD085690592
Date TSP Sig:	Not reported

Year:	2015
Manifest Number:	006247110FLE
Manifest Type:	T
Generator EPA ID:	NYR000194852
Generator Date:	01/13/2015
Mailing Address:	Not reported
Contact Name:	Not reported
Contact Phone:	401-765-1500
TSD EPA ID:	Not reported
TSD Date:	Not reported
TSD Facility Name:	Republic Environmental Systems (Pennsylvania) LLC
TSD Facility Address:	2869 Sandstone Dr
TSD Facility City:	Hatfield
TSD Facility State:	PA
Facility Telephone:	Not reported
Page Number:	1
Line Number:	2
Waste Number:	U002
Container Number:	1
Container Type:	BA
Waste Quantity:	2
Unit:	P
Handling Code:	Not reported

CVS PHARMACY #4745 (Continued) **S118068905**

TSP EPA ID:	PAD085690592
Date TSP Sig:	Not reported
Year:	2015
Manifest Number:	006247110FLE
Manifest Type:	T
Generator EPA ID:	NYR000194852
Generator Date:	01/13/2015
Mailing Address:	Not reported
Contact Name:	Not reported
Contact Phone:	401-765-1500
TSD EPA ID:	Not reported
TSD Date:	Not reported
TSD Facility Name:	Republic Environmental Systems (Pennsylvania) LLC
TSD Facility Address:	2869 Sandstone Dr
TSD Facility City:	Hatfield
TSD Facility State:	PA
Facility Telephone:	Not reported
Page Number:	1
Line Number:	2
Waste Number:	D001
Container Number:	1
Container Type:	BA
Waste Quantity:	2
Unit:	P
Handling Code:	Not reported
TSP EPA ID:	PAD085690592
Date TSP Sig:	Not reported
Year:	2015
Manifest Number:	006247110FLE
Manifest Type:	T
Generator EPA ID:	NYR000194852
Generator Date:	01/13/2015
Mailing Address:	Not reported
Contact Name:	Not reported
Contact Phone:	401-765-1500
TSD EPA ID:	Not reported
TSD Date:	Not reported
TSD Facility Name:	Republic Environmental Systems (Pennsylvania) LLC
TSD Facility Address:	2869 Sandstone Dr
TSD Facility City:	Hatfield
TSD Facility State:	PA
Facility Telephone:	Not reported
Page Number:	1
Line Number:	3
Waste Number:	D001
Container Number:	1
Container Type:	CF
Waste Quantity:	1
Unit:	P
Handling Code:	Not reported
TSP EPA ID:	PAD085690592
Date TSP Sig:	Not reported
Year:	2015
Manifest Number:	006247110FLE

CVS PHARMACY #4745 (Continued) **S118068905**

Manifest Type:	T
Generator EPA ID:	NYR000194852
Generator Date:	01/13/2015
Mailing Address:	Not reported
Contact Name:	Not reported
Contact Phone:	401-765-1500
TSD EPA ID:	Not reported
TSD Date:	Not reported
TSD Facility Name:	Republic Environmental Systems (Pennsylvania) LLC
TSD Facility Address:	2869 Sandstone Dr
TSD Facility City:	Hatfield
TSD Facility State:	PA
Facility Telephone:	Not reported
Page Number:	1
Line Number:	3
Waste Number:	U165
Container Number:	1
Container Type:	CF
Waste Quantity:	1
Unit:	P
Handling Code:	Not reported
TSP EPA ID:	PAD085690592
Date TSP Sig:	Not reported

Year:	2015
Manifest Number:	006247110FLE
Manifest Type:	T
Generator EPA ID:	NYR000194852
Generator Date:	01/13/2015
Mailing Address:	Not reported
Contact Name:	Not reported
Contact Phone:	401-765-1500
TSD EPA ID:	Not reported
TSD Date:	Not reported
TSD Facility Name:	Republic Environmental Systems (Pennsylvania) LLC
TSD Facility Address:	2869 Sandstone Dr
TSD Facility City:	Hatfield
TSD Facility State:	PA
Facility Telephone:	Not reported
Page Number:	1
Line Number:	4
Waste Number:	D009
Container Number:	1
Container Type:	CF
Waste Quantity:	2
Unit:	P
Handling Code:	Not reported
TSP EPA ID:	PAD085690592
Date TSP Sig:	Not reported

Year:	2014
Manifest Number:	007274278FLE
Manifest Type:	T
Generator EPA ID:	NYR000194852
Generator Date:	11/11/2014
Mailing Address:	Not reported
Contact Name:	Not reported

CVS PHARMACY #4745 (Continued) **S118068905**

Contact Phone:	401-765-1500
TSD EPA ID:	Not reported
TSD Date:	Not reported
TSD Facility Name:	Republic Environmental Systems (Pennsylvania) LLC
TSD Facility Address:	2869 Sandstone Dr
TSD Facility City:	Hatfield
TSD Facility State:	PA
Facility Telephone:	Not reported
Page Number:	1
Line Number:	1
Waste Number:	D001
Container Number:	1
Container Type:	BA
Waste Quantity:	4
Unit:	P
Handling Code:	Not reported
TSP EPA ID:	PAD085690592
Date TSP Sig:	Not reported

Year:	2014
Manifest Number:	007274278FLE
Manifest Type:	T
Generator EPA ID:	NYR000194852
Generator Date:	11/11/2014
Mailing Address:	Not reported
Contact Name:	Not reported
Contact Phone:	401-765-1500
TSD EPA ID:	Not reported
TSD Date:	Not reported
TSD Facility Name:	Republic Environmental Systems (Pennsylvania) LLC
TSD Facility Address:	2869 Sandstone Dr
TSD Facility City:	Hatfield
TSD Facility State:	PA
Facility Telephone:	Not reported
Page Number:	1
Line Number:	2
Waste Number:	U002
Container Number:	1
Container Type:	BA
Waste Quantity:	6
Unit:	P
Handling Code:	Not reported
TSP EPA ID:	PAD085690592
Date TSP Sig:	Not reported

Year:	2014
Manifest Number:	007274278FLE
Manifest Type:	T
Generator EPA ID:	NYR000194852
Generator Date:	11/11/2014
Mailing Address:	Not reported
Contact Name:	Not reported
Contact Phone:	401-765-1500
TSD EPA ID:	Not reported
TSD Date:	Not reported
TSD Facility Name:	Republic Environmental Systems (Pennsylvania) LLC
TSD Facility Address:	2869 Sandstone Dr

CVS PHARMACY #4745 (Continued) **S118068905**

TSD Facility City:	Hatfield
TSD Facility State:	PA
Facility Telephone:	Not reported
Page Number:	1
Line Number:	2
Waste Number:	D001
Container Number:	1
Container Type:	BA
Waste Quantity:	6
Unit:	P
Handling Code:	Not reported
TSP EPA ID:	PAD085690592
Date TSP Sig:	Not reported
Year:	2014
Manifest Number:	007274278FLE
Manifest Type:	T
Generator EPA ID:	NYR000194852
Generator Date:	11/11/2014
Mailing Address:	Not reported
Contact Name:	Not reported
Contact Phone:	401-765-1500
TSD EPA ID:	Not reported
TSD Date:	Not reported
TSD Facility Name:	Republic Environmental Systems (Pennsylvania) LLC
TSD Facility Address:	2869 Sandstone Dr
TSD Facility City:	Hatfield
TSD Facility State:	PA
Facility Telephone:	Not reported
Page Number:	1
Line Number:	3
Waste Number:	D002
Container Number:	1
Container Type:	CF
Waste Quantity:	3
Unit:	P
Handling Code:	Not reported
TSP EPA ID:	PAD085690592
Date TSP Sig:	Not reported
Year:	2014
Manifest Number:	007274278FLE
Manifest Type:	T
Generator EPA ID:	NYR000194852
Generator Date:	11/11/2014
Mailing Address:	Not reported
Contact Name:	Not reported
Contact Phone:	401-765-1500
TSD EPA ID:	Not reported
TSD Date:	Not reported
TSD Facility Name:	Republic Environmental Systems (Pennsylvania) LLC
TSD Facility Address:	2869 Sandstone Dr
TSD Facility City:	Hatfield
TSD Facility State:	PA
Facility Telephone:	Not reported
Page Number:	1
Line Number:	4

CVS PHARMACY #4745 (Continued) **S118068905**

Waste Number:	D001
Container Number:	1
Container Type:	DM
Waste Quantity:	66
Unit:	P
Handling Code:	Not reported
TSP EPA ID:	PAD085690592
Date TSP Sig:	Not reported

Click this hyperlink while viewing on your computer to access
1 additional PA MANIFEST: record(s) in the EDR Site Report.

U231 **CVS** **RCRA-VSQG** **1014958239**
East **24 MAMARONECK AVENUE** **E MANIFEST** **NYR000194852**
1/8-1/4 **WHITE PLAINS, NY 10601** **NY MANIFEST**
0.165 mi.
873 ft. **Site 7 of 15 in cluster U**

Relative: **Higher**

Actual: **213 ft.**

RCRA Listings:

Date Form Received by Agency:	20201212
Handler Name:	Cvs Pharmacy #4745
Handler Address:	Mamaroneck St
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYR000194852
Contact Name:	NICOLE WILKINSON
Contact Address:	CVS DR MC2340
Contact City,State,Zip:	WOONSOCKET, RI 02895
Contact Telephone:	401-770-7132
Contact Fax:	315-454-4467
Contact Email:	NICOLE.WILKINSON@CVSHEALTH.COM
Contact Title:	DIRECTOR, CORPORATE ENVIRONMENTAL
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Conditionally Exempt Small Quantity Generator
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Handler Activities
State District Owner:	Ny
State District:	NYSDEC R3
Mailing Address:	CVS DR MC2340
Mailing City,State,Zip:	WOONSOCKET, RI 02895
Owner Name:	24-26 Mamaroneck Avenue, Llc
Owner Type:	Private
Operator Name:	Cvs Albany, Llc
Operator Type:	Private
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No

CVS (Continued) **1014958239**

Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20201217
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Biennial: List of Years
Year: 2017

Click Here for Biennial Reporting System Data:
Year: 2015

Click Here for Biennial Reporting System Data:
Year: 2013

Click Here for Biennial Reporting System Data:

Hazardous Waste Summary:

Waste Code:	D001
Waste Description:	Ignitable Waste
Waste Code:	D002
Waste Description:	Corrosive Waste
Waste Code:	D007
Waste Description:	Chromium
Waste Code:	D009
Waste Description:	Mercury
Waste Code:	D010
Waste Description:	Selenium

CVS (Continued) **1014958239**

Waste Code: D011
Waste Description: Silver

Waste Code: D024
Waste Description: M-Cresol

Waste Code: P001
Waste Description: 2h-1-Benzopyran-2-One, 4-Hydroxy-3-(3-Oxo-1-Phenylbutyl)-, & Salts, When Present At Concentrations Greater Than 0.3% (Or) Warfarin, & Salts, When Present At Concentrations Greater Than 0.3%

Waste Code: P042
Waste Description: 1,2-Benzenediol, 4-[1-Hydroxy-2-(Methylamino)Ethyl]-, (R)- (Or) Epinephrine

Waste Code: P075
Waste Description: Nicotine, & Salts (Or) Pyridine, 3-(1-Methyl-2-Pyrrolidinyl)-,(S)-, & Salts

Waste Code: P081
Waste Description: 1,2,3-Propanetriol, Trinitrate (R) (Or) Nitroglycerine (R)

Waste Code: P188
Waste Description: Benzoic Acid, 2-Hydroxy-, Compd. With (3as-Cis)-1,2,3,3a,8,8a-Hexahydro-1,3a,8-Trimethylpyrrolo[2,3-B]Indol-5-Yl Methylcarbamate Ester (1:1) (Or) Physostigmine Salicylate

Waste Code: U002
Waste Description: 2-Propanone (I) (Or) Acetone (I)

Waste Code: U129
Waste Description: Cyclohexane, 1,2,3,4,5,6-Hexachloro-, (1alpha, 2alpha, 3beta, 4alpha, 5alpha, 6beta)- (Or) Lindane

Waste Code: U165
Waste Description: Naphthalene

Waste Code: U205
Waste Description: Selenium Sulfide (Or) Selenium Sulfide Ses2 (R,T)

Handler - Owner Operator:
Owner/Operator Indicator: Owner
Owner/Operator Name: 24-26 MAMARONECK AVENUE, LLC
Legal Status: Private
Date Became Current: 20070726
Date Ended Current: Not reported
Owner/Operator Address: 237 MAMARONECK AVENUE
Owner/Operator City,State,Zip: WHITE PLAINS, NY 10605
Owner/Operator Telephone: 914-683-8000
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Operator
Owner/Operator Name: CVS ALBANY LLC
Legal Status: Private
Date Became Current: 20071104

CVS (Continued) **1014958239**

Date Ended Current: Not reported
Owner/Operator Address: Not reported
Owner/Operator City,State,Zip: Not reported
Owner/Operator Telephone: Not reported
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Operator
Owner/Operator Name: CVS ALBANY LLC
Legal Status: Private
Date Became Current: 20071104
Date Ended Current: Not reported
Owner/Operator Address: 237 MAMARONECK AVE
Owner/Operator City,State,Zip: WHITE PLAINS, NY 10605
Owner/Operator Telephone: Not reported
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Owner
Owner/Operator Name: 24-26 MAMARONECK AVENUE LLC
Legal Status: Private
Date Became Current: 20070726
Date Ended Current: Not reported
Owner/Operator Address: 237 MAMARONECK AVE
Owner/Operator City,State,Zip: WHITE PLAINS, NY 10605
Owner/Operator Telephone: 914-683-8000
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Operator
Owner/Operator Name: CVS ALBANY, L.L.C.
Legal Status: Private
Date Became Current: 20071104
Date Ended Current: Not reported
Owner/Operator Address: 1 CVS DR
Owner/Operator City,State,Zip: WOONSOCKET, RI 02895
Owner/Operator Telephone: Not reported
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Owner
Owner/Operator Name: 24-26 MAMARONECK AVENUE, LLC
Legal Status: Private
Date Became Current: 20070726
Date Ended Current: Not reported
Owner/Operator Address: 237 MAMARONECK AVENUE
Owner/Operator City,State,Zip: WHITE PLAINS, NY 10605
Owner/Operator Telephone: 914-683-8000
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Operator

CVS (Continued) **1014958239**

Owner/Operator Name: CVS ALBANY, LLC
Legal Status: Private
Date Became Current: 20071104
Date Ended Current: Not reported
Owner/Operator Address: 1 CVS DR
Owner/Operator City,State,Zip: WOONSOCKET, RI 02895
Owner/Operator Telephone: 401-765-1500
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Owner
Owner/Operator Name: 24-26 MAMARONECK AVENUE LLC
Legal Status: Private
Date Became Current: 20070726
Date Ended Current: Not reported
Owner/Operator Address: 237 MAMARONECK AVE
Owner/Operator City,State,Zip: WHITE PLAINS, NY 10605
Owner/Operator Telephone: 914-683-8000
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Owner
Owner/Operator Name: 24-26 MAMARONECK AVENUE, LLC
Legal Status: Private
Date Became Current: 20070726
Date Ended Current: Not reported
Owner/Operator Address: 237 MAMARONECK AVENUE
Owner/Operator City,State,Zip: WHITE PLAINS, NY 10605
Owner/Operator Telephone: Not reported
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Operator
Owner/Operator Name: CVS ALBANY, LLC
Legal Status: Private
Date Became Current: 20071104
Date Ended Current: Not reported
Owner/Operator Address: 1 CVS DR
Owner/Operator City,State,Zip: WOONSOCKET, RI 02895
Owner/Operator Telephone: 401-765-1500
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Historic Generators:
Receive Date: 20140317
Handler Name: CVS PHARMACY #4745
Federal Waste Generator Description: Large Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No

CVS (Continued) **1014958239**

Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20160317
Handler Name: CVS PHARMACY #4745
Federal Waste Generator Description: Large Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20180129
Handler Name: CVS PHARMACY #4745
Federal Waste Generator Description: Large Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: No
Electronic Manifest Broker: No

Receive Date: 20120305
Handler Name: CVS PHARMACY #4745
Federal Waste Generator Description: Small Quantity Generator
State District Owner: Not reported
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20201212
Handler Name: CVS PHARMACY #4745
Federal Waste Generator Description: Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: No
Electronic Manifest Broker: No

CVS (Continued) **1014958239**

List of NAICS Codes and Descriptions:
NAICS Code: 44611
NAICS Description: Pharmacies And Drug Stores

NAICS Code: 812922
NAICS Description: One-Hour Photofinishing

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

E MANIFEST:

Manifest Tracking Number:	016000883FLE
Last Updated Date:	20210813
Shipped Date:	20210728
Received Date:	20210806
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	NYR000194852
Generator Name:	Cvs
Generator Location Street Number:	Not reported
Generator Location Street 1:	24 MAMARONECK AVENUE
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601-3308
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	24 Mamaroneck Ave
Generator Mail Street 2:	Not reported
Generator Mail City:	White Plains
Generator Mail Zip:	10601-3308
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	RID040098352
Designated Facility Name:	Northland Environmental, Llc
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	275 Allens Avenue
Designated Facility Mail City:	Providence
Designated Facility Mail Zip:	02905
Designated Facility Mail State:	RI
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	275 Allens Avenue
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	Providence
Designated Facility Location Zip:	02905
Designated Facility Location State:	RI
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

CVS (Continued) **1014958239**

Manifest Tracking Number:	013395672FLE
Last Updated Date:	20191231
Shipped Date:	20190906
Received Date:	20190920
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	NYR000194852
Generator Name:	Cvs
Generator Location Street Number:	Not reported
Generator Location Street 1:	24 MAMARONECK AVENUE
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601-3308
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	24 Mamaroneck Ave
Generator Mail Street 2:	Not reported
Generator Mail City:	White Plains
Generator Mail Zip:	10601-3308
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	INR000110197
Designated Facility Name:	Stericycle Environmental Solutions, Inc. Indianapolis
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	2770 Fortune Circle East
Designated Facility Mail City:	Indianapolis
Designated Facility Mail Zip:	46241
Designated Facility Mail State:	IN
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	2770 Fortune Circle East
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	Indianapolis
Designated Facility Location Zip:	46241
Designated Facility Location State:	IN
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Manifest Tracking Number:	013395673FLE
Last Updated Date:	20200107
Shipped Date:	20190906
Received Date:	20190917
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	NYR000194852
Generator Name:	Cvs
Generator Location Street Number:	Not reported
Generator Location Street 1:	24 MAMARONECK AVENUE
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601-3308
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	24 Mamaroneck Ave

CVS (Continued) **1014958239**

Generator Mail Street 2:	Not reported
Generator Mail City:	White Plains
Generator Mail Zip:	10601-3308
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	RID040098352
Designated Facility Name:	Northland Environmental, Llc
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	275 Allens Avenue
Designated Facility Mail City:	Providence
Designated Facility Mail Zip:	02905
Designated Facility Mail State:	RI
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	275 Allens Avenue
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	Providence
Designated Facility Location Zip:	02905
Designated Facility Location State:	RI
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Manifest Tracking Number:	015580673FLE
Last Updated Date:	20210128
Shipped Date:	20210120
Received Date:	20210127
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	NYR000194852
Generator Name:	Cvs
Generator Location Street Number:	Not reported
Generator Location Street 1:	24 MAMARONECK AVENUE
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601-3308
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	24 Mamaroneck Ave
Generator Mail Street 2:	Not reported
Generator Mail City:	White Plains
Generator Mail Zip:	10601-3308
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	RID040098352
Designated Facility Name:	Northland Environmental, Llc
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	275 Allens Avenue
Designated Facility Mail City:	Providence
Designated Facility Mail Zip:	02905
Designated Facility Mail State:	RI
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	275 Allens Avenue
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	Providence

CVS (Continued) **1014958239**

Designated Facility Location Zip:	02905
Designated Facility Location State:	RI
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N
Manifest Tracking Number:	015582051FLE
Last Updated Date:	20210407
Shipped Date:	20210324
Received Date:	20210401
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	NYR000194852
Generator Name:	Cvs
Generator Location Street Number:	Not reported
Generator Location Street 1:	24 MAMARONECK AVENUE
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601-3308
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	24 Mamaroneck Ave
Generator Mail Street 2:	Not reported
Generator Mail City:	White Plains
Generator Mail Zip:	10601-3308
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	RID040098352
Designated Facility Name:	Northland Environmental, Llc
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	275 Allens Avenue
Designated Facility Mail City:	Providence
Designated Facility Mail Zip:	02905
Designated Facility Mail State:	RI
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	275 Allens Avenue
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	Providence
Designated Facility Location Zip:	02905
Designated Facility Location State:	RI
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N
Manifest Tracking Number:	014958177FLE
Last Updated Date:	20200730
Shipped Date:	20200714
Received Date:	20200722
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	NYR000194852
Generator Name:	Cvs
Generator Location Street Number:	Not reported
Generator Location Street 1:	24 MAMARONECK AVENUE

CVS (Continued) **1014958239**

Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601-3308
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	24 Mamaroneck Ave
Generator Mail Street 2:	Not reported
Generator Mail City:	White Plains
Generator Mail Zip:	10601-3308
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	RID040098352
Designated Facility Name:	Northland Environmental, Llc
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	275 Allens Avenue
Designated Facility Mail City:	Providence
Designated Facility Mail Zip:	02905
Designated Facility Mail State:	RI
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	275 Allens Avenue
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	Providence
Designated Facility Location Zip:	02905
Designated Facility Location State:	RI
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Manifest Tracking Number:	200781362CLE
Last Updated Date:	20240701
Shipped Date:	20240424
Received Date:	20240515
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	NYR000194852
Generator Name:	Cvs Pharmacy
Generator Location Street Number:	26-32
Generator Location Street 1:	26-32 MAMARONECK ST.
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601
Generator Mail Street Number:	1
Generator Mail Street 1:	24 MAMARONECK ST.
Generator Mail Street 2:	Not reported
Generator Mail City:	WHITE PLAINS
Generator Mail Zip:	10601
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	PAD085690592
Designated Facility Name:	Republic Environmental Systems, Inc. (Pa) (Esol)
Designated Facility Mail Street Number:	2869
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	SANDSTONE DRIVE
Designated Facility Mail City:	HATFIELD

CVS (Continued) **1014958239**

Designated Facility Mail Zip:	19440
Designated Facility Mail State:	PA
Designated Facility Location Street Number:	2869
Designated Facility Location Street 1:	SANDSTONE DRIVE
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	HATFIELD
Designated Facility Location Zip:	19440
Designated Facility Location State:	PA
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Manifest Tracking Number:	013383562FLE
Last Updated Date:	20200401
Shipped Date:	20200313
Received Date:	20200319
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	NYR000194852
Generator Name:	Cvs
Generator Location Street Number:	Not reported
Generator Location Street 1:	24 MAMARONECK AVENUE
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601-3308
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	24 Mamaroneck Ave
Generator Mail Street 2:	Not reported
Generator Mail City:	White Plains
Generator Mail Zip:	10601-3308
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	RID040098352
Designated Facility Name:	Northland Environmental, Llc
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	275 Allens Avenue
Designated Facility Mail City:	Providence
Designated Facility Mail Zip:	02905
Designated Facility Mail State:	RI
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	275 Allens Avenue
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	Providence
Designated Facility Location Zip:	02905
Designated Facility Location State:	RI
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Manifest Tracking Number:	013383561FLE
Last Updated Date:	20200511
Shipped Date:	20200313
Received Date:	20200319
Manifest Status:	Signed

CVS (Continued) **1014958239**

Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	NYR000194852
Generator Name:	Cvs
Generator Location Street Number:	Not reported
Generator Location Street 1:	24 MAMARONECK AVENUE
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601-3308
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	24 Mamaroneck Ave
Generator Mail Street 2:	Not reported
Generator Mail City:	White Plains
Generator Mail Zip:	10601-3308
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	INR000110197
Designated Facility Name:	Stericycle Environmental Solutions, Inc. Indianapolis
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	2770 Fortune Circle East
Designated Facility Mail City:	Indianapolis
Designated Facility Mail Zip:	46241
Designated Facility Mail State:	IN
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	2770 Fortune Circle East
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	Indianapolis
Designated Facility Location Zip:	46241
Designated Facility Location State:	IN
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Manifest Tracking Number:	011396094FLE
Last Updated Date:	20200616
Shipped Date:	20200108
Received Date:	20200123
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	NYR000194852
Generator Name:	Cvs #04745
Generator Location Street Number:	Not reported
Generator Location Street 1:	24 MAMARONECK ST
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	24 MAMARONECK ST
Generator Mail Street 2:	Not reported
Generator Mail City:	WHITE PLAINS
Generator Mail Zip:	10601
Generator Mail State:	NY
Generator Contact Company Name:	Not reported

CVS (Continued) **1014958239**

Designated Facility EPA ID:	INR000110197
Designated Facility Name:	Stericycle Environmental Solutions Incorporated
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	2770 FORTUNE CIRCLE DR
Designated Facility Mail City:	INDIANAPOLIS
Designated Facility Mail Zip:	46241
Designated Facility Mail State:	IN
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	2770 FORTUNE CIRCLE DR
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	INDIANAPOLIS
Designated Facility Location Zip:	46241
Designated Facility Location State:	IN
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Manifest Tracking Number:	011396095FLE
Last Updated Date:	20200128
Shipped Date:	20200108
Received Date:	20200114
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	NYR000194852
Generator Name:	Cvs
Generator Location Street Number:	Not reported
Generator Location Street 1:	24 MAMARONECK AVENUE
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601-3308
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	24 Mamaroneck Ave
Generator Mail Street 2:	Not reported
Generator Mail City:	White Plains
Generator Mail Zip:	10601-3308
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	RID040098352
Designated Facility Name:	Northland Environmental, Llc
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	275 Allens Avenue
Designated Facility Mail City:	Providence
Designated Facility Mail Zip:	02905
Designated Facility Mail State:	RI
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	275 Allens Avenue
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	Providence
Designated Facility Location Zip:	02905
Designated Facility Location State:	RI
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

CVS (Continued) **1014958239**

Federal Waste:
Manifest Tracking Number: 015990780FLE
Waste Line Number: 1
Federal Waste Code: D001
Federal Waste: IGNITABLE WASTE

Manifest Tracking Number: 015990780FLE
Waste Line Number: 1
Federal Waste Code: U002
Federal Waste: 2-PROPANONE (I) (OR) ACETONE (I)

Manifest Tracking Number: 015990780FLE
Waste Line Number: 2
Federal Waste Code: D001
Federal Waste: IGNITABLE WASTE

Manifest Tracking Number: 015990780FLE
Waste Line Number: 3
Federal Waste Code: D007
Federal Waste: CHROMIUM

Manifest Tracking Number: 015990780FLE
Waste Line Number: 3
Federal Waste Code: D010
Federal Waste: SELENIUM

State Waste:
Manifest Tracking Number: 015990780FLE
Waste Line Number: 1
State Waste Code Owner: NY
State Waste Code: B
State Waste: Incineration, heat recovery, burning. Waste management method code to be used on e-Manifest only

Manifest Tracking Number: 015990780FLE
Waste Line Number: 2
State Waste Code Owner: NY
State Waste Code: B
State Waste: Incineration, heat recovery, burning. Waste management method code to be used on e-Manifest only

Manifest Tracking Number: 015990780FLE
Waste Line Number: 3
State Waste Code Owner: NY
State Waste Code: B
State Waste: Incineration, heat recovery, burning. Waste management method code to be used on e-Manifest only

Manifest Tracking Number: 015990780FLE
Waste Line Number: 4
State Waste Code Owner: RI
State Waste Code: R015
State Waste: Non-hazardous waste, manifest required by receiving state

Transporter:
Manifest Tracking Number: 015990780FLE

CVS (Continued) **1014958239**

Transporter Line Number: 1
Transporter EPA ID: PAD982661381
Transporter Name: Republic Environmental Systems

Waste Line:
Manifest Tracking Number: 015990780FLE
Waste Line Number: 1
U.S. DOT Hazardous Indicator: Y
U.S. DOT ID Number: UN1993
U.S. DOT Description: Un1993, Waste Flammable Liquids, N.O.S. (Alcohols, Acetone), 3, Pg Ii, Erg#128
Non-Hazardous Waste Description: Not reported
Number of Containers: 1
Container Type Code: BA
Container Type Description: Burlap, cloth, paper, or plastic bags
Waste Quantity: 13
Quantity Unit of Measure Code: P
Quantity Unit of Measure Description: Pounds
Waste Quantity, in Tons: 0.0065
Acute Waste Quantity, in Tons: 0
Non-Acute Waste Quantity, in Tons: 0.0065
Waste Quantity, in Kilograms: 5.895695
Acute Waste Quantity, in Kilograms: 0
Non-Acute Waste Quantity, in Kilorgrams: 5.895695
Management Method Code: H141
Management Method Description: STORAGE, BULKING AND/OR TRANSFER OFF SITE
Waste Residue Indicator: N
Quantity Discrepancy Indicator: N
Waste Type Discrepancy Indicator: N
Waste Density: Not reported
Waste Density Unit of Measure Code: Not reported
Waste Density Unit of Measure Description: Not reported
Form Code: Not reported
Form Code Description: Not reported
Source Code: Not reported
Source Code Description: Not reported
Waste Minimization Code: Not reported
Waste Minimization Code Description: Not reported
Consent Number: Not reported
EPA Waste Indicator: Y

Manifest Tracking Number: 015990780FLE
Waste Line Number: 2
U.S. DOT Hazardous Indicator: Y
U.S. DOT ID Number: UN1950
U.S. DOT Description: Un1950, Waste Aerosols 2.1, Erg#126
Non-Hazardous Waste Description: Not reported
Number of Containers: 1
Container Type Code: BA
Container Type Description: Burlap, cloth, paper, or plastic bags
Waste Quantity: 4
Quantity Unit of Measure Code: P
Quantity Unit of Measure Description: Pounds
Waste Quantity, in Tons: 0.002
Acute Waste Quantity, in Tons: 0
Non-Acute Waste Quantity, in Tons: 0.002
Waste Quantity, in Kilograms: 1.8140601

CVS (Continued) **1014958239**

Acute Waste Quantity, in Kilograms:	0
Non-Acute Waste Quantity, in Kilorgrams:	1.8140601
Management Method Code:	H141
Management Method Description:	STORAGE, BULKING AND/OR TRANSFER OFF SITE
Waste Residue Indicator:	N
Quantity Discrepancy Indicator:	N
Waste Type Discrepancy Indicator:	N
Waste Density:	Not reported
Waste Density Unit of Measure Code:	Not reported
Waste Density Unit of Measure Description:	Not reported
Form Code:	Not reported
Form Code Description:	Not reported
Source Code:	Not reported
Source Code Description:	Not reported
Waste Minimization Code:	Not reported
Waste Minimization Code Description:	Not reported
Consent Number:	Not reported
EPA Waste Indicator:	Y

Manifest Tracking Number:	015990780FLE
Waste Line Number:	3
U.S. DOT Hazardous Indicator:	Y
U.S. DOT ID Number:	UN2811
U.S. DOT Description:	Un2811, Waste Toxic Solids, Organic, N.O.S. (Chromium, Selenium), 6.1, Pg Ii, Erg#154
Non-Hazardous Waste Description:	Not reported
Number of Containers:	1
Container Type Code:	CF
Container Type Description:	Fiber or plastic boxes, cartons, cases
Waste Quantity:	5
Quantity Unit of Measure Code:	P
Quantity Unit of Measure Description:	Pounds
Waste Quantity, in Tons:	0.0025
Acute Waste Quantity, in Tons:	0
Non-Acute Waste Quantity, in Tons:	0.0025
Waste Quantity, in Kilograms:	2.267575
Acute Waste Quantity, in Kilograms:	0
Non-Acute Waste Quantity, in Kilorgrams:	2.267575
Management Method Code:	H141
Management Method Description:	STORAGE, BULKING AND/OR TRANSFER OFF SITE
Waste Residue Indicator:	N
Quantity Discrepancy Indicator:	N
Waste Type Discrepancy Indicator:	N
Waste Density:	Not reported
Waste Density Unit of Measure Code:	Not reported
Waste Density Unit of Measure Description:	Not reported
Form Code:	Not reported
Form Code Description:	Not reported
Source Code:	Not reported
Source Code Description:	Not reported
Waste Minimization Code:	Not reported
Waste Minimization Code Description:	Not reported
Consent Number:	Not reported
EPA Waste Indicator:	Y

Manifest Tracking Number:	015990780FLE
Waste Line Number:	4

CVS (Continued) **1014958239**

U.S. DOT Hazardous Indicator:	N
U.S. DOT ID Number:	Not reported
U.S. DOT Description:	Not reported
Non-Hazardous Waste Description:	Non-Hazardous, Non-Regulated Liquids & Solids
Number of Containers:	2
Container Type Code:	BA
Container Type Description:	Burlap, cloth, paper, or plastic bags
Waste Quantity:	48
Quantity Unit of Measure Code:	P
Quantity Unit of Measure Description:	Pounds
Waste Quantity, in Tons:	0.024
Acute Waste Quantity, in Tons:	0
Non-Acute Waste Quantity, in Tons:	0.024
Waste Quantity, in Kilograms:	21.76872
Acute Waste Quantity, in Kilograms:	0
Non-Acute Waste Quantity, in Kilorgrams:	21.76872
Management Method Code:	H141
Management Method Description:	STORAGE, BULKING AND/OR TRANSFER OFF SITE
Waste Residue Indicator:	N
Quantity Discrepancy Indicator:	N
Waste Type Discrepancy Indicator:	N
Waste Density:	Not reported
Waste Density Unit of Measure Code:	Not reported
Waste Density Unit of Measure Description:	Not reported
Form Code:	Not reported
Form Code Description:	Not reported
Source Code:	Not reported
Source Code Description:	Not reported
Waste Minimization Code:	Not reported
Waste Minimization Code Description:	Not reported
Consent Number:	Not reported
EPA Waste Indicator:	N

Click this hyperlink while viewing on your computer to access
25 additional US EManifest: record(s) in the EDR Site Report.

NY MANIFEST:

EPA ID:	NYR000194852
Country:	USA
Name:	Cvs Pharmacy #4745
Address:	26-32 MAMARONECK AVE
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10601
Zip 4:	Not reported
Location Address 1:	26-32 MAMARONECK ST
Location Address 2:	Not reported
Location City,State,Zip:	WHITE PLAINS, NY 10601
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Cvs Pharmacy #4745
Mailing Contact:	Cvs Pharmacy #4745
Mailing Address 1:	26-32 MAMARONECK AVE
Mailing Address 2:	Not reported

CVS (Continued) **1014958239**

Mailing City,State,Zip: WHITE PLAINS, NY 10601
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: 9149490961

Manifest Data:
Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: CTD983872698
Year: 2018
Trans2 State ID: NJD054126164
Generator Ship Date: 10/15/2012
Trans1 Recv Date: 10/15/2012
Trans2 Recv Date: 10/17/2012
TSD Site Recv Date: 10/23/2012
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYR000194852
Trans1 EPA ID: Not reported
Trans2 EPA ID: Not reported
TSDF ID 1: INR000110197
TSDF ID 2: Not reported
Manifest Tracking Number: 005442860FLE
Import Indicator: N
Export Indicator: N
Discr Quantity Indicator: N
Discr Type Indicator: N
Discr Residue Indicator: N
Discr Partial Reject Indicator: N
Discr Full Reject Indicator: N
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: H141
Waste Code a: Ignitable Waste
Waste Code b: Not reported
Waste Code c: Not reported
Waste Code e: Not reported
Waste Code f: Not reported
Waste Code g: Not reported
Waste Code 1: Not reported
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 21
Units: Pounds
Number of Containers: 1
Container Type: Fiber or plastic boxes, cartons, cases
Handling Method: Landfill
Specific Gravity: 1

Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: CTD983872698
Year: 2018

CVS (Continued) **1014958239**

Trans2 State ID:	NJD054126164
Generator Ship Date:	10/15/2012
Trans1 Recv Date:	10/15/2012
Trans2 Recv Date:	10/17/2012
TSD Site Recv Date:	10/23/2012
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000194852
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	INR000110197
TSDF ID 2:	Not reported
Manifest Tracking Number:	005442860FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H141
Waste Code a:	Ignitable Waste
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	28
Units:	Pounds
Number of Containers:	1
Container Type:	Fiber or plastic boxes, cartons, cases
Handling Method:	Landfill
Specific Gravity:	1

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	CTD983872698
Year:	2018
Trans2 State ID:	NJD054126164
Generator Ship Date:	10/15/2012
Trans1 Recv Date:	10/15/2012
Trans2 Recv Date:	10/17/2012
TSD Site Recv Date:	10/23/2012
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000194852
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported

CVS (Continued) **1014958239**

TSDF ID 1:	INR000110197
TSDF ID 2:	Not reported
Manifest Tracking Number:	005442860FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H141
Waste Code a:	2h-1-Benzopyran-2-One, 4-Hydroxy-3-(3-Oxo-1-Phenylbutyl)-, & Salts, When Present At Concentrations Greater Than 0.3% (Or) Warfarin, & Salts, When Present At Concentrations Greater Than 0.3%
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	1
Units:	Pounds
Number of Containers:	1
Container Type:	Fiber or plastic boxes, cartons, cases
Handling Method:	Landfill
Specific Gravity:	1
Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	PAD982661381
Year:	2018
Trans2 State ID:	NJR000063677
Generator Ship Date:	11/17/2015
Trans1 Recv Date:	11/17/2015
Trans2 Recv Date:	11/19/2015
TSD Site Recv Date:	11/25/2015
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000194852
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	INR000110197
TSDF ID 2:	Not reported
Manifest Tracking Number:	008652377FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N

CVS (Continued) **1014958239**

Discr Partial Reject Indicator: N
Discr Full Reject Indicator: N
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: H141
Waste Code a: Not reported
Waste Code b: Chromium
Waste Code c: Selenium
Waste Code e: Not reported
Waste Code f: Not reported
Waste Code g: Not reported
Waste Code 1: Not reported
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 1
Units: Pounds
Number of Containers: 1
Container Type: Fiber or plastic boxes, cartons, cases
Handling Method: Burn
Specific Gravity: 1

Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: CTD983872698
Year: 2018
Trans2 State ID: NJR000063677
Generator Ship Date: 04/30/2013
Trans1 Recv Date: 04/30/2013
Trans2 Recv Date: 05/01/2013
TSD Site Recv Date: 05/15/2013
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYR000194852
Trans1 EPA ID: Not reported
Trans2 EPA ID: Not reported
TSDF ID 1: INR000110197
TSDF ID 2: Not reported
Manifest Tracking Number: 006296306FLE
Import Indicator: N
Export Indicator: N
Discr Quantity Indicator: N
Discr Type Indicator: N
Discr Residue Indicator: N
Discr Partial Reject Indicator: N
Discr Full Reject Indicator: N
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: H141
Waste Code a: Ignitable Waste
Waste Code b: Not reported
Waste Code c: Not reported
Waste Code e: Not reported

CVS (Continued) **1014958239**

Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	16
Units:	Pounds
Number of Containers:	1
Container Type:	Fiber or plastic boxes, cartons, cases
Handling Method:	Landfill
Specific Gravity:	1
Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	CTD983872698
Year:	2018
Trans2 State ID:	NJR000063677
Generator Ship Date:	04/30/2013
Trans1 Recv Date:	04/30/2013
Trans2 Recv Date:	05/01/2013
TSD Site Recv Date:	05/15/2013
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000194852
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	INR000110197
TSDF ID 2:	Not reported
Manifest Tracking Number:	006296306FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H141
Waste Code a:	Corrosive Waste
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	7
Units:	Pounds

CVS (Continued) **1014958239**

Number of Containers:	1
Container Type:	Fiber or plastic boxes, cartons, cases
Handling Method:	Landfill
Specific Gravity:	1
Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	CTD983872698
Year:	2018
Trans2 State ID:	NJR000063677
Generator Ship Date:	04/30/2013
Trans1 Recv Date:	04/30/2013
Trans2 Recv Date:	05/01/2013
TSD Site Recv Date:	05/15/2013
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000194852
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	INR000110197
TSDF ID 2:	Not reported
Manifest Tracking Number:	006296306FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H141
Waste Code a:	Benzoic Acid, 2-Hydroxy-, Compd. With (3as-Cis)-1,2,3,3a,8,8a-Hexahydro-1,3a,8-Trimethylpyrrolo[2,3-B]Indol-5-Yl Methylcarbamate Ester (1:1) (Or) Physostigmine Salicylate
Waste Code b:	2h-1-Benzopyran-2-One, 4-Hydroxy-3-(3-Oxo-1-Phenylbutyl)-, & Salts, When Present At Concentrations Greater Than 0.3% (Or) Warfarin, & Salts, When Present At Concentrations Greater Than 0.3%
Waste Code c:	Nicotine, & Salts (Or) Pyridine, 3-(1-Methyl-2-Pyrrolidinyl)-,(S)-, & Salts
Waste Code e:	1,2,3-Propanetriol, Trinitrate (R) (Or) Nitroglycerine (R)
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	24
Units:	Pounds
Number of Containers:	2
Container Type:	Fiber or plastic boxes, cartons, cases
Handling Method:	Landfill
Specific Gravity:	1

CVS (Continued) **1014958239**

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	CTD983872698
Year:	2018
Trans2 State ID:	NJR000063677
Generator Ship Date:	04/30/2013
Trans1 Recv Date:	04/30/2013
Trans2 Recv Date:	05/01/2013
TSD Site Recv Date:	05/15/2013
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000194852
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	INR000110197
TSDF ID 2:	Not reported
Manifest Tracking Number:	006296306FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H141
Waste Code a:	Ignitable Waste
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	33
Units:	Pounds
Number of Containers:	1
Container Type:	Fiber or plastic boxes, cartons, cases
Handling Method:	Landfill
Specific Gravity:	1

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	CTD983872698
Year:	2018
Trans2 State ID:	NJR000063677
Generator Ship Date:	09/23/2015
Trans1 Recv Date:	09/23/2015
Trans2 Recv Date:	09/24/2015
TSD Site Recv Date:	10/01/2015
Part A Recv Date:	Not reported

CVS (Continued) **1014958239**

Part B Recv Date:	Not reported
Generator EPA ID:	NYR000194852
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	INR000110197
TSDF ID 2:	Not reported
Manifest Tracking Number:	008568095FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H141
Waste Code a:	Not reported
Waste Code b:	Chromium
Waste Code c:	Selenium
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	1
Units:	Pounds
Number of Containers:	1
Container Type:	Fiber or plastic boxes, cartons, cases
Handling Method:	Burn
Specific Gravity:	1

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	CTD983872698
Year:	2018
Trans2 State ID:	NJR000063677
Generator Ship Date:	09/23/2015
Trans1 Recv Date:	09/23/2015
Trans2 Recv Date:	09/24/2015
TSD Site Recv Date:	10/01/2015
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000194852
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	INR000110197
TSDF ID 2:	Not reported
Manifest Tracking Number:	008568095FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N

CVS (Continued) **1014958239**

Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H141
Waste Code a:	Not reported
Waste Code b:	2h-1-Benzopyran-2-One, 4-Hydroxy-3-(3-Oxo-1-Phenylbutyl)-, & Salts, When Present At Concentrations Greater Than 0.3% (Or) Warfarin, & Salts, When Present At Concentrations Greater Than 0.3%
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	0.04
Units:	Pounds
Number of Containers:	1
Container Type:	Fiber or plastic boxes, cartons, cases
Handling Method:	Burn
Specific Gravity:	1

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	CTD983872698
Year:	2018
Trans2 State ID:	NJR000063677
Generator Ship Date:	09/23/2015
Trans1 Recv Date:	09/23/2015
Trans2 Recv Date:	09/24/2015
TSD Site Recv Date:	09/29/2015
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000194852
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	RID040098352
TSDF ID 2:	Not reported
Manifest Tracking Number:	008568096FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H141

CVS (Continued) **1014958239**

Waste Code a:	Not reported
Waste Code b:	Ignitable Waste
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	27
Units:	Pounds
Number of Containers:	1
Container Type:	Fiber or plastic boxes, cartons, cases
Handling Method:	Burn
Specific Gravity:	1

Click this hyperlink while viewing on your computer to access
109 additional NY MANIFEST: record(s) in the EDR Site Report.

232
West
1/8-1/4
0.166 mi.
877 ft.

WESTCHESTER CO BRONX STREET BUS TERMINAL
1 BRONX ST- LAT 41 1.95 MIN
WHITE PLAINS, NY 10601

RCRA NonGen / NLR **1004762837**
FINDS **NYR000100974**
ECHO
NY MANIFEST

Relative:
Lower

Actual:
193 ft.

RCRA Listings:

Date Form Received by Agency:	20070101
Handler Name:	Westchester Co Bronx Street Bus Terminal
Handler Address:	Bronx St- Lat 41 1.95 Min
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYR000100974
Contact Name:	HUGH GREECHAN
Contact Address:	MARTINE AVE
Contact City,State,Zip:	WHITE PLAINS, NY 10601-3311
Contact Telephone:	914-555-1212
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	County
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R3
Mailing Address:	MARTINE AVE
Mailing City,State,Zip:	WHITE PLAINS, NY 10601-3311
Owner Name:	County Of Westchester New York
Owner Type:	County
Operator Name:	County Of Westchester New York
Operator Type:	County
Short-Term Generator Activity:	No

WESTCHESTER CO BRONX STREET BUS TERMINAL (Continued) **1004762837**

Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20150414
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Hazardous Waste Summary:

Waste Code:	D000
Waste Description:	Not Defined
Waste Code:	D008
Waste Description:	Lead

Handler - Owner Operator:

Owner/Operator Indicator:	Operator
Owner/Operator Name:	COUNTY OF WESTCHESTER NEW YORK
Legal Status:	County
Date Became Current:	20010101
Date Ended Current:	Not reported
Owner/Operator Address:	148 MARTINE AVE
Owner/Operator City,State,Zip:	WHITE PLAINS, NY 10601-3311

WESTCHESTER CO BRONX STREET BUS TERMINAL (Continued) **1004762837**

Owner/Operator Telephone: 212-555-1212
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Owner
Owner/Operator Name: COUNTY OF WESTCHESTER NEW YORK
Legal Status: County
Date Became Current: 20010101
Date Ended Current: Not reported
Owner/Operator Address: 148 MARTINE AVE
Owner/Operator City,State,Zip: WHITE PLAINS, NY 10601-3311
Owner/Operator Telephone: 212-555-1212
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Owner
Owner/Operator Name: COUNTY OF WESTCHESTER NEW YORK
Legal Status: County
Date Became Current: Not reported
Date Ended Current: Not reported
Owner/Operator Address: 148 MARTINE AVE
Owner/Operator City,State,Zip: WHITE PLAINS, NY 10601-3311
Owner/Operator Telephone: 212-555-1212
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Historic Generators:
Receive Date: 20060101
Handler Name: WESTCHESTER CO BRONX STREET BUS TERMINAL
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20070101
Handler Name: WESTCHESTER CO BRONX STREET BUS TERMINAL
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20011002

WESTCHESTER CO BRONX STREET BUS TERMINAL (Continued) **1004762837**

Handler Name: WESTCHESTER CO BRONX STREET BUS TERMINAL
Federal Waste Generator Description: Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

FINDS:
Registry ID: 110012242000

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:
The Resource Conservation and Recovery Act Information System (RCRAInfo) is EPA's comprehensive information system in support of the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. It tracks many types of information about generators, transporters, treaters, storers, and disposers of hazardous waste.

Click this hyperlink while viewing on your computer to access additional FINDS: detail in the EDR Site Report.

ECHO:
Envid: 1004762837
Registry ID: 110012242000

DFR URL:
Name: WESTCHESTER CO BRONX STREET BUS TERMINAL
Address: 1 BRONX ST- LAT 41 1.95 MIN
City,State,Zip: WHITE PLAINS, NY 10601

NY MANIFEST:
EPA ID: NYR000100974
Country: USA
Name: Westchester Co Dpw
Address: 1 BRONX ST- LAT 41 1.95 MIN
Address 2: LONG 73 46.6 MIN
City,State,Zip: WHITE PLAINS, NY 10601
Zip 4: Not reported
Location Address 1: BRONX ST BUS TERMINAL

WESTCHESTER CO BRONX STREET BUS TERMINAL (Continued) **1004762837**

Location Address 2: Not reported
Location City,State,Zip: WHITE PLAINS, NY 10601
Location Zip 4: Not reported
Facility Status: Not reported
Total Tanks: Not reported
Code: BP

Mailing:
Mailing Name: Westchester Co Dpw
Mailing Contact: Eugene Fiske
Mailing Address 1: 148 MARTINE AVE RM 526
Mailing Address 2: Not reported
Mailing City,State,Zip: WHITE PLAINS, NY 10601
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: 9149952693

Manifest Data:
Document ID: NJA4042540
Manifest Status: Not reported
Trans1 State ID: S58924
Year: 2001
Trans2 State ID: Not reported
Generator Ship Date: 10/19/2001
Trans1 Recv Date: 10/19/2001
Trans2 Recv Date: Not reported
TSD Site Recv Date: 10/22/2001
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYR000100974
Trans1 EPA ID: NYD046765574
Trans2 EPA ID: Not reported
TSDF ID 1: NJD991291105
TSDF ID 2: Not reported
Manifest Tracking Number: Not reported
Import Indicator: Not reported
Export Indicator: Not reported
Discr Quantity Indicator: Not reported
Discr Type Indicator: Not reported
Discr Residue Indicator: Not reported
Discr Partial Reject Indicator: Not reported
Discr Full Reject Indicator: Not reported
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: Not reported
Waste Code 1: Lead
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 04500
Units: Pounds
Number of Containers: 009
Container Type: Metal drums, barrels, kegs
Handling Method: Treat

WESTCHESTER CO BRONX STREET BUS TERMINAL (Continued) **1004762837**

Specific Gravity: 01.00

V233 **INNS OF COURT** **NY LTANKS** **S102399524**
ESE **99 COURT ST** **N/A**
1/8-1/4 **WHITE PLAINS, NY**
0.167 mi.
882 ft. **Site 1 of 2 in cluster V**

Relative:
Higher

Actual:
229 ft.

LTANKS:

Name:	INNS OF COURT
Address:	99 COURT ST
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9606465 / 2006-02-28
Facility ID:	9606465
Site ID:	204590
Spill Date:	1996-08-20
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1996-08-20
CID:	349
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1996-08-20
Spill Record Last Update:	2006-02-28
Spiller Name:	SUSAN HARVEY
Spiller Company:	INNS OF COURT
Spiller Address:	99 COURT ST
Spiller County:	001
Spiller Contact:	SUSAN HARVEY
Spiller Phone:	(914) 947-8400
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	170073
Latitude:	41.0301563
Longitude:	-73.7669171
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY 02/28/06 Tank passed an isolation retest but lines failed in Aug of 1996. Tank was scheduled to be abandoned in place and lines removed by NES Oct 1996. WCHD PBS databse lists site as Unregulated as of June 1997. NFA jod
Remarks:	Not reported

All TTF:

Facility ID:	9606465
Spill Number:	9606465
Spill Tank Test:	1544695
Site ID:	204590

INNS OF COURT (Continued) **S102399524**

Tank Number:	Not reported
Tank Size:	3000
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	.00
Gross Fail:	F
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	204590
Operable Unit ID:	1034262
Operable Unit:	01
Material ID:	561159
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

V234 **THE INNS OF COURT PROPERTIES** **NY UST** **U004441930**
ESE **99 COURT ST.** **N/A**
1/8-1/4 **, NY 10601**
0.167 mi.
882 ft. **Site 2 of 2 in cluster V**

Relative: WESTCHESTER CO. UST:
Higher

Actual:
229 ft.

Name:	THE INNS OF COURT PROPERTIES
Address:	99 COURT ST.
City,State,Zip:	NY 10601
Id/Status:	3-601002 / Unregulated: <1101 gal. PBS
Operator Name:	None
Owner Name:	Henry J. Miller
Owner Street:	85 Birchall Drive
Owner Address2:	Not reported
Owner City:	Scarsdale
Owner State:	NY
Owner Zipcode:	10583
GDS Number:	Not reported
Tank Number:	1
Status:	3. Closed - Removed
Capacity:	3000
Product Stored:	Not reported
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	01/01/1997

THE INNS OF COURT PROPERTIES (Continued) **U004441930**

Date Perm Closure:	01/01/1997
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	2. Underground/on ground
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	1. Painted/Asphalt Coating
Overfill Prevention:	2. High Level Alarm
Piping Secondary Containment:	Not reported
Spill Prevention:	Not reported
Dispenser:	0. None

U235 **CON EDISON** **RCRA NonGen / NLR** **1016677588**
ENE **MAMARONECK AVE & MAIN ST** **FINDS** **NYP004312302**
1/8-1/4 **WHITE PLAINS, NY 10601** **ECHO**
0.167 mi. **NY MANIFEST**
884 ft. **Site 8 of 15 in cluster U**

Relative: **Higher**
Actual: **213 ft.**

RCRA Listings:

Date Form Received by Agency:	20130614
Handler Name:	Con Edison Manhole: 1790
Handler Address:	Mamaroneck Ave & Main St
Handler City,State,Zip:	WHITE PLAINS, NY 10610
EPA ID:	NYP004312302
Contact Name:	DENNIS ROHRER
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	914-925-6219
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	SR SPECIALIST
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	VING PL, RM 828
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No

CON EDISON (Continued) **1016677588**

Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20140402
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20130514
Handler Name:	CON EDISON MANHOLE: 1790
Federal Waste Generator Description:	Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20130614
Handler Name:	CON EDISON MANHOLE: 1790
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes

CON EDISON (Continued) **1016677588**

Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

FINDS:
Registry ID: 110069677674

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:
The Resource Conservation and Recovery Act Information System (RCRAInfo) is EPA's comprehensive information system in support of the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. It tracks many types of information about generators, transporters, treaters, storers, and disposers of hazardous waste.
Registry ID: 110058876453

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:
The Resource Conservation and Recovery Act Information System (RCRAInfo) is EPA's comprehensive information system in support of the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. It tracks many types of information about generators, transporters, treaters, storers, and disposers of hazardous waste.

Click this hyperlink while viewing on your computer to access additional FINDS: detail in the EDR Site Report.

ECHO:
Envid: 1016677588
Registry ID: 110058876453

DFR URL:
Name: CON EDISON MANHOLE: 1790
Address: MAMARONECK AVE & MAIN ST
City,State,Zip: WHITE PLAINS, NY 10610

Envid: 1016677588
Registry ID: 110069677674

DFR URL:
Name: CON EDISON
Address: MAMARONECK AVE & MAIN ST
City,State,Zip: WHITE PLAINS, NY 10601

CON EDISON (Continued) **1016677588**

NY MANIFEST:

EPA ID:	NYP004312302
Country:	USA
Name:	Con Edison
Address:	MAMARONECK AVE & MAIN ST
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10610
Zip 4:	Not reported
Location Address 1:	FO 9 MAMARONECK AVE
Location Address 2:	Not reported
Location City,State,Zip:	WHITE PLAINS, NY 10601
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Edison
Mailing Contact:	Con Edison
Mailing Address 1:	4 IRVING PLACE 15TH FLOOR
Mailing Address 2:	Not reported
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	2124603770

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	05/14/2013
Trans1 Recv Date:	05/14/2013
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	05/14/2013
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004312302
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	007658315JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported

CON EDISON (Continued) **1016677588**

Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	50
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

EPA ID:	NYP004789996
Country:	USA
Name:	Con Edison
Address:	MAMARONECK AVE & MAIN ST
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10601
Zip 4:	Not reported
Location Address 1:	MAIN ST & MAMARONECK AVE
Location Address 2:	MH 1791
Location City,State,Zip:	WHITE PLAINS, NY
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Edison
Mailing Contact:	Dennis Huacon
Mailing Address 1:	4 IRVING PL 15TH FL
Mailing Address 2:	Not reported
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	2124603770

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	06/04/2015
Trans1 Recv Date:	06/04/2015
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	06/04/2015
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004789996
Trans1 EPA ID:	Not reported

CON EDISON (Continued) **1016677588**

Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	014467537JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	150
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

W236 **CONSOLIDATED EDISON** **NY MANIFEST** **S111158158**
NNW **12 WATER ST - MH 5617** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.168 mi.
885 ft. **Site 1 of 13 in cluster W**

Relative: NY MANIFEST:
Lower

Actual:
185 ft.

EPA ID:	NYP004237859
Country:	USA
Name:	Consolidated Edison
Address:	12 WATER ST - MH 5617
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10601
Zip 4:	Not reported
Location Address 1:	12 WATER ST - MH 5617
Location Address 2:	Not reported
Location City,State,Zip:	WHITE PLAINS, NY 10601
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

CONSOLIDATED EDISON (Continued) **S111158158**

Mailing Name: Consolidated Edison
Mailing Contact: Tom Teeling
Mailing Address 1: 4 IRVING PLACE RM 828
Mailing Address 2: Not reported
Mailing City,State,Zip: NEW YORK, NY 10003
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: 2124603770

Manifest Data:
Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: NJ0000027193
Year: 2018
Trans2 State ID: Not reported
Generator Ship Date: 03/02/2010
Trans1 Recv Date: 03/02/2010
Trans2 Recv Date: Not reported
TSD Site Recv Date: 03/03/2010
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYP004237859
Trans1 EPA ID: Not reported
Trans2 EPA ID: Not reported
TSDF ID 1: NJD002200046
TSDF ID 2: Not reported
Manifest Tracking Number: 007020507JJK
Import Indicator: N
Export Indicator: N
Discr Quantity Indicator: N
Discr Type Indicator: N
Discr Residue Indicator: N
Discr Partial Reject Indicator: N
Discr Full Reject Indicator: N
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: H111
Waste Code a: Lead
Waste Code b: Not reported
Waste Code c: Not reported
Waste Code e: Not reported
Waste Code f: Not reported
Waste Code g: Not reported
Waste Code 1: Not reported
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 2600
Units: Gallons (liquids only)
Number of Containers: 1
Container Type: Cargo tanks (tank trucks)
Handling Method: Treat
Specific Gravity: 1

S237 **RECKSON ASSOCIATES** **RCRA NonGen / NLR** **1004762372**
SE **140 GRAND ST** **FINDS** **NYR000096263**
1/8-1/4 **WHITE PLAINS, NY 10601** **ECHO**
0.168 mi. **NY MANIFEST**
887 ft. **Site 2 of 11 in cluster S**

Relative:
Higher

Actual:
233 ft.

RCRA Listings:

Date Form Received by Agency:	20070101
Handler Name:	Reckson Associates
Handler Address:	Grand St
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYR000096263
Contact Name:	PHILLIP FALLON
Contact Address:	BROADHOLLOW RD
Contact City,State,Zip:	MELVILLE, NY 11747
Contact Telephone:	631-622-6678
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R3
Mailing Address:	BROADHOLLOW RD
Mailing City,State,Zip:	MELVILLE, NY 11747
Owner Name:	Reckson Assoc Real Estate Corp
Owner Type:	Private
Operator Name:	Reckson Assoc Real Estate Corp
Operator Type:	Private
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No

RECKSON ASSOCIATES (Continued) **1004762372**

Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20150414
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Hazardous Waste Summary:

Waste Code:	D001
Waste Description:	Ignitable Waste

Handler - Owner Operator:

Owner/Operator Indicator:	Owner
Owner/Operator Name:	RECKSON ASSOC REAL ESTATE CORP
Legal Status:	Private
Date Became Current:	Not reported
Date Ended Current:	Not reported
Owner/Operator Address:	225 BROADHOLLOW RD
Owner/Operator City,State,Zip:	MELVILLE, NY 11747
Owner/Operator Telephone:	631-622-6678
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported
Owner/Operator Email:	Not reported

Owner/Operator Indicator:	Owner
Owner/Operator Name:	RECKSON ASSOC REAL ESTATE CORP
Legal Status:	Private
Date Became Current:	20010101
Date Ended Current:	Not reported
Owner/Operator Address:	225 BROADHOLLOW RD
Owner/Operator City,State,Zip:	MELVILLE, NY 11747
Owner/Operator Telephone:	631-622-6678
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported
Owner/Operator Email:	Not reported

Owner/Operator Indicator:	Operator
Owner/Operator Name:	RECKSON ASSOC REAL ESTATE CORP
Legal Status:	Private
Date Became Current:	20010101
Date Ended Current:	Not reported
Owner/Operator Address:	225 BROADHOLLOW RD
Owner/Operator City,State,Zip:	MELVILLE, NY 11747
Owner/Operator Telephone:	631-622-6678
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported

RECKSON ASSOCIATES (Continued) **1004762372**

Owner/Operator Email: Not reported

Historic Generators:

Receive Date: 20060101
Handler Name: RECKSON ASSOCIATES
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20070101
Handler Name: RECKSON ASSOCIATES
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20010425
Handler Name: RECKSON ASSOCIATES
Federal Waste Generator Description: Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

FINDS:
Registry ID: 110006540412

RECKSON ASSOCIATES (Continued) **1004762372**

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:
The Resource Conservation and Recovery Act Information System (RCRAInfo) is EPA's comprehensive information system in support of the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. It tracks many types of information about generators, transporters, treaters, storers, and disposers of hazardous waste.

Click this hyperlink while viewing on your computer to access additional FINDS: detail in the EDR Site Report.

ECHO:

Envid:	1004762372
Registry ID:	110006540412

DFR URL:

Name:	RECKSON ASSOCIATES
Address:	140 GRAND ST
City,State,Zip:	WHITE PLAINS, NY 10601

NY MANIFEST:

EPA ID:	NYR000096263
Country:	USA
Name:	Reckson
Address:	140 GRAND ST
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10601
Zip 4:	Not reported
Location Address 1:	140 GRAND ST
Location Address 2:	Not reported
Location City,State,Zip:	WHITE PLAINS, NY
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Reckson
Mailing Contact:	Reckson
Mailing Address 1:	140 GRAND ST
Mailing Address 2:	Not reported
Mailing City,State,Zip:	WHITE PLAINS, NY 10601
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	9147307200

Manifest Data:

Document ID:	NJA3192745
Manifest Status:	Not reported
Trans1 State ID:	S50059
Year:	2001
Trans2 State ID:	Not reported
Generator Ship Date:	04/30/2001
Trans1 Recv Date:	04/30/2001
Trans2 Recv Date:	Not reported

RECKSON ASSOCIATES (Continued) **1004762372**

TSD Site Recv Date:	05/04/2001
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000096263
Trans1 EPA ID:	NJD986607380
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Ignitable Waste
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00330
Units:	Gallons (liquids only)
Number of Containers:	006
Container Type:	Metal drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00

U238 **CON EDISON - MANHOLE 467** **NJ MANIFEST** **S120665951**
ENE **221 MAIN STREET** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10602**
0.168 mi.
888 ft. **Site 9 of 15 in cluster U**

Relative: NJ MANIFEST:
Higher

EPA ID:	NYP004308268
Name:	CON EDISON - MANHOLE 467
Address:	221 MAIN ST
City,State,Zip:	WHITE PLAINS, NY 10602
County:	Not reported
Mailing Address:	VING PL, RM 828
Mailing City,State,Zip:	NEW YORK, NY 10003
Telephone:	Not reported
Emergency Telephone:	Not reported
Contact:	GINO FRABASILE
Comments:	Not reported
SIC Code:	Not reported
County:	NY119
Municipal:	Not reported
Previous EPAID:	Not reported
Generator Flag:	Not reported
Transporter Flag:	Not reported

Actual:
213 ft.

CON EDISON - MANHOLE 467 (Continued) **S120665951**

TSDF Flag:	Not reported
Name Change:	Not reported
Date Change:	Not reported

Manifest Data:

EPA ID:	NYP004308268
Manifest Number:	014470867JJK
Date Shipped:	2/8/2016
TSDF EPA ID:	NJD002200046
Transporter EPA ID:	NYD006982359
Transporter 2 EPA ID:	Not reported
Transporter 3 EPA ID:	Not reported
Transporter 4 EPA ID:	Not reported
Transporter 5 EPA ID:	Not reported
Transporter 6 EPA ID:	Not reported
Transporter 7 EPA ID:	Not reported
Transporter 8 EPA ID:	Not reported
Transporter 9 EPA ID:	Not reported
Transporter 10 EPA ID:	Not reported
Date Trans1 Transported Waste:	Not reported
Date Trans2 Transported Waste:	Not reported
Date Trans3 Transported Waste:	Not reported
Date Trans4 Transported Waste:	Not reported
Date Trans5 Transported Waste:	Not reported
Date Trans6 Transported Waste:	Not reported
Date Trans7 Transported Waste:	Not reported
Date Trans8 Transported Waste:	Not reported
Date Trans9 Transported Waste:	Not reported
Date Trans10 Transported Waste:	Not reported
Date TSDF Received Waste:	Not reported
TSDF EPA Facility Name:	Not reported
QTY Units:	Not reported
Transporter SEQ ID:	Not reported
Transporter-1 Date:	Not reported
Waste SEQ ID:	Not reported
Waste Type Code 2:	Not reported
Waste Type Code 3:	Not reported
Waste Type Code 4:	Not reported
Waste Type Code 5:	Not reported
Waste Type Code 6:	Not reported
Date Accepted:	Not reported
Manifest Discrepancy Type:	Not reported
Data Entry Number:	Not reported
Was Load Rejected:	Not reported
Reason Load Was Rejected:	Not reported

U239 **CON EDISON MANHOLE: 467** **RCRA-LQG** **1016677263**
ENE **221 MAIN ST** **FINDS** **NYP004308268**
1/8-1/4 **WHITE PLAINS, NY 10602** **ECHO**
0.168 mi. **NY MANIFEST**
888 ft. **Site 10 of 15 in cluster U**

Relative: **Higher**
Actual: **213 ft.**

RCRA Listings:

Date Form Received by Agency:	20140327
Handler Name:	Con Edison - Manhole 467
Handler Address:	Main Street
Handler City,State,Zip:	WHITE PLAINS, NY 10602

CON EDISON MANHOLE: 467 (Continued) **1016677263**

EPA ID:	NYP004308268
Contact Name:	DENNIS HUACON
Contact Address:	IRVING PLACE, 15TH FL NE
Contact City,State,Zip:	NEW YORK, NY 10003
Contact Telephone:	212-460-2757
Contact Fax:	401-765-1500
Contact Email:	HUACOND@CONED.COM
Contact Title:	ASSOCIATE SCIENTIST
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Large Quantity Generator
Non-Notifier:	Not reported
Biennial Report Cycle:	2013
Accessibility:	Not reported
Active Site Indicator:	Handler Activities
State District Owner:	Ny
State District:	NYSDEC R3
Mailing Address:	IRVING PLACE, 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Consolidated Edison Company Of Ny, Inc.
Owner Type:	Private
Operator Name:	Consolidated Edison Company Of Ny, Inc.
Operator Type:	Private
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20150414
Recognized Trader-Importer:	No

CON EDISON MANHOLE: 467 (Continued) **1016677263**

Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Biennial: List of Years
Year: 2013

Click Here for Biennial Reporting System Data:

Hazardous Waste Summary:
Waste Code: D008
Waste Description: Lead

Handler - Owner Operator:

Owner/Operator Indicator:	Operator
Owner/Operator Name:	CONSOLIDATED EDISON COMPANY OF NY, INC.
Legal Status:	Private
Date Became Current:	20130507
Date Ended Current:	Not reported
Owner/Operator Address:	4 IRVING PLACE
Owner/Operator City,State,Zip:	NEW YORK, NY 10003
Owner/Operator Telephone:	Not reported
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported
Owner/Operator Email:	Not reported

Owner/Operator Indicator:	Owner
Owner/Operator Name:	CONSOLIDATED EDISON COMPANY OF NY, INC.
Legal Status:	Private
Date Became Current:	20130507
Date Ended Current:	Not reported
Owner/Operator Address:	4 IRVING PLACE
Owner/Operator City,State,Zip:	NEW YORK, NY 10003
Owner/Operator Telephone:	Not reported
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported
Owner/Operator Email:	Not reported

Historic Generators:

Receive Date:	20140327
Handler Name:	CON EDISON - MANHOLE 467
Federal Waste Generator Description:	Large Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

CON EDISON MANHOLE: 467 (Continued) **1016677263**

Receive Date: 20130507
Handler Name: CON EDISON MANHOLE: 467
Federal Waste Generator Description: Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20130607
Handler Name: CON EDISON MANHOLE: 467
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Code: 221122
NAICS Description: Electric Power Distribution

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

FINDS:
Registry ID: 110058879094

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:
All generators and treatment, storage, and disposal (TSD) facilities who handle hazardous waste are required to report to the EPA Administrator at least once every two years. The data collected is used to create the National Biennial Resource Conservation and Recovery Act (RCRA) Hazardous Waste Report. This data is processed within the RCRA Information (RCRAInfo) database
The Resource Conservation and Recovery Act Information System (RCRAInfo) is EPA's comprehensive information system in support of the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. It tracks many types of information about generators, transporters, treaters, storers, and disposers of hazardous waste.

CON EDISON MANHOLE: 467 (Continued) **1016677263**

Click this hyperlink while viewing on your computer to access additional FINDS: detail in the EDR Site Report.

ECHO:

Envid:	1016677263
Registry ID:	110058879094

DFR URL:

Name:	CON EDISON MANHOLE: 467
Address:	221 MAIN ST
City,State,Zip:	WHITE PLAINS, NY 10602

NY MANIFEST:

EPA ID:	NYP004308268
Country:	USA
Name:	Con Edison
Address:	221 MAIN ST
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10602
Zip 4:	Not reported
Location Address 1:	221 MAIN STREET
Location Address 2:	Not reported
Location City,State,Zip:	WHITE PLAINS, NY 10602
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Edison
Mailing Contact:	Con Edison
Mailing Address 1:	4 IRVING PLACE 15TH FLOOR
Mailing Address 2:	Not reported
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	2124603770

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NJ0000027193
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	05/07/2013
Trans1 Recv Date:	05/07/2013
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	05/13/2013
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004308268
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	010842714JJK

CON EDISON MANHOLE: 467 (Continued) **1016677263**

Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	3000
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

U240 **221 MAIN STREET** **NY BROWNFIELDS S106704121**
ENE **221 MAIN ST** **NY Spills N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.168 mi.
888 ft. **Site 11 of 15 in cluster U**

Relative: **Higher**
Actual: **213 ft.**

BROWNFIELDS:

Name:	221 MAIN STREET
Address:	221 MAIN ST
City,State,Zip:	WHITE PLAINS, NY 10601
Program:	BCP
Site Code:	58997
Acres:	2.600
HW Code:	C360073
SWIS:	6017
Town:	White Plains (c)
Record Added Date:	07/26/2004
Record Updated Date:	12/20/2007
Update By:	MJRYAN
Site Description:	Location Description: The site is located in an urban portion of Westchester County, occupying several city tax parcels, including 221 Main Street, in the City of White Plains. Current Use: The site is currently being redeveloped. The newly constructed complex will contain approximately 125 hotel rooms, 400 condominiums and approximately 10,000 square feet of street levels stores. Surrounding Uses: The site is surrounded by commercial properties with a mix of retail and office space. Historical Source(s)of contamination: The

221 MAIN STREET (Continued) **S106704121**

historical source of contamination at this site included multiple leaking underground storage tanks (USTs). Investigations revealed the presence of ten USTs. Investigations/Actions Performed to date: Previous environmental investigations include a Phase I Investigation in 2002 and a Petroleum Contamination Site Investigation completed in June of 1993. Under the Brownfield Cleanup Program, a Remedial Investigation was conducted in 2005-2006. Based on RI findings, an Interim Remedial Measure (IRM) was planned and implemented which included the removal of all USTs, and contaminated soil. Current Action: A Final Engineering Report which documents the remedial activities completed has been approved. On December 19, 2006 a Certificate of Completion was issued declaring remedial activities complete, and that a Track 1 cleanup (i.e., unrestricted use) has been achieved.

Env Problem:	Contaminant of concern: Petroleum-related compounds including volatile organic compounds (VOCs) and polycyclic aromatic hydrocarbons. Impacted Media: Soil and groundwater. Known SCGs exceedences: Investigation revealed benzene, toluene, ethyl-benzene and xylenes, however, as part of a site-wide remedial program (2005-2006) all contaminated media has been removed and properly disposed.
Health Problem:	The site is located in downtown White Plains, public water serves the area. Through the implementation of an IRM the site has been remediated and nearly all the soil has been removed to bedrock eliminating potential exposure to contaminated soil. Proposed redevelopment of the site will include a ventilated below-grade parking garage with foundation drainage which will effectively eliminate the potential for soil vapor intrusion to occur.
Dump:	Not reported
Structure:	Not reported
Lagoon:	Not reported
Landfill:	Not reported
Pond:	Not reported
Disp Start:	Not reported
Disp Term:	Not reported
Lat/Long:	Not reported
Dell:	Not reported
Record Add:	Not reported
Record Upd:	Not reported
Updated By:	Not reported
Own Op:	1
Sub Type:	06
Owner Name:	C/O CAPPELLI ENTERPRISES, INC.
Owner Company:	LC MAIN, LLC
Owner Address:	115 STEVENS AVE.
Owner Addr2:	Not reported
Owner City,St,Zip:	VALHALLA, NY 10595
Owner Country:	United States of America
Own Op:	6
Sub Type:	09
Owner Name:	Not reported
Owner Company:	RENAISSANCE HOTEL PARTNERS, LLC
Owner Address:	115 STEVENS AVENUE
Owner Addr2:	Not reported
Owner City,St,Zip:	VALHALLA, NY 10595
Owner Country:	United States of America
Own Op:	1

221 MAIN STREET (Continued) **S106704121**

Sub Type:	E
Owner Name:	Steven Elghanayan
Owner Company:	EPIC Renaissance LLC
Owner Address:	15 Watts Street, 5th Floor
Owner Addr2:	Not reported
Owner City,St,Zip:	New York, NY 10013
Owner Country:	United States of America
Own Op:	6
Sub Type:	09
Owner Name:	Not reported
Owner Company:	RENAISSANCE OFFICE PARTNERS, LLC
Owner Address:	115 STEVENS AVENUE
Owner Addr2:	Not reported
Owner City,St,Zip:	VALHALLA, NY 10595
Owner Country:	United States of America
Own Op:	6
Sub Type:	09
Owner Name:	Not reported
Owner Company:	RENAISSANCE PARKING PARTNERS, LLC
Owner Address:	115 STEVENS AVENUE
Owner Addr2:	Not reported
Owner City,St,Zip:	VALHALLA, NY 10595
Owner Country:	United States of America
Own Op:	1
Sub Type:	E
Owner Name:	James madsen
Owner Company:	770 hot springs, llc
Owner Address:	1475 Powell Street
Owner Addr2:	suite 101
Owner City,St,Zip:	Emeryville, CA 94508
Owner Country:	United States of America
Own Op:	6
Sub Type:	09
Owner Name:	Not reported
Owner Company:	RENAISSANCE RENTAL PARTNERS, LLC
Owner Address:	115 STEVENS AVENUE
Owner Addr2:	Not reported
Owner City,St,Zip:	VALHALLA, NY 10595
Owner Country:	United States of America
Own Op:	6
Sub Type:	09
Owner Name:	Not reported
Owner Company:	RENAISSANCE CONDOMINIUM PARTNERS
Owner Address:	115 STEVENS AVENUE
Owner Addr2:	Not reported
Owner City,St,Zip:	VALHALLA, NY 10595
Owner Country:	United States of America
Own Op:	6
Sub Type:	06
Owner Name:	C/O CAPPELLI ENTERPRISES, INC.
Owner Company:	LC MAIN, LLC
Owner Address:	115 STEVENS AVE.
Owner Addr2:	Not reported
Owner City,St,Zip:	VALHALLA, NY 10595
Owner Country:	United States of America
Own Op:	6
Sub Type:	09

221 MAIN STREET (Continued) **S106704121**

Owner Name:	Not reported
Owner Company:	EPIC Renaissance LLC
Owner Address:	15 Watts Street, 5th Floor
Owner Addr2:	Not reported
Owner City,St,Zip:	New York, NY 10013
Owner Country:	United States of America
HW Code:	Not reported
Waste Type:	Not reported
Waste Quantity:	Not reported
Waste Code:	Not reported
Crossref ID:	Not reported
Cross Ref Type Code:	Not reported
Cross Ref Type:	Not reported
Record Added Date:	Not reported
Record Updated:	Not reported
Updated By:	Not reported

SPILLS:

Name:	COMMERCIAL SITE
Address:	221 MAIN STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0706741 / 2008-07-31
Facility ID:	0706741
Facility Type:	ER
DER Facility ID:	292111
Site ID:	387315
DEC Region:	3
Spill Cause:	Human Error
Spill Class:	B3
SWIS:	6017
Spill Date:	2007-09-18
Investigator:	jbodee
Referred To:	WCDOH
Reported to Dept:	2007-09-18
CID:	444
Water Affected:	Not reported
Spill Source:	Commercial Vehicle
Spill Notifier:	Other
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	2007-09-18
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2007-09-18
Spill Record Last Update:	2008-07-31
Spiller Name:	VENESSA
Spiller Company:	COMMERCIAL SITE
Spiller Address:	221 MAIN STREET
Spiller Company:	001
Contact Name:	VENESSA
Latitude:	41.0327272
Longitude:	-73.7664465
DEC Memo:	7/31/08: Spill closure report from JM Associates submitted to DEC. Based upon information provided, this Department requires No Further Action at this time. jod
Remarks:	OVERFILLED THE TANK AND IS SURFACE SPILL AND IS BEING CLEANED UP'

221 MAIN STREET (Continued) **S106704121**

CALLED ENVIRO WASTE TO PUMP

All Materials:

Site ID:	387315
Operable Unit ID:	1144524
Operable Unit:	01
Material ID:	2134831
Material Code:	0008
Material Name:	diesel
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	75.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	COMMERCIAL BUSINESS
Address:	221 MAIN STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0504810 / 2008-06-17
Facility ID:	0504810
Facility Type:	ER
DER Facility ID:	292111
Site ID:	349725
DEC Region:	3
Spill Cause:	Other
Spill Class:	B3
SWIS:	6017
Spill Date:	2005-07-21
Investigator:	TDGHIOSA
Referred To:	Not reported
Reported to Dept:	2005-07-21
CID:	444
Water Affected:	Not reported
Spill Source:	Institutional, Educational, Gov., Other
Spill Notifier:	Other
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2005-07-21
Spill Record Last Update:	2008-06-17
Spiller Name:	JOHN MANFERI
Spiller Company:	COMMECRCIAL BUISNESS
Spiller Address:	221 MAIN STREET
Spiller Company:	001
Contact Name:	JOHN MANFERI
Latitude:	41.0326759
Longitude:	-73.7665840
DEC Memo:	06/17/08 Spill addressed by the Brownfield Cleanup Program remedial action, as documented in the Final Engineering Report for site no. C3-60-073. JPC
Remarks:	2 1000 GALLON TANKS: FOUND CONTAMINATION:

221 MAIN STREET (Continued) **S106704121**

All Materials:

Site ID:	349725
Operable Unit ID:	1107313
Operable Unit:	01
Material ID:	2097204
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	G
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

Name:	CONSTRUCTION PROJECT
Address:	221 MAIN STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0500820 / 2008-06-17
Facility ID:	0500820
Facility Type:	ER
DER Facility ID:	292111
Site ID:	343904
DEC Region:	3
Spill Cause:	Unknown
Spill Class:	B3
SWIS:	6017
Spill Date:	2005-04-20
Investigator:	TDGHIOSA
Referred To:	Not reported
Reported to Dept:	2005-04-20
CID:	444
Water Affected:	Not reported
Spill Source:	Institutional, Educational, Gov., Other
Spill Notifier:	Other
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2005-04-20
Spill Record Last Update:	2008-06-17
Spiller Name:	JOHN MANFREDIE
Spiller Company:	CONSTRUCTION PROJECT
Spiller Address:	221 MAIN STREET
Spiller Company:	001
Contact Name:	JOHN MANFREDIE
Latitude:	41.0326759
Longitude:	-73.7665840
DEC Memo:	3/20/05 John Manfredi reported that this spill was reported based on the results of a test pit dug in the vicinity of this tank which has already been removed. Gross contamination was found at the water table. Site is under active construction, so remediation will occur as the project

221 MAIN STREET (Continued) **S106704121**

progresses. Estimated time frame is a few months. TG 06/17/08 Spill addressed by the Brownfield
Cleanup Program remedial action, as documented in the Final Engineering Report for site no.
C3-60-073. JPC

Remarks: 5000 GALLON TANK, FOUYND WHILE EXCAVATING: HOLES IN TANK ALSO:

All Materials:

Site ID:	343904
Operable Unit ID:	1102569
Operable Unit:	01
Material ID:	582786
Material Code:	0002A
Material Name:	#4 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	G
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

Name:	BAR BUILDING ANNEX
Address:	221 MAIN STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0413395 / 2005-05-12
Facility ID:	0413395
Facility Type:	ER
DER Facility ID:	292111
Site ID:	342486
DEC Region:	3
Spill Cause:	Unknown
Spill Class:	C3
SWIS:	6017
Spill Date:	2005-03-24
Investigator:	TDGHIOSA
Referred To:	Not reported
Reported to Dept:	2005-03-24
CID:	410
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Local Agency
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2005-03-24
Spill Record Last Update:	2005-05-12
Spiller Name:	JOHN MANFREDI
Spiller Company:	NORTHEAST CORNER
Spiller Address:	BAR BUILDING ANNEX
Spiller Company:	001
Contact Name:	JOHN MANFREDI
Latitude:	41.0326760
Longitude:	-73.7665840

221 MAIN STREET (Continued) **S106704121**

DEC Memo: 4/20/05 UST removal report rec'd from JM Associates. Based on the info contained in that report,
NFA required. TG

Remarks: after excavating found a 4000 gallon tank about 70 years old contact cell phone JOHN MANFREDI 9144475634 unknown if tank is intact or if any material has gotten out into soil it is possible caller states in process of removing cleaning and testing area now

All TTF:

Facility ID:	0413395
Spill Number:	0413395
Spill Tank Test:	1548723
Site ID:	342486
Tank Number:	Not reported
Tank Size:	4000
Material:	0002
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Watchdog
Last Modified Date:	Not reported

All Materials:

Site ID:	342486
Operable Unit ID:	1101213
Operable Unit:	01
Material ID:	581340
Material Code:	0002A
Material Name:	#4 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

R241 **WHITE PLAINS RUBBER STAMP & NAMEPLATE** **RCRA NonGen / NLR** **1000397523**
SW **20 BANK ST** **FINDS** **NYD980648422**
1/8-1/4 **WHITE PLAINS, NY 10606** **ECHO**
0.171 mi. **NY MANIFEST**
902 ft. **Site 8 of 11 in cluster R**

Relative:
Higher

Actual:
204 ft.

RCRA Listings:

Date Form Received by Agency:	20070101
Handler Name:	White Plains Rubber Stamp & Nameplate
Handler Address:	Bank St
Handler City,State,Zip:	WHITE PLAINS, NY 10606
EPA ID:	NYD980648422
Contact Name:	JAY WYKA
Contact Address:	BANK ST
Contact City,State,Zip:	WHITE PLAINS, NY 10606

WHITE PLAINS RUBBER STAMP & NAMEPLATE (Continued) **1000397523**

Contact Telephone:	914-949-1900
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Not reported
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R3
Mailing Address:	BANK ST
Mailing City,State,Zip:	WHITE PLAINS, NY 10606
Owner Name:	Mr Wyka-Mrs Voneiff-Mr Sgroia
Owner Type:	Private
Operator Name:	Mr Wyka-Mrs Voneiff-Mr Sgroia
Operator Type:	Private
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20150414
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No

WHITE PLAINS RUBBER STAMP & NAMEPLATE (Continued) **1000397523**

Manifest Broker: No
Sub-Part P Indicator: No

Hazardous Waste Summary:
Waste Code: D001
Waste Description: Ignitable Waste

Handler - Owner Operator:
Owner/Operator Indicator: Owner
Owner/Operator Name: MR WYKA-MRS VONEIFF-MR SGROIA
Legal Status: Private
Date Became Current: Not reported
Date Ended Current: Not reported
Owner/Operator Address: NOT REQUIRED
Owner/Operator City,State,Zip: NOT REQUIRED, WY 99999
Owner/Operator Telephone: 212-555-1212
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Owner
Owner/Operator Name: MR WYKA-MRS VONEIFF-MR SGROIA
Legal Status: Private
Date Became Current: Not reported
Date Ended Current: Not reported
Owner/Operator Address: NOT REQUIRED
Owner/Operator City,State,Zip: NOT REQUIRED, WY 99999
Owner/Operator Telephone: 212-555-1212
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Operator
Owner/Operator Name: MR WYKA-MRS VONEIFF-MR SGROIA
Legal Status: Private
Date Became Current: Not reported
Date Ended Current: Not reported
Owner/Operator Address: NOT REQUIRED
Owner/Operator City,State,Zip: NOT REQUIRED, WY 99999
Owner/Operator Telephone: 212-555-1212
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Historic Generators:
Receive Date: 20060101
Handler Name: WHITE PLAINS RUBBER STAMP & NAMEPLATE
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No

WHITE PLAINS RUBBER STAMP & NAMEPLATE (Continued) **1000397523**

Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20070101
Handler Name: WHITE PLAINS RUBBER STAMP & NAMEPLATE
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 19820917
Handler Name: WHITE PLAINS RUBBER STAMP & NAMEPLATE
Federal Waste Generator Description: Not reported
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

FINDS:
Registry ID: 110004389000

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:
The Resource Conservation and Recovery Act Information System (RCRAInfo) is EPA's comprehensive information system in support of the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. It tracks many types of information about generators, transporters, treaters, storers, and disposers of hazardous waste.

Click this hyperlink while viewing on your computer to access additional FINDS: detail in the EDR Site Report.

ECHO:

WHITE PLAINS RUBBER STAMP & NAMEPLATE (Continued) **1000397523**

Envid: 1000397523
Registry ID: 110004389000

DFR URL:
Name: WHITE PLAINS RUBBER STAMP & NAMEPLATE
Address: 20 BANK ST
City,State,Zip: WHITE PLAINS, NY 10606

NY MANIFEST:
EPA ID: NYD980648422
Country: USA
Name: White Plains Rubber Stamp & Nameplate
Address: 20 BANK ST
Address 2: Not reported
City,State,Zip: WHITE PLAINS, NY 10606
Zip 4: Not reported
Location Address 1: 20 BANK STREET
Location Address 2: Not reported
Location City,State,Zip: WHITE PLAINS, NY 10602
Location Zip 4: Not reported
Facility Status: Not reported
Total Tanks: Not reported
Code: BP

Mailing:
Mailing Name: White Plains Rubber Stamp & Nameplate
Mailing Contact: Justin Wyla
Mailing Address 1: 20 BANK STREET
Mailing Address 2: Not reported
Mailing City,State,Zip: WHITE PLAINS, NY 10602
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: 9149491900

Manifest Data:
Document ID: NJA0462627
Manifest Status: C - Completed copy
Trans1 State ID: S58112603
Year: 1988
Trans2 State ID: Not reported
Generator Ship Date: 881207
Trans1 Recv Date: 881207
Trans2 Recv Date: Not reported
TSD Site Recv Date: 881208
Part A Recv Date: 881228
Part B Recv Date: 881215
Generator EPA ID: NYD980648422
Trans1 EPA ID: NJD982281016
Trans2 EPA ID: Not reported
TSDF ID 1: NJD002200046
TSDF ID 2: Not reported
Manifest Tracking Number: Not reported
Import Indicator: Not reported
Export Indicator: Not reported
Discr Quantity Indicator: Not reported
Discr Type Indicator: Not reported
Discr Residue Indicator: Not reported

WHITE PLAINS RUBBER STAMP & NAMEPLATE (Continued) **1000397523**

Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	The Following Spent Halogenated Solvents: Tetrachloroethylene, Methylene Chloride, Trichloroethylene, 1,1,1-Trichloroethane, Chlorobenzene, 1,1,2-Trichloro-1,2,2-Trifluoroethane, Ortho-Dichlorobenzene, Trichlorofluoromethane, And 1,1,2, Trichloroethane; All Spent Solvent Mixtures/Blends Containing, Before Use, A Total Of Ten Percent Or More (By Volume) Of One Or More Of The Above Halogenated Solvents Or Those Solvents Listed In F001, F004, And F005; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent Mixtures.
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00055
Units:	Gallons (liquids only)
Number of Containers:	001
Container Type:	Metal drums, barrels, kegs
Handling Method:	Treat
Specific Gravity:	100
Document ID:	NYB2078955
Manifest Status:	Not reported
Trans1 State ID:	IA7667
Year:	1990
Trans2 State ID:	Not reported
Generator Ship Date:	04/02/1990
Trans1 Recv Date:	04/02/1990
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	04/04/1990
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD980648422
Trans1 EPA ID:	NYD057722258
Trans2 EPA ID:	Not reported
TSDF ID 1:	NYD057722258
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	The Following Spent Halogenated Solvents Used In Degreasing: Tetrachloroethylene, Trichlorethylene, Methylene Chloride,

WHITE PLAINS RUBBER STAMP & NAMEPLATE (Continued) **1000397523**

	1,1,1-Trichloroethane, Carbon Tetrachloride And Chlorinated Fluorocarbons; All Spent Solvent Mixtures/Blends Used In Degreasing Containing, Before Use, A Total Of Ten Percent Or More (By Volume) Of One Or More Of The Above Halogenated Solvents Or Those Solvents Listed In F002, F004, And F005; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent Mixtures.
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00051
Units:	Gallons (liquids only)
Number of Containers:	001
Container Type:	Metal drums, barrels, kegs
Handling Method:	Recycle
Specific Gravity:	01.00
Document ID:	NJA0042638
Manifest Status:	K - Completed after the designated time
Trans1 State ID:	NJSWAS284
Year:	1985
Trans2 State ID:	Not reported
Generator Ship Date:	850108
Trans1 Recv Date:	850108
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	850108
Part A Recv Date:	850116
Part B Recv Date:	850212
Generator EPA ID:	NYD980648422
Trans1 EPA ID:	NJD002200046
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	The Following Spent Halogenated Solvents: Tetrachloroethylene, Methylene Chloride, Trichloroethylene, 1,1,1-Trichloroethane, Chlorobenzene, 1,1,2-Trichloro-1,2,2-Trifluoroethane, Ortho-Dichlorobenzene, Trichlorofluoromethane, And 1,1,2, Trichloroethane; All Spent Solvent Mixtures/Blends Containing, Before Use, A Total Of Ten Percent Or More (By Volume) Of One Or More Of The Above Halogenated Solvents Or Those Solvents Listed In F001, F004, And F005; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent Mixtures.
Waste Code 2:	Not reported
Waste Code 3:	Not reported

WHITE PLAINS RUBBER STAMP & NAMEPLATE (Continued) **1000397523**

Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00030
Units:	Gallons (liquids only)
Number of Containers:	001
Container Type:	Metal drums, barrels, kegs
Handling Method:	Treat
Specific Gravity:	100
Document ID:	NJA0281989
Manifest Status:	C - Completed copy
Trans1 State ID:	NJDEPS581
Year:	1987
Trans2 State ID:	Not reported
Generator Ship Date:	870427
Trans1 Recv Date:	870427
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	870505
Part A Recv Date:	870511
Part B Recv Date:	870512
Generator EPA ID:	NYD980648422
Trans1 EPA ID:	NJD085634335
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	The Following Spent Halogenated Solvents Used In Degreasing: Tetrachloroethylene, Trichlorethylene, Methylene Chloride, 1,1,1-Trichloroethane, Carbon Tetrachloride And Chlorinated Fluorocarbons; All Spent Solvent Mixtures/Blends Used In Degreasing Containing, Before Use, A Total Of Ten Percent Or More (By Volume) Of One Or More Of The Above Halogenated Solvents Or Those Solvents Listed In F002, F004, And F005; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent Mixtures.
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00060
Units:	Gallons (liquids only)
Number of Containers:	002
Container Type:	Metal drums, barrels, kegs
Handling Method:	Treat
Specific Gravity:	100

WHITE PLAINS RUBBER STAMP & NAMEPLATE (Continued) **1000397523**

Waste Code 7:	The Following Spent Halogenated Solvents Used In Degreasing: Tetrachloroethylene, Trichlorethylene, Methylene Chloride, 1,1,1-Trichloroethane, Carbon Tetrachloride And Chlorinated Fluorocarbons; All Spent Solvent Mixtures/Blends Used In Degreasing Containing, Before Use, A Total Of Ten Percent Or More (By Volume) Of One Or More Of The Above Halogenated Solvents Or Those Solvents Listed In F002, F004, And F005; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent Mixtures.
Waste Code 8:	Not reported
Waste Code:	Not reported
Waste Code 10:	Not reported
Waste Code 11:	Not reported
Quantity:	00140
Units:	Gallons (liquids only)
Number of Containers:	028
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Treat
Specific Gravity:	100
Document ID:	NJA0632329
Manifest Status:	C - Completed copy
Trans1 State ID:	S58112603
Year:	1989
Trans2 State ID:	Not reported
Generator Ship Date:	890524
Trans1 Recv Date:	890524
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	890525
Part A Recv Date:	890602
Part B Recv Date:	890601
Generator EPA ID:	NYD980648422
Trans1 EPA ID:	NJD982281016
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	The Following Spent Halogenated Solvents: Tetrachloroethylene, Methylene Chloride, Trichloroethylene, 1,1,1-Trichloroethane, Chlorobenzene, 1,1,2-Trichloro-1,2,2-Trifluoroethane, Ortho-Dichlorobenzene, Trichlorofluoromethane, And 1,1,2, Trichloroethane; All Spent Solvent Mixtures/Blends Containing, Before Use, A Total Of Ten Percent Or More (By Volume) Of One Or More Of The Above Halogenated Solvents Or Those Solvents Listed In F001, F004, And F005; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent Mixtures.
Waste Code 2:	Not reported

WHITE PLAINS RUBBER STAMP & NAMEPLATE (Continued) **1000397523**

Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00055
Units:	Gallons (liquids only)
Number of Containers:	001
Container Type:	Metal drums, barrels, kegs
Handling Method:	Recycle
Specific Gravity:	100
Document ID:	NJA0311540
Manifest Status:	K - Completed after the designated time
Trans1 State ID:	NJDEPS581
Year:	1987
Trans2 State ID:	Not reported
Generator Ship Date:	871209
Trans1 Recv Date:	871209
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	880105
Part A Recv Date:	880125
Part B Recv Date:	880112
Generator EPA ID:	NYD980648422
Trans1 EPA ID:	NJD085634335
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	The Following Spent Halogenated Solvents: Tetrachloroethylene, Methylene Chloride, Trichloroethylene, 1,1,1-Trichloroethane, Chlorobenzene, 1,1,2-Trichloro-1,2,2-Trifluoroethane, Ortho-Dichlorobenzene, Trichlorofluoromethane, And 1,1,2, Trichloroethane; All Spent Solvent Mixtures/Blends Containing, Before Use, A Total Of Ten Percent Or More (By Volume) Of One Or More Of The Above Halogenated Solvents Or Those Solvents Listed In F001, F004, And F005; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent Mixtures.
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00055
Units:	Gallons (liquids only)
Number of Containers:	001
Container Type:	Metal drums, barrels, kegs

WHITE PLAINS RUBBER STAMP & NAMEPLATE (Continued) **1000397523**

Handling Method:	Recycle
Specific Gravity:	100
Document ID:	NJO0189970
Manifest Status:	C - Completed copy
Trans1 State ID:	2841AY
Year:	1984
Trans2 State ID:	Not reported
Generator Ship Date:	840816
Trans1 Recv Date:	840816
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	840816
Part A Recv Date:	840904
Part B Recv Date:	840907
Generator EPA ID:	NYD980648422
Trans1 EPA ID:	NJD002200046
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	The Following Spent Nonhalogenated Solvents: Xylene, Acetone, Ethyl Acetate, Ethyl Benzene, Ethyl Ether, Methyl Isobutyl Ketone, N-Butyl Alcohol, Cyclohexanone, And Methanol; All Spent Solvent Mixtures/Blends Containing, Before Use, Only The Above Spent Nonhalogenated Solvents; And All Spent Solvent Mixtures/Blends Containing, Before Use, One Or More Of The Above Nonhalogenated Solvents, And A Total Of Ten Percent Or More (By Volume) Of One Or More Of Those Solvents Listed In F001, F002, F004, And F005; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent Mixtures.
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00150
Units:	Gallons (liquids only)
Number of Containers:	030
Container Type:	Dump truck
Handling Method:	Not reported
Specific Gravity:	100
Document ID:	NYA7190577
Manifest Status:	Not reported
Trans1 State ID:	IA7667
Year:	1993

WHITE PLAINS RUBBER STAMP & NAMEPLATE (Continued) **1000397523**

Trans2 State ID:	Not reported
Generator Ship Date:	08/20/1993
Trans1 Recv Date:	08/20/1993
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	08/20/1993
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD980648422
Trans1 EPA ID:	NYD057722258
Trans2 EPA ID:	Not reported
TSDF ID 1:	NYD057722258
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	The Following Spent Halogenated Solvents Used In Degreasing: Tetrachloroethylene, Trichlorethylene, Methylene Chloride, 1,1,1-Trichloroethane, Carbon Tetrachloride And Chlorinated Fluorocarbons; All Spent Solvent Mixtures/Blends Used In Degreasing Containing, Before Use, A Total Of Ten Percent Or More (By Volume) Of One Or More Of The Above Halogenated Solvents Or Those Solvents Listed In F002, F004, And F005; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent Mixtures.
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00040
Units:	Gallons (liquids only)
Number of Containers:	002
Container Type:	Metal drums, barrels, kegs
Handling Method:	Recycle
Specific Gravity:	01.21
Document ID:	NJA0472970
Manifest Status:	K - Completed after the designated time
Trans1 State ID:	S5811
Year:	1988
Trans2 State ID:	Not reported
Generator Ship Date:	880621
Trans1 Recv Date:	880621
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	880621
Part A Recv Date:	880715
Part B Recv Date:	880719
Generator EPA ID:	NYD980648422
Trans1 EPA ID:	NJD982281016

WHITE PLAINS RUBBER STAMP & NAMEPLATE (Continued) **1000397523**

Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	The Following Spent Halogenated Solvents: Tetrachloroethylene, Methylene Chloride, Trichloroethylene, 1,1,1-Trichloroethane, Chlorobenzene, 1,1,2-Trichloro-1,2,2-Trifluoroethane, Ortho-Dichlorobenzene, Trichlorofluoromethane, And 1,1,2, Trichloroethane; All Spent Solvent Mixtures/Blends Containing, Before Use, A Total Of Ten Percent Or More (By Volume) Of One Or More Of The Above Halogenated Solvents Or Those Solvents Listed In F001, F004, And F005; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent Mixtures.
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00055
Units:	Gallons (liquids only)
Number of Containers:	001
Container Type:	Metal drums, barrels, kegs
Handling Method:	Recycle
Specific Gravity:	100

T242 **SPRINT WHITE PLAINS POP** **NY UST** **U004441788**
NE **300 HAMILTON AVENUE** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.171 mi.
905 ft. **Site 11 of 13 in cluster T**

Relative: WESTCHESTER CO. UST:
Higher

Name:	SPRINT WHITE PLAINS POP
Address:	300 HAMILTON AVENUE
City,State,Zip:	WHITE PLAINS, NY 10601
Id/Status:	3-801122 / Unregulated
Operator Name:	Bill Holloway
Owner Name:	Sprint Communications
Owner Street:	p.o. box 7994
Owner Address2:	Not reported
Owner City:	Shawnee Mission
Owner State:	KS
Owner Zipcode:	66207-7994
GDS Number:	Not reported
Tank Number:	01

Actual:
213 ft.

SPRINT WHITE PLAINS POP (Continued) **U004441788**

Status:	3. Closed - Removed
Capacity:	3000
Product Stored:	0008. Diesel
Product Stored Percent:	Not reported
Tank Leak Detection:	1. Electronic Interstitial Monitoring
Date Installation:	03/01/2003
Date Perm Closure:	06/08/2017
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	6. Fiberglass reinforced plastic (FRP)
Tank Internal Protection:	3. Fiberglass liner (FRP)
Tank External Protection:	4. Fiberglass
Tank Secondary Containment:	4. Double-Walled (underground only)
Piping Location:	2. Underground/on Ground
Piping Type:	11. Flexible Piping
Piping External Protection:	4. Fiberglass
Overfill Prevention:	2. High Level Alarm,3. Automatic Shut-off
Piping Secondary Containment:	4. Double-Walled (underground only)
Spill Prevention:	1. Catch Basin
Dispenser:	2. Suction

T243 **AMCOTT ASSOCIATES** **NY UST** **U003994325**
NE **300 HAMILTON AVENUE** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.171 mi.
905 ft. **Site 12 of 13 in cluster T**

Relative: **Higher**
Actual: **213 ft.**

WESTCHESTER CO. UST:

Name:	AMCOTT ASSOCIATES
Address:	300 HAMILTON AVENUE
City,State,Zip:	WHITE PLAINS, NY 10601
Id/Status:	3-259241 / Active
Operator Name:	Amcott Associates
Owner Name:	Amcott Associates
Owner Street:	60 Morrow Avenue
Owner Address2:	Not reported
Owner City:	Scarsdale
Owner State:	NY
Owner Zipcode:	10583
GDS Number:	Not reported
Tank Number:	002
Status:	0. Administratively closed
Capacity:	3000
Product Stored:	Not reported
Product Stored Percent:	Not reported
Tank Leak Detection:	5. In-Tank System (auto tank gauge)
Date Installation:	03/01/2003
Date Perm Closure:	12/05/2003
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	6. Fiberglass reinforced plastic (FRP)
Tank Internal Protection:	Not reported
Tank External Protection:	4. Fiberglass
Tank Secondary Containment:	4. Double-Walled (underground only)
Piping Location:	3. Aboveground/underground combination
Piping Type:	99. Other
Piping External Protection:	Not reported
Overfill Prevention:	2. High Level Alarm,3. Automatic Shut-off
Piping Secondary Containment:	Not reported

AMCOTT ASSOCIATES (Continued) **U003994325**

Spill Prevention:	Not reported
Dispenser:	3. Gravity

Tank Number:	02
Status:	1. In-Service
Capacity:	8000
Product Stored:	0001. #2 Fuel Oil
Product Stored Percent:	Not reported
Tank Leak Detection:	2. Manual Interstitial Monitoring
Date Installation:	08/01/2002
Date Perm Closure:	01/01/1900
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	4. Fiberglass coated steel
Tank Internal Protection:	0. None
Tank External Protection:	4. Fiberglass
Tank Secondary Containment:	4. Double-Walled (underground only)
Piping Location:	2. Underground/on Ground
Piping Type:	6. Fiberglass Reinforced Plastic (FRP)
Piping External Protection:	6. Wrapped (Piping)
Overfill Prevention:	5. Vent Whistle
Piping Secondary Containment:	0. None
Spill Prevention:	1. Catch Basin
Dispenser:	2. Suction

Tank Number:	1
Status:	3. Closed - Removed
Capacity:	5000
Product Stored:	Not reported
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	Not reported
Date Perm Closure:	08/01/2002
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Secondary Containment:	0. None
Piping Location:	3. Aboveground/underground combination
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	6. Wrapped (Piping)
Overfill Prevention:	5. Vent Whistle
Piping Secondary Containment:	Not reported
Spill Prevention:	0. None
Dispenser:	2. Suction

T244 **AMCOTT ASSOCIATES** **NY AST** **A100486706**
NE **300 HAMILTON AVENUE** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.171 mi.
905 ft. **Site 13 of 13 in cluster T**

Relative: WESTCHESTER CO. AST:
Higher

Name:	AMCOTT ASSOCIATES
Address:	300 HAMILTON AVENUE
City,State,Zip:	WHITE PLAINS, NY 10601
PBS Number:	3-259241

Actual:
213 ft.

AMCOTT ASSOCIATES (Continued) **A100486706**

Site Status:	Active
GDS Number:	Not reported
Operator Name:	Amcott Associates
Owner Name:	Amcott Associates
Owner Street:	60 Morrow Avenue
Owner Address2:	Not reported
Owner City/State/Zip:	Scarsdale, NY 10583
Tank Number:	03
Status:	1. In-Service
Date Installation:	01/01/2010
Capacity:	25
Product Stored:	0001. #2 Fuel Oil
Product Stored Percent:	Not reported
Date Perm Closure:	01/01/1900
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Leak Detection:	2. Manual Interstitial Monitoring
Tank Secondary Containment:	12. Double-Walled (AST only)
Piping Location:	3. Aboveground/Underground Combination
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	4. Fiberglass
Piping Leak Detection:	2. Manual Interstitial Monitoring
Piping Secondary Containment:	4. Double-Walled (underground only)
Overfill Prevention:	3. Automatic Shut-off
Spill Prevention:	1. Catch Basin
Dispenser:	Not reported

W245 **CON EDISON MANHOLE 4144** **RCRA NonGen / NLR 1010327462**
North **BARKER AVE & GROVE ST** **NY MANIFEST NYP004146783**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.172 mi.
909 ft. **Site 2 of 13 in cluster W**

Relative: **Lower**
Actual: **186 ft.**

RCRA Listings:

Date Form Received by Agency:	20070111
Handler Name:	Con Edison Manhole 4144
Handler Address:	Barker Ave & Grove St
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYP004146783
Contact Name:	MICHAEL DAUGHTREY
Contact Address:	4 IRVING PL, RM 828
Contact City,State,Zip:	NEW YORK, NY 10003
Contact Telephone:	212-580-8383
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Not reported
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R3

CON EDISON MANHOLE 4144 (Continued) **1010327462**

Mailing Address:	4 IRVING PL, RM 828
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20150414
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20070109
Handler Name: CON EDISON	
Federal Waste Generator Description:	Not reported
State District Owner:	Not reported
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No

CON EDISON MANHOLE 4144 (Continued) **1010327462**

Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20070110
Handler Name: CON EDISON
Federal Waste Generator Description: Not a generator, verified
State District Owner: Not reported
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20070111
Handler Name: CON EDISON MANHOLE 4144
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

NY MANIFEST:
EPA ID: NYP004146783
Country: USA
Name: Coned
Address: BARKER AVE & GROVE ST
Address 2: Not reported
City,State,Zip: WHITE PLAINS, NY 10601
Zip 4: Not reported
Location Address 1: BARKER ST & GROVE ST
Location Address 2: Not reported
Location City,State,Zip: WHITE PLAINS, NY
Location Zip 4: Not reported
Facility Status: Not reported
Total Tanks: Not reported

CON EDISON MANHOLE 4144 (Continued) **1010327462**

Code: BP

Mailing:
Mailing Name: Coned
Mailing Contact: Coned
Mailing Address 1: 4 IRVING PLACE
Mailing Address 2: Not reported
Mailing City,State,Zip: NEW YORK, NY 10004
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: Not reported

Manifest Data:
Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: NJD003812047
Year: 2018
Trans2 State ID: NJD003812047
Generator Ship Date: 11/22/2006
Trans1 Recv Date: 11/22/2006
Trans2 Recv Date: 11/27/2006
TSD Site Recv Date: 11/27/2006
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYP004146783
Trans1 EPA ID: Not reported
Trans2 EPA ID: Not reported
TSDF ID 1: NJD980536593
TSDF ID 2: Not reported
Manifest Tracking Number: 000019664GBF
Import Indicator: N
Export Indicator: N
Discr Quantity Indicator: N
Discr Type Indicator: N
Discr Residue Indicator: N
Discr Partial Reject Indicator: N
Discr Full Reject Indicator: N
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: H141
Waste Code a: Lead
Waste Code b: Chromium
Waste Code c: Not reported
Waste Code e: Not reported
Waste Code f: Not reported
Waste Code g: Not reported
Waste Code 1: Not reported
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 2000
Units: Kilograms
Number of Containers: 12
Container Type: Metal drums, barrels, kegs

CON EDISON MANHOLE 4144 (Continued) **1010327462**

Handling Method: Landfill
Specific Gravity: 1

W246 **CONSOLIDATED EDISON** **NY MANIFEST** **S110823958**
NNW **WATER ST & LEXINGTON AVE** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10602**
0.173 mi.
912 ft. **Site 3 of 13 in cluster W**

Relative:
Lower

Actual:
187 ft.

NY MANIFEST:
EPA ID: NYP004229579
Country: USA
Name: Consolidated Edison
Address: WATER ST & LEXINGTON AVE
Address 2: Not reported
City,State,Zip: WHITE PLAINS, NY 10602
Zip 4: Not reported
Location Address 1: WATER ST & LEXINGTON AVE
Location Address 2: Not reported
Location City,State,Zip: WHITE PLAINS, NY 10602
Location Zip 4: Not reported
Facility Status: Not reported
Total Tanks: Not reported
Code: BP

Mailing:
Mailing Name: Consolidated Edison
Mailing Contact: Tom Teeling
Mailing Address 1: 4 IRVING PLACE RM 828
Mailing Address 2: Not reported
Mailing City,State,Zip: NEW YORK, NY 10003
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: 2124603770

Manifest Data:
Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: NYD006982359
Year: 2018
Trans2 State ID: Not reported
Generator Ship Date: 03/03/2011
Trans1 Recv Date: 03/03/2011
Trans2 Recv Date: Not reported
TSD Site Recv Date: 03/03/2011
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYP004229579
Trans1 EPA ID: Not reported
Trans2 EPA ID: Not reported
TSDF ID 1: NJD002200046
TSDF ID 2: Not reported
Manifest Tracking Number: 007655527JJK
Import Indicator: N
Export Indicator: N
Discr Quantity Indicator: N
Discr Type Indicator: Y

CONSOLIDATED EDISON (Continued) **S110823958**

Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H111
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	200
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

W247 **CON EDISON** **NY MANIFEST** **S117537764**
NNW **WATER ST & N LEXINGTON AV** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10801**
0.173 mi.
912 ft. **Site 4 of 13 in cluster W**

Relative: **Lower**
Actual: **187 ft.**

NY MANIFEST:

EPA ID:	NYP004703617
Country:	USA
Name:	Con Edison
Address:	WATER ST & N LEXINGTON AV
Address 2:	MH4047
City,State,Zip:	WHITE PLAINS, NY 10801
Zip 4:	Not reported
Location Address 1:	WATER ST & N LEXINGTON AV
Location Address 2:	MH4047
Location City,State,Zip:	WHITE PLAINS, NY 10801
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Edison
Mailing Contact:	Con Edison
Mailing Address 1:	4 IRVING PL
Mailing Address 2:	15TH FL
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	Not reported

CON EDISON (Continued) **S117537764**

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	MAD039322250
Year:	2018
Trans2 State ID:	MAD039322250
Generator Ship Date:	12/05/2014
Trans1 Recv Date:	12/05/2014
Trans2 Recv Date:	12/08/2014
TSD Site Recv Date:	12/08/2014
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004703617
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD991291105
TSDF ID 2:	Not reported
Manifest Tracking Number:	007747986FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	1
Units:	Cubic Yards
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Landfill
Specific Gravity:	1

W248 **CON EDISON MANHOLE 10401** **RCRA NonGen / NLR** **1014918444**
NNW **WATER ST & N LEXINGTON AVE** **NY MANIFEST** **NYP004220588**
1/8-1/4 **WHITE PLAINS, NY 10601** **NJ MANIFEST**
0.173 mi.
912 ft. **Site 5 of 13 in cluster W**

Relative: **Lower**
Actual: **187 ft.**

RCRA Listings:

Date Form Received by Agency:	20101222
Handler Name:	Con Edison Manhole 10401
Handler Address:	Water St & N Lexington Ave
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYP004220588
Contact Name:	CHRISTOPHER BLAICH
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	914-925-6219
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	SR SPECIALIST
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PL RM 828
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No

CON EDISON MANHOLE 10401 (Continued) **1014918444**

Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20110701
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20101122
Handler Name:	CON EDISON MANHOLE 10401
Federal Waste Generator Description:	Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20101222
Handler Name:	CON EDISON MANHOLE 10401
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

List of NAICS Codes and Descriptions:

NAICS Codes:	No NAICS Codes Found

Facility Has Received Notices of Violations:

Violations:	No Violations Found

Evaluation Action Summary:

Evaluations:	No Evaluations Found

CON EDISON MANHOLE 10401 (Continued) **1014918444**

NY MANIFEST:

EPA ID:	NYP004220588
Country:	USA
Name:	Consolidated Edison
Address:	WATER ST & N LEXINGTON AVE
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10601
Zip 4:	Not reported
Location Address 1:	MH10401 - WATER ST E/O N LEXINGTON
Location Address 2:	Not reported
Location City,State,Zip:	WHITE PLAINS, NY
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Consolidated Edison
Mailing Contact:	Thomas Teeling
Mailing Address 1:	4 IRVING PL RM 828
Mailing Address 2:	Not reported
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	2124603770

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	11/22/2010
Trans1 Recv Date:	11/22/2010
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	11/23/2010
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004220588
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	001057768GBF
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	Y
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H111
Waste Code a:	Lead
Waste Code b:	Not reported

CON EDISON MANHOLE 10401 (Continued) **1014918444**

Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	200
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

NJ MANIFEST:

EPA ID:	NYP004220588
Name:	CON EDISON MANHOLE 10401
Address:	WATER ST & N LEXINGTON AVE
City,State,Zip:	WHITE PLAINS, NY 10601
County:	Not reported
Mailing Address:	IRVING PL RM 828
Mailing City,State,Zip:	NEW YORK, NY 10003
Telephone:	Not reported
Emergency Telephone:	Not reported
Contact:	CHRISTOPHER BLAICH
Comments:	Not reported
SIC Code:	Not reported
County:	NY119
Municipal:	Not reported
Previous EPAID:	Not reported
Generator Flag:	Not reported
Transporter Flag:	Not reported
TSDF Flag:	Not reported
Name Change:	Not reported
Date Change:	Not reported

Manifest Data:

EPA ID:	NYP004220588
Manifest Number:	001057768GBF
Date Shipped:	11/22/2010
TSDF EPA ID:	NJD002200046
Transporter EPA ID:	NYD006982359
Transporter 2 EPA ID:	Not reported
Transporter 3 EPA ID:	Not reported
Transporter 4 EPA ID:	Not reported
Transporter 5 EPA ID:	Not reported
Transporter 6 EPA ID:	Not reported
Transporter 7 EPA ID:	Not reported
Transporter 8 EPA ID:	Not reported
Transporter 9 EPA ID:	Not reported
Transporter 10 EPA ID:	Not reported
Date Trans1 Transported Waste:	11/22/2010
Date Trans2 Transported Waste:	Not reported

CON EDISON MANHOLE 10401 (Continued) **1014918444**

Date Trans3 Transported Waste:	Not reported
Date Trans4 Transported Waste:	Not reported
Date Trans5 Transported Waste:	Not reported
Date Trans6 Transported Waste:	Not reported
Date Trans7 Transported Waste:	Not reported
Date Trans8 Transported Waste:	Not reported
Date Trans9 Transported Waste:	Not reported
Date Trans10 Transported Waste:	Not reported
Date TSDF Received Waste:	11/23/2010
TSDF EPA Facility Name:	Not reported
QTY Units:	Not reported
Transporter SEQ ID:	Not reported
Transporter-1 Date:	Not reported
Waste SEQ ID:	Not reported
Waste Type Code 2:	Not reported
Waste Type Code 3:	Not reported
Waste Type Code 4:	Not reported
Waste Type Code 5:	Not reported
Waste Type Code 6:	Not reported
Date Accepted:	Not reported
Manifest Discrepancy Type:	Not reported
Data Entry Number:	Not reported
Was Load Rejected:	N
Reason Load Was Rejected:	Not reported

Waste:

Manifest Year:	Not reported
Waste Code:	D008
Hand Code:	H111
Quantity:	200
Unit:	P

W249 **CON EDISON MANHOLE: 10401** **RCRA NonGen / NLR** **1016451291**
NNW **WATER ST & LEXINGTON AVE** **NY MANIFEST** **NYP004303343**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.173 mi.
912 ft. **Site 6 of 13 in cluster W**

Relative: **Lower**
Actual: **187 ft.**

RCRA Listings:

Date Form Received by Agency:	20130520
Handler Name:	Con Edison Manhole: 10401
Handler Address:	Water St & Lexington Ave
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYP004303343
Contact Name:	CHRISTOPHER BLAICH
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	914-925-6219
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	SR SPECIALIST
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported

CON EDISON MANHOLE: 10401 (Continued) **1016451291**

Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	Not reported
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20130910
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20130420
Handler Name:	CON EDISON MANHOLE: 10401
Federal Waste Generator Description:	Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator

CON EDISON MANHOLE: 10401 (Continued) **1016451291**

State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20130520
Handler Name: CON EDISON MANHOLE: 10401
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

NY MANIFEST:
EPA ID: NYP004303343
Country: USA
Name: Con Edison
Address: WATER ST & LEXINGTON AVE
Address 2: Not reported
City,State,Zip: WHITE PLAINS, NY 10601
Zip 4: Not reported
Location Address 1: WATER ST & LEXINGTON AVE
Location Address 2: MH 10401
Location City,State,Zip: WHITE PLAINS, NY 10601
Location Zip 4: Not reported
Facility Status: Not reported
Total Tanks: Not reported
Code: BP

Mailing:
Mailing Name: Con Edison
Mailing Contact: Tom Teeling
Mailing Address 1: 4 IRVING PLACE - 15TH FLOOR
Mailing Address 2: Not reported
Mailing City,State,Zip: NEW YORK, NY 10003
Mailing Zip 4: Not reported

CON EDISON MANHOLE: 10401 (Continued) **1016451291**

Mailing Country: USA
Mailing Phone: 2124603770

Manifest Data:
Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: NYD006982359
Year: 2018
Trans2 State ID: Not reported
Generator Ship Date: 04/20/2013
Trans1 Recv Date: 04/20/2013
Trans2 Recv Date: Not reported
TSD Site Recv Date: 04/25/2013
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYP004303343
Trans1 EPA ID: Not reported
Trans2 EPA ID: Not reported
TSDF ID 1: NJD002200046
TSDF ID 2: Not reported
Manifest Tracking Number: 007019046JJK
Import Indicator: N
Export Indicator: N
Discr Quantity Indicator: N
Discr Type Indicator: N
Discr Residue Indicator: N
Discr Partial Reject Indicator: N
Discr Full Reject Indicator: N
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: H110
Waste Code a: Lead
Waste Code b: Not reported
Waste Code c: Not reported
Waste Code e: Not reported
Waste Code f: Not reported
Waste Code g: Not reported
Waste Code 1: Not reported
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 400
Units: Pounds
Number of Containers: 1
Container Type: Cargo tanks (tank trucks)
Handling Method: Treat
Specific Gravity: 1

W250 **CON EDISON** **RCRA NonGen / NLR** **1014398364**
NNW **WATER ST & LEXINGTON AVE** **NY MANIFEST** **NYP004207167**
1/8-1/4 **WHITE PLAINS, NY 10603** **NJ MANIFEST**
0.173 mi.
912 ft. **Site 7 of 13 in cluster W**

Relative: **Lower**

Actual: **187 ft.**

RCRA Listings:

Date Form Received by Agency:	20200413
Handler Name:	Con Edison
Handler Address:	Water St & Lexington Ave
Handler City,State,Zip:	WHITE PLAINS, NY 10603
EPA ID:	NYP004207167
Contact Name:	Not reported
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	Not reported
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	Not reported
Mailing City,State,Zip:	Not reported
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No

CON EDISON (Continued) **1014398364**

Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20200413
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20100524
Handler Name: CON EDISON	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20200413
Handler Name: CON EDISON	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	No
Electronic Manifest Broker:	No

List of NAICS Codes and Descriptions:

NAICS Codes:	No NAICS Codes Found

Facility Has Received Notices of Violations:

Violations:	No Violations Found

Evaluation Action Summary:

Evaluations:	No Evaluations Found

CON EDISON (Continued) **1014398364**

NY MANIFEST:

EPA ID:	NYP004207167
Country:	USA
Name:	Consolidated Edison - Mh 10714
Address:	WATER ST & LEXINGTON AVE
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10603
Zip 4:	Not reported
Location Address 1:	WATER STREET W/O LEXINGTON
Location Address 2:	Not reported
Location City,State,Zip:	WHITE PLAINS, NY 10602
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Consolidated Edison - Mh 10714
Mailing Contact:	Tom Teeling
Mailing Address 1:	4 IRVING PLACE RM 828
Mailing Address 2:	Not reported
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	2124603770

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	05/24/2010
Trans1 Recv Date:	05/24/2010
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	05/26/2010
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004207167
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	007020795JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	Y
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H111
Waste Code a:	Lead
Waste Code b:	Not reported

CON EDISON (Continued) **1014398364**

Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	50
Units:	Pounds
Number of Containers:	100
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

NJ MANIFEST:

EPA ID:	NYP004207167
Name:	CON EDISON
Address:	WATER ST & LEXINGTON AVE
City,State,Zip:	WHITE PLAINS, NY 10603
County:	Not reported
Mailing Address:	4 IRVING PL, RM 828
Mailing City,State,Zip:	NEW YORK, NY 10003
Telephone:	Not reported
Emergency Telephone:	Not reported
Contact:	PAUL WALSH
Comments:	Not reported
SIC Code:	Not reported
County:	NY119
Municipal:	Not reported
Previous EPAID:	Not reported
Generator Flag:	Not reported
Transporter Flag:	Not reported
TSDF Flag:	Not reported
Name Change:	Not reported
Date Change:	Not reported

Manifest Data:

EPA ID:	NYP004207167
Manifest Number:	007020795JJK
Date Shipped:	05/24/2010
TSDF EPA ID:	NJD002200046
Transporter EPA ID:	NYD006982359
Transporter 2 EPA ID:	Not reported
Transporter 3 EPA ID:	Not reported
Transporter 4 EPA ID:	Not reported
Transporter 5 EPA ID:	Not reported
Transporter 6 EPA ID:	Not reported
Transporter 7 EPA ID:	Not reported
Transporter 8 EPA ID:	Not reported
Transporter 9 EPA ID:	Not reported
Transporter 10 EPA ID:	Not reported
Date Trans1 Transported Waste:	05/24/2010
Date Trans2 Transported Waste:	Not reported

CON EDISON (Continued) **1014398364**

Date Trans3 Transported Waste:	Not reported
Date Trans4 Transported Waste:	Not reported
Date Trans5 Transported Waste:	Not reported
Date Trans6 Transported Waste:	Not reported
Date Trans7 Transported Waste:	Not reported
Date Trans8 Transported Waste:	Not reported
Date Trans9 Transported Waste:	Not reported
Date Trans10 Transported Waste:	Not reported
Date TSDF Received Waste:	05/26/2010
TSDF EPA Facility Name:	Not reported
QTY Units:	Not reported
Transporter SEQ ID:	Not reported
Transporter-1 Date:	Not reported
Waste SEQ ID:	Not reported
Waste Type Code 2:	Not reported
Waste Type Code 3:	Not reported
Waste Type Code 4:	Not reported
Waste Type Code 5:	Not reported
Waste Type Code 6:	Not reported
Date Accepted:	Not reported
Manifest Discrepancy Type:	Not reported
Data Entry Number:	Not reported
Was Load Rejected:	N
Reason Load Was Rejected:	Not reported

Waste:

Manifest Year:	Not reported
Waste Code:	D008
Hand Code:	H111
Quantity:	50
Unit:	P

W251 **CON EDISON** **NY MANIFEST** **S117537747**
NNW **WATER ST & N LEXINGTON AV** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10801**
0.173 mi.
912 ft. **Site 8 of 13 in cluster W**

Relative: **Lower**
Actual: **187 ft.**

NY MANIFEST:

EPA ID:	NYP004703427
Country:	USA
Name:	Con Edison
Address:	WATER ST & N LEXINGTON AV
Address 2:	MH7653
City,State,Zip:	WHITE PLAINS, NY 10801
Zip 4:	Not reported
Location Address 1:	WATER ST & N LEXINGTON AV
Location Address 2:	MH7653
Location City,State,Zip:	WHITE PLAINS, NY 10801
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Edison
Mailing Contact:	Con Edison

CON EDISON (Continued) **S117537747**

Mailing Address 1: 4 IRVING PL
Mailing Address 2: 15TH FL
Mailing City,State,Zip: NEW YORK, NY 10003
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: Not reported

Manifest Data:
Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: MAD039322250
Year: 2018
Trans2 State ID: MAD039322250
Generator Ship Date: 12/05/2014
Trans1 Recv Date: 12/05/2014
Trans2 Recv Date: 12/08/2014
TSD Site Recv Date: 12/08/2014
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYP004703427
Trans1 EPA ID: Not reported
Trans2 EPA ID: Not reported
TSDF ID 1: NJD991291105
TSDF ID 2: Not reported
Manifest Tracking Number: 007747985FLE
Import Indicator: N
Export Indicator: N
Discr Quantity Indicator: N
Discr Type Indicator: N
Discr Residue Indicator: N
Discr Partial Reject Indicator: N
Discr Full Reject Indicator: N
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: H110
Waste Code a: Lead
Waste Code b: Not reported
Waste Code c: Not reported
Waste Code e: Not reported
Waste Code f: Not reported
Waste Code g: Not reported
Waste Code 1: Not reported
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 1
Units: Cubic Yards
Number of Containers: 1
Container Type: Cargo tanks (tank trucks)
Handling Method: Landfill
Specific Gravity: 1

W252 **CON EDISON MANHOLE: 10402** **RCRA NonGen / NLR** **1016962759**
NNW **WATER ST & LEXINGTON AVE** **NY MANIFEST** **NYP004358081**
1/8-1/4 **WHITE PLAINS, NY 10610**
0.173 mi.
912 ft. **Site 9 of 13 in cluster W**

Relative: **Lower**

Actual: **187 ft.**

RCRA Listings:

Date Form Received by Agency:	20131011
Handler Name:	Con Edison Manhole: 10402
Handler Address:	Water St & Lexington Ave
Handler City,State,Zip:	WHITE PLAINS, NY 10610
EPA ID:	NYP004358081
Contact Name:	DONALD SENNO
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	914-925-6219
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	SR SPECIALIST
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PL, RM 828
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No

CON EDISON MANHOLE: 10402 (Continued) **1016962759**

Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20140701
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20130911
Handler Name:	CON EDISON MANHOLE: 10402
Federal Waste Generator Description:	Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20131011
Handler Name:	CON EDISON MANHOLE: 10402
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

List of NAICS Codes and Descriptions:

NAICS Codes:	No NAICS Codes Found

Facility Has Received Notices of Violations:

Violations:	No Violations Found

Evaluation Action Summary:

Evaluations:	No Evaluations Found

CON EDISON MANHOLE: 10402 (Continued) **1016962759**

NY MANIFEST:

EPA ID:	NYP004358081
Country:	USA
Name:	Con Edison
Address:	WATER ST & LEXINGTON AVE
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10610
Zip 4:	Not reported
Location Address 1:	WATER ST & N LEXINGTON AVE
Location Address 2:	MH 10402
Location City,State,Zip:	WHITE PLAINS, NY
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Edison
Mailing Contact:	Con Edison
Mailing Address 1:	4 IRVING PL 15TH FL
Mailing Address 2:	Not reported
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	2124603770

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	09/11/2013
Trans1 Recv Date:	09/11/2013
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	09/16/2013
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004358081
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	011695943JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported

CON EDISON MANHOLE: 10402 (Continued) **1016962759**

Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	200
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

W253 **CON EDISON - MANHOLE 3567** **NY MANIFEST** **S120958162**
NNW **WATER ST & LEXINGTON AVE** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.173 mi.
912 ft. **Site 10 of 13 in cluster W**

Relative: NY MANIFEST:
Lower

Actual: EPA ID: NYP004917565
187 ft. Country: USA
Name: Con Edison - Manhole 3567
Address: WATER ST & LEXINGTON AVE
Address 2: Not reported
City,State,Zip: WHITE PLAINS, NY 10601
Zip 4: Not reported
Location Address 1: WATER ST & LEXINGTON AVE
Location Address 2: Not reported
Location City,State,Zip: WHITE PLAINS, NY 10601
Location Zip 4: Not reported
Facility Status: Not reported
Total Tanks: Not reported
Code: BP

Mailing:
Mailing Name: Con Edison - Manhole 3567
Mailing Contact: Con Edison
Mailing Address 1: 4 IRVING PL 15TH FL NE
Mailing Address 2: Not reported
Mailing City,State,Zip: NEW YORK, NY 10003
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: Not reported

W254 **CON EDISON** **RCRA NonGen / NLR** **1014398366**
NNW **WATER ST & LEXINGTON AVE** **NY MANIFEST** **NYP004207183**
1/8-1/4 **WHITE PLAINS, NY 10603** **NJ MANIFEST**
0.173 mi.
912 ft. **Site 11 of 13 in cluster W**

Relative: **Lower**
Actual: **187 ft.**

RCRA Listings:

Date Form Received by Agency:	20200413
Handler Name:	Con Edison
Handler Address:	Water St & Lexington Ave
Handler City,State,Zip:	WHITE PLAINS, NY 10603
EPA ID:	NYP004207183
Contact Name:	Not reported
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	Not reported
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	Not reported
Mailing City,State,Zip:	Not reported
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No

CON EDISON (Continued) **1014398366**

Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20200413
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20100525
Handler Name: CON EDISON	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20200413
Handler Name: CON EDISON	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	No
Electronic Manifest Broker:	No

List of NAICS Codes and Descriptions:

NAICS Codes:	No NAICS Codes Found

Facility Has Received Notices of Violations:

Violations:	No Violations Found

Evaluation Action Summary:

Evaluations:	No Evaluations Found

CON EDISON (Continued) **1014398366**

NY MANIFEST:

EPA ID:	NYP004207183
Country:	USA
Name:	Consolidated Edison
Address:	WATER ST & LEXINGTON AVE
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10603
Zip 4:	Not reported
Location Address 1:	WATER ST & N LEXINGTON AVE - MH 105
Location Address 2:	Not reported
Location City,State,Zip:	WHITE PLAINS, NY 10602
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Consolidated Edison
Mailing Contact:	Tom Teeling
Mailing Address 1:	4 IRVING PLACE RM 828
Mailing Address 2:	Not reported
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	2124603770

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	05/25/2010
Trans1 Recv Date:	05/25/2010
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	05/26/2010
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004207183
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	007020810JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	Y
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H111
Waste Code a:	Lead
Waste Code b:	Not reported

CON EDISON (Continued) **1014398366**

Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	550
Units:	Pounds
Number of Containers:	100
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

NJ MANIFEST:

EPA ID:	NYP004207183
Name:	CON EDISON
Address:	WATER ST & LEXINGTON AVE
City,State,Zip:	WHITE PLAINS, NY 10603
County:	Not reported
Mailing Address:	4 IRVING PL, RM 828
Mailing City,State,Zip:	NEW YORK, NY 10003
Telephone:	Not reported
Emergency Telephone:	Not reported
Contact:	PAUL WALSH
Comments:	Not reported
SIC Code:	Not reported
County:	NY119
Municipal:	Not reported
Previous EPAID:	Not reported
Generator Flag:	Not reported
Transporter Flag:	Not reported
TSDF Flag:	Not reported
Name Change:	Not reported
Date Change:	Not reported

Manifest Data:

EPA ID:	NYP004207183
Manifest Number:	007020810JJK
Date Shipped:	05/25/2010
TSDF EPA ID:	NJD002200046
Transporter EPA ID:	NYD006982359
Transporter 2 EPA ID:	Not reported
Transporter 3 EPA ID:	Not reported
Transporter 4 EPA ID:	Not reported
Transporter 5 EPA ID:	Not reported
Transporter 6 EPA ID:	Not reported
Transporter 7 EPA ID:	Not reported
Transporter 8 EPA ID:	Not reported
Transporter 9 EPA ID:	Not reported
Transporter 10 EPA ID:	Not reported
Date Trans1 Transported Waste:	05/25/2010
Date Trans2 Transported Waste:	Not reported

CON EDISON (Continued) **1014398366**

Date Trans3 Transported Waste:	Not reported
Date Trans4 Transported Waste:	Not reported
Date Trans5 Transported Waste:	Not reported
Date Trans6 Transported Waste:	Not reported
Date Trans7 Transported Waste:	Not reported
Date Trans8 Transported Waste:	Not reported
Date Trans9 Transported Waste:	Not reported
Date Trans10 Transported Waste:	Not reported
Date TSDF Received Waste:	05/26/2010
TSDF EPA Facility Name:	Not reported
QTY Units:	Not reported
Transporter SEQ ID:	Not reported
Transporter-1 Date:	Not reported
Waste SEQ ID:	Not reported
Waste Type Code 2:	Not reported
Waste Type Code 3:	Not reported
Waste Type Code 4:	Not reported
Waste Type Code 5:	Not reported
Waste Type Code 6:	Not reported
Date Accepted:	Not reported
Manifest Discrepancy Type:	Not reported
Data Entry Number:	Not reported
Was Load Rejected:	N
Reason Load Was Rejected:	Not reported

Waste:

Manifest Year:	Not reported
Waste Code:	D008
Hand Code:	H111
Quantity:	550
Unit:	P

X255 **196-200 MARTINE AVENUE** **NY AST** **A100540233**
East **196-200 MARTINE AVENUE** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.174 mi.
918 ft. **Site 1 of 8 in cluster X**

Relative:
Higher

Actual:
216 ft.

WESTCHESTER CO. AST:

Name:	196-200 MARTINE AVENUE
Address:	196-200 MARTINE AVENUE
City,State,Zip:	WHITE PLAINS, NY 10601
PBS Number:	3-802125
Site Status:	Active
GDS Number:	Not reported
Operator Name:	125th 33 Mamaroneck, LLC
Owner Name:	125th 33 Mamaroneck, LLC
Owner Street:	42 Oak Avenue, 3rd Floor
Owner Address2:	Not reported
Owner City/State/Zip:	Tuckahoe, NY 10707
Tank Number:	1
Status:	2. Temporarily out of service
Date Installation:	01/01/1970
Capacity:	3000
Product Stored:	0001. #2 Fuel Oil

196-200 MARTINE AVENUE (Continued) **A100540233**

Product Stored Percent:	Not reported
Date Perm Closure:	01/01/1900
Tank Location:	2. Aboveground (contact w/ impervious barrier)
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Leak Detection:	0. None
Tank Secondary Containment:	3. Vault (w/ no access)
Piping Location:	1. Aboveground
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	0. None
Piping Leak Detection:	0. None
Piping Secondary Containment:	0. None
Overfill Prevention:	0. None
Spill Prevention:	0. None
Dispenser:	Not reported

S256 **GRAND REALTY COMPANY** **NY UST** **U004440310**
SE **150 GRAND STREET** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.174 mi.
918 ft. **Site 3 of 11 in cluster S**

Relative: **Higher**
Actual: **234 ft.**

WESTCHESTER CO. UST:

Name:	GRAND REALTY COMPANY
Address:	150 GRAND STREET
City,State,Zip:	WHITE PLAINS, NY 10601
Id/Status:	3-176885 / Administratively Closed
Operator Name:	Tony Spagnoli
Owner Name:	Grand Realty Co
Owner Street:	110 Corporate Park Drive
Owner Address2:	Not reported
Owner City:	White Plains
Owner State:	NY
Owner Zipcode:	10604
GDS Number:	Not reported
Tank Number:	1
Status:	0. Administratively closed
Capacity:	10000
Product Stored:	Not reported
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	03/01/1960
Date Perm Closure:	06/23/2003
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	Not reported
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Overfill Prevention:	0. None
Piping Secondary Containment:	Not reported
Spill Prevention:	0. None
Dispenser:	3. Gravity

S257 **150 GRAND STREET OFFICE BUILDING** **NY UST** **U004439133**
SE **150 GRAND STREET** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.174 mi.
918 ft. **Site 4 of 11 in cluster S**

Relative: WESTCHESTER CO. UST:
Higher

Name:	150 GRAND STREET OFFICE BUILDING
Address:	150 GRAND STREET
City,State,Zip:	WHITE PLAINS, NY 10601
Id/Status:	3-800119 / Unregulated
Operator Name:	John Cuomo
Owner Name:	150 Grand Owner LLC
Owner Street:	420 Lexington Avenue
Owner Address2:	Not reported
Owner City:	New York
Owner State:	NY
Owner Zipcode:	10170
GDS Number:	Not reported
Tank Number:	1
Status:	4. Closed - in place
Capacity:	10000
Product Stored:	0001. #2 Fuel Oil
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	06/01/1962
Date Perm Closure:	08/22/2012
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	2. Underground/on ground
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Overfill Prevention:	5. Vent Whistle
Piping Secondary Containment:	0. None
Spill Prevention:	0. None
Dispenser:	2. Suction

Actual:
234 ft.

S258 **OFFICE BLDG BASEMENT** **NY LTANKS** **S102674993**
SE **150 GRAND STREET** **N/A**
1/8-1/4 **WHITE PLAINS, NY**
0.174 mi.
918 ft. **Site 5 of 11 in cluster S**

Relative: LTANKS:
Higher

Name:	OFFICE BLDG BASEMENT
Address:	150 GRAND STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8908740 / 1990-02-07
Facility ID:	8908740
Site ID:	307349
Spill Date:	1989-12-05
Spill Cause:	Tank Overfill
Spill Source:	Commercial/Industrial
Spill Class:	C3
Cleanup Ceased:	1990-02-07
SWIS:	6017

Actual:
234 ft.

OFFICE BLDG BASEMENT (Continued) **S102674993**

Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1989-12-05
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Responsible Party
Last Inspection:	1989-12-08
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1989-12-07
Spill Record Last Update:	2003-10-16
Spiller Name:	Not reported
Spiller Company:	SAME
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	248205
Latitude:	41.0283169
Longitude:	-73.7675937
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY 02/07/90: SPILL CLEANED UP BY A.L. EASTMAN . WCHD MONITORED CLEANUP.
Remarks:	FUEL SUPPLIER PAC-PETRO/PURE ENERGY GROUP(212-842-1100)CONTRACT HAULERM.B.TRUCKING(212-328-3275) AL EASTMAN IS CLEANUP CONTRACTOR T. GHIOSAYTO LOOK AT

All Materials:

Site ID:	307349
Operable Unit ID:	933790
Operable Unit:	01
Material ID:	441928
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	200.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

X259 **EMPLOYMENT BUILDING** **NY AST** **S108981735**
East **48 MAMARONECK AVE.** **NY Spills** **N/A**
1/8-1/4 **WHITE PLAINS, NY**
0.175 mi.
923 ft. **Site 2 of 8 in cluster X**

Relative:
Higher

Actual:
216 ft.

WESTCHESTER CO. AST:

Name:	48 MAMARONECK AVENUE, LLC
Address:	48 MAMARONECK AVENUE
City,State,Zip:	WHITE PLAINS, NY 10601
PBS Number:	3-074632

EMPLOYMENT BUILDING (Continued) **S108981735**

Site Status:	Unregulated: <1101 gal. PBS
GDS Number:	Not reported
Operator Name:	Ramon Lemus
Owner Name:	48 Mamaroneck Avenue, LLC c/o Silverman Realty
Owner Street:	237 Mamaroneck Avenue
Owner Address2:	Not reported
Owner City/State/Zip:	White Plains, NY 10605
Tank Number:	1
Status:	3. Closed - Removed
Date Installation:	12/01/1951
Capacity:	5000
Product Stored:	Not reported
Product Stored Percent:	Not reported
Date Perm Closure:	02/29/2008
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Leak Detection:	0. None
Tank Secondary Containment:	Not reported
Piping Location:	1. Aboveground
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Piping Leak Detection:	Not reported
Piping Secondary Containment:	Not reported
Overfill Prevention:	5. Vent Whistle
Spill Prevention:	Not reported
Dispenser:	2. Suction

SPILLS:

Name:	EMPLOYMENT BUILDING
Address:	48 MAMARONECK AVE.
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0710471 / 2008-01-08
Facility ID:	0710471
Facility Type:	ER
DER Facility ID:	341366
Site ID:	391767
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	B3
SWIS:	6017
Spill Date:	2008-01-03
Investigator:	JBODEE
Referred To:	WCDOH
Reported to Dept:	2008-01-03
CID:	406
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Local Agency
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	Not reported
Remediation Phase:	0

EMPLOYMENT BUILDING (Continued) **S108981735**

Date Entered In Computer:	2008-01-03
Spill Record Last Update:	2023-03-13
Spiller Name:	WILLIAM SILSDORF
Spiller Company:	EMPLOYMENT BUILDING?
Spiller Address:	48 MAMARONECK AVE.
Spiller Company:	001
Contact Name:	WILLIAM SILSDORF
Latitude:	41.0310216
Longitude:	-73.7666086
DEC Memo:	PBS #3-074632 - WCHD & WP Building Dept. on scene. 5000. gal. vaulted AST. Filled on 12/29/07 3200 gal. left in tank. Uses 175 gal/day x 6 days=1050 gal. Loss of potentially 1800 -100= 800 gal. Elite on site with vac truck and smaller pump. Tank in very poor condition. Todd Ghiosay contaced and will follow up.
Remarks:	Caller says the tank failed releasing the material into the basement of the building. Caller is unsure if the cause was corrosion of the tank or physical damage. Elite Environmental will be doing the clean up and the Westchester Dept. of Health is on scene.

All TTF:

Facility ID:	0710471
Spill Number:	0710471
Spill Tank Test:	2384409
Site ID:	391767
Tank Number:	1
Tank Size:	5000
Material:	0001
EPA UST:	Not reported
UST:	False
Cause:	00
Source:	01
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Watchdog
Last Modified Date:	Not reported

All Materials:

Site ID:	391767
Operable Unit ID:	1148803
Operable Unit:	01
Material ID:	2139295
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Y260 **EDGAR** **NY LTANKS** **S103479696**
North **1 BARKER AVE** **N/A**
1/8-1/4 **WHITE PLAINS, NY**
0.175 mi.
923 ft. **Site 1 of 2 in cluster Y**

Relative: **Lower**

Actual: **187 ft.**

LTANKS:

Name:	EDGAR
Address:	1 BARKER AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9807932 / 1999-11-19
Facility ID:	9807932
Site ID:	330854
Spill Date:	1998-09-29
Spill Cause:	Tank Failure
Spill Source:	Institutional, Educational, Gov., Other
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	WCHD
Referred To:	Westchester Cnty Health Dept
Reported to Dept:	1998-09-29
CID:	351
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1998-09-29
Spill Record Last Update:	1999-12-28
Spiller Name:	FRANK UZZO
Spiller Company:	WHITE PLAINS REALTY
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	ROB EDGAR
Spiller Phone:	(973) 560-1400
Spiller Extention:	159
DEC Region:	3
DER Facility ID:	266099
Latitude:	41.0345144
Longitude:	-73.7709756
DEC Memo:	Not reported
Remarks:	PBS #3-00999 TANK #001 - NOTIFIER ON SITE FOUND A HOLE IN OIL TANK - NO SOIL CONTAMINATION FOUND AS OF TIME OF THE CALL

All Materials:

Site ID:	330854
Operable Unit ID:	1069116
Operable Unit:	01
Material ID:	315471
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil

EDGAR (Continued) **S103479696**

Oxygenate: Not reported

Y261 **RESIDENCE** **NY UST** **U004441438**
North **1 BARKER AVENUE** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10606**
0.175 mi.
923 ft. **Site 2 of 2 in cluster Y**

Relative: WESTCHESTER CO. UST:
Lower

Actual: Name:	RESIDENCE
187 ft. Address:	1 BARKER AVENUE
City,State,Zip:	WHITE PLAINS, NY 10606
Id/Status:	3-600999 / Unregulated
Operator Name:	White Plains Realty Assoc LP
Owner Name:	White Plains Realty Assoc LP
Owner Street:	100 Clearbrook
Owner Address2:	Not reported
Owner City:	Elmsford
Owner State:	NY
Owner Zipcode:	10523
GDS Number:	Not reported
Tank Number:	1
Status:	3. Closed - Removed
Capacity:	10000
Product Stored:	Not reported
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	12/01/1977
Date Perm Closure:	09/01/1998
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	2. Underground/on ground
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Overfill Prevention:	0. None
Piping Secondary Containment:	Not reported
Spill Prevention:	0. None
Dispenser:	2. Suction

Z262 **AHERN PAINTING CONTRACTORS WHITE PLAINS REHAB YARD** **RCRA NonGen / NLR** **1024892049**
WNW **HAMILTON AVE & BRONX ST** **NYR000236299**
1/8-1/4 **WHITE PLAINS, NY 10603**
0.175 mi.
925 ft. **Site 1 of 3 in cluster Z**

Relative: RCRA Listings:
Lower

Actual: Date Form Received by Agency:	20190503
194 ft. Handler Name:	Ahern Painting Contractors White Plains Rehab Yard
Handler Address:	Hamilton Ave & Bronx St
Handler City,State,Zip:	WHITE PLAINS, NY 10603
EPA ID:	NYR000236299

AHERN PAINTING CONTRACTORS WHITE PLAINS REHAB YARD (Continued) **1024892049**

Contact Name:	Not reported
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	Not reported
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R3
Mailing Address:	Not reported
Mailing City,State,Zip:	Not reported
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20190503
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No

AHERN PAINTING CONTRACTORS WHITE PLAINS REHAB YARD (Continued) **1024892049**

Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Hazardous Waste Summary:

Waste Code:	D001
Waste Description:	Ignitable Waste
Waste Code:	D035
Waste Description:	Methyl Ethyl Ketone
Waste Code:	F003
Waste Description:	The Following Spent Nonhalogenated Solvents: Xylene, Acetone, Ethyl Acetate, Ethyl Benzene, Ethyl Ether, Methyl Isobutyl Ketone, N-Butyl Alcohol, Cyclohexanone, And Methanol; All Spent Solvent Mixtures/Blends Containing, Before Use, Only The Above Spent Nonhalogenated Solvents; And All Spent Solvent Mixtures/Blends Containing, Before Use, One Or More Of The Above Nonhalogenated Solvents, And A Total Of Ten Percent Or More (By Volume) Of One Or More Of Those Solvents Listed In F001, F002, F004, And F005; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent Mixtures.
Waste Code:	F005
Waste Description:	The Following Spent Nonhalogenated Solvents: Toluene, Methyl Ethyl Ketone, Carbon Disulfide, Isobutanol, Pyridine, Benzene, 2-Ethoxyethanol, And 2-Nitropropane; All Spent Solvent Mixtures/Blends Containing, Before Use, A Total Of Ten Percent Or More (By Volume) Of One Or More Of The Above Nonhalogenated Solvents Or Those Solvents Listed In F001, F002, Or F004; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent Mixtures.

Handler - Owner Operator:

Owner/Operator Indicator:	Owner
Owner/Operator Name: METRO NORTH COMMUTER	RAILROAD
Legal Status:	Private
Date Became Current:	19830101
Date Ended Current:	Not reported
Owner/Operator Address:	420 LEXINGTON AVE
Owner/Operator City,State,Zip:	NEW YORK, NY 10170
Owner/Operator Telephone:	212-340-3233
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	212-340-4035
Owner/Operator Email:	BELL@MNR.ORG
Owner/Operator Indicator:	Operator
Owner/Operator Name: AHERN PAINTING CONTRACTORS	
Legal Status:	Private
Date Became Current:	20180413
Date Ended Current:	Not reported
Owner/Operator Address:	69-24 49TH AVE
Owner/Operator City,State,Zip:	WOODSIDE, NY 11377
Owner/Operator Telephone:	718-639-5880

AHERN PAINTING CONTRACTORS WHITE PLAINS REHAB YARD (Continued) **1024892049**

Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: LIAM@AHERNCONTRACTORS.COM

Historic Generators:
Receive Date: 20190503
Handler Name: AHERN PAINTING CONTRACTORS WHITE PLAINS REHAB YARD
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: No
Electronic Manifest Broker: No

Receive Date: 20180530
Handler Name: AHERN PAINTING CONTRACTORS WHITE PLAINS REHAB YARD
Federal Waste Generator Description: Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: No
Electronic Manifest Broker: No

List of NAICS Codes and Descriptions:
NAICS Code: 238320
NAICS Description: Painting And Wall Covering Contractors

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

Z263 **AHERN PAINTING CONTRACTORS WHITE PLAINS REHAB YARD** **NY MANIFEST** **S122483160**
WNW **HAMILTON AVE & BRONX ST** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10603**
0.175 mi.
925 ft. **Site 2 of 3 in cluster Z**

Relative: NY MANIFEST:
Lower
EPA ID: NYR000236299
Actual: Country: USA
194 ft. Name: Ahern Painting Contractors White Plains Rehab Yard
Address: HAMILTON AVE & BRONX ST
Address 2: Not reported
City,State,Zip: WHITE PLAINS, NY 10603
Zip 4: Not reported

AHERN PAINTING CONTRACTORS WHITE PLAINS REHAB YARD (Continued) **S122483160**

Location Address 1:	HAMILTON AVE & BRONX ST
Location Address 2:	Not reported
Location City,State,Zip:	WHITE PLAINS, NY 10603
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Ahern Painting Contractors White Plains Rehab Yard
Mailing Contact:	Ahern Painting Contractors
Mailing Address 1:	PO BOX 1070
Mailing Address 2:	Not reported
Mailing City,State,Zip:	WOODSIDE, NY 11377
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	7186395880

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NJR986628162
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	06/04/2018
Trans1 Recv Date:	06/04/2018
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	06/04/2018
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000236299
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD991291105
TSDF ID 2:	Not reported
Manifest Tracking Number:	011536672FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H061
Waste Code a:	Methyl Ethyl Ketone
Waste Code b:	The Following Spent Nonhalogenated Solvents: Xylene, Acetone, Ethyl Acetate, Ethyl Benzene, Ethyl Ether, Methyl Isobutyl Ketone, N-Butyl Alcohol, Cyclohexanone, And Methanol; All Spent Solvent Mixtures/Blends Containing, Before Use, Only The Above Spent Nonhalogenated Solvents; And All Spent Solvent Mixtures/Blends Containing, Before Use, One Or More Of The Above Nonhalogenated Solvents, And A Total Of Ten Percent Or More (By Volume) Of One Or More Of Those Solvents Listed In F001, F002, F004, And F005; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent

AHERN PAINTING CONTRACTORS WHITE PLAINS REHAB YARD (Continued) **S122483160**

	Mixtures.
Waste Code c:	The Following Spent Nonhalogenated Solvents: Toluene, Methyl Ethyl Ketone, Carbon Disulfide, Isobutanol, Pyridine, Benzene, 2-Ethoxyethanol, And 2-Nitropropane; All Spent Solvent Mixtures/Blends Containing, Before Use, A Total Of Ten Percent Or More (By Volume) Of One Or More Of The Above Nonhalogenated Solvents Or Those Solvents Listed In F001, F002, Or F004; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent Mixtures.
Waste Code e:	Ignitable Waste
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	150
Units:	Gallons (liquids only)
Number of Containers:	3
Container Type:	Metal drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	1

Z264 **CON EDISON MANHOLE** **RCRA NonGen / NLR** **1014399077**
WNW **HAMILTON AVE & BRONX ST** **NJ MANIFEST** **NYP004214540**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.175 mi.
926 ft. **Site 3 of 3 in cluster Z**

Relative: **Lower**

Actual: **194 ft.**

RCRA Listings:

Date Form Received by Agency:	20100930
Handler Name:	Con Edison Manhole
Handler Address:	Hamilton Ave & Bronx St
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYP004214540
Contact Name:	GINO FRABASILE
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	914-925-6219
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	4 IRVING PL, RM 828
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported

CON EDISON MANHOLE (Continued) **1014399077**

Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20150414
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20100830
Handler Name: CON EDISON	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

CON EDISON MANHOLE (Continued) **1014399077**

Receive Date:	20100930
Handler Name: CON EDISON MANHOLE	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

List of NAICS Codes and Descriptions:

NAICS Codes:	No NAICS Codes Found

Facility Has Received Notices of Violations:

Violations:	No Violations Found

Evaluation Action Summary:

Evaluations:	No Evaluations Found

NJ MANIFEST:

EPA ID:	NYP004214540
Name:	CON EDISON MANHOLE
Address:	HAMILTON AVE & BRONX ST
City,State,Zip:	WHITE PLAINS, NY 10601
County:	Not reported
Mailing Address:	4 IRVING PL, RM 828
Mailing City,State,Zip:	NEW YORK, NY 10003
Telephone:	Not reported
Emergency Telephone:	Not reported
Contact:	GINO FRABASILE
Comments:	Not reported
SIC Code:	Not reported
County:	NY119
Municipal:	Not reported
Previous EPAID:	Not reported
Generator Flag:	Not reported
Transporter Flag:	Not reported
TSDF Flag:	Not reported
Name Change:	Not reported
Date Change:	Not reported

Manifest Data:

EPA ID:	NYP004214540
Manifest Number:	001086093GBF
Date Shipped:	08/30/2010
TSDF EPA ID:	NJD002200046
Transporter EPA ID:	NYD006982359
Transporter 2 EPA ID:	Not reported
Transporter 3 EPA ID:	Not reported
Transporter 4 EPA ID:	Not reported
Transporter 5 EPA ID:	Not reported
Transporter 6 EPA ID:	Not reported

CON EDISON MANHOLE (Continued) **1014399077**

Transporter 7 EPA ID:	Not reported
Transporter 8 EPA ID:	Not reported
Transporter 9 EPA ID:	Not reported
Transporter 10 EPA ID:	Not reported
Date Trans1 Transported Waste:	08/30/2010
Date Trans2 Transported Waste:	Not reported
Date Trans3 Transported Waste:	Not reported
Date Trans4 Transported Waste:	Not reported
Date Trans5 Transported Waste:	Not reported
Date Trans6 Transported Waste:	Not reported
Date Trans7 Transported Waste:	Not reported
Date Trans8 Transported Waste:	Not reported
Date Trans9 Transported Waste:	Not reported
Date Trans10 Transported Waste:	Not reported
Date TSDF Received Waste:	09/01/2010
TSDF EPA Facility Name:	Not reported
QTY Units:	Not reported
Transporter SEQ ID:	Not reported
Transporter-1 Date:	Not reported
Waste SEQ ID:	Not reported
Waste Type Code 2:	Not reported
Waste Type Code 3:	Not reported
Waste Type Code 4:	Not reported
Waste Type Code 5:	Not reported
Waste Type Code 6:	Not reported
Date Accepted:	Not reported
Manifest Discrepancy Type:	Not reported
Data Entry Number:	Not reported
Was Load Rejected:	N
Reason Load Was Rejected:	Not reported

Waste:

Manifest Year:	Not reported
Waste Code:	D008
Hand Code:	H111
Quantity:	100
Unit:	P

W265 **PEPE CADILLAC** **NY UST** **U004195985**
NNW **15 WATER STREET** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.176 mi.
929 ft. **Site 12 of 13 in cluster W**

Relative: **Lower**
Actual: **185 ft.**

WESTCHESTER CO. UST:

Name:	PEPE CADILLAC
Address:	15 WATER STREET
City,State,Zip:	WHITE PLAINS, NY 10601
Id/Status:	3-801848 / Active
Operator Name:	Ronald Bald
Owner Name:	15 WATER LLC
Owner Street:	50 Bank Street
Owner Address2:	Not reported
Owner City:	White Plains
Owner State:	NY
Owner Zipcode:	10606

PEPE CADILLAC (Continued) **U004195985**

GDS Number:	Not reported
Tank Number:	1A
Status:	1. In-Service
Capacity:	3000
Product Stored:	0009. Gasoline
Product Stored Percent:	10
Tank Leak Detection:	1. Electronic Interstitial Monitoring,5. In-Tank System (auto tank gauge)
Date Installation:	10/01/2012
Date Perm Closure:	01/01/1900
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	6. Fiberglass reinforced plastic (FRP)
Tank Internal Protection:	3. Fiberglass liner (FRP)
Tank External Protection:	4. Fiberglass
Tank Secondary Containment:	4. Double-Walled (underground only)
Piping Location:	2. Underground/on Ground
Piping Type:	6. Fiberglass Reinforced Plastic (FRP)
Piping External Protection:	4. Fiberglass
Overfill Prevention:	2. High Level Alarm,3. Automatic Shut-off
Piping Secondary Containment:	4. Double-Walled (underground only)
Spill Prevention:	1. Catch Basin
Dispenser:	1. Submersible
Tank Number:	1B
Status:	1. In-Service
Capacity:	3000
Product Stored:	0009. Gasoline
Product Stored Percent:	10
Tank Leak Detection:	1. Electronic Interstitial Monitoring,5. In-Tank System (auto tank gauge)
Date Installation:	10/01/2012
Date Perm Closure:	01/01/1900
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	6. Fiberglass reinforced plastic (FRP)
Tank Internal Protection:	3. Fiberglass liner (FRP)
Tank External Protection:	4. Fiberglass
Tank Secondary Containment:	4. Double-Walled (underground only)
Piping Location:	2. Underground/on Ground
Piping Type:	6. Fiberglass Reinforced Plastic (FRP)
Piping External Protection:	4. Fiberglass
Overfill Prevention:	2. High Level Alarm,3. Automatic Shut-off
Piping Secondary Containment:	4. Double-Walled (underground only)
Spill Prevention:	1. Catch Basin
Dispenser:	1. Submersible

W266 **PEPE CADILLAC** **NY AST** **A100379823**
NNW **15 WATER STREET** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.176 mi.
929 ft. **Site 13 of 13 in cluster W**

Relative: WESTCHESTER CO. AST:
Lower

Name:	PEPE CADILLAC
Address:	15 WATER STREET
City,State,Zip:	WHITE PLAINS, NY 10601
PBS Number:	3-801848
Site Status:	Active
GDS Number:	Not reported

Actual:
185 ft.

PEPE CADILLAC (Continued) **A100379823**

Operator Name:	Ronald Bald
Owner Name:	15 WATER LLC
Owner Street:	50 Bank Street
Owner Address2:	Not reported
Owner City/State/Zip:	White Plains, NY 10606
Tank Number:	2
Status:	1. In-Service
Date Installation:	01/01/2013
Capacity:	500
Product Stored:	0015. Motor Oil
Product Stored Percent:	Not reported
Date Perm Closure:	01/01/1900
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Leak Detection:	2. Manual Interstitial Monitoring,5. In-Tank System (auto tank gauge)
Tank Secondary Containment:	9. Modified double-walled (aboveground only)
Piping Location:	1. Aboveground
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	0. None
Piping Leak Detection:	0. None
Piping Secondary Containment:	0. None
Overfill Prevention:	2. High Level Alarm,4. Product Level Gauge (Aboveground Only)
Spill Prevention:	1. Catch Basin
Dispenser:	2. Suction
Tank Number:	3A
Status:	1. In-Service
Date Installation:	01/01/2013
Capacity:	500
Product Stored:	0022. Waste/Used Oil
Product Stored Percent:	Not reported
Date Perm Closure:	01/01/1900
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Leak Detection:	2. Manual Interstitial Monitoring,5. In-Tank System (auto tank gauge)
Tank Secondary Containment:	9. Modified double-walled (aboveground only)
Piping Location:	1. Aboveground
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	0. None
Piping Leak Detection:	9. Exempt suction piping
Piping Secondary Containment:	0. None
Overfill Prevention:	2. High Level Alarm,4. Product Level Gauge (Aboveground Only)
Spill Prevention:	1. Catch Basin
Dispenser:	0. None
Tank Number:	3B
Status:	1. In-Service
Date Installation:	01/01/2013
Capacity:	200
Product Stored:	0021. Transmission Fluid

PEPE CADILLAC (Continued) **A100379823**

Product Stored Percent:	Not reported
Date Perm Closure:	01/01/1900
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Leak Detection:	2. Manual Interstitial Monitoring,5. In-Tank System (auto tank gauge)
Tank Secondary Containment:	9. Modified double-walled (aboveground only)
Piping Location:	1. Aboveground
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	0. None
Piping Leak Detection:	0. None
Piping Secondary Containment:	0. None
Overfill Prevention:	2. High Level Alarm,4. Product Level Gauge (Aboveground Only)
Spill Prevention:	1. Catch Basin
Dispenser:	2. Suction

AA267 **CHARLES L. BRIEANT U.S. COURTHOUSE** **NY UST** **U004439713**
South **300 QUARROPAS STREET** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.177 mi.
936 ft. **Site 1 of 7 in cluster AA**

Relative: **Higher**
Actual: **197 ft.**

WESTCHESTER CO. UST:

Name:	CHARLES L. BRIEANT U.S. COURTHOUSE
Address:	300 QUARROPAS STREET
City,State,Zip:	WHITE PLAINS, NY 10601
Id/Status:	3-801467 / Active
Operator Name:	Joseph Wright
Owner Name:	General Services Administration GSA
Owner Street:	26 Federal Plaza
Owner Address2:	Room 1611
Owner City:	White Plains
Owner State:	NY
Owner Zipcode:	10601
GDS Number:	Not reported
Tank Number:	dot1
Status:	1. In-Service
Capacity:	2500
Product Stored:	0008. Diesel
Product Stored Percent:	Not reported
Tank Leak Detection:	1. Electronic Interstitial Monitoring
Date Installation:	01/01/1995
Date Perm Closure:	01/01/1900
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	6. Fiberglass reinforced plastic (FRP)
Tank Internal Protection:	0. None
Tank External Protection:	4. Fiberglass,XERES
Tank Secondary Containment:	2. Vault (w/ access)
Piping Location:	2. Underground/on Ground
Piping Type:	6. Fiberglass Reinforced Plastic (FRP)
Piping External Protection:	4. Fiberglass
Overfill Prevention:	2. High Level Alarm
Piping Secondary Containment:	4. Double-Walled (underground only)
Spill Prevention:	1. Catch Basin
Dispenser:	2. Suction

CHARLES L. BRIEANT U.S. COURTHOUSE (Continued) **U004439713**

Tank Number:	fot1
Status:	1. In-Service
Capacity:	15000
Product Stored:	0259. #5 Fuel Oil
Product Stored Percent:	Not reported
Tank Leak Detection:	1. Electronic Interstitial Monitoring
Date Installation:	01/01/1995
Date Perm Closure:	01/01/1900
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	4. Fiberglass coated steel
Tank Internal Protection:	1. Epoxy liner
Tank External Protection:	2. Original sacrificial anode
Tank Secondary Containment:	1. Diking (aboveground only)
Piping Location:	2. Underground/on Ground
Piping Type:	2. Galvanized Steel
Piping External Protection:	4. Fiberglass
Overfill Prevention:	2. High Level Alarm
Piping Secondary Containment:	4. Double-Walled (underground only)
Spill Prevention:	ohter
Dispenser:	2. Suction

AA268 **CHARLES L. BRIEANT U.S. COURTHOUSE** **NY AST** **A100532690**
South **300 QUARROPAS STREET** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.177 mi.
936 ft. **Site 2 of 7 in cluster AA**

Relative: **Higher**

Actual: **197 ft.**

WESTCHESTER CO. AST:

Name:	CHARLES L. BRIEANT U.S. COURTHOUSE
Address:	300 QUARROPAS STREET
City,State,Zip:	WHITE PLAINS, NY 10601
PBS Number:	3-801467
Site Status:	Active
GDS Number:	Not reported
Operator Name:	Joseph Wright
Owner Name:	General Services Administration GSA
Owner Street:	26 Federal Plaza
Owner Address2:	Room 1611
Owner City/State/Zip:	White Plains, NY 10601
Tank Number:	dodt1
Status:	1. In-Service
Date Installation:	01/01/1995
Capacity:	100
Product Stored:	0008. Diesel
Product Stored Percent:	Not reported
Date Perm Closure:	01/01/1900
Tank Location:	1. Aboveground (contact w/ soil)
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Leak Detection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	1. Aboveground
Piping Type:	2. Galvanized Steel
Piping External Protection:	1. Painted/Asphalt Coating
Piping Leak Detection:	2. Manual Interstitial Monitoring
Piping Secondary Containment:	0. None

CHARLES L. BRIEANT U.S. COURTHOUSE (Continued) **A100532690**

Overfill Prevention: 2. High Level Alarm
Spill Prevention: ohter
Dispenser: 2. Suction

AA269 **U.S. PROBATION OFFICE, SDNY** **E MANIFEST** **1027875841**
South **300 QUARROPAS STREET** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.177 mi.
936 ft. **Site 3 of 7 in cluster AA**

Relative:
Higher

Actual:
197 ft.

E MANIFEST:

Manifest Tracking Number:	012208014FLE
Last Updated Date:	20181212
Shipped Date:	20181010
Received Date:	20181020
Manifest Status:	Signed
Submission Type:	DataImage5Copy
Origin Type:	Service
Generator EPA ID:	CESQG
Generator Name:	U.S. Probation Office, Sdny
Generator Location Street Number:	Not reported
Generator Location Street 1:	300 QUARROPAS STREET
Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601
Generator Mail Street Number:	Not reported
Generator Mail Street 1:	500 PEARL ST FL 8
Generator Mail Street 2:	Not reported
Generator Mail City:	NEW YORK
Generator Mail Zip:	10007-1316
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	PAD085690592
Designated Facility Name:	Republic Env Sys Inc
Designated Facility Mail Street Number:	Not reported
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	2869 Sandstone Drive
Designated Facility Mail City:	Hatfield
Designated Facility Mail Zip:	19440
Designated Facility Mail State:	PA
Designated Facility Location Street Number:	Not reported
Designated Facility Location Street 1:	2869 Sandstone Drive
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	Hatfield
Designated Facility Location Zip:	19440
Designated Facility Location State:	PA
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Transporter:

Manifest Tracking Number:	012208014FLE
Transporter Line Number:	1
Transporter EPA ID:	PAD982661381
Transporter Name:	Republic Environmental Systems Transportation Group Llc

U.S. PROBATION OFFICE, SDNY (Continued) **1027875841**

Waste Line:

Manifest Tracking Number:	012208014FLE
Waste Line Number:	1
U.S. DOT Hazardous Indicator:	Y
U.S. DOT ID Number:	UN1950
U.S. DOT Description:	Un1950 Aerosols (Non Flammable) 2.2 8
Non-Hazardous Waste Description:	Not reported
Number of Containers:	1
Container Type Code:	DF
Container Type Description:	Fiberboard or plastic drums, barrels, kegs
Waste Quantity:	65
Quantity Unit of Measure Code:	P
Quantity Unit of Measure Description:	Pounds
Waste Quantity, in Tons:	0.0325
Acute Waste Quantity, in Tons:	0
Non-Acute Waste Quantity, in Tons:	0.0325
Waste Quantity, in Kilograms:	29.478476
Acute Waste Quantity, in Kilograms:	0
Non-Acute Waste Quantity, in Kilorgrams:	29.478476
Management Method Code:	H141
Management Method Description:	STORAGE, BULKING AND/OR TRANSFER OFF SITE
Waste Residue Indicator:	N
Quantity Discrepancy Indicator:	N
Waste Type Discrepancy Indicator:	N
Waste Density:	Not reported
Waste Density Unit of Measure Code:	Not reported
Waste Density Unit of Measure Description:	Not reported
Form Code:	Not reported
Form Code Description:	Not reported
Source Code:	Not reported
Source Code Description:	Not reported
Waste Minimization Code:	Not reported
Waste Minimization Code Description:	Not reported
Consent Number:	Not reported
EPA Waste Indicator:	N

R270 **YOUNG COAL & LUMBER SITE** **RCRA NonGen / NLR** **1018159122**
SW **55 BANK ST - TXI ID#125.8-1-7.11** **FINDS** **NYR000222273**
1/8-1/4 **WHITE PLAINS, NY 10601** **ECHO**
0.178 mi.
940 ft. **Site 9 of 11 in cluster R**

Relative: **Higher**
Actual: **204 ft.**

RCRA Listings:

Date Form Received by Agency:	20170418
Handler Name:	Young Coal & Lumber Site
Handler Address:	Bank St - Txi Id#125.8-1-7.11
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYR000222273
Contact Name:	ILKAY CAM-SPANOS
Contact Address:	PENN PLZ SUITE 1801
Contact City,State,Zip:	NEW YORK, NY 10119
Contact Telephone:	212-479-5410
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	SENIOR PROJECT MANAGER
EPA Region:	02
Land Type:	Private

YOUNG COAL & LUMBER SITE (Continued) **1018159122**

Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R3
Mailing Address:	PENN PLZ SUITE 1801
Mailing City,State,Zip:	NEW YORK, NY 10119
Owner Name:	Wp North Tower Llc
Owner Type:	Private
Operator Name:	Wp North Tower Llc
Operator Type:	Private
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20170518
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Biennial: List of Years

Year:	2015

YOUNG COAL & LUMBER SITE (Continued) **1018159122**

Click Here for Biennial Reporting System Data:

Hazardous Waste Summary:
Waste Code: D008
Waste Description: Lead

Handler - Owner Operator:

Owner/Operator Indicator:	Owner
Owner/Operator Name: WP NORTH TOWER LLC	
Legal Status:	Private
Date Became Current:	20150724
Date Ended Current:	Not reported
Owner/Operator Address:	1 PENN PLZ SUITE 1801
Owner/Operator City,State,Zip:	NEW YORK, NY 10119
Owner/Operator Telephone:	212-760-0060
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported
Owner/Operator Email:	Not reported

Owner/Operator Indicator:	Owner
Owner/Operator Name: WP NORTH TOWER LLC	
Legal Status:	Private
Date Became Current:	20150724
Date Ended Current:	Not reported
Owner/Operator Address:	1 PENN PLZ SUITE 1801
Owner/Operator City,State,Zip:	NEW YORK, NY 10119
Owner/Operator Telephone:	212-760-0060
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported
Owner/Operator Email:	Not reported

Owner/Operator Indicator:	Operator
Owner/Operator Name: WP NORTH TOWER LLC	
Legal Status:	Private
Date Became Current:	20150724
Date Ended Current:	Not reported
Owner/Operator Address:	1 PENN PLAZA
Owner/Operator City,State,Zip:	NEW YORK, NY 10119
Owner/Operator Telephone:	Not reported
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported
Owner/Operator Email:	Not reported

Owner/Operator Indicator:	Owner
Owner/Operator Name: WP NORTH TOWER LLC	
Legal Status:	Private
Date Became Current:	20150724
Date Ended Current:	Not reported
Owner/Operator Address:	1 PENN PLZ SUITE 1801
Owner/Operator City,State,Zip:	NEW YORK, NY 10119
Owner/Operator Telephone:	212-760-0060
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported
Owner/Operator Email:	Not reported

YOUNG COAL & LUMBER SITE (Continued) **1018159122**

Owner/Operator Indicator:	Owner
Owner/Operator Name: WP NORTH TOWER LLC	
Legal Status:	Private
Date Became Current:	20150723
Date Ended Current:	Not reported
Owner/Operator Address:	1 PENN PLZ SUITE 1801
Owner/Operator City,State,Zip:	NEW YORK, NY 10119
Owner/Operator Telephone:	212-760-0060
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported
Owner/Operator Email:	Not reported

Owner/Operator Indicator:	Operator
Owner/Operator Name: WP NORTH TOWER LLC	
Legal Status:	Private
Date Became Current:	20150723
Date Ended Current:	Not reported
Owner/Operator Address:	Not reported
Owner/Operator City,State,Zip:	Not reported
Owner/Operator Telephone:	Not reported
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported
Owner/Operator Email:	Not reported

Owner/Operator Indicator:	Operator
Owner/Operator Name: WP NORTH TOWER LLC	
Legal Status:	Private
Date Became Current:	20150724
Date Ended Current:	Not reported
Owner/Operator Address:	Not reported
Owner/Operator City,State,Zip:	Not reported
Owner/Operator Telephone:	Not reported
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported
Owner/Operator Email:	Not reported

Owner/Operator Indicator:	Operator
Owner/Operator Name: WP NORTH TOWER LLC	
Legal Status:	Private
Date Became Current:	20150724
Date Ended Current:	Not reported
Owner/Operator Address:	Not reported
Owner/Operator City,State,Zip:	Not reported
Owner/Operator Telephone:	Not reported
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported
Owner/Operator Email:	Not reported

Owner/Operator Indicator:	Owner
Owner/Operator Name: WP NORTH TOWER LLC	
Legal Status:	Private
Date Became Current:	20150724
Date Ended Current:	Not reported
Owner/Operator Address:	1 PENN PLAZA
Owner/Operator City,State,Zip:	NEW YORK, NY 10119
Owner/Operator Telephone:	212-760-0060
Owner/Operator Telephone Ext:	Not reported

YOUNG COAL & LUMBER SITE (Continued) **1018159122**

Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Operator
Owner/Operator Name: WP NORTH TOWER LLC
Legal Status: Private
Date Became Current: 20150724
Date Ended Current: Not reported
Owner/Operator Address: Not reported
Owner/Operator City,State,Zip: Not reported
Owner/Operator Telephone: Not reported
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Historic Generators:
Receive Date: 20160219
Handler Name: YOUNG COAL & LUMBER SITE
Federal Waste Generator Description: Large Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20160219
Handler Name: YOUNG COAL & LUMBER SITE
Federal Waste Generator Description: Large Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20170110
Handler Name: YOUNG COAL & LUMBER SITE
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20170418
Handler Name: YOUNG COAL & LUMBER SITE

YOUNG COAL & LUMBER SITE (Continued) **1018159122**

Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20150923
Handler Name: YOUNG COAL & LUMBER SITE
Federal Waste Generator Description: Large Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Code: 23891
NAICS Description: Site Preparation Contractors

NAICS Code: 238910
NAICS Description: Site Preparation Contractors

NAICS Code: Not reported
NAICS Description: Not reported

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

FINDS:
Registry ID: 110066950268

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:
All generators and treatment, storage, and disposal (TSD) facilities who handle hazardous waste are required to report to the EPA Administrator at least once every two years. The data collected is used to create the National Biennial Resource Conservation and Recovery Act (RCRA) Hazardous Waste Report. This data is processed within the RCRA Information (RCRAInfo) database
The Resource Conservation and Recovery Act Information System (RCRAInfo) is EPA's comprehensive information system in support of the Resource Conservation and Recovery Act (RCRA) of 1976 and the

YOUNG COAL & LUMBER SITE (Continued) **1018159122**

Hazardous and Solid Waste Amendments (HSWA) of 1984. It tracks many types of information about generators, transporters, treaters, storers, and disposers of hazardous waste.

Click this hyperlink while viewing on your computer to access additional FINDS: detail in the EDR Site Report.

ECHO:
Envid: 1018159122
Registry ID: 110066950268

DFR URL:
Name: YOUNG COAL & LUMBER SITE
Address: 55 BANK ST - TXI ID#125.8-1-7.11
City,State,Zip: WHITE PLAINS, NY 10601

R271 **HP NORTH TOWER LLC** **PA MANIFEST** **S118890132**
SW **55 BANK STREET** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.178 mi.
940 ft. **Site 10 of 11 in cluster R**

Relative:
Higher

Actual:
204 ft.

PA MANIFEST:
Name: HP NORTH TOWER LLC
Address: 55 BANK STREET
City,State,Zip: WHITE PLAINS, NY 10601
Year: 2015
Manifest Number: 009464468FLE
Manifest Type: T
Generator EPA ID: NYR000222273
Generator Date: 12/22/2015
Mailing Address: Not reported
Contact Name: Not reported
Contact Phone: Not reported
TSD EPA ID: Not reported
TSD Date: Not reported
TSD Facility Name: Republic Environmental Systems (Pennsylvania) LLC
TSD Facility Address: 2869 Sandstone Dr
TSD Facility City: Hatfield
TSD Facility State: PA
Facility Telephone: Not reported
Page Number: 1
Line Number: 1
Waste Number: D008
Container Number: 1
Container Type: DT
Waste Quantity: 40000
Unit: P
Handling Code: Not reported
TSP EPA ID: PAD085690592
Date TSP Sig: Not reported

Year: 2015
Manifest Number: 009464469FLE
Manifest Type: T
Generator EPA ID: NYR000222273
Generator Date: 12/22/2015
Mailing Address: Not reported

HP NORTH TOWER LLC (Continued) **S118890132**

Contact Name:	Not reported
Contact Phone:	Not reported
TSD EPA ID:	Not reported
TSD Date:	Not reported
TSD Facility Name:	Republic Environmental Systems (Pennsylvania) LLC
TSD Facility Address:	2869 Sandstone Dr
TSD Facility City:	Hatfield
TSD Facility State:	PA
Facility Telephone:	Not reported
Page Number:	1
Line Number:	1
Waste Number:	D008
Container Number:	1
Container Type:	DT
Waste Quantity:	22
Unit:	T
Handling Code:	Not reported
TSP EPA ID:	PAD085690592
Date TSP Sig:	Not reported
Year:	2015
Manifest Number:	009464470FLE
Manifest Type:	T
Generator EPA ID:	NYR000222273
Generator Date:	12/22/2015
Mailing Address:	Not reported
Contact Name:	Not reported
Contact Phone:	Not reported
TSD EPA ID:	Not reported
TSD Date:	Not reported
TSD Facility Name:	Republic Environmental Systems (Pennsylvania) LLC
TSD Facility Address:	2869 Sandstone Dr
TSD Facility City:	Hatfield
TSD Facility State:	PA
Facility Telephone:	Not reported
Page Number:	1
Line Number:	1
Waste Number:	D008
Container Number:	1
Container Type:	DT
Waste Quantity:	40000
Unit:	P
Handling Code:	Not reported
TSP EPA ID:	PAD085690592
Date TSP Sig:	Not reported
Year:	2015
Manifest Number:	009464471FLE
Manifest Type:	T
Generator EPA ID:	NYR000222273
Generator Date:	12/22/2015
Mailing Address:	Not reported
Contact Name:	Not reported
Contact Phone:	Not reported
TSD EPA ID:	Not reported
TSD Date:	Not reported
TSD Facility Name:	Republic Environmental Systems (Pennsylvania) LLC

HP NORTH TOWER LLC (Continued) **S118890132**

TSD Facility Address:	2869 Sandstone Dr
TSD Facility City:	Hatfield
TSD Facility State:	PA
Facility Telephone:	Not reported
Page Number:	1
Line Number:	1
Waste Number:	D008
Container Number:	1
Container Type:	DT
Waste Quantity:	40000
Unit:	P
Handling Code:	Not reported
TSP EPA ID:	PAD085690592
Date TSP Sig:	Not reported
Year:	2015
Manifest Number:	009464563FLE
Manifest Type:	T
Generator EPA ID:	NYR000222273
Generator Date:	12/23/2015
Mailing Address:	Not reported
Contact Name:	Not reported
Contact Phone:	Not reported
TSD EPA ID:	Not reported
TSD Date:	Not reported
TSD Facility Name:	Republic Environmental Systems (Pennsylvania) LLC
TSD Facility Address:	2869 Sandstone Dr
TSD Facility City:	Hatfield
TSD Facility State:	PA
Facility Telephone:	Not reported
Page Number:	1
Line Number:	1
Waste Number:	7
Container Number:	1
Container Type:	DT
Waste Quantity:	40000
Unit:	P
Handling Code:	Not reported
TSP EPA ID:	PAD085690592
Date TSP Sig:	Not reported
Year:	2015
Manifest Number:	009464563FLE
Manifest Type:	T
Generator EPA ID:	NYR000222273
Generator Date:	12/23/2015
Mailing Address:	Not reported
Contact Name:	Not reported
Contact Phone:	Not reported
TSD EPA ID:	Not reported
TSD Date:	Not reported
TSD Facility Name:	Republic Environmental Systems (Pennsylvania) LLC
TSD Facility Address:	2869 Sandstone Dr
TSD Facility City:	Hatfield
TSD Facility State:	PA
Facility Telephone:	Not reported
Page Number:	1

HP NORTH TOWER LLC (Continued) **S118890132**

Line Number:	1
Waste Number:	D008
Container Number:	1
Container Type:	DT
Waste Quantity:	40000
Unit:	P
Handling Code:	Not reported
TSP EPA ID:	PAD085690592
Date TSP Sig:	Not reported
Year:	2015
Manifest Number:	009464564FLE
Manifest Type:	T
Generator EPA ID:	NYR000222273
Generator Date:	12/23/2015
Mailing Address:	Not reported
Contact Name:	Not reported
Contact Phone:	Not reported
TSD EPA ID:	Not reported
TSD Date:	Not reported
TSD Facility Name:	Republic Environmental Systems (Pennsylvania) LLC
TSD Facility Address:	2869 Sandstone Dr
TSD Facility City:	Hatfield
TSD Facility State:	PA
Facility Telephone:	Not reported
Page Number:	1
Line Number:	1
Waste Number:	D008
Container Number:	1
Container Type:	DT
Waste Quantity:	22
Unit:	T
Handling Code:	Not reported
TSP EPA ID:	PAD085690592
Date TSP Sig:	Not reported
Year:	2015
Manifest Number:	009464565FLE
Manifest Type:	T
Generator EPA ID:	NYR000222273
Generator Date:	12/23/2015
Mailing Address:	Not reported
Contact Name:	Not reported
Contact Phone:	Not reported
TSD EPA ID:	Not reported
TSD Date:	Not reported
TSD Facility Name:	Republic Environmental Systems (Pennsylvania) LLC
TSD Facility Address:	2869 Sandstone Dr
TSD Facility City:	Hatfield
TSD Facility State:	PA
Facility Telephone:	Not reported
Page Number:	1
Line Number:	1
Waste Number:	D008
Container Number:	1
Container Type:	DT
Waste Quantity:	40000

HP NORTH TOWER LLC (Continued) **S118890132**

Unit: P
Handling Code: Not reported
TSP EPA ID: PAD085690592
Date TSP Sig: Not reported

R272 **YOUNG COAL & LUMBER SITE** **NY BROWNFIELDS** **S113492634**
SW **55 BANK STREET** **NY MANIFEST** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10606**
0.178 mi.
940 ft. **Site 11 of 11 in cluster R**

Relative: **Higher**
Actual: **204 ft.**

BROWNFIELDS:
Name: YOUNG COAL & LUMBER SITE
Address: 55 BANK STREET
City,State,Zip: WHITE PLAINS, NY 10601
Program: BCP
Site Code: 481411
Acres: 2.240
HW Code: C360131
SWIS: 6017
Town: White Plains (c)
Record Added Date: 05/01/2013
Record Updated Date: 07/17/2018
Update By: DACROSBY
Site Description: Location: The site is located at 55 Bank Street in White Plains, Westchester County. The site is located in the Central Business District of the City of White Plains on the west side of Bank Street, just south of the intersection of Main Street and Bank Street. To the west is the Metro-North railroad right of way. Bank Street is located along the eastern border, a car dealership is located adjacent to the southern border, and a parking lot for the Bank Street Commons Apartment building is located to the north. Site Features: The site is presently under construction as a commercial/residential building. The site was formerly a 2.24-acre parking lot for the nearby commuter railroad station. The site was used as a parking lot for over 40 years. Current Zoning/Use: The current zoning of the site is Core Business-4 (CB-4). Municipally-operated parking lots and multifamily dwellings, a restricted residential use, are permitted uses in CB-4 zones. Past Uses of the Site: The property was used as a coal and lumber yard starting in 1885. The lumber yard comprised of a mill, several small sheds, coal and lumber storage areas, and railroad spurs. By 1911, the property was being used for manufacturing sashes, blinds and trim, and for the storage of grain, fertilizer, and feed. During the late 1800s and early 1900s, portions of the eastern side were occupied by several residential homes. By 1953, the southeastern corner of the property was improved with a commercial building, while the remaining portions were public parking lots. The commercial building was razed by 1974, and the site has been operated as a parking lot since that time. Site Geology and Hydrogeology: The site is level ground and covered with asphalt. Surface water drains to a storm sewer system that runs to the Bronx River which is about 500 yards to the west. The shallow soil horizon consists of historic fill found at a depth from 1.5 -26 feet below grade. Below the fill, subsurface soils consist of predominantly sands with some silts and gravels. Bedrock was located at 80-120 feet below grade and is believed to by gneiss and schist. Overburden groundwater was encountered at a depth of 28 feet below grade and flows to the south. The Bronx River, which flows to the south, is located about 0.25 mile

YOUNG COAL & LUMBER SITE (Continued) **S113492634**

west of the site. However, the site is located above the current 100 year flood elevation. Site storm water is transported via storm drains to a storm water collection system and discharges to the Bronx River. The Bronx River Parkway is located adjacent to the Bronx River just west of the site.

Env Problem: Nature and Extent of Contamination: Remediation of the site to track 1 soil cleanup objectives was completed in November 2016. Soil: Remediation is complete. The entire site was excavated to a depth of approximately 26 feet. No surface soils remain. Based on the investigations conducted the primary contaminants of concern in subsurface soils were inorganics (metals) including mercury, copper lead and zinc. These metals were present above the unrestricted soil cleanup objectives. These compounds were present in the fill materials used to grade the site and surrounding areas, and contamination did not migrated from the site to adjacent parcels. These inorganics were not found in on-site groundwater above NYS Groundwater Standards in filtered samples. Aluminum, iron, and sodium were detected above standards in onsite groundwater but are considered to be naturally occurring. Groundwater: Chlorinated volatile organic compounds (CVOCs) were detected in on-site groundwater including tetracholoethylene (PCE) at a maximum level of 13 parts per billion (ppb), and trichloroethene (TCE) at a maximum level of 28 ppb. The groundwater quality standard for both of these compounds is 5 ppb. CVOCs were not detected in the subsurface soil samples collected from the site, the groundwater investigation suggests that the source originates from an off-groundwater source. The site remediation is complete. The site has a basement foundation that includes a vapor barrier and a subsurface parking garage which is ventilated. Because there is a vapor barrier and a ventilated subsurface parking garage a soil vapor intrusion investigation was not conducted.

Health Problem: People are not drinking the contaminated groundwater because the area is served by a public water supply that is not affected by this contamination. Volatile organic compounds in the groundwater may move into the soil vapor (air spaces within the soil), which in turn may move into overlying buildings and affect the indoor air quality. This process which is similar to the movement of radon gas from the subsurface in to the indoor air of buildings, is referred to as soil vapor intrusion. A vapor barrier has been installed beneath the building foundation to minimize the potential of vapors from entering the building. Additionally, a sub-grade parking garage ventilation system required by building codes will be installed prior to building occupancy to prevent vapors from accumulating in the structure.

Dump: False
Structure: False
Lagoon: False
Landfill: False
Pond: False
Disp Start: Not reported
Disp Term: Not reported
Lat/Long: Not reported
Dell: Not reported
Record Add: 2013-05-01 13:48:00
Record Upd: 2016-11-30 10:28:00
Updated By: GWHEITZM
Own Op: Document Repository
Sub Type: NNN

YOUNG COAL & LUMBER SITE (Continued) **S113492634**

Owner Name:	Brian Kenney, Director
Owner Company:	White Plains Central Library
Owner Address:	100 Martine Avenue
Owner Addr2:	Not reported
Owner City,St,Zip:	White Plains, NY 10601
Owner Country:	United States of America
Own Op:	4
Sub Type:	NNN
Owner Name:	Not reported
Owner Company:	City of White Plains
Owner Address:	255 Main Street
Owner Addr2:	Not reported
Owner City,St,Zip:	White Plains, NY 10601-2475
Owner Country:	United States of America
Own Op:	1
Sub Type:	06
Owner Name:	James M. Driscoll
Owner Company:	WP North Tower LLC
Owner Address:	One Penn Plaza, Suite 1801
Owner Addr2:	Not reported
Owner City,St,Zip:	New York, NY 10119
Owner Country:	United States of America
Own Op:	Document Repository
Sub Type:	P03
Owner Name:	Please call for appointment
Owner Company:	NYSDEC Region 3
Owner Address:	21 S. Putt Corners Road
Owner Addr2:	Not reported
Owner City,St,Zip:	New Paltz, NY 12561
Owner Country:	United States of America
Own Op:	6
Sub Type:	P03
Owner Name:	Mr. James Driscoll
Owner Company:	WP South Tower LLC
Owner Address:	One Penn Plaza
Owner Addr2:	Suite 1801
Owner City,St,Zip:	New York, NY 10119
Owner Country:	United States of America
Own Op:	1
Sub Type:	P03
Owner Name:	James Driscoll
Owner Company:	WP South Tower LLC
Owner Address:	One Penn Plaza
Owner Addr2:	Suite 1801
Owner City,St,Zip:	New York, NY 10119
Owner Country:	United States of America
Own Op:	6
Sub Type:	P03
Owner Name:	Mr. James Driscoll
Owner Company:	WP North Tower LLC
Owner Address:	One Penn Plaza
Owner Addr2:	Suite 1801
Owner City,St,Zip:	New York, NY 10119
Owner Country:	United States of America
Own Op:	6
Sub Type:	P03
Owner Name:	James Driscoll

YOUNG COAL & LUMBER SITE (Continued) **S113492634**

Owner Company:	LCOR 55 Bank Street LLC
Owner Address:	One Penn Plaza
Owner Addr2:	Suite 1801
Owner City,St,Zip:	New York, NY 10199
Owner Country:	United States of America
HW Code:	C360131
Waste Type:	tetrachloroethene (PCE)
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360131
Waste Type:	TRICHLOROETHENE (TCE)
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360131
Waste Type:	TETRACHLOROETHYLENE (PCE)
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360131
Waste Type:	LEAD
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360131
Waste Type:	ZINC
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360131
Waste Type:	BENZO(A)PYRENE
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360131
Waste Type:	MERCURY
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360131
Waste Type:	COPPER
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
Crossref ID:	C360131-12-13
Cross Ref Type Code:	23
Cross Ref Type:	Agreement/Consent Order Number
Record Added Date:	2016-10-24 13:35:00
Record Updated:	2016-10-24 13:35:00
Updated By:	DACROSBY
Crossref ID:	Test
Cross Ref Type Code:	25
Cross Ref Type:	County Recording Identifier
Record Added Date:	2015-08-03 15:48:00
Record Updated:	2015-08-03 15:48:00
Updated By:	GWHEITZM

NY MANIFEST:

EPA ID:	NYR000222273
Country:	USA
Name:	Young Coal & Lumber Site
Address:	55 BANK STREET
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10606

YOUNG COAL & LUMBER SITE (Continued) **S113492634**

Zip 4:	Not reported
Location Address 1:	55 BANK STREET
Location Address 2:	Not reported
Location City,State,Zip:	WHITE PLAINS, NY 10606
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Young Coal & Lumber Site
Mailing Contact:	Np North Toner Llc
Mailing Address 1:	ONE PENN PLAZA
Mailing Address 2:	Not reported
Mailing City,State,Zip:	NEW YORK, NY 10119
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	2127600060

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NJR000029967
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	12/22/2015
Trans1 Recv Date:	12/22/2015
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	12/22/2015
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000222273
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	PAD085690592
TSDF ID 2:	Not reported
Manifest Tracking Number:	009464468FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	Y
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported

YOUNG COAL & LUMBER SITE (Continued) **S113492634**

Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	48400
Units:	Pounds
Number of Containers:	1
Container Type:	Dump truck
Handling Method:	Treat
Specific Gravity:	1

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NJR000029967
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	12/22/2015
Trans1 Recv Date:	12/22/2015
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	12/22/2015
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000222273
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	PAD085690592
TSDF ID 2:	Not reported
Manifest Tracking Number:	009464469FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	Y
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	42380
Units:	Pounds
Number of Containers:	1
Container Type:	Dump truck
Handling Method:	Treat
Specific Gravity:	1

YOUNG COAL & LUMBER SITE (Continued) **S113492634**

Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: NJR000029967
Year: 2018
Trans2 State ID: Not reported
Generator Ship Date: 12/22/2015
Trans1 Recv Date: 12/22/2015
Trans2 Recv Date: Not reported
TSD Site Recv Date: 12/22/2015
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYR000222273
Trans1 EPA ID: Not reported
Trans2 EPA ID: Not reported
TSDF ID 1: PAD085690592
TSDF ID 2: Not reported
Manifest Tracking Number: 009464470FLE
Import Indicator: N
Export Indicator: N
Discr Quantity Indicator: Y
Discr Type Indicator: N
Discr Residue Indicator: N
Discr Partial Reject Indicator: N
Discr Full Reject Indicator: N
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: H110
Waste Code a: Lead
Waste Code b: Not reported
Waste Code c: Not reported
Waste Code e: Not reported
Waste Code f: Not reported
Waste Code g: Not reported
Waste Code 1: Not reported
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 46060
Units: Pounds
Number of Containers: 1
Container Type: Dump truck
Handling Method: Treat
Specific Gravity: 1

Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: NJR000029967
Year: 2018
Trans2 State ID: Not reported
Generator Ship Date: 12/22/2015
Trans1 Recv Date: 12/22/2015
Trans2 Recv Date: Not reported
TSD Site Recv Date: 12/22/2015
Part A Recv Date: Not reported

YOUNG COAL & LUMBER SITE (Continued) **S113492634**

Part B Recv Date:	Not reported
Generator EPA ID:	NYR000222273
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	PAD085690592
TSDF ID 2:	Not reported
Manifest Tracking Number:	009464471FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	Y
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	39820
Units:	Pounds
Number of Containers:	1
Container Type:	Dump truck
Handling Method:	Treat
Specific Gravity:	1

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NJR000029967
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	12/23/2015
Trans1 Recv Date:	12/23/2015
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	12/23/2015
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000222273
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	PAD085690592
TSDF ID 2:	Not reported
Manifest Tracking Number:	009464563FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	Y

YOUNG COAL & LUMBER SITE (Continued) **S113492634**

Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	47040
Units:	Pounds
Number of Containers:	1
Container Type:	Dump truck
Handling Method:	Treat
Specific Gravity:	1

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NJR000029967
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	12/23/2015
Trans1 Recv Date:	12/23/2015
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	12/23/2015
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000222273
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	PAD085690592
TSDF ID 2:	Not reported
Manifest Tracking Number:	009464564FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	Y
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported

YOUNG COAL & LUMBER SITE (Continued) **S113492634**

Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	44820
Units:	Pounds
Number of Containers:	1
Container Type:	Dump truck
Handling Method:	Treat
Specific Gravity:	1
Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NJR000029967
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	12/23/2015
Trans1 Recv Date:	12/23/2015
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	12/23/2015
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000222273
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	PAD085690592
TSDF ID 2:	Not reported
Manifest Tracking Number:	009464565FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	Y
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported

YOUNG COAL & LUMBER SITE (Continued) **S113492634**

Quantity:	47940
Units:	Pounds
Number of Containers:	1
Container Type:	Dump truck
Handling Method:	Treat
Specific Gravity:	1

S273 **COMMERCIAL BUSINESS** **NY LTANKS** **S107410444**
SE **158 GRAND STREET** **N/A**
1/8-1/4 **WHITE PLAINS, NY**
0.179 mi.
943 ft. **Site 6 of 11 in cluster S**

Relative: LTANKS:
Higher

Actual:
234 ft.

Name:	COMMERCIAL BUSINESS
Address:	158 GRAND STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0506649 / 2006-02-03
Facility ID:	0506649
Site ID:	351900
Spill Date:	2005-08-30
Spill Cause:	Tank Failure
Spill Source:	Commercial/Industrial
Spill Class:	B4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	TDGHIOSA
Referred To:	Not reported
Reported to Dept:	2005-08-30
CID:	444
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2005-08-30
Spill Record Last Update:	2006-02-03
Spiller Name:	MR FINGERMAN
Spiller Company:	COMMERCIAL BUSINESS
Spiller Address:	158 GRANDE STREET
Spiller County:	001
Spiller Contact:	MR FINGERMAN
Spiller Phone:	(914) 949-0308
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	299193
Latitude:	41.0282440
Longitude:	-73.7675710
DEC Memo:	Caller will inform Todd Ghiosay of the DEC. 9/7/05 Also reported as spill 04-13115. jod February 3, 2006: NES DISPOSED OF LUST AND 39.36 TONS OF CONTAMINATED SOIL. CLOSURE REPORT REVIEWED BY DEC. BASED UPON INFORMATION PROVIDED, NO FURTHER ACTION IS REQUIRED AT THIS TIME. jod
Remarks:	HOLES IN TANK: SEVERAL LARGE HOLES;

All Materials:

COMMERCIAL BUSINESS (Continued) **S107410444**

Site ID:	351900
Operable Unit ID:	1109401
Operable Unit:	01
Material ID:	2099431
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	G
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

Name:	FINGAR AND FINGAR LAW OFFICE
Address:	158 GRAND STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0413115 / 2005-09-07
Facility ID:	0413115
Site ID:	338963
Spill Date:	2005-03-16
Spill Cause:	Tank Failure
Spill Source:	Commercial/Industrial
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	JBODee
Referred To:	Not reported
Reported to Dept:	2005-03-16
CID:	408
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2005-03-16
Spill Record Last Update:	2006-02-03
Spiller Name:	DOROTHY FINGAR
Spiller Company:	DOROTHY FINGAR
Spiller Address:	158 GRAND ST.
Spiller County:	001
Spiller Contact:	DOROTHY FINGAR
Spiller Phone:	(914) 949-0308
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	299193
Latitude:	41.0282440
Longitude:	-73.7675710
DEC Memo:	03/18/05 TEMP TANK SET UP BY WILCO FUEL. SAMPLES RESULTS REPORTED TO BE VERY HIGH LEVELS OF CONTAMINATION. jod September 7, 2005: SEE SPILL 05-06649 FOR ALL UPDATE INFORMATION. NFA THIS SPILL NUMBER. jod
Remarks:	Tank was supposed to be tested today. However the tank has a hole in it, soil is compacted. samples were tkaen for testing. The old tank was removed and a new one installed, old tank was pumped out.

COMMERCIAL BUSINESS (Continued) **S107410444**

03/18/05 Tank has NOT been removed yet. jod

All Materials:

Site ID:	338963
Operable Unit ID:	1100882
Operable Unit:	01
Material ID:	581014
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

S274 **CON EDISON - VAULT 4680** **NY MANIFEST** **S120959011**
SE **161 GRAND ST** **N/A**
1/8-1/4 **BRONX, NY 10601**
0.179 mi.
947 ft. **Site 7 of 11 in cluster S**

Relative:
Higher

Actual:
235 ft.

NY MANIFEST:

EPA ID:	NYP004983803
Country:	USA
Name:	Con Edison - Vault 4680
Address:	161 GRAND ST
Address 2:	Not reported
City,State,Zip:	BRONX, NY 10601
Zip 4:	Not reported
Location Address 1:	161 GRAND ST
Location Address 2:	Not reported
Location City,State,Zip:	BRONX, NY 10601
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Edison - Vault 4680
Mailing Contact:	Con Edison
Mailing Address 1:	4 IRVING PL 15TH FL NE
Mailing Address 2:	Not reported
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	Not reported

X275 **CON EDISON** **RCRA NonGen / NLR** **1014398973**
East **240 MARTINE AVE & MAMARONECK AVE** **FINDS** **NYP004213484**
1/8-1/4 **WHITE PLAINS, NY 10601** **ECHO**
0.180 mi. **NJ MANIFEST**
948 ft. **Site 3 of 8 in cluster X**

Relative: **Higher**
Actual: **215 ft.**

RCRA Listings:

Date Form Received by Agency:	20200413
Handler Name:	Con Edison
Handler Address:	Martine Ave & Mamaroneck Ave
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYP004213484
Contact Name:	Not reported
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	Not reported
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	Not reported
Mailing City,State,Zip:	Not reported
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No

CON EDISON (Continued) **1014398973**

Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20200413
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20100813
Handler Name: CON EDISON	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20200413
Handler Name: CON EDISON	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	No
Electronic Manifest Broker:	No

List of NAICS Codes and Descriptions:

NAICS Codes:	No NAICS Codes Found

Facility Has Received Notices of Violations:

Violations:	No Violations Found

Evaluation Action Summary:

Evaluations:	No Evaluations Found

CON EDISON (Continued) **1014398973**

FINDS:
Registry ID: 110064269786

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:
The Resource Conservation and Recovery Act Information System (RCRAInfo) is EPA's comprehensive information system in support of the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. It tracks many types of information about generators, transporters, treaters, storers, and disposers of hazardous waste.

Click this hyperlink while viewing on your computer to access additional FINDS: detail in the EDR Site Report.

ECHO:
Envid: 1014398973
Registry ID: 110064269786

DFR URL:
Name: CON EDISON
Address: 240 MARTINE AVE & MAMARONECK AVE
City,State,Zip: WHITE PLAINS, NY 10601

NJ MANIFEST:
EPA ID: NYP004213484
Name: CON EDISON
Address: 240 MARTINE AVE & MAMARONECK AVE
City,State,Zip: WHITE PLAINS, NY 10601
County: Not reported
Mailing Address: 4 IRVING PL, RM 828
Mailing City,State,Zip: NEW YORK, NY 10003
Telephone: Not reported
Emergency Telephone: Not reported
Contact: DONALD SENNO
Comments: Not reported
SIC Code: Not reported
County: NY119
Municipal: Not reported
Previous EPAID: Not reported
Generator Flag: Not reported
Transporter Flag: Not reported
TSDF Flag: Not reported
Name Change: Not reported
Date Change: Not reported

Manifest Data:
EPA ID: NYP004213484
Manifest Number: 001086128GBF
Date Shipped: 08/13/2010
TSDF EPA ID: NJD002200046
Transporter EPA ID: NYD006982359
Transporter 2 EPA ID: Not reported
Transporter 3 EPA ID: Not reported
Transporter 4 EPA ID: Not reported
Transporter 5 EPA ID: Not reported
Transporter 6 EPA ID: Not reported

CON EDISON (Continued) **1014398973**

Transporter 7 EPA ID:	Not reported
Transporter 8 EPA ID:	Not reported
Transporter 9 EPA ID:	Not reported
Transporter 10 EPA ID:	Not reported
Date Trans1 Transported Waste:	08/13/2010
Date Trans2 Transported Waste:	Not reported
Date Trans3 Transported Waste:	Not reported
Date Trans4 Transported Waste:	Not reported
Date Trans5 Transported Waste:	Not reported
Date Trans6 Transported Waste:	Not reported
Date Trans7 Transported Waste:	Not reported
Date Trans8 Transported Waste:	Not reported
Date Trans9 Transported Waste:	Not reported
Date Trans10 Transported Waste:	Not reported
Date TSDF Received Waste:	08/13/2010
TSDF EPA Facility Name:	Not reported
QTY Units:	Not reported
Transporter SEQ ID:	Not reported
Transporter-1 Date:	Not reported
Waste SEQ ID:	Not reported
Waste Type Code 2:	Not reported
Waste Type Code 3:	Not reported
Waste Type Code 4:	Not reported
Waste Type Code 5:	Not reported
Waste Type Code 6:	Not reported
Date Accepted:	Not reported
Manifest Discrepancy Type:	Not reported
Data Entry Number:	Not reported
Was Load Rejected:	N
Reason Load Was Rejected:	Not reported

Waste:

Manifest Year:	Not reported
Waste Code:	D008
Hand Code:	H111
Quantity:	400
Unit:	P

AA276 **CON EDISON MANHOLE: 11362** **RCRA NonGen / NLR** **1016677744**
South **QUARROPAS ST & FISCHER CT** **FINDS** **NYP004314233**
1/8-1/4 **WHITE PLAINS, NY 10606** **ECHO**
0.180 mi. **NY MANIFEST**
951 ft. **Site 4 of 7 in cluster AA**

Relative: **Higher**
Actual: **197 ft.**

RCRA Listings:

Date Form Received by Agency:	20130616
Handler Name:	Con Edison Manhole: 11362
Handler Address:	Quarropas St & Fischer Ct
Handler City,State,Zip:	WHITE PLAINS, NY 10606
EPA ID:	NYP004314233
Contact Name:	CHRISTOPHER BLAICH
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	914-925-6219
Contact Fax:	Not reported
Contact Email:	Not reported

CON EDISON MANHOLE: 11362 (Continued) **1016677744**

Contact Title:	SR SPECIALIST
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	VING PL, RM 828
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20140402
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

CON EDISON MANHOLE: 11362 (Continued) **1016677744**

Historic Generators:

Receive Date:	20130516
Handler Name:	CON EDISON MANHOLE: 11362
Federal Waste Generator Description:	Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20130616
Handler Name:	CON EDISON MANHOLE: 11362
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

FINDS:
Registry ID: 110058878497

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:
The Resource Conservation and Recovery Act Information System (RCRAInfo) is EPA's comprehensive information system in support of the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. It tracks many types of information about generators, transporters, treaters, storers, and disposers of hazardous waste.

Click this hyperlink while viewing on your computer to access additional FINDS: detail in the EDR Site Report.

ECHO:
Envid: 1016677744

CON EDISON MANHOLE: 11362 (Continued) **1016677744**

Registry ID: 110058878497

DER URL:
Name: CON EDISON MANHOLE: 11362
Address: QUARROPAS ST & FISCHER CT
City,State,Zip: WHITE PLAINS, NY 10606

NY MANIFEST:
EPA ID: NYP004314233
Country: USA
Name: Con Edison
Address: QUARROPAS ST & FISCHER CT
Address 2: Not reported
City,State,Zip: WHITE PLAINS, NY 10606
Zip 4: Not reported
Location Address 1: QUARROPAS ST & FISHER CT
Location Address 2: Not reported
Location City,State,Zip: WHITE PLAINS, NY 10601
Location Zip 4: Not reported
Facility Status: Not reported
Total Tanks: Not reported
Code: BP

Mailing:
Mailing Name: Con Edison
Mailing Contact: Con Edison
Mailing Address 1: 4 IRVING PLACE 15TH FLOOR
Mailing Address 2: Not reported
Mailing City,State,Zip: NEW YORK, NY 10003
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: 2124603770

AA277 **CON EDISON** **NY MANIFEST** **S117059285**
South **FISHER CT & QUARROPAS ST** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10603**
0.180 mi.
951 ft. **Site 5 of 7 in cluster AA**

Relative:
Higher

Actual:
197 ft.

NY MANIFEST:
EPA ID: NYP004514436
Country: USA
Name: Con Edison
Address: FISHER CT & QUARROPAS ST
Address 2: Not reported
City,State,Zip: WHITE PLAINS, NY 10603
Zip 4: Not reported
Location Address 1: FISHER CT QUARRO PASS
Location Address 2: Not reported
Location City,State,Zip: WHITE PLAINS, NY 10602
Location Zip 4: Not reported
Facility Status: Not reported
Total Tanks: Not reported
Code: BP

Mailing:
Mailing Name: Con Edison

CON EDISON (Continued) **S117059285**

Mailing Contact: Con Edison
Mailing Address 1: 4 IRVING PL
Mailing Address 2: 15TH FL
Mailing City,State,Zip: NEW YORK, NY 10003
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: Not reported

Manifest Data:
Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: NYD006982359
Year: 2018
Trans2 State ID: Not reported
Generator Ship Date: 04/28/2014
Trans1 Recv Date: 04/28/2014
Trans2 Recv Date: Not reported
TSD Site Recv Date: 04/30/2014
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYP004514436
Trans1 EPA ID: Not reported
Trans2 EPA ID: Not reported
TSDF ID 1: NJD002200046
TSDF ID 2: Not reported
Manifest Tracking Number: 012771810JJK
Import Indicator: N
Export Indicator: N
Discr Quantity Indicator: N
Discr Type Indicator: N
Discr Residue Indicator: N
Discr Partial Reject Indicator: N
Discr Full Reject Indicator: N
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: H110
Waste Code a: Lead
Waste Code b: Not reported
Waste Code c: Not reported
Waste Code e: Not reported
Waste Code f: Not reported
Waste Code g: Not reported
Waste Code 1: Not reported
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 60
Units: Pounds
Number of Containers: 1
Container Type: Cargo tanks (tank trucks)
Handling Method: Treat
Specific Gravity: 1

AA278 **CON EDISON SERVICE BOX: 11370** **RCRA NonGen / NLR** **1017773655**
South **FISHER CT & QUARROPAS ST** **FINDS** **NYP004514436**
1/8-1/4 **WHITE PLAINS, NY 10603**
0.180 mi.
951 ft. **Site 6 of 7 in cluster AA**

Relative:
Higher

Actual:
197 ft.

RCRA Listings:

Date Form Received by Agency:	20140528
Handler Name:	Con Edison Service Box: 11370
Handler Address:	Fisher Ct & Quarropas St
Handler City,State,Zip:	WHITE PLAINS, NY 10603
EPA ID:	NYP004514436
Contact Name:	THOMAS TEELING
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	212-460-3770
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	SENIOR SCIENTIST
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PL, 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No

CON EDISON SERVICE BOX: 11370 (Continued) **1017773655**

Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20150211
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20140428
Handler Name: CON EDISON	
Federal Waste Generator Description:	Large Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20140428
Handler Name: CON EDISON	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20140528
Handler Name: CON EDISON SERVICE BOX: 11370	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

CON EDISON SERVICE BOX: 11370 (Continued) **1017773655**

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

FINDS:
Registry ID: 110063784908

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:
The Resource Conservation and Recovery Act Information System (RCRAInfo) is EPA's comprehensive information system in support of the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. It tracks many types of information about generators, transporters, treaters, storers, and disposers of hazardous waste.

Click this hyperlink while viewing on your computer to access additional FINDS: detail in the EDR Site Report.

AA279 **CON EDISON** **NY MANIFEST** **S113815061**
South **QUARROPAS ST & FISHER CT** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.180 mi.
951 ft. **Site 7 of 7 in cluster AA**

Relative:
Higher

Actual:
197 ft.

NY MANIFEST:

EPA ID:	NYP004314833
Country:	USA
Name:	Con Edison
Address:	QUARROPAS ST & FISHER CT
Address 2:	MH #11362
City,State,Zip:	WHITE PLAINS, NY 10601
Zip 4:	Not reported
Location Address 1:	QUARROPAS ST & FISHER CT
Location Address 2:	MH #11362
Location City,State,Zip:	WHITE PLAINS, NY 10601
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Edison
Mailing Contact:	Con Edison
Mailing Address 1:	4 IRVING PLACE 15TH FLOOR
Mailing Address 2:	Not reported
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	2124603770

CON EDISON (Continued) **S113815061**

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NJ0000027193
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	05/16/2013
Trans1 Recv Date:	05/16/2013
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	05/17/2013
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004314833
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	010842720JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	1500
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

X280 **1-HOUR PHOTO FINISH** **RCRA NonGen / NLR** **1001127917**
East **60B MAMARONECK AVE** **NY MANIFEST** **NYR000035253**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.181 mi.
955 ft. **Site 4 of 8 in cluster X**

Relative: **Higher**

Actual: **216 ft.**

RCRA Listings:

Date Form Received by Agency:	20070101
Handler Name:	1-Hour Photo Finish
Handler Address:	Mamaroneck Ave
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYR000035253
Contact Name:	KURT OLSEN
Contact Address:	MAMARONECK AVE
Contact City,State,Zip:	WHITE PLAINS, NY 10601
Contact Telephone:	914-761-5205
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Not reported
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R3
Mailing Address:	MAMARONECK AVE
Mailing City,State,Zip:	WHITE PLAINS, NY 10601
Owner Name:	Kurt Olsen
Owner Type:	Private
Operator Name:	Kurt Olsen
Operator Type:	Private
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No

1-HOUR PHOTO FINISH (Continued) **1001127917**

Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20150414
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Hazardous Waste Summary:

Waste Code:	D000
Waste Description:	Not Defined
Waste Code:	D011
Waste Description:	Silver

Handler - Owner Operator:

Owner/Operator Indicator:	Owner
Owner/Operator Name: KURT OLSEN	
Legal Status:	Private
Date Became Current:	Not reported
Date Ended Current:	Not reported
Owner/Operator Address:	127 GARTH ST 4G
Owner/Operator City,State,Zip:	SCARSDALE, NY 10583
Owner/Operator Telephone:	914-725-0653
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported
Owner/Operator Email:	Not reported
Owner/Operator Indicator:	Owner
Owner/Operator Name: KURT OLSEN	
Legal Status:	Private
Date Became Current:	Not reported
Date Ended Current:	Not reported
Owner/Operator Address:	127 GARTH ST 4G
Owner/Operator City,State,Zip:	SCARSDALE, NY 10583
Owner/Operator Telephone:	914-725-0653
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported
Owner/Operator Email:	Not reported
Owner/Operator Indicator:	Operator
Owner/Operator Name: KURT OLSEN	
Legal Status:	Private
Date Became Current:	Not reported
Date Ended Current:	Not reported
Owner/Operator Address:	127 GARTH ST 4G
Owner/Operator City,State,Zip:	SCARSDALE, NY 10583

1-HOUR PHOTO FINISH (Continued) **1001127917**

Owner/Operator Telephone: 914-725-0653
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Historic Generators:
Receive Date: 20060101
Handler Name: 1-HOUR PHOTO FINISH
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20070101
Handler Name: 1-HOUR PHOTO FINISH
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 19970506
Handler Name: 1-HOUR PHOTO FINISH
Federal Waste Generator Description: Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

1-HOUR PHOTO FINISH (Continued) **1001127917**

NY MANIFEST:

EPA ID:	NYR000035253
Country:	USA
Name:	1-Hour Photo Finish
Address:	60B MAMARONECK AVE
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10601
Zip 4:	Not reported
Location Address 1:	60-B MANARONECK AVE
Location Address 2:	Not reported
Location City,State,Zip:	WHITE PLAINS, NY 10601
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	1-Hour Photo Finish
Mailing Contact:	Kurt Olsen
Mailing Address 1:	60-B MAMARONECK AVE
Mailing Address 2:	Not reported
Mailing City,State,Zip:	WHITE PLAINS, NY 10601
Mailing Zip 4:	4223
Mailing Country:	USA
Mailing Phone:	9147615205

Manifest Data:

Document ID:	CTF0672246
Manifest Status:	Not reported
Trans1 State ID:	NYDW9495
Year:	1997
Trans2 State ID:	Not reported
Generator Ship Date:	12/17/1997
Trans1 Recv Date:	12/17/1997
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	12/18/1997
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000035253
Trans1 EPA ID:	ILD984908202
Trans2 EPA ID:	Not reported
TSDF ID 1:	CTD001156009
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Silver
Waste Code 2:	Not reported

1-HOUR PHOTO FINISH (Continued) **1001127917**

Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00250
Units:	Pounds
Number of Containers:	001
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Recycle
Specific Gravity:	01.00
Document ID:	CTF0673607
Manifest Status:	Not reported
Trans1 State ID:	NYLC4690
Year:	1997
Trans2 State ID:	Not reported
Generator Ship Date:	10/09/1997
Trans1 Recv Date:	10/09/1997
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	10/13/1997
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000035253
Trans1 EPA ID:	ILD984908202
Trans2 EPA ID:	Not reported
TSDF ID 1:	CTD001156009
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Silver
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00250
Units:	Pounds
Number of Containers:	001
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Recycle
Specific Gravity:	01.00
Document ID:	CTF0674310
Manifest Status:	Not reported
Trans1 State ID:	NYCR2436
Year:	1997
Trans2 State ID:	Not reported

1-HOUR PHOTO FINISH (Continued) **1001127917**

Generator Ship Date: 09/03/1997
Trans1 Recv Date: 09/03/1997
Trans2 Recv Date: Not reported
TSD Site Recv Date: 09/04/1997
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYR000035253
Trans1 EPA ID: ILD984908202
Trans2 EPA ID: Not reported
TSDF ID 1: CTD001156009
TSDF ID 2: Not reported
Manifest Tracking Number: Not reported
Import Indicator: Not reported
Export Indicator: Not reported
Discr Quantity Indicator: Not reported
Discr Type Indicator: Not reported
Discr Residue Indicator: Not reported
Discr Partial Reject Indicator: Not reported
Discr Full Reject Indicator: Not reported
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: Not reported
Waste Code 1: Silver
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 00250
Units: Pounds
Number of Containers: 001
Container Type: Fiberboard or plastic drums, barrels, kegs
Handling Method: Recycle
Specific Gravity: 01.00

Document ID: CTF0666879
Manifest Status: Not reported
Trans1 State ID: NYDW9495
Year: 1997
Trans2 State ID: Not reported
Generator Ship Date: 11/12/1997
Trans1 Recv Date: 11/12/1997
Trans2 Recv Date: Not reported
TSD Site Recv Date: 11/13/1997
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYR000035253
Trans1 EPA ID: ILD984908202
Trans2 EPA ID: Not reported
TSDF ID 1: CTD001156009
TSDF ID 2: Not reported
Manifest Tracking Number: Not reported
Import Indicator: Not reported
Export Indicator: Not reported
Discr Quantity Indicator: Not reported
Discr Type Indicator: Not reported

1-HOUR PHOTO FINISH (Continued) **1001127917**

Discr Residue Indicator: Not reported
Discr Partial Reject Indicator: Not reported
Discr Full Reject Indicator: Not reported
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: Not reported
Waste Code 1: Silver
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 00250
Units: Pounds
Number of Containers: 001
Container Type: Fiberboard or plastic drums, barrels, kegs
Handling Method: Recycle
Specific Gravity: 01.00

Document ID: CTF0669348
Manifest Status: Not reported
Trans1 State ID: NYDW9495
Year: 1998
Trans2 State ID: Not reported
Generator Ship Date: 04/01/1998
Trans1 Recv Date: 04/01/1998
Trans2 Recv Date: Not reported
TSD Site Recv Date: 04/02/1998
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYR000035253
Trans1 EPA ID: ILD984908202
Trans2 EPA ID: Not reported
TSDF ID 1: CTD001156009
TSDF ID 2: Not reported
Manifest Tracking Number: Not reported
Import Indicator: Not reported
Export Indicator: Not reported
Discr Quantity Indicator: Not reported
Discr Type Indicator: Not reported
Discr Residue Indicator: Not reported
Discr Partial Reject Indicator: Not reported
Discr Full Reject Indicator: Not reported
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: Not reported
Waste Code 1: Silver
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 00250
Units: Pounds
Number of Containers: 001

1-HOUR PHOTO FINISH (Continued) **1001127917**

Container Type: Fiberboard or plastic drums, barrels, kegs
Handling Method: Recycle
Specific Gravity: 01.00

Document ID: CTF0669886
Manifest Status: Not reported
Trans1 State ID: NYCR2436
Year: 1998
Trans2 State ID: Not reported
Generator Ship Date: 04/27/1998
Trans1 Recv Date: 04/27/1998
Trans2 Recv Date: Not reported
TSD Site Recv Date: 04/30/1998
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYR000035253
Trans1 EPA ID: ILD984908202
Trans2 EPA ID: Not reported
TSDF ID 1: CTD001156009
TSDF ID 2: Not reported
Manifest Tracking Number: Not reported
Import Indicator: Not reported
Export Indicator: Not reported
Discr Quantity Indicator: Not reported
Discr Type Indicator: Not reported
Discr Residue Indicator: Not reported
Discr Partial Reject Indicator: Not reported
Discr Full Reject Indicator: Not reported
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: Not reported
Waste Code 1: Silver
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 00250
Units: Pounds
Number of Containers: 001
Container Type: Fiberboard or plastic drums, barrels, kegs
Handling Method: Recycle
Specific Gravity: 01.00

Document ID: CTF0672155
Manifest Status: Not reported
Trans1 State ID: NYCR2436
Year: 1998
Trans2 State ID: Not reported
Generator Ship Date: 01/09/1998
Trans1 Recv Date: 01/09/1998
Trans2 Recv Date: Not reported
TSD Site Recv Date: 01/12/1998
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYR000035253

1-HOUR PHOTO FINISH (Continued) **1001127917**

Trans1 EPA ID:	ILD984908202
Trans2 EPA ID:	Not reported
TSDF ID 1:	CTD001156009
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Silver
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00250
Units:	Pounds
Number of Containers:	001
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Recycle
Specific Gravity:	01.00

Document ID:	CTF0669274
Manifest Status:	Not reported
Trans1 State ID:	NYDW9495
Year:	1998
Trans2 State ID:	Not reported
Generator Ship Date:	02/12/1998
Trans1 Recv Date:	02/12/1998
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	02/16/1998
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000035253
Trans1 EPA ID:	ILD984908202
Trans2 EPA ID:	Not reported
TSDF ID 1:	CTD001156009
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported

1-HOUR PHOTO FINISH (Continued) **1001127917**

Waste Code 1:	Silver
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00250
Units:	Pounds
Number of Containers:	001
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Recycle
Specific Gravity:	01.00
Document ID:	CTF0669296
Manifest Status:	Not reported
Trans1 State ID:	NYDW9495
Year:	1998
Trans2 State ID:	Not reported
Generator Ship Date:	03/05/1998
Trans1 Recv Date:	03/05/1998
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	03/06/1998
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000035253
Trans1 EPA ID:	ILD984908202
Trans2 EPA ID:	Not reported
TSDF ID 1:	CTD001156009
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Silver
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00250
Units:	Pounds
Number of Containers:	001
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Recycle
Specific Gravity:	01.00
Document ID:	MAJ0830070
Manifest Status:	Not reported
Trans1 State ID:	NYCR2436

1-HOUR PHOTO FINISH (Continued) **1001127917**

Year:	1998
Trans2 State ID:	FY22NXNJ
Generator Ship Date:	11/12/1998
Trans1 Recv Date:	11/12/1998
Trans2 Recv Date:	11/16/1998
TSD Site Recv Date:	12/01/1998
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000035253
Trans1 EPA ID:	ILD984908202
Trans2 EPA ID:	SCD987574647
TSDF ID 1:	MAD982755639
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Silver
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00250
Units:	Pounds
Number of Containers:	001
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Recycle
Specific Gravity:	01.00
Document ID:	MAH1245720
Manifest Status:	Not reported
Trans1 State ID:	Not reported
Year:	1998
Trans2 State ID:	T422NXNJ
Generator Ship Date:	10/29/1998
Trans1 Recv Date:	10/29/1998
Trans2 Recv Date:	11/02/1998
TSD Site Recv Date:	11/09/1998
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000035253
Trans1 EPA ID:	ILD984908202
Trans2 EPA ID:	SCD987574647
TSDF ID 1:	MAD982755639
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported

1-HOUR PHOTO FINISH (Continued) **1001127917**

Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Silver
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00250
Units:	Pounds
Number of Containers:	001
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Treat
Specific Gravity:	01.00

Click this hyperlink while viewing on your computer to access
14 additional NY MANIFEST: record(s) in the EDR Site Report.

AB281 **55 CHURCH WP LLC** **NY AST** **A100540246**
NE **55 CHURCH STREET** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.183 mi.
964 ft. **Site 1 of 3 in cluster AB**

Relative: WESTCHESTER CO. AST:
Higher

Actual: Name: 55 CHURCH WP LLC
217 ft. Address: 55 CHURCH STREET
City,State,Zip: WHITE PLAINS, NY 10601
PBS Number: 3-800303
Site Status: Active
GDS Number: Not reported
Operator Name: George Muto
Owner Name: 55 Church WP LLC
Owner Street: 55 Church Street
Owner Address2: Not reported
Owner City/State/Zip: White Plains, NY 10601

Tank Number: 001
Status: 1. In-Service
Date Installation: 01/01/1956
Capacity: 15000
Product Stored: 0001. #2 Fuel Oil
Product Stored Percent: Not reported
Date Perm Closure: 01/01/1900
Tank Location: 3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type: 1. Steel/Carbon steel/Iron
Tank Internal Protection: 0. None
Tank External Protection: 1. Painted/Asphalt Coating
Tank Leak Detection: 6. Impervious Barrier/Concrete Pad (Aboveground Only)
Tank Secondary Containment: 2. Vault (w/ access)

55 CHURCH WP LLC (Continued) **A100540246**

Piping Location:	3. Aboveground/Underground Combination
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	1. Painted/Asphalt Coating
Piping Leak Detection:	0. None
Piping Secondary Containment:	0. None
Overfill Prevention:	5. Vent Whistle
Spill Prevention:	0. None
Dispenser:	2. Suction

AB282 **CENTURYLINK - WHITE PLAINS TI** **NY AST** **A100540316**
NE **55 CHURCH STREET** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.183 mi.
964 ft. **Site 2 of 3 in cluster AB**

Relative: **Higher**

Actual: **217 ft.**

WESTCHESTER CO. AST:

Name:	CENTURYLINK - WHITE PLAINS TI
Address:	55 CHURCH STREET
City,State,Zip:	WHITE PLAINS, NY 10601
PBS Number:	3-800862
Site Status:	Active
GDS Number:	Not reported
Operator Name:	Jeffrey Schwab
Owner Name:	55 Church Street WP LLC
Owner Street:	55 Church Street
Owner Address2:	1st Floor
Owner City/State/Zip:	White Plains, NY 10601
Tank Number:	001
Status:	1. In-Service
Date Installation:	01/01/2000
Capacity:	2000
Product Stored:	0008. Diesel
Product Stored Percent:	Not reported
Date Perm Closure:	01/01/1900
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating, DW HIGHLAND OP LOCATED INSIDE BASEMENT TANK ROOM
Tank Leak Detection:	1. Electronic Interstitial Monitoring,6. Impervious Barrier/Concrete Pad (Aboveground Only)
Tank Secondary Containment:	1. Diking (aboveground only),12. Double-Walled (AST only)
Piping Location:	1. Aboveground
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	1. Painted/Asphalt Coating
Piping Leak Detection:	Not reported
Piping Secondary Containment:	10. Impervious Underlayment (AST Only)
Overfill Prevention:	2. High Level Alarm,LIQUID SENSOR INSIDE RUPTURE BASIN
Spill Prevention:	1. Catch Basin,STEEL ACCESS DOOR LEFT SIDE OF BUILDING
Dispenser:	2. Suction
Tank Number:	002
Status:	1. In-Service
Date Installation:	01/01/2000
Capacity:	275
Product Stored:	0008. Diesel
Product Stored Percent:	Not reported
Date Perm Closure:	01/01/1900

CENTURYLINK - WHITE PLAINS TI (Continued) **A100540316**

Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating,DAY TANK LOCATED IN TANK ROOM
Tank Leak Detection:	1. Electronic Interstitial Monitoring,6. Impervious Barrier/Concrete Pad (Aboveground Only)
Tank Secondary Containment:	1. Diking (aboveground only),12. Double-Walled (AST only)
Piping Location:	1. Aboveground
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	Not reported
Piping Leak Detection:	Not reported
Piping Secondary Containment:	10. Impervious Underlayment (AST Only)
Overfill Prevention:	2. High Level Alarm,3. Automatic Shut-off
Spill Prevention:	DAY TANK
Dispenser:	2. Suction

AC283 **PEPE MOTORS** **UST FINDER RELEASE** **1029067096**
SW **50 BANK ST** **N/A**
1/8-1/4 **WHITE PLAINS, NY 0**
0.185 mi.
977 ft. **Site 1 of 4 in cluster AC**

Relative: **Higher**
Actual: **206 ft.**

UST FINDER RELEASE:

Object ID:	262260
Facility ID:	NY230673
Lust ID:	NY9607100
Name:	PEPE MOTORS
Address:	50 BANK ST
City,State,Zip:	WHITE PLAINS, NY 0
Address Match Type:	Not reported
Reported Date:	1996/09/04 15:59:59+00
Status:	No Further Action
Substance:	Not reported
Population within 1500ft:	3504
Domestic Wells within 1500ft:	0
Land Use:	Developed, Medium Intensity
Within SPA:	Yes
SPA PWS Facility ID:	NY7003493_76968
SPA Water Type:	SW - SurRELEASEe Water
SPA Facility Type:	RS - Reservoir
SPA HUC12:	20301020103
Within WHPA:	No
WHPA PWS Facility ID:	Not reported
WHPA Water Type:	Not reported
WHPA Facility Type:	Not reported
WHPA HUC12:	Not reported
Within 100yr Floodplain:	No
Tribe:	Not reported
EPA Region:	2
NFA Letter 1:	Not reported
NFA Letter 2:	Not reported
NFA Letter 3:	Not reported
NFA Letter 4:	Not reported
Closed With Residual Contaminate:	Not reported
Coordinate Source:	State
X Coord:	-73.77451
Y Coord:	41.0288100000001
Latitude:	41.02881
Longitude:	-73.77451

AC284 **MERCEDES- BENZ OF WHITE PLAINS** **NY UST** **U003857474**
SW **50 BANK STREET** **NY AST** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10606**
0.185 mi.
977 ft. **Site 2 of 4 in cluster AC**

Relative:
Higher

Actual:
206 ft.

WESTCHESTER CO. UST:

Name:	MERCEDES- BENZ OF WHITE PLAINS
Address:	50 BANK STREET
City,State,Zip:	WHITE PLAINS, NY 10606
Id/Status:	3-452122 / Active
Operator Name:	Eugene Pepe
Owner Name:	Eugene Pepe
Owner Street:	50 Bank Street
Owner Address2:	Not reported
Owner City:	White Plains
Owner State:	NY
Owner Zipcode:	10606
GDS Number:	3551700341
Tank Number:	1
Status:	1. In-Service
Capacity:	3000
Product Stored:	0009. Gasoline
Product Stored Percent:	Not reported
Tank Leak Detection:	1. Electronic Interstitial Monitoring
Date Installation:	03/01/1997
Date Perm Closure:	01/01/1900
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	4. Fiberglass coated steel
Tank Internal Protection:	0. None
Tank External Protection:	4. Fiberglass
Tank Secondary Containment:	4. Double-Walled (underground only)
Piping Location:	2. Underground/on Ground
Piping Type:	6. Fiberglass Reinforced Plastic (FRP)
Piping External Protection:	4. Fiberglass
Overfill Prevention:	2. High Level Alarm,3. Automatic Shut-off
Piping Secondary Containment:	4. Double-Walled (underground only)
Spill Prevention:	1. Catch Basin
Dispenser:	2. Suction
Tank Number:	1 old
Status:	3. Closed - Removed
Capacity:	3000
Product Stored:	0009. Gasoline
Product Stored Percent:	Not reported
Tank Leak Detection:	99. Other
Date Installation:	06/01/1979
Date Perm Closure:	02/01/1997
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	0. No Pipiing
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Overfill Prevention:	Not reported

MERCEDES- BENZ OF WHITE PLAINS (Continued) **U003857474**

Piping Secondary Containment:	Not reported
Spill Prevention:	Not reported
Dispenser:	2. Suction

Tank Number:	2
Status:	1. In-Service
Capacity:	3000
Product Stored:	0008. Diesel
Product Stored Percent:	Not reported
Tank Leak Detection:	1. Electronic Interstitial Monitoring
Date Installation:	03/01/1997
Date Perm Closure:	01/01/1900
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	4. Fiberglass coated steel
Tank Internal Protection:	0. None
Tank External Protection:	4. Fiberglass
Tank Secondary Containment:	4. Double-Walled (underground only)
Piping Location:	2. Underground/on Ground
Piping Type:	6. Fiberglass Reinforced Plastic (FRP)
Piping External Protection:	4. Fiberglass
Overfill Prevention:	2. High Level Alarm,3. Automatic Shut-off
Piping Secondary Containment:	4. Double-Walled (underground only)
Spill Prevention:	1. Catch Basin
Dispenser:	2. Suction

Tank Number:	2 old
Status:	3. Closed - Removed
Capacity:	3000
Product Stored:	0008. Diesel
Product Stored Percent:	Not reported
Tank Leak Detection:	99. Other
Date Installation:	06/01/1979
Date Perm Closure:	02/01/1997
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	0. No Pipiing
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Overfill Prevention:	Not reported
Piping Secondary Containment:	Not reported
Spill Prevention:	Not reported
Dispenser:	2. Suction

Tank Number:	3
Status:	4. Closed - in place
Capacity:	550
Product Stored:	0015. Motor Oil
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	06/01/1979
Date Perm Closure:	12/02/2008

MERCEDES- BENZ OF WHITE PLAINS (Continued) **U003857474**

Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	2. Underground/on ground
Piping Type:	2. Galvanized steel
Piping External Protection:	0. None
Overfill Prevention:	0. None
Piping Secondary Containment:	Not reported
Spill Prevention:	0. None
Dispenser:	0. None

Tank Number:	4
Status:	4. Closed - in place
Capacity:	550
Product Stored:	0015. Motor Oil
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	06/01/1979
Date Perm Closure:	12/02/2008
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	2. Underground/on ground
Piping Type:	2. Galvanized steel
Piping External Protection:	0. None
Overfill Prevention:	0. None
Piping Secondary Containment:	Not reported
Spill Prevention:	0. None
Dispenser:	0. None

Tank Number:	5
Status:	0. Administratively closed
Capacity:	1000
Product Stored:	0022. Waste/Used Oil
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	06/01/1979
Date Perm Closure:	01/01/1900
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	2. Underground/on ground
Piping Type:	2. Galvanized steel
Piping External Protection:	0. None
Overfill Prevention:	0. None
Piping Secondary Containment:	Not reported
Spill Prevention:	0. None
Dispenser:	0. None

MERCEDES- BENZ OF WHITE PLAINS (Continued) **U003857474**

WESTCHESTER CO. AST:

Name:	MERCEDES- BENZ OF WHITE PLAINS
Address:	50 BANK STREET
City,State,Zip:	WHITE PLAINS, NY 10606
PBS Number:	3-452122
Site Status:	Active
GDS Number:	3551700341
Operator Name:	Eugene Pepe
Owner Name:	Eugene Pepe
Owner Street:	50 Bank Street
Owner Address2:	Not reported
Owner City/State/Zip:	White Plains, NY 10606
Tank Number:	6
Status:	3. Closed - Removed
Date Installation:	06/01/1979
Capacity:	275
Product Stored:	0015. Motor Oil
Product Stored Percent:	Not reported
Date Perm Closure:	12/02/2008
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Leak Detection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	1. Aboveground
Piping Type:	10. Copper
Piping External Protection:	0. None
Piping Leak Detection:	Not reported
Piping Secondary Containment:	Not reported
Overfill Prevention:	0. None
Spill Prevention:	0. None
Dispenser:	0. None

Tank Number:	7
Status:	1. In-Service
Date Installation:	06/01/2004
Capacity:	800
Product Stored:	0022. Waste/Used Oil
Product Stored Percent:	Not reported
Date Perm Closure:	01/01/1900
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Leak Detection:	2. Manual Interstitial Monitoring
Tank Secondary Containment:	9. Modified double-walled (aboveground only)
Piping Location:	0. No Piping
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	0. None
Piping Leak Detection:	0. None
Piping Secondary Containment:	0. None
Overfill Prevention:	4. Product Level Gauge (Aboveground Only)
Spill Prevention:	1. Catch Basin
Dispenser:	2. Suction

MERCEDES- BENZ OF WHITE PLAINS (Continued) **U003857474**

Tank Number:	8
Status:	1. In-Service
Date Installation:	03/02/2009
Capacity:	500
Product Stored:	0013. Lube Oil
Product Stored Percent:	0
Date Perm Closure:	01/01/1900
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Leak Detection:	2. Manual Interstitial Monitoring
Tank Secondary Containment:	9. Modified double-walled (aboveground only)
Piping Location:	1. Aboveground
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	1. Painted/Asphalt Coating
Piping Leak Detection:	2. Manual Interstitial Monitoring
Piping Secondary Containment:	0. None
Overfill Prevention:	3. Automatic Shut-off,4. Product Level Gauge (Aboveground Only)
Spill Prevention:	1. Catch Basin
Dispenser:	2. Suction

Tank Number:	9
Status:	1. In-Service
Date Installation:	03/02/2009
Capacity:	500
Product Stored:	0013. Lube Oil
Product Stored Percent:	0
Date Perm Closure:	01/01/1900
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Leak Detection:	2. Manual Interstitial Monitoring
Tank Secondary Containment:	9. Modified double-walled (aboveground only)
Piping Location:	1. Aboveground
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	1. Painted/Asphalt Coating
Piping Leak Detection:	2. Manual Interstitial Monitoring
Piping Secondary Containment:	0. None
Overfill Prevention:	3. Automatic Shut-off,4. Product Level Gauge (Aboveground Only)
Spill Prevention:	1. Catch Basin
Dispenser:	2. Suction

AC285 **PEPE MOTORS INC** **RCRA-VSQG** **1000197633**
SW **50 BANK ST** **NY LTANKS** **NYD056298037**
1/8-1/4 **WHITE PLAINS, NY 10606** **FINDS**
0.185 mi. **ECHO**
977 ft. **Site 3 of 4 in cluster AC** **NY MANIFEST**

Relative: **Higher**
Actual: **206 ft.**

RCRA Listings:

Date Form Received by Agency:	20070101
Handler Name:	Pepe Motors Inc
Handler Address:	Bank St
Handler City,State,Zip:	WHITE PLAINS, NY 10606
EPA ID:	NYD056298037
Contact Name:	Not reported

PEPE MOTORS INC (Continued) **1000197633**

Contact Address:	BANK ST
Contact City,State,Zip:	WHITE PLAINS, NY 10606
Contact Telephone:	Not reported
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Not reported
Federal Waste Generator Description:	Conditionally Exempt Small Quantity Generator
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Handler Activities
State District Owner:	Ny
State District:	NYSDEC R3
Mailing Address:	BANK ST
Mailing City,State,Zip:	WHITE PLAINS, NY 10606
Owner Name:	Eugene Pepe
Owner Type:	Private
Operator Name:	Eugene Pepe
Operator Type:	Private
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20150414
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No

PEPE MOTORS INC (Continued) **1000197633**

Exporter of Spent Lead Acid Batteries: No
Recycler Activity Without Storage: No
Manifest Broker: No
Sub-Part P Indicator: No

Hazardous Waste Summary:
Waste Code: D000
Waste Description: Not Defined

Waste Code: D001
Waste Description: Ignitable Waste

Waste Code: F002
Waste Description: The Following Spent Halogenated Solvents: Tetrachloroethylene, Methylene Chloride, Trichloroethylene, 1,1,1-Trichloroethane, Chlorobenzene, 1,1,2-Trichloro-1,2,2-Trifluoroethane, Ortho-Dichlorobenzene, Trichlorofluoromethane, And 1,1,2, Trichloroethane; All Spent Solvent Mixtures/Blends Containing, Before Use, A Total Of Ten Percent Or More (By Volume) Of One Or More Of The Above Halogenated Solvents Or Those Solvents Listed In F001, F004, And F005; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent Mixtures.

Waste Code: F004
Waste Description: The Following Spent Nonhalogenated Solvents: Cresols, Cresylic Acid, And Nitrobenzene; And The Still Bottoms From The Recovery Of These Solvents; All Spent Solvent Mixtures/Blends Containing, Before Use, A Total Of Ten Percent Or More (By Volume) Of One Or More Of The Above Nonhalogenated Solvents Or Those Solvents Listed In F001, F002, And F005; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent Mixtures.

Waste Code: NONE
Waste Description: Not Defined

Handler - Owner Operator:
Owner/Operator Indicator: Owner
Owner/Operator Name: EUGENE PEPE
Legal Status: Private
Date Became Current: Not reported
Date Ended Current: Not reported
Owner/Operator Address: NOT REQUIRED
Owner/Operator City,State,Zip: NOT REQUIRED, WY 99999
Owner/Operator Telephone: 212-555-1212
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Operator
Owner/Operator Name: EUGENE PEPE
Legal Status: Private
Date Became Current: Not reported
Date Ended Current: Not reported
Owner/Operator Address: NOT REQUIRED
Owner/Operator City,State,Zip: NOT REQUIRED, WY 99999

PEPE MOTORS INC (Continued) **1000197633**

Owner/Operator Telephone:	212-555-1212
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported
Owner/Operator Email:	Not reported
Owner/Operator Indicator:	Owner
Owner/Operator Name: EUGENE PEPE	
Legal Status:	Private
Date Became Current:	Not reported
Date Ended Current:	Not reported
Owner/Operator Address:	NOT REQUIRED
Owner/Operator City,State,Zip:	NOT REQUIRED, WY 99999
Owner/Operator Telephone:	212-555-1212
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported
Owner/Operator Email:	Not reported

Historic Generators:

Receive Date:	19950406
Handler Name: PEPE MOTORS INC	
Federal Waste Generator Description:	Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported
Receive Date:	20060101
Handler Name: PEPE MOTORS INC	
Federal Waste Generator Description:	Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported
Receive Date:	20070101
Handler Name: PEPE MOTORS INC	
Federal Waste Generator Description:	Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported

PEPE MOTORS INC (Continued) **1000197633**

Electronic Manifest Broker: Not reported

Receive Date: 19861119
Handler Name: PEPE MOTORS INC
Federal Waste Generator Description: Large Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 19940328
Handler Name: PEPE MOTORS INC.
Federal Waste Generator Description: Large Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Code: 44111
NAICS Description: New Car Dealers

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

LTANKS:
Name: PEPE MOTORS
Address: 50 BANK ST
City,State,Zip: WHITE PLAINS, NY
Spill Number/Closed Date: 9607100 / 1999-04-29
Facility ID: 9607100
Site ID: 284462
Spill Date: 1996-09-04
Spill Cause: Tank Test Failure
Spill Source: Gasoline Station or other PBS Facility
Spill Class: B3
Cleanup Ceased: Not reported
SWIS: 6017
Investigator: jghardy
Referred To: Not reported
Reported to Dept: 1996-09-04

PEPE MOTORS INC (Continued) **1000197633**

CID:	199
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	True
Remediation Phase:	0
Date Entered In Computer:	1996-09-04
Spill Record Last Update:	2003-09-29
Spiller Name:	Not reported
Spiller Company:	Not reported
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	STEVEN MCGUIRE
Spiller Phone:	(914) 561-1512
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	230673
Latitude:	41.0288140
Longitude:	-73.7745075
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was HARDY/BUZZELLI 04/29/1999 BASED UPON TANK CLOSURE REPORT, SPILL IS CLOSED.
Remarks:	contact person - joe sallon - 914-949-4004 on site

All TTF:

Facility ID:	9607100
Spill Number:	9607100
Spill Tank Test:	1544730
Site ID:	284462
Tank Number:	3000
Tank Size:	3000
Material:	0009
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	20
Test Method 2:	USTest 2000/P/LL plus USTest 2000/U
Leak Rate:	.10
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	284462
Operable Unit ID:	1035061
Operable Unit:	01
Material ID:	346364
Material Code:	0009
Material Name:	gasoline
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00

PEPE MOTORS INC (Continued) **1000197633**

Resource Affected: Soil
Oxygenate: Not reported

FINDS:
Registry ID: 110004360423

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:
The Resource Conservation and Recovery Act Information System (RCRAInfo) is EPA's comprehensive information system in support of the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. It tracks many types of information about generators, transporters, treaters, storers, and disposers of hazardous waste.

Click this hyperlink while viewing on your computer to access additional FINDS: detail in the EDR Site Report.

ECHO:
Envid: 1000197633
Registry ID: 110004360423

DFR URL:
Name: PEPE MOTORS INC
Address: 50 BANK ST
City,State,Zip: WHITE PLAINS, NY 10606

NY MANIFEST:
EPA ID: NYD056298037
Country: USA
Name: Pepe Motor
Address: 50 BANK STREET
Address 2: Not reported
City,State,Zip: WHITE PLAINS, NY 10606-0000
Zip 4: Not reported
Location Address 1: 50 BANK STREET
Location Address 2: Not reported
Location City,State,Zip: WHITE PLAINS, NY 10606
Location Zip 4: Not reported
Facility Status: Not reported
Total Tanks: Not reported
Code: BP

Mailing:
Mailing Name: Pepe Motor
Mailing Contact: Pepe Motor
Mailing Address 1: 50 BANK STREET
Mailing Address 2: Not reported
Mailing City,State,Zip: WHITE PLAINS, NY 10606
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: 9149494000

Manifest Data:
Document ID: ILA8347328

PEPE MOTORS INC (Continued) **1000197633**

Manifest Status:	Not reported
Trans1 State ID:	UPW015128
Year:	1999
Trans2 State ID:	UPW020395
Generator Ship Date:	03/22/1999
Trans1 Recv Date:	03/22/1999
Trans2 Recv Date:	03/24/1999
TSD Site Recv Date:	03/30/1999
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD056298037
Trans1 EPA ID:	ILD984908202
Trans2 EPA ID:	SCD987574647
TSDF ID 1:	ILD980613913
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Cadmium
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00005
Units:	Gallons (liquids only)
Number of Containers:	001
Container Type:	Metal drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00

Document ID:	ILA8347333
Manifest Status:	Not reported
Trans1 State ID:	UPW151288
Year:	1999
Trans2 State ID:	UPW203954
Generator Ship Date:	05/25/1999
Trans1 Recv Date:	05/25/1999
Trans2 Recv Date:	05/28/1999
TSD Site Recv Date:	06/07/1999
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD056298037
Trans1 EPA ID:	ILD984908202
Trans2 EPA ID:	SCD987574647
TSDF ID 1:	ILD980613913
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported

PEPE MOTORS INC (Continued) **1000197633**

Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Cadmium
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00006
Units:	Gallons (liquids only)
Number of Containers:	001
Container Type:	Metal drums, barrels, kegs
Handling Method:	Recycle
Specific Gravity:	01.00

Document ID:	ILA8347366
Manifest Status:	Not reported
Trans1 State ID:	UPW151288
Year:	1999
Trans2 State ID:	UPW203954
Generator Ship Date:	08/10/1999
Trans1 Recv Date:	08/10/1999
Trans2 Recv Date:	08/12/1999
TSD Site Recv Date:	08/17/1999
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD056298037
Trans1 EPA ID:	ILD984908202
Trans2 EPA ID:	SCD987574647
TSDF ID 1:	ILD980613913
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Cadmium
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported

PEPE MOTORS INC (Continued) **1000197633**

Waste Code 6:	Not reported
Quantity:	00007
Units:	Gallons (liquids only)
Number of Containers:	001
Container Type:	Metal drums, barrels, kegs
Handling Method:	Recycle
Specific Gravity:	01.00
Document ID:	CTF0213036
Manifest Status:	Not reported
Trans1 State ID:	NJDEPS869
Year:	1993
Trans2 State ID:	Not reported
Generator Ship Date:	04/28/1993
Trans1 Recv Date:	04/28/1993
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	05/04/1993
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD056298037
Trans1 EPA ID:	ILD051060408
Trans2 EPA ID:	Not reported
TSDF ID 1:	CTD001156009
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Ignitable Waste
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	01871
Units:	Pounds
Number of Containers:	004
Container Type:	Metal drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00
Document ID:	PAC9543472
Manifest Status:	Not reported
Trans1 State ID:	PAAH0172
Year:	1993
Trans2 State ID:	Not reported
Generator Ship Date:	05/12/1993
Trans1 Recv Date:	05/12/1993
Trans2 Recv Date:	Not reported

PEPE MOTORS INC (Continued) **1000197633**

TSD Site Recv Date:	05/12/1993
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD056298037
Trans1 EPA ID:	ILD051060408
Trans2 EPA ID:	Not reported
TSDF ID 1:	PAD987266715
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Lead
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00125
Units:	Gallons (liquids only)
Number of Containers:	001
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Recycle
Specific Gravity:	01.00

Document ID:	PAC8468670
Manifest Status:	Not reported
Trans1 State ID:	PAAH0172
Year:	1992
Trans2 State ID:	Not reported
Generator Ship Date:	10/26/1992
Trans1 Recv Date:	10/26/1992
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	10/28/1992
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD056298037
Trans1 EPA ID:	ILD051060408
Trans2 EPA ID:	Not reported
TSDF ID 1:	PAD987266715
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported

PEPE MOTORS INC (Continued) **1000197633**

Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Lead
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00150
Units:	Gallons (liquids only)
Number of Containers:	001
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	01.00

Document ID:	PAC8544771
Manifest Status:	Not reported
Trans1 State ID:	PAAH0172
Year:	1992
Trans2 State ID:	Not reported
Generator Ship Date:	11/30/1992
Trans1 Recv Date:	11/30/1992
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	12/01/1992
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD056298037
Trans1 EPA ID:	ILD051060408
Trans2 EPA ID:	Not reported
TSDF ID 1:	PAD987266715
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Lead
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00125
Units:	Gallons (liquids only)
Number of Containers:	001
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	01.00

PEPE MOTORS INC (Continued) **1000197633**

Document ID:	NJA1624181
Manifest Status:	Not reported
Trans1 State ID:	NJDEPS869
Year:	1993
Trans2 State ID:	Not reported
Generator Ship Date:	04/07/1993
Trans1 Recv Date:	04/07/1993
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	04/14/1993
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD056298037
Trans1 EPA ID:	ILD051060408
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002182897
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Ignitable Waste
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00208
Units:	Pounds
Number of Containers:	001
Container Type:	Metal drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00

Document ID:	NJA1623864
Manifest Status:	Not reported
Trans1 State ID:	NJDEPS869
Year:	1993
Trans2 State ID:	Not reported
Generator Ship Date:	03/02/1993
Trans1 Recv Date:	03/02/1993
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	03/05/1993
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD056298037
Trans1 EPA ID:	ILD051060408
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002182897
TSDF ID 2:	Not reported

PEPE MOTORS INC (Continued) **1000197633**

Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Ignitable Waste
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00209
Units:	Pounds
Number of Containers:	001
Container Type:	Metal drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00

Document ID:	CTB0074021
Manifest Status:	C - Completed copy
Trans1 State ID:	654385CT
Year:	1987
Trans2 State ID:	Not reported
Generator Ship Date:	870406
Trans1 Recv Date:	870406
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	870408
Part A Recv Date:	870417
Part B Recv Date:	870415
Generator EPA ID:	NYD056298037
Trans1 EPA ID:	VAD980831580
Trans2 EPA ID:	Not reported
TSDF ID 1:	CTD072138969
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	The Following Spent Nonhalogenated Solvents: Xylene, Acetone, Ethyl Acetate, Ethyl Benzene, Ethyl Ether, Methyl Isobutyl Ketone, N-Butyl Alcohol, Cyclohexanone, And Methanol; All Spent Solvent Mixtures/Blends Containing, Before Use, Only The Above Spent

PEPE MOTORS INC (Continued) **1000197633**

Nonhalogenated Solvents; And All Spent Solvent Mixtures/Blends Containing, Before Use, One Or More Of The Above Nonhalogenated Solvents, And A Total Of Ten Percent Or More (By Volume) Of One Or More Of Those Solvents Listed In F001, F002, F004, And F005; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent Mixtures.

Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 00420
Units: Gallons (liquids only)
Number of Containers: 001
Container Type: Cargo tanks (tank trucks)
Handling Method: Treat
Specific Gravity: 100

Document ID: CTF0640243
Manifest Status: Not reported
Trans1 State ID: NYCR2436
Year: 1997
Trans2 State ID: Not reported
Generator Ship Date: 12/16/1997
Trans1 Recv Date: 12/16/1997
Trans2 Recv Date: Not reported
TSD Site Recv Date: 12/18/1997
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYD056298037
Trans1 EPA ID: ILD984908202
Trans2 EPA ID: Not reported
TSDF ID 1: CTD001156009
TSDF ID 2: Not reported
Manifest Tracking Number: Not reported
Import Indicator: Not reported
Export Indicator: Not reported
Discr Quantity Indicator: Not reported
Discr Type Indicator: Not reported
Discr Residue Indicator: Not reported
Discr Partial Reject Indicator: Not reported
Discr Full Reject Indicator: Not reported
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: Not reported
Waste Code 1: The Following Spent Nonhalogenated Solvents: Toluene, Methyl Ethyl Ketone, Carbon Disulfide, Isobutanol, Pyridine, Benzene, 2-Ethoxyethanol, And 2-Nitropropane; All Spent Solvent Mixtures/Blends Containing, Before Use, A Total Of Ten Percent Or More (By Volume) Of One Or More Of The Above Nonhalogenated Solvents Or Those Solvents Listed In F001, F002, Or F004; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent Mixtures.
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported

PEPE MOTORS INC (Continued) **1000197633**

Waste Code 6:	Not reported
Quantity:	00112
Units:	Pounds
Number of Containers:	001
Container Type:	Metal drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00

Click this hyperlink while viewing on your computer to access
48 additional NY MANIFEST: record(s) in the EDR Site Report.

S286 **170 GRAND STREET ASSOC.** **NY UST** **U004175922**
SE **170 GRAND STREET** **NY AST** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.186 mi.
982 ft. **Site 8 of 11 in cluster S**

Relative:
Higher

Actual:
235 ft.

WESTCHESTER CO. UST:

Name:	170 GRAND STREET ASSOC.
Address:	170 GRAND STREET
City,State,Zip:	WHITE PLAINS, NY 10601
Id/Status:	3-800392 / Active
Operator Name:	Chelsea Arthur
Owner Name:	170 Grand Avenue LLC
Owner Street:	825 East 233rd Street
Owner Address2:	Not reported
Owner City:	Bronx
Owner State:	NY
Owner Zipcode:	10466
GDS Number:	Not reported
Tank Number:	1old
Status:	4. Closed - in place
Capacity:	2000
Product Stored:	Not reported
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	01/01/1900
Date Perm Closure:	03/03/2005
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	1. Aboveground
Piping Type:	0. No Pippping
Piping External Protection:	0. None
Overfill Prevention:	Not reported
Piping Secondary Containment:	Not reported
Spill Prevention:	Not reported
Dispenser:	2. Suction

WESTCHESTER CO. AST:

Name:	170 GRAND STREET ASSOC.
Address:	170 GRAND STREET
City,State,Zip:	WHITE PLAINS, NY 10601

170 GRAND STREET ASSOC. (Continued) **U004175922**

PBS Number:	3-800392
Site Status:	Active
GDS Number:	Not reported
Operator Name:	Chelsea Arthur
Owner Name:	170 Grand Avenue LLC
Owner Street:	825 East 233rd Street
Owner Address2:	Not reported
Owner City/State/Zip:	Bronx, NY 10466
Tank Number:	1
Status:	1. In-Service
Date Installation:	04/01/2005
Capacity:	2000
Product Stored:	0001. #2 Fuel Oil
Product Stored Percent:	Not reported
Date Perm Closure:	01/01/1900
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Leak Detection:	0. None,99. Other
Tank Secondary Containment:	2. Vault (w/ access)
Piping Location:	1. Aboveground
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	1. Painted/Asphalt Coating
Piping Leak Detection:	0. None
Piping Secondary Containment:	0. None
Overfill Prevention:	2. High Level Alarm
Spill Prevention:	0. None
Dispenser:	0. None

S287 **170 GRAND STREET** **NY LTANKS** **S102180212**
SE **170 GRAND STREET** **NY Spills** **N/A**
1/8-1/4 **WHITE PLAINS, NY**
0.186 mi.
982 ft. **Site 9 of 11 in cluster S**

Relative:
Higher

Actual:
235 ft.

LTANKS:

Name:	APARTMENT
Address:	170 GRAND STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0408227 / 2007-11-28
Facility ID:	0408227
Site ID:	332894
Spill Date:	2004-10-26
Spill Cause:	Tank Test Failure
Spill Source:	Private Dwelling
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	WCHD
Referred To:	WCHD
Reported to Dept:	2004-10-26
CID:	444
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False

170 GRAND STREET (Continued) **S102180212**

Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2004-10-26
Spill Record Last Update:	2007-11-28
Spiller Name:	CARDINAL TANK
Spiller Company:	APARTMENT
Spiller Address:	170 GRAND STREET
Spiller County:	001
Spiller Contact:	CARDINAL TANK
Spiller Phone:	(718) 625-4350
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	260919
Latitude:	41.0281430
Longitude:	-73.7675320
DEC Memo:	Goreau, Stefan <shg1@westchestergov.com> 11/28/2007 2:20 PM >>> Results from sidewall and bottom samples were submitted to the Dept. prior to closure in place. Results were satisfactory. Spill may be closed. Stefan Goreau Sanitarian Office of Environmental Health Risk Control Westchester County Department of Health
Remarks:	PBS No: 3-800392

All TTF:

Facility ID:	0408227
Spill Number:	0408227
Spill Tank Test:	1548281
Site ID:	332894
Tank Number:	1
Tank Size:	2000
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	21
Test Method 2:	Horner EZY3/EZY3 Locator Plus
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	JBODee
Last Modified Date:	Not reported

All Materials:

Site ID:	332894
Operable Unit ID:	1095101
Operable Unit:	01
Material ID:	575231
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	G
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

170 GRAND STREET (Continued) **S102180212**

SPILLS:

Name:	170 GRAND STREET
Address:	170 GRAND STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9509189 / 1995-10-25
Facility ID:	9509189
Facility Type:	ER
DER Facility ID:	260919
Site ID:	323874
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	E5
SWIS:	6017
Spill Date:	1995-10-25
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1995-10-25
CID:	205
Water Affected:	Not reported
Spill Source:	Private Dwelling
Spill Notifier:	Responsible Party
Cleanup Ceased:	1995-10-25
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	1995-10-25
Spill Record Last Update:	1995-11-01
Spiller Name:	Not reported
Spiller Company:	COSTAL OIL CO
Spiller Address:	Not reported
Spiller Company:	001
Contact Name:	CARLOS
Latitude:	41.0281541
Longitude:	-73.7675373
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY
Remarks:	customers guage was inaccurate.

All Materials:

Site ID:	323874
Operable Unit ID:	1019773
Operable Unit:	01
Material ID:	360149
Material Code:	0002A
Material Name:	#4 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	5.00
Units:	G
Recovered:	5.00
Resource Affected:	Soil
Oxygenate:	Not reported

X288 **WESTCHESTER ARTS COUNCIL** **NY UST** **U004442245**
East **31 MAMARONECK AVE.** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.186 mi.
984 ft. **Site 5 of 8 in cluster X**

Relative: WESTCHESTER CO. UST:
Higher

Actual: Name: WESTCHESTER ARTS COUNCIL
215 ft. Address: 31 MAMARONECK AVE.
City,State,Zip: WHITE PLAINS, NY 10601
Id/Status: 3-600118 / Unregulated: <1101 gal. PBS
Operator Name: Sandra Orsino
Owner Name: Westchester Arts Council
Owner Street: 31 Mamaroneck Avenue
Owner Address2: Not reported
Owner City: White Plains
Owner State: NY
Owner Zipcode: 10601
GDS Number: Not reported

Tank Number: 1
Status: 3. Closed - Removed
Capacity: 4000
Product Stored: Not reported
Product Stored Percent: Not reported
Tank Leak Detection: 0. None
Date Installation: Not reported
Date Perm Closure: 07/01/2004
Tank Location: 6. Underground, vaulted, with access
Tank Type: 1. Steel/Carbon steel/Iron
Tank Internal Protection: 0. None
Tank External Protection: 1. Painted/Asphalt Coating
Tank Secondary Containment: 0. None
Piping Location: 2. Underground/on ground
Piping Type: 2. Galvanized steel
Piping External Protection: 0. None
Overfill Prevention: 5. Vent Whistle
Piping Secondary Containment: Not reported
Spill Prevention: Not reported
Dispenser: 2. Suction

U289 **CON EDISON** **NJ MANIFEST** **S120665658**
ENE **MAIN ST & CHURCH ST** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.189 mi.
999 ft. **Site 12 of 15 in cluster U**

Relative: NJ MANIFEST:
Higher

Actual: EPA ID: NYP004161261
216 ft. Name: CON EDISON
Address: MAIN ST & CHURCH ST
City,State,Zip: WHITE PLAINS, NY 10601
County: Not reported
Mailing Address: 4 IRVING PL, RM 828
Mailing City,State,Zip: NEW YORK, NY 10003
Telephone: Not reported
Emergency Telephone: Not reported
Contact: DAVID DUKE
Comments: Not reported
SIC Code: Not reported

CON EDISON (Continued) **S120665658**

County:	NY119
Municipal:	Not reported
Previous EPAID:	Not reported
Generator Flag:	Not reported
Transporter Flag:	Not reported
TSDF Flag:	Not reported
Name Change:	Not reported
Date Change:	Not reported

Manifest Data:

EPA ID:	NYP004161261
Manifest Number:	015319674JJK
Date Shipped:	2/17/2016
TSDF EPA ID:	NJD002200046
Transporter EPA ID:	NYD006982359
Transporter 2 EPA ID:	Not reported
Transporter 3 EPA ID:	Not reported
Transporter 4 EPA ID:	Not reported
Transporter 5 EPA ID:	Not reported
Transporter 6 EPA ID:	Not reported
Transporter 7 EPA ID:	Not reported
Transporter 8 EPA ID:	Not reported
Transporter 9 EPA ID:	Not reported
Transporter 10 EPA ID:	Not reported
Date Trans1 Transported Waste:	Not reported
Date Trans2 Transported Waste:	Not reported
Date Trans3 Transported Waste:	Not reported
Date Trans4 Transported Waste:	Not reported
Date Trans5 Transported Waste:	Not reported
Date Trans6 Transported Waste:	Not reported
Date Trans7 Transported Waste:	Not reported
Date Trans8 Transported Waste:	Not reported
Date Trans9 Transported Waste:	Not reported
Date Trans10 Transported Waste:	Not reported
Date TSDF Received Waste:	Not reported
TSDF EPA Facility Name:	Not reported
QTY Units:	Not reported
Transporter SEQ ID:	Not reported
Transporter-1 Date:	Not reported
Waste SEQ ID:	Not reported
Waste Type Code 2:	Not reported
Waste Type Code 3:	Not reported
Waste Type Code 4:	Not reported
Waste Type Code 5:	Not reported
Waste Type Code 6:	Not reported
Date Accepted:	Not reported
Manifest Discrepancy Type:	Not reported
Data Entry Number:	Not reported
Was Load Rejected:	Not reported
Reason Load Was Rejected:	Not reported

EPA ID:	NYP004161261
Manifest Number:	015323139JJK
Date Shipped:	2/3/2016
TSDF EPA ID:	NJD002200046
Transporter EPA ID:	NYD006982359
Transporter 2 EPA ID:	Not reported
Transporter 3 EPA ID:	Not reported

CON EDISON (Continued) **S120665658**

Transporter 4 EPA ID:	Not reported
Transporter 5 EPA ID:	Not reported
Transporter 6 EPA ID:	Not reported
Transporter 7 EPA ID:	Not reported
Transporter 8 EPA ID:	Not reported
Transporter 9 EPA ID:	Not reported
Transporter 10 EPA ID:	Not reported
Date Trans1 Transported Waste:	Not reported
Date Trans2 Transported Waste:	Not reported
Date Trans3 Transported Waste:	Not reported
Date Trans4 Transported Waste:	Not reported
Date Trans5 Transported Waste:	Not reported
Date Trans6 Transported Waste:	Not reported
Date Trans7 Transported Waste:	Not reported
Date Trans8 Transported Waste:	Not reported
Date Trans9 Transported Waste:	Not reported
Date Trans10 Transported Waste:	Not reported
Date TSDF Received Waste:	Not reported
TSDF EPA Facility Name:	Not reported
QTY Units:	Not reported
Transporter SEQ ID:	Not reported
Transporter-1 Date:	Not reported
Waste SEQ ID:	Not reported
Waste Type Code 2:	Not reported
Waste Type Code 3:	Not reported
Waste Type Code 4:	Not reported
Waste Type Code 5:	Not reported
Waste Type Code 6:	Not reported
Date Accepted:	Not reported
Manifest Discrepancy Type:	Not reported
Data Entry Number:	Not reported
Was Load Rejected:	Not reported
Reason Load Was Rejected:	Not reported

U290 **CON EDISON** **RCRA NonGen / NLR** **1012185322**
ENE **MAIN ST & CHURCH ST** **NY MANIFEST** **NYP004161261**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.189 mi.
999 ft. **Site 13 of 15 in cluster U**

Relative: **Higher**
Actual: **216 ft.**

RCRA Listings:

Date Form Received by Agency:	20160601
Handler Name:	Con Edison
Handler Address:	Main St & Church St
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYP004161261
Contact Name:	DAVID DUKE
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	917-559-8971
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported

CON EDISON (Continued) **1012185322**

Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R3
Mailing Address:	4 IRVING PL, RM 828
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20161103
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:		20080918
Handler Name:	CON EDISON	
Federal Waste Generator Description:		Very Small Quantity Generator (formerly Conditionally-Exempt Small

CON EDISON (Continued) **1012185322**

Quantity Generator
State District Owner: Not reported
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20160601
Handler Name: CON EDISON
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

NY MANIFEST:
EPA ID: NYP004161261
Country: USA
Name: Consolidated Edison
Address: MAIN ST & CHURCH ST
Address 2: Not reported
City,State,Zip: WHITE PLAINS, NY 10601
Zip 4: Not reported
Location Address 1: MAIN ST & CHURCH
Location Address 2: MH1422
Location City,State,Zip: WHITE PLAINS, NY 10601
Location Zip 4: Not reported
Facility Status: Not reported
Total Tanks: Not reported
Code: BP

Mailing:
Mailing Name: Consolidated Edison
Mailing Contact: Franklyn Murray
Mailing Address 1: 4 IRVING PL RM 828
Mailing Address 2: Not reported
Mailing City,State,Zip: NEW YORK, NY 10003

CON EDISON (Continued) **1012185322**

Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: 2124602808

Manifest Data:
Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: NYD006982359
Year: 2018
Trans2 State ID: Not reported
Generator Ship Date: 09/20/2008
Trans1 Recv Date: 09/20/2008
Trans2 Recv Date: Not reported
TSD Site Recv Date: 09/22/2008
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYP004161261
Trans1 EPA ID: Not reported
Trans2 EPA ID: Not reported
TSDF ID 1: NYD077444263
TSDF ID 2: Not reported
Manifest Tracking Number: 001432820FLE
Import Indicator: N
Export Indicator: N
Discr Quantity Indicator: N
Discr Type Indicator: N
Discr Residue Indicator: N
Discr Partial Reject Indicator: N
Discr Full Reject Indicator: N
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: H141
Waste Code a: B007
Waste Code b: B002
Waste Code c: Lead
Waste Code e: Not reported
Waste Code f: Not reported
Waste Code g: Not reported
Waste Code 1: Not reported
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 100
Units: Kilograms
Number of Containers: 1
Container Type: Metal drums, barrels, kegs
Handling Method: Burn
Specific Gravity: 1

S291 **177 GRAND STREET ASSOC LLC** **RCRA NonGen / NLR** **1001233223**
SE **177 GRAND ST** **FINDS** **NYR000063727**
1/8-1/4 **WHITE PLAINS, NY 10601** **ECHO**
0.189 mi. **NY MANIFEST**
999 ft. **Site 10 of 11 in cluster S**

Relative: **Higher**
Actual: **237 ft.**

RCRA Listings:

Date Form Received by Agency:	20070101
Handler Name:	177 Grand Street Assoc Llc
Handler Address:	Grand St
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYR000063727
Contact Name:	EDMOND DELAURENTIS
Contact Address:	PO BOX 310
Contact City,State,Zip:	WHITE PLAINS, NY 10605
Contact Telephone:	914-946-1321
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Not reported
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R3
Mailing Address:	PO BOX 310
Mailing City,State,Zip:	WHITE PLAINS, NY 10605
Owner Name:	177 Grand Street Assoc
Owner Type:	Private
Operator Name:	177 Grand Street Assoc
Operator Type:	Private
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No

177 GRAND STREET ASSOC LLC (Continued) **1001233223**

Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20150414
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Hazardous Waste Summary:

Waste Code:	D001
Waste Description:	Ignitable Waste
Waste Code:	D002
Waste Description:	Corrosive Waste

Handler - Owner Operator:

Owner/Operator Indicator:	Operator
Owner/Operator Name: 177 GRAND STREET ASSOC	
Legal Status:	Private
Date Became Current:	Not reported
Date Ended Current:	Not reported
Owner/Operator Address:	PO BOX 310
Owner/Operator City,State,Zip:	WHITE PLAINS, NY 10605
Owner/Operator Telephone:	914-946-1321
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported
Owner/Operator Email:	Not reported
Owner/Operator Indicator:	Owner
Owner/Operator Name: 177 GRAND STREET ASSOC	
Legal Status:	Private
Date Became Current:	Not reported
Date Ended Current:	Not reported
Owner/Operator Address:	PO BOX 310
Owner/Operator City,State,Zip:	WHITE PLAINS, NY 10605
Owner/Operator Telephone:	914-946-1321
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported
Owner/Operator Email:	Not reported
Owner/Operator Indicator:	Owner
Owner/Operator Name: 177 GRAND STREET ASSOC	
Legal Status:	Private
Date Became Current:	Not reported
Date Ended Current:	Not reported
Owner/Operator Address:	PO BOX 310
Owner/Operator City,State,Zip:	WHITE PLAINS, NY 10605

177 GRAND STREET ASSOC LLC (Continued) **1001233223**

Owner/Operator Telephone: 914-946-1321
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Historic Generators:
Receive Date: 20060101
Handler Name: 177 GRAND STREET ASSOC LLC
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20070101
Handler Name: 177 GRAND STREET ASSOC LLC
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 19981123
Handler Name: 177 GRAND STREET ASSOC LLC
Federal Waste Generator Description: Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

177 GRAND STREET ASSOC LLC (Continued) **1001233223**

FINDS:
Registry ID: 110004548927

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:
The Resource Conservation and Recovery Act Information System (RCRAInfo) is EPA's comprehensive information system in support of the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. It tracks many types of information about generators, transporters, treaters, storers, and disposers of hazardous waste.

Click this hyperlink while viewing on your computer to access additional FINDS: detail in the EDR Site Report.

ECHO:
Envid: 1001233223
Registry ID: 110004548927

DFR URL:
Name: 177 GRAND STREET ASSOC LLC
Address: 177 GRAND ST
City,State,Zip: WHITE PLAINS, NY 10601

NY MANIFEST:
EPA ID: NYR000063727
Country: USA
Name: West Chester Hobbie
Address: 177 GRAND ST
Address 2: Not reported
City,State,Zip: WHITE PLAINS, NY 10601
Zip 4: Not reported
Location Address 1: 177 GRAND ST
Location Address 2: Not reported
Location City,State,Zip: WHITE PLAINS, NY 10605
Location Zip 4: Not reported
Facility Status: Not reported
Total Tanks: Not reported
Code: BP

Mailing:
Mailing Name: West Chester Hobbie
Mailing Contact: Margaret Hoffman
Mailing Address 1: 177 GRAND ST
Mailing Address 2: Not reported
Mailing City,State,Zip: WHITE PLAINS, NY 10605
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: 9146828236

Manifest Data:
Document ID: PAG0327353
Manifest Status: Not reported
Trans1 State ID: PAAH0146
Year: 1998
Trans2 State ID: Not reported

177 GRAND STREET ASSOC LLC (Continued) **1001233223**

Generator Ship Date:	12/01/1998
Trans1 Recv Date:	12/01/1998
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	12/02/1998
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000063727
Trans1 EPA ID:	PAD067098822
Trans2 EPA ID:	Not reported
TSDF ID 1:	PAD067098822
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	The Following Spent Nonhalogenated Solvents: Xylene, Acetone, Ethyl Acetate, Ethyl Benzene, Ethyl Ether, Methyl Isobutyl Ketone, N-Butyl Alcohol, Cyclohexanone, And Methanol; All Spent Solvent Mixtures/Blends Containing, Before Use, Only The Above Spent Nonhalogenated Solvents; And All Spent Solvent Mixtures/Blends Containing, Before Use, One Or More Of The Above Nonhalogenated Solvents, And A Total Of Ten Percent Or More (By Volume) Of One Or More Of Those Solvents Listed In F001, F002, F004, And F005; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent Mixtures.
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00055
Units:	Gallons (liquids only)
Number of Containers:	001
Container Type:	Metal drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00
Waste Code 7:	Ignitable Waste
Waste Code 8:	Not reported
Waste Code:	Not reported
Waste Code 10:	Not reported
Waste Code 11:	Not reported
Quantity:	00055
Units:	Gallons (liquids only)
Number of Containers:	001
Container Type:	Metal drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00

S292 **177 GRAND PARTNERS, LLC,LLC C/O DELAURENT** **NY UST** **U003994240**
SE **177 GRAND STREET** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.189 mi.
999 ft. **Site 11 of 11 in cluster S**

Relative: **Higher**
Actual: **237 ft.**

WESTCHESTER CO. UST:

Name:	177 GRAND PARTNERS, LLC,LLC C/O DELAURENT
Address:	177 GRAND STREET
City,State,Zip:	WHITE PLAINS, NY 10601
Id/Status:	3-049816 / Active
Operator Name:	OFFICE
Owner Name:	177 Grand St Partners LLC.
Owner Street:	384 Mamaroneck Avenue
Owner Address2:	Not reported
Owner City:	White Plains
Owner State:	NY
Owner Zipcode:	10605
GDS Number:	Not reported
Tank Number:	177
Status:	1. In-Service
Capacity:	2000
Product Stored:	0001. #2 Fuel Oil
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	01/01/1950
Date Perm Closure:	01/01/1900
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Secondary Containment:	0. None
Piping Location:	3. Aboveground/Underground Combination
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	1. Painted/Asphalt Coating
Overfill Prevention:	0. None
Piping Secondary Containment:	0. None
Spill Prevention:	0. None
Dispenser:	2. Suction

AD293 **MARRIOT INN** **NY LTANKS** **S106972718**
NNE **5 BARKER AVE** **N/A**
1/8-1/4 **WHITE PLAINS, NY**
0.189 mi.
999 ft. **Site 1 of 7 in cluster AD**

Relative: **Lower**
Actual: **193 ft.**

LTANKS:

Name:	MARIOTT RESIDENCE INN
Address:	5 BARKER AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0503865 / 2005-10-28
Facility ID:	0503865
Site ID:	348566
Spill Date:	2005-06-30
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6017

MARRIOT INN (Continued) **S106972718**

Investigator:	TDGHIOSA
Referred To:	Not reported
Reported to Dept:	2005-06-30
CID:	409
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	True
Remediation Phase:	0
Date Entered In Computer:	2005-06-30
Spill Record Last Update:	2005-10-28
Spiller Name:	PHIL DANIEL
Spiller Company:	MARIOTT RESIDENT HOTELS
Spiller Address:	5 BARKER AVE
Spiller County:	001
Spiller Contact:	PHIL DANIEL
Spiller Phone:	(301) 657-2130
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	294998
Latitude:	41.0348220
Longitude:	-73.7697950
DEC Memo:	06/30/05: Hole found in top of tank. UST was at grad level not undersoil. Castlton will remove UST. 8/22/05 UST Removal report submitted by National Environmental Specialists. One 550 gallon tank was excavated and removed along with 30.30 tons of impacted soil. NFA TG
Remarks:	TANK TEST FAILURE AND THEN A SOIL TEST FAILURE. SOIL IS GOING OUT FOR ANALYSIS FIRST. BUILDING DEPT. INSPECTOR WAS THERE FROM THE CITY. ARRANGEMENTS ARE BEING MADE FOR CLEAN UP.

All TTF:

Facility ID:	0503865
Spill Number:	0503865
Spill Tank Test:	1549038
Site ID:	348566
Tank Number:	1
Tank Size:	550
Material:	0008
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	18
Test Method 2:	Alert Model 1000 plus 1050 (Formerly Gilbarco Precision)
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Watchdog
Last Modified Date:	Not reported

All Materials:

Site ID:	348566
Operable Unit ID:	1106217
Operable Unit:	01
Material ID:	1971137

MARRIOT INN (Continued) **S106972718**

Material Code:	0008
Material Name:	diesel
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	MARRIOT INN
Address:	5 BARKER AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	1303150 / 2014-02-28
Facility ID:	1303150
Site ID:	483619
Spill Date:	2013-06-24
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	D4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	RDBENDEL
Referred To:	Not reported
Reported to Dept:	2013-06-24
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2013-06-24
Spill Record Last Update:	2014-02-28
Spiller Name:	NELSON SELIMOV
Spiller Company:	Marriot Residence Inn
Spiller Address:	5 BARKER AVE
Spiller County:	999
Spiller Contact:	NELSON SELIMOV
Spiller Phone:	(914) 761-7700
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	294998
Latitude:	41.0352916
Longitude:	-73.7699586
DEC Memo:	6/24/13 - Being handled by the Westchester County DOH, according to email: From: Lalak, Chris To: Schneider, Wayne CC: Daniel Bendell , kabrowne@gw.dec.state.ny.... Date: 6/24/2013 12:35 PM Subject: FW: Spill : 1303150 WC PBS Wayne TTF Wayne, Please handle this TTF. It is an unregistered PBS site. It is the Residence Inn, No Tix's if they register promptly. The tank is a 550 UST Diesel tank for a generator. The tested thinks it is just an air leak. It is unknown if other tanks are present. Thank You Chris Christopher J. Lalak MS Radiological and Chemical Analyst Westchester County Department of Health 145 Huguenot Street - 7th Floor New Rochelle, NY 10801

MARRIOT INN (Continued) **S106972718**

Remarks: CJL1@westchestergov.com (914) 224-7649 02-26-14 edoc retest, NFA RDB Failed test for diesel generator UST. Repair and retest is being planned.

All TTF:

Facility ID:	1303150
Spill Number:	1303150
Spill Tank Test:	2493627
Site ID:	483619
Tank Number:	G
Tank Size:	550
Material:	0008
EPA UST:	True
UST:	True
Cause:	00
Source:	01
Test Method:	21
Test Method 2:	Horner EZY3/EZY3 Locator Plus
Leak Rate:	.99
Gross Fail:	Not reported
Modified By:	JBODEE
Last Modified Date:	Not reported

All Materials:

Site ID:	483619
Operable Unit ID:	1233321
Operable Unit:	01
Material ID:	2232214
Material Code:	0008
Material Name:	diesel
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported
Resource Affected:	Not reported
Oxygenate:	Not reported

AD294 **RESIDENCE INN - TTF** **NY LTANKS** **S117853873**
NNE **5 BARKER AVE** **N/A**
1/8-1/4 **WHITE PLAINS, NY**
0.189 mi.
999 ft. **Site 2 of 7 in cluster AD**

Relative: **Lower**
Actual: **193 ft.**

LTANKS:

Name:	RESIDENCE INN - TTF
Address:	5 BARKER AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	1501552 / 2015-07-20
Facility ID:	1501552
Site ID:	507776
Spill Date:	2015-05-12
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6017

RESIDENCE INN - TTF (Continued) **S117853873**

Investigator:	TDGHIOSA
Referred To:	Not reported
Reported to Dept:	2015-05-12
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2015-05-12
Spill Record Last Update:	2015-07-20
Spiller Name:	GREG RICCALDO
Spiller Company:	RESIDENCE INN
Spiller Address:	5 ARKER AVE
Spiller County:	999
Spiller Contact:	GREG RICCALDO
Spiller Phone:	(914) 761-7700
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	294998
Latitude:	Not reported
Longitude:	Not reported
DEC Memo:	5/12/15 Spoke to tank tester, who said a retest will be done after repairing the tank connections. According to Chris Lalak of WCHD, 550 UST at facility needs to be registered as PBS. dw 07/20/15 Wayne Schneider from the WCHD reported, TTF. tank passed retest 3 days later after a tank top connection was replaced. NFA. TG
Remarks:	dry leak, retest pending

All Materials:

Site ID:	507776
Operable Unit ID:	1257101
Operable Unit:	01
Material ID:	2260075
Material Code:	0008
Material Name:	diesel
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported
Resource Affected:	Not reported
Oxygenate:	Not reported

AD295 **MARIOTT RESIDENCE INN** **UST FINDER RELEASE** **1029072430**
NNE **5 BARKER AVE** **N/A**
1/8-1/4 **WHITE PLAINS, NY 0**
0.189 mi.
999 ft. **Site 3 of 7 in cluster AD**

Relative:
Lower

Actual:
193 ft.

UST FINDER RELEASE:

Object ID:	262404
Facility ID:	NY294998
Lust ID:	NY503865
Name:	MARIOTT RESIDENCE INN

MARIOTT RESIDENCE INN (Continued) **1029072430**

Address:	5 BARKER AVE
City,State,Zip:	WHITE PLAINS, NY 0
Address Match Type:	Not reported
Reported Date:	2005/06/30 15:59:59+00
Status:	No Further Action
Substance:	Not reported
Population within 1500ft:	3562
Domestic Wells within 1500ft:	0
Land Use:	Developed, High Intensity
Within SPA:	Yes
SPA PWS Facility ID:	NY7003493_76968
SPA Water Type:	SW - SurRELEASEe Water
SPA Facility Type:	RS - Reservoir
SPA HUC12:	20301020103
Within WHPA:	No
WHPA PWS Facility ID:	Not reported
WHPA Water Type:	Not reported
WHPA Facility Type:	Not reported
WHPA HUC12:	Not reported
Within 100yr Floodplain:	No
Tribe:	Not reported
EPA Region:	2
NFA Letter 1:	Not reported
NFA Letter 2:	Not reported
NFA Letter 3:	Not reported
NFA Letter 4:	Not reported
Closed With Residual Contaminate:	Not reported
Coordinate Source:	State
X Coord:	-73.7698
Y Coord:	41.03482
Latitude:	41.03482
Longitude:	-73.7698

X296 **76 MAMARONECK AVENUE, LLC** **NY UST** **U004439278**
ESE **76 MAMARONECK AVENUE** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.189 mi.
1000 ft. **Site 6 of 8 in cluster X**

Relative: WESTCHESTER CO. UST:
Higher

Name:	76 MAMARONECK AVENUE, LLC
Address:	76 MAMARONECK AVENUE
City,State,Zip:	WHITE PLAINS, NY 10601
Id/Status:	3-074659 / Unregulated
Operator Name:	Jim Schneider
Owner Name:	76 Mamaroneck Avenue, LLC
Owner Street:	237 Mamaroneck Avenue
Owner Address2:	Not reported
Owner City:	White Plains
Owner State:	NY
Owner Zipcode:	10605
GDS Number:	Not reported
Tank Number:	1
Status:	4. Closed - in place
Capacity:	2000
Product Stored:	Not reported
Product Stored Percent:	Not reported

Actual:
217 ft.

76 MAMARONECK AVENUE, LLC (Continued) **U004439278**

Tank Leak Detection:	0. None
Date Installation:	12/01/1956
Date Perm Closure:	07/01/1990
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Secondary Containment:	0. None
Piping Location:	2. Underground/on ground
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Overfill Prevention:	0. None
Piping Secondary Containment:	Not reported
Spill Prevention:	0. None
Dispenser:	2. Suction

Tank Number:	2
Status:	3. Closed - Removed
Capacity:	1500
Product Stored:	0001. #2 Fuel Oil
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	09/01/1990
Date Perm Closure:	01/15/2013
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	1. Epoxy liner
Tank External Protection:	2. Original sacrificial anode
Tank Secondary Containment:	4. Double-Walled (underground only)
Piping Location:	2. Underground/on Ground
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	0. None
Overfill Prevention:	5. Vent Whistle
Piping Secondary Containment:	0. None
Spill Prevention:	0. None
Dispenser:	2. Suction

U297 **RENAISSANCE CORPORATE CENTER** **NY UST** **U004359606**
ENE **235 MAIN STREET** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.190 mi.
1001 ft. **Site 14 of 15 in cluster U**

Relative: **Higher**
Actual: **216 ft.**

WESTCHESTER CO. UST:

Name:	RENAISSANCE CORPORATE CENTER
Address:	235 MAIN STREET
City,State,Zip:	WHITE PLAINS, NY 10601
Id/Status:	3-049980 / Active
Operator Name:	Johnny (superintendent)
Owner Name:	235-245 Delaware Realty Associates LLC
Owner Street:	120 Bloomingdale Road
Owner Address2:	Suite 105
Owner City:	White Plains
Owner State:	NY
Owner Zipcode:	10605
GDS Number:	Not reported

RENAISSANCE CORPORATE CENTER (Continued) **U004359606**

Tank Number:	02
Status:	4. Closed - in place
Capacity:	5000
Product Stored:	0001. #2 Fuel Oil
Product Stored Percent:	Not reported
Tank Leak Detection:	Not reported
Date Installation:	01/01/1970
Date Perm Closure:	01/12/2022
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	Not reported
Tank External Protection:	Not reported
Tank Secondary Containment:	Not reported
Piping Location:	Not reported
Piping Type:	Not reported
Piping External Protection:	Not reported
Overfill Prevention:	Not reported
Piping Secondary Containment:	Not reported
Spill Prevention:	Not reported
Dispenser:	Not reported

U298 **RENAISSANCE CORPORATE CENTER** **NY AST** **A100355605**
ENE **235 MAIN STREET** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.190 mi.
1001 ft. **Site 15 of 15 in cluster U**

Relative:
Higher

Actual:
216 ft.

WESTCHESTER CO. AST:

Name:	RENAISSANCE CORPORATE CENTER
Address:	235 MAIN STREET
City,State,Zip:	WHITE PLAINS, NY 10601
PBS Number:	3-049980
Site Status:	Active
GDS Number:	Not reported
Operator Name:	Johnny (superintendent)
Owner Name:	235-245 Delaware Realty Associates LLC
Owner Street:	120 Bloomingdale Road
Owner Address2:	Suite 105
Owner City/State/Zip:	White Plains, NY 10605
Tank Number:	1
Status:	1. In-Service
Date Installation:	12/01/1974
Capacity:	10000
Product Stored:	0001. #2 Fuel Oil
Product Stored Percent:	Not reported
Date Perm Closure:	01/01/1900
Tank Location:	6. Aboveground in subterranean vault with access for inspections
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Leak Detection:	0. None
Tank Secondary Containment:	2. Vault (w/ access)
Piping Location:	2. Underground/on Ground
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	1. Painted/Asphalt Coating
Piping Leak Detection:	0. None
Piping Secondary Containment:	0. None

RENAISSANCE CORPORATE CENTER (Continued) **A100355605**

Overfill Prevention: 4. Product Level Gauge (Aboveground Only)
Spill Prevention: 0. None
Dispenser: 3. Gravity

AE299 **SLADER NEIGHBORHOOD CNTR** **NY LTANKS** **S103558463**
SSE **2 FISHER CT** **N/A**
1/8-1/4 **WHITE PLAINS, NY**
0.195 mi.
1030 ft. **Site 1 of 6 in cluster AE**

Relative:
Higher

Actual:
208 ft.

LTANKS:

Name:	SLADER NEIGHBORHOOD CNTR
Address:	2 FISHER CT
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9810451 / 2003-12-05
Facility ID:	9810451
Site ID:	214463
Spill Date:	1998-11-18
Spill Cause:	Tank Failure
Spill Source:	Institutional, Educational, Gov., Other
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	WCHD
Referred To:	Westchester Cnty Health Dept
Reported to Dept:	1998-11-18
CID:	257
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1998-11-18
Spill Record Last Update:	2003-12-05
Spiller Name:	MARK
Spiller Company:	SLADER NEIGHBORHOOD CNTR
Spiller Address:	2 FISHER CT
Spiller County:	001
Spiller Contact:	MARK
Spiller Phone:	(914) 328-6549
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	177699
Latitude:	41.0286089
Longitude:	-73.7687897
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was WCHD - GOREAU 12/05/03 CLOSED BY STEFAN GOREAU OF WCHD. TANK AND SOIL REMOVED BY ROYAL ENVIRO.
Remarks:	During tank removal caller found contaminated soil from a hole in tank. 12/11/98 Awaiting closure report.

All Materials:

Site ID:	214463
Operable Unit ID:	1071357
Operable Unit:	01
Material ID:	314318

SLADER NEIGHBORHOOD CNTR (Continued) **S103558463**

Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

AE300 **SLATER NEIGHBORHOOD CTR** **NY UST** **U004370007**
SSE **2 FISHER COURT** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.195 mi.
1030 ft. **Site 2 of 6 in cluster AE**

Relative: **Higher**
Actual: **208 ft.**

WESTCHESTER CO. UST:

Name:	SLATER NEIGHBORHOOD CTR
Address:	2 FISHER COURT
City,State,Zip:	WHITE PLAINS, NY 10601
Id/Status:	3-169560 / Unregulated: <1101 gal. PBS
Operator Name:	City Of White Plains
Owner Name:	City Of White Plains
Owner Street:	255 Main St
Owner Address2:	Not reported
Owner City:	White Plains
Owner State:	NY
Owner Zipcode:	10601
GDS Number:	Not reported
Tank Number:	26
Status:	3. Closed - Removed
Capacity:	2000
Product Stored:	Not reported
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	12/01/1979
Date Perm Closure:	12/01/1998
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	2. Underground/on ground
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Overfill Prevention:	0. None
Piping Secondary Containment:	Not reported
Spill Prevention:	0. None
Dispenser:	2. Suction

X301 **47 MAMARONECK AVENUE CORP.** **NY UST** **U004439233**
East **47 MAMARONECK AVENUE** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.195 mi.
1032 ft. **Site 7 of 8 in cluster X**

Relative: **Higher**
Actual: **216 ft.**

WESTCHESTER CO. UST:

Name:	47 MAMARONECK AVENUE CORP.
Address:	47 MAMARONECK AVENUE
City,State,Zip:	WHITE PLAINS, NY 10601
Id/Status:	3-030929 / Unregulated
Operator Name:	Not reported
Owner Name:	47 Mamaroneck Avenue Corp.
Owner Street:	47 Mamaroneck Avenue
Owner Address2:	Not reported
Owner City:	White Plains
Owner State:	NY
Owner Zipcode:	10601
GDS Number:	Not reported
Tank Number:	1
Status:	4. Closed - in place
Capacity:	2000
Product Stored:	0001. #2 Fuel Oil
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	12/01/1977
Date Perm Closure:	08/23/2012
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	2. Underground/on ground
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Overfill Prevention:	Not reported
Piping Secondary Containment:	Not reported
Spill Prevention:	Not reported
Dispenser:	2. Suction

AF302 **CON EDISON** **NY MANIFEST** **S116042137**
NW **WATER ST & FERRIS AVE** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10701**
0.197 mi.
1042 ft. **Site 1 of 3 in cluster AF**

Relative: **Lower**
Actual: **184 ft.**

NY MANIFEST:

EPA ID:	NYP004384582
Country:	USA
Name:	Con Edison
Address:	WATER ST & FERRIS AVE
Address 2:	SB10716
City,State,Zip:	WHITE PLAINS, NY 10701
Zip 4:	Not reported
Location Address 1:	WATER ST & FERRIS AVE
Location Address 2:	SB10716
Location City,State,Zip:	WHITE PLAINS, NY 10701
Location Zip 4:	Not reported
Facility Status:	Not reported

CON EDISON (Continued) **S116042137**

Total Tanks: Not reported
Code: BP

Mailing:
Mailing Name: Con Edison
Mailing Contact: Con Edison
Mailing Address 1: 4 IRVING PLACE
Mailing Address 2: 15TH FL
Mailing City,State,Zip: NEW YORK, NY 10003
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: Not reported

Manifest Data:
Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: NYD006982359
Year: 2018
Trans2 State ID: Not reported
Generator Ship Date: 11/03/2013
Trans1 Recv Date: 11/03/2013
Trans2 Recv Date: Not reported
TSD Site Recv Date: 11/12/2013
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYP004384582
Trans1 EPA ID: Not reported
Trans2 EPA ID: Not reported
TSDF ID 1: NJD002200046
TSDF ID 2: Not reported
Manifest Tracking Number: 011695089JJK
Import Indicator: N
Export Indicator: N
Discr Quantity Indicator: N
Discr Type Indicator: N
Discr Residue Indicator: N
Discr Partial Reject Indicator: N
Discr Full Reject Indicator: N
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: H110
Waste Code a: Lead
Waste Code b: Not reported
Waste Code c: Not reported
Waste Code e: Not reported
Waste Code f: Not reported
Waste Code g: Not reported
Waste Code 1: Not reported
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 40
Units: Pounds
Number of Containers: 1

CON EDISON (Continued) **S116042137**

Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

AF303 **CON EDISON MANHOLE: 10716** **RCRA NonGen / NLR** **1016965371**
NW **WATER ST & FERRIS AVE** **NY MANIFEST** **NYP004382602**
1/8-1/4 **WHITE PLAINS, NY 10607**
0.197 mi.
1042 ft. **Site 2 of 3 in cluster AF**

Relative: **Lower**
Actual: **184 ft.**

RCRA Listings:

Date Form Received by Agency:	20131130
Handler Name:	Con Edison Manhole: 10716
Handler Address:	Water St & Ferris Ave
Handler City,State,Zip:	WHITE PLAINS, NY 10607
EPA ID:	NYP004382602
Contact Name:	THOMAS TEELING
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	212-460-3770
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	SENIOR SCIENTIST
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PL, 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline

CON EDISON MANHOLE: 10716 (Continued) **1016965371**

202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20140701
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20131030
Handler Name: CON EDISON MANHOLE: 10716	
Federal Waste Generator Description:	Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20131130
Handler Name: CON EDISON MANHOLE: 10716	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

List of NAICS Codes and Descriptions:

NAICS Codes:	No NAICS Codes Found

Facility Has Received Notices of Violations:

Violations:	No Violations Found

CON EDISON MANHOLE: 10716 (Continued) **1016965371**

Evaluation Action Summary:
Evaluations: No Evaluations Found

NY MANIFEST:

EPA ID:	NYP004382602
Country:	USA
Name:	Con Edison
Address:	WATER ST & FERRIS AVE
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10607
Zip 4:	Not reported
Location Address 1:	WATER ST E/O FERRIS AVE
Location Address 2:	MH10716
Location City,State,Zip:	WHITE PLAINS, NY 11434
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Edison
Mailing Contact:	Con Edison
Mailing Address 1:	4 IRVING PLACE
Mailing Address 2:	15TH FL
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	Not reported

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	10/30/2013
Trans1 Recv Date:	10/30/2013
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	11/01/2013
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004382602
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	011694000JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported

CON EDISON MANHOLE: 10716 (Continued) **1016965371**

Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	45
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

AD304 **CON EDISON MANHOLE: 8810** **RCRA NonGen / NLR** **1016968437**
NNE **BARKER ST & COTTAGE PL** **NY MANIFEST** **NYP004420485**
1/8-1/4 **WHITE PLAINS, NY 10607**
0.198 mi.
1044 ft. **Site 4 of 7 in cluster AD**

Relative: **Higher**
Actual: **197 ft.**

RCRA Listings:

Date Form Received by Agency:	20140216
Handler Name:	Con Edison Manhole: 8810
Handler Address:	Barker St & Cottage Pl
Handler City,State,Zip:	WHITE PLAINS, NY 10607
EPA ID:	NYP004420485
Contact Name:	THOMAS TEELING
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	212-460-3770
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	SENIOR SCIENTIST
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PL, 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No

CON EDISON MANHOLE: 8810 (Continued) **1016968437**

Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20141014
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20140116
Handler Name: CON EDISON MANHOLE: 8810	
Federal Waste Generator Description:	Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20140216

CON EDISON MANHOLE: 8810 (Continued) **1016968437**

Handler Name: CON EDISON MANHOLE: 8810
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

NY MANIFEST:
EPA ID: NYP004420485
Country: USA
Name: Con Edison
Address: BARKER ST & COTTAGE PL
Address 2: Not reported
City,State,Zip: WHITE PLAINS, NY 10607
Zip 4: Not reported
Location Address 1: BARKER/COTTAGE
Location Address 2: Not reported
Location City,State,Zip: WHITE PLAINS, NY 10601
Location Zip 4: Not reported
Facility Status: Not reported
Total Tanks: Not reported
Code: BP

Mailing:
Mailing Name: Con Edison
Mailing Contact: Con Edison
Mailing Address 1: 4 IRVING PLACE
Mailing Address 2: 15TH FL
Mailing City,State,Zip: NEW YORK, NY 10003
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: Not reported

Manifest Data:
Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: NYD006982359
Year: 2018
Trans2 State ID: Not reported
Generator Ship Date: 01/16/2014

CON EDISON MANHOLE: 8810 (Continued) **1016968437**

Trans1 Recv Date:	01/16/2014
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	01/20/2014
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004420485
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	011696164JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	20
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

AD305 **CON EDISON** **RCRA-VSQG** **1031076048**
NNE **COTTAGE PL & BARKER AVE** **NYP005249790**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.198 mi.
1044 ft. **Site 5 of 7 in cluster AD**

Relative:
Higher

Actual:
197 ft.

RCRA Listings:

Date Form Received by Agency:	20240328
Handler Name:	Con Edison
Handler Address:	Cottage Pl & Barker Ave
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYP005249790
Contact Name:	NICHOLAS DIROMA
Contact Address:	IRVING PL, 15TH FL NE
Contact City,State,Zip:	NEW YORK, NY 10003
Contact Telephone:	212-460-4005

CON EDISON (Continued) **1031076048**

Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	SCIENTIST
EPA Region:	02
Land Type:	Not reported
Federal Waste Generator Description:	Conditionally Exempt Small Quantity Generator
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Handler Activities
State District Owner:	Ny
State District:	NYSDEC R3
Mailing Address:	IRVING PL, 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	Yes
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20240408
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No

CON EDISON (Continued) **1031076048**

Sub-Part P Indicator: No

Historic Generators:
Receive Date: 20240328
Handler Name: CON EDISON
Federal Waste Generator Description: Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: No
Electronic Manifest Broker: No

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

AD306 **CON EDISON** **RCRA NonGen / NLR** **1017771609**
NNE **COTTAGE PL & BARKER AVE** **FINDS** **NYP004485504**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.198 mi.
1044 ft. **Site 6 of 7 in cluster AD**

Relative: Higher
Actual: 197 ft.

RCRA Listings:
Date Form Received by Agency: 20140501
Handler Name: Con Edison Vault: 5215
Handler Address: Cottage Pl & Barker Ave
Handler City,State,Zip: WHITE PLAINS, NY 10602
EPA ID: NYP004485504
Contact Name: THOMAS TEELING
Contact Address: Not reported
Contact City,State,Zip: Not reported
Contact Telephone: 212-460-3770
Contact Fax: Not reported
Contact Email: Not reported
Contact Title: SENIOR SCIENTIST
EPA Region: 02
Land Type: Private
Federal Waste Generator Description: Not a generator, verified
Non-Notifier: Not reported
Biennial Report Cycle: Not reported
Accessibility: Not reported
Active Site Indicator: Not reported
State District Owner: Ny
State District: NYSDEC R2

CON EDISON (Continued) **1017771609**

Mailing Address:	IRVING PL, 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20150211
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20140401
Handler Name: CON EDISON	
Federal Waste Generator Description:	Large Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No

CON EDISON (Continued) **1017771609**

Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20140401
Handler Name: CON EDISON
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20140501
Handler Name: CON EDISON VAULT: 5215
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

FINDS:
Registry ID: 110063786737

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:
The Resource Conservation and Recovery Act Information System (RCRAInfo) is EPA's comprehensive information system in support of the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. It tracks many types of information about generators, transporters, treaters, storers, and disposers of hazardous waste.

Click this hyperlink while viewing on your computer to access additional FINDS: detail in the EDR Site Report.

AD307 **CON EDISON** **NY MANIFEST** **S116550253**
NNE **COTTAGE PL & BARKER AVE** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10602**
0.198 mi.
1044 ft. **Site 7 of 7 in cluster AD**

Relative:
Higher

Actual:
197 ft.

NY MANIFEST:

EPA ID:	NYP004485504
Country:	USA
Name:	Con Edison
Address:	COTTAGE PL & BARKER AVE
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10602
Zip 4:	Not reported
Location Address 1:	COTTAGE PLW
Location Address 2:	SB5215
Location City,State,Zip:	WHITE PLAINS, NY 10801
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Edison
Mailing Contact:	Con Edison
Mailing Address 1:	4 IRVING PL
Mailing Address 2:	15TH FL
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	Not reported

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	04/01/2014
Trans1 Recv Date:	04/01/2014
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	04/08/2014
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004485504
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	011693260JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported

CON EDISON (Continued) **S116550253**

Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	400
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

AE308 **CON EDISON** **NJ MANIFEST** **S120675553**
SSE **GROVE ST & FISCHER COURT** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.199 mi.
1051 ft. **Site 3 of 6 in cluster AE**

Relative:
Higher

Actual:
210 ft.

NJ MANIFEST:

EPA ID:	NYP004825978
Name:	CON EDISON
Address:	GROVE ST & FISCHER COURT
City,State,Zip:	WHITE PLAINS, NY 10601
County:	Not reported
Mailing Address:	IRVING PL 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Telephone:	Not reported
Emergency Telephone:	Not reported
Contact:	THOMAS TEELING
Comments:	Not reported
SIC Code:	Not reported
County:	NY119
Municipal:	Not reported
Previous EPAID:	Not reported
Generator Flag:	Not reported
Transporter Flag:	Not reported
TSDF Flag:	Not reported
Name Change:	Not reported
Date Change:	Not reported

Manifest Data:

EPA ID:	NYP004825978
Manifest Number:	014472095JJK
Date Shipped:	8/19/2015
TSDF EPA ID:	NJD002200046
Transporter EPA ID:	NYD006982359
Transporter 2 EPA ID:	Not reported
Transporter 3 EPA ID:	Not reported

CON EDISON (Continued) **S120675553**

Transporter 4 EPA ID:	Not reported
Transporter 5 EPA ID:	Not reported
Transporter 6 EPA ID:	Not reported
Transporter 7 EPA ID:	Not reported
Transporter 8 EPA ID:	Not reported
Transporter 9 EPA ID:	Not reported
Transporter 10 EPA ID:	Not reported
Date Trans1 Transported Waste:	Not reported
Date Trans2 Transported Waste:	Not reported
Date Trans3 Transported Waste:	Not reported
Date Trans4 Transported Waste:	Not reported
Date Trans5 Transported Waste:	Not reported
Date Trans6 Transported Waste:	Not reported
Date Trans7 Transported Waste:	Not reported
Date Trans8 Transported Waste:	Not reported
Date Trans9 Transported Waste:	Not reported
Date Trans10 Transported Waste:	Not reported
Date TSDF Received Waste:	Not reported
TSDF EPA Facility Name:	Not reported
QTY Units:	Not reported
Transporter SEQ ID:	Not reported
Transporter-1 Date:	Not reported
Waste SEQ ID:	Not reported
Waste Type Code 2:	Not reported
Waste Type Code 3:	Not reported
Waste Type Code 4:	Not reported
Waste Type Code 5:	Not reported
Waste Type Code 6:	Not reported
Date Accepted:	Not reported
Manifest Discrepancy Type:	Not reported
Data Entry Number:	Not reported
Was Load Rejected:	Not reported
Reason Load Was Rejected:	Not reported

AE309 **CONSOLIDATED EDISON** **NY MANIFEST** **S110823865**
SSE **GROVE & FISHER** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10602**
0.199 mi.
1051 ft. **Site 4 of 6 in cluster AE**

Relative: **Higher**

Actual: **210 ft.**

NY MANIFEST:

EPA ID:	NYP004228116
Country:	USA
Name:	Consolidated Edison
Address:	GROVE & FISHER
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10602
Zip 4:	Not reported
Location Address 1:	GROVE & FISHER
Location Address 2:	Not reported
Location City,State,Zip:	WHITE PLAINS, NY 10602
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

CONSOLIDATED EDISON (Continued) **S110823865**

Mailing Name: Consolidated Edison
Mailing Contact: Tom Teeling
Mailing Address 1: 4 IRVING PLACE RM 828
Mailing Address 2: Not reported
Mailing City,State,Zip: NEW YORK, NY 10003
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: 2124603770

Manifest Data:
Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: NYD006982359
Year: 2018
Trans2 State ID: Not reported
Generator Ship Date: 02/17/2011
Trans1 Recv Date: 02/17/2011
Trans2 Recv Date: Not reported
TSD Site Recv Date: 02/24/2011
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYP004228116
Trans1 EPA ID: Not reported
Trans2 EPA ID: Not reported
TSDF ID 1: NJD002200046
TSDF ID 2: Not reported
Manifest Tracking Number: 007660025JJK
Import Indicator: N
Export Indicator: N
Discr Quantity Indicator: N
Discr Type Indicator: Y
Discr Residue Indicator: N
Discr Partial Reject Indicator: N
Discr Full Reject Indicator: N
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: H111
Waste Code a: Lead
Waste Code b: Not reported
Waste Code c: Not reported
Waste Code e: Not reported
Waste Code f: Not reported
Waste Code g: Not reported
Waste Code 1: Not reported
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 200
Units: Pounds
Number of Containers: 1
Container Type: Cargo tanks (tank trucks)
Handling Method: Treat
Specific Gravity: 1

AE310 **CON EDISON** **RCRA NonGen / NLR** **1019906748**
SSE **GROVE ST & FISCHER COURT** **FINDS** **NYP004825978**
1/8-1/4 **WHITE PLAINS, NY 10601** **ECHO**
0.199 mi.
1051 ft. **Site 5 of 6 in cluster AE**

Relative: **Higher**

Actual: **210 ft.**

RCRA Listings:

Date Form Received by Agency:	20150819
Handler Name:	Con Edison
Handler Address:	Grove St & Fischer Court
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYP004825978
Contact Name:	THOMAS TEELING
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	212-460-3770
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PL 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No

CON EDISON (Continued) **1019906748**

Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20160909
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20150819
Handler Name: CON EDISON	
Federal Waste Generator Description:	Large Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20150819
Handler Name: CON EDISON	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

List of NAICS Codes and Descriptions:

NAICS Codes:	No NAICS Codes Found

Facility Has Received Notices of Violations:

Violations:	No Violations Found

Evaluation Action Summary:

Evaluations:	No Evaluations Found

CON EDISON (Continued) **1019906748**

FINDS:
Registry ID: 110069671554

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:
The Resource Conservation and Recovery Act Information System (RCRAInfo) is EPA's comprehensive information system in support of the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. It tracks many types of information about generators, transporters, treaters, storers, and disposers of hazardous waste.

Click this hyperlink while viewing on your computer to access additional FINDS: detail in the EDR Site Report.

ECHO:
Envid: 1019906748
Registry ID: 110069671554

DFR URL:
Name: CON EDISON
Address: GROVE ST & FISCHER COURT
City,State,Zip: WHITE PLAINS, NY 10601

AE311 **CON EDISON SERVICE BOX: 11370** **RCRA NonGen / NLR** **1016969239**
SSE **GROVE ST & FISCHER AVE** **NY MANIFEST** **NYP004428926**
1/8-1/4 **WHITE PLAINS, NY 10602**
0.199 mi.
1051 ft. **Site 6 of 6 in cluster AE**

Relative:
Higher

Actual:
210 ft.

RCRA Listings:

Date Form Received by Agency:	20140228
Handler Name:	Con Edison Service Box: 11370
Handler Address:	Grove St & Fischer Ave
Handler City,State,Zip:	WHITE PLAINS, NY 10602
EPA ID:	NYP004428926
Contact Name:	THOMAS TEELING
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	212-460-3770
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	SENIOR SCIENTIST
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PL, 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported

CON EDISON SERVICE BOX: 11370 (Continued) **1016969239**

Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20141014
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20140129
Handler Name: CON EDISON SERVICE BOX:	11370
Federal Waste Generator Description:	Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

CON EDISON SERVICE BOX: 11370 (Continued) **1016969239**

Receive Date:	20140228
Handler Name: CON EDISON SERVICE BOX:	11370
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

List of NAICS Codes and Descriptions:

NAICS Codes:	No NAICS Codes Found

Facility Has Received Notices of Violations:

Violations:	No Violations Found

Evaluation Action Summary:

Evaluations:	No Evaluations Found

NY MANIFEST:

EPA ID:	NYP004428926
Country:	USA
Name:	Con Edison
Address:	GROVE ST & FISCHER AVE
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10602
Zip 4:	Not reported
Location Address 1:	GROVE & FISHER
Location Address 2:	SERVICE BOX # 11370
Location City,State,Zip:	WHITE PLAINS, NY 10602
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Edison
Mailing Contact:	Tom Teeling
Mailing Address 1:	4 IRVING PLACE 15TH FLOOR
Mailing Address 2:	Not reported
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	2124603770

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported

CON EDISON SERVICE BOX: 11370 (Continued) **1016969239**

Generator Ship Date:	01/29/2014
Trans1 Recv Date:	01/29/2014
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	01/31/2014
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004428926
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	011692778JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	20
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

AB312 **HAMILTON MAIN PARKING STR** **NY LTANKS** **S100139680**
ENE **HAMILTON AVE & MAIN ST** **N/A**
1/8-1/4 **WHITE PLAINS, NY**
0.199 mi.
1051 ft. **Site 3 of 3 in cluster AB**

Relative:
Higher

Actual:
219 ft.

LTANKS:

Name:	HAMILTON MAIN PARKING STR
Address:	HAMILTON AVE & MAIN ST
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8707260 / 1989-11-29
Facility ID:	8707260
Site ID:	286661
Spill Date:	1987-11-23
Spill Cause:	Tank Test Failure

HAMILTON MAIN PARKING STR (Continued) **S100139680**

Spill Source:	Institutional, Educational, Gov., Other
Spill Class:	Not reported
Cleanup Ceased:	1989-11-29
SWIS:	6017
Investigator:	UNASSIGNED
Referred To:	Not reported
Reported to Dept:	1987-11-23
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1987-11-27
Spill Record Last Update:	1989-11-29
Spiller Name:	RED BROCCHI
Spiller Company:	C/WHITE PLAINS
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	232336
Latitude:	Not reported
Longitude:	Not reported
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was
Remarks:	2K TANK SYSTEM -.5257 GPH, TO E, I & R

All TTF:

Facility ID:	8707260
Spill Number:	8707260
Spill Tank Test:	1532412
Site ID:	286661
Tank Number:	Not reported
Tank Size:	0
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	286661
Operable Unit ID:	911136
Operable Unit:	01
Material ID:	466224
Material Code:	0001A
Material Name:	#2 fuel oil

HAMILTON MAIN PARKING STR (Continued) **S100139680**

Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	Not reported
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

AF313 **ONE WATER STREET BLACKSMITH & WHEELWRIGHT SITE** **NY BROWNFIELDS** **S129982644**
NW **P/O 1 WATER ST. AND P/O FORMER NORTH LEXINGTON AVE** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.200 mi.
1054 ft. **Site 3 of 3 in cluster AF**

Relative:
Lower

Actual:
186 ft.

BROWNFIELDS:

Name:	ONE WATER STREET BLACKSMITH & WHEELWRIGHT SITE
Address:	P/O 1 WATER ST. AND P/O FORMER NORTH LEXINGTON AVE
City,State,Zip:	WHITE PLAINS, NY 10601
Program:	BCP
Site Code:	645014
Acres:	1.230
HW Code:	C360235
SWIS:	6017
Town:	White Plains (c)
Record Added Date:	11/07/2022
Record Updated Date:	04/17/2023
Update By:	AMSERVIS
Site Description:	Site Location: The site is located at the follow addresses in an urban area in the City of White Plains, New York, 10601: p/o 1 Water Street (125.66-2-1) and p/o North Lexington Avenue (125.66-2-2). The surrounding area is occupied by commercial buildings. The site is wrapped in an arc to the north and east by a public parking lot. A car dealership and service facility are also located east of the site. Water Street is located south of the site, and Ferris Avenue is located west of the site. A New York Metropolitan Transit Authority Bus Terminal and a municipal parking garage are located southwest of the site beyond Water Street and Ferris Avenue. A municipal building and fire house are located beyond Ferris Avenue to the west. Site Features: The site was most recently developed with a four-story commercial office building. The building contained no basement. A hydraulic elevator was located within the former building. An asphalt-paved parking area and some landscaped areas were present on the site. but the site is now vacant. Two security gates are present at the parking lot entrance and exit in the southern portion of the site. In addition, a portion of the site was developed as a parking lot/roadway. An easement utilized by Consolidated Edison (Con Ed) is located north of the site in the east-west direction. The closest water body, the Bronx River, is located approximately 0.125 miles from site. The site is not located in a flood zone. The nearest surface water body is the Kensico Reservoir located approximately 2.65 miles northeast of the site. Current Zoning and Land Use: The site is currently located in the Core Business-4 (CB-4) District. The CB-4 designation allows for multi-family residential buildings and commercial uses and the site has already received all required land use approvals for the project including Site Plan approval. The site is also located in the City s Central Parking Area (CPA) overlay district. The CPA overlay was created with the purpose of

ONE WATER STREET BLACKSMITH & WHEELWRIGHT SITE (Continued) **S129982644**

setting special parking requirements for land uses within the Central Business districts. Parking requirements are lower for a given use to reflect the complementary mix of land uses in this dense downtown urban area. A New York Metropolitan Transit Authority bus terminal is located directly across Water Street from the site. The closest rail line is located approximately 290 feet from the site. The Metro North Station is located approximately 462 feet from the site. Past Use of the Site: The historical use of the site as blacksmith and wheelwright constituted a possible recognized environmental condition (REC) in the 2018 Phase I Report and further investigation of the site in 2021 and 2022 suggests this use caused SVOC and metals contamination in the soil and other contamination in groundwater and soil vapor since this use was present for many years. A wheelwright repairs wheels and this prior operation, which extended into the 1940s, may have used solvents. In addition, in 1911 Standard Oil and in 1930, The Texas Co., which operated an Oil Storage warehouse, fronted the site. In 1950, Westchester Asphalt Company fronted the site, and its operations including storage of asphalt and gasoline tanks were present. Contaminated historic fill material containing varying amount of brick, concrete, asphalt, and ash was also identified at the site during the SESI February 2018 geotechnical investigation and later 2021 and 2022 subsurface investigations. An earlier 1997 Phase I report revealed that underground storage tanks were historically present at the adjacent Fire House Station site, which may have leaked and lead to some on-site contamination. There were four historic spills at that site: April 14, 1988, Spill No. 8800487 closed January 11, 1989; April 21, 1988 Spill No. 8800670 closed January 11, 1989; and May 26, 1988 Spill No. 8801791 closed January 24, 1989; September 7, 1994 Spill No. 9408242 closed the same day. A total of four underground storage tanks (USTs) were removed from the Fire Station Site prior to April 1991. Two 10,000 galloon heating fuel oil USTs and one 2,000-gallon leaded gasoline UST were removed from that property at that same time. That property was registered under PBS No. 3-169439. An EDR Report contained within the 1997 Phase I Report also discussed the 1994 petroleum spill to the sewer on Ferris Avenue. Gasoline tanks were identified at the adjacent Surface Transportation Systems Garage, which may have leaked and lead to some groundwater or soil vapor contamination. Despite these spills in close proximity to the site, since these prior spills were closed to the satisfaction of the NYSDEC, and given that the consultant concluded that there was no evidence the tanks had leaked, the consultant that performed the initial Phase I for Cali Realty Corporation did not conclude that the spills on the adjacent parcel represented a recognized environmental condition and the Phase I report had a clean no environmental impact conclusion. Nevertheless, despite spill closure, these historic spills may have contributed to contamination under the site. The adjacent Fire House was only located 0.125 miles away. This Fire Station may have also led to some of the PFAS groundwater contamination. Trichlorofluoromethane (Freon-11) was also detected throughout the site, indicating a potential Freon-11 release. Site Geology and Hydrogeology: According to the United States Geological Survey (USGS) White Plains, NY, 2013, 7.5-minute Series topographic map, the site s average elevation is approximately 189 feet above mean sea level (amsl). The site gently slopes downward from north to south, ranging from approximately 197 feet amsl to 186 feet amsl. Groundwater is expected to flow to the south. Groundwater was observed at approximately 10-15 ft-bgs at the

ONE WATER STREET BLACKSMITH & WHEELWRIGHT SITE (Continued) **S129982644**

	site. The site is characterized by fill to depths ranging from five (5) to twelve (12) feet below grade surface (ft-bgs). The fill is characterized by gray-brown sands mixed with varying amounts of brick, concrete, asphalt, and ash. The fill may have been used to raise the site elevation to its current configuration. A brown sand layer is present beneath the fill layer. This layer contains varying amounts of clayey silt and gravel that extent to bedrock. The depth of bedrock at the site appears to vary significantly from 30 ft-bgs within the northeast portion of the site to greater than 55 ft-bgs in the southwest portion of the site.
Env Problem:	Information submitted with the BCP application regarding the environmental condition at the site are currently under review and will be revised as additional information becomes available.
Health Problem:	Information submitted with the BCP application regarding the conditions at the site are currently under review and will be revised as additional information becomes available.
Dump:	Not reported
Structure:	Not reported
Lagoon:	Not reported
Landfill:	Not reported
Pond:	Not reported
Disp Start:	Not reported
Disp Term:	Not reported
Lat/Long:	Not reported
Dell:	Not reported
Record Add:	Not reported
Record Upd:	Not reported
Updated By:	Not reported
Own Op:	Document Repository
Sub Type:	NNN
Owner Name:	Galina Chernykh
Owner Company:	Harrison Public Library - West harrison Branch
Owner Address:	2 Madison Street
Owner Addr2:	Not reported
Owner City,St,Zip:	West harrison, NY 10604
Owner Country:	United States of America
Own Op:	6
Sub Type:	P02
Owner Name:	BeverLy Sturr, Esq.
Owner Company:	1 Water Street L.L.C.
Owner Address:	Harborside 3
Owner Addr2:	210 Hudson Street, Suite 400
Owner City,St,Zip:	Jersey City, NJ 07311
Owner Country:	United States of America
Own Op:	1
Sub Type:	E
Owner Name:	BeverLy Sturr
Owner Company:	1 Water Street L.L.C.
Owner Address:	Harborside 3, 210 Hudson Street, Suite 400
Owner Addr2:	Not reported
Owner City,St,Zip:	Jersey City, NJ 07311
Owner Country:	United States of America
HW Code:	Not reported
Waste Type:	Not reported
Waste Quantity:	Not reported
Waste Code:	Not reported
Crossref ID:	Not reported

ONE WATER STREET BLACKSMITH & WHEELWRIGHT SITE (Continued) **S129982644**

Cross Ref Type Code:	Not reported
Cross Ref Type:	Not reported
Record Added Date:	Not reported
Record Updated:	Not reported
Updated By:	Not reported

AG314 **CON EDISON** **NY MANIFEST** **S117738201**
South **QUARROPAS ST & LEXINGTON AVE** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.200 mi.
1057 ft. **Site 1 of 17 in cluster AG**

Relative:
Higher

Actual:
197 ft.

NY MANIFEST:

EPA ID:	NYP004711206
Country:	USA
Name:	Con Edison
Address:	QUARROPAS ST & LEXINGTON AVE
Address 2:	MH 11362
City,State,Zip:	WHITE PLAINS, NY 10601
Zip 4:	Not reported
Location Address 1:	QUARROPAS ST & LEXINGTON AVE
Location Address 2:	MH 11362
Location City,State,Zip:	WHITE PLAINS, NY 10601
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Edison
Mailing Contact:	Tom Teeling
Mailing Address 1:	4 IRVING PLACE - 15TH FLOOR
Mailing Address 2:	Not reported
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	Not reported

AG315 **CON EDISON** **RCRA NonGen / NLR** **1018280106**
South **S LEXINGTON AVE & QUARROPAS ST** **FINDS** **NYP004749677**
1/8-1/4 **WHITE PLAINS, NY 10605** **ECHO**
0.200 mi.
1057 ft. **Site 2 of 17 in cluster AG**

Relative:
Higher

Actual:
197 ft.

RCRA Listings:

Date Form Received by Agency:	20150312
Handler Name:	Con Edison
Handler Address:	S Lexington Ave & Quarropas St
Handler City,State,Zip:	WHITE PLAINS, NY 10605
EPA ID:	NYP004749677
Contact Name:	THOMAS TEELING
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	212-460-3770
Contact Fax:	Not reported
Contact Email:	Not reported

CON EDISON (Continued) **1018280106**

Contact Title:	Not reported
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PL, 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20160502
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

CON EDISON (Continued) **1018280106**

Historic Generators:
Receive Date: 20150312
Handler Name: CON EDISON
Federal Waste Generator Description: Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20150312
Handler Name: CON EDISON
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

FINDS:
Registry ID: 110067701605

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:
The Resource Conservation and Recovery Act Information System (RCRAInfo) is EPA's comprehensive information system in support of the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. It tracks many types of information about generators, transporters, treaters, storers, and disposers of hazardous waste.

Click this hyperlink while viewing on your computer to access additional FINDS: detail in the EDR Site Report.

ECHO:
Envid: 1018280106
Registry ID: 110067701605

CON EDISON (Continued) **1018280106**

DFR URL:
Name: CON EDISON
Address: S LEXINGTON AVE & QUARROPAS ST
City,State,Zip: WHITE PLAINS, NY 10605

AG316 **CON EDISON** **NJ MANIFEST** **S120668868**
South **S LEXINGTON AVE & QUARROPAS ST** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10605**
0.200 mi.
1057 ft. **Site 3 of 17 in cluster AG**

Relative:
Higher

Actual:
197 ft.

NJ MANIFEST:
EPA ID: NYP004749677
Name: CON EDISON
Address: S LEXINGTON AVE & QUARROPAS ST
City,State,Zip: WHITE PLAINS, NY 10605
County: Not reported
Mailing Address: IRVING PL, 15TH FL NE
Mailing City,State,Zip: NEW YORK, NY 10003
Telephone: Not reported
Emergency Telephone: Not reported
Contact: THOMAS TEELING
Comments: Not reported
SIC Code: Not reported
County: NY119
Municipal: Not reported
Previous EPAID: Not reported
Generator Flag: Not reported
Transporter Flag: Not reported
TSDF Flag: Not reported
Name Change: Not reported
Date Change: Not reported

Manifest Data:
EPA ID: NYP004749677
Manifest Number: 014091664JJK
Date Shipped: 3/12/2015
TSDF EPA ID: NJD002200046
Transporter EPA ID: NYD006982359
Transporter 2 EPA ID: Not reported
Transporter 3 EPA ID: Not reported
Transporter 4 EPA ID: Not reported
Transporter 5 EPA ID: Not reported
Transporter 6 EPA ID: Not reported
Transporter 7 EPA ID: Not reported
Transporter 8 EPA ID: Not reported
Transporter 9 EPA ID: Not reported
Transporter 10 EPA ID: Not reported
Date Trans1 Transported Waste: Not reported
Date Trans2 Transported Waste: Not reported
Date Trans3 Transported Waste: Not reported
Date Trans4 Transported Waste: Not reported
Date Trans5 Transported Waste: Not reported
Date Trans6 Transported Waste: Not reported
Date Trans7 Transported Waste: Not reported
Date Trans8 Transported Waste: Not reported
Date Trans9 Transported Waste: Not reported

CON EDISON (Continued) **S120668868**

Date Trans10 Transported Waste:	Not reported
Date TSDF Received Waste:	Not reported
TSDF EPA Facility Name:	Not reported
QTY Units:	Not reported
Transporter SEQ ID:	Not reported
Transporter-1 Date:	Not reported
Waste SEQ ID:	Not reported
Waste Type Code 2:	Not reported
Waste Type Code 3:	Not reported
Waste Type Code 4:	Not reported
Waste Type Code 5:	Not reported
Waste Type Code 6:	Not reported
Date Accepted:	Not reported
Manifest Discrepancy Type:	Not reported
Data Entry Number:	Not reported
Was Load Rejected:	Not reported
Reason Load Was Rejected:	Not reported

AG317 **CON EDISON** **NJ MANIFEST** **S120670187**
South **LEXINGTON AVE & QUARROPAS ST** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.200 mi.
1057 ft. **Site 4 of 17 in cluster AG**

Relative:
Higher

Actual:
197 ft.

NJ MANIFEST:

EPA ID:	NYP004764643
Name:	CON EDISON
Address:	LEXINGTON AVE & QUARROPAS ST
City,State,Zip:	WHITE PLAINS, NY 10601
County:	Not reported
Mailing Address:	IRVING PL 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Telephone:	Not reported
Emergency Telephone:	Not reported
Contact:	THOMAS TEELING
Comments:	Not reported
SIC Code:	Not reported
County:	NY119
Municipal:	Not reported
Previous EPAID:	Not reported
Generator Flag:	Not reported
Transporter Flag:	Not reported
TSDF Flag:	Not reported
Name Change:	Not reported
Date Change:	Not reported

Manifest Data:

EPA ID:	NYP004764643
Manifest Number:	011692694JJK
Date Shipped:	4/8/2015
TSDF EPA ID:	NJD002200046
Transporter EPA ID:	NYD006982359
Transporter 2 EPA ID:	Not reported
Transporter 3 EPA ID:	Not reported
Transporter 4 EPA ID:	Not reported
Transporter 5 EPA ID:	Not reported
Transporter 6 EPA ID:	Not reported

CON EDISON (Continued) **S120670187**

Transporter 7 EPA ID:	Not reported
Transporter 8 EPA ID:	Not reported
Transporter 9 EPA ID:	Not reported
Transporter 10 EPA ID:	Not reported
Date Trans1 Transported Waste:	Not reported
Date Trans2 Transported Waste:	Not reported
Date Trans3 Transported Waste:	Not reported
Date Trans4 Transported Waste:	Not reported
Date Trans5 Transported Waste:	Not reported
Date Trans6 Transported Waste:	Not reported
Date Trans7 Transported Waste:	Not reported
Date Trans8 Transported Waste:	Not reported
Date Trans9 Transported Waste:	Not reported
Date Trans10 Transported Waste:	Not reported
Date TSDF Received Waste:	Not reported
TSDF EPA Facility Name:	Not reported
QTY Units:	Not reported
Transporter SEQ ID:	Not reported
Transporter-1 Date:	Not reported
Waste SEQ ID:	Not reported
Waste Type Code 2:	Not reported
Waste Type Code 3:	Not reported
Waste Type Code 4:	Not reported
Waste Type Code 5:	Not reported
Waste Type Code 6:	Not reported
Date Accepted:	Not reported
Manifest Discrepancy Type:	Not reported
Data Entry Number:	Not reported
Was Load Rejected:	Not reported
Reason Load Was Rejected:	Not reported

AG318 **CON EDISON MANHOLE 10129** **RCRA NonGen / NLR** **1010326270**
South **S LEXINGTON AVE & FISHER AVE** **NY MANIFEST** **NYP004140307**
1/8-1/4 **WHITE PLAINS, NY 10606**
0.200 mi.
1057 ft. **Site 5 of 17 in cluster AG**

Relative: **Higher**

Actual: **197 ft.**

RCRA Listings:

Date Form Received by Agency:	20060705
Handler Name:	Con Edison Manhole 10129
Handler Address:	S Lexington Ave & Fisher Ave
Handler City,State,Zip:	WHITE PLAINS, NY 10606
EPA ID:	NYP004140307
Contact Name:	ANTONIO DELGADO
Contact Address:	4 IRVING PL, RM 828
Contact City,State,Zip:	NEW YORK, NY 10003
Contact Telephone:	718-204-4201
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Not reported
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported

CON EDISON MANHOLE 10129 (Continued) **1010326270**

State District Owner:	Ny
State District:	NYSDEC R3
Mailing Address:	4 IRVING PL, RM 828
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20150414
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20060703
Handler Name: CON EDISON	
Federal Waste Generator Description:	Not reported
State District Owner:	Not reported
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No

CON EDISON MANHOLE 10129 (Continued) **1010326270**

Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20060704
Handler Name: CON EDISON
Federal Waste Generator Description: Not a generator, verified
State District Owner: Not reported
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20060705
Handler Name: CON EDISON MANHOLE 10129
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

NY MANIFEST:
EPA ID: NYP004140307
Country: USA
Name: Consolidated Edison
Address: SOUTH LEXINGTON AVE AND FISHER
Address 2: AVE
City,State,Zip: WHITE PLAINS, NY 10606
Zip 4: Not reported
Location Address 1: LEX & FISHER MH10129
Location Address 2: Not reported
Location City,State,Zip: WHITE PLAINS, NY 10602
Location Zip 4: Not reported

CON EDISON MANHOLE 10129 (Continued) **1010326270**

Facility Status: Not reported
Total Tanks: Not reported
Code: BP

Mailing:
Mailing Name: Consolidated Edison
Mailing Contact: Franklin Murray
Mailing Address 1: 4 IRVING PLACE RM 828
Mailing Address 2: Not reported
Mailing City,State,Zip: NEW YORK, NY 10003
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: 2124602808

Manifest Data:
Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: NYD006982359
Year: 2018
Trans2 State ID: Not reported
Generator Ship Date: 02/25/2006
Trans1 Recv Date: 02/25/2006
Trans2 Recv Date: Not reported
TSD Site Recv Date: 02/27/2006
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYP004140307
Trans1 EPA ID: Not reported
Trans2 EPA ID: Not reported
TSDF ID 1: NYD077444263
TSDF ID 2: Not reported
Manifest Tracking Number: NYE1541484
Import Indicator: N
Export Indicator: N
Discr Quantity Indicator: N
Discr Type Indicator: N
Discr Residue Indicator: N
Discr Partial Reject Indicator: N
Discr Full Reject Indicator: N
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: Not reported
Waste Code a: Lead
Waste Code b: Not reported
Waste Code c: Not reported
Waste Code e: Not reported
Waste Code f: Not reported
Waste Code g: Not reported
Waste Code 1: Not reported
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 50
Units: Pounds

CON EDISON MANHOLE 10129 (Continued) **1010326270**

Number of Containers:	1
Container Type:	Metal drums, barrels, kegs
Handling Method:	Landfill
Specific Gravity:	1

AG319 **CON EDISON** **RCRA NonGen / NLR** **1019901668**
South **LEXINGTON AVE & QUARROPAS ST** **NYP004764643**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.200 mi.
1057 ft. **Site 6 of 17 in cluster AG**

Relative: **Higher**

Actual: **197 ft.**

RCRA Listings:

Date Form Received by Agency:	20150408
Handler Name:	Con Edison
Handler Address:	Lexington Ave & Quarropas St
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYP004764643
Contact Name:	THOMAS TEELING
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	212-460-3770
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PL 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline

CON EDISON (Continued) **1019901668**

2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20160909
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20150408
Handler Name: CON EDISON	
Federal Waste Generator Description:	Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20150408
Handler Name: CON EDISON	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

List of NAICS Codes and Descriptions:

NAICS Codes:	No NAICS Codes Found

Facility Has Received Notices of Violations:

Violations:	No Violations Found

CON EDISON (Continued) **1019901668**

Evaluation Action Summary:
Evaluations: No Evaluations Found

AG320 **CON EDISON** **NY MANIFEST** **S117535428**
South **QUARRAPUS ST & LEXINGTON AV** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10801**
0.200 mi.
1057 ft. **Site 7 of 17 in cluster AG**

Relative:
Higher

Actual:
197 ft.

NY MANIFEST:

EPA ID:	NYP000471120
Country:	USA
Name:	Con Edison
Address:	QUARRAPUS ST & LEXINGTON AV
Address 2:	MH11362
City,State,Zip:	WHITE PLAINS, NY 10801
Zip 4:	Not reported
Location Address 1:	QUARRAPUS ST & LEXINGTON AV
Location Address 2:	MH11362
Location City,State,Zip:	WHITE PLAINS, NY 10801
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Edison
Mailing Contact:	Con Edison
Mailing Address 1:	4 IRVING PL
Mailing Address 2:	15TH FL
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	Not reported

AG321 **CON EDISON** **NY MANIFEST** **S118088878**
South **LEXINGTON AVE & QUARROPAS ST** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.200 mi.
1057 ft. **Site 8 of 17 in cluster AG**

Relative:
Higher

Actual:
197 ft.

NY MANIFEST:

EPA ID:	NYP004764643
Country:	USA
Name:	Con Edison
Address:	LEXINGTON AVE & QUARROPAS ST
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10601
Zip 4:	Not reported
Location Address 1:	LEXINGTON AVE & QUARROPAS ST
Location Address 2:	MH 10040
Location City,State,Zip:	WHITE PLAINS, NY 10601
Location Zip 4:	Not reported
Facility Status:	Not reported

CON EDISON (Continued) **S118088878**

Total Tanks: Not reported
Code: BP

Mailing:
Mailing Name: Con Edison
Mailing Contact: Tom Teeling
Mailing Address 1: 4 IRVING PLACE - 15TH FLOOR
Mailing Address 2: Not reported
Mailing City,State,Zip: NEW YORK, NY 10003
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: Not reported

Manifest Data:
Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: NYD006982359
Year: 2018
Trans2 State ID: Not reported
Generator Ship Date: 04/08/2015
Trans1 Recv Date: 04/08/2015
Trans2 Recv Date: Not reported
TSD Site Recv Date: 04/14/2015
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYP004764643
Trans1 EPA ID: Not reported
Trans2 EPA ID: Not reported
TSDF ID 1: NJD002200046
TSDF ID 2: Not reported
Manifest Tracking Number: 011692694JJK
Import Indicator: N
Export Indicator: N
Discr Quantity Indicator: N
Discr Type Indicator: N
Discr Residue Indicator: N
Discr Partial Reject Indicator: N
Discr Full Reject Indicator: N
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: H110
Waste Code a: Lead
Waste Code b: Not reported
Waste Code c: Not reported
Waste Code e: Not reported
Waste Code f: Not reported
Waste Code g: Not reported
Waste Code 1: Not reported
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 100
Units: Pounds
Number of Containers: 1

CON EDISON (Continued) **S118088878**

Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

AG322 **CON EDISON** **NY MANIFEST** **S117741723**
South **S LEXINGTON AVE & QUARROPAS ST** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10605**
0.200 mi.
1057 ft. **Site 9 of 17 in cluster AG**

Relative:
Higher

Actual:
197 ft.

NY MANIFEST:

EPA ID:	NYP004749677
Country:	USA
Name:	Con Edison
Address:	S LEXINGTON AVE & QUARROPAS ST
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10605
Zip 4:	Not reported
Location Address 1:	S LEXINGTON AVE & QUARROPUS ST
Location Address 2:	MH100400
Location City,State,Zip:	WHITE PLAINS, NY 10606
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Edison
Mailing Contact:	Con Edison
Mailing Address 1:	4 IRVING PL
Mailing Address 2:	15TH FL
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	Not reported

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	03/12/2015
Trans1 Recv Date:	03/12/2015
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	03/12/2015
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004749677
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	014091664JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N

CON EDISON (Continued) **S117741723**

Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	200
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

AG323 **CON EDISON MANHOLE: 8162** **RCRA NonGen / NLR** **1016965084**
South **S LEXINGTON AVE & FISHER AVE** **NY MANIFEST** **NYP004379814**
1/8-1/4 **WHITE PLAINS, NY 10607**
0.200 mi.
1057 ft. **Site 10 of 17 in cluster AG**

Relative: **Higher**

Actual: **197 ft.**

RCRA Listings:

Date Form Received by Agency:	20131124
Handler Name:	Con Edison Manhole: 8162
Handler Address:	S Lexington Ave & Fisher Ave
Handler City,State,Zip:	WHITE PLAINS, NY 10607
EPA ID:	NYP004379814
Contact Name:	THOMAS TEELING
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	212-460-3770
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	SENIOR SCIENTIST
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PL, 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003

CON EDISON MANHOLE: 8162 (Continued) **1016965084**

Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20140701
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20131024
Handler Name:	CON EDISON MANHOLE: 8162
Federal Waste Generator Description:	Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No

CON EDISON MANHOLE: 8162 (Continued) **1016965084**

Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20131124
Handler Name: CON EDISON MANHOLE: 8162
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

NY MANIFEST:
EPA ID: NYP004379814
Country: USA
Name: Con Edison
Address: S LEXINGTON AVE & FISHER AVE
Address 2: Not reported
City,State,Zip: WHITE PLAINS, NY 10607
Zip 4: Not reported
Location Address 1: SO LEXINGTON AVE FISHER
Location Address 2: SB8162
Location City,State,Zip: WHITE PLAINS, NY 10471
Location Zip 4: Not reported
Facility Status: Not reported
Total Tanks: Not reported
Code: BP

Mailing:
Mailing Name: Con Edison
Mailing Contact: Con Edison
Mailing Address 1: 4 IRVING PLACE
Mailing Address 2: 15TH FL
Mailing City,State,Zip: NEW YORK, NY 10003
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: Not reported

Manifest Data:
Document ID: Not reported

CON EDISON MANHOLE: 8162 (Continued) **1016965084**

Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	10/24/2013
Trans1 Recv Date:	10/24/2013
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	10/31/2013
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004379814
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	011693660JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	15
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

AH324 **CON EDISON - TRANSFORMER VAULT 3520** **NY MANIFEST** **S123692349**
ENE **241 MAIN ST** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.204 mi.
1079 ft. **Site 1 of 9 in cluster AH**

Relative: NY MANIFEST:
Higher

EPA ID:	NYP005192141
Country:	USA
Name:	Con Edison - Transformer Vault 3520
Address:	241 MAIN ST

Actual:
217 ft.

CON EDISON - TRANSFORMER VAULT 3520 (Continued) **S123692349**

Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10601
Zip 4:	Not reported
Location Address 1:	241 MAIN ST
Location Address 2:	Not reported
Location City,State,Zip:	WHITE PLAINS, NY 10601
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Edison - Transformer Vault 3520
Mailing Contact:	Annamarie Moylan
Mailing Address 1:	4 IRVING PLACE 15TH FL NE
Mailing Address 2:	Not reported
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	2124602278

AG325 **WINBROOK APARTMENTS** **RCRA-SQG** **1027473845**
SSW **11 FISHER AVE** **E MANIFEST** **NYR000258236**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.206 mi.
1090 ft. **Site 11 of 17 in cluster AG**

Relative:
Higher

Actual:
197 ft.

RCRA Listings:

Date Form Received by Agency:	20221019
Handler Name:	Winbrook Apartments
Handler Address:	Fisher Ave
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYR000258236
Contact Name:	TEDDIE L HERNDERSON
Contact Address:	DR MARTIN LUTHER KING JR BLVD
Contact City,State,Zip:	WHITE PLAINS, NY 10601
Contact Telephone:	914-949-6462 x1015
Contact Fax:	Not reported
Contact Email:	THENDERSON@WPHANY.COM
Contact Title:	SECRETARY
EPA Region:	02
Land Type:	Federal
Federal Waste Generator Description:	Small Quantity Generator
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Handler Activities
State District Owner:	Ny
State District:	NYSDEC R3
Mailing Address:	DR MARTIN LUTHER KING JR BLVD
Mailing City,State,Zip:	WHITE PLAINS, NY 10601
Owner Name:	White Plains Housing Authority
Owner Type:	Federal
Operator Name:	White Plains Housing Authority
Operator Type:	Federal
Short-Term Generator Activity:	No
Importer Activity:	No

WINBROOK APARTMENTS (Continued) **1027473845**

Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	The land is federally-owned, The site is federally-owned, The site is federally-operated
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20221020
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Hazardous Waste Summary:

Waste Code:	D008
Waste Description:	Lead

Handler - Owner Operator:

Owner/Operator Indicator:	Operator
Owner/Operator Name:	WHITE PLAINS HOUSING AUTHORITY
Legal Status:	Federal
Date Became Current:	19490101
Date Ended Current:	Not reported
Owner/Operator Address:	223 DR MARTIN LUTHER KING JR BLVD
Owner/Operator City,State,Zip:	WHITE PLAINS, NY 10601
Owner/Operator Telephone:	914-949-6462
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported

WINBROOK APARTMENTS (Continued) **1027473845**

Owner/Operator Email: THENDERSON@WPHANY.COM

Owner/Operator Indicator: Owner
Owner/Operator Name: WHITE PLAINS HOUSING AUTHORITY
Legal Status: Federal
Date Became Current: 19490101
Date Ended Current: Not reported
Owner/Operator Address: 223 DR MARTIN LUTHER KING JR BLVD
Owner/Operator City,State,Zip: WHITE PLAINS, NY 10601
Owner/Operator Telephone: 914-949-6462
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: THENDERSON@WPHANY.COM

Historic Generators:
Receive Date: 20221019
Handler Name: WINBROOK APARTMENTS
Federal Waste Generator Description: Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: No
Electronic Manifest Broker: No

List of NAICS Codes and Descriptions:
NAICS Code: 562910
NAICS Description: Remediation Services

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

E MANIFEST:
Manifest Tracking Number: 019942407JJK
Last Updated Date: 20240112
Shipped Date: 20230908
Received Date: 20231103
Manifest Status: Corrected
Submission Type: DataImage5Copy
Origin Type: Service
Generator EPA ID: NYR000258236
Generator Name: White Plains Housing Authority
Generator Location Street Number: 11
Generator Location Street 1: 11 FISHER AVE
Generator Location Street 2: Not reported
Generator Location City: WHITE PLAINS
Generator Location State: NY
Generator Location Zip: 10606

WINBROOK APARTMENTS (Continued) **1027473845**

Generator Mail Street Number:	223
Generator Mail Street 1:	11 FISHER AVE
Generator Mail Street 2:	Not reported
Generator Mail City:	WHITE PLAINS
Generator Mail Zip:	10606
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	NJD002200046
Designated Facility Name:	Cycle Chem, Inc.
Designated Facility Mail Street Number:	217
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	SOUTH FIRST STREET
Designated Facility Mail City:	ELIZABETH
Designated Facility Mail Zip:	07206
Designated Facility Mail State:	NJ
Designated Facility Location Street Number:	217
Designated Facility Location Street 1:	SOUTH FIRST STREET
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	ELIZABETH
Designated Facility Location Zip:	07206
Designated Facility Location State:	NJ
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Transporter:

Manifest Tracking Number:	019942407JJK
Transporter Line Number:	1
Transporter EPA ID:	NYD986988645
Transporter Name:	Tristate Transfer Inc

Manifest Tracking Number:	019942407JJK
Transporter Line Number:	2
Transporter EPA ID:	NJD003812047
Transporter Name:	Acv Environmental Service Inc.

Waste Line:

Manifest Tracking Number:	019942407JJK
Waste Line Number:	1
U.S. DOT Hazardous Indicator:	Y
U.S. DOT ID Number:	NA3077
U.S. DOT Description:	Rq, Na3077, Rq Na3077 Hazardous Waste Solid Nos (Lead), 8, Pgiii, Lead
Non-Hazardous Waste Description:	Not reported
Number of Containers:	1
Container Type Code:	DM
Container Type Description:	Metal drums, barrels, kegs
Waste Quantity:	300
Quantity Unit of Measure Code:	P
Quantity Unit of Measure Description:	Pounds
Waste Quantity, in Tons:	0.15
Acute Waste Quantity, in Tons:	0
Non-Acute Waste Quantity, in Tons:	0.15
Waste Quantity, in Kilograms:	136.0545
Acute Waste Quantity, in Kilograms:	0
Non-Acute Waste Quantity, in Kilorgrams:	136.0545
Management Method Code:	H110

WINBROOK APARTMENTS (Continued) **1027473845**

Management Method Description:	STABILIZATION
Waste Residue Indicator:	N
Quantity Discrepancy Indicator:	N
Waste Type Discrepancy Indicator:	N
Waste Density:	Not reported
Waste Density Unit of Measure Code:	Not reported
Waste Density Unit of Measure Description:	Not reported
Form Code:	Not reported
Form Code Description:	Not reported
Source Code:	Not reported
Source Code Description:	Not reported
Waste Minimization Code:	Not reported
Waste Minimization Code Description:	Not reported
Consent Number:	Not reported
EPA Waste Indicator:	Y

AG326 **WINBROOK APARTMENTS** **NY MANIFEST** **S130582904**
SSW **11 FISHER AVE** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.206 mi.
1090 ft. **Site 12 of 17 in cluster AG**

Relative:
Higher

Actual:
197 ft.

NY MANIFEST:

EPA ID:	NYR000258236
Country:	USA
Name:	Winbrook Apartments
Address:	11 FISHER AVE
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10601
Zip 4:	Not reported
Location Address 1:	11 FISHER AVE
Location Address 2:	Not reported
Location City,State,Zip:	WHITE PLAINS, NY 10601
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Winbrook Apartments
Mailing Contact:	Teddie Hernderson
Mailing Address 1:	223 DR. MARTIN LUTHER KING JR. BLVD.
Mailing Address 2:	Not reported
Mailing City,State,Zip:	WHITE PLAINS, NY 10601
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	9149496462

AI327 **CON EDISON TRANSFORMER MANHOLE: 572** **RCRA NonGen / NLR** **1016973726**
ESE **MITCHELL PL & MAMARONECK AVE** **NY MANIFEST** **NYP004475315**
1/8-1/4 **WHITE PLAINS, NY 10606**
0.209 mi.
1102 ft. **Site 1 of 12 in cluster AI**

Relative: **Higher**

Actual: **218 ft.**

RCRA Listings:

Date Form Received by Agency:	20140422
Handler Name:	Con Edison Transformer Manhole: 572
Handler Address:	Mitchell Pl & Mamaroneck Ave
Handler City,State,Zip:	WHITE PLAINS, NY 10606
EPA ID:	NYP004475315
Contact Name:	THOMAS TEELING
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	212-460-3770
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	SENIOR SCIENTIST
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PL, 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No

CON EDISON TRANSFORMER MANHOLE: 572 (Continued) **1016973726**

Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20141014
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20140322
Handler Name:	CON EDISON TRANSFORMER MANHOLE: 572
Federal Waste Generator Description:	Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20140422
Handler Name:	CON EDISON TRANSFORMER MANHOLE: 572
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

List of NAICS Codes and Descriptions:

NAICS Codes:	No NAICS Codes Found

Facility Has Received Notices of Violations:

Violations:	No Violations Found

Evaluation Action Summary:

Evaluations:	No Evaluations Found

CON EDISON TRANSFORMER MANHOLE: 572 (Continued) **1016973726**

NY MANIFEST:

EPA ID:	NYP004475315
Country:	USA
Name:	Con Edison
Address:	MITCHELL PL & MAMARONECK AVE
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10606
Zip 4:	Not reported
Location Address 1:	MITCHELL RD
Location Address 2:	Not reported
Location City,State,Zip:	WHITE PLAINS, NY 10801
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Edison
Mailing Contact:	Con Edison
Mailing Address 1:	4 IRVING ST
Mailing Address 2:	15TH ST
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	Not reported

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	03/22/2014
Trans1 Recv Date:	03/22/2014
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	03/27/2014
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004475315
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	012772704JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported

CON EDISON TRANSFORMER MANHOLE: 572 (Continued) **1016973726**

Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	300
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

AI328 **KIMCO REALTY CORP** **NY UST** **U004440666**
ESE **100 MAMARONECK AVENUE** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.209 mi.
1103 ft. **Site 2 of 12 in cluster AI**

Relative:
Higher

Actual:
219 ft.

WESTCHESTER CO. UST:

Name:	KIMCO REALTY CORP
Address:	100 MAMARONECK AVENUE
City,State,Zip:	WHITE PLAINS, NY 10601
Id/Status:	3-801328 / Unregulated: <1101 gal. PBS
Operator Name:	Not reported
Owner Name:	Kimco Realty Corp
Owner Street:	3333 New Hyde Park
Owner Address2:	Not reported
Owner City:	New Hyde Park
Owner State:	NY
Owner Zipcode:	11040
GDS Number:	Not reported
Tank Number:	1
Status:	3. Closed - Removed
Capacity:	5000
Product Stored:	Not reported
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	Not reported
Date Perm Closure:	01/25/2006
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	Not reported
Piping Location:	2. Underground/on ground
Piping Type:	10. Copper
Piping External Protection:	0. None
Overfill Prevention:	0. None
Piping Secondary Containment:	Not reported
Spill Prevention:	0. None
Dispenser:	2. Suction

X329 **204 MARTINE ASSOCIATES / ICG** **NY AST** **A100540237**
East **204 MARTINE AVE** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.209 mi.
1104 ft. **Site 8 of 8 in cluster X**

Relative: **Higher**
Actual: **216 ft.**

WESTCHESTER CO. AST:

Name:	204 MARTINE ASSOCIATES / ICG
Address:	204 MARTINE AVE
City,State,Zip:	WHITE PLAINS, NY 10601
PBS Number:	3-173398
Site Status:	Unregulated: <1101 gal. PBS
GDS Number:	Not reported
Operator Name:	204 Martine Associates
Owner Name:	204 Martine Associates / Icg
Owner Street:	One Summit Ave
Owner Address2:	Not reported
Owner City/State/Zip:	White Plains, NY 10606
Tank Number:	1
Status:	3. Closed - Removed
Date Installation:	Not reported
Capacity:	5000
Product Stored:	Not reported
Product Stored Percent:	Not reported
Date Perm Closure:	09/01/1993
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Leak Detection:	0. None
Tank Secondary Containment:	Not reported
Piping Location:	3. Aboveground/underground combination
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Piping Leak Detection:	Not reported
Piping Secondary Containment:	Not reported
Overfill Prevention:	4. Product Level Gauge (Aboveground Only)
Spill Prevention:	Not reported
Dispenser:	2. Suction

AJ330 **MCI DBA VERIZON BUSINESS** **NY UST** **U004440921**
NE **95 CHURCH STREET** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.209 mi.
1105 ft. **Site 1 of 2 in cluster AJ**

Relative: **Higher**
Actual: **217 ft.**

WESTCHESTER CO. UST:

Name:	MCI DBA VERIZON BUSINESS
Address:	95 CHURCH STREET
City,State,Zip:	WHITE PLAINS, NY 10601
Id/Status:	3-259233 / Unregulated
Operator Name:	MCI dba Verizon Business
Owner Name:	MCI dba Verizon Business
Owner Street:	2400 N. Glenville Drive
Owner Address2:	Not reported
Owner City:	Richardson
Owner State:	TX
Owner Zipcode:	75082
GDS Number:	Not reported

MCI DBA VERIZON BUSINESS (Continued) **U004440921**

Tank Number:	001
Status:	0. Administratively closed
Capacity:	1000
Product Stored:	Not reported
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	01/01/1900
Date Perm Closure:	12/29/2000
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Secondary Containment:	0. None
Piping Location:	3. Aboveground/Underground Combination
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	6. Wrapped (Piping)
Overfill Prevention:	5. Vent Whistle
Piping Secondary Containment:	Not reported
Spill Prevention:	0. None
Dispenser:	2. Suction

Tank Number:	1
Status:	3. Closed - Removed
Capacity:	4000
Product Stored:	Not reported
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	Not reported
Date Perm Closure:	12/29/2000
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Secondary Containment:	Not reported
Piping Location:	3. Aboveground/underground combination
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	6. Wrapped (Piping)
Overfill Prevention:	5. Vent Whistle
Piping Secondary Containment:	Not reported
Spill Prevention:	Not reported
Dispenser:	2. Suction

Tank Number:	2
Status:	3. Closed - Removed
Capacity:	1000
Product Stored:	0008. Diesel
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	05/01/1987
Date Perm Closure:	06/10/2013
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	4. Fiberglass coated steel
Tank Internal Protection:	0. None
Tank External Protection:	4. Fiberglass
Tank Secondary Containment:	0. None

MCI DBA VERIZON BUSINESS (Continued) **U004440921**

Piping Location:	3. Aboveground/Underground Combination
Piping Type:	plastic & copper
Piping External Protection:	0. None
Overfill Prevention:	2. High Level Alarm
Piping Secondary Containment:	0. None
Spill Prevention:	1. Catch Basin
Dispenser:	2. Suction

AC331 **SMITH'S DAIRY,INC.** **NY UST** **U004441738**
SW **61 BANK STREET** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10602**
0.210 mi.
1109 ft. **Site 4 of 4 in cluster AC**

Relative: **Higher**
Actual: **207 ft.**

WESTCHESTER CO. UST:

Name:	SMITH'S DAIRY,INC.
Address:	61 BANK STREET
City,State,Zip:	WHITE PLAINS, NY 10602
Id/Status:	3-600496 / Unregulated
Operator Name:	Michael Shames
Owner Name:	William & Loretta Shames
Owner Street:	2 Southdale Road
Owner Address2:	Not reported
Owner City:	White Plains
Owner State:	NY
Owner Zipcode:	10605
GDS Number:	Not reported
Tank Number:	001
Status:	3. Closed - Removed
Capacity:	550
Product Stored:	0009. Gasoline
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	Not reported
Date Perm Closure:	Not reported
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	2. Underground/on ground
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Overfill Prevention:	0. None
Piping Secondary Containment:	Not reported
Spill Prevention:	0. None
Dispenser:	1. Submersible
Tank Number:	002
Status:	3. Closed - Removed
Capacity:	555
Product Stored:	0009. Gasoline
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	Not reported
Date Perm Closure:	Not reported

SMITH'S DAIRY,INC. (Continued) **U004441738**

Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	2. Underground/on ground
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Overfill Prevention:	0. None
Piping Secondary Containment:	Not reported
Spill Prevention:	0. None
Dispenser:	1. Submersible

AG332 **WHITE PLAINS HOUSING AUTHORITY - WINBROOK APARTMEN** **NY AIRS** **S121490347**
SSW **33 FISHER AVE** **NY MANIFEST** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.212 mi.
1121 ft. **Site 13 of 17 in cluster AG**

Relative:
Higher

Actual:
199 ft.

AIRS:

Name:	WINBROOK HOUSES
Address:	33 FISHER AVE
City,State,Zip:	WHITE PLAINS, NY 10601
DECID:	3551700096
Process ID:	Not reported
Latitude:	Not reported
Longitude:	Not reported
FIPS Code:	Not reported
Auth Type Code:	AFR
Permit Status:	Issued
Auth Status Code:	2
Emissions:	Not reported
Issue date:	09/24/2013
Expired Date:	09/24/2023
Emission Unit date:	Not reported
Contamination:	Not reported
EPA Control Code:	Not reported
Control Eff:	Not reported
Unit:	Not reported

NY MANIFEST:

EPA ID:	NYR000258293
Country:	USA
Name:	White Plains Housing Authority - Winbrook Apartments
Address:	33 FISHER AVE
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10601
Zip 4:	Not reported
Location Address 1:	33 FISHER AVE
Location Address 2:	Not reported
Location City,State,Zip:	WHITE PLAINS, NY 10601
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

WHITE PLAINS HOUSING AUTHORITY - WINBROOK APARTMENTS (Continued) **S121490347**

Mailing:

Mailing Name:	White Plains Housing Authority - Winbrook Apartments
Mailing Contact:	Teddie Henderson
Mailing Address 1:	223 DR. MARTIN LUTHER KING JR. BLVD.
Mailing Address 2:	Not reported
Mailing City,State,Zip:	WHITE PLAINS, NY 10601
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	9149496462

AG333 **WHITE PLAINS HOUSING AUTHORITY** **NY LTANKS** **S104509303**
SSW **33 FISHER AVE** **NY Spills** **N/A**
1/8-1/4 **WHITE PLAINS, NY**
0.212 mi.
1121 ft. **Site 14 of 17 in cluster AG**

Relative:
Higher

Actual:
199 ft.

LTANKS:

Name:	WHITE PLAINS HOUSING AUTHORITY
Address:	33 FISHER AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	1007861 / 2011-07-05
Facility ID:	1007861
Site ID:	441310
Spill Date:	2010-10-25
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	jbodee
Referred To:	WCDOH
Reported to Dept:	2010-10-25
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2010-10-25
Spill Record Last Update:	2011-07-25
Spiller Name:	Not reported
Spiller Company:	WHITE PLAINS HOUSING AUTHORITY
Spiller Address:	Not reported
Spiller County:	999
Spiller Contact:	VINNY NANNI
Spiller Phone:	(914) 949-6462
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	199379
Latitude:	41.0279278
Longitude:	-73.7722556
DEC Memo:	10/25/10 - Caller believes there is a loose connection between the tanks. Tanks to be uncover, repair and retest. Westchester County DOH will conduct follow up since tanks are PBS regulated. KAB 12/13/10

WHITE PLAINS HOUSING AUTHORITY (Continued) **S104509303**

Tanks were separated and retested. Tank 1 passed. Tank 2 (tank to the right when facing the bldg) failed with bubbling as per phone call from Kathy Morgan, US Tank Tech...mm 7/5/11 as per WCDOH White Plains- ttf 10/25/10. Tank passed isolation test. Lines replaced with no contamination observed. NFA JO'M 7/22/11: Received the retest results from US Tank Tech - will be entered into eDocs. NFA. jod

Remarks: Tank test Failure

All TTF:

Facility ID:	1007861
Spill Number:	1007861
Spill Tank Test:	2489700
Site ID:	441310
Tank Number:	1
Tank Size:	20000
Material:	0002
EPA UST:	False
UST:	True
Cause:	06
Source:	00
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	kabrowne
Last Modified Date:	Not reported

Facility ID:	1007861
Spill Number:	1007861
Spill Tank Test:	2489701
Site ID:	441310
Tank Number:	2
Tank Size:	20000
Material:	0002
EPA UST:	False
UST:	True
Cause:	06
Source:	00
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	Not reported
Gross Fail:	Not reported
Modified By:	kabrowne
Last Modified Date:	Not reported

All Materials:

Site ID:	441310
Operable Unit ID:	1191875
Operable Unit:	01
Material ID:	2187076
Material Code:	0002A
Material Name:	#4 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported

WHITE PLAINS HOUSING AUTHORITY (Continued) **S104509303**

Resource Affected: Not reported
Oxygenate: Not reported

SPILLS:
Name: WIND BROOK APTS.
Address: 33 FISHER AVE
City,State,Zip: WHITE PLAINS, NY
Spill Number/Closed Date: 9301205 / 1993-05-13
Facility ID: 9301205
Facility Type: ER
DER Facility ID: 199379
Site ID: 186162
DEC Region: 3
Spill Cause: Human Error
Spill Class: D3
SWIS: 6017
Spill Date: 1993-04-26
Investigator: tdghiosa
Referred To: Not reported
Reported to Dept: 1993-04-26
CID: Not reported
Water Affected: Not reported
Spill Source: Tank Truck
Spill Notifier: Responsible Party
Cleanup Ceased: 1993-05-13
Cleanup Meets Std: False
Last Inspection: Not reported
Recommended Penalty: False
UST Trust: False
Remediation Phase: 0
Date Entered In Computer: 1993-04-29
Spill Record Last Update: 1993-05-13
Spiller Name: Not reported
Spiller Company: CASTLE OIL
Spiller Address: Not reported
Spiller Company: 999
Contact Name: Not reported
Latitude: 41.0279278
Longitude: -73.7722556
DEC Memo: Prior to Sept, 2004 data translation this spill Lead_DEC Field was
GHIOSAY 05/13/93: SPILL CLEANED
UP ACCORDING TO JANET HERNANDEZ OF CASTLE OIL. COMPLETED THE SAME DAY.
Remarks: SPILL ON GROUND CREW ENROUTE

All Materials:
Site ID: 186162
Operable Unit ID: 983121
Operable Unit: 01
Material ID: 401926
Material Code: 0002A
Material Name: #4 fuel oil
Case No.: Not reported
Material FA: Petroleum
Quantity: 15.00
Units: G
Recovered: .00

WHITE PLAINS HOUSING AUTHORITY (Continued) **S104509303**

Resource Affected:	Soil
Oxygenate:	Not reported
Name:	WHITE PLAINS HOUSING
Address:	33 FISHER AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9912180 / 2000-05-30
Facility ID:	9912180
Facility Type:	ER
DER Facility ID:	199379
Site ID:	242722
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	C3
SWIS:	6017
Spill Date:	2000-01-21
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	2000-01-21
CID:	322
Water Affected:	Not reported
Spill Source:	Commercial Vehicle
Spill Notifier:	Responsible Party
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2000-01-21
Spill Record Last Update:	2000-06-02
Spiller Name:	FRANK MONTIBELLO
Spiller Company:	MONTIBELLO COAL & FUEL
Spiller Address:	424 EAST 81ST ST
Spiller Company:	001
Contact Name:	Not reported
Latitude:	41.0279278
Longitude:	-73.7722556
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY 01/21/2000 CLEANUP COMPLETED; NFA 03/20/2000 CASE REOPENED ON INFORMATION PROVIDED THAT THE SPILL SIZE MAY HAVE BEEN UP TO 700 GALLONS 03/08/2000 T. GHIOSAY SPOKE WITH DAN KIRSHNER OF SUN ROYAL ALLIANCE INSURANCE COMPANY AND ADVISED HIM THAT PLAYGROUND ARE NEEDS MORE CLEANUP. HE WILL CALL TRI-STATE AND AUTHORIZE WORK. 05/30/2000 LETTER SENT TO DORSON ENV. MGMT BY T. GHIOSAY; SPILL FILE IS CLOSED.
Remarks:	fitting popped off pipe causing spill - spill being cleaned up

All Materials:

Site ID:	242722
Operable Unit ID:	1086701
Operable Unit:	01
Material ID:	294073
Material Code:	0002A
Material Name:	#4 fuel oil

WHITE PLAINS HOUSING AUTHORITY (Continued) **S104509303**

Case No.:	Not reported
Material FA:	Petroleum
Quantity:	30.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

AJ334 **99 CHURCH STREET** **NY UST** **U004439297**
NE **99 CHURCH STREET** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.214 mi.
1130 ft. **Site 2 of 2 in cluster AJ**

Relative:
Higher

Actual:
217 ft.

WESTCHESTER CO. UST:

Name:	99 CHURCH STREET
Address:	99 CHURCH STREET
City,State,Zip:	WHITE PLAINS, NY 10601
Id/Status:	3-149071 / Unregulated: <1101 gal. PBS
Operator Name:	Minskoff Organization, Agent
Owner Name:	Minskoff Agnt American Savings
Owner Street:	1350 Avenue Of The Americas
Owner Address2:	Not reported
Owner City:	New York
Owner State:	NY
Owner Zipcode:	10019
GDS Number:	Not reported
Tank Number:	1
Status:	3. Closed - Removed
Capacity:	12000
Product Stored:	Not reported
Product Stored Percent:	Not reported
Tank Leak Detection:	4. Groundwater Well
Date Installation:	Not reported
Date Perm Closure:	11/15/2002
Tank Location:	Not reported
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	Not reported
Piping Location:	0. No Pipiing
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Overfill Prevention:	4. Product Level Gauge (Aboveground Only)
Piping Secondary Containment:	Not reported
Spill Prevention:	Not reported
Dispenser:	2. Suction

335 West 1/8-1/4 0.216 mi. 1143 ft. | **BILL'S AUTO REPAIR**
1 MAIN ST.
PT WASHINGTON, NY | **NY UST** | **U003377471**
N/A

Relative: Lower

Actual: 189 ft.

NASSAU CO. UST:

Facility ID:	057036
Owner Name:	BILL'S AUTO REPAIR
Owner Address:	1 MAIN ST.
Owner City,St,Zip:	PT WASHINGTON, NY 11050
Permitee Name:	ASHLEY ANN ENTERPRISES
Permitee Address:	1 MAIN ST.
Permitee City,St,Zip:	PT WASHINGTON, NY 11050
Tank Status:	In Service
Tank Internal Pro:	9
Tank External Pro:	3
Install Date:	061991
Leak Detected:	1
Material Type:	Waste
Tank Material:	Fiberglass Reinforced Plastic
Piping Type:	Fiberglass
Containment:	UNDERGROUND LINER
Product Gauge:	Yes
Dispense Method:	Submersible
Fill Type:	Gravity
Tank Status:	3-Abandoned/Removed
Tank Internal Pro:	Not reported
Tank External Pro:	Not reported
Install Date:	06/01/1981
Leak Detected:	Not reported
Material Type:	Not reported
Tank Material:	Not reported
Piping Type:	Not reported
Containment:	Not reported
Product Gauge:	No
Dispense Method:	Not reported
Fill Type:	Not reported
Tank Status:	3-Abandoned/Removed
Tank Internal Pro:	Not reported
Tank External Pro:	Not reported
Install Date:	06/01/1981
Leak Detected:	Not reported
Material Type:	Not reported
Tank Material:	Not reported
Piping Type:	Not reported
Containment:	Not reported
Product Gauge:	No
Dispense Method:	Not reported
Fill Type:	Not reported
Tank Status:	3-Abandoned/Removed
Tank Internal Pro:	Not reported

BILL'S AUTO REPAIR (Continued) **U003377471**

Tank External Pro:	Not reported
Install Date:	06/01/1981
Leak Detected:	Not reported
Material Type:	Not reported
Tank Material:	Not reported
Piping Type:	Not reported
Containment:	Not reported
Product Gauge:	No
Dispense Method:	Not reported
Fill Type:	Not reported

Tank Status:	1-In Service
Tank Internal Pro:	Not reported
Tank External Pro:	Not reported
Install Date:	03/01/1991
Leak Detected:	Not reported
Material Type:	Not reported
Tank Material:	Not reported
Piping Type:	Not reported
Containment:	Not reported
Product Gauge:	No
Dispense Method:	Not reported
Fill Type:	Not reported

AI336 **110-122 MAMARONECK AVENUE, LLC** **NY UST** **U004439093**
ESE **110 MAMARONECK AVENUE** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.223 mi.
1178 ft. **Site 3 of 12 in cluster AI**

Relative: **Higher**
Actual: **221 ft.**

WESTCHESTER CO. UST:

Name:	110-122 MAMARONECK AVENUE, LLC
Address:	110 MAMARONECK AVENUE
City,State,Zip:	WHITE PLAINS, NY 10601
Id/Status:	3-074640 / Unregulated: <1101 gal. PBS
Operator Name:	Ramon Lemus
Owner Name:	110 Mamaroneck Avenue, LLC
Owner Street:	237 Mamroneck Avenue
Owner Address2:	Not reported
Owner City:	White Plains
Owner State:	NY
Owner Zipcode:	10605
GDS Number:	Not reported

Tank Number:	1
Status:	3. Closed - Removed
Capacity:	2000
Product Stored:	Not reported
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	12/01/1971
Date Perm Closure:	11/05/2002
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Secondary Containment:	0. None

110-122 MAMARONECK AVENUE, LLC (Continued) **U004439093**

Piping Location:	2. Underground/on ground
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Overfill Prevention:	0. None
Piping Secondary Containment:	Not reported
Spill Prevention:	0. None
Dispenser:	2. Suction

AI337 **SILVERMAN REALITY** **NY LTANKS** **S104950814**
ESE **110 MAMARONECK AVE** **N/A**
1/8-1/4 **WHITE PLAINS, NY**
0.223 mi.
1178 ft. **Site 4 of 12 in cluster AI**

Relative:
Higher

Actual:
221 ft.

LTANKS:

Name:	SILVERMAN REALITY
Address:	110 MAMARONECK AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0011270 / 2003-01-22
Facility ID:	0011270
Site ID:	308222
Spill Date:	2001-01-16
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	WCHD
Referred To:	Westchester Cnty Health Dept
Reported to Dept:	2001-01-16
CID:	281
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2001-01-16
Spill Record Last Update:	2003-01-28
Spiller Name:	UNKNOWN
Spiller Company:	SILVERMAN REALITY
Spiller Address:	110 MAMARONECK AVE
Spiller County:	001
Spiller Contact:	TARRICONE OIL
Spiller Phone:	(914) 693-1132
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	248921
Latitude:	41.0299911
Longitude:	-73.7657901
DEC Memo:	Not reported
Remarks:	TANK TEST FAILURE AT ABOVE LOCATION PERFORMED AT REQUEST OF OIL COMPANY. OIL COMPANY HAS BEEN ADVISED OF RESULTS. NO CALL BACK REQUESTED.

All TTF:

Facility ID:	0011270

SILVERMAN REALITY (Continued) **S104950814**

Spill Number:	0011270
Spill Tank Test:	1526050
Site ID:	308222
Tank Number:	1
Tank Size:	2000
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	F
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	308222
Operable Unit ID:	832660
Operable Unit:	01
Material ID:	541592
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

338
SSW
1/8-1/4
0.224 mi.
1183 ft.

CHURCH
65 FISHER AVE
WHITE PLAINS, NY

NY LTANKS **S107657151**
NY Spills **N/A**

Relative:
Higher

Actual:
201 ft.

LTANKS:

Name:	ALLEN AME CHURCH
Address:	65 FISHER AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0509976 / 2006-12-20
Facility ID:	0509976
Site ID:	355853
Spill Date:	2005-11-21
Spill Cause:	Tank Failure
Spill Source:	Institutional, Educational, Gov., Other
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	TDGHIOSA
Referred To:	Not reported
Reported to Dept:	2005-11-21
CID:	444
Water Affected:	Not reported

CHURCH (Continued) **S107657151**

Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2005-11-21
Spill Record Last Update:	2006-12-20
Spiller Name:	MS RIBELLA
Spiller Company:	ALLEN AME CHURCH
Spiller Address:	65 FISHER AVE
Spiller County:	001
Spiller Contact:	MS RIBELLA
Spiller Phone:	(914) 761-4397
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	305892
Latitude:	41.0279820
Longitude:	-73.7720960
DEC Memo:	LEFT MESSAGE 12/02/05 Cross River Environmental to complete clean up. Report to follow. jod 02/24/06 NES removed tank and started excavating contaminated soil. Beneath the fuel oil contamination gasoline contaminated soil was encountered. Reportedly there is a gas station nearby. Chris Lalak of Westchester County Health to inspect. jod 10/24/06 National Environmental Specialists reported that the tank was removed along with 46.5 tons of impacted soil. NFA required. TG
Remarks:	1000 GALLON TANK HAD HOLES AND CONTAMINATED SOIL;

All Materials:

Site ID:	355853
Operable Unit ID:	1113186
Operable Unit:	01
Material ID:	2103241
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	G
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

SPILLS:

Name:	CHURCH
Address:	65 FISHER AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0513604 / 2006-12-20
Facility ID:	0513604
Facility Type:	ER
DER Facility ID:	310223
Site ID:	360107
DEC Region:	3
Spill Cause:	Other
Spill Class:	C3

CHURCH (Continued) **S107657151**

SWIS:	6017
Spill Date:	2006-02-24
Investigator:	TDGHIOSA
Referred To:	Not reported
Reported to Dept:	2006-02-24
CID:	444
Water Affected:	Not reported
Spill Source:	Institutional, Educational, Gov., Other
Spill Notifier:	Other
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2006-02-24
Spill Record Last Update:	2006-12-20
Spiller Name:	REVERAND SANDERS
Spiller Company:	CHURCH
Spiller Address:	65 FISHER AVE
Spiller Company:	001
Contact Name:	REVERAND SANDERS
Latitude:	41.0279820
Longitude:	-73.7720960
DEC Memo:	10 - 15 yards removed & encountered gasoline impacted soil. Todd Ghiosay notified. 12-20-06 See remediation filed under DEC Spill 06-09976. TG
Remarks:	CONTAMINATED SOIL AT THIS LOCATION AND HE BELIEVES IT MAY BE GASOLINE; OIL TANK HAS ALREADY BEEN REMOVED: DOH HAS BEEN NOTIFIED

All Materials:

Site ID:	360107
Operable Unit ID:	1117296
Operable Unit:	01
Material ID:	2107798
Material Code:	0009
Material Name:	gasoline
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

AG339 **124 SOUTH LEXINGTON AVE. INC.** **NY UST** **U003949767**
South **124 SOUTH LEXINGTON AVENUE** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.225 mi.
1189 ft. **Site 15 of 17 in cluster AG**

Relative: WESTCHESTER CO. UST:
Lower

Name:	124 SOUTH LEXINGTON AVE. INC.
Address:	124 SOUTH LEXINGTON AVENUE
City,State,Zip:	WHITE PLAINS, NY 10601
Id/Status:	3-497231 / Active
Operator Name:	124 South Lexington Ave. Inc.

Actual:
196 ft.

124 SOUTH LEXINGTON AVE. INC. (Continued) **U003949767**

Owner Name:	124 South Lexington Ave. Inc.
Owner Street:	124 South Lexington Avenue
Owner Address2:	Not reported
Owner City:	White Plains
Owner State:	NY
Owner Zipcode:	10601
GDS Number:	3551700223
Tank Number:	1
Status:	3. Closed - Removed
Capacity:	4000
Product Stored:	0009. Gasoline
Product Stored Percent:	Not reported
Tank Leak Detection:	4. Groundwater Well
Date Installation:	06/01/1991
Date Perm Closure:	05/01/2007
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	4. Impressed Current (no retrofit)
Tank Secondary Containment:	4. Double-Walled (underground only)
Piping Location:	2. Underground/on ground
Piping Type:	2. Galvanized steel
Piping External Protection:	Not reported
Overfill Prevention:	1. Float Vent Valve
Piping Secondary Containment:	Not reported
Spill Prevention:	1. Catch Basin
Dispenser:	2. Suction
Tank Number:	10
Status:	1. In-Service
Capacity:	10000
Product Stored:	2712. Gasoline/Ethanol
Product Stored Percent:	Not reported
Tank Leak Detection:	1. Electronic Interstitial Monitoring
Date Installation:	09/01/2007
Date Perm Closure:	01/01/1900
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	6. Fiberglass reinforced plastic (FRP)
Tank Internal Protection:	0. None
Tank External Protection:	4. Fiberglass
Tank Secondary Containment:	4. Double-Walled (underground only)
Piping Location:	2. Underground/on Ground
Piping Type:	6. Fiberglass Reinforced Plastic (FRP)
Piping External Protection:	4. Fiberglass
Overfill Prevention:	2. High Level Alarm
Piping Secondary Containment:	4. Double-Walled (underground only)
Spill Prevention:	1. Catch Basin
Dispenser:	1. Submersible
Tank Number:	11
Status:	1. In-Service
Capacity:	5000
Product Stored:	2712. Gasoline/Ethanol
Product Stored Percent:	Not reported

124 SOUTH LEXINGTON AVE. INC. (Continued) **U003949767**

Tank Leak Detection:	1. Electronic Interstitial Monitoring
Date Installation:	09/01/2007
Date Perm Closure:	01/01/1900
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	6. Fiberglass reinforced plastic (FRP)
Tank Internal Protection:	0. None
Tank External Protection:	4. Fiberglass
Tank Secondary Containment:	4. Double-Walled (underground only)
Piping Location:	2. Underground/on Ground
Piping Type:	6. Fiberglass Reinforced Plastic (FRP)
Piping External Protection:	4. Fiberglass
Overfill Prevention:	2. High Level Alarm
Piping Secondary Containment:	4. Double-Walled (underground only)
Spill Prevention:	1. Catch Basin
Dispenser:	1. Submersible

Tank Number:	2
Status:	3. Closed - Removed
Capacity:	4000
Product Stored:	0009. Gasoline
Product Stored Percent:	Not reported
Tank Leak Detection:	4. Groundwater Well
Date Installation:	06/01/1991
Date Perm Closure:	05/01/2007
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	4. Impressed Current (no retrofit)
Tank Secondary Containment:	4. Double-Walled (underground only)
Piping Location:	2. Underground/on ground
Piping Type:	2. Galvanized steel
Piping External Protection:	Not reported
Overfill Prevention:	1. Float Vent Valve
Piping Secondary Containment:	Not reported
Spill Prevention:	1. Catch Basin
Dispenser:	2. Suction

Tank Number:	3
Status:	3. Closed - Removed
Capacity:	4000
Product Stored:	0009. Gasoline
Product Stored Percent:	Not reported
Tank Leak Detection:	4. Groundwater Well
Date Installation:	06/01/1991
Date Perm Closure:	05/01/2007
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	4. Impressed Current (no retrofit)
Tank Secondary Containment:	4. Double-Walled (underground only)
Piping Location:	2. Underground/on ground
Piping Type:	2. Galvanized steel
Piping External Protection:	Not reported
Overfill Prevention:	1. Float Vent Valve
Piping Secondary Containment:	Not reported

124 SOUTH LEXINGTON AVE. INC. (Continued) **U003949767**

Spill Prevention:	1. Catch Basin
Dispenser:	2. Suction

Tank Number:	4
Status:	3. Closed - Removed
Capacity:	2000
Product Stored:	0009. Gasoline
Product Stored Percent:	Not reported
Tank Leak Detection:	4. Groundwater Well
Date Installation:	06/01/1991
Date Perm Closure:	05/01/2007
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	4. Impressed Current (no retrofit)
Tank Secondary Containment:	4. Double-Walled (underground only)
Piping Location:	2. Underground/on ground
Piping Type:	2. Galvanized steel
Piping External Protection:	Not reported
Overfill Prevention:	1. Float Vent Valve
Piping Secondary Containment:	Not reported
Spill Prevention:	1. Catch Basin
Dispenser:	2. Suction

Tank Number:	5
Status:	3. Closed - Removed
Capacity:	2000
Product Stored:	0009. Gasoline
Product Stored Percent:	Not reported
Tank Leak Detection:	4. Groundwater Well
Date Installation:	06/01/1991
Date Perm Closure:	05/01/2007
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	4. Impressed Current (no retrofit)
Tank Secondary Containment:	4. Double-Walled (underground only)
Piping Location:	2. Underground/on ground
Piping Type:	2. Galvanized steel
Piping External Protection:	Not reported
Overfill Prevention:	1. Float Vent Valve
Piping Secondary Containment:	Not reported
Spill Prevention:	1. Catch Basin
Dispenser:	2. Suction

Tank Number:	6
Status:	3. Closed - Removed
Capacity:	500
Product Stored:	0022. Waste/Used Oil
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	Not reported
Date Perm Closure:	11/16/2005
Tank Location:	5. Underground including vaulted with no access for inspection

124 SOUTH LEXINGTON AVE. INC. (Continued) **U003949767**

Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	0. No Pipiing
Piping Type:	0. No Pippping
Piping External Protection:	0. None
Overfill Prevention:	0. None
Piping Secondary Containment:	Not reported
Spill Prevention:	0. None
Dispenser:	0. None

Tank Number:	7
Status:	3. Closed - Removed
Capacity:	275
Product Stored:	Not reported
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	01/01/1900
Date Perm Closure:	08/31/2010
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	Not reported
Piping Type:	Not reported
Piping External Protection:	0. None
Overfill Prevention:	0. None
Piping Secondary Containment:	Not reported
Spill Prevention:	0. None
Dispenser:	0. None

AI340 **MITCHELL PLACE ASSOC.** **NY LTANKS** **S100137749**
ESE **10 MITCHELL PLACE** **N/A**
1/8-1/4 **WHITE PLAINS, NY**
0.227 mi.
1197 ft. **Site 5 of 12 in cluster AI**

Relative: LTANKS:
Higher

Name:	MITCHELL PLACE ASSOC.
Address:	10 MITCHELL PLACE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8902485 / 1989-10-02
Facility ID:	8902485
Site ID:	76057
Spill Date:	1989-06-09
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	Not reported
Cleanup Ceased:	1989-10-02
SWIS:	6017
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1989-06-09
CID:	Not reported
Water Affected:	Not reported

Actual:
217 ft.

MITCHELL PLACE ASSOC. (Continued) **S100137749**

Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1989-06-14
Spill Record Last Update:	1989-10-02
Spiller Name:	Not reported
Spiller Company:	MITCHELL PLACE ASSOC.
Spiller Address:	10 MITCHELL PLACE
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	71149
Latitude:	41.0307184
Longitude:	-73.7655743
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was TODD GHIOSAY 10/02/89: SPILLER HIRED EES TO PULL TANK AND REMOVE CONTAMINATED SOIL. SUMP WAS PERIODICALLY CLEANE AND FREE OIL REMOVED. NFA.
Remarks:	SPOKE W/BOB HYMAN. DIGGING ON 6/14/89 TO UNCOVER TANK & RETEST.

All TTF:

Facility ID:	8902485
Spill Number:	8902485
Spill Tank Test:	1535567
Site ID:	76057
Tank Number:	Not reported
Tank Size:	0
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	76057
Operable Unit ID:	928178
Operable Unit:	01
Material ID:	450186
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	Not reported
Recovered:	.00
Resource Affected:	Groundwater

MITCHELL PLACE ASSOC. (Continued) **S100137749**

Oxygenate: Not reported

AI341 **TEN MITCHELL PLACE** **NY UST** **U004441903**
ESE **10 MITCHELL PLACE** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10602**
0.227 mi.
1197 ft. **Site 6 of 12 in cluster AI**

Relative: **Higher**
Actual: **217 ft.**

WESTCHESTER CO. UST:

Name:	TEN MITCHELL PLACE
Address:	10 MITCHELL PLACE
City,State,Zip:	WHITE PLAINS, NY 10602
Id/Status:	3-492132 / Unregulated: <1101 gal. PBS
Operator Name:	S. Robert Tolchin
Owner Name:	Ten Mitchell Place Assoc.
Owner Street:	Suite 228 14 Rye Ridge Plaza
Owner Address2:	Not reported
Owner City:	Rye Brook
Owner State:	NY
Owner Zipcode:	10573
GDS Number:	Not reported
Tank Number:	1
Status:	3. Closed - Removed
Capacity:	3000
Product Stored:	Not reported
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	12/01/1957
Date Perm Closure:	06/01/1989
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	0. No Pipiing
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Overfill Prevention:	0. None
Piping Secondary Containment:	Not reported
Spill Prevention:	0. None
Dispenser:	1. Submersible

AG342 **126 S. LEXINGTON CEDAR HILL HOLDINGS** **NY UST** **U004439111**
South **126 SOUTH LEXINGTON AVENUE** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10606**
0.229 mi.
1210 ft. **Site 16 of 17 in cluster AG**

Relative: **Lower**
Actual: **196 ft.**

WESTCHESTER CO. UST:

Name:	126 S. LEXINGTON CEDAR HILL HOLDINGS
Address:	126 SOUTH LEXINGTON AVENUE
City,State,Zip:	WHITE PLAINS, NY 10606
Id/Status:	3-802064 / Unregulated
Operator Name:	Sloan / Roger

126 S. LEXINGTON CEDAR HILL HOLDINGS (Continued) **U004439111**

Owner Name:	Cedar Hill Holdings Realty c/o Saunders
Owner Street:	145 East 74th Street, Apt. PHD
Owner Address2:	Not reported
Owner City:	New York
Owner State:	NY
Owner Zipcode:	10021
GDS Number:	Not reported

Tank Number:	1
Status:	6. Closed - Work Permit Open
Capacity:	550
Product Stored:	0009. Gasoline
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	01/01/1900
Date Perm Closure:	03/31/2016
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	2. Underground/on Ground
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	0. None
Overfill Prevention:	0. None
Piping Secondary Containment:	0. None
Spill Prevention:	0. None
Dispenser:	0. None

Tank Number:	2
Status:	6. Closed - Work Permit Open
Capacity:	1200
Product Stored:	0009. Gasoline
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	01/01/1900
Date Perm Closure:	03/31/2016
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	2. Underground/on Ground
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	0. None
Overfill Prevention:	0. None
Piping Secondary Containment:	0. None
Spill Prevention:	0. None
Dispenser:	0. None

AI343 **GAS STATION** **NY LTANKS** **S102960212**
ESE **9 MITCHELL PL** **NY Spills** **N/A**
1/8-1/4 **WHITE PLAINS, NY**
0.230 mi.
1217 ft. **Site 7 of 12 in cluster AI**

Relative:
Higher

Actual:
217 ft.

LTANKS:

Name:	GAS STATION
Address:	9 MITCHELL PL
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9710474 / 1998-10-27
Facility ID:	9710474
Site ID:	199404
Spill Date:	1997-12-12
Spill Cause:	Tank Failure
Spill Source:	Gasoline Station or other PBS Facility
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1997-12-12
CID:	205
Water Affected:	Not reported
Spill Notifier:	Responsible Party
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	True
Remediation Phase:	0
Date Entered In Computer:	1997-12-12
Spill Record Last Update:	1999-01-20
Spiller Name:	Not reported
Spiller Company:	GAS STATION
Spiller Address:	9 MITCHELL PL
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	165966
Latitude:	41.0306190
Longitude:	-73.7655405
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY
Remarks:	Caller doing site work found contaminated soil. Luzon report - no further work required.

All Materials:

Site ID:	199404
Operable Unit ID:	1056851
Operable Unit:	01
Material ID:	328768
Material Code:	0009
Material Name:	gasoline
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00

GAS STATION (Continued) **S102960212**

Resource Affected: Soil
Oxygenate: Not reported

SPILLS:

Name:	DEVON PLAZA REALTY
Address:	9 MITCHELL PLACE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	1200312 / 2012-08-02
Facility ID:	1200312
Facility Type:	ER
DER Facility ID:	417359
Site ID:	462934
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	B3
SWIS:	6017
Spill Date:	2012-04-11
Investigator:	TDGHIOSA
Referred To:	Not reported
Reported to Dept:	2012-04-11
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Other
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2012-04-11
Spill Record Last Update:	2012-08-02
Spiller Name:	LEE LEWITT
Spiller Company:	LEE LEWITT
Spiller Address:	9 MITCHELL PL
Spiller Company:	999
Contact Name:	LEE LEWITT
Latitude:	41.0305117
Longitude:	-73.7651086
DEC Memo:	4/11/12: Former PBS Facility, Mitchell Place Garage. Barbara McDonald from WCDOH reports all USTs were reportedly removed when the site was deregulated. She will follow up with owner and caller, then update DEC. jod 07/31/12 Northeast Environmental submitted a soil remediation report. They reported that they unearthed a 1000 gallon fuel oil tank. More than 60% of the tank was under the building making removal impossible. The soil immediately beneath the tank was impacted but left in place. All surrounding soils were removed. A gw monitoring well was installed in the vicinity of the tank and no contaminants were detected. NE Environmental recommended removing any remaining impacted soil once the building is demolished. NFA TG
Remarks:	cleanup pending - tank under foundation of building

GAS STATION (Continued) **S102960212**

All Materials:

Site ID:	462934
Operable Unit ID:	1213041
Operable Unit:	01
Material ID:	2210932
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported
Resource Affected:	Soil
Oxygenate:	Not reported

AI344 **MITCHELL PLACE GARAGE** **NY UST** **U004440989**
ESE **9 MITCHELL PLACE** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.230 mi.
1217 ft. **Site 8 of 12 in cluster AI**

Relative:
Higher

Actual:
217 ft.

WESTCHESTER CO. UST:

Name:	MITCHELL PLACE GARAGE
Address:	9 MITCHELL PLACE
City,State,Zip:	WHITE PLAINS, NY 10601
Id/Status:	3-168998 / Administratively Closed
Operator Name:	Mitchell Place Garage Inc
Owner Name:	Guy Zanit Mark Rubeo
Owner Street:	9 Mitchell Pl
Owner Address2:	Not reported
Owner City:	White Plains
Owner State:	NY
Owner Zipcode:	10601
GDS Number:	Not reported
Tank Number:	1
Status:	0. Administratively closed
Capacity:	2010
Product Stored:	0009. Gasoline
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	05/01/1958
Date Perm Closure:	06/01/1994
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	Not reported
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Overfill Prevention:	0. None
Piping Secondary Containment:	Not reported
Spill Prevention:	0. None
Dispenser:	2. Suction

MITCHELL PLACE GARAGE (Continued) **U004440989**

Tank Number:	2
Status:	0. Administratively closed
Capacity:	2010
Product Stored:	0009. Gasoline
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	05/01/1958
Date Perm Closure:	06/01/1994
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	Not reported
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Overfill Prevention:	0. None
Piping Secondary Containment:	Not reported
Spill Prevention:	0. None
Dispenser:	2. Suction

Tank Number:	3
Status:	0. Administratively closed
Capacity:	1000
Product Stored:	Not reported
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	01/01/1973
Date Perm Closure:	06/01/1994
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	Not reported
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Overfill Prevention:	0. None
Piping Secondary Containment:	Not reported
Spill Prevention:	0. None
Dispenser:	2. Suction

AI345 **GAS STATION** **UST FINDER RELEASE** **1029061855**
ESE **9 MITCHELL PL** **N/A**
1/8-1/4 **WHITE PLAINS, NY 0**
0.230 mi.
1217 ft. **Site 9 of 12 in cluster AI**

Relative:
Higher

Actual:
217 ft.

UST FINDER RELEASE:

Object ID:	262526
Facility ID:	NY165966
Lust ID:	NY9710474
Name:	GAS STATION
Address:	9 MITCHELL PL
City,State,Zip:	WHITE PLAINS, NY 0
Address Match Type:	Not reported
Reported Date:	1997/12/12 15:59:59+00

GAS STATION (Continued) **1029061855**

Status:	No Further Action
Substance:	Not reported
Population within 1500ft:	4037
Domestic Wells within 1500ft:	0
Land Use:	Developed, High Intensity
Within SPA:	Yes
SPA PWS Facility ID:	NY7003493_76968
SPA Water Type:	SW - SurRELEASEe Water
SPA Facility Type:	RS - Reservoir
SPA HUC12:	20301020103
Within WHPA:	No
WHPA PWS Facility ID:	Not reported
WHPA Water Type:	Not reported
WHPA Facility Type:	Not reported
WHPA HUC12:	Not reported
Within 100yr Floodplain:	No
Tribe:	Not reported
EPA Region:	2
NFA Letter 1:	Not reported
NFA Letter 2:	Not reported
NFA Letter 3:	Not reported
NFA Letter 4:	Not reported
Closed With Residual Contaminate:	Not reported
Coordinate Source:	State
X Coord:	-73.76554
Y Coord:	41.0306200000001
Latitude:	41.0306199999999
Longitude:	-73.76554

AI346 **DEVON PLAZA REALTY** **NY UST** **U004439950**
ESE **9 MITCHELL PLACE** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.230 mi.
1217 ft. **Site 10 of 12 in cluster AI**

Relative: **Higher**
Actual: **217 ft.**

WESTCHESTER CO. UST:

Name:	DEVON PLAZA REALTY
Address:	9 MITCHELL PLACE
City,State,Zip:	WHITE PLAINS, NY 10601
Id/Status:	3-412384 / Unregulated
Operator Name:	Stillman Management
Owner Name:	Devon Plaza Realty
Owner Street:	440 Mamroneck Avenue
Owner Address2:	Suite S-512
Owner City:	Harrison
Owner State:	NY
Owner Zipcode:	10528
GDS Number:	Not reported
Tank Number:	1
Status:	3. Closed - Removed
Capacity:	2000
Product Stored:	Not reported
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	Not reported
Date Perm Closure:	04/01/1998
Tank Location:	5. Underground including vaulted with no access for inspection

DEVON PLAZA REALTY (Continued) **U004439950**

Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	0. No Pipiing
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Overfill Prevention:	Not reported
Piping Secondary Containment:	Not reported
Spill Prevention:	Not reported
Dispenser:	2. Suction

Tank Number:	2
Status:	3. Closed - Removed
Capacity:	2000
Product Stored:	0009. Gasoline
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	Not reported
Date Perm Closure:	04/01/1998
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	0. No Pipiing
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Overfill Prevention:	Not reported
Piping Secondary Containment:	Not reported
Spill Prevention:	Not reported
Dispenser:	2. Suction

Tank Number:	3
Status:	4. Closed - in place
Capacity:	1000
Product Stored:	Not reported
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	01/01/1900
Date Perm Closure:	05/16/2012
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	Not reported
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	0. None
Overfill Prevention:	0. None
Piping Secondary Containment:	Not reported
Spill Prevention:	0. None
Dispenser:	2. Suction

DEVON PLAZA REALTY (Continued) **U004439950**

Tank Number:	4
Status:	3. Closed - Removed
Capacity:	1000
Product Stored:	0022. Waste/Used Oil
Product Stored Percent:	Not reported
Tank Leak Detection:	Not reported
Date Installation:	01/01/1960
Date Perm Closure:	07/27/2016
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	Not reported
Tank External Protection:	Not reported
Tank Secondary Containment:	Not reported
Piping Location:	2. Underground/on Ground
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	Not reported
Overfill Prevention:	Not reported
Piping Secondary Containment:	Not reported
Spill Prevention:	Not reported
Dispenser:	Not reported

Tank Number:	5
Status:	1. In-Service
Capacity:	500
Product Stored:	0001. #2 Fuel Oil
Product Stored Percent:	Not reported
Tank Leak Detection:	Not reported
Date Installation:	05/01/2012
Date Perm Closure:	01/01/1900
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	10. Urethane clad steel
Tank Internal Protection:	Not reported
Tank External Protection:	2. Original sacrificial anode,9. Urethane
Tank Secondary Containment:	Not reported
Piping Location:	2. Underground/on Ground
Piping Type:	10. Copper
Piping External Protection:	6. Wrapped (Piping),9. Urethane
Overfill Prevention:	2. High Level Alarm
Piping Secondary Containment:	4. Double-Walled (underground only)
Spill Prevention:	1. Catch Basin
Dispenser:	2. Suction

AI347 **NICKY'S RESTAURANT** **NY LTANKS** **S100137599**
ESE **107 MAMARONECK AVE** **N/A**
1/8-1/4 **WHITE PLAINS, NY**
0.234 mi.
1234 ft. **Site 11 of 12 in cluster AI**

Relative: **Higher**

Actual: **219 ft.**

LTANKS:

Name:	NICKY'S RESTAURANT
Address:	107 MAMARONECK AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8900599 / 1989-05-03
Facility ID:	8900599
Site ID:	239748
Spill Date:	1989-04-19
Spill Cause:	Tank Test Failure

NICKY'S RESTAURANT (Continued) **S100137599**

Spill Source:	Commercial/Industrial
Spill Class:	C3
Cleanup Ceased:	1989-05-03
SWIS:	6017
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1989-04-19
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1989-04-25
Spill Record Last Update:	2003-09-29
Spiller Name:	Not reported
Spiller Company:	NICKY'S RESTAURANT
Spiller Address:	107 MAMARONECK AVE
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	197197
Latitude:	41.0300074
Longitude:	-73.7656351
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY / / : LINES WERE CAPPED OFF AND TANK PASSED.
Remarks:	2,000 GAL. PETRO-TITE LINE LEAK >10 GPH, EXCAVATE, REPAIR & RETEST DURING TEST PRODUCT ENTERED BASEMENT THRU WELL. WILL CALL BACK WHEN EXCAVATION IS TO BE DONE.

All TTF:

Facility ID:	8900599
Spill Number:	8900599
Spill Tank Test:	1535369
Site ID:	239748
Tank Number:	Not reported
Tank Size:	0
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	239748
Operable Unit ID:	926893
Operable Unit:	01

NICKY'S RESTAURANT (Continued) **S100137599**

Material ID:	559486
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

AI348 **DEVON PLAZA REALITY** **NY LTANKS** **S118953811**
ESE **109 MAMARONECK AVE** **NY AST** **N/A**
1/8-1/4 **WHITE PLAINS, NY**
0.236 mi.
1246 ft. **Site 12 of 12 in cluster AI**

Relative:
Higher

Actual:
220 ft.

LTANKS:

Name:	DEVON PLAZA REALITY
Address:	109 MAMARONECK AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9512203 / 1995-12-29
Facility ID:	9512203
Site ID:	254450
Spill Date:	1995-12-29
Spill Cause:	Tank Overfill
Spill Source:	Commercial/Industrial
Spill Class:	D4
Cleanup Ceased:	1995-12-29
SWIS:	6017
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1995-12-29
CID:	257
Water Affected:	Not reported
Spill Notifier:	Responsible Party
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1995-12-29
Spill Record Last Update:	1996-01-22
Spiller Name:	MR MENDOLA
Spiller Company:	ROBINSON OIL
Spiller Address:	500 EXECUTIVE BLVD
Spiller County:	001
Spiller Contact:	NONE
Spiller Phone:	(914) 332-0600
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	208418
Latitude:	41.0299623
Longitude:	-73.7656241
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY
Remarks:	customer over ordered driver clean up spill

DEVON PLAZA REALITY (Continued) **S118953811**

All Materials:

Site ID:	254450
Operable Unit ID:	1026423
Operable Unit:	01
Material ID:	359516
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	3.00
Units:	G
Recovered:	3.00
Resource Affected:	Soil
Oxygenate:	Not reported

WESTCHESTER CO. AST:

Name:	DEVON PLAZA REALTY
Address:	109 MAMARONECK AVE
City,State,Zip:	WHITE PLAINS, NY 10601
PBS Number:	3-053554
Site Status:	Unregulated: <1101 gal. PBS
GDS Number:	Not reported
Operator Name:	Devon Plaza Realty
Owner Name:	Devon Plaza Realty
Owner Street:	580 White Plains Rd
Owner Address2:	Not reported
Owner City/State/Zip:	Tarrytown, NY 10593
Tank Number:	1
Status:	1. In-Service
Date Installation:	01/01/1900
Capacity:	275
Product Stored:	0001. #2 Fuel Oil
Product Stored Percent:	Not reported
Date Perm Closure:	01/01/1900
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Leak Detection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	Not reported
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	0. None
Piping Leak Detection:	Not reported
Piping Secondary Containment:	Not reported
Overfill Prevention:	0. None
Spill Prevention:	0. None
Dispenser:	2. Suction
Tank Number:	2
Status:	1. In-Service
Date Installation:	01/01/1900
Capacity:	275

DEVON PLAZA REALITY (Continued) **S118953811**

Product Stored:	0001. #2 Fuel Oil
Product Stored Percent:	Not reported
Date Perm Closure:	01/01/1900
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Leak Detection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	Not reported
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	0. None
Piping Leak Detection:	Not reported
Piping Secondary Containment:	Not reported
Overfill Prevention:	0. None
Spill Prevention:	0. None
Dispenser:	2. Suction

AH349 **MUNICIPAL BUILDING** **NY UST** **U004441071**
ENE **255 MAIN ST** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.237 mi.
1254 ft. **Site 2 of 9 in cluster AH**

Relative:
Higher

Actual:
219 ft.

WESTCHESTER CO. UST:

Name:	MUNICIPAL BUILDING
Address:	255 MAIN ST
City,State,Zip:	WHITE PLAINS, NY 10601
Id/Status:	3-169552 / Unregulated: <1101 gal. PBS
Operator Name:	City Of White Plains
Owner Name:	City Of White Plains
Owner Street:	255 Main St
Owner Address2:	Not reported
Owner City:	White Plains
Owner State:	NY
Owner Zipcode:	10601
GDS Number:	Not reported
Tank Number:	25
Status:	4. Closed - in place
Capacity:	4000
Product Stored:	Not reported
Product Stored Percent:	Not reported
Tank Leak Detection:	Not reported
Date Installation:	03/01/1988
Date Perm Closure:	Not reported
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	2. Sacrificial Anode (no retrofit)
Tank Secondary Containment:	4. Double-Walled (underground only)
Piping Location:	2. Underground/on ground
Piping Type:	2. Galvanized steel
Piping External Protection:	Not reported
Overfill Prevention:	2. High Level Alarm
Piping Secondary Containment:	Not reported
Spill Prevention:	Not reported
Dispenser:	2. Suction

AH350 **CITY HALL** **UST FINDER RELEASE** **1029067729**
ENE **255 MAIN ST** **N/A**
1/8-1/4 **WHITE PLAINS, NY 0**
0.237 mi.
1254 ft. **Site 3 of 9 in cluster AH**

Relative:
Higher

Actual:
219 ft.

UST FINDER RELEASE:

Object ID:	262531
Facility ID:	NY238304
Lust ID:	NY8707220
Name:	CITY HALL
Address:	255 MAIN ST
City,State,Zip:	WHITE PLAINS, NY 0
Address Match Type:	Not reported
Reported Date:	1987/11/21 16:00:00+00
Status:	No Further Action
Substance:	Not reported
Population within 1500ft:	5902
Domestic Wells within 1500ft:	0
Land Use:	Developed, High Intensity
Within SPA:	Yes
SPA PWS Facility ID:	NY7003493_76968
SPA Water Type:	SW - SurRELEASEe Water
SPA Facility Type:	RS - Reservoir
SPA HUC12:	20301020103
Within WHPA:	No
WHPA PWS Facility ID:	Not reported
WHPA Water Type:	Not reported
WHPA Facility Type:	Not reported
WHPA HUC12:	Not reported
Within 100yr Floodplain:	No
Tribe:	Not reported
EPA Region:	2
NFA Letter 1:	Not reported
NFA Letter 2:	Not reported
NFA Letter 3:	Not reported
NFA Letter 4:	Not reported
Closed With Residual Contaminate:	Not reported
Coordinate Source:	State
X Coord:	-73.76521
Y Coord:	41.03319
Latitude:	41.0331899999999
Longitude:	-73.7652099999999

AH351 **WHITE PLAINS DEPT OF PUBLIC WORKS** **RCRA NonGen / NLR** **1010325206**
ENE **255 MAIN ST** **E MANIFEST** **NYN008015984**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.237 mi.
1254 ft. **Site 4 of 9 in cluster AH**

Relative:
Higher

Actual:
219 ft.

RCRA Listings:

Date Form Received by Agency:	20070329
Handler Name:	White Plains Dept Of Public Works
Handler Address:	Main St
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYN008015984
Contact Name:	Not reported
Contact Address:	MAIN ST
Contact City,State,Zip:	WHITE PLAINS, NY 10601
Contact Telephone:	Not reported

WHITE PLAINS DEPT OF PUBLIC WORKS (Continued) **1010325206**

Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Municipal
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R3
Mailing Address:	Not reported
Mailing City,State,Zip:	Not reported
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20070329
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No

WHITE PLAINS DEPT OF PUBLIC WORKS (Continued) **1010325206**

Sub-Part P Indicator: No

Historic Generators:

Receive Date:	20070329
Handler Name:	WHITE PLAINS DEPT OF PUBLIC WORKS
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20070328
Handler Name:	WHITE PLAINS DEPT OF PUBLIC WORKS
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20070328
Handler Name:	WHITE PLAINS DEPT OF PUBLIC WORKS
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

List of NAICS Codes and Descriptions:

NAICS Codes:	No NAICS Codes Found

Has the Facility Received Notices of Violations:

Found Violation:	Yes
Agency Which Determined Violation:	EPA
Violation Short Description:	Generators - General
Date Violation was Determined:	20070315
Actual Return to Compliance Date:	20070315
Return to Compliance Qualifier:	Documented
Violation Responsible Agency:	EPA
Scheduled Compliance Date:	Not reported
Enforcement Identifier:	001

WHITE PLAINS DEPT OF PUBLIC WORKS (Continued) **1010325206**

Date of Enforcement Action:	20070315
Enforcement Responsible Agency:	EPA
Enforcement Docket Number:	Not reported
Enforcement Attorney:	Not reported
Corrective Action Component:	No
Appeal Initiated Date:	Not reported
Appeal Resolution Date:	Not reported
Disposition Status Date:	20070315
Disposition Status:	AS
Disposition Status Description:	ACTION SATISFIED (CASE CLOSED)
Consent/Final Order Sequence Number:	Not reported
Consent/Final Order Respondent Name:	Not reported
Consent/Final Order Lead Agency:	Not reported
Enforcement Type:	VERBAL INFORMAL
Enforcement Responsible Person:	R2OSK
Enforcement Responsible Sub-Organization:	RCB
SEP Sequence Number:	Not reported
SEP Expenditure Amount:	Not reported
SEP Scheduled Completion Date:	Not reported
SEP Actual Date:	Not reported
SEP Defaulted Date:	Not reported
SEP Type:	Not reported
SEP Type Description:	Not reported
Proposed Amount:	Not reported
Final Monetary Amount:	Not reported
Paid Amount:	Not reported
Final Count:	Not reported
Final Amount:	Not reported

Evaluation Action Summary:

Evaluation Date:	20070315
Evaluation Responsible Agency:	EPA
Found Violation:	Yes
Evaluation Type Description:	COMPLIANCE EVALUATION INSPECTION
Evaluation Responsible Person Identifier:	R2OSK
Evaluation Responsible Sub-Organization:	RCB
Actual Return to Compliance Date:	20070315
Scheduled Compliance Date:	Not reported
Date of Request:	Not reported
Date Response Received:	Not reported
Request Agency:	Not reported
Former Citation:	Not reported

E MANIFEST:

Manifest Tracking Number:	019424438JJK
Last Updated Date:	20220804
Shipped Date:	20201125
Received Date:	20201125
Manifest Status:	Corrected
Submission Type:	DataImage5Copy
Origin Type:	Web
Generator EPA ID:	NYN008015984
Generator Name:	White Plains Dept Of Public Works
Generator Location Street Number:	255
Generator Location Street 1:	255 MAIN ST

WHITE PLAINS DEPT OF PUBLIC WORKS (Continued) **1010325206**

Generator Location Street 2:	Not reported
Generator Location City:	WHITE PLAINS
Generator Location State:	NY
Generator Location Zip:	10601
Generator Mail Street Number:	255
Generator Mail Street 1:	MAIN ST
Generator Mail Street 2:	Not reported
Generator Mail City:	White Plains
Generator Mail Zip:	10601
Generator Mail State:	NY
Generator Contact Company Name:	Not reported
Designated Facility EPA ID:	CT5000001495
Designated Facility Name:	Northeast Lamp Recycling Inc
Designated Facility Mail Street Number:	250
Designated Facility Mail Street 1:	Not reported
Designated Facility Mail Street 2:	MAIN ST
Designated Facility Mail City:	EAST WINDSOR
Designated Facility Mail Zip:	06088
Designated Facility Mail State:	CT
Designated Facility Location Street Number:	250
Designated Facility Location Street 1:	MAIN ST
Designated Facility Location Street 2:	Not reported
Designated Facility Location City:	EAST WINDSOR
Designated Facility Location Zip:	06088
Designated Facility Location State:	CT
Designated Facility Contact Company Name:	Not reported
Manifest Residue Indicator:	N
Rejection Indicator:	N

Federal Waste:

Manifest Tracking Number:	019424438JJK
Waste Line Number:	1
Federal Waste Code:	D009
Federal Waste:	MERCURY

State Waste:

Manifest Tracking Number:	019424438JJK
Waste Line Number:	1
State Waste Code Owner:	NY
State Waste Code:	R
State Waste:	Material Recovery of more than 75 percent of the total material. Waste management method code to be used on e-Manifest only

Transporter:

Manifest Tracking Number:	019424438JJK
Transporter Line Number:	1
Transporter EPA ID:	CT5000001495
Transporter Name:	Northeast Lamp Recycling Inc

Waste Line:

Manifest Tracking Number:	019424438JJK
Waste Line Number:	1
U.S. DOT Hazardous Indicator:	Y
U.S. DOT ID Number:	NA3077
U.S. DOT Description:	Rq, Na3077, Hazardous Waste, Solid, N.O.S,9, Pg Iii, (Mercury),

WHITE PLAINS DEPT OF PUBLIC WORKS (Continued) **1010325206**

	Erg#171
Non-Hazardous Waste Description:	Not reported
Number of Containers:	3
Container Type Code:	DM
Container Type Description:	Metal drums, barrels, kegs
Waste Quantity:	1500
Quantity Unit of Measure Code:	P
Quantity Unit of Measure Description:	Pounds
Waste Quantity, in Tons:	0.75
Acute Waste Quantity, in Tons:	0
Non-Acute Waste Quantity, in Tons:	0.75
Waste Quantity, in Kilograms:	680.2725
Acute Waste Quantity, in Kilograms:	0
Non-Acute Waste Quantity, in Kilorgrams:	680.2725
Management Method Code:	H010
Management Method Description:	METALS RECOVERY
Waste Residue Indicator:	N
Quantity Discrepancy Indicator:	Y
Waste Type Discrepancy Indicator:	N
Waste Density:	Not reported
Waste Density Unit of Measure Code:	Not reported
Waste Density Unit of Measure Description:	Not reported
Form Code:	Not reported
Form Code Description:	Not reported
Source Code:	Not reported
Source Code Description:	Not reported
Waste Minimization Code:	Not reported
Waste Minimization Code Description:	Not reported
Consent Number:	Not reported
EPA Waste Indicator:	Y

AH352 **WHITE PLAINS DEPT OF PUBLIC WORKS** **NY LTANKS** **S105912883**
ENE **255 MAIN STREET** **NY MANIFEST** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601** **NY SPDES**
0.237 mi.
1254 ft. **Site 5 of 9 in cluster AH**

Relative:
Higher

Actual:
219 ft.

LTANKS:

Name:	CITY HALL
Address:	255 MAIN ST
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8707220 / 1988-03-14
Facility ID:	8707220
Site ID:	294455
Spill Date:	1987-11-21
Spill Cause:	Tank Test Failure
Spill Source:	Institutional, Educational, Gov., Other
Spill Class:	D3
Cleanup Ceased:	1988-03-14
SWIS:	6017
Investigator:	RICCI
Referred To:	Not reported
Reported to Dept:	1987-11-21
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	1988-03-14
Recommended Penalty:	False

WHITE PLAINS DEPT OF PUBLIC WORKS (Continued) **S105912883**

Meets Standard:	True
UST Involvement:	True
Remediation Phase:	0
Date Entered In Computer:	1987-11-27
Spill Record Last Update:	1988-12-05
Spiller Name:	Not reported
Spiller Company:	MR. BROCCHI
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	238304
Latitude:	41.0331916
Longitude:	-73.7652069
DEC Memo:	Not reported
Remarks:	5K TANK SYSTEM -.1255 GPH

All TTF:

Facility ID:	8707220
Spill Number:	8707220
Spill Tank Test:	1532403
Site ID:	294455
Tank Number:	Not reported
Tank Size:	0
Material:	0009
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	294455
Operable Unit ID:	911097
Operable Unit:	01
Material ID:	466187
Material Code:	0009
Material Name:	gasoline
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	Not reported
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

NY MANIFEST:

EPA ID:	NYD000877423
Country:	USA

WHITE PLAINS DEPT OF PUBLIC WORKS (Continued) **S105912883**

Name:	White Plains Dept Of Public Works
Address:	255 MAIN STREET
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10601
Zip 4:	Not reported
Location Address 1:	255 MAIN STREET
Location Address 2:	Not reported
Location City,State,Zip:	WHITE PLAINS, NY 10601
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	White Plains Dept Of Public Works
Mailing Contact:	Dennis Defillipis
Mailing Address 1:	255 MAIN STREET ATTN TOM
Mailing Address 2:	Not reported
Mailing City,State,Zip:	WHITE PLAINS, NY 10601
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	914429214

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	CT5000001495
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	07/07/2011
Trans1 Recv Date:	07/07/2011
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	07/07/2011
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD000877423
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	CT5000001495
TSDF ID 2:	Not reported
Manifest Tracking Number:	006572842JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	Y
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H010
Waste Code a:	Mercury
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported

WHITE PLAINS DEPT OF PUBLIC WORKS (Continued) **S105912883**

Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	933
Units:	Pounds
Number of Containers:	2
Container Type:	Metal drums, barrels, kegs
Handling Method:	Recycle
Specific Gravity:	1
Document ID:	NJA1046776
Manifest Status:	Not reported
Trans1 State ID:	NJDEPS869
Year:	1991
Trans2 State ID:	Not reported
Generator Ship Date:	04/18/1991
Trans1 Recv Date:	04/18/1991
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	04/23/1991
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD000877423
Trans1 EPA ID:	ILD051060408
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002182897
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	The Following Spent Nonhalogenated Solvents: Xylene, Acetone, Ethyl Acetate, Ethyl Benzene, Ethyl Ether, Methyl Isobutyl Ketone, N-Butyl Alcohol, Cyclohexanone, And Methanol; All Spent Solvent Mixtures/Blends Containing, Before Use, Only The Above Spent Nonhalogenated Solvents; And All Spent Solvent Mixtures/Blends Containing, Before Use, One Or More Of The Above Nonhalogenated Solvents, And A Total Of Ten Percent Or More (By Volume) Of One Or More Of Those Solvents Listed In F001, F002, F004, And F005; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent Mixtures.
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported

WHITE PLAINS DEPT OF PUBLIC WORKS (Continued) **S105912883**

Quantity:	00403
Units:	Pounds
Number of Containers:	001
Container Type:	Metal drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00
Document ID:	NJA2926210
Manifest Status:	Not reported
Trans1 State ID:	06993
Year:	2000
Trans2 State ID:	Not reported
Generator Ship Date:	01/26/2000
Trans1 Recv Date:	01/26/2000
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	01/26/2000
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD000877423
Trans1 EPA ID:	NJD980772768
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD991291105
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Trichlorethylene
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	05000
Units:	Pounds
Number of Containers:	010
Container Type:	Metal drums, barrels, kegs
Handling Method:	Landfill
Specific Gravity:	01.00
Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NJD986607380
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	12/26/2007
Trans1 Recv Date:	12/26/2007
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	01/09/2008

WHITE PLAINS DEPT OF PUBLIC WORKS (Continued) **S105912883**

Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD000877423
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	SCD036275626
TSDF ID 2:	Not reported
Manifest Tracking Number:	000397168JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H061
Waste Code a:	The Following Spent Halogenated Solvents Used In Degreasing: Tetrachloroethylene, Trichlorethylene, Methylene Chloride, 1,1,1-Trichloroethane, Carbon Tetrachloride And Chlorinated Fluorocarbons; All Spent Solvent Mixtures/Blends Used In Degreasing Containing, Before Use, A Total Of Ten Percent Or More (By Volume) Of One Or More Of The Above Halogenated Solvents Or Those Solvents Listed In F002, F004, And F005; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent Mixtures.
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	1870
Units:	Gallons (liquids only)
Number of Containers:	34
Container Type:	Metal drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	1

EPA ID:	NYN008015984
Country:	USA
Name:	White Plains Dept Of Public Works
Address:	255 MAIN ST
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10601
Zip 4:	Not reported
Location Address 1:	255 MAIN ST
Location Address 2:	Not reported
Location City,State,Zip:	WHITE PLAINS, NY 10601
Location Zip 4:	Not reported

WHITE PLAINS DEPT OF PUBLIC WORKS (Continued) **S105912883**

Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	White Plains Dept Of Public Works
Mailing Contact:	White Plains Dept Of Public Works
Mailing Address 1:	255 MAIN ST
Mailing Address 2:	Not reported
Mailing City,State,Zip:	WHITE PLAINS, NY 10601
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	9144226943

SPDES:

Name:	Thomas M Roach
Address:	255 MAIN STREET
City,State,Zip:	WHITE PLAINS, NY 10601
Permit Number:	NYR20A230
State-Region:	3
Expiration Date:	Not reported
Current Major Minor Status:	Not reported
Primary Facility SIC Code:	Not reported
State Water Body Name:	Not reported
Limit Set Status Flag:	Not reported
Total Actual Average Flow(MGD):	Not reported
Total App Design Flow(MGD):	Not reported
UDF1:	Not reported
Lat/Long:	Not reported
DMR Cognizant Official:	Not reported
UDF2:	Not reported
UDF3:	Not reported
FIPS County Code:	Not reported

Non-Gov Permit Affiliation Type Desc:	Not reported
Non-Gov Permit Org Formal Name:	Not reported
Non-Gov Permit Street Address:	Not reported
Non-Gov Permit Supplemental Location:	Not reported
Non-Gov Permit City:	Not reported
Non-Gov Permit State Code:	Not reported
Non-Gov Permit Zip Code:	Not reported
Non-Gov Facility Affiliation Type Desc:	Not reported
Non-Gov Facility Org Formal Name:	Not reported
Non-Gov Facility Street Address:	Not reported
Non-Gov Facility Supplemental Location:	Not reported
Non-Gov Facility City:	Not reported
Non-Gov Facility State Code:	Not reported
Non-Gov Facility Zip Code:	Not reported
State Water Body:	Not reported
Region Permit Processed:	Not reported
Dow Discharge Class Code:	Not reported
SPDES Class Description:	Not reported
Affiliation Type Description:	Not reported
Name:	Not reported
Contacts Title:	Not reported

WHITE PLAINS DEPT OF PUBLIC WORKS (Continued) **S105912883**

Contacts Email:	Not reported
NOI Submission Date:	Not reported
Facility Type:	Not reported

AK353 **124 MAMARONECK AVENUE** **NY UST** **U004439106**
ESE **124 MAMARONECK AVENUE** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.240 mi.
1267 ft. **Site 1 of 7 in cluster AK**

Relative: **Higher**
Actual: **225 ft.**

WESTCHESTER CO. UST:

Name:	124 MAMARONECK AVENUE
Address:	124 MAMARONECK AVENUE
City,State,Zip:	WHITE PLAINS, NY 10601
Id/Status:	3-412007 / Unregulated: <1101 gal. PBS
Operator Name:	124 Mamoraneck Avenue Associat
Owner Name:	124-128 Mamaroneck Avenue Asso
Owner Street:	3 W Main St
Owner Address2:	Not reported
Owner City:	Elmsford
Owner State:	NY
Owner Zipcode:	10523
GDS Number:	Not reported
Tank Number:	1
Status:	0. Administratively closed
Capacity:	2000
Product Stored:	Not reported
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	01/01/1900
Date Perm Closure:	06/01/1994
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	Not reported
Piping Type:	2. Galvanized steel
Piping External Protection:	0. None
Overfill Prevention:	Not reported
Piping Secondary Containment:	Not reported
Spill Prevention:	Not reported
Dispenser:	2. Suction

AH354 **CON EDISON** **NY MANIFEST** **S117065994**
ENE **218 MAIN ST** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.243 mi.
1281 ft. **Site 6 of 9 in cluster AH**

Relative: **Higher**
Actual: **220 ft.**

NY MANIFEST:

EPA ID:	NYP004586020
Country:	USA
Name:	Con Edison
Address:	218 MAIN ST
Address 2:	Not reported

CON EDISON (Continued) **S117065994**

City,State,Zip: WHITE PLAINS, NY 10601
Zip 4: Not reported
Location Address 1: 218 MAIN ST
Location Address 2: Not reported
Location City,State,Zip: WHITE PLAINS, NY 10601
Location Zip 4: Not reported
Facility Status: Not reported
Total Tanks: Not reported
Code: BP

Mailing:
Mailing Name: Con Edison
Mailing Contact: Tom Telling
Mailing Address 1: 4 IRVING PLACE-15TH FLOOR
Mailing Address 2: Not reported
Mailing City,State,Zip: NEW YORK, NY 10003
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: 2124603770

Manifest Data:
Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: NYD006982359
Year: 2018
Trans2 State ID: Not reported
Generator Ship Date: 07/03/2014
Trans1 Recv Date: 07/03/2014
Trans2 Recv Date: Not reported
TSD Site Recv Date: 07/03/2014
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYP004586020
Trans1 EPA ID: Not reported
Trans2 EPA ID: Not reported
TSDF ID 1: NYD000705939
TSDF ID 2: Not reported
Manifest Tracking Number: 006466303FLE
Import Indicator: N
Export Indicator: N
Discr Quantity Indicator: N
Discr Type Indicator: N
Discr Residue Indicator: N
Discr Partial Reject Indicator: N
Discr Full Reject Indicator: N
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: H135
Waste Code a: Benzene
Waste Code b: Not reported
Waste Code c: Not reported
Waste Code e: Not reported
Waste Code f: Not reported
Waste Code g: Not reported
Waste Code 1: Not reported
Waste Code 2: Not reported

CON EDISON (Continued) **S117065994**

Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	85
Units:	Gallons (liquids only)
Number of Containers:	3
Container Type:	Metal drums, barrels, kegs
Handling Method:	Treat
Specific Gravity:	1
Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	07/04/2014
Trans1 Recv Date:	07/04/2014
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	07/04/2014
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004586020
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NYD000705939
TSDF ID 2:	Not reported
Manifest Tracking Number:	006466358FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H135
Waste Code a:	Benzene
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	1
Units:	Gallons (liquids only)
Number of Containers:	1
Container Type:	Metal drums, barrels, kegs
Handling Method:	Treat
Specific Gravity:	1

AK355 **PER-BAR** **NY LTANKS** **S100140366**
ESE **124 MAMARONECK AVE** **N/A**
1/8-1/4 **WHITE PLAINS, NY**
0.243 mi.
1282 ft. **Site 2 of 7 in cluster AK**

Relative:
Higher

Actual:
223 ft.

LTANKS:

Name:	PER-BAR
Address:	124 MAMARONECK AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8802839 / 1989-01-18
Facility ID:	8802839
Site ID:	116904
Spill Date:	1988-06-29
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	Not reported
Cleanup Ceased:	1989-01-18
SWIS:	6017
Investigator:	jeokesso
Referred To:	Not reported
Reported to Dept:	1988-06-29
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	1989-01-18
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1988-03-23
Spill Record Last Update:	1989-02-07
Spiller Name:	Not reported
Spiller Company:	BRIAN COMI
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	101701
Latitude:	41.0296742
Longitude:	-73.7656414
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was OKESSON
Remarks:	FAILED WITH GROSS LEAK. PBS TO FOLLOW.RETEST NEEDED.

All TTF:

Facility ID:	8802839
Spill Number:	8802839
Spill Tank Test:	1534211
Site ID:	116904
Tank Number:	Not reported
Tank Size:	0
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00

PER-BAR (Continued) **S100140366**

Test Method 2: Unknown
Leak Rate: .00
Gross Fail: Not reported
Modified By: Spills
Last Modified Date: Not reported

All Materials:
Site ID: 116904
Operable Unit ID: 918126
Operable Unit: 01
Material ID: 458404
Material Code: 0001A
Material Name: #2 fuel oil
Case No.: Not reported
Material FA: Petroleum
Quantity: .00
Units: G
Recovered: .00
Resource Affected: Soil
Oxygenate: Not reported

AL356 **210 MARTINE AVENUE** **NY UST** **U004439168**
East **210 MARTINE AVENUE** **N/A**
1/8-1/4 **WHITE PLAINS, NY**
0.243 mi.
1285 ft. **Site 1 of 3 in cluster AL**

Relative: **Higher**
Actual: **217 ft.**

WESTCHESTER CO. UST:
Name: 210 MARTINE AVENUE
Address: 210 MARTINE AVENUE
City,State,Zip: WHITE PLAINS, NY
Id/Status: 3-801056 / Unregulated
Operator Name: Ron Sinclair
Owner Name: WRG Management
Owner Street: Not reported
Owner Address2: Not reported
Owner City: Not reported
Owner State: Not reported
Owner Zipcode: Not reported
GDS Number: Not reported

Tank Number: 001
Status: 4. Closed - in place
Capacity: 5000
Product Stored: Not reported
Product Stored Percent: Not reported
Tank Leak Detection: 0. None
Date Installation: 01/01/1900
Date Perm Closure: 11/16/2005
Tank Location: 5. Underground including vaulted with no access for inspection
Tank Type: 1. Steel/Carbon steel/Iron
Tank Internal Protection: 0. None
Tank External Protection: 0. None
Tank Secondary Containment: 0. None
Piping Location: 2. Underground/on ground
Piping Type: 1. Steel/Carbon/ steel/iron

210 MARTINE AVENUE (Continued) **U004439168**

Piping External Protection:	0. None
Overfill Prevention:	0. None
Piping Secondary Containment:	Not reported
Spill Prevention:	0. None
Dispenser:	0. None

AH357 **T S T WHITE PLAINS LLC** **NY Spills** **1004760649**
ENE **220 MAIN ST** **RCRA NonGen / NLR** **NYR000054361**
1/8-1/4 **WHITE PLAINS, NY 10601** **NY MANIFEST**
0.245 mi.
1291 ft. **Site 7 of 9 in cluster AH**

Relative: **Higher**
Actual: **220 ft.**

SPILLS:

Name:	ABANDONED MACY'S STORE
Address:	220 MAIN ST
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0000781 / 2002-02-27
Facility ID:	0000781
Facility Type:	ER
DER Facility ID:	283327
Site ID:	327322
DEC Region:	3
Spill Cause:	Unknown
Spill Class:	C3
SWIS:	6000
Spill Date:	2000-04-19
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	2000-04-19
CID:	397
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Fire Department
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2000-04-19
Spill Record Last Update:	2002-03-22
Spiller Name:	DEBBIE SMITH
Spiller Company:	ABANDONED MACY'S STORE
Spiller Address:	220 MAIN ST
Spiller Company:	001
Contact Name:	Not reported
Latitude:	41.0329779
Longitude:	-73.7654369
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY 04/19/2000 BUILDING UNDER DEMOLITION. TANK WAS REMOVED BUT SLUDGE AND PRODUCT REMAIN. F.D. THOUGHT #4 FUEL OIL. SPOKE WITH WCHD. 02/27/2002 S. GOREAU OF THE WCDOH REPORTED THAT AREA IS UNDER LARGE REDEVELOPMENT. ORIGINAL BUILDING HAS BEEN RAZED AND MAJOR EXCAVAATION WORK HAS ALTERED THE PROPERTY. NO FURTHER ACTION.
Remarks:	FIRE DEPT DOING A WALK THROUGH OF ABANDONED BUILDING DISCOVERED

T S T WHITE PLAINS LLC (Continued) **1004760649**

MATERIAL IN THE OIL TANK VAULT ROOM SUBJECT LISTED AS CONTACT FOR SPILLER IS PROERTY MANAGER ALSO SECURITY GUARD ON SITE.

All Materials:

Site ID:	327322
Operable Unit ID:	822544
Operable Unit:	01
Material ID:	289019
Material Code:	0003A
Material Name:	#6 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

RCRA Listings:

Date Form Received by Agency:	20070101
Handler Name:	T S T White Plains Llc
Handler Address:	Main St
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYR000054361
Contact Name:	CHARLES REID
Contact Address:	MADISON AVE
Contact City,State,Zip:	NEW YORK, NY 10022
Contact Telephone:	212-715-0300
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Not reported
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R3
Mailing Address:	MADISON AVE
Mailing City,State,Zip:	NEW YORK, NY 10022
Owner Name:	T S T White Plains Llc
Owner Type:	Private
Operator Name:	T S T White Plains Llc
Operator Type:	Private
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No

T S T WHITE PLAINS LLC (Continued) **1004760649**

Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20150414
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Hazardous Waste Summary:

Waste Code:	D000
Waste Description:	Not Defined
Waste Code:	D001
Waste Description:	Ignitable Waste
Waste Code:	D002
Waste Description:	Corrosive Waste
Waste Code:	D006
Waste Description:	Cadmium
Waste Code:	D009
Waste Description:	Mercury
Waste Code:	F001
Waste Description:	The Following Spent Halogenated Solvents Used In Degreasing: Tetrachloroethylene, Trichlorethylene, Methylene Chloride, 1,1,1-Trichloroethane, Carbon Tetrachloride And Chlorinated Fluorocarbons; All Spent Solvent Mixtures/Blends Used In Degreasing Containing, Before Use, A Total Of Ten Percent Or More (By Volume) Of One Or More Of The Above Halogenated Solvents Or Those Solvents Listed In F002, F004, And F005; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent Mixtures.

T S T WHITE PLAINS LLC (Continued) **1004760649**

Handler - Owner Operator:

Owner/Operator Indicator:	Owner
Owner/Operator Name: T S T WHITE PLAINS LLC	
Legal Status:	Private
Date Became Current:	Not reported
Date Ended Current:	Not reported
Owner/Operator Address:	520 MADISON AVE
Owner/Operator City,State,Zip:	NEW YORK, NY 10022
Owner/Operator Telephone:	212-715-0300
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported
Owner/Operator Email:	Not reported

Owner/Operator Indicator:	Owner
Owner/Operator Name: T S T WHITE PLAINS LLC	
Legal Status:	Private
Date Became Current:	Not reported
Date Ended Current:	Not reported
Owner/Operator Address:	520 MADISON AVE
Owner/Operator City,State,Zip:	NEW YORK, NY 10022
Owner/Operator Telephone:	212-715-0300
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported
Owner/Operator Email:	Not reported

Owner/Operator Indicator:	Operator
Owner/Operator Name: T S T WHITE PLAINS LLC	
Legal Status:	Private
Date Became Current:	Not reported
Date Ended Current:	Not reported
Owner/Operator Address:	520 MADISON AVE
Owner/Operator City,State,Zip:	NEW YORK, NY 10022
Owner/Operator Telephone:	212-715-0300
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported
Owner/Operator Email:	Not reported

Historic Generators:

Receive Date:	20060101
Handler Name: T S T WHITE PLAINS LLC	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20070101
Handler Name: T S T WHITE PLAINS LLC	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No

T S T WHITE PLAINS LLC (Continued) **1004760649**

Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 19980504
Handler Name: T S T WHITE PLAINS LLC
Federal Waste Generator Description: Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

NY MANIFEST:
EPA ID: NYR000054361
Country: USA
Name: Lc White Plains Llc
Address: 220 MAIN ST
Address 2: Not reported
City,State,Zip: WHITE PLAINS, NY 10601
Zip 4: Not reported
Location Address 1: 220 MAIN ST
Location Address 2: Not reported
Location City,State,Zip: WHITE PLAINS, NY
Location Zip 4: Not reported
Facility Status: Not reported
Total Tanks: Not reported
Code: BP

Mailing:
Mailing Name: Lc White Plains Llc
Mailing Contact: Lc White Plains Llc
Mailing Address 1: 220 MAIN STREET
Mailing Address 2: Not reported
Mailing City,State,Zip: WHITE PLAINS, NY 10601
Mailing Zip 4: Not reported
Mailing Country: USA

T S T WHITE PLAINS LLC (Continued) **1004760649**

Mailing Phone: 0000000000

Manifest Data:

Document ID:	MIA4344290
Manifest Status:	Not reported
Trans1 State ID:	E43375MA
Year:	1998
Trans2 State ID:	Not reported
Generator Ship Date:	06/08/1998
Trans1 Recv Date:	06/08/1998
Trans2 Recv Date:	06/11/1998
TSD Site Recv Date:	06/11/1998
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000054361
Trans1 EPA ID:	MID982606287
Trans2 EPA ID:	MID980684088
TSDF ID 1:	MID980615298
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	The Following Spent Nonhalogenated Solvents: Xylene, Acetone, Ethyl Acetate, Ethyl Benzene, Ethyl Ether, Methyl Isobutyl Ketone, N-Butyl Alcohol, Cyclohexanone, And Methanol; All Spent Solvent Mixtures/Blends Containing, Before Use, Only The Above Spent Nonhalogenated Solvents; And All Spent Solvent Mixtures/Blends Containing, Before Use, One Or More Of The Above Nonhalogenated Solvents, And A Total Of Ten Percent Or More (By Volume) Of One Or More Of Those Solvents Listed In F001, F002, F004, And F005; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent Mixtures.
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00005
Units:	Gallons (liquids only)
Number of Containers:	001
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00
Waste Code 7:	The Following Spent Halogenated Solvents Used In Degreasing: Tetrachloroethylene, Trichlorethylene, Methylene Chloride, 1,1,1-Trichloroethane, Carbon Tetrachloride And Chlorinated Fluorocarbons; All Spent Solvent Mixtures/Blends Used In Degreasing Containing, Before Use, A Total Of Ten Percent Or More (By Volume) Of

T S T WHITE PLAINS LLC (Continued) **1004760649**

	One Or More Of The Above Halogenated Solvents Or Those Solvents Listed In F002, F004, And F005; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent Mixtures.
Waste Code 8:	Not reported
Waste Code:	Not reported
Waste Code 10:	Not reported
Waste Code 11:	Not reported
Quantity:	00330
Units:	Gallons (liquids only)
Number of Containers:	006
Container Type:	Metal drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00
Waste Code 12:	The Following Spent Halogenated Solvents Used In Degreasing: Tetrachloroethylene, Trichlorethylene, Methylene Chloride, 1,1,1-Trichloroethane, Carbon Tetrachloride And Chlorinated Fluorocarbons; All Spent Solvent Mixtures/Blends Used In Degreasing Containing, Before Use, A Total Of Ten Percent Or More (By Volume) Of One Or More Of The Above Halogenated Solvents Or Those Solvents Listed In F002, F004, And F005; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent Mixtures.
Waste Code 13:	Not reported
Waste Code 14:	Not reported
Waste Code 15:	Not reported
Waste Code 16:	Not reported
Quantity:	00110
Units:	Gallons (liquids only)
Number of Containers:	002
Container Type:	Metal drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00

Document ID:	MIA4344291
Manifest Status:	Not reported
Trans1 State ID:	E43375MA
Year:	1998
Trans2 State ID:	Not reported
Generator Ship Date:	06/08/1998
Trans1 Recv Date:	06/08/1998
Trans2 Recv Date:	06/11/1998
TSD Site Recv Date:	06/11/1998
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000054361
Trans1 EPA ID:	MID982606287
Trans2 EPA ID:	MID980684088
TSDF ID 1:	MID980615298
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported

T S T WHITE PLAINS LLC (Continued) **1004760649**

Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	The Following Spent Halogenated Solvents: Tetrachloroethylene, Methylene Chloride, Trichloroethylene, 1,1,1-Trichloroethane, Chlorobenzene, 1,1,2-Trichloro-1,2,2-Trifluoroethane, Ortho-Dichlorobenzene, Trichlorofluoromethane, And 1,1,2, Trichloroethane; All Spent Solvent Mixtures/Blends Containing, Before Use, A Total Of Ten Percent Or More (By Volume) Of One Or More Of The Above Halogenated Solvents Or Those Solvents Listed In F001, F004, And F005; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent Mixtures.
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00110
Units:	Gallons (liquids only)
Number of Containers:	002
Container Type:	Metal drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00
Waste Code 7:	The Following Spent Halogenated Solvents Used In Degreasing: Tetrachloroethylene, Trichlorethylene, Methylene Chloride, 1,1,1-Trichloroethane, Carbon Tetrachloride And Chlorinated Fluorocarbons; All Spent Solvent Mixtures/Blends Used In Degreasing Containing, Before Use, A Total Of Ten Percent Or More (By Volume) Of One Or More Of The Above Halogenated Solvents Or Those Solvents Listed In F002, F004, And F005; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent Mixtures.
Waste Code 8:	Not reported
Waste Code:	Not reported
Waste Code 10:	Not reported
Waste Code 11:	Not reported
Quantity:	00055
Units:	Gallons (liquids only)
Number of Containers:	001
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00
Document ID:	MIA4344296
Manifest Status:	Not reported
Trans1 State ID:	E48325
Year:	1998
Trans2 State ID:	Not reported
Generator Ship Date:	06/08/1998
Trans1 Recv Date:	06/08/1998
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	06/10/1998
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000054361
Trans1 EPA ID:	MID982606287
Trans2 EPA ID:	Not reported
TSDF ID 1:	MID980991566

T S T WHITE PLAINS LLC (Continued) **1004760649**

TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Corrosive Waste
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00055
Units:	Gallons (liquids only)
Number of Containers:	001
Container Type:	Metal drums, barrels, kegs
Handling Method:	Treat
Specific Gravity:	01.00
Waste Code 7:	Corrosive Waste
Waste Code 8:	Not reported
Waste Code:	Not reported
Waste Code 10:	Not reported
Waste Code 11:	Not reported
Quantity:	00055
Units:	Gallons (liquids only)
Number of Containers:	001
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Treat
Specific Gravity:	01.00
Waste Code 12:	Corrosive Waste
Waste Code 13:	Not reported
Waste Code 14:	Not reported
Waste Code 15:	Not reported
Waste Code 16:	Not reported
Quantity:	00055
Units:	Gallons (liquids only)
Number of Containers:	001
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Treat
Specific Gravity:	01.00

Document ID:	NYB7516719
Manifest Status:	Not reported
Trans1 State ID:	E43375MI
Year:	1998
Trans2 State ID:	Not reported
Generator Ship Date:	06/08/1998
Trans1 Recv Date:	06/08/1998
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	06/19/1998

T S T WHITE PLAINS LLC (Continued) **1004760649**

Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000054361
Trans1 EPA ID:	MID982606287
Trans2 EPA ID:	Not reported
TSDF ID 1:	GAD093380814
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Ignitable Waste
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00110
Units:	Gallons (liquids only)
Number of Containers:	002
Container Type:	Metal drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00
Waste Code 7:	Creosote
Waste Code 8:	Not reported
Waste Code:	Not reported
Waste Code 10:	Not reported
Waste Code 11:	Not reported
Quantity:	00055
Units:	Gallons (liquids only)
Number of Containers:	001
Container Type:	Metal drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00

Document ID:	NYB7516728
Manifest Status:	Not reported
Trans1 State ID:	E43375MI
Year:	1998
Trans2 State ID:	Not reported
Generator Ship Date:	06/08/1998
Trans1 Recv Date:	06/08/1998
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	06/10/1998
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000054361
Trans1 EPA ID:	MID982606287
Trans2 EPA ID:	Not reported

T S T WHITE PLAINS LLC (Continued) **1004760649**

TSDF ID 1:	OHD083377010
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Ignitable Waste
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00057
Units:	Pounds
Number of Containers:	001
Container Type:	Metal drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00
Waste Code 7:	Ignitable Waste
Waste Code 8:	Not reported
Waste Code:	Not reported
Waste Code 10:	Not reported
Waste Code 11:	Not reported
Quantity:	00002
Units:	Gallons (liquids only)
Number of Containers:	001
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00
Waste Code 12:	Ignitable Waste
Waste Code 13:	Not reported
Waste Code 14:	Not reported
Waste Code 15:	Not reported
Waste Code 16:	Not reported
Quantity:	00050
Units:	Pounds
Number of Containers:	001
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00
Waste Code 17:	Corrosive Waste
Waste Code 18:	Not reported
Waste Code 19:	Not reported
Waste Code 20:	Not reported
Waste Code 21:	Not reported
Quantity:	00004
Units:	Gallons (liquids only)
Number of Containers:	002
Container Type:	Fiberboard or plastic drums, barrels, kegs

T S T WHITE PLAINS LLC (Continued) **1004760649**

Handling Method:	Burn
Specific Gravity:	01.00
Document ID:	NYB7516737
Manifest Status:	Not reported
Trans1 State ID:	E43375MI
Year:	1998
Trans2 State ID:	Not reported
Generator Ship Date:	06/08/1998
Trans1 Recv Date:	06/08/1998
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	06/10/1998
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000054361
Trans1 EPA ID:	MID982606287
Trans2 EPA ID:	Not reported
TSDF ID 1:	OHD083377010
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Mercury
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00001
Units:	Gallons (liquids only)
Number of Containers:	001
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Treat
Specific Gravity:	01.00
Waste Code 7:	Cadmium
Waste Code 8:	Not reported
Waste Code:	Not reported
Waste Code 10:	Not reported
Waste Code 11:	Not reported
Quantity:	00020
Units:	Pounds
Number of Containers:	001
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Treat
Specific Gravity:	01.00

AH358 **MACY'S** **NY UST** **U004440820**
ENE **220 MAIN ST** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10600**
0.245 mi.
1291 ft. **Site 8 of 9 in cluster AH**

Relative:
Higher

Actual:
220 ft.

WESTCHESTER CO. UST:

Name:	MACY'S
Address:	220 MAIN ST
City,State,Zip:	WHITE PLAINS, NY 10600
Id/Status:	3-167029 / Unregulated: <1101 gal. PBS
Operator Name:	Macys New York
Owner Name:	Macys North East, Inc.
Owner Street:	220 Main St
Owner Address2:	Not reported
Owner City:	White Plains
Owner State:	NY
Owner Zipcode:	10600
GDS Number:	Not reported
Tank Number:	1
Status:	3. Closed - Removed
Capacity:	10000
Product Stored:	Not reported
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	12/01/1949
Date Perm Closure:	12/01/1999
Tank Location:	6. Underground, vaulted, with access
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	Not reported
Piping Location:	0. No Pipiing
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Overfill Prevention:	Not reported
Piping Secondary Containment:	Not reported
Spill Prevention:	Not reported
Dispenser:	2. Suction
Tank Number:	2
Status:	3. Closed - Removed
Capacity:	10000
Product Stored:	Not reported
Product Stored Percent:	Not reported
Tank Leak Detection:	0. None
Date Installation:	12/01/1949
Date Perm Closure:	12/01/1999
Tank Location:	6. Underground, vaulted, with access
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	Not reported
Piping Location:	0. No Pipiing
Piping Type:	1. Steel/Carbon/ steel/iron
Piping External Protection:	0. None
Overfill Prevention:	Not reported

MACY'S (Continued) **U004440820**

Piping Secondary Containment: Not reported
Spill Prevention: Not reported
Dispenser: 2. Suction

AH359 **T S T WHITE PLAINS LLC** **RCRA-VSQG** **1010325228**
ENE **220 MAIN ST** **FINDS** **NYN008016099**
1/8-1/4 **WHITE PLAINS, NY 10601** **ECHO**
0.245 mi.
1291 ft. **Site 9 of 9 in cluster AH**

Relative: **Higher**
Actual: **220 ft.**

RCRA Listings:

Date Form Received by Agency:	20070403
Handler Name:	Circuit City Store #3696
Handler Address:	Main St
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYN008016099
Contact Name:	Not reported
Contact Address:	MAIN ST
Contact City,State,Zip:	WHITE PLAINS, NY 10601
Contact Telephone:	Not reported
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Conditionally Exempt Small Quantity Generator
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Handler Activities
State District Owner:	Ny
State District:	NYSDEC R3
Mailing Address:	MAIN ST
Mailing City,State,Zip:	WHITE PLAINS, NY 10601
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No

T S T WHITE PLAINS LLC (Continued) **1010325228**

Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20070405
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20070403
Handler Name: CIRCUIT CITY STORE #3696	
Federal Waste Generator Description:	Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20070402
Handler Name: CIRCUIT CITY STORE #3696	
Federal Waste Generator Description:	Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20070402
Handler Name: CIRCUIT CITY STORE #3696	
Federal Waste Generator Description:	Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No

T S T WHITE PLAINS LLC (Continued) **1010325228**

Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Has the Facility Received Notices of Violations:
Found Violation: No
Agency Which Determined Violation: Not reported
Violation Short Description: Not reported
Date Violation was Determined: Not reported
Actual Return to Compliance Date: Not reported
Return to Compliance Qualifier: Not reported
Violation Responsible Agency: Not reported
Scheduled Compliance Date: Not reported
Enforcement Identifier: Not reported
Date of Enforcement Action: Not reported
Enforcement Responsible Agency: Not reported
Enforcement Docket Number: Not reported
Enforcement Attorney: Not reported
Corrective Action Component: Not reported
Appeal Initiated Date: Not reported
Appeal Resolution Date: Not reported
Disposition Status Date: Not reported
Disposition Status: Not reported
Disposition Status Description: Not reported
Consent/Final Order Sequence Number: Not reported
Consent/Final Order Respondent Name: Not reported
Consent/Final Order Lead Agency: Not reported
Enforcement Type: Not reported
Enforcement Responsible Person: Not reported
Enforcement Responsible Sub-Organization: Not reported
SEP Sequence Number: Not reported
SEP Expenditure Amount: Not reported
SEP Scheduled Completion Date: Not reported
SEP Actual Date: Not reported
SEP Defaulted Date: Not reported
SEP Type: Not reported
SEP Type Description: Not reported
Proposed Amount: Not reported
Final Monetary Amount: Not reported
Paid Amount: Not reported
Final Count: Not reported
Final Amount: Not reported

Evaluation Action Summary:
Evaluation Date: 20070315
Evaluation Responsible Agency: EPA
Found Violation: No
Evaluation Type Description: COMPLIANCE EVALUATION INSPECTION
Evaluation Responsible Person Identifier: R2OSK

T S T WHITE PLAINS LLC (Continued) **1010325228**

Evaluation Responsible Sub-Organization:	RCB
Actual Return to Compliance Date:	Not reported
Scheduled Compliance Date:	Not reported
Date of Request:	Not reported
Date Response Received:	Not reported
Request Agency:	Not reported
Former Citation:	Not reported

FINDS:
Registry ID: 110004542889

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:
The Resource Conservation and Recovery Act Information System (RCRAInfo) is EPA's comprehensive information system in support of the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. It tracks many types of information about generators, transporters, treaters, storers, and disposers of hazardous waste.

Click this hyperlink while viewing on your computer to access additional FINDS: detail in the EDR Site Report.

ECHO:

Envid:	1010325228
Registry ID:	110004542889

DFR URL:

Name:	T S T WHITE PLAINS LLC
Address:	220 MAIN ST
City,State,Zip:	WHITE PLAINS, NY 10601

AG360 **HYDRAULIC FLUID TO SEWER** **NY LTANKS** **S104877043**
South **134 SOUTH LEXINGTON AVE** **NY Spills** **N/A**
1/8-1/4 **WHITE PLAINS, NY**
0.245 mi.
1294 ft. **Site 17 of 17 in cluster AG**

Relative:
Higher

Actual:
197 ft.

LTANKS:

Name:	UNK
Address:	134 SOUTH LEXINGTON AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0008525 / 2001-03-12
Facility ID:	0008525
Site ID:	218519
Spill Date:	2000-10-20
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	D3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	jbodee
Referred To:	Not reported
Reported to Dept:	2000-10-21
CID:	397
Water Affected:	Not reported

HYDRAULIC FLUID TO SEWER (Continued) **S104877043**

Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2000-10-21
Spill Record Last Update:	2009-12-28
Spiller Name:	Not reported
Spiller Company:	Not reported
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	AMY
Spiller Phone:	(914) 592-3117
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	107023
Latitude:	41.0276041
Longitude:	-73.7716989
DEC Memo:	03/12/2001 TANK PULLED BY CORSETTI CONTRACTING FOR DORSON ENVIRONMENTAL. TANK WAS SOUND, NO EVIDENCE OF RELEASE. A SECOND, 550 GALLON WASTE OIL TANK WAS ALSO REMOVED. NO EVIDENCE OF DISCHARGE FROM SECOND TANK WAS FOUND. NO FURTHER ACTION.
Remarks:	DORSON ENVIRONMENTAL WAS THE SUB CONTRACTOR FOR THE TANK TEST.

All TTF:

Facility ID:	0008525
Spill Number:	0008525
Spill Tank Test:	1525945
Site ID:	218519
Tank Number:	1
Tank Size:	0
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	218519
Operable Unit ID:	829124
Operable Unit:	01
Material ID:	546030
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil

HYDRAULIC FLUID TO SEWER (Continued) **S104877043**

Oxygenate: Not reported

SPILLS:

Name:	HYDRAULIC FLUID TO SEWER
Address:	134 SOUTH LEXINGTON AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0008680 / 2005-03-06
Facility ID:	0008680
Facility Type:	ER
DER Facility ID:	107023
Site ID:	123462
DEC Region:	3
Spill Cause:	Unknown
Spill Class:	C3
SWIS:	6017
Spill Date:	2000-10-25
Investigator:	WCHD
Referred To:	WESTCHESTER CNTY HEALTH D
Reported to Dept:	2000-10-25
CID:	365
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Federal Government
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2000-10-25
Spill Record Last Update:	2005-03-06
Spiller Name:	Not reported
Spiller Company:	UNKNOWN
Spiller Address:	Not reported
Spiller Company:	999
Contact Name:	Not reported
Latitude:	41.0276041
Longitude:	-73.7716989
DEC Memo:	3/6/5 15gallon hydraulic fluid spilled to sewer--close
Remarks:	THE SPILL WAS RELEASED FROM AN ELEVATOR DUE TO UNK CAUSES & WENT INTO A STORM SEWER - ACTUAL COMP TO NRC WAS FROM WHITE PLAINS POLICE DEPT, JOSEPH DEPLAO 914-422-6111 - FIRE DEPT WAS REPORTED TO HAVE BEEN ON THE SCENE

All Materials:

Site ID:	123462
Operable Unit ID:	829269
Operable Unit:	01
Material ID:	546183
Material Code:	0010
Material Name:	hydraulic oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	15.00
Units:	G
Recovered:	.00

HYDRAULIC FLUID TO SEWER (Continued) **S104877043**

Resource Affected: Sewer
Oxygenate: Not reported

AM361 **CON EDISON SERVICE BOX: 7962** **RCRA NonGen / NLR** **1016971335**
NNE **BARKER AVE & CHURCH ST** **NY MANIFEST** **NYP004450730**
1/8-1/4 **WHITE PLAINS, NY 10607**
0.247 mi.
1304 ft. **Site 1 of 2 in cluster AM**

Relative: **Higher**
Actual: **218 ft.**

RCRA Listings:

Date Form Received by Agency:	20140325
Handler Name:	Con Edison Service Box: 7962
Handler Address:	Barker Ave & Church St
Handler City,State,Zip:	WHITE PLAINS, NY 10607
EPA ID:	NYP004450730
Contact Name:	THOMAS TEELING
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	212-460-3770
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	SENIOR SCIENTIST
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PL, 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No

CON EDISON SERVICE BOX: 7962 (Continued) **1016971335**

Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20141014
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20140225
Handler Name: CON EDISON SERVICE BOX:	7962
Federal Waste Generator Description:	Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20140325
Handler Name: CON EDISON SERVICE BOX:	7962
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	Yes
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

List of NAICS Codes and Descriptions:

NAICS Codes:	No NAICS Codes Found

Facility Has Received Notices of Violations:

Violations:	No Violations Found

CON EDISON SERVICE BOX: 7962 (Continued) **1016971335**

Evaluation Action Summary:
Evaluations: No Evaluations Found

NY MANIFEST:

EPA ID:	NYP004450730
Country:	USA
Name:	Con Edison
Address:	BARKER AVE & CHURCH ST
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10607
Zip 4:	Not reported
Location Address 1:	BARKER AVE & CHURCH ST
Location Address 2:	Not reported
Location City,State,Zip:	WHITE PLAINS, NY 10801
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Edison
Mailing Contact:	Con Edision
Mailing Address 1:	4 IRVING PL
Mailing Address 2:	15TH FL
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	Not reported

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	02/25/2014
Trans1 Recv Date:	02/25/2014
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	02/25/2014
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004450730
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	012772730JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported

CON EDISON SERVICE BOX: 7962 (Continued) **1016971335**

Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	50
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

AM362 **CON EDISON MANHOLE: 4147** **RCRA NonGen / NLR** **1016963587**
NNE **BARKER AVE & CHURCH ST** **NY MANIFEST** **NYP004365813**
1/8-1/4 **WHITE PLAINS, NY 10606**
0.247 mi.
1304 ft. **Site 2 of 2 in cluster AM**

Relative: **Higher**
Actual: **218 ft.**

RCRA Listings:

Date Form Received by Agency:	20131025
Handler Name:	Con Edison Manhole: 4147
Handler Address:	Barker Ave & Church St
Handler City,State,Zip:	WHITE PLAINS, NY 10606
EPA ID:	NYP004365813
Contact Name:	THOMAS TEELING
Contact Address:	Not reported
Contact City,State,Zip:	Not reported
Contact Telephone:	212-460-3770
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	SENIOR SCIENTIST
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R2
Mailing Address:	IRVING PL, 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Owner Name:	Not reported
Owner Type:	Not reported
Operator Name:	Not reported
Operator Type:	Not reported
Short-Term Generator Activity:	No

CON EDISON MANHOLE: 4147 (Continued) **1016963587**

Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20140701
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20130925
Handler Name: CON EDISON MANHOLE: 4147	
Federal Waste Generator Description:	Very Small Quantity Generator (formerly Conditionally-Exempt Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20131025

CON EDISON MANHOLE: 4147 (Continued) **1016963587**

Handler Name: CON EDISON MANHOLE: 4147
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

NY MANIFEST:
EPA ID: NYP004365813
Country: USA
Name: Con Edison
Address: BARKER AVE & CHURCH ST
Address 2: Not reported
City,State,Zip: WHITE PLAINS, NY 10606
Zip 4: Not reported
Location Address 1: BARKER & CHURCH
Location Address 2: MH4147
Location City,State,Zip: WHITE PLAINS, NY 10601
Location Zip 4: Not reported
Facility Status: Not reported
Total Tanks: Not reported
Code: BP

Mailing:
Mailing Name: Con Edison
Mailing Contact: Con Edison
Mailing Address 1: 4 IRVING PLACE
Mailing Address 2: Not reported
Mailing City,State,Zip: NEW YORK, NY 10003
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: Not reported

Manifest Data:
Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: NYD006982359
Year: 2018
Trans2 State ID: Not reported
Generator Ship Date: 09/25/2013

CON EDISON MANHOLE: 4147 (Continued) **1016963587**

Trans1 Recv Date:	09/25/2013
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	10/03/2013
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004365813
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	011695938JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	200
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

AN363 **CON EDISON** **NY MANIFEST** **S118088814**
NE **F/O 360 HAMILTON AVE** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10602**
0.247 mi.
1306 ft. **Site 1 of 5 in cluster AN**

Relative: NY MANIFEST:
Higher

Actual: EPA ID: NYP004763934
228 ft. Country: USA
Name: Con Edison
Address: F/O 360 HAMILTON AVE
Address 2: SB 3696
City,State,Zip: WHITE PLAINS, NY 10602
Zip 4: Not reported
Location Address 1: F/O 360 HAMILTON AVE
Location Address 2: SB 3696

CON EDISON (Continued) **S118088814**

Location City,State,Zip: WHITE PLAINS, NY 10602
Location Zip 4: Not reported
Facility Status: Not reported
Total Tanks: Not reported
Code: BP

Mailing:
Mailing Name: Con Edison
Mailing Contact: Dennis Huacon
Mailing Address 1: 4 IRVING PL 15TH FL
Mailing Address 2: Not reported
Mailing City,State,Zip: NEW YORK, NY 10003
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: 2124603770

Manifest Data:
Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: NYD006982359
Year: 2018
Trans2 State ID: Not reported
Generator Ship Date: 04/07/2015
Trans1 Recv Date: 04/07/2015
Trans2 Recv Date: Not reported
TSD Site Recv Date: 04/07/2015
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYP004763934
Trans1 EPA ID: Not reported
Trans2 EPA ID: Not reported
TSDF ID 1: NJD002200046
TSDF ID 2: Not reported
Manifest Tracking Number: 011692687JJK
Import Indicator: N
Export Indicator: N
Discr Quantity Indicator: N
Discr Type Indicator: N
Discr Residue Indicator: N
Discr Partial Reject Indicator: N
Discr Full Reject Indicator: N
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: H110
Waste Code a: Lead
Waste Code b: Not reported
Waste Code c: Not reported
Waste Code e: Not reported
Waste Code f: Not reported
Waste Code g: Not reported
Waste Code 1: Not reported
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported

CON EDISON (Continued) **S118088814**

Quantity:	25
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

AN364 **A T & T** **RCRA-SQG** **1000872181**
NE **360 HAMILTON AVE** **NY Spills** **NYD986998060**
1/8-1/4 **WHITE PLAINS, NY 10601** **NY MANIFEST**
0.247 mi.
1306 ft. **Site 2 of 5 in cluster AN**

Relative: **Higher**
Actual: **228 ft.**

RCRA Listings:

Date Form Received by Agency:	20120420
Handler Name:	A T & T
Handler Address:	Hamilton Ave
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYD986998060
Contact Name:	GEOFF SMITH
Contact Address:	AT&T WAY
Contact City,State,Zip:	BEDMINSTER, NJ 07921
Contact Telephone:	800-566-9347 x4
Contact Fax:	Not reported
Contact Email:	EHSRRC@LIST.ATT.COM
Contact Title:	AT&T EH&S SUPERVISOR
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Small Quantity Generator
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Handler Activities
State District Owner:	Ny
State District:	NYSDEC R3
Mailing Address:	AT&T WAY
Mailing City,State,Zip:	BEDMINSTER, NJ 07921
Owner Name:	At&T
Owner Type:	Private
Operator Name:	At&T
Operator Type:	Private
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N

A T & T (Continued) **1000872181**

Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20150414
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Hazardous Waste Summary:

Waste Code:	D002
Waste Description:	Corrosive Waste
Waste Code:	X001
Waste Description:	Not Defined
Waste Code:	X002
Waste Description:	Not Defined

Handler - Owner Operator:

Owner/Operator Indicator:	Owner
Owner/Operator Name: AT&T	
Legal Status:	Private
Date Became Current:	20051101
Date Ended Current:	Not reported
Owner/Operator Address:	308 S AKARD
Owner/Operator City,State,Zip:	DALLAS, TX 75202
Owner/Operator Telephone:	800-566-9347
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported
Owner/Operator Email:	Not reported
Owner/Operator Indicator:	Owner
Owner/Operator Name: A T & T	
Legal Status:	Private
Date Became Current:	Not reported
Date Ended Current:	Not reported
Owner/Operator Address:	227 W MONROE SUITE 1004
Owner/Operator City,State,Zip:	CHICAGO, IL 60606

A T & T (Continued) **1000872181**

Owner/Operator Telephone: 312-230-5239
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Owner
Owner/Operator Name: VERIZON
Legal Status: Private
Date Became Current: 19791231
Date Ended Current: Not reported
Owner/Operator Address: 360 HAMILTON AVE
Owner/Operator City,State,Zip: WHITE PLAINS, NY 10601
Owner/Operator Telephone: 212-555-1212
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Operator
Owner/Operator Name: VERIZON
Legal Status: Private
Date Became Current: 19791231
Date Ended Current: Not reported
Owner/Operator Address: 360 HAMILTON AVE
Owner/Operator City,State,Zip: WHITE PLAINS, NY 10601
Owner/Operator Telephone: 212-555-1212
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Owner
Owner/Operator Name: A T & T
Legal Status: Private
Date Became Current: Not reported
Date Ended Current: Not reported
Owner/Operator Address: 227 W MONROE SUITE 1004
Owner/Operator City,State,Zip: CHICAGO, IL 60606
Owner/Operator Telephone: 312-230-5239
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Operator
Owner/Operator Name: VERIZON
Legal Status: Private
Date Became Current: 19791231
Date Ended Current: Not reported
Owner/Operator Address: 360 HAMILTON AVE
Owner/Operator City,State,Zip: WHITE PLAINS, NY 10601
Owner/Operator Telephone: 212-555-1212
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Owner
Owner/Operator Name: VERIZON
Legal Status: Private
Date Became Current: 19791231

A T & T (Continued) **1000872181**

Date Ended Current:	Not reported
Owner/Operator Address:	360 HAMILTON AVE
Owner/Operator City,State,Zip:	WHITE PLAINS, NY 10601
Owner/Operator Telephone:	212-555-1212
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported
Owner/Operator Email:	Not reported
Owner/Operator Indicator:	Operator
Owner/Operator Name: AT&T	
Legal Status:	Private
Date Became Current:	20051101
Date Ended Current:	Not reported
Owner/Operator Address:	Not reported
Owner/Operator City,State,Zip:	Not reported
Owner/Operator Telephone:	Not reported
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported
Owner/Operator Email:	Not reported
Owner/Operator Indicator:	Owner
Owner/Operator Name: A T & T	
Legal Status:	Private
Date Became Current:	Not reported
Date Ended Current:	Not reported
Owner/Operator Address:	227 W MONROE SUITE 1004
Owner/Operator City,State,Zip:	CHICAGO, IL 60606
Owner/Operator Telephone:	312-230-5239
Owner/Operator Telephone Ext:	Not reported
Owner/Operator Fax:	Not reported
Owner/Operator Email:	Not reported

Historic Generators:

Receive Date:	20060101
Handler Name: VERIZON	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported
Receive Date:	20070101
Handler Name: VERIZON	
Federal Waste Generator Description:	Not a generator, verified
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported

A T & T (Continued) **1000872181**

Electronic Manifest Broker: Not reported

Receive Date: 19930824
Handler Name: A T & T
Federal Waste Generator Description: Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20030619
Handler Name: VERIZON
Federal Waste Generator Description: Large Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20120420
Handler Name: A T & T
Federal Waste Generator Description: Small Quantity Generator
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Code: 51331
NAICS Description: Wired Telecommunications Carriers

NAICS Code: 51711
NAICS Description: Wired And Wireless Telecommunications Carriers (Except Satellite)

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

A T & T (Continued) **1000872181**

SPILLS:

Name:	CON ED TRANSFORMER VAULT 9521
Address:	360 HAMILTON AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	2204512 / 2022-12-08
Facility ID:	2204512
Facility Type:	ER
DER Facility ID:	588156
Site ID:	641669
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	B3
SWIS:	6017
Spill Date:	2022-08-22
Investigator:	TDGHIOSA
Referred To:	Not reported
Reported to Dept:	2022-08-22
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Transformer
Spill Notifier:	Responsible Party
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2022-08-22
Spill Record Last Update:	2024-08-29
Spiller Name:	Not reported
Spiller Company:	CON ED
Spiller Address:	Not reported
Spiller Company:	999
Contact Name:	PAUL DIDOMENICO
Latitude:	Not reported
Longitude:	Not reported
DEC Memo:	8/22/22 - Street level underground transformer vault is leaking dielectric fluid. The oil is entering an adjacent building into their storage room then into a Con Ed network protector room which is directly below. Unknown volume lost and leak rate. The 3 vaults nearby are being inspected. Samples have been taken and investigation of the source is ongoing. EMIS #287176. JMG 09/06/22 Latest EMIS 287176/5 loaded into DecDocs. Oil has 9ppm PCB. TG 9/13/2022 11:30 AM BW Environmental Ops Operating Supervisor Charles D'Alisera (48339) reported another area, 3rd level of the parking garage storage area was impacted with 1 gal of possible transformer oil. he will take a PCB and OIL ID sample, COC NT66547. Slote, Richard 9/13/2022 12:06 PM On 09/13/2022 at 10;30, Clean Harbors crew cleaned Network protect 9521 with simple green and absorbent. Clean Harbors vactor removed 250 pounds of waste to be disposed at Clean Earth of North Jersey under BOL 1200050. Khwalsingh, Taniki 9/15/2022 3:37 PM On 9/13/22 while

A T & T (Continued) **1000872181**

cleaning bus compartments at 360
Hamilton Ave under EMIS 287176 two maintenance workers from AT&T approached A. Olivet and stated
they found oil in there storage room on level B3. Mr. Olivet when with the two maintenance workers
to check on the spill while I continue cleaning the bus compartments. Mr. Olivet came back and
stated to me we will need to sample the spill. When we finish cleaning the bus compartments we went
with the two maintenance works to take samples. I took samples for oil ID & PCB s. We told the
maintenance crew to give us a day or two for the sample results to come back and if it is our oil
we will clean it. On 9/14/22 I received a call from Charlene Miraglia telling me she had an
environmental contractor come in and do the cleanup and asking me how AT&T can get reimburse .
Results came back under COC as Transformer oil and 7 PPM. Baxter, Brandon 9/23/2022 11:41 AM Clean
Harbors crews removed all oily debris from storage room and double washed floor and ceiling with
simple green. Generated one 20 yard dumpster .This is a update still need to remove transformer
from V9521 and clean it to close spill. TM replacement is schedule for 9/25/22 Blaich, Christopher
12/08/22 See EMIS report in decdocs for the cleanup details. NFA> TG

Remarks: Oil is on street level from a vault and leaked to a storage facility room inside a building and leaking to a network protector directly below the facility room cleanup pending

All Materials:

Site ID:	641669
Operable Unit ID:	1388702
Operable Unit:	01
Material ID:	2403649
Material Code:	0541A
Material Name:	dielectric fluid
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	46.00
Units:	G
Recovered:	Not reported
Resource Affected:	Soil, Indoor Air, Utility, Impervious Surface
Oxygenate:	Not reported

NY MANIFEST:

EPA ID:	NYD986998060
Country:	USA
Name:	At&T
Address:	360 HAMILTON AVE
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10601
Zip 4:	Not reported
Location Address 1:	360 HAMILTON AVE
Location Address 2:	Not reported
Location City,State,Zip:	WHITE PLAINS, NY 10601

A T & T (Continued) **1000872181**

Location Zip 4: Not reported
Facility Status: Not reported
Total Tanks: Not reported
Code: BP

Mailing:
Mailing Name: At&T
Mailing Contact: Louis Morello
Mailing Address 1: 227 W MONROE SUITE 1004
Mailing Address 2: Not reported
Mailing City,State,Zip: CHICAGO, IL 60606
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: 8004723389

Manifest Data:
Document ID: PAE4323955
Manifest Status: Not reported
Trans1 State ID: PAAH0312
Year: 1995
Trans2 State ID: Not reported
Generator Ship Date: 12/19/1995
Trans1 Recv Date: 12/19/1995
Trans2 Recv Date: Not reported
TSD Site Recv Date: 12/19/1995
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYD986998060
Trans1 EPA ID: MAD039322250
Trans2 EPA ID: Not reported
TSDF ID 1: PAD987367216
TSDF ID 2: Not reported
Manifest Tracking Number: Not reported
Import Indicator: Not reported
Export Indicator: Not reported
Discr Quantity Indicator: Not reported
Discr Type Indicator: Not reported
Discr Residue Indicator: Not reported
Discr Partial Reject Indicator: Not reported
Discr Full Reject Indicator: Not reported
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: Not reported
Waste Code 1: Mercury
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 03402
Units: Pounds
Number of Containers: 186
Container Type: Fiber or plastic boxes, cartons, cases
Handling Method: Recycle
Specific Gravity: 01.00

A T & T (Continued) **1000872181**

Document ID:	MAJ0045020
Manifest Status:	Not reported
Trans1 State ID:	MA23322
Year:	1995
Trans2 State ID:	ME614178
Generator Ship Date:	05/19/1995
Trans1 Recv Date:	05/19/1995
Trans2 Recv Date:	05/20/1995
TSD Site Recv Date:	05/20/1995
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD986998060
Trans1 EPA ID:	MAD039322250
Trans2 EPA ID:	MAD039322250
TSDF ID 1:	MAD053452637
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	The Following Spent Halogenated Solvents: Tetrachloroethylene, Methylene Chloride, Trichloroethylene, 1,1,1-Trichloroethane, Chlorobenzene, 1,1,2-Trichloro-1,2,2-Trifluoroethane, Ortho-Dichlorobenzene, Trichlorofluoromethane, And 1,1,2, Trichloroethane; All Spent Solvent Mixtures/Blends Containing, Before Use, A Total Of Ten Percent Or More (By Volume) Of One Or More Of The Above Halogenated Solvents Or Those Solvents Listed In F001, F004, And F005; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent Mixtures.
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00160
Units:	Pounds
Number of Containers:	002
Container Type:	Metal drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00

Document ID:	MAJ0047070
Manifest Status:	Not reported
Trans1 State ID:	MA23322
Year:	1995
Trans2 State ID:	ME614178
Generator Ship Date:	05/19/1995
Trans1 Recv Date:	05/19/1995
Trans2 Recv Date:	05/20/1995

A T & T (Continued) **1000872181**

TSD Site Recv Date:	05/22/1995
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD986998060
Trans1 EPA ID:	MAD039322250
Trans2 EPA ID:	MAD039322250
TSDF ID 1:	MAD980523203
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Corrosive Waste
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00080
Units:	Pounds
Number of Containers:	003
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Treat
Specific Gravity:	01.00

Document ID:	MAJ0047080
Manifest Status:	Not reported
Trans1 State ID:	MA23322
Year:	1995
Trans2 State ID:	ME614178
Generator Ship Date:	05/19/1995
Trans1 Recv Date:	05/19/1995
Trans2 Recv Date:	05/20/1995
TSD Site Recv Date:	05/22/1995
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD986998060
Trans1 EPA ID:	MAD039322250
Trans2 EPA ID:	MAD039322250
TSDF ID 1:	MAD980523203
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported

A T & T (Continued) **1000872181**

Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	The Following Spent Nonhalogenated Solvents: Xylene, Acetone, Ethyl Acetate, Ethyl Benzene, Ethyl Ether, Methyl Isobutyl Ketone, N-Butyl Alcohol, Cyclohexanone, And Methanol; All Spent Solvent Mixtures/Blends Containing, Before Use, Only The Above Spent Nonhalogenated Solvents; And All Spent Solvent Mixtures/Blends Containing, Before Use, One Or More Of The Above Nonhalogenated Solvents, And A Total Of Ten Percent Or More (By Volume) Of One Or More Of Those Solvents Listed In F001, F002, F004, And F005; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent Mixtures.
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00060
Units:	Pounds
Number of Containers:	001
Container Type:	Metal drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00
Waste Code 7:	Ignitable Waste
Waste Code 8:	Not reported
Waste Code:	Not reported
Waste Code 10:	Not reported
Waste Code 11:	Not reported
Quantity:	00480
Units:	Pounds
Number of Containers:	001
Container Type:	Fiber or plastic boxes, cartons, cases
Handling Method:	Burn
Specific Gravity:	01.00
Waste Code 12:	Corrosive Waste
Waste Code 13:	Not reported
Waste Code 14:	Not reported
Waste Code 15:	Not reported
Waste Code 16:	Not reported
Quantity:	00200
Units:	Pounds
Number of Containers:	003
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Recycle
Specific Gravity:	01.00
Waste Code 17:	Corrosive Waste
Waste Code 18:	Not reported
Waste Code 19:	Not reported
Waste Code 20:	Not reported
Waste Code 21:	Not reported
Quantity:	00060
Units:	Pounds
Number of Containers:	002
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Treat

A T & T (Continued) **1000872181**

Specific Gravity: 01.00

Document ID: PAE6088762
Manifest Status: Not reported
Trans1 State ID: PAAH0315
Year: 1996
Trans2 State ID: Not reported
Generator Ship Date: 11/20/1996
Trans1 Recv Date: 11/20/1996
Trans2 Recv Date: Not reported
TSD Site Recv Date: 11/20/1996
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYD986998060
Trans1 EPA ID: NYD980769947
Trans2 EPA ID: Not reported
TSDF ID 1: PAD987367216
TSDF ID 2: Not reported
Manifest Tracking Number: Not reported
Import Indicator: Not reported
Export Indicator: Not reported
Discr Quantity Indicator: Not reported
Discr Type Indicator: Not reported
Discr Residue Indicator: Not reported
Discr Partial Reject Indicator: Not reported
Discr Full Reject Indicator: Not reported
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: Not reported
Waste Code 1: Mercury
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 00030
Units: Pounds
Number of Containers: 006
Container Type: Fiber or plastic boxes, cartons, cases
Handling Method: Landfill
Specific Gravity: 01.00
Waste Code 7: Mercury
Waste Code 8: Not reported
Waste Code: Not reported
Waste Code 10: Not reported
Waste Code 11: Not reported
Quantity: 00110
Units: Pounds
Number of Containers: 001
Container Type: Metal drums, barrels, kegs
Handling Method: Landfill
Specific Gravity: 01.00

Document ID: MAH7110700
Manifest Status: Not reported
Trans1 State ID: MA13333

A T & T (Continued) **1000872181**

Year:	1994
Trans2 State ID:	ME619002
Generator Ship Date:	08/05/1994
Trans1 Recv Date:	08/05/1994
Trans2 Recv Date:	08/09/1994
TSD Site Recv Date:	08/09/1994
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD986998060
Trans1 EPA ID:	MAD039322250
Trans2 EPA ID:	MAD039322250
TSDF ID 1:	MAD053452637
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	The Following Spent Halogenated Solvents: Tetrachloroethylene, Methylene Chloride, Trichloroethylene, 1,1,1-Trichloroethane, Chlorobenzene, 1,1,2-Trichloro-1,2,2-Trifluoroethane, Ortho-Dichlorobenzene, Trichlorofluoromethane, And 1,1,2, Trichloroethane; All Spent Solvent Mixtures/Blends Containing, Before Use, A Total Of Ten Percent Or More (By Volume) Of One Or More Of The Above Halogenated Solvents Or Those Solvents Listed In F001, F004, And F005; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent Mixtures.
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00055
Units:	Gallons (liquids only)
Number of Containers:	001
Container Type:	Metal drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00
Waste Code 7:	The Following Spent Halogenated Solvents: Tetrachloroethylene, Methylene Chloride, Trichloroethylene, 1,1,1-Trichloroethane, Chlorobenzene, 1,1,2-Trichloro-1,2,2-Trifluoroethane, Ortho-Dichlorobenzene, Trichlorofluoromethane, And 1,1,2, Trichloroethane; All Spent Solvent Mixtures/Blends Containing, Before Use, A Total Of Ten Percent Or More (By Volume) Of One Or More Of The Above Halogenated Solvents Or Those Solvents Listed In F001, F004, And F005; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent Mixtures.
Waste Code 8:	Not reported
Waste Code:	Not reported
Waste Code 10:	Not reported

A T & T (Continued) **1000872181**

Waste Code 11:	Not reported
Quantity:	00330
Units:	Gallons (liquids only)
Number of Containers:	006
Container Type:	Metal drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00

Document ID:	ARA9303420
Manifest Status:	Not reported
Trans1 State ID:	H0902205
Year:	1998
Trans2 State ID:	Not reported
Generator Ship Date:	06/17/1998
Trans1 Recv Date:	06/17/1998
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	06/30/1998
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYD986998060
Trans1 EPA ID:	OHD009865825
Trans2 EPA ID:	Not reported
TSDF ID 1:	ARD069748192
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Benzene, Methyl- (Or) Toluene
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00423
Units:	Pounds
Number of Containers:	001
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00

EPA ID:	NYP005001854
Country:	USA
Name:	Con Edison - Vault Submersible Vs9521
Address:	360 HAMILTON AVE
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10601
Zip 4:	Not reported

A T & T (Continued) **1000872181**

Location Address 1: 360 HAMILTON AVE
Location Address 2: Not reported
Location City,State,Zip: WHITE PLAINS, NY 10601
Location Zip 4: Not reported
Facility Status: Not reported
Total Tanks: Not reported
Code: BP

Mailing:
Mailing Name: Con Edison - Vault Submersible Vs9521
Mailing Contact: Con Edison
Mailing Address 1: 4 IRVING PL 15TH FL NE
Mailing Address 2: Not reported
Mailing City,State,Zip: NEW YORK, NY 10003
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: Not reported

AN365 **RECKSON ASSOCIATES** **NY Spills** **1001489143**
NE **360 HAMILTON AVE - MAIN FLOOR** **RCRA NonGen / NLR** **NYR000071779**
1/8-1/4 **WHITE PLAINS, NY 10601** **FINDS**
0.247 mi. **ECHO**
1306 ft. **Site 3 of 5 in cluster AN** **NY MANIFEST**

Relative:
Higher

Actual:
228 ft.

SPILLS:
Name: OFFICE BLDG(UNDER CONST)
Address: 360 HAMILTON ROAD
City,State,Zip: WHITE PLAINS, NY
Spill Number/Closed Date: 9907464 / 1999-10-14
Facility ID: 9907464
Facility Type: ER
DER Facility ID: 243959
Site ID: 301898
DEC Region: 3
Spill Cause: Equipment Failure
Spill Class: B3
SWIS: 6017
Spill Date: 1999-09-21
Investigator: tdghiosa
Referred To: Not reported
Reported to Dept: 1999-09-21
CID: 322
Water Affected: Not reported
Spill Source: Commercial/Industrial
Spill Notifier: Other
Cleanup Ceased: Not reported
Cleanup Meets Std: True
Last Inspection: Not reported
Recommended Penalty: False
UST Trust: False
Remediation Phase: 0
Date Entered In Computer: 1999-09-21
Spill Record Last Update: 1999-10-27
Spiller Name: PHIL FALLON
Spiller Company: RECKSON ASSOCIATES
Spiller Address: 360 HAMILTON ROAD
Spiller Company: 001

RECKSON ASSOCIATES (Continued) **1001489143**

Contact Name:	PHIL FALLON
Latitude:	41.0346798
Longitude:	-73.7662259
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY 9/21/99 PER P. FALLON--TANK IN BASEMENT 275 GALLONS. DELIVERY 9/21/99. WHILE DELIVERING WENT TO CHECK TANK. ONLY 6 IN TANK-NO OIL IN BASEMENT. LINE MAY BE SEVERED IN GROUND FROM FILL TO WHERE LINE ENTERS BASEMENT. 10/14/99 LETTER SENT; SPILL FILE CLOSED.
Remarks:	while recieving an oil delivery - oil was not going into the tank - it appears there is a line leak - oil stain is now appearing in the wall - clean up crew will arrive tomorrow to start clean up

All Materials:

Site ID:	301898
Operable Unit ID:	1081749
Operable Unit:	01
Material ID:	300169
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	150.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

RCRA Listings:

Date Form Received by Agency:	20070101
Handler Name:	Reckson Associates
Handler Address:	Hamilton Ave - Main Floor
Handler City,State,Zip:	WHITE PLAINS, NY 10601
EPA ID:	NYR000071779
Contact Name:	DANIEL RIVERS
Contact Address:	GILFORD AVE
Contact City,State,Zip:	NEW HYDE PARK, NY 11040
Contact Telephone:	516-352-7466
Contact Fax:	Not reported
Contact Email:	Not reported
Contact Title:	Not reported
EPA Region:	02
Land Type:	Private
Federal Waste Generator Description:	Not a generator, verified
Non-Notifier:	Not reported
Biennial Report Cycle:	Not reported
Accessibility:	Not reported
Active Site Indicator:	Not reported
State District Owner:	Ny
State District:	NYSDEC R3
Mailing Address:	GILFORD AVE
Mailing City,State,Zip:	NEW HYDE PARK, NY 11040
Owner Name:	Rickson Associates
Owner Type:	Private
Operator Name:	Rickson Associates

RECKSON ASSOCIATES (Continued) **1001489143**

Operator Type:	Private
Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20150414
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Hazardous Waste Summary:

Waste Code:	D001
Waste Description:	Ignitable Waste
Waste Code:	D002
Waste Description:	Corrosive Waste

Handler - Owner Operator:

Owner/Operator Indicator:	Operator
Owner/Operator Name:	RICKSON ASSOCIATES
Legal Status:	Private
Date Became Current:	Not reported
Date Ended Current:	Not reported

RECKSON ASSOCIATES (Continued) **1001489143**

Owner/Operator Address: 225 BROADHOLLOW RD
Owner/Operator City,State,Zip: MELVILLE, NY 11747
Owner/Operator Telephone: 516-622-6678
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Owner
Owner/Operator Name: RICKSON ASSOCIATES
Legal Status: Private
Date Became Current: Not reported
Date Ended Current: Not reported
Owner/Operator Address: 225 BROADHOLLOW RD
Owner/Operator City,State,Zip: MELVILLE, NY 11747
Owner/Operator Telephone: 516-622-6678
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Owner/Operator Indicator: Owner
Owner/Operator Name: RICKSON ASSOCIATES
Legal Status: Private
Date Became Current: Not reported
Date Ended Current: Not reported
Owner/Operator Address: 225 BROADHOLLOW RD
Owner/Operator City,State,Zip: MELVILLE, NY 11747
Owner/Operator Telephone: 516-622-6678
Owner/Operator Telephone Ext: Not reported
Owner/Operator Fax: Not reported
Owner/Operator Email: Not reported

Historic Generators:
Receive Date: 20060101
Handler Name: RECKSON ASSOCIATES
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: No
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

Receive Date: 20070101
Handler Name: RECKSON ASSOCIATES
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

RECKSON ASSOCIATES (Continued) **1001489143**

Receive Date:	19990526
Handler Name: RECKSON ASSOCIATES	
Federal Waste Generator Description:	Small Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

FINDS:
Registry ID: 110004553297

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:
The Resource Conservation and Recovery Act Information System (RCRAInfo) is EPA's comprehensive information system in support of the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. It tracks many types of information about generators, transporters, treaters, storers, and disposers of hazardous waste.

Click this hyperlink while viewing on your computer to access additional FINDS: detail in the EDR Site Report.

ECHO:

Envid:	1001489143
Registry ID:	110004553297

DFR URL:

Name:	RECKSON ASSOCIATES
Address:	360 HAMILTON AVE - MAIN FLOOR
City,State,Zip:	WHITE PLAINS, NY 10601

NY MANIFEST:

EPA ID:	NYR000071779
Country:	USA
Name:	Rechson Associates
Address:	360 HAMILTON AVE - MAIN FLOOR
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10601
Zip 4:	Not reported

RECKSON ASSOCIATES (Continued) **1001489143**

Location Address 1:	360 HAMILTON AVE
Location Address 2:	Not reported
Location City,State,Zip:	WHITE PLAINS, NY
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Rechson Associates
Mailing Contact:	Daniel J Rivers
Mailing Address 1:	360 HAMILTON AVE
Mailing Address 2:	Not reported
Mailing City,State,Zip:	WHITE PLAINS, NY
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	5163527466

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	PAR000043752
Year:	2018
Trans2 State ID:	NJD986607380
Generator Ship Date:	06/27/2017
Trans1 Recv Date:	06/27/2017
Trans2 Recv Date:	06/30/2017
TSD Site Recv Date:	07/21/2017
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000071779
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	OHD001926740
TSDF ID 2:	Not reported
Manifest Tracking Number:	009057368FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H061
Waste Code a:	Corrosive Waste
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported

RECKSON ASSOCIATES (Continued) **1001489143**

Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	33
Units:	Pounds
Number of Containers:	1
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	1
Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	PAR000043752
Year:	2018
Trans2 State ID:	NJD986607380
Generator Ship Date:	06/27/2017
Trans1 Recv Date:	06/27/2017
Trans2 Recv Date:	06/30/2017
TSD Site Recv Date:	07/21/2017
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000071779
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	OHD001926740
TSDF ID 2:	Not reported
Manifest Tracking Number:	009057368FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H141
Waste Code a:	Corrosive Waste
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	48
Units:	Pounds
Number of Containers:	1
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Landfill
Specific Gravity:	1
Document ID:	Not reported

RECKSON ASSOCIATES (Continued) **1001489143**

Manifest Status:	Not reported
Trans1 State ID:	PAR000043752
Year:	2018
Trans2 State ID:	NJD986607380
Generator Ship Date:	06/27/2017
Trans1 Recv Date:	06/27/2017
Trans2 Recv Date:	06/30/2017
TSD Site Recv Date:	07/21/2017
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000071779
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	OHD001926740
TSDF ID 2:	Not reported
Manifest Tracking Number:	009057368FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H141
Waste Code a:	Corrosive Waste
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	300
Units:	Pounds
Number of Containers:	9
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Landfill
Specific Gravity:	1

Document ID:	NJA3015997
Manifest Status:	Not reported
Trans1 State ID:	JA334
Year:	1999
Trans2 State ID:	Not reported
Generator Ship Date:	05/27/1999
Trans1 Recv Date:	05/27/1999
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	06/01/1999
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported

RECKSON ASSOCIATES (Continued) **1001489143**

Generator EPA ID:	NYR000071779
Trans1 EPA ID:	NJD986607380
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	Not reported
Import Indicator:	Not reported
Export Indicator:	Not reported
Discr Quantity Indicator:	Not reported
Discr Type Indicator:	Not reported
Discr Residue Indicator:	Not reported
Discr Partial Reject Indicator:	Not reported
Discr Full Reject Indicator:	Not reported
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	Not reported
Waste Code 1:	Corrosive Waste
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	00015
Units:	Gallons (liquids only)
Number of Containers:	003
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Treat
Specific Gravity:	01.00
Waste Code 7:	Corrosive Waste
Waste Code 8:	Not reported
Waste Code:	Not reported
Waste Code 10:	Not reported
Waste Code 11:	Not reported
Quantity:	00010
Units:	Gallons (liquids only)
Number of Containers:	002
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Treat
Specific Gravity:	01.00
Waste Code 12:	Ignitable Waste
Waste Code 13:	Not reported
Waste Code 14:	Not reported
Waste Code 15:	Not reported
Waste Code 16:	Not reported
Quantity:	00020
Units:	Pounds
Number of Containers:	001
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	01.00

AN366 **RECKSON METRO CENTER** **NY AST** **1007796644**
NE **360 HAMILTON AVE** **US AIRS** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.247 mi.
1306 ft. **Site 4 of 5 in cluster AN**

Relative:
Higher

Actual:
228 ft.

WESTCHESTER CO. AST:

Name:	RECKSON METRO CENTER
Address:	360 HAMILTON AVENUE
City,State,Zip:	WHITE PLAINS, NY 10601
PBS Number:	3-177342
Site Status:	Active
GDS Number:	Not reported
Operator Name:	John Cuomo
Owner Name:	360 Hamilton LLC
Owner Street:	7 Renaissance Sq.,
Owner Address2:	Suite 500
Owner City/State/Zip:	White Plains, NY 10601
Tank Number:	001
Status:	1. In-Service
Date Installation:	01/01/1974
Capacity:	5000
Product Stored:	0001. #2 Fuel Oil
Product Stored Percent:	Not reported
Date Perm Closure:	01/01/1995
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Leak Detection:	6. Impervious Barrier/Concrete Pad (Aboveground Only)
Tank Secondary Containment:	2. Vault (w/ access)
Piping Location:	1. Aboveground
Piping Type:	5. Steel Encassed in Concrete
Piping External Protection:	1. Painted/Asphalt Coating
Piping Leak Detection:	0. None
Piping Secondary Containment:	0. None
Overfill Prevention:	4. Product Level Gauge (Aboveground Only),5. Vent Whistle
Spill Prevention:	1. Catch Basin
Dispenser:	2. Suction
Tank Number:	002
Status:	1. In-Service
Date Installation:	01/01/1974
Capacity:	5000
Product Stored:	0001. #2 Fuel Oil
Product Stored Percent:	Not reported
Date Perm Closure:	01/01/1995
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Leak Detection:	6. Impervious Barrier/Concrete Pad (Aboveground Only)
Tank Secondary Containment:	2. Vault (w/ access)
Piping Location:	1. Aboveground
Piping Type:	5. Steel Encassed in Concrete
Piping External Protection:	1. Painted/Asphalt Coating
Piping Leak Detection:	0. None

RECKSON METRO CENTER (Continued) **1007796644**

Piping Secondary Containment:	0. None
Overfill Prevention:	4. Product Level Gauge (Aboveground Only),5. Vent Whistle
Spill Prevention:	1. Catch Basin
Dispenser:	2. Suction

Tank Number:	003
Status:	1. In-Service
Date Installation:	01/01/1974
Capacity:	5000
Product Stored:	0001. #2 Fuel Oil
Product Stored Percent:	Not reported
Date Perm Closure:	01/01/1995
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Leak Detection:	6. Impervious Barrier/Concrete Pad (Aboveground Only)
Tank Secondary Containment:	2. Vault (w/ access)
Piping Location:	1. Aboveground
Piping Type:	5. Steel Encassed in Concrete
Piping External Protection:	1. Painted/Asphalt Coating
Piping Leak Detection:	0. None
Piping Secondary Containment:	0. None
Overfill Prevention:	4. Product Level Gauge (Aboveground Only),5. Vent Whistle
Spill Prevention:	1. Catch Basin
Dispenser:	2. Suction

Tank Number:	004
Status:	1. In-Service
Date Installation:	01/01/1974
Capacity:	5000
Product Stored:	0001. #2 Fuel Oil
Product Stored Percent:	Not reported
Date Perm Closure:	01/01/1995
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Leak Detection:	6. Impervious Barrier/Concrete Pad (Aboveground Only)
Tank Secondary Containment:	2. Vault (w/ access)
Piping Location:	1. Aboveground
Piping Type:	5. Steel Encassed in Concrete
Piping External Protection:	1. Painted/Asphalt Coating
Piping Leak Detection:	0. None
Piping Secondary Containment:	0. None
Overfill Prevention:	4. Product Level Gauge (Aboveground Only),5. Vent Whistle
Spill Prevention:	1. Catch Basin
Dispenser:	2. Suction

Tank Number:	005
Status:	1. In-Service
Date Installation:	01/01/1974
Capacity:	275
Product Stored:	0001. #2 Fuel Oil

RECKSON METRO CENTER (Continued) **1007796644**

Product Stored Percent:	Not reported
Date Perm Closure:	01/01/1900
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Leak Detection:	6. Impervious Barrier/Concrete Pad (Aboveground Only)
Tank Secondary Containment:	1. Diking (aboveground only)
Piping Location:	1. Aboveground
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	1. Painted/Asphalt Coating
Piping Leak Detection:	0. None
Piping Secondary Containment:	12. Double-Walled (Aboveground Only)
Overfill Prevention:	2. High Level Alarm,4. Product Level Gauge (Aboveground Only)
Spill Prevention:	0. None
Dispenser:	2. Suction

Tank Number:	006
Status:	1. In-Service
Date Installation:	01/01/1974
Capacity:	275
Product Stored:	0001. #2 Fuel Oil
Product Stored Percent:	Not reported
Date Perm Closure:	01/01/1900
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Leak Detection:	6. Impervious Barrier/Concrete Pad (Aboveground Only)
Tank Secondary Containment:	1. Diking (aboveground only)
Piping Location:	1. Aboveground
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	1. Painted/Asphalt Coating
Piping Leak Detection:	0. None
Piping Secondary Containment:	12. Double-Walled (Aboveground Only)
Overfill Prevention:	2. High Level Alarm,4. Product Level Gauge (Aboveground Only)
Spill Prevention:	0. None
Dispenser:	2. Suction

Tank Number:	007
Status:	1. In-Service
Date Installation:	01/01/1974
Capacity:	250
Product Stored:	0001. #2 Fuel Oil
Product Stored Percent:	Not reported
Date Perm Closure:	01/01/1900
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Leak Detection:	6. Impervious Barrier/Concrete Pad (Aboveground Only)
Tank Secondary Containment:	1. Diking (aboveground only)
Piping Location:	1. Aboveground
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	1. Painted/Asphalt Coating

RECKSON METRO CENTER (Continued) **1007796644**

Piping Leak Detection: 0. None
Piping Secondary Containment: 0. None
Overfill Prevention: 2. High Level Alarm,4. Product Level Gauge (Aboveground Only)
Spill Prevention: 0. None
Dispenser: 2. Suction

Tank Number: 008
Status: 1. In-Service
Date Installation: 01/01/1974
Capacity: 25
Product Stored: 0001. #2 Fuel Oil
Product Stored Percent: 0
Date Perm Closure: 01/01/1900
Tank Location: 3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type: 1. Steel/Carbon steel/Iron
Tank Internal Protection: 0. None
Tank External Protection: 1. Painted/Asphalt Coating
Tank Leak Detection: 6. Impervious Barrier/Concrete Pad (Aboveground Only)
Tank Secondary Containment: 0. None
Piping Location: 1. Aboveground
Piping Type: 1. Steel/Carbon/ Steel/Iron
Piping External Protection: 1. Painted/Asphalt Coating
Piping Leak Detection: 0. None
Piping Secondary Containment: 0. None
Overfill Prevention: 3. Automatic Shut-off
Spill Prevention: 0. None
Dispenser: 3. Gravity

Tank Number: 009
Status: 1. In-Service
Date Installation: 01/01/1974
Capacity: 88
Product Stored: 0001. #2 Fuel Oil
Product Stored Percent: 0
Date Perm Closure: 01/01/1900
Tank Location: 3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type: 1. Steel/Carbon steel/Iron
Tank Internal Protection: Not reported
Tank External Protection: 5. Jacketed
Tank Leak Detection: 6. Impervious Barrier/Concrete Pad (Aboveground Only)
Tank Secondary Containment: 0. None
Piping Location: 1. Aboveground
Piping Type: 1. Steel/Carbon/ Steel/Iron
Piping External Protection: 6. Wrapped (Piping)
Piping Leak Detection: 0. None
Piping Secondary Containment: 0. None
Overfill Prevention: 3. Automatic Shut-off
Spill Prevention: 0. None
Dispenser: 3. Gravity

US AIRS (AFS):
Region Code: 02
County Code: NY119
Programmatic ID: AIR NY0000003551700249
Facility Registry ID: 110019591538

RECKSON METRO CENTER (Continued) **1007796644**

D and B Number: Not reported
Facility Site Name: RECKSON METRO CENTER
Primary SIC Code: 6531
NAICS Code: 999999
Default Air Classification Code: SMI
Facility Type of Ownership Code: POF
Air CMS Category Code: Not reported
HPV Status: Not reported

US AIRS (AFS):
Region Code: 02
Programmatic ID: AIR NY0000003551700249
Facility Registry ID: 110019591538
Air Operating Status Code: OPR
Default Air Classification Code: SMI

Air Program: State Implementation Plan for National Primary and Secondary Ambient Air Quality Standards
Activity Date: 2008-10-24 00:00:00
Activity Status Date: Not reported
Activity Group: Compliance Monitoring
Activity Type: Inspection/Evaluation
Activity Status: Not reported

AK367 **CON EDISON** **RCRA NonGen / NLR** **1019908523**
ESE **128 MAMARONECK AVE** **FINDS** **NYP004846877**
1/8-1/4 **WHITE PLAINS, NY 10601** **ECHO**
0.249 mi.
1315 ft. **Site 3 of 7 in cluster AK**

Relative:
Higher

Actual:
224 ft.

RCRA Listings:
Date Form Received by Agency: 20151001
Handler Name: Con Edison
Handler Address: Mamaroneck Ave
Handler City,State,Zip: WHITE PLAINS, NY 10601
EPA ID: NYP004846877
Contact Name: THOMAS TEELING
Contact Address: Not reported
Contact City,State,Zip: Not reported
Contact Telephone: 212-460-3770
Contact Fax: Not reported
Contact Email: Not reported
Contact Title: Not reported
EPA Region: 02
Land Type: Private
Federal Waste Generator Description: Not a generator, verified
Non-Notifier: Not reported
Biennial Report Cycle: Not reported
Accessibility: Not reported
Active Site Indicator: Not reported
State District Owner: Ny
State District: NYSDEC R2
Mailing Address: IRVING PL 15TH FL NE
Mailing City,State,Zip: NEW YORK, NY 10003
Owner Name: Not reported
Owner Type: Not reported
Operator Name: Not reported
Operator Type: Not reported

CON EDISON (Continued) **1019908523**

Short-Term Generator Activity:	No
Importer Activity:	No
Mixed Waste Generator:	No
Transporter Activity:	No
Transfer Facility Activity:	No
Recycler Activity with Storage:	No
Small Quantity On-Site Burner Exemption:	No
Smelting Melting and Refining Furnace Exemption:	No
Underground Injection Control:	No
Off-Site Waste Receipt:	No
Universal Waste Indicator:	No
Universal Waste Destination Facility:	No
Federal Universal Waste:	No
Active Site State-Reg Handler:	---
Federal Facility Indicator:	Not reported
Hazardous Secondary Material Indicator:	N
Sub-Part K Indicator:	Not reported
2018 GPRA Permit Baseline:	Not on the Baseline
2018 GPRA Renewals Baseline:	Not on the Baseline
202 GPRA Corrective Action Baseline:	No
Subject to Corrective Action Universe:	No
Non-TSDFs Where RCRA CA has Been Imposed Universe:	No
Corrective Action Priority Ranking:	No NCAPS ranking
Environmental Control Indicator:	No
Institutional Control Indicator:	No
Human Exposure Controls Indicator:	N/A
Groundwater Controls Indicator:	N/A
Significant Non-Complier Universe:	No
Unaddressed Significant Non-Complier Universe:	No
Addressed Significant Non-Complier Universe:	No
Significant Non-Complier With a Compliance Schedule Universe:	No
Financial Assurance Required:	Not reported
Handler Date of Last Change:	20160909
Recognized Trader-Importer:	No
Recognized Trader-Exporter:	No
Importer of Spent Lead Acid Batteries:	No
Exporter of Spent Lead Acid Batteries:	No
Recycler Activity Without Storage:	No
Manifest Broker:	No
Sub-Part P Indicator:	No

Historic Generators:

Receive Date:	20151001
Handler Name: CON EDISON	
Federal Waste Generator Description:	Large Quantity Generator
State District Owner:	Ny
Large Quantity Handler of Universal Waste:	No
Recognized Trader Importer:	No
Recognized Trader Exporter:	No
Spent Lead Acid Battery Importer:	No
Spent Lead Acid Battery Exporter:	No
Current Record:	No
Non Storage Recycler Activity:	Not reported
Electronic Manifest Broker:	Not reported

Receive Date:	20151001

CON EDISON (Continued) **1019908523**

Handler Name: CON EDISON
Federal Waste Generator Description: Not a generator, verified
State District Owner: Ny
Large Quantity Handler of Universal Waste: No
Recognized Trader Importer: No
Recognized Trader Exporter: No
Spent Lead Acid Battery Importer: No
Spent Lead Acid Battery Exporter: No
Current Record: Yes
Non Storage Recycler Activity: Not reported
Electronic Manifest Broker: Not reported

List of NAICS Codes and Descriptions:
NAICS Codes: No NAICS Codes Found

Facility Has Received Notices of Violations:
Violations: No Violations Found

Evaluation Action Summary:
Evaluations: No Evaluations Found

FINDS:
Registry ID: 110069676185

Click Here for FRS Facility Detail Report:

Environmental Interest/Information System:
The Resource Conservation and Recovery Act Information System (RCRAInfo) is EPA's comprehensive information system in support of the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. It tracks many types of information about generators, transporters, treaters, storers, and disposers of hazardous waste.

Click this hyperlink while viewing on your computer to access additional FINDS: detail in the EDR Site Report.

ECHO:
Envid: 1019908523
Registry ID: 110069676185

DFR URL:
Name: CON EDISON
Address: 128 MAMARONECK AVE
City,State,Zip: WHITE PLAINS, NY 10601

AK368 **CON EDISON** **NY MANIFEST** **S119078146**
ESE **128 MAMARONECK AVE** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.249 mi.
1315 ft. **Site 4 of 7 in cluster AK**

Relative:
Higher

Actual:
224 ft.

NY MANIFEST:

EPA ID:	NYP004846877
Country:	USA
Name:	Con Edison
Address:	128 MAMARONECK AVE
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10601
Zip 4:	Not reported
Location Address 1:	128 MAMORONECK AVE
Location Address 2:	SB 1807
Location City,State,Zip:	WHITE PLAINS, NY 10601
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Edison
Mailing Contact:	Dennis Huacon
Mailing Address 1:	4 IRVING PL 15TH FL
Mailing Address 2:	Not reported
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	2124603770

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	10/01/2015
Trans1 Recv Date:	10/01/2015
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	10/05/2015
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004846877
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	014460357JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported

CON EDISON (Continued) **S119078146**

Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	100
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

AK369 **CON EDISON** **NJ MANIFEST** **S120677447**
ESE **128 MAMARONECK AVE** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.249 mi.
1315 ft. **Site 5 of 7 in cluster AK**

Relative:
Higher

Actual:
224 ft.

NJ MANIFEST:

EPA ID:	NYP004846877
Name:	CON EDISON
Address:	128 MAMARONECK AVE
City,State,Zip:	WHITE PLAINS, NY 10601
County:	Not reported
Mailing Address:	IRVING PL 15TH FL NE
Mailing City,State,Zip:	NEW YORK, NY 10003
Telephone:	Not reported
Emergency Telephone:	Not reported
Contact:	THOMAS TEELING
Comments:	Not reported
SIC Code:	Not reported
County:	NY119
Municipal:	Not reported
Previous EPAID:	Not reported
Generator Flag:	Not reported
Transporter Flag:	Not reported
TSDF Flag:	Not reported
Name Change:	Not reported
Date Change:	Not reported

Manifest Data:

EPA ID:	NYP004846877
Manifest Number:	014460357JJK
Date Shipped:	10/1/2015
TSDF EPA ID:	NJD002200046
Transporter EPA ID:	NYD006982359
Transporter 2 EPA ID:	Not reported
Transporter 3 EPA ID:	Not reported

CON EDISON (Continued) **S120677447**

Transporter 4 EPA ID:	Not reported
Transporter 5 EPA ID:	Not reported
Transporter 6 EPA ID:	Not reported
Transporter 7 EPA ID:	Not reported
Transporter 8 EPA ID:	Not reported
Transporter 9 EPA ID:	Not reported
Transporter 10 EPA ID:	Not reported
Date Trans1 Transported Waste:	Not reported
Date Trans2 Transported Waste:	Not reported
Date Trans3 Transported Waste:	Not reported
Date Trans4 Transported Waste:	Not reported
Date Trans5 Transported Waste:	Not reported
Date Trans6 Transported Waste:	Not reported
Date Trans7 Transported Waste:	Not reported
Date Trans8 Transported Waste:	Not reported
Date Trans9 Transported Waste:	Not reported
Date Trans10 Transported Waste:	Not reported
Date TSDF Received Waste:	Not reported
TSDF EPA Facility Name:	Not reported
QTY Units:	Not reported
Transporter SEQ ID:	Not reported
Transporter-1 Date:	Not reported
Waste SEQ ID:	Not reported
Waste Type Code 2:	Not reported
Waste Type Code 3:	Not reported
Waste Type Code 4:	Not reported
Waste Type Code 5:	Not reported
Waste Type Code 6:	Not reported
Date Accepted:	Not reported
Manifest Discrepancy Type:	Not reported
Data Entry Number:	Not reported
Was Load Rejected:	Not reported
Reason Load Was Rejected:	Not reported

AO370 **WINBROOK HOUSING DEVELOPMENT** **NY UST** **U003995071**
SSE **223 DR. MARTIN LUTHER KING BLVD.** **N/A**
1/8-1/4 **WHITE PLAINS, NY 10601**
0.250 mi.
1320 ft. **Site 1 of 3 in cluster AO**

Relative: **Higher**
Actual: **215 ft.**

WESTCHESTER CO. UST:

Name:	WINBROOK HOUSING DEVELOPMENT
Address:	223 DR. MARTIN LUTHER KING BLVD.
City,State,Zip:	WHITE PLAINS, NY 10601
Id/Status:	3-493597 / Active
Operator Name:	Teddie Henderson
Owner Name:	White Plains Housing Authority
Owner Street:	223 Dr. Martin Luther King Blvd.
Owner Address2:	Not reported
Owner City:	White Plains
Owner State:	NY
Owner Zipcode:	10601
GDS Number:	Not reported
Tank Number:	001
Status:	1. In-Service
Capacity:	20000

WINBROOK HOUSING DEVELOPMENT (Continued) **U003995071**

Product Stored:	0001. #2 Fuel Oil
Product Stored Percent:	Not reported
Tank Leak Detection:	99. Other
Date Installation:	01/01/1950
Date Perm Closure:	01/01/1900
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	2. Underground/on Ground
Piping Type:	11. Flexible Piping
Piping External Protection:	0. None
Overfill Prevention:	5. Vent Whistle
Piping Secondary Containment:	4. Double-Walled (underground only)
Spill Prevention:	1. Catch Basin
Dispenser:	0. None

Tank Number:	002
Status:	1. In-Service
Capacity:	20000
Product Stored:	0001. #2 Fuel Oil
Product Stored Percent:	Not reported
Tank Leak Detection:	99. Other
Date Installation:	01/01/1950
Date Perm Closure:	01/01/1900
Tank Location:	5. Underground including vaulted with no access for inspection
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	0. None
Tank Secondary Containment:	0. None
Piping Location:	2. Underground/on Ground
Piping Type:	11. Flexible Piping
Piping External Protection:	0. None
Overfill Prevention:	5. Vent Whistle
Piping Secondary Containment:	4. Double-Walled (underground only)
Spill Prevention:	1. Catch Basin
Dispenser:	0. None

AO371 **WINDBROOK HOUSING** **NY LTANKS** **S105996991**
SSE **223 DR MARTIN LUTHER KING** **N/A**
1/8-1/4 **WHITE PLAINS, NY**
0.250 mi.
1320 ft. **Site 2 of 3 in cluster AO**

Relative:
Higher

Actual:
215 ft.

LTANKS:

Name:	WINDBROOK HOUSING
Address:	223 DR MARTIN LUTHER KING
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0207150 / 2002-11-25
Facility ID:	0207150
Site ID:	243532
Spill Date:	2002-10-10
Spill Cause:	Tank Test Failure
Spill Source:	Private Dwelling
Spill Class:	C3
Cleanup Ceased:	Not reported

WINDBROOK HOUSING (Continued) **S105996991**

SWIS:	6017
Investigator:	WCHD
Referred To:	Westchester Cnty Health Dept
Reported to Dept:	2002-10-10
CID:	211
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2002-10-10
Spill Record Last Update:	2015-03-26
Spiller Name:	ALAN PIO
Spiller Company:	WINDBROOK HOUSING
Spiller Address:	223 DR MARTIN LUTHER KING
Spiller County:	001
Spiller Contact:	ALAN PIO
Spiller Phone:	(914) 949-6462
Spiller Extention:	13
DEC Region:	3
DER Facility ID:	200049
Latitude:	41.0278411
Longitude:	-73.7685899
DEC Memo:	3/26/15: Hard copy file pulled for FOIL request. File being scanned into DecDocs and paper file will be disgarded. jod
Remarks:	2 tanks 20000 gals joined together - failed individually & collectively

All TTF:

Facility ID:	0207150
Spill Number:	0207150
Spill Tank Test:	1527564
Site ID:	243532
Tank Number:	1
Tank Size:	20000
Material:	0002
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	243532
Operable Unit ID:	859974
Operable Unit:	01
Material ID:	517734
Material Code:	0002A
Material Name:	#4 fuel oil
Case No.:	Not reported

WINDBROOK HOUSING (Continued) **S105996991**

Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

AO372 **WHITE PLAIN HOUSING AUTH.** **NY LTANKS** **S100140591**
SSE **225 GROVE ST** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.252 mi.
1328 ft. **Site 3 of 3 in cluster AO**

Relative:
Higher

Actual:
215 ft.

LTANKS:

Name:	WHITE PLAIN HOUSING AUTH.
Address:	225 GROVE ST
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8904683 / 1992-07-30
Facility ID:	8904683
Site ID:	293104
Spill Date:	1989-08-10
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	C4
Cleanup Ceased:	1992-07-30
SWIS:	6017
Investigator:	WXWADSWO
Referred To:	Not reported
Reported to Dept:	1989-08-11
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1989-08-21
Spill Record Last Update:	1992-07-30
Spiller Name:	Not reported
Spiller Company:	Not reported
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	237240
Latitude:	41.0278231
Longitude:	-73.7685902
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was WADSWORTH
Remarks:	TANKS ARE 35 YR. OLD-2 TANKS 1 PASSED, 1 FAILED, TO ISOLATE & RETEST ASAP. VMC ADVISED 35 YRD OLD TANK MAY NOT BE WORTH REPAIRING, SHOULD BE REPLACED. W.W. TO FOLLOW UP.

All TTF:

WHITE PLAIN HOUSING AUTH. (Continued) **S100140591**

Facility ID:	8904683
Spill Number:	8904683
Spill Tank Test:	1535834
Site ID:	293104
Tank Number:	Not reported
Tank Size:	0
Material:	0002
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	293104
Operable Unit ID:	929941
Operable Unit:	01
Material ID:	448716
Material Code:	0002A
Material Name:	#4 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

AP373 **SPILL NUMBER 8809894** **NY LTANKS** **S104619049**
East **23 MITCHELL PLACE** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.259 mi.
1367 ft. **Site 1 of 5 in cluster AP**

Relative: **Higher**

Actual: **218 ft.**

LTANKS:

Name:	SPILL NUMBER 8809894
Address:	23 MITCHELL PLACE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8809894 / 1991-12-20
Facility ID:	8809894
Site ID:	286069
Spill Date:	1989-03-23
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1989-03-23
CID:	Not reported

SPILL NUMBER 8809894 (Continued) **S104619049**

Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1989-03-28
Spill Record Last Update:	2003-09-19
Spiller Name:	Not reported
Spiller Company:	SEA MGT
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	231859
Latitude:	41.0307933
Longitude:	-73.7650019
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY
Remarks:	PLUMBING LEAKED DURING FILLING FOR TEST. TO ISOLATE, EXCAVATE AND RETEST.

All TTF:

Facility ID:	8809894
Spill Number:	8809894
Spill Tank Test:	1535281
Site ID:	286069
Tank Number:	Not reported
Tank Size:	0
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	286069
Operable Unit ID:	926206
Operable Unit:	01
Material ID:	451068
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Groundwater

SPILL NUMBER 8809894 (Continued) **S104619049**

Oxygenate: Not reported

AQ374 **WESTCHESTER OFFICE BLDG.** **NY LTANKS** **S100141797**
SE **112 EAST POST ROAD** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.259 mi.
1367 ft. **Site 1 of 5 in cluster AQ**

Relative:
Higher

Actual:
238 ft.

LTANKS:

Name:	WESTCHESTER OFFICE BLDG.
Address:	112 EAST POST ROAD
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9009334 / 1990-12-11
Facility ID:	9009334
Site ID:	243138
Spill Date:	1990-11-27
Spill Cause:	Tank Failure
Spill Source:	Institutional, Educational, Gov., Other
Spill Class:	Not reported
Cleanup Ceased:	1990-12-11
SWIS:	6017
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1990-11-27
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Responsible Party
Last Inspection:	1990-12-11
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1990-11-30
Spill Record Last Update:	1991-01-14
Spiller Name:	Not reported
Spiller Company:	SAME
Spiller Address:	Not reported
Spiller County:	999
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	199725
Latitude:	41.0283436
Longitude:	-73.7667249
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY 01/14/91: FIXED LINE, TANK TECH CHECKED AND REPAIRED. NO CONTAMINATED SOIL.
Remarks:	TANK LEAKED WHEN 10 LBS. AIR PRESSURE PUT ON IT FUEL LEAKED TO CONCRETE BASEMENT FLOOR WEST,CTY. NOTIFIED DPW SPEEDI-DRY BEING APPLIED WCHD HANDLING

All Materials:

Site ID:	243138
Operable Unit ID:	949838
Operable Unit:	01
Material ID:	429553

WESTCHESTER OFFICE BLDG. (Continued) **S100141797**

Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	15.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

AQ375 **COMMERCIAL** **NY LTANKS** **S121988273**
SE **130-144 EAST POST RD** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.260 mi.
1373 ft. **Site 2 of 5 in cluster AQ**

Relative: **Higher**
Actual: **234 ft.**

LTANKS:

Name:	COMMERCIAL
Address:	130-144 EAST POST RD
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0002215 / 2011-02-28
Facility ID:	0002215
Site ID:	159846
Spill Date:	2000-05-22
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	jbodee
Referred To:	Not reported
Reported to Dept:	2000-05-22
CID:	323
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2000-05-22
Spill Record Last Update:	2011-02-28
Spiller Name:	ROBERT KIM
Spiller Company:	COMMERCIAL
Spiller Address:	130-144 EAST POST RD
Spiller County:	001
Spiller Contact:	ROBERT KIM
Spiller Phone:	(914) 723-2964
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	135018
Latitude:	41.0286801
Longitude:	-73.7661833
DEC Memo:	12/28/09: File review. Reported as a TTF of a 1K tank, commercial property, not a registered facility. Call back notes on initial report state: 1K UG - To call & advise WCHD with future . No further information received. jod 2/28/11: This is the same tank as spill

COMMERCIAL (Continued) **S121988273**

1005304. Tank was never removed or retested after initial failure. Tank was leaking. Tank was removed and clean up was completed ten years later after the shopping center burned down. jod

Remarks: UNKNOWN WHAT IS GOING TO BE DONE.

All TTF:

Facility ID:	0002215
Spill Number:	0002215
Spill Tank Test:	1525625
Site ID:	159846
Tank Number:	Not reported
Tank Size:	1000
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	.00
Gross Fail:	F
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	159846
Operable Unit ID:	823747
Operable Unit:	01
Material ID:	550585
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

AR376 **WHITE PLAINS HONDA** **NY LTANKS** **S102675103**
SW **31 WESTMPORELAND AVE** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.262 mi.
1382 ft. **Site 1 of 6 in cluster AR**

Relative:
Higher

Actual:
208 ft.

LTANKS:

Name:	WHITE PLAINS HONDA
Address:	31 WESTMPORELAND AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9514655 / 1996-02-15
Facility ID:	9514655
Site ID:	224484
Spill Date:	1996-02-15
Spill Cause:	Tank Overfill
Spill Source:	Unknown
Spill Class:	B4
Cleanup Ceased:	Not reported

WHITE PLAINS HONDA (Continued) **S102675103**

SWIS:	6000
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1996-02-15
CID:	252
Water Affected:	Not reported
Spill Notifier:	Responsible Party
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1996-02-15
Spill Record Last Update:	1996-02-23
Spiller Name:	RICK BOLOGNA
Spiller Company:	WESTMORE FUELS
Spiller Address:	86 NO WATER STREET
Spiller County:	001
Spiller Contact:	MR J CAREAGA
Spiller Phone:	(914) 948-3305
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	185537
Latitude:	41.0284486
Longitude:	-73.7757275
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY
Remarks:	tank over fill caused spill at business-spill has been cleaned up from pavement

All Materials:

Site ID:	224484
Operable Unit ID:	1029198
Operable Unit:	01
Material ID:	354785
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	6.00
Units:	G
Recovered:	6.00
Resource Affected:	Soil
Oxygenate:	Not reported

AP377 **SPILL NUMBER 9905959** **NY LTANKS** **S104620381**
East **25 MITCHELL PLACE** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.263 mi.
1390 ft. **Site 2 of 5 in cluster AP**

Relative: **Higher**
Actual: **218 ft.**

LTANKS:

Name:	SPILL NUMBER 9905959
Address:	25 MITCHELL PLACE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9905959 / 1999-10-08
Facility ID:	9905959

SPILL NUMBER 9905959 (Continued) **S104620381**

Site ID:	111332
Spill Date:	1999-08-17
Spill Cause:	Tank Failure
Spill Source:	Private Dwelling
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	WCHD
Referred To:	Westchester Cnty Health Dept
Reported to Dept:	1999-08-18
CID:	388
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1999-08-18
Spill Record Last Update:	1999-10-27
Spiller Name:	JAMES MA
Spiller Company:	W P M V INC
Spiller Address:	200 E 61ST ST SUITE 4G
Spiller County:	001
Spiller Contact:	CALLER
Spiller Phone:	(914) 472-8779
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	97378
Latitude:	41.0308195
Longitude:	-73.7649181
DEC Memo:	Not reported
Remarks:	caller reports they went to clean tank and they saw holes in the tank. Not reported

All Materials:

Site ID:	111332
Operable Unit ID:	1084404
Operable Unit:	01
Material ID:	553103
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

AR378 **MUNICIPAL GARAGE** **NY LTANKS** **S100140495**
SW **111** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.264 mi.
1396 ft. **Site 2 of 6 in cluster AR**

Relative:
Higher

Actual:
208 ft.

LTANKS:

Name:	MUNICIPAL GARAGE
Address:	111
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8808829 / 1991-08-07
Facility ID:	8808829
Site ID:	129523
Spill Date:	1989-02-10
Spill Cause:	Tank Test Failure
Spill Source:	Institutional, Educational, Gov., Other
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1989-02-10
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	True
Remediation Phase:	0
Date Entered In Computer:	1989-02-16
Spill Record Last Update:	2003-09-19
Spiller Name:	Not reported
Spiller Company:	JOHN HAINLINE
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	111644
Latitude:	40.8077550
Longitude:	-73.8549840
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY
Remarks:	2K -.6545. IER. THE GARAGE IS PULLING THE TANKS AND THE GARAGE WILL TELL US WHEN. TANK PULLER WILL BE HAZCO. ROD KING 718-575-3219

All TTF:

Facility ID:	8808829
Spill Number:	8808829
Spill Tank Test:	1535167
Site ID:	129523
Tank Number:	Not reported
Tank Size:	0
Material:	0009
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported

MUNICIPAL GARAGE (Continued) **S100140495**

Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	129523
Operable Unit ID:	925216
Operable Unit:	01
Material ID:	453596
Material Code:	0009
Material Name:	gasoline
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

AL379 **28 MITCHELL PLACE** **NY LTANKS** **U003647993**
East **28 MITCHELL PLACE** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.266 mi.
1403 ft. **Site 2 of 3 in cluster AL**

Relative:
Higher

Actual:
218 ft.

LTANKS:

Name:	28 MITCHELL PLACE
Address:	28 MITCHELL PLACE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9903630 / 2001-11-14
Facility ID:	9903630
Site ID:	206823
Spill Date:	1999-06-29
Spill Cause:	Tank Failure
Spill Source:	Commercial/Industrial
Spill Class:	B4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	WCHD
Referred To:	Westchester Cnty Health Dept
Reported to Dept:	1999-06-29
CID:	388
Water Affected:	Not reported
Spill Notifier:	Affected Persons
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1999-06-29
Spill Record Last Update:	2003-06-02
Spiller Name:	Not reported
Spiller Company:	UNKNOWN

28 MITCHELL PLACE (Continued) **U003647993**

Spiller Address:	Not reported
Spiller County:	999
Spiller Contact:	MMP DEVELOPMENT
Spiller Phone:	(914) 725-6858
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	171695
Latitude:	41.0309540
Longitude:	-73.7648680
DEC Memo:	Not reported
Remarks:	CALLER REPORTS PULLING TANK AND THE TANK WAS LEAKING.

All Materials:

Site ID:	206823
Operable Unit ID:	1082559
Operable Unit:	01
Material ID:	303542
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	SPILL NUMBER 9901259
Address:	28 MITCHELL PLACE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9901259 / 1999-05-13
Facility ID:	9901259
Site ID:	206822
Spill Date:	1999-05-03
Spill Cause:	Tank Test Failure
Spill Source:	Private Dwelling
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	jbodee
Referred To:	Not reported
Reported to Dept:	1999-05-03
CID:	382
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1999-05-03
Spill Record Last Update:	1999-07-25
Spiller Name:	PHILLIPS
Spiller Company:	Not reported
Spiller Address:	28 MITCHELL PLACE
Spiller County:	001
Spiller Contact:	PHILLIPS

28 MITCHELL PLACE (Continued) **U003647993**

Spiller Phone:	(914) 472-5424
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	171695
Latitude:	41.0309540
Longitude:	-73.7648680
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was
Remarks:	O'DEE 5/13/99 TANK PASSED ISOLATION RETEST. LINES TO BE REPLACED. NFA SYSTEM FAILURE. OWNER WAS ADVISED.

All TTF:

Facility ID:	9901259
Spill Number:	9901259
Spill Tank Test:	1547140
Site ID:	206822
Tank Number:	Not reported
Tank Size:	2000
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	206822
Operable Unit ID:	1079959
Operable Unit:	01
Material ID:	304805
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

AS380 **FIRE STATION 2** **NY LTANKS** **S107410250**
NW **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.266 mi.
1406 ft. **Site 1 of 4 in cluster AS**

Relative: **Higher**
Actual: **198 ft.**

LTANKS:

Name:	FIRE STATION 2
Address:	Not reported
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8801791 / 1989-01-24
Facility ID:	8801791
Site ID:	297873

FIRE STATION 2 (Continued) **S107410250**

Spill Date:	1988-05-26
Spill Cause:	Tank Test Failure
Spill Source:	Institutional, Educational, Gov., Other
Spill Class:	Not reported
Cleanup Ceased:	1989-01-12
SWIS:	6000
Investigator:	jeokesso
Referred To:	Not reported
Reported to Dept:	1988-05-26
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	1989-01-12
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1988-06-02
Spill Record Last Update:	1989-02-07
Spiller Name:	Not reported
Spiller Company:	FIRE STATION 2
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	284756
Latitude:	Not reported
Longitude:	Not reported
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was OKESSON
Remarks:	TANK ONLY TEST .25851 GPH. PBS TO FOLLOW. NO RESULTS

All TTF:

Facility ID:	8801791
Spill Number:	8801791
Spill Tank Test:	1533986
Site ID:	297873
Tank Number:	Not reported
Tank Size:	0
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	297873
Operable Unit ID:	917247
Operable Unit:	01

FIRE STATION 2 (Continued) **S107410250**

Material ID:	460915
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

AQ381 **COACHMAN HOTEL** **NY LTANKS** **1000912672**
SE **123 EAST POST ROAD** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.266 mi.
1407 ft. **Site 3 of 5 in cluster AQ**

Relative:
Higher

Actual:
236 ft.

LTANKS:

Name:	COACHMAN HOTEL
Address:	123 EAST POST ROAD
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9306655 / 1993-09-24
Facility ID:	9306655
Site ID:	211948
Spill Date:	1993-08-31
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	C3
Cleanup Ceased:	1993-09-24
SWIS:	6017
Investigator:	WXWADSWO
Referred To:	Not reported
Reported to Dept:	1993-08-31
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1993-09-02
Spill Record Last Update:	1993-11-16
Spiller Name:	Not reported
Spiller Company:	SAME
Spiller Address:	Not reported
Spiller County:	999
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	175633
Latitude:	41.0283944
Longitude:	-73.7664147
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was WADSWORTH
Remarks:	HOLE IN CROWN OF TANK WILL WORK WITH CTY. TO MAKE SURE NO SOIL

COACHMAN HOTEL (Continued) **1000912672**

CONTAMINATION 8K 35 YEARS OLD TANK W.C. IS LOOKING TO BUY HOTEL

All TTF:

Facility ID:	9306655
Spill Number:	9306655
Spill Tank Test:	1541932
Site ID:	211948
Tank Number:	Not reported
Tank Size:	0
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	211948
Operable Unit ID:	984819
Operable Unit:	01
Material ID:	396502
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	Not reported
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

AS382 **FIRE STATION # 2 WH PLAIN** **UST FINDER RELEASE** **1029059745**
NW **20 FERRIS AVE** **N/A**
1/4-1/2 **WHITE PLAINS, NY 0**
0.267 mi.
1410 ft. **Site 2 of 4 in cluster AS**

Relative:
Higher

Actual:
201 ft.

UST FINDER RELEASE:

Object ID:	262269
Facility ID:	NY140526
Lust ID:	NY8800670
Name:	FIRE STATION # 2 WH PLAIN
Address:	20 FERRIS AVE
City,State,Zip:	WHITE PLAINS, NY 0
Address Match Type:	Not reported
Reported Date:	1988/04/21 16:00:00+00
Status:	No Further Action
Substance:	Not reported
Population within 1500ft:	2589
Domestic Wells within 1500ft:	0
Land Use:	Developed, High Intensity
Within SPA:	Yes

FIRE STATION # 2 WH PLAIN (Continued) **1029059745**

SPA PWS Facility ID:	NY7003493_76968
SPA Water Type:	SW - SurRELEASEe Water
SPA Facility Type:	RS - Reservoir
SPA HUC12:	20301020103
Within WHPA:	No
WHPA PWS Facility ID:	Not reported
WHPA Water Type:	Not reported
WHPA Facility Type:	Not reported
WHPA HUC12:	Not reported
Within 100yr Floodplain:	No
Tribe:	Not reported
EPA Region:	2
NFA Letter 1:	Not reported
NFA Letter 2:	Not reported
NFA Letter 3:	Not reported
NFA Letter 4:	Not reported
Closed With Residual Contaminate:	Not reported
Coordinate Source:	State
X Coord:	-73.77421
Y Coord:	41.0342600000001
Latitude:	41.03426
Longitude:	-73.7742099999999

AS383 **PRIVATE ENTERPRISE** **NY LTANKS** **U000379968**
NW **20 FERRIS AVE** **NY AST** **N/A**
1/4-1/2 **WHITE PLAINS, NY** **NY Spills**
0.267 mi.
1410 ft. **Site 3 of 4 in cluster AS**

Relative: **Higher**
Actual: **201 ft.**

LTANKS:

Name:	PRIVATE ENTERPRISE
Address:	20 FERRIS AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0402326 / 2004-06-02
Facility ID:	0402326
Site ID:	166779
Spill Date:	2004-06-02
Spill Cause:	Tank Overfill
Spill Source:	Commercial/Industrial
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	2004-06-02
CID:	406
Water Affected:	Not reported
Spill Notifier:	Police Department
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2004-06-02
Spill Record Last Update:	2004-06-08
Spiller Name:	UNKNOWN NAME
Spiller Company:	VALLEY OIL CO
Spiller Address:	Not reported

PRIVATE ENTERPRISE (Continued) **U000379968**

Spiller County:	001
Spiller Contact:	UNKNOWN NAME
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	140526
Latitude:	41.0342599
Longitude:	-73.7742100
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY
Remarks:	Had an overfill while filling and underground tank. Caller could give no more information. Spill is contained and no clean up at this time.

All Materials:

Site ID:	166779
Operable Unit ID:	884005
Operable Unit:	01
Material ID:	489950
Material Code:	0008
Material Name:	diesel
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	15.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	FIRE STATION # 2
Address:	20 FERRIS AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8800487 / 1989-01-11
Facility ID:	8800487
Site ID:	166780
Spill Date:	1988-04-14
Spill Cause:	Tank Test Failure
Spill Source:	Institutional, Educational, Gov., Other
Spill Class:	D3
Cleanup Ceased:	1989-01-11
SWIS:	6017
Investigator:	jeokesso
Referred To:	Not reported
Reported to Dept:	1988-04-14
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	1989-01-11
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	True
Remediation Phase:	0
Date Entered In Computer:	1988-05-04
Spill Record Last Update:	1989-02-07
Spiller Name:	Not reported
Spiller Company:	SAME
Spiller Address:	Not reported
Spiller County:	999

PRIVATE ENTERPRISE (Continued) **U000379968**

Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	140526
Latitude:	41.0342599
Longitude:	-73.7742100
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was OKESSON
Remarks:	2K TANK LEAK @ GAUGE WILL REPAIR DEC TO CHECK BACK. PBS TO FOLLOW. NO RESULTS

All TTF:

Facility ID:	8800487
Spill Number:	8800487
Spill Tank Test:	1533659
Site ID:	166780
Tank Number:	Not reported
Tank Size:	0
Material:	0008
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	166780
Operable Unit ID:	916111
Operable Unit:	01
Material ID:	459675
Material Code:	0008
Material Name:	diesel
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	Not reported
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

Name:	FIRE STATION # 2 WH PLAIN
Address:	20 FERRIS AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8800670 / 1989-01-11
Facility ID:	8800670
Site ID:	166781
Spill Date:	1988-04-21
Spill Cause:	Tank Test Failure
Spill Source:	Institutional, Educational, Gov., Other
Spill Class:	D3

PRIVATE ENTERPRISE (Continued) **U000379968**

Cleanup Ceased:	1989-01-11
SWIS:	6017
Investigator:	jeokesso
Referred To:	Not reported
Reported to Dept:	1988-04-21
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	1989-01-11
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	True
Remediation Phase:	0
Date Entered In Computer:	1988-04-28
Spill Record Last Update:	1989-02-07
Spiller Name:	Not reported
Spiller Company:	CITY OF WHITE PLAINS
Spiller Address:	TOM MALONEY
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	140526
Latitude:	41.0342599
Longitude:	-73.7742100
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was OKESSON 11/29/95: This is additional information about material spilled from the translation of the old spill file: UNLEADED.
Remarks:	2 K SYSTEM FAILED HORNER EASY CHECK AT -.1287GPH. SAME AS 88-00487 NON RESULTS

All TTF:

Facility ID:	8800670
Spill Number:	8800670
Spill Tank Test:	1533711
Site ID:	166781
Tank Number:	Not reported
Tank Size:	0
Material:	0009
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	166781
Operable Unit ID:	917669
Operable Unit:	01
Material ID:	459844
Material Code:	0009

PRIVATE ENTERPRISE (Continued) **U000379968**

Material Name: gasoline
Case No.: Not reported
Material FA: Petroleum
Quantity: .00
Units: G
Recovered: .00
Resource Affected: Groundwater
Oxygenate: Not reported

WESTCHESTER CO. AST:
Name: FIRE STATION 2
Address: 20 FERRIS AVENUE
City,State,Zip: WHITE PLAINS, NY 10603
PBS Number: 3-169439
Site Status: Active
GDS Number: 3551700331
Operator Name: City Of White Plains
Owner Name: City Of White Plains
Owner Street: 255 Main Street
Owner Address2: Not reported
Owner City/State/Zip: White Plains, NY 10601

Tank Number: 9
Status: 3. Closed - Removed
Date Installation: 01/01/1994
Capacity: 60
Product Stored: 0008. Diesel
Product Stored Percent: 0
Date Perm Closure: 05/01/2014
Tank Location: 3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type: 1. Steel/Carbon steel/Iron
Tank Internal Protection: 0. None
Tank External Protection: 1. Painted/Asphalt Coating
Tank Leak Detection: 2. Manual Interstitial Monitoring,6. Impervious Barrier/Concrete Pad (Aboveground Only)
Tank Secondary Containment: 1. Diking (aboveground only)
Piping Location: 1. Aboveground
Piping Type: 1. Steel/Carbon/ Steel/Iron
Piping External Protection: 1. Painted/Asphalt Coating
Piping Leak Detection: 9. Exempt suction piping
Piping Secondary Containment: 0. None
Overfill Prevention: 4. Product Level Gauge (Aboveground Only)
Spill Prevention: 1. Catch Basin
Dispenser: 2. Suction

SPILLS:
Name: STORM DRAIN
Address: 20 FERRIS AVE
City,State,Zip: WHITE PLAINS, NY
Spill Number/Closed Date: 9408242 / 1997-12-05
Facility ID: 9408242
Facility Type: ER
DER Facility ID: 140526
Site ID: 241713
DEC Region: 3
Spill Cause: Housekeeping

PRIVATE ENTERPRISE (Continued) **U000379968**

Spill Class:	C3
SWIS:	6017
Spill Date:	1994-09-07
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1994-09-21
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Federal Government
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	1994-09-28
Spill Record Last Update:	1997-12-05
Spiller Name:	Not reported
Spiller Company:	Not reported
Spiller Address:	Not reported
Spiller Company:	001
Contact Name:	Not reported
Latitude:	41.0342599
Longitude:	-73.7742100
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY 09/27/95: This is additional information about material spilled from the translation of the old spill file: PAINT/LEAD Not reported
Remarks:	CLEANING A PAINT MACHINE PAINT WENT INTO STORM DRAIN W.C.H.D. INSPECTED SITE 100 GAL OF WATERBASE PAINT NOT LEAD CITY OF WHITE PLAINS SPILLER ORDERED TO CLEAN UP

All Materials:

Site ID:	241713
Operable Unit ID:	1005838
Operable Unit:	01
Material ID:	377684
Material Code:	0066A
Material Name:	unknown petroleum
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	L
Recovered:	.00
Resource Affected:	Sewer
Oxygenate:	Not reported

AS384 **FIRE STATION # 2** **UST FINDER RELEASE** **1029059746**
NW **20 FERRIS AVE** **N/A**
1/4-1/2 **WHITE PLAINS, NY 0**
0.267 mi.
1410 ft. **Site 4 of 4 in cluster AS**

Relative: **Higher**
Actual: **201 ft.**

UST FINDER RELEASE:

Object ID:	262268
Facility ID:	NY140526
Lust ID:	NY8800487
Name:	FIRE STATION # 2
Address:	20 FERRIS AVE
City,State,Zip:	WHITE PLAINS, NY 0
Address Match Type:	Not reported
Reported Date:	1988/04/14 16:00:00+00
Status:	No Further Action
Substance:	Not reported
Population within 1500ft:	2589
Domestic Wells within 1500ft:	0
Land Use:	Developed, High Intensity
Within SPA:	Yes
SPA PWS Facility ID:	NY7003493_76968
SPA Water Type:	SW - SurRELEASEe Water
SPA Facility Type:	RS - Reservoir
SPA HUC12:	20301020103
Within WHPA:	No
WHPA PWS Facility ID:	Not reported
WHPA Water Type:	Not reported
WHPA Facility Type:	Not reported
WHPA HUC12:	Not reported
Within 100yr Floodplain:	No
Tribe:	Not reported
EPA Region:	2
NFA Letter 1:	Not reported
NFA Letter 2:	Not reported
NFA Letter 3:	Not reported
NFA Letter 4:	Not reported
Closed With Residual Contaminate:	Not reported
Coordinate Source:	State
X Coord:	-73.77421
Y Coord:	41.0342600000001
Latitude:	41.03426
Longitude:	-73.7742099999999

AR385 **SPILL NUMBER 0108090** **NY LTANKS** **S105230061**
SW **31 WESTMORELAND AVE** **NY Spills** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.267 mi.
1411 ft. **Site 3 of 6 in cluster AR**

Relative: **Higher**
Actual: **208 ft.**

LTANKS:

Name:	SPILL NUMBER 0108090
Address:	31 WESTMORELAND AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0108090 / 2001-11-08
Facility ID:	0108090
Site ID:	110892
Spill Date:	2001-11-08
Spill Cause:	Tank Overfill
Spill Source:	Tank Truck

SPILL NUMBER 0108090 (Continued) **S105230061**

Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	mbmastro
Referred To:	Not reported
Reported to Dept:	2001-11-08
CID:	207
Water Affected:	Not reported
Spill Notifier:	Responsible Party
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2001-11-08
Spill Record Last Update:	2001-11-27
Spiller Name:	CALLER
Spiller Company:	ROBISON OIL
Spiller Address:	500 EXECUTIVE BLVD
Spiller County:	001
Spiller Contact:	MIKE PRAILEAU
Spiller Phone:	(914) 847-0288
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	97050
Latitude:	41.0284486
Longitude:	-73.7757275
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was MASTRO 11/08/2001 CONFIRMED INFO - SPILL ON PAVEMENT, CONTAINED, NO WATERWAYS AFFECTED. NO FURTHER ACTION.
Remarks:	cleanup in progress

All Materials:

Site ID:	110892
Operable Unit ID:	846126
Operable Unit:	01
Material ID:	529346
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	20.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	WHITE PLAINS HONDA
Address:	31 WESTMORELAND AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0206674 / 2003-02-26
Facility ID:	0206674
Site ID:	110893
Spill Date:	2002-09-25
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	C3

SPILL NUMBER 0108090 (Continued) **S105230061**

Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	JBODEE
Referred To:	WESTCHESTER CNTY HEALTH DEPT
Reported to Dept:	2002-09-27
CID:	281
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2002-09-27
Spill Record Last Update:	2024-04-01
Spiller Name:	DAVID DIDONA
Spiller Company:	WHITE PLAINS HONDA
Spiller Address:	31 WESTMORELAND AVE
Spiller County:	001
Spiller Contact:	DONNA CAIXERIO
Spiller Phone:	(914) 946-4300
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	97050
Latitude:	41.0284486
Longitude:	-73.7757275
DEC Memo:	Not reported
Remarks:	VACUM TANK TEST FAILURE AT ABOVE LOCATION. PROPERTY OWNER HAS BEEN ADVISED OF TEST RESULTS.

All TTF:

Facility ID:	0206674
Spill Number:	0206674
Spill Tank Test:	1527509
Site ID:	110893
Tank Number:	1
Tank Size:	1500
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	F
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	110893
Operable Unit ID:	858419
Operable Unit:	01
Material ID:	517277
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported

SPILL NUMBER 0108090 (Continued) **S105230061**

Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	WHITE PLAINS HONDA
Address:	31 WESTMORELAND AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0010522 / 2001-07-10
Facility ID:	0010522
Site ID:	68432
Spill Date:	2000-12-19
Spill Cause:	Tank Overfill
Spill Source:	Commercial/Industrial
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	jbodee
Referred To:	Not reported
Reported to Dept:	2000-12-19
CID:	281
Water Affected:	Not reported
Spill Notifier:	Responsible Party
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2000-12-19
Spill Record Last Update:	2002-03-15
Spiller Name:	ED ALLAN
Spiller Company:	ROBINSON OIL
Spiller Address:	500 EXECUTIVE BLVD
Spiller County:	001
Spiller Contact:	ED ALAN
Spiller Phone:	(914) 345-5700
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	97050
Latitude:	41.0284486
Longitude:	-73.7757275
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was O'DEE 07/10/2001 NEE DISPOSED OF TANK AND 11 DRUMS OF CONTAMINATED SOIL. NO FURTHER ACTION.
Remarks:	TANK OVERFILL DURING DELILVERY AT ABOVE LOCATION. ALL MATERIAL REPORTED RECOVERED. NO CALL BACK REQUESTED.

All Materials:

Site ID:	68432
Operable Unit ID:	831663
Operable Unit:	01
Material ID:	571832
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported

SPILL NUMBER 0108090 (Continued) **S105230061**

Material FA:	Petroleum
Quantity:	5.00
Units:	G
Recovered:	5.00
Resource Affected:	Soil
Oxygenate:	Not reported

SPILLS:

Name:	CIVIC CENTER MOTORS
Address:	31 WESTMORELAND AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0500300 / 2005-04-07
Facility ID:	0500300
Facility Type:	ER
DER Facility ID:	97050
Site ID:	343238
DEC Region:	3
Spill Cause:	Unknown
Spill Class:	C3
SWIS:	6017
Spill Date:	2005-04-07
Investigator:	TDGHIOSA
Referred To:	Not reported
Reported to Dept:	2005-04-07
CID:	444
Water Affected:	Not reported
Spill Source:	Commercial Vehicle
Spill Notifier:	Responsible Party
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2005-04-07
Spill Record Last Update:	2012-01-11
Spiller Name:	TODD ROBINSON
Spiller Company:	NOCO TRUCK
Spiller Address:	625 SAWKILL ROAD
Spiller Company:	001
Contact Name:	TODD ROBINSON
Latitude:	41.0288317
Longitude:	-73.7754586
DEC Memo:	Not reported
Remarks:	IN PROCESS OF CLEANING UP: WHILE SUCKING UP WASTE OIL IT OVERFILLED HIS TANK: LEAKED ON TO ASPHALT:

All Materials:

Site ID:	343238
Operable Unit ID:	1101923
Operable Unit:	01
Material ID:	582157
Material Code:	0022
Material Name:	waste oil/used oil
Case No.:	Not reported
Material FA:	Petroleum

SPILL NUMBER 0108090 (Continued) **S105230061**

Quantity:	Not reported
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	WHITEPLAINS HONDA
Address:	31 WESTMORELAND AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9814172 / 1999-02-24
Facility ID:	9814172
Facility Type:	ER
DER Facility ID:	97050
Site ID:	174406
DEC Region:	3
Spill Cause:	Human Error
Spill Class:	C4
SWIS:	6017
Spill Date:	1999-02-24
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1999-02-24
CID:	281
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Responsible Party
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	1999-02-24
Spill Record Last Update:	1999-07-28
Spiller Name:	TODD ROBINSON
Spiller Company:	NOCO LUBRICANTS
Spiller Address:	625 SAWKILL RD
Spiller Company:	001
Contact Name:	TODD ROBINSON
Latitude:	41.0284486
Longitude:	-73.7757275
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY
Remarks:	DRIVER REMOVING WASTE OIL AT ABOVE LOCATION. TRUCK OVERFILLED AND MATERIAL SPILLED ONTO PROPERTY. CALLER ON SITE AND REQUESTING CALL BACK @ 914-948-3305 IN REFERENCE TO CLEANUP - ASAP. ALL CONTAINED; NO ENVIRONMENTAL IMPACT.

All Materials:

Site ID:	174406
Operable Unit ID:	1071606
Operable Unit:	01
Material ID:	310877
Material Code:	0022
Material Name:	waste oil/used oil
Case No.:	Not reported
Material FA:	Petroleum

SPILL NUMBER 0108090 (Continued) **S105230061**

Quantity: 20.00
Units: G
Recovered: .00
Resource Affected: Soil
Oxygenate: Not reported

AL386 **SPILL NUMBER 0108164** **NY LTANKS** **S105230064**
East **32 MITCHELL PL** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.274 mi.
1449 ft. **Site 3 of 3 in cluster AL**

Relative:
Higher

Actual:
218 ft.

LTANKS:
Name: SPILL NUMBER 0108164
Address: 32 MITCHELL PL
City,State,Zip: WHITE PLAINS, NY
Spill Number/Closed Date: 0108164 / 2002-07-22
Facility ID: 0108164
Site ID: 255456
Spill Date: 2001-11-12
Spill Cause: Tank Failure
Spill Source: Private Dwelling
Spill Class: C3
Cleanup Ceased: Not reported
SWIS: 6017
Investigator: jbodee
Referred To: Not reported
Reported to Dept: 2001-11-12
CID: 270
Water Affected: Not reported
Spill Notifier: Affected Persons
Last Inspection: Not reported
Recommended Penalty: False
Meets Standard: True
UST Involvement: False
Remediation Phase: 0
Date Entered In Computer: 2001-11-12
Spill Record Last Update: 2002-07-24
Spiller Name: MITCH
Spiller Company: M AND T DEVELOPEMENT
Spiller Address: 32 MITCHELL PL
Spiller County: 001
Spiller Contact: MITCH
Spiller Phone: (914) 472-5424
Spiller Extention: Not reported
DEC Region: 3
DER Facility ID: 209243
Latitude: 41.0310063
Longitude: -73.7647005
DEC Memo: Prior to Sept, 2004 data translation this spill Lead_DEC Field was O'DEE 07/22/02 - NORTHEAST DISPOSED OF TANK AND 15.67 TONS OF CONTAMINATED SOIL. NFA
Remarks: contaminated soil discovered from tank removal

All Materials:
Site ID: 255456
Operable Unit ID: 845393

SPILL NUMBER 0108164 (Continued) **S105230064**

Operable Unit:	01
Material ID:	529414
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	SPILL NUMBER 9611678
Address:	32 MITCHELL PL
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9611678 / 1996-12-24
Facility ID:	9611678
Site ID:	255457
Spill Date:	1996-12-24
Spill Cause:	Tank Overfill
Spill Source:	Commercial/Industrial
Spill Class:	B4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1996-12-24
CID:	312
Water Affected:	Not reported
Spill Notifier:	Responsible Party
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1996-12-24
Spill Record Last Update:	1997-01-14
Spiller Name:	Not reported
Spiller Company:	Not reported
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	MITCHELL SAUNDERS
Spiller Phone:	(914) 421-1742
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	209243
Latitude:	41.0310063
Longitude:	-73.7647005
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY 12/24/96 SPILL CONTAINED ON BLACKTOP WITH SPEEDI-DRI; CLEAN UP COMPLETE.
Remarks:	DRIVER OVERFILLED THE TANK - SUPPOSEDLY NO VENT ALARM

All Materials:

Site ID:	255457
Operable Unit ID:	1043016
Operable Unit:	01

SPILL NUMBER 0108164 (Continued) **S105230064**

Material ID: 340329
Material Code: 0001A
Material Name: #2 fuel oil
Case No.: Not reported
Material FA: Petroleum
Quantity: 18.00
Units: G
Recovered: .00
Resource Affected: Soil
Oxygenate: Not reported

Name: APT COMPLEX
Address: 32 MITCHELL PL
City,State,Zip: WHITE PLAINS, NY
Spill Number/Closed Date: 9611679 / 1997-11-10
Facility ID: 9611679
Site ID: 255458
Spill Date: 1996-12-24
Spill Cause: Tank Overfill
Spill Source: Institutional, Educational, Gov., Other
Spill Class: C3
Cleanup Ceased: Not reported
SWIS: 6000
Investigator: tdghiosa
Referred To: Not reported
Reported to Dept: 1996-12-24
CID: 323
Water Affected: Not reported
Spill Notifier: Fire Department
Last Inspection: Not reported
Recommended Penalty: False
Meets Standard: True
UST Involvement: False
Remediation Phase: 0
Date Entered In Computer: 1996-12-24
Spill Record Last Update: 1997-12-10
Spiller Name: Not reported
Spiller Company: OIL COMPANY
Spiller Address: Not reported
Spiller County: 999
Spiller Contact: BOB LYONS
Spiller Phone: (914) 422-6333
Spiller Extention: Not reported
DEC Region: 3
DER Facility ID: 276053
Latitude: 41.0310063
Longitude: -73.7647005
DEC Memo: Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY
Remarks: FD ON SCENE CLEANING UP SPILL.

All Materials:
Site ID: 255458
Operable Unit ID: 1043017
Operable Unit: 01
Material ID: 569601
Material Code: 0001A

SPILL NUMBER 0108164 (Continued) **S105230064**

Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	15.00
Units:	G
Recovered:	15.00
Resource Affected:	Soil
Oxygenate:	Not reported

AK387 **COMMERCIAL PROERTY** **NY LTANKS** **S107789254**
ESE **151 EAST POST ROAD** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.277 mi.
1461 ft. **Site 6 of 7 in cluster AK**

Relative: **Higher**

Actual: **227 ft.**

LTANKS:

Name:	COMMERCIAL PROERTY
Address:	151 EAST POST ROAD
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0601015 / 2006-11-03
Facility ID:	0601015
Site ID:	363155
Spill Date:	2006-04-26
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	JBODee
Referred To:	WCDOH
Reported to Dept:	2006-04-26
CID:	409
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2006-04-26
Spill Record Last Update:	2006-11-03
Spiller Name:	TONY GASHA
Spiller Company:	COMMERCIAL PROERTY
Spiller Address:	151 EAST POST ROAD
Spiller County:	001
Spiller Contact:	TONY GASHA
Spiller Phone:	(914) 946-2357
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	313347
Latitude:	41.0290400
Longitude:	-73.7653520
DEC Memo:	5/3/06: Refer to WC PBS August 16, 2006 Tony Gashi 151 East Post Road Corp 47 Mamaroneck Ave, Suite 111 White Plains, Ny 10601 Re: PBS #3-030910 151 East Post Road, White Plains, NY NYSDEC Spill # 06-01015 TTF Dear Facility; The Westchester County Department of Health has received the retest results from July 28, 2006. The

COMMERCIAL PROERTY (Continued) **S107789254**

results are acceptable to the Department. A request for closure is being sent to NYSDEC for the above spill # and no further action is required regarding the work at this time. If you have any questions, please call me at (914) 813-5971. Sincerely, Danielle Jackson Sanitarian Office of Environmental Health Risk Control

Remarks: NO REMARKS.

All TTF:

Facility ID:	0601015
Spill Number:	0601015
Spill Tank Test:	1549917
Site ID:	363155
Tank Number:	1
Tank Size:	1500
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Watchdog
Last Modified Date:	Not reported

All Materials:

Site ID:	363155
Operable Unit ID:	1121214
Operable Unit:	01
Material ID:	2110709
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

AR388 **LEGACY MANAGEMENT** **NY LTANKS** **S128914049**
SW **39 WESTMORELAND AVE** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.277 mi.
1462 ft. **Site 4 of 6 in cluster AR**

Relative:
Higher

Actual:
209 ft.

LTANKS:

Name:	LEGACY MANAGEMENT
Address:	39 WESTMORELAND AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9411636 / 1994-11-30
Facility ID:	9411636
Site ID:	109654
Spill Date:	1994-11-30
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial

LEGACY MANAGEMENT (Continued) **S128914049**

Spill Class:	C3
Cleanup Ceased:	1994-11-30
SWIS:	6017
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1994-11-30
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1994-12-13
Spill Record Last Update:	2022-07-08
Spiller Name:	Not reported
Spiller Company:	SAME
Spiller Address:	Not reported
Spiller County:	999
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	183270
Latitude:	41.0283158
Longitude:	-73.7759441
DEC Memo:	09/27/95: This is additional information about material spilled from the translation of the old spill file: TANK TEST.
Remarks:	WILL E.I.R.

All TTF:

Facility ID:	9411636
Spill Number:	9411636
Spill Tank Test:	1543406
Site ID:	109654
Tank Number:	Not reported
Tank Size:	0
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	109654
Operable Unit ID:	1009508
Operable Unit:	01
Material ID:	373977
Material Code:	0001A
Material Name:	#2 fuel oil

LEGACY MANAGEMENT (Continued) **S128914049**

Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported
Resource Affected:	Soil
Oxygenate:	Not reported

AR389 **COMMERCIAL PROPERTY** **NY LTANKS** **S109374727**
SW **39 WESTMORELAND AVE** **NY Spills** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.277 mi.
1462 ft. **Site 5 of 6 in cluster AR**

Relative:
Higher

Actual:
209 ft.

LTANKS:

Name:	BENEROFE ASSOCIATION
Address:	39 WESTMORELAND AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0807224 / 2009-01-07
Facility ID:	0807224
Site ID:	404560
Spill Date:	2008-09-26
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	jbodee
Referred To:	WCDOH PBS 3-169102
Reported to Dept:	2008-09-26
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2008-09-26
Spill Record Last Update:	2009-01-07
Spiller Name:	KAREN GOMEZ
Spiller Company:	BENEROFE GROUP
Spiller Address:	4 NEW KING ST
Spiller County:	999
Spiller Contact:	BOB URVAN
Spiller Phone:	(631) 321-4670
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	183270
Latitude:	41.0283317
Longitude:	-73.7762386
DEC Memo:	9-26-09 Spoke with Bob Urvan. They will isolate the tank by entering manway and plugging lines and then retest. They will contact WCHD with results. Faxed spill report to WCHD. jm Passing retest and repair explanation received by WCDOH on 10/31/08 jod
Remarks:	TANK TEST FAILURE ON A 10,000 GALLON TANK, DRY PORTION LEAK. NO PRODUCT WAS SPILLED.

COMMERCIAL PROPERTY (Continued) **S109374727**

All Materials:

Site ID:	404560
Operable Unit ID:	1161209
Operable Unit:	01
Material ID:	2152403
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Not reported
Oxygenate:	Not reported

Name:	COMMERCIAL PROPERTY
Address:	39 WESTMORELAND AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9411173 / 1995-09-22
Facility ID:	9411173
Site ID:	221603
Spill Date:	1994-11-21
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	C3
Cleanup Ceased:	1995-09-22
SWIS:	6017
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1994-11-21
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1995-09-20
Spill Record Last Update:	1995-09-22
Spiller Name:	Not reported
Spiller Company:	Not reported
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	183270
Latitude:	41.0283158
Longitude:	-73.7759441
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY
Remarks:	TTF UNUSUAL CASE TANK LOCATED UNDER LOADING DOCK US TEST -.105

All TTF:

COMMERCIAL PROPERTY (Continued) **S109374727**

Facility ID:	9411173
Spill Number:	9411173
Spill Tank Test:	1543373
Site ID:	221603
Tank Number:	Not reported
Tank Size:	0
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	221603
Operable Unit ID:	1005007
Operable Unit:	01
Material ID:	377037
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	Not reported
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

SPILLS:

Name:	COMMERCIAL BLDG
Address:	39 WESTMORELAND AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0111615 / 2002-03-11
Facility ID:	0111615
Facility Type:	ER
DER Facility ID:	183270
Site ID:	283261
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	C4
SWIS:	6017
Spill Date:	2002-03-08
Investigator:	mbmastro
Referred To:	Not reported
Reported to Dept:	2002-03-08
CID:	252
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Responsible Party
Cleanup Ceased:	Not reported

COMMERCIAL PROPERTY (Continued) **S109374727**

Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2002-03-08
Spill Record Last Update:	2002-03-26
Spiller Name:	CALLER
Spiller Company:	CASTLE OIL
Spiller Address:	290 LOCUST AVE
Spiller Company:	001
Contact Name:	BENEROSS REALTY
Latitude:	41.0283158
Longitude:	-73.7759441
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was MASTRO 03/11/2002 OIL CONTAINED TO PAVEMENT. NO SOILS IMPACTED. CLEANUP COMPLETED W/PADS & SPEEDI DRY. NO FURTHER ACTION.
Remarks:	VENT ALARM WAS NOT WORKING PROPERLY-DRIVER NOT HEARING IT ACCIDENTALLY OVERFILLED TANK-CASTLE OIL HAS DISPATCHED A CLEANUP CREW. Not reported

All Materials:

Site ID:	283261
Operable Unit ID:	850255
Operable Unit:	01
Material ID:	525636
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	10.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

AQ390 **REAL ESTATE - TTF** **NY LTANKS** **S118263506**
SE **6 CHESTER AVE** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.281 mi.
1482 ft. **Site 4 of 5 in cluster AQ**

Relative:
Higher

Actual:
243 ft.

LTANKS:

Name:	REAL ESTATE - TTF
Address:	6 CHESTER AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	1506711 / 2019-02-08
Facility ID:	1506711
Site ID:	514142
Spill Date:	2015-09-24
Spill Cause:	Tank Test Failure
Spill Source:	Private Dwelling
Spill Class:	D3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	JBODEE

REAL ESTATE - TTF (Continued) **S118263506**

Referred To:	Not reported
Reported to Dept:	2015-09-24
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2015-09-24
Spill Record Last Update:	2019-02-08
Spiller Name:	Unknown
Spiller Company:	Unnamed Owner/Seller
Spiller Address:	6 CHESTER AVE
Spiller County:	999
Spiller Contact:	ANTHONY TIRONE
Spiller Phone:	914-686-7007
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	468617
Latitude:	Not reported
Longitude:	Not reported
DEC Memo:	9/24/15 Spoke to Kathy Morgan at TT. Mr. Tirone is the buyer. Owner is unknown. dw 2/06/19: I spoke with Kathy Morgan at US Tank Tech, she pulled the file on this TTF. She states there is a note on the file indicating #6 and #8 Chester Ave were together on one parcel. She states #8 had an out of service 1K gallon underground fuel tank at the time they tested #6. She believes #6 was still in service at the time they tested it for a prospective buyer. Tank failed with hissing, may have been an ullage failure. US Tank Tech did not test #8 tank. They only other info provided is that this property was a Robison customer at the time of the test and Robison was notified of the failure. US Tank Tech forwarded a site diagram showing the location of the UST at #6. There was a direct fill in the center of the front yard and a remote curb fill that was capped. Diagram will be entered into DecDocs. jod I then spoke to Tony Magnotta of the White Plains Bldg Dept. He is checking his files and will forward any information on permits that may have been filed for UST removals at this property. jod 2/06/19: White Plains Bldg Dept issued a permit for removal of USTs at this property in October of 2018. Certificate of completion was issued by the Bldg Dept on Dec 20, 2018. Work was performed by Madison Environmental. Permit and Certificate scanned into DecDocs. jod 2/07/19: I sent a message to Joe Tomasulo of Madison Environmental. He states they removed both tanks. He will forward soil sample results. He states he was never informed about the tightness test failure or the open spill number. Sample results from Madison indicate some SVOC contamination below CP-51 Guidance values. Samples will be entered into DecDocs. I left a message with Joe Tomasulo stating I will need more information on the removal of these USTs. jod 2/08/19: I spoke to Joe at Madison. He has forwarded the sample results for the UST removal at 8 Chester as well. He states neither tank was leaking. The two buidings are currently part of a construction project and are being demo'ed. Joe states White Plains Buildning Dept was onsite to inspect the removals. I also spoke with Tony Magnotta at the Bldg Dept again. He confirms the USTs and the excavations were inspected by his Dept, no evidence of any

REAL ESTATE - TTF (Continued) **S118263506**

leak or release was noted. Photos and additional sample results in DecDocs. Based upon the information received, no further action is required at this time. jod

Remarks: 1000 gallon underground tank

All TTF:

Facility ID:	1506711
Spill Number:	1506711
Spill Tank Test:	2506521
Site ID:	514142
Tank Number:	UST
Tank Size:	1000
Material:	0001
EPA UST:	False
UST:	True
Cause:	99
Source:	00
Test Method:	34
Test Method 2:	EZY 3 Locator Plus
Leak Rate:	Not reported
Gross Fail:	Not reported
Modified By:	JBODEE
Last Modified Date:	Not reported

All Materials:

Site ID:	514142
Operable Unit ID:	1263349
Operable Unit:	01
Material ID:	2267039
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported
Resource Affected:	Not reported
Oxygenate:	Not reported

AP391 **BARGAM HOME** **NY LTANKS** **S106972377**
East **36-38 MITCHELL PLACE** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.284 mi.
1497 ft. **Site 3 of 5 in cluster AP**

Relative:
Higher

Actual:
218 ft.

LTANKS:

Name:	BARGAM HOME
Address:	36-38 MITCHELL PLACE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0505320 / 2005-12-18
Facility ID:	0505320
Site ID:	350305
Spill Date:	2005-08-01
Spill Cause:	Tank Failure
Spill Source:	Private Dwelling
Spill Class:	C4
Cleanup Ceased:	Not reported

BARGAM HOME (Continued) **S106972377**

SWIS:	6017
Investigator:	JBODee
Referred To:	Not reported
Reported to Dept:	2005-08-01
CID:	444
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2005-08-01
Spill Record Last Update:	2005-12-18
Spiller Name:	GILL BARGAM
Spiller Company:	BARGAM HOME
Spiller Address:	36-38 MITCHELL PLACE
Spiller County:	001
Spiller Contact:	GILL BARGAM
Spiller Phone:	(914) 310-1500
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	296750
Latitude:	41.0310480
Longitude:	-73.7645430
DEC Memo:	Have ok to finish job. December 18, 2005: ELITE ENVIRONMENTAL DISPOSED OF LUST AND 19.56 TONS OF CONTAMINATED SOIL. BASED UPON INFORMATION PROVIDED TO DEC, NO FURTHER ACTION IS REQUIRED AT THIS TIME. jod
Remarks:	HOLES IN 1000 GALLON TANK, AND SOME CONTAMINATION IN SOIL;

All Materials:

Site ID:	350305
Operable Unit ID:	1107882
Operable Unit:	01
Material ID:	2097770
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	G
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

AT392 **PBS** **NY LTANKS** **S102155221**
SSW **82 BANK STREET** **NY Spills** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.285 mi.
1504 ft. **Site 1 of 2 in cluster AT**

Relative:
Higher

Actual:
220 ft.

LTANKS:

Name:	PBS
Address:	82 BANK STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0312286 / 2005-03-27

PBS (Continued) **S102155221**

Facility ID:	0312286
Site ID:	301757
Spill Date:	2004-02-04
Spill Cause:	Tank Test Failure
Spill Source:	Private Dwelling
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	WCHD
Referred To:	WESTCHESTER CNTY HEALTH D
Reported to Dept:	2004-02-04
CID:	405
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2004-02-04
Spill Record Last Update:	2005-03-27
Spiller Name:	Not reported
Spiller Company:	Not reported
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	KATHY
Spiller Phone:	(914) 946-1320
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	197977
Latitude:	41.0274872
Longitude:	-73.7742585
DEC Memo:	03/27/05 PBS SITE. TANK PASSED RETEST. SPILL FILE CLOSED BY DANIELLE JACKSON OF THE WESTCHESTER COUNTY HEALTH DEPT. NO FURTHER ACTION IS REQUIRED AT THIS TIME. jod
Remarks:	Re-test or remove

All TTF:

Facility ID:	0312286
Spill Number:	0312286
Spill Tank Test:	1528959
Site ID:	301757
Tank Number:	1
Tank Size:	4000
Material:	Not reported
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

PBS (Continued) **S102155221**

SPILLS:

Name:	APT. HOUSE
Address:	82 BANK STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9410155 / 1994-11-01
Facility ID:	9410155
Facility Type:	ER
DER Facility ID:	197977
Site ID:	240746
DEC Region:	3
Spill Cause:	Human Error
Spill Class:	D4
SWIS:	6017
Spill Date:	1994-10-28
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1994-10-31
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Institutional, Educational, Gov., Other
Spill Notifier:	Responsible Party
Cleanup Ceased:	1994-11-01
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2003-12-02
Spill Record Last Update:	2003-12-02
Spiller Name:	Not reported
Spiller Company:	TARRICONE FUELS
Spiller Address:	Not reported
Spiller Company:	001
Contact Name:	Not reported
Latitude:	41.0274872
Longitude:	-73.7742585
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY
Remarks:	MISREAD TANK CLEANED UP BY FUEL CO SIDEWALK AFFECTED

All Materials:

Site ID:	240746
Operable Unit ID:	1007900
Operable Unit:	01
Material ID:	376026
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	5.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

AU393 **HALPERN ENTERPRISES** **NY LTANKS** **S100140406**
ESE **170 EAST POST ROAD** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.286 mi.
1511 ft. **Site 1 of 2 in cluster AU**

Relative:
Higher

Actual:
221 ft.

LTANKS:

Name:	HALPERN ENTERPRISES
Address:	170 EAST POST ROAD
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8804996 / 2005-04-30
Facility ID:	8804996
Site ID:	154885
Spill Date:	1988-09-08
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	D4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	WXWADSWO
Referred To:	Not reported
Reported to Dept:	1988-09-08
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1988-09-16
Spill Record Last Update:	2005-04-30
Spiller Name:	Not reported
Spiller Company:	UNKNOWN
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	131293
Latitude:	41.0295566
Longitude:	-73.7647514
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was WADSWORTH 04/30/05 ADMINISTRATIVELY CLOSED AS PER DIRECTIVE FROM CENTRAL OFFIICE.
Remarks:	3,000 GAL. TANK; -.10 GPH; TO EXCAVATE, ISOLATE & RETEST. TANK TO BE RETESTED THE WEEK OF 9/12. LEAK COULD BE FROM FILL PIPE WHICH IS BENTSPOKE TO GARY GIGLIO. WILL CALL IF TANK IS TO BE REMOVED.

All TTF:

Facility ID:	8804996
Spill Number:	8804996
Spill Tank Test:	1534581
Site ID:	154885
Tank Number:	Not reported
Tank Size:	0
Material:	0001
EPA UST:	Not reported
UST:	Not reported

HALPERN ENTERPRISES (Continued) **S100140406**

Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	154885
Operable Unit ID:	922162
Operable Unit:	01
Material ID:	456917
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	Not reported
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

AK394 **OFFICE BLDG** **NY LTANKS** **S103558663**
ESE **171 EAST POST RD** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.286 mi.
1512 ft. **Site 7 of 7 in cluster AK**

Relative: **Higher**

Actual: **223 ft.**

LTANKS:

Name:	OFFICE BLDG
Address:	171 EAST POST RD
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9811157 / 2004-03-30
Facility ID:	9811157
Site ID:	293961
Spill Date:	1998-12-04
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	D3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	WCHD
Referred To:	Westchester Cnty Health Dept
Reported to Dept:	1998-12-04
CID:	252
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1998-12-04
Spill Record Last Update:	2004-03-30

OFFICE BLDG (Continued) **S103558663**

Spiller Name:	BILL CHRISTOPHER
Spiller Company:	OFFICE BLDG
Spiller Address:	171 EAST POST RD
Spiller County:	001
Spiller Contact:	BILL CHRISTOPHER
Spiller Phone:	(203) 972-0231
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	237886
Latitude:	41.0294655
Longitude:	-73.7646580
DEC Memo:	Not reported
Remarks:	TANK TO BE ISOLATED AND RE-TESTED

All TTF:

Facility ID:	9811157
Spill Number:	9811157
Spill Tank Test:	1546601
Site ID:	293961
Tank Number:	1
Tank Size:	2000
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	293961
Operable Unit ID:	1068550
Operable Unit:	01
Material ID:	315008
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

AQ395 **RESIDENTS** **NY LTANKS** **S102447976**
SE **8 CHESTER AVE** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.288 mi.
1522 ft. **Site 5 of 5 in cluster AQ**

Relative:
Higher

Actual:
244 ft.

LTANKS:

Name:	RESIDENTS
Address:	8 CHESTER AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9610881 / 2012-04-16
Facility ID:	9610881
Site ID:	71801
Spill Date:	1996-12-03
Spill Cause:	Tank Test Failure
Spill Source:	Private Dwelling
Spill Class:	B4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	UNASSIGNED
Referred To:	Not reported
Reported to Dept:	1996-12-03
CID:	282
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1996-12-03
Spill Record Last Update:	2012-04-16
Spiller Name:	SAME
Spiller Company:	SAME
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	KREISBERG RESIDENTS
Spiller Phone:	(914) 428-3000
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	67898
Latitude:	41.0278739
Longitude:	-73.7666028
DEC Memo:	8/3/10 Homeowner TTF JO'M 4/16/12 This spill has been closed administratively based on the following: 1) The spill is at least 10 years old 2) It is a Homeowner (non regulated tank) Tank Test Failure 3) There is no indication of an Environmental impact This Closure does not remove the possibility of DEC requiring further work in the future. NFA JO'M
Remarks:	THE TAN TESTER THINKS THAT THE LINES ARE BAD OR THE VENT LINES OIL COMPANY ROBISON IS DOING THE FOLLOW UP JIM ROOD IS THE EMPLOYEE FOR ROBISON 914-345-5700

All TTF:

Facility ID:	9610881
Spill Number:	9610881
Spill Tank Test:	1544908
Site ID:	71801
Tank Number:	1
Tank Size:	1000

RESIDENTS (Continued) **S102447976**

Material:	Not reported
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

AP396 **APARTMENT BLDG** **NY LTANKS** **S105997251**
East **37-43 MITCHELL PL** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.289 mi.
1526 ft. **Site 4 of 5 in cluster AP**

Relative: **Higher**

Actual: **218 ft.**

LTANKS:

Name:	APARTMENT BLDG
Address:	37-43 MITCHELL PL
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0208214 / 2003-04-07
Facility ID:	0208214
Site ID:	248365
Spill Date:	2002-11-07
Spill Cause:	Tank Failure
Spill Source:	Private Dwelling
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	jbodee
Referred To:	Not reported
Reported to Dept:	2002-11-07
CID:	390
Water Affected:	Not reported
Spill Notifier:	Local Agency
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2002-11-07
Spill Record Last Update:	2003-09-08
Spiller Name:	PHIL GUSSACK
Spiller Company:	APARTMENT BLDG
Spiller Address:	37-43 MITCHELL PL
Spiller County:	001
Spiller Contact:	PHIL GUSSACK
Spiller Phone:	(914) 497-5310
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	203790
Latitude:	41.0309676
Longitude:	-73.7644514
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was O'DEE 04/15/03: Letter to Philip Gussack from Marc Grazioli, WCHD,

APARTMENT BLDG (Continued) **S105997251**

dated 4/7/2003. Site closure report has been reviewed. Soil sample results satisfactory. WCHD recommend NFA at this time.

Remarks: caller reporting 1000 gal storage tank failed - there is soil contamination - unk amount spilled yet - soil is being stockpiled

All Materials:

Site ID:	248365
Operable Unit ID:	859738
Operable Unit:	01
Material ID:	515218
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

AR397 **IRVINGTON** **NY LTANKS** **S100139823**
SW **IRVINGTON** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.290 mi.
1532 ft. **Site 6 of 6 in cluster AR**

Relative: **Higher**

Actual: **208 ft.**

LTANKS:

Name:	IRVINGTON
Address:	IRVINGTON
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8708811 / 1988-03-03
Facility ID:	8708811
Site ID:	309074
Spill Date:	1988-01-15
Spill Cause:	Tank Test Failure
Spill Source:	Gasoline Station or other PBS Facility
Spill Class:	D3
Cleanup Ceased:	1988-03-03
SWIS:	6017
Investigator:	jeokesso
Referred To:	Not reported
Reported to Dept:	1988-01-15
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	True
Remediation Phase:	0
Date Entered In Computer:	1988-01-28
Spill Record Last Update:	1988-09-01
Spiller Name:	Not reported
Spiller Company:	Not reported
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	Not reported

IRVINGTON (Continued) **S100139823**

Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	249617
Latitude:	Not reported
Longitude:	Not reported
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was OKESSON / / : MAY HAVE ALSO BEEN REPORTED AS SPILL # 879230, WHICH HAS NOT LOGED ONTO SYSTEM. NOTE 879230 SHOWES DIFFERENT ADDRESS. V.MC.2-10-88. 03/03/88: TANK PASSED RETEST. N.F.A. L.R.
Remarks:	DON REGISTERED TANK WOULD HAVE TO CALL DPW FOR FURTHER INFO. 1-15 DPW NO ANSWER 1-16 DPW TANK TEST LEFT MESSAGE. 1-19 NO ANSWER

All TTF:

Facility ID:	8708811
Spill Number:	8708811
Spill Tank Test:	1533010
Site ID:	309074
Tank Number:	Not reported
Tank Size:	0
Material:	0009
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	309074
Operable Unit ID:	913482
Operable Unit:	01
Material ID:	464176
Material Code:	0009
Material Name:	gasoline
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

398
NNE
1/4-1/2
0.292 mi.
1542 ft.

VILLANOVA - TTF
144 CHURCH ST
WHITE PLAINS, NY

NY LTANKS

S118707784
N/A

Relative:
Higher

Actual:
220 ft.

LTANKS:

Name:	VILLANOVA - TTF
Address:	144 CHURCH ST
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	1603426 / 2016-09-06
Facility ID:	1603426
Site ID:	529884
Spill Date:	2016-07-06
Spill Cause:	Tank Test Failure
Spill Source:	Private Dwelling
Spill Class:	B3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	JBODEE
Referred To:	Not reported
Reported to Dept:	2016-07-08
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2016-07-08
Spill Record Last Update:	2016-09-07
Spiller Name:	BRIDGETT VILLANOVA
Spiller Company:	Bridgette Villanova
Spiller Address:	144 CHURCH ST
Spiller County:	999
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	483978
Latitude:	Not reported
Longitude:	Not reported
DEC Memo:	7-8-16 Spoke with Bridget. They plan to remove tank. She says C2G will be doing the work. Informed her to make sure documentation is submitted to close spill. jc 9/6/16: C2G Environmental disposed of the leaking UST and a total of 45.96 tons of petroleum contaminated soil. Soil sample results were submitted for review. Documents entered into DecDocs. Based upon the information provided, no further action is required at this time. jod
Remarks:	repair/retest pending

All Materials:

Site ID:	529884
Operable Unit ID:	1278702
Operable Unit:	01
Material ID:	2283624
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported

VILLANOVA - TTF (Continued) **S118707784**

Material FA:	Petroleum
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported
Resource Affected:	Not reported
Oxygenate:	Not reported

AP399 **APARTMENT BUILDING** **NY LTANKS** **S105999478**
East **40 MITCHELL PL** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.293 mi.
1545 ft. **Site 5 of 5 in cluster AP**

Relative: **Higher**
Actual: **218 ft.**

LTANKS:

Name:	APARTMENT BUILDING
Address:	40 MITCHELL PL
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0304394 / 2003-10-31
Facility ID:	0304394
Site ID:	151265
Spill Date:	2003-07-25
Spill Cause:	Tank Failure
Spill Source:	Private Dwelling
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	WCHD
Referred To:	Westchester Cnty Health Dept
Reported to Dept:	2003-07-25
CID:	390
Water Affected:	Not reported
Spill Notifier:	Local Agency
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2003-07-25
Spill Record Last Update:	2003-12-12
Spiller Name:	NORMAN TUNNELL
Spiller Company:	APARTMENT BUILDING
Spiller Address:	40 MITCHELL PL
Spiller County:	001
Spiller Contact:	NORMAN TUNNELL
Spiller Phone:	(914) 328-7511
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	128562
Latitude:	41.0311111
Longitude:	-73.7643893
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was WCHD-GOREAU 11/4/03: Letter to Toni Palancia, Yurik Enterprises from Stefan Goreau, WCDOH dated 10/31/2003. Site closure report has been reviewed. WCDOH recommends NFA at this time.
Remarks:	leaking underground storage tank caused spill - tank is still in ground - more will be done next week -- tank has been abandoned and covered

APARTMENT BUILDING (Continued) **S105999478**

All Materials:

Site ID:	151265
Operable Unit ID:	871197
Operable Unit:	01
Material ID:	505252
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

AN400 **AT & T TELEPHONE CO** **NY LTANKS** **S102233627**
NE **400 HAMILTON AVENUE** **NY Spills** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.293 mi.
1546 ft. **Site 5 of 5 in cluster AN**

Relative:
Higher

Actual:
234 ft.

LTANKS:

Name:	AT & T TELEPHONE CO
Address:	400 HAMILTON AVENUE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9604857 / 1996-07-22
Facility ID:	9604857
Site ID:	72317
Spill Date:	1996-07-15
Spill Cause:	Tank Failure
Spill Source:	Commercial/Industrial
Spill Class:	B3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1996-07-15
CID:	297
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1996-07-15
Spill Record Last Update:	1996-09-05
Spiller Name:	UNKNOWN
Spiller Company:	AT&T TELEPHONE COMPANY
Spiller Address:	400 HAMILTON AV
Spiller County:	001
Spiller Contact:	RICHARD EGAN
Spiller Phone:	(201) 933-5541
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	60149

AT & T TELEPHONE CO (Continued) **S102233627**

Latitude:	41.0349435
Longitude:	-73.7656143
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY 07/22/96 STEVE PONZA FROM TRC ENVIRONMENTAL REPORTED THE SPILL RESULTED FROM AN OLD LINE THAT WAS BROKEN DURING THE TANK REMOVAL SPILL HAS BEEN CLEANED UP
Remarks:	CALLER COMPLETED A TANK REMOVAL ON FRIDAY 7/12/96 AND THEY FOUND NO CONTAMINATION - TODAY THEY RETURNED TO THE WORK SITE A FOUND WHAT LOOKS LIKE WASTE OIL COMING FROM AN UNKNOWN SOURCE

All Materials:

Site ID:	72317
Operable Unit ID:	1035809
Operable Unit:	01
Material ID:	347610
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

SPILLS:

Name:	VAULT#6174
Address:	400 HAMILTON AVENUE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0507082 / 2005-09-12
Facility ID:	0507082
Facility Type:	ER
DER Facility ID:	60149
Site ID:	352409
DEC Region:	3
Spill Cause:	Unknown
Spill Class:	C4
SWIS:	6017
Spill Date:	2005-09-12
Investigator:	TDGHIOSA
Referred To:	Not reported
Reported to Dept:	2005-09-12
CID:	444
Water Affected:	Not reported
Spill Source:	Institutional, Educational, Gov., Other
Spill Notifier:	Responsible Party
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2005-09-12
Spill Record Last Update:	2005-09-21
Spiller Name:	ERT DESK'
Spiller Company:	VAULT#6174

AT & T TELEPHONE CO (Continued) **S102233627**

Spiller Address:	400 HAMILTON AVE
Spiller Company:	001
Contact Name:	ERT DESK'
Latitude:	41.0349370
Longitude:	-73.7656060
DEC Memo:	Cable leak. To fix leak equipment has to be replace in an confine space. Leak is contained ConEd arranging equipment and personell to fix the leak.
Remarks:	FOUND 1 OUNCE ON TOP OF A TRANSFORMER FROM A LEAKY DEFAULT: NO TO 5 QUESTIONS: CONED # 160995

All Materials:

Site ID:	352409
Operable Unit ID:	1109910
Operable Unit:	01
Material ID:	2099927
Material Code:	0541A
Material Name:	dielectric fluid
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	AT&T CORPORATION
Address:	400 HAMILTON AVENUE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9610406 / 1996-11-19
Facility ID:	9610406
Facility Type:	ER
DER Facility ID:	60149
Site ID:	61995
DEC Region:	3
Spill Cause:	Housekeeping
Spill Class:	C4
SWIS:	6017
Spill Date:	1996-11-19
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1996-11-19
CID:	266
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Other
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	1996-11-19
Spill Record Last Update:	1996-12-16
Spiller Name:	FRAN MAJEAU
Spiller Company:	AT&T CORPORATION
Spiller Address:	400 HAMILTON AVENUE

AT & T TELEPHONE CO (Continued) **S102233627**

Spiller Company: 001
Contact Name: FRAN MAJEAU
Latitude: 41.0349435
Longitude: -73.7656143
DEC Memo: Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY
Remarks: CONTAMINATED SOIL FOUND DURING TANK REMOVAL. FOUR OTHER TANKS TO BE REMOVED STILL. CROSS REFERENCE TO SPILL NUMBER 9604857 FROM PHASE 1 OF PROJECT.

All Materials:
Site ID: 61995
Operable Unit ID: 1038303
Operable Unit: 01
Material ID: 342618
Material Code: 0001A
Material Name: #2 fuel oil
Case No.: Not reported
Material FA: Petroleum
Quantity: .00
Units: G
Recovered: .00
Resource Affected: Soil
Oxygenate: Not reported

Name: VAULT 6174
Address: 400 HAMILTON AVENUE
City,State,Zip: WHITE PLAINS, NY
Spill Number/Closed Date: 0010086 / 2000-12-07
Facility ID: 0010086
Facility Type: ER
DER Facility ID: 60149
Site ID: 188187
DEC Region: 3
Spill Cause: Equipment Failure
Spill Class: C4
SWIS: 6017
Spill Date: 2000-12-07
Investigator: DVWEHRFR
Referred To: Not reported
Reported to Dept: 2000-12-07
CID: 312
Water Affected: Not reported
Spill Source: Commercial/Industrial
Spill Notifier: Responsible Party
Cleanup Ceased: Not reported
Cleanup Meets Std: True
Last Inspection: Not reported
Recommended Penalty: False
UST Trust: False
Remediation Phase: 0
Date Entered In Computer: 2000-12-07
Spill Record Last Update: 2000-12-21
Spiller Name: Not reported
Spiller Company: CON EDISON
Spiller Address: 4 IRVING PLACE
Spiller Company: 001

AT & T TELEPHONE CO (Continued) **S102233627**

Contact Name: Not reported
Latitude: 41.0349435
Longitude: -73.7656143
DEC Memo: Prior to Sept, 2004 data translation this spill Lead_DEC Field was WEHRFRITZ
Remarks: 10 OUNCES SPILLED FROM LEAKING JOINT - CASE #134659

All Materials:
Site ID: 188187
Operable Unit ID: 831061
Operable Unit: 01
Material ID: 544008
Material Code: 0541A
Material Name: dielectric fluid
Case No.: Not reported
Material FA: Petroleum
Quantity: 1.00
Units: G
Recovered: .00
Resource Affected: Soil
Oxygenate: Not reported

Name: VAULT 9058
Address: 400 HAMILTON AVENUE
City,State,Zip: WHITE PLAINS, NY
Spill Number/Closed Date: 0010088 / 2000-12-07
Facility ID: 0010088
Facility Type: ER
DER Facility ID: 60149
Site ID: 188188
DEC Region: 3
Spill Cause: Equipment Failure
Spill Class: C4
SWIS: 6017
Spill Date: 2000-12-07
Investigator: DVWEHRFR
Referred To: Not reported
Reported to Dept: 2000-12-07
CID: 312
Water Affected: Not reported
Spill Source: Commercial/Industrial
Spill Notifier: Responsible Party
Cleanup Ceased: Not reported
Cleanup Meets Std: True
Last Inspection: Not reported
Recommended Penalty: False
UST Trust: False
Remediation Phase: 0
Date Entered In Computer: 2000-12-07
Spill Record Last Update: 2000-12-21
Spiller Name: Not reported
Spiller Company: CON EDISON
Spiller Address: 4 IRVING PLACE
Spiller Company: 001
Contact Name: Not reported
Latitude: 41.0349435
Longitude: -73.7656143

AT & T TELEPHONE CO (Continued) **S102233627**

DEC Memo: Prior to Sept, 2004 data translation this spill Lead_DEC Field was WEHRFRITZ
Remarks: 12 OUNCES FROM LEAKING JOINT - CASE #134660

All Materials:
Site ID: 188188
Operable Unit ID: 832202
Operable Unit: 01
Material ID: 544010
Material Code: 0541A
Material Name: dielectric fluid
Case No.: Not reported
Material FA: Petroleum
Quantity: 1.00
Units: G
Recovered: .00
Resource Affected: Soil
Oxygenate: Not reported

Name: SPILL NUMBER 9606368
Address: 400 HAMILTON AVENUE
City,State,Zip: WHITE PLAINS, NY
Spill Number/Closed Date: 9606368 / 1996-08-17
Facility ID: 9606368
Facility Type: ER
DER Facility ID: 60149
Site ID: 188189
DEC Region: 3
Spill Cause: Unknown
Spill Class: C4
SWIS: 6017
Spill Date: 1996-08-17
Investigator: tdghiosa
Referred To: Not reported
Reported to Dept: 1996-08-17
CID: 257
Water Affected: Not reported
Spill Source: Commercial Vehicle
Spill Notifier: Fire Department
Cleanup Ceased: Not reported
Cleanup Meets Std: True
Last Inspection: Not reported
Recommended Penalty: False
UST Trust: False
Remediation Phase: 0
Date Entered In Computer: 1996-08-17
Spill Record Last Update: 1996-10-02
Spiller Name: Not reported
Spiller Company: UNKNOWN
Spiller Address: Not reported
Spiller Company: 999
Contact Name: MR FEDORCZAK
Latitude: 41.0349435
Longitude: -73.7656143
DEC Memo: Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY 08/17/96 LESS THAN REPORTABLE

AT & T TELEPHONE CO (Continued) **S102233627**

Remarks: fire dept still on scene caller has no further info at this time

All Materials:

Site ID:	188189
Operable Unit ID:	1034164
Operable Unit:	01
Material ID:	345628
Material Code:	0066A
Material Name:	unknown petroleum
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	3.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	400 HAMILTON AVE.
Address:	400 HAMILTON AVENUE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9416809 / 2013-07-19
Facility ID:	9416809
Facility Type:	ER
DER Facility ID:	60149
Site ID:	189820
DEC Region:	3
Spill Cause:	Unknown
Spill Class:	C3
SWIS:	6017
Spill Date:	1995-03-27
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1995-03-28
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Affected Persons
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2003-12-02
Spill Record Last Update:	2013-07-19
Spiller Name:	Not reported
Spiller Company:	Not reported
Spiller Address:	Not reported
Spiller Company:	001
Contact Name:	Not reported
Latitude:	41.0349435
Longitude:	-73.7656143
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY
Remarks:	CONTRACTOR DUGGING BELOW BUILDING DISCOVERED CONTAMINATED SOIL

All Materials:

AT & T TELEPHONE CO (Continued) **S102233627**

Site ID:	189820
Operable Unit ID:	1013927
Operable Unit:	01
Material ID:	371955
Material Code:	0066A
Material Name:	unknown petroleum
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	Not reported
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

---

401 South 1/4-1/2 0.293 mi. 1548 ft.

BROOKFIELD COMMONS PHASE 3
159 SOUTH LEXINGTON AVENUE
WHITE PLAINS, NY 10601

NY BROWNFIELDS S120700630
NY Spills N/A

Relative: Higher

Actual: 202 ft.

BROWNFIELDS:

Name:	BROOKFIELD COMMONS PHASE 3
Address:	159 SOUTH LEXINGTON AVENUE
City,State,Zip:	WHITE PLAINS, NY 10601
Program:	BCP
Site Code:	656716
Acres:	1.284
HW Code:	C360246
SWIS:	6017
Town:	White Plains (c)
Record Added Date:	09/05/2023
Record Updated Date:	06/11/2024
Update By:	SJMCCAGU
Site Description:	Location: The Project Site is located on South Lexington Avenue, south of Quarropas Street (see Figure 1) and is part of White Plains Tax Block 7, Section 125.83, part of Lot 1 in White Plains, Westchester County, New York. The Site is part of a multi-story apartment building complex identified as Brookfield Commons or Winbrook. The Winbrook property is bounded by Quarropas Street and Fisher Court to the north, East Post Road to the south, MLK Blvd to the east, and South Lexington Avenue to the west. The Project Site comprises approximately 1.284-acres of the Winbrook property, and includes the nine-story apartment building, south-adjacent parking lot, and landscaping. Site Features: The approximately 1.284-acre Site is developed with a vacant nine-story apartment building with a basement and a south-adjacent parking lot. The building is surrounded by lawns and asphalt-paved walkways. Current Zoning and Land Use: The Project Site is located within the B3 and RM-0.35 Zoning Districts, and the Central Parking Area (CPA) of the City of White Plains. The Phase 3 portion of the campus is located entirely within the B3 Zoning District. Land uses immediately to the north of the Project Site include residential uses, followed by institutional and government uses; to the south is retail and the White Plains Hospital, farther to the south; residential uses, followed by commercial and institutional uses to the east; and commercial and residential uses to the west. Overall, the surrounding area is generally built out with a mix of institutional/governmental,

BROOKFIELD COMMONS PHASE 3 (Continued) **S120700630**

residential, community, and commercial uses. The proposed project, a 174-unit multi-family building with a height of 11-stories, will be seeking a Special Permit from the Common Council for height. As a multi-family building, the Proposed Project is a Permitted Principal Use in the B-3 Zoning District requiring Site Plan approval from the Common Council. In addition, the proposed project requires City of White Plains Common Council site plan approval and a special permit under Section 5.3, Footnote (X) of the Zoning Ordinance to permit the building to be constructed to a height of 11 stories, or approximately 125 feet. Past Uses of the Site: Historic Sanborn fire insurance maps indicated the Property was vacant as early as 1900. Between 1900 and 1930, the Property was developed with small residential buildings and associated garages, multiple three to four-story apartment buildings, an upholsterer and an auto repair shop. These structures were demolished for construction of the existing apartment building and grounds, which were constructed in 1949-1950 as part of the Winbrook housing complex. The surrounding area was primarily residential in the early 1900 s, with commercial uses shown by 1911, and gasoline filling stations and auto-related uses shown by 1930. The White Plains Hospital was shown on the south-adjacent block by 1911, and subsequently expanded to cover a larger portion of this block. An undertaker was shown by 1950, and drycleaners were shown by 1987. Potential uses of concern on or in close proximity to the Property included: auto repair and an upholsterer on the Property, and nearby filling stations and stores with gasoline USTs, dry cleaners, the White Plains Hospital, auto sales, auto and bicycle repair shops, a vulcanizing (tire conditioning) facility, an undertaker, sheet metal works, and a printer. Site Geology and Hydrogeology: The Property is located at the southern end of a topographic depression, with surrounding land sloping slightly down toward it from the southeast and southwest. Based on reports compiled by the U.S. Geological Survey (White Plains, NY Quadrangle), the Property is approximately 200 feet above the North American Vertical Datum of 1988, an approximation of mean sea level. During a 2021 Subsurface (Phase II) Investigation, groundwater was typically observed at depths ranging from approximately 4 to 10 feet below grade and is presumed to flow in a northwesterly direction toward the Bronx River, located approximately 1,600 feet away. Actual groundwater flow at the Property can be affected by many factors, including past filling activities; underground utilities; other subsurface openings or obstructions such as basements; and other factors beyond the scope of this study. According to the 2014 Annual Water Quality Report prepared by the City of White Plains Department of Public Works, groundwater supply wells formerly providing potable water for White Plains were decommissioned in 2009. The City of White Plains was subsequently supplied with potable water from a reservoir in the NYC potable water supply system. Based on the previous subsurface investigation completed at the Site, the stratigraphy beneath the Site consisted of historic fill material (sand, gravel, silt, concrete, brick, glass, and asphalt) to approximately 6 feet below grade, underlain by apparent native soils (silt, peat, sand, clay and gravel) to the terminus of the borings (maximum of 15 feet bgs).

Env Problem: Information submitted with the BCP application regarding the environmental condition at the site are currently under review and will be revised as additional information becomes available.

Health Problem: Information submitted with the BCP application regarding the

BROOKFIELD COMMONS PHASE 3 (Continued) **S120700630**

	conditions at the site are currently under review and will be revised as additional information becomes available.
Dump:	False
Structure:	False
Lagoon:	False
Landfill:	False
Pond:	False
Disp Start:	Not reported
Disp Term:	Not reported
Lat/Long:	Not reported
Dell:	Not reported
Record Add:	2023-12-12 16:34:00
Record Upd:	2024-01-10 11:58:00
Updated By:	SKSAUCIE
Own Op:	Document Repository
Sub Type:	NNN
Owner Name:	Brian Kenney
Owner Company:	White Plains Public Library
Owner Address:	100 Martine Avenue
Owner Addr2:	Not reported
Owner City,St,Zip:	White Plains, NY 10601
Owner Country:	United States of America
Own Op:	6
Sub Type:	P03
Owner Name:	Rebecca Hemenway
Owner Company:	Trinity Brookfield Commons Phase Three Limited Partnership
Owner Address:	1350 Broadway, Suite 1700
Owner Addr2:	Not reported
Owner City,St,Zip:	New York, NY 10018
Owner Country:	United States of America
Own Op:	1
Sub Type:	E
Owner Name:	n/a
Owner Company:	White Plains Housing Authority (WPHA)
Owner Address:	223 Dr. Martin Luther King Jr. Boulevard
Owner Addr2:	Not reported
Owner City,St,Zip:	White Plains, NY 10601
Owner Country:	United States of America
Own Op:	4
Sub Type:	E
Owner Name:	n/a
Owner Company:	White Plains Housing Authority (WPHA)
Owner Address:	223 Dr. Martin Luther King Jr. Boulevard
Owner Addr2:	Not reported
Owner City,St,Zip:	White Plains, NY 10601
Owner Country:	United States of America
HW Code:	Not reported
Waste Type:	Not reported
Waste Quantity:	Not reported
Waste Code:	Not reported
Crossref ID:	Not reported
Cross Ref Type Code:	Not reported
Cross Ref Type:	Not reported
Record Added Date:	Not reported
Record Updated:	Not reported
Updated By:	Not reported

BROOKFIELD COMMONS PHASE 3 (Continued) **S120700630**

SPILLS:

Name:	APARTMENT BLDG
Address:	159 SOUTH LEXINGTON AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	1610459 / 2017-02-21
Facility ID:	1610459
Facility Type:	ER
DER Facility ID:	495047
Site ID:	541288
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	D4
SWIS:	6017
Spill Date:	2017-02-20
Investigator:	DXTRAVER
Referred To:	Not reported
Reported to Dept:	2017-02-20
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Other
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	Not reported
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2017-02-20
Spill Record Last Update:	2017-02-21
Spiller Name:	RODNEY PERSON
Spiller Company:	WHITE PLAINS SEWER LINE
Spiller Address:	159 SOUTH LEXINGTON AVE
Spiller Company:	999
Contact Name:	RODNEY PERSON
Latitude:	Not reported
Longitude:	Not reported
DEC Memo:	Referred Div. of Water NFA DT
Remarks:	at least 100 gallons in roadway. street was washed down, sewage washed into catch basin. may have been caused by grease build-up in line.

All Materials:

Site ID:	541288
Operable Unit ID:	1289849
Operable Unit:	01
Material ID:	2295632
Material Code:	0062A
Material Name:	raw sewage
Case No.:	Not reported
Material FA:	Other
Quantity:	100.00
Units:	G
Recovered:	Not reported
Resource Affected:	Soil, Sewer
Oxygenate:	Not reported

AV402 **10 SCHOOL STREET** **NY LTANKS** **S108983095**
West **10 SCHOOL STREET** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.298 mi.
1576 ft. **Site 1 of 4 in cluster AV**

Relative:
Higher

Actual:
215 ft.

LTANKS:

Name:	10 SCHOOL STREET
Address:	10 SCHOOL STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0710736 / 2008-05-01
Facility ID:	0710736
Site ID:	392081
Spill Date:	2008-01-10
Spill Cause:	Tank Test Failure
Spill Source:	Private Dwelling
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	jbodee
Referred To:	Not reported
Reported to Dept:	2008-01-10
CID:	444
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	Not reported
Remediation Phase:	0
Date Entered In Computer:	2008-01-10
Spill Record Last Update:	2008-05-01
Spiller Name:	LYDIA
Spiller Company:	Not reported
Spiller Address:	10 SCHOOL STREET
Spiller County:	001
Spiller Contact:	LYDIA
Spiller Phone:	(914) 949-2892
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	341690
Latitude:	41.0327517
Longitude:	-73.7777886
DEC Memo:	Tank to be uncovered, checked and retested. 5/1/2008: Advanced Environmental disposed of LUST and 6.02 tons of contaminated soil. Spill closure report submitted to DEC. Based upon information provided, this Department requires No Further Action at this time. jod
	Not reported
Remarks:	FAILED HISSING AND WILL UNCOVER AND REPAIR AND WILL RETEST: HOMEOWNER DOES NOT SPEAK GOOD ENGLISH

All TTF:

Facility ID:	0710736
Spill Number:	0710736
Spill Tank Test:	2384455
Site ID:	392081
Tank Number:	Not reported
Tank Size:	550
Material:	0001
EPA UST:	Not reported

10 SCHOOL STREET (Continued) **S108983095**

UST:	True
Cause:	03
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Watchdog
Last Modified Date:	Not reported

All Materials:

Site ID:	392081
Operable Unit ID:	1149108
Operable Unit:	01
Material ID:	2139612
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

AW403 **APARTMENT BLDG** **NY LTANKS** **S103037425**
NE **40 BARKER AVE** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.301 mi.
1591 ft. **Site 1 of 2 in cluster AW**

Relative:
Higher

Actual:
245 ft.

LTANKS:

Name:	APARTMENT BLDG
Address:	40 BARKER AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9713796 / 2001-01-31
Facility ID:	9713796
Site ID:	271212
Spill Date:	1998-03-12
Spill Cause:	Tank Test Failure
Spill Source:	Institutional, Educational, Gov., Other
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1998-03-13
CID:	312
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1998-03-13

APARTMENT BLDG (Continued) **S103037425**

Spill Record Last Update:	2001-03-27
Spiller Name:	SUPERINTENDENT
Spiller Company:	APARTMENT BLDG
Spiller Address:	40 BARKER AV
Spiller County:	001
Spiller Contact:	MANNY ZEVALOS
Spiller Phone:	(718) 830-0131
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	220750
Latitude:	41.0357440
Longitude:	-73.7671816
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY 08/09/2000 ARMOR REMOVED UST 01/31/2001 PETROSCIENCE SUBMITTED A UST CLOSURE REPORT. 149.1 TONS OF CONTAMINATED SOIL EXCAVATED & DISPOSED. NO FURTHER ACTION.
Remarks:	TANK FAILED AIR TIGHTNESS TEST - SUCTION LINE, RETURN LINE AND TANK ITSELF FALIED - ATTEMPTED TO CALL LAST NIGHT BUT WAS PUT ON HOLD

All TTF:

Facility ID:	9713796
Spill Number:	9713796
Spill Tank Test:	1545670
Site ID:	271212
Tank Number:	001
Tank Size:	5000
Material:	0003
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	271212
Operable Unit ID:	1056654
Operable Unit:	01
Material ID:	324789
Material Code:	0003A
Material Name:	#6 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

AV404 **12 HARMON STREET** **NY LTANKS** **S107410467**
WNW **12 HARMON STREET** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.303 mi.
1602 ft. **Site 2 of 4 in cluster AV**

Relative:
Higher

Actual:
214 ft.

LTANKS:

Name:	12 HARMON STREET
Address:	12 HARMON STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0506799 / 2012-08-15
Facility ID:	0506799
Site ID:	352081
Spill Date:	2005-09-02
Spill Cause:	Tank Test Failure
Spill Source:	Private Dwelling
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	UNASSIGNED
Referred To:	Not reported
Reported to Dept:	2005-09-02
CID:	444
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2005-09-02
Spill Record Last Update:	2012-08-15
Spiller Name:	DEBORAH - REALTY
Spiller Company:	Not reported
Spiller Address:	12 HARMON STREET
Spiller County:	001
Spiller Contact:	DEBORAH - REALTY
Spiller Phone:	(914) 949-8828
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	299377
Latitude:	41.0326210
Longitude:	-73.7778550
DEC Memo:	7/30/10 Homeowner TTF JO'M 8/15/12 Upon Consultation with Albany and the Region all HO TTF's greater then 5 years old and no indications of contamination or problems will be closed. NFA JO'M
Remarks:	UNCOVER REPAIR AND RETEST

All TTF:

Facility ID:	0506799
Spill Number:	0506799
Spill Tank Test:	1549268
Site ID:	352081
Tank Number:	1
Tank Size:	550
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported

12 HARMON STREET (Continued) **S107410467**

Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Watchdog
Last Modified Date:	Not reported

All Materials:

Site ID:	352081
Operable Unit ID:	1109595
Operable Unit:	01
Material ID:	2099604
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	G
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

AX405 **SPILL NUMBER 9904849** **NY LTANKS** **S102674590**
East **45 MITCHELL PLACE** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.307 mi.
1619 ft. **Site 1 of 2 in cluster AX**

Relative:
Higher

Actual:
217 ft.

LTANKS:

Name:	MGH CO
Address:	45 MITCHELL PLACE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9510979 / 1995-12-12
Facility ID:	9510979
Site ID:	143584
Spill Date:	1995-11-29
Spill Cause:	Tank Overfill
Spill Source:	Commercial/Industrial
Spill Class:	C4
Cleanup Ceased:	1995-12-12
SWIS:	6017
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1995-12-01
CID:	349
Water Affected:	Not reported
Spill Notifier:	Responsible Party
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1995-12-01
Spill Record Last Update:	1999-07-25
Spiller Name:	PHIL MENDOLA
Spiller Company:	ROBISON OIL

SPILL NUMBER 9904849 (Continued) **S102674590**

Spiller Address:	500 EXECUTIVE BLVD
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	(914) 948-6068
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	72789
Latitude:	41.0310635
Longitude:	-73.7641523
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY
Remarks:	DRIVER OVERFILLED TANK

All Materials:

Site ID:	143584
Operable Unit ID:	1021528
Operable Unit:	01
Material ID:	358334
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	1.00
Units:	G
Recovered:	1.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	SPILL NUMBER 9904849
Address:	45 MITCHELL PLACE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9904849 / 2000-01-11
Facility ID:	9904849
Site ID:	78194
Spill Date:	1999-07-23
Spill Cause:	Tank Test Failure
Spill Source:	Institutional, Educational, Gov., Other
Spill Class:	D4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	WCHD
Referred To:	Westchester Cnty Health Dept
Reported to Dept:	1999-07-23
CID:	322
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1999-07-23
Spill Record Last Update:	2000-02-04
Spiller Name:	JAY BRENNAN
Spiller Company:	Not reported
Spiller Address:	45 MITCHELL PLACE
Spiller County:	001

SPILL NUMBER 9904849 (Continued) **S102674590**

Spiller Contact:	JAY BRENNAN
Spiller Phone:	(914) 948-6068
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	72789
Latitude:	41.0310635
Longitude:	-73.7641523
DEC Memo:	Not reported
Remarks:	tank test failure

All TTF:

Facility ID:	9904849
Spill Number:	9904849
Spill Tank Test:	1547407
Site ID:	78194
Tank Number:	1
Tank Size:	3000
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	.00
Gross Fail:	F
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	78194
Operable Unit ID:	1079286
Operable Unit:	01
Material ID:	301173
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

AX406 **APT BUILDING** **NY LTANKS** **S112810131**
East **45 MITCHELL PLACE** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.307 mi.
1619 ft. **Site 2 of 2 in cluster AX**

Relative:
Higher

Actual:
217 ft.

LTANKS:

Name:	APT BUILDING
Address:	45 MITCHELL PLACE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	1212688 / 2020-02-05
Facility ID:	1212688
Site ID:	475842

APT BUILDING (Continued) **S112810131**

Spill Date:	2012-11-27
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	BTRANSOM
Referred To:	Not reported
Reported to Dept:	2012-11-28
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2012-11-28
Spill Record Last Update:	2020-02-05
Spiller Name:	ALEX HAY
Spiller Company:	M.G.H. CO. LLC
Spiller Address:	PO BOX 1755
Spiller County:	999
Spiller Contact:	UNK
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	72789
Latitude:	41.0309916
Longitude:	-73.7636086
DEC Memo:	11-28-12 Tank to be repaired and retested. 2010 WC database listes owner as MGH Co., LLC jc 04-04-14 WCHD request closure, DEC request TCR RDB 4/13/17 DEC requests retest documentation, not TCR. mt 05-11-17; no test results yet - RDB 01-23-20 Spoke to Ruby at Hayco and she will track down the tank test report and forward it. BTR 1-24-20 Yesterday (1/23) the office manager at Hayco Management emailed the tank testing reports for 2019 and 2018. I am still waiting for the 2012 and 2017 test reports. BTR 02-05-20 Requested the 2017 report again. January submittals are on D2. The tank was isolated and retested according to the white plains building inspector certificate. The tank has passed tightness testing the last two years. NFA. BTR
Remarks:	repair/retest pending - possible vent line issue

All Materials:

Site ID:	475842
Operable Unit ID:	1225683
Operable Unit:	01
Material ID:	2222965
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported
Resource Affected:	Not reported
Oxygenate:	Not reported

APT BUILDING (Continued) **S112810131**

Name:	APT BUILDING
Address:	45 MITCHELL PLACE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	1212688 / 2020-02-05
Facility ID:	1212688
Site ID:	475842
Spill Date:	2012-11-27
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	BTRANSOM
Referred To:	Not reported
Reported to Dept:	2012-11-28
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2012-11-28
Spill Record Last Update:	2020-02-05
Spiller Name:	Alex Hay
Spiller Company:	HAYCO Management
Spiller Address:	PO BOX 747
Spiller County:	999
Spiller Contact:	UNK
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	72789
Latitude:	41.0309916
Longitude:	-73.7636086
DEC Memo:	11-28-12 Tank to be repaired and retested. 2010 WC database listes owner as MGH Co., LLC jc 04-04-14 WCHD request closure, DEC request TCR RDB 4/13/17 DEC requests retest documentation, not TCR. mt 05-11-17; no test results yet - RDB 01-23-20 Spoke to Ruby at Hayco and she will track down the tank test report and forward it. BTR 1-24-20 Yesterday (1/23) the office manager at Hayco Management emailed the tank testing reports for 2019 and 2018. I am still waiting for the 2012 and 2017 test reports. BTR 02-05-20 Requested the 2017 report again. January submittals are on D2. The tank was isolated and retested according to the white plains building inspector certificate. The tank has passed tightness testing the last two years. NFA. BTR
Remarks:	repair/retest pending - possible vent line issue

All Materials:

Site ID:	475842
Operable Unit ID:	1225683
Operable Unit:	01
Material ID:	2222965
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported

APT BUILDING (Continued) **S112810131**

Material FA:	Petroleum
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported
Resource Affected:	Not reported
Oxygenate:	Not reported

AW407 **COMMERCIAL** **NY LTANKS** **S102153972**
NE **41 BARKER AVE** **NY Spills** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.310 mi.
1637 ft. **Site 2 of 2 in cluster AW**

Relative: **Higher**
Actual: **247 ft.**

LTANKS:

Name:	COMMERCIAL
Address:	41 BARKER AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0909513 / 2010-03-04
Facility ID:	0909513
Site ID:	422220
Spill Date:	2009-11-25
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	jbodee
Referred To:	WCDOH
Reported to Dept:	2009-11-25
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2009-11-25
Spill Record Last Update:	2015-06-08
Spiller Name:	CERDAN LOVELL
Spiller Company:	H AND S PROPRTY MANAGEMENT
Spiller Address:	41 BARKER AVE
Spiller County:	999
Spiller Contact:	KATHY MORGAN
Spiller Phone:	(845) 225-5240
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	254318
Latitude:	41.0363316
Longitude:	-73.7671086
DEC Memo:	11-25-09 Tank top is 103 in below grade. Test was done in relation to WCHD NOHC. NE Environmental is handling compliance issues. jc 12/10/09 -- According to WCDOH: They re in our hearing process right now. Major violations include no corrosion protection and no leak detection. They re claiming they don t have to come into compliance because White Plains issued them a certificate that everything was in compliance when the tank was installed in 1990. They re not accepting

COMMERCIAL (Continued) **S102153972**

	our explanation that the certificate only applies to White Plains building code. Because the tank is buried so deep, it will be a hardship for them to come into compliance. And The case was adjourned for them to prove compliance. If they can get proper documentation, excavation may not be necessary. They re not performing leak monitoring, at least they re not maintaining any documentation. We don t know if the tank is single- or double-walled because the interstitial port is probably not to grade. They have an ATG but there s no proof that it s performing interstitial monitoring. They need to get a contractor to determine what they ve got since we re not accepting the proof from White Plains Bldg Dept. Resolution to be determined in January, maybe. ELM 1/25/10: See eDocs for 12-31-09 letter from WCDOH/PBS - requiring additional action. jod 3/4/10: As per an e-mail recived from Chris Lalak of WCDOH dated 2-16-10, this tank was retested and passed. E-mail entered into eDocs. Based upon the information provided, DEC requires no further action at this time. jod
Remarks:	caller reporting tank test failure on a 10000 gallon ust. caller reports tank is deep, fill pipe is 103 ft long. clean up pending.

All TTF:

Facility ID:	0909513
Spill Number:	0909513
Spill Tank Test:	2488120
Site ID:	422220
Tank Number:	UST
Tank Size:	10000
Material:	0002
EPA UST:	False
UST:	True
Cause:	99
Source:	01
Test Method:	21
Test Method 2:	Horner EZY3/EZY3 Locator Plus
Leak Rate:	Not reported
Gross Fail:	Not reported
Modified By:	JBODEE
Last Modified Date:	Not reported

All Materials:

Site ID:	422220
Operable Unit ID:	1178070
Operable Unit:	01
Material ID:	2171020
Material Code:	0002A
Material Name:	#4 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	G
Recovered:	Not reported
Resource Affected:	Soil
Oxygenate:	Not reported

SPILLS:

Name:	41 BARKER AVE.

COMMERCIAL (Continued) **S102153972**

Address:	41 BARKER AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9004325 / 1990-12-26
Facility ID:	9004325
Facility Type:	ER
DER Facility ID:	254318
Site ID:	315451
DEC Region:	3
Spill Cause:	Unknown
Spill Class:	Not reported
SWIS:	6017
Spill Date:	1990-07-19
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1990-07-19
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Unknown
Spill Notifier:	Fire Department
Cleanup Ceased:	1990-12-26
Cleanup Meets Std:	True
Last Inspection:	1990-12-26
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	1990-07-20
Spill Record Last Update:	1991-01-15
Spiller Name:	Not reported
Spiller Company:	Not reported
Spiller Address:	Not reported
Spiller Company:	001
Contact Name:	Not reported
Latitude:	41.0359401
Longitude:	-73.7669876
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY 01/15/91: LUZON OIL WAS ON SITE LOADING THE LAST OF THE CONTAMINATED SOIL INTOTRUCKS FOR DISPOSAL. JOB IS COMPLETED.
Remarks:	10K TANK OR PIPING LEAKING FOR COUPLE OF DAYS CASTLE OIL FILLED TANK TODAY EASTMAN TANK IS PUMPING OUT TANK FIRE DEPT.AND DOT SANDING STORMDRAIN LEADS TO SEWER PLANT,WCHD,WC HAZMAT,EPA ALL NOTIFIED

All Materials:

Site ID:	315451
Operable Unit ID:	942144
Operable Unit:	01
Material ID:	435423
Material Code:	0003A
Material Name:	#6 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	80.00
Units:	G
Recovered:	.00
Resource Affected:	Sewer
Oxygenate:	Not reported

AY408 **STEWARD** **NY LTANKS** **S105999309**
SE **165 MAMARONECK AVENUE** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.312 mi.
1650 ft. **Site 1 of 3 in cluster AY**

Relative:
Higher

Actual:
227 ft.

LTANKS:

Name:	165 MAMARONECK AVE
Address:	165 MAMARONECK AVENUE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9701601 / 2005-02-12
Facility ID:	9701601
Site ID:	118993
Spill Date:	1997-05-06
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1997-05-06
CID:	282
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1997-05-06
Spill Record Last Update:	2005-02-12
Spiller Name:	SAME
Spiller Company:	SAME
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	N/A
Spiller Phone:	(914) 934-5992
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	151552
Latitude:	41.0286900
Longitude:	-73.7650380
DEC Memo:	02/12/05 TANK REPORTEDLY PASSED A RETEST, NO RETEST INFORMATION SUBMITTED TO DEC. TANK WAS REMOVED BY NES ON 6-30-03 AFTER CONTAMINATION WAS DISCOVERED DURING REMOVAL OF NEIGHBORING TANK AT 169 MAMARONECK AVE BY NORTHEAST ENVIRONMENTAL (SEE SPILL 03-01465). WHEN TANK WAS REMOVED BY NES, IT WAS DISCOVERED THAT THE TANK HAD BEEN FIBERGLASS RELINED IN THE PAST. THE TANK WAS NO LONGER LEAKING BUT HAD LEAKED PRIOR TO RELINING. NES REMOVING SOIL, REPORT TO FOLLOW. SEE SPILL 03-03361 FOR ALL UPDATES. NFA THIS SPILL NUMBER. jbo
	Not reported
Remarks:	TANK FAILED THE VACUUM TEST.COMMERCIAL BUILDING IS WHERE THE TEST WAS DONE.

All TTF:

Facility ID:	9701601
Spill Number:	9701601
Spill Tank Test:	1545105
Site ID:	118993

STEWARD (Continued) **S105999309**

Tank Number:	1
Tank Size:	1000
Material:	Not reported
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

Name:	STEWARD
Address:	165 MAMARONECK AVENUE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0303361 / 2007-06-22
Facility ID:	0303361
Site ID:	180689
Spill Date:	2003-06-30
Spill Cause:	Tank Failure
Spill Source:	Commercial/Industrial
Spill Class:	B3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	jbodee
Referred To:	Not reported
Reported to Dept:	2003-06-30
CID:	204
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	2003-06-30
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2003-06-30
Spill Record Last Update:	2007-06-22
Spiller Name:	BAHRU STEWARD
Spiller Company:	BAHRU STEWARD
Spiller Address:	165 MAMARONECK AVENUE
Spiller County:	001
Spiller Contact:	MARIE MULLEN
Spiller Phone:	(914) 741-5472
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	151552
Latitude:	41.0286949
Longitude:	-73.7650411
DEC Memo:	06/30/03: UST lined tank, leaked through lining, tank out, soil will be removed. Waiting on insurance. See also spill #03-01465. 02/12/05 PREVIOUSLY REPORTED AS 97-01601. UST FAILED TANK TEST, TANK WAS RELINED AND PUT BACK IN SERVICE. TANK REMOVED BY NES AFTER CONTAMINATION FOUND DURING REMOVAL OF NEIGHBORING TANK AT 169 MAMARONECK AVE. TANK HAD BEEN LEAKING PRIOR TO RELINING. jbo

STEWARD (Continued) **S105999309**

Remarks:	06/22/2007: NES COMPLETED CLEAN UP. jod OLD TANK FAILED

All Materials:

Site ID:	180689
Operable Unit ID:	871405
Operable Unit:	01
Material ID:	504234
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

AU409 **SPILL NUMBER 9900622** **NY LTANKS** **S104620122**
ESE **179 EAST COAST RD** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.314 mi.
1656 ft. **Site 2 of 2 in cluster AU**

Relative:
Higher

Actual:
223 ft.

LTANKS:

Name:	SPILL NUMBER 9900622
Address:	179 EAST COAST RD
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9900622 / 2000-03-24
Facility ID:	9900622
Site ID:	260731
Spill Date:	1999-04-16
Spill Cause:	Tank Failure
Spill Source:	Commercial/Industrial
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	jbodee
Referred To:	Not reported
Reported to Dept:	1999-04-16
CID:	312
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1999-04-16
Spill Record Last Update:	2000-03-30
Spiller Name:	ANN WEST
Spiller Company:	Not reported
Spiller Address:	179 EAST COAST RD
Spiller County:	001
Spiller Contact:	ANN WEST
Spiller Phone:	(914) 946-2370
Spiller Extention:	Not reported

SPILL NUMBER 9900622 (Continued) **S104620122**

DEC Region:	3
DER Facility ID:	212944
Latitude:	Not reported
Longitude:	Not reported
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was O'DEE 4/16/99 NES REMOVING CONTAMINATED SOIL 03/24/2000 NES DISPOSED OF TANK AND 3.65 TONS OF CONTAMINATED SOIL. NFA
Remarks:	550GAL VAULTED TANK IN BASEMENT FULL OF HOLES - LEAKED INTO SAND BELOW THE TANK

All Materials:

Site ID:	260731
Operable Unit ID:	1079395
Operable Unit:	01
Material ID:	307749
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

AT410 **CASTILLO** **NY LTANKS** **S104276655**
SW **125-127 FISHER AVE** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.317 mi.
1673 ft. **Site 2 of 2 in cluster AT**

Relative: **Higher**

Actual: **210 ft.**

LTANKS:

Name:	CASTILLO
Address:	125-127 FISHER AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8709424 / 1988-03-11
Facility ID:	8709424
Site ID:	210582
Spill Date:	1988-02-05
Spill Cause:	Tank Overfill
Spill Source:	Commercial/Industrial
Spill Class:	Not reported
Cleanup Ceased:	1988-03-11
SWIS:	6017
Investigator:	dxtraver
Referred To:	Not reported
Reported to Dept:	1988-02-05
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Responsible Party
Last Inspection:	1988-03-11
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1988-02-10
Spill Record Last Update:	1988-03-11

CASTILLO (Continued) **S104276655**

Spiller Name:	Not reported
Spiller Company:	JOE JAHENSKY,ROBINSON OIL
Spiller Address:	RIVER RD
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	174577
Latitude:	41.0270376
Longitude:	-73.7751827
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was TRAVER / / : W.C.H.D. TO INSPECT 2-18-88 LR.
Remarks:	OVERFILL FROM VENT DURING DELIVERY ONTO BLACKTOP DRIVEWAY. ROBINSON OIL CLEANING UP W/SPEEDY DRY.

All Materials:

Site ID:	210582
Operable Unit ID:	914522
Operable Unit:	01
Material ID:	464746
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	7.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

AY411 **KEMPLER RESIDENCE** **NY LTANKS** **S105998935**
SE **169 MAMARONECK AVE** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.318 mi.
1681 ft. **Site 2 of 3 in cluster AY**

Relative:
Higher

Actual:
226 ft.

LTANKS:

Name:	KEMPLER RESIDENCE
Address:	169 MAMARONECK AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0301465 / 2003-08-25
Facility ID:	0301465
Site ID:	160482
Spill Date:	2003-05-09
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	B3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	jbodee
Referred To:	Not reported
Reported to Dept:	2003-05-09
CID:	195
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	2003-06-16

KEMPLER RESIDENCE (Continued) **S105998935**

Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2003-05-09
Spill Record Last Update:	2005-02-12
Spiller Name:	PETER KEMPLER
Spiller Company:	PETER KEMPLER
Spiller Address:	169 MAMARONECK AVE
Spiller County:	001
Spiller Contact:	PETER KEMPLER
Spiller Phone:	(914) 946-3030
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	135518
Latitude:	41.0286044
Longitude:	-73.7649952
DEC Memo:	06/30/03 ALSO SPILL 03-03361. 08/25/03 NORTHEAST DISPOSED OF LUST AND 122.09 TONS OF CONTAMINATED SOIL. NFA
Remarks:	TANK WAS UNCOVERED AND TESTED. TEST FAILED. OWNER (PETER KEMPLER) WAS TOLD TO PUMP TANK OUT WITHIN 48 HOURS AND HAVE TANK REMOVED TO CHECK FOR CONTAMINATION. CALLER CAN BE REACHED AT 845-742-1666.

All TTF:

Facility ID:	0301465
Spill Number:	0301465
Spill Tank Test:	1528363
Site ID:	160482
Tank Number:	1
Tank Size:	1000
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	160482
Operable Unit ID:	867853
Operable Unit:	01
Material ID:	505959
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

412
West
1/4-1/2
0.320 mi.
1692 ft.

BUSINESS
2-4 WASHINGTON AVE
WHITE PLAINS, NY

NY LTANKS **S105998813**
N/A

Relative:
Higher

Actual:
266 ft.

LTANKS:

Name:	BUSINESS
Address:	2-4 WASHINGTON AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0300993 / 2003-06-13
Facility ID:	0300993
Site ID:	86277
Spill Date:	2003-04-28
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	WCHD
Referred To:	Westchester Cnty Health Dept
Reported to Dept:	2003-04-28
CID:	252
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2003-04-28
Spill Record Last Update:	2003-06-25
Spiller Name:	MICHAEL
Spiller Company:	BUSINESS
Spiller Address:	2-4 WASHINGTON AVE
Spiller County:	001
Spiller Contact:	MICHAEL
Spiller Phone:	(914) 674-6437
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	79185
Latitude:	41.0324769
Longitude:	-73.7787090
DEC Memo:	Not reported
Remarks:	RECOMMEND TO UNCOVER AND RE-TEST

All TTF:

Facility ID:	0300993
Spill Number:	0300993
Spill Tank Test:	1528312
Site ID:	86277
Tank Number:	Not reported
Tank Size:	2000
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II

BUSINESS (Continued) **S105998813**

Leak Rate: .00
Gross Fail: Not reported
Modified By: Spills
Last Modified Date: Not reported

All Materials:
Site ID: 86277
Operable Unit ID: 869078
Operable Unit: 01
Material ID: 509058
Material Code: 0001A
Material Name: #2 fuel oil
Case No.: Not reported
Material FA: Petroleum
Quantity: .00
Units: G
Recovered: .00
Resource Affected: Soil
Oxygenate: Not reported

AY413 **JOHN DALE INC** **NY LTANKS** **S103558559**
SE **178 MAMORENECK AVE** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.321 mi.
1693 ft. **Site 3 of 3 in cluster AY**

Relative:
Higher

Actual:
227 ft.

LTANKS:
Name: JOHN DALE INC
Address: 178 MAMORENECK AVE
City,State,Zip: WHITE PLAINS, NY
Spill Number/Closed Date: 9810809 / 1998-12-01
Facility ID: 9810809
Site ID: 325049
Spill Date: 1998-11-25
Spill Cause: Tank Failure
Spill Source: Commercial/Industrial
Spill Class: C3
Cleanup Ceased: Not reported
SWIS: 6017
Investigator: tdghiosa
Referred To: Not reported
Reported to Dept: 1998-11-25
CID: 282
Water Affected: Not reported
Spill Notifier: Other
Last Inspection: Not reported
Recommended Penalty: False
Meets Standard: False
UST Involvement: False
Remediation Phase: 0
Date Entered In Computer: 1998-11-25
Spill Record Last Update: 1999-01-16
Spiller Name: DWAYNE MONICO
Spiller Company: JOHN DALE INC
Spiller Address: 80 BUSINESS PARK DRIVE
Spiller County: 001

JOHN DALE INC (Continued) **S103558559**

Spiller Contact:	DWAYNE MONICO
Spiller Phone:	(914) 777-1930
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	261843
Latitude:	41.0283617
Longitude:	-73.7650473
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY SPILL CLOSED BY WCHD, S. GOREAU.
Remarks:	tank leaked and the soil around the tank was contaminated.soil was removed and stockpiled.site has been cleaned .

All Materials:

Site ID:	325049
Operable Unit ID:	1071785
Operable Unit:	01
Material ID:	314671
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

414
ESE
1/4-1/2
0.327 mi.
1729 ft.

APARTMENT BUILDING
193 EAST POST ROAD
WHITE PLAINS, NY

NY LTANKS **S106124534**
N/A

Relative:
Higher

Actual:
218 ft.

LTANKS:

Name:	APARTMENT BUILDING
Address:	193 EAST POST ROAD
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0310631 / 2005-10-11
Facility ID:	0310631
Site ID:	158568
Spill Date:	2003-12-15
Spill Cause:	Tank Test Failure
Spill Source:	Private Dwelling
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	WCHD
Referred To:	WESTCHESTER CNTY HEALTH D
Reported to Dept:	2003-12-15
CID:	444
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0

APARTMENT BUILDING (Continued) **S106124534**

Date Entered In Computer:	2003-12-15
Spill Record Last Update:	2005-11-01
Spiller Name:	Not reported
Spiller Company:	Not reported
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	PAOLA CORONEL
Spiller Phone:	(914) 747-9741
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	133999
Latitude:	41.0297828
Longitude:	-73.7640097
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was WCHD-JACKSON 10/11/05 letter from Barbara McDonald of WCDH to Virginia Manning saying submittals have been reviewed. NFA.
Remarks:	tank test failed. not yet being cleaned up.

All TTF:

Facility ID:	0310631
Spill Number:	0310631
Spill Tank Test:	1528864
Site ID:	158568
Tank Number:	1
Tank Size:	3000
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	158568
Operable Unit ID:	875713
Operable Unit:	01
Material ID:	499481
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	L
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

AZ415 **WHITE PLAINS HOSPITAL** **NY LTANKS** **S100964742**
SSE **DAVIS AVE & EAST POST ROAD** **NY Spills** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.333 mi.
1757 ft. **Site 1 of 6 in cluster AZ**

Relative:
Higher

Actual:
215 ft.

LTANKS:

Name:	WHITE PLAINS HOSPITAL
Address:	DAVIS AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9303501 / 1996-06-18
Facility ID:	9303501
Site ID:	66799
Spill Date:	1993-06-14
Spill Cause:	Tank Failure
Spill Source:	Institutional, Educational, Gov., Other
Spill Class:	B3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1993-06-17
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1993-06-21
Spill Record Last Update:	1996-06-18
Spiller Name:	Not reported
Spiller Company:	SAME
Spiller Address:	Not reported
Spiller County:	999
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	63920
Latitude:	41.0331599
Longitude:	-73.7628200
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY
Remarks:	TYREE DID TANK REMOVAL WCHD NOTIFIED FAXED TO TODD THEY CONVERTED TO NATURAL GAS

All Materials:

Site ID:	66799
Operable Unit ID:	985354
Operable Unit:	01
Material ID:	397066
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	L
Recovered:	.00

WHITE PLAINS HOSPITAL (Continued) **S100964742**

Resource Affected: Soil
Oxygenate: Not reported

SPILLS:
Name: WHITE PLAINS HOSPITAL
Address: DAVIS AVE & EAST POST ROAD
City,State,Zip: WHITE PLAINS, NY
Spill Number/Closed Date: 9401229 / 1994-05-05
Facility ID: 9401229
Facility Type: ER
DER Facility ID: 174910
Site ID: 210995
DEC Region: 3
Spill Cause: Equipment Failure
Spill Class: C3
SWIS: 6017
Spill Date: 1994-04-26
Investigator: tdghiosa
Referred To: Not reported
Reported to Dept: 1994-04-26
CID: Not reported
Water Affected: Not reported
Spill Source: Commercial/Industrial
Spill Notifier: Other
Cleanup Ceased: Not reported
Cleanup Meets Std: True
Last Inspection: Not reported
Recommended Penalty: False
UST Trust: False
Remediation Phase: 0
Date Entered In Computer: 1994-05-05
Spill Record Last Update: 1996-06-18
Spiller Name: Not reported
Spiller Company: Not reported
Spiller Address: Not reported
Spiller Company: 001
Contact Name: Not reported
Latitude: 41.0264640
Longitude: -73.7694250
DEC Memo: Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY 06/07/94: NO DEC INSPECTION.
Remarks: GAGE MALFUNCTION SPILL CONTAINED ON CONCRETE CASTLE TO DO CLEAN UP BEING CLEANED UP

All Materials:
Site ID: 210995
Operable Unit ID: 998531
Operable Unit: 01
Material ID: 570100
Material Code: 0003A
Material Name: #6 fuel oil
Case No.: Not reported
Material FA: Petroleum
Quantity: 40.00
Units: G

WHITE PLAINS HOSPITAL (Continued) **S100964742**

Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

AZ416 **WHITE PLAINS HOSPITAL** **NY LTANKS** **S101658669**
South **EAST NEW YORK POST ROAD** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.336 mi.
1776 ft. **Site 2 of 6 in cluster AZ**

Relative:
Higher

Actual:
214 ft.

LTANKS:

Name:	WHITE PLAINS HOSPITAL
Address:	EAST NEW YORK POST ROAD
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9506062 / 2005-01-02
Facility ID:	9506062
Site ID:	240948
Spill Date:	1995-08-15
Spill Cause:	Tank Test Failure
Spill Source:	Institutional, Educational, Gov., Other
Spill Class:	B3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1995-08-16
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	True
Remediation Phase:	0
Date Entered In Computer:	2003-12-02
Spill Record Last Update:	2005-01-02
Spiller Name:	Not reported
Spiller Company:	Not reported
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	198131
Latitude:	41.0263929
Longitude:	-73.7695590
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY 1/5/05--this was not a confirmed spill (was tank test failure in 2000 gal diesel tank for emergency generator); plan was to remove and replace tank-- would be handled as pbs matter whether removed or not--close
Remarks:	BELIEVE TANK WILL BE PULLED & REPLACED TANK WAS PREVIOUSLY FAILED BY SOMEONE ELSE TANK ONLY TEST

All TTF:

Facility ID:	9506062

WHITE PLAINS HOSPITAL (Continued) **S101658669**

Spill Number:	9506062
Spill Tank Test:	1544090
Site ID:	240948
Tank Number:	Not reported
Tank Size:	0
Material:	0008
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	240948
Operable Unit ID:	1016961
Operable Unit:	01
Material ID:	364045
Material Code:	0008
Material Name:	diesel
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	Not reported
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

AZ417 **WHITE PLAINS CITGO** **UST FINDER RELEASE** **1029060053**
South **34 EAST POST ROAD** **N/A**
1/4-1/2 **WHITE PLAINS, NY 0**
0.340 mi.
1797 ft. **Site 3 of 6 in cluster AZ**

Relative:
Higher

Actual:
209 ft.

UST FINDER RELEASE:

Object ID:	262403
Facility ID:	NY144434
Lust ID:	NY9516188
Name:	WHITE PLAINS CITGO
Address:	34 EAST POST ROAD
City,State,Zip:	WHITE PLAINS, NY 0
Address Match Type:	Not reported
Reported Date:	1996/03/18 15:59:59+00
Status:	No Further Action
Substance:	Not reported
Population within 1500ft:	5470
Domestic Wells within 1500ft:	0
Land Use:	Developed, High Intensity
Within SPA:	Yes
SPA PWS Facility ID:	NY7003493_76968
SPA Water Type:	SW - SurRELEASEe Water
SPA Facility Type:	RS - Reservoir

WHITE PLAINS CITGO (Continued) **1029060053**

SPA HUC12:	20301020103
Within WHPA:	No
WHPA PWS Facility ID:	Not reported
WHPA Water Type:	Not reported
WHPA Facility Type:	Not reported
WHPA HUC12:	Not reported
Within 100yr Floodplain:	No
Tribe:	Not reported
EPA Region:	2
NFA Letter 1:	Not reported
NFA Letter 2:	Not reported
NFA Letter 3:	Not reported
NFA Letter 4:	Not reported
Closed With Residual Contaminate:	Not reported
Coordinate Source:	State
X Coord:	-73.76994
Y Coord:	41.0262900000001
Latitude:	41.02629
Longitude:	-73.76994

AZ418 **WHITE PLAINS HOSPITAL CENTER** **NY LTANKS** **S104284805**
South **41 POST RD** **NY Spills** **N/A**
1/4-1/2 **WHITE PLAINS, NY 10601** **NY MANIFEST**
0.341 mi.
1801 ft. **Site 4 of 6 in cluster AZ**

Relative:
Higher

Actual:
214 ft.

LTANKS:

Name:	WHITE PLAINS HOSPITAL
Address:	41 EAST POST RD
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	1107393 / 2011-10-31
Facility ID:	1107393
Site ID:	455090
Spill Date:	2011-09-12
Spill Cause:	Tank Test Failure
Spill Source:	Institutional, Educational, Gov., Other
Spill Class:	B3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	jbodee
Referred To:	Not reported
Reported to Dept:	2011-09-12
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Responsible Party
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2011-09-12
Spill Record Last Update:	2011-10-31
Spiller Name:	BOB
Spiller Company:	WHITE PLAINS HOSPITAL
Spiller Address:	41 EAST POST RD
Spiller County:	999
Spiller Contact:	STEPHANIE EAGANS
Spiller Phone:	(845) 528-0370

WHITE PLAINS HOSPITAL CENTER (Continued) **S104284805**

Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	350007
Latitude:	41.0259317
Longitude:	-73.7690486
DEC Memo:	9/12/11- Elite reports failure was below product level. Tank also failed previous test- 1105346. Elite reports that Todd ghiosay and WCHD are involved with site. DT >>> Lalak, Chris 9/12/2011 2:32 PM >>> I am dealing with this site. I have asked them to empty the tank immediately. (product was present in the tank top sump) There is also an old open spill with oil getting into the basement from their other UST. jod 10/31/11: Update received from Chris Lalak of WCDoH: 1107393 NFA WP Hospital (see 1105346 open) jod
Remarks:	Failed Tank Test

All Materials:

Site ID:	455090
Operable Unit ID:	1205238
Operable Unit:	01
Material ID:	2202084
Material Code:	0003A
Material Name:	#6 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	G
Recovered:	Not reported
Resource Affected:	Soil
Oxygenate:	Not reported

SPILLS:

Name:	WHITE PLAINS HOSPITAL
Address:	41 EAST POST RD
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	1105346 / 2017-04-04
Facility ID:	1105346
Facility Type:	ER
DER Facility ID:	350007
Site ID:	452999
DEC Region:	3
Spill Cause:	Unknown
Spill Class:	B3
SWIS:	6017
Spill Date:	2011-08-10
Investigator:	RDBENDEL
Referred To:	Not reported
Reported to Dept:	2011-08-10
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Institutional, Educational, Gov., Other
Spill Notifier:	Tank Tester
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	2011-08-10
Recommended Penalty:	False
UST Trust:	False

WHITE PLAINS HOSPITAL CENTER (Continued) **S104284805**

Remediation Phase:	0
Date Entered In Computer:	2011-08-10
Spill Record Last Update:	2017-04-04
Spiller Name:	Not reported
Spiller Company:	WHITE PLAINS HOSPITAL
Spiller Address:	Not reported
Spiller Company:	999
Contact Name:	STEPHANIE EAGENS
Latitude:	Not reported
Longitude:	Not reported
DEC Memo:	8/10/11 - During a tank test of a 20K UST, No. 6 fuel oil was discovered in the sump. Caller is scheduling for 8/11/11: I responded to the location yesterday. I first checked outfall at Bronx River and no oil or sheen was noted. I spoke with Ray Hilyer, Elite was scheduled to test the tank last week and did not after finding an uncapped feed line. Ray states he notified WCDOH Wayne Schneider. Elite returned yesterday and found a large quantitiy of #6 Oil in a manway sump next to the UST. I met with Hospital Engineer Bob Biddiscombe and observed the oil in the sump. He states it is contained within the secondary containment and stated Elite was en route to vac it out. I again contacted Elite, they have not been hired. Bob Biddiscombe spoke with Elite via phone directly while I was there. Elite will be there first thing in the morning. No oil was observed in the basement sump where previous major spills have occurred. Mr Biddiscombe stated the sump has been re-piped, and now discharges to the sanitary sewer instead of the storm drain. WCDOH will follow up. Chris Lalak is enroute this morning to confirm the sump has been vacuumed out and investigation will continue. jod *Chris Lalak reports that the manway has still not been vacuumed out this morning. Email update from Chris: Lalak, Chris 8/11/2011 11:52 AM They still didn't pump it out Robert Biddiscombe was going to call Elite or Island pump and tank to get it pumped. He doesn't know if it is a contained sump. I gave him 1 week to TT tank and lines. 1 month for env. Investigation and. pump it out today and check daily. I also stated if it is visually found that the sump is leaking an immediate investigation is needed. jod 8/12/11: Chris Lalak reports Envirowaste completed pump out. Further investigation required. jod 10/16/12: See letter from Chris Lalak of WCDoH in EDocs. jod 5/30/13: Report from Elite dated Jan 14th 2013 entered into Edocs. Message sent to Chris Lalak requesting status report. jod 040417- Email, This spill started on 2009 with 6 oil entering a basement Sump. The sump apparently collects water the buildings footing drains. White Plains hospital is a huge urban hospital complex, occupying a full city block. The spill was determined to be from piping leaks associate with two old 6

WHITE PLAINS HOSPITAL CENTER (Continued) **S104284805**

oil tanks. Tank 1 (20K ust
was abandoned in place by Castlton). Removal of this tank was not possible. Free product was
encountered around this tank. Castlton installed a monitoring/recovery well thru the tank. The well
is identified as 15 . Free product was recovered from the well, into a holding tank. The well was
then sampled 4 times 2014/2015. Some minor volatile and semi-volatiles are still present. The
highest is 29 PPB pyrene. MW number 4 is located next to the abandoned tank and was sampled at the
same time and was essentially clean. Tank 2 was removed by Elite. (the other old 20K UST) Royal
remediated the sump for approximately 2 years.(2009-2010) Hydro Environmental Technologies (HETI)
performed a GW monitoring investigation in 2012. The Hospital has been cooperatively remediating a
very difficult spill. No oil has been found in the sump since 2013.
The monitoring/recovery well
installed thru the 20 K 6 oil UST, (and thru the concrete Pads) has been substantially remediated.
Pristine remediation is not possible in this case. Well sampling performed by Castlton in 2014 and
2015 is attached. The hospital is located in an urban city with no drinking water wells near by.
The abandoned UST has been filled in with slurry Concrete except for the recovery well. It could
not be removed. NFA- RDB

Remarks: sump is full of oil/investigation underway

All Materials:

Site ID:	452999
Operable Unit ID:	1203158
Operable Unit:	01
Material ID:	2199776
Material Code:	0003A
Material Name:	#6 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	100.00
Units:	G
Recovered:	Not reported
Resource Affected:	Not reported
Oxygenate:	Not reported

Name:	WHITE PLAINS HOSPITAL
Address:	41 EAST POST ROAD
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0504642 / 2006-05-23
Facility ID:	0504642
Facility Type:	ER
DER Facility ID:	65131
Site ID:	349576
DEC Region:	3
Spill Cause:	Other
Spill Class:	C4
SWIS:	6017

WHITE PLAINS HOSPITAL CENTER (Continued) **S104284805**

Spill Date:	2005-07-18
Investigator:	MBMASTRO
Referred To:	Not reported
Reported to Dept:	2005-07-18
CID:	38
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Responsible Party
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2005-07-20
Spill Record Last Update:	2006-05-26
Spiller Name:	DAHL, OSSIE
Spiller Company:	WHITE PLAINS HOSPITAL
Spiller Address:	41 EAST POST RD
Spiller Company:	001
Contact Name:	DAHL, OSSIE
Latitude:	41.0263830
Longitude:	-73.7695490
DEC Memo:	amount of oil is minimal, slight sheen on water, being cleaned up - nfa
Remarks:	Flooding in basement caused residual oil in basement area to mix w/ water. Cleanup is being done by northeast environmental and tradewinds will be responding later.

All Materials:

Site ID:	349576
Operable Unit ID:	1107165
Operable Unit:	01
Material ID:	2097060
Material Code:	0003A
Material Name:	#6 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	WHITE PLAINS HOSPITAL
Address:	41 EAST POST ROAD
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9910974 / 2005-01-02
Facility ID:	9910974
Facility Type:	ER
DER Facility ID:	65131
Site ID:	149038
DEC Region:	3
Spill Cause:	Unknown
Spill Class:	C3
SWIS:	6017
Spill Date:	1999-12-15

WHITE PLAINS HOSPITAL CENTER (Continued) **S104284805**

Investigator:	JBODEE
Referred To:	Not reported
Reported to Dept:	1999-12-15
CID:	246
Water Affected:	Not reported
Spill Source:	Institutional, Educational, Gov., Other
Spill Notifier:	Responsible Party
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	1999-12-15
Spill Record Last Update:	2019-11-07
Spiller Name:	UNKNOWN
Spiller Company:	Unknown
Spiller Address:	UNKNOWN
Spiller Company:	999
Contact Name:	SCOTT WILLIAMS
Latitude:	41.0263922
Longitude:	-73.7695566
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was 1/2/05 report that there was a 12 gallon overfill of #6 oil during delivery--close
Remarks:	driver making a fuel delivery-a possible broken fill line caused material to come up from ground beneath fill hole. spill contained and being investigated in am.

All Materials:

Site ID:	149038
Operable Unit ID:	1089666
Operable Unit:	01
Material ID:	296448
Material Code:	0003A
Material Name:	#6 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	12.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	WHITE PLAINS HOSPITAL
Address:	41 EAST POST RD
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0803913 / 2008-07-07
Facility ID:	0803913
Facility Type:	ER
DER Facility ID:	350007
Site ID:	400727
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	C3
SWIS:	6017
Spill Date:	2008-07-03

WHITE PLAINS HOSPITAL CENTER (Continued) **S104284805**

Investigator:	mbmastro
Referred To:	Not reported
Reported to Dept:	2008-07-03
CID:	406
Water Affected:	Not reported
Spill Source:	Institutional, Educational, Gov., Other
Spill Notifier:	Police Department
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	Not reported
Remediation Phase:	0
Date Entered In Computer:	2008-07-03
Spill Record Last Update:	2008-07-22
Spiller Name:	DISP 603 CEPIN
Spiller Company:	WHITE PLAINS HOSPITAL
Spiller Address:	41 EAST POST RD.
Spiller Company:	001
Contact Name:	DISP 603 CEPIN
Latitude:	41.0259317
Longitude:	-73.7690486
DEC Memo:	FD did cleanup, hospital crew will have speedi-dri material disposed of. - NFA
Remarks:	Material was released from the elevator into the parking structure. Spill is contained. Absorbent material was applied unknown who is completing clean up.

All Materials:

Site ID:	400727
Operable Unit ID:	1157541
Operable Unit:	01
Material ID:	2148564
Material Code:	0010
Material Name:	hydraulic oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	25.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	WHITE PLAINS HOSPITAL
Address:	41 EAST POST RD
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	2003833 / 2020-09-01
Facility ID:	2003833
Facility Type:	ER
DER Facility ID:	350007
Site ID:	609568
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	A4
SWIS:	6017
Spill Date:	2020-08-06
Investigator:	BTRANSOM

WHITE PLAINS HOSPITAL CENTER (Continued) **S104284805**

Referred To:	Not reported
Reported to Dept:	2020-08-06
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Institutional, Educational, Gov., Other
Spill Notifier:	Other
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2020-08-06
Spill Record Last Update:	2020-09-01
Spiller Name:	Not reported
Spiller Company:	WHITE PLAINS HOSPITAL
Spiller Address:	41 EAST POST ROAD
Spiller Company:	999
Contact Name:	JIM INGERSOLL
Latitude:	Not reported
Longitude:	Not reported
DEC Memo:	8/6/20 White Plains Hospital, PBS #3-177148. A 20k-gal #6 Fuel Oil UST was previously closed-in-place in 2013 by Castlton. The hospital says it's Tank #1, but based on PBS record it looks like Tank #2. At the time of closure, a 18 dewatering well was installed and the tank was filled with K-Crete flowable fill. The Hospital is currently doing major construction and their engineering department opened the dewatering well manhole and observed product. There are two sumps within 20 ft and no impact observed in either sump. Bill Jacobson from Castlton is on-site now. They will mobilize a vac truck to remove product and water from the dewatering well, but the Hospital needs to move a lot of equipment first to make room for the vac truck and it might not be accessible until tomorrow. Tank could not be removed because it is beneath foundations of a 5-story and a 6-story building. JG 08-24-20 Rec'd closure report from Castlton. BTR 08-27-20 Closure report reviewed. Castlton removed approximately 2,200 gallons of petroleum and water mixture from the recovery well. The last round of sampling on 08/17 indicated there were no detections of VOCs in the recovery well. Oil absorbing snares were placed in the recovery well and were removed at the end of the project for disposal. A nearby monitoring well MW-4 was tested and at no point during the project were VOCs detected. NFA. BTR
Remarks:	Contained to put...cleanup pending

All Materials:

Site ID:	609568
Operable Unit ID:	1356720
Operable Unit:	01
Material ID:	2368041
Material Code:	0001A

WHITE PLAINS HOSPITAL CENTER (Continued) **S104284805**

Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	5.00
Units:	G
Recovered:	Not reported
Resource Affected:	Not reported
Oxygenate:	Not reported

NY MANIFEST:

EPA ID:	NYR000129965
Country:	USA
Name:	White Plains Hospital Center
Address:	41 POST RD
Address 2:	Not reported
City,State,Zip:	WHITE PLAINS, NY 10601
Zip 4:	Not reported
Location Address 1:	41 E. POST ROAD
Location Address 2:	Not reported
Location City,State,Zip:	WHITE PLAINS, NY 10601
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	White Plains Hospital Center
Mailing Contact:	Lisa Silver
Mailing Address 1:	41 POST ROAD
Mailing Address 2:	Not reported
Mailing City,State,Zip:	WHITE PLAINS, NY 10601
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	9146810600

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	MAD985286988
Year:	2018
Trans2 State ID:	TXR000050930
Generator Ship Date:	06/30/2008
Trans1 Recv Date:	06/30/2008
Trans2 Recv Date:	07/10/2008
TSD Site Recv Date:	07/10/2008
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000129965
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002182897
TSDF ID 2:	Not reported
Manifest Tracking Number:	003748817JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N

WHITE PLAINS HOSPITAL CENTER (Continued) **S104284805**

Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H061
Waste Code a:	Ignitable Waste
Waste Code b:	The Following Spent Nonhalogenated Solvents: Xylene, Acetone, Ethyl Acetate, Ethyl Benzene, Ethyl Ether, Methyl Isobutyl Ketone, N-Butyl Alcohol, Cyclohexanone, And Methanol; All Spent Solvent Mixtures/Blends Containing, Before Use, Only The Above Spent Nonhalogenated Solvents; And All Spent Solvent Mixtures/Blends Containing, Before Use, One Or More Of The Above Nonhalogenated Solvents, And A Total Of Ten Percent Or More (By Volume) Of One Or More Of Those Solvents Listed In F001, F002, F004, And F005; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent Mixtures.
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	360
Units:	Pounds
Number of Containers:	8
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	1
Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	MAD039322250
Year:	2018
Trans2 State ID:	MAD039322250
Generator Ship Date:	12/09/2011
Trans1 Recv Date:	12/09/2011
Trans2 Recv Date:	12/09/2011
TSD Site Recv Date:	12/22/2011
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000129965
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	OHD000816629
TSDF ID 2:	Not reported
Manifest Tracking Number:	004782899FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N

WHITE PLAINS HOSPITAL CENTER (Continued) **S104284805**

Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H141
Waste Code a:	Ignitable Waste
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	10
Units:	Gallons (liquids only)
Number of Containers:	2
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	1

Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	MAD039322250
Year:	2018
Trans2 State ID:	MAD039322250
Generator Ship Date:	12/09/2011
Trans1 Recv Date:	12/09/2011
Trans2 Recv Date:	12/09/2011
TSD Site Recv Date:	12/23/2011
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000129965
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	OHD980587364
TSDF ID 2:	Not reported
Manifest Tracking Number:	004782900FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H141
Waste Code a:	Ignitable Waste
Waste Code b:	The Following Spent Nonhalogenated Solvents: Xylene, Acetone, Ethyl Acetate, Ethyl Benzene, Ethyl Ether, Methyl Isobutyl Ketone, N-Butyl

WHITE PLAINS HOSPITAL CENTER (Continued) **S104284805**

Alcohol, Cyclohexanone, And Methanol; All Spent Solvent Mixtures/Blends Containing, Before Use, Only The Above Spent Nonhalogenated Solvents; And All Spent Solvent Mixtures/Blends Containing, Before Use, One Or More Of The Above Nonhalogenated Solvents, And A Total Of Ten Percent Or More (By Volume) Of One Or More Of Those Solvents Listed In F001, F002, F004, And F005; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent Mixtures.

Waste Code c: Not reported
Waste Code e: Not reported
Waste Code f: Not reported
Waste Code g: Not reported
Waste Code 1: Not reported
Waste Code 2: Not reported
Waste Code 3: Not reported
Waste Code 4: Not reported
Waste Code 5: Not reported
Waste Code 6: Not reported
Quantity: 30
Units: Gallons (liquids only)
Number of Containers: 6
Container Type: Fiberboard or plastic drums, barrels, kegs
Handling Method: Burn
Specific Gravity: 1

Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: MAD039322250
Year: 2018
Trans2 State ID: MAD039322250
Generator Ship Date: 08/13/2010
Trans1 Recv Date: 08/13/2010
Trans2 Recv Date: 08/13/2010
TSD Site Recv Date: 08/18/2010
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYR000129965
Trans1 EPA ID: Not reported
Trans2 EPA ID: Not reported
TSDF ID 1: OHD000816629
TSDF ID 2: Not reported
Manifest Tracking Number: 003031958FLE
Import Indicator: N
Export Indicator: N
Discr Quantity Indicator: N
Discr Type Indicator: N
Discr Residue Indicator: N
Discr Partial Reject Indicator: N
Discr Full Reject Indicator: N
Manifest Ref Number: Not reported
Alt Facility RCRA ID: Not reported
Alt Facility Sign Date: Not reported
MGMT Method Type Code: H141
Waste Code a: Ignitable Waste
Waste Code b: Not reported
Waste Code c: Not reported
Waste Code e: Not reported

WHITE PLAINS HOSPITAL CENTER (Continued) **S104284805**

Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	25
Units:	Gallons (liquids only)
Number of Containers:	5
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	1
Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	MAD039322250
Year:	2018
Trans2 State ID:	MAD039322250
Generator Ship Date:	08/13/2010
Trans1 Recv Date:	08/13/2010
Trans2 Recv Date:	08/13/2010
TSD Site Recv Date:	08/18/2010
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000129965
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	OHD000816629
TSDF ID 2:	Not reported
Manifest Tracking Number:	003031958FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H141
Waste Code a:	Ignitable Waste
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	15
Units:	Gallons (liquids only)

WHITE PLAINS HOSPITAL CENTER (Continued) **S104284805**

Number of Containers:	3
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	1
Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	MAD039322250
Year:	2018
Trans2 State ID:	MAD039322250
Generator Ship Date:	08/13/2010
Trans1 Recv Date:	08/13/2010
Trans2 Recv Date:	08/13/2010
TSD Site Recv Date:	08/18/2010
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000129965
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	OHD000816629
TSDF ID 2:	Not reported
Manifest Tracking Number:	003031958FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H141
Waste Code a:	Ignitable Waste
Waste Code b:	Silver
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	5
Units:	Gallons (liquids only)
Number of Containers:	1
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Treat
Specific Gravity:	1
Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	MAD985286988
Year:	2018
Trans2 State ID:	Not reported

WHITE PLAINS HOSPITAL CENTER (Continued) **S104284805**

Generator Ship Date:	08/01/2007
Trans1 Recv Date:	08/01/2007
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	08/02/2007
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000129965
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NYD077444263
TSDF ID 2:	Not reported
Manifest Tracking Number:	002070293JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H141
Waste Code a:	Ignitable Waste
Waste Code b:	The Following Spent Nonhalogenated Solvents: Xylene, Acetone, Ethyl Acetate, Ethyl Benzene, Ethyl Ether, Methyl Isobutyl Ketone, N-Butyl Alcohol, Cyclohexanone, And Methanol; All Spent Solvent Mixtures/Blends Containing, Before Use, Only The Above Spent Nonhalogenated Solvents; And All Spent Solvent Mixtures/Blends Containing, Before Use, One Or More Of The Above Nonhalogenated Solvents, And A Total Of Ten Percent Or More (By Volume) Of One Or More Of Those Solvents Listed In F001, F002, F004, And F005; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent Mixtures.
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	120
Units:	Pounds
Number of Containers:	3
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	1
Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	MAD039322250
Year:	2018
Trans2 State ID:	ALD067138891
Generator Ship Date:	03/26/2014

WHITE PLAINS HOSPITAL CENTER (Continued) **S104284805**

Trans1 Recv Date:	03/26/2014
Trans2 Recv Date:	04/04/2014
TSD Site Recv Date:	04/14/2014
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000129965
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NCD000648451
TSDF ID 2:	Not reported
Manifest Tracking Number:	007094914FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H141
Waste Code a:	Ignitable Waste
Waste Code b:	The Following Spent Nonhalogenated Solvents: Xylene, Acetone, Ethyl Acetate, Ethyl Benzene, Ethyl Ether, Methyl Isobutyl Ketone, N-Butyl Alcohol, Cyclohexanone, And Methanol; All Spent Solvent Mixtures/Blends Containing, Before Use, Only The Above Spent Nonhalogenated Solvents; And All Spent Solvent Mixtures/Blends Containing, Before Use, One Or More Of The Above Nonhalogenated Solvents, And A Total Of Ten Percent Or More (By Volume) Of One Or More Of Those Solvents Listed In F001, F002, F004, And F005; And Still Bottoms From The Recovery Of These Spent Solvents And Spent Solvent Mixtures.
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	315
Units:	Pounds
Number of Containers:	7
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	1
Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	MAD039322250
Year:	2018
Trans2 State ID:	ALD067138891
Generator Ship Date:	03/26/2014
Trans1 Recv Date:	03/26/2014

WHITE PLAINS HOSPITAL CENTER (Continued) **S104284805**

Trans2 Recv Date:	04/04/2014
TSD Site Recv Date:	04/14/2014
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000129965
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NCD000648451
TSDF ID 2:	Not reported
Manifest Tracking Number:	007094914FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H141
Waste Code a:	1,2-Dichloroethane
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	1
Units:	Pounds
Number of Containers:	1
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Burn
Specific Gravity:	1
Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	MAD039322250
Year:	2018
Trans2 State ID:	ALD067138891
Generator Ship Date:	03/26/2014
Trans1 Recv Date:	03/26/2014
Trans2 Recv Date:	04/04/2014
TSD Site Recv Date:	04/14/2014
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000129965
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NCD000648451
TSDF ID 2:	Not reported
Manifest Tracking Number:	007094914FLE

WHITE PLAINS HOSPITAL CENTER (Continued) **S104284805**

Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H141
Waste Code a:	Corrosive Waste
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	1
Units:	Pounds
Number of Containers:	1
Container Type:	Fiberboard or plastic drums, barrels, kegs
Handling Method:	Treat
Specific Gravity:	1
Document ID:	Not reported
Manifest Status:	Not reported
Trans1 State ID:	MAD985286988
Year:	2018
Trans2 State ID:	NYD982792814
Generator Ship Date:	11/10/2011
Trans1 Recv Date:	11/10/2011
Trans2 Recv Date:	11/16/2011
TSD Site Recv Date:	11/18/2011
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYR000129965
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	OHD048415665
TSDF ID 2:	Not reported
Manifest Tracking Number:	004163342FLE
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported

WHITE PLAINS HOSPITAL CENTER (Continued) **S104284805**

MGMT Method Type Code:	H040
Waste Code a:	Ignitable Waste
Waste Code b:	Barium
Waste Code c:	Mercury
Waste Code e:	Selenium
Waste Code f:	Silver
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	15
Units:	Pounds
Number of Containers:	1
Container Type:	Fiber or plastic boxes, cartons, cases
Handling Method:	Burn
Specific Gravity:	1

Click this hyperlink while viewing on your computer to access
327 additional NY MANIFEST: record(s) in the EDR Site Report.

AZ419 **WHITE PLAINS HOSPITAL** **NY LTANKS** **S104513751**
South **41 EAST POST ROAD** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.341 mi.
1801 ft. **Site 5 of 6 in cluster AZ**

Relative:
Higher

Actual:
214 ft.

LTANKS:

Name:	WHITE PLAINS HOSPITAL
Address:	41 EAST POST ROAD
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9414693 / 1995-02-13
Facility ID:	9414693
Site ID:	68377
Spill Date:	1995-02-08
Spill Cause:	Tank Overfill
Spill Source:	Commercial/Industrial
Spill Class:	D4
Cleanup Ceased:	1995-02-13
SWIS:	6017
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1995-02-08
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Responsible Party
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2003-12-02
Spill Record Last Update:	2003-12-02
Spiller Name:	Not reported
Spiller Company:	HESS OIL

WHITE PLAINS HOSPITAL (Continued) **S104513751**

Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	65131
Latitude:	41.0263922
Longitude:	-73.7695566
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY
Remarks:	DRIVER WAS TOLD BY HOSPITAL ENGINEER TO OFF LOAD 6000 GALS. OF #6 FUEL OIL INTO TANK TANK IS SUPPOSED TO HOLD 20000 GALS TANK VENTED & SPILLED ABOUT 50 GAL CREW CLEANED UP

All Materials:

Site ID:	68377
Operable Unit ID:	1012229
Operable Unit:	01
Material ID:	373425
Material Code:	0003A
Material Name:	#6 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	50.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

BA420 **CON ED HOLE # TM 2514** **NY LTANKS S102155353**
East **MARTINE AVE WEST OF BDWAY** **NY Spills N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.342 mi.
1805 ft. **Site 1 of 3 in cluster BA**

Relative:
Higher

Actual:
219 ft.

LTANKS:

Name:	COUNTY OFFICE BLD
Address:	MARTINE AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8806957 / 1989-02-06
Facility ID:	8806957
Site ID:	172819
Spill Date:	1988-11-21
Spill Cause:	Tank Overfill
Spill Source:	Tank Truck
Spill Class:	C3
Cleanup Ceased:	1988-11-23
SWIS:	6017
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1988-11-21
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Fire Department
Last Inspection:	1988-11-21
Recommended Penalty:	False

CON ED HOLE # TM 2514 (Continued) **S102155353**

Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1989-01-03
Spill Record Last Update:	1996-01-02
Spiller Name:	Not reported
Spiller Company:	RAD OIL
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	145441
Latitude:	41.0321489
Longitude:	-73.7631970
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY
Remarks:	TANK OVERFILL

All Materials:

Site ID:	172819
Operable Unit ID:	923699
Operable Unit:	01
Material ID:	455302
Material Code:	0009
Material Name:	gasoline
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	200.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

SPILLS:

Name:	CON ED HOLE # TM 2514
Address:	MARTINE AVE WEST OF BDWAY
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9414918 / 1995-02-23
Facility ID:	9414918
Facility Type:	ER
DER Facility ID:	150830
Site ID:	179716
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	C3
SWIS:	6017
Spill Date:	1995-02-13
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1995-02-13
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Unknown
Spill Notifier:	Responsible Party

CON ED HOLE # TM 2514 (Continued) **S102155353**

Cleanup Ceased:	1995-02-23
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2003-12-02
Spill Record Last Update:	2003-12-02
Spiller Name:	Not reported
Spiller Company:	CON ED
Spiller Address:	Not reported
Spiller Company:	999
Contact Name:	Not reported
Latitude:	41.0321489
Longitude:	-73.7631970
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY
Remarks:	LEAK NOTICED DURING ROUTINE INSPECTION CON ED TO CLEAN UP

All Materials:

Site ID:	179716
Operable Unit ID:	1012341
Operable Unit:	01
Material ID:	373638
Material Code:	0017A
Material Name:	PCB oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	10.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

AV421 **N.Y. TELEPHONE** **NY LTANKS** **S104953708**
West **40 WASHINGTON AVE.** **NY AST** **N/A**
1/4-1/2 **GREENBURGH, NY** **NY Spills**
0.343 mi.
1812 ft. **Site 3 of 4 in cluster AV**

Relative:
Higher

Actual:
245 ft.

LTANKS:

Name:	N.Y. TELEPHONE
Address:	40 WASHINGTON AVE.
City,State,Zip:	GREENBURGH, NY
Spill Number/Closed Date:	9110542 / 1992-03-17
Facility ID:	9110542
Site ID:	329591
Spill Date:	1992-01-08
Spill Cause:	Tank Overfill
Spill Source:	Commercial/Industrial
Spill Class:	C3
Cleanup Ceased:	1992-01-16
SWIS:	6026
Investigator:	TAYLOR
Referred To:	Not reported
Reported to Dept:	1992-01-08
CID:	Not reported

N.Y. TELEPHONE (Continued) **S104953708**

Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	1992-01-16
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	True
Remediation Phase:	0
Date Entered In Computer:	1992-01-14
Spill Record Last Update:	1992-03-17
Spiller Name:	Not reported
Spiller Company:	SAME
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	265168
Latitude:	41.0325400
Longitude:	-73.7787280
DEC Memo:	Not reported
Remarks:	DISCOVERED WHILE PULLING U/G TANK

All Materials:

Site ID:	329591
Operable Unit ID:	960570
Operable Unit:	01
Material ID:	419067
Material Code:	0008
Material Name:	diesel
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	1.00
Units:	G
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

WESTCHESTER CO. AST:

Name:	VERIZON NEW YORK, INC. (NY96528)
Address:	40 WASHINGTON AVENUE
City,State,Zip:	GREENBURGH, NY 10603
PBS Number:	3-494607
Site Status:	Active
GDS Number:	3552600440
Operator Name:	Verizon New York Inc.
Owner Name:	Verizon New York, Inc.
Owner Street:	140 West Street
Owner Address2:	Not reported
Owner City/State/Zip:	New York, NY 10007
Tank Number:	7
Status:	1. In-Service
Date Installation:	06/01/1989
Capacity:	290
Product Stored:	0022. Waste/Used Oil

N.Y. TELEPHONE (Continued) **S104953708**

Product Stored Percent:	Not reported
Date Perm Closure:	01/01/1900
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Leak Detection:	6. Impervious Barrier/Concrete Pad (Aboveground Only)
Tank Secondary Containment:	1. Diking (aboveground only),9. Modified double-walled (aboveground only)
Piping Location:	1. Aboveground
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	0. None
Piping Leak Detection:	0. None
Piping Secondary Containment:	0. None
Overfill Prevention:	4. Product Level Gauge (Aboveground Only)
Spill Prevention:	1. Catch Basin
Dispenser:	0. None

Tank Number:	9
Status:	1. In-Service
Date Installation:	02/01/2004
Capacity:	275
Product Stored:	0015. Motor Oil
Product Stored Percent:	Not reported
Date Perm Closure:	01/01/1900
Tank Location:	3. Aboveground on saddles,legs,stilts,racks or cradle
Tank Type:	1. Steel/Carbon steel/Iron
Tank Internal Protection:	0. None
Tank External Protection:	1. Painted/Asphalt Coating
Tank Leak Detection:	6. Impervious Barrier/Concrete Pad (Aboveground Only)
Tank Secondary Containment:	9. Modified double-walled (aboveground only)
Piping Location:	1. Aboveground
Piping Type:	1. Steel/Carbon/ Steel/Iron
Piping External Protection:	0. None
Piping Leak Detection:	0. None
Piping Secondary Containment:	0. None
Overfill Prevention:	4. Product Level Gauge (Aboveground Only),5. Vent Whistle
Spill Prevention:	1. Catch Basin
Dispenser:	2. Suction

SPILLS:

Name:	NYNEX
Address:	40 WASHINGTON AVENUE
City,State,Zip:	GREENBURGH, NY
Spill Number/Closed Date:	9512282 / 1996-01-02
Facility ID:	9512282
Facility Type:	ER
DER Facility ID:	140314
Site ID:	166534
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	B4
SWIS:	6000
Spill Date:	1995-12-31
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1995-12-31

N.Y. TELEPHONE (Continued) **S104953708**

CID:	204
Water Affected:	Not reported
Spill Source:	Tank Truck
Spill Notifier:	Other
Cleanup Ceased:	1996-01-02
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	1995-12-31
Spill Record Last Update:	1996-01-16
Spiller Name:	CHRIS?
Spiller Company:	NYNEX
Spiller Address:	40 WASHINGTON AVENUE
Spiller Company:	001
Contact Name:	CHRIS ?
Latitude:	41.0325400
Longitude:	-73.7787280
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY 1/2/96 NYNEX REPORTED THAT CLEAN UP WAS COMPLETE
Remarks:	ALL THE PRODUCT WHEN INTO A SUMP HOLE WHICH WAS PUMPED OUT

All Materials:

Site ID:	166534
Operable Unit ID:	1023240
Operable Unit:	01
Material ID:	356035
Material Code:	0008
Material Name:	diesel
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	100.00
Units:	G
Recovered:	100.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	BELL ATLANTIC GARAGE SITE
Address:	40 WASHINGTON AVE
City,State,Zip:	GREENBURGH, NY
Spill Number/Closed Date:	9803352 / 2012-01-09
Facility ID:	9803352
Facility Type:	ER
DER Facility ID:	390498
Site ID:	66930
DEC Region:	3
Spill Cause:	Housekeeping
Spill Class:	B3
SWIS:	6026
Spill Date:	1998-06-16
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1998-06-16
CID:	365
Water Affected:	Not reported

N.Y. TELEPHONE (Continued) **S104953708**

Spill Source:	Commercial/Industrial
Spill Notifier:	Other
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	1998-06-16
Spill Record Last Update:	2012-01-09
Spiller Name:	DALE HOGAN
Spiller Company:	BELL ATLANTIC GARAGE SITE
Spiller Address:	WASHINGTON AV
Spiller Company:	001
Contact Name:	DALE HOGAN
Latitude:	40.9922717
Longitude:	-73.8824286
DEC Memo:	01/21/2000 JUDITH GARDNER FROM S&W SERVICES INC. SUBMITTED A PROPOSAL FOR A GEO PROBLE SURVEY. PROPOSAL APPROVED. 8/3/10 Need Status Update JO'M 1/9/12: Refer to Spill 1002458. See email in EDocs for further info. jod
Remarks:	IN GARAGE AREA OF BLDG THERE IS AN ACCUMULATION OVER THE YEARS OF WASTE WATER & OILS - THEY DUG UP THE CONTAMINATION & SENT IT OUT FOR SAMPLES CONTACT EITHER GREG MYKA OR LUKE MACKENEY AT CALLERS PHONE # SINCE HE IS OUT IN THE FIELD

All Materials:

Site ID:	66930
Operable Unit ID:	1061266
Operable Unit:	01
Material ID:	321665
Material Code:	9999
Material Name:	other -
Case No.:	Not reported
Material FA:	Other
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Site ID:	66930
Operable Unit ID:	1061266
Operable Unit:	01
Material ID:	321666
Material Code:	0060A
Material Name:	wastewater
Case No.:	Not reported
Material FA:	Other
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	VERIZON

N.Y. TELEPHONE (Continued) **S104953708**

Address:	40 WASHINGTON AVE
City,State,Zip:	GREENBURGH, NY
Spill Number/Closed Date:	0013045 / 2001-03-13
Facility ID:	0013045
Facility Type:	ER
DER Facility ID:	283751
Site ID:	60527
DEC Region:	3
Spill Cause:	Unknown
Spill Class:	C4
SWIS:	6000
Spill Date:	2001-03-13
Investigator:	DVWEHRFR
Referred To:	Not reported
Reported to Dept:	2001-03-13
CID:	396
Water Affected:	Not reported
Spill Source:	Unknown
Spill Notifier:	Federal Government
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2001-03-13
Spill Record Last Update:	2001-03-14
Spiller Name:	SAME
Spiller Company:	SAME
Spiller Address:	Not reported
Spiller Company:	001
Contact Name:	JEFF BECHTEL
Latitude:	41.0470370
Longitude:	-73.7989990
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was WEHRFRITZ
Remarks:	Not reported

All Materials:

Site ID:	60527
Operable Unit ID:	834579
Operable Unit:	01
Material ID:	539774
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	NYNEX GARAGE
Address:	40 WASHINGTON AVE
City,State,Zip:	GREENBURGH, NY
Spill Number/Closed Date:	9613870 / 1998-12-11

N.Y. TELEPHONE (Continued) **S104953708**

Facility ID:	9613870
Facility Type:	ER
DER Facility ID:	283751
Site ID:	60529
DEC Region:	3
Spill Cause:	Unknown
Spill Class:	C4
SWIS:	6000
Spill Date:	1997-02-26
Investigator:	WCHD
Referred To:	Westchester Cnty Health Dept
Reported to Dept:	1997-02-26
CID:	370
Water Affected:	Not reported
Spill Source:	Unknown
Spill Notifier:	Citizen
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	1997-02-26
Spill Record Last Update:	1999-01-26
Spiller Name:	Not reported
Spiller Company:	NYNEX GARAGE
Spiller Address:	40 WASHINGTON AVE
Spiller Company:	001
Contact Name:	Not reported
Latitude:	41.0325400
Longitude:	-73.7787280
DEC Memo:	Not reported
Remarks:	GARAGE WORKING ON VEH CAUSING SPILL ANTIFREEZE IN BARRELS LEAKING OIL BARRELS LEAKING OLD BATTERIES LEAKING GARAGE LEAVES THESE ITEMS TO LEAK AND DOESN'T CLEAN UP. ONCE IN A WHILE THEY HOSE IT INTO THE STORM DRAIN. 12/11/98 NO FURTHER ACTION.

All Materials:

Site ID:	60529
Operable Unit ID:	1041447
Operable Unit:	01
Material ID:	338969
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Site ID:	60529
Operable Unit ID:	1041447
Operable Unit:	01
Material ID:	338970
Material Code:	0010
Material Name:	hydraulic oil

N.Y. TELEPHONE (Continued) **S104953708**

Case No.: Not reported
Material FA: Petroleum
Quantity: .00
Units: G
Recovered: .00
Resource Affected: Soil
Oxygenate: Not reported

Site ID: 60529
Operable Unit ID: 1041447
Operable Unit: 01
Material ID: 338971
Material Code: 0043A
Material Name: antifreeze
Case No.: Not reported
Material FA: Other
Quantity: .00
Units: G
Recovered: .00
Resource Affected: Soil
Oxygenate: Not reported

Site ID: 60529
Operable Unit ID: 1041447
Operable Unit: 01
Material ID: 338972
Material Code: 0044A
Material Name: battery acid
Case No.: Not reported
Material FA: Other
Quantity: .00
Units: G
Recovered: .00
Resource Affected: Soil
Oxygenate: Not reported

Name: VERIZON
Address: 40 WASHINGTON AVE
City,State,Zip: GREENBURGH, NY
Spill Number/Closed Date: 0013592 / 2001-03-28
Facility ID: 0013592
Facility Type: ER
DER Facility ID: 390498
Site ID: 158759
DEC Region: 3
Spill Cause: Equipment Failure
Spill Class: C4
SWIS: 6026
Spill Date: 2001-03-28
Investigator: TDGHIOSA
Referred To: Not reported
Reported to Dept: 2001-03-28
CID: 405
Water Affected: Not reported
Spill Source: Passenger Vehicle
Spill Notifier: Local Agency

N.Y. TELEPHONE (Continued) **S104953708**

Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2001-03-28
Spill Record Last Update:	2012-01-09
Spiller Name:	NEIL TOMASETTI
Spiller Company:	VERIZON
Spiller Address:	40 WASHINGTON AV
Spiller Company:	001
Contact Name:	NEIL TOMASETTI
Latitude:	41.0470370
Longitude:	-73.7989990
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was BENDELL 03/28/2001 RDB SPOKE TO CHRIS DELO @ ENVIRONMENTAL PRODUCTS. THEY THOUGHT DRUM FELL OVER, BUT ACTUALLY CAR LEAKED OIL INTO STORM DRAIN. CONTAINED. ENV. PRODUCTS CHECKED. DOESN'T LOOK LIKE ANY IMPACT. NO FURTHER ACTION.
Remarks:	has gone into storm drains / lining storm drain with absorbant materials/ clean up in progress

All Materials:

Site ID:	158759
Operable Unit ID:	835076
Operable Unit:	01
Material ID:	540301
Material Code:	0015
Material Name:	motor oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	5.00
Units:	G
Recovered:	5.00
Resource Affected:	Sewer
Oxygenate:	Not reported

Name:	BELL ATLANTIC
Address:	40 WASHINGTON AVE
City,State,Zip:	GREENBURGH, NY
Spill Number/Closed Date:	9710201 / 1997-12-04
Facility ID:	9710201
Facility Type:	ER
DER Facility ID:	390498
Site ID:	158760
DEC Region:	3
Spill Cause:	Human Error
Spill Class:	C4
SWIS:	6026
Spill Date:	1997-12-04
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1997-12-04
CID:	211
Water Affected:	Not reported

N.Y. TELEPHONE (Continued) **S104953708**

Spill Source:	Commercial/Industrial
Spill Notifier:	Other
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	1997-12-04
Spill Record Last Update:	2012-01-09
Spiller Name:	CALVIN ARMSTRONG
Spiller Company:	BELL ATLANTIC
Spiller Address:	40 WASHINGTON AV
Spiller Company:	001
Contact Name:	CALVIN ARMSTRONG
Latitude:	41.0325400
Longitude:	-73.7787280
DEC Memo:	Not reported
Remarks:	CALLER REPORTS EMPLOYEE WAS FUELING VEHICLE AND HELD OPEN NOZZLE TOO LONG CAUSING SPILL - SPILL HAS BEEN CLEANED UP

All Materials:

Site ID:	158760
Operable Unit ID:	1056593
Operable Unit:	01
Material ID:	328510
Material Code:	0008
Material Name:	diesel
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	10.00
Units:	G
Recovered:	10.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	NY TEL
Address:	40 WASHINGTON AVE.
City,State,Zip:	GREENBURGH, NY
Spill Number/Closed Date:	9308507 / 2012-01-09
Facility ID:	9308507
Facility Type:	ER
DER Facility ID:	265168
Site ID:	329592
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	B3
SWIS:	6026
Spill Date:	1993-10-13
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1993-10-13
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Other
Cleanup Ceased:	Not reported

N.Y. TELEPHONE (Continued) **S104953708**

Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	1993-10-18
Spill Record Last Update:	2012-01-09
Spiller Name:	Not reported
Spiller Company:	Not reported
Spiller Address:	Not reported
Spiller Company:	001
Contact Name:	Not reported
Latitude:	41.0325400
Longitude:	-73.7787280
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY 01/21/2000 JUDITH GARDNER FROM S&W SERVICES SUBMITTED A PROPOSAL FOR A GEO PROBE SURVEY. PROPOSAL APPROVED. 3/24/10 TG will follow up JO'M 1/9/12: Refer to Spill 1002458. See email in EDocs for further info. jod
Remarks:	REMOVING OUTDATED EQUIPMENT AND FOUND CONTAMINATED SOIL PLAN TO EXCAVATE SOIL

All Materials:

Site ID:	329592
Operable Unit ID:	987163
Operable Unit:	01
Material ID:	394735
Material Code:	0066A
Material Name:	unknown petroleum
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	G
Recovered:	Not reported
Resource Affected:	Soil, Groundwater
Oxygenate:	Not reported

Name:	VERIZON GREENBURGH
Address:	40 WASHINGTON AVE
City,State,Zip:	GREENBURGH, NY
Spill Number/Closed Date:	1002458 / 2012-05-03
Facility ID:	1002458
Facility Type:	ER
DER Facility ID:	390498
Site ID:	435597
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	B3
SWIS:	6026
Spill Date:	2010-06-03
Investigator:	jbodee
Referred To:	Not reported
Reported to Dept:	2010-06-03
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Commercial/Industrial

N.Y. TELEPHONE (Continued) **S104953708**

Spill Notifier:	Other
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	2010-06-03
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2010-06-03
Spill Record Last Update:	2012-05-03
Spiller Name:	JAMIE MCELMANN
Spiller Company:	VERIZON
Spiller Address:	Not reported
Spiller Company:	999
Contact Name:	JEFF BOHLEN
Latitude:	40.3003630
Longitude:	-79.5563500
DEC Memo:	Spoke to Jeff at Envirotrac. Nearby MW has approx. one inch of product. WCHD was on site for removal. Cleanup is ongoing. Groundwater is shallow. DT 6/3/10 7/16/10 WCDOH Reviewed TCR. Site has groundwater contamination and will do quarterly monitoring. First report due 11/10. JO'M 1/19/11 as per WCDOH Sent letter 1/19/11 requiring quarterly groundwater monitoring. Results to be reviewed after one year. JO'M 3/18/11 First Quartly report received and reviewed continue monitoring. JO'M 1/5/12: Barbara McDonlad of WCDOH PBS requiring an additional one year of ground water monitoring. Letter dated 1-3-12 entered into eDocs. Email sent to Barbara McDonald, inquiring status of two additional open spill at the same location. jod 4/30/12: Barbara McDonald forwarded me the most recent set of ground water sampling data. We then discussed the sampling history. jod 5/3/12: Barbara McDonald recommending no further action. I had recommended the same to her. DEC requires no further action at this time. jod
Remarks:	5000gal ust/tank is currently being removed

All Materials:

Site ID:	435597
Operable Unit ID:	1186352
Operable Unit:	01
Material ID:	2181146
Material Code:	0008
Material Name:	diesel
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	G
Recovered:	Not reported
Resource Affected:	Soil, Groundwater
Oxygenate:	Not reported

AV422 **N.Y. TELEPHONE** **UST FINDER RELEASE** **1029069889**
West **40 WASHINGTON AVE.** **N/A**
1/4-1/2 **GREENBURGH, NY 0**
0.343 mi.
1812 ft. **Site 4 of 4 in cluster AV**

Relative: **Higher**
Actual: **245 ft.**

UST FINDER RELEASE:

Object ID:	262114
Facility ID:	NY265168
Lust ID:	NY9110542
Name:	N.Y. TELEPHONE
Address:	40 WASHINGTON AVE.
City,State,Zip:	GREENBURGH, NY 0
Address Match Type:	Not reported
Reported Date:	1992/01/08 15:59:59+00
Status:	No Further Action
Substance:	Not reported
Population within 1500ft:	3384
Domestic Wells within 1500ft:	0
Land Use:	Developed, Low Intensity
Within SPA:	Yes
SPA PWS Facility ID:	NY7003493_76968
SPA Water Type:	SW - SurRELEASEe Water
SPA Facility Type:	RS - Reservoir
SPA HUC12:	20301020103
Within WHPA:	No
WHPA PWS Facility ID:	Not reported
WHPA Water Type:	Not reported
WHPA Facility Type:	Not reported
WHPA HUC12:	Not reported
Within 100yr Floodplain:	No
Tribe:	Not reported
EPA Region:	2
NFA Letter 1:	Not reported
NFA Letter 2:	Not reported
NFA Letter 3:	Not reported
NFA Letter 4:	Not reported
Closed With Residual Contaminate:	Not reported
Coordinate Source:	State
X Coord:	-73.7787299999999
Y Coord:	41.03254
Latitude:	41.0325399999999
Longitude:	-73.7787299999999

BB423 **AUTOMOBILE CLUB OF NEW YORK** **NY SHWS** **S105057848**
SW **101 WESTMORELAND AVENUE** **NY ENG CONTROLS** **N/A**
1/4-1/2 **WHITE PLAINS, NY 10606** **NY INST CONTROL**
0.352 mi. **NY Spills**
1856 ft. **Site 1 of 2 in cluster BB**

Relative: **Higher**
Actual: **205 ft.**

SHWS:

Name:	AUTOMOBILE CLUB OF NEW YORK
Address:	101 WESTMORELAND AVENUE
City,State,Zip:	WHITE PLAINS, NY 10606
Program:	HW
Site Code:	374633
Classification:	C
Region:	3
Acres:	0.200
HW Code:	360095

AUTOMOBILE CLUB OF NEW YORK (Continued) **S105057848**

Record Add: 12/08/2006
Record Upd: 03/20/2023
Updated By: AMOMOROG
Site Description: Location: The Automobile Club of New York site is located on the northwest side of Westmoreland Avenue, approximately 100 feet west of the intersection of Westmoreland Avenue and Home Place in the City of White Plains. The site is approximately 0.2 acres Site Features: The site is essentially flat and includes a one-story, concrete block, L-shaped occupied building that covers approximately 75 percent of the site. The northeastern portion of the property is covered with an asphalt parking area, while the western portion of the site contains a gravel parking area. The Bronx River is located approximately 700 feet to the northwest of the site. Current Zoning and Land Use: The site is zoned light industrial and is currently used as an AAA of NY auto-repair shop, which utilizes the building for auto repairs and exterior detailing. Past Use of the Site: A former on-site dry well and former fuel and waste oil underground storage tanks (USTs) appear to be the sources of on-site contamination. There also appears to be an off-site source of 1,1,1 TCA entering the property from the east. Site Geology and Hydrogeology: The site consists of approximately 2 feet of fill, represented by dark gray to black fine coarse sand and gravel with fragments of coal, underlined by light gray to yellow-brown, well sorted fine-medium sand to a depth of 40 feet below grade. Groundwater depth at the site ranges from approximately 25 to 29 feet below grade. Groundwater flows to the north-northwest.
Env Problem: Nature and Extent of Contamination: Remediation at the site is complete. The primary contaminants of concern include Tetrachloroethene (PCE) and related daughter products and residual petroleum contamination in shallow site soils, groundwater and/or soil vapor. An unknown off-site source of 1,1,1 TCA is also impacting site groundwater. Residual contamination in the soil, groundwater and soil vapor are being managed under a Site Management Plan.
Health Problem: Since some contaminated soils remain at the site below the building foundation or pavement, people will not come in contact with contaminated soils unless they dig below the surface materials. Contaminated groundwater in the area is not used for drinking or other purposes and the site is served by a public water supply. Volatile organic compounds in the groundwater may move into the soil vapor (air spaces within the soil), which in turn may move into overlying buildings and affect the indoor air quality. This process, which is similar to the movement of radon gas from the subsurface into the indoor air of buildings, is referred to as soil vapor intrusion. If the site is redeveloped, the need to take measures to prevent soil vapor intrusion will be re-evaluated. There are no off-site soil vapor concerns associated with this site. However, there is the potential for soil vapor intrusion concerns in off-site buildings due to the presence of off-site contamination not related to this site.
Dump: Not reported
Structure: Not reported
Lagoon: Not reported
Landfill: Not reported
Pond: Not reported
Disp Start: Not reported
Disp Term: Not reported
Lat/Long: Not reported
Dell: Not reported

AUTOMOBILE CLUB OF NEW YORK (Continued) **S105057848**

Record Add:	Not reported
Record Upd:	Not reported
Updated By:	Not reported
Own Op:	1
Sub Type:	NNN
Owner Name:	James Clifford
Owner Company:	Automobile Club of New York, Inc. (AAA)
Owner Address:	110 Royal Little Drive
Owner Addr2:	Not reported
Owner City,St,Zip:	Providence, RI 02904
Owner Country:	United States of America
Own Op:	4
Sub Type:	NNN
Owner Name:	RJT MOROTIST SERVICES
Owner Company:	RJT MOROTIST SERVICES
Owner Address:	101 WESTMORELAND AVENUE
Owner Addr2:	Not reported
Owner City,St,Zip:	WHITE PLAINS, NY 10606
Owner Country:	United States of America
Own Op:	6
Sub Type:	01
Owner Name:	James Clifford
Owner Company:	Automobile Club of New York
Owner Address:	110 Royal Little Drive
Owner Addr2:	Not reported
Owner City,St,Zip:	Providence, NY 02904
Owner Country:	United States of America
Own Op:	4
Sub Type:	02
Owner Name:	James Clifford
Owner Company:	Automobile Club of New York
Owner Address:	110 Royal Little Drive
Owner Addr2:	Not reported
Owner City,St,Zip:	Providence, NY 02904
Owner Country:	United States of America
HW Code:	Not reported
Waste Type:	Not reported
Waste Quantity:	Not reported
Waste Code:	Not reported
Crossref ID:	D3-0504-06-09
Cross Ref Type Code:	23
Cross Ref Type:	Agreement/Consent Order Number
Record Added Date:	2015-05-04 15:12:00
Record Updated:	2015-05-04 15:12:00
Updated By:	JLVERRIG
Crossref ID:	563023198
Cross Ref Type Code:	25
Cross Ref Type:	County Recording Identifier
Record Added Date:	2017-07-14 08:08:00
Record Updated:	2017-07-14 08:08:00
Updated By:	JLVERRIG

ENG CONTROLS:

Name:	AUTOMOBILE CLUB OF NEW YORK
Address:	101 WESTMORELAND AVENUE
City,State,Zip:	WHITE PLAINS, NY 10606
Site Code:	374633

AUTOMOBILE CLUB OF NEW YORK (Continued) **S105057848**

HW Code:	360095
Control Code:	35
Control Type:	ENG
Date Record Added:	10/15/2015
Date Rec Updated:	01/16/2024
Updated By:	RWRICHAR
Site Description:	Location: The Automobile Club of New York site is located on the northwest side of Westmoreland Avenue, approximately 100 feet west of the intersection of Westmoreland Avenue and Home Place in the City of White Plains. The site is approximately 0.2 acres Site Features: The site is essentially flat and includes a one-story, concrete block, L-shaped occupied building that covers approximately 75 percent of the site. The northeastern portion of the property is covered with an asphalt parking area, while the western portion of the site contains a gravel parking area. The Bronx River is located approximately 700 feet to the northwest of the site. Current Zoning and Land Use: The site is zoned light industrial and is currently used as an AAA of NY auto-repair shop, which utilizes the building for auto repairs and exterior detailing. Past Use of the Site: A former on-site dry well and former fuel and waste oil underground storage tanks (USTs) appear to be the sources of on-site contamination. There also appears to be an off-site source of 1,1,1 TCA entering the property from the east. Site Geology and Hydrogeology: The site consists of approximately 2 feet of fill, represented by dark gray to black fine coarse sand and gravel with fragments of coal, underlined by light gray to yellow-brown, well sorted fine-medium sand to a depth of 40 feet below grade. Groundwater depth at the site ranges from approximately 25 to 29 feet below grade. Groundwater flows to the north-northwest.
Env Problem:	Nature and Extent of Contamination: Remediation at the site is complete. The primary contaminants of concern include Tetrachloroethene (PCE) and related daughter products and residual petroleum contamination in shallow site soils, groundwater and/or soil vapor. An unknown off-site source of 1,1,1 TCA is also impacting site groundwater. Residual contamination in the soil, groundwater and soil vapor are being managed under a Site Management Plan.
Health Problem:	Since some contaminated soils remain at the site below the building foundation or pavement, people will not come in contact with contaminated soils unless they dig below the surface materials. Contaminated groundwater in the area is not used for drinking or other purposes and the site is served by a public water supply. Volatile organic compounds in the groundwater may move into the soil vapor (air spaces within the soil), which in turn may move into overlying buildings and affect the indoor air quality. This process, which is similar to the movement of radon gas from the subsurface into the indoor air of buildings, is referred to as soil vapor intrusion. If the site is redeveloped, the need to take measures to prevent soil vapor intrusion will be re-evaluated. There are no off-site soil vapor concerns associated with this site. However, there is the potential for soil vapor intrusion concerns in off-site buildings due to the presence of off-site contamination not related to this site.
Dump:	Not reported
Structure:	Not reported
Lagoon:	Not reported
Landfill:	Not reported
Pond:	Not reported
Disp Start:	Not reported

AUTOMOBILE CLUB OF NEW YORK (Continued) **S105057848**

Disp Term:	Not reported
Lat/Long:	Not reported
Dell:	Not reported
Record Add:	Not reported
Record Upd:	Not reported
Updated By:	Not reported
Own Op:	1
Sub Type:	NNN
Owner Name:	James Clifford
Owner Company:	Automobile Club of New York, Inc. (AAA)
Owner Address:	110 Royal Little Drive
Owner Addr2:	Not reported
Owner City,St,Zip:	Providence, RI 02904
Owner Country:	United States of America
Own Op:	4
Sub Type:	NNN
Owner Name:	RJT MOROTIST SERVICES
Owner Company:	RJT MOROTIST SERVICES
Owner Address:	101 WESTMORELAND AVENUE
Owner Addr2:	Not reported
Owner City,St,Zip:	WHITE PLAINS, NY 10606
Owner Country:	United States of America
Own Op:	6
Sub Type:	01
Owner Name:	James Clifford
Owner Company:	Automobile Club of New York
Owner Address:	110 Royal Little Drive
Owner Addr2:	Not reported
Owner City,St,Zip:	Providence, NY 02904
Owner Country:	United States of America
Own Op:	4
Sub Type:	02
Owner Name:	James Clifford
Owner Company:	Automobile Club of New York
Owner Address:	110 Royal Little Drive
Owner Addr2:	Not reported
Owner City,St,Zip:	Providence, NY 02904
Owner Country:	United States of America
HW Code:	Not reported
Waste Type:	Not reported
Waste Quantity:	Not reported
Waste Code:	Not reported
Crossref ID:	D3-0504-06-09
Cross Ref Type Code:	23
Cross Ref Type:	Agreement/Consent Order Number
Record Added Date:	2015-05-04 15:12:00
Record Updated:	2015-05-04 15:12:00
Updated By:	JLVERRIG
Crossref ID:	563023198
Cross Ref Type Code:	25
Cross Ref Type:	County Recording Identifier
Record Added Date:	2017-07-14 08:08:00
Record Updated:	2017-07-14 08:08:00
Updated By:	JLVERRIG
Name:	AUTOMOBILE CLUB OF NEW YORK
Address:	101 WESTMORELAND AVENUE

AUTOMOBILE CLUB OF NEW YORK (Continued) **S105057848**

City,State,Zip:	WHITE PLAINS, NY 10606
Site Code:	374633
HW Code:	360095
Control Code:	15
Control Type:	ENG
Date Record Added:	10/15/2015
Date Rec Updated:	01/16/2024
Updated By:	RWRICHAR
Site Description:	Location: The Automobile Club of New York site is located on the northwest side of Westmoreland Avenue, approximately 100 feet west of the intersection of Westmoreland Avenue and Home Place in the City of White Plains. The site is approximately 0.2 acres Site Features: The site is essentially flat and includes a one-story, concrete block, L-shaped occupied building that covers approximately 75 percent of the site. The northeastern portion of the property is covered with an asphalt parking area, while the western portion of the site contains a gravel parking area. The Bronx River is located approximately 700 feet to the northwest of the site. Current Zoning and Land Use: The site is zoned light industrial and is currently used as an AAA of NY auto-repair shop, which utilizes the building for auto repairs and exterior detailing. Past Use of the Site: A former on-site dry well and former fuel and waste oil underground storage tanks (USTs) appear to be the sources of on-site contamination. There also appears to be an off-site source of 1,1,1 TCA entering the property from the east. Site Geology and Hydrogeology: The site consists of approximately 2 feet of fill, represented by dark gray to black fine coarse sand and gravel with fragments of coal, underlined by light gray to yellow-brown, well sorted fine-medium sand to a depth of 40 feet below grade. Groundwater depth at the site ranges from approximately 25 to 29 feet below grade. Groundwater flows to the north-northwest.
Env Problem:	Nature and Extent of Contamination: Remediation at the site is complete. The primary contaminants of concern include Tetrachloroethene (PCE) and related daughter products and residual petroleum contamination in shallow site soils, groundwater and/or soil vapor. An unknown off-site source of 1,1,1 TCA is also impacting site groundwater. Residual contamination in the soil, groundwater and soil vapor are being managed under a Site Management Plan.
Health Problem:	Since some contaminated soils remain at the site below the building foundation or pavement, people will not come in contact with contaminated soils unless they dig below the surface materials. Contaminated groundwater in the area is not used for drinking or other purposes and the site is served by a public water supply. Volatile organic compounds in the groundwater may move into the soil vapor (air spaces within the soil), which in turn may move into overlying buildings and affect the indoor air quality. This process, which is similar to the movement of radon gas from the subsurface into the indoor air of buildings, is referred to as soil vapor intrusion. If the site is redeveloped, the need to take measures to prevent soil vapor intrusion will be re-evaluated. There are no off-site soil vapor concerns associated with this site. However, there is the potential for soil vapor intrusion concerns in off-site buildings due to the presence of off-site contamination not related to this site.
Dump:	Not reported
Structure:	Not reported
Lagoon:	Not reported
Landfill:	Not reported

AUTOMOBILE CLUB OF NEW YORK (Continued) **S105057848**

Pond:	Not reported
Disp Start:	Not reported
Disp Term:	Not reported
Lat/Long:	Not reported
Dell:	Not reported
Record Add:	Not reported
Record Upd:	Not reported
Updated By:	Not reported
Own Op:	1
Sub Type:	NNN
Owner Name:	James Clifford
Owner Company:	Automobile Club of New York, Inc. (AAA)
Owner Address:	110 Royal Little Drive
Owner Addr2:	Not reported
Owner City,St,Zip:	Providence, RI 02904
Owner Country:	United States of America
Own Op:	4
Sub Type:	NNN
Owner Name:	RJT MOROTIST SERVICES
Owner Company:	RJT MOROTIST SERVICES
Owner Address:	101 WESTMORELAND AVENUE
Owner Addr2:	Not reported
Owner City,St,Zip:	WHITE PLAINS, NY 10606
Owner Country:	United States of America
Own Op:	6
Sub Type:	01
Owner Name:	James Clifford
Owner Company:	Automobile Club of New York
Owner Address:	110 Royal Little Drive
Owner Addr2:	Not reported
Owner City,St,Zip:	Providence, NY 02904
Owner Country:	United States of America
Own Op:	4
Sub Type:	02
Owner Name:	James Clifford
Owner Company:	Automobile Club of New York
Owner Address:	110 Royal Little Drive
Owner Addr2:	Not reported
Owner City,St,Zip:	Providence, NY 02904
Owner Country:	United States of America
HW Code:	Not reported
Waste Type:	Not reported
Waste Quantity:	Not reported
Waste Code:	Not reported
Crossref ID:	D3-0504-06-09
Cross Ref Type Code:	23
Cross Ref Type:	Agreement/Consent Order Number
Record Added Date:	2015-05-04 15:12:00
Record Updated:	2015-05-04 15:12:00
Updated By:	JLVERRIG
Crossref ID:	563023198
Cross Ref Type Code:	25
Cross Ref Type:	County Recording Identifier
Record Added Date:	2017-07-14 08:08:00
Record Updated:	2017-07-14 08:08:00
Updated By:	JLVERRIG

AUTOMOBILE CLUB OF NEW YORK (Continued) **S105057848**

INST CONTROL:

Name:	AUTOMOBILE CLUB OF NEW YORK
Address:	101 WESTMORELAND AVENUE
City,State,Zip:	WHITE PLAINS, NY 10606
Site Code:	374633
Control Name:	Monitoring Plan
HW Code:	360095
Control Code:	31
Control Type:	INST
Dt record added:	10/15/2015
Dt rec updated:	01/16/2024
Updated By:	RWRICHAR
Site Code:	374633
Site Description:	Location: The Automobile Club of New York site is located on the northwest side of Westmoreland Avenue, approximately 100 feet west of the intersection of Westmoreland Avenue and Home Place in the City of White Plains. The site is approximately 0.2 acres Site Features: The site is essentially flat and includes a one-story, concrete block, L-shaped occupied building that covers approximately 75 percent of the site. The northeastern portion of the property is covered with an asphalt parking area, while the western portion of the site contains a gravel parking area. The Bronx River is located approximately 700 feet to the northwest of the site. Current Zoning and Land Use: The site is zoned light industrial and is currently used as an AAA of NY auto-repair shop, which utilizes the building for auto repairs and exterior detailing. Past Use of the Site: A former on-site dry well and former fuel and waste oil underground storage tanks (USTs) appear to be the sources of on-site contamination. There also appears to be an off-site source of 1,1,1 TCA entering the property from the east. Site Geology and Hydrogeology: The site consists of approximately 2 feet of fill, represented by dark gray to black fine coarse sand and gravel with fragments of coal, underlined by light gray to yellow-brown, well sorted fine-medium sand to a depth of 40 feet below grade. Groundwater depth at the site ranges from approximately 25 to 29 feet below grade. Groundwater flows to the north-northwest.
Env Problem:	Nature and Extent of Contamination: Remediation at the site is complete. The primary contaminants of concern include Tetrachloroethene (PCE) and related daughter products and residual petroleum contamination in shallow site soils, groundwater and/or soil vapor. An unknown off-site source of 1,1,1 TCA is also impacting site groundwater. Residual contamination in the soil, groundwater and soil vapor are being managed under a Site Management Plan.
Health Problem:	Since some contaminated soils remain at the site below the building foundation or pavement, people will not come in contact with contaminated soils unless they dig below the surface materials. Contaminated groundwater in the area is not used for drinking or other purposes and the site is served by a public water supply. Volatile organic compounds in the groundwater may move into the soil vapor (air spaces within the soil), which in turn may move into overlying buildings and affect the indoor air quality. This process, which is similar to the movement of radon gas from the subsurface into the indoor air of buildings, is referred to as soil vapor intrusion. If the site is redeveloped, the need to take measures to prevent soil vapor intrusion will be re-evaluated. There are no off-site soil vapor concerns associated with this site. However, there is the potential for soil vapor intrusion concerns in off-site buildings due to the presence of off-site contamination not related

AUTOMOBILE CLUB OF NEW YORK (Continued) **S105057848**

to this site.
Dump: Not reported
Structure: Not reported
Lagoon: Not reported
Landfill: Not reported
Pond: Not reported
Disp Start: Not reported
Disp Term: Not reported
Lat/Long: Not reported
Dell: Not reported
Record Add: Not reported
Record Upd: Not reported
Updated By: Not reported
Own Op: 1
Sub Type: NNN
Owner Name: James Clifford
Owner Company: Automobile Club of New York, Inc. (AAA)
Owner Address: 110 Royal Little Drive
Owner Addr2: Not reported
Owner City,St,Zip: Providence, RI 02904
Owner Country: United States of America
Own Op: 4
Sub Type: NNN
Owner Name: RJT MOROTIST SERVICES
Owner Company: RJT MOROTIST SERVICES
Owner Address: 101 WESTMORELAND AVENUE
Owner Addr2: Not reported
Owner City,St,Zip: WHITE PLAINS, NY 10606
Owner Country: United States of America
Own Op: 6
Sub Type: 01
Owner Name: James Clifford
Owner Company: Automobile Club of New York
Owner Address: 110 Royal Little Drive
Owner Addr2: Not reported
Owner City,St,Zip: Providence, NY 02904
Owner Country: United States of America
Own Op: 4
Sub Type: 02
Owner Name: James Clifford
Owner Company: Automobile Club of New York
Owner Address: 110 Royal Little Drive
Owner Addr2: Not reported
Owner City,St,Zip: Providence, NY 02904
Owner Country: United States of America
HW Code: Not reported
Waste Type: Not reported
Waste Quantity: Not reported
Waste Code: Not reported
Crossref ID: D3-0504-06-09
Cross Ref Type Code: 23
Cross Ref Type: Agreement/Consent Order Number
Record Added Date: 2015-05-04 15:12:00
Record Updated: 2015-05-04 15:12:00
Updated By: JLVERRIG
Crossref ID: 563023198
Cross Ref Type Code: 25

AUTOMOBILE CLUB OF NEW YORK (Continued) **S105057848**

Cross Ref Type: County Recording Identifier
Record Added Date: 2017-07-14 08:08:00
Record Updated: 2017-07-14 08:08:00
Updated By: JLVERRIG

Name: AUTOMOBILE CLUB OF NEW YORK
Address: 101 WESTMORELAND AVENUE
City,State,Zip: WHITE PLAINS, NY 10606
Site Code: 374633
Control Name: O&M Plan
HW Code: 360095
Control Code: 33
Control Type: INST
Dt record added: 10/15/2015
Dt rec updated: 01/16/2024
Updated By: RWRICHAR
Site Code: 374633
Site Description: Location: The Automobile Club of New York site is located on the northwest side of Westmoreland Avenue, approximately 100 feet west of the intersection of Westmoreland Avenue and Home Place in the City of White Plains. The site is approximately 0.2 acres Site Features: The site is essentially flat and includes a one-story, concrete block, L-shaped occupied building that covers approximately 75 percent of the site. The northeastern portion of the property is covered with an asphalt parking area, while the western portion of the site contains a gravel parking area. The Bronx River is located approximately 700 feet to the northwest of the site. Current Zoning and Land Use: The site is zoned light industrial and is currently used as an AAA of NY auto-repair shop, which utilizes the building for auto repairs and exterior detailing. Past Use of the Site: A former on-site dry well and former fuel and waste oil underground storage tanks (USTs) appear to be the sources of on-site contamination. There also appears to be an off-site source of 1,1,1 TCA entering the property from the east. Site Geology and Hydrogeology: The site consists of approximately 2 feet of fill, represented by dark gray to black fine coarse sand and gravel with fragments of coal, underlined by light gray to yellow-brown, well sorted fine-medium sand to a depth of 40 feet below grade. Groundwater depth at the site ranges from approximately 25 to 29 feet below grade. Groundwater flows to the north-northwest.
Env Problem: Nature and Extent of Contamination: Remediation at the site is complete. The primary contaminants of concern include Tetrachloroethene (PCE) and related daughter products and residual petroleum contamination in shallow site soils, groundwater and/or soil vapor. An unknown off-site source of 1,1,1 TCA is also impacting site groundwater. Residual contamination in the soil, groundwater and soil vapor are being managed under a Site Management Plan.
Health Problem: Since some contaminated soils remain at the site below the building foundation or pavement, people will not come in contact with contaminated soils unless they dig below the surface materials. Contaminated groundwater in the area is not used for drinking or other purposes and the site is served by a public water supply. Volatile organic compounds in the groundwater may move into the soil vapor (air spaces within the soil), which in turn may move into overlying buildings and affect the indoor air quality. This process, which is similar to the movement of radon gas from the subsurface into the indoor air of buildings, is referred to as soil vapor intrusion. If the site is redeveloped, the need to take measures to

AUTOMOBILE CLUB OF NEW YORK (Continued) **S105057848**

prevent soil vapor intrusion will be re-evaluated. There are no off-site soil vapor concerns associated with this site. However, there is the potential for soil vapor intrusion concerns in off-site buildings due to the presence of off-site contamination not related to this site.

Dump: Not reported
Structure: Not reported
Lagoon: Not reported
Landfill: Not reported
Pond: Not reported
Disp Start: Not reported
Disp Term: Not reported
Lat/Long: Not reported
Dell: Not reported
Record Add: Not reported
Record Upd: Not reported
Updated By: Not reported
Own Op: 1
Sub Type: NNN
Owner Name: James Clifford
Owner Company: Automobile Club of New York, Inc. (AAA)
Owner Address: 110 Royal Little Drive
Owner Addr2: Not reported
Owner City,St,Zip: Providence, RI 02904
Owner Country: United States of America
Own Op: 4
Sub Type: NNN
Owner Name: RJT MOROTIST SERVICES
Owner Company: RJT MOROTIST SERVICES
Owner Address: 101 WESTMORELAND AVENUE
Owner Addr2: Not reported
Owner City,St,Zip: WHITE PLAINS, NY 10606
Owner Country: United States of America
Own Op: 6
Sub Type: 01
Owner Name: James Clifford
Owner Company: Automobile Club of New York
Owner Address: 110 Royal Little Drive
Owner Addr2: Not reported
Owner City,St,Zip: Providence, NY 02904
Owner Country: United States of America
Own Op: 4
Sub Type: 02
Owner Name: James Clifford
Owner Company: Automobile Club of New York
Owner Address: 110 Royal Little Drive
Owner Addr2: Not reported
Owner City,St,Zip: Providence, NY 02904
Owner Country: United States of America
HW Code: Not reported
Waste Type: Not reported
Waste Quantity: Not reported
Waste Code: Not reported
Crossref ID: D3-0504-06-09
Cross Ref Type Code: 23
Cross Ref Type: Agreement/Consent Order Number
Record Added Date: 2015-05-04 15:12:00

AUTOMOBILE CLUB OF NEW YORK (Continued) **S105057848**

Record Updated: 2015-05-04 15:12:00
Updated By: JLVERRIG
Crossref ID: 563023198
Cross Ref Type Code: 25
Cross Ref Type: County Recording Identifier
Record Added Date: 2017-07-14 08:08:00
Record Updated: 2017-07-14 08:08:00
Updated By: JLVERRIG

Name: AUTOMOBILE CLUB OF NEW YORK
Address: 101 WESTMORELAND AVENUE
City,State,Zip: WHITE PLAINS, NY 10606
Site Code: 374633
Control Name: Landuse Restriction
HW Code: 360095
Control Code: 25
Control Type: INST
Dt record added: 10/15/2015
Dt rec updated: 01/16/2024
Updated By: RWRICHAR
Site Code: 374633
Site Description: Location: The Automobile Club of New York site is located on the northwest side of Westmoreland Avenue, approximately 100 feet west of the intersection of Westmoreland Avenue and Home Place in the City of White Plains. The site is approximately 0.2 acres Site Features: The site is essentially flat and includes a one-story, concrete block, L-shaped occupied building that covers approximately 75 percent of the site. The northeastern portion of the property is covered with an asphalt parking area, while the western portion of the site contains a gravel parking area. The Bronx River is located approximately 700 feet to the northwest of the site. Current Zoning and Land Use: The site is zoned light industrial and is currently used as an AAA of NY auto-repair shop, which utilizes the building for auto repairs and exterior detailing. Past Use of the Site: A former on-site dry well and former fuel and waste oil underground storage tanks (USTs) appear to be the sources of on-site contamination. There also appears to be an off-site source of 1,1,1 TCA entering the property from the east. Site Geology and Hydrogeology: The site consists of approximately 2 feet of fill, represented by dark gray to black fine coarse sand and gravel with fragments of coal, underlined by light gray to yellow-brown, well sorted fine-medium sand to a depth of 40 feet below grade. Groundwater depth at the site ranges from approximately 25 to 29 feet below grade. Groundwater flows to the north-northwest.
Env Problem: Nature and Extent of Contamination: Remediation at the site is complete. The primary contaminants of concern include Tetrachloroethene (PCE) and related daughter products and residual petroleum contamination in shallow site soils, groundwater and/or soil vapor. An unknown off-site source of 1,1,1 TCA is also impacting site groundwater. Residual contamination in the soil, groundwater and soil vapor are being managed under a Site Management Plan.
Health Problem: Since some contaminated soils remain at the site below the building foundation or pavement, people will not come in contact with contaminated soils unless they dig below the surface materials. Contaminated groundwater in the area is not used for drinking or other purposes and the site is served by a public water supply. Volatile organic compounds in the groundwater may move into the soil vapor (air spaces within the soil), which in turn may move into

AUTOMOBILE CLUB OF NEW YORK (Continued) **S105057848**

overlying buildings and affect the indoor air quality. This process, which is similar to the movement of radon gas from the subsurface into the indoor air of buildings, is referred to as soil vapor intrusion. If the site is redeveloped, the need to take measures to prevent soil vapor intrusion will be re-evaluated. There are no off-site soil vapor concerns associated with this site. However, there is the potential for soil vapor intrusion concerns in off-site buildings due to the presence of off-site contamination not related to this site.

Dump: Not reported
Structure: Not reported
Lagoon: Not reported
Landfill: Not reported
Pond: Not reported
Disp Start: Not reported
Disp Term: Not reported
Lat/Long: Not reported
Dell: Not reported
Record Add: Not reported
Record Upd: Not reported
Updated By: Not reported
Own Op: 1
Sub Type: NNN
Owner Name: James Clifford
Owner Company: Automobile Club of New York, Inc. (AAA)
Owner Address: 110 Royal Little Drive
Owner Addr2: Not reported
Owner City,St,Zip: Providence, RI 02904
Owner Country: United States of America
Own Op: 4
Sub Type: NNN
Owner Name: RJT MOROTIST SERVICES
Owner Company: RJT MOROTIST SERVICES
Owner Address: 101 WESTMORELAND AVENUE
Owner Addr2: Not reported
Owner City,St,Zip: WHITE PLAINS, NY 10606
Owner Country: United States of America
Own Op: 6
Sub Type: 01
Owner Name: James Clifford
Owner Company: Automobile Club of New York
Owner Address: 110 Royal Little Drive
Owner Addr2: Not reported
Owner City,St,Zip: Providence, NY 02904
Owner Country: United States of America
Own Op: 4
Sub Type: 02
Owner Name: James Clifford
Owner Company: Automobile Club of New York
Owner Address: 110 Royal Little Drive
Owner Addr2: Not reported
Owner City,St,Zip: Providence, NY 02904
Owner Country: United States of America
HW Code: Not reported
Waste Type: Not reported
Waste Quantity: Not reported
Waste Code: Not reported

AUTOMOBILE CLUB OF NEW YORK (Continued) **S105057848**

Crossref ID: D3-0504-06-09
Cross Ref Type Code: 23
Cross Ref Type: Agreement/Consent Order Number
Record Added Date: 2015-05-04 15:12:00
Record Updated: 2015-05-04 15:12:00
Updated By: JLVERRIG
Crossref ID: 563023198
Cross Ref Type Code: 25
Cross Ref Type: County Recording Identifier
Record Added Date: 2017-07-14 08:08:00
Record Updated: 2017-07-14 08:08:00
Updated By: JLVERRIG

Name: AUTOMOBILE CLUB OF NEW YORK
Address: 101 WESTMORELAND AVENUE
City,State,Zip: WHITE PLAINS, NY 10606
Site Code: 374633
Control Name: Site Management Plan
HW Code: 360095
Control Code: 32
Control Type: INST
Dt record added: 10/15/2015
Dt rec updated: 01/16/2024
Updated By: RWRICHAR
Site Code: 374633
Site Description: Location: The Automobile Club of New York site is located on the northwest side of Westmoreland Avenue, approximately 100 feet west of the intersection of Westmoreland Avenue and Home Place in the City of White Plains. The site is approximately 0.2 acres Site Features: The site is essentially flat and includes a one-story, concrete block, L-shaped occupied building that covers approximately 75 percent of the site. The northeastern portion of the property is covered with an asphalt parking area, while the western portion of the site contains a gravel parking area. The Bronx River is located approximately 700 feet to the northwest of the site. Current Zoning and Land Use: The site is zoned light industrial and is currently used as an AAA of NY auto-repair shop, which utilizes the building for auto repairs and exterior detailing. Past Use of the Site: A former on-site dry well and former fuel and waste oil underground storage tanks (USTs) appear to be the sources of on-site contamination. There also appears to be an off-site source of 1,1,1 TCA entering the property from the east. Site Geology and Hydrogeology: The site consists of approximately 2 feet of fill, represented by dark gray to black fine coarse sand and gravel with fragments of coal, underlined by light gray to yellow-brown, well sorted fine-medium sand to a depth of 40 feet below grade. Groundwater depth at the site ranges from approximately 25 to 29 feet below grade. Groundwater flows to the north-northwest.
Env Problem: Nature and Extent of Contamination: Remediation at the site is complete. The primary contaminants of concern include Tetrachloroethene (PCE) and related daughter products and residual petroleum contamination in shallow site soils, groundwater and/or soil vapor. An unknown off-site source of 1,1,1 TCA is also impacting site groundwater. Residual contamination in the soil, groundwater and soil vapor are being managed under a Site Management Plan.
Health Problem: Since some contaminated soils remain at the site below the building foundation or pavement, people will not come in contact with contaminated soils unless they dig below the surface materials.

AUTOMOBILE CLUB OF NEW YORK (Continued) **S105057848**

Contaminated groundwater in the area is not used for drinking or other purposes and the site is served by a public water supply. Volatile organic compounds in the groundwater may move into the soil vapor (air spaces within the soil), which in turn may move into overlying buildings and affect the indoor air quality. This process, which is similar to the movement of radon gas from the subsurface into the indoor air of buildings, is referred to as soil vapor intrusion. If the site is redeveloped, the need to take measures to prevent soil vapor intrusion will be re-evaluated. There are no off-site soil vapor concerns associated with this site. However, there is the potential for soil vapor intrusion concerns in off-site buildings due to the presence of off-site contamination not related to this site.

Dump: Not reported
Structure: Not reported
Lagoon: Not reported
Landfill: Not reported
Pond: Not reported
Disp Start: Not reported
Disp Term: Not reported
Lat/Long: Not reported
Dell: Not reported
Record Add: Not reported
Record Upd: Not reported
Updated By: Not reported
Own Op: 1
Sub Type: NNN
Owner Name: James Clifford
Owner Company: Automobile Club of New York, Inc. (AAA)
Owner Address: 110 Royal Little Drive
Owner Addr2: Not reported
Owner City,St,Zip: Providence, RI 02904
Owner Country: United States of America
Own Op: 4
Sub Type: NNN
Owner Name: RJT MOROTIST SERVICES
Owner Company: RJT MOROTIST SERVICES
Owner Address: 101 WESTMORELAND AVENUE
Owner Addr2: Not reported
Owner City,St,Zip: WHITE PLAINS, NY 10606
Owner Country: United States of America
Own Op: 6
Sub Type: 01
Owner Name: James Clifford
Owner Company: Automobile Club of New York
Owner Address: 110 Royal Little Drive
Owner Addr2: Not reported
Owner City,St,Zip: Providence, NY 02904
Owner Country: United States of America
Own Op: 4
Sub Type: 02
Owner Name: James Clifford
Owner Company: Automobile Club of New York
Owner Address: 110 Royal Little Drive
Owner Addr2: Not reported
Owner City,St,Zip: Providence, NY 02904
Owner Country: United States of America

AUTOMOBILE CLUB OF NEW YORK (Continued) **S105057848**

HW Code: Not reported
Waste Type: Not reported
Waste Quantity: Not reported
Waste Code: Not reported
Crossref ID: D3-0504-06-09
Cross Ref Type Code: 23
Cross Ref Type: Agreement/Consent Order Number
Record Added Date: 2015-05-04 15:12:00
Record Updated: 2015-05-04 15:12:00
Updated By: JLVERRIG
Crossref ID: 563023198
Cross Ref Type Code: 25
Cross Ref Type: County Recording Identifier
Record Added Date: 2017-07-14 08:08:00
Record Updated: 2017-07-14 08:08:00
Updated By: JLVERRIG

Name: AUTOMOBILE CLUB OF NEW YORK
Address: 101 WESTMORELAND AVENUE
City,State,Zip: WHITE PLAINS, NY 10606
Site Code: 374633
Control Name: IC/EC Plan
HW Code: 360095
Control Code: 34
Control Type: INST
Dt record added: 10/15/2015
Dt rec updated: 01/16/2024
Updated By: RWRICHAR
Site Code: 374633
Site Description: Location: The Automobile Club of New York site is located on the northwest side of Westmoreland Avenue, approximately 100 feet west of the intersection of Westmoreland Avenue and Home Place in the City of White Plains. The site is approximately 0.2 acres Site Features: The site is essentially flat and includes a one-story, concrete block, L-shaped occupied building that covers approximately 75 percent of the site. The northeastern portion of the property is covered with an asphalt parking area, while the western portion of the site contains a gravel parking area. The Bronx River is located approximately 700 feet to the northwest of the site. Current Zoning and Land Use: The site is zoned light industrial and is currently used as an AAA of NY auto-repair shop, which utilizes the building for auto repairs and exterior detailing. Past Use of the Site: A former on-site dry well and former fuel and waste oil underground storage tanks (USTs) appear to be the sources of on-site contamination. There also appears to be an off-site source of 1,1,1 TCA entering the property from the east. Site Geology and Hydrogeology: The site consists of approximately 2 feet of fill, represented by dark gray to black fine coarse sand and gravel with fragments of coal, underlined by light gray to yellow-brown, well sorted fine-medium sand to a depth of 40 feet below grade. Groundwater depth at the site ranges from approximately 25 to 29 feet below grade. Groundwater flows to the north-northwest.
Env Problem: Nature and Extent of Contamination: Remediation at the site is complete. The primary contaminants of concern include Tetrachloroethene (PCE) and related daughter products and residual petroleum contamination in shallow site soils, groundwater and/or soil vapor. An unknown off-site source of 1,1,1 TCA is also impacting site groundwater. Residual contamination in the soil, groundwater and

AUTOMOBILE CLUB OF NEW YORK (Continued) **S105057848**

soil vapor are being managed under a Site Management Plan.
Health Problem: Since some contaminated soils remain at the site below the building foundation or pavement, people will not come in contact with contaminated soils unless they dig below the surface materials. Contaminated groundwater in the area is not used for drinking or other purposes and the site is served by a public water supply. Volatile organic compounds in the groundwater may move into the soil vapor (air spaces within the soil), which in turn may move into overlying buildings and affect the indoor air quality. This process, which is similar to the movement of radon gas from the subsurface into the indoor air of buildings, is referred to as soil vapor intrusion. If the site is redeveloped, the need to take measures to prevent soil vapor intrusion will be re-evaluated. There are no off-site soil vapor concerns associated with this site. However, there is the potential for soil vapor intrusion concerns in off-site buildings due to the presence of off-site contamination not related to this site.
Dump: Not reported
Structure: Not reported
Lagoon: Not reported
Landfill: Not reported
Pond: Not reported
Disp Start: Not reported
Disp Term: Not reported
Lat/Long: Not reported
Dell: Not reported
Record Add: Not reported
Record Upd: Not reported
Updated By: Not reported
Own Op: 1
Sub Type: NNN
Owner Name: James Clifford
Owner Company: Automobile Club of New York, Inc. (AAA)
Owner Address: 110 Royal Little Drive
Owner Addr2: Not reported
Owner City,St,Zip: Providence, RI 02904
Owner Country: United States of America
Own Op: 4
Sub Type: NNN
Owner Name: RJT MOROTIST SERVICES
Owner Company: RJT MOROTIST SERVICES
Owner Address: 101 WESTMORELAND AVENUE
Owner Addr2: Not reported
Owner City,St,Zip: WHITE PLAINS, NY 10606
Owner Country: United States of America
Own Op: 6
Sub Type: 01
Owner Name: James Clifford
Owner Company: Automobile Club of New York
Owner Address: 110 Royal Little Drive
Owner Addr2: Not reported
Owner City,St,Zip: Providence, NY 02904
Owner Country: United States of America
Own Op: 4
Sub Type: 02
Owner Name: James Clifford
Owner Company: Automobile Club of New York

AUTOMOBILE CLUB OF NEW YORK (Continued) **S105057848**

Owner Address: 110 Royal Little Drive
Owner Addr2: Not reported
Owner City,St,Zip: Providence, NY 02904
Owner Country: United States of America
HW Code: Not reported
Waste Type: Not reported
Waste Quantity: Not reported
Waste Code: Not reported
Crossref ID: D3-0504-06-09
Cross Ref Type Code: 23
Cross Ref Type: Agreement/Consent Order Number
Record Added Date: 2015-05-04 15:12:00
Record Updated: 2015-05-04 15:12:00
Updated By: JLVERRIG
Crossref ID: 563023198
Cross Ref Type Code: 25
Cross Ref Type: County Recording Identifier
Record Added Date: 2017-07-14 08:08:00
Record Updated: 2017-07-14 08:08:00
Updated By: JLVERRIG

Name: AUTOMOBILE CLUB OF NEW YORK
Address: 101 WESTMORELAND AVENUE
City,State,Zip: WHITE PLAINS, NY 10606
Site Code: 374633
Control Name: Environmental Easement
HW Code: 360095
Control Code: J
Control Type: INST
Dt record added: 10/15/2015
Dt rec updated: 01/16/2024
Updated By: RWRICHAR
Site Code: 374633
Site Description: Location: The Automobile Club of New York site is located on the northwest side of Westmoreland Avenue, approximately 100 feet west of the intersection of Westmoreland Avenue and Home Place in the City of White Plains. The site is approximately 0.2 acres Site Features: The site is essentially flat and includes a one-story, concrete block, L-shaped occupied building that covers approximately 75 percent of the site. The northeastern portion of the property is covered with an asphalt parking area, while the western portion of the site contains a gravel parking area. The Bronx River is located approximately 700 feet to the northwest of the site. Current Zoning and Land Use: The site is zoned light industrial and is currently used as an AAA of NY auto-repair shop, which utilizes the building for auto repairs and exterior detailing. Past Use of the Site: A former on-site dry well and former fuel and waste oil underground storage tanks (USTs) appear to be the sources of on-site contamination. There also appears to be an off-site source of 1,1,1 TCA entering the property from the east. Site Geology and Hydrogeology: The site consists of approximately 2 feet of fill, represented by dark gray to black fine coarse sand and gravel with fragments of coal, underlined by light gray to yellow-brown, well sorted fine-medium sand to a depth of 40 feet below grade. Groundwater depth at the site ranges from approximately 25 to 29 feet below grade. Groundwater flows to the north-northwest.
Env Problem: Nature and Extent of Contamination: Remediation at the site is complete. The primary contaminants of concern include

AUTOMOBILE CLUB OF NEW YORK (Continued) **S105057848**

Tetrachloroethene (PCE) and related daughter products and residual petroleum contamination in shallow site soils, groundwater and/or soil vapor. An unknown off-site source of 1,1,1 TCA is also impacting site groundwater. Residual contamination in the soil, groundwater and soil vapor are being managed under a Site Management Plan.

Health Problem: Since some contaminated soils remain at the site below the building foundation or pavement, people will not come in contact with contaminated soils unless they dig below the surface materials. Contaminated groundwater in the area is not used for drinking or other purposes and the site is served by a public water supply. Volatile organic compounds in the groundwater may move into the soil vapor (air spaces within the soil), which in turn may move into overlying buildings and affect the indoor air quality. This process, which is similar to the movement of radon gas from the subsurface into the indoor air of buildings, is referred to as soil vapor intrusion. If the site is redeveloped, the need to take measures to prevent soil vapor intrusion will be re-evaluated. There are no off-site soil vapor concerns associated with this site. However, there is the potential for soil vapor intrusion concerns in off-site buildings due to the presence of off-site contamination not related to this site.

Dump: Not reported
Structure: Not reported
Lagoon: Not reported
Landfill: Not reported
Pond: Not reported
Disp Start: Not reported
Disp Term: Not reported
Lat/Long: Not reported
Dell: Not reported
Record Add: Not reported
Record Upd: Not reported
Updated By: Not reported
Own Op: 1
Sub Type: NNN
Owner Name: James Clifford
Owner Company: Automobile Club of New York, Inc. (AAA)
Owner Address: 110 Royal Little Drive
Owner Addr2: Not reported
Owner City,St,Zip: Providence, RI 02904
Owner Country: United States of America
Own Op: 4
Sub Type: NNN
Owner Name: RJT MOROTIST SERVICES
Owner Company: RJT MOROTIST SERVICES
Owner Address: 101 WESTMORELAND AVENUE
Owner Addr2: Not reported
Owner City,St,Zip: WHITE PLAINS, NY 10606
Owner Country: United States of America
Own Op: 6
Sub Type: 01
Owner Name: James Clifford
Owner Company: Automobile Club of New York
Owner Address: 110 Royal Little Drive
Owner Addr2: Not reported
Owner City,St,Zip: Providence, NY 02904
Owner Country: United States of America

AUTOMOBILE CLUB OF NEW YORK (Continued) **S105057848**

Own Op: 4
Sub Type: 02
Owner Name: James Clifford
Owner Company: Automobile Club of New York
Owner Address: 110 Royal Little Drive
Owner Addr2: Not reported
Owner City,St,Zip: Providence, NY 02904
Owner Country: United States of America
HW Code: Not reported
Waste Type: Not reported
Waste Quantity: Not reported
Waste Code: Not reported
Crossref ID: D3-0504-06-09
Cross Ref Type Code: 23
Cross Ref Type: Agreement/Consent Order Number
Record Added Date: 2015-05-04 15:12:00
Record Updated: 2015-05-04 15:12:00
Updated By: JLVERRIG
Crossref ID: 563023198
Cross Ref Type Code: 25
Cross Ref Type: County Recording Identifier
Record Added Date: 2017-07-14 08:08:00
Record Updated: 2017-07-14 08:08:00
Updated By: JLVERRIG

Name: AUTOMOBILE CLUB OF NEW YORK
Address: 101 WESTMORELAND AVENUE
City,State,Zip: WHITE PLAINS, NY 10606
Site Code: 374633
Control Name: Soil Management Plan
HW Code: 360095
Control Code: 14
Control Type: INST
Dt record added: 10/15/2015
Dt rec updated: 01/16/2024
Updated By: RWRICHAR
Site Code: 374633
Site Description: Location: The Automobile Club of New York site is located on the northwest side of Westmoreland Avenue, approximately 100 feet west of the intersection of Westmoreland Avenue and Home Place in the City of White Plains. The site is approximately 0.2 acres Site Features: The site is essentially flat and includes a one-story, concrete block, L-shaped occupied building that covers approximately 75 percent of the site. The northeastern portion of the property is covered with an asphalt parking area, while the western portion of the site contains a gravel parking area. The Bronx River is located approximately 700 feet to the northwest of the site. Current Zoning and Land Use: The site is zoned light industrial and is currently used as an AAA of NY auto-repair shop, which utilizes the building for auto repairs and exterior detailing. Past Use of the Site: A former on-site dry well and former fuel and waste oil underground storage tanks (USTs) appear to be the sources of on-site contamination. There also appears to be an off-site source of 1,1,1 TCA entering the property from the east. Site Geology and Hydrogeology: The site consists of approximately 2 feet of fill, represented by dark gray to black fine coarse sand and gravel with fragments of coal, underlined by light gray to yellow-brown, well sorted fine-medium sand to a depth of 40 feet

AUTOMOBILE CLUB OF NEW YORK (Continued) **S105057848**

below grade. Groundwater depth at the site ranges from approximately 25 to 29 feet below grade. Groundwater flows to the north-northwest.

Env Problem: Nature and Extent of Contamination: Remediation at the site is complete. The primary contaminants of concern include Tetrachloroethene (PCE) and related daughter products and residual petroleum contamination in shallow site soils, groundwater and/or soil vapor. An unknown off-site source of 1,1,1 TCA is also impacting site groundwater. Residual contamination in the soil, groundwater and soil vapor are being managed under a Site Management Plan.

Health Problem: Since some contaminated soils remain at the site below the building foundation or pavement, people will not come in contact with contaminated soils unless they dig below the surface materials. Contaminated groundwater in the area is not used for drinking or other purposes and the site is served by a public water supply. Volatile organic compounds in the groundwater may move into the soil vapor (air spaces within the soil), which in turn may move into overlying buildings and affect the indoor air quality. This process, which is similar to the movement of radon gas from the subsurface into the indoor air of buildings, is referred to as soil vapor intrusion. If the site is redeveloped, the need to take measures to prevent soil vapor intrusion will be re-evaluated. There are no off-site soil vapor concerns associated with this site. However, there is the potential for soil vapor intrusion concerns in off-site buildings due to the presence of off-site contamination not related to this site.

Dump: Not reported
Structure: Not reported
Lagoon: Not reported
Landfill: Not reported
Pond: Not reported
Disp Start: Not reported
Disp Term: Not reported
Lat/Long: Not reported
Dell: Not reported
Record Add: Not reported
Record Upd: Not reported
Updated By: Not reported
Own Op: 1
Sub Type: NNN
Owner Name: James Clifford
Owner Company: Automobile Club of New York, Inc. (AAA)
Owner Address: 110 Royal Little Drive
Owner Addr2: Not reported
Owner City,St,Zip: Providence, RI 02904
Owner Country: United States of America
Own Op: 4
Sub Type: NNN
Owner Name: RJT MOROTIST SERVICES
Owner Company: RJT MOROTIST SERVICES
Owner Address: 101 WESTMORELAND AVENUE
Owner Addr2: Not reported
Owner City,St,Zip: WHITE PLAINS, NY 10606
Owner Country: United States of America
Own Op: 6
Sub Type: 01
Owner Name: James Clifford
Owner Company: Automobile Club of New York

AUTOMOBILE CLUB OF NEW YORK (Continued) **S105057848**

Owner Address: 110 Royal Little Drive
Owner Addr2: Not reported
Owner City,St,Zip: Providence, NY 02904
Owner Country: United States of America
Own Op: 4
Sub Type: 02
Owner Name: James Clifford
Owner Company: Automobile Club of New York
Owner Address: 110 Royal Little Drive
Owner Addr2: Not reported
Owner City,St,Zip: Providence, NY 02904
Owner Country: United States of America
HW Code: Not reported
Waste Type: Not reported
Waste Quantity: Not reported
Waste Code: Not reported
Crossref ID: D3-0504-06-09
Cross Ref Type Code: 23
Cross Ref Type: Agreement/Consent Order Number
Record Added Date: 2015-05-04 15:12:00
Record Updated: 2015-05-04 15:12:00
Updated By: JLVERRIG
Crossref ID: 563023198
Cross Ref Type Code: 25
Cross Ref Type: County Recording Identifier
Record Added Date: 2017-07-14 08:08:00
Record Updated: 2017-07-14 08:08:00
Updated By: JLVERRIG

Name: AUTOMOBILE CLUB OF NEW YORK
Address: 101 WESTMORELAND AVENUE
City,State,Zip: WHITE PLAINS, NY 10606
Site Code: 374633
Control Name: Ground Water Use Restriction
HW Code: 360095
Control Code: 08
Control Type: INST
Dt record added: 10/15/2015
Dt rec updated: 01/16/2024
Updated By: RWRICHAR
Site Code: 374633
Site Description: Location: The Automobile Club of New York site is located on the northwest side of Westmoreland Avenue, approximately 100 feet west of the intersection of Westmoreland Avenue and Home Place in the City of White Plains. The site is approximately 0.2 acres Site Features: The site is essentially flat and includes a one-story, concrete block, L-shaped occupied building that covers approximately 75 percent of the site. The northeastern portion of the property is covered with an asphalt parking area, while the western portion of the site contains a gravel parking area. The Bronx River is located approximately 700 feet to the northwest of the site. Current Zoning and Land Use: The site is zoned light industrial and is currently used as an AAA of NY auto-repair shop, which utilizes the building for auto repairs and exterior detailing. Past Use of the Site: A former on-site dry well and former fuel and waste oil underground storage tanks (USTs) appear to be the sources of on-site contamination. There also appears to be an off-site source of 1,1,1 TCA entering the property from the east.

AUTOMOBILE CLUB OF NEW YORK (Continued) **S105057848**

Site Geology and Hydrogeology: The site consists of approximately 2 feet of fill, represented by dark gray to black fine coarse sand and gravel with fragments of coal, underlined by light gray to yellow-brown, well sorted fine-medium sand to a depth of 40 feet below grade. Groundwater depth at the site ranges from approximately 25 to 29 feet below grade. Groundwater flows to the north-northwest.

Env Problem: Nature and Extent of Contamination: Remediation at the site is complete. The primary contaminants of concern include Tetrachloroethene (PCE) and related daughter products and residual petroleum contamination in shallow site soils, groundwater and/or soil vapor. An unknown off-site source of 1,1,1 TCA is also impacting site groundwater. Residual contamination in the soil, groundwater and soil vapor are being managed under a Site Management Plan.

Health Problem: Since some contaminated soils remain at the site below the building foundation or pavement, people will not come in contact with contaminated soils unless they dig below the surface materials. Contaminated groundwater in the area is not used for drinking or other purposes and the site is served by a public water supply. Volatile organic compounds in the groundwater may move into the soil vapor (air spaces within the soil), which in turn may move into overlying buildings and affect the indoor air quality. This process, which is similar to the movement of radon gas from the subsurface into the indoor air of buildings, is referred to as soil vapor intrusion. If the site is redeveloped, the need to take measures to prevent soil vapor intrusion will be re-evaluated. There are no off-site soil vapor concerns associated with this site. However, there is the potential for soil vapor intrusion concerns in off-site buildings due to the presence of off-site contamination not related to this site.

Dump: Not reported
Structure: Not reported
Lagoon: Not reported
Landfill: Not reported
Pond: Not reported
Disp Start: Not reported
Disp Term: Not reported
Lat/Long: Not reported
Dell: Not reported
Record Add: Not reported
Record Upd: Not reported
Updated By: Not reported
Own Op: 1
Sub Type: NNN
Owner Name: James Clifford
Owner Company: Automobile Club of New York, Inc. (AAA)
Owner Address: 110 Royal Little Drive
Owner Addr2: Not reported
Owner City,St,Zip: Providence, RI 02904
Owner Country: United States of America
Own Op: 4
Sub Type: NNN
Owner Name: RJT MOROTIST SERVICES
Owner Company: RJT MOROTIST SERVICES
Owner Address: 101 WESTMORELAND AVENUE
Owner Addr2: Not reported
Owner City,St,Zip: WHITE PLAINS, NY 10606
Owner Country: United States of America

AUTOMOBILE CLUB OF NEW YORK (Continued) **S105057848**

Own Op: 6
Sub Type: 01
Owner Name: James Clifford
Owner Company: Automobile Club of New York
Owner Address: 110 Royal Little Drive
Owner Addr2: Not reported
Owner City,St,Zip: Providence, NY 02904
Owner Country: United States of America
Own Op: 4
Sub Type: 02
Owner Name: James Clifford
Owner Company: Automobile Club of New York
Owner Address: 110 Royal Little Drive
Owner Addr2: Not reported
Owner City,St,Zip: Providence, NY 02904
Owner Country: United States of America
HW Code: Not reported
Waste Type: Not reported
Waste Quantity: Not reported
Waste Code: Not reported
Crossref ID: D3-0504-06-09
Cross Ref Type Code: 23
Cross Ref Type: Agreement/Consent Order Number
Record Added Date: 2015-05-04 15:12:00
Record Updated: 2015-05-04 15:12:00
Updated By: JLVERRIG
Crossref ID: 563023198
Cross Ref Type Code: 25
Cross Ref Type: County Recording Identifier
Record Added Date: 2017-07-14 08:08:00
Record Updated: 2017-07-14 08:08:00
Updated By: JLVERRIG

SPILLS:
Name: RJT MOTORS
Address: 101 WESTMORELAND AVE
City,State,Zip: WHITE PLAINS, NY
Spill Number/Closed Date: 0300596 / 2003-07-09
Facility ID: 0300596
Facility Type: ER
DER Facility ID: 100883
Site ID: 115839
DEC Region: 3
Spill Cause: Other
Spill Class: C3
SWIS: 6017
Spill Date: 2003-02-15
Investigator: JBODEE
Referred To: WESTCHESTER CNTY HEALTH DEPT
Reported to Dept: 2003-04-16
CID: 297
Water Affected: Not reported
Spill Source: Commercial Vehicle
Spill Notifier: Other
Cleanup Ceased: Not reported
Cleanup Meets Std: False
Last Inspection: Not reported

AUTOMOBILE CLUB OF NEW YORK (Continued) **S105057848**

Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2003-04-16
Spill Record Last Update:	2024-04-01
Spiller Name:	Not reported
Spiller Company:	RJT MOTORS
Spiller Address:	101 WESTMORELAND AV
Spiller Company:	001
Contact Name:	CHUCK BUTTERSWORTH
Latitude:	41.0276253
Longitude:	-73.7770869
DEC Memo:	Not reported
Remarks:	CALLER STATES HE WAS HIRED BY THE TRUCKING COMPANY'S INSURANCE COMPANY TO CLEAN UP THE AREA OF A TRUCK FIRE THAT OCCURED IN FEBRUARY - CALLER STATED THE FUEL TANK RUPTURED DURING THE FIRE AND IT WAS NOT NOTICED UNTIL THE SNOW MELTED

All Materials:

Site ID:	115839
Operable Unit ID:	866954
Operable Unit:	01
Material ID:	508676
Material Code:	0008
Material Name:	diesel
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	25.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	AUTOMOBILE CLUB OF NY
Address:	101 WESTMORELAND AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0102386 / 2005-03-22
Facility ID:	0102386
Facility Type:	ER
DER Facility ID:	100883
Site ID:	276229
DEC Region:	3
Spill Cause:	Unknown
Spill Class:	B3
SWIS:	6017
Spill Date:	2001-06-02
Investigator:	jkomara
Referred To:	Not reported
Reported to Dept:	2001-06-02
CID:	281
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Other
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False

AUTOMOBILE CLUB OF NEW YORK (Continued) **S105057848**

UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2001-06-02
Spill Record Last Update:	2023-10-23
Spiller Name:	SAME
Spiller Company:	SAME
Spiller Address:	Not reported
Spiller Company:	001
Contact Name:	BILLY MCBRIDE
Latitude:	41.0276253
Longitude:	-73.7770869
DEC Memo:	12/04/2001 LETTER SENT TO AUTOMOBILE CLUB BY B. MCDONALD (WCDOH); LAB REPORT INDICAATES GW HAS BEEN IMPACTED. BASED ON RESULTS OF ADDITIONAL SAMPLING PERIODS, FURTHER ACTION MAY BE REQUIRED. 04-24-02 LETTER FROM B MCDONALD SENT TO AUTO CLUB STATING THAT GW SAMPLES EXCEED STATE GUIDELINES. REPORT SENT TO O'MARA FOR REVIEW BY DEC. 3/22/05 minimal petroleum contamination; various solvents up to approx 140ppm--close and refer to haz sites
Remarks:	SUSPECTED TANK FAILURE AT ABOVE LOCATION. #2 FUEL OIL IS A 550 GALLON UNDERGROUND TANK. WASTE OIL IS A 250 GALLON UNDERGROUND TANK. TANKS HAVE BEEN REMOVED AND EXCAVATION IS UNDERWAY AT SITE.

All Materials:

Site ID:	276229
Operable Unit ID:	839144
Operable Unit:	01
Material ID:	534502
Material Code:	0022
Material Name:	waste oil/used oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Site ID:	276229
Operable Unit ID:	839144
Operable Unit:	01
Material ID:	534501
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

BC424 **LASALLE PARTNERS** **NY LTANKS** **S118953675**
ENE **1 NORTH BROADWAY** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.361 mi.
1904 ft. **Site 1 of 3 in cluster BC**

Relative:
Higher

Actual:
216 ft.

LTANKS:

Name:	LASALLE PARTNERS
Address:	1 NORTH BROADWAY
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8807326 / 1989-03-08
Facility ID:	8807326
Site ID:	245085
Spill Date:	1988-12-05
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	Not reported
Cleanup Ceased:	1989-03-08
SWIS:	6017
Investigator:	jeokesso
Referred To:	Not reported
Reported to Dept:	1988-12-06
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1988-12-07
Spill Record Last Update:	1989-03-08
Spiller Name:	Not reported
Spiller Company:	Not reported
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	201325
Latitude:	41.0339110
Longitude:	-73.7634090
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was J. OKESSON 03/08/89: BULK STORAGE APPLICATION RECEIVED AND REGISTERED AS PER J.OKESSON'S REQUEST. TANK TEST RESULTS ARE INCLUDED WITH APPLICATION SHOWING TANK PASSED RE-TEST AT +.002 GPH. NFA.
Remarks:	20K -.921 SYSTEM FAILURE. TANK ONLY TEST TO BE DONE SOON. TANK PASSED RETEST. SEE HISTORY. NFA.

All TTF:

Facility ID:	8807326
Spill Number:	8807326
Spill Tank Test:	1534970
Site ID:	245085
Tank Number:	Not reported
Tank Size:	0
Material:	0001
EPA UST:	Not reported
UST:	Not reported

LASALLE PARTNERS (Continued) **S118953675**

Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	245085
Operable Unit ID:	922741
Operable Unit:	01
Material ID:	455672
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

BD425 **GREENRIDGE ESTATES** **NY LTANKS** **S110140617**
SE **1-13 GREENRIDGE AVE** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.361 mi.
1904 ft. **Site 1 of 3 in cluster BD**

Relative: **Higher**

Actual: **254 ft.**

LTANKS:

Name:	GREENRIDGE ESTATES
Address:	1-13 GREENRIDGE AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0912193 / 2011-12-22
Facility ID:	0912193
Site ID:	425068
Spill Date:	2010-02-22
Spill Cause:	Tank Test Failure
Spill Source:	Private Dwelling
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	jbodee
Referred To:	Not reported
Reported to Dept:	2010-02-22
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2010-02-22
Spill Record Last Update:	2020-02-14

GREENRIDGE ESTATES (Continued) **S110140617**

Spiller Name:	Not reported
Spiller Company:	GREEN RIDGE ESTATES
Spiller Address:	1-13 GREEN RIDGE AVE
Spiller County:	999
Spiller Contact:	WILLIAM
Spiller Phone:	(914) 760-5494
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	373978
Latitude:	41.0268866
Longitude:	-73.7660466
DEC Memo:	2/22/10 tank is a 5k ust, will repair and retest...mm From Lalak, Chris 6/10/2011 12:51 PM :: Wayne, Please follow up on these two old open spills 0912193 - 0911533 Chris --This is a PBS regulated facility. Wayne Schneider of WCDOH will follow up. jod Schneider, Wayne 12/22/2011 1:46 PM 0912193: 1-13 Greenridge Ave, White Plains tf 1/22/10. tanks are ASTs and passed retests. 12/22/11: DEC requires NFA at this time. jod
Remarks:	TANK TEST FAILURE. RETEST- UNCLEAR WHAT THE NEXT STEP WILL BE.

All Materials:

Site ID:	425068
Operable Unit ID:	1180801
Operable Unit:	01
Material ID:	2174794
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported
Resource Affected:	Not reported
Oxygenate:	Not reported

BD426 **GREENRIDGE ESTATES CONDOMINIUM TANK 1** **NY LTANKS** **S126222167**
SE **1-13 GREENRIDGE AVE** **N/A**
1/4-1/2 **WHITE PLAINS, NY 10603**
0.361 mi.
1904 ft. **Site 2 of 3 in cluster BD**

Relative: **Higher**
Actual: **254 ft.**

LTANKS:

Name:	GREENRIDGE ESTATES CONDOMINIUM TANK 1
Address:	1-13 GREENRIDGE AVE
City,State,Zip:	WHITE PLAINS, NY 10603
Spill Number/Closed Date:	1910929 / 2022-05-11
Facility ID:	1910929
Site ID:	601600
Spill Date:	2020-02-25
Spill Cause:	Tank Test Failure
Spill Source:	Private Dwelling
Spill Class:	D4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	TDGHIOSA
Referred To:	Not reported
Reported to Dept:	2020-02-25

GREENRIDGE ESTATES CONDOMINIUM TANK 1 (Continued) **S126222167**

CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2020-02-25
Spill Record Last Update:	2022-05-11
Spiller Name:	Trey White
Spiller Company:	White Management (Management Company)
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	TREY WHITE
Spiller Phone:	(914) 874-5424
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	583024
Latitude:	Not reported
Longitude:	Not reported
DEC Memo:	2/25/2020 Three 5000 gallon indoor vaulted tanks (vaults filled with sand) were tested, all failed with hissing sound. No leaks to environment noted. ga 05/14/21 See Northeast Environmental PBS Closure Report in DecDocs. WCHD authorized that the Tank could be abandoned in place. Soil sample taken through the bottom of the tank was below DEC soil guidance values. NFA. TG
Remarks:	3 5000 gal tank indoor vaulted- no leaks noted

All Materials:

Site ID:	601600
Operable Unit ID:	1348716
Operable Unit:	01
Material ID:	2359272
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported
Resource Affected:	Not reported
Oxygenate:	Not reported

Name:	GREENRIDGE ESTATES CONDOMINIUMS TANK 5
Address:	1-13 GREENRIDGE AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	1911181 / 2022-05-11
Facility ID:	1911181
Site ID:	601870
Spill Date:	2020-03-04
Spill Cause:	Tank Test Failure
Spill Source:	Private Dwelling
Spill Class:	Not reported
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	TDGHIOSA

GREENRIDGE ESTATES CONDOMINIUM TANK 1 (Continued) **S126222167**

Referred To:	Not reported
Reported to Dept:	2020-03-04
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2020-03-04
Spill Record Last Update:	2022-05-11
Spiller Name:	Trey White - White Management company
Spiller Company:	GREENRIDGE ESTATES
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	TREY WHITE
Spiller Phone:	(914) 874-5424
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	373978
Latitude:	Not reported
Longitude:	Not reported
DEC Memo:	3/4/2020 US Tank Tech retested tank # 9 which failed with hissing. Other tanks to be re-tested on Friday. ga 05/14/21 See Northeast Environmental PBS Closure Report in DecDocs. WCHD authorized that the Tank could be abandoned in place. Soil sample taken through the bottom of the tank was below DEC soil guidance values. NFA. TG
Remarks:	failed w/hissing sound and a loss of vacuum (retest) PBS 3-039128

All Materials:

Site ID:	601870
Operable Unit ID:	1348984
Operable Unit:	01
Material ID:	2359551
Material Code:	9999
Material Name:	other - TANK TEST FAILURE
Case No.:	Not reported
Material FA:	Other
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported
Resource Affected:	Not reported
Oxygenate:	Not reported

Name:	GREENRIDGE ESTATES CONDOMINIUM TANK 9
Address:	1-13 GREENRIDGE AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	1911256 / 2022-05-11
Facility ID:	1911256
Site ID:	601947
Spill Date:	2020-03-06
Spill Cause:	Tank Test Failure
Spill Source:	Non Major Facility > 1,100 gal
Spill Class:	B3
Cleanup Ceased:	Not reported
SWIS:	6017

GREENRIDGE ESTATES CONDOMINIUM TANK 1 (Continued) **S126222167**

Investigator:	TDGHIOSA
Referred To:	Not reported
Reported to Dept:	2020-03-06
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2020-03-06
Spill Record Last Update:	2022-05-11
Spiller Name:	WHITE MANAGEMENT-TREY WHITE
Spiller Company:	GREENRIDGE ESTATES CONDOMINIUM
Spiller Address:	1-13 GREENRIDGE AVE
Spiller County:	999
Spiller Contact:	WHITE MANAGEMENT-TREY WHITE
Spiller Phone:	(914) 874-5424
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	373978
Latitude:	Not reported
Longitude:	Not reported
DEC Memo:	3/6/2020 - Talked to Cathy Morgan of US Tank: they had tested 3-5000 gal tanks on 2/25 and all failed. They then removed all fittings and replaced with plugs and then retested but 2 have failed. PBS # 3-039128. No leakage has been observed. Tanks are in vaults. Westchester Co (Chris Lalak) was called. No product to the environment. fjk 03/30/20 Emailed Chris Lalak for a status. TG 05/14/21 See Northeast Environmental PBS Closure Report in DecDocs. WCHD authorized that the Tank could be abandoned in place. Soil sample taken through the bottom of the tank was below DEC soil guidance values. NFA. TG
Remarks:	Retest failure. Already spill # in place for the location, but R3 Spills wants a new spill number for a retest on the same tank.

All Materials:

Site ID:	601947
Operable Unit ID:	1349080
Operable Unit:	01
Material ID:	2359635
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported
Resource Affected:	Not reported
Oxygenate:	Not reported

BE427 **OFFICE BLDG - TTF** **NY LTANKS** **S102960015**
SE **203 MAMARONECK AVE** **NY Spills** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.361 mi.
1907 ft. **Site 1 of 4 in cluster BE**

Relative:
Higher

Actual:
227 ft.

LTANKS:

Name:	OFFICE BLDG - TTF
Address:	203 MAMARONECK AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9710787 / Not Reported
Facility ID:	9710787
Site ID:	329412
Spill Date:	1997-12-22
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1997-12-22
CID:	312
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	4
Date Entered In Computer:	1997-12-22
Spill Record Last Update:	2023-07-20
Spiller Name:	Not reported
Spiller Company:	Spencer-Adams, Inc.
Spiller Address:	203 MAMARONECK AVE
Spiller County:	001
Spiller Contact:	GREG Vadja
Spiller Phone:	(914) 693-1132
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	265043
Latitude:	41.0278441
Longitude:	-73.7646645
DEC Memo:	8/3/10 need Update JO'M 04/2023 See spill notes in file. TG 7/20/2023: This is PBS 3-411906. This UST is listed as Closed in place on 2/3/1998 on the Westchester County PBS database. jod
Remarks:	TANK FAILED

All TTF:

Facility ID:	9710787
Spill Number:	9710787
Spill Tank Test:	1545530
Site ID:	329412
Tank Number:	001
Tank Size:	3000
Material:	0001
EPA UST:	False
UST:	True
Cause:	00
Source:	99

OFFICE BLDG - TTF (Continued) **S102960015**

Test Method:	34
Test Method 2:	EZY 3 Locator Plus
Leak Rate:	Not reported
Gross Fail:	Not reported
Modified By:	JBODEE
Last Modified Date:	Not reported

SPILLS:

Name:	BASEMENT
Address:	203 MAMARONECK AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9711397 / 1998-01-12
Facility ID:	9711397
Facility Type:	ER
DER Facility ID:	265043
Site ID:	329413
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	C4
SWIS:	6017
Spill Date:	1998-01-10
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1998-01-10
CID:	207
Water Affected:	Not reported
Spill Source:	Private Dwelling
Spill Notifier:	Police Department
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	1998-01-10
Spill Record Last Update:	2018-01-18
Spiller Name:	ARNOLD LIPMAN
Spiller Company:	Not reported
Spiller Address:	203 MAMARONECK AVE
Spiller Company:	001
Contact Name:	ARNOLD LIPMAN
Latitude:	41.0278441
Longitude:	-73.7646645
DEC Memo:	01/10/98 BASEMENT FLOOR OF BUILDING; WCHD RESPONDING; 01/12/98 SMALL SPILL ONTO BOILER ROOM FLOOR; NO DRAIN AFFECTED; CONTAINED WITH SPEEDI-DRI; CHRIS LELAK (WCHD);
Remarks:	temp oil storage leaked - oil co enroute to clean up

All Materials:

Site ID:	329413
Operable Unit ID:	1057884
Operable Unit:	01
Material ID:	326067
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported

OFFICE BLDG - TTF (Continued) **S102960015**

Material FA:	Petroleum
Quantity:	10.00
Units:	G
Recovered:	Not reported
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	SPENCER ADAMS STORE
Address:	203 MAMARONECK AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0800340 / 2008-04-25
Facility ID:	0800340
Facility Type:	ER
DER Facility ID:	265043
Site ID:	396080
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	C3
SWIS:	6017
Spill Date:	2008-04-09
Investigator:	jbodee
Referred To:	Not reported
Reported to Dept:	2008-04-09
CID:	444
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Other
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	Not reported
Remediation Phase:	0
Date Entered In Computer:	2008-04-09
Spill Record Last Update:	2008-04-28
Spiller Name:	STORE MANAGER-DAVE
Spiller Company:	SPENCER ADAMS STORE
Spiller Address:	203 MANAMACK AVE
Spiller Company:	001
Contact Name:	STORE MANAGER-DAVE
Latitude:	41.0280317
Longitude:	-73.7642886
DEC Memo:	Spill of 10 to 20 gallons, contained to concrete. Robison completed cleanup. NFA jod
Remarks:	BROKEN OIL LINE AND IN PROCESS OF CLEANING AND IS CONTAINED IN A PIT

All Materials:

Site ID:	396080
Operable Unit ID:	1153026
Operable Unit:	01
Material ID:	2143804
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	20.00
Units:	G

OFFICE BLDG - TTF (Continued) **S102960015**

Recovered: Not reported
Resource Affected: Soil
Oxygenate: Not reported

---

428 **WHITE PLAINS HOSPITAL** **NY LTANKS** **S110045423**
SSE **8 LONGVIEW AVE** **NY Spills** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.363 mi.
1917 ft.

Relative: **Higher**
Actual: **234 ft.**

LTANKS:

Name:	WHITE PLAINS HOSPITAL
Address:	8 LONGVIEW AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	1007255 / 2017-12-12
Facility ID:	1007255
Site ID:	440652
Spill Date:	2010-10-06
Spill Cause:	Tank Test Failure
Spill Source:	Institutional, Educational, Gov., Other
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	JBODEE
Referred To:	WCDOH
Reported to Dept:	2010-10-06
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2010-10-06
Spill Record Last Update:	2017-12-12
Spiller Name:	BOB BIDDISCOMBE
Spiller Company:	WHITE PLAINS HOSPITAL
Spiller Address:	8 LONGVIEW AVE
Spiller County:	999
Spiller Contact:	BOB BIDDISCOMBE
Spiller Phone:	(914) 681-1000
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	343572
Latitude:	41.0264516
Longitude:	-73.7682586
DEC Memo:	10-6-10 Spoke with Kathy. This is a 4k UST. Loud bubbling during tank test. PBS #3-104469 RP was told by US Tank Tech that they need to empty tank. Undecided about next step. Will notify WCHD. jm 10/14/10 Hospital wanted tank uncover, repaired and retested. There was nothing to repair so a well point sample was collected. Sample is contaminated with petroleum. Tank will not be retested....mm 12/12/17: This 4k UST failed a tightness test on Oct 6, 2010 reported as this Spill 1007255 Callback notes on this case number indicate UST would not be retested as well point was contaminated. The UST was retested on Oct 20, 2010 and failed. Retest was reported as Spill

WHITE PLAINS HOSPITAL (Continued) **S110045423**

1007877 That second Spill number was closed on July 5, 2011 with the following notation: 7/5/11 ttf, tank removed, contamination removed, endpoint samples below CP-51 standards NFA JO'M *WCDoH PBS data 3-104469 indicates this 4k UST was closed/removed January 2011 and a new 2k UST was installed. Based upon this information, this Spill case number closed and referred to Spill 1007877. jod

Remarks: tank test failure. restest likely

All Materials:

Site ID:	440652
Operable Unit ID:	1191260
Operable Unit:	01
Material ID:	2186382
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported
Resource Affected:	Not reported
Oxygenate:	Not reported

Name:	4K GALLON UST/TTF
Address:	8 LONGVIEW AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	1007877 / 2011-07-05
Facility ID:	1007877
Site ID:	441326
Spill Date:	2010-10-25
Spill Cause:	Tank Test Failure
Spill Source:	Private Dwelling
Spill Class:	B3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	jbodee
Referred To:	WCDOH
Reported to Dept:	2010-10-25
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2010-10-25
Spill Record Last Update:	2017-12-12
Spiller Name:	Not reported
Spiller Company:	HOMEOWNER
Spiller Address:	Not reported
Spiller County:	999
Spiller Contact:	STEPHANIE EAGANS
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	343572

WHITE PLAINS HOSPITAL (Continued) **S110045423**

Latitude:	41.0264516
Longitude:	-73.7682586
DEC Memo:	10/25/10 - Retest. Follow up will be conducted by Westchester County DOH since tank is PBS regulated. KAB 7/5/11 ttf, tank removed, contamination removed, endpoint samples below CP-51 standards NFA JO'M 12/12/17: Also see Spill 1007255. jod
Remarks:	TANK TEST FAILURE.

All Materials:

Site ID:	441326
Operable Unit ID:	1191891
Operable Unit:	01
Material ID:	2187096
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported
Resource Affected:	Not reported
Oxygenate:	Not reported

Name:	WHITE PLAINS HOSPITAL
Address:	8 LONGVIEW AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0907812 / 2009-11-04
Facility ID:	0907812
Site ID:	420361
Spill Date:	2009-10-12
Spill Cause:	Tank Test Failure
Spill Source:	Private Dwelling
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	jbodee
Referred To:	WCDOH
Reported to Dept:	2009-10-12
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2009-10-12
Spill Record Last Update:	2009-11-04
Spiller Name:	Not reported
Spiller Company:	WHITE PLAINS HOSP
Spiller Address:	Not reported
Spiller County:	999
Spiller Contact:	ROSS EDDY
Spiller Phone:	(914) 681-1000
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	343572

WHITE PLAINS HOSPITAL (Continued) **S110045423**

Latitude:	41.0264516
Longitude:	-73.7682586
DEC Memo:	10/15/09: I called the tank tester Ken Gelok from CTT. Confirmed TTF at PBS regulated facilty. He had no further info on a plan of action. WCDOH PBS will follow up. jod 11/04/09: From WCDOH PBS - #0907812 White plains Hospital, 8 Longview Ave, White Plains Tightness test failure - tank passed on 10/20/2009 NFA jod
Remarks:	Not reported

All Materials:

Site ID:	420361
Operable Unit ID:	1176335
Operable Unit:	01
Material ID:	2169020
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	G
Recovered:	Not reported
Resource Affected:	Not reported
Oxygenate:	Not reported

SPILLS:

Name:	APARTMENT
Address:	8 LONGVIEW AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0712395 / 2008-07-16
Facility ID:	0712395
Facility Type:	ER
DER Facility ID:	343572
Site ID:	394002
DEC Region:	3
Spill Cause:	Human Error
Spill Class:	C3
SWIS:	6017
Spill Date:	2008-02-25
Investigator:	jbodee
Referred To:	Not reported
Reported to Dept:	2008-02-25
CID:	444
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Other
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	Not reported
Remediation Phase:	0
Date Entered In Computer:	2008-02-25
Spill Record Last Update:	2008-07-16
Spiller Name:	SAL MANCUSO
Spiller Company:	APART
Spiller Address:	8 LONGVIEW AVE

WHITE PLAINS HOSPITAL (Continued) **S110045423**

Spiller Company:	001
Contact Name:	WESTCHESTER ESTATES
Latitude:	41.0264516
Longitude:	-73.7682586
DEC Memo:	Spoke with Jeneen Ferrara from National Environmental. Mancuso Oil caused spill. NES will begin cleanup tomorrow. She says that they were informed that it was minor. Tried to contact PRP phone number that was given, but it appears to be a fax machine. 7/19/08: Stefan Goreau of WCHD confirmed NES completed clean up and soil sample results were ND for contamination. NFA jod
Remarks:	OVERFILL OF TANK AND CALLERS CLEANING UP

All Materials:

Site ID:	394002
Operable Unit ID:	1150949
Operable Unit:	01
Material ID:	2141603
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

429
ESE
1/4-1/2
0.364 mi.
1920 ft.

240 EAST POST RD
240 EAST POST RD
WHITE PLAINS, NY

NY LTANKS **S103941435**
N/A

Relative:
Higher

Actual:
208 ft.

LTANKS:

Name:	240 EAST POST RD
Address:	240 EAST POST RD
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9903233 / 1999-12-15
Facility ID:	9903233
Site ID:	135983
Spill Date:	1999-06-21
Spill Cause:	Tank Failure
Spill Source:	Private Dwelling
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	WCHD
Referred To:	Westchester Cnty Health Dept
Reported to Dept:	1999-06-21
CID:	205
Water Affected:	Not reported
Spill Notifier:	Responsible Party
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True

240 EAST POST RD (Continued) **S103941435**

UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1999-06-21
Spill Record Last Update:	2000-04-05
Spiller Name:	NATE GORHAM
Spiller Company:	240 EAST POST RD
Spiller Address:	240 EAST POST RD
Spiller County:	001
Spiller Contact:	CALLER
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	116709
Latitude:	41.0301553
Longitude:	-73.7634674
DEC Memo:	Not reported
Remarks:	TANK REMOVED AND CONTAMINATION FOUND IN SOIL.

All Materials:

Site ID:	135983
Operable Unit ID:	1082158
Operable Unit:	01
Material ID:	303161
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

BF430 **15 NORTH BROADWAY** **NY LTANKS** **S100494055**
NE **15 NORTH BROADWAY** **NY Spills** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.365 mi.
1926 ft. **Site 1 of 2 in cluster BF**

Relative:
Higher

Actual:
231 ft.

LTANKS:

Name:	OFFICE BUILDING
Address:	15 NORTH BROADWAY
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9207265 / 1996-02-01
Facility ID:	9207265
Site ID:	125976
Spill Date:	1992-09-23
Spill Cause:	Tank Failure
Spill Source:	Commercial/Industrial
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	jkomara
Referred To:	Not reported
Reported to Dept:	1992-09-23
CID:	Not reported
Water Affected:	Not reported

15 NORTH BROADWAY (Continued) **S100494055**

Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1992-09-25
Spill Record Last Update:	2003-07-29
Spiller Name:	Not reported
Spiller Company:	Not reported
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	108944
Latitude:	41.0353444
Longitude:	-73.7643577
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was O'MARA 09/27/95: This is additional information about material spilled from the translation of the old spill file: TANK TEST. 02/01/96 LETTER FROM JOHN O'MARA TO GEORGE ARDITTI, G&M ENTERPRISES, DEC REQUIRES NO FURTHER ACTION.
Remarks:	RECOMMEND E.I.R. AIRLAY

All Materials:

Site ID:	125976
Operable Unit ID:	974235
Operable Unit:	01
Material ID:	554233
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	L
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

SPILLS:

Name:	15 NORTH BROADWAY
Address:	15 NORTH BROADWAY
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0403095 / 2004-10-06
Facility ID:	0403095
Facility Type:	ER
DER Facility ID:	108944
Site ID:	125975
DEC Region:	3
Spill Cause:	Unknown
Spill Class:	C3
SWIS:	6017
Spill Date:	2004-06-21
Investigator:	tdghiosa

15 NORTH BROADWAY (Continued) **S100494055**

Referred To:	Not reported
Reported to Dept:	2004-06-21
CID:	408
Water Affected:	Not reported
Spill Source:	Private Dwelling
Spill Notifier:	Affected Persons
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2004-06-21
Spill Record Last Update:	2004-10-06
Spiller Name:	Not reported
Spiller Company:	Not reported
Spiller Address:	Not reported
Spiller Company:	Not reported
Contact Name:	TONY KLOSS
Latitude:	41.0353444
Longitude:	-73.7643577
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY 09-13-04 Spill/discharge investigation and remediation report received from Impact Environmental. Based on the information contained in that report, NFA TG
Remarks:	ELEVATOR HYDROLIC OIL: IN THE PROCESS OF BEING CLEANED UP: IT HAS BEEN IDENTIFIED

All Materials:

Site ID:	125975
Operable Unit ID:	885057
Operable Unit:	01
Material ID:	490698
Material Code:	0066A
Material Name:	unknown petroleum
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	250.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

BC431 **ES GORDON** **NY LTANKS** **S100560022**
ENE **7-11 SOUTH BROADWAY** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.366 mi.
1935 ft. **Site 2 of 3 in cluster BC**

Relative: **Higher**

Actual: **211 ft.**

LTANKS:

Name:	ES GORDON
Address:	7-11 SOUTH BROADWAY
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9303840 / 1994-05-04
Facility ID:	9303840
Site ID:	86174

ES GORDON (Continued) **S100560022**

Spill Date:	1993-06-24
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	C3
Cleanup Ceased:	1994-05-04
SWIS:	6017
Investigator:	wxwadswo
Referred To:	Not reported
Reported to Dept:	1993-06-24
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1993-07-01
Spill Record Last Update:	1994-05-26
Spiller Name:	Not reported
Spiller Company:	SAME
Spiller Address:	Not reported
Spiller County:	999
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	79091
Latitude:	41.0335094
Longitude:	-73.7631049
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was W. WADSWORTH 09/27/95: This is additional information about material spilled from the translation of the old spill file: TANK TEST.
Remarks:	SUSPECT LINE LEAK WILL INVESTIGATE HORNER

All TTF:

Facility ID:	9303840
Spill Number:	9303840
Spill Tank Test:	1541701
Site ID:	86174
Tank Number:	Not reported
Tank Size:	0
Material:	0002
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	86174
Operable Unit ID:	982139

ES GORDON (Continued) **S100560022**

Operable Unit:	01
Material ID:	397384
Material Code:	0002A
Material Name:	#4 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	Not reported
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

BG432 **SPILL NUMBER 0103645** **NY LTANKS** **S105055231**
South **12 EAST POST RD** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.368 mi.
1942 ft. **Site 1 of 11 in cluster BG**

Relative: **Higher**

Actual: **208 ft.**

LTANKS:

Name:	SPILL NUMBER 0103645
Address:	12 EAST POST RD
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0103645 / 2003-12-09
Facility ID:	0103645
Site ID:	129951
Spill Date:	2001-07-05
Spill Cause:	Tank Failure
Spill Source:	Private Dwelling
Spill Class:	B3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	WCHD
Referred To:	Westchester Cnty Health Dept
Reported to Dept:	2001-07-05
CID:	205
Water Affected:	Not reported
Spill Notifier:	Responsible Party
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2001-07-05
Spill Record Last Update:	2003-12-09
Spiller Name:	Not reported
Spiller Company:	PHILIP WERBEL
Spiller Address:	12 EAST POST RD
Spiller County:	001
Spiller Contact:	CALLER
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	111992
Latitude:	41.0257926
Longitude:	-73.7707691
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was WCHD-GOREAU 12/09/03 CLOSED BY STEFAN GOREAU OF THE WESTCHESTER

SPILL NUMBER 0103645 (Continued) **S105055231**

COUNTY HEALTH DEPARTMENT.
Remarks: u/g tank leaking. pulled. cleanup starting soon.

All Materials:
Site ID: 129951
Operable Unit ID: 840256
Operable Unit: 01
Material ID: 535715
Material Code: 0001A
Material Name: #2 fuel oil
Case No.: Not reported
Material FA: Petroleum
Quantity: .00
Units: G
Recovered: .00
Resource Affected: Soil
Oxygenate: Not reported

BA433 **BART GOLDBERG APT. BLDG** **NY LTANKS** **S100141680**
East **277 MARTINE AVE** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.369 mi.
1950 ft. **Site 2 of 3 in cluster BA**

Relative: **Higher**
Actual: **214 ft.**

LTANKS:
Name: BART GOLDBERG APT. BLDG
Address: 277 MARTINE AVE
City,State,Zip: WHITE PLAINS, NY
Spill Number/Closed Date: 9008032 / 1990-11-08
Facility ID: 9008032
Site ID: 255929
Spill Date: 1990-10-22
Spill Cause: Tank Test Failure
Spill Source: Commercial/Industrial
Spill Class: Not reported
Cleanup Ceased: 1953-06-18
SWIS: 6017
Investigator: WXWADSWO
Referred To: Not reported
Reported to Dept: 1990-10-22
CID: Not reported
Water Affected: Not reported
Spill Notifier: Tank Tester
Last Inspection: Not reported
Recommended Penalty: False
Meets Standard: True
UST Involvement: False
Remediation Phase: 0
Date Entered In Computer: 1990-10-30
Spill Record Last Update: 1990-11-20
Spiller Name: Not reported
Spiller Company: SAME
Spiller Address: Not reported
Spiller County: 001
Spiller Contact: Not reported
Spiller Phone: Not reported
Spiller Extention: Not reported

BART GOLDBERG APT. BLDG (Continued) **S100141680**

DEC Region:	3
DER Facility ID:	209602
Latitude:	41.0321031
Longitude:	-73.7636570
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was WADSWORTH 11/08/90: TANK PASSED RETEST. 09/27/95: This is additional information about material spilled from the translation of the old spill file: TANK TEST.
Remarks:	TO E I R PETRO-TITE GROSS LEAK

All TTF:

Facility ID:	9008032
Spill Number:	9008032
Spill Tank Test:	1537746
Site ID:	255929
Tank Number:	Not reported
Tank Size:	0
Material:	0002
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	255929
Operable Unit ID:	948684
Operable Unit:	01
Material ID:	431865
Material Code:	0002A
Material Name:	#4 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	Not reported
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

AZ434 **HOSPITAL (UNK NAME)** **NY LTANKS** **S103479243**
SSE **41 EAST COAST ROAD** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.371 mi.
1961 ft. **Site 6 of 6 in cluster AZ**

Relative:
Higher

Actual:
221 ft.

LTANKS:

Name:	HOSPITAL (UNK NAME)
Address:	41 EAST COAST ROAD
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9806058 / 1998-08-17
Facility ID:	9806058
Site ID:	191235

HOSPITAL (UNK NAME) (Continued) **S103479243**

Spill Date:	1998-08-14
Spill Cause:	Tank Overfill
Spill Source:	Institutional, Educational, Gov., Other
Spill Class:	B2
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1998-08-14
CID:	199
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1998-08-14
Spill Record Last Update:	1998-10-02
Spiller Name:	Not reported
Spiller Company:	MYSTIC BULK CARRIERS
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	159508
Latitude:	Not reported
Longitude:	Not reported
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY 8/17/98 SEE SPILL 9806078. SAME SPILL AND SPILLER. NFA
Remarks:	TANK OVERFILL BY CARRIER - CALLER IS ENROUTE AT THIS TIME WITH VACUMN TRUCK FOR CLEAN-UP -- SOME MATERAL ALSO GOT INTO STORM SEWERS

All Materials:

Site ID:	191235
Operable Unit ID:	1067237
Operable Unit:	01
Material ID:	317230
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	2000.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

BH435 **VILLE HOME** **NY LTANKS** **S108299226**
West **167 HARDING AVE** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.373 mi.
1969 ft. **Site 1 of 2 in cluster BH**

Relative:
Higher

Actual:
302 ft.

LTANKS:

Name:	VILLE HOME
Address:	167 HARDING AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0611042 / 2007-03-30
Facility ID:	0611042
Site ID:	375611
Spill Date:	2007-01-01
Spill Cause:	Tank Failure
Spill Source:	Private Dwelling
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	TDGHIOSA
Referred To:	Not reported
Reported to Dept:	2007-01-03
CID:	444
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	2007-01-04
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2007-01-03
Spill Record Last Update:	2007-03-30
Spiller Name:	JULIUS VILLE
Spiller Company:	VILLE HOME
Spiller Address:	167 HARDING AVE
Spiller County:	001
Spiller Contact:	JULIUS VILLE
Spiller Phone:	(914) 421-2014
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	325230
Latitude:	41.0308917
Longitude:	-73.7794186
DEC Memo:	01/04/07 Met with David Visaggi and the homeowner. The homeowner observed that the 275 gallon tank began to leak after the last delivery. He called the oil company who responded and put a magnetic patch on the tank until temporary tank could be set up and the oil transferred into that tank. A minor amount of oil leaked onto the concrete floor beneath the tank. Almeida oil will remove the tank and clean the floor to get rid of the oil odor. TG 03/30/07 David Vissagi rpeorted that the tank was removed and the homeowner cleaned the concrete himself. NFA TG
Remarks:	ABOVE GROUND IN CRAWL SPACE: STILL INVESTIGATING WHERE LEAKING: LEAKED ON A CEMENT BASE: STOPPED LEAKING AND IS CONTAINED AND A TEMP TANK HAS BEEN SET UP:

All Materials:

Site ID:	375611
Operable Unit ID:	1133232
Operable Unit:	01

VILLE HOME (Continued) **S108299226**

Material ID:	2123035
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

---

436 GOMES RESIDENCE **NY LTANKS S110309398**
West 140 HARDING AVE **N/A**
1/4-1/2 WHITE PLAINS, NY
0.373 mi.
1970 ft.

Relative: Higher

Actual: 285 ft.

LTANKS:

Name:	GOMES RESIDENCE
Address:	140 HARDING AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	1001359 / 2010-07-08
Facility ID:	1001359
Site ID:	434408
Spill Date:	2010-05-05
Spill Cause:	Tank Test Failure
Spill Source:	Private Dwelling
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	jbodee
Referred To:	Not reported
Reported to Dept:	2010-05-05
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2010-05-05
Spill Record Last Update:	2010-07-08
Spiller Name:	Not reported
Spiller Company:	TANK TEST FAILURE
Spiller Address:	Not reported
Spiller County:	999
Spiller Contact:	LEONARDO GOMES
Spiller Phone:	(914) 473-0830
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	389286
Latitude:	41.0318817
Longitude:	-73.7791786
DEC Memo:	5-5-10 Spoke with Kathy. As stated, they will be isolating tank and piping for retest. This is a 1000 gallon UST. jm 7/8/2010: Tank passed a retest after the fill and vent pipe were replaced by Ellis

GOMES RESIDENCE (Continued) **S110309398**

Remarks: Oil. No contamination was noted during repair work. Based upon the information provided, no further action is required at this time. jod trying to isolate problem and retest -

All Materials:

Site ID:	434408
Operable Unit ID:	1185236
Operable Unit:	01
Material ID:	2179544
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported
Resource Affected:	Not reported
Oxygenate:	Not reported

BI437 **WHITE PLAINS HOSPITAL** **NY LTANKS** **S107417344**
ENE **MAPLE AVE** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.374 mi.
1975 ft. **Site 1 of 2 in cluster BI**

Relative:
Higher

Actual:
210 ft.

LTANKS:

Name:	WHITE PLAINS HOSPITAL
Address:	MAPLE AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9304740 / 1994-01-06
Facility ID:	9304740
Site ID:	290020
Spill Date:	1993-07-15
Spill Cause:	Tank Overfill
Spill Source:	Commercial/Industrial
Spill Class:	B3
Cleanup Ceased:	1994-01-06
SWIS:	6017
Investigator:	MALONE
Referred To:	Not reported
Reported to Dept:	1993-07-15
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1993-07-27
Spill Record Last Update:	1994-01-06
Spiller Name:	Not reported
Spiller Company:	SAME
Spiller Address:	Not reported
Spiller County:	999
Spiller Contact:	Not reported
Spiller Phone:	Not reported

WHITE PLAINS HOSPITAL (Continued) **S107417344**

Spiller Extention: Not reported
DEC Region: 3
DER Facility ID: 81239
Latitude: 41.0331599
Longitude: -73.7628200
DEC Memo: Not reported
Remarks: SOIL DISCOVERED IN TANK PULL WILL SYOCKPILE SOIL

All Materials:
Site ID: 290020
Operable Unit ID: 983028
Operable Unit: 01
Material ID: 398220
Material Code: 0001A
Material Name: #2 fuel oil
Case No.: Not reported
Material FA: Petroleum
Quantity: .00
Units: Not reported
Recovered: .00
Resource Affected: Soil
Oxygenate: Not reported

BG438 **SPILL NUMBER 8600048** **NY LTANKS** **S104619203**
South **11 EAST POST ROAD** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.375 mi.
1981 ft. **Site 2 of 11 in cluster BG**

Relative: **Higher**

Actual: **209 ft.**

LTANKS:
Name: SPILL NUMBER 8600048
Address: 11 EAST POST ROAD
City,State,Zip: WHITE PLAINS, NY
Spill Number/Closed Date: 8600048 / 1987-02-24
Facility ID: 8600048
Site ID: 200602
Spill Date: 1986-04-02
Spill Cause: Tank Failure
Spill Source: Gasoline Station or other PBS Facility
Spill Class: C3
Cleanup Ceased: 1987-02-24
SWIS: 6017
Investigator: dxtraver
Referred To: Not reported
Reported to Dept: 1986-04-02
CID: Not reported
Water Affected: Not reported
Spill Notifier: Citizen
Last Inspection: 1987-02-24
Recommended Penalty: False
Meets Standard: True
UST Involvement: True
Remediation Phase: 0
Date Entered In Computer: 1986-04-25
Spill Record Last Update: 1997-06-06
Spiller Name: Not reported
Spiller Company: POWERTEST GETTY GAS

SPILL NUMBER 8600048 (Continued) **S104619203**

Spiller Address:	11 EAST POST RD.
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	266859
Latitude:	41.0257811
Longitude:	-73.7705433
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was TRAVER 2/24/87 WCHD INVESTIGATED NFA.
Remarks:	PRODUCT OBSERVED IN OBS WELLS-LOSING PRODUCT FROM AUG,85

All Materials:

Site ID:	200602
Operable Unit ID:	896383
Operable Unit:	01
Material ID:	480238
Material Code:	0009
Material Name:	gasoline
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	L
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

BG439 **GETTY SERVICE STATION** **UST FINDER RELEASE** **1029065708**
South **11 EAST POST ROAD** **N/A**
1/4-1/2 **WHITE PLAINS, NY 0**
0.375 mi.
1981 ft. **Site 3 of 11 in cluster BG**

Relative:
Higher

Actual:
209 ft.

UST FINDER RELEASE:

Object ID:	262375
Facility ID:	NY213498
Lust ID:	NY9710611
Name:	GETTY SERVICE STATION
Address:	11 EAST POST ROAD
City,State,Zip:	WHITE PLAINS, NY 0
Address Match Type:	Not reported
Reported Date:	1997/12/17 15:59:59+00
Status:	No Further Action
Substance:	Not reported
Population within 1500ft:	5829
Domestic Wells within 1500ft:	0
Land Use:	Developed, High Intensity
Within SPA:	Yes
SPA PWS Facility ID:	NY7003493_76968
SPA Water Type:	SW - SurRELEASEe Water
SPA Facility Type:	RS - Reservoir
SPA HUC12:	20301020103
Within WHPA:	No
WHPA PWS Facility ID:	Not reported
WHPA Water Type:	Not reported
WHPA Facility Type:	Not reported

GETTY SERVICE STATION (Continued) **1029065708**

WHPA HUC12:	Not reported
Within 100yr Floodplain:	No
Tribe:	Not reported
EPA Region:	2
NFA Letter 1:	Not reported
NFA Letter 2:	Not reported
NFA Letter 3:	Not reported
NFA Letter 4:	Not reported
Closed With Residual Contaminate:	Not reported
Coordinate Source:	State
X Coord:	-73.77054
Y Coord:	41.0257800000001
Latitude:	41.0257799999999
Longitude:	-73.7705399999999

BG440 **GETTY GAS #58108** **UST FINDER RELEASE** **1029070062**
South **11 EAST POST ROAD** **N/A**
1/4-1/2 **WHITE PLAINS, NY 0**
0.375 mi.
1981 ft. **Site 4 of 11 in cluster BG**

Relative: **Higher**
Actual: **209 ft.**

UST FINDER RELEASE:

Object ID:	262376
Facility ID:	NY266859
Lust ID:	NY407127
Name:	GETTY GAS #58108
Address:	11 EAST POST ROAD
City,State,Zip:	WHITE PLAINS, NY 0
Address Match Type:	Not reported
Reported Date:	2004/09/27 15:59:59+00
Status:	No Further Action
Substance:	Not reported
Population within 1500ft:	5837
Domestic Wells within 1500ft:	0
Land Use:	Developed, High Intensity
Within SPA:	Yes
SPA PWS Facility ID:	NY7003493_76968
SPA Water Type:	SW - SurRELEASEe Water
SPA Facility Type:	RS - Reservoir
SPA HUC12:	20301020103
Within WHPA:	No
WHPA PWS Facility ID:	Not reported
WHPA Water Type:	Not reported
WHPA Facility Type:	Not reported
WHPA HUC12:	Not reported
Within 100yr Floodplain:	No
Tribe:	Not reported
EPA Region:	2
NFA Letter 1:	Not reported
NFA Letter 2:	Not reported
NFA Letter 3:	Not reported
NFA Letter 4:	Not reported
Closed With Residual Contaminate:	Not reported
Coordinate Source:	State
X Coord:	-73.77053
Y Coord:	41.0257700000001
Latitude:	41.02577
Longitude:	-73.7705299999999

BG441 **SPILL NUMBER 8600048** **UST FINDER RELEASE** **1029070063**
South **11 EAST POST ROAD** **N/A**
1/4-1/2 **WHITE PLAINS, NY 0**
0.375 mi.
1981 ft. **Site 5 of 11 in cluster BG**

Relative: UST FINDER RELEASE:
Higher

Actual:
209 ft.

Object ID:	262374
Facility ID:	NY266859
Lust ID:	NY8600048
Name:	SPILL NUMBER 8600048
Address:	11 EAST POST ROAD
City,State,Zip:	WHITE PLAINS, NY 0
Address Match Type:	Not reported
Reported Date:	1986/04/02 16:00:00+00
Status:	No Further Action
Substance:	Not reported
Population within 1500ft:	5829
Domestic Wells within 1500ft:	0
Land Use:	Developed, High Intensity
Within SPA:	Yes
SPA PWS Facility ID:	NY7003493_76968
SPA Water Type:	SW - SurRELEASEe Water
SPA Facility Type:	RS - Reservoir
SPA HUC12:	20301020103
Within WHPA:	No
WHPA PWS Facility ID:	Not reported
WHPA Water Type:	Not reported
WHPA Facility Type:	Not reported
WHPA HUC12:	Not reported
Within 100yr Floodplain:	No
Tribe:	Not reported
EPA Region:	2
NFA Letter 1:	Not reported
NFA Letter 2:	Not reported
NFA Letter 3:	Not reported
NFA Letter 4:	Not reported
Closed With Residual Contaminate:	Not reported
Coordinate Source:	State
X Coord:	-73.77054
Y Coord:	41.0257800000001
Latitude:	41.0257799999999
Longitude:	-73.7705399999999

BG442 **GETTY # 58108** **UST FINDER RELEASE** **1029070059**
South **11 EAST POST ROAD** **N/A**
1/4-1/2 **WHITE PLAINS, NY 0**
0.375 mi.
1981 ft. **Site 6 of 11 in cluster BG**

Relative: UST FINDER RELEASE:
Higher

Actual:
209 ft.

Object ID:	262379
Facility ID:	NY266859
Lust ID:	NY513284
Name:	GETTY # 58108
Address:	11 EAST POST ROAD
City,State,Zip:	WHITE PLAINS, NY 0
Address Match Type:	Not reported
Reported Date:	2006/02/17 15:59:59+00
Status:	No Further Action

GETTY # 58108 (Continued) **1029070059**

Substance:	Not reported
Population within 1500ft:	5837
Domestic Wells within 1500ft:	0
Land Use:	Developed, High Intensity
Within SPA:	Yes
SPA PWS Facility ID:	NY7003493_76968
SPA Water Type:	SW - SurRELEASEe Water
SPA Facility Type:	RS - Reservoir
SPA HUC12:	20301020103
Within WHPA:	No
WHPA PWS Facility ID:	Not reported
WHPA Water Type:	Not reported
WHPA Facility Type:	Not reported
WHPA HUC12:	Not reported
Within 100yr Floodplain:	No
Tribe:	Not reported
EPA Region:	2
NFA Letter 1:	Not reported
NFA Letter 2:	Not reported
NFA Letter 3:	Not reported
NFA Letter 4:	Not reported
Closed With Residual Contaminate:	Not reported
Coordinate Source:	State
X Coord:	-73.77053
Y Coord:	41.0257700000001
Latitude:	41.02577
Longitude:	-73.7705299999999

BG443 **GETTY GAS #58108** **NY LTANKS** **S104514642**
South **11 EAST POST ROAD** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.375 mi.
1981 ft. **Site 7 of 11 in cluster BG**

Relative: **Higher**

Actual: **209 ft.**

LTANKS:

Name:	GETTY SERVICE STATION
Address:	11 EAST POST ROAD
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9710611 / 1998-05-08
Facility ID:	9710611
Site ID:	261415
Spill Date:	1997-12-17
Spill Cause:	Tank Test Failure
Spill Source:	Gasoline Station or other PBS Facility
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6000
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1997-12-17
CID:	205
Water Affected:	Not reported
Spill Notifier:	Responsible Party
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	True
Remediation Phase:	0

GETTY GAS #58108 (Continued) **S104514642**

Date Entered In Computer:	1997-12-17
Spill Record Last Update:	1998-06-08
Spiller Name:	Not reported
Spiller Company:	GETTY SERVICE STATION
Spiller Address:	11 EAST POST ROAD
Spiller County:	001
Spiller Contact:	TYREE INC
Spiller Phone:	(203) 740-8200
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	213498
Latitude:	41.0257811
Longitude:	-73.7705433
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY 05/08/98 FUTHER INVESTIGATION AND REMEDIATION WILL BE CONDUCTED UNDER SPILL # 97-10575
Remarks:	TWO TANKS BOTH 4000 GALLON CAPACITY MANIFOLDED TOGETHER. FAILED TEST.

All TTF:

Facility ID:	9710611
Spill Number:	9710611
Spill Tank Test:	1545523
Site ID:	261415
Tank Number:	003 & 004
Tank Size:	4000
Material:	Not reported
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	20
Test Method 2:	USTest 2000/P/LL plus USTest 2000/U
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

Name:	GETTY GAS #58108
Address:	11 EAST POST ROAD
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0407127 / 2004-09-27
Facility ID:	0407127
Site ID:	261414
Spill Date:	2004-09-27
Spill Cause:	Tank Overfill
Spill Source:	Gasoline Station or other PBS Facility
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	MBMASTRO
Referred To:	WCHD
Reported to Dept:	2004-09-27
CID:	407
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False

GETTY GAS #58108 (Continued) **S104514642**

Meets Standard:	True
UST Involvement:	True
Remediation Phase:	0
Date Entered In Computer:	2004-09-27
Spill Record Last Update:	2004-10-18
Spiller Name:	SCOTT HANLEY
Spiller Company:	GETTY GAS #58108
Spiller Address:	11 EAST POST ROAD
Spiller County:	001
Spiller Contact:	SCOTT HANLEY
Spiller Phone:	(516) 542-5273
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	266859
Latitude:	41.0257720
Longitude:	-73.7705280
DEC Memo:	Not reported
Remarks:	Spilled into containment. Spill is being cleanedup, no release into the environment.

All Materials:

Site ID:	261414
Operable Unit ID:	890394
Operable Unit:	01
Material ID:	484968
Material Code:	0009
Material Name:	gasoline
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	4.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

BG444 **GETTY 58108** **UST FINDER RELEASE** **1029070061**
South **11 EAST POST ROAD** **N/A**
1/4-1/2 **WHITE PLAINS, NY 0**
0.375 mi.
1981 ft. **Site 8 of 11 in cluster BG**

Relative:
Higher

Actual:
209 ft.

UST FINDER RELEASE:

Object ID:	262378
Facility ID:	NY266859
Lust ID:	NY512391
Name:	GETTY 58108
Address:	11 EAST POST ROAD
City,State,Zip:	WHITE PLAINS, NY 0
Address Match Type:	Not reported
Reported Date:	2006/01/25 15:59:59+00
Status:	No Further Action
Substance:	Not reported
Population within 1500ft:	5837
Domestic Wells within 1500ft:	0
Land Use:	Developed, High Intensity
Within SPA:	Yes
SPA PWS Facility ID:	NY7003493_76968

GETTY 58108 (Continued) **1029070061**

SPA Water Type:	SW - SurRELEASEe Water
SPA Facility Type:	RS - Reservoir
SPA HUC12:	20301020103
Within WHPA:	No
WHPA PWS Facility ID:	Not reported
WHPA Water Type:	Not reported
WHPA Facility Type:	Not reported
WHPA HUC12:	Not reported
Within 100yr Floodplain:	No
Tribe:	Not reported
EPA Region:	2
NFA Letter 1:	Not reported
NFA Letter 2:	Not reported
NFA Letter 3:	Not reported
NFA Letter 4:	Not reported
Closed With Residual Contaminate:	Not reported
Coordinate Source:	State
X Coord:	-73.77053
Y Coord:	41.0257700000001
Latitude:	41.02577
Longitude:	-73.7705299999999

Object ID:	262380
Facility ID:	NY266859
Lust ID:	NY603141
Name:	GETTY 58108
Address:	11 EAST POST ROAD
City,State,Zip:	WHITE PLAINS, NY 0
Address Match Type:	Not reported
Reported Date:	2006/06/21 15:59:59+00
Status:	No Further Action
Substance:	Not reported
Population within 1500ft:	5824
Domestic Wells within 1500ft:	0
Land Use:	Developed, High Intensity
Within SPA:	Yes
SPA PWS Facility ID:	NY7003493_76968
SPA Water Type:	SW - SurRELEASEe Water
SPA Facility Type:	RS - Reservoir
SPA HUC12:	20301020103
Within WHPA:	No
WHPA PWS Facility ID:	Not reported
WHPA Water Type:	Not reported
WHPA Facility Type:	Not reported
WHPA HUC12:	Not reported
Within 100yr Floodplain:	No
Tribe:	Not reported
EPA Region:	2
NFA Letter 1:	Not reported
NFA Letter 2:	Not reported
NFA Letter 3:	Not reported
NFA Letter 4:	Not reported
Closed With Residual Contaminate:	Not reported
Coordinate Source:	State
X Coord:	-73.7704199999999
Y Coord:	41.0258000000001
Latitude:	41.0257999999999

GETTY 58108 (Continued) **1029070061**

Longitude: -73.77042

BG445 **GETTY #58108** **UST FINDER RELEASE** **1029070060**
South **11 EAST POST ROAD** **N/A**
1/4-1/2 **WHITE PLAINS, NY 0**
0.375 mi.
1981 ft. **Site 9 of 11 in cluster BG**

Relative: **Higher**
Actual: **209 ft.**

UST FINDER RELEASE:

Object ID:	262377
Facility ID:	NY266859
Lust ID:	NY512154
Name:	GETTY #58108
Address:	11 EAST POST ROAD
City,State,Zip:	WHITE PLAINS, NY 0
Address Match Type:	Not reported
Reported Date:	2006/01/20 15:59:59+00
Status:	No Further Action
Substance:	Not reported
Population within 1500ft:	5837
Domestic Wells within 1500ft:	0
Land Use:	Developed, High Intensity
Within SPA:	Yes
SPA PWS Facility ID:	NY7003493_76968
SPA Water Type:	SW - SurRELEASEe Water
SPA Facility Type:	RS - Reservoir
SPA HUC12:	20301020103
Within WHPA:	No
WHPA PWS Facility ID:	Not reported
WHPA Water Type:	Not reported
WHPA Facility Type:	Not reported
WHPA HUC12:	Not reported
Within 100yr Floodplain:	No
Tribe:	Not reported
EPA Region:	2
NFA Letter 1:	Not reported
NFA Letter 2:	Not reported
NFA Letter 3:	Not reported
NFA Letter 4:	Not reported
Closed With Residual Contaminate:	Not reported
Coordinate Source:	State
X Coord:	-73.77053
Y Coord:	41.0257700000001
Latitude:	41.02577
Longitude:	-73.7705299999999

BH446 **W2 POLE** **NY LTANKS** **S101658499**
West **155 HARDING AVE** **NY Spills** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.376 mi.
1986 ft. **Site 2 of 2 in cluster BH**

Relative: **Higher**
Actual: **301 ft.**

LTANKS:

Name:	SLATE SUPERVISION
Address:	155 HARDING AVE
City,State,Zip:	WHITE PLAINS, NY

W2 POLE (Continued) **S101658499**

Spill Number/Closed Date:	9500861 / 1995-05-24
Facility ID:	9500861
Site ID:	313435
Spill Date:	1995-04-20
Spill Cause:	Tank Failure
Spill Source:	Private Dwelling
Spill Class:	C3
Cleanup Ceased:	1995-04-22
SWIS:	6017
Investigator:	WCHD
Referred To:	Westchester Cnty Health Dept
Reported to Dept:	1995-04-20
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1995-05-24
Spill Record Last Update:	2003-08-05
Spiller Name:	Not reported
Spiller Company:	Not reported
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	252736
Latitude:	41.0318668
Longitude:	-73.7795184
DEC Memo:	Not reported
Remarks:	RUPTURE OF 3000 GAL TANK LEAK CONTAINED A.L. EASTMAN ENROUTE TO CLEAN UP CONTAINED IN VAULT

All Materials:

Site ID:	313435
Operable Unit ID:	1014989
Operable Unit:	01
Material ID:	561415
Material Code:	0002A
Material Name:	#4 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	L
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

SPILLS:

Name:	W2 POLE
Address:	155 HARDING AVE
City,State,Zip:	WHITE PLAINS, NY

W2 POLE (Continued) **S101658499**

Spill Number/Closed Date:	1213451 / 2012-12-12
Facility ID:	1213451
Facility Type:	ER
DER Facility ID:	252736
Site ID:	476636
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	D4
SWIS:	6017
Spill Date:	2012-12-12
Investigator:	dxtraver
Referred To:	Not reported
Reported to Dept:	2012-12-12
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Transformer
Spill Notifier:	Other
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	Not reported
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2012-12-12
Spill Record Last Update:	2012-12-12
Spiller Name:	Not reported
Spiller Company:	CON ED
Spiller Address:	Not reported
Spiller Company:	999
Contact Name:	ERT
Latitude:	41.0311617
Longitude:	-73.7794986
DEC Memo:	12/12/12- Spoke to Pat at ERT desk. Overhead transformer leak of non-PCB oil. Con Ed is on site performing cleanup. Soil only impacted. NFA DT
Remarks:	private property, soil , c/u pending

All Materials:

Site ID:	476636
Operable Unit ID:	1226462
Operable Unit:	01
Material ID:	2223727
Material Code:	0020A
Material Name:	transformer oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	1.00
Units:	G
Recovered:	Not reported
Resource Affected:	Soil
Oxygenate:	Not reported

447
North
1/4-1/2
0.377 mi.
1988 ft.

LAZZARO
47 PARK AVE
WHITE PLAINS, NY

NY LTANKS **S104620069**
N/A

Relative:
Higher

Actual:
314 ft.

LTANKS:

Name:	LAZZARO
Address:	47 PARK AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9815351 / 2004-12-07
Facility ID:	9815351
Site ID:	238028
Spill Date:	1999-03-26
Spill Cause:	Tank Test Failure
Spill Source:	Private Dwelling
Spill Class:	C6
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	jbodee
Referred To:	Not reported
Reported to Dept:	1999-03-26
CID:	322
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1999-03-26
Spill Record Last Update:	2004-12-07
Spiller Name:	BATRICE LAZZARO
Spiller Company:	Not reported
Spiller Address:	47 PARK AVE
Spiller County:	001
Spiller Contact:	BATRICE LAZZARO
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	196045
Latitude:	41.0373679
Longitude:	-73.7721170
DEC Memo:	04/27/99 Letter sent to tank owner by John O'Dee requesting information on tank/spill status. 12/07/04 TANK TEST FAILURE OF UNREGULATED, RESIDENTIAL HEATING OIL TANK. NO FURTHER INFORMATION RECEIVED BY DEC. SPILL FILE ADMINISTRATIVELY CLOSED. jbo
Remarks:	GROSS FAILURE OF TANK TEST

All TTF:

Facility ID:	9815351
Spill Number:	9815351
Spill Tank Test:	1546986
Site ID:	238028
Tank Number:	1
Tank Size:	1000
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported

LAZZARO (Continued) **S104620069**

Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	.00
Gross Fail:	F
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	238028
Operable Unit ID:	1076380
Operable Unit:	01
Material ID:	566379
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

BJ448 **PDUZZI - TTF** **NY LTANKS** **S104191606**
North **188 CHURCH ST** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.380 mi.
2008 ft. **Site 1 of 2 in cluster BJ**

Relative: **Higher**

Actual: **262 ft.**

LTANKS:

Name:	PDUZZI - TTF
Address:	188 CHURCH ST
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9905239 / 2009-12-16
Facility ID:	9905239
Site ID:	108306
Spill Date:	1999-07-31
Spill Cause:	Tank Test Failure
Spill Source:	Private Dwelling
Spill Class:	D3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	JBODEE
Referred To:	Not reported
Reported to Dept:	1999-07-31
CID:	196
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1999-07-31
Spill Record Last Update:	2022-03-17
Spiller Name:	EDWARD PDUZZI

PDUZZI - TTF (Continued) **S104191606**

Spiller Company:	EDWARD PDUZZI
Spiller Address:	188CHURCH ST
Spiller County:	001
Spiller Contact:	JOHN BUETI
Spiller Phone:	(914) 697-7654
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	276356
Latitude:	41.0513699
Longitude:	-73.7767000
DEC Memo:	06/18/05 SPILL FOUND ON DATABASE TODAY. TARRYTOWN SUB-OFFICE NEVER RECEIVED THIS SPILL REPORT FROM NEW PALTZ. jod 12/16/09 NFA JO'M
Remarks:	TANK TO BE UNCOVERED AND RETESTED.

All TTF:

Facility ID:	9905239
Spill Number:	9905239
Spill Tank Test:	1547440
Site ID:	108306
Tank Number:	1
Tank Size:	550
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	3.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	108306
Operable Unit ID:	1079671
Operable Unit:	01
Material ID:	301544
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	G
Recovered:	Not reported
Resource Affected:	Soil
Oxygenate:	Not reported

BE449
SE
1/4-1/2
0.382 mi.
2015 ft.

WHITE PLAINS-FIRE HOUSE 6
MAMARONECK & MAPLE AVE
WHITE PLAINS, NY

Site 2 of 4 in cluster BE

NY LTANKS **S100140233**
N/A

Relative:
Higher

Actual:
228 ft.

LTANKS:

Name:	WHITE PLAINS-FIRE HOUSE 6
Address:	MAMARONECK & MAPLE AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8707149 / 1989-01-05
Facility ID:	8707149
Site ID:	311048
Spill Date:	1987-11-19
Spill Cause:	Tank Test Failure
Spill Source:	Institutional, Educational, Gov., Other
Spill Class:	Not reported
Cleanup Ceased:	1989-01-05
SWIS:	6017
Investigator:	jeokesso
Referred To:	Not reported
Reported to Dept:	1987-11-19
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	1989-01-05
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1987-11-20
Spill Record Last Update:	1989-01-12
Spiller Name:	MR. BROCCHI
Spiller Company:	CITY OF WHITE PLAINS
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	251062
Latitude:	41.0274450
Longitude:	-73.7644691
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was OKESSON
Remarks:	2K SYSTEM- HIGH VOLUME LEAK.TO E & I & R. TANK REMOVED. NEW TANK INSTALLED

All TTF:

Facility ID:	8707149
Spill Number:	8707149
Spill Tank Test:	1532377
Site ID:	311048
Tank Number:	Not reported
Tank Size:	0
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported

WHITE PLAINS-FIRE HOUSE 6 (Continued) **S100140233**

Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	311048
Operable Unit ID:	911037
Operable Unit:	01
Material ID:	466122
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	Not reported
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

BE450 **WHITE PLAINS DPW** **UST FINDER RELEASE** **1029078598**
SE **MAPLE & MAMARONECK AVE** **N/A**
1/4-1/2 **WHITE PLAINS, NY 0**
0.382 mi.
2015 ft. **Site 3 of 4 in cluster BE**

Relative: **Higher**
Actual: **228 ft.**

UST FINDER RELEASE:

Object ID:	262543
Facility ID:	NY81978
Lust ID:	NY9111846
Name:	WHITE PLAINS DPW
Address:	MAPLE & MAMARONECK AVE
City,State,Zip:	WHITE PLAINS, NY 0
Address Match Type:	Not reported
Reported Date:	1992/02/18 15:59:59+00
Status:	No Further Action
Substance:	Not reported
Population within 1500ft:	4828
Domestic Wells within 1500ft:	0
Land Use:	Developed, High Intensity
Within SPA:	Yes
SPA PWS Facility ID:	NY7003493_76968
SPA Water Type:	SW - SurRELEASEe Water
SPA Facility Type:	RS - Reservoir
SPA HUC12:	20301020103
Within WHPA:	No
WHPA PWS Facility ID:	Not reported
WHPA Water Type:	Not reported
WHPA Facility Type:	Not reported
WHPA HUC12:	Not reported
Within 100yr Floodplain:	No
Tribe:	Not reported
EPA Region:	2
NFA Letter 1:	Not reported

WHITE PLAINS DPW (Continued) **1029078598**

NFA Letter 2:	Not reported
NFA Letter 3:	Not reported
NFA Letter 4:	Not reported
Closed With Residual Contaminate:	Not reported
Coordinate Source:	State
X Coord:	-73.76447
Y Coord:	41.02745
Latitude:	41.02745
Longitude:	-73.76447

BE451 **WHITE PLAINS DPW** **NY LTANKS** **S100177896**
SE **MAPLE & MAMARONECK AVE** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.382 mi.
2015 ft. **Site 4 of 4 in cluster BE**

Relative:
Higher

Actual:
228 ft.

LTANKS:

Name:	WHITE PLAINS DPW
Address:	MAPLE & MAMARONECK AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9111846 / 1992-03-10
Facility ID:	9111846
Site ID:	90852
Spill Date:	1992-02-18
Spill Cause:	Tank Failure
Spill Source:	Institutional, Educational, Gov., Other
Spill Class:	D3
Cleanup Ceased:	1992-02-18
SWIS:	6017
Investigator:	TAYLOR
Referred To:	Not reported
Reported to Dept:	1992-02-18
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	1992-02-18
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	True
Remediation Phase:	0
Date Entered In Computer:	1992-02-25
Spill Record Last Update:	1992-03-10
Spiller Name:	Not reported
Spiller Company:	SAME
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	81978
Latitude:	41.0274450
Longitude:	-73.7644691
DEC Memo:	Not reported
Remarks:	DURING UPGRADE TANK PULL CONTAMINATED SOIL DISCOVERED EXCAVATED AND STOCKPILED WILL TEST AND DISPOSED

All Materials:

WHITE PLAINS DPW (Continued) **S100177896**

Site ID:	90852
Operable Unit ID:	965509
Operable Unit:	01
Material ID:	567527
Material Code:	0009
Material Name:	gasoline
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	Not reported
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

BB452 **SEACON METAL - TTF** **NY LTANKS** **S131920570**
SW **7 INTERVALE STREET** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.386 mi.
2036 ft. **Site 2 of 2 in cluster BB**

Relative:
Higher

Actual:
208 ft.

LTANKS:

Name:	SEACON METAL - TTF
Address:	7 INTERVALE STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8904791 / 1989-11-30
Facility ID:	8904791
Site ID:	252170
Spill Date:	1989-08-14
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	D4
Cleanup Ceased:	1989-11-30
SWIS:	6017
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1989-08-14
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1989-08-21
Spill Record Last Update:	2024-02-07
Spiller Name:	Not reported
Spiller Company:	SEACON METAL
Spiller Address:	7 INTERVAIL ST.
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	206645
Latitude:	41.0271517
Longitude:	-73.7774406

SEACON METAL - TTF (Continued) **S131920570**

DEC Memo: 08/18/89: TANK IS TO BE CLEANED BY MONDAY 8/21/89. TANK TO BE REMOVED OR ABANDONED. 2/07/2024: Spill was reported as a tightness test failure on a 2k gallon heating oil UST. Reported as Seacon Metal at 7 Intervale Street. Westchester County PBS data lists Seacon Metal as being located at 12 Intervale, PBS 3-426903, with a 2k gallon heating oil UST closed/removed 1/1/1995. Westchester County PBS data lists 7 Intervale as Metro Auto Tech, PBS 3-800781, with two waste oil ASTs closed/removed 6/1/2005. jod
Remarks: 2K, PETRO, -.160, EXCAVATE, ISOLATE & RETEST ASAP

All TTF:

Facility ID:	8904791
Spill Number:	8904791
Spill Tank Test:	1535847
Site ID:	252170
Tank Number:	1
Tank Size:	2000
Material:	0001
EPA UST:	False
UST:	True
Cause:	00
Source:	99
Test Method:	66
Test Method 2:	Petro Tite II
Leak Rate:	Not reported
Gross Fail:	Not reported
Modified By:	JBODEE
Last Modified Date:	Not reported

All Materials:

Site ID:	252170
Operable Unit ID:	930043
Operable Unit:	01
Material ID:	448822
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	G
Recovered:	Not reported
Resource Affected:	Groundwater
Oxygenate:	Not reported

BK453 **35 PARK AVENUE** **NY LTANKS** **S105999311**
North **35 PARK AVENUE** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.387 mi.
2045 ft. **Site 1 of 2 in cluster BK**

Relative:
Higher

Actual:
291 ft.

LTANKS:

Name:	35 PARK AVENUE
Address:	35 PARK AVENUE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0303364 / 2010-06-29
Facility ID:	0303364
Site ID:	272501

35 PARK AVENUE (Continued) **S105999311**

Spill Date:	2003-06-30
Spill Cause:	Tank Test Failure
Spill Source:	Private Dwelling
Spill Class:	D5
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	jbodee
Referred To:	Not reported
Reported to Dept:	2003-06-30
CID:	204
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2003-06-30
Spill Record Last Update:	2010-06-29
Spiller Name:	DENNIS CHIULLI
Spiller Company:	35 PARK AVENUE
Spiller Address:	35 PARK AVENUE
Spiller County:	001
Spiller Contact:	MARTY MORGAN
Spiller Phone:	(914) 225-5240
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	221792
Latitude:	41.0376489
Longitude:	-73.7706610
DEC Memo:	6/29/10: File review. Report of a residential TTF. No indication of contamination noted on initial report. No updates or callback information from the dispatch desk. No further information received. jod
Remarks:	TANK TEST FAILURE

All TTF:

Facility ID:	0303364
Spill Number:	0303364
Spill Tank Test:	1528485
Site ID:	272501
Tank Number:	1
Tank Size:	550
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	272501

35 PARK AVENUE (Continued) **S105999311**

Operable Unit ID:	871411
Operable Unit:	01
Material ID:	504237
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

BA454 **SPILL NUMBER 0206553** **NY LTANKS S105996852**
East **300 MARTINE AVE** **NY Spills N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.389 mi.
2052 ft. **Site 3 of 3 in cluster BA**

Relative: LTANKS:
Higher

Name:	SPILL NUMBER 0206553
Address:	300 MARTINE AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0206553 / 2002-12-13
Facility ID:	0206553
Site ID:	293177
Spill Date:	2002-09-24
Spill Cause:	Tank Test Failure
Spill Source:	Private Dwelling
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	WCHD
Referred To:	Westchester Cnty Health Dept
Reported to Dept:	2002-09-24
CID:	211
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2002-09-24
Spill Record Last Update:	2003-03-25
Spiller Name:	Not reported
Spiller Company:	JAINE VOGHAN
Spiller Address:	209 GARTH RD
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	147087
Latitude:	41.0320547
Longitude:	-73.7633486
DEC Memo:	Not reported

Actual:
207 ft.

SPILL NUMBER 0206553 (Continued) **S105996852**

Remarks: gross leak coming from manhole cover - resealing manhole cover and retest

All TTF:

Facility ID:	0206553
Spill Number:	0206553
Spill Tank Test:	1527492
Site ID:	293177
Tank Number:	1
Tank Size:	10000
Material:	0002
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	293177
Operable Unit ID:	858167
Operable Unit:	01
Material ID:	517155
Material Code:	0002A
Material Name:	#4 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

SPILLS:

Name:	CEMMEL HOUSE BUILDING
Address:	300 MARTINE AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0311391 / 2004-01-08
Facility ID:	0311391
Facility Type:	ER
DER Facility ID:	147087
Site ID:	174952
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	C4
SWIS:	6017
Spill Date:	2004-01-08
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	2004-01-08
CID:	402
Water Affected:	Not reported

SPILL NUMBER 0206553 (Continued) **S105996852**

Spill Source:	Institutional, Educational, Gov., Other
Spill Notifier:	Other
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2004-01-08
Spill Record Last Update:	2004-01-13
Spiller Name:	Not reported
Spiller Company:	Not reported
Spiller Address:	Not reported
Spiller Company:	001
Contact Name:	JAMIE BARNABA
Latitude:	41.0320547
Longitude:	-73.7633486
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY 01/08/04: Mechanical failure from a fitting on boiler. Nick Barnaba reported cleanup completed tonight. NFA at this time. Not reported
Remarks:	Crew on scene to clean it up.

All Materials:

Site ID:	174952
Operable Unit ID:	879016
Operable Unit:	01
Material ID:	500202
Material Code:	0002A
Material Name:	#4 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	40.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

BG455 **SPILL NUMBER 0013009** **NY LTANKS** **S104950648**
South **1 EAST POST RD** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.390 mi.
2058 ft. **Site 10 of 11 in cluster BG**

Relative:
Higher

Actual:
208 ft.

LTANKS:

Name:	SPILL NUMBER 0013009
Address:	1 EAST POST RD
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0013009 / 2001-03-12
Facility ID:	0013009
Site ID:	156648
Spill Date:	2001-03-12
Spill Cause:	Tank Overfill
Spill Source:	Tank Truck
Spill Class:	C3
Cleanup Ceased:	Not reported

SPILL NUMBER 0013009 (Continued) **S104950648**

SWIS:	6017
Investigator:	dxtraver
Referred To:	Not reported
Reported to Dept:	2001-03-12
CID:	207
Water Affected:	Not reported
Spill Notifier:	Health Department
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2001-03-12
Spill Record Last Update:	2001-03-14
Spiller Name:	Not reported
Spiller Company:	FRANGO OIL CO
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	ELVIRA ALBANO
Spiller Phone:	(914) 684-9073
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	132543
Latitude:	41.0254718
Longitude:	-73.7710962
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was TRAVER 03/12/2001 WCDOH TO FOLLOW UP. NYSDEC SPILLS NO FURTHER ACTION. Not reported
Remarks:	cleanup in progress

All Materials:

Site ID:	156648
Operable Unit ID:	834948
Operable Unit:	01
Material ID:	539736
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	5.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

BD456 **JOHN LWHITE CONDO** **NY LTANKS** **S110140588**
SE **9 GREENRIDGE AVE** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.390 mi.
2059 ft. **Site 3 of 3 in cluster BD**

Relative: **Higher**

Actual: **260 ft.**

LTANKS:

Name:	JOHN LWHITE CONDO
Address:	9 GREENRIDGE AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0911533 / 2011-10-28
Facility ID:	0911533

JOHN LWHITE CONDO (Continued) **S110140588**

Site ID:	424347
Spill Date:	2010-01-27
Spill Cause:	Tank Test Failure
Spill Source:	Private Dwelling
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	jbodee
Referred To:	Not reported
Reported to Dept:	2010-01-27
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2010-01-27
Spill Record Last Update:	2020-02-14
Spiller Name:	KEN GELOK
Spiller Company:	JOHN L WHITE RESIDENCE
Spiller Address:	9 GREEN RIDGE AVE
Spiller County:	999
Spiller Contact:	KEN GELOK
Spiller Phone:	(201) 797-1909
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	373287
Latitude:	41.0262116
Longitude:	-73.7657583
DEC Memo:	Site is condominimum. Tank size is 5K. Caller states tank is registered with WCHD and he will notify WCHD. dt 1/27/10 5/13/11: Message sent to WCDOH requesting PBS info. jod From Lalak, Chris 6/10/2011 12:51 PM :: Wayne, Please follow up on these two old open spills 0912193 - 0911533 Chris --This is a PBS regulated facility. Wayne Schneider of WCDOH will follow up. jod 10/28/2011 As per WCDOH Greenridge estates. 1-13 Greenridge ave, white plains- passed retest NFA JO'M
Remarks:	TANK TEST FAILURE

All Materials:

Site ID:	424347
Operable Unit ID:	1180129
Operable Unit:	01
Material ID:	2173988
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported
Resource Affected:	Not reported
Oxygenate:	Not reported

457
ESE
1/4-1/2
0.393 mi.
2076 ft.

PIRRO, MONSELL REALTY
40 WALLER AVE
WHITE PLAINS, NY

NY LTANKS

S100139873
N/A

Relative:
Higher

Actual:
221 ft.

LTANKS:

Name:	PIRRO, MONSELL REALTY
Address:	40 WALLER AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8709325 / 1988-02-02
Facility ID:	8709325
Site ID:	162080
Spill Date:	1988-02-02
Spill Cause:	Tank Failure
Spill Source:	Commercial/Industrial
Spill Class:	Not reported
Cleanup Ceased:	1988-02-02
SWIS:	6017
Investigator:	jeokesso
Referred To:	Not reported
Reported to Dept:	1988-02-02
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	1988-02-02
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1988-02-09
Spill Record Last Update:	1988-02-10
Spiller Name:	MARIE TEDESCHI
Spiller Company:	JOE ZAHENSKY,914-478-5700
Spiller Address:	ROBISON OIL CORP.
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	136800
Latitude:	41.0281376
Longitude:	-73.7634695
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was OKESSON / / : WCHD NOTIFIED, RICH DORAN, SPILL IS CONTAINED. N.F.A. / / : 02-10-88 DRAIN IN CELLAR HAS CAP ON IT.
Remarks:	TANK RUPTURE IN BASEMENT 275GAL. A/G TANK. CEMENT FLOOR. USEING SPEEDY DRY TO CLEAN UP.

All Materials:

Site ID:	162080
Operable Unit ID:	914412
Operable Unit:	01
Material ID:	464653
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G

PIRRO, MONSELL REALTY (Continued) **S100139873**

Recovered: .00
Resource Affected: Soil
Oxygenate: Not reported

BL458 **APT BUILDING** **NY LTANKS** **S102153144**
ENE **16 NORTH BROADWAY** **NY Spills** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.395 mi.
2087 ft. **Site 1 of 2 in cluster BL**

Relative:
Higher

Actual:
227 ft.

LTANKS:
Name: APARTMENT BUILDING
Address: 16 NORTH BROADWAY
City,State,Zip: WHITE PLAINS, NY
Spill Number/Closed Date: 0701599 / 2007-12-12
Facility ID: 0701599
Site ID: 381144
Spill Date: 2007-05-08
Spill Cause: Tank Test Failure
Spill Source: Private Dwelling
Spill Class: B3
Cleanup Ceased: Not reported
SWIS: 6017
Investigator: WCHD
Referred To: WCDOH
Reported to Dept: 2007-05-08
CID: 408
Water Affected: Not reported
Spill Notifier: Tank Tester
Last Inspection: Not reported
Recommended Penalty: False
Meets Standard: False
UST Involvement: False
Remediation Phase: 0
Date Entered In Computer: 2007-05-08
Spill Record Last Update: 2007-12-12
Spiller Name: ARLENE
Spiller Company: APARTMENT BUILDING
Spiller Address: 16 NORTH BROADWAY
Spiller County: 001
Spiller Contact: ARLENE
Spiller Phone: (914) 779-0405
Spiller Extention: Not reported
DEC Region: 3
DER Facility ID: 90153
Latitude: 41.0352716
Longitude: -73.7627786
DEC Memo: 07/31/07 Repaired and retested and closed by D Jackson - WCHD. TG
Remarks: MINIAMAL AMOUNT RELEASED;

All TTF:
Facility ID: 0701599
Spill Number: 0701599
Spill Tank Test: 1550827
Site ID: 381144
Tank Number: 1
Tank Size: 10000

APT BUILDING (Continued) **S102153144**

Material:	0002
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Watchdog
Last Modified Date:	Not reported

All Materials:

Site ID:	381144
Operable Unit ID:	1138611
Operable Unit:	01
Material ID:	2128606
Material Code:	0002A
Material Name:	#4 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

Name:	APT BUILDING
Address:	16 NORTH BROADWAY
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0412306 / 2005-08-27
Facility ID:	0412306
Site ID:	337751
Spill Date:	2005-02-17
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	B3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	JBODEE
Referred To:	WCDOH
Reported to Dept:	2005-02-17
CID:	74
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2005-02-18
Spill Record Last Update:	2023-10-27
Spiller Name:	Not reported
Spiller Company:	Not reported
Spiller Address:	Not reported
Spiller County:	001

APT BUILDING (Continued) **S102153144**

Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	90153
Latitude:	41.0350760
Longitude:	-73.7634180
DEC Memo:	August 27, 2005: PBS SITE. TANK PASSED RETEST. SPILL FILE CLOSED BY DANIELLE JACKSON OF THE WESTCHESTER COUNTY HEALTH DEPT. NO FURTHER ACTION IS REQUIRED AT THIS TIME. jod
Remarks:	PBS No: 3-167223

All TTF:

Facility ID:	0412306
Spill Number:	0412306
Spill Tank Test:	1548607
Site ID:	337751
Tank Number:	1
Tank Size:	10000
Material:	Not reported
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Watchdog
Last Modified Date:	Not reported

SPILLS:

Name:	VAULT 3688
Address:	16 NORTH BROADWAY
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	1104037 / 2011-07-12
Facility ID:	1104037
Facility Type:	ER
DER Facility ID:	90153
Site ID:	451622
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	C3
SWIS:	6017
Spill Date:	2011-07-12
Investigator:	kabrowne
Referred To:	Not reported
Reported to Dept:	2011-07-12
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Other
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	Not reported

APT BUILDING (Continued) **S102153144**

UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2011-07-12
Spill Record Last Update:	2011-09-30
Spiller Name:	ERT
Spiller Company:	CON ED
Spiller Address:	16 NORTH BROADWAY
Spiller Company:	999
Contact Name:	ERT
Latitude:	41.0352716
Longitude:	-73.7627786
DEC Memo:	Not reported
Remarks:	Caller reporting a spill of an unknown material contained in concrete Structure. Clean up pending identification.

All Materials:

Site ID:	451622
Operable Unit ID:	1201809
Operable Unit:	01
Material ID:	2198370
Material Code:	0064A
Material Name:	unknown material
Case No.:	Not reported
Material FA:	Other
Quantity:	Not reported
Units:	G
Recovered:	Not reported
Resource Affected:	Not reported
Oxygenate:	Not reported

Name:	APT. BUILDING
Address:	16 NORTH BROADWAY
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8802449 / 1988-06-30
Facility ID:	8802449
Facility Type:	ER
DER Facility ID:	90153
Site ID:	101750
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	Not reported
SWIS:	6017
Spill Date:	1988-06-16
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1988-06-17
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Institutional, Educational, Gov., Other
Spill Notifier:	Health Department
Cleanup Ceased:	1988-06-22
Cleanup Meets Std:	True
Last Inspection:	1988-06-22
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	1988-06-24

APT BUILDING (Continued) **S102153144**

Spill Record Last Update:	1988-03-23
Spiller Name:	Not reported
Spiller Company:	SAME
Spiller Address:	Not reported
Spiller Company:	001
Contact Name:	Not reported
Latitude:	41.0350822
Longitude:	-73.7634228
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY 06/30/88: RUPTURED RETURN LINE REPAIRED FROM TANK TO BOILER. CONTAMINATED SOIL EXCAVATED AND REMOVED. 06/30/88: RUPTURED RETURN LINE REPLACED FROM TANK TO BOILER. CONTAMINATED SOIL EXCAVATED AND REMOVED.
Remarks:	#6 FUEL OIL LEAKED OUT EXCAVATE THE SOIL AND DEBRIS

All Materials:

Site ID:	101750
Operable Unit ID:	919673
Operable Unit:	01
Material ID:	458015
Material Code:	0003A
Material Name:	#6 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	125.00
Units:	G
Recovered:	125.00
Resource Affected:	Soil
Oxygenate:	Not reported

BF459 **BUILDING** **NY LTANKS S102155428**
ENE **20 NORTH BROADWAY** **NY Spills N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.395 mi.
2088 ft. **Site 2 of 2 in cluster BF**

Relative: **Higher**
Actual: **229 ft.**

LTANKS:

Name:	APT COMPLEX
Address:	20 NORTH BROADWAY
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0111039 / 2002-03-11
Facility ID:	0111039
Site ID:	84678
Spill Date:	2002-02-20
Spill Cause:	Tank Failure
Spill Source:	Commercial/Industrial
Spill Class:	A3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	jbodee
Referred To:	Not reported
Reported to Dept:	2002-02-20
CID:	397
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported

BUILDING (Continued) **S102155428**

Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2002-02-20
Spill Record Last Update:	2002-12-04
Spiller Name:	Not reported
Spiller Company:	APT COMPLEX
Spiller Address:	Not reported
Spiller County:	999
Spiller Contact:	CALLER
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	77855
Latitude:	41.0353273
Longitude:	-73.7635967
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was O'DEE 03/11/02 NORTHEAST REMOVED TANK AND DISPOSED OF 364 CUBIC YARDS OF CONTAMINATED SOIL.
Remarks:	caller co was removing tank and discovered soil contamination

All Materials:

Site ID:	84678
Operable Unit ID:	848108
Operable Unit:	01
Material ID:	528641
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	BUILDING
Address:	20 NORTH BROADWAY
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0800897 / 2008-06-08
Facility ID:	0800897
Site ID:	396726
Spill Date:	2008-04-22
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	jbodee
Referred To:	WCDOH
Reported to Dept:	2008-04-22
CID:	444
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False

BUILDING (Continued) **S102155428**

Meets Standard:	True
UST Involvement:	Not reported
Remediation Phase:	0
Date Entered In Computer:	2008-04-22
Spill Record Last Update:	2008-06-08
Spiller Name:	ISSAC
Spiller Company:	BUILDING
Spiller Address:	20 NORTH BROADWAY
Spiller County:	001
Spiller Contact:	ISSAC
Spiller Phone:	(718) 378-3000
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	77855
Latitude:	41.0357217
Longitude:	-73.7628286
DEC Memo:	PBS 3-167320 June 8, 2008: Tank passed a retest after piping was repaired. Based upon information provided to DEC, no further action is required at this time. jod
Remarks:	FAILED DRY LEAK

All TTF:

Facility ID:	0800897
Spill Number:	0800897
Spill Tank Test:	2453566
Site ID:	396726
Tank Number:	Not reported
Tank Size:	5000
Material:	0001
EPA UST:	Not reported
UST:	True
Cause:	Not reported
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Watchdog
Last Modified Date:	Not reported

All Materials:

Site ID:	396726
Operable Unit ID:	1153696
Operable Unit:	01
Material ID:	2144464
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

BUILDING (Continued) **S102155428**

SPILLS:

Name:	BROADLAWN APART.
Address:	20 NORTH BROADWAY
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9500251 / 1997-12-05
Facility ID:	9500251
Facility Type:	ER
DER Facility ID:	77855
Site ID:	84679
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	C3
SWIS:	6017
Spill Date:	1995-04-06
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1995-04-06
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Private Dwelling
Spill Notifier:	Other
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	1995-04-18
Spill Record Last Update:	1997-12-05
Spiller Name:	Not reported
Spiller Company:	Not reported
Spiller Address:	Not reported
Spiller Company:	001
Contact Name:	Not reported
Latitude:	41.0353273
Longitude:	-73.7635967
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY
Remarks:	DEFECTIVE GUAGE TANK OVERFILL ON CONCRETE FLOOR CONTRACTOR DOING CLEAN UP

All Materials:

Site ID:	84679
Operable Unit ID:	1011023
Operable Unit:	01
Material ID:	368859
Material Code:	0003A
Material Name:	#6 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	L
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

BUILDING (Continued) **S102155428**

Name:	APARTMENT BLDG
Address:	20 NORTH BROADWAY
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9808000 / 2002-04-01
Facility ID:	9808000
Facility Type:	ER
DER Facility ID:	77855
Site ID:	84680
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	C4
SWIS:	6017
Spill Date:	1998-09-30
Investigator:	jbodee
Referred To:	Not reported
Reported to Dept:	1998-09-30
CID:	252
Water Affected:	Not reported
Spill Source:	Institutional, Educational, Gov., Other
Spill Notifier:	Other
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	1998-09-30
Spill Record Last Update:	2003-09-09
Spiller Name:	WES WOODLEAF
Spiller Company:	APARTMENT BLDG
Spiller Address:	20 NORTH BROADWAY
Spiller Company:	001
Contact Name:	WES WOODLEAF
Latitude:	41.0353273
Longitude:	-73.7635967
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was O'DEE 04/01/2002 SEE NORTHEAST ENVIRONMENTAL UST REMEDIATION REPORT UNDER SPILL NUMBER 01-11039. NO FURTHER ACTION.
Remarks:	OIL LINES HAVE BEEN EXCAVATED FROM TANK TO BLDG-PIPES HAVE A CRACK IN THEM RUNNING THROUGH FOUNDATION-BOIL HAS BEEN SHUT DOWN AND LEAK TO BE REPAIRED. NORTH EAST ENVIRONMENTAL ON SITE FOR REMOVAL OF CONTAMINATED SOIL.

All Materials:

Site ID:	84680
Operable Unit ID:	1065560
Operable Unit:	01
Material ID:	315536
Material Code:	0003A
Material Name:	#6 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

BL460 **CON ED** **NY LTANKS** **S105998980**
ENE **10 NORTH BROADWAY** **NY Spills** **N/A**
1/4-1/2 **WHITE PLAINS, NY 10601** **NY MANIFEST**
0.396 mi.
2091 ft. **Site 2 of 2 in cluster BL**

Relative:
Higher

Actual:
222 ft.

LTANKS:

Name:	APARTMENT COMPLEX
Address:	10 NORTH BROADWAY
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0301652 / 2003-12-12
Facility ID:	0301652
Site ID:	302706
Spill Date:	2003-05-15
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	WCHD
Referred To:	Westchester Cnty Health Dept
Reported to Dept:	2003-05-15
CID:	282
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2003-05-15
Spill Record Last Update:	2003-12-12
Spiller Name:	DONNA
Spiller Company:	BROOK PROPERTIES
Spiller Address:	60 MORROW AVE
Spiller County:	001
Spiller Contact:	RENE LEWIS
Spiller Phone:	(718) 378-7000
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	244561
Latitude:	41.0347280
Longitude:	-73.7631558
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was WCHD-JACKSON 12/12/03 TANK PASSED RETEST 6/6/03. CLOSED BY WCHD.
Remarks:	TANK FAILED THE TEST.

All TTF:

Facility ID:	0301652
Spill Number:	0301652
Spill Tank Test:	1528379
Site ID:	302706
Tank Number:	1
Tank Size:	7500
Material:	0003
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	03

CON ED (Continued) **S105998980**

Test Method 2: Horner EZ Check I or II
Leak Rate: .00
Gross Fail: Not reported
Modified By: Spills
Last Modified Date: Not reported

All Materials:
Site ID: 302706
Operable Unit ID: 868209
Operable Unit: 01
Material ID: 506144
Material Code: 0003A
Material Name: #6 fuel oil
Case No.: Not reported
Material FA: Petroleum
Quantity: .00
Units: G
Recovered: .00
Resource Affected: Soil
Oxygenate: Not reported

SPILLS:
Name: APARTMENT COMPLEX
Address: 10 NORTH BROADWAY
City,State,Zip: WHITE PLAINS, NY
Spill Number/Closed Date: 0908496 / 2010-10-01
Facility ID: 0908496
Facility Type: ER
DER Facility ID: 244561
Site ID: 421100
DEC Region: 3
Spill Cause: Equipment Failure
Spill Class: C3
SWIS: 6017
Spill Date: 2009-10-28
Investigator: JKOMARA
Referred To: Not reported
Reported to Dept: 2009-10-28
CID: Not reported
Water Affected: Not reported
Spill Source: Commercial/Industrial
Spill Notifier: Other
Cleanup Ceased: Not reported
Cleanup Meets Std: False
Last Inspection: Not reported
Recommended Penalty: False
UST Trust: False
Remediation Phase: 0
Date Entered In Computer: 2009-10-28
Spill Record Last Update: 2010-10-01
Spiller Name: Not reported
Spiller Company: ABEL GONZOLES
Spiller Address: Not reported
Spiller Company: 999
Contact Name: SAME AS ABOVE

CON ED (Continued) **S105998980**

Latitude:	41.0348716
Longitude:	-73.7627586
DEC Memo:	10-28-09: V.Mc. ^ JAMES WILSON/R&D SER.: Apt.complex, 7.5K UST, installed 1953, R&D to recomment EIR. 10/1/10 As per WCDOH Tibbets Apartments, 10 North Broadway, White Plains can be closed. Tightness test failure. Tank discovered to be leaking #6 oil, removed. Remediation completed. Numbers are ok. NFA JO'M
Remarks:	Unk amount of # 6 oil spilled due to leak in underground tank. Clean up is pending at this time.

All Materials:

Site ID:	421100
Operable Unit ID:	1177035
Operable Unit:	01
Material ID:	2169776
Material Code:	0003A
Material Name:	#6 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported
Resource Affected:	Soil
Oxygenate:	Not reported

NY MANIFEST:

EPA ID:	NYP004849257
Country:	USA
Name:	Con Ed
Address:	10 NORTH BROADWAY
Address 2:	SB 3687
City,State,Zip:	WHITE PLAINS, NY 10601
Zip 4:	Not reported
Location Address 1:	10 NORTH BROADWAY
Location Address 2:	SB 3687
Location City,State,Zip:	WHITE PLAINS, NY 10601
Location Zip 4:	Not reported
Facility Status:	Not reported
Total Tanks:	Not reported
Code:	BP

Mailing:

Mailing Name:	Con Ed
Mailing Contact:	Tom Teeling
Mailing Address 1:	4 IRVING PLACE - 15TH FLOOR
Mailing Address 2:	Not reported
Mailing City,State,Zip:	NEW YORK, NY 10003
Mailing Zip 4:	Not reported
Mailing Country:	USA
Mailing Phone:	2124603770

Manifest Data:

Document ID:	Not reported
Manifest Status:	Not reported

CON ED (Continued) **S105998980**

Trans1 State ID:	NYD006982359
Year:	2018
Trans2 State ID:	Not reported
Generator Ship Date:	10/07/2015
Trans1 Recv Date:	10/07/2015
Trans2 Recv Date:	Not reported
TSD Site Recv Date:	10/09/2015
Part A Recv Date:	Not reported
Part B Recv Date:	Not reported
Generator EPA ID:	NYP004849257
Trans1 EPA ID:	Not reported
Trans2 EPA ID:	Not reported
TSDF ID 1:	NJD002200046
TSDF ID 2:	Not reported
Manifest Tracking Number:	013245150JJK
Import Indicator:	N
Export Indicator:	N
Discr Quantity Indicator:	N
Discr Type Indicator:	N
Discr Residue Indicator:	N
Discr Partial Reject Indicator:	N
Discr Full Reject Indicator:	N
Manifest Ref Number:	Not reported
Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Lead
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Not reported
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	20
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

BG461 **BISCARDI CLEANERS** **NY LTANKS** **S110246037**
South **201 SO. LEXINGTON AVE.** **NY Spills** **N/A**
1/4-1/2 **WHITE PLAINS, NY 10601** **NY DRYCLEANERS**
0.397 mi.
2095 ft. **Site 11 of 11 in cluster BG**

Relative: **Higher**
Actual: **209 ft.**

LTANKS:

Name:	BISSCARDI CLEANERS
Address:	201 SOUTH LEXINGTON AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0100630 / 2006-05-01
Facility ID:	0100630

BISCARDI CLEANERS (Continued) **S110246037**

Site ID:	322267
Spill Date:	2001-04-17
Spill Cause:	Tank Failure
Spill Source:	Commercial/Industrial
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	JBODee
Referred To:	Not reported
Reported to Dept:	2001-04-17
CID:	382
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2001-04-17
Spill Record Last Update:	2006-05-01
Spiller Name:	Not reported
Spiller Company:	BISSCARDI CLEANERS
Spiller Address:	201 SOUTH LEXINGTON AVE
Spiller County:	001
Spiller Contact:	BISSCARDI CLEANERS
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	259613
Latitude:	41.0254270
Longitude:	-73.7711208
DEC Memo:	04/17/2001 275 GALLON A/G. NORTHEAST ENVIRONMENTAL RESPONDING -QUANTITY LOST UNKNOWN AT THIS TIME. 150 GALLONS LOST.
Remarks:	tank let go at location. unknown how much oil on floor of basement.

All Materials:

Site ID:	322267
Operable Unit ID:	839472
Operable Unit:	01
Material ID:	536346
Material Code:	0032C
Material Name:	wood alcohol
Case No.:	00067561
Material FA:	Hazardous Material
Quantity:	150.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

SPILLS:

Name:	ALBANO
Address:	201 SOUTH LEXINGTON AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0013010 / 2001-03-12
Facility ID:	0013010

BISCARDI CLEANERS (Continued) **S110246037**

Facility Type:	ER
DER Facility ID:	259613
Site ID:	254787
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	C4
SWIS:	6017
Spill Date:	2001-03-12
Investigator:	dxtraver
Referred To:	Not reported
Reported to Dept:	2001-03-12
CID:	323
Water Affected:	Not reported
Spill Source:	Private Dwelling
Spill Notifier:	Other
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2001-03-12
Spill Record Last Update:	2005-05-15
Spiller Name:	Not reported
Spiller Company:	TJ NETHERCOTT
Spiller Address:	Not reported
Spiller Company:	001
Contact Name:	TERRY NETHERCOTT
Latitude:	41.0254270
Longitude:	-73.7711208
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was TRAVER 03/12/2001 WCDOH WAS ON SITE ACCORDING TO SPILLER. MINOR SPILL DUE TO LOOSE GAUGE FITTING. CLEANUP TO BE COMPLETED BY SPILLER. NO FURTHER ACTION.
Remarks:	GUAGE ON TANK FAILED. SPILL CLEANED UP, GAUGE REPLACED.

All Materials:

Site ID:	254787
Operable Unit ID:	834546
Operable Unit:	01
Material ID:	539737
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	1.00
Units:	G
Recovered:	1.00
Resource Affected:	Soil
Oxygenate:	Not reported

DRYCLEANERS:

Name:	BISCARDI CLEANERS
Address:	201 SO. LEXINGTON AVE.
City,State,Zip:	WHITE PLAINS, NY 10601

BISCARDI CLEANERS (Continued) **S110246037**

Facility ID:	3-5517-00279
Phone Number:	914-684-9073
Region:	Not reported
Registration Effective Date:	N/A
Inspection Date:	04/12/1930
Install Date:	92/12
Expiration Date:	Not reported
Removal Date:	Not reported
Drop Shop:	Not reported
Shutdown:	Y
Alternate Solvent:	Not reported
Current Business:	Not reported

BM462 **HART RESIDENCE** **NY LTANKS** **S112810201**
NNW **77 PARK AVE** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.398 mi.
2101 ft. **Site 1 of 2 in cluster BM**

Relative: **Higher**

Actual: **301 ft.**

LTANKS:

Name:	HART RESIDENCE
Address:	77 PARK AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	1214615 / 2013-04-22
Facility ID:	1214615
Site ID:	477863
Spill Date:	2013-01-14
Spill Cause:	Tank Test Failure
Spill Source:	Private Dwelling
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	TDGHIOSA
Referred To:	Not reported
Reported to Dept:	2013-01-15
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2013-01-15
Spill Record Last Update:	2013-04-22
Spiller Name:	Not reported
Spiller Company:	FAILED TANK TANK TEST
Spiller Address:	Not reported
Spiller County:	999
Spiller Contact:	PAUL SCORZELLI
Spiller Phone:	(914) 557-3491
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	433168
Latitude:	41.0375417
Longitude:	-73.7737386
DEC Memo:	1-15-13 Spoke with Paul Scorzelli. He was testing tank for potential buyer. Listing agent for property is Dorothy Mamdar at 914-771-8500

HART RESIDENCE (Continued) **S112810201**

x120. Called and left message for Dorothy to return call to dispatch desk. jm
Remarks: Calling in for the buyer of the property.

All Materials:
Site ID: 477863
Operable Unit ID: 1227661
Operable Unit: 01
Material ID: 2225104
Material Code: 0001A
Material Name: #2 fuel oil
Case No.: Not reported
Material FA: Petroleum
Quantity: Not reported
Units: Not reported
Recovered: Not reported
Resource Affected: Not reported
Oxygenate: Not reported

463
SSW
1/4-1/2
0.398 mi.
2101 ft.

PARKER RES **NY LTANKS** **S108298451**
3 WYANOKE STREET **N/A**
WHITE PLAINS, NY

Relative:
Higher

Actual:
248 ft.

LTANKS:
Name: WINSTON HOME
Address: 3 WYANOKE STREET
City,State,Zip: WHITE PLAINS, NY
Spill Number/Closed Date: 0610630 / 2007-02-06
Facility ID: 0610630
Site ID: 375107
Spill Date: 2006-12-19
Spill Cause: Tank Failure
Spill Source: Private Dwelling
Spill Class: C4
Cleanup Ceased: Not reported
SWIS: 6017
Investigator: JBODee
Referred To: Not reported
Reported to Dept: 2006-12-19
CID: 444
Water Affected: Not reported
Spill Notifier: Other
Last Inspection: Not reported
Recommended Penalty: False
Meets Standard: True
UST Involvement: False
Remediation Phase: 0
Date Entered In Computer: 2006-12-19
Spill Record Last Update: 2007-02-06
Spiller Name: WINSTON PARKER
Spiller Company: WINSTON HOME
Spiller Address: 3 WYANOKE STREET
Spiller County: 001
Spiller Contact: WINSTON PARKER
Spiller Phone: (914) 316-0784

PARKER RES (Continued) **S108298451**

Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	321454
Latitude:	41.0256317
Longitude:	-73.7752486
DEC Memo:	PREVIOUSLY REPORTED TTFs ARE 06-07149 AND 06-07758 February 6, 2007: NORTHEAST ENVIRONMENTAL DISPOSED OF LUST AND 2 DRUMS OF CONTAMINATED SOIL. CLOSURE REPORT REVIEWED BY DEC. BASED UPON INFORMATION PROVIDED, NO FURTHER ACTION IS REQUIRED AT THIS TIME. jod
Remarks:	1000 GALLON TANK HAD HOLES AND CONTAMINATED SOIL

All Materials:

Site ID:	375107
Operable Unit ID:	1132758
Operable Unit:	01
Material ID:	2122543
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	RESIDENCE
Address:	3 WYANOKE STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0607149 / 2007-02-06
Facility ID:	0607149
Site ID:	370661
Spill Date:	2006-09-21
Spill Cause:	Tank Test Failure
Spill Source:	Private Dwelling
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	JBODee
Referred To:	Not reported
Reported to Dept:	2006-09-21
CID:	410
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2006-09-21
Spill Record Last Update:	2007-02-06
Spiller Name:	JUAN ROSAS
Spiller Company:	RESIDENCE
Spiller Address:	3 WYANOKE STREET
Spiller County:	001
Spiller Contact:	JUAN ROSAS
Spiller Phone:	(914) 671-1924

PARKER RES (Continued) **S108298451**

Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	321454
Latitude:	41.0256317
Longitude:	-73.7752486
DEC Memo:	(D. Weitz) Elite was called in by prospective buyer of property. A proposal has been sent to the owners to dig up top of tank & retest. See spills 06-07758 and 06-10630. NFA jod
Remarks:	None:

All TTF:

Facility ID:	0607149
Spill Number:	0607149
Spill Tank Test:	1550297
Site ID:	370661
Tank Number:	1
Tank Size:	550
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Watchdog
Last Modified Date:	Not reported

All Materials:

Site ID:	370661
Operable Unit ID:	1128450
Operable Unit:	01
Material ID:	2118064
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	PARKER RES
Address:	3 WYANOKE STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0607758 / 2007-02-06
Facility ID:	0607758
Site ID:	371575
Spill Date:	2006-10-07
Spill Cause:	Tank Test Failure
Spill Source:	Private Dwelling
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6017

PARKER RES (Continued) **S108298451**

Investigator:	JBODee
Referred To:	Not reported
Reported to Dept:	2006-10-07
CID:	27
Water Affected:	Not reported
Spill Notifier:	Local Agency
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2006-10-07
Spill Record Last Update:	2007-02-06
Spiller Name:	Not reported
Spiller Company:	PARKER RES
Spiller Address:	3 WYANOKE STREET
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	(914) 316-0784
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	321454
Latitude:	41.0256317
Longitude:	-73.7752486
DEC Memo:	Previously reported TTF is 06-07149 See spill 06-10630 for closure. NFA jod
Remarks:	Winston Parker tank failed due to bubbling.

All TTF:

Facility ID:	0607758
Spill Number:	0607758
Spill Tank Test:	1550343
Site ID:	371575
Tank Number:	1
Tank Size:	1000
Material:	Not reported
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	21
Test Method 2:	Horner EZY3/EZY3 Locator Plus
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	JBODee
Last Modified Date:	Not reported

BC464 **PATRIOT MANAGEMENT** **NY LTANKS** **S100165922**
ENE **2 WESTCHESTER AVE** **NY Spills** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.399 mi.
2108 ft. **Site 3 of 3 in cluster BC**

Relative:
Higher

Actual:
218 ft.

LTANKS:

Name:	PRESIDENTIAL MANAGEMENT
Address:	2 WESTCHESTER AVE
City,State,Zip:	WHITE PLAINS, NY

PATRIOT MANAGEMENT (Continued) **S100165922**

Spill Number/Closed Date:	8800351 / 2004-05-06
Facility ID:	8800351
Site ID:	322460
Spill Date:	1988-04-11
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	jbodee
Referred To:	Not reported
Reported to Dept:	1988-04-11
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1988-05-02
Spill Record Last Update:	2004-05-10
Spiller Name:	Not reported
Spiller Company:	SAME
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	259772
Latitude:	41.0341199
Longitude:	-73.7627270
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was O'DEE 05/06/04 TANK WAS REMOVED IN 1988 BUT NO CLOSURE REPORT WAS SUBMITTED. ON 4-6-2004, PROPERTY OWNER HAD SOIL SAMPLES TAKEN FROM BORING IN AREA OF ORIGINAL TANK GRAVE. SAMPLE RESULTS FROM ADVANCED TANK SERVICES WERE ND. BASED UPON REPORT, NFA REQUIRED. jbo
Remarks:	5K TANK, LEAK RATE GREATER THAN 10GPH. PUMP TANK OUT.

All TTF:

Facility ID:	8800351
Spill Number:	8800351
Spill Tank Test:	1533629
Site ID:	322460
Tank Number:	Not reported
Tank Size:	0
Material:	0003
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

PATRIOT MANAGEMENT (Continued) **S100165922**

All Materials:

Site ID:	322460
Operable Unit ID:	915986
Operable Unit:	01
Material ID:	463066
Material Code:	0003A
Material Name:	#6 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

SPILLS:

Name:	PATRIOT MANAGEMENT
Address:	2 WESTCHESTER AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	1112238 / 2012-01-20
Facility ID:	1112238
Facility Type:	ER
DER Facility ID:	259772
Site ID:	460167
DEC Region:	3
Spill Cause:	Human Error
Spill Class:	C3
SWIS:	6017
Spill Date:	2012-01-20
Investigator:	VPMCCABE
Referred To:	Not reported
Reported to Dept:	2012-01-20
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Responsible Party
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2012-01-20
Spill Record Last Update:	2012-01-20
Spiller Name:	MIKE/ROBISON OIL
Spiller Company:	ROBISON OIL
Spiller Address:	2 WESTCHESTER AVE
Spiller Company:	999
Contact Name:	ROBISON OIL
Latitude:	41.0342017
Longitude:	-73.7621486
DEC Memo:	1-20-12: V.Mc. call to MIKE/ Rob.Oil: Outside Ab.Gr.vaulted tank, spilled onto concrete slab to tank. Crew on site completing clean up, expecting to finish clean up today. NFA.

PATRIOT MANAGEMENT (Continued) **S100165922**

Remarks: Overfill spilled onto concrete pad. Cleanup underway.

All Materials:

Site ID:	460167
Operable Unit ID:	1210261
Operable Unit:	01
Material ID:	2207863
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	5.00
Units:	G
Recovered:	Not reported
Resource Affected:	Soil
Oxygenate:	Not reported

BM465 **GABERIAL** **NY LTANKS** **S104621388**
NNW **7 FAIRVIEW AVE** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.403 mi.
2128 ft. **Site 2 of 2 in cluster BM**

Relative: **Higher**

Actual: **288 ft.**

LTANKS:

Name:	GABERIAL
Address:	7 FAIRVIEW AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0000372 / 2000-10-13
Facility ID:	0000372
Site ID:	65789
Spill Date:	2000-04-10
Spill Cause:	Tank Test Failure
Spill Source:	Private Dwelling
Spill Class:	D4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	jbodee
Referred To:	Not reported
Reported to Dept:	2000-04-10
CID:	270
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2000-04-10
Spill Record Last Update:	2000-10-20
Spiller Name:	THEO GABERIAL
Spiller Company:	MR GABERIAL
Spiller Address:	7 FAIRVIEW AV
Spiller County:	001
Spiller Contact:	THEO GABERIAL
Spiller Phone:	(914) 948-2886
Spiller Extention:	Not reported
DEC Region:	3

GABERIAL (Continued) **S104621388**

DER Facility ID:	63092
Latitude:	41.0376116
Longitude:	-73.7742134
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was O'DEE 10/13/2000 TANK FAILED AN ISOLATION RETEST. TANK PULLED BY BARNABA GROUP WITH OVERSITE FROM ERM FOR HOMEOWNER'S INSURANCE. TANK WAS FOUND TO HAVE HOLES BUT NO CONTAMINATION WAS FOUND. NFA
Remarks:	UNCOVER ISOLATE AND RETEST

All TTF:

Facility ID:	0000372
Spill Number:	0000372
Spill Tank Test:	1525468
Site ID:	65789
Tank Number:	1
Tank Size:	550
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	1.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	65789
Operable Unit ID:	822087
Operable Unit:	01
Material ID:	288622
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

BJ466 **SPILL NUMBER 0209590** **NY LTANKS** **S105997663**
North **25 PARK AVE** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.404 mi.
2135 ft. **Site 2 of 2 in cluster BJ**

Relative:
Higher

Actual:
274 ft.

LTANKS:

Name:	SPILL NUMBER 0209590
Address:	25 PARK AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0209590 / 2002-12-18
Facility ID:	0209590
Site ID:	206038
Spill Date:	2002-12-18

SPILL NUMBER 0209590 (Continued) **S105997663**

Spill Cause:	Tank Overfill
Spill Source:	Private Dwelling
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	jghardy
Referred To:	Not reported
Reported to Dept:	2002-12-18
CID:	257
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2002-12-18
Spill Record Last Update:	2003-05-12
Spiller Name:	DR. INCH
Spiller Company:	Not reported
Spiller Address:	25 PARK AVE
Spiller County:	001
Spiller Contact:	DR. INCH
Spiller Phone:	(914) 693-8193
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	171101
Latitude:	41.0379219
Longitude:	-73.7694870
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was HARDY
Remarks:	tried to fill a tank that was full

All Materials:

Site ID:	206038
Operable Unit ID:	860847
Operable Unit:	01
Material ID:	513010
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	15.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

BN467 **WHITE PLAINS PRESBYTERIAN CHURCH** **NY LTANKS** **S100139602**
NE **39 NORTH BROADWAY** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.405 mi.
2139 ft. **Site 1 of 3 in cluster BN**

Relative:
Higher

Actual:
256 ft.

LTANKS:

Name:	PRESBYTERIAN CHURCH
Address:	39 NORTH BROADWAY
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8705816 / 1988-03-04
Facility ID:	8705816
Site ID:	120033
Spill Date:	1987-10-09
Spill Cause:	Tank Test Failure
Spill Source:	Institutional, Educational, Gov., Other
Spill Class:	C3
Cleanup Ceased:	1988-03-04
SWIS:	6017
Investigator:	jeokesso
Referred To:	Not reported
Reported to Dept:	1987-10-09
CID:	Not reported
Water Affected:	NONE
Spill Notifier:	Tank Tester
Last Inspection:	1988-03-04
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1987-11-18
Spill Record Last Update:	2003-08-20
Spiller Name:	JACK JONES
Spiller Company:	SAME
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	104243
Latitude:	41.0368609
Longitude:	-73.7654952
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was OKESSON / / : 10/13/87-WILL RETEST. / / : 02-16-88 TANK HAS BEEN RELINED & REFILLED. WILL RETEST ASAP. WILL CALL IN RESULTS. L.R. 03/04/88: TANK PASSED RETEST. N.F.A. L.R.
Remarks:	TTTF-8K TANK;-0.253 GPH

All TTF:

Facility ID:	8705816
Spill Number:	8705816
Spill Tank Test:	1531881
Site ID:	120033
Tank Number:	Not reported
Tank Size:	0
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported

WHITE PLAINS PRESBYTERIAN CHURCH (Continued) **S100139602**

Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	120033
Operable Unit ID:	911852
Operable Unit:	01
Material ID:	468384
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

Name:	WHITE PLAINS PRESBYTERIAN CHURCH
Address:	39 NORTH BROADWAY
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0911530 / 2017-05-11
Facility ID:	0911530
Site ID:	424343
Spill Date:	2010-01-27
Spill Cause:	Tank Test Failure
Spill Source:	Institutional, Educational, Gov., Other
Spill Class:	A2
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	JBODEE
Referred To:	Not reported
Reported to Dept:	2010-01-27
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2010-01-27
Spill Record Last Update:	2017-06-01
Spiller Name:	VINCENTE VALSCO
Spiller Company:	WHITE PLAINS PRESBYTERIAN CHURCH
Spiller Address:	39 NORTH BROADWAY
Spiller County:	999
Spiller Contact:	BOB URBAN
Spiller Phone:	(631) 321-4670
Spiller Extention:	Not reported
DEC Region:	3

WHITE PLAINS PRESBYTERIAN CHURCH (Continued) **S100139602**

DER Facility ID:	104243
Latitude:	Not reported
Longitude:	Not reported
DEC Memo:	ProTest to propose to excavate, isolate and retest. DT 1/27/10 3/4/10: WCHD PBS site. JO'M 10/12/11: This tank was repiped and retested in February of 2010. Tank reportedly passed the retest. Prior to documentation being submitted for closure of this spill, several thousand gallons of heating oil from this tank system impacted neighboring properties, storm drains, and the Bronx River. See Spill 0912623 for additional information. jod 05/11/17 This 8,000 LUST was removed under spill number 0912623. NFA for this spill number. TG
Remarks:	TANK TEST FAILURE ON A 8000 GALLON UST

All Materials:

Site ID:	424343
Operable Unit ID:	1180125
Operable Unit:	01
Material ID:	2173985
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	G
Recovered:	Not reported
Resource Affected:	Not reported
Oxygenate:	Not reported

BO468 **UNK HOMEOWNER** **NY LTANKS** **S111160003**
SW **163 FISHER AVE** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.405 mi.
2141 ft. **Site 1 of 2 in cluster BO**

Relative:
Higher

Actual:
238 ft.

LTANKS:

Name:	UNK HOMEOWNER
Address:	163 FISHER AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	1104419 / 2014-11-05
Facility ID:	1104419
Site ID:	452024
Spill Date:	2011-07-20
Spill Cause:	Tank Test Failure
Spill Source:	Private Dwelling
Spill Class:	D4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	JBODEE
Referred To:	Not reported
Reported to Dept:	2011-07-21
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False

UNK HOMEOWNER (Continued) **S111160003**

UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2011-07-21
Spill Record Last Update:	2022-03-17
Spiller Name:	REED SMERSNIA
Spiller Company:	UNK HOMEOWNER
Spiller Address:	163 FISHER AVE
Spiller County:	999
Spiller Contact:	REED SMERSNIA
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	406615
Latitude:	41.0260117
Longitude:	-73.7762786
DEC Memo:	7/21/11 done for real estate transaction...mm 11/05/2014 Homeowner Tank Test Failure at least two years old with no known impact, as per Albany, will be closed. NFA JO M
Remarks:	test done for potential buyer, unk retest or repair

All Materials:

Site ID:	452024
Operable Unit ID:	1202203
Operable Unit:	01
Material ID:	2198771
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported
Resource Affected:	Not reported
Oxygenate:	Not reported

BI469 **PATRIOT MANAGEMENT: 5K UST** **NY LTANKS S102152995**
ENE **12 WESTCHESTER AVE** **NY Spills N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.408 mi.
2154 ft. **Site 2 of 2 in cluster BI**

Relative:
Higher

Actual:
205 ft.

LTANKS:

Name:	PATRIOT MANAGEMENT: 5K UST
Address:	12 WESTCHESTER AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0900020 / 2015-06-05
Facility ID:	0900020
Site ID:	411931
Spill Date:	2009-04-01
Spill Cause:	Tank Test Failure
Spill Source:	Private Dwelling
Spill Class:	B3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	JKOMARA
Referred To:	Not reported
Reported to Dept:	2009-04-01

PATRIOT MANAGEMENT: 5K UST (Continued) **S102152995**

CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2009-04-01
Spill Record Last Update:	2015-06-05
Spiller Name:	DAVID DRASHOW
Spiller Company:	PATRIOT MANAGEMENT
Spiller Address:	12 WESTCHETER AVE
Spiller County:	999
Spiller Contact:	ROBIN WIECZOREK
Spiller Phone:	(845) 434-7805
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	176944
Latitude:	41.0319050
Longitude:	-73.7622400
DEC Memo:	4-1-09: V.Mc.^ DAVID DRASHOW/PATRIOT: UST is 5K, as per Mr.Drashow. To authorize Luzon to proceed with repair of line and retest of system. 5/14/09: During investigation the tank was found to be 7,500 gallons in size. Tank was out of service and partly filled with sand. Reps from Luzon, Lane Engineering and the White Plains Bldg Dept met on site 5-18-09. It was determined the tank cannot be removed without causing severe damage to the structure. Accessible contaminated soil will be remediated and the tank will be abandoned in place. jod 06/24/09 Luzon Environmental Services submitted a Underground Storage Tank Closure Report. Structural concerns prevented the removal of the tank, so the WCHD allowed the oil tank to be cleaned and abandoned in place. Recovery well was placed in an area where oil was seeping from beneath the tank and will be monitored for a year. TG 12/14/09: Well data including sample results from November 19 submitted by Luzon. Further vaccing of well and additional sampling necessary. Results to be entered into eDocs. jod 09/06/11 GW sampling report submitted by Luzon. Report in Edocs. TG 06/02/15 Monitoring Well Sampling Event Report submitted by Northeast Environmental. VOC and SVOC levels reduced to trace levels. No further action is required. TG
Remarks:	LINE TEST FAILURE ON 10,000 GALLON VAULTED TANK, WHICH IS IN THE BASEMENT. REMOTE FILL LINE IS LEAKING UNK AMOUNT.

All Materials:

Site ID:	411931
Operable Unit ID:	1168423
Operable Unit:	01
Material ID:	2160029
Material Code:	0003A
Material Name:	#6 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	G
Recovered:	Not reported
Resource Affected:	Soil
Oxygenate:	Not reported

PATRIOT MANAGEMENT: 5K UST (Continued) **S102152995**

SPILLS:

Name:	M B TRUCKING
Address:	12 WESTCHESTER AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8710547 / 1988-03-17
Facility ID:	8710547
Facility Type:	ER
DER Facility ID:	176944
Site ID:	213572
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	Not reported
SWIS:	6017
Spill Date:	1988-03-17
Investigator:	jeokesso
Referred To:	Not reported
Reported to Dept:	1988-03-17
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Tank Truck
Spill Notifier:	Responsible Party
Cleanup Ceased:	1988-03-17
Cleanup Meets Std:	True
Last Inspection:	1988-03-17
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2003-12-02
Spill Record Last Update:	2003-12-02
Spiller Name:	TRUCKERS FOR HESS OIL
Spiller Company:	DAVE UNGEKER, M B TRUCK
Spiller Address:	212-328-3275
Spiller Company:	001
Contact Name:	Not reported
Latitude:	41.0336859
Longitude:	-73.7625805
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was OKESSON
Remarks:	M B TO TAKE RESPONSIBILITY FOR CLEANUP. UPDATE:3-17-88 AS PER D.UNGEKER: 1GAL SPILLED, DRIVER DID NOT CAUSE SPILL BUT MB TRUCK TAKES RESPONSIBILITY. FUEL SPILLED ON ASPHALT.MB CLEANED UP. N.F.A. D.O'B

All Materials:

Site ID:	213572
Operable Unit ID:	916420
Operable Unit:	01
Material ID:	462318
Material Code:	0003A
Material Name:	#6 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	10.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

PATRIOT MANAGEMENT: 5K UST (Continued) **S102152995**

Name:	PARK ROSE
Address:	12 WESTCHESTER AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8607154 / 1987-03-07
Facility ID:	8607154
Facility Type:	ER
DER Facility ID:	176944
Site ID:	213571
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	C3
SWIS:	6017
Spill Date:	1987-02-24
Investigator:	PATEL
Referred To:	Not reported
Reported to Dept:	1987-02-24
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Responsible Party
Cleanup Ceased:	1987-03-07
Cleanup Meets Std:	True
Last Inspection:	1987-03-07
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	1987-02-27
Spill Record Last Update:	1998-01-29
Spiller Name:	Not reported
Spiller Company:	PARK ROSE MGT
Spiller Address:	22 SAW MILL RIVER RD
Spiller Company:	001
Contact Name:	Not reported
Latitude:	41.0336859
Longitude:	-73.7625805
DEC Memo:	Not reported
Remarks:	OIL SEEPING AFTER DELIVERY

All Materials:

Site ID:	213571
Operable Unit ID:	903844
Operable Unit:	01
Material ID:	472679
Material Code:	0003A
Material Name:	#6 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	10.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

BP470 **AVIS** **UST FINDER RELEASE** **1029059259**
South **20 WEST POST RD** **N/A**
1/4-1/2 **WHITE PLAINS, NY 0**
0.409 mi.
2161 ft. **Site 1 of 3 in cluster BP**

Relative: **Higher**
Actual: **209 ft.**

UST FINDER RELEASE:

Object ID:	262334
Facility ID:	NY134698
Lust ID:	NY8706892
Name:	AVIS
Address:	20 WEST POST RD
City,State,Zip:	WHITE PLAINS, NY 0
Address Match Type:	Not reported
Reported Date:	1987/11/13 16:00:00+00
Status:	No Further Action
Substance:	Not reported
Population within 1500ft:	6072
Domestic Wells within 1500ft:	0
Land Use:	Developed, High Intensity
Within SPA:	Yes
SPA PWS Facility ID:	NY7003493_76968
SPA Water Type:	SW - SurRELEASEe Water
SPA Facility Type:	RS - Reservoir
SPA HUC12:	20301020103
Within WHPA:	No
WHPA PWS Facility ID:	Not reported
WHPA Water Type:	Not reported
WHPA Facility Type:	Not reported
WHPA HUC12:	Not reported
Within 100yr Floodplain:	No
Tribe:	Not reported
EPA Region:	2
NFA Letter 1:	Not reported
NFA Letter 2:	Not reported
NFA Letter 3:	Not reported
NFA Letter 4:	Not reported
Closed With Residual Contaminate:	Not reported
Coordinate Source:	State
X Coord:	-73.7717699999999
Y Coord:	41.0251700000001
Latitude:	41.02517
Longitude:	-73.77177

BP471 **AVIS** **NY LTANKS** **S100165725**
South **20 WEST POST RD** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.409 mi.
2161 ft. **Site 2 of 3 in cluster BP**

Relative: **Higher**
Actual: **209 ft.**

LTANKS:

Name:	AVIS
Address:	20 WEST POST RD
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8706892 / 1988-07-27
Facility ID:	8706892
Site ID:	159466
Spill Date:	1987-11-13
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial

AVIS (Continued) **S100165725**

Spill Class:	D3
Cleanup Ceased:	1988-06-27
SWIS:	6017
Investigator:	jeokesso
Referred To:	Not reported
Reported to Dept:	1987-11-13
CID:	Not reported
Water Affected:	NONE
Spill Notifier:	Responsible Party
Last Inspection:	1988-06-27
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	True
Remediation Phase:	0
Date Entered In Computer:	1987-11-18
Spill Record Last Update:	2009-01-23
Spiller Name:	JIM SENECAL
Spiller Company:	AVIS
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	134698
Latitude:	41.0251727
Longitude:	-73.7717679
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was OKESSON / / : 11/13/87-WILL REPLACE TANKS. / / : 2-2K SYSTEMS REMOVED. 02/17/88: WILL REMOVE TANKS LR 02-17-88. 07/27/88: TANKS TO BE REMOVED.EMPTIED.
Remarks:	TTTF-2:2K TANKS

All TTF:

Facility ID:	8706892
Spill Number:	8706892
Spill Tank Test:	1532256
Site ID:	159466
Tank Number:	Not reported
Tank Size:	0
Material:	0009
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	159466
Operable Unit ID:	912747
Operable Unit:	01
Material ID:	465880

AVIS (Continued) **S100165725**

Material Code:	0009
Material Name:	gasoline
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

BQ472 **PBS TTF** **NY LTANKS** **S106702432**
SE **235 MAMARONECK AVE** **NY Spills** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.412 mi.
2176 ft. **Site 1 of 3 in cluster BQ**

Relative: **Higher**
Actual: **232 ft.**

LTANKS:

Name:	SILVERMAN REALTY
Address:	235 MAMARONECK AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	1112859 / 2012-03-30
Facility ID:	1112859
Site ID:	460824
Spill Date:	2012-02-09
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	D4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	TDGHIOSA
Referred To:	Not reported
Reported to Dept:	2012-02-09
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2012-02-09
Spill Record Last Update:	2012-04-02
Spiller Name:	TONYA BASALYGA
Spiller Company:	SILVERMAN REALTY
Spiller Address:	235 MAMARONECK DR
Spiller County:	999
Spiller Contact:	TONYA BASALYGA
Spiller Phone:	(914) 683-8000
Spiller Extention:	328
DEC Region:	3
DER Facility ID:	110492
Latitude:	41.0271416
Longitude:	-73.7638886
DEC Memo:	2/9/12 - To isolate the tank and retest. KAB 3/30/12 As per WCDOH ttf, passed retest after remote fill and vent replacement.
Remarks:	retest pending, failed with dry leak

PBS TTF (Continued) **S106702432**

All Materials:

Site ID:	460824
Operable Unit ID:	1210926
Operable Unit:	01
Material ID:	2208598
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported
Resource Affected:	Not reported
Oxygenate:	Not reported

Name:	PBS TTF
Address:	235 MAMARONECK AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0404588 / 2005-01-10
Facility ID:	0404588
Site ID:	128036
Spill Date:	2004-07-28
Spill Cause:	Tank Test Failure
Spill Source:	Non Major Facility > 1,100 gal
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	JBODEE
Referred To:	WCHD
Reported to Dept:	2004-07-28
CID:	408
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2004-07-28
Spill Record Last Update:	2024-06-12
Spiller Name:	Not reported
Spiller Company:	SILVERMANN REALITY
Spiller Address:	237 MAMARONECK AVE.
Spiller County:	001
Spiller Contact:	SILVERMANN REALITY
Spiller Phone:	(914) 557-0310
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	110492
Latitude:	41.0270520
Longitude:	-73.7643140
DEC Memo:	01/10/05 PBS SITE. TANK PASSED RETEST. SPILL FILE CLOSED BY DANIELLE JACKSON OF THE WESTCHESTER COUNTY HEALTH DEPT. NO FURTHER ACTION IS REQUIRED AT THIS TIME. jbo
Remarks:	VACCUM TEST; VENT IS BROKEN

PBS TTF (Continued) **S106702432**

All TTF:

Facility ID:	0404588
Spill Number:	0404588
Spill Tank Test:	1529478
Site ID:	128036
Tank Number:	1
Tank Size:	5000
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	128036
Operable Unit ID:	887658
Operable Unit:	01
Material ID:	488573
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	L
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

SPILLS:

Name:	COMMERCIAL PROPERTY
Address:	235 MAMARONECK AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0712619 / 2008-03-06
Facility ID:	0712619
Facility Type:	ER
DER Facility ID:	110492
Site ID:	394259
DEC Region:	3
Spill Cause:	Human Error
Spill Class:	C3
SWIS:	6017
Spill Date:	2008-03-02
Investigator:	jbodee
Referred To:	Not reported
Reported to Dept:	2008-03-02
CID:	41
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Other

PBS TTF (Continued) **S106702432**

Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	Not reported
Remediation Phase:	0
Date Entered In Computer:	2008-03-02
Spill Record Last Update:	2008-03-13
Spiller Name:	Not reported
Spiller Company:	Not reported
Spiller Address:	Not reported
Spiller Company:	001
Contact Name:	ABOVE
Latitude:	41.0271416
Longitude:	-73.7638886
DEC Memo:	WCDOH responded, clean up completed.
Remarks:	OVERFILL OF TANK - OIL COMPANY ON SITE - THREW DRAINING PIPE INTO SUB PUMP - BLDG OWNER WANTS AUTHORIZATION TO HAVE PUMP TURNED BACK ON - REQUESTS CALLBACK ASAP

All Materials:

Site ID:	394259
Operable Unit ID:	1151204
Operable Unit:	01
Material ID:	2141910
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	5.00
Units:	G
Recovered:	5.00
Resource Affected:	Soil
Oxygenate:	Not reported

BR473 **PRIVATE RES** **NY LTANKS** **S106702734**
NE **3 LAKE VIEW DR NORTH** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.420 mi.
2216 ft. **Site 1 of 2 in cluster BR**

Relative:
Higher

Actual:
247 ft.

LTANKS:

Name:	PRIVATE RES
Address:	3 LAKE VIEW DR NORTH
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0406400 / 2004-12-12
Facility ID:	0406400
Site ID:	284223
Spill Date:	2004-09-10
Spill Cause:	Tank Failure
Spill Source:	Private Dwelling
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	jbodee
Referred To:	Not reported
Reported to Dept:	2004-09-10

PRIVATE RES (Continued) **S106702734**

CID:	406
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2004-09-10
Spill Record Last Update:	2004-12-12
Spiller Name:	EDDEN EVANS
Spiller Company:	PRIVATE RES
Spiller Address:	3 LAKE VIEW DR NORTH
Spiller County:	001
Spiller Contact:	EDDEN EVANS
Spiller Phone:	(914) 761-8693
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	230501
Latitude:	41.0546720
Longitude:	-73.7629830
DEC Memo:	09/21/04 ALSO SEE SPILL 01-07667. jbo 12/12/04 ADVANCED ENVIRONMENTAL DISPOSED OF LUST AND 8.25 TONS OF CONTAMINATED SOIL. BASED UPON INFORMATION PROVIDED TO DEC, NO FURTHER ACTION IS REQUIRED AT THIS TIME. jbo
Remarks:	Were removing tank and found holes. Advanced enviro. will be doing the clean up.

All TTF:

Facility ID:	0406400
Spill Number:	0406400
Spill Tank Test:	1529658
Site ID:	284223
Tank Number:	Not reported
Tank Size:	550
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	284223
Operable Unit ID:	889001
Operable Unit:	01
Material ID:	568294
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00

PRIVATE RES (Continued) **S106702734**

Units:	Not reported
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported
Site ID:	284223
Operable Unit ID:	889001
Operable Unit:	01
Material ID:	568295
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

BS474 **JEFFERSON APTS** **NY LTANKS** **S113406310**
West **64 JEFFERSON AVE** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.420 mi.
2218 ft. **Site 1 of 4 in cluster BS**

Relative: LTANKS:
Higher

Actual: **317 ft.**

Name:	JEFFERSON APTS
Address:	64 JEFFERSON AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	1215993 / 2014-03-14
Facility ID:	1215993
Site ID:	479338
Spill Date:	2013-03-01
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	B3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	RDBENDEL
Referred To:	Not reported
Reported to Dept:	2013-03-01
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2013-03-01
Spill Record Last Update:	2014-03-14
Spiller Name:	GIL BERGMAN
Spiller Company:	JEFFERSON APTS
Spiller Address:	Not reported
Spiller County:	999
Spiller Contact:	GIL BERGMAN
Spiller Phone:	(914) 686-3474

JEFFERSON APTS (Continued) **S113406310**

Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	434605
Latitude:	Not reported
Longitude:	Not reported
DEC Memo:	3/1/13 Called US Tank Tech. Kathy Morgan did say tank was registered with WC-PBS, and was referred to on spill database. Called # for apts. and spoke to somebody who said Mr. Bergman was not there, but would call back. He called and left message, and said to call 914-310-1500. Called there and left message. dw 12-13-13 request update and FIR from County RDB 12-18-13 rec'd FIR RDB 12-19-13, email from county, 3/1/13: ttf dry leak,7/3/13: tank removed. No apparent contamination. Work permit expires 9/24/13. NES will send a report,12/12/13: NES working on the report. Will send within 2 weeks RDB 03-14-14 TCR in Edocs NFA RDB
Remarks:	2000 gal tank - repair/retest pending

All TTF:

Facility ID:	1215993
Spill Number:	1215993
Spill Tank Test:	2493097
Site ID:	479338
Tank Number:	0
Tank Size:	2000
Material:	0001
EPA UST:	False
UST:	True
Cause:	99
Source:	00
Test Method:	21
Test Method 2:	Horner EZY3/EZY3 Locator Plus
Leak Rate:	Not reported
Gross Fail:	Not reported
Modified By:	jbodee
Last Modified Date:	Not reported

All Materials:

Site ID:	479338
Operable Unit ID:	1229074
Operable Unit:	01
Material ID:	2226829
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported
Resource Affected:	Soil
Oxygenate:	Not reported

BN475 @ **NY LTANKS S104645518**
NE **44 NORTH BROADWAY** **NY Spills N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.422 mi.
2226 ft. **Site 2 of 3 in cluster BN**

Relative: **Higher**

Actual: **254 ft.**

LTANKS:

Name:	@
Address:	44 NORTH BROADWAY
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0302230 / 2009-11-05
Facility ID:	0302230
Site ID:	328668
Spill Date:	2003-06-02
Spill Cause:	Tank Test Failure
Spill Source:	Institutional, Educational, Gov., Other
Spill Class:	D3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	jkomara
Referred To:	WESTCHESTER CNTY HEALTH DEPT
Reported to Dept:	2003-06-02
CID:	205
Water Affected:	Not reported
Spill Notifier:	Responsible Party
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2003-06-02
Spill Record Last Update:	2009-11-05
Spiller Name:	KATHRIN KRASOVIC
Spiller Company:	BROADLAKE CO
Spiller Address:	44 NORTH BROADWAY
Spiller County:	001
Spiller Contact:	CALLER
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	264506
Latitude:	41.0370199
Longitude:	-73.7650700
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was WCHD - JACKSON
Remarks:	Not reported

All TTF:

Facility ID:	0302230
Spill Number:	0302230
Spill Tank Test:	1528418
Site ID:	328668
Tank Number:	1
Tank Size:	7500
Material:	0003
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	03

@ **(Continued)** **S104645518**

Test Method 2: Horner EZ Check I or II
Leak Rate: .00
Gross Fail: Not reported
Modified By: Spills
Last Modified Date: Not reported

All Materials:
Site ID: 328668
Operable Unit ID: 868941
Operable Unit: 01
Material ID: 506707
Material Code: 0003A
Material Name: #6 fuel oil
Case No.: Not reported
Material FA: Petroleum
Quantity: .00
Units: G
Recovered: .00
Resource Affected: Soil
Oxygenate: Not reported

SPILLS:
Name: WESTCHESTER ONE
Address: 44 SOUTH BROADWAY
City,State,Zip: WHITE PLAINS, NY
Spill Number/Closed Date: 0703466 / 2007-06-25
Facility ID: 0703466
Facility Type: ER
DER Facility ID: 137201
Site ID: 383396
DEC Region: 3
Spill Cause: Other
Spill Class: C3
SWIS: 6017
Spill Date: 2007-06-25
Investigator: JYMCCART
Referred To: Not reported
Reported to Dept: 2007-06-25
CID: 410
Water Affected: Not reported
Spill Source: Commercial/Industrial
Spill Notifier: Local Agency
Cleanup Ceased: Not reported
Cleanup Meets Std: True
Last Inspection: Not reported
Recommended Penalty: False
UST Trust: False
Remediation Phase: 0
Date Entered In Computer: 2007-06-25
Spill Record Last Update: 2007-08-15
Spiller Name: DAVID ANAGONUS
Spiller Company: WESTCHESTER ONE
Spiller Address: 44 SOUTH BROADWAY
Spiller Company: 001
Contact Name: DAVID ANAGONUS

@ **(Continued)** **S104645518**

Latitude:	41.0309616
Longitude:	-73.7616086
DEC Memo:	Clean up completed. NFA.
Remarks:	DURING A TANK CLOSURE, A REMOTE FILL LINE LEAKED SOME OIL : ROUGHLY 4-5 GALLONS: CLEANUP IS COMPLETE: SUPERVISOR ON SCENE IS JIM LEWIS CELL # 908-461-3056,

All Materials:

Site ID:	383396
Operable Unit ID:	1140750
Operable Unit:	01
Material ID:	2130845
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	5.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	VAULT # 9944
Address:	44 SOUTH BROADWAY
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0313703 / 2004-03-15
Facility ID:	0313703
Facility Type:	ER
DER Facility ID:	137201
Site ID:	162622
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	C4
SWIS:	6017
Spill Date:	2004-03-15
Investigator:	JYMCCART
Referred To:	Not reported
Reported to Dept:	2004-03-15
CID:	444
Water Affected:	Not reported
Spill Source:	Institutional, Educational, Gov., Other
Spill Notifier:	Responsible Party
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2004-03-15
Spill Record Last Update:	2004-04-02
Spiller Name:	ERT DESK
Spiller Company:	CON ED VAULT #9944
Spiller Address:	44 SOUTH BROADWAY
Spiller Company:	001
Contact Name:	ERT DESK
Latitude:	41.0308535
Longitude:	-73.7622172

@ **(Continued)** **S104645518**

DEC Memo: Prior to Sept, 2004 data translation this spill Lead_DEC Field was MCCARTHY
Remarks: FAULTY TRANSFORMER: NO TO 5 QUESTIONS: SUMP IN HOLE NOTY OPERATING AT TIME BUT FOUND OIL INSIDE OF IT: CON ED # 152504

All Materials:
Site ID: 162622
Operable Unit ID: 878833
Operable Unit: 01
Material ID: 568399
Material Code: 0541A
Material Name: dielectric fluid
Case No.: Not reported
Material FA: Petroleum
Quantity: 2.00
Units: G
Recovered: .00
Resource Affected: Soil
Oxygenate: Not reported

Name: CON ED VAULT # 6407
Address: 44 SOUTH BROADWAY
City,State,Zip: WHITE PLAINS, NY
Spill Number/Closed Date: 0313749 / 2004-03-16
Facility ID: 0313749
Facility Type: ER
DER Facility ID: 137201
Site ID: 162623
DEC Region: 3
Spill Cause: Equipment Failure
Spill Class: C4
SWIS: 6017
Spill Date: 2004-03-16
Investigator: DVWEHRFR
Referred To: Not reported
Reported to Dept: 2004-03-16
CID: 444
Water Affected: Not reported
Spill Source: Institutional, Educational, Gov., Other
Spill Notifier: Responsible Party
Cleanup Ceased: Not reported
Cleanup Meets Std: True
Last Inspection: Not reported
Recommended Penalty: False
UST Trust: False
Remediation Phase: 0
Date Entered In Computer: 2004-03-16
Spill Record Last Update: 2004-04-02
Spiller Name: ERT DESK
Spiller Company: CON ED VAULT #6407
Spiller Address: 44 SOUTH BROADWAY
Spiller Company: 001
Contact Name: ERT DESK
Latitude: 41.0308535
Longitude: -73.7622172
DEC Memo: Prior to Sept, 2004 data translation this spill Lead_DEC Field was WEHRFRITZ

@ (Continued) **S104645518**

Remarks: 40 GALLONS OF WATER WITH THE OIL IN HOLE; FAULTY TRANSFORMER: NO TO ALL 5 QUESTIONS: CON ED # 152526 SUMP IN VAULTY AND WAS NOT OPERATING: Not reported

All Materials:

Site ID:	162623
Operable Unit ID:	880842
Operable Unit:	01
Material ID:	495341
Material Code:	0541A
Material Name:	dielectric fluid
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	10.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	CON ED VAULT#9829
Address:	44 SOUTH BROADWAY
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0313751 / 2004-03-16
Facility ID:	0313751
Facility Type:	ER
DER Facility ID:	137201
Site ID:	162624
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	C4
SWIS:	6017
Spill Date:	2004-03-16
Investigator:	DVWEHRFR
Referred To:	Not reported
Reported to Dept:	2004-03-16
CID:	444
Water Affected:	Not reported
Spill Source:	Institutional, Educational, Gov., Other
Spill Notifier:	Responsible Party
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2004-03-16
Spill Record Last Update:	2004-04-02
Spiller Name:	ERT DESK
Spiller Company:	CON ED VAULT #9829
Spiller Address:	44 SOUTH BROADWAY
Spiller Company:	001
Contact Name:	ERT DESK
Latitude:	41.0308535
Longitude:	-73.7622172
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was WEHRFRITZ See e2mis 152527
Remarks:	10 GALLONS OIL WITHIN BOTTOM OF HOLE NO WATER SAMPLE TAKEN CLEAN UP

@ (Continued) **S104645518**

IN PROGRESS: CON ED # 152527 NMO TO THE 5 QUESTIONS:

All Materials:

Site ID:	162624
Operable Unit ID:	880844
Operable Unit:	01
Material ID:	495343
Material Code:	0541A
Material Name:	dielectric fluid
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	10.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	SPILL NUMBER 0308354
Address:	44 NORTH BROADWAY
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0308354 / 2003-11-07
Facility ID:	0308354
Facility Type:	ER
DER Facility ID:	264506
Site ID:	328669
DEC Region:	3
Spill Cause:	Unknown
Spill Class:	C3
SWIS:	6017
Spill Date:	2003-11-07
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	2003-11-07
CID:	199
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Affected Persons
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2003-11-07
Spill Record Last Update:	2003-11-07
Spiller Name:	ROBERT HILL
Spiller Company:	CASTLE OIL
Spiller Address:	290 LOCUST AVE
Spiller Company:	001
Contact Name:	CALLER
Latitude:	41.0370199
Longitude:	-73.7650700
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY 11/7/03 INSPECTED BY GHIOSAY. SATISFACTORY CLEANUP COMPLETED BY 11:30 AM. NFA. TG
Remarks:	caller states this morning castle oil overfilled the tank of his apt building and it appears approx 10 gal went onto pavement speedy dry

@ **(Continued)** **S104645518**

has been put down but the area is still able to be accessed by children and animals - caller would like someone to check situtation to make sure it is being handled properly

All Materials:

Site ID:	328669
Operable Unit ID:	874612
Operable Unit:	01
Material ID:	501866
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	10.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	SPILL NUMBER 9610799
Address:	44 NORTH BROADWAY
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9610799 / 1996-12-02
Facility ID:	9610799
Facility Type:	ER
DER Facility ID:	264506
Site ID:	328670
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	B4
SWIS:	6017
Spill Date:	1996-12-02
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1996-12-02
CID:	199
Water Affected:	Not reported
Spill Source:	Institutional, Educational, Gov., Other
Spill Notifier:	Responsible Party
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	1996-12-02
Spill Record Last Update:	1999-07-28
Spiller Name:	JIM CAREY
Spiller Company:	CASTLE OIL
Spiller Address:	290 LOCUST AVE
Spiller Company:	001
Contact Name:	VAL
Latitude:	41.0370199
Longitude:	-73.7650700
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY
Remarks:	BROKEN DECK HOSE (DISCHARGE HOSE) CAUSED MATERAL TO LEAK ONTO STREET

@ (Continued) **S104645518**

(PAVEMENT) ALL MATERAL CONTAINED - SPILL CLEAN UP CREW ON THE WAY TO CLEAN AT THIS TIME

All Materials:

Site ID:	328670
Operable Unit ID:	1042178
Operable Unit:	01
Material ID:	343015
Material Code:	0003A
Material Name:	#6 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	40.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

BK476 **SPILL NUMBER 9909558** **NY LTANKS** **S104620619**
North **7 PARK CIRCLE** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.422 mi.
2227 ft. **Site 2 of 2 in cluster BK**

Relative:
Higher

Actual:
323 ft.

LTANKS:

Name:	SPILL NUMBER 9909558
Address:	7 PARK CIRCLE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9909558 / 2000-01-12
Facility ID:	9909558
Site ID:	222795
Spill Date:	1999-11-05
Spill Cause:	Tank Test Failure
Spill Source:	Private Dwelling
Spill Class:	D4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	jbodee
Referred To:	Not reported
Reported to Dept:	1999-11-05
CID:	365
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1999-11-05
Spill Record Last Update:	2000-01-18
Spiller Name:	LISA MARIE LONGO
Spiller Company:	Not reported
Spiller Address:	7 PARK CIRCLE
Spiller County:	001
Spiller Contact:	LISA MARIE LONGO
Spiller Phone:	(203) 532-9675
Spiller Extention:	Not reported

SPILL NUMBER 9909558 (Continued) **S104620619**

DEC Region:	3
DER Facility ID:	184228
Latitude:	41.0381411
Longitude:	-73.7714911
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was O'DEE 01/12/2000 ROBISON OIL PULLED TANK. TANK WAS SOUND, NO RELEASE; NFA
Remarks:	within 10 days they most likely pull the tank

All TTF:

Facility ID:	9909558
Spill Number:	9909558
Spill Tank Test:	1547817
Site ID:	222795
Tank Number:	1
Tank Size:	550
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	.00
Gross Fail:	F
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	222795
Operable Unit ID:	1088254
Operable Unit:	01
Material ID:	298637
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

BS477 **BARILE RESIDENCE** **NY LTANKS** **S107658775**
West **75 JEFFERSON AVE** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.424 mi.
2239 ft. **Site 2 of 4 in cluster BS**

Relative:
Higher

Actual:
323 ft.

LTANKS:

Name:	BARILE RESIDENCE
Address:	75 JEFFERSON AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0514297 / 2006-06-01
Facility ID:	0514297
Site ID:	360988
Spill Date:	2006-03-14

BARILE RESIDENCE (Continued) **S107658775**

Spill Cause:	Tank Test Failure
Spill Source:	Private Dwelling
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	JBODee
Referred To:	Not reported
Reported to Dept:	2006-03-14
CID:	406
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2006-03-14
Spill Record Last Update:	2006-06-01
Spiller Name:	LAURA BARILE
Spiller Company:	BARILE RESIDENCE
Spiller Address:	75 JEFFERSON AVE.
Spiller County:	001
Spiller Contact:	LAURA BARILE
Spiller Phone:	(914) 761-0146
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	311173
Latitude:	41.0310780
Longitude:	-73.7803030
DEC Memo:	June 1, 2006: NES REMOVED AND DISPOSED OF TANK. NO EVIDENCE OF LEAK OR CONTAMINATION WAS FOUND. BASED UPON INFORMATION PROVIDED TO DEC, NO FURTHER ACTION IS REQUIRED AT THIS TIME. jod
Remarks:	Tank test failure. Recommend Uncover , retest, recheck and possilby remove.

All TTF:

Facility ID:	0514297
Spill Number:	0514297
Spill Tank Test:	1549804
Site ID:	360988
Tank Number:	1
Tank Size:	550
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Watchdog
Last Modified Date:	Not reported

All Materials:

Site ID:	360988
Operable Unit ID:	1118089

BARILE RESIDENCE (Continued) **S107658775**

Operable Unit:	01
Material ID:	2108602
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

478
SSW
1/4-1/2
0.424 mi.
2241 ft.

MITCHELL ESTATE - TTF
5 NUTGROVE ST
WHITE PLAINS, NY

NY LTANKS **S117364448**
N/A

Relative:
Higher

Actual:
285 ft.

LTANKS:

Name:	MITCHELL ESTATE - TTF
Address:	5 NUTGROVE ST
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	1405501 / 2014-11-19
Facility ID:	1405501
Site ID:	498930
Spill Date:	2014-08-20
Spill Cause:	Tank Test Failure
Spill Source:	Private Dwelling
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	JBODEE
Referred To:	Not reported
Reported to Dept:	2014-08-20
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2014-08-20
Spill Record Last Update:	2014-11-19
Spiller Name:	CHRISTINA LAFARO (LISTING AGENT)
Spiller Company:	ESTATE OF MITCHELL
Spiller Address:	5 NUTGROVE ST
Spiller County:	999
Spiller Contact:	CHRISTINA LAFARO (LISTING AGENT)
Spiller Phone:	9143370900
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	453887
Latitude:	41.0248317
Longitude:	-73.7742486
DEC Memo:	8/20/14 Spoke to tank tester, who said there was hissing, popping, and bonging . Part of a real estate transaction involving an estate.

MITCHELL ESTATE - TTF (Continued) **S117364448**

Not known what will happen. dw 11/19/2014: UST removed by C2G Environmental. No evidence of a leak or any significant contamination found. Closure Report/Documentation has been reviewed and will be entered into DecDocs. Based upon information provided, no further action required at this time. jod

Remarks: 550G UST failed test, no known losses.

All Materials:

Site ID:	498930
Operable Unit ID:	1248365
Operable Unit:	01
Material ID:	2249796
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported
Resource Affected:	Not reported
Oxygenate:	Not reported

BS479 **SPILL NUMBER 9808775** **NY LTANKS** **S104619747**
West **48 JEFFERSON AVE** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.427 mi.
2253 ft. **Site 3 of 4 in cluster BS**

Relative:
Higher

Actual:
305 ft.

LTANKS:

Name:	SPILL NUMBER 9808775
Address:	48 JEFFERSON AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9808775 / 1999-03-16
Facility ID:	9808775
Site ID:	120913
Spill Date:	1998-10-14
Spill Cause:	Tank Test Failure
Spill Source:	Private Dwelling
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	jbodee
Referred To:	Not reported
Reported to Dept:	1998-10-14
CID:	233
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1998-10-14
Spill Record Last Update:	1999-07-25
Spiller Name:	Not reported
Spiller Company:	IRENE THOMPSON
Spiller Address:	44 JEFFERSON AVE

SPILL NUMBER 9808775 (Continued) **S104619747**

Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	104944
Latitude:	41.0319752
Longitude:	-73.7803967
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was O'DEE 03/10/99 - ENVIROSTAR (FRANK DiBARTOLO) WAS CONTRACTED BY HOME OWNER'S OIL COMPANY - ROBISON OIL (JIM ROOD) - TO ABANDON TANK IN PLACE, WITHOUT ADDRESSING TANK TEST FAILURE. ENVIROSTAR WAS NOT INFORMED TANK HAD FAILED, OR THAT THERE WAS A DEC SPILL REPORT. AFTER CONSULTING WITH DEC, TANK WAS CUT AND CLEANED. TANK WAS INSPECTED BY ENVIROSTAR AND THE WHITE PLAINS BUILDING DEPARTMENT AND FOUND TO BE FREE OF HOLES. BORINGS AND SOIL SAMPLES WERE TAKEN THROUGH THE BOTTOM OF TANK. TANK FAILURE WAS DUE TO A CORRODED VENT PIPE.
Remarks:	U/G TANK ADVISED TO UNCOVER AND RETEST

All TTF:

Facility ID:	9808775
Spill Number:	9808775
Spill Tank Test:	1546395
Site ID:	120913
Tank Number:	1
Tank Size:	550
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	.00
Gross Fail:	F
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	120913
Operable Unit ID:	1066167
Operable Unit:	01
Material ID:	316260
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

480
SSE
1/4-1/2
0.430 mi.
2273 ft.

RESIDENCE
25 LONGVIEW AVE
WHITE PLAINS, NY

NY LTANKS **S106868939**
N/A

Relative:
Higher

Actual:
241 ft.

LTANKS:

Name:	RESIDENCE
Address:	25 LONGVIEW AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0413208 / 2005-05-08
Facility ID:	0413208
Site ID:	339072
Spill Date:	2005-03-18
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6000
Investigator:	JBODee
Referred To:	Not reported
Reported to Dept:	2005-03-18
CID:	410
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2005-03-18
Spill Record Last Update:	2005-05-08
Spiller Name:	Not reported
Spiller Company:	Not reported
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	LIUS LIPKIN
Spiller Phone:	(914) 681-0645
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	285687
Latitude:	41.0254380
Longitude:	-73.7671980
DEC Memo:	INVALID TANK TEST METHOD. jod 05/08/05 ADVANCED ENVIRONMENTAL DISPOSED OF LUST AND 3.30 TONS OF CONTAMINATED SOIL. BASED UPON INFORMATION PROVIDED TO DEC, NO FURTHER ACTION IS REQUIRED AT THIS TIME. jod
Remarks:	failure on a tightness test no oil noted in soil mesa 2d 1000 gallon

All Materials:

Site ID:	339072
Operable Unit ID:	1100989
Operable Unit:	01
Material ID:	581136
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G

RESIDENCE (Continued) **S106868939**

Recovered: .00
Resource Affected: Soil
Oxygenate: Not reported

BN481 **APT. BUILDING** **NY LTANKS** **S100494668**
NE **50 NORTH BROADWAY** **NY Spills** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.432 mi.
2279 ft. **Site 3 of 3 in cluster BN**

Relative:
Higher

Actual:
265 ft.

LTANKS:
Name: 50 N. BWAY. OWNERS INC.
Address: 50 NORTH BROADWAY
City,State,Zip: WHITE PLAINS, NY
Spill Number/Closed Date: 9212081 / 1994-06-29
Facility ID: 9212081
Site ID: 219739
Spill Date: 1993-01-22
Spill Cause: Tank Failure
Spill Source: Commercial/Industrial
Spill Class: C3
Cleanup Ceased: 1994-06-29
SWIS: 6017
Investigator: tdghiosa
Referred To: Not reported
Reported to Dept: 1993-01-22
CID: Not reported
Water Affected: Not reported
Spill Notifier: Responsible Party
Last Inspection: Not reported
Recommended Penalty: False
Meets Standard: False
UST Involvement: False
Remediation Phase: 0
Date Entered In Computer: 1993-01-25
Spill Record Last Update: 1994-06-29
Spiller Name: Not reported
Spiller Company: Not reported
Spiller Address: Not reported
Spiller County: 001
Spiller Contact: Not reported
Spiller Phone: Not reported
Spiller Extention: Not reported
DEC Region: 3
DER Facility ID: 181732
Latitude: 41.0373736
Longitude: -73.7654261
DEC Memo: Prior to Sept, 2004 data translation this spill Lead_DEC Field was
GHIOSAY 06/28/94: TANK REMOVED BY TANK TECH. CLOSURE REPORT SUBMITTED.
Not reported
Remarks: DURING ROUTINE MAINTENANCE AND TANK CLEANING BY A.L. EASTMAN & CO.
TWO SMALL HOLES DISCOVERED TEMPORARY TANK SET UP LEAKING TANK EMPTIED
REQUEST CALL BACK MONDAY

All Materials:
Site ID: 219739
Operable Unit ID: 978925

APT. BUILDING (Continued) **S100494668**

Operable Unit:	01
Material ID:	557072
Material Code:	0003A
Material Name:	#6 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	Not reported
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

SPILLS:

Name:	APT. BUILDING
Address:	50 NORTH BROADWAY
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8907277 / 1989-10-24
Facility ID:	8907277
Facility Type:	ER
DER Facility ID:	181732
Site ID:	308058
DEC Region:	3
Spill Cause:	Human Error
Spill Class:	Not reported
SWIS:	6017
Spill Date:	1989-10-24
Investigator:	DUNN
Referred To:	Not reported
Reported to Dept:	1989-10-24
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Other
Cleanup Ceased:	1989-10-24
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2003-12-02
Spill Record Last Update:	2003-12-02
Spiller Name:	Not reported
Spiller Company:	ORIGINAL OIL
Spiller Address:	Not reported
Spiller Company:	001
Contact Name:	Not reported
Latitude:	41.0373736
Longitude:	-73.7654261
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was P. DUNN
Remarks:	APPLIED SPEEDY DRY. SPILL IS CONTAINED. A.L. EASTMONT WAS CONTRACTOR THAT CLEANED UP.

All Materials:

Site ID:	308058
Operable Unit ID:	934922

APT. BUILDING (Continued) **S100494668**

Operable Unit:	01
Material ID:	444070
Material Code:	0003A
Material Name:	#6 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	20.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

BP482 **WHITE PLAINS LINC/MERCURY** **NY LTANKS** **S104782116**
South **25 WEST COAST RD** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.432 mi.
2280 ft. **Site 3 of 3 in cluster BP**

Relative: **Higher**

Actual: **211 ft.**

LTANKS:

Name:	WHITE PLAINS LINC/MERCURY
Address:	25 WEST COAST RD
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0005954 / 2001-04-24
Facility ID:	0005954
Site ID:	226425
Spill Date:	2000-08-18
Spill Cause:	Tank Failure
Spill Source:	Commercial/Industrial
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	2000-08-18
CID:	211
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2000-08-18
Spill Record Last Update:	2001-05-08
Spiller Name:	CARY FRANKEL
Spiller Company:	WHITE PLAINS LINC/MERCURY
Spiller Address:	25 WEST COAST RD
Spiller County:	001
Spiller Contact:	CARY FRANKEL
Spiller Phone:	(914) 946-2100
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	186890
Latitude:	40.9948743
Longitude:	-73.7443699
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY 08/18/2000 INSTRUCTED OWNER TO HAVE CONTRACTOR PREPARE REPORT

WHITE PLAINS LINC/MERCURY (Continued) **S104782116**

W/RESULTS AND SUBMIT TO DEC. 01/18/2001 LETTER FROM NORTHEAST ENVIRONMENTAL RECEIVED. 86.48 TONS OF SOIL WERE EXCAVATED & DISPOSED. A FOUR INCH WELL WAS INSTALLED IN THE TANK GRAVE FOR MONITORING AND TESTING PURPOSES. 04/24/2001 LETTER SENT TO NORTHEAST ENVIRONMENTAL BY T. GHIOSAY; BASED ON LETTER & WATER SAMPLE RESULTS, NO FURTHER ACTION IS REQUIRED AT THIS TIME. SPILL REPORT LISTED AS CLOSED.

Remarks: during tank removal 1000 gal ust soil contamination discovered

All Materials:

Site ID:	226425
Operable Unit ID:	826863
Operable Unit:	01
Material ID:	547087
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

BQ483 **YMCA OF CENTRAL & NORTHERN WESTCHESTER** **NY LTANKS** **S105058672**
SE **250 MAMARONECK AVENUE** **NY CBS** **N/A**
1/4-1/2 **WHITE PLAINS, NY 10605** **NY BROWNFIELDS**
0.433 mi. **NY Spills**
2285 ft. **Site 2 of 3 in cluster BQ** **NY PFAS**

Relative: Higher

Actual: 235 ft.

LTANKS:

Name:	YMCA
Address:	250 MAMARONECK AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9013259 / 2002-03-23
Facility ID:	9013259
Site ID:	263885
Spill Date:	1991-03-28
Spill Cause:	Tank Test Failure
Spill Source:	Institutional, Educational, Gov., Other
Spill Class:	B3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	WXWADSWO
Referred To:	Not reported
Reported to Dept:	1991-03-28
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1991-04-01
Spill Record Last Update:	2020-09-23
Spiller Name:	Not reported
Spiller Company:	SAME

YMCA OF CENTRAL & NORTHERN WESTCHESTER (Continued) **S105058672**

Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	323652
Latitude:	41.0264431
Longitude:	-73.7642149
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was WADSWORTH 05/01/91: MAY 1, FRED TOOT DIRECTOR STILL ATTEMPTING TO GET BIDS TO EXCAVATE THE LINES TO RETEST. 09/27/95: This is additional information about material spilled from the translation of the old spill file: TANK TEST. 03/23/2002 LETTER SENT TO TEAM ENV. CONSULTANTS BY T. GHIOSAY; BASED ON 3/13/02 CORRESPONDENCE, NO FURTHER ACTION REQUIRED AT THIS TIME. SPILL NUMBER CLOSED.
Remarks:	E I R TODAY PETRO-TITE -.126

All TTF:

Facility ID:	9013259
Spill Number:	9013259
Spill Tank Test:	1538385
Site ID:	263885
Tank Number:	Not reported
Tank Size:	0
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	263885
Operable Unit ID:	953354
Operable Unit:	01
Material ID:	426138
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	L
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

CBS:

Name:	YMCA OF CENTRAL & NORTHERN WESTCHESTER
Address:	250 MAMARONECK AVENUE
City,State,Zip:	WHITE PLAINS, NY 10605

YMCA OF CENTRAL & NORTHERN WESTCHESTER (Continued) **S105058672**

CBS Number: 3-000313
Program Type: CBS
Facility Status: Unregulated/Closed
Expiration Date: Not reported
Dec Region: 3
UTMX: 603883.39681
UTMY: 4542444.03426

BROWNFIELDS:
Name: YMCA - WHITE PLAINS
Address: 250 MAMARONECK AVENUE
City,State,Zip: WHITE PLAINS, NY 10605
Program: BCP
Site Code: 612426
Acres: 1.160
HW Code: C360206
SWIS: 6017
Town: White Plains (c)
Record Added Date: 10/19/2020
Record Updated Date: 07/29/2024
Update By: AMOMOROG
Site Description: Location: The 1.16-acre site is located in a suburban, mixed use (commercial/residential) area in White Plains, New York. The property is bounded by residential properties to the west, commercial properties (retail and offices) to the north, east, and south, a church to the east, and a health clinic to the southwest. The site is located 200 feet south of the intersection of Mamaroneck Avenue and Maple Avenue. Site Features: The site has a prominent slope with elevations that decrease towards Mamaroneck Avenue to the east. The site is currently vacant with no existing buildings. Current Zoning and Land Use: The site is zoned BR-2 (Business Residential-2). The zoning allows for both commercial and multi-family dwelling use. The surrounding parcels are currently zoned business residential or business. Past Use of the Site: The property has historically been used for residential purposes from at least 1905 and up until at least 1911. By 1930, the White Plains YMCA, a recreational facility, occupied the existing building on the northern portion of the site with a small annex and boarding house on the southern portion of the site. Around 1971, the annex and boarding house were replaced with a 6-story building that was razed in 2021. Past uses of the site that led to the site becoming contaminated included the storage of heating oil for the YMCA in at least one underground storage tank (UST). A 12,000-gallon UST was removed in 2015 which included the removal of petroleum impacted soils adjacent to the UST, but not adjacent to the fuel oil lines where a leak appeared to occur. In 2018 oil was observed coming into the basement and reported as spill number 1709377. The spill is being addressed as part of the brownfield remediation. Site Geology and Hydrogeology: The stratigraphy of the site, from the surface down, consists primarily of urban fill from grade ranging down to approximately 3 to 10 feet below ground surface (bgs.) The unconsolidated material beneath the urban fill material is composed of dense, grey fine-grained sands, silty sands, and clayey sands with gravel. The depth to bedrock varies between 30 to 50 feet bgs with a slope that generally matches surface topography. The groundwater table was encountered at approximately 6 to 12 feet bgs. Groundwater flow direction follows the topography and generally flows to the east.

YMCA OF CENTRAL & NORTHERN WESTCHESTER (Continued) **S105058672**

Env Problem:

Nature and extent of contamination: Soil and groundwater were analyzed for volatile organic compounds (VOCs), semi-volatile organic compounds (SVOCs), metals, polychlorinated biphenyls (PCBs), per- and polyfluoroalkyl substances (PFAS), and pesticides. Based upon investigations conducted to date, the primary contaminants of concern are certain VOCs, SVOCs, metals, and per- and poly fluoroalkyl substances. Soil: To characterize surface and subsurface soil conditions, 60 samples for VOCs and SVOCs and 52 samples for metals, pesticides/PCBs and PFAS, were collected from 26 soil borings. N-Propylbenzene was detected in soil at concentrations up to 15 parts per million (ppm), exceeding the unrestricted use soil cleanup objective (UUSCO) of 3.9 ppm. Sec-Butylbenzene was detected in soil at concentrations up to 18 ppm, exceeding the UUSCO of 11 ppm. The highest concentrations of these VOCs were found in the central-eastern portion of the site at a depth of approximately five feet below ground surface (bgs). Benzo(a)anthracene, benzo(a)pyrene, and benzo(b)fluoranthene were detected in soil at concentrations up to 2.22 ppm, 3.09 ppm and 2.69 ppm respectively, exceeding the UUSCO of 1 ppm for each compound. Indeno(1,2,3-cd)pyrene was detected at concentrations up to 2.35 ppm, exceeding the UUSCO of 0.5 ppm. The highest concentration of these SVOCs was found in the central-western portion of the site at a depth of approximately two feet bgs. Lead was detected in soil at concentrations up to 483 ppm, exceeding the UUSCO of 63 ppm. Mercury was detected at concentrations up to 0.227 ppm, exceeding the UUSCO of 0.18 ppm. Copper was detected at concentrations up to 4,180 ppm, exceeding the UUSCO of 50 ppm. Trivalent chromium was detected at concentrations up to 153 ppm, exceeding the UUSCO of 30 ppm. The highest concentrations of metals were found in the sump pit located in the central-eastern portion of the site. Perfluorooctanoic acid (PFOA) and perfluorooctanesulfonic (PFOS) were detected in soil at concentrations up to 1.43 and 9.43 parts per billion (ppb), respectively, exceeding the proposed UUSCO of 0.66 ppb and 0.88 ppb, respectively. Data do not indicate any off-site impacts in soil related to this site. Groundwater: From 16 monitoring wells, 27 groundwater samples were collected for VOC and SVOC analysis. 21 groundwater samples were collected for metals, pesticides/PCBs and PFAS. Benzene was detected in groundwater at concentrations up to 5.66 parts per billion (ppb), exceeding the Class GA standard (standard) of 1 ppb. N-Propylbenzene was detected in groundwater at concentrations up to 32.2 ppb (standard= 5 ppb). Sec-Butylbenzene was detected in groundwater at concentrations up to 18.7 ppb (standard= 5 ppb). N-Butylbenzene was detected in groundwater at concentrations up to 11 ppb (standard= 5 ppb). Isopropylbenzene was found in groundwater at concentrations up to 25.4 ppb (standard= 5 ppb). Naphthalene was found in groundwater at concentrations up to 25.4 ppb (guidance value = 10 ppb). Benzo(a)pyrene was detected up to 0.13 ppb (standard = not detected). Benzo(a)anthracene was detected up to 0.14 ppb, benzo(b)fluoranthene was detected up to 0.108 ppb, and chrysene was detected at 0.179; the guidance value for each of these compounds is 0.002 ppb. In general, these exceedances were in the vicinity of the former underground petroleum storage tank. Dissolved tri-valent chromium was detected in groundwater up to 10 ppb, below the standard of 50 ppb. Dissolved copper and lead were not detected in groundwater; mercury was not detected in groundwater. PFOA and PFOS were detected in groundwater samples at concentrations up to 48 and 86 parts per trillion (ppt), respectively, exceeding the 10 ppt drinking water maximum contaminant

YMCA OF CENTRAL & NORTHERN WESTCHESTER (Continued) **S105058672**

	level for each compound. PFOA and PFOS were present in on-site monitoring wells as well as in upgradient monitoring wells, suggesting an off-site contribution. Groundwater analyzed from monitoring wells along the downgradient edge of the site did not exceed the groundwater standards or guidance values for the contaminants of concern with the exception of PFOA and PFOS. The finding of these compounds in groundwater upgradient, as well as in site soil, suggest both on-site and off-site contributions. Soil Vapor: Soil vapor samples were collected from 10 locations throughout the site at a depth of two feet above the groundwater table. Petroleum related compounds, such as benzene (maximum 55.2 micrograms per cubic meter (mcg/m3), toluene (maximum 222 mcg/m3), ethylbenzene (maximum 24.2 mcg/m3), and xylenes (maximum 140.9 mcg/m3), were detected in each soil vapor sample. Carbon tetrachloride was detected up to 0.605 mcg/m3, cis-1,2-dichloroethene was detected up to 1.33 mcg/m3, trichloroethene was detected up to 6 mcg/m3 and tetrachloroethene was detected up to 47 mcg/m3. Data do not indicate any off-site impacts in soil vapor related to this site.
Health Problem:	Since the site is completely fenced and covered by asphalt or concrete, people will not come in contact with site related soil and groundwater contamination unless they dig below the surface. People are not drinking the contaminated groundwater because the area is served by a public water supply that is not affected by this contamination. Volatile organic compounds in the groundwater may move into the soil vapor (air spaces within the soil), which in turn may move into overlying buildings and affect indoor air quality. This process, which is similar to the movement of radon gas from the subsurface into the indoor air of buildings, is referred to as soil vapor intrusion. Because the site is vacant , the inhalation of site-related contaminants due to soil vapor intrusion does not represent a current concern. Furthermore, environmental sampling indicates soil vapor intrusion is not a concern for off-site buildings.
Dump:	False
Structure:	False
Lagoon:	False
Landfill:	False
Pond:	False
Disp Start:	Not reported
Disp Term:	Not reported
Lat/Long:	Not reported
Dell:	Not reported
Record Add:	2020-12-28 16:59:00
Record Upd:	2024-07-24 14:16:00
Updated By:	JCSTARR
Own Op:	6
Sub Type:	P03
Owner Name:	Brian Sewell
Owner Company:	Mamaroneck White Plains, LLC
Owner Address:	3990 Hillsboro Pike
Owner Addr2:	Suite 400
Owner City,St,Zip:	Nashville, TN 37215
Owner Country:	United States of America
Own Op:	Document Repository
Sub Type:	NNN
Owner Name:	Not reported
Owner Company:	White Plains Public Library

YMCA OF CENTRAL & NORTHERN WESTCHESTER (Continued) **S105058672**

Owner Address:	100 Martine Avenue
Owner Addr2:	Not reported
Owner City,St,Zip:	White Plains, NY 10601
Owner Country:	United States of America
Own Op:	1
Sub Type:	P03
Owner Name:	JON NEVID
Owner Company:	Mamaroneck White Plains, LLC
Owner Address:	3990 hillsboro pike suite 400
Owner Addr2:	Not reported
Owner City,St,Zip:	nashville, TN 37215
Owner Country:	United States of America
HW Code:	C360206
Waste Type:	indeno(1,2,3-cd)pyrene
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360206
Waste Type:	perfluorooctane sulfonic acid
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360206
Waste Type:	benzo(a)anthracene
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360206
Waste Type:	copper
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360206
Waste Type:	sec-butylbenzene
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360206
Waste Type:	benzo(a)pyrene
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360206
Waste Type:	naphthalene
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360206
Waste Type:	lead
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360206
Waste Type:	mercury
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360206
Waste Type:	n-propylbenzene
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360206
Waste Type:	chromium
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360206

YMCA OF CENTRAL & NORTHERN WESTCHESTER (Continued) **S105058672**

Waste Type:	perfluorooctanoic acid
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360206
Waste Type:	benzo(b)fluoranthene
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360206
Waste Type:	benzene
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360206
Waste Type:	isopropylbenzene
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
Crossref ID:	C360206-04-21
Cross Ref Type Code:	23
Cross Ref Type:	Agreement/Consent Order Number
Record Added Date:	2024-07-24 14:13:00
Record Updated:	2024-07-24 14:13:00
Updated By:	JCSTARR
Crossref ID:	04/13/2021
Cross Ref Type Code:	26
Cross Ref Type:	Agreement/Consent Order Date
Record Added Date:	2024-07-24 14:14:00
Record Updated:	2024-07-24 14:14:00
Updated By:	JCSTARR
Crossref ID:	1709377
Cross Ref Type Code:	01
Cross Ref Type:	Spill No.
Record Added Date:	2020-12-28 16:57:00
Record Updated:	2020-12-28 16:57:00
Updated By:	JEBROWN

SPILLS:

Name:	WHITE PLAINS YMCA
Address:	250 MAMARONECK AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	1709377 / 2024-06-12
Facility ID:	1709377
Facility Type:	ER
DER Facility ID:	323652
Site ID:	565820
DEC Region:	3
Spill Cause:	Unknown
Spill Class:	B1
SWIS:	6017
Spill Date:	2018-01-12
Investigator:	JBODEE
Referred To:	Not reported
Reported to Dept:	2018-01-12
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Institutional, Educational, Gov., Other
Spill Notifier:	Tank Tester
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False

YMCA OF CENTRAL & NORTHERN WESTCHESTER (Continued) **S105058672**

Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2018-01-12
Spill Record Last Update:	2024-06-12
Spiller Name:	TOM HAY
Spiller Company:	YMCA
Spiller Address:	250 MAMARONECK AVE
Spiller Company:	999
Contact Name:	CYNTHIA RUBINA
Latitude:	Not reported
Longitude:	Not reported
DEC Memo:	1/12/18 US Tank was called to try to find leaking UST at YMCA Oil was coming into the basement through the back wall. No evidence of buried tank found. A tank was removed at the front of the property years ago. Sheen was noticed at the back of the property coming up from cracks in the asphalt, believed to be coming from a retaining wall. Other side of wall is condos / townhouses. US Tank told YMCA to call Northeast, their usual cleanup contractor, to put booms in place in storm drain at parking lot, sump pump, and cubby of basement to prevent further oil impact. Rain is causing oil to sheen on parking lot, making it easy to trace path from property behind them. Spoke to Tom @ YMCA - confirmed that Northeast Env. was called, did boom the sump in the basement, the storm drain at back of parking lot, and the pipe cubby in basement were evidence of residual oil was found. Northeast would like to speak to DEC for advice on how to proceed. ga 01/17/18 Received a report prepared by US Tank Tech describing their effort to locate a tank on the property. No tank was located. Report in DecDocs. TG 02/07/18 Inspected the site on a rainy day. No sign of oil observed at the time of the inspection. TG 04/16/18 YMCA hired HydroEnvironmental Solutions to conduct an investigation both outside in the rear parking lot and inside the basement to try to determine where the oil is originating. All outside soil boring locations were clean, eliminating the idea that there is an offsite source. Report concludes that the oil is from the numerous past spills that have occurred in their basement. See report in DecDocs. TG 09/25/18 Spoke to Tom Hay. He stated that the building may be sold in the near future. GW in the basement is being pumped through an oil water separator before being discharged. Little if any oil is accumulating in the separator according to Tom. TG 07/01/20 The YMCA had no funds to do any type of cleanup and was sold to a developer. It is anticipated that the cleanup will be performed once the building is razed. TG 3/25/21: BCP site YMCA - White Plains (C360206) submitted for this spill (PM John

YMCA OF CENTRAL & NORTHERN WESTCHESTER (Continued) **S105058672**

Spellman. Site will be tracked under that code and this spill closed upon receipt of COC. MDK
6/12/2024: The building has been demolished. The remediation is being handled through the
Brownfield Program. See BCP C360206 for further information. This spill file closed at this time.
jod

Remarks: leaking at base of wall - in basement of YMCA unknown were it is coming from - off site clean up pending crew.

All Materials:

Site ID:	565820
Operable Unit ID:	1313761
Operable Unit:	01
Material ID:	2321241
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported
Resource Affected:	Indoor Air
Oxygenate:	Not reported

Name:	WHITE PLAINS YMCA
Address:	250 MAMARONECK AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	1709377 / 2024-06-12
Facility ID:	1709377
Facility Type:	ER
DER Facility ID:	323652
Site ID:	565820
DEC Region:	3
Spill Cause:	Unknown
Spill Class:	B1
SWIS:	6017
Spill Date:	2018-01-12
Investigator:	JBODEE
Referred To:	Not reported
Reported to Dept:	2018-01-12
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Institutional, Educational, Gov., Other
Spill Notifier:	Tank Tester
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2018-01-12
Spill Record Last Update:	2024-06-12
Spiller Name:	TOM HAY
Spiller Company:	YMCA
Spiller Address:	250 MAMARONECK AVE
Spiller Company:	999

YMCA OF CENTRAL & NORTHERN WESTCHESTER (Continued) **S105058672**

Contact Name: TOM HAYES
Latitude: Not reported
Longitude: Not reported
DEC Memo: 1/12/18 US Tank was called to try to find leaking UST at YMCA Oil was coming into the basement through the back wall. No evidence of buried tank found. A tank was removed at the front of the property years ago. Sheen was noticed at the back of the property coming up from cracks in the asphalt, believed to be coming from a retaining wall. Other side of wall is condos / townhouses. US Tank told YMCA to call Northeast, their usual cleanup contractor, to put booms in place in storm drain at parking lot, sump pump, and cubby of basement to prevent further oil impact. Rain is causing oil to sheen on parking lot, making it easy to trace path from property behind them. Spoke to Tom @ YMCA - confirmed that Northeast Env. was called, did boom the sump in the basement, the storm drain at back of parking lot, and the pipe cubby in basement were evidence of residual oil was found. Northeast would like to speak to DEC for advice on how to proceed. ga 01/17/18 Received a report prepared by US Tank Tech describing their effort to locate a tank on the property. No tank was located. Report in DecDocs. TG 02/07/18 Inspected the site on a rainy day. No sign of oil observed at the time of the inspection. TG 04/16/18 YMCA hired HydroEnvironmental Solutions to conduct an investigation both outside in the rear parking lot and inside the basement to try to determine where the oil is originating. All outside soil boring locations were clean, eliminating the idea that there is an offsite source. Report concludes that the oil is from the numerous past spills that have occurred in their basement. See report in DecDocs. TG 09/25/18 Spoke to Tom Hay. He stated that the building may be sold in the near future. GW in the basement is being pumped through an oil water separator before being discharged. Little if any oil is accumulating in the separator according to Tom. TG 07/01/20 The YMCA had no funds to do any type of cleanup and was sold to a developer. It is anticipated that the cleanup will be performed once the building is razed. TG 3/25/21: BCP site YMCA - White Plains (C360206) submitted for this spill (PM John Spellman. Site will be tracked under that code and this spill closed upon receipt of COC. MDK 6/12/2024: The building has been demolished. The remediation is being handled through the Brownfield Program. See BCP C360206 for further information. This spill file closed at this time. jod
Remarks: leaking at base of wall - in basement of YMCA unknown were it is coming from - off site clean up pending crew.

YMCA OF CENTRAL & NORTHERN WESTCHESTER (Continued) **S105058672**

All Materials:

Site ID:	565820
Operable Unit ID:	1313761
Operable Unit:	01
Material ID:	2321241
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported
Resource Affected:	Indoor Air
Oxygenate:	Not reported

Name:	WHITE PLAINS YMCA
Address:	250 MAMARONECK AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	1709377 / 2024-06-12
Facility ID:	1709377
Facility Type:	ER
DER Facility ID:	323652
Site ID:	565820
DEC Region:	3
Spill Cause:	Unknown
Spill Class:	B1
SWIS:	6017
Spill Date:	2018-01-12
Investigator:	JBODEE
Referred To:	Not reported
Reported to Dept:	2018-01-12
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Institutional, Educational, Gov., Other
Spill Notifier:	Tank Tester
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2018-01-12
Spill Record Last Update:	2024-06-12
Spiller Name:	TOM HAY
Spiller Company:	YMCA
Spiller Address:	250 MAMARONECK AVE
Spiller Company:	999
Contact Name:	TOM HAYES
Latitude:	Not reported
Longitude:	Not reported
DEC Memo:	1/12/18 US Tank was called to try to find leaking UST at YMCA Oil was coming into the basement through the back wall. No evidence of buried tank found. A tank was removed at the front of the property years ago. Sheen was noticed at the back of the property coming up from cracks in the

YMCA OF CENTRAL & NORTHERN WESTCHESTER (Continued) **S105058672**

asphalt, believed to be coming from a retaining wall. Other side of wall is condos / townhouses. US Tank told YMCA to call Northeast, their usual cleanup contractor, to put booms in place in storm drain at parking lot, sump pump, and cubby of basement to prevent further oil impact. Rain is causing oil to sheen on parking lot, making it easy to trace path from property behind them. Spoke to Tom @ YMCA - confirmed that Northeast Env. was called, did boom the sump in the basement, the storm drain at back of parking lot, and the pipe cubby in basement were evidence of residual oil was found. Northeast would like to speak to DEC for advice on how to proceed. ga 01/17/18 Received a report prepared by US Tank Tech describing their effort to locate a tank on the property. No tank was located. Report in DecDocs. TG 02/07/18 Inspected the site on a rainy day. No sign of oil observed at the time of the inspection. TG 04/16/18 YMCA hired HydroEnvironmental Solutions to conduct an investigation both outside in the rear parking lot and inside the basement to try to determine where the oil is originating. All outside soil boring locations were clean, eliminating the idea that there is an offsite source. Report concludes that the oil is from the numerous past spills that have occurred in their basement. See report in DecDocs. TG 09/25/18 Spoke to Tom Hay. He stated that the building may be sold in the near future. GW in the basement is being pumped through an oil water separator before being discharged. Little if any oil is accumulating in the separator according to Tom. TG 07/01/20 The YMCA had no funds to do any type of cleanup and was sold to a developer. It is anticipated that the cleanup will be performed once the building is razed. TG 3/25/21: BCP site YMCA - White Plains (C360206) submitted for this spill (PM John Spellman. Site will be tracked under that code and this spill closed upon receipt of COC. MDK 6/12/2024: The building has been demolished. The remediation is being handled through the Brownfield Program. See BCP C360206 for further information. This spill file closed at this time. jod

Remarks: leaking at base of wall - in basement of YMCA unknown were it is coming from - off site clean up pending crew.

All Materials:

Site ID:	565820
Operable Unit ID:	1313761
Operable Unit:	01
Material ID:	2321241
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported

YMCA OF CENTRAL & NORTHERN WESTCHESTER (Continued) **S105058672**

Units:	Not reported
Recovered:	Not reported
Resource Affected:	Indoor Air
Oxygenate:	Not reported

Name:	YMCA
Address:	250 MAMARONECK AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0103636 / 2002-02-19
Facility ID:	0103636
Facility Type:	ER
DER Facility ID:	323652
Site ID:	111311
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	C3
SWIS:	6017
Spill Date:	2001-07-05
Investigator:	WCHD
Referred To:	Westchester Cnty Health Dept
Reported to Dept:	2001-07-05
CID:	201
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Fire Department
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2001-07-05
Spill Record Last Update:	2002-04-29
Spiller Name:	HEDI RAHIMI
Spiller Company:	YMCA
Spiller Address:	250 MAMARONECK AV
Spiller Company:	001
Contact Name:	CALLER
Latitude:	41.0266603
Longitude:	-73.7643060
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was WCDOH 07/05/2001 GAUGE BROKE IN BOILER ROOM. FIRE DEPT. ESTIMATES 30 GALLONS CONTAINED ON FLOOR AND 10 GALLONS INTO FLOOR DRAIN. YMCA HAS CONTACTED CASTLE OIL FOR CLEANUP. YMCA STATES FLOOR DRAIN GOES TO SANITARY SEWER. ODORS EVIDENT IN POOL AREA; POOL AREA; POOL AREA IS CLOSED AND YMCA TO VENT WITH FANS. CONTACTED WCDOH - STEFAN GOREAU. WCDOH TO FOLLOW UP DUE TO ODOR PROBLEM & CHECK CLEANUP. 02/19/2002 LETTER SENT TO YMCA BY S. GOREAU (WCDOH); SPILL CLEANUP BY CONTRACTOR WAS SATISFACTORY. WCDOH REQUIRES NO FURTHER ACTION.
Remarks:	VALVE CAUSED SPILL. FLOOR HAS A LARGE POOL OF OIL. SOME OF THE OIL WENT INTO THE FLOOR DRAIN. THE DRAIN HAS BEEN PLUGED SO NO MORE PRODUCT WILL GO INTO DRAIN.

YMCA OF CENTRAL & NORTHERN WESTCHESTER (Continued) **S105058672**

All Materials:

Site ID:	111311
Operable Unit ID:	840246
Operable Unit:	01
Material ID:	535707
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	40.00
Units:	G
Recovered:	.00
Resource Affected:	Sewer
Oxygenate:	Not reported

Name:	WHITE PLAINS YMCA
Address:	250 MAMARONECK AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0609639 / 2007-01-10
Facility ID:	0609639
Facility Type:	ER
DER Facility ID:	323652
Site ID:	373926
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	C3
SWIS:	6017
Spill Date:	2006-11-22
Investigator:	TDGHIOSA
Referred To:	Not reported
Reported to Dept:	2006-11-22
CID:	444
Water Affected:	Not reported
Spill Source:	Institutional, Educational, Gov., Other
Spill Notifier:	Other
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2006-11-22
Spill Record Last Update:	2007-01-10
Spiller Name:	HEDI RAHIMI FACILITY DIRECTOR
Spiller Company:	WHITE PLAINS YMCA
Spiller Address:	250 MAMARONECK AVE
Spiller Company:	999
Contact Name:	DWAYNE MONACO
Latitude:	41.0264416
Longitude:	-73.7645887
DEC Memo:	11/22/06 Two valves feeding oil to the boiler failed, resulting in the constant pumping of oil into the boiler. The boiler failed and oil eventually drained out of the bottom of the boiler and flooded a large section of the boiler room floor. Oil entered a drainage pump pit but no evidence

YMCA OF CENTRAL & NORTHERN WESTCHESTER (Continued) **S105058672**

of a discharge of oil into the storm drain system was observed. YMCA hired Northeast Environmental
for the spill cleanup. NE will vac up the oil and decon the floor and the pit. TG

Remarks: BOILER MALFUNCTION, AND CALLER ENROUTE TO CLEAN UP: SOME DID GO INTO DRAINAGE:

All Materials:

Site ID:	373926
Operable Unit ID:	1131616
Operable Unit:	01
Material ID:	2121327
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	100.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	YMCA
Address:	250 MAMARONECK AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9009604 / 1990-12-14
Facility ID:	9009604
Facility Type:	ER
DER Facility ID:	323652
Site ID:	315712
DEC Region:	3
Spill Cause:	Human Error
Spill Class:	Not reported
SWIS:	6017
Spill Date:	1990-12-04
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1990-12-04
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Responsible Party
Cleanup Ceased:	1953-06-18
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	1990-12-14
Spill Record Last Update:	1991-01-03
Spiller Name:	Not reported
Spiller Company:	CASTLE OIL
Spiller Address:	Not reported
Spiller Company:	999
Contact Name:	Not reported
Latitude:	41.0266603
Longitude:	-73.7643060

YMCA OF CENTRAL & NORTHERN WESTCHESTER (Continued) **S105058672**

DEC Memo: Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY
Remarks: SPOKE WITH MR.CAREY SPILL MOSTLY ON PAVEMENT SOME ENTERED STORM DRAIN CASTLE OIL CALLED AE EASTMAN TO CLEAN UP MR.CAREY TO CALL BACK WITH UPDATE TODD GHIOSAY INSPECTED

All Materials:
Site ID: 315712
Operable Unit ID: 949993
Operable Unit: 01
Material ID: 429813
Material Code: 0001A
Material Name: #2 fuel oil
Case No.: Not reported
Material FA: Petroleum
Quantity: 50.00
Units: G
Recovered: .00
Resource Affected: Soil
Oxygenate: Not reported

Name: YMCA
Address: 250 MAMARONECK AVE
City,State,Zip: WHITE PLAINS, NY
Spill Number/Closed Date: 9010124 / 1990-12-20
Facility ID: 9010124
Facility Type: ER
DER Facility ID: 323652
Site ID: 315713
DEC Region: 3
Spill Cause: Equipment Failure
Spill Class: Not reported
SWIS: 6017
Spill Date: 1990-12-18
Investigator: tdghiosa
Referred To: Not reported
Reported to Dept: 1990-12-18
CID: Not reported
Water Affected: Not reported
Spill Source: Tank Truck
Spill Notifier: Responsible Party
Cleanup Ceased: 1953-06-18
Cleanup Meets Std: True
Last Inspection: Not reported
Recommended Penalty: False
UST Trust: False
Remediation Phase: 0
Date Entered In Computer: 2003-12-02
Spill Record Last Update: 2020-09-28
Spiller Name: Not reported
Spiller Company: CASTLE OIL
Spiller Address: 290 LOCUST AVE.
Spiller Company: 001
Contact Name: Not reported
Latitude: 41.0266603
Longitude: -73.7643060
DEC Memo: Prior to Sept, 2004 data translation this spill Lead_DEC Field was

YMCA OF CENTRAL & NORTHERN WESTCHESTER (Continued) **S105058672**

GHIOSAY 9/28/20: Based on hard copy spill report, a blockage in the line led to an overfill by Castle Oil Co. to the paved parking area. MDK

Remarks: BLOCKAGE IN LINE AND SPILL CAME OUT FILL ONTO PAVEMENT CASTLE OIL SENDING CLEAN UP CREW

All Materials:

Site ID:	315713
Operable Unit ID:	950603
Operable Unit:	01
Material ID:	430294
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	20.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	YMCA
Address:	250 MAMARONECK AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9010653 / 1991-05-01
Facility ID:	9010653
Facility Type:	ER
DER Facility ID:	323652
Site ID:	315714
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	Not reported
SWIS:	6017
Spill Date:	1991-01-05
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1991-01-05
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Responsible Party
Cleanup Ceased:	1953-06-18
Cleanup Meets Std:	True
Last Inspection:	1990-01-05
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	1991-01-10
Spill Record Last Update:	1991-05-02
Spiller Name:	Not reported
Spiller Company:	CASTLE OIL CO.
Spiller Address:	290 LOCUST AVE.
Spiller Company:	001
Contact Name:	Not reported
Latitude:	41.0266603
Longitude:	-73.7643060

YMCA OF CENTRAL & NORTHERN WESTCHESTER (Continued) **S105058672**

DEC Memo: Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY 05/01/91: SPILL CAUSE SIMILAR TO SPILL NUMBER 90-10124. SUPPLY LINE BLOCKAGE. LINE HAS BEEN REPAIRED. FACILITY WAS INSTRUCTED TO TEST THE SYSTEM. TEST RESULTS INDICATE FAILURE. SEE SPILL90-13259.
Remarks: SPILL HAS BEEN CLEANED UP WITH SPEEDI-DRY INSPECTION WILL BE PERFORMEDTO VERIFY CLEAN UP

All Materials:
Site ID: 315714
Operable Unit ID: 950901
Operable Unit: 01
Material ID: 430791
Material Code: 0001A
Material Name: #2 fuel oil
Case No.: Not reported
Material FA: Petroleum
Quantity: 5.00
Units: G
Recovered: .00
Resource Affected: Soil
Oxygenate: Not reported

Name: YMCA
Address: 250 MAMARONECK AVE
City,State,Zip: WHITE PLAINS, NY
Spill Number/Closed Date: 9204628 / 1997-11-07
Facility ID: 9204628
Facility Type: ER
DER Facility ID: 323652
Site ID: 315715
DEC Region: 3
Spill Cause: Human Error
Spill Class: C3
SWIS: 6017
Spill Date: 1992-07-22
Investigator: tdghiosa
Referred To: Not reported
Reported to Dept: 1992-07-22
CID: Not reported
Water Affected: Not reported
Spill Source: Commercial/Industrial
Spill Notifier: Responsible Party
Cleanup Ceased: Not reported
Cleanup Meets Std: True
Last Inspection: Not reported
Recommended Penalty: False
UST Trust: False
Remediation Phase: 0
Date Entered In Computer: 1992-07-23
Spill Record Last Update: 2020-09-28
Spiller Name: Not reported
Spiller Company: CASTLE OIL CO.
Spiller Address: Not reported
Spiller Company: 001
Contact Name: Not reported

YMCA OF CENTRAL & NORTHERN WESTCHESTER (Continued) **S105058672**

Latitude:	41.0266603
Longitude:	-73.7643060
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY 9/28/20: Based on hard copy spill report, fuel oil tank overfill by Castle Oil Co. to paved parking. Speedy dry applied and spill closed.
Remarks:	CALLER SUSPECTS DRIVER MISREAD TANK STICK READINGS OIL WENT TO PAVED PARKING LOT DRIVER APPLIED SPEEDI-DRI AND SPILL TEAM ENROUTE TO COMPLETE CLEAN UP

All Materials:

Site ID:	315715
Operable Unit ID:	968275
Operable Unit:	01
Material ID:	412329
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	20.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	WHITE PLAINS YMCA
Address:	250 MAMARONECK AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	1505596 / 2015-12-08
Facility ID:	1505596
Facility Type:	ER
DER Facility ID:	323652
Site ID:	512969
DEC Region:	3
Spill Cause:	Other
Spill Class:	B3
SWIS:	6017
Spill Date:	2015-08-25
Investigator:	RDBENDEL
Referred To:	Not reported
Reported to Dept:	2015-08-25
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Institutional, Educational, Gov., Other
Spill Notifier:	Other
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2015-08-25
Spill Record Last Update:	2018-01-18
Spiller Name:	THOMAS HAY
Spiller Company:	WHITE PLAINS YMCA
Spiller Address:	250 MAMARONECK AVE

YMCA OF CENTRAL & NORTHERN WESTCHESTER (Continued) **S105058672**

Spiller Company:	999
Contact Name:	THOMAS HAY
Latitude:	Not reported
Longitude:	Not reported
DEC Memo:	8/25/15 - The tank is being prepare to be removed. The Westchester County DOH will be on site on 8/26. KAB
Remarks:	overburdened soils are impacted, c/u pending

All Materials:

Site ID:	512969
Operable Unit ID:	1262211
Operable Unit:	01
Material ID:	2265725
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported
Resource Affected:	Soil
Oxygenate:	Not reported

Click this hyperlink while viewing on your computer to access additional NY SPILL: detail in the EDR Site Report.

PFAS 3:

Name:	YMCA - WHITE PLAINS
Address:	250 MAMARONECK AVENUE
City,State,Zip:	WHITE PLAINS, NY 10605
Site Code:	612426
HW Code:	C360206
Program:	BCP
Class Code:	A
Region:	3
Acres:	1.160
Date Record Added:	10/19/2020
Date Record Updated:	07/29/2024
Water Quantity:	UNKNOWN
Updated By:	AMOMOROG
Site Description:	Location: The 1.16-acre site is located in a suburban, mixed use (commercial/residential) area in White Plains, New York. The property is bounded by residential properties to the west, commercial properties (retail and offices) to the north, east, and south, a church to the east, and a health clinic to the southwest. The site is located 200 feet south of the intersection of Mamaroneck Avenue and Maple Avenue. Site Features: The site has a prominent slope with elevations that decrease towards Mamaroneck Avenue to the east. The site is currently vacant with no existing buildings. Current Zoning and Land Use: The site is zoned BR-2 (Business Residential-2). The zoning allows for both commercial and multi-family dwelling use. The surrounding parcels are currently zoned business residential or business. Past Use of the Site: The property has historically been used for residential purposes from at least 1905 and up until at least 1911. By 1930, the White Plains YMCA, a recreational facility,

YMCA OF CENTRAL & NORTHERN WESTCHESTER (Continued) **S105058672**

occupied the existing building on the northern portion of the site with a small annex and boarding house on the southern portion of the site. Around 1971, the annex and boarding house were replaced with a 6-story building that was razed in 2021. Past uses of the site that led to the site becoming contaminated included the storage of heating oil for the YMCA in at least one underground storage tank (UST). A 12,000-gallon UST was removed in 2015 which included the removal of petroleum impacted soils adjacent to the UST, but not adjacent to the fuel oil lines where a leak appeared to occur. In 2018 oil was observed coming into the basement and reported as spill number 1709377. The spill is being addressed as part of the brownfield remediation. Site Geology and Hydrogeology: The stratigraphy of the site, from the surface down, consists primarily of urban fill from grade ranging down to approximately 3 to 10 feet below ground surface (bgs.) The unconsolidated material beneath the urban fill material is composed of dense, grey fine-grained sands, silty sands, and clayey sands with gravel. The depth to bedrock varies between 30 to 50 feet bgs with a slope that generally matches surface topography. The groundwater table was encountered at approximately 6 to 12 feet bgs. Groundwater flow direction follows the topography and generally flows to the east.

Summary:

Since the site is completely fenced and covered by asphalt or concrete, people will not come in contact with site related soil and groundwater contamination unless they dig below the surface. People are not drinking the contaminated groundwater because the area is served by a public water supply that is not affected by this contamination. Volatile organic compounds in the groundwater may move into the soil vapor (air spaces within the soil), which in turn may move into overlying buildings and affect indoor air quality. This process, which is similar to the movement of radon gas from the subsurface into the indoor air of buildings, is referred to as soil vapor intrusion. Because the site is vacant , the inhalation of site-related contaminants due to soil vapor intrusion does not represent a current concern. Furthermore, environmental sampling indicates soil vapor intrusion is not a concern for off-site buildings.

Summary:

Nature and extent of contamination: Soil and groundwater were analyzed for volatile organic compounds (VOCs), semi-volatile organic compounds (SVOCs), metals, polychlorinated biphenyls (PCBs), per- and polyfluoroalkyl substances (PFAS), and pesticides. Based upon investigations conducted to date, the primary contaminants of concern are certain VOCs, SVOCs, metals, and per- and poly fluoroalkyl substances. Soil: To characterize surface and subsurface soil conditions, 60 samples for VOCs and SVOCs and 52 samples for metals, pesticides/PCBs and PFAS, were collected from 26 soil borings. N-Propylbenzene was detected in soil at concentrations up to 15 parts per million (ppm), exceeding the unrestricted use soil cleanup objective (UUSCO) of 3.9 ppm. Sec-Butylbenzene was detected in soil at concentrations up to 18 ppm, exceeding the UUSCO of 11 ppm. The highest concentrations of these VOCs were found in the central-eastern portion of the site at a depth of approximately five feet below ground surface (bgs). Benzo(a)anthracene, benzo(a)pyrene, and benzo(b)fluoranthene were detected in soil at concentrations up to 2.22 ppm, 3.09 ppm and 2.69 ppm respectively, exceeding the UUSCO of 1 ppm for each compound. Indeno(1,2,3-cd)pyrene was detected at

YMCA OF CENTRAL & NORTHERN WESTCHESTER (Continued) **S105058672**

concentrations up to 2.35 ppm, exceeding the UUSCO of 0.5 ppm. The highest concentration of these SVOCs was found in the central-western portion of the site at a depth of approximately two feet bgs. Lead was detected in soil at concentrations up to 483 ppm, exceeding the UUSCO of 63 ppm. Mercury was detected at concentrations up to 0.227 ppm, exceeding the UUSCO of 0.18 ppm. Copper was detected at concentrations up to 4,180 ppm, exceeding the UUSCO of 50 ppm. Trivalent chromium was detected at concentrations up to 153 ppm, exceeding the UUSCO of 30 ppm. The highest concentrations of metals were found in the sump pit located in the central-eastern portion of the site. Perfluorooctanoic acid (PFOA) and perfluorooctanesulfonic (PFOS) were detected in soil at concentrations up to 1.43 and 9.43 parts per billion (ppb), respectively, exceeding the proposed UUSCO of 0.66 ppb and 0.88 ppb, respectively. Data do not indicate any off-site impacts in soil related to this site. Groundwater: From 16 monitoring wells, 27 groundwater samples were collected for VOC and SVOC analysis. 21 groundwater samples were collected for metals, pesticides/PCBs and PFAS. Benzene was detected in groundwater at concentrations up to 5.66 parts per billion (ppb), exceeding the Class GA standard (standard) of 1 ppb. N-Propylbenzene was detected in groundwater at concentrations up to 32.2 ppb (standard= 5 ppb). Sec-Butylbenzene was detected in groundwater at concentrations up to 18.7 ppb (standard= 5 ppb). N-Butylbenzene was detected in groundwater at concentrations up to 11 ppb (standard= 5 ppb). Isopropylbenzene was found in groundwater at concentrations up to 25.4 ppb (standard= 5 ppb). Naphthalene was found in groundwater at concentrations up to 25.4 ppb (guidance value = 10 ppb). Benzo(a)pyrene was detected up to 0.13 ppb (standard = not detected). Benzo(a)anthracene was detected up to 0.14 ppb, benzo(b)fluoranthene was detected up to 0.108 ppb, and chrysene was detected at 0.179; the guidance value for each of these compounds is 0.002 ppb. In general, these exceedances were in the vicinity of the former underground petroleum storage tank. Dissolved tri-valent chromium was detected in groundwater up to 10 ppb, below the standard of 50 ppb. Dissolved copper and lead were not detected in groundwater; mercury was not detected in groundwater. PFOA and PFOS were detected in groundwater samples at concentrations up to 48 and 86 parts per trillion (ppt), respectively, exceeding the 10 ppt drinking water maximum contaminant level for each compound. PFOA and PFOS were present in on-site monitoring wells as well as in upgradient monitoring wells, suggesting an off-site contribution. Groundwater analyzed from monitoring wells along the downgradient edge of the site did not exceed the groundwater standards or guidance values for the contaminants of concern with the exception of PFOA and PFOS. The finding of these compounds in groundwater upgradient, as well as in site soil, suggest both on-site and off-site contributions. Soil Vapor: Soil vapor samples were collected from 10 locations throughout the site at a depth of two feet above the groundwater table. Petroleum related compounds, such as benzene (maximum 55.2 micrograms per cubic meter (mcg/m3), toluene (maximum 222 mcg/m3), ethylbenzene (maximum 24.2 mcg/m3), and xylenes (maximum 140.9 mcg/m3), were detected in each soil vapor sample. Carbon tetrachloride was detected up to 0.605 mcg/m3, cis-1,2-dichloroethene was detected up to 1.33 mcg/m3, trichloroethene was detected up to 6 mcg/m3 and tetrachloroethene was detected up to 47 mcg/m3. Data do not indicate any off-site impacts in soil vapor related to this site.

YMCA OF CENTRAL & NORTHERN WESTCHESTER (Continued) **S105058672**

Water Type: perfluorooctane sulfonic acid

PFAS 3:
Water Type: perfluorooctanoic acid

BQ484 **WHITE PLAINS YMCA** **NY LTANKS** **S117395185**
SE **250 MAMARONECK AVE** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.433 mi.
2285 ft. **Site 3 of 3 in cluster BQ**

Relative:
Higher

Actual:
235 ft.

LTANKS:

Name:	WHITE PLAINS YMCA
Address:	250 MAMARONECK AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	1410006 / 2015-12-08
Facility ID:	1410006
Site ID:	503665
Spill Date:	2015-01-12
Spill Cause:	Tank Test Failure
Spill Source:	Institutional, Educational, Gov., Other
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	RDBENDEL
Referred To:	Not reported
Reported to Dept:	2015-01-12
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2015-01-12
Spill Record Last Update:	2024-06-12
Spiller Name:	THOMAS HAY
Spiller Company:	WHITE PLAINS YMCA
Spiller Address:	250 MAMARONECK RD
Spiller County:	999
Spiller Contact:	THOMAS HAY
Spiller Phone:	(914) 949-8030
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	323652
Latitude:	Not reported
Longitude:	Not reported
DEC Memo:	1-12-15 Spoke with Chris, WCDOH. See below. They will be handling. jm Joe, This is a PBS site 3-074071 TTF 12K (AST with 10% or more below grade) Wayne- please follow up on the TTF. Chris Christopher J. Lalak MS Radiological and Chemical Analyst Westchester County Department of Health 145 Huguenot Street - 7th Floor New Rochelle, NY 10801 CJL1@westchestergov.com (914) 224-7649 12-8-15 tank removed and spill under 15-05596; Close this spill before TCR review RDB
Remarks:	unknown retest.

WHITE PLAINS YMCA (Continued) **S117395185**

All Materials:

Site ID:	503665
Operable Unit ID:	1253015
Operable Unit:	01
Material ID:	2255190
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported
Resource Affected:	Not reported
Oxygenate:	Not reported

---

485 **WHITE PLAINS MED CENTER** **NY LTANKS** **S104781873**
South **170 MAPLE AVE** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.434 mi.
2290 ft.

Relative:
Higher

Actual:
228 ft.

LTANKS:

Name:	WHITE PLAINS MED CENTER
Address:	170 MAPLE AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0004388 / 2001-06-22
Facility ID:	0004388
Site ID:	204425
Spill Date:	2000-07-12
Spill Cause:	Tank Failure
Spill Source:	Commercial/Industrial
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	WCHD
Referred To:	Westchester Cnty Health Dept
Reported to Dept:	2000-07-12
CID:	396
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2000-07-12
Spill Record Last Update:	2003-08-05
Spiller Name:	Not reported
Spiller Company:	SAME
Spiller Address:	Not reported
Spiller County:	999
Spiller Contact:	JOHN HOLZINGER
Spiller Phone:	(914) 337-1312
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	169978

WHITE PLAINS MED CENTER (Continued) **S104781873**

Latitude:	41.0248630
Longitude:	-73.7697635
DEC Memo:	Not reported
Remarks:	unk. amt. spilled soil being stockpiled at this time.

All Materials:

Site ID:	204425
Operable Unit ID:	826936
Operable Unit:	01
Material ID:	549126
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

BR486 **BUSINESS** **NY LTANKS** **S106125358**
NE **7 LAKE STREET** **NY Spills** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.439 mi.
2319 ft. **Site 2 of 2 in cluster BR**

Relative:
Higher

Actual:
249 ft.

LTANKS:

Name:	APARTMENT BUILDING
Address:	7 LAKE STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0701292 / 2007-09-28
Facility ID:	0701292
Site ID:	380826
Spill Date:	2007-05-01
Spill Cause:	Tank Overfill
Spill Source:	Private Dwelling
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	TDGHIOSA
Referred To:	Not reported
Reported to Dept:	2007-05-01
CID:	444
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2007-05-02
Spill Record Last Update:	2007-09-28
Spiller Name:	ED ALLEN
Spiller Company:	ROBISON OIL
Spiller Address:	Not reported
Spiller County:	999
Spiller Contact:	ED ALLEN

BUSINESS (Continued) **S106125358**

Spiller Phone:	(914) 345-5700
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	82292
Latitude:	41.0372617
Longitude:	-73.7637186
DEC Memo:	09/25/07 Northeast Environmental reported that they were hired and completed the cleanup. NFA TG
Remarks:	THERE WAS NO ROOM IN THE OIL TANK AND CAUSED A SPLASH OUT AND IN PROCESS OF CLEANING UP

All Materials:

Site ID:	380826
Operable Unit ID:	1138299
Operable Unit:	01
Material ID:	2128284
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	2.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	BUSINESS
Address:	7 LAKE STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0604972 / 2006-11-17
Facility ID:	0604972
Site ID:	368064
Spill Date:	2006-08-01
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	JBODee
Referred To:	WCDOH
Reported to Dept:	2006-08-01
CID:	444
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2006-08-01
Spill Record Last Update:	2006-11-17
Spiller Name:	LISA DEROSA
Spiller Company:	BUSINESS
Spiller Address:	7 LAKE STREET
Spiller County:	001
Spiller Contact:	LISA DEROSA
Spiller Phone:	(914) 682-1800

BUSINESS (Continued) **S106125358**

Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	82292
Latitude:	41.0372617
Longitude:	-73.7637186
DEC Memo:	November 17, 2006: TANK PASSED A RETEST AFTER PIPING WAS REPAIRED. BASED UPON INFORMATION PROVIDED TO DEC, NO FURTHER ACTION IS REQUIRED AT THIS TIME. jod
Remarks:	PBS No: 3-492078 -PBS No. not found in UIS, may be invalid. DRY LEAK

All TTF:

Facility ID:	0604972
Spill Number:	0604972
Spill Tank Test:	1550165
Site ID:	368064
Tank Number:	1
Tank Size:	8000
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Watchdog
Last Modified Date:	Not reported

All Materials:

Site ID:	368064
Operable Unit ID:	1125954
Operable Unit:	01
Material ID:	2115478
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	SOLITARE AND SEVEN ASSOCIATES
Address:	7 LAKE ST
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	1401610 / 2015-07-17
Facility ID:	1401610
Site ID:	494900
Spill Date:	2014-05-14
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	B3
Cleanup Ceased:	Not reported
SWIS:	6017

BUSINESS (Continued) **S106125358**

Investigator:	RDBENDEL
Referred To:	Not reported
Reported to Dept:	2014-05-14
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2014-05-14
Spill Record Last Update:	2015-07-17
Spiller Name:	LISA DEROSA
Spiller Company:	PROPERTY OWNER
Spiller Address:	7 LAKE ST
Spiller County:	999
Spiller Contact:	LISA DEROSA
Spiller Phone:	9146821800
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	449814
Latitude:	41.0372617
Longitude:	-73.7637186
DEC Memo:	This is a WC PBS site, no one available for update. WCDOH notified...mm 7-17-15, This was a ttf due to piping or manway gasket issues. Piping excavated without any visible contamination. tank passed isolation test and was closed in place. Soil samples below CP51. Wayne- RDB
Remarks:	unknown if any product was lost

All Materials:

Site ID:	494900
Operable Unit ID:	1244408
Operable Unit:	01
Material ID:	2245225
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported
Resource Affected:	Not reported
Oxygenate:	Not reported

Name:	COMMERCIAL
Address:	7 LAKE STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0706405 / 2008-07-31
Facility ID:	0706405
Site ID:	386923
Spill Date:	2007-09-07
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	C3
Cleanup Ceased:	Not reported

BUSINESS (Continued) **S106125358**

SWIS:	6017
Investigator:	TDGHIOSA
Referred To:	WCDOH
Reported to Dept:	2007-09-07
CID:	444
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2007-09-07
Spill Record Last Update:	2023-04-19
Spiller Name:	LISA DEROSA
Spiller Company:	COMMERCIAL
Spiller Address:	7 LAKE STREET
Spiller County:	001
Spiller Contact:	LISA DEROSA
Spiller Phone:	(914) 682-1800
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	82292
Latitude:	41.0372617
Longitude:	-73.7637186
DEC Memo:	07/31/08 Danielle Jackson - WCHD reported 7 lake st, white plains, ny - bad petrometer , repaired and retested, passed, NFA. TG
Remarks:	DRY LEAK- PIN HOLE

All TTF:

Facility ID:	0706405
Spill Number:	0706405
Spill Tank Test:	1764097
Site ID:	386923
Tank Number:	1
Tank Size:	8000
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Watchdog
Last Modified Date:	Not reported

All Materials:

Site ID:	386923
Operable Unit ID:	1144147
Operable Unit:	01
Material ID:	2134436
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum

BUSINESS (Continued) **S106125358**

Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

SPILLS:

Name:	DEROSA BUILDERS
Address:	7 LAKE STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0311640 / 2004-03-23
Facility ID:	0311640
Facility Type:	ER
DER Facility ID:	82292
Site ID:	91506
DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	B4
SWIS:	6017
Spill Date:	2004-01-15
Investigator:	jbodee
Referred To:	Not reported
Reported to Dept:	2004-01-15
CID:	444
Water Affected:	Not reported
Spill Source:	Private Dwelling
Spill Notifier:	Responsible Party
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2004-01-15
Spill Record Last Update:	2004-03-23
Spiller Name:	RAY GORHAM
Spiller Company:	TARRICONE OIL
Spiller Address:	59 MAIN STREET
Spiller Company:	001
Contact Name:	DEROSA BUILDERS
Latitude:	41.0366126
Longitude:	-73.7633347
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was O'DEE 03/23/04 NORTHEAST COMPLETED CLEAN UP.
Remarks:	WHILE DELIVERING OIL THE DROP PIPE CAME LOOSE AND SPILLED. ALL CLEANED UP.

All Materials:

Site ID:	91506
Operable Unit ID:	879249
Operable Unit:	01
Material ID:	496892
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported

BUSINESS (Continued) **S106125358**

Material FA:	Petroleum
Quantity:	3.00
Units:	G
Recovered:	3.00
Resource Affected:	Soil
Oxygenate:	Not reported

BO487 **179 FISHER AVE** **NY LTANKS** **S109064135**
SW **179 FISHER AVE** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.440 mi.
2324 ft. **Site 2 of 2 in cluster BO**

Relative:
Higher

Actual:
240 ft.

LTANKS:

Name:	179 FISHER AVE
Address:	179 FISHER AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0712211 / 2009-08-31
Facility ID:	0712211
Site ID:	393798
Spill Date:	2008-02-20
Spill Cause:	Tank Test Failure
Spill Source:	Private Dwelling
Spill Class:	D4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	JBODEE
Referred To:	Not reported
Reported to Dept:	2008-02-20
CID:	444
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	Not reported
Remediation Phase:	0
Date Entered In Computer:	2008-02-20
Spill Record Last Update:	2022-03-17
Spiller Name:	PATRICIA REMAREZ
Spiller Company:	Not reported
Spiller Address:	179 FISHER AVE
Spiller County:	001
Spiller Contact:	PATRICIA REMAREZ
Spiller Phone:	(914) 391-5176
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	343382
Latitude:	41.0257216
Longitude:	-73.7767786
DEC Memo:	8/31/2009 -- Tank test failure with no details on method or appropriateness of the method. WCDOH would have required additional testing. No information in 1 1/2 years. NFA at this time. ELM
Remarks:	Not reported

All TTF:

Facility ID:	0712211

179 FISHER AVE (Continued) **S109064135**

Spill Number:	0712211
Spill Tank Test:	2384714
Site ID:	393798
Tank Number:	Not reported
Tank Size:	550
Material:	Not reported
EPA UST:	Not reported
UST:	False
Cause:	Not reported
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Watchdog
Last Modified Date:	Not reported

All Materials:

Site ID:	393798
Operable Unit ID:	1150752
Operable Unit:	01
Material ID:	2141391
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

---

488 **SPILL NUMBER 8807217** **NY LTANKS** **S107417139**
NNE **52 NORTH BROADWAY** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.445 mi.
2350 ft.

Relative: **Higher**
Actual: **275 ft.**

LTANKS:

Name:	GOOD COUNCIL CONVENT
Address:	52 NORTH BROADWAY
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0509076 / 2006-03-21
Facility ID:	0509076
Site ID:	354798
Spill Date:	2005-10-28
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	WCHD
Referred To:	WCDOH
Reported to Dept:	2005-10-28
CID:	409
Water Affected:	Not reported

SPILL NUMBER 8807217 (Continued) **S107417139**

Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2005-10-28
Spill Record Last Update:	2006-03-21
Spiller Name:	JOHN
Spiller Company:	GOOD COUNCIL CONVENT
Spiller Address:	52 NORTH BROADWAY
Spiller County:	001
Spiller Contact:	JOHN
Spiller Phone:	(914) 557-0334
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	304812
Latitude:	41.0377300
Longitude:	-73.7658440
DEC Memo:	3-14-06 Letter reported submitted by Pro Test. Lines to the tank were excavated, removed and replaced along with 93.87 tons of petroleum impacted soil. Post ex samples were satifactory. NFA. TG
Remarks:	NO REMARKS.

All TTF:

Facility ID:	0509076
Spill Number:	0509076
Spill Tank Test:	1549468
Site ID:	354798
Tank Number:	1
Tank Size:	15000
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Watchdog
Last Modified Date:	Not reported

All Materials:

Site ID:	354798
Operable Unit ID:	1112188
Operable Unit:	01
Material ID:	2102231
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

SPILL NUMBER 8807217 (Continued) **S107417139**

Name:	SPILL NUMBER 8807217
Address:	52 NORTH BROADWAY
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8807217 / 1988-12-02
Facility ID:	8807217
Site ID:	181366
Spill Date:	1988-12-01
Spill Cause:	Tank Overfill
Spill Source:	Tank Truck
Spill Class:	Not reported
Cleanup Ceased:	1988-12-01
SWIS:	6017
Investigator:	dxtraver
Referred To:	Not reported
Reported to Dept:	1988-12-01
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Responsible Party
Last Inspection:	1988-12-01
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2003-12-02
Spill Record Last Update:	2003-12-02
Spiller Name:	Not reported
Spiller Company:	ROBISON OIL
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	304812
Latitude:	41.0377295
Longitude:	-73.7658478
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was D. TRAVER
Remarks:	SPILLAGE DUE TO PLUGGED VENT. USED SORBENT IN CLEAN-UP. ROBISON OIL - NO RESOURCES AFFECTED. CLEANUP IS COMPLETE. NFA

All Materials:

Site ID:	181366
Operable Unit ID:	923880
Operable Unit:	01
Material ID:	455561
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	10.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

BT489 **CON ED** **NY LTANKS** **S103558616**
ENE **300 MAIN ST** **NY MANIFEST** **N/A**
1/4-1/2 **WHITE PLAINS, NY 10601**
0.448 mi.
2367 ft. **Site 1 of 2 in cluster BT**

Relative:
Higher

Actual:
222 ft.

LTANKS:

Name:	BRENT WOOD APTS
Address:	300 MAIN STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8708398 / 1988-02-17
Facility ID:	8708398
Site ID:	76155
Spill Date:	1987-12-30
Spill Cause:	Tank Test Failure
Spill Source:	Private Dwelling
Spill Class:	Not reported
Cleanup Ceased:	1988-02-17
SWIS:	6017
Investigator:	jeokesso
Referred To:	Not reported
Reported to Dept:	1987-12-30
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Affected Persons
Last Inspection:	1988-02-17
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1988-01-28
Spill Record Last Update:	1988-04-04
Spiller Name:	Not reported
Spiller Company:	W.R.G. MANAGEMENT
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	130071
Latitude:	41.0345900
Longitude:	-73.7620520
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was
Remarks:	OKESSON 02/17/88: JOSH SEGEL INDICATED THAT TANK TESTED TIGHT ON 01-21-88 HAZCO. N.F.A.J.OK. 04/04/88: AS PER JOE MCCARTHY: NOTHING DONE AT THIS POINT. CALLED TANK COMPANY TO LOOK AT SITUATION. REQUESTED TANK TO BE EMPTIED ASAP. JOSH SEIGEL TO CALL BACK TODAY. 4YRS. TANK WAS CLEANED HAD TO CUT HHOLE IN TANK. SOIL IS CONTAMINATED OOZING WITH PRODUCT LEAK RATE HIGH 5K TANK. WANT DEC ADVICE

All TTF:

Facility ID:	8708398
Spill Number:	8708398
Spill Tank Test:	1532856
Site ID:	76155
Tank Number:	Not reported
Tank Size:	0
Material:	0002
EPA UST:	Not reported

CON ED (Continued) **S103558616**

UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	76155
Operable Unit ID:	913830
Operable Unit:	01
Material ID:	463792
Material Code:	0002A
Material Name:	#4 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

Name:	APT BUILDING
Address:	300 MAIN STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9810968 / 2000-02-09
Facility ID:	9810968
Site ID:	76156
Spill Date:	1998-12-01
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	D4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	WCHD
Referred To:	Westchester Cnty Health Dept
Reported to Dept:	1998-12-01
CID:	252
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1998-12-01
Spill Record Last Update:	2000-03-24
Spiller Name:	TOM GALLINGER
Spiller Company:	APT BUILDING
Spiller Address:	101 ELWOOD AV
Spiller County:	001
Spiller Contact:	JOYCE PARKER
Spiller Phone:	(914) 939-7100

CON ED (Continued) **S103558616**

Spiller Extention:	118
DEC Region:	3
DER Facility ID:	130071
Latitude:	41.0345900
Longitude:	-73.7620520
DEC Memo:	Not reported
Remarks:	ISOLATION TEST TO BE DONE IN NEXT TWO WEEKS

All TTF:

Facility ID:	9810968
Spill Number:	9810968
Spill Tank Test:	1546589
Site ID:	76156
Tank Number:	1
Tank Size:	5000
Material:	0002
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	76156
Operable Unit ID:	1071857
Operable Unit:	01
Material ID:	314826
Material Code:	0002A
Material Name:	#4 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	BRENTWOOD CONDOS
Address:	300 MAIN STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9209346 / 1993-07-19
Facility ID:	9209346
Site ID:	153296
Spill Date:	1992-11-11
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	C3
Cleanup Ceased:	1993-07-19
SWIS:	6017
Investigator:	WXWADSWO
Referred To:	Not reported

CON ED (Continued) **S103558616**

Reported to Dept:	1992-11-11
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1992-11-19
Spill Record Last Update:	1993-08-03
Spiller Name:	Not reported
Spiller Company:	SAME
Spiller Address:	Not reported
Spiller County:	999
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	130071
Latitude:	41.0345900
Longitude:	-73.7620520
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was WADSWORTH 09/27/95: This is additional information about material spilled from the translation of the old spill file: TANK TEST.
Remarks:	WILL EIR PETRO-TITE

All TTF:

Facility ID:	9209346
Spill Number:	9209346
Spill Tank Test:	1540836
Site ID:	153296
Tank Number:	Not reported
Tank Size:	0
Material:	0002
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	153296
Operable Unit ID:	972998
Operable Unit:	01
Material ID:	406397
Material Code:	0002A
Material Name:	#4 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	Not reported

CON ED (Continued) **S103558616**

Recovered: .00
Resource Affected: Soil
Oxygenate: Not reported

NY MANIFEST:
EPA ID: NYP004859546
Country: USA
Name: Con Ed
Address: 300 MAIN ST
Address 2: Not reported
City,State,Zip: WHITE PLAINS, NY 10601
Zip 4: Not reported
Location Address 1: 300 MAIN ST
Location Address 2: Not reported
Location City,State,Zip: WHITE PLAINS, NY 10601
Location Zip 4: Not reported
Facility Status: Not reported
Total Tanks: Not reported
Code: BP

Mailing:
Mailing Name: Con Ed
Mailing Contact: Tom Teeling
Mailing Address 1: 4 IRVING PLACE - 15TH FLOOR
Mailing Address 2: Not reported
Mailing City,State,Zip: NEW YORK, NY 10003
Mailing Zip 4: Not reported
Mailing Country: USA
Mailing Phone: 2124603770

Manifest Data:
Document ID: Not reported
Manifest Status: Not reported
Trans1 State ID: NJ0000027193
Year: 2018
Trans2 State ID: Not reported
Generator Ship Date: 10/24/2015
Trans1 Recv Date: 10/24/2015
Trans2 Recv Date: Not reported
TSD Site Recv Date: 10/28/2015
Part A Recv Date: Not reported
Part B Recv Date: Not reported
Generator EPA ID: NYP004859546
Trans1 EPA ID: Not reported
Trans2 EPA ID: Not reported
TSDF ID 1: NJD002200046
TSDF ID 2: Not reported
Manifest Tracking Number: 014473206JJK
Import Indicator: N
Export Indicator: N
Discr Quantity Indicator: N
Discr Type Indicator: N
Discr Residue Indicator: N
Discr Partial Reject Indicator: N
Discr Full Reject Indicator: N
Manifest Ref Number: Not reported

CON ED (Continued) **S103558616**

Alt Facility RCRA ID:	Not reported
Alt Facility Sign Date:	Not reported
MGMT Method Type Code:	H110
Waste Code a:	Not reported
Waste Code b:	Not reported
Waste Code c:	Not reported
Waste Code e:	Lead
Waste Code f:	Not reported
Waste Code g:	Not reported
Waste Code 1:	Not reported
Waste Code 2:	Not reported
Waste Code 3:	Not reported
Waste Code 4:	Not reported
Waste Code 5:	Not reported
Waste Code 6:	Not reported
Quantity:	11000
Units:	Pounds
Number of Containers:	1
Container Type:	Cargo tanks (tank trucks)
Handling Method:	Treat
Specific Gravity:	1

BU490 **ATI** **UST FINDER RELEASE** **1029063599**
NW **RTE 100 CENTRAL AVE** **N/A**
1/4-1/2 **HARTSDALE, NY 0**
0.448 mi.
2368 ft. **Site 1 of 6 in cluster BU**

Relative: **Lower**
Actual: **179 ft.**

UST FINDER RELEASE:

Object ID:	262128
Facility ID:	NY187773
Lust ID:	NY9902841
Name:	ATI
Address:	RTE 100 CENTRAL AVE
City,State,Zip:	HARTSDALE, NY 0
Address Match Type:	StreetAddress
Reported Date:	1999/06/11 15:59:59+00
Status:	No Further Action
Substance:	Not reported
Population within 1500ft:	2531
Domestic Wells within 1500ft:	0
Land Use:	Developed, Medium Intensity
Within SPA:	Yes
SPA PWS Facility ID:	NY7003493_76968
SPA Water Type:	SW - SurRELEASEe Water
SPA Facility Type:	RS - Reservoir
SPA HUC12:	20301020103
Within WHPA:	No
WHPA PWS Facility ID:	Not reported
WHPA Water Type:	Not reported
WHPA Facility Type:	Not reported
WHPA HUC12:	Not reported
Within 100yr Floodplain:	Yes
Tribe:	Not reported
EPA Region:	2
NFA Letter 1:	Not reported
NFA Letter 2:	Not reported

ATI (Continued) **1029063599**

NFA Letter 3:	Not reported
NFA Letter 4:	Not reported
Closed With Residual Contaminate:	Not reported
Coordinate Source:	Geocode
X Coord:	-73.7780299999999
Y Coord:	41.03666
Latitude:	41.0366599999999
Longitude:	-73.77803

BU491 **NEWMARK AND LEWIS PROPERT** **NY LTANKS** **S104513694**
NW **111 S.CENTRAL PARK AVE.** **N/A**
1/4-1/2 **GREENBURGH, NY**
0.449 mi.
2369 ft. **Site 2 of 6 in cluster BU**

Relative: **Lower**

Actual: **180 ft.**

LTANKS:

Name:	NEWMARK AND LEWIS PROPERT
Address:	111 S.CENTRAL PARK AVE.
City,State,Zip:	GREENBURGH, NY
Spill Number/Closed Date:	9000996 / 1990-06-13
Facility ID:	9000996
Site ID:	284169
Spill Date:	1990-04-26
Spill Cause:	Tank Failure
Spill Source:	Commercial/Industrial
Spill Class:	C3
Cleanup Ceased:	1990-05-21
SWIS:	6026
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1990-04-26
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	1990-05-21
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	True
Remediation Phase:	0
Date Entered In Computer:	1990-05-07
Spill Record Last Update:	1990-06-13
Spiller Name:	Not reported
Spiller Company:	595 SOUTH BROADWAY CO.
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	230455
Latitude:	41.0365628
Longitude:	-73.7780874
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY 06/13/90: FIVE HUNDRED YARDS OF GASOLINE CONTAMINATED SOIL REMOVED BY TANK TECH. CLEANUP SATISFACTORY.
Remarks:	DURING TANK EXCAVATION CONTAMINATION WAS DISCOVERED TANK HAS BEEN PULLED AND CUT UP TEN CUBIC YARDS STOCKPILED ON GROUND UNDER PLASTIC WILL COMPLETE SOIL REMOVAL & DISPOSAL TODD ON SCENE

NEWMARK AND LEWIS PROPERT (Continued) **S104513694**

All Materials:

Site ID:	284169
Operable Unit ID:	940816
Operable Unit:	01
Material ID:	439353
Material Code:	0009
Material Name:	gasoline
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	Not reported
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

492
West
1/4-1/2
0.449 mi.
2373 ft.

REAL ESTATE TRANS - TTF **NY LTANKS** **S116156804**
14 JEFFERSON AVE **N/A**
WHITE PLAINS, NY

Relative:
Higher

Actual:
274 ft.

LTANKS:

Name:	REAL ESTATE TRANS - TTF
Address:	14 JEFFERSON AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	1309859 / 2014-07-01
Facility ID:	1309859
Site ID:	490678
Spill Date:	2014-01-10
Spill Cause:	Tank Test Failure
Spill Source:	Private Dwelling
Spill Class:	D4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	JBODEE
Referred To:	Not reported
Reported to Dept:	2014-01-10
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2014-01-10
Spill Record Last Update:	2014-07-01
Spiller Name:	J.D. DAVIS (LISTING BROKER)
Spiller Company:	PROPERTY OWNER
Spiller Address:	14 JEFFERSON AVE
Spiller County:	999
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	445709

REAL ESTATE TRANS - TTF (Continued) **S116156804**

Latitude:	41.0330116
Longitude:	-73.7804486
DEC Memo:	1/10/14: Tank test failure of residential UST. Tested for a prospective buyer. I left a message with the listing broker (JD Davis?) requesting a call back to the dispatch desk. jod 7/1/2014: Royal Environmental removed and disposed of the UST. No evidence of a leak or of petroleum contamination was found. Post Ex samples were below CP-51 Guidance. The Tank Closure report has been reviewed and will need to be entered into DecDocs system at a later date. Based upon information provided to DEC, no further action is required at this time. jod
Remarks:	No KNOWN Loss of Product, 1000G UST.

All Materials:

Site ID:	490678
Operable Unit ID:	1240235
Operable Unit:	01
Material ID:	2240357
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported
Resource Affected:	Not reported
Oxygenate:	Not reported

BU493 **COUNTRY CENTER** **NY LTANKS** **S102663833**
NW **CENTRAL AVE** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.452 mi.
2384 ft. **Site 3 of 6 in cluster BU**

Relative:
Lower

Actual:
182 ft.

LTANKS:

Name:	COUNTRY CENTER
Address:	CENTRAL AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8808026 / 1989-02-07
Facility ID:	8808026
Site ID:	215666
Spill Date:	1989-01-06
Spill Cause:	Tank Overfill
Spill Source:	Commercial/Industrial
Spill Class:	C4
Cleanup Ceased:	1989-01-18
SWIS:	6000
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1989-01-06
CID:	Not reported
Water Affected:	BRONX RIVER
Spill Notifier:	Responsible Party
Last Inspection:	1989-02-07
Recommended Penalty:	True
Meets Standard:	True
UST Involvement:	False

COUNTRY CENTER (Continued) **S102663833**

Remediation Phase:	0
Date Entered In Computer:	1989-01-09
Spill Record Last Update:	1997-10-07
Spiller Name:	Not reported
Spiller Company:	ROBINSON OIL
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	283160
Latitude:	41.0365799
Longitude:	-73.7782300
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY
Remarks:	OVERFILLED TANK EES ON SCENE BROOK NEARNBY

All Materials:

Site ID:	215666
Operable Unit ID:	923509
Operable Unit:	01
Material ID:	452792
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	50.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

494
NNW
1/4-1/2
0.457 mi.
2411 ft.

REALTY TRANSACTION **NY LTANKS** **S106971986**
52 PARK CIRCLE **N/A**
WHITE PLAINS, NY

Relative:
Higher

Actual:
330 ft.

LTANKS:

Name:	REALTY TRANSACTION
Address:	52 PARK CIRCLE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0502737 / 2005-07-25
Facility ID:	0502737
Site ID:	347156
Spill Date:	2005-06-07
Spill Cause:	Tank Test Failure
Spill Source:	Private Dwelling
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	JBODee
Referred To:	Not reported
Reported to Dept:	2005-06-07
CID:	444
Water Affected:	Not reported

REALTY TRANSACTION (Continued) **S106971986**

Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2005-06-07
Spill Record Last Update:	2005-07-25
Spiller Name:	PAUL SCORZELLI
Spiller Company:	REALTY TRANSACTION
Spiller Address:	52 PARK CIRCLE
Spiller County:	001
Spiller Contact:	PAUL SCORZELLI
Spiller Phone:	(914) 946-4300
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	293448
Latitude:	41.0390460
Longitude:	-73.7733340
DEC Memo:	SEE SPILL 05-03444 FOR CLOSURE REPORT. jod July 25, 2005: NES DISPOSED OF LUST AND 7.12 TONS OF CONTAMINATED SOIL. CLOSURE REPORT RECEIVED FROM JM ASSOCIATES. BASED UPON INFORMATION PROVIDED TO DEC, NO FURTHER ACTION IS REQUIRED AT THIS TIME. jod
Remarks:	ISOLATE AND TEST AGAIN

All TTF:

Facility ID:	0502737
Spill Number:	0502737
Spill Tank Test:	1548966
Site ID:	347156
Tank Number:	1
Tank Size:	1000
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Watchdog
Last Modified Date:	Not reported

All Materials:

Site ID:	347156
Operable Unit ID:	1104902
Operable Unit:	01
Material ID:	1262229
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	G
Recovered:	.00
Resource Affected:	Groundwater

REALTY TRANSACTION (Continued) **S106971986**

Oxygenate: Not reported

BT495 **RESIDENCE** **NY LTANKS** **S102960214**
ENE **325 MAIN ST** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.458 mi.
2416 ft. **Site 2 of 2 in cluster BT**

Relative:
Higher

Actual:
219 ft.

LTANKS:

Name:	RESIDENCE
Address:	325 MAIN ST
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9710553 / 1998-01-09
Facility ID:	9710553
Site ID:	230651
Spill Date:	1997-12-15
Spill Cause:	Tank Failure
Spill Source:	Private Dwelling
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1997-12-15
CID:	211
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1997-12-15
Spill Record Last Update:	1998-01-29
Spiller Name:	IZET
Spiller Company:	325 MAIN ST OWNERS CORP
Spiller Address:	12 EAST END AV
Spiller County:	001
Spiller Contact:	JIM CAREY
Spiller Phone:	(718) 579-3414
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	190083
Latitude:	41.0350176
Longitude:	-73.7616039
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY 12/16/97 7,500 GAL TANK IN APT. BUILDING BASEMENT TANK ROOM; #6 FUEL OIL, 100 GAL SPILLED; CONFINED TO TANK ROOM; CONTRACTOR IN PROCESS OF CLEANING ROOM; 01/09/98 TANK HAS BEEN CLEANED; ODORS IN TANK ROOM ARE MINIMAL; NO ODORS OUTSIDE TANK ROOM; NFA;
Remarks:	CALLER STATES TANK RUPTURED - SPILL IS RECOVERABLE - CLEAN UP CREW ON WAY

All Materials:

Site ID:	230651
Operable Unit ID:	1056913
Operable Unit:	01

RESIDENCE (Continued) **S102960214**

Material ID:	328850
Material Code:	0003A
Material Name:	#6 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	100.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

496
NNE
1/4-1/2
0.459 mi.
2422 ft.

SUBODH DESHMUKH RESIDENCE
39 PARKVIEW CT
WHITE PLAINS, NY

NY LTANKS **S110309446**
N/A

Relative:
Higher

Actual:
284 ft.

LTANKS:

Name:	SUBODH DESHMUKH RESIDENCE
Address:	39 PARKVIEW CT
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	1001726 / 2010-08-03
Facility ID:	1001726
Site ID:	434804
Spill Date:	2010-05-13
Spill Cause:	Tank Test Failure
Spill Source:	Private Dwelling
Spill Class:	B3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	jbodee
Referred To:	Not reported
Reported to Dept:	2010-05-13
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	2010-06-18
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2010-05-13
Spill Record Last Update:	2010-08-03
Spiller Name:	JEFF MCKENZIE
Spiller Company:	UNKNOWN
Spiller Address:	39 PARKVIEW CT
Spiller County:	999
Spiller Contact:	JEFF MCKENZIE
Spiller Phone:	(973) 229-5897
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	389678
Latitude:	41.0386816
Longitude:	-73.7690186
DEC Memo:	5/14/10: Core soil samples were taken around the UST showing f/o contamination. Left message with resident and explained they had to address the mattter (remove tank) ASAP. Told them to call the spill

SUBODH DESHMUKH RESIDENCE (Continued) **S110309446**

desk for more information...ra > Call back from owner. Tank was tested by his employer (Prudential?) for a pending real estate transaction. He is being relocated by his employer and they are assisting in the sale of his house. He states he already has a prospective buyer who wants to close on the house in early June. Owner has contacted his insurance carrier Travlers and was told he has no coverage for an oil leak. He is contacting ATS to try and get copies of the sample results, and states he will contact a contractor - most likely Northeast Environmental - to address the spill issue. jod 6/17/10: NES has removed the tank. Contamination extends unto the neighboring property at 37 Parkview Court. The owner does not feel he showed be responsible for the clean up over the rpoperty line. Left owner a messge requesting he call me back. jod 6/29/10: Letter from NES entered into eDocs. jod 6/30/10: I spoke with the neighbor Mrs Adele Reus at 37 Parkview 914-948-5279. She has received a copy of the access agreement from NES and will be reviewing it soon. I left my name and number in case she has any questions. jod 8/3/10: NES reports has been entered into eDocs. I confirmed with Al Cianflone of NES that all contaminated soil has been removed from the property. No further action is required at this time. jod

Remarks: Caller reporting tank test failure.

All Materials:

Site ID:	434804
Operable Unit ID:	1185606
Operable Unit:	01
Material ID:	2180349
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	G
Recovered:	Not reported
Resource Affected:	Soil
Oxygenate:	Not reported

497
East
1/4-1/2
0.459 mi.
2426 ft.

CROWN PLACE HOTEL **NY LTANKS** **S111836460**
66 HALE AVE **N/A**
WHITE PLAINS, NY 10601

Relative:
Lower

Actual:
168 ft.

LTANKS:

Name:	CROWN PLAZA HOTEL
Address:	66 HALE AVE
City,State,Zip:	WHITE PLAINS, NY 10601
Spill Number/Closed Date:	1105926 / 2020-04-30
Facility ID:	1105926
Site ID:	453595
Spill Date:	2011-08-24
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	jbodee

CROWN PLAZA HOTEL (Continued) **S111836460**

Referred To:	Not reported
Reported to Dept:	2011-08-24
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2011-08-24
Spill Record Last Update:	2021-10-22
Spiller Name:	HOTETON SMITH
Spiller Company:	CROWN PLAZA HOTEL
Spiller Address:	66 TALE AVE
Spiller County:	999
Spiller Contact:	HOTETON SMITH
Spiller Phone:	(914) 821-1349
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	408220
Latitude:	41.0300617
Longitude:	-73.7604587
DEC Memo:	8-24-11: V.Mc. call to H.Smith: Left Mess.:Req. Call to Dispt. 8-25-11 Mr Smith called. Will be meeting with NE Env to discuss repair and retest. Advised him to submit documentation to close spill. jc 4/11/12 Tank was repaired by Northeast and retested. It failed again. The tank's owner is contacting Northeast to have the tank removed...mm 4/29/20: Message sent to Northeast requesting status update. jod *Northeast reports this UST was located under the city sidewalk on Paulding Street and was being used for the hotel generator. Dwayne Monaco also states the UST was replaced by Barrier Fuel. jod 4/30/20: I spoke with Wayne Jeffers of Barrier. He confirms his company removed and replaced this UST sometime in 2012 and replacing it with a double wall Stip3. He states the tank was corroded but sound, there was no contamination evident. He was unaware of the open TTF spill number so no report was submitted. Wayne forwarded a photo of the UST taken in 2012, photo will be scanned to DecDocs system at a later date. NFA required at this time. jod 10/22/2021: Photo uploaded to D2/DecDocs. jod
Remarks:	tank failure -

All Materials:

Site ID:	453595
Operable Unit ID:	1203754
Operable Unit:	01
Material ID:	2200483
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported
Resource Affected:	Not reported
Oxygenate:	Not reported

BV498 **FIRE HOUSE # 4** **NY LTANKS** **U000379970**
South **MAPLE AVE & S LEXINGTON** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.461 mi.
2432 ft. **Site 1 of 3 in cluster BV**

Relative:
Higher

Actual:
224 ft.

LTANKS:

Name:	FIRE HOUSE # 4
Address:	MAPLE AVE & S LEXINGTON
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8707150 / 1989-01-05
Facility ID:	8707150
Site ID:	178231
Spill Date:	1987-11-19
Spill Cause:	Tank Test Failure
Spill Source:	Institutional, Educational, Gov., Other
Spill Class:	Not reported
Cleanup Ceased:	1989-01-05
SWIS:	6017
Investigator:	jeokesso
Referred To:	Not reported
Reported to Dept:	1987-11-19
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	1989-01-05
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1987-11-20
Spill Record Last Update:	1989-02-07
Spiller Name:	MR. BROCCHI
Spiller Company:	CITY OF WHITE PLAINS
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	149695
Latitude:	41.0331599
Longitude:	-73.7628200
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was OKESSON
Remarks:	K SYSTEM- -.0709GPH. TO E & I & R. PBS TO FOLLOW.NO RESULTS

All TTF:

Facility ID:	8707150
Spill Number:	8707150
Spill Tank Test:	1532378
Site ID:	178231
Tank Number:	Not reported
Tank Size:	0
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00

FIRE HOUSE # 4 (Continued) **U000379970**

Test Method 2: Unknown
Leak Rate: .00
Gross Fail: Not reported
Modified By: Spills
Last Modified Date: Not reported

All Materials:
Site ID: 178231
Operable Unit ID: 912874
Operable Unit: 01
Material ID: 466123
Material Code: 0001A
Material Name: #2 fuel oil
Case No.: Not reported
Material FA: Petroleum
Quantity: .00
Units: Not reported
Recovered: .00
Resource Affected: Groundwater
Oxygenate: Not reported

---

499 West 1/4-1/2 0.462 mi. 2437 ft. **RESIDENCE** **NY LTANKS** **S106971869**
84 LINCOLN AVE **N/A**
WHITE PLAINS, NY

Relative: Higher
Actual: 333 ft.

LTANKS:
Name: RESIDENCE
Address: 84 LINCOLN AVE
City,State,Zip: WHITE PLAINS, NY
Spill Number/Closed Date: 0502066 / 2005-07-17
Facility ID: 0502066
Site ID: 346355
Spill Date: 2005-05-20
Spill Cause: Tank Test Failure
Spill Source: Private Dwelling
Spill Class: C4
Cleanup Ceased: Not reported
SWIS: 6017
Investigator: JBODee
Referred To: Not reported
Reported to Dept: 2005-05-20
CID: 408
Water Affected: Not reported
Spill Notifier: Tank Tester
Last Inspection: Not reported
Recommended Penalty: False
Meets Standard: True
UST Involvement: False
Remediation Phase: 0
Date Entered In Computer: 2005-05-20
Spill Record Last Update: 2005-07-17
Spiller Name: KENNETH FRAZER
Spiller Company: RESIDENCE
Spiller Address: 84 LINCOLN AVE

RESIDENCE (Continued) **S106971869**

Spiller County:	001
Spiller Contact:	KENNETH FRAZER
Spiller Phone:	(914) 684-0136
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	294067
Latitude:	41.0306690
Longitude:	-73.7809510
DEC Memo:	July 17, 2005: PREVIOUSLY REPORTED AS SPILL 05-01947. NORTHEAST ENVIRONMENTAL REMOVED AND DISPOSED OF TANK. NO EVIDENCE OF LEAK OR CONTAMINATION WAS FOUND. BASED UPON INFORMATION PROVIDED TO DEC, NO FURTHER ACTION IS REQUIRED AT THIS TIME. jod
Remarks:	RECOMMEND UNCOVER, REPAIR, RETEST

All TTF:

Facility ID:	0502066
Spill Number:	0502066
Spill Tank Test:	1548931
Site ID:	346355
Tank Number:	1
Tank Size:	1000
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	.00
Gross Fail:	F
Modified By:	Watchdog
Last Modified Date:	Not reported

All Materials:

Site ID:	346355
Operable Unit ID:	1104085
Operable Unit:	01
Material ID:	584290
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	FRAZER HOME
Address:	84 LINCOLN AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0501947 / 2005-07-17
Facility ID:	0501947
Site ID:	346210
Spill Date:	2005-05-18
Spill Cause:	Tank Test Failure

RESIDENCE (Continued) **S106971869**

Spill Source:	Private Dwelling
Spill Class:	D4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	JBODee
Referred To:	Not reported
Reported to Dept:	2005-05-18
CID:	444
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2005-05-18
Spill Record Last Update:	2005-07-17
Spiller Name:	KEN FRAZER
Spiller Company:	FRAZER HOME
Spiller Address:	84 LINCOLN AVE
Spiller County:	001
Spiller Contact:	KEN FRAZER
Spiller Phone:	(914) 684-0136
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	294067
Latitude:	41.0306690
Longitude:	-73.7809510
DEC Memo:	INVALID TEST METHOD. TANK FAILED A SECOND TEST. SEE SPILL 05-02066. NFA THIS NUMBER. jod
Remarks:	MESA TEST: TIGHTNESS TEST FAILURE AND IS REPAIRED

All TTF:

Facility ID:	0501947
Spill Number:	0501947
Spill Tank Test:	1548919
Site ID:	346210
Tank Number:	1
Tank Size:	1000
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Watchdog
Last Modified Date:	Not reported

All Materials:

Site ID:	346210
Operable Unit ID:	1103945
Operable Unit:	01
Material ID:	584152
Material Code:	0001A

RESIDENCE (Continued) **S106971869**

Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	G
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

BS500 **SMITH - TTF** **NY LTANKS** **S116156783**
West **70 LINCOLN AVE** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.465 mi.
2454 ft. **Site 4 of 4 in cluster BS**

Relative:
Higher

Actual:
332 ft.

LTANKS:

Name:	SMITH - TTF
Address:	70 LINCOLN AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	1309316 / 2014-05-14
Facility ID:	1309316
Site ID:	490109
Spill Date:	2013-12-20
Spill Cause:	Tank Test Failure
Spill Source:	Private Dwelling
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	JBODEE
Referred To:	Not reported
Reported to Dept:	2013-12-20
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2013-12-20
Spill Record Last Update:	2014-05-14
Spiller Name:	KELLY SMITH
Spiller Company:	Smith Residence
Spiller Address:	70 LINCOLN AVE
Spiller County:	999
Spiller Contact:	KELLY MORRIS
Spiller Phone:	(203) 453-7441
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	445184
Latitude:	41.0310016
Longitude:	-73.7807986
DEC Memo:	12/20/13: Residential TTF, tested for a pending real estate transaction. US Tank Tech will email additional information after Realtor has been notified. jod -It is a real estate transaction. Tank failed hissing and dripping. 550 tank. Owner is Smith. jod 1/13/14: Listing agent is Bill Vrooman from Better Homes & Gardens Rand

SMITH - TTF (Continued) **S116156783**

914-328-0333 x3150 He states the owners are in the process of getting estimates to have the top of the tank excavated and the piping inspected. jod 5/14/2014: Closure Report from Madison Environmental reviewed and entered into DecDocs system. Minimal amount of contamination was present, cleanup completed. Based upon information provided, no further action required at this time. jod

Remarks: repair/retest pending

All TTF:

Facility ID:	1309316
Spill Number:	1309316
Spill Tank Test:	2494909
Site ID:	490109
Tank Number:	1
Tank Size:	550
Material:	9999
EPA UST:	False
UST:	True
Cause:	99
Source:	00
Test Method:	21
Test Method 2:	Horner EZY3/EZY3 Locator Plus
Leak Rate:	Not reported
Gross Fail:	Not reported
Modified By:	JBODEE
Last Modified Date:	Not reported

All Materials:

Site ID:	490109
Operable Unit ID:	1239675
Operable Unit:	01
Material ID:	2239730
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported
Resource Affected:	Not reported
Oxygenate:	Not reported

BU501 **WESTCHESTER COUNTY AIRPOR** **NY LTANKS** **S102664220**
NW **HANGER A** **NY Spills** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.465 mi.
2454 ft. **Site 4 of 6 in cluster BU**

Relative: **Lower**
Actual: **188 ft.**

LTANKS:

Name:	WESTCHESTER COUNTY AIRPOR
Address:	HANGER A
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0105432 / 2001-08-20
Facility ID:	0105432
Site ID:	212243
Spill Date:	2001-08-20
Spill Cause:	Tank Overfill

WESTCHESTER COUNTY AIRPOR (Continued) **S102664220**

Spill Source:	Commercial Vehicle
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6000
Investigator:	mbmastro
Referred To:	Not reported
Reported to Dept:	2001-08-20
CID:	257
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2001-08-20
Spill Record Last Update:	2001-09-11
Spiller Name:	Not reported
Spiller Company:	TAG AVIATION
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	JOHN STARACE
Spiller Phone:	(914) 995-4850
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	277532
Latitude:	41.0365180
Longitude:	-73.7786640
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was MASTRO 08/20/2001 JOHN STARACE CALLED BACK. NO FURTHER ACTION.
Remarks:	2 gals out of left wing vent valve

All Materials:

Site ID:	212243
Operable Unit ID:	842343
Operable Unit:	01
Material ID:	533900
Material Code:	0011
Material Name:	jet fuel
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	2.00
Units:	G
Recovered:	2.00
Resource Affected:	Soil
Oxygenate:	Not reported

SPILLS:

Name:	WESTCHESTER COUNTY AIRPOR
Address:	HANGER A
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0004344 / 2000-07-11
Facility ID:	0004344
Facility Type:	ER
DER Facility ID:	277532
Site ID:	212242

WESTCHESTER COUNTY AIRPOR (Continued) **S102664220**

DEC Region:	3
Spill Cause:	Other
Spill Class:	C4
SWIS:	6000
Spill Date:	2000-07-11
Investigator:	rdbendel
Referred To:	Not reported
Reported to Dept:	2000-07-11
CID:	233
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Affected Persons
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2000-07-11
Spill Record Last Update:	2000-07-17
Spiller Name:	Not reported
Spiller Company:	SIGNATURE FLIGHT SUPPORT
Spiller Address:	240 AIRPORT RD, HANGAR A
Spiller Company:	001
Contact Name:	JOHN KASTENS
Latitude:	41.0365180
Longitude:	-73.7786640
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was BENDELL 07/11/2000 NO RESPONSE NEEDED; NFA
Remarks:	capt of aircraft was transfering fuel from one tank to another material leaked out of a vent material spilled to pavement material was cleaned by spiller

All Materials:

Site ID:	212242
Operable Unit ID:	826884
Operable Unit:	01
Material ID:	549085
Material Code:	0011
Material Name:	jet fuel
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	5.00
Units:	G
Recovered:	5.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	WESTCHESTER COUNTY AIRPRT
Address:	HANGER A
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0207673 / 2002-10-24
Facility ID:	0207673
Facility Type:	ER
DER Facility ID:	277532
Site ID:	212246

WESTCHESTER COUNTY AIRPOR (Continued) **S102664220**

DEC Region:	3
Spill Cause:	Equipment Failure
Spill Class:	C4
SWIS:	6000
Spill Date:	2002-10-24
Investigator:	dxtraver
Referred To:	Not reported
Reported to Dept:	2002-10-24
CID:	204
Water Affected:	Not reported
Spill Source:	Private Dwelling
Spill Notifier:	Local Agency
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2002-10-24
Spill Record Last Update:	2002-10-31
Spiller Name:	JOHN STARACE
Spiller Company:	WESTCHESTER COUNTY AIRPRT
Spiller Address:	HANGER A
Spiller Company:	001
Contact Name:	JOHN STARACE
Latitude:	41.0365180
Longitude:	-73.7786640
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was TRAVER 10/24/02: SPILL CONTAINED TO ASPHALT. NO DRAINS IMPACTED. NFA REQUIRED AT THIS TIME.
Remarks:	LEFT WING VENT VALVE

All Materials:

Site ID:	212246
Operable Unit ID:	859262
Operable Unit:	01
Material ID:	514685
Material Code:	0011
Material Name:	jet fuel
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	5.00
Units:	G
Recovered:	5.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	WESTCHESTER COUNTY AIRPOR
Address:	HANGER A
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9702457 / 1997-05-28
Facility ID:	9702457
Facility Type:	ER
DER Facility ID:	277532
Site ID:	212249
DEC Region:	3
Spill Cause:	Equipment Failure

WESTCHESTER COUNTY AIRPOR (Continued) **S102664220**

Spill Class:	C4
SWIS:	6000
Spill Date:	1997-05-28
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1997-05-28
CID:	205
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Affected Persons
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	1997-05-28
Spill Record Last Update:	1999-07-28
Spiller Name:	Not reported
Spiller Company:	CESSENA AIRCRAFT COMPANY
Spiller Address:	1 CESSENA BLVD
Spiller Company:	001
Contact Name:	JOHN STARACE
Latitude:	41.0365180
Longitude:	-73.7786640
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY
Remarks:	aircraft left wing vent, vented fuel to tarmack.

All Materials:

Site ID:	212249
Operable Unit ID:	1048448
Operable Unit:	01
Material ID:	335396
Material Code:	0011
Material Name:	jet fuel
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	5.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

BU502 **WESTCHESTER COUNTY AIRPOR** **NY LTANKS** **S106702751**
NW **HANGER E - TELLER ROAD** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.465 mi.
2454 ft. **Site 5 of 6 in cluster BU**

Relative:
Lower

Actual:
188 ft.

LTANKS:

Name:	WESTCHESTER COUNTY AIRPOR
Address:	HANGER E - TELLER ROAD
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0406492 / 2004-09-13
Facility ID:	0406492
Site ID:	307691

WESTCHESTER COUNTY AIRPOR (Continued) **S106702751**

Spill Date:	2004-09-12
Spill Cause:	Tank Overfill
Spill Source:	Passenger Vehicle
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	jbodee
Referred To:	Not reported
Reported to Dept:	2004-09-13
CID:	444
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2004-09-13
Spill Record Last Update:	2004-09-24
Spiller Name:	Not reported
Spiller Company:	AIRPLANE
Spiller Address:	Not reported
Spiller County:	999
Spiller Contact:	GARY SALK
Spiller Phone:	(914) 995-4850
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	248490
Latitude:	41.0365180
Longitude:	-73.7786640
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was O'DEE
Remarks:	the fuel vented out of wing while fueling: all cleaned up:

All Materials:

Site ID:	307691
Operable Unit ID:	889111
Operable Unit:	01
Material ID:	487590
Material Code:	0011
Material Name:	jet fuel
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	2.00
Units:	G
Recovered:	2.00
Resource Affected:	Soil
Oxygenate:	Not reported

BU503 **WESTCHESTER COUNTY AIRPOR** **NY LTANKS** **S105135494**
NW **AVITAT RAMP** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.465 mi.
2454 ft. **Site 6 of 6 in cluster BU**

Relative:
Lower

Actual:
188 ft.

LTANKS:

Name:	WESTCHESTER COUNTY AIRPOR
Address:	AVITAT RAMP
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0106275 / 2001-09-14
Facility ID:	0106275
Site ID:	201432
Spill Date:	2001-09-13
Spill Cause:	Tank Overfill
Spill Source:	Vessel
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	mbmastro
Referred To:	Not reported
Reported to Dept:	2001-09-13
CID:	390
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2001-09-13
Spill Record Last Update:	2001-10-01
Spiller Name:	Not reported
Spiller Company:	AVITAT FUELERS
Spiller Address:	AIRPORT
Spiller County:	001
Spiller Contact:	ABOVE
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	167592
Latitude:	41.0365180
Longitude:	-73.7786640
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was MASTRO
Remarks:	aircraft was overfilled - all cleaned up

All Materials:

Site ID:	201432
Operable Unit ID:	843200
Operable Unit:	01
Material ID:	531138
Material Code:	0011
Material Name:	jet fuel
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	10.00
Units:	G
Recovered:	10.00
Resource Affected:	Soil

WESTCHESTER COUNTY AIRPOR (Continued) **S105135494**

Oxygenate: Not reported

504
North
1/4-1/2
0.467 mi.
2464 ft.

BERTE HOME **NY LTANKS** **S106869335**
3 CHURCH COURT **N/A**
WHITE PLAINS, NY

Relative:
Higher

Actual:
302 ft.

LTANKS:

Name:	BERTE HOME
Address:	3 CHURCH COURT
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0501302 / 2005-06-19
Facility ID:	0501302
Site ID:	344494
Spill Date:	2005-05-02
Spill Cause:	Tank Failure
Spill Source:	Private Dwelling
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	JBODee
Referred To:	Not reported
Reported to Dept:	2005-05-02
CID:	444
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2005-05-02
Spill Record Last Update:	2005-06-19
Spiller Name:	DENNIS BERTE
Spiller Company:	BERTE HOME
Spiller Address:	3 CHURCH COURT
Spiller County:	001
Spiller Contact:	DENNIS BERTE
Spiller Phone:	(914) 761-2877
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	291183
Latitude:	41.0388820
Longitude:	-73.7700810
DEC Memo:	June 19, 2005: ELITE ENVIRONMENTAL DISPOSED OF LUST AND 6.17 TONS OF CONTAMINATED SOIL. BASED UPON INFORMATION PROVIDED TO DEC, NO FURTHER ACTION IS REQUIRED AT THIS TIME. jod
Remarks:	FOUND HOLES WHILE REMOVING:

All Materials:

Site ID:	344494
Operable Unit ID:	1103135
Operable Unit:	01
Material ID:	583340
Material Code:	0001A
Material Name:	#2 fuel oil

BERTE HOME (Continued) **S106869335**

Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	G
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

BW505 **9 LAFAYETTE STREET** **NY LTANKS** **S105997345**
SW **9 LAFAYETTE STREET** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.468 mi.
2471 ft. **Site 1 of 2 in cluster BW**

Relative:
Higher

Actual:
233 ft.

LTANKS:

Name:	9 LAFAYETTE STREET
Address:	9 LAFAYETTE STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0208594 / 2012-08-13
Facility ID:	0208594
Site ID:	322970
Spill Date:	2002-11-19
Spill Cause:	Tank Test Failure
Spill Source:	Private Dwelling
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	UNASSIGNED
Referred To:	Not reported
Reported to Dept:	2002-11-19
CID:	204
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2002-11-19
Spill Record Last Update:	2012-08-13
Spiller Name:	DOROTHY JENSEN REALITY
Spiller Company:	9 LAFAYETTE STREET
Spiller Address:	9 LAFAYETTE STREET
Spiller County:	001
Spiller Contact:	KATHY MORGAN
Spiller Phone:	(845) 225-5240
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	260176
Latitude:	41.0258137
Longitude:	-73.7778341
DEC Memo:	7/28/10 Homeowner TTF JO'M 8/13/12 With Albany and regional approval all Homeowner Tank Test Failure with no impact older than 5 years will be closed. NFA JO M
Remarks:	TANK TEST FAILURE

All TTF:

9 LAFAYETTE STREET (Continued) **S105997345**

Facility ID:	0208594
Spill Number:	0208594
Spill Tank Test:	1527730
Site ID:	322970
Tank Number:	Not reported
Tank Size:	0
Material:	Not reported
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

Facility ID:	0208594
Spill Number:	0208594
Spill Tank Test:	1527731
Site ID:	322970
Tank Number:	1
Tank Size:	550
Material:	Not reported
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	322970
Operable Unit ID:	861580
Operable Unit:	01
Material ID:	515595
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

506
NNE
1/4-1/2
0.471 mi.
2486 ft.

YWCA
69 NORTH BROADWAY
WHITE PLAINS, NY

NY LTANKS

S105997109
N/A

Relative:
Higher

Actual:
288 ft.

LTANKS:

Name:	YWCA
Address:	69 NORTH BROADWAY
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0207697 / 2003-05-09
Facility ID:	0207697
Site ID:	63852
Spill Date:	2002-10-24
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	D3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	WCHD
Referred To:	Westchester Cnty Health Dept
Reported to Dept:	2002-10-24
CID:	252
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2002-10-24
Spill Record Last Update:	2003-06-25
Spiller Name:	REGINALD BUSH
Spiller Company:	YWCA
Spiller Address:	69 NORTH BROADWAY
Spiller County:	001
Spiller Contact:	REGINALD BUSH
Spiller Phone:	(914) 428-1130
Spiller Extention:	303
DEC Region:	3
DER Facility ID:	61609
Latitude:	41.0388010
Longitude:	-73.7666487
DEC Memo:	Not reported
Remarks:	RECOMMENDATION TO UNCOVER-RE-TEST AND OR REMOVE TANK.

All TTF:

Facility ID:	0207697
Spill Number:	0207697
Spill Tank Test:	1527616
Site ID:	63852
Tank Number:	Not reported
Tank Size:	3000
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II

YWCA (Continued) **S105997109**

Leak Rate: .00
Gross Fail: Not reported
Modified By: Spills
Last Modified Date: Not reported

All Materials:
Site ID: 63852
Operable Unit ID: 859285
Operable Unit: 01
Material ID: 514708
Material Code: 0001A
Material Name: #2 fuel oil
Case No.: Not reported
Material FA: Petroleum
Quantity: .00
Units: G
Recovered: .00
Resource Affected: Soil
Oxygenate: Not reported

507
SW
1/4-1/2
0.471 mi.
2489 ft.

WHITE PLAINS PROJECT LLC
179 WESTMORELAND AVE
WHITE PLAINS, NY

NY LTANKS **S110769273**
NY Spills **N/A**

Relative:
Higher

Actual:
215 ft.

LTANKS:
Name: BENEROFE PROPERTIES INC
Address: 179 WESTMORELAND AVE
City,State,Zip: WHITE PLAINS, NY
Spill Number/Closed Date: 8800315 / 1988-11-25
Facility ID: 8800315
Site ID: 317805
Spill Date: 1988-04-08
Spill Cause: Tank Test Failure
Spill Source: Commercial/Industrial
Spill Class: C4
Cleanup Ceased: 1988-11-16
SWIS: 6017
Investigator: jeokesso
Referred To: Not reported
Reported to Dept: 1988-04-11
CID: Not reported
Water Affected: Not reported
Spill Notifier: Tank Tester
Last Inspection: 1988-11-16
Recommended Penalty: False
Meets Standard: True
UST Involvement: False
Remediation Phase: 0
Date Entered In Computer: 1988-05-02
Spill Record Last Update: 2012-01-11
Spiller Name: Not reported
Spiller Company: SAME
Spiller Address: Not reported
Spiller County: 001

WHITE PLAINS PROJECT LLC (Continued) **S110769273**

Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	401552
Latitude:	41.0264639
Longitude:	-73.7788450
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was OKESSON 11/25/88: RETEST PASSED.
Remarks:	10,000 GAL. TANK GROSS LEAK SPILLER TO CALL WITH UPDATE.RETEST NEEDED. Not reported

All TTF:

Facility ID:	8800315
Spill Number:	8800315
Spill Tank Test:	1533621
Site ID:	317805
Tank Number:	Not reported
Tank Size:	0
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	317805
Operable Unit ID:	917150
Operable Unit:	01
Material ID:	463028
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

SPILLS:

Name:	WHITE PLAINS PROJECT LLC
Address:	179 WESTMORELAND AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	1012728 / 2012-11-28
Facility ID:	1012728
Facility Type:	ER
DER Facility ID:	401552
Site ID:	446944
DEC Region:	3

WHITE PLAINS PROJECT LLC (Continued) **S110769273**

Spill Cause:	Equipment Failure
Spill Class:	A3
SWIS:	6017
Spill Date:	2011-03-22
Investigator:	jbodee
Referred To:	Not reported
Reported to Dept:	2011-03-22
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Other
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2011-03-22
Spill Record Last Update:	2024-04-01
Spiller Name:	JOHN ARREDONDO
Spiller Company:	WHITE PLAINS PROJECT LLC
Spiller Address:	179 WEFTMORELAND AVE
Spiller Company:	999
Contact Name:	JOHN ARREDONDO
Latitude:	41.0264890
Longitude:	-73.7787893
DEC Memo:	3-22-11 Building was demolished in Feb. There was suspected contamination in area of boiler room. While digging in that area, found contamination and unregistered 5000 gal tank. Denise H from WCHD was at site already. Contaminated soil being removed and taken to New Windsor. jc Update from WCDOH PBS: Heinzinger, Denise dmh3@westchestergov.com 11/21/2012 1:30 PM Hi John, This spill resulted from an unknown underground storage tank at an empty lot at 170 Westmoreland Avenue, White Plains. They were removing a registered 10,000 gallon ust then found this second unregistered 5,000 gallon tank. Grave samples came back high for the 5,000 so 2,237.85 tons of contaminated soil was then removed. End samples look good. -Denise Heinzinger *Based open the information received, no further action is required at this time. jod
Remarks:	an unknown tank was discovered during construction, believed to be 2000 gallons w/ either #2 or # 4 fuel, clean up and removal pending

All Materials:

Site ID:	446944
Operable Unit ID:	1197080
Operable Unit:	01
Material ID:	2193411
Material Code:	0066A
Material Name:	unknown petroleum
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported

WHITE PLAINS PROJECT LLC (Continued) **S110769273**

Resource Affected: Soil
Oxygenate: Not reported

BW508 **PVT DWELLING** **NY LTANKS** **S110140532**
SW **195 FISHER AVE** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.473 mi.
2497 ft. **Site 2 of 2 in cluster BW**

Relative:
Higher

Actual:
239 ft.

LTANKS:

Name:	PVT DWELLING
Address:	195 FISHER AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0909891 / 2014-01-16
Facility ID:	0909891
Site ID:	422623
Spill Date:	2009-12-07
Spill Cause:	Tank Test Failure
Spill Source:	Private Dwelling
Spill Class:	D5
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	JBODEE
Referred To:	Not reported
Reported to Dept:	2009-12-07
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2009-12-07
Spill Record Last Update:	2020-07-22
Spiller Name:	SID WALKER
Spiller Company:	PVT DWELLING
Spiller Address:	195 FISHER AVE
Spiller County:	999
Spiller Contact:	KEITH SINISTORE
Spiller Phone:	(845) 255-5240
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	371554
Latitude:	41.0253117
Longitude:	-73.7774086
DEC Memo:	12/7/09 Tank tester says house is owned by bank, who would not divulge any other info. dw 1/16/14 With Albany's OK any HOTTF with no indication odf a spill will be closed or assigned to someone after 3 years. NFA JO'M
Remarks:	TANK TEST FAILURE ON A 550 GALLON UST.

All Materials:

Site ID:	422623
Operable Unit ID:	1178458
Operable Unit:	01
Material ID:	2171834

PVT DWELLING (Continued) **S110140532**

Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	G
Recovered:	Not reported
Resource Affected:	Not reported
Oxygenate:	Not reported

509
SSE
1/4-1/2
0.477 mi.
2517 ft.

APARTMENT BLDG
21 GREENRIDGE AVE
WHITE PLAINS, NY

NY LTANKS **S102152028**
NY Spills **N/A**

Relative:
Higher

Actual:
270 ft.

LTANKS:

Name:	RESIDENCE
Address:	21 GREENRIDGE AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0410525 / 2005-02-24
Facility ID:	0410525
Site ID:	335499
Spill Date:	2004-12-22
Spill Cause:	Tank Test Failure
Spill Source:	Private Dwelling
Spill Class:	B3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	JBODEE
Referred To:	WCDOH
Reported to Dept:	2004-12-22
CID:	407
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2004-12-22
Spill Record Last Update:	2023-09-01
Spiller Name:	JOHN PORZIO
Spiller Company:	RESIDENCE
Spiller Address:	21 GREENRIDGE AVE
Spiller County:	001
Spiller Contact:	JOHN PORZIO
Spiller Phone:	(914) 980-5005
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	270748
Latitude:	41.0252870
Longitude:	-73.7652250
DEC Memo:	3/4/05: PBS 3-410608; Letter to John S. Porzio from Karen Magnuson, WCDOH dated 24Feb2005. WCDOH recommends NFA at this time.
Remarks:	PBS No: 3-410608

APARTMENT BLDG (Continued) **S102152028**

All TTF:

Facility ID:	0410525
Spill Number:	0410525
Spill Tank Test:	1548433
Site ID:	335499
Tank Number:	1
Tank Size:	2000
Material:	Not reported
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Watchdog
Last Modified Date:	Not reported

SPILLS:

Name:	APARTMENT BLDG
Address:	21 GREENRIDGE AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9204409 / 1992-07-20
Facility ID:	9204409
Facility Type:	ER
DER Facility ID:	270748
Site ID:	167659
DEC Region:	3
Spill Cause:	Human Error
Spill Class:	C3
SWIS:	6017
Spill Date:	1992-07-16
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1992-07-17
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Responsible Party
Cleanup Ceased:	1992-07-20
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2003-12-02
Spill Record Last Update:	2005-02-12
Spiller Name:	Not reported
Spiller Company:	REGENT OIL
Spiller Address:	53 CHARLES STREET
Spiller Company:	001
Contact Name:	Not reported
Latitude:	41.0252920
Longitude:	-73.7652355

APARTMENT BLDG (Continued) **S102152028**

DEC Memo: Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY

Remarks: EMPTYING OIL HOSE AND FUEL CAME OUT VENT PIPE WPFD WAS ON SCENE AND LUZON ON SCENE PUT DOWN SPEEDI-DRI SPOKE WITH KENNY (LUZON) THEY ARE PICKING UP CONTAMINATED SOIL AND WILL DISPOSE

All Materials:

Site ID:	167659
Operable Unit ID:	968157
Operable Unit:	01
Material ID:	412135
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	10.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

---

510 ENE 1/4-1/2 0.480 mi. 2533 ft. **3-5 FRANKLIN AVE** **NY LTANKS S102154546**
3-5 FRANKLIN AVE **NY Spills N/A**
WHITE PLAINS, NY

Relative: Lower
Actual: 180 ft.

LTANKS:

Name:	3-5 FRANKLIN AVE
Address:	3-5 FRANKLIN AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8800464 / 1989-01-11
Facility ID:	8800464
Site ID:	161165
Spill Date:	1988-04-14
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	Not reported
Cleanup Ceased:	1989-01-11
SWIS:	6017
Investigator:	jeokesso
Referred To:	Not reported
Reported to Dept:	1988-04-14
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	1989-01-11
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1988-05-04
Spill Record Last Update:	1989-02-07
Spiller Name:	Not reported
Spiller Company:	PRESIDENTIAL MANAGEMENT
Spiller Address:	180 S. BROADWAY
Spiller County:	001

3-5 FRANKLIN AVE (Continued) **S102154546**

Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	136071
Latitude:	41.0337696
Longitude:	-73.7603068
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was OKESSON
Remarks:	5K TTF AT GROSS RATE. PBS TO FOLLOW.RETEST NEEDED.

All TTF:

Facility ID:	8800464
Spill Number:	8800464
Spill Tank Test:	1533653
Site ID:	161165
Tank Number:	Not reported
Tank Size:	0
Material:	0002
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	161165
Operable Unit ID:	917348
Operable Unit:	01
Material ID:	459648
Material Code:	0002A
Material Name:	#4 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	Not reported
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

Name:	APT. BUILDING
Address:	3-5 FRANKLIN AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9207566 / 1993-02-05
Facility ID:	9207566
Site ID:	161166
Spill Date:	1992-09-29
Spill Cause:	Tank Failure
Spill Source:	Commercial/Industrial
Spill Class:	C3
Cleanup Ceased:	1993-02-05

3-5 FRANKLIN AVE (Continued) **S102154546**

SWIS:	6017
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1992-09-30
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Responsible Party
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1992-09-30
Spill Record Last Update:	1993-02-05
Spiller Name:	Not reported
Spiller Company:	SAME
Spiller Address:	Not reported
Spiller County:	999
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	136071
Latitude:	41.0337696
Longitude:	-73.7603068
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY 02/05/93: SPOKE WITH ED TORHAN WCHD- SPILL HAS BEEN CLEANED UP BY SPILLER.
Remarks:	PIPE LINE REPAIRED SPEEDI-DRI APPLIED WILL PICK UP AND DISPOSE W.P.F.D. RESPONDED FOR ROUTINE INSPECTION

All Materials:

Site ID:	161166
Operable Unit ID:	974406
Operable Unit:	01
Material ID:	408196
Material Code:	0002A
Material Name:	#4 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	10.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

SPILLS:

Name:	3-5 FRANKLIN AVE. OWNERS
Address:	3-5 FRANKLIN AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9305571 / 1997-11-20
Facility ID:	9305571
Facility Type:	ER
DER Facility ID:	136071
Site ID:	161167
DEC Region:	3

3-5 FRANKLIN AVE (Continued) **S102154546**

Spill Cause:	Equipment Failure
Spill Class:	C3
SWIS:	6017
Spill Date:	1993-08-04
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1993-08-04
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Private Dwelling
Spill Notifier:	Other
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	1993-08-16
Spill Record Last Update:	1997-12-29
Spiller Name:	Not reported
Spiller Company:	SAME
Spiller Address:	Not reported
Spiller Company:	999
Contact Name:	Not reported
Latitude:	41.0337696
Longitude:	-73.7603068
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY 11/29/95 OIL RECOVERY SYSTEM INSTALLED BY EES HAVE BEEN INEFFECTIVE IN RECOVERING PRODUCT NEW SYSTEM WILL BE DESIGNED BY DAN FLORENTINO OF AEON ENVIRON. SPEC. 11/20/97 LETTER SENT BY TODD; NFA;
Remarks:	FUEL OIL SEEPING UP THROUGH FLOOR OF BOILER ROOM IN APARTMENT BUILDING Not reported

All TTF:

Facility ID:	9305571
Spill Number:	9305571
Spill Tank Test:	1541846
Site ID:	161167
Tank Number:	Not reported
Tank Size:	0
Material:	0002
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	00
Test Method 2:	Unknown
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	161167
Operable Unit ID:	987082

3-5 FRANKLIN AVE (Continued) **S102154546**

Operable Unit:	01
Material ID:	395483
Material Code:	0002A
Material Name:	#4 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	L
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

---

511 **APT BUILDING** **NY LTANKS** **S110243958**
NE **16 LAKE STREET** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.483 mi.
2548 ft.

Relative:
Higher

Actual:
240 ft.

LTANKS:

Name:	APARTMENT BUILDING
Address:	16 LAKE ST
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	2102648 / 2021-09-28
Facility ID:	2102648
Site ID:	620396
Spill Date:	2021-06-21
Spill Cause:	Tank Test Failure
Spill Source:	Non Major Facility > 1,100 gal
Spill Class:	B3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	BTRANSOM
Referred To:	Not reported
Reported to Dept:	2021-06-21
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2021-06-21
Spill Record Last Update:	2023-05-17
Spiller Name:	Not reported
Spiller Company:	BUILDING OWNER
Spiller Address:	Not reported
Spiller County:	999
Spiller Contact:	KATHY MORGAN
Spiller Phone:	(845) 855-3970
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	567897
Latitude:	Not reported
Longitude:	Not reported
DEC Memo:	6/21/21 Tank test failure on 7,500-gal UST with 96 diameter. Failed EZY3 Locator Plus above liquid level. Test did not isolate lines

APT BUILDING (Continued) **S110243958**

separately. JG 6/22/21: From Chris Lalak at WCDOH PBS: TTF at PBS site 16 Lake St owners ins 16 Lake st ,WP PBS 3-123293 7500 UST from 1966 US Tank Tech failed tank. US TT reports they are hiring NEE to investigate. Site contact is Robert Lindenbaum Prime location 914-963-7400 X214 I left Bob a VM. To action and get me something within 2 weeks and to call me. jod 07-27-21 Tank will be pumped dry either today or tomorrow. Tank removal pending a new contract. BTR 09-28-21 Closing. See spill 2103947 for updates. BTR

Remarks: Tank test failure

All Materials:

Site ID:	620396
Operable Unit ID:	1367580
Operable Unit:	01
Material ID:	2380422
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported
Resource Affected:	Not reported
Oxygenate:	Not reported

Name:	LAKE ST OWNERS - PBS TTF RETEST
Address:	16 LAKE ST
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	2103947 / 2024-10-18
Facility ID:	2103947
Site ID:	622740
Spill Date:	2021-07-26
Spill Cause:	Tank Test Failure
Spill Source:	Private Dwelling
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	TDGHIOSA
Referred To:	Not reported
Reported to Dept:	2021-07-26
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2021-07-26
Spill Record Last Update:	2024-10-18
Spiller Name:	Not reported
Spiller Company:	LAKE ST OWNERS
Spiller Address:	16 LAKE ST
Spiller County:	999
Spiller Contact:	KATHY
Spiller Phone:	845-855-3970
Spiller Extention:	Not reported

APT BUILDING (Continued) **S110243958**

DEC Region: 3
DER Facility ID: 567897
Latitude: Not reported
Longitude: Not reported
DEC Memo: 7/26/21 called back the number for the spill caller and it continues to ring without going to voicemail. BW 07-26-21 Same as spill 2102648 for a previous line failure. Information from WCHD: TTF at PBS site 16 Lake St owners ins 16 Lake st ,WP PBS 3-123293 7500 UST from 1966 US Tank Tech failed tank. US TT reports they are hiring NEE to investigate. BTR 07-27-21 Update from NEE: Tank will be pumped dry either today or tomorrow. Tank removal pending a new contract. BTR 7/28/21: Update from Chris Lalak at WCDOH via email: 2nd TTF NEE is pumping out the tank today. 2102548 6-21-21 TTF 2103947 7-26-21 2nd TTF 16 Lake St Owners 16 Lake Street White Plains NY 10607 PBS 3-123293 7500 UST from 1966 The building is on Gas interruptible service and is running on gas. NEE is working on it Bob Lindenbaum 914-963-7400x214 Prime locations is the property mng. jod 09-21-21 Spoke to NEE. Tank has been pumped out and removal is pending new contract. BTR 4/19/2023: DEC Lead changed during spill file review. Tank is still listed as in service on current WCDOH PBS database. Will followup with County on status. jod 5/17/2023: All Boro Environmental contacted DEC Div of Water requesting approval to perform an in-place abandonment of this 7,500 gallon UST. Christopher Quintana from All Boro states he has been working with Daniel Bucci from WCDOH PBS who requested soil samples from below the UST. All Boro was referred back to the County Health Dept. Message sent to WCDOH Chris Lalak requesting an update. jod 05/25/23 Chris Lalak emailed to Chris Quintana at All Boro, The WCDOH permit to close the tank in place has been issued. That date is acceptable. What will you be filling the tank with? No inspection is required please complete the work and then submit a report of the activities. TG 10/18/24 Emailed Natasha Court asking if the spill should be closed. Natasha Court emailed the tank closure documents. Based on that information, NFA. See report in DecDocs. TG
Remarks: 7500 gal ust tank. no release to environment just tank test failure.

All TTF:
Facility ID: 2103947
Spill Number: 2103947
Spill Tank Test: 2509222
Site ID: 622740
Tank Number: UST
Tank Size: 7500
Material: 0001
EPA UST: False
UST: True
Cause: 99
Source: 00
Test Method: 34
Test Method 2: EZY 3 Locator Plus
Leak Rate: Not reported
Gross Fail: Not reported
Modified By: JBODEE
Last Modified Date: Not reported

All Materials:
Site ID: 622740

APT BUILDING (Continued) **S110243958**

Operable Unit ID:	1369894
Operable Unit:	01
Material ID:	2382857
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	Not reported
Recovered:	Not reported
Resource Affected:	Not reported
Oxygenate:	Not reported

Name:	APT BUILDING
Address:	16 LAKE STREET
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0912833 / 2010-06-23
Facility ID:	0912833
Site ID:	425742
Spill Date:	2010-03-10
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	JKOMARA
Referred To:	Not reported
Reported to Dept:	2010-03-10
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2010-03-10
Spill Record Last Update:	2010-06-23
Spiller Name:	Not reported
Spiller Company:	FAILED TANK TEST
Spiller Address:	Not reported
Spiller County:	999
Spiller Contact:	MEG @ WHITE MGMT
Spiller Phone:	(914) 874-5424
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	374630
Latitude:	41.0363116
Longitude:	-73.7627787
DEC Memo:	Spoke to Kathy at US tank. Hole in vent pipe below pavement. US Tank advised owner to excavate tank top, isolate and retest. WCHD to be notified also by US Tank. WCHD regulated site. DT 3/10/10 6/23/10 WCDOH reports that ttf 3/10/10.received report from petroleum tank claners indicating replacement of fill port and passing retest JO'M
Remarks:	Not reported

APT BUILDING (Continued) **S110243958**

All Materials:

Site ID:	425742
Operable Unit ID:	1181454
Operable Unit:	01
Material ID:	2175539
Material Code:	0002A
Material Name:	#4 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	G
Recovered:	Not reported
Resource Affected:	Not reported
Oxygenate:	Not reported

Site ID:	425742
Operable Unit ID:	1181454
Operable Unit:	01
Material ID:	2175540
Material Code:	0002A
Material Name:	#4 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	Not reported
Units:	G
Recovered:	Not reported
Resource Affected:	Not reported
Oxygenate:	Not reported

512
SE
1/4-1/2
0.484 mi.
2553 ft.

ROADWAY
285 MAMARONECK AVE
WHITE PLAINS, NY

NY LTANKS **S102240718**
NY Spills **N/A**

Relative:
Higher

Actual:
236 ft.

LTANKS:

Name:	C STAR DINER
Address:	285 MAMARONECK ST
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9712450 / 2020-07-10
Facility ID:	9712450
Site ID:	85909
Spill Date:	1998-02-07
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1998-02-07
CID:	211
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False

ROADWAY (Continued) **S102240718**

Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1998-02-07
Spill Record Last Update:	2020-07-10
Spiller Name:	WILLIAM S OLESON
Spiller Company:	C STAR DINER
Spiller Address:	285 MAMARONECK ST
Spiller County:	001
Spiller Contact:	WILLIAM S OLESON
Spiller Phone:	(914) 948-4500
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	78861
Latitude:	41.0256811
Longitude:	-73.7637177
DEC Memo:	02/07/98 ROBISON OIL WILL ARRANGE TO E.I.R. 8/3/10 TTF JO'M 07/10/20 Emailed Chris Lalak about the status of this tank. He responded that a tank for the facility was removed in 1998. Facility has been redeveloped and is now a TD Bank. NFA. TG
Remarks:	REQ DEC REP CONTACT OWNER OF DINER ON MONDAY

All TTF:

Facility ID:	9712450
Spill Number:	9712450
Spill Tank Test:	1545605
Site ID:	85909
Tank Number:	1
Tank Size:	2000
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	.00
Gross Fail:	F
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	85909
Operable Unit ID:	1058741
Operable Unit:	01
Material ID:	327052
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

ROADWAY (Continued) **S102240718**

SPILLS:

Name:	ROADWAY
Address:	285 MAMARONECK AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9511162 / 1995-12-05
Facility ID:	9511162
Facility Type:	ER
DER Facility ID:	139914
Site ID:	166024
DEC Region:	3
Spill Cause:	Unknown
Spill Class:	C5
SWIS:	6017
Spill Date:	1995-12-05
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1995-12-05
CID:	233
Water Affected:	Not reported
Spill Source:	Commercial Vehicle
Spill Notifier:	Fire Department
Cleanup Ceased:	1995-12-05
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	1995-12-05
Spill Record Last Update:	1995-12-12
Spiller Name:	Not reported
Spiller Company:	UNKNOWN
Spiller Address:	Not reported
Spiller Company:	999
Contact Name:	Not reported
Latitude:	41.0256811
Longitude:	-73.7637177
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY
Remarks:	tanker truck was leaking as it drove down the road the majority of the spill is in front of the above address leak is stopped clean up underway

All Materials:

Site ID:	166024
Operable Unit ID:	1025458
Operable Unit:	01
Material ID:	358513
Material Code:	0066A
Material Name:	unknown petroleum
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	50.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

513
SSW
1/4-1/2
0.492 mi.
2597 ft.

POST ROAD CORRIDOR - WHITE PLAINS - OFF-SITE
77 WEST POST ROAD
WHITE PLAINS, NY 10606

NY BROWNFIELDS

S128906198
N/A

Relative:
Higher

Actual:
223 ft.

BROWNFIELDS:

Name:	POST ROAD CORRIDOR - WHITE PLAINS - OFF-SITE
Address:	77 WEST POST ROAD
City,State,Zip:	WHITE PLAINS, NY 10606
Program:	BCP
Site Code:	544843
Acres:	Not reported
HW Code:	C360129A
SWIS:	6017
Town:	White Plains (c)
Record Added Date:	04/07/2017
Record Updated Date:	03/28/2024
Update By:	AMOMOROG
Site Description:	Site Location: The site is located in the City of White Plains, Westchester County. To the west of the site is Rathbun Avenue and commercial properties, to the north are residential properties, to the east is South Lexington Avenue, and to the south is Maple Avenue and residential properties. Site Features: The site consists of several tax parcels adjacent to the Post Road Corridor BCP site C360129. Several commercial buildings and parking lots make up the site. Current Zoning and Land Use: The site is zoned B-3, which is a general retail district allowing retail, office and service business uses and multi-family dwellings. Surrounding land use is mixed, consisting of residential and commercial properties. Past Use of the Site: Former commercial uses at the Post Road Corridor BCP site included dry cleaners; gas stations with underground storage tanks (USTs); automobile sales and service facilities with USTs, above ground storage tanks (ASTs), hydraulic lifts, and associated parking lots; various commercial businesses and offices; and commercial parking lots. Site Geology and Hydrogeology: The site geology consists of historic fill material, native till, highly weathered bedrock. The depth to bedrock ranges from approximately 17 to 52 feet below grade. Groundwater at the site most likely ranges from 3 to 11 feet below ground surface and flows to the northeast.
Env Problem:	The on-site investigation results shows potential for off-site impact from the previous uses on-site as well as a potential upgradient source of contamination as groundwater impacted with both petroleum related hydrocarbons and chlorinated volatile organic compounds appears to be migrating on-site. Due to high concentrations of tetrachloroethene (PCE) in groundwater, the potential exists for vapor intrusion impacts in off-site buildings. An off-site investigation focused on soil vapor intrusion is on-going at this time.
Health Problem:	Information submitted with the BCP application regarding the conditions at the site are currently under review and will be revised as additional information becomes available.
Dump:	False
Structure:	False
Lagoon:	False
Landfill:	False
Pond:	False
Disp Start:	Not reported
Disp Term:	Not reported

POST ROAD CORRIDOR - WHITE PLAINS - OFF-SITE (Continued) **S128906198**

Lat/Long:	Not reported
Dell:	Not reported
Record Add:	2017-04-11 11:29:00
Record Upd:	2017-04-11 11:29:00
Updated By:	JLVERRIG
Own Op:	Not reported
Sub Type:	Not reported
Owner Name:	Not reported
Owner Company:	Not reported
Owner Address:	Not reported
Owner Addr2:	Not reported
Owner City,St,Zip:	Not reported
Owner Country:	Not reported
HW Code:	Not reported
Waste Type:	Not reported
Waste Quantity:	Not reported
Waste Code:	Not reported
Crossref ID:	1112748
Cross Ref Type Code:	01
Cross Ref Type:	Spill No.
Record Added Date:	2023-08-15 10:58:00
Record Updated:	2023-08-15 10:58:00
Updated By:	JBODEE
Crossref ID:	0901804
Cross Ref Type Code:	01
Cross Ref Type:	Spill No.
Record Added Date:	2023-08-15 10:59:00
Record Updated:	2023-08-15 10:59:00
Updated By:	JBODEE
Crossref ID:	9408341
Cross Ref Type Code:	01
Cross Ref Type:	Spill No.
Record Added Date:	2023-08-15 11:04:00
Record Updated:	2023-08-15 11:04:00
Updated By:	JBODEE
Crossref ID:	0709611
Cross Ref Type Code:	01
Cross Ref Type:	Spill No.
Record Added Date:	2023-08-15 10:59:00
Record Updated:	2023-08-15 10:59:00
Updated By:	JBODEE
Crossref ID:	0901783
Cross Ref Type Code:	01
Cross Ref Type:	Spill No.
Record Added Date:	2023-08-15 10:59:00
Record Updated:	2023-08-15 10:59:00
Updated By:	JBODEE
Crossref ID:	0508992
Cross Ref Type Code:	01
Cross Ref Type:	Spill No.
Record Added Date:	2023-08-15 11:00:00
Record Updated:	2023-08-15 11:00:00
Updated By:	JBODEE
Crossref ID:	0600932
Cross Ref Type Code:	01
Cross Ref Type:	Spill No.
Record Added Date:	2023-08-15 11:00:00

POST ROAD CORRIDOR - WHITE PLAINS - OFF-SITE (Continued) **S128906198**

Record Updated:	2023-08-15 11:00:00
Updated By:	JBODEE
Crossref ID:	2304166
Cross Ref Type Code:	01
Cross Ref Type:	Spill No.
Record Added Date:	2023-08-15 10:50:00
Record Updated:	2023-08-15 10:50:00
Updated By:	JBODEE
Crossref ID:	1007370
Cross Ref Type Code:	01
Cross Ref Type:	Spill No.
Record Added Date:	2023-08-15 10:58:00
Record Updated:	2023-08-15 10:58:00
Updated By:	JBODEE
Crossref ID:	2006472
Cross Ref Type Code:	01
Cross Ref Type:	Spill No.
Record Added Date:	2023-08-15 10:57:00
Record Updated:	2023-08-15 10:57:00
Updated By:	JBODEE
Crossref ID:	2303950
Cross Ref Type Code:	01
Cross Ref Type:	Spill No.
Record Added Date:	2023-08-15 10:57:00
Record Updated:	2023-08-15 10:57:00
Updated By:	JBODEE

BV514 **WHITE PLAINS FD STATION 4** **NY LTANKS** **S103478832**
South **234 SOUTH LEXINGTON AVE** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.495 mi.
2611 ft. **Site 2 of 3 in cluster BV**

Relative: **Higher**

Actual: **231 ft.**

LTANKS:

Name:	WHITE PLAINS FD STATION 4
Address:	234 SOUTH LEXINGTON AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9804511 / 1998-08-12
Facility ID:	9804511
Site ID:	320194
Spill Date:	1998-07-10
Spill Cause:	Tank Failure
Spill Source:	Commercial/Industrial
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1998-07-10
CID:	312
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1998-07-10

WHITE PLAINS FD STATION 4 (Continued) **S103478832**

Spill Record Last Update:	1998-10-02
Spiller Name:	Not reported
Spiller Company:	C/O WHITE PLAINS
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	MARK TSCHANTRE
Spiller Phone:	(914) 328-6549
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	257972
Latitude:	41.0240200
Longitude:	-73.7709567
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY
Remarks:	LEAKING 2000 GAL UST - CALLER HAS ONLY PERFORMED SOIL SAMPLING SO FAR

All Materials:

Site ID:	320194
Operable Unit ID:	1065392
Operable Unit:	01
Material ID:	319224
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

515
WNW
1/4-1/2
0.495 mi.
2615 ft.

SPILL NUMBER 9812431
88-90 CHATTERTON AVE
WHITE PLAINS, NY

NY LTANKS **S104619917**
N/A

Relative:
Higher

Actual:
272 ft.

LTANKS:

Name:	SPILL NUMBER 9812431
Address:	88-90 CHATTERTON AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9812431 / 1999-02-02
Facility ID:	9812431
Site ID:	319434
Spill Date:	1999-01-07
Spill Cause:	Tank Test Failure
Spill Source:	Private Dwelling
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	jbodee
Referred To:	Not reported
Reported to Dept:	1999-01-07
CID:	351
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported

SPILL NUMBER 9812431 (Continued) **S104619917**

Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1999-01-07
Spill Record Last Update:	1999-03-11
Spiller Name:	CAROLE P. VERSACE
Spiller Company:	CAROLE VERSACE
Spiller Address:	88-90 CHATTERTON AV
Spiller County:	001
Spiller Contact:	CAROLE P. VERSACE
Spiller Phone:	(914) 345-9319
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	257354
Latitude:	41.0334999
Longitude:	-73.7814749
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was O'DEE 02/02/99 - PASSED RE-TEST.
Remarks:	SITE IS A 3 FAMILY HOME - CALLER TO RECCOMEND TO UNCOVER ISOLATE & RETEST - POSSIBLE LOOSE PIPE

All TTF:

Facility ID:	9812431
Spill Number:	9812431
Spill Tank Test:	1546727
Site ID:	319434
Tank Number:	Not reported
Tank Size:	1000
Material:	0001
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	.00
Gross Fail:	F
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	319434
Operable Unit ID:	1069690
Operable Unit:	01
Material ID:	556082
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

BX516 **WESTCHESTER SHOPPING CENT** **NY LTANKS** **S100782169**
East **WEST AVE & PAWLING ST** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.495 mi.
2616 ft. **Site 1 of 2 in cluster BX**

Relative: **Lower**
Actual: **165 ft.**

LTANKS:

Name:	WESTCHESTER SHOPPING CENT
Address:	WEST AVE & PAWLING ST
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9310531 / 1995-01-20
Facility ID:	9310531
Site ID:	213450
Spill Date:	1993-09-09
Spill Cause:	Tank Failure
Spill Source:	Commercial/Industrial
Spill Class:	D4
Cleanup Ceased:	1995-01-20
SWIS:	6017
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1993-11-30
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1993-12-28
Spill Record Last Update:	1995-01-20
Spiller Name:	Not reported
Spiller Company:	FASHION MALL PARTNERS
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	176839
Latitude:	Not reported
Longitude:	Not reported
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY
Remarks:	EXCAVATING REMOVING SOIL TANKS ARE REMOVED

All Materials:

Site ID:	213450
Operable Unit ID:	992245
Operable Unit:	01
Material ID:	393136
Material Code:	0066A
Material Name:	unknown petroleum
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	Not reported
Recovered:	.00
Resource Affected:	Soil

WESTCHESTER SHOPPING CENT (Continued) **S100782169**

Oxygenate: Not reported

BX517 **WHITE PLAINS CHRYSLER CAR DEALERSHIP** **NY BROWNFIELDS** **S104501016**
East **70 WESTCHESTER AVENUE** **NY Spills** **N/A**
1/4-1/2 **WHITE PLAINS, NY 10601** **NY PFAS**
0.496 mi.
2621 ft. **Site 2 of 2 in cluster BX**

Relative: **Lower**
Actual: **165 ft.**

BROWNFIELDS:

Name:	WHITE PLAINS CHRYSLER CAR DEALERSHIP
Address:	70 WESTCHESTER AVENUE
City,State,Zip:	WHITE PLAINS, NY 10601
Program:	BCP
Site Code:	613124
Acres:	1.826
HW Code:	C360209
SWIS:	6017
Town:	White Plains (c)
Record Added Date:	11/11/2020
Record Updated Date:	12/26/2023
Update By:	KAMALONE
Site Description:	Location: The White Plains Chrysler Car Dealership site is a 1.826-acre site located at 70 Westchester Avenue, White Plains, New York. The site is in a commercial and residential downtown neighborhood. The site is bounded by Franklin Avenue, a dense residential neighborhood, a school, a ball field, and retail businesses to the north, the White Coach Diner to the west, Westchester Avenue and the Westchester Mall to the south, and a closed car dealership to the east. Site Features: The southeastern portion of the site is currently occupied by a car dealership building which consists of a small show room and car service bays. The northern and western portion of the site consists of an asphalt parking lot for the dealership. There is a small lawn area in the front of the building along Westchester Avenue. The eastern portion of the building, which was constructed in 1925, consists of a single-story and two-story structure with small partial basement under the southeastern corner of the building. The western portion of the building, which was constructed in 1990, consists of a single-story structure with a half basement. Current Zoning and Land Use: The site is currently active and is used as a car dealership. The northern portion of site is located in a Residential Multi-Family District and southern portion is located in an Intermediate Business District zone. Therefore, half the property is zoned residential. Past Use of the Site: The site has been an active car dealership with auto repair since at least 1967. However, the on-site commercial building has been present on the site since 1925, suggesting this was an auto dealership dating back to potentially 1925. Some of the historical owner names suggest a dealership or auto related use has been on the site since at least the early 1940s. Site Geology and Hydrogeology: The site slopes from west to east. Soil consists of gray-brown fine to coarse sand with brick fragments (historic fill) with depth ranging from 0-6 feet to 0-13 feet below ground surface (bgs). The fill is underlain by brown coarse sand with trace silt and gravel to 35 feet bgs. The depth of the bedrock varies from 16 to 50 feet bgs. Groundwater is present at approximately 11 to 21 feet bgs and flows to the east-southeast.
Env Problem:	Nature and Extent of Contamination: Soil and groundwater samples were

WHITE PLAINS CHRYSLER CAR DEALERSHIP (Continued) **S104501016**

analyzed for volatile organic compounds (VOCs), semi-volatile organic compounds (SVOCs), metals, polychlorinated biphenyls (PCBs), per- and polyfluoroalkyl substances (PFAS), and pesticides. Soil vapor, indoor air and ambient air samples were analyzed for VOCs. Based upon investigations conducted to date, the primary contaminants of concern for site include SVOCs and metals. Soil: A total of 95 soil samples were collected from 20 soil borings installed at a maximum depth of 20 feet bgs during the remedial investigation. Several SVOCs, primarily polycyclic aromatic hydrocarbons (PAHs), were detected sitewide. Most of the PAH contamination is present in the top 6 feet of subsurface soil. Specifically, indeno(1,2,3-cd)pyrene was detected in 12 samples out of 95 above the unrestricted soil cleanup objective (USCO) of 1 ppm (parts per million) with the maximum concentration of 220 ppm. Benzo(b)fluoranthene was detected in 11 samples out of 95 above the USCO of 1 ppm with the maximum concentration of 390 ppm. Benzo(a)anthracene, benzo(a)pyrene and chrysene were detected in 10 samples out of 95 above their respective USCO of 1 ppm with the maximum concentration of 350 ppm, 330 ppm and 320 ppm respectively. Lead exceeded the USCO of 63 ppm in 17 out of 95 samples, with a maximum concentration of 524 ppm. Chromium (maximum 65.9 ppm, USCO of 30 ppm), copper (maximum 179 ppm, USCO of 50 ppm), mercury (maximum 0.394 ppm, USCO of 0.18 ppm), nickel (maximum 61.9 ppm, USCO of 30 ppm) and zinc (maximum 360 ppm, USCO 0f 109 ppm) were also detected in a small number of samples. Perfluorooctane sulfonic acid (PFOS) was detected above its USCO of 0.88 parts per billion (ppb) in two samples with the maximum concentration of 1.39 ppb. Data does not indicate any off-site impacts in soil related to this site.
Groundwater: A total of 20 groundwater samples were collected from 14 monitoring wells during the remedial investigation. The depth of the monitoring wells varied between 19 feet to 24 feet. Perfluorooctanoic acid (PFOA) was detected above the ambient groundwater quality guidance value of 2.7 parts per trillion (ppt) with a maximum concentration of 36.9 ppt. PFOS was detected at a maximum of 117 ppt compared to the ambient groundwater quality guidance value of 6.7 ppt. The maximum concentration of both PFOA and PFOS was detected in the southeastern corner of the site, underneath the building. PFOA and PFOS were also detected in similar concentrations in upgradient wells, thus suggesting it is likely from an off-site source. Benzo(a)anthracene (0.11 ppb maximum), benzo(b)fluoranthene (0.2 ppb maximum), and chrysene (0.12 ppb maximum), were detected above their respective ground water standard of 0.002 ppb in a small fraction of samples. Lead (259 ppb, groundwater standard of 25 ppb), chromium (283 ppb, groundwater standard of 50 ppb), and nickel (228 ppb, groundwater standard of 100 ppb) were detected in the well located upgradient along the western site boundary. Volatile organic compounds (VOCs) were not detected in any groundwater samples. Data does not indicate any off-site migration of contaminated groundwater.
Soil Vapor: A wide range of VOCs were detected in soil vapor samples collected across the site. The chlorinated VOCs carbon tetrachloride (34.9 micrograms per cubic meter [g/m3]), cis 1,2-DCE (85.2 g/m3), TCE (216 g/m3), and PCE (834 g/m3) were detected in the sample collected beneath the slab from the northeastern portion of the on-site building. Cis 1,2-DCE, TCE and PCE were not detected in the indoor air sample. Carbon tetrachloride was detected at 0.41 g/m3 in indoor air. As per the NYSDOH Guidance for Evaluating Soil Vapor Intrusion in the State of New York, mitigation of the human health exposure resulting from the soil vapor intrusion for cis 1,2-DCE and

WHITE PLAINS CHRYSLER CAR DEALERSHIP (Continued) **S104501016**

	TCE is required. The data does not indicate any off-site impacts in soil vapor related to this site.
Health Problem:	Direct contact with contaminants in soil is unlikely because the majority of the site is covered with a building and asphalt pavement. Contaminated groundwater at the site is not used for drinking or other purposes, and the site is served by a public water supply that obtains water from a different source not affected by this contamination. Volatile organic compounds in the soil vapor (air spaces within the soil) can move into overlying buildings and affect the indoor air quality. This process, which is similar to the movement of radon gas from the subsurface into the indoor air of buildings, is referred to as soil vapor intrusion. The potential exists for people to inhale site contaminants in indoor air due to soil vapor intrusion for the current building and any future on-site development. Environmental sampling indicates that soil vapor intrusion is not a concern for off-site structures.
Dump:	False
Structure:	False
Lagoon:	False
Landfill:	False
Pond:	False
Disp Start:	Not reported
Disp Term:	Not reported
Lat/Long:	Not reported
Dell:	Not reported
Record Add:	2021-02-12 08:48:00
Record Upd:	2023-04-28 12:34:00
Updated By:	PBAMIN
Own Op:	1
Sub Type:	E
Owner Name:	n/a
Owner Company:	70 Westchester LLC
Owner Address:	70 Westchester Avenue
Owner Addr2:	Not reported
Owner City,St,Zip:	White Plains, NY 10601
Owner Country:	United States of America
Own Op:	6
Sub Type:	P03
Owner Name:	Martin Berger
Owner Company:	Saber-North White Plains, LLC
Owner Address:	2453 Route 6
Owner Addr2:	Not reported
Owner City,St,Zip:	Brewster, NY 10509
Owner Country:	United States of America
Own Op:	Document Repository
Sub Type:	NNN
Owner Name:	Brian Kenney
Owner Company:	White Plains Public Library
Owner Address:	100 Martine Avenue
Owner Addr2:	Not reported
Owner City,St,Zip:	White Plains, NY 10601
Owner Country:	United States of America
Own Op:	4
Sub Type:	E
Owner Name:	Agostino DiFeo
Owner Company:	White Plains Chrysler Jeep Dodge
Owner Address:	70 Westchester Avenue

WHITE PLAINS CHRYSLER CAR DEALERSHIP (Continued) **S104501016**

Owner Addr2:	Not reported
Owner City,St,Zip:	White Plains, NY 10601
Owner Country:	United States of America
Own Op:	Document Repository
Sub Type:	NNN
Owner Name:	Brian Kenney
Owner Company:	White Plains Public Library
Owner Address:	100 Martine Avenue
Owner Addr2:	Not reported
Owner City,St,Zip:	White Plains, NY 10601
Owner Country:	United States of America
HW Code:	C360209
Waste Type:	indeno(1,2,3-cd)pyrene
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360209
Waste Type:	tetrachloroethene (PCE)
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360209
Waste Type:	chrysene
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360209
Waste Type:	benzo(a)anthracene
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360209
Waste Type:	nickel
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360209
Waste Type:	trichloroethene (TCE)
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360209
Waste Type:	chromium
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360209
Waste Type:	copper
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360209
Waste Type:	benzo(a)pyrene
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360209
Waste Type:	mercury
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360209
Waste Type:	zinc
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360209
Waste Type:	benzo(b)fluoranthene

WHITE PLAINS CHRYSLER CAR DEALERSHIP (Continued) **S104501016**

Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360209
Waste Type:	lead
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360209
Waste Type:	perfluorooctanoic acid
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
HW Code:	C360209
Waste Type:	dichloroethene (cis-1,2-)
Waste Quantity:	UNKNOWN
Waste Code:	Not reported
Crossref ID:	9407257
Cross Ref Type Code:	01
Cross Ref Type:	Spill No.
Record Added Date:	2020-11-24 11:44:00
Record Updated:	2020-11-24 11:44:00
Updated By:	KAJUNKIN
Crossref ID:	8808621
Cross Ref Type Code:	01
Cross Ref Type:	Spill No.
Record Added Date:	2020-11-24 11:42:00
Record Updated:	2020-11-24 11:42:00
Updated By:	KAJUNKIN
Crossref ID:	9511683
Cross Ref Type Code:	01
Cross Ref Type:	Spill No.
Record Added Date:	2020-11-24 11:41:00
Record Updated:	2020-11-24 11:41:00
Updated By:	KAJUNKIN
Crossref ID:	0008186
Cross Ref Type Code:	01
Cross Ref Type:	Spill No.
Record Added Date:	2020-11-24 11:41:00
Record Updated:	2020-11-24 11:41:00
Updated By:	KAJUNKIN

SPILLS:

Name:	WESTCHESTER CHRYSLER
Address:	70 WESTCHESTER AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9511683 / 2002-02-01
Facility ID:	9511683
Facility Type:	ER
DER Facility ID:	64767
Site ID:	68317
DEC Region:	3
Spill Cause:	Deliberate
Spill Class:	B3
SWIS:	6017
Spill Date:	1995-01-01
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1995-12-15
CID:	322

WHITE PLAINS CHRYSLER CAR DEALERSHIP (Continued) **S104501016**

Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Citizen
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	1995-12-15
Spill Record Last Update:	2020-11-24
Spiller Name:	Not reported
Spiller Company:	WESTCHESTER CHRYSLER
Spiller Address:	70 WESCHESTER AVE
Spiller Company:	001
Contact Name:	Not reported
Latitude:	41.0329716
Longitude:	-73.7596986
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY 09/20/2001 LETTER SENT TO DAIMLER CHRYSLER BY T. GHIOSAY; PHASE II ENV. SITE ASSESSMENT BY NORTH CONSULTANTS HAS BEEN REVIEWED. DEC REQUIRING REMOVAL OF ALL LIFTS AND DISPOSAL OF ALL CONTAMINATED SOILS AT THIS SITE. 02/01/2002 LETTER SENT TO DAIMLER CHRYSLER BY T. GHIOSAY; BASED ON SUPPLEMENTAL SOIL SAMPLING ANALYTICAL REPORT SUBMITTED FOR THIS SITE, NO FURTHER ACTION IS REQUIRED AT THIS TIME. SPILL REPORT LISTED AS CLOSED.
Remarks:	CALLER RECIEVED INFO FROM AN EMPLOYEE THAT THE DEALERSHIP INSTALLED NEW CAR LIFTS - THE OLD LIFTS WERE JUST CEMENTED OVER - CALLER DOES NOT BELIEVE THAT THE FLUIDS WERE DRAINED FROM THE OLD LIFTS

All Materials:

Site ID:	68317
Operable Unit ID:	1025894
Operable Unit:	01
Material ID:	359012
Material Code:	0010
Material Name:	hydraulic oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	WESTCHESTER CHRY PLYM
Address:	70 WESTCHESTER AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0008186 / 2001-09-20
Facility ID:	0008186
Facility Type:	ER
DER Facility ID:	64767
Site ID:	67839
DEC Region:	3

WHITE PLAINS CHRYSLER CAR DEALERSHIP (Continued) **S104501016**

Spill Cause:	Unknown
Spill Class:	C4
SWIS:	6017
Spill Date:	2000-10-12
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	2000-10-12
CID:	257
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Other
Cleanup Ceased:	Not reported
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2000-10-12
Spill Record Last Update:	2020-11-24
Spiller Name:	THOMAS NOLES
Spiller Company:	WESTCHESTER CHRY PLYM
Spiller Address:	70 WESTCHESTER AVE
Spiller Company:	001
Contact Name:	THOMAS NOLES
Latitude:	41.0325565
Longitude:	-73.7597467
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY 09/20/2001 LETTER SENT TO DAIMLER CHRYSLER BY T. GHIOSAY; BASED ON EARTH TECH REPORT, NO FURTHER ACTION REQUIRED AT THIS TIME.
Remarks:	tanks were pulled in 1989 and test were taken just now and found contaminated soil from the area were the tanks were - dec did over see the tank removal in 1989

All Materials:

Site ID:	67839
Operable Unit ID:	830581
Operable Unit:	01
Material ID:	545705
Material Code:	0009
Material Name:	gasoline
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	WHITE PLAINS CRYTSLER PLM
Address:	70 WESTCHESTER AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	8808621 / 1990-02-01
Facility ID:	8808621
Facility Type:	ER
DER Facility ID:	64767

WHITE PLAINS CHRYSLER CAR DEALERSHIP (Continued) **S104501016**

Site ID:	194239
DEC Region:	3
Spill Cause:	Unknown
Spill Class:	Not reported
SWIS:	6017
Spill Date:	1989-01-26
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1989-02-01
CID:	Not reported
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Other
Cleanup Ceased:	1990-02-01
Cleanup Meets Std:	True
Last Inspection:	1990-01-15
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	1989-02-03
Spill Record Last Update:	1990-02-01
Spiller Name:	Not reported
Spiller Company:	WHITE PLAINS CRYSTLER PLM
Spiller Address:	70 WESTCHESTER AVE.
Spiller Company:	001
Contact Name:	Not reported
Latitude:	41.0325565
Longitude:	-73.7597467
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was T. GHIOSAY 02/01/90: PROPERTY OWNER HIRED OBRIEN AND GERE TO OVERSEE TANK REMOVAL. MANY MORE TANKS REMOVED THAN ORIGINALLY EXPECTED. SOIL STOCKPILED AND REMOVED. 11/29/95: This is additional information about material spilled from the translation of the old spill file: FUEL OIL TOO.
Remarks:	2 2K TANKS REMOVED. CONTAMINED SOIL FOUND AND TO BE REMOVED. STOCK PILED AND SAMPLED.

All Materials:

Site ID:	194239
Operable Unit ID:	924519
Operable Unit:	01
Material ID:	554720
Material Code:	0009
Material Name:	gasoline
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

PFAS 3:

Name:	WHITE PLAINS CHRYSLER CAR DEALERSHIP
Address:	70 WESTCHESTER AVENUE

WHITE PLAINS CHRYSLER CAR DEALERSHIP (Continued) **S104501016**

City,State,Zip:	WHITE PLAINS, NY 10601
Site Code:	613124
HW Code:	C360209
Program:	BCP
Class Code:	A
Region:	3
Acres:	1.826
Date Record Added:	11/11/2020
Date Record Updated:	12/26/2023
Water Quantity:	UNKNOWN
Updated By:	KAMALONE
Site Description:	Location: The White Plains Chrysler Car Dealership site is a 1.826-acre site located at 70 Westchester Avenue, White Plains, New York. The site is in a commercial and residential downtown neighborhood. The site is bounded by Franklin Avenue, a dense residential neighborhood, a school, a ball field, and retail businesses to the north, the White Coach Diner to the west, Westchester Avenue and the Westchester Mall to the south, and a closed car dealership to the east. Site Features: The southeastern portion of the site is currently occupied by a car dealership building which consists of a small show room and car service bays. The northern and western portion of the site consists of an asphalt parking lot for the dealership. There is a small lawn area in the front of the building along Westchester Avenue. The eastern portion of the building, which was constructed in 1925, consists of a single-story and two-story structure with small partial basement under the southeastern corner of the building. The western portion of the building, which was constructed in 1990, consists of a single-story structure with a half basement. Current Zoning and Land Use: The site is currently active and is used as a car dealership. The northern portion of site is located in a Residential Multi-Family District and southern portion is located in an Intermediate Business District zone. Therefore, half the property is zoned residential. Past Use of the Site: The site has been an active car dealership with auto repair since at least 1967. However, the on-site commercial building has been present on the site since 1925, suggesting this was an auto dealership dating back to potentially 1925. Some of the historical owner names suggest a dealership or auto related use has been on the site since at least the early 1940s. Site Geology and Hydrogeology: The site slopes from west to east. Soil consists of gray-brown fine to coarse sand with brick fragments (historic fill) with depth ranging from 0-6 feet to 0-13 feet below ground surface (bgs). The fill is underlain by brown coarse sand with trace silt and gravel to 35 feet bgs. The depth of the bedrock varies from 16 to 50 feet bgs. Groundwater is present at approximately 11 to 21 feet bgs and flows to the east-southeast.
Summary:	Direct contact with contaminants in soil is unlikely because the majority of the site is covered with a building and asphalt pavement. Contaminated groundwater at the site is not used for drinking or other purposes, and the site is served by a public water supply that obtains water from a different source not affected by this contamination. Volatile organic compounds in the soil vapor (air spaces within the soil) can move into overlying buildings and affect the indoor air quality. This process, which is similar to the movement of radon gas from the subsurface into the indoor air of buildings, is referred to as soil vapor intrusion. The potential exists for people to inhale

WHITE PLAINS CHRYSLER CAR DEALERSHIP (Continued) **S104501016**

site contaminants in indoor air due to soil vapor intrusion for the current building and any future on-site development. Environmental sampling indicates that soil vapor intrusion is not a concern for off-site structures.

Summary:

Nature and Extent of Contamination: Soil and groundwater samples were analyzed for volatile organic compounds (VOCs), semi-volatile organic compounds (SVOCs), metals, polychlorinated biphenyls (PCBs), per- and polyfluoroalkyl substances (PFAS), and pesticides. Soil vapor, indoor air and ambient air samples were analyzed for VOCs. Based upon investigations conducted to date, the primary contaminants of concern for site include SVOCs and metals. Soil: A total of 95 soil samples were collected from 20 soil borings installed at a maximum depth of 20 feet bgs during the remedial investigation. Several SVOCs, primarily polycyclic aromatic hydrocarbons (PAHs), were detected sitewide. Most of the PAH contamination is present in the top 6 feet of subsurface soil. Specifically, indeno(1,2,3-cd)pyrene was detected in 12 samples out of 95 above the unrestricted soil cleanup objective (USCO) of 1 ppm (parts per million) with the maximum concentration of 220 ppm. Benzo(b)fluoranthene was detected in 11 samples out of 95 above the USCO of 1 ppm with the maximum concentration of 390 ppm. Benzo(a)anthracene, benzo(a)pyrene and chrysene were detected in 10 samples out of 95 above their respective USCO of 1 ppm with the maximum concentration of 350 ppm, 330 ppm and 320 ppm respectively. Lead exceeded the USCO of 63 ppm in 17 out of 95 samples, with a maximum concentration of 524 ppm. Chromium (maximum 65.9 ppm, USCO of 30 ppm), copper (maximum 179 ppm, USCO of 50 ppm), mercury (maximum 0.394 ppm, USCO of 0.18 ppm), nickel (maximum 61.9 ppm, USCO of 30 ppm) and zinc (maximum 360 ppm, USCO 0f 109 ppm) were also detected in a small number of samples. Perfluorooctane sulfonic acid (PFOS) was detected above its USCO of 0.88 parts per billion (ppb) in two samples with the maximum concentration of 1.39 ppb. Data does not indicate any off-site impacts in soil related to this site.
Groundwater: A total of 20 groundwater samples were collected from 14 monitoring wells during the remedial investigation. The depth of the monitoring wells varied between 19 feet to 24 feet. Perfluorooctanoic acid (PFOA) was detected above the ambient groundwater quality guidance value of 2.7 parts per trillion (ppt) with a maximum concentration of 36.9 ppt. PFOS was detected at a maximum of 117 ppt compared to the ambient groundwater quality guidance value of 6.7 ppt. The maximum concentration of both PFOA and PFOS was detected in the southeastern corner of the site, underneath the building. PFOA and PFOS were also detected in similar concentrations in upgradient wells, thus suggesting it is likely from an off-site source. Benzo(a)anthracene (0.11 ppb maximum), benzo(b)fluoranthene (0.2 ppb maximum), and chrysene (0.12 ppb maximum), were detected above their respective ground water standard of 0.002 ppb in a small fraction of samples. Lead (259 ppb, groundwater standard of 25 ppb), chromium (283 ppb, groundwater standard of 50 ppb), and nickel (228 ppb, groundwater standard of 100 ppb) were detected in the well located upgradient along the western site boundary. Volatile organic compounds (VOCs) were not detected in any groundwater samples. Data does not indicate any off-site migration of contaminated groundwater.
Soil Vapor: A wide range of VOCs were detected in soil vapor samples collected across the site. The chlorinated VOCs carbon tetrachloride (34.9 micrograms per cubic meter [g/m3]), cis 1,2-DCE (85.2 g/m3), TCE (216 g/m3), and PCE (834 g/m3) were detected in the sample

WHITE PLAINS CHRYSLER CAR DEALERSHIP (Continued) **S104501016**

collected beneath the slab from the northeastern portion of the on-site building. Cis 1,2-DCE, TCE and PCE were not detected in the indoor air sample. Carbon tetrachloride was detected at 0.41 g/m3 in indoor air. As per the NYSDOH Guidance for Evaluating Soil Vapor Intrusion in the State of New York, mitigation of the human health exposure resulting from the soil vapor intrusion for cis 1,2-DCE and TCE is required. The data does not indicate any off-site impacts in soil vapor related to this site.

Water Type: perfluorooctanoic acid

BV518 **GREAT GRANT MANOR PROP** **NY LTANKS** **S100879284**
South **235 SOUTH LEXINGTON AVE** **N/A**
1/4-1/2 **WHITE PLAINS, NY**
0.500 mi.
2640 ft. **Site 3 of 3 in cluster BV**

Relative: **Higher**
Actual: **233 ft.**

LTANKS:

Name:	GREAT GRANT MANOR PROP
Address:	235 SOUTH LEXINGTON AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0204243 / 2002-11-06
Facility ID:	0204243
Site ID:	147077
Spill Date:	2002-07-23
Spill Cause:	Tank Test Failure
Spill Source:	Commercial/Industrial
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	WCHD
Referred To:	Westchester Cnty Health Dept
Reported to Dept:	2002-07-23
CID:	281
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2002-07-23
Spill Record Last Update:	2003-10-20
Spiller Name:	Not reported
Spiller Company:	SAME
Spiller Address:	Not reported
Spiller County:	999
Spiller Contact:	ED OR BETH DEALAUREANTS
Spiller Phone:	(914) 946-1321
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	125226
Latitude:	41.0240455
Longitude:	-73.7708135
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was WCHD - SCHNEIDER 11/06/02 TANK PASSED A RETEST AS PER WAYNE SCHNEIDER OF WCHD.
Remarks:	TANK TEST FAILURE AT ABOVE LOCATION PROPERTY OWNER HAS BEEN ADVISED

GREAT GRANT MANOR PROP (Continued) **S100879284**

OF PROBLEM. RECOMMENDING UNCOVERED,REPAIR AND RETEST.

All TTF:

Facility ID:	0204243
Spill Number:	0204243
Spill Tank Test:	1527308
Site ID:	147077
Tank Number:	1
Tank Size:	20000
Material:	0003
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	.00
Gross Fail:	F
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	147077
Operable Unit ID:	855411
Operable Unit:	01
Material ID:	518501
Material Code:	0003A
Material Name:	#6 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	SPILL NUMBER 0304500
Address:	235 SOUTH LEXINGTON AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0304500 / 2003-10-31
Facility ID:	0304500
Site ID:	147078
Spill Date:	2003-07-29
Spill Cause:	Tank Failure
Spill Source:	Private Dwelling
Spill Class:	C4
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	WCHD
Referred To:	Westchester Cnty Health Dept
Reported to Dept:	2003-07-29
CID:	199
Water Affected:	Not reported
Spill Notifier:	Other
Last Inspection:	Not reported
Recommended Penalty:	False

GREAT GRANT MANOR PROP (Continued) **S100879284**

Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	2003-07-29
Spill Record Last Update:	2003-12-12
Spiller Name:	Not reported
Spiller Company:	SOUTH LEX PARTNERS LLC C/O DELAURNETIS MANAGEMEN
Spiller Address:	235 S LEXINGTON
Spiller County:	001
Spiller Contact:	ED OR BETH DEALAUREANTS
Spiller Phone:	(914) 946-1321
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	125226
Latitude:	41.0240455
Longitude:	-73.7708135
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was WCHD-LALAK 10/15/03 Closure letter sent to DeLaurentis Mgmt. Co from C Lalak from the WCHD note: Any health related questions regarding soil contaminants should be referred to the Health Department. TG
Remarks:	Not reported

All Materials:

Site ID:	147078
Operable Unit ID:	871313
Operable Unit:	01
Material ID:	505359
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

Name:	235 SOUTH LEXINGTON AVE
Address:	235 SOUTH LEXINGTON AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9313731 / 1995-01-05
Facility ID:	9313731
Site ID:	147079
Spill Date:	1994-02-22
Spill Cause:	Tank Failure
Spill Source:	Commercial/Industrial
Spill Class:	C3
Cleanup Ceased:	1995-01-05
SWIS:	6017
Investigator:	MONACO
Referred To:	Not reported
Reported to Dept:	1994-02-22
CID:	Not reported
Water Affected:	Not reported
Spill Notifier:	Fire Department
Last Inspection:	1994-09-27
Recommended Penalty:	False

GREAT GRANT MANOR PROP (Continued) **S100879284**

Meets Standard:	False
UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1994-03-08
Spill Record Last Update:	2003-10-20
Spiller Name:	Not reported
Spiller Company:	PRESIDENCIAL MANAGEMENT
Spiller Address:	Not reported
Spiller County:	001
Spiller Contact:	Not reported
Spiller Phone:	Not reported
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	125226
Latitude:	41.0240455
Longitude:	-73.7708135
DEC Memo:	Not reported
Remarks:	20,000 GAL IN GROUND TANK SPILL THROUGH WALL INTO SUMP PUMP INTO WASTE LINES LT. DAMAN (FD) TOLD SPT. TO START CLEAN UP FAXED TO TODD EASTMAN TANK PUMPING OUT TANK CLEAN UP IN PROGRESS

All Materials:

Site ID:	147079
Operable Unit ID:	992182
Operable Unit:	01
Material ID:	389103
Material Code:	0001A
Material Name:	#2 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	L
Recovered:	.00
Resource Affected:	Groundwater
Oxygenate:	Not reported

Name:	GRANT MANOR PROPERTIES
Address:	235 SOUTH LEXINGTON AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	9706472 / 1998-02-27
Facility ID:	9706472
Site ID:	147080
Spill Date:	1997-08-28
Spill Cause:	Tank Test Failure
Spill Source:	Institutional, Educational, Gov., Other
Spill Class:	C3
Cleanup Ceased:	Not reported
SWIS:	6017
Investigator:	tdghiosa
Referred To:	Not reported
Reported to Dept:	1997-08-28
CID:	323
Water Affected:	Not reported
Spill Notifier:	Tank Tester
Last Inspection:	Not reported
Recommended Penalty:	False
Meets Standard:	True

GREAT GRANT MANOR PROP (Continued) **S100879284**

UST Involvement:	False
Remediation Phase:	0
Date Entered In Computer:	1997-08-28
Spill Record Last Update:	2003-10-20
Spiller Name:	LESTER CHAYET
Spiller Company:	GRANT MANOR PROPERTIES
Spiller Address:	235 SOUTH LEXINGTON AV
Spiller County:	001
Spiller Contact:	LESTER CHAYET
Spiller Phone:	(718) 649-9400
Spiller Extention:	Not reported
DEC Region:	3
DER Facility ID:	125226
Latitude:	41.0240455
Longitude:	-73.7708135
DEC Memo:	Prior to Sept, 2004 data translation this spill Lead_DEC Field was GHIOSAY 02/27/98 RETEST AFTER REPAIRS; ALL OK;
Remarks:	UNABLE TO OBTAIN A VACUUM. WILL REPAIR MANWAY SEALS AND RETEST.

All TTF:

Facility ID:	9706472
Spill Number:	9706472
Spill Tank Test:	1545287
Site ID:	147080
Tank Number:	1
Tank Size:	20000
Material:	0003
EPA UST:	Not reported
UST:	Not reported
Cause:	Not reported
Source:	Not reported
Test Method:	03
Test Method 2:	Horner EZ Check I or II
Leak Rate:	.00
Gross Fail:	Not reported
Modified By:	Spills
Last Modified Date:	Not reported

All Materials:

Site ID:	147080
Operable Unit ID:	1049837
Operable Unit:	01
Material ID:	332052
Material Code:	0003A
Material Name:	#6 fuel oil
Case No.:	Not reported
Material FA:	Petroleum
Quantity:	.00
Units:	G
Recovered:	.00
Resource Affected:	Soil
Oxygenate:	Not reported

519 SE 1/2-1 0.600 mi. 3169 ft.

MAMARONECK AVENUE DRY CLEANERS
359-369 MAMARONECK AVENUE
WHITE PLAINS, NY 10605

NY SHWS **S106970795**
NY Spills **N/A**

Relative: Higher

Actual: 235 ft.

SHWS:

Name:	MAMARONECK AVENUE DRY CLEANERS
Address:	359-369 MAMARONECK AVENUE
City,State,Zip:	WHITE PLAINS, NY 10605
Program:	HW
Site Code:	387008
Classification:	N
Region:	3
Acres:	0.250
HW Code:	360102
Record Add:	09/10/2007
Record Upd:	08/28/2012
Updated By:	RXKEATIN
Site Description:	Location Description: The site is located at 359-369 Mamaroneck Avenue in a mixed use commercial and residential area in the southern part of the City of White Plains, Westchester County NY. Site Features: The site is on approximately 0.25 acres of land which is flat and contains a 6,763 square foot building with a full basement. Current Use: The building contains a drycleaner, a nail salon, an insurance agency, and two restaurants. The remainder of the site consists of a paved parking lot. Surrounding Use: The site is surrounded with businesses to the north and south of the site and residences to the east and west. Immediately to the east of the site is a municipal parking lot. Historical Sources of Contamination: Dry cleaner operated at this location is a potential source of PCE contamination. Site Hydrology: Groundwater flows though sand at only several feet below ground surface.
Env Problem:	Based upon investigations to date, the primary contaminants of concern at the site included tetrachloroetylene (PCE) and its associated breakdown products. After a thorough Site Characterization, as described in a final report dated July 2012, it was determined that this site did not qualify for the registry.
Health Problem:	Not reported
Dump:	Not reported
Structure:	Not reported
Lagoon:	Not reported
Landfill:	Not reported
Pond:	Not reported
Disp Start:	Not reported
Disp Term:	Not reported
Lat/Long:	Not reported
Dell:	Not reported
Record Add:	Not reported
Record Upd:	Not reported
Updated By:	Not reported
Own Op:	Not reported
Sub Type:	Not reported
Owner Name:	Not reported
Owner Company:	Not reported
Owner Address:	Not reported
Owner Addr2:	Not reported
Owner City,St,Zip:	Not reported
Owner Country:	Not reported

MAMARONECK AVENUE DRY CLEANERS (Continued) **S106970795**

HW Code:	Not reported
Waste Type:	Not reported
Waste Quantity:	Not reported
Waste Code:	Not reported
Crossref ID:	Not reported
Cross Ref Type Code:	Not reported
Cross Ref Type:	Not reported
Record Added Date:	Not reported
Record Updated:	Not reported
Updated By:	Not reported

SPILLS:

Name:	BUSINESS
Address:	359-369 MAMARONECK AVE
City,State,Zip:	WHITE PLAINS, NY
Spill Number/Closed Date:	0505152 / 2005-10-04
Facility ID:	0505152
Facility Type:	ER
DER Facility ID:	296563
Site ID:	350119
DEC Region:	3
Spill Cause:	Other
Spill Class:	B3
SWIS:	6017
Spill Date:	2005-07-28
Investigator:	TDGHIOSA
Referred To:	DIV OF HAZWASTE
Reported to Dept:	2005-07-28
CID:	444
Water Affected:	Not reported
Spill Source:	Commercial/Industrial
Spill Notifier:	Other
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2005-07-28
Spill Record Last Update:	2006-09-12
Spiller Name:	ERIC HARVEY
Spiller Company:	BUSINESS
Spiller Address:	359-369 MARNAMEK AVE
Spiller Company:	001
Contact Name:	ERIC HARVEY
Latitude:	41.0242670
Longitude:	-73.7630620
DEC Memo:	08/23/05 Groundwater & Environmental Services, Inc. submitted a subsurface investigation report that documented the presence of chlorinated solvents at a dry cleaner. GES report forwarded to Paul John for a referral to Haz Waste Remediation. NFA by Spills. TG 09/01/06 Quarterly monitoring report for July to September 2006 submitted by GES. Sent to Paul John to forward to Haz Remediation. TG
Remarks:	FOUND CONTAMINATION IN SOIL WHILE DOING SOIL BORINGS:

Count: 5 records. ORPHAN SUMMARY

City	EDR ID	Site Name	Site Address	Zip	Database(s)
HARRISON	S108925392	FORMER DPW STAGING AREA	OLD LAKE STREET	10604	NY VCP
HARRISON	S108925402	FORMER HANGAR B SEPTIC FIELD	WESTCHESTER CO. AIRPORT (OLD K	10604	NY VCP
SCARSDALE	S118263554	FORECLOSED - TTF	949 POST RD		NY LTANKS
WHITE PLAINS	S126023349	MICA PRODUCTS LANDFILL	2238 NY-22		NY SWF/LF, NY PFAS
WHITE PLAINS	S128660468	WHITE PLAINS FIRE DEPARTMENT DRILL	OLD ORCHARD STREET	10603	NY SHWS, NY PFAS

GOVERNMENT RECORDS SEARCHED / DATA CURRENCY TRACKING

To maintain currency of the following federal and state databases, EDR contacts the appropriate governmental agency on a monthly or quarterly basis, as required.

Number of Days to Update: Provides confirmation that EDR is reporting records that have been updated within 90 days from the date the government agency made the information available to the public.

STANDARD ENVIRONMENTAL RECORDS

Lists of Federal NPL (Superfund) sites

NPL: National Priority List

National Priorities List (Superfund). The NPL is a subset of CERCLIS and identifies over 1,200 sites for priority cleanup under the Superfund Program. NPL sites may encompass relatively large areas. As such, EDR provides polygon coverage for over 1,000 NPL site boundaries produced by EPA's Environmental Photographic Interpretation Center (EPIC) and regional EPA offices.

Date of Government Version: 12/19/2024
Date Data Arrived at EDR: 01/02/2025
Date Made Active in Reports: 01/21/2025
Number of Days to Update: 19

Source: EPA
Telephone: N/A
Last EDR Contact: 02/03/2025
Next Scheduled EDR Contact: 04/07/2025
Data Release Frequency: Quarterly

NPL Site Boundaries

Sources:

EPA's Environmental Photographic Interpretation Center (EPIC)
Telephone: 202-564-7333

EPA Region 1
Telephone 617-918-1143

EPA Region 3
Telephone 215-814-5418

EPA Region 4
Telephone 404-562-8033

EPA Region 5
Telephone 312-886-6686

EPA Region 10
Telephone 206-553-8665

EPA Region 6
Telephone: 214-655-6659

EPA Region 7
Telephone: 913-551-7247

EPA Region 8
Telephone: 303-312-6774

EPA Region 9
Telephone: 415-947-4246

Proposed NPL: Proposed National Priority List Sites

A site that has been proposed for listing on the National Priorities List through the issuance of a proposed rule in the Federal Register. EPA then accepts public comments on the site, responds to the comments, and places on the NPL those sites that continue to meet the requirements for listing.

Date of Government Version: 12/19/2024
Date Data Arrived at EDR: 01/02/2025
Date Made Active in Reports: 01/21/2025
Number of Days to Update: 19

Source: EPA
Telephone: N/A
Last EDR Contact: 02/03/2025
Next Scheduled EDR Contact: 04/07/2025
Data Release Frequency: Quarterly

NPL LIENS: Federal Superfund Liens

Federal Superfund Liens. Under the authority granted the USEPA by CERCLA of 1980, the USEPA has the authority to file liens against real property in order to recover remedial action expenditures or when the property owner received notification of potential liability. USEPA compiles a listing of filed notices of Superfund Liens.

Date of Government Version: 10/15/1991
Date Data Arrived at EDR: 02/02/1994
Date Made Active in Reports: 03/30/1994
Number of Days to Update: 56

Source: EPA
Telephone: 202-564-4267
Last EDR Contact: 08/15/2011
Next Scheduled EDR Contact: 11/28/2011
Data Release Frequency: No Update Planned

Lists of Federal Delisted NPL sites

Delisted NPL: National Priority List Deletions

The National Oil and Hazardous Substances Pollution Contingency Plan (NCP) establishes the criteria that the EPA uses to delete sites from the NPL. In accordance with 40 CFR 300.425.(e), sites may be deleted from the NPL where no further response is appropriate.

Date of Government Version: 12/19/2024
Date Data Arrived at EDR: 01/02/2025
Date Made Active in Reports: 01/21/2025
Number of Days to Update: 19

Source: EPA
Telephone: N/A
Last EDR Contact: 02/04/2025
Next Scheduled EDR Contact: 04/07/2025
Data Release Frequency: Quarterly

Lists of Federal sites subject to CERCLA removals and CERCLA orders

FEDERAL FACILITY: Federal Facility Site Information listing

A listing of National Priority List (NPL) and Base Realignment and Closure (BRAC) sites found in the Comprehensive Environmental Response, Compensation and Liability Information System (CERCLIS) Database where EPA Federal Facilities Restoration and Reuse Office is involved in cleanup activities.

Date of Government Version: 11/20/2024
Date Data Arrived at EDR: 12/18/2024
Date Made Active in Reports: 12/20/2024
Number of Days to Update: 2

Source: Environmental Protection Agency
Telephone: 703-603-8704
Last EDR Contact: 12/18/2024
Next Scheduled EDR Contact: 04/07/2025
Data Release Frequency: Varies

SEMS: Superfund Enterprise Management System

SEMS (Superfund Enterprise Management System) tracks hazardous waste sites, potentially hazardous waste sites, and remedial activities performed in support of EPA's Superfund Program across the United States. The list was formerly know as CERCLIS, renamed to SEMS by the EPA in 2015. The list contains data on potentially hazardous waste sites that have been reported to the USEPA by states, municipalities, private companies and private persons, pursuant to Section 103 of the Comprehensive Environmental Response, Compensation, and Liability Act (CERCLA). This dataset also contains sites which are either proposed to or on the National Priorities List (NPL) and the sites which are in the screening and assessment phase for possible inclusion on the NPL.

Date of Government Version: 12/19/2024
Date Data Arrived at EDR: 01/02/2025
Date Made Active in Reports: 01/21/2025
Number of Days to Update: 19

Source: EPA
Telephone: 800-424-9346
Last EDR Contact: 02/03/2025
Next Scheduled EDR Contact: 04/21/2025
Data Release Frequency: Quarterly

Lists of Federal CERCLA sites with NFRAP

SEMS-ARCHIVE: Superfund Enterprise Management System Archive

SEMS-ARCHIVE (Superfund Enterprise Management System Archive) tracks sites that have no further interest under the Federal Superfund Program based on available information. The list was formerly known as the CERCLIS-NFRAP, renamed to SEMS ARCHIVE by the EPA in 2015. EPA may perform a minimal level of assessment work at a site while it is archived if site conditions change and/or new information becomes available. Archived sites have been removed and archived from the inventory of SEMS sites. Archived status indicates that, to the best of EPA's knowledge, assessment at a site has been completed and that EPA has determined no further steps will be taken to list the site on the National Priorities List (NPL), unless information indicates this decision was not appropriate or other considerations require a recommendation for listing at a later time. The decision does not necessarily mean that there is no hazard associated with a given site; it only means that. based upon available information, the location is not judged to be potential NPL site.

Date of Government Version: 12/19/2024
Date Data Arrived at EDR: 01/02/2025
Date Made Active in Reports: 01/21/2025
Number of Days to Update: 19

Source: EPA
Telephone: 800-424-9346
Last EDR Contact: 02/03/2025
Next Scheduled EDR Contact: 04/21/2025
Data Release Frequency: Quarterly

Lists of Federal RCRA facilities undergoing Corrective Action

CORRACTS: Corrective Action Report

CORRACTS identifies hazardous waste handlers with RCRA corrective action activity.

Date of Government Version: 09/16/2024
Date Data Arrived at EDR: 09/17/2024
Date Made Active in Reports: 12/06/2024
Number of Days to Update: 80

Source: EPA
Telephone: 800-424-9346
Last EDR Contact: 02/19/2025
Next Scheduled EDR Contact: 03/31/2025
Data Release Frequency: Quarterly

Lists of Federal RCRA TSD facilities

RCRA-TSDF: RCRA - Treatment, Storage and Disposal

RCRAInfo is EPA's comprehensive information system, providing access to data supporting the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. The database includes selective information on sites which generate, transport, store, treat and/or dispose of hazardous waste as defined by the Resource Conservation and Recovery Act (RCRA). Transporters are individuals or entities that move hazardous waste from the generator offsite to a facility that can recycle, treat, store, or dispose of the waste. TSDFs treat, store, or dispose of the waste.

Date of Government Version: 09/16/2024
Date Data Arrived at EDR: 09/17/2024
Date Made Active in Reports: 12/06/2024
Number of Days to Update: 80

Source: Environmental Protection Agency
Telephone: (212) 637-3660
Last EDR Contact: 02/19/2025
Next Scheduled EDR Contact: 03/31/2025
Data Release Frequency: Quarterly

Lists of Federal RCRA generators

RCRA-LQG: RCRA - Large Quantity Generators

RCRAInfo is EPA's comprehensive information system, providing access to data supporting the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. The database includes selective information on sites which generate, transport, store, treat and/or dispose of hazardous waste as defined by the Resource Conservation and Recovery Act (RCRA). Large quantity generators (LQGs) generate over 1,000 kilograms (kg) of hazardous waste, or over 1 kg of acutely hazardous waste per month.

Date of Government Version: 09/16/2024
Date Data Arrived at EDR: 09/17/2024
Date Made Active in Reports: 12/06/2024
Number of Days to Update: 80

Source: Environmental Protection Agency
Telephone: (212) 637-3660
Last EDR Contact: 02/19/2025
Next Scheduled EDR Contact: 03/31/2025
Data Release Frequency: Quarterly

RCRA-SQG: RCRA - Small Quantity Generators

RCRAInfo is EPA's comprehensive information system, providing access to data supporting the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. The database includes selective information on sites which generate, transport, store, treat and/or dispose of hazardous waste as defined by the Resource Conservation and Recovery Act (RCRA). Small quantity generators (SQGs) generate between 100 kg and 1,000 kg of hazardous waste per month.

Date of Government Version: 09/16/2024
Date Data Arrived at EDR: 09/17/2024
Date Made Active in Reports: 12/06/2024
Number of Days to Update: 80

Source: Environmental Protection Agency
Telephone: (212) 637-3660
Last EDR Contact: 02/19/2025
Next Scheduled EDR Contact: 03/31/2025
Data Release Frequency: Quarterly

RCRA-VSQG: RCRA - Very Small Quantity Generators (Formerly Conditionally Exempt Small Quantity Generators)

RCRAInfo is EPA's comprehensive information system, providing access to data supporting the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. The database includes selective information on sites which generate, transport, store, treat and/or dispose of hazardous waste as defined by the Resource Conservation and Recovery Act (RCRA). Very small quantity generators (VSQGs) generate less than 100 kg of hazardous waste, or less than 1 kg of acutely hazardous waste per month.

Date of Government Version: 09/16/2024
Date Data Arrived at EDR: 09/17/2024
Date Made Active in Reports: 12/06/2024
Number of Days to Update: 80

Source: Environmental Protection Agency
Telephone: (212) 637-3660
Last EDR Contact: 02/19/2025
Next Scheduled EDR Contact: 03/31/2025
Data Release Frequency: Quarterly

Federal institutional controls / engineering controls registries

LUCIS: Land Use Control Information System

LUCIS contains records of land use control information pertaining to the former Navy Base Realignment and Closure properties.

Date of Government Version: 11/11/2024
Date Data Arrived at EDR: 11/25/2024
Date Made Active in Reports: 02/18/2025
Number of Days to Update: 85

Source: Department of the Navy
Telephone: 843-820-7326
Last EDR Contact: 02/20/2025
Next Scheduled EDR Contact: 05/19/2025
Data Release Frequency: Varies

US ENG CONTROLS: Engineering Controls Sites List

A listing of sites with engineering controls in place. Engineering controls include various forms of caps, building foundations, liners, and treatment methods to create pathway elimination for regulated substances to enter environmental media or effect human health.

Date of Government Version: 11/04/2024
Date Data Arrived at EDR: 11/15/2024
Date Made Active in Reports: 02/11/2025
Number of Days to Update: 88

Source: Environmental Protection Agency
Telephone: 703-603-0695
Last EDR Contact: 02/18/2025
Next Scheduled EDR Contact: 12/02/2024
Data Release Frequency: Varies

US INST CONTROLS: Institutional Controls Sites List

A listing of sites with institutional controls in place. Institutional controls include administrative measures, such as groundwater use restrictions, construction restrictions, property use restrictions, and post remediation care requirements intended to prevent exposure to contaminants remaining on site. Deed restrictions are generally required as part of the institutional controls.

Date of Government Version: 11/04/2024
Date Data Arrived at EDR: 11/15/2024
Date Made Active in Reports: 02/11/2025
Number of Days to Update: 88

Source: Environmental Protection Agency
Telephone: 703-603-0695
Last EDR Contact: 02/18/2025
Next Scheduled EDR Contact: 06/02/2025
Data Release Frequency: Varies

Federal ERNS list

ERNS: Emergency Response Notification System

Emergency Response Notification System. ERNS records and stores information on reported releases of oil and hazardous substances.

Date of Government Version: 12/03/2024
Date Data Arrived at EDR: 12/11/2024
Date Made Active in Reports: 02/18/2025
Number of Days to Update: 69

Source: National Response Center, United States Coast Guard
Telephone: 202-267-2180
Last EDR Contact: 12/11/2024
Next Scheduled EDR Contact: 03/31/2025
Data Release Frequency: Quarterly

Lists of state- and tribal hazardous waste facilities

SHWS: Inactive Hazardous Waste Disposal Sites in New York State

Referred to as the State Superfund Program, the Inactive Hazardous Waste Disposal Site Remedial Program is the cleanup program for inactive hazardous waste sites and now includes hazardous substance sites

Date of Government Version: 11/04/2024
Date Data Arrived at EDR: 11/05/2024
Date Made Active in Reports: 01/22/2025
Number of Days to Update: 78

Source: Department of Environmental Conservation
Telephone: 518-402-9622
Last EDR Contact: 02/04/2025
Next Scheduled EDR Contact: 05/19/2025
Data Release Frequency: Annually

Lists of state and tribal landfills and solid waste disposal facilities

SWF/LF: Facility Register

Solid Waste Facilities/Landfill Sites. SWF/LF type records typically contain an inventory of solid waste disposal facilities or landfills in a particular state. Depending on the state, these may be active or inactive facilities or open dumps that failed to meet RCRA Subtitle D Section 4004 criteria for solid waste landfills or disposal sites.

Date of Government Version: 12/11/2024
Date Data Arrived at EDR: 12/17/2024
Date Made Active in Reports: 12/27/2024
Number of Days to Update: 10

Source: Department of Environmental Conservation
Telephone: 518-402-8678
Last EDR Contact: 12/17/2024
Next Scheduled EDR Contact: 04/07/2025
Data Release Frequency: Quarterly

Lists of state and tribal leaking storage tanks

INDIAN LUST R5: Leaking Underground Storage Tanks on Indian Land

Leaking underground storage tanks located on Indian Land in Michigan, Minnesota and Wisconsin.

Date of Government Version: 04/11/2024
Date Data Arrived at EDR: 05/30/2024
Date Made Active in Reports: 08/28/2024
Number of Days to Update: 90

Source: EPA, Region 5
Telephone: 312-886-7439
Last EDR Contact: 01/16/2025
Next Scheduled EDR Contact: 04/28/2025
Data Release Frequency: Varies

INDIAN LUST R6: Leaking Underground Storage Tanks on Indian Land

LUSTs on Indian land in New Mexico and Oklahoma.

Date of Government Version: 05/07/2024
Date Data Arrived at EDR: 05/30/2024
Date Made Active in Reports: 08/28/2024
Number of Days to Update: 90

Source: EPA Region 6
Telephone: 214-665-6597
Last EDR Contact: 01/16/2025
Next Scheduled EDR Contact: 04/28/2025
Data Release Frequency: Varies

INDIAN LUST R10: Leaking Underground Storage Tanks on Indian Land

LUSTs on Indian land in Alaska, Idaho, Oregon and Washington.

Date of Government Version: 05/07/2024
Date Data Arrived at EDR: 05/30/2024
Date Made Active in Reports: 08/28/2024
Number of Days to Update: 90

Source: EPA Region 10
Telephone: 206-553-2857
Last EDR Contact: 01/16/2025
Next Scheduled EDR Contact: 04/28/2025
Data Release Frequency: Varies

INDIAN LUST R1: Leaking Underground Storage Tanks on Indian Land
A listing of leaking underground storage tank locations on Indian Land.

Date of Government Version: 05/07/2024
Date Data Arrived at EDR: 05/30/2024
Date Made Active in Reports: 08/28/2024
Number of Days to Update: 90

Source: EPA Region 1
Telephone: 617-918-1313
Last EDR Contact: 01/16/2025
Next Scheduled EDR Contact: 04/28/2025
Data Release Frequency: Varies

INDIAN LUST R4: Leaking Underground Storage Tanks on Indian Land
LUSTs on Indian land in Florida, Mississippi and North Carolina.

Date of Government Version: 05/07/2024
Date Data Arrived at EDR: 05/30/2024
Date Made Active in Reports: 08/28/2024
Number of Days to Update: 90

Source: EPA Region 4
Telephone: 404-562-8677
Last EDR Contact: 01/16/2025
Next Scheduled EDR Contact: 04/28/2025
Data Release Frequency: Varies

INDIAN LUST R9: Leaking Underground Storage Tanks on Indian Land
LUSTs on Indian land in Arizona, California, New Mexico and Nevada

Date of Government Version: 05/07/2024
Date Data Arrived at EDR: 05/30/2024
Date Made Active in Reports: 08/28/2024
Number of Days to Update: 90

Source: Environmental Protection Agency
Telephone: 415-972-3372
Last EDR Contact: 01/16/2025
Next Scheduled EDR Contact: 04/28/2025
Data Release Frequency: Varies

INDIAN LUST R8: Leaking Underground Storage Tanks on Indian Land
LUSTs on Indian land in Colorado, Montana, North Dakota, South Dakota, Utah and Wyoming.

Date of Government Version: 05/07/2024
Date Data Arrived at EDR: 05/30/2024
Date Made Active in Reports: 08/28/2024
Number of Days to Update: 90

Source: EPA Region 8
Telephone: 303-312-6271
Last EDR Contact: 01/16/2025
Next Scheduled EDR Contact: 04/28/2025
Data Release Frequency: Varies

INDIAN LUST R7: Leaking Underground Storage Tanks on Indian Land
LUSTs on Indian land in Iowa, Kansas, and Nebraska

Date of Government Version: 05/07/2024
Date Data Arrived at EDR: 05/30/2024
Date Made Active in Reports: 08/28/2024
Number of Days to Update: 90

Source: EPA Region 7
Telephone: 913-551-7003
Last EDR Contact: 01/16/2025
Next Scheduled EDR Contact: 04/28/2025
Data Release Frequency: Varies

LTANKS: Spills Information Database
Leaking Storage Tank Incident Reports. These records contain an inventory of reported leaking storage tank incidents reported from 4/1/86 through the most recent update. They can be either leaking underground storage tanks or leaking aboveground storage tanks. The causes of the incidents are tank test failures, tank failures or tank overfills.

Date of Government Version: 11/03/2024
Date Data Arrived at EDR: 11/05/2024
Date Made Active in Reports: 12/05/2024
Number of Days to Update: 30

Source: Department of Environmental Conservation
Telephone: 518-402-9549
Last EDR Contact: 02/04/2025
Next Scheduled EDR Contact: 05/19/2025
Data Release Frequency: Varies

HIST LTANKS: Listing of Leaking Storage Tanks

A listing of leaking underground and aboveground storage tanks. The causes of the incidents are tank test failures, tank failures or tank overfills. In 2002, the Department of Environmental Conservation stopped providing updates to its original Spills Information Database. This database includes fields that are no longer available from the NYDEC as of January 1, 2002. Current information may be found in the NY LTANKS database. Department of Environmental Conservation.

Date of Government Version: 01/01/2002
Date Data Arrived at EDR: 07/08/2005
Date Made Active in Reports: 07/14/2005
Number of Days to Update: 6

Source: Department of Environmental Conservation
Telephone: 518-402-9549
Last EDR Contact: 07/07/2005
Next Scheduled EDR Contact: N/A
Data Release Frequency: No Update Planned

Lists of state and tribal registered storage tanks

FEMA UST: Underground Storage Tank Listing

A listing of all FEMA owned underground storage tanks.

Date of Government Version: 08/12/2024
Date Data Arrived at EDR: 10/30/2024
Date Made Active in Reports: 01/14/2025
Number of Days to Update: 76

Source: FEMA
Telephone: 202-646-5797
Last EDR Contact: 12/23/2024
Next Scheduled EDR Contact: 04/14/2025
Data Release Frequency: Varies

UST: Petroleum Bulk Storage (PBS) Database

Facilities that have petroleum storage capacities in excess of 1,100 gallons and less than 400,000 gallons.

Date of Government Version: 09/16/2024
Date Data Arrived at EDR: 09/17/2024
Date Made Active in Reports: 11/26/2024
Number of Days to Update: 70

Source: Department of Environmental Conservation
Telephone: 518-402-9549
Last EDR Contact: 12/12/2024
Next Scheduled EDR Contact: 03/31/2025
Data Release Frequency: No Update Planned

CBS UST: Chemical Bulk Storage Database

Facilities that store regulated hazardous substances in underground tanks of any size

Date of Government Version: 01/01/2002
Date Data Arrived at EDR: 02/20/2002
Date Made Active in Reports: 03/22/2002
Number of Days to Update: 30

Source: NYSDEC
Telephone: 518-402-9549
Last EDR Contact: 10/24/2005
Next Scheduled EDR Contact: 01/23/2006
Data Release Frequency: No Update Planned

MOSF UST: Major Oil Storage Facilities Database

Facilities that may be onshore facilities or vessels, with petroleum storage capacities of 400,000 gallons or greater.

Date of Government Version: 01/01/2002
Date Data Arrived at EDR: 02/20/2002
Date Made Active in Reports: 03/22/2002
Number of Days to Update: 30

Source: NYSDEC
Telephone: 518-402-9549
Last EDR Contact: 07/25/2005
Next Scheduled EDR Contact: 10/24/2005
Data Release Frequency: No Update Planned

CBS: Chemical Bulk Storage Site Listing

These facilities store regulated hazardous substances in aboveground tanks with capacities of 185 gallons or greater, and/or in underground tanks of any size

Date of Government Version: 09/16/2024
Date Data Arrived at EDR: 09/17/2024
Date Made Active in Reports: 11/26/2024
Number of Days to Update: 70

Source: Department of Environmental Conservation
Telephone: 518-402-9549
Last EDR Contact: 12/12/2024
Next Scheduled EDR Contact: 03/31/2025
Data Release Frequency: Quarterly

MOSF: Major Oil Storage Facility Site Listing

These facilities may be onshore facilities or vessels, with petroleum storage capacities of 400,000 gallons or greater.

Date of Government Version: 09/16/2024
Date Data Arrived at EDR: 09/17/2024
Date Made Active in Reports: 11/26/2024
Number of Days to Update: 70

Source: Department of Environmental Conservation
Telephone: 518-402-9549
Last EDR Contact: 12/12/2024
Next Scheduled EDR Contact: 03/31/2025
Data Release Frequency: Quarterly

AST: Petroleum Bulk Storage

Registered Aboveground Storage Tanks.

Date of Government Version: 09/16/2024
Date Data Arrived at EDR: 09/17/2024
Date Made Active in Reports: 11/26/2024
Number of Days to Update: 70

Source: Department of Environmental Conservation
Telephone: 518-402-9549
Last EDR Contact: 12/12/2024
Next Scheduled EDR Contact: 03/31/2025
Data Release Frequency: No Update Planned

CBS AST: Chemical Bulk Storage Database

Facilities that store regulated hazardous substances in aboveground tanks with capacities of 185 gallons or greater, and/or in underground tanks of any size.

Date of Government Version: 01/01/2002
Date Data Arrived at EDR: 02/20/2002
Date Made Active in Reports: 03/22/2002
Number of Days to Update: 30

Source: NYSDEC
Telephone: 518-402-9549
Last EDR Contact: 07/25/2005
Next Scheduled EDR Contact: 10/24/2005
Data Release Frequency: No Update Planned

MOSF AST: Major Oil Storage Facilities Database

Facilities that may be onshore facilities or vessels, with petroleum storage capacities of 400,000 gallons or greater.

Date of Government Version: 01/01/2002
Date Data Arrived at EDR: 02/20/2002
Date Made Active in Reports: 03/22/2002
Number of Days to Update: 30

Source: NYSDEC
Telephone: 518-402-9549
Last EDR Contact: 07/25/2005
Next Scheduled EDR Contact: 10/24/2005
Data Release Frequency: No Update Planned

INDIAN UST R8: Underground Storage Tanks on Indian Land

The Indian Underground Storage Tank (UST) database provides information about underground storage tanks on Indian land in EPA Region 8 (Colorado, Montana, North Dakota, South Dakota, Utah, Wyoming and 27 Tribal Nations).

Date of Government Version: 05/14/2024
Date Data Arrived at EDR: 05/30/2024
Date Made Active in Reports: 08/28/2024
Number of Days to Update: 90

Source: EPA Region 8
Telephone: 303-312-6137
Last EDR Contact: 01/16/2025
Next Scheduled EDR Contact: 04/28/2025
Data Release Frequency: Varies

INDIAN UST R9: Underground Storage Tanks on Indian Land

The Indian Underground Storage Tank (UST) database provides information about underground storage tanks on Indian land in EPA Region 9 (Arizona, California, Hawaii, Nevada, the Pacific Islands, and Tribal Nations).

Date of Government Version: 05/14/2024
Date Data Arrived at EDR: 05/30/2024
Date Made Active in Reports: 08/28/2024
Number of Days to Update: 90

Source: EPA Region 9
Telephone: 415-972-3368
Last EDR Contact: 01/16/2025
Next Scheduled EDR Contact: 04/28/2025
Data Release Frequency: Varies

INDIAN UST R4: Underground Storage Tanks on Indian Land

The Indian Underground Storage Tank (UST) database provides information about underground storage tanks on Indian land in EPA Region 4 (Alabama, Florida, Georgia, Kentucky, Mississippi, North Carolina, South Carolina, Tennessee and Tribal Nations)

Date of Government Version: 05/14/2024
Date Data Arrived at EDR: 05/30/2024
Date Made Active in Reports: 08/28/2024
Number of Days to Update: 90

Source: EPA Region 4
Telephone: 404-562-9424
Last EDR Contact: 01/16/2025
Next Scheduled EDR Contact: 07/29/2024
Data Release Frequency: Varies

INDIAN UST R1: Underground Storage Tanks on Indian Land

The Indian Underground Storage Tank (UST) database provides information about underground storage tanks on Indian land in EPA Region 1 (Connecticut, Maine, Massachusetts, New Hampshire, Rhode Island, Vermont and ten Tribal Nations).

Date of Government Version: 05/14/2024
Date Data Arrived at EDR: 05/30/2024
Date Made Active in Reports: 08/28/2024
Number of Days to Update: 90

Source: EPA, Region 1
Telephone: 617-918-1313
Last EDR Contact: 01/16/2025
Next Scheduled EDR Contact: 04/28/2025
Data Release Frequency: Varies

INDIAN UST R10: Underground Storage Tanks on Indian Land

The Indian Underground Storage Tank (UST) database provides information about underground storage tanks on Indian land in EPA Region 10 (Alaska, Idaho, Oregon, Washington, and Tribal Nations).

Date of Government Version: 05/14/2024
Date Data Arrived at EDR: 05/30/2024
Date Made Active in Reports: 08/28/2024
Number of Days to Update: 90

Source: EPA Region 10
Telephone: 206-553-2857
Last EDR Contact: 01/16/2025
Next Scheduled EDR Contact: 04/28/2025
Data Release Frequency: Varies

INDIAN UST R6: Underground Storage Tanks on Indian Land

The Indian Underground Storage Tank (UST) database provides information about underground storage tanks on Indian land in EPA Region 6 (Louisiana, Arkansas, Oklahoma, New Mexico, Texas and 65 Tribes).

Date of Government Version: 05/14/2024
Date Data Arrived at EDR: 05/30/2024
Date Made Active in Reports: 08/28/2024
Number of Days to Update: 90

Source: EPA Region 6
Telephone: 214-665-7591
Last EDR Contact: 01/16/2025
Next Scheduled EDR Contact: 04/28/2025
Data Release Frequency: Varies

INDIAN UST R5: Underground Storage Tanks on Indian Land

The Indian Underground Storage Tank (UST) database provides information about underground storage tanks on Indian land in EPA Region 5 (Michigan, Minnesota and Wisconsin and Tribal Nations).

Date of Government Version: 04/11/2024
Date Data Arrived at EDR: 05/30/2024
Date Made Active in Reports: 08/28/2024
Number of Days to Update: 90

Source: EPA Region 5
Telephone: 312-886-6136
Last EDR Contact: 01/16/2025
Next Scheduled EDR Contact: 04/28/2025
Data Release Frequency: Varies

INDIAN UST R7: Underground Storage Tanks on Indian Land

The Indian Underground Storage Tank (UST) database provides information about underground storage tanks on Indian land in EPA Region 7 (Iowa, Kansas, Missouri, Nebraska, and 9 Tribal Nations).

Date of Government Version: 05/14/2024
Date Data Arrived at EDR: 05/30/2024
Date Made Active in Reports: 08/28/2024
Number of Days to Update: 90

Source: EPA Region 7
Telephone: 913-551-7003
Last EDR Contact: 01/16/2025
Next Scheduled EDR Contact: 04/28/2025
Data Release Frequency: Varies

TANKS: Storage Tank Faciliy Listing
This database contains records of facilities that are or have been regulated under Bulk Storage Program. Tank information for these facilities may not be releasable by the state agency.

Date of Government Version: 09/16/2024
Date Data Arrived at EDR: 09/17/2024
Date Made Active in Reports: 11/26/2024
Number of Days to Update: 70
Source: Department of Environmental Conservation
Telephone: 518-402-9543
Last EDR Contact: 12/12/2024
Next Scheduled EDR Contact: 03/31/2025
Data Release Frequency: Quarterly

State and tribal institutional control / engineering control registries

ENV RES DECL: Environmental Restrictive Declarations
The Environmental Restrictive Declarations (ERD) listed were recorded in connection with a zoning action against the noted Tax Blocks and Tax Lots, or portion thereof, and are available in the property records on file at the Office of the City Register for Bronx, Kings, New York and Queens counties or at the Richmond County Clerk's office. They contain environmental requirements with respect to hazardous materials, air quality and/or noise in accordance with Section 11-15 of this Resolution.

Date of Government Version: 07/17/2024
Date Data Arrived at EDR: 09/11/2024
Date Made Active in Reports: 11/22/2024
Number of Days to Update: 72
Source: New York City Department of City Planning
Telephone: 212-720-3300
Last EDR Contact: 12/09/2024
Next Scheduled EDR Contact: 03/24/2025
Data Release Frequency: Varies

RES DECL: Restrictive Declarations Listing
A restrictive declaration is a covenant running with the land which binds the present and future owners of the property. As a condition of certain special permits, the City Planning Commission may require an applicant to sign and record a restrictive declaration that places specified conditions on the future use and development of the property. Certain restrictive declarations are indicated by a D on zoning maps.

Date of Government Version: 07/17/2024
Date Data Arrived at EDR: 09/10/2024
Date Made Active in Reports: 11/25/2024
Number of Days to Update: 76
Source: NYC Department of City Planning
Telephone: 212-720-3401
Last EDR Contact: 12/09/2024
Next Scheduled EDR Contact: 03/24/2025
Data Release Frequency: Varies

ENG CONTROLS: Registry of Engineering Controls
Environmental Remediation sites that have engineering controls in place.

Date of Government Version: 11/04/2024
Date Data Arrived at EDR: 11/05/2024
Date Made Active in Reports: 01/22/2025
Number of Days to Update: 78
Source: Department of Environmental Conservation
Telephone: 518-402-9553
Last EDR Contact: 02/04/2025
Next Scheduled EDR Contact: 05/19/2025
Data Release Frequency: Quarterly

INST CONTROL: Registry of Institutional Controls
Environmental Remediation sites that have institutional controls in place.

Date of Government Version: 11/04/2024
Date Data Arrived at EDR: 11/05/2024
Date Made Active in Reports: 01/22/2025
Number of Days to Update: 78
Source: Department of Environmental Conservation
Telephone: 518-402-9553
Last EDR Contact: 02/04/2025
Next Scheduled EDR Contact: 05/19/2025
Data Release Frequency: Quarterly

Lists of state and tribal voluntary cleanup sites

INDIAN VCP R1: Voluntary Cleanup Priority Listing
A listing of voluntary cleanup priority sites located on Indian Land located in Region 1.

Date of Government Version: 07/27/2015
Date Data Arrived at EDR: 09/29/2015
Date Made Active in Reports: 02/18/2016
Number of Days to Update: 142

Source: EPA, Region 1
Telephone: 617-918-1102
Last EDR Contact: 12/10/2024
Next Scheduled EDR Contact: 03/31/2025
Data Release Frequency: Varies

INDIAN VCP R7: Voluntary Cleanup Priority Lisitng

A listing of voluntary cleanup priority sites located on Indian Land located in Region 7.

Date of Government Version: 03/20/2008
Date Data Arrived at EDR: 04/22/2008
Date Made Active in Reports: 05/19/2008
Number of Days to Update: 27

Source: EPA, Region 7
Telephone: 913-551-7365
Last EDR Contact: 07/08/2021
Next Scheduled EDR Contact: 07/20/2009
Data Release Frequency: Varies

VCP NYC: Voluntary Cleanup Program Listing NYC

New York City voluntary cleanup program sites.

Date of Government Version: 09/03/2024
Date Data Arrived at EDR: 09/04/2024
Date Made Active in Reports: 11/15/2024
Number of Days to Update: 72

Source: New York City Office of Environmental Protection
Telephone: 212-788-8841
Last EDR Contact: 12/04/2024
Next Scheduled EDR Contact: 03/17/2025
Data Release Frequency: Varies

VCP: Voluntary Cleanup Agreements

New York established its Voluntary Cleanup Program (VCP) to address the environmental, legal and financial barriers that often hinder the redevelopment and reuse of contaminated properties. The Voluntary Cleanup Program was developed to enhance private sector cleanup of brownfields by enabling parties to remediate sites using private rather than public funds and to reduce the development pressures on "greenfield" sites.

Date of Government Version: 11/04/2024
Date Data Arrived at EDR: 11/05/2024
Date Made Active in Reports: 01/22/2025
Number of Days to Update: 78

Source: Department of Environmental Conservation
Telephone: 518-402-9711
Last EDR Contact: 02/04/2025
Next Scheduled EDR Contact: 05/19/2025
Data Release Frequency: Semi-Annually

Lists of state and tribal brownfield sites

BROWNFIELDS: Brownfields Site List

A Brownfield is any real property where redevelopment or re-use may be complicated by the presence or potential presence of a hazardous waste, petroleum, pollutant, or contaminant.

Date of Government Version: 11/04/2024
Date Data Arrived at EDR: 11/05/2024
Date Made Active in Reports: 01/22/2025
Number of Days to Update: 78

Source: Department of Environmental Conservation
Telephone: 518-402-9764
Last EDR Contact: 02/04/2025
Next Scheduled EDR Contact: 05/19/2025
Data Release Frequency: Semi-Annually

ERP: Environmental Restoration Program Listing

In an effort to spur the cleanup and redevelopment of brownfields, New Yorkers approved a $200 million Environmental Restoration or Brownfields Fund as part of the $1.75 billion Clean Water/Clean Air Bond Act of 1996 (1996 Bond Act). Enhancements to the program were enacted on October 7, 2003. Under the Environmental Restoration Program, the State provides grants to municipalities to reimburse up to 90 percent of on-site eligible costs and 100% of off-site eligible costs for site investigation and remediation activities. Once remediated, the property may then be reused for commercial, industrial, residential or public use.

Date of Government Version: 11/04/2024
Date Data Arrived at EDR: 11/05/2024
Date Made Active in Reports: 01/22/2025
Number of Days to Update: 78

Source: Department of Environmental Conservation
Telephone: 518-402-9622
Last EDR Contact: 02/04/2025
Next Scheduled EDR Contact: 05/19/2025
Data Release Frequency: Quarterly

ADDITIONAL ENVIRONMENTAL RECORDS

Local Brownfield lists

US BROWNFIELDS: A Listing of Brownfields Sites

Brownfields are real property, the expansion, redevelopment, or reuse of which may be complicated by the presence or potential presence of a hazardous substance, pollutant, or contaminant. Cleaning up and reinvesting in these properties takes development pressures off of undeveloped, open land, and both improves and protects the environment. Assessment, Cleanup and Redevelopment Exchange System (ACRES) stores information reported by EPA Brownfields grant recipients on brownfields properties assessed or cleaned up with grant funding as well as information on Targeted Brownfields Assessments performed by EPA Regions. A listing of ACRES Brownfield sites is obtained from Cleanups in My Community. Cleanups in My Community provides information on Brownfields properties for which information is reported back to EPA, as well as areas served by Brownfields grant programs.

Date of Government Version: 09/09/2024
Date Data Arrived at EDR: 09/11/2024
Date Made Active in Reports: 12/06/2024
Number of Days to Update: 86

Source: Environmental Protection Agency
Telephone: 202-566-2777
Last EDR Contact: 12/12/2024
Next Scheduled EDR Contact: 03/24/2025
Data Release Frequency: Semi-Annually

Local Lists of Landfill / Solid Waste Disposal Sites

SWTIRE: Registered Waste Tire Storage & Facility List

A listing of facilities registered to accept waste tires.

Date of Government Version: 02/27/2018
Date Data Arrived at EDR: 04/06/2018
Date Made Active in Reports: 06/08/2018
Number of Days to Update: 63

Source: Department of Environmental Conservation
Telephone: 518-402-8694
Last EDR Contact: 11/27/2024
Next Scheduled EDR Contact: 03/17/2025
Data Release Frequency: No Update Planned

SWRCY: Registered Recycling Facility List

A listing of recycling facilities.

Date of Government Version: 12/11/2024
Date Data Arrived at EDR: 12/17/2024
Date Made Active in Reports: 12/27/2024
Number of Days to Update: 10

Source: Department of Environmental Conservation
Telephone: 518-402-8678
Last EDR Contact: 12/17/2024
Next Scheduled EDR Contact: 04/07/2025
Data Release Frequency: Quarterly

INDIAN ODI: Report on the Status of Open Dumps on Indian Lands

Location of open dumps on Indian land.

Date of Government Version: 12/31/1998
Date Data Arrived at EDR: 12/03/2007
Date Made Active in Reports: 01/24/2008
Number of Days to Update: 52

Source: Environmental Protection Agency
Telephone: 703-308-8245
Last EDR Contact: 01/16/2025
Next Scheduled EDR Contact: 05/05/2025
Data Release Frequency: Varies

DEBRIS REGION 9: Torres Martinez Reservation Illegal Dump Site Locations

A listing of illegal dump sites location on the Torres Martinez Indian Reservation located in eastern Riverside County and northern Imperial County, California.

Date of Government Version: 01/12/2009
Date Data Arrived at EDR: 05/07/2009
Date Made Active in Reports: 09/21/2009
Number of Days to Update: 137

Source: EPA, Region 9
Telephone: 415-947-4219
Last EDR Contact: 01/23/2025
Next Scheduled EDR Contact: 04/28/2025
Data Release Frequency: No Update Planned

ODI: Open Dump Inventory

An open dump is defined as a disposal facility that does not comply with one or more of the Part 257 or Part 258 Subtitle D Criteria.

Date of Government Version: 06/30/1985
Date Data Arrived at EDR: 08/09/2004
Date Made Active in Reports: 09/17/2004
Number of Days to Update: 39

Source: Environmental Protection Agency
Telephone: 800-424-9346
Last EDR Contact: 06/09/2004
Next Scheduled EDR Contact: N/A
Data Release Frequency: No Update Planned

IHS OPEN DUMPS: Open Dumps on Indian Land

A listing of all open dumps located on Indian Land in the United States.

Date of Government Version: 02/07/2024
Date Data Arrived at EDR: 11/13/2024
Date Made Active in Reports: 11/19/2024
Number of Days to Update: 6

Source: Department of Health & Human Serivces, Indian Health Service
Telephone: 301-443-1452
Last EDR Contact: 12/09/2024
Next Scheduled EDR Contact: 05/05/2025
Data Release Frequency: Varies

Local Lists of Hazardous waste / Contaminated Sites

US HIST CDL: National Clandestine Laboratory Register

A listing of clandestine drug lab locations that have been removed from the DEAs National Clandestine Laboratory Register.

Date of Government Version: 05/20/2024
Date Data Arrived at EDR: 08/19/2024
Date Made Active in Reports: 10/09/2024
Number of Days to Update: 51

Source: Drug Enforcement Administration
Telephone: 202-307-1000
Last EDR Contact: 02/20/2025
Next Scheduled EDR Contact: 06/02/2025
Data Release Frequency: No Update Planned

DEL SHWS: Delisted Registry Sites

A database listing of sites delisted from the Registry of Inactive Hazardous Waste Disposal Sites.

Date of Government Version: 11/04/2024
Date Data Arrived at EDR: 11/05/2024
Date Made Active in Reports: 01/22/2025
Number of Days to Update: 78

Source: Department of Environmental Conservation
Telephone: 518-402-9622
Last EDR Contact: 02/04/2025
Next Scheduled EDR Contact: 05/19/2025
Data Release Frequency: Quarterly

US CDL: Clandestine Drug Labs

A listing of clandestine drug lab locations. The U.S. Department of Justice ("the Department") provides this web site as a public service. It contains addresses of some locations where law enforcement agencies reported they found chemicals or other items that indicated the presence of either clandestine drug laboratories or dumpsites. In most cases, the source of the entries is not the Department, and the Department has not verified the entry and does not guarantee its accuracy. Members of the public must verify the accuracy of all entries by, for example, contacting local law enforcement and local health departments.

Date of Government Version: 05/20/2024
Date Data Arrived at EDR: 08/19/2024
Date Made Active in Reports: 10/09/2024
Number of Days to Update: 51

Source: Drug Enforcement Administration
Telephone: 202-307-1000
Last EDR Contact: 02/20/2025
Next Scheduled EDR Contact: 06/02/2025
Data Release Frequency: Quarterly

Local Lists of Registered Storage Tanks

HIST UST: Historical Petroleum Bulk Storage Database

These facilities have petroleum storage capacities in excess of 1,100 gallons and less than 400,000 gallons. This database contains detailed information per site. It is no longer updated due to the sensitive nature of the information involved. See UST for more current data.

Date of Government Version: 01/01/2002
Date Data Arrived at EDR: 06/02/2006
Date Made Active in Reports: 07/20/2006
Number of Days to Update: 48

Source: Department of Environmental Conservation
Telephone: 518-402-9549
Last EDR Contact: 10/23/2006
Next Scheduled EDR Contact: 01/22/2007
Data Release Frequency: Varies

HIST AST: Historical Petroleum Bulk Storage Database

These facilities have petroleum storage capabilities in excess of 1,100 gallons and less than 400,000 gallons. This database contains detailed information per site. No longer updated due to the sensitive nature of the information involved. See AST for more current data.

Date of Government Version: 01/01/2002
Date Data Arrived at EDR: 06/02/2006
Date Made Active in Reports: 07/20/2006
Number of Days to Update: 48

Source: Department of Environmental Conservation
Telephone: 518-402-9549
Last EDR Contact: 10/23/2006
Next Scheduled EDR Contact: 01/22/2007
Data Release Frequency: No Update Planned

Local Land Records

LIENS: Spill Liens Information

Lien information from the Oil Spill Fund.

Date of Government Version: 10/28/2024
Date Data Arrived at EDR: 10/29/2024
Date Made Active in Reports: 01/22/2025
Number of Days to Update: 85

Source: Office of the State Comptroller
Telephone: 518-474-9034
Last EDR Contact: 01/23/2025
Next Scheduled EDR Contact: 05/12/2025
Data Release Frequency: Quarterly

LIENS 2: CERCLA Lien Information

A Federal CERCLA ('Superfund') lien can exist by operation of law at any site or property at which EPA has spent Superfund monies. These monies are spent to investigate and address releases and threatened releases of contamination. CERCLIS provides information as to the identity of these sites and properties.

Date of Government Version: 12/19/2024
Date Data Arrived at EDR: 01/02/2025
Date Made Active in Reports: 01/21/2025
Number of Days to Update: 19

Source: Environmental Protection Agency
Telephone: 202-564-6023
Last EDR Contact: 02/03/2025
Next Scheduled EDR Contact: 04/07/2025
Data Release Frequency: Semi-Annually

Records of Emergency Release Reports

HMIRS: Hazardous Materials Information Reporting System

Hazardous Materials Incident Report System. HMIRS contains hazardous material spill incidents reported to DOT.

Date of Government Version: 06/14/2024
Date Data Arrived at EDR: 06/17/2024
Date Made Active in Reports: 06/24/2024
Number of Days to Update: 7

Source: U.S. Department of Transportation
Telephone: 202-366-4555
Last EDR Contact: 12/11/2024
Next Scheduled EDR Contact: 03/31/2025
Data Release Frequency: Quarterly

SPILLS: Spills Information Database

Data collected on spills reported to NYSDEC as required by one or more of the following: Article 12 of the Navigation Law, 6 NYCRR Section 613.8 (from PBS regs), or 6 NYCRR Section 595.2 (from CBS regs). It includes spills active as of April 1, 1986, as well as spills occurring since this date.

Date of Government Version: 11/03/2024
Date Data Arrived at EDR: 11/05/2024
Date Made Active in Reports: 12/05/2024
Number of Days to Update: 30

Source: Department of Environmental Conservation
Telephone: 518-402-9549
Last EDR Contact: 02/04/2025
Next Scheduled EDR Contact: 05/19/2025
Data Release Frequency: Varies

HIST SPILLS: SPILLS Database

This database contains records of chemical and petroleum spill incidents. Under State law, petroleum and hazardous chemical spills that can impact the waters of the state must be reported by the spiller (and, in some cases, by anyone who has knowledge of the spills). In 2002, the Department of Environmental Conservation stopped providing updates to its original Spills Information Database. This database includes fields that are no longer available from the NYDEC as of January 1, 2002. Current information may be found in the NY SPILLS database. Department of Environmental Conservation.

Date of Government Version: 01/01/2002
Date Data Arrived at EDR: 07/08/2005
Date Made Active in Reports: 07/14/2005
Number of Days to Update: 6

Source: Department of Environmental Conservation
Telephone: 518-402-9549
Last EDR Contact: 07/07/2005
Next Scheduled EDR Contact: N/A
Data Release Frequency: No Update Planned

SPILLS 90: SPILLS90 data from FirstSearch

Spills 90 includes those spill and release records available exclusively from FirstSearch databases. Typically, they may include chemical, oil and/or hazardous substance spills recorded after 1990. Duplicate records that are already included in EDR incident and release records are not included in Spills 90.

Date of Government Version: 12/14/2012
Date Data Arrived at EDR: 01/03/2013
Date Made Active in Reports: 02/12/2013
Number of Days to Update: 40

Source: FirstSearch
Telephone: N/A
Last EDR Contact: 01/03/2013
Next Scheduled EDR Contact: N/A
Data Release Frequency: No Update Planned

SPILLS 80: SPILLS80 data from FirstSearch

Spills 80 includes those spill and release records available from FirstSearch databases prior to 1990. Typically, they may include chemical, oil and/or hazardous substance spills recorded before 1990. Duplicate records that are already included in EDR incident and release records are not included in Spills 80.

Date of Government Version: 11/02/2010
Date Data Arrived at EDR: 01/03/2013
Date Made Active in Reports: 03/07/2013
Number of Days to Update: 63

Source: FirstSearch
Telephone: N/A
Last EDR Contact: 01/03/2013
Next Scheduled EDR Contact: N/A
Data Release Frequency: No Update Planned

Other Ascertainable Records

RCRA NonGen / NLR: RCRA - Non Generators / No Longer Regulated

RCRAInfo is EPA's comprehensive information system, providing access to data supporting the Resource Conservation and Recovery Act (RCRA) of 1976 and the Hazardous and Solid Waste Amendments (HSWA) of 1984. The database includes selective information on sites which generate, transport, store, treat and/or dispose of hazardous waste as defined by the Resource Conservation and Recovery Act (RCRA). Non-Generators do not presently generate hazardous waste.

Date of Government Version: 09/16/2024
Date Data Arrived at EDR: 09/17/2024
Date Made Active in Reports: 12/06/2024
Number of Days to Update: 80

Source: Environmental Protection Agency
Telephone: (212) 637-3660
Last EDR Contact: 02/19/2025
Next Scheduled EDR Contact: 03/31/2025
Data Release Frequency: Quarterly

FUDS: Formerly Used Defense Sites

The listing includes locations of Formerly Used Defense Sites properties where the US Army Corps of Engineers is actively working or will take necessary cleanup actions.

Date of Government Version: 10/01/2024
Date Data Arrived at EDR: 11/12/2024
Date Made Active in Reports: 01/21/2025
Number of Days to Update: 70

Source: U.S. Army Corps of Engineers
Telephone: 202-528-4285
Last EDR Contact: 02/11/2025
Next Scheduled EDR Contact: 05/26/2025
Data Release Frequency: Varies

DOD: Department of Defense Sites

This data set consists of federally owned or administered lands, administered by the Department of Defense, that have any area equal to or greater than 640 acres of the United States, Puerto Rico, and the U.S. Virgin Islands.

Date of Government Version: 06/07/2021
Date Data Arrived at EDR: 07/13/2021
Date Made Active in Reports: 03/09/2022
Number of Days to Update: 239

Source: USGS
Telephone: 888-275-8747
Last EDR Contact: 01/07/2025
Next Scheduled EDR Contact: 04/21/2025
Data Release Frequency: Varies

FEDLAND: Federal and Indian Lands

Federally and Indian administrated lands of the United States. Lands included are administrated by: Army Corps of Engineers, Bureau of Reclamation, National Wild and Scenic River, National Wildlife Refuge, Public Domain Land, Wilderness, Wilderness Study Area, Wildlife Management Area, Bureau of Indian Affairs, Bureau of Land Management, Department of Justice, Forest Service, Fish and Wildlife Service, National Park Service.

Date of Government Version: 04/02/2018
Date Data Arrived at EDR: 04/11/2018
Date Made Active in Reports: 11/06/2019
Number of Days to Update: 574

Source: U.S. Geological Survey
Telephone: 888-275-8747
Last EDR Contact: 12/30/2024
Next Scheduled EDR Contact: 04/14/2025
Data Release Frequency: N/A

SCRD DRYCLEANERS: State Coalition for Remediation of Drycleaners Listing

The State Coalition for Remediation of Drycleaners was established in 1998, with support from the U.S. EPA Office of Superfund Remediation and Technology Innovation. It is comprised of representatives of states with established drycleaner remediation programs. Currently the member states are Alabama, Connecticut, Florida, Illinois, Kansas, Minnesota, Missouri, North Carolina, Oregon, South Carolina, Tennessee, Texas, and Wisconsin.

Date of Government Version: 07/30/2021
Date Data Arrived at EDR: 02/03/2023
Date Made Active in Reports: 02/10/2023
Number of Days to Update: 7

Source: Environmental Protection Agency
Telephone: 615-532-8599
Last EDR Contact: 02/03/2025
Next Scheduled EDR Contact: 05/19/2025
Data Release Frequency: Varies

US FIN ASSUR: Financial Assurance Information

All owners and operators of facilities that treat, store, or dispose of hazardous waste are required to provide proof that they will have sufficient funds to pay for the clean up, closure, and post-closure care of their facilities.

Date of Government Version: 09/16/2024
Date Data Arrived at EDR: 09/17/2024
Date Made Active in Reports: 12/20/2024
Number of Days to Update: 94

Source: Environmental Protection Agency
Telephone: 202-566-1917
Last EDR Contact: 02/19/2025
Next Scheduled EDR Contact: 03/31/2025
Data Release Frequency: Quarterly

EPA WATCH LIST: EPA Watch List

EPA maintains a "Watch List" to facilitate dialogue between EPA, state and local environmental agencies on enforcement matters relating to facilities with alleged violations identified as either significant or high priority. Being on the Watch List does not mean that the facility has actually violated the law only that an investigation by EPA or a state or local environmental agency has led those organizations to allege that an unproven violation has in fact occurred. Being on the Watch List does not represent a higher level of concern regarding the alleged violations that were detected, but instead indicates cases requiring additional dialogue between EPA, state and local agencies - primarily because of the length of time the alleged violation has gone unaddressed or unresolved.

Date of Government Version: 08/30/2013
Date Data Arrived at EDR: 03/21/2014
Date Made Active in Reports: 06/17/2014
Number of Days to Update: 88

Source: Environmental Protection Agency
Telephone: 617-520-3000
Last EDR Contact: 01/27/2025
Next Scheduled EDR Contact: 05/12/2025
Data Release Frequency: No Update Planned

2020 COR ACTION: 2020 Corrective Action Program List

The EPA has set ambitious goals for the RCRA Corrective Action program by creating the 2020 Corrective Action Universe. This RCRA cleanup baseline includes facilities expected to need corrective action. The 2020 universe contains a wide variety of sites. Some properties are heavily contaminated while others were contaminated but have since been cleaned up. Still others have not been fully investigated yet, and may require little or no remediation. Inclusion in the 2020 Universe does not necessarily imply failure on the part of a facility to meet its RCRA obligations.

Date of Government Version: 09/30/2017
Date Data Arrived at EDR: 05/08/2018
Date Made Active in Reports: 07/20/2018
Number of Days to Update: 73

Source: Environmental Protection Agency
Telephone: 703-308-4044
Last EDR Contact: 01/30/2025
Next Scheduled EDR Contact: 05/12/2025
Data Release Frequency: Varies

GOVERNMENT RECORDS SEARCHED / DATA CURRENCY TRACKING

TSCA: Toxic Substances Control Act

Toxic Substances Control Act. TSCA identifies manufacturers and importers of chemical substances included on the TSCA Chemical Substance Inventory list. It includes data on the production volume of these substances by plant site.

Date of Government Version: 12/31/2020
Date Data Arrived at EDR: 06/14/2022
Date Made Active in Reports: 03/24/2023
Number of Days to Update: 283

Source: EPA
Telephone: 202-260-5521
Last EDR Contact: 12/12/2024
Next Scheduled EDR Contact: 03/24/2025
Data Release Frequency: Every 4 Years

TRIS: Toxic Chemical Release Inventory System

Toxic Release Inventory System. TRIS identifies facilities which release toxic chemicals to the air, water and land in reportable quantities under SARA Title III Section 313.

Date of Government Version: 12/31/2023
Date Data Arrived at EDR: 02/11/2025
Date Made Active in Reports: 02/18/2025
Number of Days to Update: 7

Source: EPA
Telephone: 202-566-0250
Last EDR Contact: 02/11/2025
Next Scheduled EDR Contact: 05/26/2025
Data Release Frequency: Annually

SSTS: Section 7 Tracking Systems

Section 7 of the Federal Insecticide, Fungicide and Rodenticide Act, as amended (92 Stat. 829) requires all registered pesticide-producing establishments to submit a report to the Environmental Protection Agency by March 1st each year. Each establishment must report the types and amounts of pesticides, active ingredients and devices being produced, and those having been produced and sold or distributed in the past year.

Date of Government Version: 10/15/2024
Date Data Arrived at EDR: 10/16/2024
Date Made Active in Reports: 01/14/2025
Number of Days to Update: 90

Source: EPA
Telephone: 202-564-4203
Last EDR Contact: 01/15/2025
Next Scheduled EDR Contact: 04/28/2025
Data Release Frequency: Annually

ROD: Records Of Decision

Record of Decision. ROD documents mandate a permanent remedy at an NPL (Superfund) site containing technical and health information to aid in the cleanup.

Date of Government Version: 10/24/2024
Date Data Arrived at EDR: 11/01/2024
Date Made Active in Reports: 11/19/2024
Number of Days to Update: 18

Source: EPA
Telephone: 703-416-0223
Last EDR Contact: 02/03/2025
Next Scheduled EDR Contact: 03/10/2025
Data Release Frequency: Annually

RMP: Risk Management Plans

When Congress passed the Clean Air Act Amendments of 1990, it required EPA to publish regulations and guidance for chemical accident prevention at facilities using extremely hazardous substances. The Risk Management Program Rule (RMP Rule) was written to implement Section 112(r) of these amendments. The rule, which built upon existing industry codes and standards, requires companies of all sizes that use certain flammable and toxic substances to develop a Risk Management Program, which includes a(n): Hazard assessment that details the potential effects of an accidental release, an accident history of the last five years, and an evaluation of worst-case and alternative accidental releases; Prevention program that includes safety precautions and maintenance, monitoring, and employee training measures; and Emergency response program that spells out emergency health care, employee training measures and procedures for informing the public and response agencies (e.g the fire department) should an accident occur.

Date of Government Version: 10/01/2024
Date Data Arrived at EDR: 10/23/2024
Date Made Active in Reports: 01/14/2025
Number of Days to Update: 83

Source: Environmental Protection Agency
Telephone: 202-564-8600
Last EDR Contact: 01/09/2025
Next Scheduled EDR Contact: 04/28/2025
Data Release Frequency: Varies

RAATS: RCRA Administrative Action Tracking System

RCRA Administration Action Tracking System. RAATS contains records based on enforcement actions issued under RCRA pertaining to major violators and includes administrative and civil actions brought by the EPA. For administration actions after September 30, 1995, data entry in the RAATS database was discontinued. EPA will retain a copy of the database for historical records. It was necessary to terminate RAATS because a decrease in agency resources made it impossible to continue to update the information contained in the database.

Date of Government Version: 04/17/1995
Date Data Arrived at EDR: 07/03/1995
Date Made Active in Reports: 08/07/1995
Number of Days to Update: 35

Source: EPA
Telephone: 202-564-4104
Last EDR Contact: 06/02/2008
Next Scheduled EDR Contact: 09/01/2008
Data Release Frequency: No Update Planned

PRP: Potentially Responsible Parties

A listing of verified Potentially Responsible Parties

Date of Government Version: 09/19/2023
Date Data Arrived at EDR: 10/03/2023
Date Made Active in Reports: 10/19/2023
Number of Days to Update: 16

Source: EPA
Telephone: 202-564-6023
Last EDR Contact: 02/03/2025
Next Scheduled EDR Contact: 05/12/2025
Data Release Frequency: Quarterly

PADS: PCB Activity Database System

PCB Activity Database. PADS Identifies generators, transporters, commercial storers and/or brokers and disposers of PCB's who are required to notify the EPA of such activities.

Date of Government Version: 07/01/2024
Date Data Arrived at EDR: 10/02/2024
Date Made Active in Reports: 01/10/2025
Number of Days to Update: 100

Source: EPA
Telephone: 202-566-0500
Last EDR Contact: 01/02/2025
Next Scheduled EDR Contact: 04/14/2025
Data Release Frequency: Annually

ICIS: Integrated Compliance Information System

The Integrated Compliance Information System (ICIS) supports the information needs of the national enforcement and compliance program as well as the unique needs of the National Pollutant Discharge Elimination System (NPDES) program.

Date of Government Version: 11/18/2016
Date Data Arrived at EDR: 11/23/2016
Date Made Active in Reports: 02/10/2017
Number of Days to Update: 79

Source: Environmental Protection Agency
Telephone: 202-564-2501
Last EDR Contact: 12/23/2024
Next Scheduled EDR Contact: 04/14/2025
Data Release Frequency: Quarterly

GOVERNMENT RECORDS SEARCHED / DATA CURRENCY TRACKING

FTTS: FIFRA/ TSCA Tracking System - FIFRA (Federal Insecticide, Fungicide, & Rodenticide Act)/TSCA (Toxic Substances Control Act)
FTTS tracks administrative cases and pesticide enforcement actions and compliance activities related to FIFRA, TSCA and EPCRA (Emergency Planning and Community Right-to-Know Act). To maintain currency, EDR contacts the Agency on a quarterly basis.

Date of Government Version: 04/09/2009
Date Data Arrived at EDR: 04/16/2009
Date Made Active in Reports: 05/11/2009
Number of Days to Update: 25
Source: EPA/Office of Prevention, Pesticides and Toxic Substances
Telephone: 202-566-1667
Last EDR Contact: 08/18/2017
Next Scheduled EDR Contact: 12/04/2017
Data Release Frequency: No Update Planned

FTTS INSP: FIFRA/ TSCA Tracking System - FIFRA (Federal Insecticide, Fungicide, & Rodenticide Act)/TSCA (Toxic Substances Control Act)
A listing of FIFRA/TSCA Tracking System (FTTS) inspections and enforcements.

Date of Government Version: 04/09/2009
Date Data Arrived at EDR: 04/16/2009
Date Made Active in Reports: 05/11/2009
Number of Days to Update: 25
Source: EPA
Telephone: 202-566-1667
Last EDR Contact: 08/18/2017
Next Scheduled EDR Contact: 12/04/2017
Data Release Frequency: No Update Planned

MLTS: Material Licensing Tracking System
MLTS is maintained by the Nuclear Regulatory Commission and contains a list of approximately 8,100 sites which possess or use radioactive materials and which are subject to NRC licensing requirements. To maintain currency, EDR contacts the Agency on a quarterly basis.

Date of Government Version: 10/12/2024
Date Data Arrived at EDR: 10/17/2024
Date Made Active in Reports: 11/19/2024
Number of Days to Update: 33
Source: Nuclear Regulatory Commission
Telephone: 301-415-0717
Last EDR Contact: 01/09/2025
Next Scheduled EDR Contact: 04/28/2025
Data Release Frequency: Quarterly

COAL ASH DOE: Steam-Electric Plant Operation Data
A listing of power plants that store ash in surface ponds.

Date of Government Version: 12/31/2023
Date Data Arrived at EDR: 10/16/2024
Date Made Active in Reports: 01/14/2025
Number of Days to Update: 90
Source: Department of Energy
Telephone: 202-586-8719
Last EDR Contact: 11/20/2024
Next Scheduled EDR Contact: 03/10/2025
Data Release Frequency: Varies

COAL ASH EPA: Coal Combustion Residues Surface Impoundments List
A listing of coal combustion residues surface impoundments with high hazard potential ratings.

Date of Government Version: 01/12/2017
Date Data Arrived at EDR: 03/05/2019
Date Made Active in Reports: 11/11/2019
Number of Days to Update: 251
Source: Environmental Protection Agency
Telephone: N/A
Last EDR Contact: 11/20/2024
Next Scheduled EDR Contact: 03/10/2025
Data Release Frequency: Varies

PCB TRANSFORMER: PCB Transformer Registration Database
The database of PCB transformer registrations that includes all PCB registration submittals.

Date of Government Version: 09/13/2019
Date Data Arrived at EDR: 11/06/2019
Date Made Active in Reports: 02/10/2020
Number of Days to Update: 96
Source: Environmental Protection Agency
Telephone: 202-566-0517
Last EDR Contact: 01/30/2025
Next Scheduled EDR Contact: 05/12/2025
Data Release Frequency: Varies

RADINFO: Radiation Information Database
The Radiation Information Database (RADINFO) contains information about facilities that are regulated by U.S. Environmental Protection Agency (EPA) regulations for radiation and radioactivity.

Date of Government Version: 07/01/2019
Date Data Arrived at EDR: 07/01/2019
Date Made Active in Reports: 09/23/2019
Number of Days to Update: 84

Source: Environmental Protection Agency
Telephone: 202-343-9775
Last EDR Contact: 12/17/2024
Next Scheduled EDR Contact: 04/07/2025
Data Release Frequency: Quarterly

HIST FTTS: FIFRA/TSCA Tracking System Administrative Case Listing

A complete administrative case listing from the FIFRA/TSCA Tracking System (FTTS) for all ten EPA regions. The information was obtained from the National Compliance Database (NCDB). NCDB supports the implementation of FIFRA (Federal Insecticide, Fungicide, and Rodenticide Act) and TSCA (Toxic Substances Control Act). Some EPA regions are now closing out records. Because of that, and the fact that some EPA regions are not providing EPA Headquarters with updated records, it was decided to create a HIST FTTS database. It included records that may not be included in the newer FTTS database updates. This database is no longer updated.

Date of Government Version: 10/19/2006
Date Data Arrived at EDR: 03/01/2007
Date Made Active in Reports: 04/10/2007
Number of Days to Update: 40

Source: Environmental Protection Agency
Telephone: 202-564-2501
Last EDR Contact: 12/17/2007
Next Scheduled EDR Contact: 03/17/2008
Data Release Frequency: No Update Planned

HIST FTTS INSP: FIFRA/TSCA Tracking System Inspection & Enforcement Case Listing

A complete inspection and enforcement case listing from the FIFRA/TSCA Tracking System (FTTS) for all ten EPA regions. The information was obtained from the National Compliance Database (NCDB). NCDB supports the implementation of FIFRA (Federal Insecticide, Fungicide, and Rodenticide Act) and TSCA (Toxic Substances Control Act). Some EPA regions are now closing out records. Because of that, and the fact that some EPA regions are not providing EPA Headquarters with updated records, it was decided to create a HIST FTTS database. It included records that may not be included in the newer FTTS database updates. This database is no longer updated.

Date of Government Version: 10/19/2006
Date Data Arrived at EDR: 03/01/2007
Date Made Active in Reports: 04/10/2007
Number of Days to Update: 40

Source: Environmental Protection Agency
Telephone: 202-564-2501
Last EDR Contact: 12/17/2008
Next Scheduled EDR Contact: 03/17/2008
Data Release Frequency: No Update Planned

DOT OPS: Incident and Accident Data

Department of Transporation, Office of Pipeline Safety Incident and Accident data.

Date of Government Version: 10/04/2024
Date Data Arrived at EDR: 10/16/2024
Date Made Active in Reports: 12/06/2024
Number of Days to Update: 51

Source: Department of Transporation, Office of Pipeline Safety
Telephone: 202-366-4595
Last EDR Contact: 01/22/2025
Next Scheduled EDR Contact: 05/05/2025
Data Release Frequency: Quarterly

CONSENT: Superfund (CERCLA) Consent Decrees

Major legal settlements that establish responsibility and standards for cleanup at NPL (Superfund) sites. Released periodically by United States District Courts after settlement by parties to litigation matters.

Date of Government Version: 09/30/2024
Date Data Arrived at EDR: 10/09/2024
Date Made Active in Reports: 01/10/2025
Number of Days to Update: 93

Source: Department of Justice, Consent Decree Library
Telephone: Varies
Last EDR Contact: 12/30/2024
Next Scheduled EDR Contact: 04/14/2025
Data Release Frequency: Varies

BRS: Biennial Reporting System

The Biennial Reporting System is a national system administered by the EPA that collects data on the generation and management of hazardous waste. BRS captures detailed data from two groups: Large Quantity Generators (LQG) and Treatment, Storage, and Disposal Facilities.

Date of Government Version: 12/31/2021
Date Data Arrived at EDR: 03/09/2023
Date Made Active in Reports: 03/20/2023
Number of Days to Update: 11

Source: EPA/NTIS
Telephone: 800-424-9346
Last EDR Contact: 12/12/2024
Next Scheduled EDR Contact: 03/31/2025
Data Release Frequency: Biennially

INDIAN RESERV: Indian Reservations

This map layer portrays Indian administered lands of the United States that have any area equal to or greater than 640 acres.

Date of Government Version: 12/31/2014
Date Data Arrived at EDR: 07/14/2015
Date Made Active in Reports: 01/10/2017
Number of Days to Update: 546

Source: USGS
Telephone: 202-208-3710
Last EDR Contact: 12/30/2024
Next Scheduled EDR Contact: 04/14/2025
Data Release Frequency: Semi-Annually

FUSRAP: Formerly Utilized Sites Remedial Action Program

DOE established the Formerly Utilized Sites Remedial Action Program (FUSRAP) in 1974 to remediate sites where radioactive contamination remained from Manhattan Project and early U.S. Atomic Energy Commission (AEC) operations.

Date of Government Version: 03/03/2023
Date Data Arrived at EDR: 03/03/2023
Date Made Active in Reports: 06/09/2023
Number of Days to Update: 98

Source: Department of Energy
Telephone: 202-586-3559
Last EDR Contact: 01/23/2025
Next Scheduled EDR Contact: 05/12/2025
Data Release Frequency: Varies

UMTRA: Uranium Mill Tailings Sites

Uranium ore was mined by private companies for federal government use in national defense programs. When the mills shut down, large piles of the sand-like material (mill tailings) remain after uranium has been extracted from the ore. Levels of human exposure to radioactive materials from the piles are low; however, in some cases tailings were used as construction materials before the potential health hazards of the tailings were recognized.

Date of Government Version: 05/08/2024
Date Data Arrived at EDR: 08/14/2024
Date Made Active in Reports: 08/28/2024
Number of Days to Update: 14

Source: Department of Energy
Telephone: 505-845-0011
Last EDR Contact: 02/06/2025
Next Scheduled EDR Contact: 05/26/2025
Data Release Frequency: Varies

LEAD SMELTER 1: Lead Smelter Sites

A listing of former lead smelter site locations.

Date of Government Version: 12/19/2024
Date Data Arrived at EDR: 01/02/2025
Date Made Active in Reports: 01/21/2025
Number of Days to Update: 19

Source: Environmental Protection Agency
Telephone: 703-603-8787
Last EDR Contact: 02/03/2025
Next Scheduled EDR Contact: 04/07/2025
Data Release Frequency: Varies

LEAD SMELTER 2: Lead Smelter Sites

A list of several hundred sites in the U.S. where secondary lead smelting was done from 1931and 1964. These sites may pose a threat to public health through ingestion or inhalation of contaminated soil or dust

Date of Government Version: 04/05/2001
Date Data Arrived at EDR: 10/27/2010
Date Made Active in Reports: 12/02/2010
Number of Days to Update: 36

Source: American Journal of Public Health
Telephone: 703-305-6451
Last EDR Contact: 12/02/2009
Next Scheduled EDR Contact: N/A
Data Release Frequency: No Update Planned

US AIRS (AFS): Aerometric Information Retrieval System Facility Subsystem (AFS)

The database is a sub-system of Aerometric Information Retrieval System (AIRS). AFS contains compliance data on air pollution point sources regulated by the U.S. EPA and/or state and local air regulatory agencies. This information comes from source reports by various stationary sources of air pollution, such as electric power plants, steel mills, factories, and universities, and provides information about the air pollutants they produce. Action, air program, air program pollutant, and general level plant data. It is used to track emissions and compliance data from industrial plants.

Date of Government Version: 10/12/2016
Date Data Arrived at EDR: 10/26/2016
Date Made Active in Reports: 02/03/2017
Number of Days to Update: 100

Source: EPA
Telephone: 202-564-2496
Last EDR Contact: 09/26/2017
Next Scheduled EDR Contact: 01/08/2018
Data Release Frequency: Annually

US AIRS MINOR: Air Facility System Data
A listing of minor source facilities.

Date of Government Version: 10/12/2016
Date Data Arrived at EDR: 10/26/2016
Date Made Active in Reports: 02/03/2017
Number of Days to Update: 100

Source: EPA
Telephone: 202-564-2496
Last EDR Contact: 09/26/2017
Next Scheduled EDR Contact: 01/08/2018
Data Release Frequency: Annually

MINES VIOLATIONS: MSHA Violation Assessment Data
Mines violation and assessment information. Department of Labor, Mine Safety & Health Administration.

Date of Government Version: 10/01/2024
Date Data Arrived at EDR: 10/02/2024
Date Made Active in Reports: 10/09/2024
Number of Days to Update: 7

Source: DOL, Mine Safety & Health Admi
Telephone: 202-693-9424
Last EDR Contact: 02/19/2025
Next Scheduled EDR Contact: 06/02/2025
Data Release Frequency: Quarterly

US MINES: Mines Master Index File
Contains all mine identification numbers issued for mines active or opened since 1971. The data also includes violation information.

Date of Government Version: 11/01/2024
Date Data Arrived at EDR: 11/18/2024
Date Made Active in Reports: 02/11/2025
Number of Days to Update: 85

Source: Department of Labor, Mine Safety and Health Administration
Telephone: 303-231-5959
Last EDR Contact: 02/18/2025
Next Scheduled EDR Contact: 06/02/2025
Data Release Frequency: Semi-Annually

US MINES 2: Ferrous and Nonferrous Metal Mines Database Listing
This map layer includes ferrous (ferrous metal mines are facilities that extract ferrous metals, such as iron ore or molybdenum) and nonferrous (Nonferrous metal mines are facilities that extract nonferrous metals, such as gold, silver, copper, zinc, and lead) metal mines in the United States.

Date of Government Version: 05/02/2024
Date Data Arrived at EDR: 08/20/2024
Date Made Active in Reports: 10/09/2024
Number of Days to Update: 50

Source: USGS
Telephone: 703-648-7709
Last EDR Contact: 02/20/2025
Next Scheduled EDR Contact: 06/02/2025
Data Release Frequency: Varies

US MINES 3: Active Mines & Mineral Plants Database Listing
Active Mines and Mineral Processing Plant operations for commodities monitored by the Minerals Information Team of the USGS.

Date of Government Version: 04/14/2011
Date Data Arrived at EDR: 06/08/2011
Date Made Active in Reports: 09/13/2011
Number of Days to Update: 97

Source: USGS
Telephone: 703-648-7709
Last EDR Contact: 02/20/2025
Next Scheduled EDR Contact: 06/02/2025
Data Release Frequency: Varies

ABANDONED MINES: Abandoned Mines
An inventory of land and water impacted by past mining (primarily coal mining) is maintained by OSMRE to provide information needed to implement the Surface Mining Control and Reclamation Act of 1977 (SMCRA). The inventory contains information on the location, type, and extent of AML impacts, as well as, information on the cost associated with the reclamation of those problems. The inventory is based upon field surveys by State, Tribal, and OSMRE program officials. It is dynamic to the extent that it is modified as new problems are identified and existing problems are reclaimed.

Date of Government Version: 12/10/2024
Date Data Arrived at EDR: 12/11/2024
Date Made Active in Reports: 02/18/2025
Number of Days to Update: 69

Source: Department of Interior
Telephone: 202-208-2609
Last EDR Contact: 12/10/2024
Next Scheduled EDR Contact: 03/17/2025
Data Release Frequency: Quarterly

MINES MRDS: Mineral Resources Data System
Mineral Resources Data System

Date of Government Version: 06/04/2024
Date Data Arrived at EDR: 11/22/2024
Date Made Active in Reports: 02/18/2025
Number of Days to Update: 88

Source: USGS
Telephone: 703-648-6533
Last EDR Contact: 02/20/2025
Next Scheduled EDR Contact: 06/02/2025
Data Release Frequency: Varies

FINDS: Facility Index System/Facility Registry System
Facility Index System. FINDS contains both facility information and 'pointers' to other sources that contain more detail. EDR includes the following FINDS databases in this report: PCS (Permit Compliance System), AIRS (Aerometric Information Retrieval System), DOCKET (Enforcement Docket used to manage and track information on civil judicial enforcement cases for all environmental statutes), FURS (Federal Underground Injection Control), C-DOCKET (Criminal Docket System used to track criminal enforcement actions for all environmental statutes), FFIS (Federal Facilities Information System), STATE (State Environmental Laws and Statutes), and PADS (PCB Activity Data System).

Date of Government Version: 11/11/2024
Date Data Arrived at EDR: 11/20/2024
Date Made Active in Reports: 02/18/2025
Number of Days to Update: 90

Source: EPA
Telephone: (212) 637-3000
Last EDR Contact: 11/20/2024
Next Scheduled EDR Contact: 03/10/2025
Data Release Frequency: Quarterly

UXO: Unexploded Ordnance Sites
A listing of unexploded ordnance site locations

Date of Government Version: 09/06/2023
Date Data Arrived at EDR: 09/13/2023
Date Made Active in Reports: 12/11/2023
Number of Days to Update: 89

Source: Department of Defense
Telephone: 703-704-1564
Last EDR Contact: 01/06/2025
Next Scheduled EDR Contact: 04/21/2025
Data Release Frequency: Varies

DOCKET HWC: Hazardous Waste Compliance Docket Listing
A complete list of the Federal Agency Hazardous Waste Compliance Docket Facilities.

Date of Government Version: 05/06/2021
Date Data Arrived at EDR: 05/21/2021
Date Made Active in Reports: 08/11/2021
Number of Days to Update: 82

Source: Environmental Protection Agency
Telephone: 202-564-0527
Last EDR Contact: 02/12/2025
Next Scheduled EDR Contact: 06/02/2025
Data Release Frequency: Varies

ECHO: Enforcement & Compliance History Information
ECHO provides integrated compliance and enforcement information for about 800,000 regulated facilities nationwide.

Date of Government Version: 12/21/2024
Date Data Arrived at EDR: 12/27/2024
Date Made Active in Reports: 01/10/2025
Number of Days to Update: 14

Source: Environmental Protection Agency
Telephone: 202-564-2280
Last EDR Contact: 12/27/2024
Next Scheduled EDR Contact: 04/14/2025
Data Release Frequency: Quarterly

FUELS PROGRAM: EPA Fuels Program Registered Listing
This listing includes facilities that are registered under the Part 80 (Code of Federal Regulations) EPA Fuels Programs. All companies now are required to submit new and updated registrations.

Date of Government Version: 11/08/2024
Date Data Arrived at EDR: 11/08/2024
Date Made Active in Reports: 01/14/2025
Number of Days to Update: 67

Source: EPA
Telephone: 800-385-6164
Last EDR Contact: 02/13/2025
Next Scheduled EDR Contact: 05/26/2025
Data Release Frequency: Quarterly

PFAS NPL: Superfund Sites with PFAS Detections Information

EPA's Office of Land and Emergency Management and EPA Regional Offices maintain data describing what is known about site investigations, contamination, and remedial actions under the Comprehensive Environmental Response, Compensation, and Liability Act (CERCLA) where PFAS is present in the environment.

Date of Government Version: 12/30/2024
Date Data Arrived at EDR: 01/02/2025
Date Made Active in Reports: 01/10/2025
Number of Days to Update: 8

Source: Environmental Protection Agency
Telephone: 703-603-8895
Last EDR Contact: 02/20/2025
Next Scheduled EDR Contact: 04/14/2025
Data Release Frequency: Varies

PFAS FEDERAL SITES: Federal Sites PFAS Information

Several federal entities, such as the federal Superfund program, Department of Defense, National Aeronautics and Space Administration, Department of Transportation, and Department of Energy provided information for sites with known or suspected detections at federal facilities.

Date of Government Version: 12/30/2024
Date Data Arrived at EDR: 01/02/2025
Date Made Active in Reports: 01/10/2025
Number of Days to Update: 8

Source: Environmental Protection Agency
Telephone: 202-272-0167
Last EDR Contact: 02/20/2025
Next Scheduled EDR Contact: 04/14/2025
Data Release Frequency: Varies

PFAS TRIS: List of PFAS Added to the TRI

Section 7321 of the National Defense Authorization Act for Fiscal Year 2020 (NDAA) immediately added certain per- and polyfluoroalkyl substances (PFAS) to the list of chemicals covered by the Toxics Release Inventory (TRI) under Section 313 of the Emergency Planning and Community Right-to-Know Act (EPCRA) and provided a framework for additional PFAS to be added to TRI on an annual basis.

Date of Government Version: 12/30/2024
Date Data Arrived at EDR: 01/02/2025
Date Made Active in Reports: 01/10/2025
Number of Days to Update: 8

Source: Environmental Protection Agency
Telephone: 202-566-0250
Last EDR Contact: 02/20/2025
Next Scheduled EDR Contact: 04/14/2025
Data Release Frequency: Varies

PFAS TSCA: PFAS Manufacture and Imports Information

EPA issued the Chemical Data Reporting (CDR) Rule under the Toxic Substances Control Act (TSCA) and requires chemical manufacturers and facilities that manufacture or import chemical substances to report data to EPA. EPA publishes non-confidential business information (non-CBI) and includes descriptive information about each site, corporate parent, production volume, other manufacturing information, and processing and use information.

Date of Government Version: 12/30/2024
Date Data Arrived at EDR: 01/02/2025
Date Made Active in Reports: 01/10/2025
Number of Days to Update: 8

Source: Environmental Protection Agency
Telephone: 202-272-0167
Last EDR Contact: 02/20/2025
Next Scheduled EDR Contact: 04/14/2025
Data Release Frequency: Varies

PFAS RCRA MANIFEST: PFAS Transfers Identified In the RCRA Database Listing

To work around the lack of PFAS waste codes in the RCRA database, EPA developed the PFAS Transfers dataset by mining e-Manifest records containing at least one of these common PFAS keywords: PFAS, PFOA, PFOS, PERFL, AFFF, GENX, GEN-X (plus the VT waste codes). These keywords were searched for in the following text fields: Manifest handling instructions (MANIFEST_HANDLING_INSTR), Non-hazardous waste description (NON_HAZ_WASTE_DESCRIPTION), DOT printed information (DOT_PRINTED_INFORMATION), Waste line handling instructions (WASTE_LINE_HANDLING_INSTR), Waste residue comments (WASTE_RESIDUE_COMMENTS).

Date of Government Version: 12/30/2024
Date Data Arrived at EDR: 01/02/2025
Date Made Active in Reports: 01/10/2025
Number of Days to Update: 8

Source: Environmental Protection Agency
Telephone: 202-272-0167
Last EDR Contact: 02/20/2025
Next Scheduled EDR Contact: 04/14/2025
Data Release Frequency: Varies

PFAS ATSDR: PFAS Contamination Site Location Listing

PFAS contamination site locations from the Department of Health & Human Services, Center for Disease Control & Prevention. ATSDR is involved at a number of PFAS-related sites, either directly or through assisting state and federal partners. As of now, most sites are related to drinking water contamination connected with PFAS production facilities or fire training areas where aqueous film-forming firefighting foam (AFFF) was regularly used.

Date of Government Version: 06/24/2020
Date Data Arrived at EDR: 03/17/2021
Date Made Active in Reports: 11/08/2022
Number of Days to Update: 601

Source: Department of Health & Human Services
Telephone: 202-741-5770
Last EDR Contact: 01/16/2025
Next Scheduled EDR Contact: 05/05/2025
Data Release Frequency: Varies

PFAS WQP: Ambient Environmental Sampling for PFAS

The Water Quality Portal (WQP) is a part of a modernized repository storing ambient sampling data for all environmental media and tissue samples. A wide range of federal, state, tribal and local governments, academic and non-governmental organizations and individuals submit project details and sampling results to this public repository. The information is commonly used for research and assessments of environmental quality.

Date of Government Version: 12/13/2024
Date Data Arrived at EDR: 01/02/2025
Date Made Active in Reports: 01/10/2025
Number of Days to Update: 8

Source: Environmental Protection Agency
Telephone: 202-272-0167
Last EDR Contact: 02/20/2025
Next Scheduled EDR Contact: 04/14/2025
Data Release Frequency: Varies

PFAS PROJECT: NORTHEASTERN UNIVERSITY PFAS PROJECT

The PFAS Contamination Site Tracker records qualitative and quantitative data from each site in a chart, specifically examining discovery, contamination levels, government response, litigation, health impacts, media coverage, and community characteristics. All data presented in the chart were extracted from government websites, such as state health departments or the Environmental Protection Agency, and news articles.

Date of Government Version: 05/19/2023
Date Data Arrived at EDR: 04/05/2024
Date Made Active in Reports: 06/06/2024
Number of Days to Update: 62

Source: Social Science Environmental Health Research Institute
Telephone: N/A
Last EDR Contact: 12/05/2024
Next Scheduled EDR Contact: 03/17/2025
Data Release Frequency: Varies

PFAS NPDES: Clean Water Act Discharge Monitoring Information

Any discharger of pollutants to waters of the United States from a point source must have a National Pollutant Discharge Elimination System (NPDES) permit. The process for obtaining limits involves the regulated entity (permittee) disclosing releases in a NPDES permit application and the permitting authority (typically the state but sometimes EPA) deciding whether to require monitoring or monitoring with limits. Caveats and Limitations: Less than half of states have required PFAS monitoring for at least one of their permittees and fewer states have established PFAS effluent limits for permittees. New rulemakings have been initiated that may increase the number of facilities monitoring for PFAS in the future.

Date of Government Version: 12/30/2024
Date Data Arrived at EDR: 01/02/2025
Date Made Active in Reports: 01/14/2025
Number of Days to Update: 12

Source: Environmental Protection Agency
Telephone: 202-272-0167
Last EDR Contact: 01/02/2025
Next Scheduled EDR Contact: 04/14/2025
Data Release Frequency: Varies

PFAS ECHO: Facilities in Industries that May Be Handling PFAS Listing

Regulators and the public have expressed interest in knowing which regulated entities may be using PFAS. EPA has developed a dataset from various sources that show which industries may be handling PFAS. Approximately 120,000 facilities subject to federal environmental programs have operated or currently operate in industry sectors with processes that may involve handling and/or release of PFAS.

Date of Government Version: 12/30/2024
Date Data Arrived at EDR: 01/02/2025
Date Made Active in Reports: 01/10/2025
Number of Days to Update: 8

Source: Environmental Protection Agency
Telephone: 202-272-0167
Last EDR Contact: 02/20/2025
Next Scheduled EDR Contact: 04/14/2025
Data Release Frequency: Varies

PFAS ECHO FIRE TRAIN: Facilities in Industries that May Be Handling PFAS Listing

A list of fire training sites was added to the Industry Sectors dataset using a keyword search on the permitted facilitys name to identify sites where fire-fighting foam may have been used in training exercises. Additionally, you may view an example spreadsheet of the subset of fire training facility data, as well as the keywords used in selecting or deselecting a facility for the subset. as well as the keywords used in selecting or deselecting a facility for the subset. These keywords were tested to maximize accuracy in selecting facilities that may use fire-fighting foam in training exercises, however, due to the lack of a required reporting field in the data systems for designating fire training sites, this methodology may not identify all fire training sites or may potentially misidentify them.

Date of Government Version: 12/30/2024
Date Data Arrived at EDR: 01/02/2025
Date Made Active in Reports: 01/10/2025
Number of Days to Update: 8

Source: Environmental Protection Agency
Telephone: 202-272-0167
Last EDR Contact: 02/20/2025
Next Scheduled EDR Contact: 04/14/2025
Data Release Frequency: Varies

PFAS PT 139 AIRPORT: All Certified Part 139 Airports PFAS Information Listing

Since July 1, 2006, all certified part 139 airports are required to have fire-fighting foam onsite that meet military specifications (MIL-F-24385) (14 CFR 139.317). To date, these military specification fire-fighting foams are fluorinated and have been historically used for training and extinguishing. The 2018 FAA Reauthorization Act has a provision stating that no later than October 2021, FAA shall not require the use of fluorinated AFFF. This provision does not prohibit the use of fluorinated AFFF at Part 139 civilian airports; it only prohibits FAA from mandating its use. The Federal Aviation Administration?s document AC 150/5210-6D - Aircraft Fire Extinguishing Agents provides guidance on Aircraft Fire Extinguishing Agents, which includes Aqueous Film Forming Foam (AFFF).

Date of Government Version: 12/30/2024
Date Data Arrived at EDR: 01/02/2025
Date Made Active in Reports: 01/10/2025
Number of Days to Update: 8

Source: Environmental Protection Agency
Telephone: 202-272-0167
Last EDR Contact: 02/20/2025
Next Scheduled EDR Contact: 04/14/2025
Data Release Frequency: Varies

AQUEOUS FOAM NRC: Aqueous Foam Related Incidents Listing

The National Response Center (NRC) serves as an emergency call center that fields initial reports for pollution and railroad incidents and forwards that information to appropriate federal/state agencies for response. The spreadsheets posted to the NRC website contain initial incident data that has not been validated or investigated by a federal/state response agency. Response center calls from 1990 to the most recent complete calendar year where there was indication of Aqueous Film Forming Foam (AFFF) usage are included in this dataset. NRC calls may reference AFFF usage in the ?Material Involved? or ?Incident Description? fields.

Date of Government Version: 12/30/2024
Date Data Arrived at EDR: 01/02/2025
Date Made Active in Reports: 01/10/2025
Number of Days to Update: 8

Source: Environmental Protection Agency
Telephone: 202-267-2675
Last EDR Contact: 02/20/2025
Next Scheduled EDR Contact: 04/14/2025
Data Release Frequency: Varies

PCS ENF: Enforcement data

No description is available for this data

Date of Government Version: 12/31/2014
Date Data Arrived at EDR: 02/05/2015
Date Made Active in Reports: 03/06/2015
Number of Days to Update: 29

Source: EPA
Telephone: 202-564-2497
Last EDR Contact: 12/23/2024
Next Scheduled EDR Contact: 04/14/2025
Data Release Frequency: Varies

PCS: Permit Compliance System

PCS is a computerized management information system that contains data on National Pollutant Discharge Elimination System (NPDES) permit holding facilities. PCS tracks the permit, compliance, and enforcement status of NPDES facilities.

Date of Government Version: 12/16/2016
Date Data Arrived at EDR: 01/06/2017
Date Made Active in Reports: 03/10/2017
Number of Days to Update: 63

Source: EPA, Office of Water
Telephone: 202-564-2496
Last EDR Contact: 12/23/2024
Next Scheduled EDR Contact: 04/14/2025
Data Release Frequency: No Update Planned

BIOSOLIDS: ICIS-NPDES Biosolids Facility Data

The data reflects compliance information about facilities in the biosolids program.

Date of Government Version: 10/13/2024
Date Data Arrived at EDR: 10/16/2024
Date Made Active in Reports: 10/23/2024
Number of Days to Update: 7

Source: Environmental Protection Agency
Telephone: 202-564-4700
Last EDR Contact: 01/14/2025
Next Scheduled EDR Contact: 04/28/2025
Data Release Frequency: Varies

UST FINDER: UST Finder Database

EPA developed UST Finder, a web map application containing a comprehensive, state-sourced national map of underground storage tank (UST) and leaking UST (LUST) data. It provides the attributes and locations of active and closed USTs, UST facilities, and LUST sites from states and from Tribal lands and US territories . UST Finder contains information about proximity of UST facilities and LUST sites to: surface and groundwater public drinking water protection areas; estimated number of private domestic wells and number of people living nearby; and flooding and wildfires.

Date of Government Version: 06/08/2023
Date Data Arrived at EDR: 10/04/2023
Date Made Active in Reports: 01/18/2024
Number of Days to Update: 106

Source: Environmental Protection Agency
Telephone: 202-564-0394
Last EDR Contact: 02/06/2025
Next Scheduled EDR Contact: 05/19/2025
Data Release Frequency: Varies

UST FINDER RELEASE: UST Finder Releases Database

US EPA's UST Finder data is a national composite of leaking underground storage tanks. This data contains information about, and locations of, leaking underground storage tanks. Data was collected from state sources and standardized into a national profile by EPA's Office of Underground Storage Tanks, Office of Research and Development, and the Association of State and Territorial Solid Waste Management Officials.

Date of Government Version: 06/08/2023
Date Data Arrived at EDR: 10/31/2023
Date Made Active in Reports: 01/18/2024
Number of Days to Update: 79

Source: Environmental Protecton Agency
Telephone: 202-564-0394
Last EDR Contact: 02/06/2025
Next Scheduled EDR Contact: 05/19/2025
Data Release Frequency: Semi-Annually

E MANIFEST: Hazardous Waste Electronic Manifest System

EPA established a national system for tracking hazardous waste shipments electronically. This system, known as ?e-Manifest,? will modernize the nation?s cradle-to-grave hazardous waste tracking process while saving valuable time, resources, and dollars for industry and states.

Date of Government Version: 09/16/2024
Date Data Arrived at EDR: 09/17/2024
Date Made Active in Reports: 12/20/2024
Number of Days to Update: 94

Source: Environmental Protection Agency
Telephone: 833-501-6826
Last EDR Contact: 02/19/2025
Next Scheduled EDR Contact: 03/31/2025
Data Release Frequency: Varies

PFAS: PFAS Contamination Site Location Listing

DEC surveyed select businesses, fire departments, fire training centers, bulk storage facilities, airports, and Department of Defense (DoD) facilities. The responses to the survey have helped to determine if these entities used or stored materials containing PFOA/PFOS including AFFF and dispersants used in Teflon coating operations. The results of this survey will be updated periodically as additional responses are received..

Date of Government Version: 01/16/2019
Date Data Arrived at EDR: 05/08/2019
Date Made Active in Reports: 06/24/2019
Number of Days to Update: 47

Source: Department of Environmental Conservation
Telephone: 518-402-9020
Last EDR Contact: 01/30/2025
Next Scheduled EDR Contact: 05/12/2025
Data Release Frequency: Varies

PFAS 3: PFAS Environmental Site Remediation List

A list of records included in the Environmental Remediation database whose material is listed as Perfluorooctanoic Acid or Perfluorooctane Sulfonic Acid.

Date of Government Version: 11/04/2024
Date Data Arrived at EDR: 11/06/2024
Date Made Active in Reports: 01/22/2025
Number of Days to Update: 77

Source: Department of Environmental Conservation
Telephone: 518-402-9759
Last EDR Contact: 02/04/2025
Next Scheduled EDR Contact: 05/19/2025
Data Release Frequency: Varies

PFAS 2: New York State Inactive Landfill Initiative

A list of landfills that were investigated and the analytical results for PFOA and PFOS for those landfills. These data represent the landfills from the ILI database that were investigated.

Date of Government Version: 12/12/2022
Date Data Arrived at EDR: 08/10/2023
Date Made Active in Reports: 10/25/2023
Number of Days to Update: 76

Source: Department of Environmental Conservation
Telephone: 518-402-9662
Last EDR Contact: 01/23/2025
Next Scheduled EDR Contact: 05/12/2025
Data Release Frequency: Varies

AIRS: Air Emissions Data

Point source emissions inventory data.

Date of Government Version: 10/09/2024
Date Data Arrived at EDR: 11/05/2024
Date Made Active in Reports: 11/21/2024
Number of Days to Update: 16

Source: Department of Environmental Conservation
Telephone: 518-402-8452
Last EDR Contact: 01/09/2025
Next Scheduled EDR Contact: 04/28/2025
Data Release Frequency: Annually

COAL ASH: Coal Ash Disposal Site Listing

A listing of coal ash disposal site locations.

Date of Government Version: 09/26/2024
Date Data Arrived at EDR: 10/01/2024
Date Made Active in Reports: 12/16/2024
Number of Days to Update: 76

Source: Department of Environmental Conservation
Telephone: 518-402-8660
Last EDR Contact: 12/17/2024
Next Scheduled EDR Contact: 04/07/2025
Data Release Frequency: Quarterly

DRYCLEANERS: Registered Drycleaners

A listing of all registered drycleaning facilities.

Date of Government Version: 08/29/2024
Date Data Arrived at EDR: 08/29/2024
Date Made Active in Reports: 09/03/2024
Number of Days to Update: 5

Source: Department of Environmental Conservation
Telephone: 518-402-8403
Last EDR Contact: 11/27/2024
Next Scheduled EDR Contact: 03/17/2025
Data Release Frequency: Annually

E DESIGNATION: E DESIGNATION SITE LISTING

The (E (Environmental)) designation would ensure that sampling and remediation take place on the subject properties, and would avoid any significant impacts related to hazardous materials at these locations. The (E) designations would require that the fee owner of the sites conduct a testing and sampling protocol, and remediation where appropriate, to the satisfaction of the NYCDEP before the issuance of a building permit by the Department of Buildings pursuant to the provisions of Section 11-15 of the Zoning Resolution (Environmental Requirements). The (E) designations also include a mandatory construction-related health and safety plan which must be approved by NYCDEP.

Date of Government Version: 08/19/2024
Date Data Arrived at EDR: 09/10/2024
Date Made Active in Reports: 11/22/2024
Number of Days to Update: 73

Source: New York City Department of City Planning
Telephone: 718-595-6658
Last EDR Contact: 12/19/2024
Next Scheduled EDR Contact: 03/24/2025
Data Release Frequency: Semi-Annually

FIN ASSURANCE 1: Financial Assurance Information Listing

Financial assurance information.

Date of Government Version: 12/11/2024
Date Data Arrived at EDR: 12/18/2024
Date Made Active in Reports: 01/22/2025
Number of Days to Update: 35

Source: Department of Environmental Conservation
Telephone: 518-402-8660
Last EDR Contact: 12/17/2024
Next Scheduled EDR Contact: 04/07/2025
Data Release Frequency: Quarterly

FIN ASSURANCE 2: Financial Assurance Information Listing

A listing of financial assurance information for hazardous waste facilities. Financial assurance is intended to ensure that resources are available to pay for the cost of closure, post-closure care, and corrective measures if the owner or operator of a regulated facility is unable or unwilling to pay.

Date of Government Version: 08/30/2024
Date Data Arrived at EDR: 08/30/2024
Date Made Active in Reports: 09/13/2024
Number of Days to Update: 14

Source: Department of Environmental Conservation
Telephone: 518-402-8712
Last EDR Contact: 11/27/2024
Next Scheduled EDR Contact: 03/17/2025
Data Release Frequency: Varies

HSWDS: Hazardous Substance Waste Disposal Site Inventory

The list includes any known or suspected hazardous substance waste disposal sites. Also included are sites delisted from the Registry of Inactive Hazardous Waste Disposal Sites and non-Registry sites that U.S. EPA Preliminary Assessment (PA) reports or Site Investigation (SI) reports were prepared. Hazardous Substance Waste Disposal Sites are eligible to be Superfund sites now that the New York State Superfund has been refinanced and changed. This means that the study inventory has served its purpose and will no longer be maintained as a separate entity. The last version of the study inventory is frozen in time. The sites on the study will not automatically be made Superfund sites, rather each site will be further evaluated for listing on the Registry. So overtime they will be added to the registry or not.

Date of Government Version: 01/01/2003
Date Data Arrived at EDR: 10/20/2006
Date Made Active in Reports: 11/30/2006
Number of Days to Update: 41

Source: Department of Environmental Conservation
Telephone: 518-402-9564
Last EDR Contact: 05/26/2009
Next Scheduled EDR Contact: 08/24/2009
Data Release Frequency: No Update Planned

NYC LEAD: Lead-based Paint Testing Results

The results of the inspections for all classrooms serving students under six in applicable buildings. Identifies all classrooms, whether there was observation of peeling paint, and if there was, standard response protocol was followed.

Date of Government Version: 07/10/2024
Date Data Arrived at EDR: 07/30/2024
Date Made Active in Reports: 10/17/2024
Number of Days to Update: 79

Source: New York City Department of Education
Telephone: 212-374-5141
Last EDR Contact: 01/28/2025
Next Scheduled EDR Contact: 05/12/2025
Data Release Frequency: Varies

NYC LEAD 2: Recent Lead Paint Violations

Pursuant to New York City?s Housing Maintenance Code, the Department of Housing Preservation and Development (HPD) issues violations against conditions in rental dwelling units that have been verified to violate the New York City Housing Maintenance Code (HMC) or the New York State Multiple Dwelling Law (MDL). Violations are issued when an inspection verifies that a violation of the HMC or MDL exists. It is closed when the violation is corrected, as observed/verified by HPD or as certified by the landlord.

Date of Government Version: 10/28/2024
Date Data Arrived at EDR: 10/30/2024
Date Made Active in Reports: 01/22/2025
Number of Days to Update: 84

Source: New York City Department of Housing Preservation & Development
Telephone: 212-863-8200
Last EDR Contact: 01/28/2025
Next Scheduled EDR Contact: 05/12/2025
Data Release Frequency: Varies

NY MANIFEST: Facility and Manifest Data

Manifest is a document that lists and tracks hazardous waste from the generator through transporters to a TSD facility.

Date of Government Version: 12/31/2019
Date Data Arrived at EDR: 11/30/2023
Date Made Active in Reports: 12/01/2023
Number of Days to Update: 1

Source: Department of Environmental Conservation
Telephone: 518-402-8651
Last EDR Contact: 01/23/2025
Next Scheduled EDR Contact: 05/05/2025
Data Release Frequency: Quarterly

SPDES: State Pollutant Discharge Elimination System

New York State has a state program which has been approved by the United States Environmental Protection Agency for the control of wastewater and stormwater discharges in accordance with the Clean Water Act. Under New York State law the program is known as the State Pollutant Discharge Elimination System (SPDES) and is broader in scope than that required by the Clean Water Act in that it controls point source discharges to groundwaters as well as surface waters.

Date of Government Version: 10/10/2024
Date Data Arrived at EDR: 11/08/2024
Date Made Active in Reports: 12/02/2024
Number of Days to Update: 24

Source: Department of Environmental Conservation
Telephone: 518-402-8233
Last EDR Contact: 01/09/2025
Next Scheduled EDR Contact: 04/28/2025
Data Release Frequency: No Update Planned

VAPOR REOPENED: Vapor Intrusion Legacy Site List

New York is currently re-evaluating previous assumptions and decisions regarding the potential for soil vapor intrusion exposures at sites. As a result, all past, current, and future contaminated sites will be evaluated to determine whether these sites have the potential for exposures related to soil vapor intrusion.

Date of Government Version: 01/01/2022
Date Data Arrived at EDR: 02/08/2022
Date Made Active in Reports: 05/06/2022
Number of Days to Update: 87

Source: Department of Environmenal Conservation
Telephone: 518-402-9814
Last EDR Contact: 02/06/2025
Next Scheduled EDR Contact: 05/19/2025
Data Release Frequency: Varies

UIC: Underground Injection Control Wells

A listing of enhanced oil recovery underground injection wells.

Date of Government Version: 11/19/2024
Date Data Arrived at EDR: 11/20/2024
Date Made Active in Reports: 02/14/2025
Number of Days to Update: 86

Source: Department of Environmental Conservation
Telephone: 518-402-8056
Last EDR Contact: 11/20/2024
Next Scheduled EDR Contact: 03/10/2025
Data Release Frequency: Quarterly

COOLING TOWERS: Registered Cooling Towers

This data includes the location of cooling towers registered with New York State. The data is self-reported by owners/property managers of cooling towers in service in New York State. In August 2015, the New York State Department of Health released emergency regulations requiring the owners of cooling towers to register them with New York State.

Date of Government Version: 10/01/2024
Date Data Arrived at EDR: 10/08/2024
Date Made Active in Reports: 12/23/2024
Number of Days to Update: 76

Source: Department of Health
Telephone: 518-402-7650
Last EDR Contact: 01/07/2025
Next Scheduled EDR Contact: 04/21/2025
Data Release Frequency: Varies

NYC LAND USE: New York City Land Use Information
Land use colors

Date of Government Version: 06/18/2024
Date Data Arrived at EDR: 09/10/2024
Date Made Active in Reports: 11/25/2024
Number of Days to Update: 76

Source: New York City Department of City Planning
Telephone: 212-720-3300
Last EDR Contact: 12/09/2024
Next Scheduled EDR Contact: 03/24/2025
Data Release Frequency: Varies

MGP: Manufactured Gas Plants Listing
From the late 1800's to the mid 1900's, hundreds of manufactured gas plants across New York State supplied homes and industry with fuel for heating, cooking, and lighting. Today, the New York State DEC is overseeing the investigation and cleanup of contamination left behind from these plants.

Date of Government Version: 08/28/2024
Date Data Arrived at EDR: 08/28/2024
Date Made Active in Reports: 10/01/2024
Number of Days to Update: 34

Source: Department of Environmental Conservation
Telephone: 518-402-9662
Last EDR Contact: 11/27/2024
Next Scheduled EDR Contact: 03/17/2025
Data Release Frequency: Varies

ILI: New York State Inactive Landfill Initiative
A solid waste site priority list of mitigation and remedial activities to address sites causing, or substantially contributing to, impairments of drinking water quality. Inactive solid waste disposal sites, primarily landfills, and their potential impact on New York?s drinking water resources from site-related contaminants, with a focus on emerging contaminants.

Date of Government Version: 05/16/2024
Date Data Arrived at EDR: 05/30/2024
Date Made Active in Reports: 08/26/2024
Number of Days to Update: 88

Source: Department of Environmental Conservation
Telephone: 518-402-8671
Last EDR Contact: 02/10/2025
Next Scheduled EDR Contact: 05/12/2025
Data Release Frequency: Varies

NYC OER: OER Cleanup Sites Listing
Properties remediated under OER's oversight, both in the E-Designation program and the NYC Voluntary Cleanup Program. Includes sites completed and in progress.

Date of Government Version: 09/03/2024
Date Data Arrived at EDR: 09/04/2024
Date Made Active in Reports: 11/15/2024
Number of Days to Update: 72

Source: Office of Environmental Remediation
Telephone: 212-788-8841
Last EDR Contact: 12/04/2024
Next Scheduled EDR Contact: 03/17/2025
Data Release Frequency: Varies

EDR HIGH RISK HISTORICAL RECORDS

EDR Exclusive Records

EDR MGP: EDR Proprietary Manufactured Gas Plants
The EDR Proprietary Manufactured Gas Plant Database includes records of coal gas plants (manufactured gas plants) compiled by EDR's researchers. Manufactured gas sites were used in the United States from the 1800's to 1950's to produce a gas that could be distributed and used as fuel. These plants used whale oil, rosin, coal, or a mixture of coal, oil, and water that also produced a significant amount of waste. Many of the byproducts of the gas production, such as coal tar (oily waste containing volatile and non-volatile chemicals), sludges, oils and other compounds are potentially hazardous to human health and the environment. The byproduct from this process was frequently disposed of directly at the plant site and can remain or spread slowly, serving as a continuous source of soil and groundwater contamination.

Date of Government Version: N/A
Date Data Arrived at EDR: N/A
Date Made Active in Reports: N/A
Number of Days to Update: N/A

Source: EDR, Inc.
Telephone: N/A
Last EDR Contact: N/A
Next Scheduled EDR Contact: N/A
Data Release Frequency: No Update Planned

EDR Hist Auto: EDR Exclusive Historical Auto Stations

EDR has searched selected national collections of business directories and has collected listings of potential gas station/filling station/service station sites that were available to EDR researchers. EDR's review was limited to those categories of sources that might, in EDR's opinion, include gas station/filling station/service station establishments. The categories reviewed included, but were not limited to gas, gas station, gasoline station, filling station, auto, automobile repair, auto service station, service station, etc. This database falls within a category of information EDR classifies as "High Risk Historical Records", or HRHR. EDR's HRHR effort presents unique and sometimes proprietary data about past sites and operations that typically create environmental concerns, but may not show up in current government records searches.

Date of Government Version: N/A
Date Data Arrived at EDR: N/A
Date Made Active in Reports: N/A
Number of Days to Update: N/A

Source: EDR, Inc.
Telephone: N/A
Last EDR Contact: N/A
Next Scheduled EDR Contact: N/A
Data Release Frequency: Varies

EDR Hist Cleaner: EDR Exclusive Historical Cleaners

EDR has searched selected national collections of business directories and has collected listings of potential dry cleaner sites that were available to EDR researchers. EDR's review was limited to those categories of sources that might, in EDR's opinion, include dry cleaning establishments. The categories reviewed included, but were not limited to dry cleaners, cleaners, laundry, laundromat, cleaning/laundry, wash & dry etc. This database falls within a category of information EDR classifies as "High Risk Historical Records", or HRHR. EDR's HRHR effort presents unique and sometimes proprietary data about past sites and operations that typically create environmental concerns, but may not show up in current government records searches.

Date of Government Version: N/A
Date Data Arrived at EDR: N/A
Date Made Active in Reports: N/A
Number of Days to Update: N/A

Source: EDR, Inc.
Telephone: N/A
Last EDR Contact: N/A
Next Scheduled EDR Contact: N/A
Data Release Frequency: Varies

EDR RECOVERED GOVERNMENT ARCHIVES

Exclusive Recovered Govt. Archives

RGA HWS: Recovered Government Archive State Hazardous Waste Facilities List

The EDR Recovered Government Archive State Hazardous Waste database provides a list of SHWS incidents derived from historical databases and includes many records that no longer appear in current government lists. Compiled from Records formerly available from the Department of Environmental Conservation in New York.

Date of Government Version: N/A
Date Data Arrived at EDR: 07/01/2013
Date Made Active in Reports: 12/30/2013
Number of Days to Update: 182

Source: Department of Environmental Conservation
Telephone: N/A
Last EDR Contact: 06/01/2012
Next Scheduled EDR Contact: N/A
Data Release Frequency: Varies

RGA LF: Recovered Government Archive Solid Waste Facilities List

The EDR Recovered Government Archive Landfill database provides a list of landfills derived from historical databases and includes many records that no longer appear in current government lists. Compiled from Records formerly available from the Department of Environmental Conservation in New York.

Date of Government Version: N/A
Date Data Arrived at EDR: 07/01/2013
Date Made Active in Reports: 01/10/2014
Number of Days to Update: 193

Source: Department of Environmental Conservation
Telephone: N/A
Last EDR Contact: 06/01/2012
Next Scheduled EDR Contact: N/A
Data Release Frequency: Varies

GOVERNMENT RECORDS SEARCHED / DATA CURRENCY TRACKING

COUNTY RECORDS

CORTLAND COUNTY:

AST - CORTLAND: Cortland County Storage Tank Listing
A listing of aboveground storage tank sites located in Cortland County.

Date of Government Version: 08/20/2019
Date Data Arrived at EDR: 08/20/2019
Date Made Active in Reports: 10/16/2019
Number of Days to Update: 57

Source: Cortland County Health Department
Telephone: 607-753-5035
Last EDR Contact: 01/16/2025
Next Scheduled EDR Contact: 05/05/2025
Data Release Frequency: Quarterly

UST - CORTLAND: Cortland County Storage Tank Listing
A listing of underground storage tank sites located in Cortland County.

Date of Government Version: 08/20/2019
Date Data Arrived at EDR: 08/20/2019
Date Made Active in Reports: 10/16/2019
Number of Days to Update: 57

Source: Cortland County Health Department
Telephone: 607-753-5035
Last EDR Contact: 01/16/2025
Next Scheduled EDR Contact: 05/05/2025
Data Release Frequency: Quarterly

NASSAU COUNTY:

AST - NASSAU: Registered Tank Database
A listing of aboveground storage tank sites located in Nassau County.

Date of Government Version: 11/27/2023
Date Data Arrived at EDR: 11/28/2023
Date Made Active in Reports: 02/06/2024
Number of Days to Update: 70

Source: Nassau County Health Department
Telephone: 516-571-3314
Last EDR Contact: 01/16/2025
Next Scheduled EDR Contact: 05/05/2025
Data Release Frequency: No Update Planned

AST NCFM: Storage Tank Database
A listing of aboveground storage tank sites located in Nassau County.

Date of Government Version: 02/15/2011
Date Data Arrived at EDR: 02/23/2011
Date Made Active in Reports: 03/29/2011
Number of Days to Update: 34

Source: Nassau County Office of the Fire Marshal
Telephone: 516-572-1000
Last EDR Contact: 02/12/2025
Next Scheduled EDR Contact: 05/05/2025
Data Release Frequency: Varies

TANKS NASSAU: Registered Tank Database in Nassau County
A listing of facilities in Nassau County with storage tanks.

Date of Government Version: 11/27/2023
Date Data Arrived at EDR: 11/28/2023
Date Made Active in Reports: 02/06/2024
Number of Days to Update: 70

Source: Nassau County Department of Health
Telephone: 516-227-9691
Last EDR Contact: 01/16/2025
Next Scheduled EDR Contact: 05/05/2025
Data Release Frequency: No Update Planned

UST - NASSAU: Registered Tank Database
A listing of underground storage tank sites located in Nassau County.

Date of Government Version: 11/27/2023
Date Data Arrived at EDR: 11/28/2023
Date Made Active in Reports: 02/06/2024
Number of Days to Update: 70

Source: Nassau County Health Department
Telephone: 516-571-3314
Last EDR Contact: 01/16/2025
Next Scheduled EDR Contact: 05/05/2025
Data Release Frequency: No Update Planned

UST NCFM: Storage Tank Database
A listing of underground storage tank sites located in Nassau County.

Date of Government Version: 02/15/2011
Date Data Arrived at EDR: 02/23/2011
Date Made Active in Reports: 03/29/2011
Number of Days to Update: 34

Source: Nassau County Office of the Fire Marshal
Telephone: 516-572-1000
Last EDR Contact: 02/12/2025
Next Scheduled EDR Contact: 05/05/2025
Data Release Frequency: Varies

ROCKLAND COUNTY:

AST - ROCKLAND: Petroleum Bulk Storage Database
A listing of aboveground storage tank sites located in Rockland County. Rockland County?s Petroleum Bulk Storage (PBS) program is no longer in service. All related operations/duties are now wholly overseen by the New York State Dept. of Environmental Conservation (NYSDEC).

Date of Government Version: 02/02/2017
Date Data Arrived at EDR: 03/17/2017
Date Made Active in Reports: 09/22/2017
Number of Days to Update: 189

Source: Rockland County Health Department
Telephone: 914-364-2605
Last EDR Contact: 02/20/2025
Next Scheduled EDR Contact: 06/09/2025
Data Release Frequency: No Update Planned

UST - ROCKLAND: Petroleum Bulk Storage Database
A listing of underground storage tank sites located in Rockland County. Rockland County?s Petroleum Bulk Storage (PBS) program is no longer in service. All related operations/duties are now wholly overseen by the New York State Dept. of Environmental Conservation (NYSDEC).

Date of Government Version: 02/02/2017
Date Data Arrived at EDR: 03/17/2017
Date Made Active in Reports: 09/22/2017
Number of Days to Update: 189

Source: Rockland County Health Department
Telephone: 914-364-2605
Last EDR Contact: 02/20/2025
Next Scheduled EDR Contact: 06/09/2025
Data Release Frequency: No Update Planned

SUFFOLK COUNTY:

AST - SUFFOLK: Storage Tank Database
A listing of aboveground storage tank sites located in Suffolk County.

Date of Government Version: 06/28/2018
Date Data Arrived at EDR: 12/06/2018
Date Made Active in Reports: 02/07/2019
Number of Days to Update: 63

Source: Suffolk County Department of Health Services
Telephone: 631-854-2521
Last EDR Contact: 01/16/2025
Next Scheduled EDR Contact: 05/05/2025
Data Release Frequency: No Update Planned

TANKS SUFFOLK: Storage Tank Database
This county is not included in the state?s database. These are facilities that have no tank information in the storage tank database.

Date of Government Version: 06/28/2018
Date Data Arrived at EDR: 02/05/2019
Date Made Active in Reports: 03/08/2019
Number of Days to Update: 31

Source: Department of Health Services
Telephone: 631-854-2516
Last EDR Contact: 01/16/2025
Next Scheduled EDR Contact: 05/05/2025
Data Release Frequency: Varies

UST - SUFFOLK: Storage Tank Database
A listing of underground storage tank sites located in Suffolk County.

Date of Government Version: 06/28/2018
Date Data Arrived at EDR: 12/06/2018
Date Made Active in Reports: 02/07/2019
Number of Days to Update: 63

Source: Suffolk County Department of Health Services
Telephone: 631-854-2521
Last EDR Contact: 01/16/2025
Next Scheduled EDR Contact: 05/05/2025
Data Release Frequency: No Update Planned

WESTCHESTER COUNTY:

AST - WESTCHESTER: Listing of Storage Tanks
A listing of aboveground storage tank sites located in Westchester County.

Date of Government Version: 11/13/2024
Date Data Arrived at EDR: 11/14/2024
Date Made Active in Reports: 02/07/2025
Number of Days to Update: 85

Source: Westchester County Department of Health
Telephone: 914-813-5161
Last EDR Contact: 01/23/2025
Next Scheduled EDR Contact: 05/05/2025
Data Release Frequency: Semi-Annually

UST - WESTCHESTER: Listing of Storage Tanks
A listing of underground storage tank sites located in Westchester County.

Date of Government Version: 11/13/2024
Date Data Arrived at EDR: 11/14/2024
Date Made Active in Reports: 02/07/2025
Number of Days to Update: 85

Source: Westchester County Department of Health
Telephone: 914-813-5161
Last EDR Contact: 01/23/2025
Next Scheduled EDR Contact: 05/05/2025
Data Release Frequency: Semi-Annually

OTHER DATABASE(S)

Depending on the geographic area covered by this report, the data provided in these specialty databases may or may not be complete. For example, the existence of wetlands information data in a specific report does not mean that all wetlands in the area covered by the report are included. Moreover, the absence of any reported wetlands information does not necessarily mean that wetlands do not exist in the area covered by the report.

CT MANIFEST: Hazardous Waste Manifest Data
Facility and manifest data. Manifest is a document that lists and tracks hazardous waste from the generator through transporters to a tsd facility.

Date of Government Version: 11/04/2024
Date Data Arrived at EDR: 11/05/2024
Date Made Active in Reports: 01/27/2025
Number of Days to Update: 83

Source: Department of Energy & Environmental Protection
Telephone: 860-424-3375
Last EDR Contact: 02/04/2025
Next Scheduled EDR Contact: 05/19/2025
Data Release Frequency: No Update Planned

NJ MANIFEST: Manifest Information
Hazardous waste manifest information.

Date of Government Version: 12/31/2018
Date Data Arrived at EDR: 04/10/2019
Date Made Active in Reports: 05/16/2019
Number of Days to Update: 36

Source: Department of Environmental Protection
Telephone: N/A
Last EDR Contact: 12/23/2024
Next Scheduled EDR Contact: 04/14/2025
Data Release Frequency: Annually

PA MANIFEST: Manifest Information
Hazardous waste manifest information.

Date of Government Version: 06/30/2018
Date Data Arrived at EDR: 07/19/2019
Date Made Active in Reports: 09/10/2019
Number of Days to Update: 53

Source: Department of Environmental Protection
Telephone: 717-783-8990
Last EDR Contact: 01/06/2025
Next Scheduled EDR Contact: 04/21/2025
Data Release Frequency: Annually

RI MANIFEST: Manifest information
Hazardous waste manifest information

Date of Government Version: 12/31/2020
Date Data Arrived at EDR: 11/30/2021
Date Made Active in Reports: 02/18/2022
Number of Days to Update: 80

Source: Department of Environmental Management
Telephone: 401-222-2797
Last EDR Contact: 02/06/2025
Next Scheduled EDR Contact: 05/26/2025
Data Release Frequency: Annually

VT MANIFEST: Hazardous Waste Manifest Data
Hazardous waste manifest information.

Date of Government Version: 10/28/2019
Date Data Arrived at EDR: 10/29/2019
Date Made Active in Reports: 01/09/2020
Number of Days to Update: 72

Source: Department of Environmental Conservation
Telephone: 802-241-3443
Last EDR Contact: 01/06/2025
Next Scheduled EDR Contact: 04/21/2025
Data Release Frequency: Annually

WI MANIFEST: Manifest Information
Hazardous waste manifest information.

Date of Government Version: 05/31/2018
Date Data Arrived at EDR: 06/19/2019
Date Made Active in Reports: 09/03/2019
Number of Days to Update: 76

Source: Department of Natural Resources
Telephone: N/A
Last EDR Contact: 11/27/2024
Next Scheduled EDR Contact: 03/17/2025
Data Release Frequency: Annually

Oil/Gas Pipelines
Source: Endeavor Business Media
Petroleum Bundle (Crude Oil, Refined Products, Petrochemicals, Gas Liquids (LPG/NGL), and Specialty Gases (Miscellaneous)) N = Natural Gas Bundle (Natural Gas, Gas Liquids (LPG/NGL), and Specialty Gases (Miscellaneous)). This map includes information copyrighted by Endeavor Business Media. This information is provided on a best effort basis and Endeavor Business Media does not guarantee its accuracy nor warrant its fitness for any particular purpose. Such information has been reprinted with the permission of Endeavor Business Media.

Electric Power Transmission Line Data
Source: Endeavor Business Media
This map includes information copyrighted by Endeavor Business Media. This information is provided on a best effort basis and Endeavor Business Media does not guarantee its accuracy nor warrant its fitness for any particular purpose. Such information has been reprinted with the permission of Endeavor Business Media.

Sensitive Receptors: There are individuals deemed sensitive receptors due to their fragile immune systems and special sensitivity to environmental discharges. These sensitive receptors typically include the elderly, the sick, and children. While the location of all sensitive receptors cannot be determined, EDR indicates those buildings and facilities - schools, daycares, hospitals, medical centers, and nursing homes - where individuals who are sensitive receptors are likely to be located.

AHA Hospitals:
Source: American Hospital Association, Inc.
Telephone: 312-280-5991
The database includes a listing of hospitals based on the American Hospital Association's annual survey of hospitals.

Medical Centers: Provider of Services Listing
Source: Centers for Medicare & Medicaid Services
Telephone: 410-786-3000
A listing of hospitals with Medicare provider number, produced by Centers of Medicare & Medicaid Services, a federal agency within the U.S. Department of Health and Human Services.

Nursing Homes
Source: National Institutes of Health
Telephone: 301-594-6248
Information on Medicare and Medicaid certified nursing homes in the United States.

Public Schools
Source: National Center for Education Statistics
Telephone: 202-502-7300
The National Center for Education Statistics' primary database on elementary and secondary public education in the United States. It is a comprehensive, annual, national statistical database of all public elementary and secondary schools and school districts, which contains data that are comparable across all states.

GOVERNMENT RECORDS SEARCHED / DATA CURRENCY TRACKING

Private Schools
Source: National Center for Education Statistics
Telephone: 202-502-7300
The National Center for Education Statistics' primary database on private school locations in the United States.
Daycare Centers: Day Care Providers
Source: Department of Health
Telephone: 212-676-2444

Flood Zone Data: This data was obtained from the Federal Emergency Management Agency (FEMA). It depicts 100-year and 500-year flood zones as defined by FEMA. It includes the National Flood Hazard Layer (NFHL) which incorporates Flood Insurance Rate Map (FIRM) data and Q3 data from FEMA in areas not covered by NFHL.
Source: FEMA
Telephone: 877-336-2627
Date of Government Version: 2003, 2015

NWI: National Wetlands Inventory. This data, available in select counties across the country, was obtained by EDR in 2002, 2005, 2010 and 2015 from the U.S. Fish and Wildlife Service.

State Wetlands Data: Freshwater Wetlands
Source: Department of Environmental Conservation
Telephone: 518-402-8961

Current USGS 7.5 Minute Topographic Map
Source: U.S. Geological Survey

STREET AND ADDRESS INFORMATION

© 2015 TomTom North America, Inc. All rights reserved. This material is proprietary and the subject of copyright protection and other intellectual property rights owned by or licensed to Tele Atlas North America, Inc. The use of this material is subject to the terms of a license agreement. You will be held liable for any unauthorized copying or disclosure of this material.

GEOCHECK ®- PHYSICAL SETTING SOURCE ADDENDUM

TARGET PROPERTY ADDRESS

100 MAIN STREET
100 MAIN STREET
WHITE PLAINS, NY 10601

TARGET PROPERTY COORDINATES

Latitude (North):	41.03164 - 41° 1' 53.90''
Longitude (West):	73.770797 - 73° 46' 14.87''
Universal Tranverse Mercator:	Zone 18
UTM X (Meters):	603332.3
UTM Y (Meters):	4542785.0
Elevation:	197 ft. above sea level

USGS TOPOGRAPHIC MAP

Target Property Map:	14142197 WHITE PLAINS, NY
Version Date:	2019
Northeast Map:	20023960 GLENVILLE, CT
Version Date:	2021

EDR's GeoCheck Physical Setting Source Addendum is provided to assist the environmental professional in forming an opinion about the impact of potential contaminant migration.

Assessment of the impact of contaminant migration generally has two principle investigative components:

1. Groundwater flow direction, and
2. Groundwater flow velocity.

Groundwater flow direction may be impacted by surface topography, hydrology, hydrogeology, characteristics of the soil, and nearby wells. Groundwater flow velocity is generally impacted by the nature of the geologic strata.

GEOCHECK® - PHYSICAL SETTING SOURCE SUMMARY

GROUNDWATER FLOW DIRECTION INFORMATION

Groundwater flow direction for a particular site is best determined by a qualified environmental professional using site-specific well data. If such data is not reasonably ascertainable, it may be necessary to rely on other sources of information, such as surface topographic information, hydrologic information, hydrogeologic data collected on nearby properties, and regional groundwater flow information (from deep aquifers).

TOPOGRAPHIC INFORMATION

Surface topography may be indicative of the direction of surficial groundwater flow. This information can be used to assist the environmental professional in forming an opinion about the impact of nearby contaminated properties or, should contamination exist on the target property, what downgradient sites might be impacted.

TARGET PROPERTY TOPOGRAPHY

General Topographic Gradient: General West

SURROUNDING TOPOGRAPHY: ELEVATION PROFILES



Source: Topography has been determined from the USGS 7.5' Digital Elevation Model and should be evaluated on a relative (not an absolute) basis. Relative elevation information between sites of close proximity should be field verified.

GEOCHECK® - PHYSICAL SETTING SOURCE SUMMARY

HYDROLOGIC INFORMATION

Surface water can act as a hydrologic barrier to groundwater flow. Such hydrologic information can be used to assist the environmental professional in forming an opinion about the impact of nearby contaminated properties or, should contamination exist on the target property, what downgradient sites might be impacted.

Refer to the Physical Setting Source Map following this summary for hydrologic information (major waterways and bodies of water).

FEMA FLOOD ZONE

Flood Plain Panel at Target Property	FEMA Source Type
36119C0267F	FEMA FIRM Flood data

Additional Panels in search area:	FEMA Source Type
36119C0266F	FEMA FIRM Flood data
36119C0268F	FEMA FIRM Flood data
36119C0269F	FEMA FIRM Flood data

NATIONAL WETLAND INVENTORY

NWI Quad at Target Property	NWI Electronic Data Coverage
WHITE PLAINS	YES - refer to the Overview Map and Detail Map

HYDROGEOLOGIC INFORMATION

Hydrogeologic information obtained by installation of wells on a specific site can often be an indicator of groundwater flow direction in the immediate area. Such hydrogeologic information can be used to assist the environmental professional in forming an opinion about the impact of nearby contaminated properties or, should contamination exist on the target property, what downgradient sites might be impacted.

Site-Specific Hydrogeological Data*:

Search Radius:	1.25 miles
Status:	Not found

AQUIFLOW®

Search Radius: 1.000 Mile.

EDR has developed the AQUIFLOW Information System to provide data on the general direction of groundwater flow at specific points. EDR has reviewed reports submitted by environmental professionals to regulatory authorities at select sites and has extracted the date of the report, groundwater flow direction as determined hydrogeologically, and the depth to water table.

MAP ID	LOCATION FROM TP	GENERAL DIRECTION GROUNDWATER FLOW
Not Reported		

* ©1996 Site−specific hydrogeological data gathered by CERCLIS Alerts, Inc., Bainbridge Island, WA. All rights reserved. All of the information and opinions presented are those of the cited EPA report(s), which were completed under a Comprehensive Environmental Response Compensation and Liability Information System (CERCLIS) investigation.

GEOCHECK® - PHYSICAL SETTING SOURCE SUMMARY

GROUNDWATER FLOW VELOCITY INFORMATION

Groundwater flow velocity information for a particular site is best determined by a qualified environmental professional using site specific geologic and soil strata data. If such data are not reasonably ascertainable, it may be necessary to rely on other sources of information, including geologic age identification, rock stratigraphic unit and soil characteristics data collected on nearby properties and regional soil information. In general, contaminant plumes move more quickly through sandy-gravelly types of soils than silty-clayey types of soils.

GEOLOGIC INFORMATION IN GENERAL AREA OF TARGET PROPERTY

Geologic information can be used by the environmental professional in forming an opinion about the relative speed at which contaminant migration may be occurring.

ROCK STRATIGRAPHIC UNIT

Era:	Precambrian
System:	Precambrian
Series:	Paragneiss and schist
Code:	Ym *(decoded above as Era, System & Series)*

GEOLOGIC AGE IDENTIFICATION

Category: Metamorphic Rocks

Geologic Age and Rock Stratigraphic Unit Source: P.G. Schruben, R.E. Arndt and W.J. Bawiec, Geology of the Conterminous U.S. at 1:2,500,000 Scale - a digital representation of the 1974 P.B. King and H.M. Beikman Map, USGS Digital Data Series DDS - 11 (1994).

SSURGO SOIL MAP - 7906442.2s



Target Property
SSURGO Soil
Water

0 1/16 1/8 1/4 Miles

N

SITE NAME:	100 Main Street	CLIENT:	SESI Consulting Engineers
ADDRESS:	100 Main Street White Plains NY 10601	CONTACT:	Annmarie Yannaco
LAT/LONG:	41.03164 / 73.770797	INQUIRY #:	7906442.2s
		DATE:	February 24, 2025 1:47 pm

Copyright © 2025 EDR, Inc. © 2015 TomTom Rel. 2015.

GEOCHECK® - PHYSICAL SETTING SOURCE SUMMARY

DOMINANT SOIL COMPOSITION IN GENERAL AREA OF TARGET PROPERTY

The U.S. Department of Agriculture's (USDA) Soil Conservation Service (SCS) leads the National Cooperative Soil Survey (NCSS) and is responsible for collecting, storing, maintaining and distributing soil survey information for privately owned lands in the United States. A soil map in a soil survey is a representation of soil patterns in a landscape. The following information is based on Soil Conservation Service SSURGO data.

Soil Map ID: 1

Soil Component Name: Urban land

Soil Surface Texture:
Hydrologic Group: Not reported

Soil Drainage Class:
Hydric Status: Unknown

Corrosion Potential - Uncoated Steel: Not Reported

Depth to Bedrock Min: > 0 inches

Depth to Watertable Min: > 0 inches

No Layer Information available.

Soil Map ID: 2

Soil Component Name: Udorthents

Soil Surface Texture: gravelly loam

Hydrologic Group: Not reported

Soil Drainage Class: Moderately well drained

Hydric Status: Not hydric

Corrosion Potential - Uncoated Steel: Not Reported

Depth to Bedrock Min: > 127 inches

Depth to Watertable Min: > 84 inches

Soil Layer Information							
	Boundary			Classification		Saturated hydraulic conductivity micro m/sec	Soil Reaction (pH)
Layer	Upper	Lower	Soil Texture Class	AASHTO Group	Unified Soil		
1	0 inches	3 inches	gravelly loam	Silt-Clay Materials (more than 35 pct. passing No. 200), Silty Soils.	FINE-GRAINED SOILS, Silts and Clays (liquid limit less than 50%), Lean Clay	Max: 42 Min: 0.42	Max: 8.4 Min: 4.5
2	3 inches	70 inches	very gravelly loam	Silt-Clay Materials (more than 35 pct. passing No. 200), Silty Soils.	FINE-GRAINED SOILS, Silts and Clays (liquid limit less than 50%), Lean Clay	Max: 42 Min: 0.42	Max: 8.4 Min: 4.5

Soil Map ID: 3

Soil Component Name: Udifluvents

Soil Surface Texture: gravelly silt loam

Hydrologic Group: Class D - Very slow infiltration rates. Soils are clayey, have a high water table, or are shallow to an impervious layer.

Soil Drainage Class: Poorly drained

Hydric Status: Partially hydric

Corrosion Potential - Uncoated Steel: High

Depth to Bedrock Min: > 0 inches

Depth to Watertable Min: > 0 inches

Soil Layer Information							
	Boundary			Classification		Saturated hydraulic conductivity micro m/sec	Soil Reaction (pH)
Layer	Upper	Lower	Soil Texture Class	AASHTO Group	Unified Soil		
1	0 inches	3 inches	gravelly silt loam	Silt-Clay Materials (more than 35 pct. passing No. 200), Silty Soils.	COARSE-GRAINED SOILS, Gravels, Gravels with fines, Clayey Gravel	Max: 141 Min: 0.42	Max: 8.4 Min: 4.5

GEOCHECK® - PHYSICAL SETTING SOURCE SUMMARY

Soil Layer Information							
	Boundary			Classification		Saturated hydraulic conductivity micro m/sec	Soil Reaction (pH)
Layer	Upper	Lower	Soil Texture Class	AASHTO Group	Unified Soil		
2	3 inches	70 inches	very gravelly loam	Silt-Clay Materials (more than 35 pct. passing No. 200), Silty Soils.	COARSE-GRAINED SOILS, Gravels, Gravels with fines, Clayey Gravel	Max: 141 Min: 0.42	Max: 8.4 Min: 4.5

LOCAL / REGIONAL WATER AGENCY RECORDS

EDR Local/Regional Water Agency records provide water well information to assist the environmental professional in assessing sources that may impact ground water flow direction, and in forming an opinion about the impact of contaminant migration on nearby drinking water wells.

WELL SEARCH DISTANCE INFORMATION

DATABASE	SEARCH DISTANCE (miles)
Federal USGS	1.000
Federal FRDS PWS	Nearest PWS within 1 mile
State Database	1.000

FEDERAL USGS WELL INFORMATION

MAP ID	WELL ID	LOCATION FROM TP
A1	USGS40000837305	1/8 - 1/4 Mile WNW
A2	USGS40000837306	1/8 - 1/4 Mile WNW
3	USGS40000837292	1/8 - 1/4 Mile East
B4	USGS40000837317	1/8 - 1/4 Mile NNE
B5	USGS40000837318	1/8 - 1/4 Mile NNE
6	USGS40000837264	1/8 - 1/4 Mile SE
7	USGS40000837302	1/4 - 1/2 Mile East
8	USGS40000839114	1/4 - 1/2 Mile East
9	USGS40000837283	1/4 - 1/2 Mile East
10	USGS40000837246	1/4 - 1/2 Mile SSE
11	USGS40000837239	1/4 - 1/2 Mile South
12	USGS40000837255	1/4 - 1/2 Mile SW
13	USGS40000837243	1/2 - 1 Mile SE
14	USGS40000837244	1/2 - 1 Mile SW
15	USGS40000837356	1/2 - 1 Mile NW
16	USGS40000837237	1/2 - 1 Mile SE
17	USGS40000837368	1/2 - 1 Mile NE

GEOCHECK® - PHYSICAL SETTING SOURCE SUMMARY

FEDERAL USGS WELL INFORMATION

MAP ID	WELL ID	LOCATION FROM TP
18	USGS40000837362	1/2 - 1 Mile NE
C19	USGS40000837260	1/2 - 1 Mile ESE
C20	USGS40000837261	1/2 - 1 Mile ESE
21	USGS40000837348	1/2 - 1 Mile ENE
22	USGS40000837312	1/2 - 1 Mile West
23	USGS40000837349	1/2 - 1 Mile ENE
D24	USGS40000837338	1/2 - 1 Mile ENE
D25	USGS40000837339	1/2 - 1 Mile ENE

FEDERAL FRDS PUBLIC WATER SUPPLY SYSTEM INFORMATION

MAP ID	WELL ID	LOCATION FROM TP
No PWS System Found		

Note: PWS System location is not always the same as well location.

STATE DATABASE WELL INFORMATION

MAP ID	WELL ID	LOCATION FROM TP
No Wells Found		

OTHER STATE DATABASE INFORMATION

STATE OIL/GAS WELL INFORMATION

MAP ID	WELL ID	LOCATION FROM TP
1	NYOG20000045129	1/4 - 1/2 Mile NW
2	NYOG20000045130	1/2 - 1 Mile East

PHYSICAL SETTING SOURCE MAP - 7906442.2s



0 1/4 1/2 1 Miles

- County Boundary
- Major Roads
- Contour Lines
- Earthquake epicenter, Richter 5 or greater
- Water Wells
- Public Water Supply Wells
- Cluster of Multiple Icons
- Groundwater Flow Direction
- Indeterminate Groundwater Flow at Location
- Groundwater Flow Varies at Location
- Closest Hydrogeological Data
- Oil, gas or related wells

SITE NAME:	100 Main Street	CLIENT:	SESI Consulting Engineers
ADDRESS:	100 Main Street White Plains NY 10601	CONTACT:	Annmarie Yannaco
		INQUIRY #:	7906442.2s
LAT/LONG:	41.03164 / 73.770797	DATE:	February 24, 2025 1:46 pm

Copyright © 2025 EDR, Inc. © 2015 TomTom Rel. 2015.

GEOCHECK® - PHYSICAL SETTING SOURCE MAP FINDINGS

Map ID
Direction
Distance
Elevation | Database | EDR ID Number

A1
WNW
1/8 - 1/4 Mile
Higher

FED USGS **USGS40000837305**

Organization ID:	USGS-NY	Organization Name:	USGS New York Water Science Center
Monitor Location:	WE 121	Type:	Well
Description:	Not Reported	HUC:	02030102
Drainage Area:	Not Reported	Drainage Area Units:	Not Reported
Contrib Drainage Area:	Not Reported	Contrib Drainage Area Unts:	Not Reported
Aquifer:	Not Reported	Formation Type:	Bedrock
Aquifer Type:	Not Reported	Construction Date:	Not Reported
Well Depth:	310	Well Depth Units:	ft
Well Hole Depth:	Not Reported	Well Hole Depth Units:	Not Reported

---

A2
WNW
1/8 - 1/4 Mile
Higher

FED USGS **USGS40000837306**

Organization ID:	USGS-NY	Organization Name:	USGS New York Water Science Center
Monitor Location:	WE 123	Type:	Well
Description:	Not Reported	HUC:	02030102
Drainage Area:	Not Reported	Drainage Area Units:	Not Reported
Contrib Drainage Area:	Not Reported	Contrib Drainage Area Unts:	Not Reported
Aquifer:	Not Reported	Formation Type:	Bedrock
Aquifer Type:	Not Reported	Construction Date:	Not Reported
Well Depth:	300	Well Depth Units:	ft
Well Hole Depth:	Not Reported	Well Hole Depth Units:	Not Reported

---

3
East
1/8 - 1/4 Mile
Higher

FED USGS **USGS40000837292**

Organization ID:	USGS-NY	Organization Name:	USGS New York Water Science Center
Monitor Location:	WE 4	Type:	Well
Description:	Not Reported	HUC:	02030102
Drainage Area:	Not Reported	Drainage Area Units:	Not Reported
Contrib Drainage Area:	Not Reported	Contrib Drainage Area Unts:	Not Reported
Aquifer:	Not Reported	Formation Type:	Basement Complex
Aquifer Type:	Not Reported	Construction Date:	1912
Well Depth:	203	Well Depth Units:	ft
Well Hole Depth:	203.1	Well Hole Depth Units:	ft

B4
NNE
1/8 - 1/4 Mile
Lower

FED USGS **USGS40000837317**

Organization ID:	USGS-NY	Organization Name:	USGS New York Water Science Center
Monitor Location:	WE 87	Type:	Well
Description:	Not Reported	HUC:	02030102
Drainage Area:	Not Reported	Drainage Area Units:	Not Reported

Contrib Drainage Area:	Not Reported	Contrib Drainage Area Unts:	Not Reported
Aquifer:	Not Reported	Formation Type:	Bedrock
Aquifer Type:	Not Reported	Construction Date:	Not Reported
Well Depth:	700	Well Depth Units:	ft
Well Hole Depth:	Not Reported	Well Hole Depth Units:	Not Reported

---

B5
NNE **FED USGS** **USGS40000837318**
1/8 - 1/4 Mile
Lower

Organization ID:	USGS-NY	Organization Name:	USGS New York Water Science Center
Monitor Location:	WE 88	Type:	Well
Description:	Not Reported	HUC:	02030102
Drainage Area:	Not Reported	Drainage Area Units:	Not Reported
Contrib Drainage Area:	Not Reported	Contrib Drainage Area Unts:	Not Reported
Aquifer:	Not Reported	Formation Type:	Bedrock
Aquifer Type:	Not Reported	Construction Date:	Not Reported
Well Depth:	250	Well Depth Units:	ft
Well Hole Depth:	Not Reported	Well Hole Depth Units:	Not Reported

---

6
SE **FED USGS** **USGS40000837264**
1/8 - 1/4 Mile
Higher

Organization ID:	USGS-NY	Organization Name:	USGS New York Water Science Center
Monitor Location:	WE 96	Type:	Well
Description:	Not Reported	HUC:	02030102
Drainage Area:	Not Reported	Drainage Area Units:	Not Reported
Contrib Drainage Area:	Not Reported	Contrib Drainage Area Unts:	Not Reported
Aquifer:	Not Reported	Formation Type:	Bedrock
Aquifer Type:	Not Reported	Construction Date:	Not Reported
Well Depth:	725	Well Depth Units:	ft
Well Hole Depth:	Not Reported	Well Hole Depth Units:	Not Reported

---

7
East **FED USGS** **USGS40000837302**
1/4 - 1/2 Mile
Higher

Organization ID:	USGS-NY	Organization Name:	USGS New York Water Science Center
Monitor Location:	WE 161	Type:	Well
Description:	Not Reported	HUC:	02030102
Drainage Area:	Not Reported	Drainage Area Units:	Not Reported
Contrib Drainage Area:	Not Reported	Contrib Drainage Area Unts:	Not Reported
Aquifer:	Not Reported	Formation Type:	Bedrock
Aquifer Type:	Not Reported	Construction Date:	Not Reported
Well Depth:	225	Well Depth Units:	ft
Well Hole Depth:	Not Reported	Well Hole Depth Units:	Not Reported

Map ID
Direction
Distance
Elevation | Database | EDR ID Number

8
East
1/4 - 1/2 Mile
Higher

FED USGS **USGS40000839114**

Organization ID:	USGS-NY	Organization Name:	USGS New York Water Science Center
Monitor Location:	WE 119	Type:	Well
Description:	Not Reported	HUC:	02030102
Drainage Area:	Not Reported	Drainage Area Units:	Not Reported
Contrib Drainage Area:	Not Reported	Contrib Drainage Area Unts:	Not Reported
Aquifer:	Not Reported	Formation Type:	Bedrock
Aquifer Type:	Not Reported	Construction Date:	Not Reported
Well Depth:	350	Well Depth Units:	ft
Well Hole Depth:	Not Reported	Well Hole Depth Units:	Not Reported

---

9
East
1/4 - 1/2 Mile
Higher

FED USGS **USGS40000837283**

Organization ID:	USGS-NY	Organization Name:	USGS New York Water Science Center
Monitor Location:	WE 118	Type:	Well
Description:	Not Reported	HUC:	02030102
Drainage Area:	Not Reported	Drainage Area Units:	Not Reported
Contrib Drainage Area:	Not Reported	Contrib Drainage Area Unts:	Not Reported
Aquifer:	Not Reported	Formation Type:	Bedrock
Aquifer Type:	Not Reported	Construction Date:	Not Reported
Well Depth:	108	Well Depth Units:	ft
Well Hole Depth:	Not Reported	Well Hole Depth Units:	Not Reported

---

10
SSE
1/4 - 1/2 Mile
Higher

FED USGS **USGS40000837246**

Organization ID:	USGS-NY	Organization Name:	USGS New York Water Science Center
Monitor Location:	WE 95	Type:	Well
Description:	Not Reported	HUC:	02030102
Drainage Area:	Not Reported	Drainage Area Units:	Not Reported
Contrib Drainage Area:	Not Reported	Contrib Drainage Area Unts:	Not Reported
Aquifer:	Not Reported	Formation Type:	Bedrock
Aquifer Type:	Not Reported	Construction Date:	Not Reported
Well Depth:	495	Well Depth Units:	ft
Well Hole Depth:	Not Reported	Well Hole Depth Units:	Not Reported

---

11
South
1/4 - 1/2 Mile
Higher

FED USGS **USGS40000837239**

Organization ID:	USGS-NY	Organization Name:	USGS New York Water Science Center
Monitor Location:	WE 94	Type:	Well
Description:	Not Reported	HUC:	02030102
Drainage Area:	Not Reported	Drainage Area Units:	Not Reported

Contrib Drainage Area:	Not Reported	Contrib Drainage Area Unts:	Not Reported
Aquifer:	Not Reported	Formation Type:	Bedrock
Aquifer Type:	Not Reported	Construction Date:	Not Reported
Well Depth:	302	Well Depth Units:	ft
Well Hole Depth:	Not Reported	Well Hole Depth Units:	Not Reported

---

12
SW
1/4 - 1/2 Mile
Higher

FED USGS **USGS40000837255**

Organization ID:	USGS-NY	Organization Name:	USGS New York Water Science Center
Monitor Location:	WE 133	Type:	Well
Description:	Not Reported	HUC:	02030102
Drainage Area:	Not Reported	Drainage Area Units:	Not Reported
Contrib Drainage Area:	Not Reported	Contrib Drainage Area Unts:	Not Reported
Aquifer:	Not Reported	Formation Type:	Bedrock
Aquifer Type:	Not Reported	Construction Date:	Not Reported
Well Depth:	500	Well Depth Units:	ft
Well Hole Depth:	Not Reported	Well Hole Depth Units:	Not Reported

---

13
SE
1/2 - 1 Mile
Higher

FED USGS **USGS40000837243**

Organization ID:	USGS-NY	Organization Name:	USGS New York Water Science Center
Monitor Location:	WE 305	Type:	Well
Description:	Not Reported	HUC:	02030102
Drainage Area:	Not Reported	Drainage Area Units:	Not Reported
Contrib Drainage Area:	Not Reported	Contrib Drainage Area Unts:	Not Reported
Aquifer:	Not Reported	Formation Type:	Bedrock
Aquifer Type:	Not Reported	Construction Date:	Not Reported
Well Depth:	484	Well Depth Units:	ft
Well Hole Depth:	Not Reported	Well Hole Depth Units:	Not Reported

---

14
SW
1/2 - 1 Mile
Higher

FED USGS **USGS40000837244**

Organization ID:	USGS-NY	Organization Name:	USGS New York Water Science Center
Monitor Location:	WE1064	Type:	Well
Description:	Not Reported	HUC:	02030102
Drainage Area:	Not Reported	Drainage Area Units:	Not Reported
Contrib Drainage Area:	Not Reported	Contrib Drainage Area Unts:	Not Reported
Aquifer:	Not Reported	Formation Type:	Bedrock
Aquifer Type:	Not Reported	Construction Date:	Not Reported
Well Depth:	508	Well Depth Units:	ft
Well Hole Depth:	Not Reported	Well Hole Depth Units:	Not Reported

Map ID
Direction
Distance
Elevation | Database | EDR ID Number

15
NW
1/2 - 1 Mile
Lower

FED USGS **USGS40000837356**

Organization ID:	USGS-NY	Organization Name:	USGS New York Water Science Center
Monitor Location:	WE1379	Type:	Well
Description:	Not Reported	HUC:	02030102
Drainage Area:	Not Reported	Drainage Area Units:	Not Reported
Contrib Drainage Area:	Not Reported	Contrib Drainage Area Unts:	Not Reported
Aquifer:	Not Reported	Formation Type:	Bedrock
Aquifer Type:	Not Reported	Construction Date:	Not Reported
Well Depth:	Not Reported	Well Depth Units:	Not Reported
Well Hole Depth:	Not Reported	Well Hole Depth Units:	Not Reported

---

16
SE
1/2 - 1 Mile
Higher

FED USGS **USGS40000837237**

Organization ID:	USGS-NY	Organization Name:	USGS New York Water Science Center
Monitor Location:	WE 120	Type:	Well
Description:	Not Reported	HUC:	02030102
Drainage Area:	Not Reported	Drainage Area Units:	Not Reported
Contrib Drainage Area:	Not Reported	Contrib Drainage Area Unts:	Not Reported
Aquifer:	Not Reported	Formation Type:	Bedrock
Aquifer Type:	Not Reported	Construction Date:	Not Reported
Well Depth:	200	Well Depth Units:	ft
Well Hole Depth:	Not Reported	Well Hole Depth Units:	Not Reported

---

17
NE
1/2 - 1 Mile
Higher

FED USGS **USGS40000837368**

Organization ID:	USGS-NY	Organization Name:	USGS New York Water Science Center
Monitor Location:	WE 91	Type:	Well
Description:	Not Reported	HUC:	02030102
Drainage Area:	Not Reported	Drainage Area Units:	Not Reported
Contrib Drainage Area:	Not Reported	Contrib Drainage Area Unts:	Not Reported
Aquifer:	Not Reported	Formation Type:	Bedrock
Aquifer Type:	Not Reported	Construction Date:	Not Reported
Well Depth:	350	Well Depth Units:	ft
Well Hole Depth:	Not Reported	Well Hole Depth Units:	Not Reported

---

18
NE
1/2 - 1 Mile
Lower

FED USGS **USGS40000837362**

Organization ID:	USGS-NY	Organization Name:	USGS New York Water Science Center
Monitor Location:	WE 92	Type:	Well
Description:	Not Reported	HUC:	02030102
Drainage Area:	Not Reported	Drainage Area Units:	Not Reported

Contrib Drainage Area:	Not Reported	Contrib Drainage Area Unts:	Not Reported
Aquifer:	Not Reported	Formation Type:	Bedrock
Aquifer Type:	Not Reported	Construction Date:	Not Reported
Well Depth:	332	Well Depth Units:	ft
Well Hole Depth:	Not Reported	Well Hole Depth Units:	Not Reported

---

C19
ESE
1/2 - 1 Mile
Higher

FED USGS **USGS40000837260**

Organization ID:	USGS-NY	Organization Name:	USGS New York Water Science Center
Monitor Location:	WE 200	Type:	Well
Description:	Not Reported	HUC:	02030102
Drainage Area:	Not Reported	Drainage Area Units:	Not Reported
Contrib Drainage Area:	Not Reported	Contrib Drainage Area Unts:	Not Reported
Aquifer:	Sand and gravel aquifers (glaciated regions)		
Formation Type:	Sand and Gravel	Aquifer Type:	Not Reported
Construction Date:	Not Reported	Well Depth:	22
Well Depth Units:	ft	Well Hole Depth:	Not Reported
Well Hole Depth Units:	Not Reported		

C20
ESE
1/2 - 1 Mile
Higher

FED USGS **USGS40000837261**

Organization ID:	USGS-NY	Organization Name:	USGS New York Water Science Center
Monitor Location:	WE 220	Type:	Well
Description:	Not Reported	HUC:	02030102
Drainage Area:	Not Reported	Drainage Area Units:	Not Reported
Contrib Drainage Area:	Not Reported	Contrib Drainage Area Unts:	Not Reported
Aquifer:	Sand and gravel aquifers (glaciated regions)		
Formation Type:	Sand and Gravel	Aquifer Type:	Not Reported
Construction Date:	Not Reported	Well Depth:	40
Well Depth Units:	ft	Well Hole Depth:	Not Reported
Well Hole Depth Units:	Not Reported		

21
ENE
1/2 - 1 Mile
Lower

FED USGS **USGS40000837348**

Organization ID:	USGS-NY	Organization Name:	USGS New York Water Science Center
Monitor Location:	WE 93	Type:	Well
Description:	Not Reported	HUC:	02030102
Drainage Area:	Not Reported	Drainage Area Units:	Not Reported
Contrib Drainage Area:	Not Reported	Contrib Drainage Area Unts:	Not Reported
Aquifer:	Not Reported	Formation Type:	Bedrock
Aquifer Type:	Not Reported	Construction Date:	Not Reported
Well Depth:	250	Well Depth Units:	ft
Well Hole Depth:	Not Reported	Well Hole Depth Units:	Not Reported

Map ID
Direction
Distance
Elevation | Database | EDR ID Number

22
West
1/2 - 1 Mile
Higher

FED USGS **USGS40000837312**

Organization ID:	USGS-NY	Organization Name:	USGS New York Water Science Center
Monitor Location:	WE 586	Type:	Well
Description:	Not Reported	HUC:	02030102
Drainage Area:	Not Reported	Drainage Area Units:	Not Reported
Contrib Drainage Area:	Not Reported	Contrib Drainage Area Unts:	Not Reported
Aquifer:	Not Reported	Formation Type:	Bedrock
Aquifer Type:	Not Reported	Construction Date:	Not Reported
Well Depth:	102	Well Depth Units:	ft
Well Hole Depth:	Not Reported	Well Hole Depth Units:	Not Reported

---

23
ENE
1/2 - 1 Mile
Lower

FED USGS **USGS40000837349**

Organization ID:	USGS-NY	Organization Name:	USGS New York Water Science Center
Monitor Location:	WE1407	Type:	Well
Description:	Not Reported	HUC:	02030102
Drainage Area:	Not Reported	Drainage Area Units:	Not Reported
Contrib Drainage Area:	Not Reported	Contrib Drainage Area Unts:	Not Reported
Aquifer:	Not Reported	Formation Type:	Bedrock
Aquifer Type:	Not Reported	Construction Date:	Not Reported
Well Depth:	298	Well Depth Units:	ft
Well Hole Depth:	Not Reported	Well Hole Depth Units:	Not Reported

---

D24
ENE
1/2 - 1 Mile
Lower

FED USGS **USGS40000837338**

Organization ID:	USGS-NY	Organization Name:	USGS New York Water Science Center
Monitor Location:	WE 89	Type:	Well
Description:	Not Reported	HUC:	02030102
Drainage Area:	Not Reported	Drainage Area Units:	Not Reported
Contrib Drainage Area:	Not Reported	Contrib Drainage Area Unts:	Not Reported
Aquifer:	Sand and gravel aquifers (glaciated regions)		
Formation Type:	Sand	Aquifer Type:	Not Reported
Construction Date:	Not Reported	Well Depth:	52
Well Depth Units:	ft	Well Hole Depth:	Not Reported
Well Hole Depth Units:	Not Reported		

D25
ENE
1/2 - 1 Mile
Lower

FED USGS **USGS40000837339**

Organization ID:	USGS-NY	Organization Name:	USGS New York Water Science Center
Monitor Location:	WE 90	Type:	Well
Description:	Not Reported	HUC:	02030102

GEOCHECK® - PHYSICAL SETTING SOURCE MAP FINDINGS

Drainage Area:	Not Reported	Drainage Area Units:	Not Reported
Contrib Drainage Area:	Not Reported	Contrib Drainage Area Unts:	Not Reported
Aquifer:	Sand and gravel aquifers (glaciated regions)		
Formation Type:	Sand	Aquifer Type:	Not Reported
Construction Date:	Not Reported	Well Depth:	60
Well Depth Units:	ft	Well Hole Depth:	Not Reported
Well Hole Depth Units:	Not Reported		

GEOCHECK® - PHYSICAL SETTING SOURCE MAP FINDINGS

Map ID
Direction
Distance

Database EDR ID Number

1
NW **OIL_GAS** **NYOG20000045129**
1/4 - 1/2 Mile

OIL_GAS:

API #:	31119236850000	Well Name:	KCT B-4
Well Type:	Stratigraphic	Well Status:	Plugged and Abandoned
Owner:	New York City Dept. of Environmental Protection		
Operator:	2127	Permit Date:	Not Reported
SPUD Date:	Not Reported	Completion Date:	13-SEP-06
Plug Date:	Not Reported	Field Name:	Not Applicable
Formation:	Fordham Gneiss	Borehole Slant:	Vertical
True Depth (ft):	560	Measured Length (ft):	560
URL:	http://extapps.dec.ny.gov/cfmx/extapps/GasOil/search/wells/index.cfm?api=31119236850000		

2
East **OIL_GAS** **NYOG20000045130**
1/2 - 1 Mile

OIL_GAS:

API #:	31119236860000	Well Name:	KCT B-5
Well Type:	Stratigraphic	Well Status:	Plugged and Abandoned
Owner:	New York City Dept. of Environmental Protection		
Operator:	2127	Permit Date:	Not Reported
SPUD Date:	Not Reported	Completion Date:	21-SEP-06
Plug Date:	Not Reported	Field Name:	Not Applicable
Formation:	Yonkers Gneiss	Borehole Slant:	Vertical
True Depth (ft):	530	Measured Length (ft):	530
URL:	http://extapps.dec.ny.gov/cfmx/extapps/GasOil/search/wells/index.cfm?api=31119236860000		

GEOCHECK® - PHYSICAL SETTING SOURCE MAP FINDINGS
RADON

AREA RADON INFORMATION

State Database: NY Radon

Radon Test Results

County	Town	Num Tests	Avg Result	Geo Mean	Max Result
WESTCHESTER	BEDFORD	108	2.44	1.65	21.7
WESTCHESTER	CORTLANDT	169	5.15	2.22	95.4
WESTCHESTER	EASTCHESTER	76	2.89	1.75	41.9
WESTCHESTER	GREENBURGH	222	2.26	1.46	21.8
WESTCHESTER	HARRISON	69	3.3	2.07	42.3
WESTCHESTER	LEWISBORO	72	3.91	2.61	19.2
WESTCHESTER	MAMARONECK	123	4	2.42	35.9
WESTCHESTER	MT. KISCO	38	2.33	1.72	9.3
WESTCHESTER	MT. PLEASANT	172	2.13	1.43	17.1
WESTCHESTER	MT. VERNON	53	2.82	1.65	32
WESTCHESTER	NEW CASTLE	134	2.2	1.46	31.7
WESTCHESTER	NEW ROCHELLE	127	1.92	1.31	13.8
WESTCHESTER	NO. CASTLE	64	3.49	2.25	16.5
WESTCHESTER	NO. SALEM	56	3.78	2.56	25.7
WESTCHESTER	OSSINING	65	2.08	1.39	10.9
WESTCHESTER	PEEKSKILL	47	3.66	2.34	19.9
WESTCHESTER	PELHAM	26	2.5	1.91	9.1
WESTCHESTER	POUND RIDGE	34	3.37	2.22	18.5
WESTCHESTER	RYE	98	2.24	1.63	9.5
WESTCHESTER	SCARSDALE	138	2.35	1.63	22.4
WESTCHESTER	SOMERS	72	3.89	2.82	21.3
WESTCHESTER	WHITE PLAINS	132	2.76	1.48	65.2
WESTCHESTER	YONKERS	153	2.23	1.37	16
WESTCHESTER	YORKTOWN	181	2.7	1.72	27.2

Federal EPA Radon Zone for WESTCHESTER County: 3

Note: Zone 1 indoor average level > 4 pCi/L.
: Zone 2 indoor average level >= 2 pCi/L and <= 4 pCi/L.
: Zone 3 indoor average level < 2 pCi/L.

Federal Area Radon Information for WESTCHESTER COUNTY, NY

Number of sites tested: 650

Area	Average Activity	% <4 pCi/L	% 4-20 pCi/L	% >20 pCi/L
Living Area	0.930 pCi/L	97%	3%	0%
Basement	1.730 pCi/L	84%	13%	2%

PHYSICAL SETTING SOURCE RECORDS SEARCHED

TOPOGRAPHIC INFORMATION

USGS 7.5' Digital Elevation Model (DEM)
Source: United States Geologic Survey
EDR acquired the USGS 7.5' Digital Elevation Model in 2002 and updated it in 2006. The 7.5 minute DEM corresponds to the USGS 1:24,000- and 1:25,000-scale topographic quadrangle maps. The DEM provides elevation data with consistent elevation units and projection.

Current USGS 7.5 Minute Topographic Map
Source: U.S. Geological Survey

HYDROLOGIC INFORMATION

Flood Zone Data: This data was obtained from the Federal Emergency Management Agency (FEMA). It depicts 100-year and 500-year flood zones as defined by FEMA. It includes the National Flood Hazard Layer (NFHL) which incorporates Flood Insurance Rate Map (FIRM) data and Q3 data from FEMA in areas not covered by NFHL.
Source: FEMA
Telephone: 877-336-2627
Date of Government Version: 2003, 2015

NWI: National Wetlands Inventory. This data, available in select counties across the country, was obtained by EDR in 2002, 2005, 2010 and 2015 from the U.S. Fish and Wildlife Service.

State Wetlands Data: Freshwater Wetlands
Source: Department of Environmental Conservation
Telephone: 518-402-8961

HYDROGEOLOGIC INFORMATION

AQUIFLOW^{R} Information System
Source: EDR proprietary database of groundwater flow information
EDR has developed the AQUIFLOW Information System (AIS) to provide data on the general direction of groundwater flow at specific points. EDR has reviewed reports submitted to regulatory authorities at select sites and has extracted the date of the report, hydrogeologically determined groundwater flow direction and depth to water table information.

GEOLOGIC INFORMATION

Geologic Age and Rock Stratigraphic Unit
Source: P.G. Schruben, R.E. Arndt and W.J. Bawiec, Geology of the Conterminous U.S. at 1:2,500,000 Scale - A digital representation of the 1974 P.B. King and H.M. Beikman Map, USGS Digital Data Series DDS - 11 (1994).

STATSGO: State Soil Geographic Database
Source: Department of Agriculture, Natural Resources Conservation Service (NRCS)
The U.S. Department of Agriculture's (USDA) Natural Resources Conservation Service (NRCS) leads the national Conservation Soil Survey (NCSS) and is responsible for collecting, storing, maintaining and distributing soil survey information for privately owned lands in the United States. A soil map in a soil survey is a representation of soil patterns in a landscape. Soil maps for STATSGO are compiled by generalizing more detailed (SSURGO) soil survey maps.

SSURGO: Soil Survey Geographic Database
Source: Department of Agriculture, Natural Resources Conservation Service (NRCS)
Telephone: 800-672-5559
SSURGO is the most detailed level of mapping done by the Natural Resources Conservation Service, mapping scales generally range from 1:12,000 to 1:63,360. Field mapping methods using national standards are used to construct the soil maps in the Soil Survey Geographic (SSURGO) database. SSURGO digitizing duplicates the original soil survey maps. This level of mapping is designed for use by landowners, townships and county natural resource planning and management.

PHYSICAL SETTING SOURCE RECORDS SEARCHED

LOCAL / REGIONAL WATER AGENCY RECORDS

FEDERAL WATER WELLS

PWS: Public Water Systems
Source: EPA/Office of Drinking Water
Telephone: 202-564-3750
Public Water System data from the Federal Reporting Data System. A PWS is any water system which provides water to at least 25 people for at least 60 days annually. PWSs provide water from wells, rivers and other sources.

PWS ENF: Public Water Systems Violation and Enforcement Data
Source: EPA/Office of Drinking Water
Telephone: 202-564-3750
Violation and Enforcement data for Public Water Systems from the Safe Drinking Water Information System (SDWIS) after August 1995. Prior to August 1995, the data came from the Federal Reporting Data System (FRDS).

USGS Water Wells: USGS National Water Inventory System (NWIS)
This database contains descriptive information on sites where the USGS collects or has collected data on surface water and/or groundwater. The groundwater data includes information on wells, springs, and other sources of groundwater.

STATE RECORDS

New York Public Water Wells
Source: New York Department of Health
Telephone: 518-458-6731

OTHER STATE DATABASE INFORMATION

Oil and Gas Well Database
Source: Department of Environmental Conservation
Telephone: 518-402-8072
These files contain records, in the database, of wells that have been drilled.

RADON

State Database: NY Radon
Source: Department of Health
Telephone: 518-402-7556
Radon Test Results

Area Radon Information
Source: USGS
Telephone: 703-356-4020
The National Radon Database has been developed by the U.S. Environmental Protection Agency (USEPA) and is a compilation of the EPA/State Residential Radon Survey and the National Residential Radon Survey. The study covers the years 1986 - 1992. Where necessary data has been supplemented by information collected at private sources such as universities and research institutions.

EPA Radon Zones
Source: EPA
Telephone: 703-356-4020
Sections 307 & 309 of IRAA directed EPA to list and identify areas of U.S. with the potential for elevated indoor radon levels.

OTHER

Airport Landing Facilities: Private and public use landing facilities
Source: Federal Aviation Administration, 800-457-6656

Epicenters: World earthquake epicenters, Richter 5 or greater
Source: Department of Commerce, National Oceanic and Atmospheric Administration

Earthquake Fault Lines: The fault lines displayed on EDR's Topographic map are digitized quaternary faultlines, prepared in 1975 by the United State Geological Survey

PHYSICAL SETTING SOURCE RECORDS SEARCHED

STREET AND ADDRESS INFORMATION

© 2015 TomTom North America, Inc. All rights reserved. This material is proprietary and the subject of copyright protection and other intellectual property rights owned by or licensed to Tele Atlas North America, Inc. The use of this material is subject to the terms of a license agreement. You will be held liable for any unauthorized copying or disclosure of this material.

100 Main Street

100 Main Street

White Plains, NY 10601

Inquiry Number: 7906442.3

February 24, 2025

Certified Sanborn® Map Report

6 Armstrong Road, 4th floor
Shelton, CT 06484
Toll Free: 800.352.0050
www.edrnet.com

Certified Sanborn® Map Report

02/24/25

Site Name:

100 Main Street
100 Main Street
White Plains, NY 10601
EDR Inquiry # 7906442.3

Client Name:

SESI Consulting Engineers
959 Route 46E 3rd Floor
Parsippany, NJ 07054
Contact: Annmarie Yannaco

The Sanborn Library has been searched by EDR and maps covering the target property location as provided by SESI Consulting Engineers were identified for the years listed below. The Sanborn Library is the largest, most complete collection of fire insurance maps. The collection includes maps from Sanborn, Bromley, Perris & Browne, Hopkins, Barlow, and others. Only Environmental Data Resources Inc. (EDR) is authorized to grant rights for commercial reproduction of maps by the Sanborn Library LLC, the copyright holder for the collection. Results can be authenticated by visiting www.edrnet.com/sanborn.

The Sanborn Library is continually enhanced with newly identified map archives. This report accesses all maps in the collection as of the day this report was generated.

Certified Sanborn Results:

Certification # EC34-4D4C-B1E6

PO # NA

Project 12859

Maps Provided:

2004	1989	1894
2003	1987	1889
2002	1950	1885
1995	1942	
1994	1930	
1993	1911	
1992	1905	
1990	1900	

Sanborn® Library search results

Certification #: EC34-4D4C-B1E6

The Sanborn Library includes more than 1.2 million fire insurance maps from Sanborn, Bromley, Perris & Browne, Hopkins, Barlow and others which track historical property usage in approximately 12,000 American cities and towns. Collections searched:

- ☑ Library of Congress
- ☑ University Publications of America
- ☑ EDR Private Collection

The Sanborn Library LLC Since 1866™

Limited Permission To Make Copies

SESI Consulting Engineers (the client) is permitted to make up to FIVE photocopies of this Sanborn Map transmittal and each fire insurance map accompanying this report solely for the limited use of its customer. No one other than the client is authorized to make copies. Upon request made directly to an EDR Account Executive, the client may be permitted to make a limited number of additional photocopies. This permission is conditioned upon compliance by the client, its customer and their agents with EDR's copyright policy; a copy of which is available upon request.

Disclaimer - Copyright and Trademark Notice

This Report contains certain information obtained from a variety of public and other sources reasonably available to Environmental Data Resources, LLC. It cannot be concluded from this Report that coverage information for the target and surrounding properties does not exist from other sources. This Report is provided on an "AS IS", "AS AVAILABLE" basis. NO WARRANTY EXPRESS OR IMPLIED IS MADE WHATSOEVER IN CONNECTION WITH THIS REPORT. ENVIRONMENTAL DATA RESOURCES, LLC AND ITS SUBSIDIARIES, AFFILIATES AND THIRD PARTY SUPPLIERS DISCLAIM ALL WARRANTIES, OF ANY KIND OR NATURE, EXPRESS OR IMPLIED, ARISING OUT OF OR RELATED TO THIS REPORT OR ANY OF THE DATA AND INFORMATION PROVIDED IN THIS REPORT, INCLUDING WITHOUT LIMITATION, ANY WARRANTIES REGARDING ACCURACY, QUALITY, CORRECTNESS, COMPLETENESS, COMPREHENSIVENESS, SUITABILITY, MERCHANTABILITY, FITNESS FOR A PARTICULAR PURPOSE, TITLE, NON-INFRINGEMENT, MISAPPROPRIATION, OR OTHERWISE. ALL RISK IS ASSUMED BY THE USER. IN NO EVENT SHALL ENVIRONMENTAL DATA RESOURCES, LLC OR ITS SUBSIDIARIES, AFFILIATES OR THIRD PARTY SUPPLIERS BE LIABLE TO ANYONE FOR ANY DIRECT, INCIDENTAL, INDIRECT, SPECIAL, CONSEQUENTIAL OR OTHER DAMAGES OF ANY TYPE OR KIND (INCLUDING BUT NOT LIMITED TO LOSS OF PROFITS, LOSS OF USE, OR LOSS OF DATA), ARISING OUT OF OR IN ANY WAY CONNECTED WITH THIS REPORT OR ANY OF THE DATA AND INFORMATION PROVIDED IN THIS REPORT. Any analyses, estimates, ratings, environmental risk levels, or risk codes provided in this Report are provided for illustrative purposes only, and are not intended to provide, nor should they be interpreted as providing any facts regarding, or prediction or forecast of, any environmental risk for any property. Only an assessment performed by a qualified environmental professional can provide findings, opinions or conclusions regarding the environmental risk or conditions in, on or at any property.

Copyright 2025 by Environmental Data Resources, Inc. All rights reserved. Reproduction in any media or format, in whole or in part, of any report or map of Environmental Data Resources, Inc., or its affiliates, is prohibited without prior written permission.

EDR and its logos (including Sanborn and Sanborn Map) are trademarks of Environmental Data Resources, LLC or its affiliates. All other trademarks used herein are the property of their respective owners.

Sanborn Sheet Key

This Certified Sanborn Map Report is based upon the following Sanborn Fire Insurance map sheets.

2004 Source Sheets



Volume 1, Sheet 2
2004



Volume 1, Sheet 1
2004

Volume 1, Sheet 6
2004

2003 Source Sheets

Volume 1, Sheet 6
2003



Volume 1, Sheet 1
2003



Volume 1, Sheet 2
2003

2002 Source Sheets



Volume 1, Sheet 2
2002



Volume 1, Sheet 1
2002



Volume 1, Sheet 6
2002

1995 Source Sheets



Volume 1, Sheet 2
1995



Volume 1, Sheet 1
1995

Volume 1, Sheet 6
1995

Sanborn Sheet Key

This Certified Sanborn Map Report is based upon the following Sanborn Fire Insurance map sheets.

1994 Source Sheets

Volume 1, Sheet 6
1994

Volume 1, Sheet 7
1994

Volume 1, Sheet 1
1994

Volume 1, Sheet 2
1994

1993 Source Sheets


Volume 1, Sheet 2
1993

Volume 1, Sheet 6
1993

Volume 1, Sheet 1
1993

1992 Source Sheets

Volume 1, Sheet 6
1992

Volume 1, Sheet 1
1992


Volume 1, Sheet 2
1992

1990 Source Sheets


Volume 1, Sheet 1
1990


Volume 1, Sheet 2
1990

Volume 1, Sheet 6
1990

Sanborn Sheet Key

This Certified Sanborn Map Report is based upon the following Sanborn Fire Insurance map sheets.

1989 Source Sheets



Volume 1, Sheet 2
1989



Volume 1, Sheet 1
1989

Volume 1, Sheet 6
1989

1987 Source Sheets

Volume 1, Sheet 6
1987



Volume 1, Sheet 1
1987



Volume 1, Sheet 2
1987

1950 Source Sheets



Volume 1, Sheet 1
1950

Volume 1, Sheet 6
1950

Volume 1, Sheet 2
1950

1942 Source Sheets

Volume 2, Sheet xxxx
1942

Volume 2, Sheet 22
1942

Sanborn Sheet Key

This Certified Sanborn Map Report is based upon the following Sanborn Fire Insurance map sheets.

1930 Source Sheets


Volume 1, Sheet 1
1930


Volume 1, Sheet 2
1930

Volume 1, Sheet 6
1930

1911 Source Sheets

Volume 1, Sheet 14
1911

Volume 1, Sheet 13
1911


Volume 1, Sheet 7
1911

1905 Source Sheets


Volume 1, Sheet 22
1905

Volume 1, Sheet 21
1905

Volume 1, Sheet 16
1905

1900 Source Sheets

Volume 1, Sheet 4
1900

Volume 1, Sheet 11
1900


Volume 1, Sheet 7
1900


Volume 1, Sheet 6
1900

Sanborn Sheet Key

This Certified Sanborn Map Report is based upon the following Sanborn Fire Insurance map sheets.

1894 Source Sheets



Volume 1, Sheet 5
1894



Volume 1, Sheet 4
1894

Volume 1, Sheet 3
1894

1889 Source Sheets



Volume 1, Sheet 7
1889



Volume 1, Sheet 4
1889



Volume 1, Sheet 5
1889



Volume 1, Sheet 3
1889

1885 Source Sheets

Volume 1, Sheet 3
1885

Volume 1, Sheet 2
1885

The certified Sanborn Library search results in this report can be authenticated by visiting www.edrnet.com/sanborn and entering the certification number. Only Environmental Data Resources Inc. (EDR) is authorized to grant rights for commercial reproduction of maps by The Sanborn Library LLC, the copyright holder for the collection.

Certification # EC34-4D4C-B1E6



Site Name:	100 Main Street
Address:	100 Main Street
City, ST, ZIP:	White Plains, NY 10601
Client:	SESI Consulting Engineers
EDR Inquiry:	7906442.3
Order Date:	02/24/2025
Certification #:	EC34-4D4C-B1E6
Copyright	2004

This Certified Sanborn Map combines the following sheets.
Outlined areas indicate map sheets within the collection.



Volume 1, Sheet 6
Volume 1, Sheet 1
Volume 1, Sheet 2

0 Feet 150 300 600

N



The certified Sanborn Library search results in this report can be authenticated by visiting www.edrnet.com/sanborn and entering the certification number. Only Environmental Data Resources Inc. (EDR) is authorized to grant rights for commercial reproduction of maps by The Sanborn Library LLC, the copyright holder for the collection.

Site Name:	100 Main Street
Address:	100 Main Street
City, ST, ZIP:	White Plains, NY 10601
Client:	SESI Consulting Engineers
EDR Inquiry:	7906442.3
Order Date:	02/24/2025
Certification #:	EC34-4D4C-B1E6
Copyright	2003

This Certified Sanborn Map combines the following sheets.
Outlined areas indicate map sheets within the collection.



Volume 1, Sheet 2
Volume 1, Sheet 1
Volume 1, Sheet 6

0 Feet 150 300 600

N

Certified Sanborn® Map

2002



The certified Sanborn Library search results in this report can be authenticated by visiting www.edrnet.com/sanborn and entering the certification number. Only Environmental Data Resources Inc. (EDR) is authorized to grant rights for commercial reproduction of maps by The Sanborn Library LLC, the copyright holder for the collection.

Certification # EC34-4D4C-B1E6

Site Name:	100 Main Street
Address:	100 Main Street
City, ST, ZIP:	White Plains, NY 10601
Client:	SESI Consulting Engineers
EDR Inquiry:	7906442.3
Order Date:	02/24/2025
Certification #:	EC34-4D4C-B1E6
Copyright	2002

This Certified Sanborn Map combines the following sheets.
Outlined areas indicate map sheets within the collection.





Volume 1, Sheet 6
Volume 1, Sheet 1
Volume 1, Sheet 2

0 Feet 150 300 600

N



The certified Sanborn Library search results in this report can be authenticated by visiting www.edrnet.com/sanborn and entering the certification number. Only Environmental Data Resources Inc. (EDR) is authorized to grant rights for commercial reproduction of maps by The Sanborn Library LLC, the copyright holder for the collection.

Certification # EC34-4D4C-B1E6

Site Name:	100 Main Street
Address:	100 Main Street
City, ST, ZIP:	White Plains, NY 10601
Client:	SESI Consulting Engineers
EDR Inquiry:	7906442.3
Order Date:	02/24/2025
Certification #:	EC34-4D4C-B1E6
Copyright	1995

This Certified Sanborn Map combines the following sheets.
Outlined areas indicate map sheets within the collection.





Volume 1, Sheet 6
Volume 1, Sheet 1
Volume 1, Sheet 2

0 Feet 150 300 600

N

The certified Sanborn Library search results in this report can be authenticated by visiting www.edrnet.com/sanborn and entering the certification number. Only Environmental Data Resources Inc. (EDR) is authorized to grant rights for commercial reproduction of maps by The Sanborn Library LLC, the copyright holder for the collection.

Certification # EC34-4D4C-B1E6



Site Name:	100 Main Street
Address:	100 Main Street
City, ST, ZIP:	White Plains, NY 10601
Client:	SESI Consulting Engineers
EDR Inquiry:	7906442.3
Order Date:	02/24/2025
Certification #:	EC34-4D4C-B1E6
Copyright	1994

This Certified Sanborn Map combines the following sheets.
Outlined areas indicate map sheets within the collection.



Volume 1, Sheet 2
Volume 1, Sheet 1
Volume 1, Sheet 7
Volume 1, Sheet 6

0 Feet 150 300 600

N

The certified Sanborn Library search results in this report can be authenticated by visiting www.edrnet.com/sanborn and entering the certification number. Only Environmental Data Resources Inc. (EDR) is authorized to grant rights for commercial reproduction of maps by The Sanborn Library LLC, the copyright holder for the collection.

Certification # EC34-4D4C-B1E6



Site Name:	100 Main Street
Address:	100 Main Street
City, ST, ZIP:	White Plains, NY 10601
Client:	SESI Consulting Engineers
EDR Inquiry:	7906442.3
Order Date:	02/24/2025
Certification #:	EC34-4D4C-B1E6
Copyright	1993

This Certified Sanborn Map combines the following sheets.
Outlined areas indicate map sheets within the collection.



Volume 1, Sheet 1
Volume 1, Sheet 6
Volume 1, Sheet 2

0 Feet 150 300 600

N

Certified Sanborn® Map

1992



The certified Sanborn Library search results in this report can be authenticated by visiting www.edrnet.com/sanborn and entering the certification number. Only Environmental Data Resources Inc. (EDR) is authorized to grant rights for commercial reproduction of maps by The Sanborn Library LLC, the copyright holder for the collection.

Certification # EC34-4D4C-B1E6

Site Name:	100 Main Street
Address:	100 Main Street
City, ST, ZIP:	White Plains, NY 10601
Client:	SESI Consulting Engineers
EDR Inquiry:	7906442.3
Order Date:	02/24/2025
Certification #	EC34-4D4C-B1E6
Copyright	1992

This Certified Sanborn Map combines the following sheets.
Outlined areas indicate map sheets within the collection.





Volume 1, Sheet 2
Volume 1, Sheet 1
Volume 1, Sheet 6

0 Feet 150 300 600

N

The certified Sanborn Library search results in this report can be authenticated by visiting www.edrnet.com/sanborn and entering the certification number. Only Environmental Data Resources Inc. (EDR) is authorized to grant rights for commercial reproduction of maps by The Sanborn Library LLC, the copyright holder for the collection.

Certification # EC34-4D4C-B1E6



Site Name:	100 Main Street
Address:	100 Main Street
City, ST, ZIP:	White Plains, NY 10601
Client:	SESI Consulting Engineers
EDR Inquiry:	7906442.3
Order Date:	02/24/2025
Certification #:	EC34-4D4C-B1E6
Copyright	1990

This Certified Sanborn Map combines the following sheets.
Outlined areas indicate map sheets within the collection.





Volume 1, Sheet 6
Volume 1, Sheet 2
Volume 1, Sheet 1

0 Feet 150 300 600

N

The certified Sanborn Library search results in this report can be authenticated by visiting www.edrnet.com/sanborn and entering the certification number. Only Environmental Data Resources Inc. (EDR) is authorized to grant rights for commercial reproduction of maps by The Sanborn Library LLC, the copyright holder for the collection.

Certification # EC34-4D4C-B1E6



Site Name:	100 Main Street
Address:	100 Main Street
City, ST, ZIP:	White Plains, NY 10601
Client:	SESI Consulting Engineers
EDR Inquiry:	7906442.3
Order Date:	02/24/2025
Certification #:	EC34-4D4C-B1E6
Copyright	1989

This Certified Sanborn Map combines the following sheets.
Outlined areas indicate map sheets within the collection.



Volume 1, Sheet 6
Volume 1, Sheet 1
Volume 1, Sheet 2

0 Feet 150 300 600

N

The certified Sanborn Library search results in this report can be authenticated by visiting www.edrnet.com/sanborn and entering the certification number. Only Environmental Data Resources Inc. (EDR) is authorized to grant rights for commercial reproduction of maps by The Sanborn Library LLC, the copyright holder for the collection.

Certification # EC34-4D4C-B1E6



Site Name:	100 Main Street
Address:	100 Main Street
City, ST, ZIP:	White Plains, NY 10601
Client:	SESI Consulting Engineers
EDR Inquiry:	7906442.3
Order Date:	02/24/2025
Certification #:	EC34-4D4C-B1E6
Copyright	1987

This Certified Sanborn Map combines the following sheets.
Outlined areas indicate map sheets within the collection.





Volume 1, Sheet 2
Volume 1, Sheet 1
Volume 1, Sheet 6

0 Feet 150 300 600

N

The certified Sanborn Library search results in this report can be authenticated by visiting www.edrnet.com/sanborn and entering the certification number. Only Environmental Data Resources Inc. (EDR) is authorized to grant rights for commercial reproduction of maps by The Sanborn Library LLC, the copyright holder for the collection.

Certification # EC34-4D4C-B1E6



Site Name:	100 Main Street
Address:	100 Main Street
City, ST, ZIP:	White Plains, NY 10601
Client:	SESI Consulting Engineers
EDR Inquiry:	7906442.3
Order Date:	02/24/2025
Certification #:	EC34-4D4C-B1E6
Copyright	1950

This Certified Sanborn Map combines the following sheets.
Outlined areas indicate map sheets within the collection.



Volume 1, Sheet 2
Volume 1, Sheet 6
Volume 1, Sheet 1

0 Feet 150 300 600

N

The certified Sanborn Library search results in this report can be authenticated by visiting www.edrnet.com/sanborn and entering the certification number. Only Environmental Data Resources Inc. (EDR) is authorized to grant rights for commercial reproduction of maps by The Sanborn Library LLC, the copyright holder for the collection.

Certification # EC34-4D4C-B1E6



Site Name:	100 Main Street
Address:	100 Main Street
City, ST, ZIP:	White Plains, NY 10601
Client:	SESI Consulting Engineers
EDR Inquiry:	7906442.3
Order Date:	02/24/2025
Certification #:	EC34-4D4C-B1E6
Copyright	1942

This Certified Sanborn Map combines the following sheets.
Outlined areas indicate map sheets within the collection.

0 Feet 150 300 600

Volume 2, Sheet 22
Volume 2, Sheet xxxx

N

The certified Sanborn Library search results in this report can be authenticated by visiting www.edrnet.com/sanborn and entering the certification number. Only Environmental Data Resources Inc. (EDR) is authorized to grant rights for commercial reproduction of maps by The Sanborn Library LLC, the copyright holder for the collection.

Certification # EC34-4D4C-B1E6



Site Name:	100 Main Street
Address:	100 Main Street
City, ST, ZIP:	White Plains, NY 10601
Client:	SESI Consulting Engineers
EDR Inquiry:	7906442.3
Order Date:	02/24/2025
Certification #:	EC34-4D4C-B1E6
Copyright	1930

This Certified Sanborn Map combines the following sheets.
Outlined areas indicate map sheets within the collection.



Volume 1, Sheet 6
Volume 1, Sheet 2
Volume 1, Sheet 1

0 Feet 150 300 600

N

The certified Sanborn Library search results in this report can be authenticated by visiting www.edrnet.com/sanborn and entering the certification number. Only Environmental Data Resources Inc. (EDR) is authorized to grant rights for commercial reproduction of maps by The Sanborn Library LLC, the copyright holder for the collection.

Certification # EC34-4D4C-B1E6



Site Name: 100 Main Street
Address: 100 Main Street
City, ST, ZIP: White Plains, NY 10601
Client: SESI Consulting Engineers
EDR Inquiry: 7906442.3
Order Date: 02/24/2025
Certification #: EC34-4D4C-B1E6
Copyright 1911

This Certified Sanborn Map combines the following sheets.
Outlined areas indicate map sheets within the collection.

0 Feet 150 300 600



Volume 1, Sheet 7
Volume 1, Sheet 13
Volume 1, Sheet 14

N

The certified Sanborn Library search results in this report can be authenticated by visiting www.edrnet.com/sanborn and entering the certification number. Only Environmental Data Resources Inc. (EDR) is authorized to grant rights for commercial reproduction of maps by The Sanborn Library LLC, the copyright holder for the collection.

Certification # EC34-4D4C-B1E6



This Certified Sanborn Map combines the following sheets.
Outlined areas indicate map sheets within the collection.

0 Feet 150 300 600



Volume 1, Sheet 16
Volume 1, Sheet 21
Volume 1, Sheet 22

N



The certified Sanborn Library search results in this report can be authenticated by visiting www.edrnet.com/sanborn and entering the certification number. Only Environmental Data Resources Inc. (EDR) is authorized to grant rights for commercial reproduction of maps by The Sanborn Library LLC, the copyright holder for the collection.

Site Name:	100 Main Street
Address:	100 Main Street
City, ST, ZIP:	White Plains, NY 10601
Client:	SESI Consulting Engineers
EDR Inquiry:	7906442.3
Order Date:	02/24/2025
Certification #	EC34-4D4C-B1E6
Copyright	1900

This Certified Sanborn Map combines the following sheets.
Outlined areas indicate map sheets within the collection.



Volume 1, Sheet 6
Volume 1, Sheet 7
Volume 1, Sheet 11
Volume 1, Sheet 4

0 Feet 150 300 600

N

Certified Sanborn® Map

1894


HAMILTON AV.
RAIL ROAD AV.
MARTINE AV.
LEXINGTON AV. NE
LEXINGTON
MILLWAY
RABBITT
GROVE
FIELD
ST. JOHN'S HALL 1ST PAROCHIAL SCHOOL 2ª
ST. JOHN'S R.C. CHURCH
ST. JOHN'S ACADEMY
Priests
LALANDS HOTEL & LIVERY
MORAN'S BLK
NOWILL BLDG
COX BLK
TUTTLES HOTEL
P.O.
ALBRO BLOCK
RAILROAD AV. HOTEL
WHITE PLAINS HOTEL
JOHN R. BREESE Carriage Wks.
Dairy
Bakery
HOTEL
Carriage Fact'y
Boiling Wks.
Stream
YOUNGS LIVERY
CALLANS HOTEL
UNION M.E. CO.
Village Rink
Geo. J. Powers Bowling Alley
Undertakers Storage
Poor Ho
W. YOUNG & SONS LUMBER YARD, FEED &c.
Coal Shed & Storage
Sheds
PETER MANN
SWEENYS HOTEL
Shed
Stable
Garage
Tenem.
Bl. Sm.
Fact'y
Carriage Ho.
Paint Shop
Plumbing
Tinning
Gas Fitting
Steam Heating
Sheet Metal Work
Hall 2 Sty.
2 Gro.
Store
Dwell.
Offices
Barber Shop
Express Office
Telegraph Office
Masonic Hall
Lodge Room
Bank
Safe
Vault
Clothing
Dry Goods
Millinery
Boots & Shoes
Jewelry
Meat Market
Grocery
Liquors
Saloon
Billiard Room
Bowling Alley
Restaurant
Ice Cream
Confectionery
Fruit
Cigars
Tobacco
Barber
Tailor
Shoe Repairing
Photographs
Artist
Dentist
Physician
Lawyer
Real Estate
Insurance
Agent
Printing
Publishing
Newspaper
Express
Telegraph
Telephone
Electric Light
Gas Works
Water Works
Fire Engine House
Police Station
Court House
Jail
Public Library
Reading Room
Church
Parsonage
Sexton
Cemetery
Vacant
Lumber
Coal
Wood
Feed
Grain
Flour
Hay
Straw
Ice
Stone Cutting
Marble Works
Monuments
Granite
Slate
Roofing
Paper Hanging
Painting
Glazing
Upholstering
Furniture
Carpets
Oil Cloths
Mattresses
Bedding
Pianos
Organs
Musical Instruments
Sheet Music
Toys
Fancy Goods
Notions
Hardware
Stoves
Tinware
Cutlery
Guns
Sporting Goods
Bicycles
Carriages
Harness
Saddlery
Horse Goods
Blacksmith
Horseshoeing
Wagon Shop
Machine Shop
Foundry
Iron Works
Boiler Works
Engine Works
Pump Works
Scale Works
Safe Works
Agricultural Implements
Seeds
Nursery
Florist
Greenhouse
Conservatory
Garden
Park
Fountain
Statue
Monument
Flagpole
Bandstand
Grandstand
Baseball
Football
Basketball
Tennis
Golf
Croquet
Bowling
Billiards
Pool
Cards
Chess
Checkers
Dominoes
Backgammon
Dice
Roulette
Wheel of Fortune
Gambling
Lottery
Raffle
Auction
Sale
Rent
Lease
Mortgage
Deed
Will
Estate
Trust
Bank
Insurance
Agent
Broker
Commission
Merchant
Manufacturer
Wholesale
Retail
Jobber
Peddler
Hawker
Huckster
Street Vendor
Pushcart
Wagon
Truck
Delivery
Express
Freight
Depot
Station
Yard
Track
Switch
Signal
Crossing
Bridge
Tunnel
Viaduct
Trestle
Culvert
Dam
Reservoir
Standpipe
Water Tower
Windmill
Pump
Well
Cistern
Sewer
Drain
Manhole
Catch Basin
Gutter
Curb
Sidewalk
Pavement
Macadam
Asphalt
Concrete
Brick
Cobblestone
Belgian Block
Granite Block
Wood Block
Gravel
Dirt
Mud
Snow
Ice
Rain
Wind
Storm
Flood
Fire
Smoke
Steam
Heat
Cold
Weather
Temperature
Barometer
Thermometer
Rain Gauge
Anemometer
Weather Vane
Lightning Rod
Fire Escape
Ladder
Hose
Nozzle
Hydrant
Fire Alarm
Fire Bell
Fire Whistle
Fire Horn
Fire Gong
Fire Siren
Fire Truck
Fire Engine
Fire Hose
Fire Nozzle
Fire

The certified Sanborn Library search results in this report can be authenticated by visiting www.edrnet.com/sanborn and entering the certification number. Only Environmental Data Resources Inc. (EDR) is authorized to grant rights for commercial reproduction of maps by The Sanborn Library LLC, the copyright holder for the collection.



Site Name:	100 Main Street
Address:	100 Main Street
City, ST, ZIP:	White Plains, NY 10601
Client:	SESI Consulting Engineers
EDR Inquiry:	7906442.3
Order Date:	02/24/2025
Certification #	EC34-4D4C-B1E6
Copyright	1889

This Certified Sanborn Map combines the following sheets.
Outlined areas indicate map sheets within the collection.

0 Feet 150 300 600

Volume 1, Sheet 3
Volume 1, Sheet 5
Volume 1, Sheet 4
Volume 1, Sheet 7

N



The certified Sanborn Library search results in this report can be authenticated by visiting www.edrnet.com/sanborn and entering the certification number. Only Environmental Data Resources Inc. (EDR) is authorized to grant rights for commercial reproduction of maps by The Sanborn Library LLC, the copyright holder for the collection.

Site Name:	100 Main Street
Address:	100 Main Street
City, ST, ZIP:	White Plains, NY 10601
Client:	SESI Consulting Engineers
EDR Inquiry:	7906442.3
Order Date:	02/24/2025
Certification #	EC34-4D4C-B1E6
Copyright	1885

This Certified Sanborn Map combines the following sheets.
Outlined areas indicate map sheets within the collection.



Volume 1, Sheet 2
Volume 1, Sheet 3

0 Feet 150 300 600

N

100 Main Street

100 Main Street

White Plains, NY 10601

Inquiry Number: 7906442.4

February 24, 2025

EDR Historical Topo Map Report

with QuadMatch™

6 Armstrong Road, 4th floor
Shelton, CT 06484
Toll Free: 800.352.0050
www.edrnet.com

EDR Historical Topo Map Report

02/24/25

Site Name:

100 Main Street
100 Main Street
White Plains, NY 10601
EDR Inquiry # 7906442.4

Client Name:

SESI Consulting Engineers
959 Route 46E 3rd Floor
Parsippany, NJ 07054
Contact: Annmarie Yannaco

EDR Topographic Map Library has been searched by EDR and maps covering the target property location as provided by SESI Consulting Engineers were identified for the years listed below. EDR's Historical Topo Map Report is designed to assist professionals in evaluating potential liability on a target property resulting from past activities. EDRs Historical Topo Map Report includes a search of a collection of public and private color historical topographic maps, dating back to the late 1800s.

Search Results:

P.O.# NA
Project: 12859

Coordinates:

Latitude:	41.03164 41° 1' 54" North
Longitude:	-73.770797 -73° 46' 15" West
UTM Zone:	Zone 18 North
UTM X Meters:	603329.51
UTM Y Meters:	4542997.11
Elevation:	196.89' above sea level

Maps Provided:

2021, 2019	1938
2018, 2016	1932
2015, 2013	1899, 1902
1994	1893
1979	1892
1967, 1971	
1957, 1960	
1944, 1947	

Disclaimer - Copyright and Trademark Notice

This Report contains certain information obtained from a variety of public and other sources reasonably available to Environmental Data Resources, LLC. It cannot be concluded from this Report that coverage information for the target and surrounding properties does not exist from other sources. This Report is provided on an "AS IS", "AS AVAILABLE" basis. NO WARRANTY EXPRESS OR IMPLIED IS MADE WHATSOEVER IN CONNECTION WITH THIS REPORT. ENVIRONMENTAL DATA RESOURCES, LLC AND ITS SUBSIDIARIES, AFFILIATES AND THIRD PARTY SUPPLIERS DISCLAIM ALL WARRANTIES, OF ANY KIND OR NATURE, EXPRESS OR IMPLIED, ARISING OUT OF OR RELATED TO THIS REPORT OR ANY OF THE DATA AND INFORMATION PROVIDED IN THIS REPORT, INCLUDING WITHOUT LIMITATION, ANY WARRANTIES REGARDING ACCURACY, QUALITY, CORRECTNESS, COMPLETENESS, COMPREHENSIVENESS, SUITABILITY, MERCHANTABILITY, FITNESS FOR A PARTICULAR PURPOSE, TITLE, NON-INFRINGEMENT, MISAPPROPRIATION, OR OTHERWISE. ALL RISK IS ASSUMED BY THE USER. IN NO EVENT SHALL ENVIRONMENTAL DATA RESOURCES, LLC OR ITS SUBSIDIARIES, AFFILIATES OR THIRD PARTY SUPPLIERS BE LIABLE TO ANYONE FOR ANY DIRECT, INCIDENTAL, INDIRECT, SPECIAL, CONSEQUENTIAL OR OTHER DAMAGES OF ANY TYPE OR KIND (INCLUDING BUT NOT LIMITED TO LOSS OF PROFITS, LOSS OF USE, OR LOSS OF DATA), ARISING OUT OF OR IN ANY WAY CONNECTED WITH THIS REPORT OR ANY OF THE DATA AND INFORMATION PROVIDED IN THIS REPORT. Any analyses, estimates, ratings, environmental risk levels, or risk codes provided in this Report are provided for illustrative purposes only, and are not intended to provide, nor should they be interpreted as providing any facts regarding, or prediction or forecast of, any environmental risk for any property. Only an assessment performed by a qualified environmental professional can provide findings, opinions or conclusions regarding the environmental risk or conditions in, on or at any property.

Copyright 2025 by Environmental Data Resources, Inc. All rights reserved. Reproduction in any media or format, in whole or in part, of any report or map of Environmental Data Resources, Inc., or its affiliates, is prohibited without prior written permission.

EDR and its logos (including Sanborn and Sanborn Map) are trademarks of Environmental Data Resources, LLC or its affiliates. All other trademarks used herein are the property of their respective owners.

Topo Sheet Key

This EDR Topo Map Report is based upon the following USGS topographic map sheets.

2021, 2019 Source Sheets

Glenville
2021
7.5-minute, 24000



White Plains
2019
7.5-minute, 24000

2018, 2016 Source Sheets

Glenville
2018
7.5-minute, 24000



White Plains
2016
7.5-minute, 24000

2015, 2013 Source Sheets

Glenville
2015
7.5-minute, 24000



White Plains
2013
7.5-minute, 24000

1994 Source Sheets



WHITE PLAINS
1994
7.5-minute, 24000

Topo Sheet Key

This EDR Topo Map Report is based upon the following USGS topographic map sheets.

1979 Source Sheets



White Plains
1979
7.5-minute, 24000
Aerial Photo Revised 1977

1967, 1971 Source Sheets



White Plains
1967
7.5-minute, 24000
Aerial Photo Revised 1965



Glenville
1971
7.5-minute, 24000
Aerial Photo Revised 1971

1957, 1960 Source Sheets



White Plains
1957
7.5-minute, 24000

Glenville
1960
7.5-minute, 24000
Aerial Photo Revised 1949

1944, 1947 Source Sheets

Glenville
1944
7.5-minute, 24000
Aerial Photo Revised 1941



White Plains
1947
7.5-minute, 24000
Aerial Photo Revised 1940

Topo Sheet Key

This EDR Topo Map Report is based upon the following USGS topographic map sheets.

1938 Source Sheets

White Plains
1938
7.5-minute, 31680

1932 Source Sheets

White Plains
1932
7.5-minute, 24000

1899, 1902 Source Sheets

Stamford
1899
15-minute, 62500



Tarrytown
1902
15-minute, 62500

1893 Source Sheets

Tarrytown
1893
15-minute, 62500



Stamford
1893
15-minute, 62500

Topo Sheet Key

This EDR Topo Map Report is based upon the following USGS topographic map sheets.

1892 Source Sheets



Tarrytown
1892
15-minute, 62500



Stamford
1892
15-minute, 62500

Historical Topo Map

2021, 2019



This report includes information from the following map sheet(s).

0 Miles 0.25 0.5 1 1.5

NW N NE
W E
SW S SE

TP, White Plains, 2019, 7.5-minute
NE, Glenville, 2021, 7.5-minute

SITE NAME: 100 Main Street
ADDRESS: 100 Main Street
White Plains, NY 10601
CLIENT: SESI Consulting Engineers

N



This report includes information from the following map sheet(s).

0 Miles 0.25 0.5 1 1.5

NW N NE
W E
SW S SE

TP, White Plains, 2016, 7.5-minute
NE, Glenville, 2018, 7.5-minute

SITE NAME: 100 Main Street
ADDRESS: 100 Main Street
White Plains, NY 10601
CLIENT: SESI Consulting Engineers

N

Historical Topo Map

2015, 2013



This report includes information from the following map sheet(s).

0 Miles 0.25 0.5 1 1.5

NW N NE
W E
SW S SE

TP, White Plains, 2013, 7.5-minute
NE, Glenville, 2015, 7.5-minute

SITE NAME: 100 Main Street
ADDRESS: 100 Main Street
White Plains, NY 10601
CLIENT: SESI Consulting Engineers

N



This report includes information from the following map sheet(s).

0 Miles 0.25 0.5 1 1.5

NW N NE
W E
SW S SE

TP, WHITE PLAINS, 1994, 7.5-minute

SITE NAME: 100 Main Street
ADDRESS: 100 Main Street
White Plains, NY 10601
CLIENT: SESI Consulting Engineers

N



This report includes information from the following map sheet(s).

0 Miles 0.25 0.5 1 1.5

NW N NE
W E
SW S SE

TP, White Plains, 1979, 7.5-minute

SITE NAME: 100 Main Street
ADDRESS: 100 Main Street
White Plains, NY 10601
CLIENT: SESI Consulting Engineers

N



This report includes information from the following map sheet(s).

0 Miles 0.25 0.5 1 1.5



TP, White Plains, 1967, 7.5-minute
NE, Glenville, 1971, 7.5-minute

SITE NAME: 100 Main Street
ADDRESS: 100 Main Street
White Plains, NY 10601
CLIENT: SESI Consulting Engineers

N



This report includes information from the following map sheet(s).

0 Miles 0.25 0.5 1 1.5

NW N NE
W E
SW S SE

TP, White Plains, 1957, 7.5-minute
NE, Glenville, 1960, 7.5-minute

SITE NAME: 100 Main Street
ADDRESS: 100 Main Street
White Plains, NY 10601
CLIENT: SESI Consulting Engineers

N



This report includes information from the following map sheet(s).

0 Miles 0.25 0.5 1 1.5

NW N NE
W E
SW S SE

TP, White Plains, 1947, 7.5-minute
NE, Glenville, 1944, 7.5-minute

SITE NAME: 100 Main Street
ADDRESS: 100 Main Street
White Plains, NY 10601
CLIENT: SESI Consulting Engineers

N

This report includes information from the following map sheet(s).

0 Miles 0.25 0.5 1 1.5

NW N NE
W E
SW S SE

TP, White Plains, 1938, 7.5-minute

SITE NAME: 100 Main Street
ADDRESS: 100 Main Street
White Plains, NY 10601
CLIENT: SESI Consulting Engineers

N

This report includes information from the following map sheet(s).

0 Miles 0.25 0.5 1 1.5

NW N NE
W E
SW S SE

TP, White Plains, 1932, 7.5-minute

SITE NAME: 100 Main Street
ADDRESS: 100 Main Street
White Plains, NY 10601
CLIENT: SESI Consulting Engineers

N



This report includes information from the following map sheet(s).

0 Miles 0.25 0.5 1 1.5

NW N NE
W E
SW S SE

TP, Tarrytown, 1902, 15-minute
NE, Stamford, 1899, 15-minute

SITE NAME: 100 Main Street
ADDRESS: 100 Main Street
White Plains, NY 10601
CLIENT: SESI Consulting Engineers

N



This report includes information from the following map sheet(s).

0 Miles 0.25 0.5 1 1.5



TP, Tarrytown, 1893, 15-minute
NE, Stamford, 1893, 15-minute

SITE NAME: 100 Main Street
ADDRESS: 100 Main Street
White Plains, NY 10601
CLIENT: SESI Consulting Engineers

N



This report includes information from the following map sheet(s).

0 Miles 0.25 0.5 1 1.5

NW N NE
W E
SW S SE

TP, Tarrytown, 1892, 15-minute
NE, Stamford, 1892, 15-minute

SITE NAME: 100 Main Street
ADDRESS: 100 Main Street
White Plains, NY 10601
CLIENT: SESI Consulting Engineers

N

Appendix D:

Environmental Reports and Relevant Historical Documents

SESI
CONSULTING ENGINEERS

Geotechnical
Environmental
Site Civil

959 Route 46E, Fl 3, Ste 300
Parsippany, NJ 07054
973.808.9050
www.sesi.org

Phase II Environmental Site Assessment Report

For:

80 Main Street

White Plains, Westchester County, NY

Prepared for:

MLK Developers LLC

SESI Project No:
12859

Date:
February 2026

TABLE OF CONTENTS

LIST OF ACRONYMS ..... **I**
1.0 INTRODUCTION **1**
1.1 SUBJECT PROPERTY SETTING 1
1.2 SUBJECT PROPERTY HISTORY 1
2.0 FIELD INVESTIGATION **2**
3.0 ANALYTICAL RESULTS **3**
3.1 SOIL INVESTIGATION RESULTS 3
3.2 GROUNDWATER INVESTIGATION RESULTS 6
3.3 SOIL VAPOR INVESTIGATION RESULTS 7
4.0 CONCLUSIONS AND RECOMMENDATIONS **9**

TABLES

TABLE 2.1 SUMMARY OF SAMPLE COLLECTION
TABLE 3.1 SUMMARY OF SOIL SAMPLE RESULTS
TABLE 3.2 SUMMARY OF SOIL SAMPLE EXCEEDANCES
TABLE 3.3 SUMMARY OF GROUNDWATER ANALYTICAL RESULTS
TABLE 3.4 SUMMARY OF GROUNDWATER EXCEEDANCES
TABLE 3.5 SUMMARY OF SOIL VAPOR RESULTS
TABLE 3.6 SUMMARY OF SOIL VAPOR DETECTIONS

FIGURES

FIGURE 1.1 SUBJECT PROPERTY LOCATION MAP
FIGURE 3.1 SOIL SAMPLE LOCATION PLAN
FIGURE 3.2 GROUNDWATER SAMPLE LOCATION PLAN
FIGURE 3.3 SOIL VAPOR SAMPLE LOCATION PLAN

APPENDICES

APPENDIX A BORING LOGS
APPENDIX B LABORATORY REPORTS

LIST OF ACRONYMS

Acronym	Definition
AWQS	Class GA Ambient Water Quality Standards and Guidance Values
ft-bgs	feet below ground surface
NYSDEC	New York State Department of Environmental Conservation
NYSDOH	New York State Department of Health
PAH	Polycyclic Aromatic Hydrocarbons
PCB	Polychlorinated Biphenyls
PFAS	Per- and Polyfluoroalkyl Substances
PGWSCO	Protection of Groundwater Soil Cleanup Objectives
Phase II ESA	Phase II Environmental Site Assessment
PHC	Petroleum Hydrocarbon
RRSCO	Restricted Residential Soil Cleanup Objective
SCO	Soil Cleanup Objective
SESI	SESI Consulting Engineers, DPC
SVOC	Semi-Volatile Organic Compound
TAL	Target Analyte List
TCL	Target Compound List
USCO	Unrestricted Use Soil Cleanup Objective
UST	Underground Storage Tank
VOC	Volatile Organic Compound

1.0 INTRODUCTION

SESI Consulting Engineers (SESI) has conducted this Phase II Environmental Site Assessment (Phase II ESA) on behalf of MLK Developers LLC, for the property located at 80 Main Street, White Plains, New York ("Site"). The Site is a 1.1743-acre parcel with tax designation Section 125.75 Block 4 lot 2..2. The Site is located in a commercial/residential/government building area and the Site's use was previously a portion of the Galleria Mall. The Site is currently vacant. A Subject Property Location Map is presented as **Figure 1.1**.

This Phase II ESA report complies with the American Society for Testing and Materials Standards (ASTM E1903) and the New York State Department of Environmental Conservation (NYSDEC) Guidance Document for Site Investigations DER-10.

1.1 SUBJECT PROPERTY SETTING

The Site is composed of a 1.1743-acre parcel that has been developed with the now closed Galleria Mall. The Site is bound to the north by Main Street, to the east by Dr. Martin Luther King Blvd, to the west by a portion of the Galleria Mall at 70 Main Street, and to the south by the former Galleria Mall associated parking. The closest notable surface water body is the Bronx River located approximately 0.35 miles west of the Site.

1.2 SUBJECT PROPERTY HISTORY

The Subject Property was developed prior to 1885 based on the Sanborn Fire Insurance Maps and contained the following historic uses (circa 1885-1950) that were noted to be of concern: gas tank, carriage shop (including woodworking), several blacksmiths with painting, marble cutter, cabinet shop, furniture repair, tailor, several printing shops (one with gas engine), laundry, tailors several paint and oil shops, cobbler, several upholstery shops, and bicycle repair shop. The Galleria Mall was constructed in approximately 1980. The ground floor of the Subject Property was previously improved with a Blink Fitness gym as well as storage rooms, a mechanical room, an electrical room, common spaces for the mall, and a loading dock. The second through fourth floors consisted of retail and common spaces associated with the Galleria Mall.

2.0 FIELD INVESTIGATION

SESI collected soil samples, groundwater samples, and sub-slab vapor samples and collocated indoor air samples for the investigation of REC's identified in the Phase I ESA from April 2023 to April 2024. **Table 2.1** attached presents a summary of the borings conducted and the samples collected. All samples were transported under chain of custody to Alpha Laboratories and SGS North America, New York State Department of Health (NYSDOH) Environmental Laboratory Accreditation Program-certified laboratories. Prior to conducting subsurface drilling, SESI's drilling contractors contacted New York's utility mark-out system.

Soil and groundwater samples were analyzed for Target Compound List (TCL) +30/Target Analyte List (TAL) list including volatile organic compounds (VOCs) by EPA Method 8260, semi-VOCs (SVOCs) by EPA Method 8270, TAL metals, polychlorinated biphenyls (PCBs) by EPA Method 8082A, and pesticides by EPA Method 8081, in addition to cyanide. Additionally, certain soil and groundwater samples were analyzed for per and polyfluoroalkyl substances (PFAS) by EPA Method 1633 and 1,4 dioxane by EPA Method 8270D SIM. Soil vapor samples were analyzed for VOCs in accordance with EPA Method TO-15.

The borings were advanced to depths ranging from 5 to 20 feet below ground surface (ft-bgs). Based on the subsurface investigations conducted to date, the stratigraphy of the Subject Property, from the surface down, consists of fill material below surface cover to depths of approximately up to 13 ft-bgs. Fill material is underlain by brown coarse to fine sand, some gravel and trace silt to boring completion. Based on review of the Remedial Investigation Report from an upgradient nearby Brownfield Cleanup Program Site (C360073) to the northeast (221 Main Street), the elevation of groundwater at the subject property is approximately 180-200 feet above mean sea level, and groundwater flow direction is expected to be in the western direction. Photoionization detector readings and detailed soil descriptions are provided in the boring logs presented in **Appendix A**.

3.0 ANALYTICAL RESULTS

3.1 SOIL INVESTIGATION RESULTS

The soil samples were sent to SGS and Alpha Laboratories under a Chain of Custody for the analysis of the TCL+30/TAL suite of parameters, which include VOCs by EPA Method 8260C, SVOCs by EPA Method 8270D, TAL metals by EPA Method 6010C/7471, PCBs by EPA Method 8082A, pesticides by EPA Method 8081B, and cyanide by EPA Method 9082. In addition, certain samples were analyzed for PFAS by EPA Method 1633, and 1,4 dioxane by EPA Method 8270D SIM.

A summary table of the analytical results for samples collected compared to NYSDEC Unrestricted Use Soil Cleanup Objectives (USCOs), Restricted Residential Cleanup Objectives (RRSCOs), the Protection of Groundwater Soil Cleanup Objectives (PGWQSOs), and the latest NYSDEC Soil Screening Levels for emerging contaminants (NYSDEC Guidelines for Sampling and Analysis of PFAS Under NYSDEC's Part 375 Remedial Programs) is presented in **Table 3.1**. A summary of the samples exceeding the soil cleanup objectives (SCOs) is presented on **Table 3.2** below and on **Figure 3.1**. The laboratory analytical data is provided in **Appendix B.**

As shown on **Table 3.2** below and **Figure 3.1**, based on the results of soil sampling conducted, the following observations were made:

- VOCs were found to exceed the USCOs and Protection of Groundwater Soil Cleanup Objectives (PGWSCOs) on the Site from grade to 10 ft-bgs (SB-5G[9.5-10]).
- SVOCs (primarily polycyclic aromatic hydrocarbons [PAHs]) were found to exceed the PGWSCOs, RRSCOs or USCOs throughout the Site from grade to 6.5 ft-bgs (SB-10G[6-6.5]).
- Metals were found above the USCOs throughout the Site to depths ranging from grade to 5.5 ft-bgs (SB-7G[5-5.5]).
- Pesticides were found above the USCOs to 4 ft-bgs at the southern and northern portions of the Site (SB-22 [3.5-4]) and SB-45G [3.5-4]).

Table 3.2: Summary of Soil Sample Exceedances

SAMPLE ID	PGWSCOs	RRSCOs	USCOs	Units	SB-5G (3-3.5)		SB-5G (9.5-10)		SB-7G (5-5.5)		SB-10G (6-6.5)	
LAB ID					L2317575-07		L2317575-08		L2317575-05		L2317865-03	
SAMPLE DATE					4/4/2023		4/4/2023		4/4/2023		4/5/2023	
					Results	Qual	Results	Qual	Results	Qual	Results	Qual
Semivolatile Organics by GC/MS												
Acenaphthene	98	100	20	mg/kg	0.34		0.15	U	0.15	U	53	
Anthracene	1000	100	100	mg/kg	2		0.038	J	0.11	U	180	
Benzo(a)anthracene	1	1.4	1	mg/kg	6.1		0.13		0.044	J	200	
Benzo(a)pyrene	22	1	1	mg/kg	6		0.14	J	0.054	J	180	
Benzo(b)fluoranthene	2.1	1.4	1	mg/kg	7.2	J	0.15		0.061	J	210	
Benzo(k)fluoranthene	2	4.9	0.8	mg/kg	2.6		0.06	J	0.11	U	68	
Chrysene	1	4.9	1	mg/kg	5.2		0.12		0.043	J	180	
Benzo(ghi)perylene	1000	4.9	0.64	mg/kg	2.4		0.068	J	0.03	J	100	
Fluoranthene	1000	100	85	mg/kg	13	E	0.2		0.1	J	540	
Fluorene	386	100	30	mg/kg	0.53		0.18	U	0.19	U	90	
Phenanthrene	1000	4.9	1.1	mg/kg	8.2		0.13		0.06	J	850	
Dibenzo(a,h)anthracene	1000	0.33	0.33	mg/kg	0.77		0.11	U	0.11	U	28	
Dibenzofuran	110	18	2.1	mg/kg	0.21		0.18	U	0.19	U	110	
Indeno(1,2,3-cd)pyrene	6.6	1.4	0.5	mg/kg	3.1		0.083	J	0.033	J	95	
Pyrene	1000	100	64	mg/kg	11	E	0.2		0.088	J	400	
Naphthalene	12	100	12	mg/kg	0.034	J	0.18	U	0.19	U	110	
Total Metals												
Lead, Total	450	400	63	mg/kg	14		13.2		70.5		19.7	
Mercury, Total	0.73	0.3	0.18	mg/kg	0.066	U	0.73	U	0.175		0.053	J
Volatile Organics by EPA 5035/8260												
Acetone	0.03	100	0.03	mg/kg	0.0051	J	0.032		0.021		0.33	
Organochlorine Pesticides by GC												
4,4'-DDE	9.3	3.4	0.0033	mg/kg	0.00168	U	0.00175	U	0.0183	U	0.00171	U

LOCATION	PGWSCOs	RRSCOs	USCOs	Units	SB-12G (4-4.5)		SB-21G (9-9.5)		SB-45G(3.5-4)	
SAMPLING DATE					L2317865-06		L2331226-02		L2341039-02	
SAMPLE TYPE					4/5/2023		6/5/2023		7/18/2023	
					Results	Qual	Results	Qual	Results	Qual
Semivolatile Organics by GC/MS										
Acenaphthene	98	100	20	mg/kg	0.049	J	0.14	U	0.13	J
Anthracene	1000	100	100	mg/kg	0.1	J	0.11	U	0.33	
Benzo(a)anthracene	1	1.4	1	mg/kg	0.22		0.033	J	0.83	
Benzo(a)pyrene	22	1	1	mg/kg	0.18		0.14	U	0.78	
Benzo(b)fluoranthene	2.1	1.4	1	mg/kg	0.2		0.043	J	0.96	
Benzo(k)fluoranthene	2	4.9	0.8	mg/kg	0.081	J	0.11	U	0.3	
Chrysene	1	4.9	1	mg/kg	0.21		0.029	J	0.79	
Benzo(ghi)perylene	1000	4.9	0.64	mg/kg	0.091	J	0.14	U	0.43	
Fluoranthene	1000	100	85	mg/kg	0.43		0.057	J	1.8	
Fluorene	386	100	30	mg/kg	0.052	J	0.18	U	0.14	J
Phenanthrene	1000	4.9	1.1	mg/kg	0.36		0.028	J	1.2	
Dibenzo(a,h)anthracene	1000	0.33	0.33	mg/kg	0.025	J	0.11	U	0.11	
Dibenzofuran	110	18	2.1	mg/kg	0.026	J	0.18	U	0.085	J
Indeno(1,2,3-cd)pyrene	6.6	1.4	0.5	mg/kg	0.1	J	0.14	U	0.51	
Pyrene	1000	100	64	mg/kg	0.38		0.048	J	1.5	
Naphthalene	12	100	12	mg/kg	0.18	U	0.18	U	0.076	J
Total Metals										
Lead, Total	450	400	63	mg/kg	29.4		4.18	J	131	
Mercury, Total	0.73	0.3	0.18	mg/kg	0.185		0.069	U	0.236	
Volatile Organics by EPA 5035/8260										
Acetone	0.03	100	0.03	mg/kg	0.0095	U	0.091		0.0098	U
Organochlorine Pesticides by GC										
4,4'-DDE	9.3	3.4	0.0033	mg/kg	0.000711	JIP	0.0017	U	0.00655	

Notes

Concentration Exceeds the USCO

Concentration Exceeds the PGWSCO or RRSCO

PGWSCOs: New York 2025 NYCRR Part 375 Groundwater Criteria, New York Restricted use Criteria per 6 NYCRR Part 375 Environmental Remediation Programs, effective 12/2006 amended 12/2025.

RRSCOs: New York 2025 NYCRR Part 375 Restricted-Residential Criteria, New York Restricted use Criteria per 6 NYCRR Part 375 Environmental Remediation Programs, effective 12/2006 amended 12/2025.

USCOs: New York 2025 NYCRR Part 375 New York Unrestricted use Criteria Criteria per 6 NYCRR Part 375 Environmental Remediation Programs, effective 12/2006 amended 12/2025.

mg/Kg = Milligrams per Kilogram

d = Associated CCV outside of control limits low. Low-level verification was analyzed to demonstrate system suitability to detect affected analytes. Estimated value, due to corresponding failure in the batch associated CCV.

J = Estimated concentration

E = Concentration Exceeds the calibrated analysis range

SAMPLE ID	PGWSCOs	RRSCOs	USCOs	Units	SB-22(3.5-4)030724	SB-22(8-8.5)030724	SB-25(1.5-2)030724	SB-25(3-3.5)030724	SB-25(7.5-8)030724
LAB ID					JD83927-14	JD83927-15	JD83927-16	JD83927-17	JD83927-18
SAMPLE DATE					3/7/2024 11:25 AM	3/7/2024 11:30 AM	3/7/2024 12:00 PM	3/7/2024 12:05 PM	3/7/2024 12:10 PM
(GC/LC Semi-volatiles (SW846 8081B))									
Dieldrin	0.1	0.075	0.005	mg/kg	0.0094	0.00029 J	0.0021	ND (0.000064)	ND (0.000066)
4,4'-DDT	135	3.8	0.0033	mg/kg	0.0054	0.00045	0.00084 °	0.0008 °	ND (0.000072)
(MS Semi-volatiles (SW846 8270E))									
Benzo(a)anthracene	1	1.4	1	mg/kg	ND (0.0096)	0.107	4.37	0.504	0.0478
Benzo(a)pyrene	22	1	1	mg/kg	ND (0.015)	0.119	4.72	0.507	0.0476
Benzo(b)fluoranthene	2.1	1.4	1	mg/kg	ND (0.015)	0.127	5.92	0.504	0.0429
Benzo(g,h,i)perylene	1000	4.9	0.64	mg/kg	0.0236 J	0.0879	3.35	0.269	0.0354
Benzo(k)fluoranthene	2	4.9	0.8	mg/kg	ND (0.016)	0.0411	2.14	0.198	0.023 J
Chrysene	1	4.9	1	mg/kg	ND (0.011)	0.105	4.89	0.444	0.0336 J
Dibenzo(a,h)anthracene	1000	0.33	0.33	mg/kg	ND (0.015)	0.023 J	0.925	0.0717	ND (0.015)
Indeno(1,2,3-cd)pyrene	6.6	1.4	0.5	mg/kg	ND (0.016)	0.0602	2.77	0.229	0.0229 J
Phenanthrene	1000	4.9	1.1	mg/kg	ND (0.011) [b]	0.102 [d]	1.51 [d]	0.293 [d]	0.0309 J [d]

Notes

Concentration Exceeds the USCO

Concentration Exceeds the PGWSCO or RRSCO

PGWSCOs: New York 2025 NYCRR Part 375 Groundwater Criteria, New York Restricted use Criteria per 6 NYCRR Part 375 Environmental Remediation Programs, effective 12/2006 amended 12/2025.

RRSCOs: New York 2025 NYCRR Part 375 Restricted-Residential Criteria, New York Restricted use Criteria per 6 NYCRR Part 375 Environmental Remediation Programs, effective 12/2006 amended 12/2025.

USCOs: New York 2025 NYCRR Part 375 New York Unrestricted use Criteria Criteria per 6 NYCRR Part 375 Environmental Remediation Programs, effective 12/2006 amended 12/2025.

mg/Kg = Milligrams per Kilogram

d = Associated CCV outside of control limits low. Low-level verification was analyzed to demonstrate system suitability to detect affected analytes. Estimated value, due to corresponding failure in the batch associated CCV.

J = Estimated concentration

E = Concentration Exceeds the calibrated analysis range

3.2 GROUNDWATER INVESTIGATION RESULTS

Three (3) groundwater temporary wellpoints were installed and sampled by SESI in April 2023 and June 2023. A total of three (3) groundwater samples were collected and analyzed for various parameters including VOCs by EPA Method 8260C, SVOCs by EPA Method 8270D, TAL metals by EPA Method 6010C/7471, PCBs by EPA Method 8082A, pesticides by EPA Method 8081B, cyanide by EPA Method 9082, PFAS by EPA Method 1633 and 1.4-dioxane by EPA Method 8270D SIM. Metals compounds were analyzed for total metals (unfiltered). A summary table of the analytical results compared to NYSDEC Technical and Operational Guidance Series 1.1.1 Class GA Ambient Water Quality Standards and Guidance Values (AWQS) is presented on **Table 3.3**. A summary of compounds exceeding the AWQS is presented on **Table 3.4** below and on **Figure 3.2**. The laboratory analytical reports are provided in **Appendix B**.

As presented on **Table 3.4** and **Figure 3.2**, the groundwater analytical results indicate consistent concentrations of VOCs, SVOCs, metals, and PFAS were found to exceed the AWQS throughout the Site.

Table 3.4: Summary of Groundwater Sample Exceedances

SAMPLE ID:		GW-8		GW-9		GW-10	
COLLECTION DATE:		4/7/2023		4/7/2023		6/5/2023	
ANALYTES	AWQS	Conc	Q	Conc	Q	Conc	Q
Acetone	50	72		11		2.2	J
Styrene	5	16		8.3		ND	
Perfluorooctanesulfonic Acid (PFOS)	2.7	11.6		24.1		-	-
Perfluorooctanoic Acid (PFOA)	6.7	7.4		29		-	-
Phenol	1	0.72	J	1.2	J	ND	
Benzo(a)anthracene	0.002	ND		6.1		0.03	J
Benzo(a)pyrene	0	ND		6.4		0.02	J
Benzo(b)fluoranthene	0.002	ND		7.2		0.02	J
Benzo(k)fluoranthene	0.002	ND		2.4		0.01	J
Chrysene	0.002	ND		5.5		0.03	J
Indeno(1,2,3-cd)pyrene	0.002	ND		3.7		ND	
Arsenic, Total	25	15.71		26.29		8.26	
Barium, Total	1000	1934		2441		1905	
Beryllium, Total	3	3.22		3.59		1.89	
Chromium, Total	50	235		453.1		177.2	
Copper, Total	200	477		426		234.6	
Iron, Total	300	172000		205000		124000	
Lead, Total	25	88.21		213		68.99	
Magnesium, Total	35000	267000		190000		152000	
Manganese, Total	300	4584		9555		4414	
Mercury, Total	0.7	0.22		1.88		ND	
Nickel, Total	100	179		206.9		123.4	
Selenium, Total	10	29.7		42.2		8.12	
Sodium, Total	20000	223000		480000		160000	
Thallium, Total	0.5	1.5		1.37	J	1.35	

Notes
NYSDEC AWQS - New York State Department of Environmental Conservation Ambient Water Quality Standard
Exceedance of the NYSDEC AWQS
J = Estimated
ND = Not Detected

3.3 SOIL VAPOR INVESTIGATION RESULTS

Two (2) soil vapor samples and two (2) indoor air samples were collected from temporary points in April 2023. The soil vapor samples were analyzed for VOCs in accordance with EPA Method TO-15. A summary of the analytical results is presented on **Table 3.5**. A summary of the soil vapor and indoor air detections is presented on **Table 3.6** below and **Figure 3.3**. The laboratory analytical report is provided in **Appendix B**.

The concentrations of soil vapor compounds were evaluated against the NYSDOH Soil Vapor/Indoor Air decision matrices for comparison purposes only. As presented on **Table 3.6** below, the results indicate detections of chlorinated VOCs and petroleum hydrocarbon (PHC) VOCs in indoor air and soil vapor.

Table 3.6: Summary of Soil Vapor Detections

SAMPLE ID:											IA-9		SSV-9	
LAB ID:											L2318681-01		L2318681-03	
COLLECTION DATE:											4/7/2023		4/7/2023	
SAMPLE MATRIX:											INDOOR AIR		SOIL_VAPOR	
VOLATILE ORGANICS IN AIR (ug/m3)	IAC-A	IAC-B	IAC-D	IAC-E	IAC-F	SSC-A	SSC-B	SSC-D	SSC-E	SSC-F	Conc	RL	Conc	RL
1,2,4-Trimethylbenzene			2					60			1.45	0.983	18.7	13.2
1,3,5-Trimethylbenzene			2					60			ND	0.983	ND	13.2
1,3-Butadiene											1.46	0.442	38.7	5.95
2,2,4-Trimethylpentane			2					60			1.23	0.934	ND	12.6
2-Butanone											ND	1.47	1150	19.8
4-Ethyltoluene											ND	0.983	21	13.2
Acetone											14.8	2.38	4320	32.1
Benzene			2					60			3.48	0.639	37.1	8.59
Carbon disulfide											ND	0.623	14	8.38
Carbon tetrachloride	0.2					6					0.51	0.126	ND	16.9
Chloroform											ND	0.977	31.3	13.1
Chloromethane											1.07	0.413	ND	5.55
Cyclohexane			2					60			ND	0.688	ND	9.26
Dichlorodifluoromethane											2.71	0.989	ND	13.3
Ethanol											22.4	9.42	976	127
Ethylbenzene			2					60			1.46	0.869	886	11.7
Heptane				6					200		1.07	0.82	16.2	11
Isopropanol											2.1	1.23	225	16.5
Methylene chloride		3					100				ND	1.74	ND	23.4
n-Hexane				6					200		1.96	0.705	16.2	9.48
o-Xylene			2					60			1.89	0.869	66.5	11.7
p/m-Xylene				6					200		5.26	1.74	77.3	23.4
Tertiary butyl Alcohol											6.4	1.52	92.2	20.4
Tetrachloroethene		3					100				0.176	0.136	27.5	18.2
Toluene					10					300	6.1	0.754	43.3	10.1
Trichlorofluoromethane											1.39	1.12	ND	15.1

Notes

SSC-A: New York DOH Matrix A Sub-slab Vapor Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

SSC-B: New York DOH Matrix B Sub-slab Vapor Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

SSC-D: New York DOH Matrix D Sub-slab Vapor Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

SSC-E: New York DOH Matrix E Sub-slab Vapor Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

SSC-F: New York DOH Matrix F Sub-slab Vapor Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

IAC-A: New York DOH Matrix A Indoor Air Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

IAC-B: New York DOH Matrix A Indoor Air Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

IAC-D: New York DOH Matrix A Indoor Air Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

IAC-E: New York DOH Matrix A Indoor Air Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

IAC-F: New York DOH Matrix A Indoor Air Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

Exceedance of a IAC/SSC NYDOH Matrix

SAMPLE ID:											IA-10		SSV-10	
LAB ID:											L2318681-02		L2318681-04	
COLLECTION DATE:											4/7/2023		4/7/2023	
SAMPLE MATRIX:											INDOOR AIR		SOIL_VAPOR	
VOLATILE ORGANICS IN AIR (ug/m3)	IAC-A	IAC-B	IAC-D	IAC-E	IAC-F	SSC-A	SSC-B	SSC-D	SSC-E	SSC-F	Conc	RL	Conc	RL
1,2,4-Trimethylbenzene			2					60			1.47	0.983	5.6	5.46
1,3,5-Trimethylbenzene			2					60			ND	0.983	ND	5.46
1,3-Butadiene											1.67	0.442	90.9	2.46
2,2,4-Trimethylpentane			2					60			1.45	0.934	ND	5.18
2-Butanone											3.07	1.47	378	8.2
4-Ethyltoluene											ND	0.983	8.65	5.46
Acetone											30.6	2.38	2680	13.2
Benzene			2					60			4.06	0.639	63.9	3.55
Carbon disulfide											ND	0.623	6.73	3.46
Carbon tetrachloride	0.2					6					0.522	0.126	ND	6.98
Chloroform											ND	0.977	ND	5.42
Chloromethane											1.08	0.413	ND	2.29
Cyclohexane			2					60			ND	0.688	ND	3.82
Dichlorodifluoromethane											2.79	0.989	418	5.49
Ethanol											9.59	9.42	409	52.4
Ethylbenzene			2					60			2.01	0.869	247	4.82
Heptane				6					200		1.16	0.82	ND	4.55
Isopropanol											ND	1.23	60.2	6.83
Methylene chloride		3					100				ND	1.74	ND	9.66
n-Hexane				6					200		2.27	0.705	5.08	3.91
o-Xylene			2					60			2.42	0.869	27.6	4.82
p/m-Xylene				6					200		7.34	1.74	133	9.64
Tertiary butyl Alcohol											ND	1.52	69.4	8.43
Tetrachloroethene		3					100				ND	0.136	16.4	7.53
Toluene					10					300	7.16	0.754	107	4.18
Trichlorofluoromethane											1.28	1.12	ND	6.24

Notes

SSC-A: New York DOH Matrix A Sub-slab Vapor Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

SSC-B: New York DOH Matrix B Sub-slab Vapor Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

SSC-D: New York DOH Matrix D Sub-slab Vapor Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

SSC-E: New York DOH Matrix E Sub-slab Vapor Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

SSC-F: New York DOH Matrix F Sub-slab Vapor Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

IAC-A: New York DOH Matrix A Indoor Air Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

IAC-B: New York DOH Matrix A Indoor Air Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

IAC-D: New York DOH Matrix A Indoor Air Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

IAC-E: New York DOH Matrix A Indoor Air Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

IAC-F: New York DOH Matrix A Indoor Air Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

Exceedance of a IAC/SSC NYDOH Matrix

4.0 CONCLUSIONS AND RECOMMENDATIONS

The exceedances in the soil, groundwater, and soil vapor reported during the investigation are likely a result of the Site's historical land use, potential presence of underground storage tanks (USTs) and the presence of contaminated historic fill.

- VOCs were found to exceed the USCOs and PGWSCOs on the Site from grade to 10 ft-bgs (SB-5G[9.5-10]). SVOCs (primarily polycyclic aromatic hydrocarbons [PAHs]) were found to exceed the PGWSCOs, RRSCOs or USCOs throughout the Site from grade to 6.5 ft-bgs (SB-10G[6-6.5]). Metals were found above the USCOs throughout the Site to depths ranging from grade to 5.5 ft-bgs (SB-7G[5-5.5]). Pesticides were found above the USCOs to 4 ft-bgs at the southern and northern portions of the Site (SB-22 [3.5-4]) and SB-45G [3.5-4]).

- VOCs, PFAS, PAHs, and metals were found in groundwater to exceed the AWQS throughout the Site, likely associated with historical uses, potential USTs, and historic fill contamination.

- Several PHC and chlorinated VOCs were detected in the soil vapor and indoor air samples, which may indicate contamination is present throughout the Site.

SESI recommends that prior to any development on the Subject Property additional investigation be conducted to delineate the extent of the VOCs, SVOCs (PAHs), metals, pesticides, and PFAS contamination in soil and to evaluate soil remedial options. The investigation should also delineate the VOC, SVOCs (PAHs), metals, and PFAS contamination in groundwater and evaluate remedial options available to comply with the AWQS. Finally, a soil vapor intrusion evaluation is recommended to address the potential for soil vapor contamination.

Tables

Table 2.1 Summary of Sample Collection
80 Main Street
White Plains, New York
SESI Project #12859

Sample Location ID	Lab ID	Sample ID	Sample/Well Depth (ft bgs)	Date Collected	Analyses
Soil Samples					
SB-5G	L2317575	SB-5G (3-3.5)	3-3.5	4/4/2023	TCL/TAL, 1,4-Dioxane
	L2317575	SB-5G (9.5-10)	9.5-10	4/4/2023	TCL/TAL, 1,4-Dioxane
SB-7G	L2317575	SB-7G (5-5.5)	5-5.5	4/4/2023	TCL/TAL, 1,4-Dioxane
SB-10G	L2317865	SB-10G (1-1.5)	1-1.5	4/5/2023	TCL/TAL, 1,4-Dioxane, PFAS
	L2317865	SB-10G (6-6.5)	6-6.5	4/5/2023	TCL/TAL, 1,4-Dioxane
SB-12G	L2317865	SB-12G (4-4.5)	4-4.5	4/5/2023	TCL/TAL, 1,4-Dioxane
SB-21G	L2331226	SB-21G (9-9.5)	9-9.5	6/5/2023	TCL/TAL
	L2331226	SB-21G (12-12.5)	12-12.5	6/5/2023	TCL/TAL
SB-45G	L2341039	SB-45G (3.5-4)	3.5-4	7/18/2023	TCL/TAL
Sample Location ID	**Lab ID**	**Sample ID**	**Sample/Well Depth (ft bgs)**	**Date Collected**	**Analyses**
Soil Samples					
SB-22	JD83927	SB-22(3.5-4)030724	3.5-4.0	3/7/2024	TCL/TAL
	JD83927	SB-22(8-8.5)030724	8.0-8.5	3/7/2024	TCL/TAL
SB-25	JD83927	SB-25(1.5-2)030724	1.5-2.0	3/7/2024	TCL/TAL
	JD83927	SB-25(3-3.5)030724	3.0-3.5	3/7/2024	TCL/TAL
	JD83927	SB-25(7.5-8)030724	7.5-8.0	3/7/2024	TCL/TAL
Groundwater Samples					
GW-8	L2318715	GW-8	NA	4/7/2023	TCL+30/TAL, PFAS. 1,4-Dioxane
GW-9	L2318715	GW-9	NA	4/7/2023	TCL+30/TAL, PFAS. 1,4-Dioxane
GW-10	L2331226	GW-10	20	6/5/2023	TCL+30/TAL
Sample Location ID	**Lab ID**	**Sample ID**	**Sample/Well Depth (ft bgs)**	**Date Collected**	**Analyses**
Air Samples					
SSV-9	L2318681	SSV-9	5	4/7/2023	TO-15
IA-9	L2318681	IA-9	NA	4/7/2023	TO-15
SSV-10	L2318681	SSV-10	5	4/7/2023	TO-15
IA-10	L2318681	IA-10	NA	4/7/2023	TO-15

NA = Not Applicable / Depth to Water was not obtained due to a lack of a depth to water meter

SESI
CONSULTING ENGINEERS

Table 3.1 - Summary of Soil Results
80 Main Street
White Plains, New York
SESI Project #12859

Client Sample ID:	CAS #	Type	Unit	PGWSCO	RRSCO	USCO	SB-22(3.5-4)030724	SB-22(8-8.5)030724	SB-25(1.5-2)030724	SB-25(3-3.5)030724	SB-25(7.5-8)030724
Lab Sample ID:							JD83927-14	JD83927-15	JD83927-16	JD83927-17	JD83927-18
Date Sampled:							3/7/2024 11:25 AM	3/7/2024 11:30 AM	3/7/2024 12:00 PM	3/7/2024 12:05 PM	3/7/2024 12:10 PM
(GC/LC Semi-volatiles (SW846 8081B))											
Aldrin	309-00-2	REG	mg/kg	0.19	0.044	0.0048	ND (0.00008)	ND (0.000074)	0.0002 J	ND (0.000078)	ND (0.00008)
alpha-BHC	319-84-6	REG	mg/kg	0.02	0.18	0.02	ND (0.000047)	ND (0.000044)	0.000078 J [c]	ND (0.000046)	ND (0.000047)
beta-BHC	319-85-7	REG	mg/kg	0.09	0.18	0.021	0.0089 [c]	ND (0.000055)	ND (0.000057)	ND (0.000058)	ND (0.00006)
delta-BHC	319-86-8	REG	mg/kg	0.1	100	0.04	ND (0.000062)	ND (0.000057)	0.00022 J [f]	ND (0.00006)	ND (0.000062)
gamma-BHC (Lindane)	58-89-9	REG	mg/kg	0.05	0.21	0.025	0.009	0.00047	ND (0.000069)	ND (0.00007)	ND (0.000072)
alpha-Chlordane	5103-71-9	REG	mg/kg	4.5	0.65	0.014	ND (0.000055)	ND (0.000052)	ND (0.000053)	ND (0.000054)	ND (0.000056)
gamma-Chlordane	5103-74-2	REG	mg/kg	NS	NS	NS	ND (0.000062)	0.00027 J [c]	ND (0.000059)	ND (0.00006)	ND (0.000062)
Dieldrin	60-57-1	REG	mg/kg	0.1	0.075	0.005	0.0094	0.00029 J	0.0021	ND (0.000064)	ND (0.000066)
4,4'-DDD	72-54-8	REG	mg/kg	14	5	0.0033	ND (0.000043)	ND (0.00004)	0.00015 J [c]	ND (0.000042)	ND (0.000043)
4,4'-DDE	72-55-9	REG	mg/kg	9.3	3.4	0.0033	ND (0.000049)	ND (0.000046)	0.0002 J [c]	ND (0.000048)	ND (0.000049)
4,4'-DDT	50-29-3	REG	mg/kg	135	3.8	0.0033	0.0054	0.00045	0.00084 [c]	0.0008 [c]	ND (0.000072)
Endrin	72-20-8	REG	mg/kg	0.06	5.3	0.014	ND (0.00006)	ND (0.000055)	ND (0.000057)	ND (0.000058)	ND (0.00006)
Endosulfan sulfate	1031-07-8	REG	mg/kg	47	35	4.3	ND (0.000049)	ND (0.000046)	ND (0.000047)	ND (0.000048)	ND (0.000049)
Endrin aldehyde	7421-93-4	REG	mg/kg	NS	NS	NS	ND (0.00012)	ND (0.00011)	ND (0.00011)	ND (0.00012)	ND (0.00012)
Endosulfan-I	959-98-8	REG	mg/kg	65	35	4.3	ND (0.000055)	ND (0.000052)	ND (0.000053)	ND (0.000054)	ND (0.000056)
Endosulfan-II	33213-65-9	REG	mg/kg	44	35	4.3	ND (0.000058)	ND (0.000053)	ND (0.000055)	ND (0.000056)	ND (0.000058)
Heptachlor	76-44-8	REG	mg/kg	0.38	0.53	0.013	0.0028 [c]	ND (0.00005)	ND (0.000051)	ND (0.000052)	ND (0.000054)
Heptachlor epoxide	1024-57-3	REG	mg/kg	NS	NS	NS	ND (0.000074)	ND (0.000069)	0.00011 J [c]	ND (0.000072)	ND (0.000074)
Methoxychlor	72-43-5	REG	mg/kg	NS	NS	NS	ND (0.00016)	ND (0.00015)	ND (0.00015)	ND (0.00016)	ND (0.00016)
Endrin ketone	53494-70-5	REG	mg/kg	NS	NS	NS	ND (0.000066)	ND (0.000061)	ND (0.000063)	ND (0.000064)	ND (0.000066)
Toxaphene	8001-35-2	REG	mg/kg	NS	NS	NS	ND (0.0034)	ND (0.0031)	ND (0.0032)	ND (0.0033)	ND (0.0034)
(GC/LC Semi-volatiles (SW846 8082A))											
Aroclor 1016	12674-11-2	REG	mg/kg	3.2	1	0.1	ND (0.0087)	ND (0.0081)	ND (0.0083)	ND (0.0085)	ND (0.0088)
Aroclor 1221	11104-28-2	REG	mg/kg	3.2	1	0.1	ND (0.0069)	ND (0.0064)	ND (0.0066)	ND (0.0067)	ND (0.0069)
Aroclor 1232	11141-16-5	REG	mg/kg	3.2	1	0.1	ND (0.017)	ND (0.016)	ND (0.016)	ND (0.017)	ND (0.017)
Aroclor 1242	53469-21-9	REG	mg/kg	3.2	1	0.1	ND (0.012)	ND (0.011)	ND (0.012)	ND (0.012)	ND (0.012)
Aroclor 1248	12672-29-6	REG	mg/kg	3.2	1	0.1	ND (0.0044)	ND (0.0041)	ND (0.0042)	ND (0.0043)	ND (0.0044)
Aroclor 1254	11097-69-1	REG	mg/kg	3.2	1	0.1	ND (0.0022)	ND (0.0021)	ND (0.0021)	ND (0.0022)	ND (0.0022)
Aroclor 1260	11096-82-5	REG	mg/kg	3.2	1	0.1	ND (0.0071)	ND (0.0066)	ND (0.0068)	ND (0.0069)	ND (0.0071)
Aroclor 1268	11100-14-4	REG	mg/kg	3.2	1	0.1	ND (0.0021)	ND (0.0019)	ND (0.002)	ND (0.002)	ND (0.0021)
Aroclor 1262	37324-23-5	REG	mg/kg	3.2	1	0.1	ND (0.0017)	ND (0.0016)	ND (0.0016)	ND (0.0017)	ND (0.0017)
(General Chemistry (SM2540 G 18TH ED MOD))											
Solids, Percent	PERCENT SOLIDS	REG	%	NS	NS	NS	95.4	95.3	94.5	94.2	93.4
(General Chemistry (SW846 9012B/LACHAT))											
Cyanide	57-12-5	REG	mg/kg	40	13	2.3	ND (0.23)	ND (0.25)	ND (0.24)	ND (0.25)	ND (0.23)
(Metals Analysis (SW846 6010D))											
Aluminum	7429-90-5	REG	mg/kg	NS	NS	NS	5500	6100	6280	6230	6410
Antimony	7440-36-0	REG	mg/kg	NS	NS	NS	ND (2.1)	ND (2.1)	ND (2.2)	ND (2.2)	ND (2.1)
Arsenic	7440-38-2	REG	mg/kg	16	16	13	ND (2.1)	ND (2.1)	ND (2.2)	ND (2.2)	ND (2.1)
Barium	7440-39-3	REG	mg/kg	820	410	410	44.1	36.5	56.9	52.4	51.4
Beryllium	7440-41-7	REG	mg/kg	47	43	4.4	0.24	0.25	0.29	0.34	0.32
Cadmium	7440-43-9	REG	mg/kg	7.5	2.5	2.5	ND (0.52)	ND (0.53)	ND (0.55)	ND (0.55)	ND (0.54)
Calcium	7440-70-2	REG	mg/kg	NS	NS	NS	14800	5950	13300	12700	11200
Chromium	7440-47-3	REG	mg/kg	NS	NS	NS	11	10.6	12.8	13.6	12.8
Cobalt	7440-48-4	REG	mg/kg	NS	NS	NS	ND (5.2)	ND (5.3)	ND (5.5)	ND (5.5)	ND (5.4)
Copper	7440-50-8	REG	mg/kg	1720	280	50	12.5	11.5	14.8	15.7	14.6
Iron	7439-89-6	REG	mg/kg	NS	NS	NS	10800	11700	12000	11200	12300
Lead	7439-92-1	REG	mg/kg	450	400	63	8.1	10.3	27.1	24.8	11.1
Magnesium	7439-95-4	REG	mg/kg	NS	NS	NS	9810	4610	8240	7830	7480
Manganese	7439-96-5	REG	mg/kg	2000	2000	1600	189	197	181	147	193
Nickel	7440-02-0	REG	mg/kg	130	320	30	9.6	11.1	10.3	10.8	10.6
Potassium	7440-09-7	REG	mg/kg	NS	NS	NS	1850	1340	1740	1600	1970
Selenium	7782-49-2	REG	mg/kg	4	110	3.9	ND (2.1)	ND (2.1)	ND (2.2)	ND (2.2)	ND (2.1)
Silver	7440-22-4	REG	mg/kg	8.3	110	2	ND (0.52)	ND (0.53)	ND (0.55)	ND (0.55)	ND (0.54)
Sodium	7440-23-5	REG	mg/kg	NS	NS	NS	ND (1000)	ND (1100)	ND (1100)	ND (1100)	ND (1100)
Thallium	7440-28-0	REG	mg/kg	NS	NS	NS	ND (1.0)	ND (1.1)	ND (1.1)	ND (1.1)	ND (1.1)
Vanadium	7440-62-2	REG	mg/kg	NS	NS	NS	16.5	15.2	18.2	17	18.4
Zinc	7440-66-6	REG	mg/kg	2480	6600	109	28.7	30.8	44.4	55.9	33.6
(Metals Analysis (SW846 7471B))											
Mercury	7439-97-6	REG	mg/kg	0.73	0.3	0.18	ND (0.032)	0.066	0.061	0.1	0.035

SESI CONSULTING ENGINEERS

Table 3.1 - Summary of Soil Results
80 Main Street
White Plains, New York
SESI Project #12859

Client Sample ID:	CAS #	Type	Unit	PGWSCO	RRSCO	USCO	SB-22(3.5-4)030724	SB-22(8-8.5)030724	SB-25(1.5-2)030724	SB-25(3-3.5)030724	SB-25(7.5-8)030724
Lab Sample ID:							JD83927-14	JD83927-15	JD83927-16	JD83927-17	JD83927-18
Date Sampled:							3/7/2024 11:25 AM	3/7/2024 11:30 AM	3/7/2024 12:00 PM	3/7/2024 12:05 PM	3/7/2024 12:10 PM
(MS Semi-volatiles (SW846 8270E))											
2-Chlorophenol	95-57-8	REG	mg/kg	NS	NS	NS	ND (0.017)	ND (0.017)	ND (0.017)	ND (0.017)	ND (0.017)
4-Chloro-3-methyl phenol	59-50-7	REG	mg/kg	NS	NS	NS	ND (0.021)	ND (0.021)	ND (0.021)	ND (0.022)	ND (0.021)
2,4-Dichlorophenol	120-83-2	REG	mg/kg	NS	NS	NS	ND (0.029)	ND (0.029)	ND (0.029)	ND (0.03)	ND (0.029)
2,4-Dimethylphenol	105-67-9	REG	mg/kg	NS	NS	NS	ND (0.06)	ND (0.061)	ND (0.061)	ND (0.063)	ND (0.061)
2,4-Dinitrophenol	51-28-5	REG	mg/kg	NS	NS	NS	ND (0.13)	ND (0.13)	ND (0.13)	ND (0.13)	ND (0.13)
4,6-Dinitro-o-cresol	534-52-1	REG	mg/kg	NS	NS	NS	ND (0.036)	ND (0.036)	ND (0.037)	ND (0.038)	ND (0.036)
2-Methylphenol	95-48-7	REG	mg/kg	0.33	100	0.33	ND (0.022)	ND (0.022)	ND (0.022)	ND (0.023)	ND (0.022)
3&4-Methylphenol	M+P-CRESOLS	REG	mg/kg	0.33	100	0.33	ND (0.028)	ND (0.028)	ND (0.028)	ND (0.029)	ND (0.028)
2-Nitrophenol	88-75-5	REG	mg/kg	NS	NS	NS	ND (0.022)	ND (0.023)	ND (0.023)	ND (0.023)	ND (0.022)
4-Nitrophenol	100-02-7	REG	mg/kg	NS	NS	NS	ND (0.09)	ND (0.091)	ND (0.092)	ND (0.094)	ND (0.091)
Pentachlorophenol	87-86-5	REG	mg/kg	0.8	1.3	0.8	ND (0.032)	ND (0.032)	ND (0.032)	ND (0.033)	ND (0.032)
Phenol	108-95-2	REG	mg/kg	0.33	100	0.33	ND (0.018)	ND (0.018)	ND (0.018)	ND (0.018)	ND (0.018)
2,3,4,6-Tetrachlorophenol	58-90-2	REG	mg/kg	NS	NS	NS	ND (0.022)	ND (0.023)	ND (0.023)	ND (0.023)	ND (0.023)
2,4,5-Trichlorophenol	95-95-4	REG	mg/kg	NS	NS	NS	ND (0.025)	ND (0.026)	ND (0.026)	ND (0.027)	ND (0.025)
2,4,6-Trichlorophenol	88-06-2	REG	mg/kg	NS	NS	NS	ND (0.02)	ND (0.02)	ND (0.02)	ND (0.021)	ND (0.02)
Acenaphthene	83-32-9	REG	mg/kg	98	100	20	ND (0.012) [b]	ND (0.012) [b]	0.075 [d]	0.0235 J [d]	ND (0.012) [b]
Acenaphthylene	208-96-8	REG	mg/kg	365	100	100	ND (0.017)	ND (0.017)	ND (0.017)	0.0398	ND (0.017)
Acetophenone	98-86-2	REG	mg/kg	NS	NS	NS	ND (0.0073)	ND (0.0073)	ND (0.0074)	ND (0.0076)	ND (0.0073)
Anthracene	120-12-7	REG	mg/kg	1000	100	100	ND (0.021)	0.0234 J	0.416	0.0988	ND (0.021)
Atrazine	1912-24-9	REG	mg/kg	NS	NS	NS	ND (0.014)	ND (0.015)	ND (0.015)	ND (0.015)	ND (0.015)
Benzo(a)anthracene	56-55-3	REG	mg/kg	1	1.4	1	ND (0.0096)	0.107	4.37	0.504	0.0478
Benzo(a)pyrene	50-32-8	REG	mg/kg	22	1	1	ND (0.015)	0.119	4.72	0.507	0.0476
Benzo(b)fluoranthene	205-99-2	REG	mg/kg	2.1	1.4	1	ND (0.015)	0.127	5.92	0.504	0.0429
Benzo(g,h,i)perylene	191-24-2	REG	mg/kg	1000	4.9	0.64	0.0236 J	0.0879	3.35	0.269	0.0354
Benzo(k)fluoranthene	207-08-9	REG	mg/kg	2	4.9	0.8	ND (0.016)	0.0411	2.14	0.198	0.023 J
4-Bromophenyl phenyl ether	101-55-3	REG	mg/kg	NS	NS	NS	ND (0.013)	ND (0.013)	ND (0.013)	ND (0.014)	ND (0.013)
Butyl benzyl phthalate	85-68-7	REG	mg/kg	NS	NS	NS	ND (0.0083)	ND (0.0083)	ND (0.0084)	ND (0.0086)	ND (0.0083)
1,1'-Biphenyl	92-52-4	REG	mg/kg	NS	NS	NS	0.0072 J	ND (0.0047)	ND (0.0047)	ND (0.0048)	ND (0.0047)
Benzaldehyde	100-52-7	REG	mg/kg	NS	NS	NS	ND (0.0084) [a]	ND (0.0084) [a]	ND (0.0085) [a]	ND (0.0088) [a]	ND (0.0084) [a]
2-Chloronaphthalene	91-58-7	REG	mg/kg	NS	NS	NS	ND (0.008)	ND (0.0081)	ND (0.0082)	ND (0.0084)	ND (0.0081)
4-Chloroaniline	106-47-8	REG	mg/kg	NS	NS	NS	ND (0.012)	ND (0.012)	ND (0.012)	ND (0.013)	ND (0.012)
Carbazole	86-74-8	REG	mg/kg	NS	NS	NS	ND (0.0049)	0.016 J	0.196	0.0376 J	ND (0.0049)
Caprolactam	105-60-2	REG	mg/kg	NS	NS	NS	ND (0.013)	ND (0.013)	ND (0.014)	ND (0.014)	ND (0.013)
Chrysene	218-01-9	REG	mg/kg	1	4.9	1	ND (0.011)	0.105	4.89	0.444	0.0336 J
bis(2-Chloroethoxy)methane	111-91-1	REG	mg/kg	NS	NS	NS	ND (0.0072)	ND (0.0073)	ND (0.0074)	ND (0.0076)	ND (0.0073)
bis(2-Chloroethyl)ether	111-44-4	REG	mg/kg	NS	NS	NS	ND (0.015)	ND (0.015)	ND (0.015)	ND (0.015)	ND (0.015)
2,2'-Oxybis(1-chloropropane)	108-60-1	REG	mg/kg	NS	NS	NS	ND (0.012)	ND (0.012)	ND (0.012)	ND (0.013)	ND (0.012)
4-Chlorophenyl phenyl ether	7005-72-3	REG	mg/kg	NS	NS	NS	ND (0.011)	ND (0.011)	ND (0.011)	ND (0.011)	ND (0.011)
2,4-Dinitrotoluene	121-14-2	REG	mg/kg	NS	NS	NS	ND (0.01)	ND (0.011)	ND (0.011)	ND (0.011)	ND (0.011)
2,6-Dinitrotoluene	606-20-2	REG	mg/kg	NS	NS	NS	ND (0.017)	ND (0.017)	ND (0.017)	ND (0.018)	ND (0.017)
3,3'-Dichlorobenzidine	91-94-1	REG	mg/kg	NS	NS	NS	ND (0.028)	ND (0.028)	ND (0.029)	ND (0.03)	ND (0.028)
1,4-Dioxane	123-91-1	REG	mg/kg	0.1	5.7	0.1	ND (0.022)	ND (0.023)	ND (0.023)	ND (0.023)	ND (0.022)
Dibenzo(a,h)anthracene	53-70-3	REG	mg/kg	1000	0.33	0.33	ND (0.015)	0.023 J	0.925	0.0717	ND (0.015)
Dibenzofuran	132-64-9	REG	mg/kg	110	18	2.1	ND (0.014) [b]	ND (0.014) [b]	0.0217 J [d]	0.0142 J [d]	ND (0.014) [b]
Di-n-butyl phthalate	84-74-2	REG	mg/kg	NS	NS	NS	ND (0.0055)	ND (0.0056)	ND (0.0056)	ND (0.0058)	ND (0.0055)
Di-n-octyl phthalate	117-84-0	REG	mg/kg	NS	NS	NS	ND (0.0084)	ND (0.0085)	ND (0.0086)	ND (0.0088)	ND (0.0085)
Diethyl phthalate	84-66-2	REG	mg/kg	NS	NS	NS	ND (0.0072)	ND (0.0073)	ND (0.0073)	ND (0.0075)	ND (0.0072)
Dimethyl phthalate	131-11-3	REG	mg/kg	NS	NS	NS	ND (0.006)	ND (0.0061)	ND (0.0061)	ND (0.0063)	ND (0.0061)
bis(2-Ethylhexyl)phthalate	117-81-7	REG	mg/kg	NS	NS	NS	ND (0.0079)	ND (0.008)	0.0349 J	ND (0.0083)	ND (0.008)
Fluoranthene	206-44-0	REG	mg/kg	1000	100	85	ND (0.015)	0.197	7.04	0.711	0.0721
Fluorene	86-73-7	REG	mg/kg	386	100	30	ND (0.016) [b]	ND (0.016) [b]	0.0566 [d]	0.0246 J [d]	ND (0.016) [b]
Hexachlorobenzene	118-74-1	REG	mg/kg	3.2	0.33	0.33	ND (0.0086) [b]	ND (0.0086) [b]	ND (0.0087) [b]	ND (0.009) [b]	ND (0.0086) [b]
Hexachlorobutadiene	87-68-3	REG	mg/kg	NS	NS	NS	ND (0.014) [b]	ND (0.014) [b]	ND (0.014) [b]	ND (0.014) [b]	ND (0.014) [b]
Hexachlorocyclopentadiene	77-47-4	REG	mg/kg	NS	NS	NS	ND (0.013)	ND (0.014)	ND (0.014)	ND (0.014)	ND (0.014)
Hexachloroethane	67-72-1	REG	mg/kg	NS	NS	NS	ND (0.017)	ND (0.017)	ND (0.017)	ND (0.018)	ND (0.017)
Indeno(1,2,3-cd)pyrene	193-39-5	REG	mg/kg	6.6	1.4	0.5	ND (0.016)	0.0602	2.77	0.229	0.0229 J
Isophorone	78-59-1	REG	mg/kg	NS	NS	NS	ND (0.0072)	ND (0.0073)	ND (0.0074)	ND (0.0076)	ND (0.0073)
2-Methylnaphthalene	91-57-6	REG	mg/kg	NS	NS	NS	0.0268 J	ND (0.0077)	ND (0.0078)	ND (0.008)	ND (0.0077)
2-Nitroaniline	88-74-4	REG	mg/kg	NS	NS	NS	ND (0.008)	ND (0.008)	ND (0.0081)	ND (0.0084)	ND (0.008)
3-Nitroaniline	99-09-2	REG	mg/kg	NS	NS	NS	ND (0.0085)	ND (0.0085)	ND (0.0086)	ND (0.0088)	ND (0.0085)
4-Nitroaniline	100-01-6	REG	mg/kg	NS	NS	NS	ND (0.0088)	ND (0.0088)	ND (0.0089)	ND (0.0092)	ND (0.0088)
Naphthalene	91-20-3	REG	mg/kg	12	100	12	0.0147 J [d]	ND (0.0096) [b]	ND (0.0097) [b]	0.0135 J [d]	ND (0.0096) [b]
Nitrobenzene	98-95-3	REG	mg/kg	0.08	1.8	0.08	ND (0.013)	ND (0.013)	ND (0.013)	ND (0.014)	ND (0.013)
N-Nitroso-di-n-propylamine	621-64-7	REG	mg/kg	NS	NS	NS	ND (0.0098)	ND (0.0098)	ND (0.0099)	ND (0.01)	ND (0.0098)
N-Nitrosodiphenylamine	86-30-6	REG	mg/kg	NS	NS	NS	ND (0.012)	ND (0.012)	ND (0.013)	ND (0.013)	ND (0.012)
Phenanthrene	85-01-8	REG	mg/kg	1000	4.9	1.1	ND (0.011) [b]	0.102 [d]	1.51 [d]	0.293 [d]	0.0309 J [d]
Pyrene	129-00-0	REG	mg/kg	1000	100	64	ND (0.011)	0.169	6.57	0.599	0.065
1,2,4,5-Tetrachlorobenzene	95-94-3	REG	mg/kg	NS	NS	NS	ND (0.0086)	ND (0.0087)	ND (0.0087)	ND (0.009)	ND (0.0086)

SESI
CONSULTING ENGINEERS

Table 3.1 - Summary of Soil Results
80 Main Street
White Plains, New York
SESI Project #12859

Client Sample ID:	CAS #	Type	Unit	PGWSCO	RRSCO	USCO	SB-22(3.5-4)030724	SB-22(8-8.5)030724	SB-25(1.5-2)030724	SB-25(3-3.5)030724	SB-25(7.5-8)030724
Lab Sample ID:							JD83927-14	JD83927-15	JD83927-16	JD83927-17	JD83927-18
Date Sampled:							3/7/2024 11:25 AM	3/7/2024 11:30 AM	3/7/2024 12:00 PM	3/7/2024 12:05 PM	3/7/2024 12:10 PM
(MS Volatiles (SW846 8260D))											
Acetone	67-64-1	REG	mg/kg	0.03	100	0.03	ND (0.004)	ND (0.022)	ND (0.0041)	ND (0.0042)	ND (0.0044)
Benzene	71-43-2	REG	mg/kg	0.06	3.7	0.06	ND (0.00044)	ND (0.0024)	ND (0.00045)	ND (0.00046)	ND (0.00049)
Bromochloromethane	74-97-5	REG	mg/kg	NS	NS	NS	ND (0.00054)	ND (0.0029)	ND (0.00056)	ND (0.00057)	ND (0.0006)
Bromodichloromethane	75-27-4	REG	mg/kg	NS	NS	NS	ND (0.00042)	ND (0.0023)	ND (0.00043)	ND (0.00044)	ND (0.00046)
Bromoform	75-25-2	REG	mg/kg	NS	NS	NS	ND (0.0013)	ND (0.0071)	ND (0.0014)	ND (0.0014)	ND (0.0015)
Bromomethane	74-83-9	REG	mg/kg	NS	NS	NS	ND (0.00074) [a]	ND (0.004) [a]	ND (0.00076) [a]	ND (0.00078) [a]	ND (0.00082) [a]
2-Butanone (MEK)	78-93-3	REG	mg/kg	0.1	100	0.1	ND (0.0024)	ND (0.013)	ND (0.0024)	ND (0.0025)	ND (0.0026)
Carbon disulfide	75-15-0	REG	mg/kg	NS	NS	NS	ND (0.00052)	ND (0.0028)	ND (0.00053)	ND (0.00055)	ND (0.00057)
Carbon tetrachloride	56-23-5	REG	mg/kg	0.76	7.1	0.76	ND (0.0006)	ND (0.0032)	ND (0.00062)	ND (0.00063)	ND (0.00066)
Chlorobenzene	108-90-7	REG	mg/kg	4.5	100	4.5	ND (0.00045)	ND (0.0024)	ND (0.00046)	ND (0.00047)	ND (0.00049)
Chloroethane	75-00-3	REG	mg/kg	NS	NS	NS	ND (0.00057)	ND (0.0031)	ND (0.00059)	ND (0.0006)	ND (0.00063)
Chloroform	67-66-3	REG	mg/kg	0.37	24	0.37	ND (0.0005)	ND (0.0027)	ND (0.00052)	ND (0.00053)	ND (0.00056)
Chloromethane	74-87-3	REG	mg/kg	NS	NS	NS	ND (0.0019)	ND (0.01)	ND (0.002)	ND (0.002)	ND (0.0021)
Cyclohexane	110-82-7	REG	mg/kg	NS	NS	NS	ND (0.00064)	ND (0.0034)	ND (0.00066)	ND (0.00067)	ND (0.0007)
1,2-Dibromo-3-chloropropane	96-12-8	REG	mg/kg	NS	NS	NS	ND (0.00067)	ND (0.0036)	ND (0.00069)	ND (0.00071)	ND (0.00074)
Dibromochloromethane	124-48-1	REG	mg/kg	NS	NS	NS	ND (0.00054)	ND (0.0029)	ND (0.00056)	ND (0.00057)	ND (0.0006)
1,2-Dibromoethane	106-93-4	REG	mg/kg	NS	NS	NS	ND (0.00041)	ND (0.0022)	ND (0.00042)	ND (0.00043)	ND (0.00045)
1,2-Dichlorobenzene	95-50-1	REG	mg/kg	1.1	100	1.1	ND (0.00053)	ND (0.0029)	ND (0.00055)	ND (0.00056)	ND (0.00058)
1,3-Dichlorobenzene	541-73-1	REG	mg/kg	2.6	38	2.6	ND (0.00048)	ND (0.0026)	ND (0.0005)	ND (0.00051)	ND (0.00053)
1,4-Dichlorobenzene	106-46-7	REG	mg/kg	1.8	24	1.8	ND (0.00048)	ND (0.0026)	ND (0.00049)	ND (0.0005)	ND (0.00053)
Dichlorodifluoromethane	75-71-8	REG	mg/kg	NS	NS	NS	ND (0.00071) [a]	ND (0.0038) [a]	ND (0.00073) [a]	ND (0.00074) [a]	ND (0.00078) [a]
1,1-Dichloroethane	75-34-3	REG	mg/kg	0.27	47	0.27	ND (0.00048)	ND (0.0026)	ND (0.00049)	ND (0.00051)	ND (0.00053)
1,2-Dichloroethane	107-06-2	REG	mg/kg	0.02	5.8	0.02	ND (0.00046)	ND (0.0025)	ND (0.00047)	ND (0.00048)	ND (0.0005)
1,1-Dichloroethene	75-35-4	REG	mg/kg	0.33	0.98	0.24	ND (0.00064)	ND (0.0034)	ND (0.00065)	ND (0.00067)	ND (0.0007)
cis-1,2-Dichloroethene	156-59-2	REG	mg/kg	0.19	41	0.19	ND (0.00082)	ND (0.0044)	ND (0.00084)	ND (0.00086)	ND (0.0009)
trans-1,2-Dichloroethene	156-60-5	REG	mg/kg	0.19	100	0.19	ND (0.00059)	ND (0.0032)	ND (0.00061)	ND (0.00062)	ND (0.00065)
1,2-Dichloropropane	78-87-5	REG	mg/kg	NS	NS	NS	ND (0.00046)	ND (0.0025)	ND (0.00047)	ND (0.00048)	ND (0.00051)
cis-1,3-Dichloropropene	10061-01-5	REG	mg/kg	NS	NS	NS	ND (0.00046)	ND (0.0025)	ND (0.00047)	ND (0.00048)	ND (0.00051)
trans-1,3-Dichloropropene	10061-02-6	REG	mg/kg	NS	NS	NS	ND (0.00044)	ND (0.0024)	ND (0.00046)	ND (0.00047)	ND (0.00049)
Ethylbenzene	100-41-4	REG	mg/kg	1	76	1	ND (0.00044)	ND (0.0024)	ND (0.00045)	ND (0.00046)	ND (0.00049)
Freon 113	76-13-1	REG	mg/kg	NS	NS	NS	ND (0.0026)	ND (0.014)	ND (0.0027)	ND (0.0027)	ND (0.0029)
2-Hexanone	591-78-6	REG	mg/kg	NS	NS	NS	ND (0.0021)	ND (0.011)	ND (0.0021)	ND (0.0022)	ND (0.0023)
Isopropylbenzene	98-82-8	REG	mg/kg	NS	NS	NS	ND (0.0014)	ND (0.0075)	ND (0.0014)	ND (0.0014)	ND (0.0015)
Methyl Acetate	79-20-9	REG	mg/kg	NS	NS	NS	ND (0.0013)	ND (0.0073)	ND (0.0014)	ND (0.0014)	ND (0.0015)
Methylcyclohexane	108-87-2	REG	mg/kg	NS	NS	NS	ND (0.00085)	ND (0.0046)	ND (0.00087)	ND (0.00089)	ND (0.00094)
Methyl Tert Butyl Ether	1634-04-4	REG	mg/kg	0.1	100	0.1	ND (0.00046)	ND (0.0025)	ND (0.00047)	ND (0.00048)	ND (0.0005)
4-Methyl-2-pentanone(MIBK)	108-10-1	REG	mg/kg	NS	NS	NS	ND (0.0022)	ND (0.012)	ND (0.0023)	ND (0.0023)	ND (0.0024)
Methylene chloride	75-09-2	REG	mg/kg	0.05	81	0.05	ND (0.0025)	ND (0.014)	ND (0.0026)	ND (0.0027)	ND (0.0028)
Styrene	100-42-5	REG	mg/kg	NS	NS	NS	ND (0.00039)	ND (0.0021)	ND (0.0004)	ND (0.00041)	ND (0.00043)
1,1,2,2-Tetrachloroethane	79-34-5	REG	mg/kg	NS	NS	NS	ND (0.00058)	ND (0.0031)	ND (0.0006)	ND (0.00061)	ND (0.00064)
Tetrachloroethene	127-18-4	REG	mg/kg	1.3	18	1.3	ND (0.00056)	ND (0.003)	ND (0.00058)	ND (0.00059)	ND (0.00062)
Toluene	108-88-3	REG	mg/kg	0.7	100	0.7	ND (0.00051)	ND (0.0028)	ND (0.00052)	ND (0.00054)	ND (0.00056)
1,2,3-Trichlorobenzene	87-61-6	REG	mg/kg	NS	NS	NS	ND (0.0024)	ND (0.013)	ND (0.0025)	ND (0.0026)	ND (0.0027)
1,2,4-Trichlorobenzene	120-82-1	REG	mg/kg	NS	NS	NS	ND (0.0024)	ND (0.013)	ND (0.0025)	ND (0.0026)	ND (0.0027)
1,1,1-Trichloroethane	71-55-6	REG	mg/kg	0.68	100	0.68	ND (0.00047)	ND (0.0025)	ND (0.00048)	ND (0.00049)	ND (0.00052)
1,1,2-Trichloroethane	79-00-5	REG	mg/kg	NS	NS	NS	ND (0.00054)	ND (0.0029)	ND (0.00055)	ND (0.00057)	ND (0.00059)
Trichloroethene	79-01-6	REG	mg/kg	0.47	6.4	0.47	ND (0.00074)	ND (0.004)	ND (0.00076)	ND (0.00078)	ND (0.00082)
Trichlorofluoromethane	75-69-4	REG	mg/kg	NS	NS	NS	ND (0.00066)	ND (0.0036)	ND (0.00068)	ND (0.0007)	ND (0.00073)
Vinyl chloride	75-01-4	REG	mg/kg	0.03	0.48	0.03	ND (0.00047)	ND (0.0025)	ND (0.00048)	ND (0.00049)	ND (0.00051)
m,p-Xylene	M,P-XYLENE	REG	mg/kg	1.2	100	0.26	ND (0.00087)	ND (0.0047)	ND (0.00089)	ND (0.00091)	ND (0.00096)
o-Xylene	95-47-6	REG	mg/kg	1.2	100	0.26	ND (0.00044)	ND (0.0024)	ND (0.00046)	ND (0.00047)	ND (0.00049)
Xylene (total)	1330-20-7	REG	mg/kg	1.2	100	0.26	ND (0.00044)	ND (0.0024)	ND (0.00046)	ND (0.00047)	ND (0.00049)

Concentration Exceeds the USCO

Concentration Exceeds the PGWSCO or RRSCO

PGWSCOs: New York 2025 NYCRR Part 375 Groundwater Criteria, New York Restricted use Criteria per 6 NYCRR Part 375 Environmental Remediation Programs, effective 12/2006 amended 12/2025.

RRSCOs: New York 2025 NYCRR Part 375 Restricted-Residential Criteria, New York Restricted use Criteria per 6 NYCRR Part 375 Environmental Remediation Programs, effective 12/2006 amended 12/2025.

USCOs: New York 2025 NYCRR Part 375 New York Unrestricted use Criteria Criteria per 6 NYCRR Part 375 Environmental Remediation Programs, effective 12/2006 amended 12/2025.

mg/Kg = Milligrams per Kilogram

d = Associated CCV outside of control limits low. Low-level verification was analyzed to demonstrate system suitability to detect affected analytes. Estimated value, due to corresponding failure in the batch associated CCV.

J = Estimated concentration

E = Concentration Exceeds the calibrated analysis range

NS = No Standard

ND = Not Detected

Footnote	Comments
a	Associated CCV outside of control limits high, sample was ND.
b	Associated CCV outside of control limits low. Low-level verification was analyzed to demonstrate system suitability to detect affected analytes. Sample was ND.
c	More than 40 % RPD for detected concentrations between the two GC columns.
d	Associated CCV outside of control limits low. Low-level verification was analyzed to demonstrate system suitability to detect affected analytes. Estimated value, due to corresponding failure in the batch associated CCV.
e	Outside control limits due to matrix interference.
f	Reported from the 2nd signal. The %D of the CCV on the 1st signal exceeds the method criteria of 20%, so it being used for confirmation only. More than 40 % RPD for detected concentrations between the two GC columns.

SESI CONSULTING ENGINEERS

Table 3.1 - Summary of Soil Results
80 Main Street
White Plains, New York
SESI Project #12859

Client Sample ID:	CAS #	Unit	PGWSCO	RRSCO	USCO	SB-7G (5-5.5)		SB-5G (3-3.5)		SB-5G (3-3.5)		SB-5G (9.5-10)		SB-10G (1-1.5)		SB-10G (6-6.5)		SB-10G (6-6.5)	
Date Sampled:						4/4/2023		4/4/2023		4/4/2023		4/4/2023		4/5/2023		4/5/2023		4/5/2023	
Lab Sample ID:						L2317575-05		L2317575-07		L2317575-07 R1		L2317575-08		L2317865-02		L2317865-03		L2317865-03 R1	
						Conc	Q	Conc	Q	Conc	Q	Conc	Q	Conc	Q	Conc	Q	Conc	Q
General Chemistry																			
Solids, Total	NONE	%	NS	NS	NS	86		94.3		-	-	89.5		93.9		91.6		-	-
Cyanide, Total	57-12-5	40	40	13	2.3	1.1	U	1	U	-	-	1.1	U	1	U	1	U	-	-
Organochlorine Pesticides by GC																			
Delta-BHC	319-86-8	mg/Kg	0.1	100	0.04	0.0183	U	0.00168	U	-	-	0.00175	U	0.00168	U	0.00171	U	-	-
Lindane	58-89-9	mg/Kg	0.05	0.21	0.025	0.00764	U	0.000698	U	-	-	0.000731	U	0.000702	U	0.000713	U	-	-
Alpha-BHC	319-84-6	mg/Kg	0.02	0.18	0.02	0.00764	U	0.000698	U	-	-	0.000731	U	0.000702	U	0.000713	U	-	-
Beta-BHC	319-85-7	mg/Kg	0.09	0.18	0.021	0.0183	U	0.00168	U	-	-	0.00175	U	0.00168	U	0.00171	U	-	-
Heptachlor	76-44-8	mg/Kg	0.38	0.53	0.013	0.00917	U	0.000838	U	-	-	0.000877	U	0.000843	U	0.000856	U	-	-
Aldrin	309-00-2	mg/Kg	0.19	0.044	0.0048	0.0183	U	0.00168	U	-	-	0.00175	U	0.00168	U	0.00171	U	-	-
Heptachlor epoxide	1024-57-3	mg/Kg	NS	NS	NS	0.0344	U	0.00314	U	-	-	0.00329	U	0.00316	U	0.00321	U	-	-
Endrin	72-20-8	mg/Kg	0.06	5.3	0.014	0.00764	U	0.000698	U	-	-	0.000731	U	0.000702	U	0.000713	U	-	-
Endrin aldehyde	7421-93-4	mg/Kg	NS	NS	NS	0.0229	U	0.0021	U	-	-	0.00219	U	0.00211	U	0.00214	U	-	-
Endrin ketone	53494-70-5	mg/Kg	NS	NS	NS	0.0183	U	0.00168	U	-	-	0.00175	U	0.00168	U	0.00171	U	-	-
Dieldrin	60-57-1	mg/Kg	0.1	0.075	0.005	0.0114	U	0.00105	U	-	-	0.0011	U	0.00105	U	0.00107	U	-	-
4,4'-DDE	72-55-9	mg/Kg	9.3	3.4	0.0033	0.0183	U	0.00168	U	-	-	0.00175	U	0.00168	U	0.00171	U	-	-
4,4'-DDD	72-54-8	mg/Kg	14	5	0.0033	0.0183	U	0.00168	U	-	-	0.00175	U	0.00168	U	0.00171	U	-	-
4,4'-DDT	50-29-3	mg/Kg	135	3.8	0.0033	0.0183	U	0.00168	U	-	-	0.00175	U	0.00168	U	0.00171	U	-	-
Endosulfan I	959-98-8	mg/Kg	65	35	4.3	0.0183	U	0.00168	U	-	-	0.00175	U	0.00168	U	0.00171	U	-	-
Endosulfan II	33213-65-9	mg/Kg	44	35	4.3	0.0183	U	0.00168	U	-	-	0.00175	U	0.00168	U	0.00171	U	-	-
Endosulfan sulfate	1031-07-8	mg/Kg	47	35	4.3	0.00764	U	0.000698	U	-	-	0.000731	U	0.000702	U	0.000713	U	-	-
Methoxychlor	72-43-5	mg/Kg	NS	NS	NS	0.0344	U	0.00314	U	-	-	0.00329	U	0.00316	U	0.00321	U	-	-
Toxaphene	8001-35-2	mg/Kg	NS	NS	NS	0.344	U	0.0314	U	-	-	0.0329	U	0.0316	U	0.0321	U	-	-
cis-Chlordane	5103-71-9	mg/Kg	4.5	0.65	0.014	0.0229	U	0.0021	U	-	-	0.00219	U	0.00211	U	0.00214	U	-	-
trans-Chlordane	5103-74-2	mg/Kg	NS	NS	NS	0.0064	JIP	0.0021	U	-	-	0.00219	U	0.00211	U	0.00214	U	-	-
Chlordane	57-74-9	mg/Kg	NS	NS	NS	0.153	U	0.014	U	-	-	0.0146	U	0.014	U	0.0143	U	-	-
Perfluorinated Alkyl Acids by EPA 1633																			
Perfluorobutanoic Acid (PFBA)	375-22-4	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	0.000787	U	-	-	-	-
Perfluoropentanoic Acid (PFPeA)	2706-90-3	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	0.000394	U	-	-	-	-
Perfluorobutanesulfonic Acid (PFBS)	375-73-5	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	0.000047	J	-	-	-	-
Perfluorohexanoic Acid (PFHxA)	307-24-4	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	0.000055	J	-	-	-	-
Perfluoroheptanoic Acid (PFHpA)	375-85-9	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	0.000197	U	-	-	-	-
Perfluorohexanesulfonic Acid (PFHxS)	355-46-4	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	0.000409		-	-	-	-
Perfluorooctanoic Acid (PFOA)	335-67-1	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	0.000165	J	-	-	-	-
1H,1H,2H,2H-Perfluorooctanesulfonic Acid (6:2FTS)	27619-97-2	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	0.000787	U	-	-	-	-
Perfluoroheptanesulfonic Acid (PFHpS)	375-92-8	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	0.000197	U	-	-	-	-
Perfluorononanoic Acid (PFNA)	375-95-1	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	0.000197	U	-	-	-	-
Perfluorooctanesulfonic Acid (PFOS)	1763-23-1	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	0.000378		-	-	-	-
Perfluorodecanoic Acid (PFDA)	335-76-2	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	0.000197	U	-	-	-	-
1H,1H,2H,2H-Perfluorodecanesulfonic Acid (8:2FTS)	39108-34-4	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	0.000787	U	-	-	-	-
N-Methyl Perfluorooctanesulfonamidoacetic Acid (NMeFOSAA)	2355-31-9	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	0.000197	U	-	-	-	-
Perfluoroundecanoic Acid (PFUnA)	2058-94-8	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	0.000197	U	-	-	-	-
Perfluorodecanesulfonic Acid (PFDS)	335-77-3	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	0.000197	U	-	-	-	-
Perfluorooctanesulfonamide (PFOSA)	754-91-6	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	0.000197	U	-	-	-	-
N-Ethyl Perfluorooctanesulfonamidoacetic Acid (NEtFOSAA)	2991-50-6	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	0.000197	U	-	-	-	-
Perfluorododecanoic Acid (PFDoA)	307-55-1	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	0.000197	U	-	-	-	-
Perfluorotridecanoic Acid (PFTrDA)	72629-94-8	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	0.000197	U	-	-	-	-
Perfluorotetradecanoic Acid (PFTeDA)	376-06-7	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	0.000197	U	-	-	-	-
PFOA/PFOS, Total	null	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	0.000543	J	-	-	-	-
Polychlorinated Biphenyls by GC																			
Aroclor 1016	12674-11-2	mg/Kg	3.2	1	0.1	0.0378	U	0.0342	U	-	-	0.0365	U	0.0347	U	0.0349	U	-	-
Aroclor 1221	11104-28-2	mg/Kg	3.2	1	0.1	0.0378	U	0.0342	U	-	-	0.0365	U	0.0347	U	0.0349	U	-	-
Aroclor 1232	11141-16-5	mg/Kg	3.2	1	0.1	0.0378	U	0.0342	U	-	-	0.0365	U	0.0347	U	0.0349	U	-	-
Aroclor 1242	53469-21-9	mg/Kg	3.2	1	0.1	0.0378	U	0.0342	U	-	-	0.0365	U	0.0347	U	0.0349	U	-	-
Aroclor 1248	12672-29-6	mg/Kg	3.2	1	0.1	0.0378	U	0.0342	U	-	-	0.0365	U	0.0347	U	0.0349	U	-	-
Aroclor 1254	11097-69-1	mg/Kg	3.2	1	0.1	0.0378	U	0.0342	U	-	-	0.0365	U	0.0347	U	0.0218	J	-	-
Aroclor 1260	11096-82-5	mg/Kg	3.2	1	0.1	0.0378	U	0.0118	J	-	-	0.0365	U	0.0347	U	0.00676	J	-	-
Aroclor 1262	37324-23-5	mg/Kg	3.2	1	0.1	0.0378	U	0.0342	U	-	-	0.0365	U	0.0347	U	0.0349	U	-	-
Aroclor 1268	11100-14-4	mg/Kg	3.2	1	0.1	0.0378	U	0.0342	U	-	-	0.0365	U	0.0347	U	0.0349	U	-	-
PCBs, Total	1336-36-3	mg/Kg	3.2	1	0.1	0.0378	U	0.0118	J	-	-	0.0365	U	0.0347	U	0.0286	J	-	-

SESI
CONSULTING ENGINEERS

Table 3.1 - Summary of Soil Results
80 Main Street
White Plains, New York
SESI Project #12859

Client Sample ID:	CAS #	Unit	PGWSCO	RRSCO	USCO	SB-7G (5-5.5)		SB-5G (3-3.5)		SB-5G (3-3.5)		SB-5G (9.5-10)		SB-10G (1-1.5)		SB-10G (6-6.5)		SB-10G (6-6.5)	
Date Sampled:						4/4/2023		4/4/2023		4/4/2023		4/4/2023		4/5/2023		4/5/2023		4/5/2023	
Lab Sample ID:						L2317575-05		L2317575-07		L2317575-07 R1		L2317575-08		L2317865-02		L2317865-03		L2317865-03 R1	
Semivolatile Organics by GC/MS																			
Acenaphthene	83-32-9	mg/Kg	98	100	20	0.15	U	0.34		-	-	0.15	U	0.14	U	53		-	-
1,2,4-Trichlorobenzene	120-82-1	mg/Kg	NS	NS	NS	0.19	U	0.17	U	-	-	0.18	U	0.18	U	1.8	U	-	-
Hexachlorobenzene	118-74-1	mg/Kg	3.2	0.33	0.33	0.11	U	0.1	U	-	-	0.11	U	0.1	U	1.1	U	-	-
Bis(2-chloroethyl)ether	111-44-4	mg/Kg	NS	NS	NS	0.17	U	0.16	U	-	-	0.16	U	0.16	U	1.6	U	-	-
2-Chloronaphthalene	91-58-7	mg/Kg	NS	NS	NS	0.19	U	0.17	U	-	-	0.18	U	0.18	U	1.8	U	-	-
1,2-Dichlorobenzene	95-50-1	mg/Kg	1.1	100	1.1	0.19	U	0.17	U	-	-	0.18	U	0.18	U	1.8	U	-	-
1,3-Dichlorobenzene	541-73-1	mg/Kg	2.6	38	2.6	0.19	U	0.17	U	-	-	0.18	U	0.18	U	1.8	U	-	-
1,4-Dichlorobenzene	106-46-7	mg/Kg	1.8	24	1.8	0.19	U	0.17	U	-	-	0.18	U	0.18	U	1.8	U	-	-
3,3'-Dichlorobenzidine	91-94-1	mg/Kg	NS	NS	NS	0.19	U	0.17	U	-	-	0.18	U	0.18	U	1.8	U	-	-
2,4-Dinitrotoluene	121-14-2	mg/Kg	NS	NS	NS	0.19	U	0.17	U	-	-	0.18	U	0.18	U	1.8	U	-	-
2,6-Dinitrotoluene	606-20-2	mg/Kg	NS	NS	NS	0.19	U	0.17	U	-	-	0.18	U	0.18	U	1.8	U	-	-
Fluoranthene	206-44-0	mg/Kg	1000	100	85	0.1	J	13	E	14		0.2		0.1		180	E	540	
4-Chlorophenyl phenyl ether	7005-72-3	mg/Kg	NS	NS	NS	0.19	U	0.17	U	-	-	0.18	U	0.18	U	1.8	U	-	-
4-Bromophenyl phenyl ether	101-55-3	mg/Kg	NS	NS	NS	0.19	U	0.17	U	-	-	0.18	U	0.18	U	1.8	U	-	-
Bis(2-chloroisopropyl)ether	108-60-1	mg/Kg	NS	NS	NS	0.23	U	0.21	U	-	-	0.22	U	0.21	U	2.2	U	-	-
Bis(2-chloroethoxy)methane	111-91-1	mg/Kg	NS	NS	NS	0.2	U	0.19	U	-	-	0.2	U	0.19	U	1.9	U	-	-
Hexachlorobutadiene	87-68-3	mg/Kg	NS	NS	NS	0.19	U	0.17	U	-	-	0.18	U	0.18	U	1.8	U	-	-
Hexachlorocyclopentadiene	77-47-4	mg/Kg	NS	NS	NS	0.54	U	0.5	U	-	-	0.52	U	0.5	U	5.1	U	-	-
Hexachloroethane	67-72-1	mg/Kg	NS	NS	NS	0.15	U	0.14	U	-	-	0.15	U	0.14	U	1.4	U	-	-
Isophorone	78-59-1	mg/Kg	NS	NS	NS	0.17	U	0.16	U	-	-	0.16	U	0.16	U	1.6	U	-	-
Naphthalene	91-20-3	mg/Kg	12	100	12	0.19	U	0.034	J	-	-	0.18	U	0.18	U	87	E	110	
Nitrobenzene	98-95-3	mg/Kg	0.08	1.8	0.08	0.17	U	0.16	U	-	-	0.16	U	0.16	U	1.6	U	-	-
NDPA/DPA	86-30-6	mg/Kg	NS	NS	NS	0.15	U	0.14	U	-	-	0.15	U	0.14	U	1.4	U	-	-
n-Nitrosodi-n-propylamine	621-64-7	mg/Kg	NS	NS	NS	0.19	U	0.17	U	-	-	0.18	U	0.18	U	1.8	U	-	-
Bis(2-ethylhexyl)phthalate	117-81-7	mg/Kg	NS	NS	NS	0.19	U	0.17	U	-	-	0.18	U	0.075	J	1.8	U	-	-
Butyl benzyl phthalate	85-68-7	mg/Kg	NS	NS	NS	0.19	U	0.17	U	-	-	0.18	U	0.18	U	1.8	U	-	-
Di-n-butylphthalate	84-74-2	mg/Kg	NS	NS	NS	0.19	U	0.17	U	-	-	0.18	U	0.18	U	1.8	U	-	-
Di-n-octylphthalate	117-84-0	mg/Kg	NS	NS	NS	0.19	U	0.17	U	-	-	0.18	U	0.18	U	1.8	U	-	-
Diethyl phthalate	84-66-2	mg/Kg	NS	NS	NS	0.19	U	0.17	U	-	-	0.18	U	0.18	U	1.8	U	-	-
Dimethyl phthalate	131-11-3	mg/Kg	NS	NS	NS	0.19	U	0.17	U	-	-	0.18	U	0.18	U	1.8	U	-	-
Benzo(a)anthracene	56-55-3	mg/Kg	1	1.4	1	0.044	J	6.1		-	-	0.13		0.074	J	140	E	200	
Benzo(a)pyrene	50-32-8	mg/Kg	22	1	1	0.054	J	6		-	-	0.14	J	0.072	J	130	E	180	
Benzo(b)fluoranthene	205-99-2	mg/Kg	2.1	1.4	1	0.061	J	7.2	E	6.4		0.15		0.089	J	210		-	-
Benzo(k)fluoranthene	207-08-9	mg/Kg	2	4.9	0.8	0.11	U	2.6		-	-	0.06	J	0.1	U	68		-	-
Chrysene	218-01-9	mg/Kg	1	4.9	1	0.043	J	5.2		-	-	0.12		0.069	J	120	E	180	
Acenaphthylene	208-96-8	mg/Kg	365	100	100	0.15	U	0.42		-	-	0.15	U	0.14	U	7.7		-	-
Anthracene	120-12-7	mg/Kg	1000	100	100	0.11	U	2		-	-	0.038	J	0.1	U	98	E	180	
Benzo(ghi)perylene	191-24-2	mg/Kg	1000	4.9	0.64	0.03	J	2.4		-	-	0.068	J	0.047	J	75	E	100	
Fluorene	86-73-7	mg/Kg	386	100	30	0.19	U	0.53		-	-	0.18	U	0.18	U	74	E	90	
Phenanthrene	85-01-8	mg/Kg	1000	4.9	1.1	0.06	J	8.2	E	7.4		0.13		0.048	J	200	E	-	-
Dibenzo(a,h)anthracene	53-70-3	mg/Kg	1000	0.33	0.33	0.11	U	0.77		-	-	0.11	U	0.1	U	28		-	-
Indeno(1,2,3-cd)pyrene	193-39-5	mg/Kg	6.6	1.4	0.5	0.033	J	3.1		-	-	0.083	J	0.053	J	76	E	95	
Pyrene	129-00-0	mg/Kg	1000	100	64	0.088	J	11	E	11		0.2		0.099	J	160	E	400	
Biphenyl	92-52-4	mg/Kg	NS	NS	NS	0.43	U	0.4	U	-	-	0.42	U	0.4	U	15		-	-
4-Chloroaniline	106-47-8	mg/Kg	NS	NS	NS	0.19	U	0.17	U	-	-	0.18	U	0.18	U	1.8	U	-	-
2-Nitroaniline	88-74-4	mg/Kg	NS	NS	NS	0.19	U	0.17	U	-	-	0.18	U	0.18	U	1.8	U	-	-
3-Nitroaniline	99-09-2	mg/Kg	NS	NS	NS	0.19	U	0.17	U	-	-	0.18	U	0.18	U	1.8	U	-	-
4-Nitroaniline	100-01-6	mg/Kg	NS	NS	NS	0.19	U	0.17	U	-	-	0.18	U	0.18	U	1.8	U	-	-
Dibenzofuran	132-64-9	mg/Kg	110	18	2.1	0.19	U	0.21		-	-	0.18	U	0.18	U	88	E	110	
2-Methylnaphthalene	91-57-6	mg/Kg	NS	NS	NS	0.23	U	0.028	J	-	-	0.22	U	0.21	U	46		-	-
1,2,4,5-Tetrachlorobenzene	95-94-3	mg/Kg	NS	NS	NS	0.19	U	0.17	U	-	-	0.18	U	0.18	U	1.8	U	-	-
Acetophenone	98-86-2	mg/Kg	NS	NS	NS	0.19	U	0.17	U	-	-	0.18	U	0.18	U	1.8	U	-	-
2,4,6-Trichlorophenol	88-06-2	mg/Kg	NS	NS	NS	0.11	U	0.1	U	-	-	0.11	U	0.1	U	1.1	U	-	-
p-Chloro-m-cresol	59-50-7	mg/Kg	NS	NS	NS	0.19	U	0.17	U	-	-	0.18	U	0.18	U	1.8	U	-	-
2-Chlorophenol	95-57-8	mg/Kg	NS	NS	NS	0.19	U	0.17	U	-	-	0.18	U	0.18	U	1.8	U	-	-
2,4-Dichlorophenol	120-83-2	mg/Kg	NS	NS	NS	0.17	U	0.16	U	-	-	0.16	U	0.16	U	1.6	U	-	-
2,4-Dimethylphenol	105-67-9	mg/Kg	NS	NS	NS	0.19	U	0.17	U	-	-	0.18	U	0.18	U	1.8	U	-	-
2-Nitrophenol	88-75-5	mg/Kg	NS	NS	NS	0.41	U	0.38	U	-	-	0.4	U	0.38	U	3.9	U	-	-
4-Nitrophenol	100-02-7	mg/Kg	NS	NS	NS	0.27	U	0.24	U	-	-	0.26	U	0.24	U	2.5	U	-	-
2,4-Dinitrophenol	51-28-5	mg/Kg	NS	NS	NS	0.91	U	0.84	U	-	-	0.88	U	0.84	U	8.6	U	-	-
4,6-Dinitro-o-cresol	534-52-1	mg/Kg	NS	NS	NS	0.49	U	0.45	U	-	-	0.48	U	0.46	U	4.7	U	-	-
Pentachlorophenol	87-86-5	mg/Kg	0.8	1.3	0.8	0.15	U	0.14	U	-	-	0.15	U	0.14	U	1.4	U	-	-
Phenol	108-95-2	mg/Kg	0.33	100	0.33	0.19	U	0.17	U	-	-	0.18	U	0.18	U	1.8	U	-	-
2-Methylphenol	95-48-7	mg/Kg	0.33	100	0.33	0.19	U	0.17	U	-	-	0.18	U	0.18	U	1.8	U	-	-
3-Methylphenol/4-Methylphenol	108-39-4/106-44-5	mg/Kg	0.33	100	0.33	0.27	U	0.25	U	-	-	0.26	U	0.25	U	2.6	U	-	-
2,4,5-Trichlorophenol	95-95-4	mg/Kg	NS	NS	NS	0.19	U	0.17	U	-	-	0.18	U	0.18	U	1.8	U	-	-
Benzoic Acid	65-85-0	mg/Kg	NS	NS	NS	0.62	U	0.56	U	-	-	0.59	U	0.57	U	5.8	U	-	-
Benzyl Alcohol	100-51-6	mg/Kg	NS	NS	NS	0.19	U	0.17	U	-	-	0.18	U	0.18	U	1.8	U	-	-
Carbazole	86-74-8	mg/Kg	NS	NS	NS	0.19	U	0.29		-	-	0.02	J	0.18	U	64		-	-
1,4-Dioxane	123-91-1	mg/Kg	0.1	5.7	0.1	0.028	U	0.026	U	-	-	0.028	U	0.026	U	0.27	U	-	-
Total Metals																			
Aluminum, Total	7429-90-5	mg/Kg	NS	NS	NS	7780		6670		-	-	6430		6320		7660		-	-
Antimony, Total	7440-36-0	mg/Kg	NS	NS	NS	4.51	U	4.17	U	-	-	4.34	U	4.08	U	4.15	U	-	-
Arsenic, Total	7440-38-2	mg/Kg	16	16	13	2		1.25		-	-	1.9		1.24		1.29		-	-
Barium, Total	7440-39-3	mg/Kg	820	410	410	69.4		64.3		-	-	57.2		50.2		58.2		-	-
Beryllium, Total	7440-41-7	mg/Kg	47	43	4.4	0.06	J	0.417	U	-	-	0.434	U	0.169	J	0.203	J	-	-
Cadmium, Total	7440-43-9	mg/Kg	7.5	2.5	2.5	0.189	J	0.223	J	-	-	0.284	J	0.632	J	0.143	J	-	-
Calcium, Total	7440-70-2	mg/Kg	NS	NS	NS	10900		8760		-	-	12300		9400		7720		-	-
Chromium, Total	7440-47-3	mg/Kg	NS	NS	NS	16.9		14.2		-	-	13.7		11.8		12.9		-	-
Cobalt, Total	7440-48-4	mg/Kg	NS	NS	NS	5.8		5.63		-	-	5.19		4.7		4.89		-	-
Copper, Total	7440-50-8	mg/Kg	1720	280	50	20.7		17.9		-	-	18.9		14.6		14.2		-	-
Iron, Total	7439-89-6	mg/Kg	NS	NS	NS	13300		12800		-	-	15200		11700		12900		-	-
Lead, Total	7439-92-1	mg/Kg	450	400	63	70.5		14		-	-	13.2		15.1		19.7		-	-
Magnesium, Total	7439-95-4	mg/Kg	NS	NS	NS	8190		7730		-	-	8120		6260		5430		-	-
Manganese, Total	7439-96-5	mg/Kg	2000	2000	1600	158		181		-	-	177		167		197		-	-
Mercury, Total	7439-97-6	mg/Kg	0.73	0.3	0.18	0.175		0.066	U	-	-	0.073	U	0.072	U	0.053	J	-	-
Nickel, Total	7440-02-0	mg/Kg	130	320	30	11.8		11.6		-	-	18.2		10.2		9.87		-	-
Potassium, Total	7440-09-7	mg/Kg	NS	NS	NS	2040		2280		-	-	2170		1840		2030		-	-
Selenium, Total	7782-49-2	mg/Kg	4	110	3.9	1.8	U	1.67	U	-	-	1.73	U	1.63	U	1.66	U	-	-
Silver, Total	7440-22-4	mg/Kg	8.3	110	2	0.277	J	0.417	U	-	-	0.31	J	0.408	U	0.415	U	-	-
Sodium, Total	7440-23-5	mg/Kg	NS	NS	NS	127	J	87.4	J	-	-	124	J	108	J	144	J	-	-
Thallium, Total	7440-28-0	mg/Kg	NS	NS	NS	0.59	J	0.704	J	-	-	0.458	J	1.63	U	1.66	U	-	-
Vanadium, Total	7440-62-2	mg/Kg	NS	NS	NS	23		19.8		-	-	19		17.1		18.6		-	-
Zinc, Total	7440-66-6	mg/Kg	2480	6600	109	64		38.7		-	-	34.6		36.6		36.7		-	-

SESI
CONSULTING ENGINEERS

Table 3.1 - Summary of Soil Results
80 Main Street
White Plains, New York
SESI Project #12859

Client Sample ID:	CAS #	Unit	PGWSCO	RRSCO	USCO	SB-7G (5-5.5)		SB-5G (3-3.5)		SB-5G (3-3.5)		SB-5G (9.5-10)		SB-10G (1-1.5)		SB-10G (6-6.5)		SB-10G (6-6.5)	
Date Sampled:						4/4/2023		4/4/2023		4/4/2023		4/4/2023		4/5/2023		4/5/2023		4/5/2023	
Lab Sample ID:						L2317575-05		L2317575-07		L2317575-07 R1		L2317575-08		L2317865-02		L2317865-03		L2317865-03 R1	
Volatile Organics by EPA 5035/8260																			
Methylene chloride	75-09-2	mg/Kg	0.05	81	0.05	0.0049	U	0.0052	U	-	-	0.0046	U	0.005	U	0.0052	U	-	-
1,1-Dichloroethane	75-34-3	mg/Kg	0.27	47	0.27	0.00099	U	0.001	U	-	-	0.00092	U	0.001	U	0.001	U	-	-
Chloroform	67-66-3	mg/Kg	0.37	24	0.37	0.0015	U	0.0016	U	-	-	0.0014	U	0.0015	U	0.0016	U	-	-
Carbon tetrachloride	56-23-5	mg/Kg	0.76	7.1	0.76	0.00099	U	0.001	U	-	-	0.00092	U	0.001	U	0.001	U	-	-
1,2-Dichloropropane	78-87-5	mg/Kg	NS	NS	NS	0.00099	U	0.001	U	-	-	0.00092	U	0.001	U	0.001	U	-	-
Dibromochloromethane	124-48-1	mg/Kg	NS	NS	NS	0.00099	U	0.001	U	-	-	0.00092	U	0.001	U	0.001	U	-	-
1,1,2-Trichloroethane	79-00-5	mg/Kg	NS	NS	NS	0.00099	U	0.001	U	-	-	0.00092	U	0.001	U	0.001	U	-	-
Tetrachloroethene	127-18-4	mg/Kg	1.3	18	1.3	0.00049	U	0.00052	U	-	-	0.00046	U	0.00022	J	0.00052	U	-	-
Chlorobenzene	108-90-7	mg/Kg	4.5	100	4.5	0.00049	U	0.00052	U	-	-	0.00046	U	0.0005	U	0.00052	U	-	-
Trichlorofluoromethane	75-69-4	mg/Kg	NS	NS	NS	0.004	U	0.0042	U	-	-	0.0037	U	0.004	U	0.0042	U	-	-
1,2-Dichloroethane	107-06-2	mg/Kg	0.02	5.8	0.02	0.00099	U	0.001	U	-	-	0.00092	U	0.001	U	0.001	U	-	-
1,1,1-Trichloroethane	71-55-6	mg/Kg	0.68	100	0.68	0.00049	U	0.00052	U	-	-	0.00046	U	0.0005	U	0.00052	U	-	-
Bromodichloromethane	75-27-4	mg/Kg	NS	NS	NS	0.00049	U	0.00052	U	-	-	0.00046	U	0.0005	U	0.00052	U	-	-
trans-1,3-Dichloropropene	10061-02-6	mg/Kg	NS	NS	NS	0.00099	U	0.001	U	-	-	0.00092	U	0.001	U	0.001	U	-	-
cis-1,3-Dichloropropene	10061-01-5	mg/Kg	NS	NS	NS	0.00049	U	0.00052	U	-	-	0.00046	U	0.0005	U	0.00052	U	-	-
1,3-Dichloropropene, Total	542-75-6	mg/Kg	NS	NS	NS	0.00049	U	0.00052	U	-	-	0.00046	U	0.0005	U	0.00052	U	-	-
1,1-Dichloropropene	563-58-6	mg/Kg	NS	NS	NS	0.00049	U	0.00052	U	-	-	0.00046	U	0.0005	U	0.00052	U	-	-
Bromoform	75-25-2	mg/Kg	NS	NS	NS	0.004	U	0.0042	U	-	-	0.0037	U	0.004	U	0.0042	U	-	-
1,1,2,2-Tetrachloroethane	79-34-5	mg/Kg	NS	NS	NS	0.00049	U	0.00052	U	-	-	0.00046	U	0.0005	U	0.00052	U	-	-
Benzene	71-43-2	mg/Kg	0.06	3.7	0.06	0.00049	U	0.00052	U	-	-	0.00046	U	0.0005	U	0.00052	U	-	-
Toluene	108-88-3	mg/Kg	0.7	100	0.7	0.00099	U	0.001	U	-	-	0.00092	U	0.001	U	0.001	U	-	-
Ethylbenzene	100-41-4	mg/Kg	1	76	1	0.00099	U	0.001	U	-	-	0.00092	U	0.001	U	0.001	U	-	-
Chloromethane	74-87-3	mg/Kg	NS	NS	NS	0.004	U	0.0042	U	-	-	0.0037	U	0.004	U	0.0042	U	-	-
Bromomethane	74-83-9	mg/Kg	NS	NS	NS	0.002	U	0.0021	U	-	-	0.0018	U	0.002	U	0.0021	U	-	-
Vinyl chloride	75-01-4	mg/Kg	0.03	0.48	0.03	0.00099	U	0.001	U	-	-	0.00092	U	0.001	U	0.001	U	-	-
Chloroethane	75-00-3	mg/Kg	NS	NS	NS	0.002	U	0.0021	U	-	-	0.0018	U	0.002	U	0.0021	U	-	-
1,1-Dichloroethene	75-35-4	mg/Kg	0.33	0.98	0.24	0.00099	U	0.001	U	-	-	0.00092	U	0.001	U	0.001	U	-	-
trans-1,2-Dichloroethene	156-60-5	mg/Kg	0.19	100	0.19	0.0015	U	0.0016	U	-	-	0.0014	U	0.0015	U	0.0016	U	-	-
Trichloroethene	79-01-6	mg/Kg	0.47	6.4	0.47	0.00049	U	0.00052	U	-	-	0.00046	U	0.0005	U	0.00052	U	-	-
1,2-Dichlorobenzene	95-50-1	mg/Kg	1.1	100	1.1	0.002	U	0.0021	U	-	-	0.0018	U	0.002	U	0.0021	U	-	-
1,3-Dichlorobenzene	541-73-1	mg/Kg	2.6	38	2.6	0.002	U	0.0021	U	-	-	0.0018	U	0.002	U	0.0021	U	-	-
1,4-Dichlorobenzene	106-46-7	mg/Kg	1.8	24	1.8	0.002	U	0.0021	U	-	-	0.0018	U	0.002	U	0.0021	U	-	-
Methyl tert butyl ether	1634-04-4	mg/Kg	0.1	100	0.1	0.002	U	0.0021	U	-	-	0.0018	U	0.002	U	0.0021	U	-	-
p/m-Xylene	179601-23-1	mg/Kg	NS	NS	NS	0.002	U	0.0021	U	-	-	0.0018	U	0.002	U	0.0021	U	-	-
o-Xylene	95-47-6	mg/Kg	NS	NS	NS	0.00099	U	0.001	U	-	-	0.00092	U	0.001	U	0.001	U	-	-
Xylenes, Total	1330-20-7	mg/Kg	1.2	100	0.26	0.00099	U	0.001	U	-	-	0.00092	U	0.001	U	0.001	U	-	-
cis-1,2-Dichloroethene	156-59-2	mg/Kg	0.19	41	0.19	0.00099	U	0.001	U	-	-	0.00092	U	0.001	U	0.001	U	-	-
1,2-Dichloroethene, Total	540-59-0	mg/Kg	NS	NS	NS	0.00099	U	0.001	U	-	-	0.00092	U	0.001	U	0.001	U	-	-
Dibromomethane	74-95-3	mg/Kg	NS	NS	NS	0.002	U	0.0021	U	-	-	0.0018	U	0.002	U	0.0021	U	-	-
Styrene	100-42-5	mg/Kg	NS	NS	NS	0.00099	U	0.001	U	-	-	0.00092	U	0.001	U	0.001	U	-	-
Dichlorodifluoromethane	75-71-8	mg/Kg	NS	NS	NS	0.0099	U	0.01	U	-	-	0.0092	U	0.01	U	0.01	U	-	-
Acetone	67-64-1	mg/Kg	0.03	100	0.03	0.021		0.0051	J	-	-	0.032		0.01	U	0.033		-	-
Carbon disulfide	75-15-0	mg/Kg	NS	NS	NS	0.0099	U	0.01	U	-	-	0.0092	U	0.01	U	0.01	U	-	-
2-Butanone	78-93-3	mg/Kg	0.1	100	0.1	0.0029	J	0.01	U	-	-	0.0059	J	0.01	U	0.0068	J	-	-
Vinyl acetate	108-05-4	mg/Kg	NS	NS	NS	0.0099	U	0.01	U	-	-	0.0092	U	0.01	U	0.01	U	-	-
4-Methyl-2-pentanone	108-10-1	mg/Kg	NS	NS	NS	0.0099	U	0.01	U	-	-	0.0092	U	0.01	U	0.01	U	-	-
1,2,3-Trichloropropane	96-18-4	mg/Kg	NS	NS	NS	0.002	U	0.0021	U	-	-	0.0018	U	0.002	U	0.0021	U	-	-
2-Hexanone	591-78-6	mg/Kg	NS	NS	NS	0.0099	U	0.01	U	-	-	0.0092	U	0.01	U	0.01	U	-	-
Bromochloromethane	74-97-5	mg/Kg	NS	NS	NS	0.002	U	0.0021	U	-	-	0.0018	U	0.002	U	0.0021	U	-	-
2,2-Dichloropropane	594-20-7	mg/Kg	NS	NS	NS	0.002	U	0.0021	U	-	-	0.0018	U	0.002	U	0.0021	U	-	-
1,2-Dibromoethane	106-93-4	mg/Kg	NS	NS	NS	0.00099	U	0.001	U	-	-	0.00092	U	0.001	U	0.001	U	-	-
1,3-Dichloropropane	142-28-9	mg/Kg	NS	NS	NS	0.002	U	0.0021	U	-	-	0.0018	U	0.002	U	0.0021	U	-	-
1,1,1,2-Tetrachloroethane	630-20-6	mg/Kg	NS	NS	NS	0.00049	U	0.00052	U	-	-	0.00046	U	0.0005	U	0.00052	U	-	-
Bromobenzene	108-86-1	mg/Kg	NS	NS	NS	0.002	U	0.0021	U	-	-	0.0018	U	0.002	U	0.0021	U	-	-
n-Butylbenzene	104-51-8	mg/Kg	18	100	18	0.00099	U	0.001	U	-	-	0.00092	U	0.001	U	0.001	U	-	-
sec-Butylbenzene	135-98-8	mg/Kg	25	100	25	0.00099	U	0.001	U	-	-	0.00092	U	0.001	U	0.001	U	-	-
tert-Butylbenzene	98-06-6	mg/Kg	11	100	11	0.002	U	0.0021	U	-	-	0.0018	U	0.002	U	0.0021	U	-	-
o-Chlorotoluene	95-49-8	mg/Kg	NS	NS	NS	0.002	U	0.0021	U	-	-	0.0018	U	0.002	U	0.0021	U	-	-
p-Chlorotoluene	106-43-4	mg/Kg	NS	NS	NS	0.002	U	0.0021	U	-	-	0.0018	U	0.002	U	0.0021	U	-	-
1,2-Dibromo-3-chloropropane	96-12-8	mg/Kg	NS	NS	NS	0.003	U	0.0031	U	-	-	0.0028	U	0.003	U	0.0031	U	-	-
Hexachlorobutadiene	87-68-3	mg/Kg	NS	NS	NS	0.004	U	0.0042	U	-	-	0.0037	U	0.004	U	0.0042	U	-	-
Isopropylbenzene	98-82-8	mg/Kg	NS	NS	NS	0.00099	U	0.001	U	-	-	0.00092	U	0.001	U	0.001	U	-	-
p-Isopropyltoluene	99-87-6	mg/Kg	NS	NS	NS	0.00014	J	0.001	U	-	-	0.00092	U	0.001	U	0.001	U	-	-
Naphthalene	91-20-3	mg/Kg	12	100	12	0.004	U	0.0042	U	-	-	0.0037	U	0.004	U	0.0014	J	-	-
Acrylonitrile	107-13-1	mg/Kg	NS	NS	NS	0.004	U	0.0042	U	-	-	0.0037	U	0.004	U	0.0042	U	-	-
n-Propylbenzene	103-65-1	mg/Kg	5	100	5	0.00099	U	0.001	U	-	-	0.00092	U	0.001	U	0.001	U	-	-
1,2,3-Trichlorobenzene	87-61-6	mg/Kg	NS	NS	NS	0.002	U	0.0021	U	-	-	0.0018	U	0.002	U	0.0021	U	-	-
1,2,4-Trichlorobenzene	120-82-1	mg/Kg	NS	NS	NS	0.002	U	0.0021	U	-	-	0.0018	U	0.002	U	0.0021	U	-	-
1,3,5-Trimethylbenzene	108-67-8	mg/Kg	3.1	100	3.1	0.002	U	0.0021	U	-	-	0.0018	U	0.002	U	0.0021	U	-	-
1,2,4-Trimethylbenzene	95-63-6	mg/Kg	5.9	100	5.9	0.002	U	0.0021	U	-	-	0.0018	U	0.002	U	0.0021	U	-	-
1,4-Dioxane	123-91-1	mg/Kg	0.1	5.7	0.1	0.079	U	0.083	U	-	-	0.074	U	0.081	U	0.083	U	-	-
p-Diethylbenzene	105-05-5	mg/Kg	NS	NS	NS	0.002	U	0.0021	U	-	-	0.0018	U	0.002	U	0.0021	U	-	-
p-Ethyltoluene	622-96-8	mg/Kg	NS	NS	NS	0.002	U	0.0021	U	-	-	0.0018	U	0.002	U	0.0021	U	-	-
1,2,4,5-Tetramethylbenzene	95-93-2	mg/Kg	NS	NS	NS	0.002	U	0.0021	U	-	-	0.0018	U	0.002	U	0.0021	U	-	-
Ethyl ether	60-29-7	mg/Kg	NS	NS	NS	0.002	U	0.0021	U	-	-	0.0018	U	0.002	U	0.0021	U	-	-
trans-1,4-Dichloro-2-butene	110-57-6	mg/Kg	NS	NS	NS	0.0049	U	0.0052	U	-	-	0.0046	U	0.005	U	0.0052	U	-	-

SESI
CONSULTING ENGINEERS

Table 3.1 - Summary of Soil Results
80 Main Street
White Plains, New York
SESI Project #12859

Client Sample ID:	CAS #	Unit	PGWSCO	RRSCO	USCO	SB-7G (5-5.5)		SB-5G (3-3.5)		SB-5G (3-3.5)		SB-5G (9.5-10)		SB-10G (1-1.5)		SB-10G (6-6.5)		SB-10G (6-6.5)	
Date Sampled:						4/4/2023		4/4/2023		4/4/2023		4/4/2023		4/5/2023		4/5/2023		4/5/2023	
Lab Sample ID:						L2317575-05		L2317575-07		L2317575-07 R1		L2317575-08		L2317865-02		L2317865-03		L2317865-03 R1	
Volatile Organics by EPA 5035 High/8260																			
Methylene chloride	75-09-2	mg/Kg	0.05	81	0.05	-	-	-	-	-	-	-	-	-	-	-	-	-	-
1,1-Dichloroethane	75-34-3	mg/Kg	0.27	47	0.27	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Chloroform	67-66-3	mg/Kg	0.37	24	0.37	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Carbon tetrachloride	56-23-5	mg/Kg	0.76	7.1	0.76	-	-	-	-	-	-	-	-	-	-	-	-	-	-
1,2-Dichloropropane	78-87-5	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Dibromochloromethane	124-48-1	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-
1,1,2-Trichloroethane	79-00-5	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Tetrachloroethene	127-18-4	mg/Kg	1.3	18	1.3	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Chlorobenzene	108-90-7	mg/Kg	4.5	100	4.5	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Trichlorofluoromethane	75-69-4	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-
1,2-Dichloroethane	107-06-2	mg/Kg	0.02	5.8	0.02	-	-	-	-	-	-	-	-	-	-	-	-	-	-
1,1,1-Trichloroethane	71-55-6	mg/Kg	0.68	100	0.68	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Bromodichloromethane	75-27-4	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-
trans-1,3-Dichloropropene	10061-02-6	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-
cis-1,3-Dichloropropene	10061-01-5	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-
1,3-Dichloropropene, Total	542-75-6	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-
1,1-Dichloropropene	563-58-6	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Bromoform	75-25-2	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-
1,1,2,2-Tetrachloroethane	79-34-5	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Benzene	71-43-2	mg/Kg	0.06	3.7	0.06	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Toluene	108-88-3	mg/Kg	0.7	100	0.7	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Ethylbenzene	100-41-4	mg/Kg	1	76	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Chloromethane	74-87-3	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Bromomethane	74-83-9	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Vinyl chloride	75-01-4	mg/Kg	0.03	0.48	0.03	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Chloroethane	75-00-3	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-
1,1-Dichloroethene	75-35-4	mg/Kg	0.33	0.98	0.24	-	-	-	-	-	-	-	-	-	-	-	-	-	-
trans-1,2-Dichloroethene	156-60-5	mg/Kg	0.19	100	0.19	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Trichloroethene	79-01-6	mg/Kg	0.47	6.4	0.47	-	-	-	-	-	-	-	-	-	-	-	-	-	-
1,2-Dichlorobenzene	95-50-1	mg/Kg	1.1	100	1.1	-	-	-	-	-	-	-	-	-	-	-	-	-	-
1,3-Dichlorobenzene	541-73-1	mg/Kg	2.6	38	2.6	-	-	-	-	-	-	-	-	-	-	-	-	-	-
1,4-Dichlorobenzene	106-46-7	mg/Kg	1.8	24	1.8	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Methyl tert butyl ether	1634-04-4	mg/Kg	0.1	100	0.1	-	-	-	-	-	-	-	-	-	-	-	-	-	-
p/m-Xylene	179601-23-1	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-
o-Xylene	95-47-6	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Xylenes, Total	1330-20-7	mg/Kg	1.2	100	0.26	-	-	-	-	-	-	-	-	-	-	-	-	-	-
cis-1,2-Dichloroethene	156-59-2	mg/Kg	0.19	41	0.19	-	-	-	-	-	-	-	-	-	-	-	-	-	-
1,2-Dichloroethene, Total	540-59-0	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Dibromomethane	74-95-3	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Styrene	100-42-5	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Dichlorodifluoromethane	75-71-8	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Acetone	67-64-1	mg/Kg	0.03	100	0.03	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Carbon disulfide	75-15-0	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2-Butanone	78-93-3	mg/Kg	0.1	100	0.1	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Vinyl acetate	108-05-4	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-
4-Methyl-2-pentanone	108-10-1	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-
1,2,3-Trichloropropane	96-18-4	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2-Hexanone	591-78-6	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Bromochloromethane	74-97-5	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2,2-Dichloropropane	594-20-7	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-
1,2-Dibromoethane	106-93-4	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-
1,3-Dichloropropane	142-28-9	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-
1,1,1,2-Tetrachloroethane	630-20-6	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Bromobenzene	108-86-1	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-
n-Butylbenzene	104-51-8	mg/Kg	18	100	18	-	-	-	-	-	-	-	-	-	-	-	-	-	-
sec-Butylbenzene	135-98-8	mg/Kg	25	100	25	-	-	-	-	-	-	-	-	-	-	-	-	-	-
tert-Butylbenzene	98-06-6	mg/Kg	11	100	11	-	-	-	-	-	-	-	-	-	-	-	-	-	-
o-Chlorotoluene	95-49-8	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-
p-Chlorotoluene	106-43-4	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-
1,2-Dibromo-3-chloropropane	96-12-8	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Hexachlorobutadiene	87-68-3	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Isopropylbenzene	98-82-8	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-
p-Isopropyltoluene	99-87-6	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Naphthalene	91-20-3	mg/Kg	12	100	12	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Acrylonitrile	107-13-1	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-
n-Propylbenzene	103-65-1	mg/Kg	5	100	5	-	-	-	-	-	-	-	-	-	-	-	-	-	-
1,2,3-Trichlorobenzene	87-61-6	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-
1,2,4-Trichlorobenzene	120-82-1	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-
1,3,5-Trimethylbenzene	108-67-8	mg/Kg	3.1	100	3.1	-	-	-	-	-	-	-	-	-	-	-	-	-	-
1,2,4-Trimethylbenzene	95-63-6	mg/Kg	5.9	100	5.9	-	-	-	-	-	-	-	-	-	-	-	-	-	-
1,4-Dioxane	123-91-1	mg/Kg	0.1	5.7	0.1	-	-	-	-	-	-	-	-	-	-	-	-	-	-
p-Diethylbenzene	105-05-5	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-
p-Ethyltoluene	622-96-8	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-
1,2,4,5-Tetramethylbenzene	95-93-2	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Ethyl ether	60-29-7	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-
trans-1,4-Dichloro-2-butene	110-57-6	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-	-	-	-	-

Concentration Exceeds the USCO

Concentration Exceeds the PGWSCO or RRSCO

PGWSCOs: New York 2025 NYCRR Part 375 Groundwater Criteria, New York Restricted use Criteria per 6 NYCRR Part 375 Environmental Remediation Programs, effective 12/2006 amended 12/2025.

RRSCOs: New York 2025 NYCRR Part 375 Restricted-Residential Criteria, New York Restricted use Criteria per 6 NYCRR Part 375 Environmental Remediation Programs, effective 12/2006 amended 12/2025.

USCOs: New York 2025 NYCRR Part 375 New York Unrestricted use Criteria Criteria per 6 NYCRR Part 375 Environmental Remediation Programs, effective 12/2006 amended 12/2025.

mg/Kg = Milligrams per Kilogram

U = Not Detected

J = Estimated concentration

E = Concentration Exceeds the calibrated analysis range

NS = No Standard

SESI CONSULTING ENGINEERS

Table 3.1 - Summary of Soil Results
80 Main Street
White Plains, New York
SESI Project #12859

Client Sample ID:	CAS #	Unit	PGWSCO	RRSCO	USCO	SB-10G (6-6.5)		SB-12G (4-4.5)		SB-21G (9-9.5)		SB-21G (12-12.5)		SB-45G(3.5-4)	
Date Sampled:						4/5/2023		4/5/2023		6/5/2023		6/5/2023		7/18/2023	
Lab Sample ID:						L2317865-03 R2		L2317865-06		L2331226-02		L2331226-03		L2341039-02	
						Conc	Q	Conc	Q	Conc	Q	Conc	Q	Conc	Q
General Chemistry															
Solids, Total	NONE	%	NS	NS	NS	-	-	90.6		90.5		82.2		90.6	
Cyanide, Total	57-12-5	40	40	13	2.3	-	-	1	U	1.1	U	1.1	U	1.1	U
Organochlorine Pesticides by GC															
Delta-BHC	319-86-8	mg/Kg	0.1	100	0.04	-	-	0.00169	U	0.0017	U	0.00187	U	0.00172	U
Lindane	58-89-9	mg/Kg	0.05	0.21	0.025	-	-	0.000705	U	0.000708	U	0.000778	U	0.000715	U
Alpha-BHC	319-84-6	mg/Kg	0.02	0.18	0.02	-	-	0.000705	U	0.000708	U	0.000778	U	0.000715	U
Beta-BHC	319-85-7	mg/Kg	0.09	0.18	0.021	-	-	0.00169	U	0.0017	U	0.00187	U	0.00172	U
Heptachlor	76-44-8	mg/Kg	0.38	0.53	0.013	-	-	0.000846	U	0.000849	U	0.000934	U	0.000858	U
Aldrin	309-00-2	mg/Kg	0.19	0.044	0.0048	-	-	0.00169	U	0.0017	U	0.00187	U	0.00172	U
Heptachlor epoxide	1024-57-3	mg/Kg	NS	NS	NS	-	-	0.00317	U	0.00318	U	0.0035	U	0.00322	U
Endrin	72-20-8	mg/Kg	0.06	5.3	0.014	-	-	0.000705	U	0.000708	U	0.000778	U	0.000715	U
Endrin aldehyde	7421-93-4	mg/Kg	NS	NS	NS	-	-	0.00212	U	0.00212	U	0.00234	U	0.00214	U
Endrin ketone	53494-70-5	mg/Kg	NS	NS	NS	-	-	0.00169	U	0.0017	U	0.00187	U	0.00172	U
Dieldrin	60-57-1	mg/Kg	0.1	0.075	0.005	-	-	0.00128		0.00106	U	0.00117	U	0.00107	U
4,4'-DDE	72-55-9	mg/Kg	9.3	3.4	0.0033	-	-	0.000711	JIP	0.0017	U	0.00187	U	0.00655	
4,4'-DDD	72-54-8	mg/Kg	14	5	0.0033	-	-	0.00169	U	0.0017	U	0.00187	U	0.00143	J
4,4'-DDT	50-29-3	mg/Kg	135	3.8	0.0033	-	-	0.00169	U	0.0017	U	0.00187	U	0.00139	JIF
Endosulfan I	959-98-8	mg/Kg	65	35	4.3	-	-	0.00169	U	0.0017	U	0.00187	U	0.00172	U
Endosulfan II	33213-65-9	mg/Kg	44	35	4.3	-	-	0.00169	U	0.0017	U	0.00187	U	0.00172	U
Endosulfan sulfate	1031-07-8	mg/Kg	47	35	4.3	-	-	0.000705	U	0.000708	U	0.000778	U	0.000715	U
Methoxychlor	72-43-5	mg/Kg	NS	NS	NS	-	-	0.00317	U	0.00318	U	0.0035	U	0.00322	U
Toxaphene	8001-35-2	mg/Kg	NS	NS	NS	-	-	0.0317	U	0.0318	U	0.035	U	0.0322	U
cis-Chlordane	5103-71-9	mg/Kg	4.5	0.65	0.014	-	-	0.00212	U	0.00212	U	0.00234	U	0.00444	
trans-Chlordane	5103-74-2	mg/Kg	NS	NS	NS	-	-	0.00212	U	0.00212	U	0.00234	U	0.0036	IP
Chlordane	57-74-9	mg/Kg	NS	NS	NS	-	-	0.0141	U	0.0142	U	0.0156	U	0.0299	
Perfluorinated Alkyl Acids by EPA 1633															
Perfluorobutanoic Acid (PFBA)	375-22-4	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-
Perfluoropentanoic Acid (PFPeA)	2706-90-3	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-
Perfluorobutanesulfonic Acid (PFBS)	375-73-5	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-
Perfluorohexanoic Acid (PFHxA)	307-24-4	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-
Perfluoroheptanoic Acid (PFHpA)	375-85-9	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-
Perfluorohexanesulfonic Acid (PFHxS)	355-46-4	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-
Perfluorooctanoic Acid (PFOA)	335-67-1	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-
1H,1H,2H,2H-Perfluorooctanesulfonic Acid (6:2FTS)	27619-97-2	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-
Perfluoroheptanesulfonic Acid (PFHpS)	375-92-8	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-
Perfluorononanoic Acid (PFNA)	375-95-1	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-
Perfluorooctanesulfonic Acid (PFOS)	1763-23-1	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-
Perfluorodecanoic Acid (PFDA)	335-76-2	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-
1H,1H,2H,2H-Perfluorodecanesulfonic Acid (8:2FTS)	39108-34-4	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-
N-Methyl Perfluorooctanesulfonamidoacetic Acid (NMeFOSAA)	2355-31-9	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-
Perfluoroundecanoic Acid (PFUnA)	2058-94-8	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-
Perfluorodecanesulfonic Acid (PFDS)	335-77-3	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-
Perfluorooctanesulfonamide (PFOSA)	754-91-6	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-
N-Ethyl Perfluorooctanesulfonamidoacetic Acid (NEtFOSAA)	2991-50-6	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-
Perfluorododecanoic Acid (PFDoA)	307-55-1	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-
Perfluorotridecanoic Acid (PFTrDA)	72629-94-8	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-
Perfluorotetradecanoic Acid (PFTeDA)	376-06-7	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-
PFOA/PFOS, Total	null	mg/Kg	NS	NS	NS	-	-	-	-	-	-	-	-	-	-
Polychlorinated Biphenyls by GC															
Aroclor 1016	12674-11-2	mg/Kg	3.2	1	0.1	-	-	0.0362	U	0.0534	U	0.0554	U	0.0545	U
Aroclor 1221	11104-28-2	mg/Kg	3.2	1	0.1	-	-	0.0362	U	0.0534	U	0.0554	U	0.0545	U
Aroclor 1232	11141-16-5	mg/Kg	3.2	1	0.1	-	-	0.0362	U	0.0534	U	0.0554	U	0.0545	U
Aroclor 1242	53469-21-9	mg/Kg	3.2	1	0.1	-	-	0.0362	U	0.0534	U	0.0554	U	0.0545	U
Aroclor 1248	12672-29-6	mg/Kg	3.2	1	0.1	-	-	0.0362	U	0.0534	U	0.0554	U	0.0545	U
Aroclor 1254	11097-69-1	mg/Kg	3.2	1	0.1	-	-	0.0362	U	0.0534	U	0.0554	U	0.0545	U
Aroclor 1260	11096-82-5	mg/Kg	3.2	1	0.1	-	-	0.0362	U	0.0534	U	0.0554	U	0.0545	U
Aroclor 1262	37324-23-5	mg/Kg	3.2	1	0.1	-	-	0.0362	U	0.0534	U	0.0554	U	0.0545	U
Aroclor 1268	11100-14-4	mg/Kg	3.2	1	0.1	-	-	0.0362	U	0.0534	U	0.0554	U	0.0545	U
PCBs, Total	1336-36-3	mg/Kg	3.2	1	0.1	-	-	0.0362	U	0.0534	U	0.0554	U	0.0545	U

SESI
CONSULTING ENGINEERS

Table 3.1 - Summary of Soil Results
80 Main Street
White Plains, New York
SESI Project #12859

Client Sample ID:	CAS #	Unit	PGWSCO	RRSCO	USCO	SB-10G (6-6.5)		SB-12G (4-4.5)		SB-21G (9-9.5)		SB-21G (12-12.5)		SB-45G(3.5-4)	
Date Sampled:						4/5/2023		4/5/2023		6/5/2023		6/5/2023		7/18/2023	
Lab Sample ID:						L2317865-03 R2		L2317865-06		L2331226-02		L2331226-03		L2341039-02	
Semivolatile Organics by GC/MS															
Acenaphthene	83-32-9	mg/Kg	98	100	20	-	-	0.049	J	0.14	U	0.16	U	0.13	J
1,2,4-Trichlorobenzene	120-82-1	mg/Kg	NS	NS	NS	-	-	0.18	U	0.18	U	0.2	U	0.18	U
Hexachlorobenzene	118-74-1	mg/Kg	3.2	0.33	0.33	-	-	0.11	U	0.11	U	0.12	U	0.11	U
Bis(2-chloroethyl)ether	111-44-4	mg/Kg	NS	NS	NS	-	-	0.16	U	0.16	U	0.18	U	0.16	U
2-Chloronaphthalene	91-58-7	mg/Kg	NS	NS	NS	-	-	0.18	U	0.18	U	0.2	U	0.18	U
1,2-Dichlorobenzene	95-50-1	mg/Kg	1.1	100	1.1	-	-	0.18	U	0.18	U	0.2	U	0.18	U
1,3-Dichlorobenzene	541-73-1	mg/Kg	2.6	38	2.6	-	-	0.18	U	0.18	U	0.2	U	0.18	U
1,4-Dichlorobenzene	106-46-7	mg/Kg	1.8	24	1.8	-	-	0.18	U	0.18	U	0.2	U	0.18	U
3,3'-Dichlorobenzidine	91-94-1	mg/Kg	NS	NS	NS	-	-	0.18	U	0.18	U	0.2	U	0.18	U
2,4-Dinitrotoluene	121-14-2	mg/Kg	NS	NS	NS	-	-	0.18	U	0.18	U	0.2	U	0.18	U
2,6-Dinitrotoluene	606-20-2	mg/Kg	NS	NS	NS	-	-	0.18	U	0.18	U	0.2	U	0.18	U
Fluoranthene	206-44-0	mg/Kg	1000	100	85	-	-	0.43		0.057	J	0.12	U	1.8	
4-Chlorophenyl phenyl ether	7005-72-3	mg/Kg	NS	NS	NS	-	-	0.18	U	0.18	U	0.2	U	0.18	U
4-Bromophenyl phenyl ether	101-55-3	mg/Kg	NS	NS	NS	-	-	0.18	U	0.18	U	0.2	U	0.18	U
Bis(2-chloroisopropyl)ether	108-60-1	mg/Kg	NS	NS	NS	-	-	0.22	U	0.22	U	0.24	U	0.21	U
Bis(2-chloroethoxy)methane	111-91-1	mg/Kg	NS	NS	NS	-	-	0.2	U	0.19	U	0.22	U	0.19	U
Hexachlorobutadiene	87-68-3	mg/Kg	NS	NS	NS	-	-	0.18	U	0.18	U	0.2	U	0.18	U
Hexachlorocyclopentadiene	77-47-4	mg/Kg	NS	NS	NS	-	-	0.52	U	0.51	U	0.58	U	0.51	U
Hexachloroethane	67-72-1	mg/Kg	NS	NS	NS	-	-	0.14	U	0.14	U	0.16	U	0.14	U
Isophorone	78-59-1	mg/Kg	NS	NS	NS	-	-	0.16	U	0.16	U	0.18	U	0.16	U
Naphthalene	91-20-3	mg/Kg	12	100	12	-	-	0.18	U	0.18	U	0.2	U	0.076	J
Nitrobenzene	98-95-3	mg/Kg	0.08	1.8	0.08	-	-	0.16	U	0.16	U	0.18	U	0.16	U
NDPA/DPA	86-30-6	mg/Kg	NS	NS	NS	-	-	0.14	U	0.14	U	0.16	U	0.14	U
n-Nitrosodi-n-propylamine	621-64-7	mg/Kg	NS	NS	NS	-	-	0.18	U	0.18	U	0.2	U	0.18	U
Bis(2-ethylhexyl)phthalate	117-81-7	mg/Kg	NS	NS	NS	-	-	0.18	U	0.18	U	0.2	U	0.074	J
Butyl benzyl phthalate	85-68-7	mg/Kg	NS	NS	NS	-	-	0.18	U	0.18	U	0.2	U	0.18	U
Di-n-butylphthalate	84-74-2	mg/Kg	NS	NS	NS	-	-	0.18	U	0.18	U	0.2	U	0.18	U
Di-n-octylphthalate	117-84-0	mg/Kg	NS	NS	NS	-	-	0.18	U	0.18	U	0.2	U	0.18	U
Diethyl phthalate	84-66-2	mg/Kg	NS	NS	NS	-	-	0.18	U	0.18	U	0.2	U	0.18	U
Dimethyl phthalate	131-11-3	mg/Kg	NS	NS	NS	-	-	0.18	U	0.18	U	0.2	U	0.18	U
Benzo(a)anthracene	56-55-3	mg/Kg	1	1.4	1	-	-	0.22		0.033	J	0.12	U	0.83	
Benzo(a)pyrene	50-32-8	mg/Kg	22	1	1	-	-	0.18		0.14	U	0.16	U	0.78	
Benzo(b)fluoranthene	205-99-2	mg/Kg	2.1	1.4	1	-	-	0.2		0.043	J	0.12	U	0.96	
Benzo(k)fluoranthene	207-08-9	mg/Kg	2	4.9	0.8	-	-	0.081	J	0.11	U	0.12	U	0.3	
Chrysene	218-01-9	mg/Kg	1	4.9	1	-	-	0.21		0.029	J	0.12	U	0.79	
Acenaphthylene	208-96-8	mg/Kg	365	100	100	-	-	0.03	J	0.14	U	0.16	U	0.076	J
Anthracene	120-12-7	mg/Kg	1000	100	100	-	-	0.1	J	0.11	U	0.12	U	0.33	
Benzo(ghi)perylene	191-24-2	mg/Kg	1000	4.9	0.64	-	-	0.091	J	0.14	U	0.16	U	0.43	
Fluorene	86-73-7	mg/Kg	386	100	30	-	-	0.052	J	0.18	U	0.2	U	0.14	J
Phenanthrene	85-01-8	mg/Kg	1000	4.9	1.1	850		0.36		0.028	J	0.12	U	1.2	
Dibenzo(a,h)anthracene	53-70-3	mg/Kg	1000	0.33	0.33	-	-	0.025	J	0.11	U	0.12	U	0.11	
Indeno(1,2,3-cd)pyrene	193-39-5	mg/Kg	6.6	1.4	0.5	-	-	0.1	J	0.14	U	0.16	U	0.51	
Pyrene	129-00-0	mg/Kg	1000	100	64	-	-	0.38		0.048	J	0.12	U	1.5	
Biphenyl	92-52-4	mg/Kg	NS	NS	NS	-	-	0.41	U	0.41	U	0.46	U	0.41	U
4-Chloroaniline	106-47-8	mg/Kg	NS	NS	NS	-	-	0.18	U	0.18	U	0.2	U	0.18	U
2-Nitroaniline	88-74-4	mg/Kg	NS	NS	NS	-	-	0.18	U	0.18	U	0.2	U	0.18	U
3-Nitroaniline	99-09-2	mg/Kg	NS	NS	NS	-	-	0.18	U	0.18	U	0.2	U	0.18	U
4-Nitroaniline	100-01-6	mg/Kg	NS	NS	NS	-	-	0.18	U	0.18	U	0.2	U	0.18	U
Dibenzofuran	132-64-9	mg/Kg	110	18	2.1	-	-	0.026	J	0.18	U	0.2	U	0.085	J
2-Methylnaphthalene	91-57-6	mg/Kg	NS	NS	NS	-	-	0.22	U	0.22	U	0.24	U	0.039	J
1,2,4,5-Tetrachlorobenzene	95-94-3	mg/Kg	NS	NS	NS	-	-	0.18	U	0.18	U	0.2	U	0.18	U
Acetophenone	98-86-2	mg/Kg	NS	NS	NS	-	-	0.18	U	0.18	U	0.2	U	0.18	U
2,4,6-Trichlorophenol	88-06-2	mg/Kg	NS	NS	NS	-	-	0.11	U	0.11	U	0.12	U	0.11	U
p-Chloro-m-cresol	59-50-7	mg/Kg	NS	NS	NS	-	-	0.18	U	0.18	U	0.2	U	0.18	U
2-Chlorophenol	95-57-8	mg/Kg	NS	NS	NS	-	-	0.18	U	0.18	U	0.2	U	0.18	U
2,4-Dichlorophenol	120-83-2	mg/Kg	NS	NS	NS	-	-	0.16	U	0.16	U	0.18	U	0.16	U
2,4-Dimethylphenol	105-67-9	mg/Kg	NS	NS	NS	-	-	0.18	U	0.18	U	0.2	U	0.18	U
2-Nitrophenol	88-75-5	mg/Kg	NS	NS	NS	-	-	0.39	U	0.39	U	0.44	U	0.38	U
4-Nitrophenol	100-02-7	mg/Kg	NS	NS	NS	-	-	0.25	U	0.25	U	0.28	U	0.25	U
2,4-Dinitrophenol	51-28-5	mg/Kg	NS	NS	NS	-	-	0.87	U	0.86	U	0.97	U	0.86	U
4,6-Dinitro-o-cresol	534-52-1	mg/Kg	NS	NS	NS	-	-	0.47	U	0.47	U	0.52	U	0.46	U
Pentachlorophenol	87-86-5	mg/Kg	0.8	1.3	0.8	-	-	0.14	U	0.14	U	0.16	U	0.14	U
Phenol	108-95-2	mg/Kg	0.33	100	0.33	-	-	0.18	U	0.18	U	0.2	U	0.18	U
2-Methylphenol	95-48-7	mg/Kg	0.33	100	0.33	-	-	0.18	U	0.18	U	0.2	U	0.18	U
3-Methylphenol/4-Methylphenol	108-39-4/106-44-5	mg/Kg	0.33	100	0.33	-	-	0.26	U	0.26	U	0.29	U	0.26	U
2,4,5-Trichlorophenol	95-95-4	mg/Kg	NS	NS	NS	-	-	0.18	U	0.18	U	0.2	U	0.18	U
Benzoic Acid	65-85-0	mg/Kg	NS	NS	NS	-	-	0.58	U	0.58	U	0.65	U	0.58	U
Benzyl Alcohol	100-51-6	mg/Kg	NS	NS	NS	-	-	0.18	U	0.18	U	0.2	U	0.18	U
Carbazole	86-74-8	mg/Kg	NS	NS	NS	-	-	0.038	J	0.18	U	0.2	U	0.17	J
1,4-Dioxane	123-91-1	mg/Kg	0.1	5.7	0.1	-	-	0.027	U	0.027	U	0.03	U	0.027	U
Total Metals															
Aluminum, Total	7429-90-5	mg/Kg	NS	NS	NS	-	-	7450		9780		5380		7680	
Antimony, Total	7440-36-0	mg/Kg	NS	NS	NS	-	-	4.23	U	4.3	U	4.71	U	3.03	J
Arsenic, Total	7440-38-2	mg/Kg	16	16	13	-	-	2.02		0.602	J	0.489	J	2.78	
Barium, Total	7440-39-3	mg/Kg	820	410	410	-	-	67		74.9		49.1		88.9	
Beryllium, Total	7440-41-7	mg/Kg	47	43	4.4	-	-	0.206	J	0.578		0.305	J	0.44	
Cadmium, Total	7440-43-9	mg/Kg	7.5	2.5	2.5	-	-	0.107	J	0.144	J	0.15	J	0.326	J
Calcium, Total	7440-70-2	mg/Kg	NS	NS	NS	-	-	8750		7350		20400		15200	
Chromium, Total	7440-47-3	mg/Kg	NS	NS	NS	-	-	13.3		18.8		12.2		18.5	
Cobalt, Total	7440-48-4	mg/Kg	NS	NS	NS	-	-	4.93		8.14		5.62		5.7	
Copper, Total	7440-50-8	mg/Kg	1720	280	50	-	-	15.6		15.7		14.4		29.8	
Iron, Total	7439-89-6	mg/Kg	NS	NS	NS	-	-	13700		17500		11800		13600	
Lead, Total	7439-92-1	mg/Kg	450	400	63	-	-	29.4		4.18	J	2.3	J	131	
Magnesium, Total	7439-95-4	mg/Kg	NS	NS	NS	-	-	6000		6420		12800		6340	
Manganese, Total	7439-96-5	mg/Kg	2000	2000	1600	-	-	236		160		204		298	
Mercury, Total	7439-97-6	mg/Kg	0.73	0.3	0.18	-	-	0.185		0.069	U	0.077	U	0.236	
Nickel, Total	7440-02-0	mg/Kg	130	320	30	-	-	10.3		14.2		10.2		12.1	
Potassium, Total	7440-09-7	mg/Kg	NS	NS	NS	-	-	2000		3830		2350		2060	
Selenium, Total	7782-49-2	mg/Kg	4	110	3.9	-	-	1.69	U	1.72	U	1.88	U	1.68	U
Silver, Total	7440-22-4	mg/Kg	8.3	110	2	-	-	0.423	U	0.43	U	0.471	U	0.42	U
Sodium, Total	7440-23-5	mg/Kg	NS	NS	NS	-	-	106	J	158	J	139	J	315	
Thallium, Total	7440-28-0	mg/Kg	NS	NS	NS	-	-	1.69	U	1.72	U	1.88	U	1.68	U
Vanadium, Total	7440-62-2	mg/Kg	NS	NS	NS	-	-	19.6		27.7		17.3		22.9	
Zinc, Total	7440-66-6	mg/Kg	2480	6600	109	-	-	41.6		41		27.9		79.9	

SESI CONSULTING ENGINEERS

Table 3.1 - Summary of Soil Results
80 Main Street
White Plains, New York
SESI Project #12859

Client Sample ID:	CAS #	Unit	PGWSCO	RRSCO	USCO	SB-10G (6-6.5)		SB-12G (4-4.5)		SB-21G (9-9.5)		SB-21G (12-12.5)		SB-45G(3.5-4)	
Date Sampled:						4/5/2023		4/5/2023		6/5/2023		6/5/2023		7/18/2023	
Lab Sample ID:						L2317865-03 R2		L2317865-06		L2331226-02		L2331226-03		L2341039-02	
Volatile Organics by EPA 5035/8260															
Methylene chloride	75-09-2	mg/Kg	0.05	81	0.05	-	-	0.0047	U	0.0052	U	0.0055	U	0.0049	U
1,1-Dichloroethane	75-34-3	mg/Kg	0.27	47	0.27	-	-	0.00095	U	0.001	U	0.0011	U	0.00098	U
Chloroform	67-66-3	mg/Kg	0.37	24	0.37	-	-	0.0014	U	0.0016	U	0.0016	U	0.0015	U
Carbon tetrachloride	56-23-5	mg/Kg	0.76	7.1	0.76	-	-	0.00095	U	0.001	U	0.0011	U	0.00098	U
1,2-Dichloropropane	78-87-5	mg/Kg	NS	NS	NS	-	-	0.00095	U	0.001	U	0.0011	U	0.00098	U
Dibromochloromethane	124-48-1	mg/Kg	NS	NS	NS	-	-	0.00095	U	0.001	U	0.0011	U	0.00098	U
1,1,2-Trichloroethane	79-00-5	mg/Kg	NS	NS	NS	-	-	0.00095	U	0.001	U	0.0011	U	0.00098	U
Tetrachloroethene	127-18-4	mg/Kg	1.3	18	1.3	-	-	0.00047	U	0.00052	U	0.00055	U	0.00049	U
Chlorobenzene	108-90-7	mg/Kg	4.5	100	4.5	-	-	0.00047	U	0.00052	U	0.00055	U	0.00049	U
Trichlorofluoromethane	75-69-4	mg/Kg	NS	NS	NS	-	-	0.0038	U	0.0041	U	0.0044	U	0.0039	U
1,2-Dichloroethane	107-06-2	mg/Kg	0.02	5.8	0.02	-	-	0.00095	U	0.001	U	0.0011	U	0.00098	U
1,1,1-Trichloroethane	71-55-6	mg/Kg	0.68	100	0.68	-	-	0.00047	U	0.00052	U	0.00055	U	0.00049	U
Bromodichloromethane	75-27-4	mg/Kg	NS	NS	NS	-	-	0.00047	U	0.00052	U	0.00055	U	0.00049	U
trans-1,3-Dichloropropene	10061-02-6	mg/Kg	NS	NS	NS	-	-	0.00095	U	0.001	U	0.0011	U	0.00098	U
cis-1,3-Dichloropropene	10061-01-5	mg/Kg	NS	NS	NS	-	-	0.00047	U	0.00052	U	0.00055	U	0.00049	U
1,3-Dichloropropene, Total	542-75-6	mg/Kg	NS	NS	NS	-	-	0.00047	U	0.00052	U	0.00055	U	0.00049	U
1,1-Dichloropropene	563-58-6	mg/Kg	NS	NS	NS	-	-	0.00047	U	0.00052	U	0.00055	U	0.00049	U
Bromoform	75-25-2	mg/Kg	NS	NS	NS	-	-	0.0038	U	0.0041	U	0.0044	U	0.0039	U
1,1,2,2-Tetrachloroethane	79-34-5	mg/Kg	NS	NS	NS	-	-	0.00047	U	0.00052	U	0.00055	U	0.00049	U
Benzene	71-43-2	mg/Kg	0.06	3.7	0.06	-	-	0.00047	U	0.00052	U	0.00055	U	0.00049	U
Toluene	108-88-3	mg/Kg	0.7	100	0.7	-	-	0.00095	U	0.001	U	0.0011	U	0.00098	U
Ethylbenzene	100-41-4	mg/Kg	1	76	1	-	-	0.00095	U	0.001	U	0.0011	U	0.00098	U
Chloromethane	74-87-3	mg/Kg	NS	NS	NS	-	-	0.0038	U	0.0041	U	0.0044	U	0.0039	U
Bromomethane	74-83-9	mg/Kg	NS	NS	NS	-	-	0.0019	U	0.0021	U	0.0022	U	0.002	U
Vinyl chloride	75-01-4	mg/Kg	0.03	0.48	0.03	-	-	0.00095	U	0.001	U	0.0011	U	0.00098	U
Chloroethane	75-00-3	mg/Kg	NS	NS	NS	-	-	0.0019	U	0.0021	U	0.0022	U	0.002	U
1,1-Dichloroethene	75-35-4	mg/Kg	0.33	0.98	0.24	-	-	0.00095	U	0.001	U	0.0011	U	0.00098	U
trans-1,2-Dichloroethene	156-60-5	mg/Kg	0.19	100	0.19	-	-	0.0014	U	0.0016	U	0.0016	U	0.0015	U
Trichloroethene	79-01-6	mg/Kg	0.47	6.4	0.47	-	-	0.00047	U	0.00052	U	0.00055	U	0.00049	U
1,2-Dichlorobenzene	95-50-1	mg/Kg	1.1	100	1.1	-	-	0.0019	U	0.0021	U	0.0022	U	0.002	U
1,3-Dichlorobenzene	541-73-1	mg/Kg	2.6	38	2.6	-	-	0.0019	U	0.0021	U	0.0022	U	0.002	U
1,4-Dichlorobenzene	106-46-7	mg/Kg	1.8	24	1.8	-	-	0.0019	U	0.0021	U	0.0022	U	0.002	U
Methyl tert butyl ether	1634-04-4	mg/Kg	0.1	100	0.1	-	-	0.0019	U	0.0021	U	0.0022	U	0.002	U
p/m-Xylene	179601-23-1	mg/Kg	NS	NS	NS	-	-	0.0019	U	0.0021	U	0.0022	U	0.002	U
o-Xylene	95-47-6	mg/Kg	NS	NS	NS	-	-	0.00095	U	0.001	U	0.0011	U	0.00098	U
Xylenes, Total	1330-20-7	mg/Kg	1.2	100	0.26	-	-	0.00095	U	0.001	U	0.0011	U	0.00098	U
cis-1,2-Dichloroethene	156-59-2	mg/Kg	0.19	41	0.19	-	-	0.00095	U	0.001	U	0.0011	U	0.00098	U
1,2-Dichloroethene, Total	540-59-0	mg/Kg	NS	NS	NS	-	-	0.00095	U	0.001	U	0.0011	U	0.00098	U
Dibromomethane	74-95-3	mg/Kg	NS	NS	NS	-	-	0.0019	U	0.0021	U	0.0022	U	0.002	U
Styrene	100-42-5	mg/Kg	NS	NS	NS	-	-	0.00095	U	0.001	U	0.0011	U	0.00098	U
Dichlorodifluoromethane	75-71-8	mg/Kg	NS	NS	NS	-	-	0.0095	U	0.01	U	0.011	U	0.0098	U
Acetone	67-64-1	mg/Kg	0.03	100	0.03	-	-	0.0095	U	0.091		0.009	J	0.0098	U
Carbon disulfide	75-15-0	mg/Kg	NS	NS	NS	-	-	0.0095	U	0.01	U	0.011	U	0.0098	U
2-Butanone	78-93-3	mg/Kg	0.1	100	0.1	-	-	0.0095	U	0.0096	J	0.0046	J	0.0098	U
Vinyl acetate	108-05-4	mg/Kg	NS	NS	NS	-	-	0.0095	U	0.01	U	0.011	U	0.0098	U
4-Methyl-2-pentanone	108-10-1	mg/Kg	NS	NS	NS	-	-	0.0095	U	0.01	U	0.011	U	0.0098	U
1,2,3-Trichloropropane	96-18-4	mg/Kg	NS	NS	NS	-	-	0.0019	U	0.0021	U	0.0022	U	0.002	U
2-Hexanone	591-78-6	mg/Kg	NS	NS	NS	-	-	0.0095	U	0.01	U	0.011	U	0.0098	U
Bromochloromethane	74-97-5	mg/Kg	NS	NS	NS	-	-	0.0019	U	0.0021	U	0.0022	U	0.002	U
2,2-Dichloropropane	594-20-7	mg/Kg	NS	NS	NS	-	-	0.0019	U	0.0021	U	0.0022	U	0.002	U
1,2-Dibromoethane	106-93-4	mg/Kg	NS	NS	NS	-	-	0.00095	U	0.001	U	0.0011	U	0.00098	U
1,3-Dichloropropane	142-28-9	mg/Kg	NS	NS	NS	-	-	0.0019	U	0.0021	U	0.0022	U	0.002	U
1,1,1,2-Tetrachloroethane	630-20-6	mg/Kg	NS	NS	NS	-	-	0.00047	U	0.00052	U	0.00055	U	0.00049	U
Bromobenzene	108-86-1	mg/Kg	NS	NS	NS	-	-	0.0019	U	0.0021	U	0.0022	U	0.002	U
n-Butylbenzene	104-51-8	mg/Kg	18	100	18	-	-	0.00095	U	0.001	U	0.0011	U	0.00098	U
sec-Butylbenzene	135-98-8	mg/Kg	25	100	25	-	-	0.00095	U	0.001	U	0.0011	U	0.00098	U
tert-Butylbenzene	98-06-6	mg/Kg	11	100	11	-	-	0.0019	U	0.0021	U	0.0022	U	0.002	U
o-Chlorotoluene	95-49-8	mg/Kg	NS	NS	NS	-	-	0.0019	U	0.0021	U	0.0022	U	0.002	U
p-Chlorotoluene	106-43-4	mg/Kg	NS	NS	NS	-	-	0.0019	U	0.0021	U	0.0022	U	0.002	U
1,2-Dibromo-3-chloropropane	96-12-8	mg/Kg	NS	NS	NS	-	-	0.0028	U	0.0031	U	0.0033	U	0.0029	U
Hexachlorobutadiene	87-68-3	mg/Kg	NS	NS	NS	-	-	0.0038	U	0.0041	U	0.0044	U	0.0039	U
Isopropylbenzene	98-82-8	mg/Kg	NS	NS	NS	-	-	0.00095	U	0.001	U	0.0011	U	0.00098	U
p-Isopropyltoluene	99-87-6	mg/Kg	NS	NS	NS	-	-	0.00095	U	1	E	0.00056	J	0.00098	U
Naphthalene	91-20-3	mg/Kg	12	100	12	-	-	0.0038	U	0.0041	U	0.0044	U	0.0039	U
Acrylonitrile	107-13-1	mg/Kg	NS	NS	NS	-	-	0.0038	U	0.0041	U	0.0044	U	0.0039	U
n-Propylbenzene	103-65-1	mg/Kg	5	100	5	-	-	0.00095	U	0.001	U	0.0011	U	0.00098	U
1,2,3-Trichlorobenzene	87-61-6	mg/Kg	NS	NS	NS	-	-	0.0019	U	0.0021	U	0.0022	U	0.002	U
1,2,4-Trichlorobenzene	120-82-1	mg/Kg	NS	NS	NS	-	-	0.0019	U	0.0021	U	0.0022	U	0.002	U
1,3,5-Trimethylbenzene	108-67-8	mg/Kg	3.1	100	3.1	-	-	0.0019	U	0.00044	J	0.0022	U	0.002	U
1,2,4-Trimethylbenzene	95-63-6	mg/Kg	5.9	100	5.9	-	-	0.0019	U	0.0021	U	0.0022	U	0.002	U
1,4-Dioxane	123-91-1	mg/Kg	0.1	5.7	0.1	-	-	0.076	U	0.083	U	0.087	U	0.078	U
p-Diethylbenzene	105-05-5	mg/Kg	NS	NS	NS	-	-	0.0019	U	0.0021	U	0.0022	U	0.002	U
p-Ethyltoluene	622-96-8	mg/Kg	NS	NS	NS	-	-	0.0019	U	0.0021	U	0.0022	U	0.002	U
1,2,4,5-Tetramethylbenzene	95-93-2	mg/Kg	NS	NS	NS	-	-	0.0019	U	0.0021	U	0.0022	U	0.002	U
Ethyl ether	60-29-7	mg/Kg	NS	NS	NS	-	-	0.0019	U	0.0021	U	0.0022	U	0.002	U
trans-1,4-Dichloro-2-butene	110-57-6	mg/Kg	NS	NS	NS	-	-	0.0047	U	0.0052	U	0.0055	U	0.0049	U

SESI
CONSULTING ENGINEERS

Table 3.1 - Summary of Soil Results
80 Main Street
White Plains, New York
SESI Project #12859

Client Sample ID:	CAS #	Unit	PGWSCO	RRSCO	USCO	SB-10G (6-6.5)		SB-12G (4-4.5)		SB-21G (9-9.5)		SB-21G (12-12.5)		SB-45G(3.5-4)	
Date Sampled:						4/5/2023		4/5/2023		6/5/2023		6/5/2023		7/18/2023	
Lab Sample ID:						L2317865-03 R2		L2317865-06		L2331226-02		L2331226-03		L2341039-02	
Volatile Organics by EPA 5035 High/8260															
Methylene chloride	75-09-2	mg/Kg	0.05	81	0.05	-	-	-	-	0.3	U	-	-	-	-
1,1-Dichloroethane	75-34-3	mg/Kg	0.27	47	0.27	-	-	-	-	0.06	U	-	-	-	-
Chloroform	67-66-3	mg/Kg	0.37	24	0.37	-	-	-	-	0.09	U	-	-	-	-
Carbon tetrachloride	56-23-5	mg/Kg	0.76	7.1	0.76	-	-	-	-	0.06	U	-	-	-	-
1,2-Dichloropropane	78-87-5	mg/Kg	NS	NS	NS	-	-	-	-	0.06	U	-	-	-	-
Dibromochloromethane	124-48-1	mg/Kg	NS	NS	NS	-	-	-	-	0.06	U	-	-	-	-
1,1,2-Trichloroethane	79-00-5	mg/Kg	NS	NS	NS	-	-	-	-	0.06	U	-	-	-	-
Tetrachloroethene	127-18-4	mg/Kg	1.3	18	1.3	-	-	-	-	0.03	U	-	-	-	-
Chlorobenzene	108-90-7	mg/Kg	4.5	100	4.5	-	-	-	-	0.03	U	-	-	-	-
Trichlorofluoromethane	75-69-4	mg/Kg	NS	NS	NS	-	-	-	-	0.24	U	-	-	-	-
1,2-Dichloroethane	107-06-2	mg/Kg	0.02	5.8	0.02	-	-	-	-	0.06	U	-	-	-	-
1,1,1-Trichloroethane	71-55-6	mg/Kg	0.68	100	0.68	-	-	-	-	0.03	U	-	-	-	-
Bromodichloromethane	75-27-4	mg/Kg	NS	NS	NS	-	-	-	-	0.03	U	-	-	-	-
trans-1,3-Dichloropropene	10061-02-6	mg/Kg	NS	NS	NS	-	-	-	-	0.06	U	-	-	-	-
cis-1,3-Dichloropropene	10061-01-5	mg/Kg	NS	NS	NS	-	-	-	-	0.03	U	-	-	-	-
1,3-Dichloropropene, Total	542-75-6	mg/Kg	NS	NS	NS	-	-	-	-	0.03	U	-	-	-	-
1,1-Dichloropropene	563-58-6	mg/Kg	NS	NS	NS	-	-	-	-	0.03	U	-	-	-	-
Bromoform	75-25-2	mg/Kg	NS	NS	NS	-	-	-	-	0.24	U	-	-	-	-
1,1,2,2-Tetrachloroethane	79-34-5	mg/Kg	NS	NS	NS	-	-	-	-	0.03	U	-	-	-	-
Benzene	71-43-2	mg/Kg	0.06	3.7	0.06	-	-	-	-	0.03	U	-	-	-	-
Toluene	108-88-3	mg/Kg	0.7	100	0.7	-	-	-	-	0.06	U	-	-	-	-
Ethylbenzene	100-41-4	mg/Kg	1	76	1	-	-	-	-	0.06	U	-	-	-	-
Chloromethane	74-87-3	mg/Kg	NS	NS	NS	-	-	-	-	0.24	U	-	-	-	-
Bromomethane	74-83-9	mg/Kg	NS	NS	NS	-	-	-	-	0.12	U	-	-	-	-
Vinyl chloride	75-01-4	mg/Kg	0.03	0.48	0.03	-	-	-	-	0.06	U	-	-	-	-
Chloroethane	75-00-3	mg/Kg	NS	NS	NS	-	-	-	-	0.12	U	-	-	-	-
1,1-Dichloroethene	75-35-4	mg/Kg	0.33	0.98	0.24	-	-	-	-	0.06	U	-	-	-	-
trans-1,2-Dichloroethene	156-60-5	mg/Kg	0.19	100	0.19	-	-	-	-	0.09	U	-	-	-	-
Trichloroethene	79-01-6	mg/Kg	0.47	6.4	0.47	-	-	-	-	0.03	U	-	-	-	-
1,2-Dichlorobenzene	95-50-1	mg/Kg	1.1	100	1.1	-	-	-	-	0.12	U	-	-	-	-
1,3-Dichlorobenzene	541-73-1	mg/Kg	2.6	38	2.6	-	-	-	-	0.12	U	-	-	-	-
1,4-Dichlorobenzene	106-46-7	mg/Kg	1.8	24	1.8	-	-	-	-	0.12	U	-	-	-	-
Methyl tert butyl ether	1634-04-4	mg/Kg	0.1	100	0.1	-	-	-	-	0.12	U	-	-	-	-
p/m-Xylene	179601-23-1	mg/Kg	NS	NS	NS	-	-	-	-	0.12	U	-	-	-	-
o-Xylene	95-47-6	mg/Kg	NS	NS	NS	-	-	-	-	0.06	U	-	-	-	-
Xylenes, Total	1330-20-7	mg/Kg	1.2	100	0.26	-	-	-	-	0.06	U	-	-	-	-
cis-1,2-Dichloroethene	156-59-2	mg/Kg	0.19	41	0.19	-	-	-	-	0.06	U	-	-	-	-
1,2-Dichloroethene, Total	540-59-0	mg/Kg	NS	NS	NS	-	-	-	-	0.06	U	-	-	-	-
Dibromomethane	74-95-3	mg/Kg	NS	NS	NS	-	-	-	-	0.12	U	-	-	-	-
Styrene	100-42-5	mg/Kg	NS	NS	NS	-	-	-	-	0.06	U	-	-	-	-
Dichlorodifluoromethane	75-71-8	mg/Kg	NS	NS	NS	-	-	-	-	0.6	U	-	-	-	-
Acetone	67-64-1	mg/Kg	0.03	100	0.03	-	-	-	-	0.6	U	-	-	-	-
Carbon disulfide	75-15-0	mg/Kg	NS	NS	NS	-	-	-	-	0.6	U	-	-	-	-
2-Butanone	78-93-3	mg/Kg	0.1	100	0.1	-	-	-	-	0.6	U	-	-	-	-
Vinyl acetate	108-05-4	mg/Kg	NS	NS	NS	-	-	-	-	0.6	U	-	-	-	-
4-Methyl-2-pentanone	108-10-1	mg/Kg	NS	NS	NS	-	-	-	-	0.6	U	-	-	-	-
1,2,3-Trichloropropane	96-18-4	mg/Kg	NS	NS	NS	-	-	-	-	0.12	U	-	-	-	-
2-Hexanone	591-78-6	mg/Kg	NS	NS	NS	-	-	-	-	0.6	U	-	-	-	-
Bromochloromethane	74-97-5	mg/Kg	NS	NS	NS	-	-	-	-	0.12	U	-	-	-	-
2,2-Dichloropropane	594-20-7	mg/Kg	NS	NS	NS	-	-	-	-	0.12	U	-	-	-	-
1,2-Dibromoethane	106-93-4	mg/Kg	NS	NS	NS	-	-	-	-	0.06	U	-	-	-	-
1,3-Dichloropropane	142-28-9	mg/Kg	NS	NS	NS	-	-	-	-	0.12	U	-	-	-	-
1,1,1,2-Tetrachloroethane	630-20-6	mg/Kg	NS	NS	NS	-	-	-	-	0.03	U	-	-	-	-
Bromobenzene	108-86-1	mg/Kg	NS	NS	NS	-	-	-	-	0.12	U	-	-	-	-
n-Butylbenzene	104-51-8	mg/Kg	18	100	18	-	-	-	-	0.06	U	-	-	-	-
sec-Butylbenzene	135-98-8	mg/Kg	25	100	25	-	-	-	-	0.06	U	-	-	-	-
tert-Butylbenzene	98-06-6	mg/Kg	11	100	11	-	-	-	-	0.12	U	-	-	-	-
o-Chlorotoluene	95-49-8	mg/Kg	NS	NS	NS	-	-	-	-	0.12	U	-	-	-	-
p-Chlorotoluene	106-43-4	mg/Kg	NS	NS	NS	-	-	-	-	0.12	U	-	-	-	-
1,2-Dibromo-3-chloropropane	96-12-8	mg/Kg	NS	NS	NS	-	-	-	-	0.18	U	-	-	-	-
Hexachlorobutadiene	87-68-3	mg/Kg	NS	NS	NS	-	-	-	-	0.24	U	-	-	-	-
Isopropylbenzene	98-82-8	mg/Kg	NS	NS	NS	-	-	-	-	0.06	U	-	-	-	-
p-Isopropyltoluene	99-87-6	mg/Kg	NS	NS	NS	-	-	-	-	2.5		-	-	-	-
Naphthalene	91-20-3	mg/Kg	12	100	12	-	-	-	-	0.24	U	-	-	-	-
Acrylonitrile	107-13-1	mg/Kg	NS	NS	NS	-	-	-	-	0.24	U	-	-	-	-
n-Propylbenzene	103-65-1	mg/Kg	5	100	5	-	-	-	-	0.06	U	-	-	-	-
1,2,3-Trichlorobenzene	87-61-6	mg/Kg	NS	NS	NS	-	-	-	-	0.12	U	-	-	-	-
1,2,4-Trichlorobenzene	120-82-1	mg/Kg	NS	NS	NS	-	-	-	-	0.12	U	-	-	-	-
1,3,5-Trimethylbenzene	108-67-8	mg/Kg	3.1	100	3.1	-	-	-	-	0.12	U	-	-	-	-
1,2,4-Trimethylbenzene	95-63-6	mg/Kg	5.9	100	5.9	-	-	-	-	0.12	U	-	-	-	-
1,4-Dioxane	123-91-1	mg/Kg	0.1	5.7	0.1	-	-	-	-	4.8	U	-	-	-	-
p-Diethylbenzene	105-05-5	mg/Kg	NS	NS	NS	-	-	-	-	0.12	U	-	-	-	-
p-Ethyltoluene	622-96-8	mg/Kg	NS	NS	NS	-	-	-	-	0.12	U	-	-	-	-
1,2,4,5-Tetramethylbenzene	95-93-2	mg/Kg	NS	NS	NS	-	-	-	-	0.12	U	-	-	-	-
Ethyl ether	60-29-7	mg/Kg	NS	NS	NS	-	-	-	-	0.12	U	-	-	-	-
trans-1,4-Dichloro-2-butene	110-57-6	mg/Kg	NS	NS	NS	-	-	-	-	0.3	U	-	-	-	-

Concentration Exceeds the USCO

Concentration Exceeds the PGWSCO or RRSCO

PGWSCOs: New York 2025 NYCRR Part 375 Groundwater Criteria, New York Restricted use Criteria per 6 NYCRR Part 375 Environmental Remediation Program

RRSCOs: New York 2025 NYCRR Part 375 Restricted-Residential Criteria, New York Restricted use Criteria per 6 NYCRR Part 375 Environmental Remediation P

USCOs: New York 2025 NYCRR Part 375 New York Unrestricted use Criteria Criteria per 6 NYCRR Part 375 Environmental Remediation Programs, effective 12/2

mg/Kg = Milligrams per Kilogram

U = Not Detected

J = Estimated concentration

E = Concentration Exceeds the calibrated analysis range

NS = No Standard

SESI CONSULTING ENGINEERS

Table 3.3 - Summary of Groundwater Analytical Results
80 Main Street
White Plains, New York
SESI Project #12859

SAMPLE ID:			GW-2			GW-3			GW-4			GW-5			GW-6			GW-7			GW-8			GW-9		
LAB ID:			L2316452-05			L2316865-01			L2316865-02			L2316865-03			L2316865-04			L2316865-05			L2318715-01			L2318715-02		
COLLECTION DATE:			3/29/2023			3/30/2023			3/30/2023			3/30/2023			3/30/2023			3/30/2023			4/7/2023			4/7/2023		
SAMPLE MATRIX:			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER		
ANALYTES	CAS	NY-AWQS	Conc	Q	RL	Conc	Q	RL	Conc	Q	RL	Conc	Q	RL	Conc	Q	RL	Conc	Q	RL	Conc	Q	RL	Conc	Q	RL
VOCs (ug/l)																										
1,1,1,2-Tetrachloroethane	630-20-6	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,1,1-Trichloroethane	71-55-6	5	ND		2.5	ND		2.5	4.1		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,1,2,2-Tetrachloroethane	79-34-5	5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5
1,1,2-Trichloroethane	79-00-5	1	ND		1.5	ND		1.5	ND		1.5	ND		1.5	ND		1.5	ND		1.5	ND		1.5	ND		1.5
1,1-Dichloroethane	75-34-3	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,1-Dichloroethene	75-35-4	5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5
1,1-Dichloropropene	563-58-6	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,2,3-Trichlorobenzene	87-61-6	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,2,3-Trichloropropane	96-18-4	0.04	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,2,4,5-Tetramethylbenzene	95-93-2	5	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2
1,2,4-Trichlorobenzene	120-82-1	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,2,4-Trimethylbenzene	95-63-6	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,2-Dibromo-3-chloropropane	96-12-8	0.04	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,2-Dibromoethane	106-93-4	0.0006	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2
1,2-Dichlorobenzene	95-50-1	3	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,2-Dichloroethane	107-06-2	0.6	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5
1,2-Dichloroethene, Total	540-59-0		ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,2-Dichloropropane	78-87-5	1	ND		1	ND		1	ND		1	ND		1	ND		1	ND		1	ND		1	ND		1
1,3,5-Trimethylbenzene	108-67-8	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,3-Dichlorobenzene	541-73-1	3	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,3-Dichloropropane	142-28-9	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,3-Dichloropropene, Total	542-75-6		ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5
1,4-Dichlorobenzene	106-46-7	3	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,4-Dioxane	123-91-1		ND		250	ND		250	ND		250	ND		250	ND		250	ND		250	ND		250	ND		250
2,2-Dichloropropane	594-20-7	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
2-Butanone	78-93-3	50	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	42		5	3.3	J	5
2-Hexanone	591-78-6	50	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5
4-Methyl-2-pentanone	108-10-1		ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5
Acetone	67-64-1	50	14		5	6.1		5	9.2		5	1.7	J	5	ND		5	3	J	5	72		5	11		5
Acrylonitrile	107-13-1	5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5
Benzene	71-43-2	1	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	0.24	J	0.5	ND		0.5
Bromobenzene	108-86-1	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Bromochloromethane	74-97-5	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Bromodichloromethane	75-27-4	50	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5
Bromoform	75-25-2	50	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2
Bromomethane	74-83-9	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Carbon disulfide	75-15-0	60	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5
Carbon tetrachloride	56-23-5	5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5
Chlorobenzene	108-90-7	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Chloroethane	75-00-3	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Chloroform	67-66-3	7	ND		2.5	ND		2.5	ND		2.5	ND		2.5	12		2.5	5.3		2.5	ND		2.5	ND		2.5
Chloromethane	74-87-3		ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
cis-1,2-Dichloroethene	156-59-2	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
cis-1,3-Dichloropropene	10061-01-5	0.4	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5
Dibromochloromethane	124-48-1	50	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5
Dibromomethane	74-95-3	5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5
Dichlorodifluoromethane	75-71-8	5	ND		5	ND		5	ND		5	ND		5	3	J	5	2.6	J	5	ND		5	ND		5
Ethyl ether	60-29-7		ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Ethylbenzene	100-41-4	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	1.4	J	2.5	ND		2.5
Hexachlorobutadiene	87-68-3	0.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Isopropylbenzene	98-82-8	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Methyl tert butyl ether	1634-04-4	10	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Methylene chloride	75-09-2	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
n-Butylbenzene	104-51-8	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
n-Propylbenzene	103-65-1	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Naphthalene	91-20-3	10	ND		2.5	0.81	J	2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
o-Chlorotoluene	95-49-8	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
o-Xylene	95-47-6	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
p-Chlorotoluene	106-43-4	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
p-Diethylbenzene	105-05-5		ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2
p-Ethyltoluene	622-96-8		ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2
p-Isopropyltoluene	99-87-6	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
p/m-Xylene	179601-23-1	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
sec-Butylbenzene	135-98-8	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Styrene	100-42-5	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	16		2.5	8.3		2.5
tert-Butylbenzene	98-06-6	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Tetrachloroethene	127-18-4	5	ND		0.5	ND		0.5	ND		0.5	1.1		0.5	0.96		0.5	0.53		0.5	ND		0.5	ND		0.5
Toluene	108-88-3	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
trans-1,2-Dichloroethene	156-60-5	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
trans-1,3-Dichloropropene	10061-02-6	0.4	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5
trans-1,4-Dichloro-2-butene	110-57-6	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Trichloroethene	79-01-6	5	1.6		0.5	ND		0.5	ND		0.5	0.21	J	0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5
Trichlorofluoromethane	75-69-4	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Vinyl acetate	108-05-4		ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5
Vinyl chloride	75-01-4	2	ND		1	ND		1	ND		1	ND		1	ND		1	ND		1	ND		1	ND		1
Xylenes, Total	1330-20-7		ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Total VOCs			15.6	-	-	6.91	-	-	13.3	-	-	3.01	-	-	15.96	-	-	11.43	-	-	131.64	-	-	22.6	-	-

SESI CONSULTING ENGINEERS

Table 3.3 - Summary of Groundwater Analytical Results
80 Main Street
White Plains, New York
SESI Project #12859

SAMPLE ID:			GW-2			GW-3			GW-4			GW-5			GW-6			GW-7			GW-8			GW-9		
LAB ID:			L2316452-05			L2316865-01			L2316865-02			L2316865-03			L2316865-04			L2316865-05			L2318715-01			L2318715-02		
COLLECTION DATE:			3/29/2023			3/30/2023			3/30/2023			3/30/2023			3/30/2023			3/30/2023			4/7/2023			4/7/2023		
SAMPLE MATRIX:			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER		
ANALYTES	**CAS**	**NY-AWQS**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**
VOCs TICs (ug/l)																										
1-Propene, 2-methyl-	000115-11-7		-		-	-		-	1.64	NJ	0	-		-	-		-	1.54	NJ	0	-		-	-		-
No Tentatively Identified Compounds			ND		0	-		-	-		-	-		-	ND		0	-		-	-		-	-		-
Nonanal	000124-19-6		-		-	1.37	NJ	0	-		-	-		-	-		-	-		-	-		-	-		-
Unknown			-		-	-		-	1.36	J	0	1.01	J	0	-		-	-		-	-		-	-		-
Unknown			-		-	1.06	J	0	-		-	-		-	-		-	-		-	2.52	J	0	1.23	J	0
Unknown			-		-	1.31	J	0	-		-	-		-	-		-	-		-	3.34	J	0	1.4	J	0
Unknown Aromatic			-		-	-		-	-		-	-		-	-		-	-		-	-		-	2	J	0
Unknown Aromatic			-		-	-		-	-		-	-		-	-		-	-		-	-		-	1.1	J	0
Unknown Aromatic			-		-	-		-	-		-	-		-	-		-	-		-	-		-	1.67	J	0
Unknown Naphthalene			-		-	-		-	-		-	-		-	-		-	-		-	-		-	1.68	J	0
Unknown Naphthalene			-		-	-		-	-		-	-		-	-		-	-		-	-		-	1.35	J	0
Total TIC Compounds			-		-	3.74	J	0	3	J	0	1.01	J	0	-		-	1.54	J	0	5.86	J	0	10.4	J	0
1,4 DIOXANE (ug/l)																										
1,4-Dioxane	123-91-1	1	ND		0.136	ND		0.144	2.03		0.139	ND		0.136	ND		0.136	ND		0.136	0.147		0.134	ND		6.7
PFAS (ng/l)																										
1H,1H,2H,2H-Perfluorodecanesulfonic Acid (8:2FTS)	39108-34-4		ND		8.27	ND		6.25	6.73		6.41	ND		6.41	ND		6.24	ND		5.74	ND		6.16	ND		6.38
1H,1H,2H,2H-Perfluorooctanesulfonic Acid (6:2FTS)	27619-97-2		ND		8.27	7.42		6.25	58.6		6.41	ND		6.41	ND		6.24	ND		5.74	ND		6.16	4.3	J	6.38
N-Ethyl Perfluorooctanesulfonamidoacetic Acid (NEtFOSAA)	2991-50-6		ND		2.07	ND		1.56	2.96		1.6	5.77		1.6	ND		1.56	ND		1.44	2.46	F	1.54	7.89		1.59
N-Methyl Perfluorooctanesulfonamidoacetic Acid (NMeFOSAA)	2355-31-9		ND		2.07	ND		1.56	ND		1.6	ND		1.6	ND		1.56	ND		1.44	ND		1.54	ND		1.59
Perfluorobutanesulfonic Acid (PFBS)	375-73-5		10.4		2.07	83.5		1.56	22.2		1.6	2.24		1.6	11.8		1.56	6.82		1.44	3.7		1.54	4.46		1.59
Perfluorobutanoic Acid (PFBA)	375-22-4		57.5		8.27	23.6		6.25	26.4		6.41	5.69	J	6.41	7.8		6.24	8.47		5.74	4	J	6.16	13.4		6.38
Perfluorodecanesulfonic Acid (PFDS)	335-77-3		ND		2.07	ND		1.56	ND		1.6	0.481	J	1.6	ND		1.56	ND		1.44	ND		1.54	0.558	J	1.59
Perfluorodecanoic Acid (PFDA)	335-76-2		ND		2.07	1.48	J	1.56	1.52	J	1.6	1.12	JF	1.6	ND		1.56	1.72		1.44	ND		1.54	0.717	JF	1.59
Perfluorododecanoic Acid (PFDoA)	307-55-1		ND		2.07	ND		1.56	ND		1.6	ND		1.6	ND		1.56	ND		1.44	ND		1.54	ND		1.59
Perfluoroheptanesulfonic Acid (PFHpS)	375-92-8		ND		2.07	ND		1.56	0.961	J	1.6	ND		1.6	2.1		1.56	0.646	J	1.44	ND		1.54	0.638	J	1.59
Perfluoroheptanoic Acid (PFHpA)	375-85-9		57.7		2.07	16.2		1.56	17.4		1.6	2.32	F	1.6	7.25		1.56	5.81		1.44	1.54		1.54	9.32		1.59
Perfluorohexanesulfonic Acid (PFHxS)	355-46-4		4.44		2.07	14.1		1.56	12.7		1.6	3.6		1.6	348		1.56	26.3		1.44	3.93		1.54	9.8		1.59
Perfluorohexanoic Acid (PFHxA)	307-24-4		138		2.07	23.9		1.56	40.1		1.6	4.65		1.6	17.8		1.56	11		1.44	4		1.54	40.8		1.59
Perfluorononanoic Acid (PFNA)	375-95-1		4.44		2.07	0.859	J	1.56	1.2	J	1.6	1.52	J	1.6	0.702	J	1.56	1.58		1.44	ND		1.54	2.07		1.59
Perfluorooctanesulfonamide (PFOSA)	754-91-6		ND		2.07	ND		1.56	1.92		1.6	1.28	J	1.6	ND		1.56	ND		1.44	ND		1.54	0.638	J	1.59
Perfluorooctanesulfonic Acid (PFOS)	1763-23-1	2.7	8.16		2.07	1.87		1.56	10.9		1.6	20.8		1.6	20.9		1.56	23		1.44	11.6		1.54	24.1		1.59
Perfluorooctanoic Acid (PFOA)	335-67-1	6.7	121		2.07	26.3		1.56	31.8		1.6	7.05		1.6	23.9		1.56	15.6		1.44	7.4		1.54	29		1.59
Perfluoropentanoic Acid (PFPeA)	2706-90-3		134		4.13	31.5		3.12	36		3.2	8.33		3.2	11.8		3.12	9.47		2.87	3.54		3.08	37.4		3.19
Perfluorotetradecanoic Acid (PFTeDA)	376-06-7		ND		2.07	ND		1.56	ND		1.6	ND		1.6	ND		1.56	ND		1.44	ND		1.54	ND		1.59
Perfluorotridecanoic Acid (PFTrDA)	72629-94-8		ND		2.07	ND		1.56	ND		1.6	ND		1.6	ND		1.56	ND		1.44	ND		1.54	ND		1.59
Perfluoroundecanoic Acid (PFUnA)	2058-94-8		ND		2.07	ND		1.56	ND		1.6	ND		1.6	ND		1.56	ND		1.44	ND		1.54	ND		1.59
PFOA/PFOS, Total			129		2.07	28.2		1.56	42.7		1.6	27.9		1.6	44.8		1.56	38.6		1.44	19		1.54	53.1		1.59
SVOCs (ug/l)																										
1,2,4,5-Tetrachlorobenzene	95-94-3	5	ND		10	ND		10	ND		11	ND		10	ND		10	ND		10	ND		10	ND		10
1,2,4-Trichlorobenzene	120-82-1	5	ND		5	ND		5	ND		5.8	ND		5	ND		5	ND		5.3	ND		5	ND		5
1,2-Dichlorobenzene	95-50-1	3	ND		2	ND		2	ND		2.3	ND		2	ND		2	ND		2.1	ND		2	ND		2
1,3-Dichlorobenzene	541-73-1	3	ND		2	ND		2	ND		2.3	ND		2	ND		2	ND		2.1	ND		2	ND		2
1,4-Dichlorobenzene	106-46-7	3	ND		2	ND		2	ND		2.3	ND		2	ND		2	ND		2.1	ND		2	ND		2
2,4,5-Trichlorophenol	95-95-4		ND		5	ND		5	ND		5.8	ND		5	ND		5	ND		5.3	ND		5	ND		5
2,4,6-Trichlorophenol	88-06-2		ND		5	ND		5	ND		5.8	ND		5	ND		5	ND		5.3	ND		5	ND		5
2,4-Dichlorophenol	120-83-2	1	ND		5	ND		5	ND		5.8	ND		5	ND		5	ND		5.3	ND		5	ND		5
2,4-Dimethylphenol	105-67-9	50	ND		5	ND		5	ND		5.8	ND		5	ND		5	ND		5.3	ND		5	ND		5
2,4-Dinitrophenol	51-28-5	10	ND		20	ND		20	ND		23	ND		20	ND		20	ND		21	ND		20	ND		20
2,4-Dinitrotoluene	121-14-2	5	ND		5	ND		5	ND		5.8	ND		5	ND		5	ND		5.3	ND		5	ND		5
2,6-Dinitrotoluene	606-20-2	5	ND		5	ND		5	ND		5.8	ND		5	ND		5	ND		5.3	ND		5	ND		5
2-Chlorophenol	95-57-8		ND		2	ND		2	ND		2.3	ND		2	ND		2	ND		2.1	ND		2	ND		2
2-Methylphenol	95-48-7		ND		5	ND		5	ND		5.8	ND		5	ND		5	ND		5.3	ND		5	ND		5
2-Nitroaniline	88-74-4	5	ND		5	ND		5	ND		5.8	ND		5	ND		5	ND		5.3	ND		5	ND		5
2-Nitrophenol	88-75-5		ND		10	ND		10	ND		11	ND		10	ND		10	ND		10	ND		10	ND		10
3,3'-Dichlorobenzidine	91-94-1	5	ND		5	ND		5	ND		5.8	ND		5	ND		5	ND		5.3	ND		5	ND		5
3-Methylphenol/4-Methylphenol	108-39-4/106-44-5		ND		5	ND		5	ND		5.8	ND		5	ND		5	ND		5.3	ND		5	ND		5
3-Nitroaniline	99-09-2	5	ND		5	ND		5	ND		5.8	ND		5	ND		5	ND		5.3	ND		5	ND		5
4,6-Dinitro-o-cresol	534-52-1		ND		10	ND		10	ND		11	ND		10	ND		10	ND		10	ND		10	ND		10
4-Bromophenyl phenyl ether	101-55-3		ND		2	ND		2	ND		2.3	ND		2	ND		2	ND		2.1	ND		2	ND		2
4-Chloroaniline	106-47-8	5	ND		5	ND		5	ND		5.8	ND		5	ND		5	ND		5.3	ND		5	ND		5
4-Chlorophenyl phenyl ether	7005-72-3		ND		2	ND		2	ND		2.3	ND		2	ND		2	ND		2.1	ND		2	ND		2
4-Nitroaniline	100-01-6	5	ND		5	ND		5	ND		5.8	ND		5	ND		5	ND		5.3	ND		5	ND		5
4-Nitrophenol	100-02-7		ND		10	ND		10	ND		11	ND		10	ND		10	ND		10	ND		10	ND		10
Acetophenone	98-86-2		ND		5	ND		5	ND		5.8	ND		5	ND		5	ND		5.3	1.5	J	5	0.93	J	5
Benzoic Acid	65-85-0		16	J	50	10	J	50	65		58	9.3	J	50	ND		50	9.6	J	53	88		50	150		50
Benzyl Alcohol	100-51-6		ND		2	ND		2	31		2.3	ND		2	ND		2	ND		2.1	0.69	J	2	2.1		2
Biphenyl	92-52-4		ND		2	ND		2	ND		2.3	ND		2	ND		2	ND		2.1	ND		2	ND		2
Bis(2-chloroethoxy)methane	111-91-1	5	ND		5	ND		5	ND		5.8	ND		5	ND		5	ND		5.3	ND		5	ND		5
Bis(2-chloroethyl)ether	111-44-4	1	ND		2	ND		2	ND		2.3	ND		2	ND		2	ND		2.1	ND		2	ND		2
Bis(2-chloroisopropyl)ether	108-60-1	5	ND		2	ND		2	ND		2.3	ND		2	ND		2	ND		2.1	ND		2	ND		2
Bis(2-ethylhexyl)phthalate	117-81-7	5	2	J	3	ND		3	ND		3.4	ND		3	ND		3	ND		3.2	ND		3	ND		3
Butyl benzyl phthalate	85-68-7	50	ND		5	ND		5	3.1	J	5.8	ND		5	ND		5	4.4	J	5.3	ND		5	ND		5
Carbazole	86-74-8		ND		2	ND		2	ND		2.3	ND		2	ND		2	ND		2.1	ND		2	1.5	J	2
Di-n-butylphthalate	84-74-2	50	ND		5	2.3	J	5	1.5	J	5.8	ND		5	ND		5	1.4	J	5.3	ND		5	ND		5
Di-n-octylphthalate	117-84-0	50	ND		5	ND		5	ND		5.8	ND		5	ND		5	ND		5.3	ND		5	ND		5
Dibenzofuran	132-64-9		ND		2	ND		2	ND		2.3	ND		2	ND		2	ND		2.1	ND		2	0.89	J	2
Diethyl phthalate	84-66-2	50	ND		5	ND		5	ND		5.8	ND		5	ND		5	ND		5.3	ND		5	ND		5
Dimethyl phthalate	131-11-3	50	ND		5	ND		5	ND		5.8	ND		5	ND		5	ND		5.3	ND		5	ND		5
Hexachlorocyclopentadiene	77-47-4	5	ND		20	ND		20	ND		23	ND		20	ND		20	ND		21	ND		20	ND		20
Isophorone	78-59-1	50	ND		5	ND		5	ND		5.8	ND		5	ND		5	ND		5.3	ND		5	ND		5
n-Nitrosodi-n-propylamine	621-64-7		ND		5	ND		5	ND		5.8	ND		5	ND		5	ND		5.3	ND		5	ND		5
NDPA/DPA	86-30-6	50	ND		2	ND		2	ND		2.3	ND		2	ND		2	ND		2.1	ND		2	ND		2
Nitrobenzene	98-95-3	0.4	ND		2	ND		2	ND		2.3	ND		2	ND		2	ND		2.1	ND		2	ND		2
p-Chloro-m-cresol	59-50-7		ND		2	ND		2	ND		2.3	ND		2	ND		2	ND		2.1	ND		2	ND		2
Phenol	108-95-2	1	ND		5	ND		5	0.72	J	5.8	ND		5	ND		5	ND		5.3	0.72	J	5	1.2	J	5
Total SVOCs			18	-	-	12.3	-	-	101.32	-	-	9.3	-	-	-	-	-	15.4	-	-	90.91	-	-	156.62	-	-

SESI CONSULTING ENGINEERS

Table 3.3 - Summary of Groundwater Analytical Results
80 Main Street
White Plains, New York
SESI Project #12859

SAMPLE ID:			GW-2			GW-3			GW-4			GW-5			GW-6			GW-7			GW-8			GW-9		
LAB ID:			L2316452-05			L2316865-01			L2316865-02			L2316865-03			L2316865-04			L2316865-05			L2318715-01			L2318715-02		
COLLECTION DATE:			3/29/2023			3/30/2023			3/30/2023			3/30/2023			3/30/2023			3/30/2023			4/7/2023			4/7/2023		
SAMPLE MATRIX:			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER		
ANALYTES	**CAS**	**NY-AWQS**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**
SVOCs by SIM (ug/l)																										
2-Chloronaphthalene	91-58-7	10	ND		0.2	ND		0.2	ND		0.23	ND		0.2	ND		0.2	ND		0.21	ND		0.2	ND		1
2-Methylnaphthalene	91-57-6		0.18		0.1	0.11		0.1	0.19		0.11	ND		0.1	ND		0.1	ND		0.1	0.03	J	0.1	3.4		0.5
Acenaphthene	83-32-9	20	0.25		0.1	0.07	J	0.1	0.16		0.11	0.03	J	0.1	ND		0.1	ND		0.1	0.06	J	0.1	1.8		0.5
Acenaphthylene	208-96-8		0.1		0.1	0.03	J	0.1	0.05	J	0.11	0.01	J	0.1	ND		0.1	ND		0.1	ND		0.1	0.2	J	0.5
Anthracene	120-12-7	50	0.49		0.1	0.06	J	0.1	0.14		0.11	0.04	J	0.1	ND		0.1	ND		0.1	0.06	J	0.1	2.9		0.5
Benzo(a)anthracene	56-55-3	0.002	1.3		0.1	0.12		0.1	0.07	J	0.11	0.09	J	0.1	0.03	J	0.1	0.02	J	0.1	ND		0.1	6.1		0.5
Benzo(a)pyrene	50-32-8	0	1.5		0.1	0.1	J	0.1	0.05	J	0.11	0.08	J	0.1	ND		0.1	ND		0.1	ND		0.1	6.4		0.5
Benzo(b)fluoranthene	205-99-2	0.002	1.7		0.1	0.11		0.1	0.06	J	0.11	0.09	J	0.1	ND		0.1	ND		0.1	ND		0.1	7.2		0.5
Benzo(ghi)perylene	191-24-2		0.85		0.1	0.07	J	0.1	0.03	J	0.11	0.06	J	0.1	ND		0.1	ND		0.1	ND		0.1	3.6		0.5
Benzo(k)fluoranthene	207-08-9	0.002	0.59		0.1	0.04	J	0.1	0.02	J	0.11	0.04	J	0.1	ND		0.1	ND		0.1	ND		0.1	2.4		0.5
Chrysene	218-01-9	0.002	1.2		0.1	0.09	J	0.1	0.05	J	0.11	0.06	J	0.1	ND		0.1	ND		0.1	ND		0.1	5.5		0.5
Dibenzo(a,h)anthracene	53-70-3		0.23		0.1	0.02	J	0.1	ND		0.11	0.02	J	0.1	ND		0.1	ND		0.1	ND		0.1	0.93		0.5
Fluoranthene	206-44-0	50	2.8		0.1	0.22		0.1	0.15		0.11	0.17		0.1	ND		0.1	0.02	J	0.1	0.03	J	0.1	14		0.5
Fluorene	86-73-7	50	0.34		0.1	0.04	J	0.1	0.06	J	0.11	0.03	J	0.1	ND		0.1	ND		0.1	ND		0.1	2		0.5
Hexachlorobenzene	118-74-1	0.04	ND		0.8	ND		0.8	ND		0.92	ND		0.8	ND		0.8	ND		0.85	ND		0.8	ND		4
Hexachlorobutadiene	87-68-3	0.5	ND		0.5	ND		0.5	ND		0.57	ND		0.5	ND		0.5	ND		0.53	ND		0.5	ND		2.5
Hexachloroethane	67-72-1	5	ND		0.8	ND		0.8	ND		0.92	ND		0.8	ND		0.8	ND		0.85	ND		0.8	ND		4
Indeno(1,2,3-cd)pyrene	193-39-5	0.002	0.9		0.1	0.07	J	0.1	0.03	J	0.11	0.06	J	0.1	ND		0.1	ND		0.1	ND		0.1	3.7		0.5
Naphthalene	91-20-3	10	0.6		0.1	0.18		0.1	0.37		0.11	ND		0.1	ND		0.1	ND		0.1	0.05	J	0.1	1.1		0.5
Pentachlorophenol	87-86-5	1	0.1	J	0.8	0.09	J	0.8	ND		0.92	ND		0.8	ND		0.8	ND		0.85	0.16	J	0.8	ND		4
Phenanthrene	85-01-8	50	1.8		0.1	0.18		0.1	0.18		0.11	0.14		0.1	ND		0.1	0.03	J	0.1	0.04	J	0.1	11		0.5
Pyrene	129-00-0	50	2.5		0.1	0.2		0.1	0.17		0.11	0.14		0.1	ND		0.1	0.02	J	0.1	0.03	J	0.1	12		0.5
Total SVOCs			17.43	-	-	1.8	-	-	1.78	-	-	1.06	-	-	0.03	-	-	0.09	-	-	0.46	-	-	84.23	-	-
SVOCs TICs (ug/l)																										
Cyclic Octaatomic Sulfur	010544-50-0		-		-	-		-	-		-	-		-	-		-	-		-	-		-	-		-
Unknown			-		-	79.2	J	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Unknown			-		-	58.4	J	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Unknown			-		-	91.1	J	0	-		-	-		-	-		-	-		-	-		-	-		-	-
Unknown			15.9	JB	0	6.22	J	0	23.7	J	0	3.05	J	0	-		-	-		-	-		-	-		-	-
Unknown			4.51	JB	0	10	J	0	92.6	J	0	1.93	J	0	6.94	J	0	-		-	-		-	-		-	-
Unknown			2.58	J	0	5.74	J	0	21.9	J	0	4.25	J	0	9.05	J	0	-		-	17.8	J	0	-		-
Unknown			2.29	J	0	5.2	J	0	13.1	J	0	1.74	JB	0	3.34	J	0	2.88	J	0	4.54	J	0	11	J	0
Unknown			2.91	J	0	4.25	J	0	12.7	J	0	2.11	J	0	1.6	J	0	3.19	JB	0	13.6	J	0	7.02	JB	0
Unknown			2.98	J	0	4.18	J	0	19.2	J	0	2.07	J	0	1.56	JB	0	2.38	J	0	6.25	J	0	8.25	JB	0
Unknown			3.05	J	0	6.84	JB	0	24.2	J	0	2.8	J	0	1.64	J	0	1.92	JB	0	6.76	JB	0	19.5	J	0
Unknown			3.24	J	0	4.18	JB	0	11.2	J	0	3.85	JB	0	3.53	JB	0	1.58	J	0	8.22	JB	0	9.49	J	0
Unknown			3.31	J	0	4.4	J	0	36.5	J	0	2.36	J	0	2.47	J	0	4.15	JB	0	11.8	J	0	26.1	J	0
Unknown			2.91	J	0	4.54	J	0	15.6	J	0	4.94	J	0	1.82	J	0	4.27	J	0	7.31	J	0	35.1	J	0
Unknown Alcohol			-		-	-		-	-		-	-		-	-		-	-		-	-		-	-		-
Unknown Alcohol			-		-	-		-	14.8	J	0	3.31	J	0	-		-	-		-	-		-	-		-	-
Unknown Alcohol			-		-	-		-	-		-	-		-	-		-	-		-	-		-	-		-	-
Unknown Aldehyde			-		-	-		-	12.1	J	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Unknown Alkane			-		-	-		-	-		-	-		-	-		-	-		-	-		-	-		-	-
Unknown Alkane			-		-	-		-	-		-	-		-	-		-	-		-	-		-	-		-	-
Unknown Alkane			-		-	-		-	-		-	-		-	-		-	-		-	-		-	-		-	-
Unknown Alkane			5.64	J	0	-		-	-		-	-		-	-		-	-		-	-		-	-		-	-
Unknown Alkane			-		-	-		-	-		-	-		-	-		-	-		-	-		-	-		-	-
Unknown Alkane			4.65	J	0	-		-	-		-	-		-	-		-	-		-	-		-	-		-	-
Unknown Alkene			-		-	-		-	-		-	-		-	-		-	-		-	14.2	J	0	-		-
Unknown Amide			5.64	J	0	9.24	J	0	-		-	-		-	-		-	-		-	-		-	-		-
Unknown Amine			-		-	-		-	-		-	-		-	-		-	-		-	-		-	-		-
Unknown Benzene			-		-	-		-	-		-	-		-	-		-	-		-	-		-	-		-
Unknown Naphthalene			-		-	-		-	-		-	-		-	-		-	-		-	-		-	8.76	J	0
Unknown Naphthalene			-		-	-		-	-		-	-		-	-		-	-		-	-		-	10.2	J	0
Unknown Organic Acid			-		-	-		-	-		-	-		-	-		-	-		-	-		-	-		-
Unknown Organic Acid			-		-	-		-	-		-	-		-	-		-	-		-	-		-	-		-
Unknown Organic Acid			-		-	-		-	-		-	-		-	-		-	-		-	48.8	JB	0	-		-
Unknown Organic Acid			-		-	-		-	-		-	26	J	0	-		-	-		-	36.5	JB	0	-		-
Unknown Organic Acid			-		-	-		-	27	J	0	15.3	J	0	24.9	J	0	-		-	4.07	J	0	12.2	JB	0
Unknown Organic Acid			-		-	100	JB	0	-		-	-		-	-		-	-		-	-		-	-		-
Unknown Organic Acid			43.1	JB	0	-		-	87.5	J	0	1.96	J	0	2.8	JB	0	2.12	JB	0	4.18	J	0	5.2	J	0
Unknown Organic Acid			36.5	JB	0	-		-	15.2	J	0	3.31	J	0	14.8	J	0	19.8	J	0	6.14	J	0	15.4	JB	0
Unknown PAH			-		-	-		-	-		-	-		-	-		-	-		-	-		-	7.89	J	0
Unknown PAH			-		-	-		-	-		-	-		-	-		-	-		-	-		-	10.6	J	0
Unknown PAH			-		-	-		-	-		-	-		-	-		-	-		-	-		-	6.98	J	0
Unknown Siloxane			-		-	-		-	-		-	-		-	-		-	-		-	-		-	-		-
Unknown Siloxane			-		-	-		-	-		-	-		-	-		-	-		-	-		-	-		-
Total TIC Compounds			139	J	0	393	J	0	427	J	0	79	J	0	74.5	J	0	42.3	J	0	190	J	0	194	J	0

SESI CONSULTING ENGINEERS

Table 3.3 - Summary of Groundwater Analytical Results
80 Main Street
White Plains, New York
SESI Project #12859

SAMPLE ID:			GW-2			GW-3			GW-4			GW-5			GW-6			GW-7			GW-8			GW-9		
LAB ID:			L2316452-05			L2316865-01			L2316865-02			L2316865-03			L2316865-04			L2316865-05			L2318715-01			L2318715-02		
COLLECTION DATE:			3/29/2023			3/30/2023			3/30/2023			3/30/2023			3/30/2023			3/30/2023			4/7/2023			4/7/2023		
SAMPLE MATRIX:			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER		
ANALYTES	**CAS**	**NY-AWQS**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**
Presicides (ug/l)																										
4,4'-DDD	72-54-8	0.3	0.007	J	0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029
4,4'-DDE	72-55-9	0.2	0.005	J	0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029
4,4'-DDT	50-29-3	0.2	0.015	J	0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029	0.004	JIP	0.029	ND		0.029	ND		0.029
Aldrin	309-00-2	0	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014
Alpha-BHC	319-84-6	0.01	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014
Beta-BHC	319-85-7	0.04	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014
Chlordane	57-74-9	0.05	0.177		0.143	ND		0.143	ND		0.143	ND		0.143	ND		0.143	ND		0.143	ND		0.143	ND		0.143
cis-Chlordane	5103-71-9		0.01	J	0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014
Delta-BHC	319-86-8	0.04	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014
Dieldrin	60-57-1	0.004	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029
Endosulfan I	959-98-8		ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014
Endosulfan II	33213-65-9		ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029
Endosulfan sulfate	1031-07-8		ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029
Endrin	72-20-8	0	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029
Endrin aldehyde	7421-93-4	5	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029
Endrin ketone	53494-70-5	5	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029
Heptachlor	76-44-8	0.04	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014
Heptachlor epoxide	1024-57-3	0.03	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014
Lindane	58-89-9	0.05	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014
Methoxychlor	72-43-5	35	ND		0.143	ND		0.143	ND		0.143	ND		0.143	ND		0.143	ND		0.143	ND		0.143	ND		0.143
Toxaphene	8001-35-2	0.06	ND		0.143	ND		0.143	ND		0.143	ND		0.143	ND		0.143	ND		0.143	ND		0.143	ND		0.143
trans-Chlordane	5103-74-2		ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014
PCBs (ug/l)																										
Aroclor 1016	12674-11-2	0.09	ND		0.071	ND		0.091	ND		0.081	ND		0.077	ND		0.071	ND		0.071	ND		0.071	ND		0.071
Aroclor 1221	11104-28-2	0.09	ND		0.071	ND		0.091	ND		0.081	ND		0.077	ND		0.071	ND		0.071	ND		0.071	ND		0.071
Aroclor 1232	11141-16-5	0.09	ND		0.071	ND		0.091	ND		0.081	ND		0.077	ND		0.071	ND		0.071	ND		0.071	ND		0.071
Aroclor 1242	53469-21-9	0.09	ND		0.071	ND		0.091	ND		0.081	ND		0.077	ND		0.071	ND		0.071	ND		0.071	ND		0.071
Aroclor 1248	12672-29-6	0.09	ND		0.071	ND		0.091	ND		0.081	ND		0.077	ND		0.071	ND		0.071	ND		0.071	ND		0.071
Aroclor 1254	11097-69-1	0.09	ND		0.071	ND		0.091	0.076	J	0.081	0.075	J	0.077	ND		0.071	ND		0.071	ND		0.071	ND		0.071
Aroclor 1260	11096-82-5	0.09	ND		0.071	ND		0.091	ND		0.081	ND		0.077	ND		0.071	ND		0.071	ND		0.071	ND		0.071
Aroclor 1262	37324-23-5	0.09	ND		0.071	ND		0.091	ND		0.081	ND		0.077	ND		0.071	ND		0.071	ND		0.071	ND		0.071
Aroclor 1268	11100-14-4	0.09	ND		0.071	ND		0.091	ND		0.081	ND		0.077	ND		0.071	ND		0.071	ND		0.071	ND		0.071
PCBs, Total	1336-36-3		ND		0.071	ND		0.091	0.076	J	0.081	0.075	J	0.077	ND		0.071	ND		0.071	ND		0.071	ND		0.071
Metals (ug/l)																										
Aluminum, Total	7429-90-5		44400		100	32400		100	289000		200	91800		100	104000		100	80700		100	94700		10	105000		20
Antimony, Total	7440-36-0	3	5.5	J	40	ND		40	ND		80	ND		40	ND		40	ND		40	ND		4	ND		8
Arsenic, Total	7440-38-2	25	16.5		5	4.27	J	5	37.94		10	6.97		5	11.94		5	10.24		5	15.71		0.5	26.29		1
Barium, Total	7440-39-3	1000	1182		5	748.8		5	10690		10	2409		5	2435		5	1417		5	1934		0.5	2441		1
Beryllium, Total	7440-41-7	3	2.06	J	5	ND		5	12.83		10	3.19	J	5	5.17		5	3.2	J	5	3.22		0.5	3.59		1
Cadmium, Total	7440-43-9	5	1.33	J	2	ND		2	7.35		4	3.56		2	5.35		2	3.35		2	1.34		0.2	3.03		0.4
Calcium, Total	7440-70-2		430000		1000	335000		1000	2710000		2000	421000		1000	901000		1000	669000		1000	660000		500	2260000		2000
Chromium, Total	7440-47-3	50	303.3		10	143.8		10	1295		20	251.8		10	291		10	613.6		10	235		1	453.1		2
Cobalt, Total	7440-48-4		101.8		5	72.32		5	820.4		10	248.5		5	306.8		5	240.4		5	114.1		0.5	118		1
Copper, Total	7440-50-8	200	292.5		10	170.9		10	1818		20	820		10	731.8		10	619.1		10	477		1	426		2
Iron, Total	7439-89-6	300	102000		500	71100		500	389000		1000	182000		500	215000		500	208000		500	172000		50	205000		100
Lead, Total	7439-92-1	25	258.3		10	39.12		10	632.8		20	166.5		10	201.4		10	118		10	88.21		1	213		2
Magnesium, Total	7439-95-4	35000	156000		700	116000		700	854000		1400	237000		700	368000		700	281000		700	267000		70	190000		140
Manganese, Total	7439-96-5	300	4715		10	2103		10	25420		20	26100		10	5809		10	9712		10	4584		1	9555		2
Mercury, Total	7439-97-6	0.7	0.23		0.2	0.11	J	0.2	1.17		0.2	0.23		0.2	0.21		0.2	0.16	J	0.2	0.22		0.2	1.88		1
Nickel, Total	7440-02-0	100	144.8		20	94.79		20	896.6		40	437.4		20	338.8		20	400.6		20	179		2	206.9		4
Potassium, Total	7440-09-7		28900		1000	38900		1000	112000		2000	47900		1000	58200		1000	43000		1000	83600		100	97100		200
Selenium, Total	7782-49-2	10	37.9	J	50	ND		50	61.4	J	100	ND		50	ND		50	ND		50	29.7		5	42.2		10
Silver, Total	7440-22-4	50	ND		4	ND		4	7.24	J	8	ND		4	ND		4	ND		4	0.51		0.4	0.64	J	0.8
Sodium, Total	7440-23-5	20000	465000		1000	2780000		1000	1250000		2000	298000		1000	614000		1000	710000		1000	223000		100	480000		200
Thallium, Total	7440-28-0	0.5	ND		10	ND		20	7.23	J	40	3.97	J	20	2.21	J	20	1.65	J	20	1.5		1	1.37	J	2
Vanadium, Total	7440-62-2		110.1		50	85.32		50	330.5		100	164.2		50	186.1		50	159.8		50	172		5	241.4		10
Zinc, Total	7440-66-6	2000	436.2		100	515.2		100	1378		200	568.5		100	628.1		100	528.1		100	388.1		10	435		20
General Chemistry (ug/l)																										
Cyanide, Total	57-12-5	200	3	J	5	9		5	2	J	5	2	J	5	5		5	3	J	5	ND		5	2	J	5

Notes

NYSDEC AWQS - New York State Department of Environmental Conservation Ambient Water Quality Standard

Exceedance of the NYSDEC AWQS

J = Estimated

ND = Not Detected

SESI CONSULTING ENGINEERS

Table 3.3 - Summary of Groundwater Analytical Results
80 Main Street
White Plains, New York
SESI Project #12859

SAMPLE ID:			GW-10			GW-11			GW-12			GW-13			GW-14			GW-15			GW-16			GW-17			GW-18			GW-19			GW-20		
LAB ID:			L2331226-08			L2331226-09			L2331480-06			L2331480-07			L2331827-06			L2331827-07			L2332665-06			L2332665-07			L2341423-01			L2341423-02			L2341423-03		
COLLECTION DATE:			6/5/2023			6/5/2023			6/6/2023			6/6/2023			6/7/2023			6/7/2023			6/9/2023			6/9/2023			7/19/2023			7/19/2023			7/19/2023		
SAMPLE MATRIX:			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER		
ANALYTES	**CAS**	**NY-AWQS**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**
VOCs (ug/l)																																		
1,1,1,2-Tetrachloroethane	630-20-6	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,1,1-Trichloroethane	71-55-6	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,1,2,2-Tetrachloroethane	79-34-5	5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5
1,1,2-Trichloroethane	79-00-5	1	ND		1.5	ND		1.5	ND		1.5	ND		1.5	ND		1.5	ND		1.5	ND		1.5	ND		1.5	ND		1.5	ND		1.5	ND		1.5
1,1-Dichloroethane	75-34-3	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,1-Dichloroethene	75-35-4	5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5
1,1-Dichloropropene	563-58-6	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,2,3-Trichlorobenzene	87-61-6	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,2,3-Trichloropropane	96-18-4	0.04	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,2,4,5-Tetramethylbenzene	95-93-2	5	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2
1,2,4-Trichlorobenzene	120-82-1	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,2,4-Trimethylbenzene	95-63-6	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,2-Dibromo-3-chloropropane	96-12-8	0.04	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,2-Dibromoethane	106-93-4	0.0006	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2
1,2-Dichlorobenzene	95-50-1	3	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,2-Dichloroethane	107-06-2	0.6	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5
1,2-Dichloroethene, Total	540-59-0		ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,2-Dichloropropane	78-87-5	1	ND		1	ND		1	ND		1	ND		1	ND		1	ND		1	ND		1	ND		1	ND		1	ND		1	ND		1	ND		1
1,3,5-Trimethylbenzene	108-67-8	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,3-Dichlorobenzene	541-73-1	3	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,3-Dichloropropane	142-28-9	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,3-Dichloropropene, Total	542-75-6		ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5
1,4-Dichlorobenzene	106-46-7	3	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,4-Dioxane	123-91-1		ND		250	ND		250	ND		250	ND		250	ND		250	ND		250	ND		250	ND		250	ND		250	ND		250	ND		250	ND		250
2,2-Dichloropropane	594-20-7	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
2-Butanone	78-93-3	50	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5
2-Hexanone	591-78-6	50	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5
4-Methyl-2-pentanone	108-10-1		ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5
Acetone	67-64-1	50	2.2	J	5	ND		5	3	J	5	ND		5	ND		5	1.9	J	5	2.3	J	5	1.8	J	5	ND		5	1.7	J	5	ND		5
Acrylonitrile	107-13-1	5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5
Benzene	71-43-2	1	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5
Bromobenzene	108-86-1	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Bromochloromethane	74-97-5	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Bromodichloromethane	75-27-4	50	ND		0.5	ND		0.5	ND		0.5	ND		0.5	0.24	J	0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5
Bromoform	75-25-2	50	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2
Bromomethane	74-83-9	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Carbon disulfide	75-15-0	60	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5
Carbon tetrachloride	56-23-5	5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5
Chlorobenzene	108-90-7	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Chloroethane	75-00-3	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Chloroform	67-66-3	7	ND		2.5	ND		2.5	ND		2.5	7		2.5	17		2.5	4.6		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Chloromethane	74-87-3		ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
cis-1,2-Dichloroethene	156-59-2	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
cis-1,3-Dichloropropene	10061-01-5	0.4	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5
Dibromochloromethane	124-48-1	50	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5
Dibromomethane	74-95-3	5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5
Dichlorodifluoromethane	75-71-8	5	ND		5	ND		5	ND		5	3.6	J	5	3	J	5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5
Ethyl ether	60-29-7		ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Ethylbenzene	100-41-4	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Hexachlorobutadiene	87-68-3	0.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Isopropylbenzene	98-82-8	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Methyl tert butyl ether	1634-04-4	10	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	1.2	J	2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Methylene chloride	75-09-2	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
n-Butylbenzene	104-51-8	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
n-Propylbenzene	103-65-1	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Naphthalene	91-20-3	10	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
o-Chlorotoluene	95-49-8	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
o-Xylene	95-47-6	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
p-Chlorotoluene	106-43-4	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
p-Diethylbenzene	105-05-5		ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2
p-Ethyltoluene	622-96-8		ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2
p-Isopropyltoluene	99-87-6	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
p/m-Xylene	179601-23-1	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
sec-Butylbenzene	135-98-8	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Styrene	100-42-5	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
tert-Butylbenzene	98-06-6	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Tetrachloroethene	127-18-4	5	ND		0.5	ND		0.5	ND		0.5	0.88		0.5	1.1		0.5	0.28	J	0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5
Toluene	108-88-3	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
trans-1,2-Dichloroethene	156-60-5	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
trans-1,3-Dichloropropene	10061-02-6	0.4	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5
trans-1,4-Dichloro-2-butene	110-57-6	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Trichloroethene	79-01-6	5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5
Trichlorofluoromethane	75-69-4	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Vinyl acetate	108-05-4		ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5
Vinyl chloride	75-01-4	2	ND		1	ND		1	ND		1	ND		1	ND		1	ND		1	ND		1	ND		1	ND		1	ND		1	ND		1	ND		1	ND		1	ND		1
Xylenes, Total	1330-20-7		ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Total VOCs			2.2	-	-	-	-	-	3	-	-	11.48	-	-	21.34	-	-	6.78	-	-	3.5	-	-	1.8	-	-	-	-	-	1.7	-	-	-	-	-

SESI CONSULTING ENGINEERS

Table 3.3 - Summary of Groundwater Analytical Results
80 Main Street
White Plains, New York
SESI Project #12859

SAMPLE ID:			GW-10			GW-11			GW-12			GW-13			GW-14			GW-15			GW-16			GW-17			GW-18			GW-19			GW-20		
LAB ID:			L2331226-08			L2331226-09			L2331480-06			L2331480-07			L2331827-06			L2331827-07			L2332665-06			L2332665-07			L2341423-01			L2341423-02			L2341423-03		
COLLECTION DATE:			6/5/2023			6/5/2023			6/6/2023			6/6/2023			6/7/2023			6/7/2023			6/9/2023			6/9/2023			7/19/2023			7/19/2023			7/19/2023		
SAMPLE MATRIX:			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER		
ANALYTES	**CAS**	**NY-AWQS**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**
VOCs TICs (ug/l)																																			
1-Propene, 2-methyl-	000115-11-7		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
No Tentatively Identified Compounds			ND		0	ND		0	ND		0	ND		0	ND		0	ND		0	ND		0	ND		0	ND		0	ND		0	ND		0
Nonanal	000124-19-6		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Unknown			-		-	-		-	-		-	-		-	-		-	-		-	-		-	-		-	-		-	-		-	-		-
Unknown			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Unknown			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Unknown Aromatic			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Unknown Aromatic			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Unknown Aromatic			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Unknown Naphthalene			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Unknown Naphthalene			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Total TIC Compounds			-		-	-		-	-		-	-		-	-		-	-		-	-		-	-		-	-		-	-		-	-		-
1,4 DIOXANE (ug/l)																																			
1,4-Dioxane	123-91-1	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
PFAS (ng/l)																																			
1H,1H,2H,2H-Perfluorodecanesulfonic Acid (8:2FTS)	39108-34-4		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
1H,1H,2H,2H-Perfluorooctanesulfonic Acid (6:2FTS)	27619-97-2		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
N-Ethyl Perfluorooctanesulfonamidoacetic Acid (NEtFOSAA)	2991-50-6		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
N-Methyl Perfluorooctanesulfonamidoacetic Acid (NMeFOSAA)	2355-31-9		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Perfluorobutanesulfonic Acid (PFBS)	375-73-5		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Perfluorobutanoic Acid (PFBA)	375-22-4		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Perfluorodecanesulfonic Acid (PFDS)	335-77-3		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Perfluorodecanoic Acid (PFDA)	335-76-2		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Perfluorododecanoic Acid (PFDoA)	307-55-1		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Perfluoroheptanesulfonic Acid (PFHpS)	375-92-8		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Perfluoroheptanoic Acid (PFHpA)	375-85-9		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Perfluorohexanesulfonic Acid (PFHxS)	355-46-4		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Perfluorohexanoic Acid (PFHxA)	307-24-4		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Perfluorononanoic Acid (PFNA)	375-95-1		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Perfluorooctanesulfonamide (PFOSA)	754-91-6		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Perfluorooctanesulfonic Acid (PFOS)	1763-23-1	2.7	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Perfluorooctanoic Acid (PFOA)	335-67-1	6.7	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Perfluoropentanoic Acid (PFPeA)	2706-90-3		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Perfluorotetradecanoic Acid (PFTeDA)	376-06-7		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Perfluorotridecanoic Acid (PFTrDA)	72629-94-8		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Perfluoroundecanoic Acid (PFUnA)	2058-94-8		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
PFOA/PFOS, Total			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
SVOCs (ug/l)																																			
1,2,4,5-Tetrachlorobenzene	95-94-3	5	ND		10	ND		10	ND		10	ND		10	ND		10	ND		10	ND		10	ND		10	ND		10	ND		10	ND		10
1,2,4-Trichlorobenzene	120-82-1	5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5
1,2-Dichlorobenzene	95-50-1	3	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2
1,3-Dichlorobenzene	541-73-1	3	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2
1,4-Dichlorobenzene	106-46-7	3	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2
2,4,5-Trichlorophenol	95-95-4		ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5
2,4,6-Trichlorophenol	88-06-2		ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5
2,4-Dichlorophenol	120-83-2	1	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5
2,4-Dimethylphenol	105-67-9	50	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5
2,4-Dinitrophenol	51-28-5	10	ND		20	ND		20	ND		20	ND		20	ND		20	ND		20	ND		20	ND		20	ND		20	ND		20	ND		20
2,4-Dinitrotoluene	121-14-2	5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5
2,6-Dinitrotoluene	606-20-2	5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5
2-Chlorophenol	95-57-8		ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2
2-Methylphenol	95-48-7		ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5
2-Nitroaniline	88-74-4	5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5
2-Nitrophenol	88-75-5		ND		10	ND		10	ND		10	ND		10	ND		10	ND		10	ND		10	ND		10	ND		10	ND		10	ND		10
3,3'-Dichlorobenzidine	91-94-1	5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5
3-Methylphenol/4-Methylphenol	108-39-4/106-44-5		ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5
3-Nitroaniline	99-09-2	5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5
4,6-Dinitro-o-cresol	534-52-1		ND		10	ND		10	ND		10	ND		10	ND		10	ND		10	ND		10	ND		10	ND		10	ND		10	ND		10
4-Bromophenyl phenyl ether	101-55-3		ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2
4-Chloroaniline	106-47-8	5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5
4-Chlorophenyl phenyl ether	7005-72-3		ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2
4-Nitroaniline	100-01-6	5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5
4-Nitrophenol	100-02-7		ND		10	ND		10	ND		10	ND		10	ND		10	ND		10	ND		10	ND		10	ND		10	ND		10	ND		10
Acetophenone	98-86-2		ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5
Benzoic Acid	65-85-0		ND		50	ND		50	9.3	J	50	7.8	J	50	8.6	J	50	10	J	50	8.1	J	50	11	J	50	ND		50	ND		50	25	J	50
Benzyl Alcohol	100-51-6		ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2
Biphenyl	92-52-4		ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2
Bis(2-chloroethoxy)methane	111-91-1	5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5
Bis(2-chloroethyl)ether	111-44-4	1	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2
Bis(2-chloroisopropyl)ether	108-60-1	5	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2
Bis(2-ethylhexyl)phthalate	117-81-7	5	ND		3	ND		3	ND		3	ND		3	2	J	3	ND		3	ND		3	ND		3	ND		3	ND		3	ND		3
Butyl benzyl phthalate	85-68-7	50	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5
Carbazole	86-74-8		ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2
Di-n-butylphthalate	84-74-2	50	ND		5	ND		5	ND		5	ND		5	ND		5	0.58	J	5	ND		5	ND		5	ND		5	ND		5	0.9	J	5
Di-n-octylphthalate	117-84-0	50	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5
Dibenzofuran	132-64-9		ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2
Diethyl phthalate	84-66-2	50	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5
Dimethyl phthalate	131-11-3	50	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5
Hexachlorocyclopentadiene	77-47-4	5	ND		20	ND		20	ND		20	ND		20	ND		20	ND		20	ND		20	ND		20	ND		20	ND		20	ND		20
Isophorone	78-59-1	50	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5
n-Nitrosodi-n-propylamine	621-64-7		ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5
NDPA/DPA	86-30-6	50	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2
Nitrobenzene	98-95-3	0.4	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2
p-Chloro-m-cresol	59-50-7		ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2	ND		2
Phenol	108-95-2	1	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	ND		5	1.3	J	5	ND		5	ND		5	ND		5
Total SVOCs			-	-	-	-	-	-	9.3	-	-	7.8	-	-	10.6	-	-	10.58	-	-	8.1	-	-	12.3	-	-	-	-	-	-	-	-	25.9	-	-

SESI CONSULTING ENGINEERS

Table 3.3 - Summary of Groundwater Analytical Results
80 Main Street
White Plains, New York
SESI Project #12859

SAMPLE ID:			GW-10			GW-11			GW-12			GW-13			GW-14			GW-15			GW-16			GW-17			GW-18			GW-19			GW-20		
LAB ID:			L2331226-08			L2331226-09			L2331480-06			L2331480-07			L2331827-06			L2331827-07			L2332665-06			L2332665-07			L2341423-01			L2341423-02			L2341423-03		
COLLECTION DATE:			6/5/2023			6/5/2023			6/6/2023			6/6/2023			6/7/2023			6/7/2023			6/9/2023			6/9/2023			7/19/2023			7/19/2023			7/19/2023		
SAMPLE MATRIX:			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER		
ANALYTES	**CAS**	**NY-AWQS**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**
SVOCs by SIM (ug/l)																																		
2-Chloronaphthalene	91-58-7	10	ND		0.2	ND		0.2	ND		0.2	ND		0.2	ND		0.2	ND		0.2	ND		0.2	ND		0.2	ND		0.2	ND		0.2	ND		0.2
2-Methylnaphthalene	91-57-6		0.08	J	0.1	ND		0.1	0.23		0.1	0.03	J	0.1	0.08	J	0.1	0.04	J	0.1	ND		0.1	0.66		0.1	ND		0.1	ND		0.1	0.02	J	0.1
Acenaphthene	83-32-9	20	0.04	J	0.1	ND		0.1	0.04	J	0.1	0.02	J	0.1	0.03	J	0.1	0.02	J	0.1	0.04	J	0.1	0.11		0.1	ND		0.1	ND		0.1	ND		0.1
Acenaphthylene	208-96-8		0.02	J	0.1	0.02	J	0.1	0.02	J	0.1	0.02	J	0.1	0.04	J	0.1	0.03	J	0.1	ND		0.1	ND		0.1	ND		0.1	ND		0.1	ND		0.1
Anthracene	120-12-7	50	0.06	J	0.1	0.03	J	0.1	0.06	J	0.1	0.02	J	0.1	0.04	J	0.1	0.03	J	0.1	0.02	J	0.1	0.04	J	0.1	0.01	J	0.1	0.03	J	0.1	0.02	J	0.1
Benzo(a)anthracene	56-55-3	0.002	0.03	J	0.1	0.02	J	0.1	0.02	J	0.1	ND		0.1	0.21		0.1	0.11		0.1	ND		0.1	ND		0.1	ND		0.1	ND		0.1	ND		0.1
Benzo(a)pyrene	50-32-8	0	0.02	J	0.1	ND		0.1	0.02	J	0.1	ND		0.1	0.1		0.1	0.09	J	0.1	ND		0.1	0.02	J	0.1	ND		0.1	ND		0.1	ND		0.1
Benzo(b)fluoranthene	205-99-2	0.002	0.02	J	0.1	0.01	J	0.1	0.02	J	0.1	0.01	J	0.1	0.14		0.1	0.11		0.1	ND		0.1	0.02	J	0.1	ND		0.1	ND		0.1	0.03	J	0.1
Benzo(ghi)perylene	191-24-2		ND		0.1	ND		0.1	ND		0.1	ND		0.1	0.1	J	0.1	0.07	J	0.1	ND		0.1	ND		0.1	ND		0.1	ND		0.1	0.02	J	0.1
Benzo(k)fluoranthene	207-08-9	0.002	0.01	J	0.1	0.01	J	0.1	0.01	J	0.1	0.01	J	0.1	0.05	J	0.1	0.05	J	0.1	ND		0.1	ND		0.1	ND		0.1	0.01	J	0.1	0.02	J	0.1
Chrysene	218-01-9	0.002	0.03	J	0.1	0.01	J	0.1	0.02	J	0.1	0.01	J	0.1	0.09	J	0.1	0.1		0.1	ND		0.1	0.02	J	0.1	ND		0.1	ND		0.1	0.02	J	0.1
Dibenzo(a,h)anthracene	53-70-3		ND		0.1	ND		0.1	ND		0.1	ND		0.1	ND		0.1	ND		0.1	ND		0.1	ND		0.1	ND		0.1	ND		0.1	ND		0.1
Fluoranthene	206-44-0	50	0.12		0.1	0.05	J	0.1	0.1	J	0.1	0.03	J	0.1	0.2		0.1	0.18		0.1	0.02	J	0.1	0.08	J	0.1	0.02	J	0.1	0.04	J	0.1	0.03	J	0.1
Fluorene	86-73-7	50	0.05	J	0.1	0.03	J	0.1	0.14		0.1	0.03	J	0.1	0.05	J	0.1	0.04	J	0.1	0.03	J	0.1	0.08	J	0.1	ND		0.1	0.02	J	0.1	0.02	J	0.1
Hexachlorobenzene	118-74-1	0.04	ND		0.8	0.03	J	0.8	ND		0.8	ND		0.8	0.03	J	0.8	0.04	J	0.8	ND		0.8	ND		0.8	ND		0.8	0.02	J	0.8	ND		0.8
Hexachlorobutadiene	87-68-3	0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5
Hexachloroethane	67-72-1	5	ND		0.8	ND		0.8	ND		0.8	ND		0.8	ND		0.8	ND		0.8	ND		0.8	ND		0.8	ND		0.8	ND		0.8	ND		0.8
Indeno(1,2,3-cd)pyrene	193-39-5	0.002	ND		0.1	ND		0.1	0.01	J	0.1	ND		0.1	0.08	J	0.1	0.06	J	0.1	ND		0.1	ND		0.1	ND		0.1	ND		0.1	0.02	J	0.1
Naphthalene	91-20-3	10	0.26		0.1	ND		0.1	0.06	J	0.1	ND		0.1	0.1		0.1	ND		0.1	ND		0.1	1.3		0.1	ND		0.1	ND		0.1	ND		0.1
Pentachlorophenol	87-86-5	1	ND		0.8	ND		0.8	ND		0.8	ND		0.8	ND		0.8	ND		0.8	ND		0.8	ND		0.8	ND		0.8	ND		0.8	ND		0.8
Phenanthrene	85-01-8	50	0.25		0.1	0.11		0.1	0.33		0.1	0.05	J	0.1	0.11		0.1	0.14		0.1	0.04	J	0.1	0.15		0.1	ND		0.1	0.05	J	0.1	0.04	J	0.1
Pyrene	129-00-0	50	0.14		0.1	ND		0.1	0.14		0.1	0.03	J	0.1	ND		0.1	ND		0.1	0.02	J	0.1	0.08	J	0.1	0.02	J	0.1	0.04	J	0.1	ND		0.1
Total SVOCs			1.13	-	-	0.32	-	-	1.22	-	-	0.26	-	-	1.45	-	-	1.11	-	-	0.17	-	-	2.56	-	-	0.05	-	-	0.21	-	-	0.24	-	-
SVOCs TICs (ug/l)																																		
Cyclic Octaatomic Sulfur	010544-50-0		3.16	NJ	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Unknown			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Unknown			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Unknown			-		-	-		-	3.64	J	0	4.18	J	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Unknown			-		-	-		-	1.53	J	0	3.45	J	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Unknown			-		-	6.65	J	0	2.25	J	0	5.96	J	0	-		-	-		-	1.74	J	0	-	-	-	-	-	-	-	-	-	-	-	-
Unknown			-		-	1.96	J	0	4.98	J	0	7.93	J	0	6.73	J	0	-		-	15.2	J	0	-	-	-	-	-	-	-	-	-	-	-	-
Unknown			4.87	J	0	2.44	J	0	6.29	J	0	1.56	J	0	5.96	J	0	11.2	J	0	6.33	J	0	-		-	-		-	-		-	-		-
Unknown			3.38	J	0	10.2	J	0	1.78	J	0	2.14	J	0	21.6	J	0	4	J	0	1.89	J	0	5.2	J	0	-		-	2.04	J	0	-		-
Unknown			7.16	J	0	2	J	0	2.62	J	0	3.42	J	0	5.64	J	0	2.54	J	0	4.58	J	0	3.49	J	0	-		-	1.67	J	0	-		-
Unknown			11.4	J	0	1.49	J	0	1.82	J	0	2.54	J	0	4.07	J	0	3.24	J	0	1.6	J	0	1.78	J	0	-		-	2.11	J	0	2.47	J	0
Unknown			1.71	J	0	10.3	J	0	10.1	J	0	13.2	J	0	4.44	J	0	4.73	J	0	1.56	J	0	1.93	J	0	1.82	J	0	2.04	J	0	2.11	J	0
Unknown			2.44	J	0	3.53	J	0	2.47	J	0	1.67	J	0	17.6	J	0	24.2	J	0	3.42	J	0	3.89	J	0	1.85	J	0	2.22	J	0	5.78	J	0
Unknown			11.2	J	0	3.93	J	0	3.74	J	0	4.73	J	0	15	J	0	2.65	J	0	1.89	J	0	2.29	J	0	3.78	J	0	4.29	J	0	3.85	J	0
Unknown Alcohol			-		-	-		-	-		-	-		-	-		-	-		-	-		-	-		-	-		-	-		-	-		-
Unknown Alcohol			-		-	-		-	-		-	-		-	-		-	-		-	-		-	-		-	-		-	-		-	2.36	J	0
Unknown Alcohol			-		-	-		-	-		-	-		-	-		-	-		-	-		-	-		-	-		-	-		-	-		-
Unknown Aldehyde			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Unknown Alkane			-		-	-		-	-		-	-		-	-		-	2.65	J	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Unknown Alkane			-		-	-		-	-		-	-		-	-		-	3.02	J	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Unknown Alkane			-		-	-		-	-		-	-		-	-		-	6.25	J	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Unknown Alkane			-		-	-		-	-		-	-		-	-		-	3.24	J	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Unknown Alkane			-		-	-		-	-		-	-		-	4.8	J	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Unknown Alkane			-		-	-		-	-		-	-		-	-		-	7.53	J	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Unknown Alkene			-		-	-		-	-		-	-		-	19.3	J	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Unknown Amide			-		-	-		-	-		-	-		-	7.02	J	0	-		-	-		-	5.49	J	0	-	-	-	-	-	-	-	-	-
Unknown Amine			-		-	-		-	-		-	-		-	11.2	J	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Unknown Benzene			-		-	-		-	-		-	-		-	-		-	10.2	J	0	-		-	3.67	J	0	-	-	-	-	-	-	-	-	-
Unknown Naphthalene			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Unknown Naphthalene			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Unknown Organic Acid			-		-	-		-	-		-	-		-	-		-	-		-	-		-	34.7	J	0	-	-	-	-	-	-	-	-	-
Unknown Organic Acid			-		-	-		-	-		-	-		-	-		-	-		-	-		-	22.2	J	0	-		-	-		-	-		-
Unknown Organic Acid			-		-	-		-	-		-	-		-	-		-	-		-	33.6	J	0	5.16	J	0	-		-	-		-	11.4	J	0
Unknown Organic Acid			-		-	-		-	-		-	13.6	J	0	-		-	-		-	2.22	J	0	5.89	J	0	-		-	-		-	1.6	J	0
Unknown Organic Acid			-		-	-		-	-		-	10.4	J	0	-		-	-		-	5.71	J	0	2.87	J	0	6.11	J	0	-		-	4.91	J	0
Unknown Organic Acid			-		-	-		-	-		-	-		-	56.2	J	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Unknown Organic Acid			7.34	J	0	9.05	J	0	6	J	0	1.53	J	0	-		-	3.34	J	0	8.62	J	0	2.44	J	0	2	J	0	4.84	J	0	2.04	J	0
Unknown Organic Acid			14.5	J	0	14.5	J	0	11.5	J	0	1.78	J	0	-		-	72	J	0	6.54	J	0	5.64	J	0	7.31	J	0	2.22	J	0	2.8	J	0
Unknown PAH			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Unknown PAH			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Unknown PAH			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Unknown Siloxane			-		-	-		-	-		-	-		-	5.85	J	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Unknown Siloxane			-		-	-		-	-		-	-		-	4.22	J	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Total TIC Compounds			67.2	J	0	66.1	J	0	58.7	J	0	78.1	J	0	190	J	0	161	J	0	94.9	J	0	107	J	0	22.9	J	0	21.4	J	0	39.3	J	0

SESI CONSULTING ENGINEERS

Table 3.3 - Summary of Groundwater Analytical Results
80 Main Street
White Plains, New York
SESI Project #12859

SAMPLE ID:			GW-10			GW-11			GW-12			GW-13			GW-14			GW-15			GW-16			GW-17			GW-18			GW-19			GW-20		
LAB ID:			L2331226-08			L2331226-09			L2331480-06			L2331480-07			L2331827-06			L2331827-07			L2332665-06			L2332665-07			L2341423-01			L2341423-02			L2341423-03		
COLLECTION DATE:			6/5/2023			6/5/2023			6/6/2023			6/6/2023			6/7/2023			6/7/2023			6/9/2023			6/9/2023			7/19/2023			7/19/2023			7/19/2023		
SAMPLE MATRIX:			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER		
ANALYTES	**CAS**	**NY-AWQS**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**
Presicides (ug/l)																																		
4,4'-DDD	72-54-8	0.3	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.033	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029
4,4'-DDE	72-55-9	0.2	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.033	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029
4,4'-DDT	50-29-3	0.2	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.033	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029
Aldrin	309-00-2	0	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.017	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014
Alpha-BHC	319-84-6	0.01	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.017	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014
Beta-BHC	319-85-7	0.04	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.017	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014
Chlordane	57-74-9	0.05	ND		0.143	ND		0.143	ND		0.143	ND		0.143	ND		0.143	ND		0.167	ND		0.143	ND		0.143	ND		0.143	ND		0.143	ND		0.143
cis-Chlordane	5103-71-9		ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.017	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014
Delta-BHC	319-86-8	0.04	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.017	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014
Dieldrin	60-57-1	0.004	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.033	ND		0.029	ND		0.029	ND		0.029	ND		0.029	0.013	J	0.029
Endosulfan I	959-98-8		ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.017	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014
Endosulfan II	33213-65-9		ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.033	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029
Endosulfan sulfate	1031-07-8		ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.033	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029
Endrin	72-20-8	0	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.033	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029
Endrin aldehyde	7421-93-4	5	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.033	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029
Endrin ketone	53494-70-5	5	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.033	ND		0.029	ND		0.029	ND		0.029	ND		0.029	ND		0.029
Heptachlor	76-44-8	0.04	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.017	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014
Heptachlor epoxide	1024-57-3	0.03	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.017	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014
Lindane	58-89-9	0.05	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.017	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014
Methoxychlor	72-43-5	35	ND		0.143	ND		0.143	ND		0.143	ND		0.143	ND		0.143	ND		0.167	ND		0.143	ND		0.143	ND		0.143	ND		0.143	ND		0.143
Toxaphene	8001-35-2	0.06	ND		0.143	ND		0.143	ND		0.143	ND		0.143	ND		0.143	ND		0.167	ND		0.143	ND		0.143	ND		0.143	ND		0.143	ND		0.143
trans-Chlordane	5103-74-2		ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.017	ND		0.014	ND		0.014	ND		0.014	ND		0.014	ND		0.014
PCBs (ug/l)																																		
Aroclor 1016	12674-11-2	0.09	ND		0.071	ND		0.071	ND		0.071	ND		0.071	ND		0.071	ND		0.071	ND		0.089	ND		0.071	ND		0.071	ND		0.071	ND		0.071
Aroclor 1221	11104-28-2	0.09	ND		0.071	ND		0.071	ND		0.071	ND		0.071	ND		0.071	ND		0.071	ND		0.089	ND		0.071	ND		0.071	ND		0.071	ND		0.071
Aroclor 1232	11141-16-5	0.09	ND		0.071	ND		0.071	ND		0.071	ND		0.071	ND		0.071	ND		0.071	ND		0.089	ND		0.071	ND		0.071	ND		0.071	ND		0.071
Aroclor 1242	53469-21-9	0.09	ND		0.071	ND		0.071	ND		0.071	ND		0.071	ND		0.071	ND		0.071	ND		0.089	ND		0.071	ND		0.071	ND		0.071	ND		0.071
Aroclor 1248	12672-29-6	0.09	ND		0.071	ND		0.071	ND		0.071	ND		0.071	ND		0.071	ND		0.071	ND		0.089	ND		0.071	ND		0.071	ND		0.071	ND		0.071
Aroclor 1254	11097-69-1	0.09	ND		0.071	ND		0.071	ND		0.071	ND		0.071	ND		0.071	ND		0.071	ND		0.089	ND		0.071	ND		0.071	ND		0.071	ND		0.071
Aroclor 1260	11096-82-5	0.09	ND		0.071	ND		0.071	ND		0.071	ND		0.071	ND		0.071	ND		0.071	ND		0.089	ND		0.071	ND		0.071	ND		0.071	ND		0.071
Aroclor 1262	37324-23-5	0.09	ND		0.071	ND		0.071	ND		0.071	ND		0.071	ND		0.071	ND		0.071	ND		0.089	ND		0.071	ND		0.071	ND		0.071	ND		0.071
Aroclor 1268	11100-14-4	0.09	ND		0.071	ND		0.071	ND		0.071	ND		0.071	ND		0.071	ND		0.071	ND		0.089	ND		0.071	ND		0.071	ND		0.071	ND		0.071
PCBs, Total	1336-36-3		ND		0.071	ND		0.071	ND		0.071	ND		0.071	ND		0.071	ND		0.071	ND		0.089	ND		0.071	ND		0.071	ND		0.071	ND		0.071
Metals (ug/l)																																		
Aluminum, Total	7429-90-5		56600		10	102000		10	66600		10	64400		10	33600		10	71600		10	27700		10	48000		10	16300		10	9990		10	15900		10
Antimony, Total	7440-36-0	3	ND		4	ND		4	0.47	J	4	ND		4	ND		4	ND		4	ND		4	ND		4	ND		4	ND		4	ND		4	ND		4
Arsenic, Total	7440-38-2	25	8.26		0.5	15.44		0.5	6.4		0.5	5.5		0.5	4.3		0.5	4.8		0.5	2.23		0.5	3.22		0.5	4.36		0.5	16.2		0.5	2.55		0.5
Barium, Total	7440-39-3	1000	1905		0.5	4007		0.5	1586		0.5	1620		0.5	1029		0.5	2540		0.5	664.6		0.5	2032		0.5	859		0.5	2396		0.5	574.8		0.5
Beryllium, Total	7440-41-7	3	1.89		0.5	2.42		0.5	2		0.5	2.03		0.5	1.29		0.5	4.67		0.5	0.67		0.5	1.51		0.5	0.99		0.5	1.17		0.5	0.28	J	0.5
Cadmium, Total	7440-43-9	5	1.55		0.2	3.63		0.2	1.06		0.2	1.85		0.2	1.31		0.2	4.47		0.2	0.56		0.2	1.39		0.2	2.05		0.2	1.65		0.2	0.22		0.2
Calcium, Total	7440-70-2		480000		1000	980000		1000	617000		1000	283000		1000	312000		100	203000		100	207000		100	400000		100	357000		100	701000		1000	503000		1000
Chromium, Total	7440-47-3	50	177.2		1	272.7		1	119.3		1	82.65		1	56.73		1	104.4		1	57.69		1	116.8		1	40.1		1	95.15		1	89.21		1
Cobalt, Total	7440-48-4		78.62		0.5	161.6		0.5	97.48		0.5	148.4		0.5	76.52		0.5	362.5		5	49.13		0.5	132.4		5	52.61		0.5	40.75		0.5	69.44		0.5
Copper, Total	7440-50-8	200	234.6		1	620.9		1	216.8		1	245.8		1	221.8		1	296.9		1	151.5		1	200.2		1	76.45		1	133.6		1	95.2		1
Iron, Total	7439-89-6	300	124000		50	260000		50	108000		50	103000		50	60200		50	80500		50	46500		50	78400		50	25200		50	71000		50	31500		50
Lead, Total	7439-92-1	25	68.99		1	164		1	125.2		1	119		1	55.53		1	114.9		1	51.9		1	80.37		1	30.32		1	71.55		1	9.44		1
Magnesium, Total	7439-95-4	35000	152000		70	297000		70	166000		70	148000		70	95900		70	77400		70	127000		70	265000		70	108000		70	222000		70	168000		70
Manganese, Total	7439-96-5	300	4414		1	22690		10	2550		1	6738		1	6747		1	5566		1	1926		1	4566		1	3830		1	6587		1	1373		1
Mercury, Total	7439-97-6	0.7	ND		0.2	ND		0.2	0.32		0.2	0.32		0.2	ND		0.2	0.13	J	0.2	ND		0.2	ND		0.2	0.23		0.2	0.29		0.2	ND		0.2
Nickel, Total	7440-02-0	100	123.4		2	338.9		2	146.4		2	296		2	120.4		2	144.1		2	73.78		2	130.2		2	42.47		2	51.17		2	49.44		2
Potassium, Total	7440-09-7		38500		100	83100		100	52200		100	37800		100	35600		100	31600		100	20200		100	26700		100	73400		100	45100		100	27500		100
Selenium, Total	7782-49-2	10	8.12		5	14.3		5	44.8		5	51.2		5	36.7		5	95.9		5	34		5	104		50	25.5		5	6.26		5	3.81	J	5
Silver, Total	7440-22-4	50	0.36	J	0.4	1.14		0.4	0.81		0.4	0.51		0.4	0.32	J	0.4	0.31	J	0.4	0.32	J	0.4	1.35		0.4	0.26	J	0.4	ND		0.4	ND		0.4
Sodium, Total	7440-23-5	20000	160000		100	337000		100	458000		100	606000		1000	389000		1000	372000		1000	610000		1000	1770000		1000	862000		1000	836000		1000	1020000		1000
Thallium, Total	7440-28-0	0.5	1.35		1	3.66		1	1.59		1	1.79		1	2.01		1	1.18		1	0.59	J	1	1.42		1	0.51	J	1	0.23	J	1	0.26	J	1
Vanadium, Total	7440-62-2		129.5		5	226		5	106.4		5	97.37		5	53.1		5	71.51		5	53.86		5	43.51		5	32.29		5	41.87		5	53.77		5
Zinc, Total	7440-66-6	2000	245.5		10	410.8		10	345.1		10	391.2		10	191.2		10	504.5		10	199.8		10	274.9		10	108.9		10	73.28		10	73.09		10
General Chemistry (ug/l)																																		
Cyanide, Total	57-12-5	200	3	J	5	ND		5	1	J	5	4	J	5	5		5	1	J	5	ND		5	3	J	5	2	J	5	ND		5	3	J	5

Notes

NYSDEC AWQS - New York State Department of Environmental Conservation Ambient Water Quality Standard

Exceedance of the NYSDEC AWQS

J = Estimated

ND = Not Detected

SESI CONSULTING ENGINEERS

Table 3.3 - Summary of Groundwater Analytical Results
80 Main Street
White Plains, New York
SESI Project #12859

SAMPLE ID:			GW-21			GW-22			GW-23			GW-27		
LAB ID:			L2341423-04			L2341423-05			L2341423-06			L2341778-01		
COLLECTION DATE:			7/19/2023			7/19/2023			7/19/2023			7/20/2023		
SAMPLE MATRIX:			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER		
ANALYTES	**CAS**	**NY-AWQS**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**
VOCs (ug/l)														
1,1,1,2-Tetrachloroethane	630-20-6	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,1,1-Trichloroethane	71-55-6	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,1,2,2-Tetrachloroethane	79-34-5	5	ND		0.5	ND		0.5	ND		0.5	ND		0.5
1,1,2-Trichloroethane	79-00-5	1	ND		1.5	ND		1.5	ND		1.5	ND		1.5
1,1-Dichloroethane	75-34-3	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,1-Dichloroethene	75-35-4	5	ND		0.5	ND		0.5	ND		0.5	ND		0.5
1,1-Dichloropropene	563-58-6	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,2,3-Trichlorobenzene	87-61-6	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,2,3-Trichloropropane	96-18-4	0.04	ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,2,4,5-Tetramethylbenzene	95-93-2	5	ND		2	ND		2	ND		2	ND		2
1,2,4-Trichlorobenzene	120-82-1	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,2,4-Trimethylbenzene	95-63-6	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,2-Dibromo-3-chloropropane	96-12-8	0.04	ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,2-Dibromoethane	106-93-4	0.0006	ND		2	ND		2	ND		2	ND		2
1,2-Dichlorobenzene	95-50-1	3	ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,2-Dichloroethane	107-06-2	0.6	ND		0.5	ND		0.5	ND		0.5	ND		0.5
1,2-Dichloroethene, Total	540-59-0		ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,2-Dichloropropane	78-87-5	1	ND		1	ND		1	ND		1	ND		1
1,3,5-Trimethylbenzene	108-67-8	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,3-Dichlorobenzene	541-73-1	3	ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,3-Dichloropropane	142-28-9	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,3-Dichloropropene, Total	542-75-6		ND		0.5	ND		0.5	ND		0.5	ND		0.5
1,4-Dichlorobenzene	106-46-7	3	ND		2.5	ND		2.5	ND		2.5	ND		2.5
1,4-Dioxane	123-91-1		ND		250	ND		250	ND		250	ND		250
2,2-Dichloropropane	594-20-7	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
2-Butanone	78-93-3	50	ND		5	ND		5	ND		5	ND		5
2-Hexanone	591-78-6	50	ND		5	ND		5	ND		5	ND		5
4-Methyl-2-pentanone	108-10-1		ND		5	ND		5	ND		5	ND		5
Acetone	67-64-1	50	1.8	J	5	1.8	J	5	1.6	J	5	4.5	J	5
Acrylonitrile	107-13-1	5	ND		5	ND		5	ND		5	ND		5
Benzene	71-43-2	1	ND		0.5	ND		0.5	ND		0.5	ND		0.5
Bromobenzene	108-86-1	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Bromochloromethane	74-97-5	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Bromodichloromethane	75-27-4	50	ND		0.5	ND		0.5	ND		0.5	0.95		0.5
Bromoform	75-25-2	50	ND		2	ND		2	ND		2	ND		2
Bromomethane	74-83-9	5	ND		2.5	ND		2.5	0.84	J	2.5	ND		2.5
Carbon disulfide	75-15-0	60	ND		5	ND		5	ND		5	ND		5
Carbon tetrachloride	56-23-5	5	ND		0.5	ND		0.5	ND		0.5	ND		0.5
Chlorobenzene	108-90-7	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Chloroethane	75-00-3	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Chloroform	67-66-3	7	ND		2.5	ND		2.5	ND		2.5	12		2.5
Chloromethane	74-87-3		ND		2.5	ND		2.5	ND		2.5	ND		2.5
cis-1,2-Dichloroethene	156-59-2	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
cis-1,3-Dichloropropene	10061-01-5	0.4	ND		0.5	ND		0.5	ND		0.5	ND		0.5
Dibromochloromethane	124-48-1	50	ND		0.5	ND		0.5	ND		0.5	ND		0.5
Dibromomethane	74-95-3	5	ND		5	ND		5	ND		5	ND		5
Dichlorodifluoromethane	75-71-8	5	ND		5	ND		5	ND		5	ND		5
Ethyl ether	60-29-7		ND		2.5	ND		2.5	ND		2.5	ND		2.5
Ethylbenzene	100-41-4	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Hexachlorobutadiene	87-68-3	0.5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Isopropylbenzene	98-82-8	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Methyl tert butyl ether	1634-04-4	10	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Methylene chloride	75-09-2	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
n-Butylbenzene	104-51-8	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
n-Propylbenzene	103-65-1	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Naphthalene	91-20-3	10	ND		2.5	ND		2.5	ND		2.5	ND		2.5
o-Chlorotoluene	95-49-8	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
o-Xylene	95-47-6	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
p-Chlorotoluene	106-43-4	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
p-Diethylbenzene	105-05-5		ND		2	ND		2	ND		2	ND		2
p-Ethyltoluene	622-96-8		ND		2	ND		2	ND		2	ND		2
p-Isopropyltoluene	99-87-6	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
p/m-Xylene	179601-23-1	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
sec-Butylbenzene	135-98-8	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Styrene	100-42-5	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
tert-Butylbenzene	98-06-6	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Tetrachloroethene	127-18-4	5	ND		0.5	ND		0.5	ND		0.5	ND		0.5
Toluene	108-88-3	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
trans-1,2-Dichloroethene	156-60-5	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
trans-1,3-Dichloropropene	10061-02-6	0.4	ND		0.5	ND		0.5	ND		0.5	ND		0.5
trans-1,4-Dichloro-2-butene	110-57-6	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Trichloroethene	79-01-6	5	ND		0.5	ND		0.5	ND		0.5	1		0.5
Trichlorofluoromethane	75-69-4	5	ND		2.5	ND		2.5	ND		2.5	ND		2.5
Vinyl acetate	108-05-4		ND		5	ND		5	ND		5	ND		5
Vinyl chloride	75-01-4	2	ND		1	ND		1	ND		1	ND		1
Xylenes, Total	1330-20-7		ND		2.5	ND		2.5	ND		2.5	ND		2.5
Total VOCs			1.8	-	-	1.8	-	-	2.44	-	-	18.45	-	-

SESI
CONSULTING ENGINEERS

Table 3.3 - Summary of Groundwater Analytical Results
80 Main Street
White Plains, New York
SESI Project #12859

SAMPLE ID:			GW-21			GW-22			GW-23			GW-27		
LAB ID:			L2341423-04			L2341423-05			L2341423-06			L2341778-01		
COLLECTION DATE:			7/19/2023			7/19/2023			7/19/2023			7/20/2023		
SAMPLE MATRIX:			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER		
ANALYTES	**CAS**	**NY-AWQS**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**
VOCs TICs (ug/l)														
1-Propene, 2-methyl-	000115-11-7		-	-	-	-	-	-	-	-	-	-	-	-
No Tentatively Identified Compounds			ND		0	ND		0	-		-	ND		0
Nonanal	000124-19-6		-	-	-	-	-	-	-	-	-	-	-	-
Unknown			-		-	-		-	1.1	J	0	-	-	-
Unknown			-	-	-	-	-	-	-	-	-	-	-	-
Unknown			-	-	-	-	-	-	-	-	-	-	-	-
Unknown Aromatic			-	-	-	-	-	-	-	-	-	-	-	-
Unknown Aromatic			-	-	-	-	-	-	-	-	-	-	-	-
Unknown Aromatic			-	-	-	-	-	-	-	-	-	-	-	-
Unknown Naphthalene			-	-	-	-	-	-	-	-	-	-	-	-
Unknown Naphthalene			-	-	-	-	-	-	-	-	-	-	-	-
Total TIC Compounds			-		-	-		-	1.1	J	0	-	-	-
1,4 DIOXANE (ug/l)														
1,4-Dioxane	123-91-1	1	-	-	-	-	-	-	-	-	-	-	-	-
PFAS (ng/l)														
1H,1H,2H,2H-Perfluorodecanesulfonic Acid (8:2FTS)	39108-34-4		-	-	-	-	-	-	-	-	-	-	-	-
1H,1H,2H,2H-Perfluorooctanesulfonic Acid (6:2FTS)	27619-97-2		-	-	-	-	-	-	-	-	-	-	-	-
N-Ethyl Perfluorooctanesulfonamidoacetic Acid (NEtFOSAA)	2991-50-6		-	-	-	-	-	-	-	-	-	-	-	-
N-Methyl Perfluorooctanesulfonamidoacetic Acid (NMeFOSAA)	2355-31-9		-	-	-	-	-	-	-	-	-	-	-	-
Perfluorobutanesulfonic Acid (PFBS)	375-73-5		-	-	-	-	-	-	-	-	-	-	-	-
Perfluorobutanoic Acid (PFBA)	375-22-4		-	-	-	-	-	-	-	-	-	-	-	-
Perfluorodecanesulfonic Acid (PFDS)	335-77-3		-	-	-	-	-	-	-	-	-	-	-	-
Perfluorodecanoic Acid (PFDA)	335-76-2		-	-	-	-	-	-	-	-	-	-	-	-
Perfluorododecanoic Acid (PFDoA)	307-55-1		-	-	-	-	-	-	-	-	-	-	-	-
Perfluoroheptanesulfonic Acid (PFHpS)	375-92-8		-	-	-	-	-	-	-	-	-	-	-	-
Perfluoroheptanoic Acid (PFHpA)	375-85-9		-	-	-	-	-	-	-	-	-	-	-	-
Perfluorohexanesulfonic Acid (PFHxS)	355-46-4		-	-	-	-	-	-	-	-	-	-	-	-
Perfluorohexanoic Acid (PFHxA)	307-24-4		-	-	-	-	-	-	-	-	-	-	-	-
Perfluorononanoic Acid (PFNA)	375-95-1		-	-	-	-	-	-	-	-	-	-	-	-
Perfluorooctanesulfonamide (PFOSA)	754-91-6		-	-	-	-	-	-	-	-	-	-	-	-
Perfluorooctanesulfonic Acid (PFOS)	1763-23-1	2.7	-	-	-	-	-	-	-	-	-	-	-	-
Perfluorooctanoic Acid (PFOA)	335-67-1	6.7	-	-	-	-	-	-	-	-	-	-	-	-
Perfluoropentanoic Acid (PFPeA)	2706-90-3		-	-	-	-	-	-	-	-	-	-	-	-
Perfluorotetradecanoic Acid (PFTeDA)	376-06-7		-	-	-	-	-	-	-	-	-	-	-	-
Perfluorotridecanoic Acid (PFTrDA)	72629-94-8		-	-	-	-	-	-	-	-	-	-	-	-
Perfluoroundecanoic Acid (PFUnA)	2058-94-8		-	-	-	-	-	-	-	-	-	-	-	-
PFOA/PFOS, Total			-	-	-	-	-	-	-	-	-	-	-	-
SVOCs (ug/l)														
1,2,4,5-Tetrachlorobenzene	95-94-3	5	ND		10	ND		10	ND		10	ND		10
1,2,4-Trichlorobenzene	120-82-1	5	ND		5	ND		5	ND		5	ND		5
1,2-Dichlorobenzene	95-50-1	3	ND		2	ND		2	ND		2	ND		2
1,3-Dichlorobenzene	541-73-1	3	ND		2	ND		2	ND		2	ND		2
1,4-Dichlorobenzene	106-46-7	3	ND		2	ND		2	ND		2	ND		2
2,4,5-Trichlorophenol	95-95-4		ND		5	ND		5	ND		5	ND		5
2,4,6-Trichlorophenol	88-06-2		ND		5	ND		5	ND		5	ND		5
2,4-Dichlorophenol	120-83-2	1	ND		5	ND		5	ND		5	ND		5
2,4-Dimethylphenol	105-67-9	50	ND		5	ND		5	ND		5	ND		5
2,4-Dinitrophenol	51-28-5	10	ND		20	ND		20	ND		20	ND		20
2,4-Dinitrotoluene	121-14-2	5	ND		5	ND		5	ND		5	ND		5
2,6-Dinitrotoluene	606-20-2	5	ND		5	ND		5	ND		5	ND		5
2-Chlorophenol	95-57-8		ND		2	ND		2	ND		2	ND		2
2-Methylphenol	95-48-7		ND		5	ND		5	ND		5	ND		5
2-Nitroaniline	88-74-4	5	ND		5	ND		5	ND		5	ND		5
2-Nitrophenol	88-75-5		ND		10	ND		10	ND		10	ND		10
3,3'-Dichlorobenzidine	91-94-1	5	ND		5	ND		5	ND		5	ND		5
3-Methylphenol/4-Methylphenol	108-39-4/106-44-5		ND		5	ND		5	ND		5	ND		5
3-Nitroaniline	99-09-2	5	ND		5	ND		5	ND		5	ND		5
4,6-Dinitro-o-cresol	534-52-1		ND		10	ND		10	ND		10	ND		10
4-Bromophenyl phenyl ether	101-55-3		ND		2	ND		2	ND		2	ND		2
4-Chloroaniline	106-47-8	5	ND		5	ND		5	ND		5	ND		5
4-Chlorophenyl phenyl ether	7005-72-3		ND		2	ND		2	ND		2	ND		2
4-Nitroaniline	100-01-6	5	ND		5	ND		5	ND		5	ND		5
4-Nitrophenol	100-02-7		ND		10	ND		10	3	J	10	ND		10
Acetophenone	98-86-2		ND		5	ND		5	ND		5	ND		5
Benzoic Acid	65-85-0		6.8	J	50	ND		50	57		50	6.7	J	50
Benzyl Alcohol	100-51-6		ND		2	ND		2	ND		2	ND		2
Biphenyl	92-52-4		ND		2	ND		2	ND		2	ND		2
Bis(2-chloroethoxy)methane	111-91-1	5	ND		5	ND		5	ND		5	ND		5
Bis(2-chloroethyl)ether	111-44-4	1	ND		2	ND		2	ND		2	ND		2
Bis(2-chloroisopropyl)ether	108-60-1	5	ND		2	ND		2	ND		2	ND		2
Bis(2-ethylhexyl)phthalate	117-81-7	5	ND		3	ND		3	ND		3	ND		3
Butyl benzyl phthalate	85-68-7	50	ND		5	ND		5	ND		5	ND		5
Carbazole	86-74-8		ND		2	ND		2	ND		2	ND		2
Di-n-butylphthalate	84-74-2	50	0.57	J	5	ND		5	0.81	J	5	0.48	J	5
Di-n-octylphthalate	117-84-0	50	ND		5	ND		5	ND		5	ND		5
Dibenzofuran	132-64-9		ND		2	ND		2	ND		2	ND		2
Diethyl phthalate	84-66-2	50	ND		5	ND		5	ND		5	ND		5
Dimethyl phthalate	131-11-3	50	ND		5	ND		5	ND		5	ND		5
Hexachlorocyclopentadiene	77-47-4	5	ND		20	ND		20	ND		20	ND		20
Isophorone	78-59-1	50	ND		5	ND		5	ND		5	ND		5
n-Nitrosodi-n-propylamine	621-64-7		ND		5	ND		5	ND		5	ND		5
NDPA/DPA	86-30-6	50	ND		2	ND		2	ND		2	ND		2
Nitrobenzene	98-95-3	0.4	ND		2	ND		2	ND		2	ND		2
p-Chloro-m-cresol	59-50-7		ND		2	ND		2	ND		2	ND		2
Phenol	108-95-2	1	ND		5	ND		5	ND		5	ND		5
Total SVOCs			7.37	-	-	-	-	-	60.81	-	-	7.18	-	-

SESI
CONSULTING ENGINEERS

Table 3.3 - Summary of Groundwater Analytical Results
80 Main Street
White Plains, New York
SESI Project #12859

SAMPLE ID:			GW-21			GW-22			GW-23			GW-27		
LAB ID:			L2341423-04			L2341423-05			L2341423-06			L2341778-01		
COLLECTION DATE:			7/19/2023			7/19/2023			7/19/2023			7/20/2023		
SAMPLE MATRIX:			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER		
ANALYTES	**CAS**	**NY-AWQS**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**
SVOCs by SIM (ug/l)														
2-Chloronaphthalene	91-58-7	10	ND		0.2	ND		0.2	ND		0.2	ND		0.2
2-Methylnaphthalene	91-57-6		ND		0.1	ND		0.1	0.32		0.1	ND		0.1
Acenaphthene	83-32-9	20	ND		0.1	ND		0.1	0.07	J	0.1	0.02	J	0.1
Acenaphthylene	208-96-8		ND		0.1	ND		0.1	0.02	J	0.1	0.03	J	0.1
Anthracene	120-12-7	50	0.03	J	0.1	ND		0.1	0.02	J	0.1	0.05	J	0.1
Benzo(a)anthracene	56-55-3	0.002	ND		0.1	ND		0.1	0.02	J	0.1	0.04	J	0.1
Benzo(a)pyrene	50-32-8	0	ND		0.1	ND		0.1	ND		0.1	0.04	J	0.1
Benzo(b)fluoranthene	205-99-2	0.002	0.02	J	0.1	ND		0.1	0.05	J	0.1	0.04	J	0.1
Benzo(ghi)perylene	191-24-2		0.02	J	0.1	ND		0.1	0.02	J	0.1	0.03	J	0.1
Benzo(k)fluoranthene	207-08-9	0.002	0.02	J	0.1	ND		0.1	0.03	J	0.1	0.04	J	0.1
Chrysene	218-01-9	0.002	0.02	J	0.1	ND		0.1	0.03	J	0.1	0.03	J	0.1
Dibenzo(a,h)anthracene	53-70-3		0.01	J	0.1	ND		0.1	ND		0.1	0.03	J	0.1
Fluoranthene	206-44-0	50	0.04	J	0.1	ND		0.1	ND		0.1	0.07	J	0.1
Fluorene	86-73-7	50	0.02	J	0.1	ND		0.1	0.12		0.1	0.04	J	0.1
Hexachlorobenzene	118-74-1	0.04	0.02	J	0.8	ND		0.8	ND		0.8	0.04	J	0.8
Hexachlorobutadiene	87-68-3	0.5	ND		0.5	ND		0.5	ND		0.5	ND		0.5
Hexachloroethane	67-72-1	5	ND		0.8	ND		0.8	ND		0.8	ND		0.8
Indeno(1,2,3-cd)pyrene	193-39-5	0.002	0.02	J	0.1	ND		0.1	0.02	J	0.1	0.03	J	0.1
Naphthalene	91-20-3	10	ND		0.1	ND		0.1	0.14	B	0.1	ND		0.1
Pentachlorophenol	87-86-5	1	ND		0.8	ND		0.8	ND		0.8	0.26	J	0.8
Phenanthrene	85-01-8	50	0.04	J	0.1	ND		0.1	0.16		0.1	0.08	J	0.1
Pyrene	129-00-0	50	0.06	J	0.1	ND		0.1	ND		0.1	0.07	J	0.1
Total SVOCs			0.32	-	-	-	-	-	1.02	-	-	0.94	-	-
SVOCs TICs (ug/l)														
Cyclic Octaatomic Sulfur	010544-50-0		-	-	-	-	-	-	-	-	-	-	-	-
Unknown			-	-	-	-	-	-	-	-	-	-	-	-
Unknown			-	-	-	-	-	-	-	-	-	-	-	-
Unknown			-	-	-	-	-	-	-	-	-	-	-	-
Unknown			-	-	-	-	-	-	-	-	-	-	-	-
Unknown			-	-	-	-	-	-	-	-	-	-	-	-
Unknown			-	-	-	-	-	-	-	-	-	-	-	-
Unknown			-	-	-	-	-	-	5.2	J	0	-	-	-
Unknown			2	J	0	-		-	2.11	J	0	-	-	-
Unknown			1.93	J	0	-		-	1.89	J	0	1.6	J	0
Unknown			2.87	J	0	-		-	2.29	J	0	5.38	J	0
Unknown			1.74	J	0	2.11	J	0	3.16	J	0	3.16	J	0
Unknown			3.78	J	0	2	J	0	12.1	J	0	1.49	J	0
Unknown			4.8	J	0	3.85	J	0	4.54	J	0	4.29	J	0
Unknown Alcohol			-		-	-		-	9.24	J	0	-	-	-
Unknown Alcohol			-	-	-	-	-	-	-	-	-	-	-	-
Unknown Alcohol			-		-	-		-	1.78	J	0	-	-	-
Unknown Aldehyde			-	-	-	-	-	-	-	-	-	-	-	-
Unknown Alkane			-	-	-	-	-	-	-	-	-	-	-	-
Unknown Alkane			-	-	-	-	-	-	-	-	-	-	-	-
Unknown Alkane			-	-	-	-	-	-	-	-	-	-	-	-
Unknown Alkane			-	-	-	-	-	-	-	-	-	-	-	-
Unknown Alkane			-	-	-	-	-	-	-	-	-	-	-	-
Unknown Alkane			-	-	-	-	-	-	-	-	-	-	-	-
Unknown Alkene			-	-	-	-	-	-	-	-	-	-	-	-
Unknown Amide			-	-	-	-	-	-	-	-	-	-	-	-
Unknown Amine			-	-	-	-	-	-	-	-	-	-	-	-
Unknown Benzene			-	-	-	-	-	-	-	-	-	-	-	-
Unknown Naphthalene			-	-	-	-	-	-	-	-	-	-	-	-
Unknown Naphthalene			-	-	-	-	-	-	-	-	-	-	-	-
Unknown Organic Acid			-	-	-	-	-	-	-	-	-	-	-	-
Unknown Organic Acid			-		-	-		-	7.09	J	0	2.98	J	0
Unknown Organic Acid			11.3	J	0	-		-	4.65	J	0	1.67	J	0
Unknown Organic Acid			1.74	J	0	-		-	5.38	J	0	4.98	J	0
Unknown Organic Acid			4.69	J	0	2.4	J	0	12.4	J	0	2.62	J	0
Unknown Organic Acid			-	-	-	-	-	-	-	-	-	-	-	-
Unknown Organic Acid			2.07	J	0	1.49	J	0	18.8	J	0	3.82	J	0
Unknown Organic Acid			2	J	0	4.54	J	0	5.24	J	0	4.8	J	0
Unknown PAH			-	-	-	-	-	-	-	-	-	-	-	-
Unknown PAH			-	-	-	-	-	-	-	-	-	-	-	-
Unknown PAH			-	-	-	-	-	-	-	-	-	-	-	-
Unknown Siloxane			-	-	-	-	-	-	-	-	-	-	-	-
Unknown Siloxane			-	-	-	-	-	-	-	-	-	-	-	-
Total TIC Compounds			38.9	J	0	16.4	J	0	95.9	J	0	36.8	J	0

SESI CONSULTING ENGINEERS

Table 3.3 - Summary of Groundwater Analytical Results
80 Main Street
White Plains, New York
SESI Project #12859

SAMPLE ID:			GW-21			GW-22			GW-23			GW-27		
LAB ID:			L2341423-04			L2341423-05			L2341423-06			L2341778-01		
COLLECTION DATE:			7/19/2023			7/19/2023			7/19/2023			7/20/2023		
SAMPLE MATRIX:			GROUNDWATER			GROUNDWATER			GROUNDWATER			GROUNDWATER		
ANALYTES	**CAS**	**NY-AWQS**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**	**Conc**	**Q**	**RL**
Presicides (ug/l)														
4,4'-DDD	72-54-8	0.3	ND		0.029	ND		0.029	ND		0.029	ND		0.029
4,4'-DDE	72-55-9	0.2	ND		0.029	ND		0.029	ND		0.029	ND		0.029
4,4'-DDT	50-29-3	0.2	ND		0.029	ND		0.029	ND		0.029	ND		0.029
Aldrin	309-00-2	0	ND		0.014	ND		0.014	ND		0.014	ND		0.014
Alpha-BHC	319-84-6	0.01	ND		0.014	ND		0.014	ND		0.014	ND		0.014
Beta-BHC	319-85-7	0.04	ND		0.014	ND		0.014	ND		0.014	ND		0.014
Chlordane	57-74-9	0.05	ND		0.143	ND		0.143	ND		0.143	ND		0.143
cis-Chlordane	5103-71-9		ND		0.014	ND		0.014	ND		0.014	ND		0.014
Delta-BHC	319-86-8	0.04	ND		0.014	ND		0.014	ND		0.014	ND		0.014
Dieldrin	60-57-1	0.004	ND		0.029	ND		0.029	ND		0.029	ND		0.029
Endosulfan I	959-98-8		ND		0.014	ND		0.014	ND		0.014	ND		0.014
Endosulfan II	33213-65-9		ND		0.029	ND		0.029	ND		0.029	ND		0.029
Endosulfan sulfate	1031-07-8		ND		0.029	ND		0.029	ND		0.029	ND		0.029
Endrin	72-20-8	0	ND		0.029	ND		0.029	ND		0.029	ND		0.029
Endrin aldehyde	7421-93-4	5	ND		0.029	ND		0.029	ND		0.029	ND		0.029
Endrin ketone	53494-70-5	5	ND		0.029	ND		0.029	ND		0.029	ND		0.029
Heptachlor	76-44-8	0.04	ND		0.014	ND		0.014	ND		0.014	ND		0.014
Heptachlor epoxide	1024-57-3	0.03	ND		0.014	ND		0.014	ND		0.014	ND		0.014
Lindane	58-89-9	0.05	ND		0.014	ND		0.014	ND		0.014	ND		0.014
Methoxychlor	72-43-5	35	ND		0.143	ND		0.143	ND		0.143	ND		0.143
Toxaphene	8001-35-2	0.06	ND		0.143	ND		0.143	ND		0.143	ND		0.143
trans-Chlordane	5103-74-2		ND		0.014	ND		0.014	ND		0.014	ND		0.014
PCBs (ug/l)														
Aroclor 1016	12674-11-2	0.09	ND		0.071	ND		0.071	ND		0.071	ND		0.071
Aroclor 1221	11104-28-2	0.09	ND		0.071	ND		0.071	ND		0.071	ND		0.071
Aroclor 1232	11141-16-5	0.09	ND		0.071	ND		0.071	ND		0.071	ND		0.071
Aroclor 1242	53469-21-9	0.09	ND		0.071	ND		0.071	ND		0.071	ND		0.071
Aroclor 1248	12672-29-6	0.09	ND		0.071	ND		0.071	ND		0.071	ND		0.071
Aroclor 1254	11097-69-1	0.09	ND		0.071	ND		0.071	ND		0.071	ND		0.071
Aroclor 1260	11096-82-5	0.09	ND		0.071	ND		0.071	ND		0.071	ND		0.071
Aroclor 1262	37324-23-5	0.09	ND		0.071	ND		0.071	ND		0.071	ND		0.071
Aroclor 1268	11100-14-4	0.09	ND		0.071	ND		0.071	ND		0.071	ND		0.071
PCBs, Total	1336-36-3		ND		0.071	ND		0.071	ND		0.071	ND		0.071
Metals (ug/l)														
Aluminum, Total	7429-90-5		21600		10	8880		10	10800		10	92300		10
Antimony, Total	7440-36-0	3	ND		4	ND		4	ND		4	ND		4
Arsenic, Total	7440-38-2	25	3.29		0.5	1.51		0.5	3.44		0.5	8.74		0.5
Barium, Total	7440-39-3	1000	621.6		0.5	333.8		0.5	371.4		0.5	1833		0.5
Beryllium, Total	7440-41-7	3	0.74		0.5	0.22	J	0.5	0.27	J	0.5	3.46		0.5
Cadmium, Total	7440-43-9	5	0.46		0.2	0.16	J	0.2	0.21		0.2	1.39		0.2
Calcium, Total	7440-70-2		624000		1000	193000		100	655000		1000	354000		100
Chromium, Total	7440-47-3	50	83.88		1	52.83		1	72.86		1	225		1
Cobalt, Total	7440-48-4		90.47		0.5	48.9		0.5	27.42		0.5	139.7		0.5
Copper, Total	7440-50-8	200	98.22		1	52.4		1	25.66		1	579.8		1
Iron, Total	7439-89-6	300	36600		50	18900		50	16700		50	154000		50
Lead, Total	7439-92-1	25	27.42		1	9.01		1	8.33		1	95.06		1
Magnesium, Total	7439-95-4	35000	210000		70	67200		70	91900		70	201000		70
Manganese, Total	7439-96-5	300	3057		1	1226		1	676.1		1	3440		1
Mercury, Total	7439-97-6	0.7	0.09	J	0.2	ND		0.2	ND		0.2	ND		0.2
Nickel, Total	7440-02-0	100	71.63		2	37.72		2	27.57		2	246.9		2
Potassium, Total	7440-09-7		34100		100	21800		100	50300		100	48300		100
Selenium, Total	7782-49-2	10	5.77		5	2.54	J	5	3.36	J	5	20.1		5
Silver, Total	7440-22-4	50	0.18	J	0.4	ND		0.4	ND		0.4	0.93		0.4
Sodium, Total	7440-23-5	20000	1940000		1000	2060000		1000	2320000		1000	206000		100
Thallium, Total	7440-28-0	0.5	0.45	J	1	0.22	J	1	ND		1	1.52		1
Vanadium, Total	7440-62-2		61.11		5	22.22		5	30.86		5	171.4		25
Zinc, Total	7440-66-6	2000	140.6		10	37.32		10	78.9		10	604.1		10
General Chemistry (ug/l)														
Cyanide, Total	57-12-5	200	4	J	5	19		5	3	J	5	2	J	5

Notes
NYSDEC AWQS - New York State Department of Environmental Conservation Ambient Water Quality Standard

Exceedance of the NYSDEC AWQS
J = Estimated
ND = Not Detected

SESI CONSULTING ENGINEERS

Table 3.5 - Summary of Soil Vapor Analytical Results
80 Main Street
White Plains, New York
SESI Project #12859

SAMPLE ID:														IA-3		SSV-3		IA-4		SSV-4		IA-5		SSV-5	
LAB ID:														L2316892-01		L2316892-07		L2316892-02		L2316892-08		L2316892-03		L2316892-09	
COLLECTION DATE:														3/30/2023		3/30/2023		3/30/2023		3/30/2023		3/30/2023		3/30/2023	
SAMPLE MATRIX:														INDOOR AIR		SOIL_VAPOR		INDOOR AIR		SOIL_VAPOR		INDOOR AIR		SOIL_VAPOR	
VOCs (ug/m3)	CAS	IAC-A	IAC-B	IAC-C	IAC-D	IAC-E	IAC-F	SSC-A	SSC-B	SSC-C	SSC-D	SSC-E	SSC-F	Conc	RL	Conc	RL	Conc	RL	Conc	RL	Conc	RL	Conc	RL
1,1,1-Trichloroethane	71-55-6		3						100					ND	0.109	ND	1.09	ND	0.109	ND	1.09	ND	0.109	ND	1.09
1,1,2,2-Tetrachloroethane	79-34-5													ND	1.37	ND	1.37	ND	1.37	ND	1.37	ND	1.37	ND	1.37
1,1,2-Trichloroethane	79-00-5													ND	1.09	ND	1.09	ND	1.09	ND	1.09	ND	1.09	ND	1.09
1,1-Dichloroethane	75-34-3													ND	0.809	ND	0.809	ND	0.809	ND	0.809	ND	0.809	ND	0.809
1,1-Dichloroethene	75-35-4	0.2						6						ND	0.079	ND	0.793	ND	0.079	ND	0.793	ND	0.079	ND	0.793
1,2,4-Trichlorobenzene	120-82-1													ND	1.48	ND	1.48	ND	1.48	ND	1.48	ND	1.48	ND	1.48
1,2,4-Trimethylbenzene	95-63-6				2						60			ND	0.983	5.16	0.983	ND	0.983	7.96	0.983	ND	0.983	7.87	0.983
1,2-Dibromoethane	106-93-4													ND	1.54	ND	1.54	ND	1.54	ND	1.54	ND	1.54	ND	1.54
1,2-Dichlorobenzene	95-50-1													ND	1.2	ND	1.2	ND	1.2	ND	1.2	ND	1.2	ND	1.2
1,2-Dichloroethane	107-06-2													ND	0.809	ND	0.809	ND	0.809	ND	0.809	ND	0.809	ND	0.809
1,2-Dichloropropane	78-87-5													ND	0.924	ND	0.924	ND	0.924	ND	0.924	ND	0.924	ND	0.924
1,3,5-Trimethylbenzene	108-67-8				2						60			ND	0.983	1.65	0.983	ND	0.983	3.15	0.983	ND	0.983	2.35	0.983
1,3-Butadiene	106-99-0													ND	0.442	ND	0.442	0.903	0.442	ND	0.442	ND	0.442	ND	0.442
1,3-Dichlorobenzene	541-73-1													ND	1.2	ND	1.2	ND	1.2	ND	1.2	ND	1.2	ND	1.2
1,4-Dichlorobenzene	106-46-7													ND	1.2	ND	1.2	ND	1.2	ND	1.2	ND	1.2	ND	1.2
1,4-Dioxane	123-91-1													ND	0.721	ND	0.721	ND	0.721	ND	0.721	ND	0.721	ND	0.721
2,2,4-Trimethylpentane	540-84-1				2						60			ND	0.934	ND	0.934	1.63	0.934	3.1	0.934	ND	0.934	ND	0.934
2-Butanone	78-93-3													ND	1.47	ND	1.47	ND	1.47	20.2	1.47	ND	1.47	1.5	1.47
2-Hexanone	591-78-6													ND	0.82	ND	0.82	ND	0.82	ND	0.82	ND	0.82	ND	0.82
3-Chloropropene	107-05-1													ND	0.626	ND	0.626	ND	0.626	ND	0.626	ND	0.626	ND	0.626
4-Ethyltoluene	622-96-8													ND	0.983	ND	0.983	ND	0.983	1.64	0.983	ND	0.983	1.28	0.983
4-Methyl-2-pentanone	108-10-1													ND	2.05	ND	2.05	ND	2.05	ND	2.05	ND	2.05	ND	2.05
Acetone	67-64-1													6.13	2.38	10.6	2.38	2.54	2.38	65.3	2.38	13.9	2.38	178	2.38
Benzene	71-43-2				2						60			1.53	0.639	0.824	0.639	3.35	0.639	1.44	0.639	0.974	0.639	0.91	0.639
Benzyl chloride	100-44-7													ND	1.04	ND	1.04	ND	1.04	ND	1.04	ND	1.04	ND	1.04
Bromodichloromethane	75-27-4													ND	1.34	ND	1.34	ND	1.34	ND	1.34	ND	1.34	ND	1.34
Bromoform	75-25-2													ND	2.07	ND	2.07	ND	2.07	ND	2.07	ND	2.07	ND	2.07
Bromomethane	74-83-9													ND	0.777	ND	0.777	ND	0.777	ND	0.777	ND	0.777	ND	0.777
Carbon disulfide	75-15-0													ND	0.623	ND	0.623	ND	0.623	2.97	0.623	ND	0.623	ND	0.623
Carbon tetrachloride	56-23-5	0.2						6						0.465	0.126	ND	1.26	0.497	0.126	ND	1.26	0.503	0.126	ND	1.26

SESI
CONSULTING ENGINEERS

Table 3.5 - Summary of Soil Vapor Analytical Results
80 Main Street
White Plains, New York
SESI Project #12859

SAMPLE ID:														IA-3		SSV-3		IA-4		SSV-4		IA-5		SSV-5	
LAB ID:														L2316892-01		L2316892-07		L2316892-02		L2316892-08		L2316892-03		L2316892-09	
COLLECTION DATE:														3/30/2023		3/30/2023		3/30/2023		3/30/2023		3/30/2023		3/30/2023	
SAMPLE MATRIX:														INDOOR AIR		SOIL_VAPOR		INDOOR AIR		SOIL_VAPOR		INDOOR AIR		SOIL_VAPOR	
VOCs (ug/m3)	CAS	IAC-A	IAC-B	IAC-C	IAC-D	IAC-E	IAC-F	SSC-A	SSC-B	SSC-C	SSC-D	SSC-E	SSC-F	Conc	RL	Conc	RL	Conc	RL	Conc	RL	Conc	RL	Conc	RL
Chlorobenzene	108-90-7													ND	0.921	ND	0.921	ND	0.921	ND	0.921	ND	0.921	ND	0.921
Chloroethane	75-00-3													ND	0.528	ND	0.528	ND	0.528	ND	0.528	ND	0.528	ND	0.528
Chloroform	67-66-3													ND	0.977	ND	0.977	ND	0.977	1.83	0.977	ND	0.977	ND	0.977
Chloromethane	74-87-3													1.08	0.413	0.681	0.413	1.09	0.413	ND	0.413	1.08	0.413	1.02	0.413
cis-1,2-Dichloroethene	156-59-2	0.2						6						ND	0.079	ND	0.793	ND	0.079	ND	0.793	ND	0.079	ND	0.793
cis-1,3-Dichloropropene	10061-01-5													ND	0.908	ND	0.908	ND	0.908	ND	0.908	ND	0.908	ND	0.908
Cyclohexane	110-82-7				2						60			ND	0.688	ND	0.688	ND	0.688	1.34	0.688	ND	0.688	ND	0.688
Dibromochloromethane	124-48-1													ND	1.7	ND	1.7	ND	1.7	ND	1.7	ND	1.7	ND	1.7
Dichlorodifluoromethane	75-71-8													2.79	0.989	24.9	0.989	2.79	0.989	287	0.989	2.9	0.989	3.76	0.989
Ethanol	64-17-5													ND	9.42	ND	9.42	ND	9.42	20.5	9.42	ND	9.42	ND	9.42
Ethyl Acetate	141-78-6													ND	1.8	ND	1.8	ND	1.8	ND	1.8	ND	1.8	ND	1.8
Ethylbenzene	100-41-4				2						60			ND	0.869	ND	0.869	1.09	0.869	3.63	0.869	ND	0.869	1.37	0.869
Freon-113	76-13-1													ND	1.53	ND	1.53	ND	1.53	ND	1.53	ND	1.53	ND	1.53
Freon-114	76-14-2													ND	1.4	ND	1.4	ND	1.4	ND	1.4	ND	1.4	ND	1.4
Heptane	142-82-5					6						200		ND	0.82	ND	0.82	1.18	0.82	3.44	0.82	ND	0.82	ND	0.82
Hexachlorobutadiene	87-68-3													ND	2.13	ND	2.13	ND	2.13	ND	2.13	ND	2.13	ND	2.13
Isopropanol	67-63-0													ND	1.23	ND	1.23	1.74	1.23	8.38	1.23	1.52	1.23	13.6	1.23
Methyl tert butyl ether	1634-04-4													ND	0.721	ND	0.721	ND	0.721	ND	0.721	ND	0.721	ND	0.721
Methylene chloride	75-09-2		3						100					ND	1.74	ND	1.74	ND	1.74	ND	1.74	ND	1.74	ND	1.74
n-Hexane	110-54-3					6						200		0.849	0.705	ND	0.705	2.23	0.705	2.05	0.705	ND	0.705	ND	0.705
o-Xylene	95-47-6				2						60			ND	0.869	1.55	0.869	1.23	0.869	8.77	0.869	ND	0.869	3.76	0.869
p/m-Xylene	179601-23-1					6						200		ND	1.74	2.6	1.74	3.2	1.74	19.9	1.74	ND	1.74	9.99	1.74
Styrene	100-42-5													ND	0.852	ND	0.852	ND	0.852	ND	0.852	ND	0.852	ND	0.852
Tertiary butyl Alcohol	75-65-0													ND	1.52	4.52	1.52	ND	1.52	3.06	1.52	ND	1.52	4.34	1.52
Tetrachloroethene	127-18-4		3						100					ND	0.136	15	1.36	0.163	0.136	3.48	1.36	ND	0.136	6.43	1.36
Tetrahydrofuran	109-99-9													ND	1.47	ND	1.47	ND	1.47	ND	1.47	ND	1.47	ND	1.47
Toluene	108-88-3						10						300	2.2	0.754	1.25	0.754	5.28	0.754	6.71	0.754	1.19	0.754	1.62	0.754
trans-1,2-Dichloroethene	156-60-5													ND	0.793	ND	0.793	ND	0.793	ND	0.793	ND	0.793	ND	0.793
trans-1,3-Dichloropropene	10061-02-6													ND	0.908	ND	0.908	ND	0.908	ND	0.908	ND	0.908	ND	0.908
Trichloroethene	79-01-6	0.2						6						ND	0.107	ND	1.07	ND	0.107	ND	1.07	ND	0.107	ND	1.07
Trichlorofluoromethane	75-69-4													1.5	1.12	1.39	1.12	1.47	1.12	ND	1.12	1.46	1.12	1.45	1.12
Vinyl bromide	593-60-2													ND	0.874	ND	0.874	ND	0.874	ND	0.874	ND	0.874	ND	0.874
Vinyl chloride	75-01-4			0.2						6				ND	0.051	ND	0.511	ND	0.051	ND	0.511	ND	0.051	ND	0.511

Notes

SSC-A: New York DOH Matrix A Sub-slab Vapor Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

SSC-B: New York DOH Matrix B Sub-slab Vapor Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

SSC-C: New York DOH Matrix D Sub-slab Vapor Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

SSC-D: New York DOH Matrix D Sub-slab Vapor Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

SSC-E: New York DOH Matrix E Sub-slab Vapor Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

SSC-F: New York DOH Matrix F Sub-slab Vapor Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

IAC-A: New York DOH Matrix A Indoor Air Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

IAC-B: New York DOH Matrix A Indoor Air Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

IAC-C: New York DOH Matrix A Indoor Air Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

IAC-D: New York DOH Matrix A Indoor Air Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

IAC-E: New York DOH Matrix A Indoor Air Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

IAC-F: New York DOH Matrix A Indoor Air Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

Exceedance of a IAC/SSC NYDOH Matrix

SESI CONSULTING ENGINEERS

Table 3.5 - Summary of Soil Vapor Analytical Results
80 Main Street
White Plains, New York
SESI Project #12859

SAMPLE ID:														IA-6		SSV-6		IA-7		SSV-7		IA-8		SSV-8	
LAB ID:														L2316892-04		L2316892-10		L2316892-05		L2316892-11		L2316892-06		L2316892-12	
COLLECTION DATE:														3/30/2023		3/30/2023		3/30/2023		3/30/2023		3/30/2023		3/30/2023	
SAMPLE MATRIX:														INDOOR AIR		SOIL_VAPOR		INDOOR AIR		SOIL_VAPOR		INDOOR AIR		SOIL_VAPOR	
VOCs (ug/m3)	CAS	IAC-A	IAC-B	IAC-C	IAC-D	IAC-E	IAC-F	SSC-A	SSC-B	SSC-C	SSC-D	SSC-E	SSC-F	Conc	RL	Conc	RL	Conc	RL	Conc	RL	Conc	RL	Conc	RL
1,1,1-Trichloroethane	71-55-6		3						100					ND	0.109	3.05	1.09	ND	0.109	ND	1.09	ND	0.109	ND	1.09
1,1,2,2-Tetrachloroethane	79-34-5													ND	1.37	ND	1.37	ND	1.37	ND	1.37	ND	1.37	ND	1.37
1,1,2-Trichloroethane	79-00-5													ND	1.09	ND	1.09	ND	1.09	ND	1.09	ND	1.09	ND	1.09
1,1-Dichloroethane	75-34-3													ND	0.809	ND	0.809	ND	0.809	ND	0.809	ND	0.809	ND	0.809
1,1-Dichloroethene	75-35-4	0.2						6						ND	0.079	ND	0.793	ND	0.079	ND	0.793	ND	0.079	ND	0.793
1,2,4-Trichlorobenzene	120-82-1													ND	1.48	ND	1.48	ND	1.48	ND	1.48	ND	1.48	ND	1.48
1,2,4-Trimethylbenzene	95-63-6				2						60			ND	0.983	3.81	0.983	ND	0.983	1.01	0.983	ND	0.983	1.08	0.983
1,2-Dibromoethane	106-93-4													ND	1.54	ND	1.54	ND	1.54	ND	1.54	ND	1.54	ND	1.54
1,2-Dichlorobenzene	95-50-1													ND	1.2	ND	1.2	ND	1.2	ND	1.2	ND	1.2	ND	1.2
1,2-Dichloroethane	107-06-2													ND	0.809	ND	0.809	ND	0.809	ND	0.809	ND	0.809	ND	0.809
1,2-Dichloropropane	78-87-5													ND	0.924	ND	0.924	ND	0.924	ND	0.924	ND	0.924	ND	0.924
1,3,5-Trimethylbenzene	108-67-8				2						60			ND	0.983	1.5	0.983	ND	0.983	ND	0.983	ND	0.983	ND	0.983
1,3-Butadiene	106-99-0													ND	0.442	ND	0.442	ND	0.442	ND	0.442	ND	0.442	ND	0.442
1,3-Dichlorobenzene	541-73-1													ND	1.2	ND	1.2	ND	1.2	ND	1.2	ND	1.2	ND	1.2
1,4-Dichlorobenzene	106-46-7													ND	1.2	ND	1.2	ND	1.2	ND	1.2	ND	1.2	ND	1.2
1,4-Dioxane	123-91-1													ND	0.721	ND	0.721	ND	0.721	ND	0.721	ND	0.721	ND	0.721
2,2,4-Trimethylpentane	540-84-1				2						60			ND	0.934	ND	0.934	ND	0.934	ND	0.934	ND	0.934	ND	0.934
2-Butanone	78-93-3													ND	1.47	5.37	1.47	ND	1.47	2.46	1.47	ND	1.47	3.66	1.47
2-Hexanone	591-78-6													ND	0.82	ND	0.82	ND	0.82	ND	0.82	ND	0.82	ND	0.82
3-Chloropropene	107-05-1													ND	0.626	ND	0.626	ND	0.626	ND	0.626	ND	0.626	ND	0.626
4-Ethyltoluene	622-96-8													ND	0.983	ND	0.983	ND	0.983	ND	0.983	ND	0.983	ND	0.983
4-Methyl-2-pentanone	108-10-1													ND	2.05	ND	2.05	ND	2.05	2.07	2.05	ND	2.05	ND	2.05
Acetone	67-64-1													6.32	2.38	50.4	2.38	5.46	2.38	21.6	2.38	8.72	2.38	76.7	2.38
Benzene	71-43-2				2						60			0.885	0.639	1.64	0.639	0.91	0.639	0.923	0.639	ND	0.639	5.78	0.639
Benzyl chloride	100-44-7													ND	1.04	ND	1.04	ND	1.04	ND	1.04	ND	1.04	ND	1.04
Bromodichloromethane	75-27-4													ND	1.34	ND	1.34	ND	1.34	ND	1.34	ND	1.34	ND	1.34
Bromoform	75-25-2													ND	2.07	ND	2.07	ND	2.07	ND	2.07	ND	2.07	ND	2.07
Bromomethane	74-83-9													ND	0.777	ND	0.777	ND	0.777	ND	0.777	ND	0.777	ND	0.777
Carbon disulfide	75-15-0													ND	0.623	3.89	0.623	ND	0.623	1.8	0.623	ND	0.623	5.08	0.623
Carbon tetrachloride	56-23-5	0.2						6						0.491	0.126	ND	1.26	0.44	0.126	ND	1.26	0.535	0.126	ND	1.26

SESI
CONSULTING ENGINEERS

Table 3.5 - Summary of Soil Vapor Analytical Results
80 Main Street
White Plains, New York
SESI Project #12859

SAMPLE ID:														IA-6		SSV-6		IA-7		SSV-7		IA-8		SSV-8	
LAB ID:														L2316892-04		L2316892-10		L2316892-05		L2316892-11		L2316892-06		L2316892-12	
COLLECTION DATE:														3/30/2023		3/30/2023		3/30/2023		3/30/2023		3/30/2023		3/30/2023	
SAMPLE MATRIX:														INDOOR AIR		SOIL_VAPOR		INDOOR AIR		SOIL_VAPOR		INDOOR AIR		SOIL_VAPOR	
VOCs (ug/m3)	CAS	IAC-A	IAC-B	IAC-C	IAC-D	IAC-E	IAC-F	SSC-A	SSC-B	SSC-C	SSC-D	SSC-E	SSC-F	Conc	RL	Conc	RL	Conc	RL	Conc	RL	Conc	RL	Conc	RL
Chlorobenzene	108-90-7													ND	0.921	ND	0.921	ND	0.921	ND	0.921	ND	0.921	ND	0.921
Chloroethane	75-00-3													ND	0.528	ND	0.528	ND	0.528	ND	0.528	ND	0.528	ND	0.528
Chloroform	67-66-3													ND	0.977	16.3	0.977	ND	0.977	1.25	0.977	ND	0.977	30.1	0.977
Chloromethane	74-87-3													1.11	0.413	ND	0.413	1.06	0.413	ND	0.413	1.11	0.413	ND	0.413
cis-1,2-Dichloroethene	156-59-2	0.2						6						ND	0.079	ND	0.793	ND	0.079	ND	0.793	ND	0.079	ND	0.793
cis-1,3-Dichloropropene	10061-01-5													ND	0.908	ND	0.908	ND	0.908	ND	0.908	ND	0.908	ND	0.908
Cyclohexane	110-82-7				2						60			ND	0.688	0.809	0.688	ND	0.688	ND	0.688	ND	0.688	ND	0.688
Dibromochloromethane	124-48-1													ND	1.7	ND	1.7	ND	1.7	ND	1.7	ND	1.7	ND	1.7
Dichlorodifluoromethane	75-71-8													2.77	0.989	32.6	0.989	2.78	0.989	5.29	0.989	2.81	0.989	17.9	0.989
Ethanol	64-17-5													ND	9.42	10.9	9.42	ND	9.42	19.2	9.42	ND	9.42	ND	9.42
Ethyl Acetate	141-78-6													ND	1.8	ND	1.8	ND	1.8	ND	1.8	ND	1.8	ND	1.8
Ethylbenzene	100-41-4				2						60			ND	0.869	2.81	0.869	ND	0.869	1.01	0.869	ND	0.869	1.82	0.869
Freon-113	76-13-1													ND	1.53	ND	1.53	ND	1.53	ND	1.53	ND	1.53	ND	1.53
Freon-114	76-14-2													ND	1.4	3.98	1.4	ND	1.4	ND	1.4	ND	1.4	ND	1.4
Heptane	142-82-5					6						200		ND	0.82	2.57	0.82	ND	0.82	ND	0.82	ND	0.82	1.22	0.82
Hexachlorobutadiene	87-68-3													ND	2.13	ND	2.13	ND	2.13	ND	2.13	ND	2.13	ND	2.13
Isopropanol	67-63-0													ND	1.23	2.24	1.23	ND	1.23	ND	1.23	ND	1.23	ND	1.23
Methyl tert butyl ether	1634-04-4													ND	0.721	ND	0.721	ND	0.721	ND	0.721	ND	0.721	ND	0.721
Methylene chloride	75-09-2		3						100					29.3	1.74	ND	1.74	ND	1.74	ND	1.74	ND	1.74	ND	1.74
n-Hexane	110-54-3					6						200		ND	0.705	1.87	0.705	ND	0.705	ND	0.705	ND	0.705	0.828	0.705
o-Xylene	95-47-6				2						60			ND	0.869	1.66	0.869	ND	0.869	0.908	0.869	ND	0.869	2.05	0.869
p/m-Xylene	179601-23-1					6						200		ND	1.74	3.96	1.74	ND	1.74	2.49	1.74	ND	1.74	4.95	1.74
Styrene	100-42-5													ND	0.852	ND	0.852	ND	0.852	ND	0.852	ND	0.852	ND	0.852
Tertiary butyl Alcohol	75-65-0													ND	1.52	1.94	1.52	ND	1.52	2.11	1.52	ND	1.52	4.06	1.52
Tetrachloroethene	127-18-4		3						100					0.156	0.136	12.9	1.36	ND	0.136	19.6	1.36	ND	0.136	22	1.36
Tetrahydrofuran	109-99-9													ND	1.47	ND	1.47	ND	1.47	ND	1.47	ND	1.47	ND	1.47
Toluene	108-88-3						10						300	2.35	0.754	2.65	0.754	1.11	0.754	3.77	0.754	ND	0.754	11.4	0.754
trans-1,2-Dichloroethene	156-60-5													ND	0.793	ND	0.793	ND	0.793	ND	0.793	ND	0.793	ND	0.793
trans-1,3-Dichloropropene	10061-02-6													ND	0.908	ND	0.908	ND	0.908	ND	0.908	ND	0.908	ND	0.908
Trichloroethene	79-01-6	0.2						6						ND	0.107	ND	1.07	ND	0.107	ND	1.07	ND	0.107	3.07	1.07
Trichlorofluoromethane	75-69-4													1.42	1.12	11.2	1.12	1.48	1.12	6.63	1.12	1.53	1.12	1.83	1.12
Vinyl bromide	593-60-2													ND	0.874	ND	0.874	ND	0.874	ND	0.874	ND	0.874	ND	0.874
Vinyl chloride	75-01-4			0.2						6				ND	0.051	ND	0.511	ND	0.051	ND	0.511	ND	0.051	ND	0.511

Notes

SSC-A: New York DOH Matrix A Sub-slab Vapor Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

SSC-B: New York DOH Matrix B Sub-slab Vapor Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

SSC-C: New York DOH Matrix D Sub-slab Vapor Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

SSC-D: New York DOH Matrix D Sub-slab Vapor Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

SSC-E: New York DOH Matrix E Sub-slab Vapor Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

SSC-F: New York DOH Matrix F Sub-slab Vapor Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

IAC-A: New York DOH Matrix A Indoor Air Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

IAC-B: New York DOH Matrix A Indoor Air Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

IAC-C: New York DOH Matrix A Indoor Air Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

IAC-D: New York DOH Matrix A Indoor Air Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

IAC-E: New York DOH Matrix A Indoor Air Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

IAC-F: New York DOH Matrix A Indoor Air Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

Exceedance of a IAC/SSC NYDOH Matrix

SESI CONSULTING ENGINEERS

Table 3.5 - Summary of Soil Vapor Analytical Results
80 Main Street
White Plains, New York
SESI Project #12859

SAMPLE ID:														IA-9		SSV-9		IA-10		SSV-10	
LAB ID:														L2318681-01		L2318681-03		L2318681-02		L2318681-04	
COLLECTION DATE:														4/7/2023		4/7/2023		4/7/2023		4/7/2023	
SAMPLE MATRIX:														INDOOR AIR		SOIL_VAPOR		INDOOR AIR		SOIL_VAPOR	
VOCs (ug/m3)	CAS	IAC-A	IAC-B	IAC-C	IAC-D	IAC-E	IAC-F	SSC-A	SSC-B	SSC-C	SSC-D	SSC-E	SSC-F	Conc	RL	Conc	RL	Conc	RL	Conc	RL
1,1,1-Trichloroethane	71-55-6		3						100					ND	0.109	ND	14.7	ND	0.109	ND	6.06
1,1,2,2-Tetrachloroethane	79-34-5													ND	1.37	ND	18.5	ND	1.37	ND	7.62
1,1,2-Trichloroethane	79-00-5													ND	1.09	ND	14.7	ND	1.09	ND	6.06
1,1-Dichloroethane	75-34-3													ND	0.809	ND	10.9	ND	0.809	ND	4.49
1,1-Dichloroethene	75-35-4	0.2						6						ND	0.079	ND	10.7	ND	0.079	ND	4.4
1,2,4-Trichlorobenzene	120-82-1													ND	1.48	ND	20	ND	1.48	ND	8.24
1,2,4-Trimethylbenzene	95-63-6				2						60			1.45	0.983	18.7	13.2	1.47	0.983	5.6	5.46
1,2-Dibromoethane	106-93-4													ND	1.54	ND	20.7	ND	1.54	ND	8.53
1,2-Dichlorobenzene	95-50-1													ND	1.2	ND	16.2	ND	1.2	ND	6.67
1,2-Dichloroethane	107-06-2													ND	0.809	ND	10.9	ND	0.809	ND	4.49
1,2-Dichloropropane	78-87-5													ND	0.924	ND	12.4	ND	0.924	ND	5.13
1,3,5-Trimethylbenzene	108-67-8				2						60			ND	0.983	ND	13.2	ND	0.983	ND	5.46
1,3-Butadiene	106-99-0													1.46	0.442	38.7	5.95	1.67	0.442	90.9	2.46
1,3-Dichlorobenzene	541-73-1													ND	1.2	ND	16.2	ND	1.2	ND	6.67
1,4-Dichlorobenzene	106-46-7													ND	1.2	ND	16.2	ND	1.2	ND	6.67
1,4-Dioxane	123-91-1													ND	0.721	ND	9.69	ND	0.721	ND	4
2,2,4-Trimethylpentane	540-84-1				2						60			1.23	0.934	ND	12.6	1.45	0.934	ND	5.18
2-Butanone	78-93-3													ND	1.47	1150	19.8	3.07	1.47	378	8.2
2-Hexanone	591-78-6													ND	0.82	ND	11	ND	0.82	ND	4.55
3-Chloropropene	107-05-1													ND	0.626	ND	8.42	ND	0.626	ND	3.47
4-Ethyltoluene	622-96-8													ND	0.983	21	13.2	ND	0.983	8.65	5.46
4-Methyl-2-pentanone	108-10-1													ND	2.05	ND	27.6	ND	2.05	ND	11.4
Acetone	67-64-1													14.8	2.38	4320	32.1	30.6	2.38	2680	13.2
Benzene	71-43-2				2						60			3.48	0.639	37.1	8.59	4.06	0.639	63.9	3.55
Benzyl chloride	100-44-7													ND	1.04	ND	13.9	ND	1.04	ND	5.75
Bromodichloromethane	75-27-4													ND	1.34	ND	18	ND	1.34	ND	7.44
Bromoform	75-25-2													ND	2.07	ND	27.8	ND	2.07	ND	11.5
Bromomethane	74-83-9													ND	0.777	ND	10.4	ND	0.777	ND	4.31
Carbon disulfide	75-15-0													ND	0.623	14	8.38	ND	0.623	6.73	3.46
Carbon tetrachloride	56-23-5	0.2						6						0.51	0.126	ND	16.9	0.522	0.126	ND	6.98

SESI
CONSULTING ENGINEERS

Table 3.5 - Summary of Soil Vapor Analytical Results
80 Main Street
White Plains, New York
SESI Project #12859

SAMPLE ID:														IA-9		SSV-9		IA-10		SSV-10	
LAB ID:														L2318681-01		L2318681-03		L2318681-02		L2318681-04	
COLLECTION DATE:														4/7/2023		4/7/2023		4/7/2023		4/7/2023	
SAMPLE MATRIX:														INDOOR AIR		SOIL_VAPOR		INDOOR AIR		SOIL_VAPOR	
VOCs (ug/m3)	CAS	IAC-A	IAC-B	IAC-C	IAC-D	IAC-E	IAC-F	SSC-A	SSC-B	SSC-C	SSC-D	SSC-E	SSC-F	Conc	RL	Conc	RL	Conc	RL	Conc	RL
Chlorobenzene	108-90-7													ND	0.921	ND	12.4	ND	0.921	ND	5.11
Chloroethane	75-00-3													ND	0.528	14.2	7.1	ND	0.528	ND	2.93
Chloroform	67-66-3													ND	0.977	31.3	13.1	ND	0.977	ND	5.42
Chloromethane	74-87-3													1.07	0.413	ND	5.55	1.08	0.413	ND	2.29
cis-1,2-Dichloroethene	156-59-2	0.2						6						ND	0.079	ND	10.7	ND	0.079	ND	4.4
cis-1,3-Dichloropropene	10061-01-5													ND	0.908	ND	12.2	ND	0.908	ND	5.04
Cyclohexane	110-82-7				2						60			ND	0.688	ND	9.26	ND	0.688	ND	3.82
Dibromochloromethane	124-48-1													ND	1.7	ND	22.9	ND	1.7	ND	9.46
Dichlorodifluoromethane	75-71-8													2.71	0.989	ND	13.3	2.79	0.989	418	5.49
Ethanol	64-17-5													22.4	9.42	976	127	9.59	9.42	409	52.4
Ethyl Acetate	141-78-6													ND	1.8	ND	24.3	ND	1.8	28.2	10
Ethylbenzene	100-41-4				2						60			1.46	0.869	886	11.7	2.01	0.869	247	4.82
Freon-113	76-13-1													ND	1.53	ND	20.6	ND	1.53	ND	8.51
Freon-114	76-14-2													ND	1.4	ND	18.8	ND	1.4	ND	7.76
Heptane	142-82-5					6						200		1.07	0.82	16.2	11	1.16	0.82	ND	4.55
Hexachlorobutadiene	87-68-3													ND	2.13	ND	28.7	ND	2.13	ND	11.8
Isopropanol	67-63-0													2.1	1.23	225	16.5	ND	1.23	60.2	6.83
Methyl tert butyl ether	1634-04-4													ND	0.721	ND	9.7	ND	0.721	ND	4
Methylene chloride	75-09-2		3						100					ND	1.74	ND	23.4	ND	1.74	ND	9.66
n-Hexane	110-54-3					6						200		1.96	0.705	16.2	9.48	2.27	0.705	5.08	3.91
o-Xylene	95-47-6				2						60			1.89	0.869	66.5	11.7	2.42	0.869	27.6	4.82
p/m-Xylene	179601-23-1					6						200		5.26	1.74	77.3	23.4	7.34	1.74	133	9.64
Styrene	100-42-5													ND	0.852	4850	11.5	ND	0.852	2090	4.73
Tertiary butyl Alcohol	75-65-0													6.4	1.52	92.2	20.4	ND	1.52	69.4	8.43
Tetrachloroethene	127-18-4		3						100					0.176	0.136	27.5	18.2	ND	0.136	16.4	7.53
Tetrahydrofuran	109-99-9													ND	1.47	ND	19.8	ND	1.47	ND	8.2
Toluene	108-88-3						10						300	6.1	0.754	43.3	10.1	7.16	0.754	107	4.18
trans-1,2-Dichloroethene	156-60-5													ND	0.793	ND	10.7	ND	0.793	ND	4.4
trans-1,3-Dichloropropene	10061-02-6													ND	0.908	ND	12.2	ND	0.908	ND	5.04
Trichloroethene	79-01-6	0.2						6						ND	0.107	ND	14.5	ND	0.107	ND	5.97
Trichlorofluoromethane	75-69-4													1.39	1.12	ND	15.1	1.28	1.12	ND	6.24
Vinyl bromide	593-60-2													ND	0.874	ND	11.8	ND	0.874	ND	4.85
Vinyl chloride	75-01-4			0.2						6				ND	0.051	ND	6.88	ND	0.051	ND	2.84

Notes

SSC-A: New York DOH Matrix A Sub-slab Vapor Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

SSC-B: New York DOH Matrix B Sub-slab Vapor Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

SSC-C: New York DOH Matrix D Sub-slab Vapor Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

SSC-D: New York DOH Matrix D Sub-slab Vapor Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

SSC-E: New York DOH Matrix E Sub-slab Vapor Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

SSC-F: New York DOH Matrix F Sub-slab Vapor Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

IAC-A: New York DOH Matrix A Indoor Air Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

IAC-B: New York DOH Matrix A Indoor Air Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

IAC-C: New York DOH Matrix A Indoor Air Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

IAC-D: New York DOH Matrix A Indoor Air Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

IAC-E: New York DOH Matrix A Indoor Air Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

IAC-F: New York DOH Matrix A Indoor Air Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

Exceedance of a IAC/SSC NYDOH Matrix

SESI CONSULTING ENGINEERS

Figures



REFERENCE:

UNITED STATES GEOLOGICAL SURVEY (USGS)
WHITE PLAINS, NY USGS QUADRANGLE - 2019

LEGEND:

SUBJECT PROPERTY

SCALE: 1" = 2,000'

0 1,000 2,000 4,000 FEET

80 MAIN STREET
WHITE PLAINS, WESTCHESTER COUNTY, NY

SUBJECT PROPERTY LOCATION MAP

SESI CONSULTING ENGINEERS
GEOTECHNICAL | ENVIRONMENTAL | SITE CIVIL
959 ROUTE 46E, 3RD FLOOR, PARSIPPANY, NJ 07054 PH: 973.808.9050

FIG-1.1	
DRAWN BY:	KBV
CHECKED BY:	CM
SCALE:	AS NOTED
DATE:	6/6/2024
JOB NO:	12859

Y:\GIS\Project_Numbers\12859\APRX_PROJECT\APRX_Phase1_Prj_No.aprx, 6/6/2024 8:55 AM, Kim Vanderklein, LAYOUT: FIG-1.1

N:\ACAD\12859\CAD\GEOTECH\LOCATION PLANS\GALLERIA WEST – UNIT A\PHASE II ESA\12859.DWG_SOIL SAMP PLAN – [CONDO PLAN] (A–B–C).DWG 02/02/26 07:50:26AM, alan.ward, LAYOUT:UNIT C PLAN (80 MAIN S

Sample ID	SB-45G(3.5-4)	
Sample Date	7/18/2023	
	Results	Qual
SVOCs		
Phenanthrene	1.2	
Indeno(1,2,3-cd)pyrene	0.51	
Metals		
Lead	131	
Mercury	0.236	
Pesticides		
4,4'-DDE	0.00655	

Sample ID	SB-21G (9-9.5)	
Sample Date	6/5/2023	
	Results	Qual
VOCs		
Acetone	0.091	

Sample ID	SB-5G (3-3.5)	
Sample Date	4/4/2023	
	Results	Qual
SVOCs		
Benzo(a)anthracene	6.1	
Benzo(a)pyrene	6	
Benzo(b)fluoranthene	7.2	J
Benzo(k)fluoranthene	2.6	
Chrysene	5.2	
Benzo(ghi)perylene	2.4	
Phenanthrene	8.2	
Dibenzo(a,h)anthracene	0.77	
Indeno(1,2,3-cd)pyrene	3.1	
Sample ID	**SB-5G (9.5-10)**	
Sample Date	**4/4/2023**	
	Results	**Qual**
VOCs		
Acetone	0.032	

Sample ID	SB-10G (6-6.5)	
Sample Date	4/5/2023	
	Results	Qual
VOCs		
Acetone	0.33	
SVOCs		
Acenaphthene	53	
Anthracene	180	
Benzo(a)anthracene	200	J
Benzo(a)pyrene	180	
Benzo(b)fluoranthene	210	
Benzo(k)fluoranthene	68	
Chrysene	180	
Benzo(ghi)perylene	100	
Fluoranthene	540	
Fluorene	90	
Phenanthrene	850	
Dibenzo(a,h)anthracene	28	
Dibenzofuran	110	
Indeno(1,2,3-cd)pyrene	95	
Pyrene	400	
Naphthalene	110	



Sample ID	SB-12G (4-4.5)	
Sample Date	4/5/2023	
	Results	Qual
Metals		
Mercury	0.185	

Sample ID	SB-7G (5-5.5)	
Sample Date	4/4/2023	
	Results	Qual
Metals		
Lead	70.5	

Sample ID	SB-22(3.5-4)	
Sample Date	3/7/2024	
	Results	Qual
Pesticides		
Dieldrin	0.0094	
4,4'-DDT	0.0054	

Sample ID	SB-25(1.5-2)	
Sample Date	3/7/2024	
	Results	Qual
SVOCs		
Benzo(a)anthracene	4.37	
Benzo(a)pyrene	4.72	
Benzo(b)fluoranthene	5.92	J
Benzo(g,h,i)perylene	3.35	
Benzo(k)fluoranthene	2.14	
Chrysene	4.89	
Dibenzo(a,h)anthracene	0.925	
Indeno(1,2,3-cd)pyrene	2.77	
Phenanthrene	1.51	d

Compound	Unit	PGWSCOs	RRSCOs	USCOs
VOCs				
Acetone	mg/kg	0.03	100	0.03
SVOCs				
Acenaphthene	mg/kg	98	100	20
Anthracene	mg/kg	1000	100	100
Benzo(a)anthracene	mg/kg	1	1.4	1
Benzo(a)pyrene	mg/kg	22	1	1
Benzo(b)fluoranthene	mg/kg	2.1	1.4	1
Benzo(k)fluoranthene	mg/kg	2	4.9	0.8
Chrysene	mg/kg	1	4.9	1
Benzo(ghi)perylene	mg/kg	1000	4.9	0.64
Fluoranthene	mg/kg	1000	100	85
Fluorene	mg/kg	386	100	30
Phenanthrene	mg/kg	1000	4.9	1.1
Dibenzo(a,h)anthracene	mg/kg	1000	0.33	0.33
Dibenzofuran	mg/kg	110	18	2.1
Indeno(1,2,3-cd)pyrene	mg/kg	6.6	1.4	0.5
Pyrene	mg/kg	1000	100	64
Naphthalene	mg/kg	12	100	12
Metals				
Lead, Total	mg/kg	450	400	63
Mercury, Total	mg/kg	0.73	0.3	0.18
Pesticides				
Dieldrin	mg/kg	0.1	0.075	0.005
4,4'-DDE	mg/kg	9.3	3.4	0.0033
4,4'-DDT	mg/kg	135	3.8	0.0033

Notes:

Concentration Exceeds the USCO

Concentration Exceeds the PGWSCO or RRSCO

PGWSCOs: New York 2025 NYCRR Part 375 Groundwater Criteria, New York Restricted use Criteria per 6 NYCRR Part 375 Environmental Remediation Programs, effective 12/2006 amended 12/2025.

RRSCOs: New York 2025 NYCRR Part 375 Restricted-Residential Criteria, New York Restricted use Criteria per 6 NYCRR Part 375 Environmental Remediation Programs, effective 12/2006 amended 12/2025.

USCOs: New York 2025 NYCRR Part 375 New York Unrestricted use Criteria Criteria per 6 NYCRR Part 375 Environmental Remediation Programs, effective 12/2006 amended 12/2025.

mg/Kg = Milligrams per Kilogram

d = Associated CCV outside of control limits low . Low-level verification w as analyzed to demonstrate system suitability to detect affected analytes. Estimated value, due to corresponding failure in the batch associated CCV.

J = Estimated concentration

E = Concentration Exceeds the calibrated analysis range

LEGEND:

SB-25 - SOIL BORING NUMBER & APPROX. LOCATION

NOTE:
THIS PLAN IS FOR LOCATING SOIL SAMPLES ONLY.
OTHER SITE WORK SHOWN HERE IS NOT INTENDED FOR CONSTRUCTION.

REFERENCE
1. BASE MAP IS TAKEN FROM "SUBDIVISION OF PROPERTY" PREPARED BY LINE & GRADE SURVEYORS, D.P.C., DATED FEBRUARY 3, 2025.

SCALE: 1"=60'
0 60 120

NYS Education Law
Unauthorized alterations or additions to this plan are a violation of section 7209 (2) of the New York State Education Law. Copies of this map not having the seal of the engineer shall not be valid.

© SESI CONSULTING ENGINEERS 2026
This drawing and all information contained here on is proprietary information of SESI CONSULTING ENGINEERS and may not be copied or reproduced, either in whole or in part, by any method, without written permission of SESI CONSULTING ENGINEERS

dwg by: AW
chk by: SG
scale: AS NOTED
date: 02/19/2025

SESI CONSULTING ENGINEERS
GEOTECHNICAL | ENVIRONMENTAL | SITE CIVIL
959 ROUTE 46E, 3RD FLOOR, PARSIPPANY, NJ 07054 PH: 973.808.9050

project: 80 MAIN STREET
CITY OF WHITE PLAINS
WESTCHESTER COUNTY, NEW YORK

title: SOIL SAMPLE LOCATION PLAN

job no: 12859
drawing no:

FIG 3.1

N:\ACAD\12859\CAD\GEOTECH\LOCATION PLANS\GALLERIA WEST – UNIT A\PHASE II ESA\12859.DWG_SOIL SAMP PLAN – [CONDO PLAN] (GALLERIA WEST) (SV).DWG 02/20/25 10:46:58AM, alan.ward, LAYOUT:UNIT C [GW]

ANALYTES	NY-AWQS
VOCs (ug/l)	
Acetone	50
Chloroform	7
Styrene	5
PFAS (ng/l)	
Perfluorooctanesulfonic Acid (PFOS)	2.7
Perfluorooctanoic Acid (PFOA)	6.7
SVOCs (ug/l)	
Phenol	1
SVOCs by SIM (ug/l)	
Benzo(a)anthracene	0.002
Benzo(a)pyrene	0
Benzo(b)fluoranthene	0.002
Benzo(k)fluoranthene	0.002
Chrysene	0.002
Hexachlorobenzene	0.04
Indeno(1,2,3-cd)pyrene	0.002
Presicides (ug/l)	
Dieldrin	0.004
Chlordane	0.05
Metals (ug/l)	
Antimony, Total	3
Arsenic, Total	25
Barium, Total	1000
Beryllium, Total	3
Cadmium, Total	5
Chromium, Total	50
Copper, Total	200
Iron, Total	300
Lead, Total	25
Magnesium, Total	35000
Manganese, Total	300
Mercury, Total	0.7
Nickel, Total	100
Selenium, Total	10
Sodium, Total	20000
Thallium, Total	0.5

Notes
NYSDEC AWQS - New York State Department of Environmental Conservation Ambient Water Quality Standard
Exceedance of the NYSDEC AWQS
J = Estimated
ND = Not Detected

SAMPLE ID:	GW-9
COLLECTION DATE:	4/7/2023
ANALYTES	Conc Q
Styrene	8.3
PFAS (ng/l)	
Perfluorooctanesulfonic Acid (PFOS)	24.1
Perfluorooctanoic Acid (PFOA)	29
SVOCs (ug/l)	
Phenol	1.2 J
SVOCs by SIM (ug/l)	
Benzo(a)anthracene	6.1
Benzo(a)pyrene	6.4
Benzo(b)fluoranthene	7.2
Benzo(k)fluoranthene	2.4
Chrysene	5.5
Indeno(1,2,3-cd)pyrene	3.7
Metals (ug/l)	
Arsenic, Total	26.29
Barium, Total	2441
Beryllium, Total	3.59
Chromium, Total	453.1
Copper, Total	426
Iron, Total	205000
Lead, Total	213
Magnesium, Total	190000
Manganese, Total	9555
Mercury, Total	1.88
Nickel, Total	206.9
Selenium, Total	42.2
Sodium, Total	480000
Thallium, Total	1.37 J

SAMPLE ID:	GW-10
COLLECTION DATE:	6/5/2023
ANALYTES	Conc Q
SVOCs by SIM (ug/l)	
Benzo(a)anthracene	0.03 J
Benzo(a)pyrene	0.02 J
Benzo(b)fluoranthene	0.02 J
Benzo(k)fluoranthene	0.01 J
Chrysene	0.03 J
Metals (ug/l)	
Barium, Total	1905
Chromium, Total	177.2
Copper, Total	234.6
Iron, Total	124000
Lead, Total	68.99
Magnesium, Total	152000
Manganese, Total	4414
Nickel, Total	123.4
Sodium, Total	160000
Thallium, Total	1.35

SAMPLE ID:	GW-8
COLLECTION DATE:	4/7/2023
ANALYTES	Conc Q
VOCs (ug/l)	
Acetone	72
Styrene	16
PFAS (ng/l)	
Perfluorooctanesulfonic Acid (PFOS)	11.6
Perfluorooctanoic Acid (PFOA)	7.4
SVOCs by SIM (ug/l)	
Metals (ug/l)	
Barium, Total	1934
Beryllium, Total	3.22
Chromium, Total	236
Copper, Total	477
Iron, Total	172000
Lead, Total	88.21
Magnesium, Total	267000
Manganese, Total	468.4
Nickel, Total	179
Selenium, Total	29.7
Sodium, Total	229000
Thallium, Total	1.5



UNIT C PLAN

INS

NOTE:
THIS PLAN IS FOR LOCATING SOIL SAMPLES ONLY.
OTHER SITE WORK SHOWN HERE IS NOT INTENDED FOR CONSTRUCTION.

REFERENCE
1. BASE MAP IS TAKEN FROM "SUBDIVISION OF PROPERTY" PREPARED BY LINE & GRADE SURVEYORS, D.P.C., DATED FEBRUARY 3, 2025.

LEGEND:

GW-8 ● - GROUNDWATER BORING NUMBER AND APPROX. LOCATION

SCALE: 1"=60'
0 60 120

NYS Education Law
Unauthorized alterations or additions to this plan are a violation of section 7209 (2) of the New York State Education Law. Copies of this map not having the seal of the engineer shall not be valid.

© SESI CONSULTING ENGINEERS 2025
This drawing and all information contained here on is proprietary information of SESI CONSULTING ENGINEERS and may not be copied or reproduced, either in whole or in part, by any method, without written permission of SESI CONSULTING ENGINEERS

dwg by: AW
chk by: SG
scale: AS NOTED
date: 02/20/2025

SESI CONSULTING ENGINEERS
GEOTECHNICAL | ENVIRONMENTAL | SITE CIVIL
959 ROUTE 46E, 3RD FLOOR, PARSIPPANY, NJ 07054 PH: 973.808.9050

project: 100 MAIN STREET
UNIT C
CITY OF WHITE PLAINS
WESTCHESTER COUNTY, NEW YORK

title: GROUNDWATER LOCATION PLAN

job no: 12859
drawing no:

FIG 3.2

N:\ACAD\12859\CAD\GEOTECH\LOCATION PLANS\GALLERIA WEST — UNIT A\PHASE II ESA\12859.DWG_SOIL SAMP PLAN — [CONDO PLAN] (GALLERIA WEST) (SV).DWG 02/20/25 11:06:44AM, alan.ward, LAYOUT:UNIT C [SOIL VAPOR]

SAMPLE ID:	IA-10		SSV-10	
LAB ID:	L2318681-02		L2318681-04	
COLLECTION DATE:	4/7/2023		4/7/2023	
SAMPLE MATRIX:	INDOOR AIR		SOIL_VAPOR	
VOCs (ug/m3)	Conc	RL	Conc	RL
1,2,4-Trimethylbenzene	1.47	0.983	5.6	5.46
1,3-Butadiene	1.67	0.442	90.9	2.46
2,2,4-Trimethylpentane	1.45	0.934	ND	5.18
2-Butanone	3.07	1.47	378	8.2
4-Ethyltoluene	ND	0.983	8.65	5.46
Acetone	30.6	2.38	2680	13.2
Benzene	4.06	0.639	63.9	3.55
Carbon disulfide	ND	0.623	6.73	3.46
Carbon tetrachloride	0.522	0.126	ND	6.98
Chloromethane	1.08	0.413	ND	2.29
Dichlorodifluoromethane	2.79	0.989	418	5.49
Ethanol	9.59	9.42	409	52.4
Ethylbenzene	2.01	0.869	247	4.82
Heptane	1.16	0.82	ND	4.55
Isopropanol	ND	1.23	60.2	6.83
n-Hexane	2.27	0.705	5.08	3.91
o-Xylene	2.42	0.869	27.6	4.82
p/m-Xylene	7.34	1.74	133	9.64
Tertiary butyl Alcohol	ND	1.52	69.4	8.43
Tetrachloroethene	ND	0.136	16.4	7.53
Toluene	7.16	0.754	107	4.18
Trichlorofluoromethane	1.28	1.12	ND	6.24



SAMPLE ID:	IA-9		SSV-9	
LAB ID:	L2318681-01		L2318681-03	
COLLECTION DATE:	4/7/2023		4/7/2023	
SAMPLE MATRIX:	INDOOR AIR		SOIL_VAPOR	
VOCs (ug/m3)	Conc	RL	Conc	RL
1,2,4-Trimethylbenzene	1.45	0.983	18.7	13.2
1,3-Butadiene	1.46	0.442	38.7	5.95
2,2,4-Trimethylpentane	1.23	0.934	ND	12.6
2-Butanone	ND	1.47	1150	19.8
4-Ethyltoluene	ND	0.983	21	13.2
Acetone	14.8	2.38	4320	32.1
Benzene	3.48	0.639	37.1	8.59
Carbon disulfide	ND	0.623	14	8.38
Carbon tetrachloride	0.51	0.126	ND	16.9
Chloroform	ND	0.977	31.3	13.1
Chloromethane	1.07	0.413	ND	5.55
Dichlorodifluoromethane	2.71	0.989	ND	13.3
Ethanol	22.4	9.42	976	127
Ethylbenzene	1.46	0.869	886	11.7
Heptane	1.07	0.82	16.2	11
Isopropanol	2.1	1.23	225	16.5
n-Hexane	1.96	0.705	16.2	9.48
o-Xylene	1.89	0.869	66.5	11.7
p/m-Xylene	5.26	1.74	77.3	23.4
Tertiary butyl Alcohol	6.4	1.52	92.2	20.4
Tetrachloroethene	0.176	0.136	27.5	18.2
Toluene	6.1	0.754	43.3	10.1
Trichlorofluoromethane	1.39	1.12	ND	15.1

VOLATILE ORGANICS IN AIR (ug/m3)	IAC-A	IAC-B	IAC-D	IAC-E	IAC-F	SSC-A	SSC-B	SSC-D	SSC-E	SSC-F
1,2,4-Trimethylbenzene			2					60		
1,3,5-Trimethylbenzene			2					60		
1,3-Butadiene										
2,2,4-Trimethylpentane			2					60		
2-Butanone										
4-Ethyltoluene										
Acetone										
Benzene			2					60		
Carbon disulfide										
Carbon tetrachloride	0.2					6				
Chloroform										
Chloromethane										
Cyclohexane			2					60		
Dichlorodifluoromethane										
Ethanol										
Ethylbenzene			2					60		
Heptane				6					200	
Isopropanol										
Methylene chloride		3					100			
n-Hexane				6					200	
o-Xylene			2					60		
p/m-Xylene				6					200	
Tertiary butyl Alcohol										
Tetrachloroethene		3					100			
Toluene					10					300
Trichlorofluoromethane										

Notes

SSC-A: New York DOH Matrix A Sub-slab Vapor Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

SSC-B: New York DOH Matrix B Sub-slab Vapor Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

SSC-D: New York DOH Matrix D Sub-slab Vapor Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

SSC-E: New York DOH Matrix E Sub-slab Vapor Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

SSC-F: New York DOH Matrix F Sub-slab Vapor Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

IA-C-A: New York DOH Matrix A Indoor Air Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

IA-C-B: New York DOH Matrix A Indoor Air Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

IA-C-D: New York DOH Matrix A Indoor Air Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

IA-C-E: New York DOH Matrix A Indoor Air Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

IA-C-F: New York DOH Matrix A Indoor Air Concentrations Criteria per Guidance for Evaluating Soil Vapor Intrusion, October 2006, and updated February 2024

Exceedance of a IA/SSC NYDOH Matrix

Reporting Limit is above the IA/SSC NYDOH Matrix

NYS Education Law

Unauthorized alterations or additions to this plan are a violation of section 7209 (2) of the New York State Education Law. Copies of this map not having the seal of the engineer shall not be valid.

© SESI CONSULTING ENGINEERS 2025

This drawing and all information contained here on is proprietary information of SESI CONSULTING ENGINEERS and may not be copied or reproduced, either in whole or in part, by any method, without written permission of SESI CONSULTING ENGINEERS

NOTE:

THIS PLAN IS FOR LOCATING SOIL SAMPLES ONLY.
OTHER SITE WORK SHOWN HERE IS NOT INTENDED FOR CONSTRUCTION.

REFERENCE

1. BASE MAP IS TAKEN FROM "SUBDIVISION OF PROPERTY" PREPARED BY LINE & GRADE SURVEYORS, D.P.C., DATED FEBRUARY 3, 2025.

LEGEND:

SSV-9/IA-9 - SOIL VAPOR NUMBER AND APPROX. LOCATION

SCALE: 1"=60'

0 60 120

dwg by: AW
chk by: SG
scale: AS NOTED
date: 02/20/2025

SESI CONSULTING ENGINEERS
GEOTECHNICAL | ENVIRONMENTAL | SITE CIVIL
959 ROUTE 46E, 3RD FLOOR, PARSIPPANY, NJ 07054 PH: 973.808.9050

project: 100 MAIN STREET
UNIT C
CITY OF WHITE PLAINS
WESTCHESTER COUNTY, NEW YORK

title: SOIL VAPOR LOCATION PLAN

job no: 12859
drawing no:

FIG 3.3

Appendix A:

Boring Logs

SESI CONSULTING ENGINEERS

PROJECT NAME:	Galleria Mall	GEOPROBE NO.	**SB-5G**
LOCATION:	White Plains, NY	JOB NO.	12461
METHOD:	Direct Push	GROUND ELEVATION:	NA
GEOPROBE BY:		DATE STARTED:	04/04/23
INSPECTOR:	Christian Barletta	DATE COMPLETED:	

GROUNDWATER TABLE DEPTH: N/E — 0 Hr. | 24 Hr. | Date

DEPTH (ft)	RECOVERY (in)	SAMPLE TUBE No.	DEPTH FROM (ft)	DEPTH TO (ft)	ENVIRONMENTAL SOIL SAMPLE NAME	SOIL DESCRIPTION AND STRATIFICATION	PID
0			0			Concrete	0
							0
					SB-5G (3-3.5)		0
							0
5				5		Light-brown yellow c-f SAND, little Silt, little Gravel, trace Clay	0
			5				0
							0
							0
						Gray-white c-f GRAVEL and SAND, some Silt, trace Clay (stone)	0
10				10	SB-5G (9.5-10)	Black-gray c-f SAND and SILT, little Gravel, little Clay	0
						Boring Complete at 10 Feet BGS	
15							
20							
25							
30							
35							
40							

Nominal I.D. of Hole	in.
Nominal I.D. of Barrel Sampler	1⅜ in

The subsurface information shown hereon was obtained for the design and estimating purposes for our client. It is made available to authorized users only that they may have access to the same information available to our client. It is presented in good faith, but it is not intended as a substitute for investigations, interpretations or judgment of such authorized users. Information on the logs should not be relied upon without the geotechnical engineers recommendations contained in the report from which these logs were extracted.

Pp: Pocket Penetrometer; DP: Direct Push

Approximate Change in Strata: _____ Inferred Change in Strata: _ _ _ _ _ _ _ _ _ _ _ _

Soil descriptions represent a field identification after D. M. Burmister unless otherwise noted.

FIGURE #

SESI CONSULTING ENGINEERS

PROJECT NAME:	Galleria Mall	GEOPROBE NO.	**SB-7G**
LOCATION:	White Plains, NY	JOB NO.	12461
METHOD:	Direct Push	GROUND ELEVATION:	NA
GEOPROBE BY:		DATE STARTED:	04/04/23
INSPECTOR:	Christian Barletta	DATE COMPLETED:	

GROUNDWATER TABLE DEPTH: 7' bgs — 0 Hr. | 24 Hr. | Date

DEPTH (ft)	RECOVERY (in)	SAMPLE TUBE No.	DEPTH FROM (ft)	DEPTH TO (ft)	ENVIRONMENTAL SOIL SAMPLE NAME	SOIL DESCRIPTION AND STRATIFICATION	PID
0	36	1	0			FILL: Concrete	0
							0
							0
							0
5				5		Light-brown c-f SAND, some Gravel, little Silt, trace Clay	0
		2	5		SB-7G (5-5.5)		0
							0
						GW encountered	0
							0
10				10			0
		3	10				0
							0
							0
							0
15							0
				15		SAND and SILT	0
						Boring Completed at 15 Feet BGS	
20							
25							
30							
35							
40							

Nominal I.D. of Hole	in.
Nominal I.D. of Barrel Sampler	1⅜ in

The subsurface information shown hereon was obtained for the design and estimating purposes for our client. It is made available to authorized users only that they may have access to the same information available to our client. It is presented in good faith, but it is not intended as a substitute for investigations, interpretations or judgment of such authorized users. Information on the logs should not be relied upon without the geotechnical engineers recommendations contained in the report from which these logs were extracted.

Pp: Pocket Penetrometer; DP: Direct Push

Approximate Change in Strata: _____ Inferred Change in Strata: _ _ _ _ _ _ _ _ _ _ _ _

Soil descriptions represent a field identification after D. M. Burmister unless otherwise noted.

FIGURE #

SESI CONSULTING ENGINEERS

PROJECT NAME:	Galleria Mall	GEOPROBE NO.	**SB-10G**
LOCATION:	White Plains, NY	JOB NO.	12461
METHOD:	Direct Push	GROUND ELEVATION:	NA
GEOPROBE BY:		DATE STARTED:	04/04/23
INSPECTOR:	Christian Barletta	DATE COMPLETED:	

GROUNDWATER TABLE DEPTH: 13' bgs

0 Hr.	24 Hr.	Date

DEPTH (ft)	RECOVERY (in)	SAMPLE TUBE No.	DEPTH FROM (ft)	DEPTH TO (ft)	ENVIRONMENTAL SOIL SAMPLE NAME	SOIL DESCRIPTION AND STRATIFICATION	PID
0		1	0			Concrete	0
					SB-10G (1-1.5)		0
							0
							0
5				5			0
		2	5			FILL: Dark-brown c-f SAND, some Silt, some Gravel, trace Clay	0
					SB-10G (6-6.5)	(odors)	0
							0
							0
10				10			0
		3	10				0
						Dark-gray c-f SAND, some Silt, some Gravel, trace Clay	0
							0
						(Groundwater encountered)	0
15				15		Dark-gray c-f SAND and SILT, some Clay, some Gravel	0
						Boring Complete at 15 Feet BGS	
20							
25							
30							
35							
40							

Nominal I.D. of Hole	in.
Nominal I.D. of Barrel Sampler	1⅜ in

The subsurface information shown hereon was obtained for the design and estimating purposes for our client. It is made available to authorized users only that they may have access to the same information available to our client. It is presented in good faith, but it is not intended as a substitute for investigations, interpretations or judgment of such authorized users. Information on the logs should not be relied upon without the geotechnical engineers recommendations contained in the report from which these logs were extracted.

Pp: Pocket Penetrometer; DP: Direct Push

Approximate Change in Strata: _____ Inferred Change in Strata: _ _ _ _ _ _ _ _ _ _ _ _

Soil descriptions represent a field identification after D. M. Burmister unless otherwise noted.

FIGURE #

SESI CONSULTING ENGINEERS

PROJECT NAME:	Galleria Mall	GEOPROBE NO.	**SB-12G**
LOCATION:	White Plains, NY	JOB NO.	12461
METHOD:	Direct Push	GROUND ELEVATION:	NA
GEOPROBE BY:		DATE STARTED:	04/04/23
INSPECTOR:	Christian Barletta	DATE COMPLETED:	

GROUNDWATER TABLE DEPTH: N/E — 0 Hr. | 24 Hr. | Date

DEPTH (ft)	RECOVERY (in)	SAMPLE TUBE No.	DEPTH FROM (ft)	DEPTH TO (ft)	ENVIRONMENTAL SOIL SAMPLE NAME	SOIL DESCRIPTION AND STRATIFICATION	PID
0		1	0			Concrete	0
							0
							0
					SB-12G (4-4.5)		0
5				5			0
		2	5				0
						Light-brown c-f SAND, some Silt, some Gravel, trace Clay	0
							0
						Dark-brown gray c-f SAND and Silt, some Gravel, some Clay	0
10				10		Dark-brown gray c-f SAND, some Silt, some Gravel, some Clay	0
						Boring Complete at 10 Feet BGS	0
15							
20							
25							
30							
35							
40							

Nominal I.D. of Hole	in.
Nominal I.D. of Barrel Sampler	1⅜ in

The subsurface information shown hereon was obtained for the design and estimating purposes for our client. It is made available to authorized users only that they may have access to the same information available to our client. It is presented in good faith, but it is not intended as a substitute for investigations, interpretations or judgment of such authorized users. Information on the logs should not be relied upon without the geotechnical engineers recommendations contained in the report from which these logs were extracted.

Pp: Pocket Penetrometer; DP: Direct Push

Approximate Change in Strata: _____ Inferred Change in Strata: _ _ _ _ _ _ _ _ _ _ _ _

Soil descriptions represent a field identification after D. M. Burmister unless otherwise noted.

FIGURE #

SESI CONSULTING ENGINEERS

PROJECT NAME:	Galleria Mall	GEOPROBE NO.	**SB-21G**
LOCATION:	White Plains, NY	JOB NO.	12461
METHOD:	Direct Push	GROUND ELEVATION:	NA
GEOPROBE BY:		DATE STARTED:	04/04/23
INSPECTOR:	Christian Barletta	DATE COMPLETED:	

GROUNDWATER TABLE DEPTH: N/E — 0 Hr. | 24 Hr. | Date

DEPTH (ft)	RECOVERY (in)	SAMPLE TUBE No.	DEPTH FROM (ft)	DEPTH TO (ft)	ENVIRONMENTAL SOIL SAMPLE NAME	SOIL DESCRIPTION AND STRATIFICATION	PID
0		1	0		SB-21G (0.5-1)	Concrete	0
							0
							0
						FILL: Brown-yellow c-f SAND, some Silt, some c-f Gravel, trace Clay (brick)	0
5				5			0
						Boring Complete at 5 Feet BGS	
10							
15							
20							
25							
30							
35							
40							

Nominal I.D. of Hole	in.
Nominal I.D. of Barrel Sampler	1⅜ in

The subsurface information shown hereon was obtained for the design and estimating purposes for our client. It is made available to authorized users only that they may have access to the same information available to our client. It is presented in good faith, but it is not intended as a substitute for investigations, interpretations or judgment of such authorized users. Information on the logs should not be relied upon without the geotechnical engineers recommendations contained in the report from which these logs were extracted.

Pp: Pocket Penetrometer; DP: Direct Push

Approximate Change in Strata: _____ Inferred Change in Strata: _ _ _ _ _ _ _ _ _ _ _ _

Soil descriptions represent a field identification after D. M. Burmister unless otherwise noted.

FIGURE #

SESI CONSULTING ENGINEERS

PROJECT NAME:	Galleria Mall	GEOPROBE NO.	**SB-22**
LOCATION:	100 Main Street White Plains, NY	JOB NO.	12461
METHOD:	Direct Push	GROUND ELEVATION:	NA
GEOPROBE BY:	ADT	DATE STARTED:	03/23/23
INSPECTOR:	Christian Barletta	DATE COMPLETED:	03/30/23

GROUNDWATER TABLE DEPTH: N/E — 0 Hr. | 24 Hr. | Date

DEPTH (ft)	RECOVERY (in)	SAMPLE TUBE No.	DEPTH FROM (ft)	DEPTH TO (ft)	ENVIRONMENTAL SOIL SAMPLE NAME	SOIL DESCRIPTION AND STRATIFICATION	PID
0	24	1	0				0
				2			0
	24	2	2		SB-22 (2-2.5)		0
				4		Black-brown c-f SAND, little Silt, little Gravel, trace Clay	0
5	24	3	4				0
				6			0
	24	4	6		SB-22 (6-6.5)		0
				8		Yellow-brown c-f SAND and SILT, some Gravel, trace Clay	0
						Boring Complete at 8 Feet BGS	
10							
15							
20							
25							
30							
35							
40							

Nominal I.D. of Hole	in.
Nominal I.D. of Barrel Sampler	1⅜ in

The subsurface information shown hereon was obtained for the design and estimating purposes for our client. It is made available to authorized users only that they may have access to the same information available to our client. It is presented in good faith, but it is not intended as a substitute for investigations, interpretations or judgment of such authorized users. Information on the logs should not be relied upon without the geotechnical engineers recommendations contained in the report from which these logs were extracted.

Pp: Pocket Penetrometer; DP: Direct Push

Approximate Change in Strata: _____ Inferred Change in Strata: _ _ _ _ _ _ _ _ _ _ _ _

Soil descriptions represent a field identification after D. M. Burmister unless otherwise noted.

FIGURE #

6tlvLYBpCxn4CokC

SESI CONSULTING ENGINEERS

PROJECT NAME:	Galleria Mall	GEOPROBE NO.	**SB-25**
LOCATION:	100 Main Street White Plains, NY	JOB NO.	12461
METHOD:	Direct Push	GROUND ELEVATION:	NA
GEOPROBE BY:	ADT	DATE STARTED:	03/23/23
INSPECTOR:	Christian Barletta	DATE COMPLETED:	03/30/23

GROUNDWATER TABLE DEPTH: N/E — 0 Hr. | 24 Hr. | Date

DEPTH (ft)	RECOVERY (in)	SAMPLE TUBE No.	DEPTH FROM (ft)	DEPTH TO (ft)	ENVIRONMENTAL SOIL SAMPLE NAME	SOIL DESCRIPTION AND STRATIFICATION	PID
0	24	1	0			FILL: Concrete	0
				2			0
	24	2	2		SB-25 (2.5-3)		0
				4			0
5	24	3	4			FILL: SAND and GRAVEL, little Silt, trace Clay (brick)	0
				6		Yellow-brown c-f SAND and SILT, some Gravel, trace Clay	0
						Boring Complete at 6 Feet BGS	
10							
15							
20							
25							
30							
35							
40							

Nominal I.D. of Hole	in.
Nominal I.D. of Barrel Sampler	1⅜ in

The subsurface information shown hereon was obtained for the design and estimating purposes for our client. It is made available to authorized users only that they may have access to the same information available to our client. It is presented in good faith, but it is not intended as a substitute for investigations, interpretations or judgment of such authorized users. Information on the logs should not be relied upon without the geotechnical engineers recommendations contained in the report from which these logs were extracted.

Pp: Pocket Penetrometer; DP: Direct Push

Approximate Change in Strata: _____ Inferred Change in Strata: _ _ _ _ _ _ _ _ _ _ _ _

Soil descriptions represent a field identification after D. M. Burmister unless otherwise noted.

FIGURE #

SESI CONSULTING ENGINEERS
GEOTECHNICAL | ENVIRONMENTAL | SITE CIVIL

BOREHOLE NUMBER: SB-45G

PROJECT NAME Galleria
PROJECT NO. 12859
DATE STARTED 07-01-2023 **COMPLETED** 07-01-2023
DRILLING CONTRACTOR ADT/Cascade
SAMPLER
EQUIPMENT
DRILLING FOREMAN **HELPER**
LOGGED BY C. Barletta **CHECKED BY** C. Malvicini
LATITUDE **LONGITUDE**

PROJECT LOCATION White Plains, New York
ELEVATION DATUM **GROUND ELEVATION**
DRILLING METHOD
SAMPLE HAMMER
AUGER INNER DIAMETER **OUTER DIAMETER**
ROTARY BIT DIAMETER **GROUNDWATER LEVELS:**
CASING DIAMETER ▽ **AT TIME OF DRILLING**
CASING DEPTH ▼ **AT END OF DRILLING**
FINAL DEPTH 5.0± ft ▼ **AFTER DRILLING**

Material Symbol	EL (ft)	Sample Description	Depth (ft)	Sleeve Number	Sample Data: Type	Sample Data: Rec. (in)	Sample Data: Environmental Soil Sample Name	Sample Data: Blows/6-in Core time/ft	Sample Data: PID (ppm)	Remarks
		Concrete							0.0	
		Light yellow coarse to medium SAND, little Silt, trace Clay/Gravel		S-1					0.0	
									0.0	
		Gray/black coarse to fine SAND, some Silt/Gravel, trace Cl					SB-45G (3.5-4)		0.0	
	-5	BOREHOLE COMPLETED AT 5± FEET	5						0.0	
	-10		10							
	-15		15							
	-20		20							
	-25		25							
	-30		30							

Appendix B:

Laboratory Reports

ANALYTICAL REPORT

Lab Number:	L2318681
Client:	Soils Engineering Services, Inc. 959 Route 46E Parsippany, NJ 07054
ATTN:	Jonathan Stuart
Phone:	(973) 808-9050
Project Name:	100 MAIN ST
Project Number:	12461:1
Report Date:	04/14/23

The original project report/data package is held by Alpha Analytical. This report/data package is paginated and should be reproduced only in its entirety. Alpha Analytical holds no responsibility for results and/or data that are not consistent with the original.

Certifications & Approvals: MA (M-MA030), NH NELAP (2062), CT (PH-0141), DoD (L2474), FL (E87814), IL (200081), LA (85084), ME (MA00030), MD (350), NJ (MA015), NY (11627), NC (685), OH (CL106), PA (68-02089), RI (LAO00299), TX (T104704419), VT (VT-0015), VA (460194), WA (C954), US Army Corps of Engineers, USDA (Permit #P330-17-00150), USFWS (Permit #206964).

320 Forbes Boulevard, Mansfield, MA 02048-1806
508-822-9300 (Fax) 508-822-3288 800-624-9220 - www.alphalab.com

Project Name: 100 MAIN ST
Project Number: 12461:1

Lab Number: L2318681
Report Date: 04/14/23

Alpha Sample ID	Client ID	Matrix	Sample Location	Collection Date/Time	Receive Date
L2318681-01	IA-9	AIR	WHITE PLAINS, NY	04/07/23 11:25	04/07/23
L2318681-02	IA-10	AIR	WHITE PLAINS, NY	04/07/23 10:30	04/07/23
L2318681-03	SSV-9	SOIL_VAPOR	WHITE PLAINS, NY	04/07/23 12:42	04/07/23
L2318681-04	SSV-10	SOIL_VAPOR	WHITE PLAINS, NY	04/07/23 13:02	04/07/23

Project Name:	100 MAIN ST	**Lab Number:**	L2318681
Project Number:	12461:1	**Report Date:**	04/14/23

Case Narrative

The samples were received in accordance with the Chain of Custody and no significant deviations were encountered during the preparation or analysis unless otherwise noted. Sample Receipt, Container Information, and the Chain of Custody are located at the back of the report.

Results contained within this report relate only to the samples submitted under this Alpha Lab Number and meet NELAP requirements for all NELAP accredited parameters unless otherwise noted in the following narrative. The data presented in this report is organized by parameter (i.e. VOC, SVOC, etc.). Sample specific Quality Control data (i.e. Surrogate Spike Recovery) is reported at the end of the target analyte list for each individual sample, followed by the Laboratory Batch Quality Control at the end of each parameter. Tentatively Identified Compounds (TICs), if requested, are reported for compounds identified to be present and are not part of the method/program Target Compound List, even if only a subset of the TCL are being reported. If a sample was re-analyzed or re-extracted due to a required quality control corrective action and if both sets of data are reported, the Laboratory ID of the re-analysis or re-extraction is designated with an "R" or "RE", respectively.

When multiple Batch Quality Control elements are reported (e.g. more than one LCS), the associated samples for each element are noted in the grey shaded header line of each data table. Any Laboratory Batch, Sample Specific % recovery or RPD value that is outside the listed Acceptance Criteria is bolded in the report. In reference to questions H (CAM) or 4 (RCP) when "NO" is checked, the performance criteria for CAM and RCP methods allow for some quality control failures to occur and still be within method compliance. In these instances, the specific failure is not narrated but noted in the associated QC Outlier Summary Report, located directly after the Case Narrative. QC information is also incorporated in the Data Usability Assessment table (Format 11) of our Data Merger tool, where it can be reviewed in conjunction with the sample result, associated regulatory criteria and any associated data usability implications.

Soil/sediments, solids and tissues are reported on a dry weight basis unless otherwise noted. Definitions of all data qualifiers and acronyms used in this report are provided in the Glossary located at the back of the report.

HOLD POLICY - For samples submitted on hold, Alpha's policy is to hold samples (with the exception of Air canisters) free of charge for 21 calendar days from the date the project is completed. After 21 calendar days, we will dispose of all samples submitted including those put on hold unless you have contacted your Alpha Project Manager and made arrangements for Alpha to continue to hold the samples. Air canisters will be disposed after 3 business days from the date the project is completed.

Please contact Project Management at 800-624-9220 with any questions.

Project Name:	100 MAIN ST	**Lab Number:**	L2318681
Project Number:	12461:1	**Report Date:**	04/14/23

Case Narrative (continued)

Volatile Organics in Air

Canisters were released from the laboratory on April 6, 2023. The canister certification results are provided as an addendum.

L2318681-03D: The sample has elevated detection limits due to the dilution required by the elevated concentrations of target compounds in the sample.

L2318681-04D: The sample has elevated detection limits due to the dilution required by the elevated concentrations of target compounds in the sample.

I, the undersigned, attest under the pains and penalties of perjury that, to the best of my knowledge and belief and based upon my personal inquiry of those responsible for providing the information contained in this analytical report, such information is accurate and complete. This certificate of analysis is not complete unless this page accompanies any and all pages of this report.

Authorized Signature: Christopher J. Anderson

Title: Technical Director/Representative Date: 04/14/23

AIR

Project Name: 100 MAIN ST
Project Number: 12461:1

Lab Number: L2318681
Report Date: 04/14/23

SAMPLE RESULTS

Lab ID: L2318681-01
Client ID: IA-9
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 11:25
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Air
Anaytical Method: 48,TO-15
Analytical Date: 04/13/23 21:21
Analyst: RAY

	ppbV			ug/m3				
Parameter	**Results**	**RL**	**MDL**	**Results**	**RL**	**MDL**	**Qualifier**	**Dilution Factor**
Volatile Organics in Air - Mansfield Lab								
Dichlorodifluoromethane	0.548	0.200	--	2.71	0.989	--		1
Chloromethane	0.519	0.200	--	1.07	0.413	--		1
Freon-114	ND	0.200	--	ND	1.40	--		1
1,3-Butadiene	0.661	0.200	--	1.46	0.442	--		1
Bromomethane	ND	0.200	--	ND	0.777	--		1
Chloroethane	ND	0.200	--	ND	0.528	--		1
Ethanol	11.9	5.00	--	22.4	9.42	--		1
Vinyl bromide	ND	0.200	--	ND	0.874	--		1
Acetone	6.23	1.00	--	14.8	2.38	--		1
Trichlorofluoromethane	0.248	0.200	--	1.39	1.12	--		1
Isopropanol	0.854	0.500	--	2.10	1.23	--		1
Tertiary butyl Alcohol	2.11	0.500	--	6.40	1.52	--		1
Methylene chloride	ND	0.500	--	ND	1.74	--		1
3-Chloropropene	ND	0.200	--	ND	0.626	--		1
Carbon disulfide	ND	0.200	--	ND	0.623	--		1
Freon-113	ND	0.200	--	ND	1.53	--		1
trans-1,2-Dichloroethene	ND	0.200	--	ND	0.793	--		1
1,1-Dichloroethane	ND	0.200	--	ND	0.809	--		1
Methyl tert butyl ether	ND	0.200	--	ND	0.721	--		1
2-Butanone	ND	0.500	--	ND	1.47	--		1
Ethyl Acetate	ND	0.500	--	ND	1.80	--		1
Chloroform	ND	0.200	--	ND	0.977	--		1
Tetrahydrofuran	ND	0.500	--	ND	1.47	--		1

Project Name: 100 MAIN ST
Project Number: 12461:1

Lab Number: L2318681
Report Date: 04/14/23

SAMPLE RESULTS

Lab ID: L2318681-01
Client ID: IA-9
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 11:25
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
1,2-Dichloroethane	ND	0.200	--	ND	0.809	--		1
n-Hexane	0.556	0.200	--	1.96	0.705	--		1
Benzene	1.09	0.200	--	3.48	0.639	--		1
Cyclohexane	ND	0.200	--	ND	0.688	--		1
1,2-Dichloropropane	ND	0.200	--	ND	0.924	--		1
Bromodichloromethane	ND	0.200	--	ND	1.34	--		1
1,4-Dioxane	ND	0.200	--	ND	0.721	--		1
2,2,4-Trimethylpentane	0.263	0.200	--	1.23	0.934	--		1
Heptane	0.261	0.200	--	1.07	0.820	--		1
cis-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
4-Methyl-2-pentanone	ND	0.500	--	ND	2.05	--		1
trans-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
1,1,2-Trichloroethane	ND	0.200	--	ND	1.09	--		1
Toluene	1.62	0.200	--	6.10	0.754	--		1
2-Hexanone	ND	0.200	--	ND	0.820	--		1
Dibromochloromethane	ND	0.200	--	ND	1.70	--		1
1,2-Dibromoethane	ND	0.200	--	ND	1.54	--		1
Chlorobenzene	ND	0.200	--	ND	0.921	--		1
Ethylbenzene	0.336	0.200	--	1.46	0.869	--		1
p/m-Xylene	1.21	0.400	--	5.26	1.74	--		1
Bromoform	ND	0.200	--	ND	2.07	--		1
Styrene	ND	0.200	--	ND	0.852	--		1
1,1,2,2-Tetrachloroethane	ND	0.200	--	ND	1.37	--		1
o-Xylene	0.434	0.200	--	1.89	0.869	--		1
4-Ethyltoluene	ND	0.200	--	ND	0.983	--		1
1,3,5-Trimethylbenzene	ND	0.200	--	ND	0.983	--		1

Project Name: 100 MAIN ST
Project Number: 12461:1

Lab Number: L2318681
Report Date: 04/14/23

SAMPLE RESULTS

Lab ID: L2318681-01
Client ID: IA-9
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 11:25
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
1,2,4-Trimethylbenzene	0.295	0.200	--	1.45	0.983	--		1
Benzyl chloride	ND	0.200	--	ND	1.04	--		1
1,3-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,4-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,2-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,2,4-Trichlorobenzene	ND	0.200	--	ND	1.48	--		1
Hexachlorobutadiene	ND	0.200	--	ND	2.13	--		1

Internal Standard	% Recovery	Qualifier	Acceptance Criteria
1,4-Difluorobenzene	99		60-140
Bromochloromethane	99		60-140
chlorobenzene-d5	99		60-140

Project Name: 100 MAIN ST
Project Number: 12461:1

Lab Number: L2318681
Report Date: 04/14/23

SAMPLE RESULTS

Lab ID: L2318681-01
Client ID: IA-9
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 11:25
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Air
Anaytical Method: 48,TO-15-SIM
Analytical Date: 04/13/23 21:21
Analyst: RAY

	ppbV			ug/m3				
Parameter	**Results**	**RL**	**MDL**	**Results**	**RL**	**MDL**	**Qualifier**	**Dilution Factor**
Volatile Organics in Air by SIM - Mansfield Lab								
Vinyl chloride	ND	0.020	--	ND	0.051	--		1
1,1-Dichloroethene	ND	0.020	--	ND	0.079	--		1
cis-1,2-Dichloroethene	ND	0.020	--	ND	0.079	--		1
1,1,1-Trichloroethane	ND	0.020	--	ND	0.109	--		1
Carbon tetrachloride	0.081	0.020	--	0.510	0.126	--		1
Trichloroethene	ND	0.020	--	ND	0.107	--		1
Tetrachloroethene	0.026	0.020	--	0.176	0.136	--		1

Internal Standard	**% Recovery**	**Qualifier**	**Acceptance Criteria**
1,4-difluorobenzene	97		60-140
bromochloromethane	99		60-140
chlorobenzene-d5	102		60-140

Project Name: 100 MAIN ST
Project Number: 12461:1

Lab Number: L2318681
Report Date: 04/14/23

SAMPLE RESULTS

Lab ID: L2318681-02
Client ID: IA-10
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 10:30
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Air
Anaytical Method: 48,TO-15
Analytical Date: 04/13/23 22:01
Analyst: RAY

	ppbV			ug/m3				
Parameter	**Results**	**RL**	**MDL**	**Results**	**RL**	**MDL**	**Qualifier**	**Dilution Factor**
Volatile Organics in Air - Mansfield Lab								
Dichlorodifluoromethane	0.564	0.200	--	2.79	0.989	--		1
Chloromethane	0.524	0.200	--	1.08	0.413	--		1
Freon-114	ND	0.200	--	ND	1.40	--		1
1,3-Butadiene	0.755	0.200	--	1.67	0.442	--		1
Bromomethane	ND	0.200	--	ND	0.777	--		1
Chloroethane	ND	0.200	--	ND	0.528	--		1
Ethanol	5.09	5.00	--	9.59	9.42	--		1
Vinyl bromide	ND	0.200	--	ND	0.874	--		1
Acetone	12.9	1.00	--	30.6	2.38	--		1
Trichlorofluoromethane	0.227	0.200	--	1.28	1.12	--		1
Isopropanol	ND	0.500	--	ND	1.23	--		1
Tertiary butyl Alcohol	ND	0.500	--	ND	1.52	--		1
Methylene chloride	ND	0.500	--	ND	1.74	--		1
3-Chloropropene	ND	0.200	--	ND	0.626	--		1
Carbon disulfide	ND	0.200	--	ND	0.623	--		1
Freon-113	ND	0.200	--	ND	1.53	--		1
trans-1,2-Dichloroethene	ND	0.200	--	ND	0.793	--		1
1,1-Dichloroethane	ND	0.200	--	ND	0.809	--		1
Methyl tert butyl ether	ND	0.200	--	ND	0.721	--		1
2-Butanone	1.04	0.500	--	3.07	1.47	--		1
Ethyl Acetate	ND	0.500	--	ND	1.80	--		1
Chloroform	ND	0.200	--	ND	0.977	--		1
Tetrahydrofuran	ND	0.500	--	ND	1.47	--		1

Project Name: 100 MAIN ST
Project Number: 12461:1

Lab Number: L2318681
Report Date: 04/14/23

SAMPLE RESULTS

Lab ID: L2318681-02
Client ID: IA-10
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 10:30
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
1,2-Dichloroethane	ND	0.200	--	ND	0.809	--		1
n-Hexane	0.644	0.200	--	2.27	0.705	--		1
Benzene	1.27	0.200	--	4.06	0.639	--		1
Cyclohexane	ND	0.200	--	ND	0.688	--		1
1,2-Dichloropropane	ND	0.200	--	ND	0.924	--		1
Bromodichloromethane	ND	0.200	--	ND	1.34	--		1
1,4-Dioxane	ND	0.200	--	ND	0.721	--		1
2,2,4-Trimethylpentane	0.311	0.200	--	1.45	0.934	--		1
Heptane	0.283	0.200	--	1.16	0.820	--		1
cis-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
4-Methyl-2-pentanone	ND	0.500	--	ND	2.05	--		1
trans-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
1,1,2-Trichloroethane	ND	0.200	--	ND	1.09	--		1
Toluene	1.90	0.200	--	7.16	0.754	--		1
2-Hexanone	ND	0.200	--	ND	0.820	--		1
Dibromochloromethane	ND	0.200	--	ND	1.70	--		1
1,2-Dibromoethane	ND	0.200	--	ND	1.54	--		1
Chlorobenzene	ND	0.200	--	ND	0.921	--		1
Ethylbenzene	0.463	0.200	--	2.01	0.869	--		1
p/m-Xylene	1.69	0.400	--	7.34	1.74	--		1
Bromoform	ND	0.200	--	ND	2.07	--		1
Styrene	ND	0.200	--	ND	0.852	--		1
1,1,2,2-Tetrachloroethane	ND	0.200	--	ND	1.37	--		1
o-Xylene	0.558	0.200	--	2.42	0.869	--		1
4-Ethyltoluene	ND	0.200	--	ND	0.983	--		1
1,3,5-Trimethylbenzene	ND	0.200	--	ND	0.983	--		1

Project Name: 100 MAIN ST
Project Number: 12461:1

Lab Number: L2318681
Report Date: 04/14/23

SAMPLE RESULTS

Lab ID: L2318681-02
Client ID: IA-10
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 10:30
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
1,2,4-Trimethylbenzene	0.300	0.200	--	1.47	0.983	--		1
Benzyl chloride	ND	0.200	--	ND	1.04	--		1
1,3-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,4-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,2-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,2,4-Trichlorobenzene	ND	0.200	--	ND	1.48	--		1
Hexachlorobutadiene	ND	0.200	--	ND	2.13	--		1

Internal Standard	% Recovery	Qualifier	Acceptance Criteria
1,4-Difluorobenzene	98		60-140
Bromochloromethane	98		60-140
chlorobenzene-d5	97		60-140

Project Name: 100 MAIN ST
Project Number: 12461:1

Lab Number: L2318681
Report Date: 04/14/23

SAMPLE RESULTS

Lab ID: L2318681-02
Client ID: IA-10
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 10:30
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Air
Anaytical Method: 48,TO-15-SIM
Analytical Date: 04/13/23 22:01
Analyst: RAY

	ppbV			ug/m3				
Parameter	**Results**	**RL**	**MDL**	**Results**	**RL**	**MDL**	**Qualifier**	**Dilution Factor**
Volatile Organics in Air by SIM - Mansfield Lab								
Vinyl chloride	ND	0.020	--	ND	0.051	--		1
1,1-Dichloroethene	ND	0.020	--	ND	0.079	--		1
cis-1,2-Dichloroethene	ND	0.020	--	ND	0.079	--		1
1,1,1-Trichloroethane	ND	0.020	--	ND	0.109	--		1
Carbon tetrachloride	0.083	0.020	--	0.522	0.126	--		1
Trichloroethene	ND	0.020	--	ND	0.107	--		1
Tetrachloroethene	ND	0.020	--	ND	0.136	--		1

Internal Standard	**% Recovery**	**Qualifier**	**Acceptance Criteria**
1,4-difluorobenzene	96		60-140
bromochloromethane	98		60-140
chlorobenzene-d5	100		60-140

Project Name: 100 MAIN ST
Project Number: 12461:1

Lab Number: L2318681
Report Date: 04/14/23

SAMPLE RESULTS

Lab ID: L2318681-03 D
Client ID: SSV-9
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 12:42
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil_Vapor
Anaytical Method: 48,TO-15
Analytical Date: 04/14/23 02:25
Analyst: RAY

	ppbV			ug/m3				
Parameter	**Results**	**RL**	**MDL**	**Results**	**RL**	**MDL**	**Qualifier**	**Dilution Factor**
Volatile Organics in Air - Mansfield Lab								
Dichlorodifluoromethane	ND	2.69	--	ND	13.3	--		13.46
Chloromethane	ND	2.69	--	ND	5.55	--		13.46
Freon-114	ND	2.69	--	ND	18.8	--		13.46
Vinyl chloride	ND	2.69	--	ND	6.88	--		13.46
1,3-Butadiene	17.5	2.69	--	38.7	5.95	--		13.46
Bromomethane	ND	2.69	--	ND	10.4	--		13.46
Chloroethane	5.37	2.69	--	14.2	7.10	--		13.46
Ethanol	518	67.3	--	976	127	--		13.46
Vinyl bromide	ND	2.69	--	ND	11.8	--		13.46
Acetone	1820	13.5	--	4320	32.1	--		13.46
Trichlorofluoromethane	ND	2.69	--	ND	15.1	--		13.46
Isopropanol	91.7	6.73	--	225	16.5	--		13.46
1,1-Dichloroethene	ND	2.69	--	ND	10.7	--		13.46
Tertiary butyl Alcohol	30.4	6.73	--	92.2	20.4	--		13.46
Methylene chloride	ND	6.73	--	ND	23.4	--		13.46
3-Chloropropene	ND	2.69	--	ND	8.42	--		13.46
Carbon disulfide	4.50	2.69	--	14.0	8.38	--		13.46
Freon-113	ND	2.69	--	ND	20.6	--		13.46
trans-1,2-Dichloroethene	ND	2.69	--	ND	10.7	--		13.46
1,1-Dichloroethane	ND	2.69	--	ND	10.9	--		13.46
Methyl tert butyl ether	ND	2.69	--	ND	9.70	--		13.46
2-Butanone	390	6.73	--	1150	19.8	--		13.46
cis-1,2-Dichloroethene	ND	2.69	--	ND	10.7	--		13.46

Project Name: 100 MAIN ST
Project Number: 12461:1

Lab Number: L2318681
Report Date: 04/14/23

SAMPLE RESULTS

Lab ID: L2318681-03 D
Client ID: SSV-9
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 12:42
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
Ethyl Acetate	ND	6.73	--	ND	24.3	--		13.46
Chloroform	6.41	2.69	--	31.3	13.1	--		13.46
Tetrahydrofuran	ND	6.73	--	ND	19.8	--		13.46
1,2-Dichloroethane	ND	2.69	--	ND	10.9	--		13.46
n-Hexane	4.59	2.69	--	16.2	9.48	--		13.46
1,1,1-Trichloroethane	ND	2.69	--	ND	14.7	--		13.46
Benzene	11.6	2.69	--	37.1	8.59	--		13.46
Carbon tetrachloride	ND	2.69	--	ND	16.9	--		13.46
Cyclohexane	ND	2.69	--	ND	9.26	--		13.46
1,2-Dichloropropane	ND	2.69	--	ND	12.4	--		13.46
Bromodichloromethane	ND	2.69	--	ND	18.0	--		13.46
1,4-Dioxane	ND	2.69	--	ND	9.69	--		13.46
Trichloroethene	ND	2.69	--	ND	14.5	--		13.46
2,2,4-Trimethylpentane	ND	2.69	--	ND	12.6	--		13.46
Heptane	3.96	2.69	--	16.2	11.0	--		13.46
cis-1,3-Dichloropropene	ND	2.69	--	ND	12.2	--		13.46
4-Methyl-2-pentanone	ND	6.73	--	ND	27.6	--		13.46
trans-1,3-Dichloropropene	ND	2.69	--	ND	12.2	--		13.46
1,1,2-Trichloroethane	ND	2.69	--	ND	14.7	--		13.46
Toluene	11.5	2.69	--	43.3	10.1	--		13.46
2-Hexanone	ND	2.69	--	ND	11.0	--		13.46
Dibromochloromethane	ND	2.69	--	ND	22.9	--		13.46
1,2-Dibromoethane	ND	2.69	--	ND	20.7	--		13.46
Tetrachloroethene	4.05	2.69	--	27.5	18.2	--		13.46
Chlorobenzene	ND	2.69	--	ND	12.4	--		13.46
Ethylbenzene	204	2.69	--	886	11.7	--		13.46

Project Name: 100 MAIN ST
Project Number: 12461:1

Lab Number: L2318681
Report Date: 04/14/23

SAMPLE RESULTS

Lab ID: L2318681-03 D
Client ID: SSV-9
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 12:42
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
p/m-Xylene	17.8	5.38	--	77.3	23.4	--		13.46
Bromoform	ND	2.69	--	ND	27.8	--		13.46
Styrene	1140	2.69	--	4850	11.5	--		13.46
1,1,2,2-Tetrachloroethane	ND	2.69	--	ND	18.5	--		13.46
o-Xylene	15.3	2.69	--	66.5	11.7	--		13.46
4-Ethyltoluene	4.28	2.69	--	21.0	13.2	--		13.46
1,3,5-Trimethylbenzene	ND	2.69	--	ND	13.2	--		13.46
1,2,4-Trimethylbenzene	3.81	2.69	--	18.7	13.2	--		13.46
Benzyl chloride	ND	2.69	--	ND	13.9	--		13.46
1,3-Dichlorobenzene	ND	2.69	--	ND	16.2	--		13.46
1,4-Dichlorobenzene	ND	2.69	--	ND	16.2	--		13.46
1,2-Dichlorobenzene	ND	2.69	--	ND	16.2	--		13.46
1,2,4-Trichlorobenzene	ND	2.69	--	ND	20.0	--		13.46
Hexachlorobutadiene	ND	2.69	--	ND	28.7	--		13.46

Internal Standard	% Recovery	Qualifier	Acceptance Criteria
1,4-Difluorobenzene	105		60-140
Bromochloromethane	105		60-140
chlorobenzene-d5	108		60-140

Project Name: 100 MAIN ST
Project Number: 12461:1

Lab Number: L2318681
Report Date: 04/14/23

SAMPLE RESULTS

Lab ID: L2318681-04 D
Client ID: SSV-10
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 13:02
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil_Vapor
Anaytical Method: 48,TO-15
Analytical Date: 04/14/23 03:01
Analyst: RAY

	ppbV			ug/m3				
Parameter	**Results**	**RL**	**MDL**	**Results**	**RL**	**MDL**	**Qualifier**	**Dilution Factor**
Volatile Organics in Air - Mansfield Lab								
Dichlorodifluoromethane	84.6	1.11	--	418	5.49	--		5.556
Chloromethane	ND	1.11	--	ND	2.29	--		5.556
Freon-114	ND	1.11	--	ND	7.76	--		5.556
Vinyl chloride	ND	1.11	--	ND	2.84	--		5.556
1,3-Butadiene	41.1	1.11	--	90.9	2.46	--		5.556
Bromomethane	ND	1.11	--	ND	4.31	--		5.556
Chloroethane	ND	1.11	--	ND	2.93	--		5.556
Ethanol	217	27.8	--	409	52.4	--		5.556
Vinyl bromide	ND	1.11	--	ND	4.85	--		5.556
Acetone	1130	5.56	--	2680	13.2	--		5.556
Trichlorofluoromethane	ND	1.11	--	ND	6.24	--		5.556
Isopropanol	24.5	2.78	--	60.2	6.83	--		5.556
1,1-Dichloroethene	ND	1.11	--	ND	4.40	--		5.556
Tertiary butyl Alcohol	22.9	2.78	--	69.4	8.43	--		5.556
Methylene chloride	ND	2.78	--	ND	9.66	--		5.556
3-Chloropropene	ND	1.11	--	ND	3.47	--		5.556
Carbon disulfide	2.16	1.11	--	6.73	3.46	--		5.556
Freon-113	ND	1.11	--	ND	8.51	--		5.556
trans-1,2-Dichloroethene	ND	1.11	--	ND	4.40	--		5.556
1,1-Dichloroethane	ND	1.11	--	ND	4.49	--		5.556
Methyl tert butyl ether	ND	1.11	--	ND	4.00	--		5.556
2-Butanone	128	2.78	--	378	8.20	--		5.556
cis-1,2-Dichloroethene	ND	1.11	--	ND	4.40	--		5.556

Project Name: 100 MAIN ST
Project Number: 12461:1

Lab Number: L2318681
Report Date: 04/14/23

SAMPLE RESULTS

Lab ID: L2318681-04 D
Client ID: SSV-10
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 13:02
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
Ethyl Acetate	7.83	2.78	--	28.2	10.0	--		5.556
Chloroform	ND	1.11	--	ND	5.42	--		5.556
Tetrahydrofuran	ND	2.78	--	ND	8.20	--		5.556
1,2-Dichloroethane	ND	1.11	--	ND	4.49	--		5.556
n-Hexane	1.44	1.11	--	5.08	3.91	--		5.556
1,1,1-Trichloroethane	ND	1.11	--	ND	6.06	--		5.556
Benzene	20.0	1.11	--	63.9	3.55	--		5.556
Carbon tetrachloride	ND	1.11	--	ND	6.98	--		5.556
Cyclohexane	ND	1.11	--	ND	3.82	--		5.556
1,2-Dichloropropane	ND	1.11	--	ND	5.13	--		5.556
Bromodichloromethane	ND	1.11	--	ND	7.44	--		5.556
1,4-Dioxane	ND	1.11	--	ND	4.00	--		5.556
Trichloroethene	ND	1.11	--	ND	5.97	--		5.556
2,2,4-Trimethylpentane	ND	1.11	--	ND	5.18	--		5.556
Heptane	ND	1.11	--	ND	4.55	--		5.556
cis-1,3-Dichloropropene	ND	1.11	--	ND	5.04	--		5.556
4-Methyl-2-pentanone	ND	2.78	--	ND	11.4	--		5.556
trans-1,3-Dichloropropene	ND	1.11	--	ND	5.04	--		5.556
1,1,2-Trichloroethane	ND	1.11	--	ND	6.06	--		5.556
Toluene	28.4	1.11	--	107	4.18	--		5.556
2-Hexanone	ND	1.11	--	ND	4.55	--		5.556
Dibromochloromethane	ND	1.11	--	ND	9.46	--		5.556
1,2-Dibromoethane	ND	1.11	--	ND	8.53	--		5.556
Tetrachloroethene	2.42	1.11	--	16.4	7.53	--		5.556
Chlorobenzene	ND	1.11	--	ND	5.11	--		5.556
Ethylbenzene	56.9	1.11	--	247	4.82	--		5.556

Project Name: 100 MAIN ST
Project Number: 12461:1

Lab Number: L2318681
Report Date: 04/14/23

SAMPLE RESULTS

Lab ID: L2318681-04 D
Client ID: SSV-10
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 13:02
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
p/m-Xylene	30.7	2.22	--	133	9.64	--		5.556
Bromoform	ND	1.11	--	ND	11.5	--		5.556
Styrene	492	1.11	--	2090	4.73	--		5.556
1,1,2,2-Tetrachloroethane	ND	1.11	--	ND	7.62	--		5.556
o-Xylene	6.36	1.11	--	27.6	4.82	--		5.556
4-Ethyltoluene	1.76	1.11	--	8.65	5.46	--		5.556
1,3,5-Trimethylbenzene	ND	1.11	--	ND	5.46	--		5.556
1,2,4-Trimethylbenzene	1.14	1.11	--	5.60	5.46	--		5.556
Benzyl chloride	ND	1.11	--	ND	5.75	--		5.556
1,3-Dichlorobenzene	ND	1.11	--	ND	6.67	--		5.556
1,4-Dichlorobenzene	ND	1.11	--	ND	6.67	--		5.556
1,2-Dichlorobenzene	ND	1.11	--	ND	6.67	--		5.556
1,2,4-Trichlorobenzene	ND	1.11	--	ND	8.24	--		5.556
Hexachlorobutadiene	ND	1.11	--	ND	11.8	--		5.556

Internal Standard	% Recovery	Qualifier	Acceptance Criteria
1,4-Difluorobenzene	102		60-140
Bromochloromethane	101		60-140
chlorobenzene-d5	107		60-140

Project Name: 100 MAIN ST
Project Number: 12461:1
Lab Number: L2318681
Report Date: 04/14/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 48,TO-15
Analytical Date: 04/13/23 17:51

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab for sample(s): 01-04 Batch: WG1766472-4								
Dichlorodifluoromethane	ND	0.200	--	ND	0.989	--		1
Chloromethane	ND	0.200	--	ND	0.413	--		1
Freon-114	ND	0.200	--	ND	1.40	--		1
Vinyl chloride	ND	0.200	--	ND	0.511	--		1
1,3-Butadiene	ND	0.200	--	ND	0.442	--		1
Bromomethane	ND	0.200	--	ND	0.777	--		1
Chloroethane	ND	0.200	--	ND	0.528	--		1
Ethanol	ND	5.00	--	ND	9.42	--		1
Vinyl bromide	ND	0.200	--	ND	0.874	--		1
Acetone	ND	1.00	--	ND	2.38	--		1
Trichlorofluoromethane	ND	0.200	--	ND	1.12	--		1
Isopropanol	ND	0.500	--	ND	1.23	--		1
1,1-Dichloroethene	ND	0.200	--	ND	0.793	--		1
Tertiary butyl Alcohol	ND	0.500	--	ND	1.52	--		1
Methylene chloride	ND	0.500	--	ND	1.74	--		1
3-Chloropropene	ND	0.200	--	ND	0.626	--		1
Carbon disulfide	ND	0.200	--	ND	0.623	--		1
Freon-113	ND	0.200	--	ND	1.53	--		1
trans-1,2-Dichloroethene	ND	0.200	--	ND	0.793	--		1
1,1-Dichloroethane	ND	0.200	--	ND	0.809	--		1
Methyl tert butyl ether	ND	0.200	--	ND	0.721	--		1
2-Butanone	ND	0.500	--	ND	1.47	--		1
cis-1,2-Dichloroethene	ND	0.200	--	ND	0.793	--		1
Ethyl Acetate	ND	0.500	--	ND	1.80	--		1
Chloroform	ND	0.200	--	ND	0.977	--		1

Project Name: 100 MAIN ST
Project Number: 12461:1
Lab Number: L2318681
Report Date: 04/14/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 48,TO-15
Analytical Date: 04/13/23 17:51

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab for sample(s): 01-04 Batch: WG1766472-4								
Tetrahydrofuran	ND	0.500	--	ND	1.47	--		1
1,2-Dichloroethane	ND	0.200	--	ND	0.809	--		1
n-Hexane	ND	0.200	--	ND	0.705	--		1
1,1,1-Trichloroethane	ND	0.200	--	ND	1.09	--		1
Benzene	ND	0.200	--	ND	0.639	--		1
Carbon tetrachloride	ND	0.200	--	ND	1.26	--		1
Cyclohexane	ND	0.200	--	ND	0.688	--		1
1,2-Dichloropropane	ND	0.200	--	ND	0.924	--		1
Bromodichloromethane	ND	0.200	--	ND	1.34	--		1
1,4-Dioxane	ND	0.200	--	ND	0.721	--		1
Trichloroethene	ND	0.200	--	ND	1.07	--		1
2,2,4-Trimethylpentane	ND	0.200	--	ND	0.934	--		1
Heptane	ND	0.200	--	ND	0.820	--		1
cis-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
4-Methyl-2-pentanone	ND	0.500	--	ND	2.05	--		1
trans-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
1,1,2-Trichloroethane	ND	0.200	--	ND	1.09	--		1
Toluene	ND	0.200	--	ND	0.754	--		1
2-Hexanone	ND	0.200	--	ND	0.820	--		1
Dibromochloromethane	ND	0.200	--	ND	1.70	--		1
1,2-Dibromoethane	ND	0.200	--	ND	1.54	--		1
Tetrachloroethene	ND	0.200	--	ND	1.36	--		1
Chlorobenzene	ND	0.200	--	ND	0.921	--		1
Ethylbenzene	ND	0.200	--	ND	0.869	--		1
p/m-Xylene	ND	0.400	--	ND	1.74	--		1

Project Name: 100 MAIN ST
Project Number: 12461:1
Lab Number: L2318681
Report Date: 04/14/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 48,TO-15
Analytical Date: 04/13/23 17:51

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab for sample(s): 01-04 Batch: WG1766472-4								
Bromoform	ND	0.200	--	ND	2.07	--		1
Styrene	ND	0.200	--	ND	0.852	--		1
1,1,2,2-Tetrachloroethane	ND	0.200	--	ND	1.37	--		1
o-Xylene	ND	0.200	--	ND	0.869	--		1
4-Ethyltoluene	ND	0.200	--	ND	0.983	--		1
1,3,5-Trimethylbenzene	ND	0.200	--	ND	0.983	--		1
1,2,4-Trimethylbenzene	ND	0.200	--	ND	0.983	--		1
Benzyl chloride	ND	0.200	--	ND	1.04	--		1
1,3-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,4-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,2-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,2,4-Trichlorobenzene	ND	0.200	--	ND	1.48	--		1
Hexachlorobutadiene	ND	0.200	--	ND	2.13	--		1

Project Name: 100 MAIN ST
Project Number: 12461:1
Lab Number: L2318681
Report Date: 04/14/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 48,TO-15-SIM
Analytical Date: 04/13/23 17:51

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air by SIM - Mansfield Lab for sample(s): 01-02 Batch: WG1766473-4								
Vinyl chloride	ND	0.020	--	ND	0.051	--		1
1,1-Dichloroethene	ND	0.020	--	ND	0.079	--		1
cis-1,2-Dichloroethene	ND	0.020	--	ND	0.079	--		1
1,1,1-Trichloroethane	ND	0.020	--	ND	0.109	--		1
Carbon tetrachloride	ND	0.020	--	ND	0.126	--		1
Trichloroethene	ND	0.020	--	ND	0.107	--		1
Tetrachloroethene	ND	0.020	--	ND	0.136	--		1

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST
Project Number: 12461:1

Lab Number: L2318681
Report Date: 04/14/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics in Air - Mansfield Lab Associated sample(s): 01-04 Batch: WG1766472-3								
Dichlorodifluoromethane	100		-		70-130	-		
Chloromethane	92		-		70-130	-		
Freon-114	99		-		70-130	-		
Vinyl chloride	97		-		70-130	-		
1,3-Butadiene	101		-		70-130	-		
Bromomethane	98		-		70-130	-		
Chloroethane	94		-		70-130	-		
Ethanol	100		-		40-160	-		
Vinyl bromide	94		-		70-130	-		
Acetone	85		-		40-160	-		
Trichlorofluoromethane	106		-		70-130	-		
Isopropanol	98		-		40-160	-		
1,1-Dichloroethene	99		-		70-130	-		
Tertiary butyl Alcohol	107		-		70-130	-		
Methylene chloride	99		-		70-130	-		
3-Chloropropene	99		-		70-130	-		
Carbon disulfide	89		-		70-130	-		
Freon-113	100		-		70-130	-		
trans-1,2-Dichloroethene	93		-		70-130	-		
1,1-Dichloroethane	96		-		70-130	-		
Methyl tert butyl ether	99		-		70-130	-		
2-Butanone	92		-		70-130	-		
cis-1,2-Dichloroethene	98		-		70-130	-		

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST

Project Number: 12461:1

Lab Number: L2318681

Report Date: 04/14/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics in Air - Mansfield Lab Associated sample(s): 01-04 Batch: WG1766472-3								
Ethyl Acetate	99		-		70-130	-		
Chloroform	104		-		70-130	-		
Tetrahydrofuran	92		-		70-130	-		
1,2-Dichloroethane	104		-		70-130	-		
n-Hexane	100		-		70-130	-		
1,1,1-Trichloroethane	102		-		70-130	-		
Benzene	94		-		70-130	-		
Carbon tetrachloride	116		-		70-130	-		
Cyclohexane	100		-		70-130	-		
1,2-Dichloropropane	98		-		70-130	-		
Bromodichloromethane	107		-		70-130	-		
1,4-Dioxane	103		-		70-130	-		
Trichloroethene	104		-		70-130	-		
2,2,4-Trimethylpentane	103		-		70-130	-		
Heptane	100		-		70-130	-		
cis-1,3-Dichloropropene	110		-		70-130	-		
4-Methyl-2-pentanone	107		-		70-130	-		
trans-1,3-Dichloropropene	97		-		70-130	-		
1,1,2-Trichloroethane	106		-		70-130	-		
Toluene	94		-		70-130	-		
2-Hexanone	101		-		70-130	-		
Dibromochloromethane	105		-		70-130	-		
1,2-Dibromoethane	98		-		70-130	-		

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST

Project Number: 12461:1

Lab Number: L2318681

Report Date: 04/14/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics in Air - Mansfield Lab Associated sample(s): 01-04 Batch: WG1766472-3								
Tetrachloroethene	96		-		70-130	-		
Chlorobenzene	98		-		70-130	-		
Ethylbenzene	102		-		70-130	-		
p/m-Xylene	102		-		70-130	-		
Bromoform	110		-		70-130	-		
Styrene	100		-		70-130	-		
1,1,2,2-Tetrachloroethane	100		-		70-130	-		
o-Xylene	105		-		70-130	-		
4-Ethyltoluene	101		-		70-130	-		
1,3,5-Trimethylbenzene	96		-		70-130	-		
1,2,4-Trimethylbenzene	105		-		70-130	-		
Benzyl chloride	118		-		70-130	-		
1,3-Dichlorobenzene	100		-		70-130	-		
1,4-Dichlorobenzene	101		-		70-130	-		
1,2-Dichlorobenzene	98		-		70-130	-		
1,2,4-Trichlorobenzene	96		-		70-130	-		
Hexachlorobutadiene	101		-		70-130	-		

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST

Project Number: 12461:1

Lab Number: L2318681

Report Date: 04/14/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics in Air by SIM - Mansfield Lab Associated sample(s): 01-02 Batch: WG1766473-3								
Vinyl chloride	92		-		70-130	-		25
1,1-Dichloroethene	94		-		70-130	-		25
cis-1,2-Dichloroethene	96		-		70-130	-		25
1,1,1-Trichloroethane	94		-		70-130	-		25
Carbon tetrachloride	102		-		70-130	-		25
Trichloroethene	94		-		70-130	-		25
Tetrachloroethene	95		-		70-130	-		25

Lab Duplicate Analysis
Batch Quality Control

Project Name: 100 MAIN ST
Project Number: 12461:1

Lab Number: L2318681
Report Date: 04/14/23

Parameter	Native Sample	Duplicate Sample	Units	RPD	Qual	RPD Limits
Volatile Organics in Air - Mansfield Lab Associated sample(s): 01-04 QC Batch ID: WG1766472-5 QC Sample: L2318681-02 Client ID: IA-10						
Dichlorodifluoromethane	0.564	0.561	ppbV	1		25
Chloromethane	0.524	0.526	ppbV	0		25
Freon-114	ND	ND	ppbV	NC		25
1,3-Butadiene	0.755	0.761	ppbV	1		25
Bromomethane	ND	ND	ppbV	NC		25
Chloroethane	ND	ND	ppbV	NC		25
Ethanol	5.09	5.03	ppbV	1		25
Vinyl bromide	ND	ND	ppbV	NC		25
Acetone	12.9	12.6	ppbV	2		25
Trichlorofluoromethane	0.227	0.224	ppbV	1		25
Isopropanol	ND	ND	ppbV	NC		25
Tertiary butyl Alcohol	ND	ND	ppbV	NC		25
Methylene chloride	ND	ND	ppbV	NC		25
3-Chloropropene	ND	ND	ppbV	NC		25
Carbon disulfide	ND	ND	ppbV	NC		25
Freon-113	ND	ND	ppbV	NC		25
trans-1,2-Dichloroethene	ND	ND	ppbV	NC		25
1,1-Dichloroethane	ND	ND	ppbV	NC		25
Methyl tert butyl ether	ND	ND	ppbV	NC		25
2-Butanone	1.04	1.04	ppbV	0		25
Ethyl Acetate	ND	ND	ppbV	NC		25

Lab Duplicate Analysis
Batch Quality Control

Project Name: 100 MAIN ST
Project Number: 12461:1

Lab Number: L2318681
Report Date: 04/14/23

Parameter	Native Sample	Duplicate Sample	Units	RPD	Qual	RPD Limits
Volatile Organics in Air - Mansfield Lab Associated sample(s): 01-04 QC Batch ID: WG1766472-5 QC Sample: L2318681-02 Client ID: IA-10						
Chloroform	ND	ND	ppbV	NC		25
Tetrahydrofuran	ND	ND	ppbV	NC		25
1,2-Dichloroethane	ND	ND	ppbV	NC		25
n-Hexane	0.644	0.626	ppbV	3		25
Benzene	1.27	1.25	ppbV	2		25
Cyclohexane	ND	ND	ppbV	NC		25
1,2-Dichloropropane	ND	ND	ppbV	NC		25
Bromodichloromethane	ND	ND	ppbV	NC		25
1,4-Dioxane	ND	ND	ppbV	NC		25
2,2,4-Trimethylpentane	0.311	0.303	ppbV	3		25
Heptane	0.283	0.276	ppbV	3		25
cis-1,3-Dichloropropene	ND	ND	ppbV	NC		25
4-Methyl-2-pentanone	ND	ND	ppbV	NC		25
trans-1,3-Dichloropropene	ND	ND	ppbV	NC		25
1,1,2-Trichloroethane	ND	ND	ppbV	NC		25
Toluene	1.90	1.83	ppbV	4		25
2-Hexanone	ND	ND	ppbV	NC		25
Dibromochloromethane	ND	ND	ppbV	NC		25
1,2-Dibromoethane	ND	ND	ppbV	NC		25
Chlorobenzene	ND	ND	ppbV	NC		25
Ethylbenzene	0.463	0.446	ppbV	4		25

Lab Duplicate Analysis
Batch Quality Control

Project Name: 100 MAIN ST
Project Number: 12461:1

Lab Number: L2318681
Report Date: 04/14/23

Parameter	Native Sample	Duplicate Sample	Units	RPD	Qual	RPD Limits
Volatile Organics in Air - Mansfield Lab Associated sample(s): 01-04 QC Batch ID: WG1766472-5 QC Sample: L2318681-02 Client ID: IA-10						
p/m-Xylene	1.69	1.64	ppbV	3		25
Bromoform	ND	ND	ppbV	NC		25
Styrene	ND	ND	ppbV	NC		25
1,1,2,2-Tetrachloroethane	ND	ND	ppbV	NC		25
o-Xylene	0.558	0.537	ppbV	4		25
4-Ethyltoluene	ND	ND	ppbV	NC		25
1,3,5-Trimethylbenzene	ND	ND	ppbV	NC		25
1,2,4-Trimethylbenzene	0.300	0.295	ppbV	2		25
Benzyl chloride	ND	ND	ppbV	NC		25
1,3-Dichlorobenzene	ND	ND	ppbV	NC		25
1,4-Dichlorobenzene	ND	ND	ppbV	NC		25
1,2-Dichlorobenzene	ND	ND	ppbV	NC		25
1,2,4-Trichlorobenzene	ND	ND	ppbV	NC		25
Hexachlorobutadiene	ND	ND	ppbV	NC		25
Volatile Organics in Air by SIM - Mansfield Lab Associated sample(s): 01-02 QC Batch ID: WG1766473-5 QC Sample: L2318681-02 Client ID: IA-10						
Vinyl chloride	ND	ND	ppbV	NC		25
1,1-Dichloroethene	ND	ND	ppbV	NC		25
cis-1,2-Dichloroethene	ND	ND	ppbV	NC		25
1,1,1-Trichloroethane	ND	ND	ppbV	NC		25
Carbon tetrachloride	0.083	0.076	ppbV	9		25
Trichloroethene	ND	ND	ppbV	NC		25
Tetrachloroethene	ND	ND	ppbV	NC		25

Project Name: 100 MAIN ST

Project Number: 12461:1

Lab Number: L2318681

Report Date: 04/14/23

Canister and Flow Controller Information

Samplenum	Client ID	Media ID	Media Type	Date Prepared	Bottle Order	Cleaning Batch ID	Can Leak Check	Initial Pressure (in. Hg)	Pressure on Receipt (in. Hg)	Flow Controler Leak Chk	Flow Out mL/min	Flow In mL/min	% RPD
L2318681-01	IA-9	0490	Flow 2	04/06/23	419690		-	-	-	Pass	160	45.5	111
L2318681-01	IA-9	594	6.0L Can	04/06/23	419690	L2317106-03	Pass	-30.3	-6.8	-	-	-	-
L2318681-02	IA-10	0481	Flow 1	04/06/23	419690		-	-	-	Pass	160	156	3
L2318681-02	IA-10	2712	6.0L Can	04/06/23	419690	L2316821-10	Pass	-30.3	-4.4	-	-	-	-
L2318681-03	SSV-9	0319	Flow 1	04/06/23	419690		-	-	-	Pass	200	206	3
L2318681-03	SSV-9	3712	2.7L Can	04/06/23	419690	L2316550-05	Pass	-30.3	-1.2	-	-	-	-
L2318681-04	SSV-10	0352	Flow 1	04/06/23	419690		-	-	-	Pass	200	199	1
L2318681-04	SSV-10	491	2.7L Can	04/06/23	419690	L2315828-05	Pass	-30.3	-4.8	-	-	-	-

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT

Lab Number: L2315828
Report Date: 04/14/23

Air Canister Certification Results

Lab ID: L2315828-05
Client ID: CAN 362 SHELF 12
Sample Location:

Date Collected: 03/26/23 09:00
Date Received: 03/27/23
Field Prep: Not Specified

Sample Depth:
Matrix: Air
Anaytical Method: 48,TO-15
Analytical Date: 03/27/23 20:45
Analyst: RAY

	ppbV			ug/m3				
Parameter	**Results**	**RL**	**MDL**	**Results**	**RL**	**MDL**	**Qualifier**	**Dilution Factor**
Volatile Organics in Air - Mansfield Lab								
Chlorodifluoromethane	ND	0.200	--	ND	0.707	--		1
Propylene	ND	0.500	--	ND	0.861	--		1
Propane	ND	0.500	--	ND	0.902	--		1
Dichlorodifluoromethane	ND	0.200	--	ND	0.989	--		1
Chloromethane	ND	0.200	--	ND	0.413	--		1
Freon-114	ND	0.200	--	ND	1.40	--		1
Methanol	ND	5.00	--	ND	6.55	--		1
Vinyl chloride	ND	0.200	--	ND	0.511	--		1
1,3-Butadiene	ND	0.200	--	ND	0.442	--		1
Butane	ND	0.200	--	ND	0.475	--		1
Bromomethane	ND	0.200	--	ND	0.777	--		1
Chloroethane	ND	0.200	--	ND	0.528	--		1
Ethanol	ND	5.00	--	ND	9.42	--		1
Dichlorofluoromethane	ND	0.200	--	ND	0.842	--		1
Vinyl bromide	ND	0.200	--	ND	0.874	--		1
Acrolein	ND	0.500	--	ND	1.15	--		1
Acetone	ND	1.00	--	ND	2.38	--		1
Acetonitrile	ND	0.200	--	ND	0.336	--		1
Trichlorofluoromethane	ND	0.200	--	ND	1.12	--		1
Isopropanol	ND	0.500	--	ND	1.23	--		1
Acrylonitrile	ND	0.500	--	ND	1.09	--		1
Pentane	ND	0.200	--	ND	0.590	--		1
Ethyl ether	ND	0.200	--	ND	0.606	--		1
1,1-Dichloroethene	ND	0.200	--	ND	0.793	--		1

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2315828
Report Date: 04/14/23

Air Canister Certification Results

Lab ID: L2315828-05
Client ID: CAN 362 SHELF 12
Sample Location:

Date Collected: 03/26/23 09:00
Date Received: 03/27/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
Tertiary butyl Alcohol	ND	0.500	--	ND	1.52	--		1
Methylene chloride	ND	0.500	--	ND	1.74	--		1
3-Chloropropene	ND	0.200	--	ND	0.626	--		1
Carbon disulfide	ND	0.200	--	ND	0.623	--		1
Freon-113	ND	0.200	--	ND	1.53	--		1
trans-1,2-Dichloroethene	ND	0.200	--	ND	0.793	--		1
1,1-Dichloroethane	ND	0.200	--	ND	0.809	--		1
Methyl tert butyl ether	ND	0.200	--	ND	0.721	--		1
Vinyl acetate	ND	1.00	--	ND	3.52	--		1
2-Butanone	ND	0.500	--	ND	1.47	--		1
Xylenes, total	ND	0.600	--	ND	0.869	--		1
cis-1,2-Dichloroethene	ND	0.200	--	ND	0.793	--		1
Ethyl Acetate	ND	0.500	--	ND	1.80	--		1
Chloroform	ND	0.200	--	ND	0.977	--		1
Tetrahydrofuran	ND	0.500	--	ND	1.47	--		1
2,2-Dichloropropane	ND	0.200	--	ND	0.924	--		1
1,2-Dichloroethane	ND	0.200	--	ND	0.809	--		1
n-Hexane	ND	0.200	--	ND	0.705	--		1
Diisopropyl ether	ND	0.200	--	ND	0.836	--		1
tert-Butyl Ethyl Ether	ND	0.200	--	ND	0.836	--		1
1,2-Dichloroethene (total)	ND	1.00	--	ND	1.00	--		1
1,1,1-Trichloroethane	ND	0.200	--	ND	1.09	--		1
1,1-Dichloropropene	ND	0.200	--	ND	0.908	--		1
Benzene	ND	0.200	--	ND	0.639	--		1
Carbon tetrachloride	ND	0.200	--	ND	1.26	--		1
Cyclohexane	ND	0.200	--	ND	0.688	--		1
tert-Amyl Methyl Ether	ND	0.200	--	ND	0.836	--		1

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2315828
Report Date: 04/14/23

Air Canister Certification Results

Lab ID: L2315828-05
Client ID: CAN 362 SHELF 12
Sample Location:

Date Collected: 03/26/23 09:00
Date Received: 03/27/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
Dibromomethane	ND	0.200	--	ND	1.42	--		1
1,2-Dichloropropane	ND	0.200	--	ND	0.924	--		1
Bromodichloromethane	ND	0.200	--	ND	1.34	--		1
1,4-Dioxane	ND	0.200	--	ND	0.721	--		1
Trichloroethene	ND	0.200	--	ND	1.07	--		1
2,2,4-Trimethylpentane	ND	0.200	--	ND	0.934	--		1
Methyl Methacrylate	ND	0.500	--	ND	2.05	--		1
Heptane	ND	0.200	--	ND	0.820	--		1
cis-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
4-Methyl-2-pentanone	ND	0.500	--	ND	2.05	--		1
trans-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
1,1,2-Trichloroethane	ND	0.200	--	ND	1.09	--		1
Toluene	ND	0.200	--	ND	0.754	--		1
1,3-Dichloropropane	ND	0.200	--	ND	0.924	--		1
2-Hexanone	ND	0.200	--	ND	0.820	--		1
Dibromochloromethane	ND	0.200	--	ND	1.70	--		1
1,2-Dibromoethane	ND	0.200	--	ND	1.54	--		1
Butyl acetate	ND	0.500	--	ND	2.38	--		1
Octane	ND	0.200	--	ND	0.934	--		1
Tetrachloroethene	ND	0.200	--	ND	1.36	--		1
1,1,1,2-Tetrachloroethane	ND	0.200	--	ND	1.37	--		1
Chlorobenzene	ND	0.200	--	ND	0.921	--		1
Ethylbenzene	ND	0.200	--	ND	0.869	--		1
p/m-Xylene	ND	0.400	--	ND	1.74	--		1
Bromoform	ND	0.200	--	ND	2.07	--		1
Styrene	ND	0.200	--	ND	0.852	--		1
1,1,2,2-Tetrachloroethane	ND	0.200	--	ND	1.37	--		1

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2315828
Report Date: 04/14/23

Air Canister Certification Results

Lab ID: L2315828-05
Client ID: CAN 362 SHELF 12
Sample Location:

Date Collected: 03/26/23 09:00
Date Received: 03/27/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
o-Xylene	ND	0.200	--	ND	0.869	--		1
1,2,3-Trichloropropane	ND	0.200	--	ND	1.21	--		1
Nonane	ND	0.200	--	ND	1.05	--		1
Isopropylbenzene	ND	0.200	--	ND	0.983	--		1
Bromobenzene	ND	0.200	--	ND	0.793	--		1
2-Chlorotoluene	ND	0.200	--	ND	1.04	--		1
n-Propylbenzene	ND	0.200	--	ND	0.983	--		1
4-Chlorotoluene	ND	0.200	--	ND	1.04	--		1
4-Ethyltoluene	ND	0.200	--	ND	0.983	--		1
1,3,5-Trimethylbenzene	ND	0.200	--	ND	0.983	--		1
tert-Butylbenzene	ND	0.200	--	ND	1.10	--		1
1,2,4-Trimethylbenzene	ND	0.200	--	ND	0.983	--		1
Decane	ND	0.200	--	ND	1.16	--		1
Benzyl chloride	ND	0.200	--	ND	1.04	--		1
1,3-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,4-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
sec-Butylbenzene	ND	0.200	--	ND	1.10	--		1
p-Isopropyltoluene	ND	0.200	--	ND	1.10	--		1
1,2-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
n-Butylbenzene	ND	0.200	--	ND	1.10	--		1
1,2-Dibromo-3-chloropropane	ND	0.200	--	ND	1.93	--		1
Undecane	ND	0.200	--	ND	1.28	--		1
Dodecane	ND	0.200	--	ND	1.39	--		1
1,2,4-Trichlorobenzene	ND	0.200	--	ND	1.48	--		1
Naphthalene	ND	0.200	--	ND	1.05	--		1
1,2,3-Trichlorobenzene	ND	0.200	--	ND	1.48	--		1
Hexachlorobutadiene	ND	0.200	--	ND	2.13	--		1

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2315828
Report Date: 04/14/23

Air Canister Certification Results

Lab ID: L2315828-05
Client ID: CAN 362 SHELF 12
Sample Location:

Date Collected: 03/26/23 09:00
Date Received: 03/27/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								

	Results	Qualifier	Units	RDL	Dilution Factor
Tentatively Identified Compounds					

No Tentatively Identified Compounds

Internal Standard	% Recovery	Qualifier	Acceptance Criteria
1,4-Difluorobenzene	92		60-140
Bromochloromethane	97		60-140
chlorobenzene-d5	94		60-140

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2315828
Report Date: 04/14/23

Air Canister Certification Results

Lab ID: L2315828-05
Client ID: CAN 362 SHELF 12
Sample Location:

Date Collected: 03/26/23 09:00
Date Received: 03/27/23
Field Prep: Not Specified

Sample Depth:
Matrix: Air
Anaytical Method: 48,TO-15-SIM
Analytical Date: 03/27/23 20:45
Analyst: RAY

	ppbV			ug/m3				
Parameter	**Results**	**RL**	**MDL**	**Results**	**RL**	**MDL**	**Qualifier**	**Dilution Factor**
Volatile Organics in Air by SIM - Mansfield Lab								
Dichlorodifluoromethane	ND	0.200	--	ND	0.989	--		1
Chloromethane	ND	0.200	--	ND	0.413	--		1
Freon-114	ND	0.050	--	ND	0.349	--		1
Vinyl chloride	ND	0.020	--	ND	0.051	--		1
1,3-Butadiene	ND	0.020	--	ND	0.044	--		1
Bromomethane	ND	0.020	--	ND	0.078	--		1
Chloroethane	ND	0.100	--	ND	0.264	--		1
Acrolein	ND	0.050	--	ND	0.115	--		1
Acetone	ND	1.00	--	ND	2.38	--		1
Trichlorofluoromethane	ND	0.050	--	ND	0.281	--		1
Acrylonitrile	ND	0.500	--	ND	1.09	--		1
1,1-Dichloroethene	ND	0.020	--	ND	0.079	--		1
Methylene chloride	ND	0.500	--	ND	1.74	--		1
Freon-113	ND	0.050	--	ND	0.383	--		1
trans-1,2-Dichloroethene	ND	0.020	--	ND	0.079	--		1
1,1-Dichloroethane	ND	0.020	--	ND	0.081	--		1
Methyl tert butyl ether	ND	0.200	--	ND	0.721	--		1
2-Butanone	ND	0.500	--	ND	1.47	--		1
cis-1,2-Dichloroethene	ND	0.020	--	ND	0.079	--		1
Chloroform	ND	0.020	--	ND	0.098	--		1
1,2-Dichloroethane	ND	0.020	--	ND	0.081	--		1
1,1,1-Trichloroethane	ND	0.020	--	ND	0.109	--		1
Benzene	ND	0.100	--	ND	0.319	--		1
Carbon tetrachloride	ND	0.020	--	ND	0.126	--		1

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2315828
Report Date: 04/14/23

Air Canister Certification Results

Lab ID: L2315828-05
Client ID: CAN 362 SHELF 12
Sample Location:

Date Collected: 03/26/23 09:00
Date Received: 03/27/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air by SIM - Mansfield Lab								
1,2-Dichloropropane	ND	0.020	--	ND	0.092	--		1
Bromodichloromethane	ND	0.020	--	ND	0.134	--		1
1,4-Dioxane	ND	0.100	--	ND	0.360	--		1
Trichloroethene	ND	0.020	--	ND	0.107	--		1
cis-1,3-Dichloropropene	ND	0.020	--	ND	0.091	--		1
4-Methyl-2-pentanone	ND	0.500	--	ND	2.05	--		1
trans-1,3-Dichloropropene	ND	0.020	--	ND	0.091	--		1
1,1,2-Trichloroethane	ND	0.020	--	ND	0.109	--		1
Toluene	ND	0.100	--	ND	0.377	--		1
Dibromochloromethane	ND	0.020	--	ND	0.170	--		1
1,2-Dibromoethane	ND	0.020	--	ND	0.154	--		1
Tetrachloroethene	ND	0.020	--	ND	0.136	--		1
1,1,1,2-Tetrachloroethane	ND	0.020	--	ND	0.137	--		1
Chlorobenzene	ND	0.100	--	ND	0.461	--		1
Ethylbenzene	ND	0.020	--	ND	0.087	--		1
p/m-Xylene	ND	0.040	--	ND	0.174	--		1
Bromoform	ND	0.020	--	ND	0.207	--		1
Styrene	ND	0.020	--	ND	0.085	--		1
1,1,2,2-Tetrachloroethane	ND	0.020	--	ND	0.137	--		1
o-Xylene	ND	0.020	--	ND	0.087	--		1
Isopropylbenzene	ND	0.200	--	ND	0.983	--		1
4-Ethyltoluene	ND	0.020	--	ND	0.098	--		1
1,3,5-Trimethybenzene	ND	0.020	--	ND	0.098	--		1
1,2,4-Trimethylbenzene	ND	0.020	--	ND	0.098	--		1
Benzyl chloride	ND	0.100	--	ND	0.518	--		1
1,3-Dichlorobenzene	ND	0.020	--	ND	0.120	--		1
1,4-Dichlorobenzene	ND	0.020	--	ND	0.120	--		1

Project Name: BATCH CANISTER CERTIFICATION **Lab Number:** L2315828

Project Number: CANISTER QC BAT **Report Date:** 04/14/23

Air Canister Certification Results

Lab ID: L2315828-05
Client ID: CAN 362 SHELF 12
Sample Location:

Date Collected: 03/26/23 09:00
Date Received: 03/27/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air by SIM - Mansfield Lab								
sec-Butylbenzene	ND	0.200	--	ND	1.10	--		1
p-Isopropyltoluene	ND	0.200	--	ND	1.10	--		1
1,2-Dichlorobenzene	ND	0.020	--	ND	0.120	--		1
n-Butylbenzene	ND	0.200	--	ND	1.10	--		1
1,2,4-Trichlorobenzene	ND	0.050	--	ND	0.371	--		1
Naphthalene	ND	0.050	--	ND	0.262	--		1
1,2,3-Trichlorobenzene	ND	0.050	--	ND	0.371	--		1
Hexachlorobutadiene	ND	0.050	--	ND	0.533	--		1

Internal Standard	% Recovery	Qualifier	Acceptance Criteria
1,4-difluorobenzene	94		60-140
bromochloromethane	99		60-140
chlorobenzene-d5	96		60-140

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT

Lab Number: L2316550
Report Date: 04/14/23

Air Canister Certification Results

Lab ID: L2316550-05
Client ID: CAN 533 SHELF 10
Sample Location:

Date Collected: 03/29/23 18:00
Date Received: 03/30/23
Field Prep: Not Specified

Sample Depth:
Matrix: Air
Anaytical Method: 48,TO-15
Analytical Date: 03/30/23 21:55
Analyst: RAY

	ppbV			ug/m3				
Parameter	**Results**	**RL**	**MDL**	**Results**	**RL**	**MDL**	**Qualifier**	**Dilution Factor**
Volatile Organics in Air - Mansfield Lab								
Chlorodifluoromethane	ND	0.200	--	ND	0.707	--		1
Propylene	ND	0.500	--	ND	0.861	--		1
Propane	ND	0.500	--	ND	0.902	--		1
Dichlorodifluoromethane	ND	0.200	--	ND	0.989	--		1
Chloromethane	ND	0.200	--	ND	0.413	--		1
Freon-114	ND	0.200	--	ND	1.40	--		1
Methanol	ND	5.00	--	ND	6.55	--		1
Vinyl chloride	ND	0.200	--	ND	0.511	--		1
1,3-Butadiene	ND	0.200	--	ND	0.442	--		1
Butane	ND	0.200	--	ND	0.475	--		1
Bromomethane	ND	0.200	--	ND	0.777	--		1
Chloroethane	ND	0.200	--	ND	0.528	--		1
Ethanol	ND	5.00	--	ND	9.42	--		1
Dichlorofluoromethane	ND	0.200	--	ND	0.842	--		1
Vinyl bromide	ND	0.200	--	ND	0.874	--		1
Acrolein	ND	0.500	--	ND	1.15	--		1
Acetone	ND	1.00	--	ND	2.38	--		1
Acetonitrile	ND	0.200	--	ND	0.336	--		1
Trichlorofluoromethane	ND	0.200	--	ND	1.12	--		1
Isopropanol	ND	0.500	--	ND	1.23	--		1
Acrylonitrile	ND	0.500	--	ND	1.09	--		1
Pentane	ND	0.200	--	ND	0.590	--		1
Ethyl ether	ND	0.200	--	ND	0.606	--		1
1,1-Dichloroethene	ND	0.200	--	ND	0.793	--		1

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2316550
Report Date: 04/14/23

Air Canister Certification Results

Lab ID: L2316550-05
Client ID: CAN 533 SHELF 10
Sample Location:

Date Collected: 03/29/23 18:00
Date Received: 03/30/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
Tertiary butyl Alcohol	ND	0.500	--	ND	1.52	--		1
Methylene chloride	ND	0.500	--	ND	1.74	--		1
3-Chloropropene	ND	0.200	--	ND	0.626	--		1
Carbon disulfide	ND	0.200	--	ND	0.623	--		1
Freon-113	ND	0.200	--	ND	1.53	--		1
trans-1,2-Dichloroethene	ND	0.200	--	ND	0.793	--		1
1,1-Dichloroethane	ND	0.200	--	ND	0.809	--		1
Methyl tert butyl ether	ND	0.200	--	ND	0.721	--		1
Vinyl acetate	ND	1.00	--	ND	3.52	--		1
Xylenes, total	ND	0.600	--	ND	0.869	--		1
2-Butanone	ND	0.500	--	ND	1.47	--		1
cis-1,2-Dichloroethene	ND	0.200	--	ND	0.793	--		1
Ethyl Acetate	ND	0.500	--	ND	1.80	--		1
Chloroform	ND	0.200	--	ND	0.977	--		1
Tetrahydrofuran	ND	0.500	--	ND	1.47	--		1
2,2-Dichloropropane	ND	0.200	--	ND	0.924	--		1
1,2-Dichloroethane	ND	0.200	--	ND	0.809	--		1
n-Hexane	ND	0.200	--	ND	0.705	--		1
Diisopropyl ether	ND	0.200	--	ND	0.836	--		1
tert-Butyl Ethyl Ether	ND	0.200	--	ND	0.836	--		1
1,2-Dichloroethene (total)	ND	1.00	--	ND	1.00	--		1
1,1,1-Trichloroethane	ND	0.200	--	ND	1.09	--		1
1,1-Dichloropropene	ND	0.200	--	ND	0.908	--		1
Benzene	ND	0.200	--	ND	0.639	--		1
Carbon tetrachloride	ND	0.200	--	ND	1.26	--		1
Cyclohexane	ND	0.200	--	ND	0.688	--		1
tert-Amyl Methyl Ether	ND	0.200	--	ND	0.836	--		1

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2316550
Report Date: 04/14/23

Air Canister Certification Results

Lab ID: L2316550-05
Client ID: CAN 533 SHELF 10
Sample Location:

Date Collected: 03/29/23 18:00
Date Received: 03/30/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
Dibromomethane	ND	0.200	--	ND	1.42	--		1
1,2-Dichloropropane	ND	0.200	--	ND	0.924	--		1
Bromodichloromethane	ND	0.200	--	ND	1.34	--		1
1,4-Dioxane	ND	0.200	--	ND	0.721	--		1
Trichloroethene	ND	0.200	--	ND	1.07	--		1
2,2,4-Trimethylpentane	ND	0.200	--	ND	0.934	--		1
Methyl Methacrylate	ND	0.500	--	ND	2.05	--		1
Heptane	ND	0.200	--	ND	0.820	--		1
cis-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
4-Methyl-2-pentanone	ND	0.500	--	ND	2.05	--		1
trans-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
1,1,2-Trichloroethane	ND	0.200	--	ND	1.09	--		1
Toluene	ND	0.200	--	ND	0.754	--		1
1,3-Dichloropropane	ND	0.200	--	ND	0.924	--		1
2-Hexanone	ND	0.200	--	ND	0.820	--		1
Dibromochloromethane	ND	0.200	--	ND	1.70	--		1
1,2-Dibromoethane	ND	0.200	--	ND	1.54	--		1
Butyl acetate	ND	0.500	--	ND	2.38	--		1
Octane	ND	0.200	--	ND	0.934	--		1
Tetrachloroethene	ND	0.200	--	ND	1.36	--		1
1,1,1,2-Tetrachloroethane	ND	0.200	--	ND	1.37	--		1
Chlorobenzene	ND	0.200	--	ND	0.921	--		1
Ethylbenzene	ND	0.200	--	ND	0.869	--		1
p/m-Xylene	ND	0.400	--	ND	1.74	--		1
Bromoform	ND	0.200	--	ND	2.07	--		1
Styrene	ND	0.200	--	ND	0.852	--		1
1,1,2,2-Tetrachloroethane	ND	0.200	--	ND	1.37	--		1

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2316550
Report Date: 04/14/23

Air Canister Certification Results

Lab ID: L2316550-05
Client ID: CAN 533 SHELF 10
Sample Location:

Date Collected: 03/29/23 18:00
Date Received: 03/30/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
o-Xylene	ND	0.200	--	ND	0.869	--		1
1,2,3-Trichloropropane	ND	0.200	--	ND	1.21	--		1
Nonane	ND	0.200	--	ND	1.05	--		1
Isopropylbenzene	ND	0.200	--	ND	0.983	--		1
Bromobenzene	ND	0.200	--	ND	0.793	--		1
2-Chlorotoluene	ND	0.200	--	ND	1.04	--		1
n-Propylbenzene	ND	0.200	--	ND	0.983	--		1
4-Chlorotoluene	ND	0.200	--	ND	1.04	--		1
4-Ethyltoluene	ND	0.200	--	ND	0.983	--		1
1,3,5-Trimethylbenzene	ND	0.200	--	ND	0.983	--		1
tert-Butylbenzene	ND	0.200	--	ND	1.10	--		1
1,2,4-Trimethylbenzene	ND	0.200	--	ND	0.983	--		1
Decane	ND	0.200	--	ND	1.16	--		1
Benzyl chloride	ND	0.200	--	ND	1.04	--		1
1,3-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,4-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
sec-Butylbenzene	ND	0.200	--	ND	1.10	--		1
p-Isopropyltoluene	ND	0.200	--	ND	1.10	--		1
1,2-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
n-Butylbenzene	ND	0.200	--	ND	1.10	--		1
1,2-Dibromo-3-chloropropane	ND	0.200	--	ND	1.93	--		1
Undecane	ND	0.200	--	ND	1.28	--		1
Dodecane	ND	0.200	--	ND	1.39	--		1
1,2,4-Trichlorobenzene	ND	0.200	--	ND	1.48	--		1
Naphthalene	ND	0.200	--	ND	1.05	--		1
1,2,3-Trichlorobenzene	ND	0.200	--	ND	1.48	--		1
Hexachlorobutadiene	ND	0.200	--	ND	2.13	--		1

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2316550
Report Date: 04/14/23

Air Canister Certification Results

Lab ID: L2316550-05
Client ID: CAN 533 SHELF 10
Sample Location:

Date Collected: 03/29/23 18:00
Date Received: 03/30/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								

	Results	Qualifier	Units	RDL	Dilution Factor
Tentatively Identified Compounds					

No Tentatively Identified Compounds

Internal Standard	% Recovery	Qualifier	Acceptance Criteria
1,4-Difluorobenzene	93		60-140
Bromochloromethane	98		60-140
chlorobenzene-d5	92		60-140

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT

Lab Number: L2316550
Report Date: 04/14/23

Air Canister Certification Results

Lab ID: L2316550-05
Client ID: CAN 533 SHELF 10
Sample Location:

Date Collected: 03/29/23 18:00
Date Received: 03/30/23
Field Prep: Not Specified

Sample Depth:
Matrix: Air
Anaytical Method: 48,TO-15-SIM
Analytical Date: 03/30/23 21:55
Analyst: RAY

	ppbV			ug/m3				
Parameter	**Results**	**RL**	**MDL**	**Results**	**RL**	**MDL**	**Qualifier**	**Dilution Factor**
Volatile Organics in Air by SIM - Mansfield Lab								
Dichlorodifluoromethane	ND	0.200	--	ND	0.989	--		1
Chloromethane	ND	0.200	--	ND	0.413	--		1
Freon-114	ND	0.050	--	ND	0.349	--		1
Vinyl chloride	ND	0.020	--	ND	0.051	--		1
1,3-Butadiene	ND	0.020	--	ND	0.044	--		1
Bromomethane	ND	0.020	--	ND	0.078	--		1
Chloroethane	ND	0.100	--	ND	0.264	--		1
Acrolein	ND	0.050	--	ND	0.115	--		1
Acetone	ND	1.00	--	ND	2.38	--		1
Trichlorofluoromethane	ND	0.050	--	ND	0.281	--		1
Acrylonitrile	ND	0.500	--	ND	1.09	--		1
1,1-Dichloroethene	ND	0.020	--	ND	0.079	--		1
Methylene chloride	ND	0.500	--	ND	1.74	--		1
Freon-113	ND	0.050	--	ND	0.383	--		1
trans-1,2-Dichloroethene	ND	0.020	--	ND	0.079	--		1
1,1-Dichloroethane	ND	0.020	--	ND	0.081	--		1
Methyl tert butyl ether	ND	0.200	--	ND	0.721	--		1
2-Butanone	ND	0.500	--	ND	1.47	--		1
cis-1,2-Dichloroethene	ND	0.020	--	ND	0.079	--		1
Chloroform	ND	0.020	--	ND	0.098	--		1
1,2-Dichloroethane	ND	0.020	--	ND	0.081	--		1
1,1,1-Trichloroethane	ND	0.020	--	ND	0.109	--		1
Benzene	ND	0.100	--	ND	0.319	--		1
Carbon tetrachloride	ND	0.020	--	ND	0.126	--		1

Project Name: BATCH CANISTER CERTIFICATION **Lab Number:** L2316550

Project Number: CANISTER QC BAT **Report Date:** 04/14/23

Air Canister Certification Results

Lab ID: L2316550-05
Client ID: CAN 533 SHELF 10
Sample Location:

Date Collected: 03/29/23 18:00
Date Received: 03/30/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air by SIM - Mansfield Lab								
1,2-Dichloropropane	ND	0.020	--	ND	0.092	--		1
Bromodichloromethane	ND	0.020	--	ND	0.134	--		1
1,4-Dioxane	ND	0.100	--	ND	0.360	--		1
Trichloroethene	ND	0.020	--	ND	0.107	--		1
cis-1,3-Dichloropropene	ND	0.020	--	ND	0.091	--		1
4-Methyl-2-pentanone	ND	0.500	--	ND	2.05	--		1
trans-1,3-Dichloropropene	ND	0.020	--	ND	0.091	--		1
1,1,2-Trichloroethane	ND	0.020	--	ND	0.109	--		1
Toluene	ND	0.100	--	ND	0.377	--		1
Dibromochloromethane	ND	0.020	--	ND	0.170	--		1
1,2-Dibromoethane	ND	0.020	--	ND	0.154	--		1
Tetrachloroethene	ND	0.020	--	ND	0.136	--		1
1,1,1,2-Tetrachloroethane	ND	0.020	--	ND	0.137	--		1
Chlorobenzene	ND	0.100	--	ND	0.461	--		1
Ethylbenzene	ND	0.020	--	ND	0.087	--		1
p/m-Xylene	ND	0.040	--	ND	0.174	--		1
Bromoform	ND	0.020	--	ND	0.207	--		1
Styrene	ND	0.020	--	ND	0.085	--		1
1,1,2,2-Tetrachloroethane	ND	0.020	--	ND	0.137	--		1
o-Xylene	ND	0.020	--	ND	0.087	--		1
Isopropylbenzene	ND	0.200	--	ND	0.983	--		1
4-Ethyltoluene	ND	0.020	--	ND	0.098	--		1
1,3,5-Trimethybenzene	ND	0.020	--	ND	0.098	--		1
1,2,4-Trimethylbenzene	ND	0.020	--	ND	0.098	--		1
Benzyl chloride	ND	0.100	--	ND	0.518	--		1
1,3-Dichlorobenzene	ND	0.020	--	ND	0.120	--		1
1,4-Dichlorobenzene	ND	0.020	--	ND	0.120	--		1

Project Name: BATCH CANISTER CERTIFICATION **Lab Number:** L2316550

Project Number: CANISTER QC BAT **Report Date:** 04/14/23

Air Canister Certification Results

Lab ID: L2316550-05
Client ID: CAN 533 SHELF 10
Sample Location:

Date Collected: 03/29/23 18:00
Date Received: 03/30/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air by SIM - Mansfield Lab								
sec-Butylbenzene	ND	0.200	--	ND	1.10	--		1
p-Isopropyltoluene	ND	0.200	--	ND	1.10	--		1
1,2-Dichlorobenzene	ND	0.020	--	ND	0.120	--		1
n-Butylbenzene	ND	0.200	--	ND	1.10	--		1
1,2,4-Trichlorobenzene	ND	0.050	--	ND	0.371	--		1
Naphthalene	ND	0.050	--	ND	0.262	--		1
1,2,3-Trichlorobenzene	ND	0.050	--	ND	0.371	--		1
Hexachlorobutadiene	ND	0.050	--	ND	0.533	--		1

Internal Standard	% Recovery	Qualifier	Acceptance Criteria
1,4-difluorobenzene	95		60-140
bromochloromethane	100		60-140
chlorobenzene-d5	94		60-140

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT

Lab Number: L2316821
Report Date: 04/14/23

Air Canister Certification Results

Lab ID: L2316821-10
Client ID: CAN 3344 SHELF 42
Sample Location:

Date Collected: 03/31/23 10:00
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Air
Anaytical Method: 48,TO-15
Analytical Date: 04/03/23 03:29
Analyst: NFL

	ppbV			ug/m3				
Parameter	**Results**	**RL**	**MDL**	**Results**	**RL**	**MDL**	**Qualifier**	**Dilution Factor**
Volatile Organics in Air - Mansfield Lab								
Chlorodifluoromethane	ND	0.200	--	ND	0.707	--		1
Propylene	ND	0.500	--	ND	0.861	--		1
Propane	ND	0.500	--	ND	0.902	--		1
Dichlorodifluoromethane	ND	0.200	--	ND	0.989	--		1
Chloromethane	ND	0.200	--	ND	0.413	--		1
Freon-114	ND	0.200	--	ND	1.40	--		1
Methanol	ND	5.00	--	ND	6.55	--		1
Vinyl chloride	ND	0.200	--	ND	0.511	--		1
1,3-Butadiene	ND	0.200	--	ND	0.442	--		1
Butane	ND	0.200	--	ND	0.475	--		1
Bromomethane	ND	0.200	--	ND	0.777	--		1
Chloroethane	ND	0.200	--	ND	0.528	--		1
Ethanol	ND	5.00	--	ND	9.42	--		1
Dichlorofluoromethane	ND	0.200	--	ND	0.842	--		1
Vinyl bromide	ND	0.200	--	ND	0.874	--		1
Acrolein	ND	0.500	--	ND	1.15	--		1
Acetone	ND	1.00	--	ND	2.38	--		1
Acetonitrile	ND	0.200	--	ND	0.336	--		1
Trichlorofluoromethane	ND	0.200	--	ND	1.12	--		1
Isopropanol	ND	0.500	--	ND	1.23	--		1
Acrylonitrile	ND	0.500	--	ND	1.09	--		1
Pentane	ND	0.200	--	ND	0.590	--		1
Ethyl ether	ND	0.200	--	ND	0.606	--		1
1,1-Dichloroethene	ND	0.200	--	ND	0.793	--		1

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2316821
Report Date: 04/14/23

Air Canister Certification Results

Lab ID: L2316821-10
Client ID: CAN 3344 SHELF 42
Sample Location:

Date Collected: 03/31/23 10:00
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
Tertiary butyl Alcohol	ND	0.500	--	ND	1.52	--		1
Methylene chloride	ND	0.500	--	ND	1.74	--		1
3-Chloropropene	ND	0.200	--	ND	0.626	--		1
Carbon disulfide	ND	0.200	--	ND	0.623	--		1
Freon-113	ND	0.200	--	ND	1.53	--		1
trans-1,2-Dichloroethene	ND	0.200	--	ND	0.793	--		1
1,1-Dichloroethane	ND	0.200	--	ND	0.809	--		1
Methyl tert butyl ether	ND	0.200	--	ND	0.721	--		1
Vinyl acetate	ND	1.00	--	ND	3.52	--		1
Xylenes, total	ND	0.600	--	ND	0.869	--		1
2-Butanone	ND	0.500	--	ND	1.47	--		1
cis-1,2-Dichloroethene	ND	0.200	--	ND	0.793	--		1
Ethyl Acetate	ND	0.500	--	ND	1.80	--		1
Chloroform	ND	0.200	--	ND	0.977	--		1
Tetrahydrofuran	ND	0.500	--	ND	1.47	--		1
2,2-Dichloropropane	ND	0.200	--	ND	0.924	--		1
1,2-Dichloroethane	ND	0.200	--	ND	0.809	--		1
n-Hexane	ND	0.200	--	ND	0.705	--		1
Diisopropyl ether	ND	0.200	--	ND	0.836	--		1
tert-Butyl Ethyl Ether	ND	0.200	--	ND	0.836	--		1
1,2-Dichloroethene (total)	ND	1.00	--	ND	1.00	--		1
1,1,1-Trichloroethane	ND	0.200	--	ND	1.09	--		1
1,1-Dichloropropene	ND	0.200	--	ND	0.908	--		1
Benzene	ND	0.200	--	ND	0.639	--		1
Carbon tetrachloride	ND	0.200	--	ND	1.26	--		1
Cyclohexane	ND	0.200	--	ND	0.688	--		1
tert-Amyl Methyl Ether	ND	0.200	--	ND	0.836	--		1

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2316821
Report Date: 04/14/23

Air Canister Certification Results

Lab ID: L2316821-10
Client ID: CAN 3344 SHELF 42
Sample Location:

Date Collected: 03/31/23 10:00
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
Dibromomethane	ND	0.200	--	ND	1.42	--		1
1,2-Dichloropropane	ND	0.200	--	ND	0.924	--		1
Bromodichloromethane	ND	0.200	--	ND	1.34	--		1
1,4-Dioxane	ND	0.200	--	ND	0.721	--		1
Trichloroethene	ND	0.200	--	ND	1.07	--		1
2,2,4-Trimethylpentane	ND	0.200	--	ND	0.934	--		1
Methyl Methacrylate	ND	0.500	--	ND	2.05	--		1
Heptane	ND	0.200	--	ND	0.820	--		1
cis-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
4-Methyl-2-pentanone	ND	0.500	--	ND	2.05	--		1
trans-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
1,1,2-Trichloroethane	ND	0.200	--	ND	1.09	--		1
Toluene	ND	0.200	--	ND	0.754	--		1
1,3-Dichloropropane	ND	0.200	--	ND	0.924	--		1
2-Hexanone	ND	0.200	--	ND	0.820	--		1
Dibromochloromethane	ND	0.200	--	ND	1.70	--		1
1,2-Dibromoethane	ND	0.200	--	ND	1.54	--		1
Butyl acetate	ND	0.500	--	ND	2.38	--		1
Octane	ND	0.200	--	ND	0.934	--		1
Tetrachloroethene	ND	0.200	--	ND	1.36	--		1
1,1,1,2-Tetrachloroethane	ND	0.200	--	ND	1.37	--		1
Chlorobenzene	ND	0.200	--	ND	0.921	--		1
Ethylbenzene	ND	0.200	--	ND	0.869	--		1
p/m-Xylene	ND	0.400	--	ND	1.74	--		1
Bromoform	ND	0.200	--	ND	2.07	--		1
Styrene	ND	0.200	--	ND	0.852	--		1
1,1,2,2-Tetrachloroethane	ND	0.200	--	ND	1.37	--		1

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2316821
Report Date: 04/14/23

Air Canister Certification Results

Lab ID: L2316821-10
Client ID: CAN 3344 SHELF 42
Sample Location:

Date Collected: 03/31/23 10:00
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
o-Xylene	ND	0.200	--	ND	0.869	--		1
1,2,3-Trichloropropane	ND	0.200	--	ND	1.21	--		1
Nonane	ND	0.200	--	ND	1.05	--		1
Isopropylbenzene	ND	0.200	--	ND	0.983	--		1
Bromobenzene	ND	0.200	--	ND	0.793	--		1
2-Chlorotoluene	ND	0.200	--	ND	1.04	--		1
n-Propylbenzene	ND	0.200	--	ND	0.983	--		1
4-Chlorotoluene	ND	0.200	--	ND	1.04	--		1
4-Ethyltoluene	ND	0.200	--	ND	0.983	--		1
1,3,5-Trimethylbenzene	ND	0.200	--	ND	0.983	--		1
tert-Butylbenzene	ND	0.200	--	ND	1.10	--		1
1,2,4-Trimethylbenzene	ND	0.200	--	ND	0.983	--		1
Decane	ND	0.200	--	ND	1.16	--		1
Benzyl chloride	ND	0.200	--	ND	1.04	--		1
1,3-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,4-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
sec-Butylbenzene	ND	0.200	--	ND	1.10	--		1
p-Isopropyltoluene	ND	0.200	--	ND	1.10	--		1
1,2-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
n-Butylbenzene	ND	0.200	--	ND	1.10	--		1
1,2-Dibromo-3-chloropropane	ND	0.200	--	ND	1.93	--		1
Undecane	ND	0.200	--	ND	1.28	--		1
Dodecane	ND	0.200	--	ND	1.39	--		1
1,2,4-Trichlorobenzene	ND	0.200	--	ND	1.48	--		1
Naphthalene	ND	0.200	--	ND	1.05	--		1
1,2,3-Trichlorobenzene	ND	0.200	--	ND	1.48	--		1
Hexachlorobutadiene	ND	0.200	--	ND	2.13	--		1

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2316821
Report Date: 04/14/23

Air Canister Certification Results

Lab ID: L2316821-10
Client ID: CAN 3344 SHELF 42
Sample Location:

Date Collected: 03/31/23 10:00
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								

	Results	Qualifier	Units	RDL	Dilution Factor
Tentatively Identified Compounds					

No Tentatively Identified Compounds

Internal Standard	% Recovery	Qualifier	Acceptance Criteria
1,4-Difluorobenzene	90		60-140
Bromochloromethane	95		60-140
chlorobenzene-d5	88		60-140

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2316821
Report Date: 04/14/23

Air Canister Certification Results

Lab ID: L2316821-10
Client ID: CAN 3344 SHELF 42
Sample Location:

Date Collected: 03/31/23 10:00
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Air
Anaytical Method: 48,TO-15-SIM
Analytical Date: 04/03/23 03:29
Analyst: NFL

	ppbV			ug/m3				
Parameter	**Results**	**RL**	**MDL**	**Results**	**RL**	**MDL**	**Qualifier**	**Dilution Factor**
Volatile Organics in Air by SIM - Mansfield Lab								
Dichlorodifluoromethane	ND	0.200	--	ND	0.989	--		1
Chloromethane	ND	0.200	--	ND	0.413	--		1
Freon-114	ND	0.050	--	ND	0.349	--		1
Vinyl chloride	ND	0.020	--	ND	0.051	--		1
1,3-Butadiene	ND	0.020	--	ND	0.044	--		1
Bromomethane	ND	0.020	--	ND	0.078	--		1
Chloroethane	ND	0.100	--	ND	0.264	--		1
Acrolein	ND	0.050	--	ND	0.115	--		1
Acetone	ND	1.00	--	ND	2.38	--		1
Trichlorofluoromethane	ND	0.050	--	ND	0.281	--		1
Acrylonitrile	ND	0.500	--	ND	1.09	--		1
1,1-Dichloroethene	ND	0.020	--	ND	0.079	--		1
Methylene chloride	ND	0.500	--	ND	1.74	--		1
Freon-113	ND	0.050	--	ND	0.383	--		1
trans-1,2-Dichloroethene	ND	0.020	--	ND	0.079	--		1
1,1-Dichloroethane	ND	0.020	--	ND	0.081	--		1
Methyl tert butyl ether	ND	0.200	--	ND	0.721	--		1
2-Butanone	ND	0.500	--	ND	1.47	--		1
cis-1,2-Dichloroethene	ND	0.020	--	ND	0.079	--		1
Chloroform	ND	0.020	--	ND	0.098	--		1
1,2-Dichloroethane	ND	0.020	--	ND	0.081	--		1
1,1,1-Trichloroethane	ND	0.020	--	ND	0.109	--		1
Benzene	ND	0.100	--	ND	0.319	--		1
Carbon tetrachloride	ND	0.020	--	ND	0.126	--		1

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2316821
Report Date: 04/14/23

Air Canister Certification Results

Lab ID: L2316821-10
Client ID: CAN 3344 SHELF 42
Sample Location:

Date Collected: 03/31/23 10:00
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air by SIM - Mansfield Lab								
1,2-Dichloropropane	ND	0.020	--	ND	0.092	--		1
Bromodichloromethane	ND	0.020	--	ND	0.134	--		1
1,4-Dioxane	ND	0.100	--	ND	0.360	--		1
Trichloroethene	ND	0.020	--	ND	0.107	--		1
cis-1,3-Dichloropropene	ND	0.020	--	ND	0.091	--		1
4-Methyl-2-pentanone	ND	0.500	--	ND	2.05	--		1
trans-1,3-Dichloropropene	ND	0.020	--	ND	0.091	--		1
1,1,2-Trichloroethane	ND	0.020	--	ND	0.109	--		1
Toluene	ND	0.100	--	ND	0.377	--		1
Dibromochloromethane	ND	0.020	--	ND	0.170	--		1
1,2-Dibromoethane	ND	0.020	--	ND	0.154	--		1
Tetrachloroethene	ND	0.020	--	ND	0.136	--		1
1,1,1,2-Tetrachloroethane	ND	0.020	--	ND	0.137	--		1
Chlorobenzene	ND	0.100	--	ND	0.461	--		1
Ethylbenzene	ND	0.020	--	ND	0.087	--		1
p/m-Xylene	ND	0.040	--	ND	0.174	--		1
Bromoform	ND	0.020	--	ND	0.207	--		1
Styrene	ND	0.020	--	ND	0.085	--		1
1,1,2,2-Tetrachloroethane	ND	0.020	--	ND	0.137	--		1
o-Xylene	ND	0.020	--	ND	0.087	--		1
Isopropylbenzene	ND	0.200	--	ND	0.983	--		1
4-Ethyltoluene	ND	0.020	--	ND	0.098	--		1
1,3,5-Trimethybenzene	ND	0.020	--	ND	0.098	--		1
1,2,4-Trimethylbenzene	ND	0.020	--	ND	0.098	--		1
Benzyl chloride	ND	0.100	--	ND	0.518	--		1
1,3-Dichlorobenzene	ND	0.020	--	ND	0.120	--		1
1,4-Dichlorobenzene	ND	0.020	--	ND	0.120	--		1

Project Name: BATCH CANISTER CERTIFICATION **Lab Number:** L2316821

Project Number: CANISTER QC BAT **Report Date:** 04/14/23

Air Canister Certification Results

Lab ID: L2316821-10
Client ID: CAN 3344 SHELF 42
Sample Location:

Date Collected: 03/31/23 10:00
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air by SIM - Mansfield Lab								
sec-Butylbenzene	ND	0.200	--	ND	1.10	--		1
p-Isopropyltoluene	ND	0.200	--	ND	1.10	--		1
1,2-Dichlorobenzene	ND	0.020	--	ND	0.120	--		1
n-Butylbenzene	ND	0.200	--	ND	1.10	--		1
1,2,4-Trichlorobenzene	ND	0.050	--	ND	0.371	--		1
Naphthalene	ND	0.050	--	ND	0.262	--		1
1,2,3-Trichlorobenzene	ND	0.050	--	ND	0.371	--		1
Hexachlorobutadiene	ND	0.050	--	ND	0.533	--		1

Internal Standard	% Recovery	Qualifier	Acceptance Criteria
1,4-difluorobenzene	92		60-140
bromochloromethane	97		60-140
chlorobenzene-d5	90		60-140

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT

Lab Number: L2317106
Report Date: 04/14/23

Air Canister Certification Results

Lab ID: L2317106-03
Client ID: CAN 2106 SHELF 31
Sample Location:

Date Collected: 03/31/23 18:00
Date Received: 04/01/23
Field Prep: Not Specified

Sample Depth:
Matrix: Air
Anaytical Method: 48,TO-15
Analytical Date: 04/02/23 19:42
Analyst: NFL

	ppbV			ug/m3				
Parameter	**Results**	**RL**	**MDL**	**Results**	**RL**	**MDL**	**Qualifier**	**Dilution Factor**
Volatile Organics in Air - Mansfield Lab								
Chlorodifluoromethane	ND	0.200	--	ND	0.707	--		1
Propylene	ND	0.500	--	ND	0.861	--		1
Propane	ND	0.500	--	ND	0.902	--		1
Dichlorodifluoromethane	ND	0.200	--	ND	0.989	--		1
Chloromethane	ND	0.200	--	ND	0.413	--		1
Freon-114	ND	0.200	--	ND	1.40	--		1
Methanol	ND	5.00	--	ND	6.55	--		1
Vinyl chloride	ND	0.200	--	ND	0.511	--		1
1,3-Butadiene	ND	0.200	--	ND	0.442	--		1
Butane	ND	0.200	--	ND	0.475	--		1
Bromomethane	ND	0.200	--	ND	0.777	--		1
Chloroethane	ND	0.200	--	ND	0.528	--		1
Ethanol	ND	5.00	--	ND	9.42	--		1
Dichlorofluoromethane	ND	0.200	--	ND	0.842	--		1
Vinyl bromide	ND	0.200	--	ND	0.874	--		1
Acrolein	ND	0.500	--	ND	1.15	--		1
Acetone	ND	1.00	--	ND	2.38	--		1
Acetonitrile	ND	0.200	--	ND	0.336	--		1
Trichlorofluoromethane	ND	0.200	--	ND	1.12	--		1
Isopropanol	ND	0.500	--	ND	1.23	--		1
Acrylonitrile	ND	0.500	--	ND	1.09	--		1
Pentane	ND	0.200	--	ND	0.590	--		1
Ethyl ether	ND	0.200	--	ND	0.606	--		1
1,1-Dichloroethene	ND	0.200	--	ND	0.793	--		1

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2317106
Report Date: 04/14/23

Air Canister Certification Results

Lab ID: L2317106-03
Client ID: CAN 2106 SHELF 31
Sample Location:

Date Collected: 03/31/23 18:00
Date Received: 04/01/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
Tertiary butyl Alcohol	ND	0.500	--	ND	1.52	--		1
Methylene chloride	ND	0.500	--	ND	1.74	--		1
3-Chloropropene	ND	0.200	--	ND	0.626	--		1
Carbon disulfide	ND	0.200	--	ND	0.623	--		1
Freon-113	ND	0.200	--	ND	1.53	--		1
trans-1,2-Dichloroethene	ND	0.200	--	ND	0.793	--		1
1,1-Dichloroethane	ND	0.200	--	ND	0.809	--		1
Methyl tert butyl ether	ND	0.200	--	ND	0.721	--		1
Vinyl acetate	ND	1.00	--	ND	3.52	--		1
2-Butanone	ND	0.500	--	ND	1.47	--		1
Xylenes, total	ND	0.600	--	ND	0.869	--		1
cis-1,2-Dichloroethene	ND	0.200	--	ND	0.793	--		1
Ethyl Acetate	ND	0.500	--	ND	1.80	--		1
Chloroform	ND	0.200	--	ND	0.977	--		1
Tetrahydrofuran	ND	0.500	--	ND	1.47	--		1
2,2-Dichloropropane	ND	0.200	--	ND	0.924	--		1
1,2-Dichloroethane	ND	0.200	--	ND	0.809	--		1
n-Hexane	ND	0.200	--	ND	0.705	--		1
Diisopropyl ether	ND	0.200	--	ND	0.836	--		1
tert-Butyl Ethyl Ether	ND	0.200	--	ND	0.836	--		1
1,2-Dichloroethene (total)	ND	1.00	--	ND	1.00	--		1
1,1,1-Trichloroethane	ND	0.200	--	ND	1.09	--		1
1,1-Dichloropropene	ND	0.200	--	ND	0.908	--		1
Benzene	ND	0.200	--	ND	0.639	--		1
Carbon tetrachloride	ND	0.200	--	ND	1.26	--		1
Cyclohexane	ND	0.200	--	ND	0.688	--		1
tert-Amyl Methyl Ether	ND	0.200	--	ND	0.836	--		1

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2317106
Report Date: 04/14/23

Air Canister Certification Results

Lab ID: L2317106-03
Client ID: CAN 2106 SHELF 31
Sample Location:

Date Collected: 03/31/23 18:00
Date Received: 04/01/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
Dibromomethane	ND	0.200	--	ND	1.42	--		1
1,2-Dichloropropane	ND	0.200	--	ND	0.924	--		1
Bromodichloromethane	ND	0.200	--	ND	1.34	--		1
1,4-Dioxane	ND	0.200	--	ND	0.721	--		1
Trichloroethene	ND	0.200	--	ND	1.07	--		1
2,2,4-Trimethylpentane	ND	0.200	--	ND	0.934	--		1
Methyl Methacrylate	ND	0.500	--	ND	2.05	--		1
Heptane	ND	0.200	--	ND	0.820	--		1
cis-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
4-Methyl-2-pentanone	ND	0.500	--	ND	2.05	--		1
trans-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
1,1,2-Trichloroethane	ND	0.200	--	ND	1.09	--		1
Toluene	ND	0.200	--	ND	0.754	--		1
1,3-Dichloropropane	ND	0.200	--	ND	0.924	--		1
2-Hexanone	ND	0.200	--	ND	0.820	--		1
Dibromochloromethane	ND	0.200	--	ND	1.70	--		1
1,2-Dibromoethane	ND	0.200	--	ND	1.54	--		1
Butyl acetate	ND	0.500	--	ND	2.38	--		1
Octane	ND	0.200	--	ND	0.934	--		1
Tetrachloroethene	ND	0.200	--	ND	1.36	--		1
1,1,1,2-Tetrachloroethane	ND	0.200	--	ND	1.37	--		1
Chlorobenzene	ND	0.200	--	ND	0.921	--		1
Ethylbenzene	ND	0.200	--	ND	0.869	--		1
p/m-Xylene	ND	0.400	--	ND	1.74	--		1
Bromoform	ND	0.200	--	ND	2.07	--		1
Styrene	ND	0.200	--	ND	0.852	--		1
1,1,2,2-Tetrachloroethane	ND	0.200	--	ND	1.37	--		1

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2317106
Report Date: 04/14/23

Air Canister Certification Results

Lab ID: L2317106-03
Client ID: CAN 2106 SHELF 31
Sample Location:

Date Collected: 03/31/23 18:00
Date Received: 04/01/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
o-Xylene	ND	0.200	--	ND	0.869	--		1
1,2,3-Trichloropropane	ND	0.200	--	ND	1.21	--		1
Nonane	ND	0.200	--	ND	1.05	--		1
Isopropylbenzene	ND	0.200	--	ND	0.983	--		1
Bromobenzene	ND	0.200	--	ND	0.793	--		1
2-Chlorotoluene	ND	0.200	--	ND	1.04	--		1
n-Propylbenzene	ND	0.200	--	ND	0.983	--		1
4-Chlorotoluene	ND	0.200	--	ND	1.04	--		1
4-Ethyltoluene	ND	0.200	--	ND	0.983	--		1
1,3,5-Trimethylbenzene	ND	0.200	--	ND	0.983	--		1
tert-Butylbenzene	ND	0.200	--	ND	1.10	--		1
1,2,4-Trimethylbenzene	ND	0.200	--	ND	0.983	--		1
Decane	ND	0.200	--	ND	1.16	--		1
Benzyl chloride	ND	0.200	--	ND	1.04	--		1
1,3-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,4-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
sec-Butylbenzene	ND	0.200	--	ND	1.10	--		1
p-Isopropyltoluene	ND	0.200	--	ND	1.10	--		1
1,2-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
n-Butylbenzene	ND	0.200	--	ND	1.10	--		1
1,2-Dibromo-3-chloropropane	ND	0.200	--	ND	1.93	--		1
Undecane	ND	0.200	--	ND	1.28	--		1
Dodecane	ND	0.200	--	ND	1.39	--		1
1,2,4-Trichlorobenzene	ND	0.200	--	ND	1.48	--		1
Naphthalene	ND	0.200	--	ND	1.05	--		1
1,2,3-Trichlorobenzene	ND	0.200	--	ND	1.48	--		1
Hexachlorobutadiene	ND	0.200	--	ND	2.13	--		1

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2317106
Report Date: 04/14/23

Air Canister Certification Results

Lab ID: L2317106-03
Client ID: CAN 2106 SHELF 31
Sample Location:

Date Collected: 03/31/23 18:00
Date Received: 04/01/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								

	Results	Qualifier	Units	RDL	Dilution Factor
Tentatively Identified Compounds					

No Tentatively Identified Compounds

Internal Standard	% Recovery	Qualifier	Acceptance Criteria
1,4-Difluorobenzene	91		60-140
Bromochloromethane	96		60-140
chlorobenzene-d5	91		60-140

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2317106
Report Date: 04/14/23

Air Canister Certification Results

Lab ID: L2317106-03
Client ID: CAN 2106 SHELF 31
Sample Location:

Date Collected: 03/31/23 18:00
Date Received: 04/01/23
Field Prep: Not Specified

Sample Depth:
Matrix: Air
Anaytical Method: 48,TO-15-SIM
Analytical Date: 04/02/23 19:42
Analyst: NFL

	ppbV			ug/m3				
Parameter	**Results**	**RL**	**MDL**	**Results**	**RL**	**MDL**	**Qualifier**	**Dilution Factor**
Volatile Organics in Air by SIM - Mansfield Lab								
Dichlorodifluoromethane	ND	0.200	--	ND	0.989	--		1
Chloromethane	ND	0.200	--	ND	0.413	--		1
Freon-114	ND	0.050	--	ND	0.349	--		1
Vinyl chloride	ND	0.020	--	ND	0.051	--		1
1,3-Butadiene	ND	0.020	--	ND	0.044	--		1
Bromomethane	ND	0.020	--	ND	0.078	--		1
Chloroethane	ND	0.100	--	ND	0.264	--		1
Acrolein	ND	0.050	--	ND	0.115	--		1
Acetone	ND	1.00	--	ND	2.38	--		1
Trichlorofluoromethane	ND	0.050	--	ND	0.281	--		1
Acrylonitrile	ND	0.500	--	ND	1.09	--		1
1,1-Dichloroethene	ND	0.020	--	ND	0.079	--		1
Methylene chloride	ND	0.500	--	ND	1.74	--		1
Freon-113	ND	0.050	--	ND	0.383	--		1
trans-1,2-Dichloroethene	ND	0.020	--	ND	0.079	--		1
1,1-Dichloroethane	ND	0.020	--	ND	0.081	--		1
Methyl tert butyl ether	ND	0.200	--	ND	0.721	--		1
2-Butanone	ND	0.500	--	ND	1.47	--		1
cis-1,2-Dichloroethene	ND	0.020	--	ND	0.079	--		1
Chloroform	ND	0.020	--	ND	0.098	--		1
1,2-Dichloroethane	ND	0.020	--	ND	0.081	--		1
1,1,1-Trichloroethane	ND	0.020	--	ND	0.109	--		1
Benzene	ND	0.100	--	ND	0.319	--		1
Carbon tetrachloride	ND	0.020	--	ND	0.126	--		1

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2317106
Report Date: 04/14/23

Air Canister Certification Results

Lab ID: L2317106-03
Client ID: CAN 2106 SHELF 31
Sample Location:

Date Collected: 03/31/23 18:00
Date Received: 04/01/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air by SIM - Mansfield Lab								
1,2-Dichloropropane	ND	0.020	--	ND	0.092	--		1
Bromodichloromethane	ND	0.020	--	ND	0.134	--		1
1,4-Dioxane	ND	0.100	--	ND	0.360	--		1
Trichloroethene	ND	0.020	--	ND	0.107	--		1
cis-1,3-Dichloropropene	ND	0.020	--	ND	0.091	--		1
4-Methyl-2-pentanone	ND	0.500	--	ND	2.05	--		1
trans-1,3-Dichloropropene	ND	0.020	--	ND	0.091	--		1
1,1,2-Trichloroethane	ND	0.020	--	ND	0.109	--		1
Toluene	ND	0.100	--	ND	0.377	--		1
Dibromochloromethane	ND	0.020	--	ND	0.170	--		1
1,2-Dibromoethane	ND	0.020	--	ND	0.154	--		1
Tetrachloroethene	ND	0.020	--	ND	0.136	--		1
1,1,1,2-Tetrachloroethane	ND	0.020	--	ND	0.137	--		1
Chlorobenzene	ND	0.100	--	ND	0.461	--		1
Ethylbenzene	ND	0.020	--	ND	0.087	--		1
p/m-Xylene	ND	0.040	--	ND	0.174	--		1
Bromoform	ND	0.020	--	ND	0.207	--		1
Styrene	ND	0.020	--	ND	0.085	--		1
1,1,2,2-Tetrachloroethane	ND	0.020	--	ND	0.137	--		1
o-Xylene	ND	0.020	--	ND	0.087	--		1
Isopropylbenzene	ND	0.200	--	ND	0.983	--		1
4-Ethyltoluene	ND	0.020	--	ND	0.098	--		1
1,3,5-Trimethybenzene	ND	0.020	--	ND	0.098	--		1
1,2,4-Trimethylbenzene	ND	0.020	--	ND	0.098	--		1
Benzyl chloride	ND	0.100	--	ND	0.518	--		1
1,3-Dichlorobenzene	ND	0.020	--	ND	0.120	--		1
1,4-Dichlorobenzene	ND	0.020	--	ND	0.120	--		1

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2317106
Report Date: 04/14/23

Air Canister Certification Results

Lab ID: L2317106-03
Client ID: CAN 2106 SHELF 31
Sample Location:

Date Collected: 03/31/23 18:00
Date Received: 04/01/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air by SIM - Mansfield Lab								
sec-Butylbenzene	ND	0.200	--	ND	1.10	--		1
p-Isopropyltoluene	ND	0.200	--	ND	1.10	--		1
1,2-Dichlorobenzene	ND	0.020	--	ND	0.120	--		1
n-Butylbenzene	ND	0.200	--	ND	1.10	--		1
1,2,4-Trichlorobenzene	ND	0.050	--	ND	0.371	--		1
Naphthalene	ND	0.050	--	ND	0.262	--		1
1,2,3-Trichlorobenzene	ND	0.050	--	ND	0.371	--		1
Hexachlorobutadiene	ND	0.050	--	ND	0.533	--		1

Internal Standard	% Recovery	Qualifier	Acceptance Criteria
1,4-difluorobenzene	94		60-140
bromochloromethane	99		60-140
chlorobenzene-d5	93		60-140

Project Name: 100 MAIN ST
Project Number: 12461:1

Lab Number: L2318681
Report Date: 04/14/23

Sample Receipt and Container Information

Were project specific reporting limits specified? YES

Cooler Information

Cooler	Custody Seal
NA	Absent

Container Information

Container ID	Container Type	Cooler	Initial pH	Final pH	Temp deg C	Pres	Seal	Frozen Date/Time	Analysis(*)
L2318681-01A	Canister - 6 Liter	NA	NA			Y	Absent		TO15-SIM(30),TO15-LL(30)
L2318681-02A	Canister - 6 Liter	NA	NA			Y	Absent		TO15-LL(30),TO15-SIM(30)
L2318681-03A	Canister - 2.7 Liter	NA	NA			Y	Absent		TO15-LL(30)
L2318681-04A	Canister - 2.7 Liter	NA	NA			Y	Absent		TO15-LL(30)

*Values in parentheses indicate holding time in days

Project Name:	100 MAIN ST	**Lab Number:**	L2318681
Project Number:	12461:1	**Report Date:**	04/14/23

GLOSSARY

Acronyms

DL - Detection Limit: This value represents the level to which target analyte concentrations are reported as estimated values, when those target analyte concentrations are quantified below the limit of quantitation (LOQ). The DL includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.)

EDL - Estimated Detection Limit: This value represents the level to which target analyte concentrations are reported as estimated values, when those target analyte concentrations are quantified below the reporting limit (RL). The EDL includes any adjustments from dilutions, concentrations or moisture content, where applicable. The use of EDLs is specific to the analysis of PAHs using Solid-Phase Microextraction (SPME).

EMPC - Estimated Maximum Possible Concentration: The concentration that results from the signal present at the retention time of an analyte when the ions meet all of the identification criteria except the ion abundance ratio criteria. An EMPC is a worst-case estimate of the concentration.

EPA - Environmental Protection Agency.

LCS - Laboratory Control Sample: A sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes or a material containing known and verified amounts of analytes.

LCSD - Laboratory Control Sample Duplicate: Refer to LCS.

LFB - Laboratory Fortified Blank: A sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes or a material containing known and verified amounts of analytes.

LOD - Limit of Detection: This value represents the level to which a target analyte can reliably be detected for a specific analyte in a specific matrix by a specific method. The LOD includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.)

LOQ - Limit of Quantitation: The value at which an instrument can accurately measure an analyte at a specific concentration. The LOQ includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.)

Limit of Quantitation: The value at which an instrument can accurately measure an analyte at a specific concentration. The LOQ includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.)

MDL - Method Detection Limit: This value represents the level to which target analyte concentrations are reported as estimated values, when those target analyte concentrations are quantified below the reporting limit (RL). The MDL includes any adjustments from dilutions, concentrations or moisture content, where applicable.

MS - Matrix Spike Sample: A sample prepared by adding a known mass of target analyte to a specified amount of matrix sample for which an independent estimate of target analyte concentration is available. For Method 332.0, the spike recovery is calculated using the native concentration, including estimated values.

MSD - Matrix Spike Sample Duplicate: Refer to MS.

NA - Not Applicable.

NC - Not Calculated: Term is utilized when one or more of the results utilized in the calculation are non-detect at the parameter's reporting unit.

NDPA/DPA - N-Nitrosodiphenylamine/Diphenylamine.

NI - Not Ignitable.

NP - Non-Plastic: Term is utilized for the analysis of Atterberg Limits in soil.

NR - No Results: Term is utilized when 'No Target Compounds Requested' is reported for the analysis of Volatile or Semivolatile Organic TIC only requests.

RL - Reporting Limit: The value at which an instrument can accurately measure an analyte at a specific concentration. The RL includes any adjustments from dilutions, concentrations or moisture content, where applicable.

RPD - Relative Percent Difference: The results from matrix and/or matrix spike duplicates are primarily designed to assess the precision of analytical results in a given matrix and are expressed as relative percent difference (RPD). Values which are less than five times the reporting limit for any individual parameter are evaluated by utilizing the absolute difference between the values; although the RPD value will be provided in the report.

SRM - Standard Reference Material: A reference sample of a known or certified value that is of the same or similar matrix as the associated field samples.

STLP - Semi-dynamic Tank Leaching Procedure per EPA Method 1315.

TEF - Toxic Equivalency Factors: The values assigned to each dioxin and furan to evaluate their toxicity relative to 2,3,7,8-TCDD.

TEQ - Toxic Equivalent: The measure of a sample's toxicity derived by multiplying each dioxin and furan by its corresponding TEF and then summing the resulting values.

TIC - Tentatively Identified Compound: A compound that has been identified to be present and is not part of the target compound list (TCL) for the method and/or program. All TICs are qualitatively identified and reported as estimated concentrations.

Report Format: Data Usability Report

Project Name:	100 MAIN ST	**Lab Number:**	L2318681
Project Number:	12461:1	**Report Date:**	04/14/23

Footnotes

1 - The reference for this analyte should be considered modified since this analyte is absent from the target analyte list of the original method.

Terms

Analytical Method: Both the document from which the method originates and the analytical reference method. (Example: EPA 8260B is shown as 1,8260B.) The codes for the reference method documents are provided in the References section of the Addendum.

Chlordane: The target compound Chlordane (CAS No. 57-74-9) is reported for GC ECD analyses. Per EPA,this compound "refers to a mixture of chlordane isomers, other chlorinated hydrocarbons and numerous other components." (Reference: USEPA Toxicological Review of Chlordane, In Support of Summary Information on the Integrated Risk Information System (IRIS), December 1997.)

Difference: With respect to Total Oxidizable Precursor (TOP) Assay analysis, the difference is defined as the Post-Treatment value minus the Pre-Treatment value.

Final pH: As it pertains to Sample Receipt & Container Information section of the report, Final pH reflects pH of container determined after adjustment at the laboratory, if applicable. If no adjustment required, value reflects Initial pH.

Frozen Date/Time: With respect to Volatile Organics in soil, Frozen Date/Time reflects the date/time at which associated Reagent Water-preserved vials were initially frozen. Note: If frozen date/time is beyond 48 hours from sample collection, value will be reflected in 'bold'.

Gasoline Range Organics (GRO): Gasoline Range Organics (GRO) results include all chromatographic peaks eluting from Methyl tert butyl ether through Naphthalene, with the exception of GRO analysis in support of State of Ohio programs, which includes all chromatographic peaks eluting from Hexane through Dodecane.

Initial pH: As it pertains to Sample Receipt & Container Information section of the report, Initial pH reflects pH of container determined upon receipt, if applicable.

PAH Total: With respect to Alkylated PAH analyses, the 'PAHs, Total' result is defined as the summation of results for all or a subset of the following compounds: Naphthalene, C1-C4 Naphthalenes, 2-Methylnaphthalene, 1-Methylnaphthalene, Biphenyl, Acenaphthylene, Acenaphthene, Fluorene, C1-C3 Fluorenes, Phenanthrene, C1-C4 Phenanthrenes/Anthracenes, Anthracene, Fluoranthene, Pyrene, C1-C4 Fluoranthenes/Pyrenes, Benz(a)anthracene, Chrysene, C1-C4 Chrysenes, Benzo(b)fluoranthene, Benzo(j)+(k)fluoranthene, Benzo(e)pyrene, Benzo(a)pyrene, Perylene, Indeno(1,2,3-cd)pyrene, Dibenz(ah)+(ac)anthracene, Benzo(g,h,i)perylene. If a 'Total' result is requested, the results of its individual components will also be reported.

PFAS Total: With respect to PFAS analyses, the 'PFAS, Total (5)' result is defined as the summation of results for: PFHpA, PFHxS, PFOA, PFNA and PFOS. In addition, the 'PFAS, Total (6)' result is defined as the summation of results for: PFHpA, PFHxS, PFOA, PFNA, PFDA and PFOS. For MassDEP DW compliance analysis only, the 'PFAS, Total (6)' result is defined as the summation of results at or above the RL. Note: If a 'Total' result is requested, the results of its individual components will also be reported.

Total: With respect to Organic analyses, a 'Total' result is defined as the summation of results for individual isomers or Aroclors. If a 'Total' result is requested, the results of its individual components will also be reported. This is applicable to 'Total' results for methods 8260, 8081 and 8082.

Data Qualifiers

A - Spectra identified as "Aldol Condensates" are byproducts of the extraction/concentration procedures when acetone is introduced in the process.

B - The analyte was detected above the reporting limit in the associated method blank. Flag only applies to associated field samples that have detectable concentrations of the analyte at less than ten times (10x) the concentration found in the blank. For MCP-related projects, flag only applies to associated field samples that have detectable concentrations of the analyte at less than ten times (10x) the concentration found in the blank. For DOD-related projects, flag only applies to associated field samples that have detectable concentrations of the analyte at less than ten times (10x) the concentration found in the blank AND the analyte was detected above one-half the reporting limit (or above the reporting limit for common lab contaminants) in the associated method blank. For NJ-Air-related projects, flag only applies to associated field samples that have detectable concentrations of the analyte above the reporting limit. For NJ-related projects (excluding Air), flag only applies to associated field samples that have detectable concentrations of the analyte, which was detected above the reporting limit in the associated method blank or above five times the reporting limit for common lab contaminants (Phthalates, Acetone, Methylene Chloride, 2-Butanone).

C - Co-elution: The target analyte co-elutes with a known lab standard (i.e. surrogate, internal standards, etc.) for co-extracted analyses.

D - Concentration of analyte was quantified from diluted analysis. Flag only applies to field samples that have detectable concentrations of the analyte.

E - Concentration of analyte exceeds the range of the calibration curve and/or linear range of the instrument.

F - The ratio of quantifier ion response to qualifier ion response falls outside of the laboratory criteria. Results are considered to be an estimated maximum concentration.

G - The concentration may be biased high due to matrix interferences (i.e, co-elution) with non-target compound(s). The result should be considered estimated.

H - The analysis of pH was performed beyond the regulatory-required holding time of 15 minutes from the time of sample collection.

I - The lower value for the two columns has been reported due to obvious interference.

J - Estimated value. This represents an estimated concentration for Tentatively Identified Compounds (TICs).

M - Reporting Limit (RL) exceeds the MCP CAM Reporting Limit for this analyte.

Report Format: Data Usability Report

Project Name:	100 MAIN ST	**Lab Number:**	L2318681
Project Number:	12461:1	**Report Date:**	04/14/23

Data Qualifiers

ND - Not detected at the reporting limit (RL) for the sample.

NJ - Presumptive evidence of compound. This represents an estimated concentration for Tentatively Identified Compounds (TICs), where the identification is based on a mass spectral library search.

P - The RPD between the results for the two columns exceeds the method-specified criteria.

Q - The quality control sample exceeds the associated acceptance criteria. For DOD-related projects, LCS and/or Continuing Calibration Standard exceedences are also qualified on all associated sample results. Note: This flag is not applicable for matrix spike recoveries when the sample concentration is greater than 4x the spike added or for batch duplicate RPD when the sample concentrations are less than 5x the RL. (Metals only.)

R - Analytical results are from sample re-analysis.

RE - Analytical results are from sample re-extraction.

S - Analytical results are from modified screening analysis.

V - The surrogate associated with this target analyte has a recovery outside the QC acceptance limits. (Applicable to MassDEP DW Compliance samples only.)

Z - The batch matrix spike and/or duplicate associated with this target analyte has a recovery/RPD outside the QC acceptance limits. (Applicable to MassDEP DW Compliance samples only.)

Report Format: Data Usability Report

Project Name:	100 MAIN ST	**Lab Number:**	L2318681
Project Number:	12461:1	**Report Date:**	04/14/23

REFERENCES

48 Compendium of Methods for the Determination of Toxic Organic Compounds in Ambient Air. Second Edition. EPA/625/R-96/010b, January 1999.

LIMITATION OF LIABILITIES

Alpha Analytical performs services with reasonable care and diligence normal to the analytical testing laboratory industry. In the event of an error, the sole and exclusive responsibility of Alpha Analytical shall be to re-perform the work at it's own expense. In no event shall Alpha Analytical be held liable for any incidental, consequential or special damages, including but not limited to, damages in any way connected with the use of, interpretation of, information or analysis provided by Alpha Analytical.

We strongly urge our clients to comply with EPA protocol regarding sample volume, preservation, cooling, containers, sampling procedures, holding time and splitting of samples in the field.

Certification Information

The following analytes are not included in our Primary NELAP Scope of Accreditation:

Westborough Facility
EPA 624/624.1: m/p-xylene, o-xylene, Naphthalene
EPA 625/625.1: alpha-Terpineol
EPA 8260C/8260D: NPW: 1,2,4,5-Tetramethylbenzene; 4-Ethyltoluene, Azobenzene; SCM: Iodomethane (methyl iodide), 1,2,4,5-Tetramethylbenzene; 4-Ethyltoluene.
EPA 8270D/8270E: NPW: Dimethylnaphthalene,1,4-Diphenylhydrazine, alpha-Terpineol; SCM: Dimethylnaphthalene,1,4-Diphenylhydrazine.
SM4500: NPW: Amenable Cyanide; SCM: Total Phosphorus, TKN, NO2, NO3.

Mansfield Facility
SM 2540D: TSS
EPA 8082A: NPW: PCB: 1, 5, 31, 87,101, 110, 141, 151, 153, 180, 183, 187.
EPA TO-15: Halothane, 2,4,4-Trimethyl-2-pentene, 2,4,4-Trimethyl-1-pentene, Thiophene, 2-Methylthiophene, 3-Methylthiophene, 2-Ethylthiophene, 1,2,3-Trimethylbenzene, Indan, Indene, 1,2,4,5-Tetramethylbenzene, Benzothiophene, 1-Methylnaphthalene.
Biological Tissue Matrix: EPA 3050B

The following analytes are included in our Massachusetts DEP Scope of Accreditation

Westborough Facility:

Drinking Water
EPA 300.0: Chloride, Nitrate-N, Fluoride, Sulfate; **EPA 353.2**: Nitrate-N, Nitrite-N; **SM4500NO3-F**: Nitrate-N, Nitrite-N; **SM4500F-C, SM4500CN-CE, EPA 180.1, SM2130B, SM4500Cl-D, SM2320B, SM2540C, SM4500H-B, SM4500NO2-B**
EPA 332: Perchlorate; **EPA 524.2:** THMs and VOCs; **EPA 504.1:** EDB, DBCP.
Microbiology: **SM9215B; SM9223-P/A, SM9223B-Colilert-QT,SM9222D**.

Non-Potable Water
SM4500H,B, EPA 120.1, SM2510B, SM2540C, SM2320B, SM4500CL-E, SM4500F-BC, SM4500NH3-BH: Ammonia-N and Kjeldahl-N, **EPA 350.1**: Ammonia-N, **LACHAT 10-107-06-1-B**: Ammonia-N, **EPA 351.1, SM4500NO3-F, EPA 353.2**: Nitrate-N, **SM4500P-E, SM4500P-B, E, SM4500SO4-E, SM5220D, EPA 410.4, SM5210B, SM5310C, SM4500CL-D, EPA 1664, EPA 420.1, SM4500-CN-CE, SM2540D, EPA 300: Chloride, Sulfate, Nitrate.**
EPA 624.1: Volatile Halocarbons & Aromatics,
EPA 608.3: Chlordane, Toxaphene, Aldrin, alpha-BHC, beta-BHC, gamma-BHC, delta-BHC, Dieldrin, DDD, DDE, DDT, Endosulfan I, Endosulfan II, Endosulfan sulfate, Endrin, Endrin Aldehyde, Heptachlor, Heptachlor Epoxide, PCBs
EPA 625.1: SVOC (Acid/Base/Neutral Extractables), **EPA 600/4-81-045**: PCB-Oil.
Microbiology: **SM9223B-Colilert-QT; Enterolert-QT, SM9221E, EPA 1600, EPA 1603, SM9222D.**

Mansfield Facility:

Drinking Water
EPA 200.7: Al, Ba, Cd, Cr, Cu, Fe, Mn, Ni, Na, Ag, Ca, Zn. **EPA 200.8:** Al, Sb, As, Ba, Be, Cd, Cr, Cu, Pb, Mn, Ni, Se, Ag, TL, Zn. **EPA 245.1** Hg.
EPA 522, EPA 537.1.

Non-Potable Water
EPA 200.7: Al, Sb, As, Be, Cd, Ca, Cr, Co, Cu, Fe, Pb, Mg, Mn, Mo, Ni, K, Se, Ag, Na, Sr, TL, Ti, V, Zn.
EPA 200.8: Al, Sb, As, Be, Cd, Cr, Cu, Fe, Pb, Mn, Ni, K, Se, Ag, Na, TL, Zn.
EPA 245.1 Hg.
SM2340B

For a complete listing of analytes and methods, please contact your Alpha Project Manager.

AIR ANALYSIS

PAGE 1 OF 1

CHAIN OF CUSTODY

320 Forbes Blvd, Mansfield, MA 02048
TEL: 508-822-9300 FAX: 508-822-3288

Date Rec'd in Lab: 4/6/23

ALPHA Job #: L2318681

Client Information

Client: SESI
Address: 959 US 46 FI3 S300
Parsippany NJ 07054
Phone: 973 808 9050
Fax:
Email: JCS@sesi.org
☐ These samples have been previously analyzed by Alpha

Project Information

Project Name: 100 Main St
Project Location: White Plains NY
Project #: 12461:1
Project Manager: Jon Stuart
ALPHA Quote #:

Turn-Around Time

☑ Standard ☐ RUSH (only confirmed if pre-approved)
Date Due: Time:

Report Information - Data Deliverables

☐ FAX
☑ ADEx
Criteria Checker:
(Default based on Regulatory Criteria Indicated)
Other Formats:
☐ EMAIL (standard pdf report)
☐ Additional Deliverables:
Report to: (if different than Project Manager)

Billing Information

☐ Same as Client info PO #: 12461
Renaissance Env. Mgmt
Attn: Kevin McNamus

Regulatory Requirements/Report Limits

State/Fed	Program	Res / Comm

Other Project Specific Requirements/Comments:

Project-Specific Target Compound List: ☐

ANALYSIS

All Columns Below Must Be Filled Out

ALPHA Lab ID (Lab Use Only)	Sample ID	COLLECTION End Date	Start Time	End Time	Initial Vacuum	Final Vacuum	Sample Matrix*	Sampler's Initials	Can Size	I D Can	I D - Flow Controller	TO-15	TO-15 SIM	APH Subtract Non-petroleum HC's	Fixed Gases ☐	Sulfides & Mercaptans by TO-15	Sample Comments (i.e. PID)
8681-01	IA-9	4/10/23	955	1125	30.29	8.24	AA	CB	6L	594	490	✓					
-02	IA-10	↓	1000	1030	29.68	5.89	AA	CB	6L	2712	481	✓					
-03	SSV-9		1230	1242	29.51	3.25	SV	CB	2.7L	3712	319	✓					
-04	SSV-10		1250	1302	29.60	5.56	SV	CB	2.7L	491	352	✓					

*SAMPLE MATRIX CODES

AA = Ambient Air (Indoor/Outdoor)
SV = Soil Vapor/Landfill Gas/SVE
Other = Please Specify

Container Type: Summa

Please print clearly, legibly and completely. Samples can not be logged in and turnaround time clock will not start until any ambiguities are resolved. All samples submitted are subject to Alpha's Terms and Conditions. See reverse side.

Relinquished By:	Date/Time	Received By:	Date/Time:
[signature] AAL - 4/7/23	04/10/23 17:50	[signature] AAL - 4/7/23	15:10
Paul Maggella	4/7/23 2355	Paul Maggella	4/7/23 2015
			4/7/23 2355

ANALYTICAL REPORT

Lab Number:	L2316892
Client:	Soils Engineering Services, Inc. 959 Route 46E Parsippany, NJ 07054
ATTN:	Steven Gustems
Phone:	(973) 808-9050
Project Name:	100 MAIN ST.
Project Number:	12461
Report Date:	04/07/23

The original project report/data package is held by Alpha Analytical. This report/data package is paginated and should be reproduced only in its entirety. Alpha Analytical holds no responsibility for results and/or data that are not consistent with the original.

Certifications & Approvals: MA (M-MA030), NH NELAP (2062), CT (PH-0141), DoD (L2474), FL (E87814), IL (200081), LA (85084), ME (MA00030), MD (350), NJ (MA015), NY (11627), NC (685), OH (CL106), PA (68-02089), RI (LAO00299), TX (T104704419), VT (VT-0015), VA (460194), WA (C954), US Army Corps of Engineers, USDA (Permit #P330-17-00150), USFWS (Permit #206964).

320 Forbes Boulevard, Mansfield, MA 02048-1806
508-822-9300 (Fax) 508-822-3288 800-624-9220 - www.alphalab.com

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316892
Report Date: 04/07/23

Alpha Sample ID	Client ID	Matrix	Sample Location	Collection Date/Time	Receive Date
L2316892-01	IA-3	AIR	WHITE PLAINS, NY	03/30/23 13:40	03/31/23
L2316892-02	IA-4	AIR	WHITE PLAINS, NY	03/30/23 14:45	03/31/23
L2316892-03	IA-5	AIR	WHITE PLAINS, NY	03/30/23 14:35	03/31/23
L2316892-04	IA-6	AIR	WHITE PLAINS, NY	03/30/23 15:15	03/31/23
L2316892-05	IA-7	AIR	WHITE PLAINS, NY	03/30/23 15:05	03/31/23
L2316892-06	IA-8	AIR	WHITE PLAINS, NY	03/30/23 14:55	03/31/23
L2316892-07	SSV-3	SOIL_VAPOR	WHITE PLAINS, NY	03/30/23 13:17	03/31/23
L2316892-08	SSV-4	SOIL_VAPOR	WHITE PLAINS, NY	03/30/23 14:25	03/31/23
L2316892-09	SSV-5	SOIL_VAPOR	WHITE PLAINS, NY	03/30/23 14:15	03/31/23
L2316892-10	SSV-6	SOIL_VAPOR	WHITE PLAINS, NY	03/30/23 13:20	03/31/23
L2316892-11	SSV-7	SOIL_VAPOR	WHITE PLAINS, NY	03/30/23 14:43	03/31/23
L2316892-12	SSV-8	SOIL_VAPOR	WHITE PLAINS, NY	03/30/23 14:55	03/31/23

Project Name:	100 MAIN ST.	**Lab Number:**	L2316892
Project Number:	12461	**Report Date:**	04/07/23

Case Narrative

The samples were received in accordance with the Chain of Custody and no significant deviations were encountered during the preparation or analysis unless otherwise noted. Sample Receipt, Container Information, and the Chain of Custody are located at the back of the report.

Results contained within this report relate only to the samples submitted under this Alpha Lab Number and meet NELAP requirements for all NELAP accredited parameters unless otherwise noted in the following narrative. The data presented in this report is organized by parameter (i.e. VOC, SVOC, etc.). Sample specific Quality Control data (i.e. Surrogate Spike Recovery) is reported at the end of the target analyte list for each individual sample, followed by the Laboratory Batch Quality Control at the end of each parameter. Tentatively Identified Compounds (TICs), if requested, are reported for compounds identified to be present and are not part of the method/program Target Compound List, even if only a subset of the TCL are being reported. If a sample was re-analyzed or re-extracted due to a required quality control corrective action and if both sets of data are reported, the Laboratory ID of the re-analysis or re-extraction is designated with an "R" or "RE", respectively.

When multiple Batch Quality Control elements are reported (e.g. more than one LCS), the associated samples for each element are noted in the grey shaded header line of each data table. Any Laboratory Batch, Sample Specific % recovery or RPD value that is outside the listed Acceptance Criteria is bolded in the report. In reference to questions H (CAM) or 4 (RCP) when "NO" is checked, the performance criteria for CAM and RCP methods allow for some quality control failures to occur and still be within method compliance. In these instances, the specific failure is not narrated but noted in the associated QC Outlier Summary Report, located directly after the Case Narrative. QC information is also incorporated in the Data Usability Assessment table (Format 11) of our Data Merger tool, where it can be reviewed in conjunction with the sample result, associated regulatory criteria and any associated data usability implications.

Soil/sediments, solids and tissues are reported on a dry weight basis unless otherwise noted. Definitions of all data qualifiers and acronyms used in this report are provided in the Glossary located at the back of the report.

HOLD POLICY - For samples submitted on hold, Alpha's policy is to hold samples (with the exception of Air canisters) free of charge for 21 calendar days from the date the project is completed. After 21 calendar days, we will dispose of all samples submitted including those put on hold unless you have contacted your Alpha Project Manager and made arrangements for Alpha to continue to hold the samples. Air canisters will be disposed after 3 business days from the date the project is completed.

Please contact Project Management at 800-624-9220 with any questions.

Project Name:	100 MAIN ST.	**Lab Number:**	L2316892
Project Number:	12461	**Report Date:**	04/07/23

Case Narrative (continued)

Volatile Organics in Air

Canisters were released from the laboratory on February 23, 2023. The canister certification results are provided as an addendum.

Sample Receipt

L2316892-10: The canister ID number for the sample is listed on the CoC as 544 but should be 2356.

L2316892-12: The canister ID number for the sample is listed on the CoC as 2356 but should be 2045.

I, the undersigned, attest under the pains and penalties of perjury that, to the best of my knowledge and belief and based upon my personal inquiry of those responsible for providing the information contained in this analytical report, such information is accurate and complete. This certificate of analysis is not complete unless this page accompanies any and all pages of this report.

Authorized Signature: Christopher J. Anderson

Title: Technical Director/Representative Date: 04/07/23

AIR

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316892
Report Date: 04/07/23

SAMPLE RESULTS

Lab ID: L2316892-01
Client ID: IA-3
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 13:40
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Air
Anaytical Method: 48,TO-15
Analytical Date: 04/06/23 22:42
Analyst: RAY

	ppbV			ug/m3				
Parameter	**Results**	**RL**	**MDL**	**Results**	**RL**	**MDL**	**Qualifier**	**Dilution Factor**
Volatile Organics in Air - Mansfield Lab								
Dichlorodifluoromethane	0.565	0.200	--	2.79	0.989	--		1
Chloromethane	0.525	0.200	--	1.08	0.413	--		1
Freon-114	ND	0.200	--	ND	1.40	--		1
1,3-Butadiene	ND	0.200	--	ND	0.442	--		1
Bromomethane	ND	0.200	--	ND	0.777	--		1
Chloroethane	ND	0.200	--	ND	0.528	--		1
Ethanol	ND	5.00	--	ND	9.42	--		1
Vinyl bromide	ND	0.200	--	ND	0.874	--		1
Acetone	2.58	1.00	--	6.13	2.38	--		1
Trichlorofluoromethane	0.267	0.200	--	1.50	1.12	--		1
Isopropanol	ND	0.500	--	ND	1.23	--		1
Tertiary butyl Alcohol	ND	0.500	--	ND	1.52	--		1
Methylene chloride	ND	0.500	--	ND	1.74	--		1
3-Chloropropene	ND	0.200	--	ND	0.626	--		1
Carbon disulfide	ND	0.200	--	ND	0.623	--		1
Freon-113	ND	0.200	--	ND	1.53	--		1
trans-1,2-Dichloroethene	ND	0.200	--	ND	0.793	--		1
1,1-Dichloroethane	ND	0.200	--	ND	0.809	--		1
Methyl tert butyl ether	ND	0.200	--	ND	0.721	--		1
2-Butanone	ND	0.500	--	ND	1.47	--		1
Ethyl Acetate	ND	0.500	--	ND	1.80	--		1
Chloroform	ND	0.200	--	ND	0.977	--		1
Tetrahydrofuran	ND	0.500	--	ND	1.47	--		1

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316892
Report Date: 04/07/23

SAMPLE RESULTS

Lab ID: L2316892-01
Client ID: IA-3
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 13:40
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
1,2-Dichloroethane	ND	0.200	--	ND	0.809	--		1
n-Hexane	0.241	0.200	--	0.849	0.705	--		1
Benzene	0.479	0.200	--	1.53	0.639	--		1
Cyclohexane	ND	0.200	--	ND	0.688	--		1
1,2-Dichloropropane	ND	0.200	--	ND	0.924	--		1
Bromodichloromethane	ND	0.200	--	ND	1.34	--		1
1,4-Dioxane	ND	0.200	--	ND	0.721	--		1
2,2,4-Trimethylpentane	ND	0.200	--	ND	0.934	--		1
Heptane	ND	0.200	--	ND	0.820	--		1
cis-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
4-Methyl-2-pentanone	ND	0.500	--	ND	2.05	--		1
trans-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
1,1,2-Trichloroethane	ND	0.200	--	ND	1.09	--		1
Toluene	0.584	0.200	--	2.20	0.754	--		1
2-Hexanone	ND	0.200	--	ND	0.820	--		1
Dibromochloromethane	ND	0.200	--	ND	1.70	--		1
1,2-Dibromoethane	ND	0.200	--	ND	1.54	--		1
Chlorobenzene	ND	0.200	--	ND	0.921	--		1
Ethylbenzene	ND	0.200	--	ND	0.869	--		1
p/m-Xylene	ND	0.400	--	ND	1.74	--		1
Bromoform	ND	0.200	--	ND	2.07	--		1
Styrene	ND	0.200	--	ND	0.852	--		1
1,1,2,2-Tetrachloroethane	ND	0.200	--	ND	1.37	--		1
o-Xylene	ND	0.200	--	ND	0.869	--		1
4-Ethyltoluene	ND	0.200	--	ND	0.983	--		1
1,3,5-Trimethylbenzene	ND	0.200	--	ND	0.983	--		1

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316892
Report Date: 04/07/23

SAMPLE RESULTS

Lab ID: L2316892-01
Client ID: IA-3
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 13:40
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
1,2,4-Trimethylbenzene	ND	0.200	--	ND	0.983	--		1
Benzyl chloride	ND	0.200	--	ND	1.04	--		1
1,3-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,4-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,2-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,2,4-Trichlorobenzene	ND	0.200	--	ND	1.48	--		1
Hexachlorobutadiene	ND	0.200	--	ND	2.13	--		1

Internal Standard	% Recovery	Qualifier	Acceptance Criteria
1,4-Difluorobenzene	86		60-140
Bromochloromethane	90		60-140
chlorobenzene-d5	83		60-140

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316892
Report Date: 04/07/23

SAMPLE RESULTS

Lab ID: L2316892-01
Client ID: IA-3
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 13:40
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Air
Anaytical Method: 48,TO-15-SIM
Analytical Date: 04/06/23 22:42
Analyst: RAY

	ppbV			ug/m3				
Parameter	**Results**	**RL**	**MDL**	**Results**	**RL**	**MDL**	**Qualifier**	**Dilution Factor**
Volatile Organics in Air by SIM - Mansfield Lab								
Vinyl chloride	ND	0.020	--	ND	0.051	--		1
1,1-Dichloroethene	ND	0.020	--	ND	0.079	--		1
cis-1,2-Dichloroethene	ND	0.020	--	ND	0.079	--		1
1,1,1-Trichloroethane	ND	0.020	--	ND	0.109	--		1
Carbon tetrachloride	0.074	0.020	--	0.465	0.126	--		1
Trichloroethene	ND	0.020	--	ND	0.107	--		1
Tetrachloroethene	ND	0.020	--	ND	0.136	--		1

Internal Standard	**% Recovery**	**Qualifier**	**Acceptance Criteria**
1,4-difluorobenzene	88		60-140
bromochloromethane	89		60-140
chlorobenzene-d5	90		60-140

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316892
Report Date: 04/07/23

SAMPLE RESULTS

Lab ID: L2316892-02
Client ID: IA-4
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 14:45
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Air
Anaytical Method: 48,TO-15
Analytical Date: 04/06/23 18:46
Analyst: RAY

	ppbV			ug/m3				
Parameter	**Results**	**RL**	**MDL**	**Results**	**RL**	**MDL**	**Qualifier**	**Dilution Factor**
Volatile Organics in Air - Mansfield Lab								
Dichlorodifluoromethane	0.564	0.200	--	2.79	0.989	--		1
Chloromethane	0.528	0.200	--	1.09	0.413	--		1
Freon-114	ND	0.200	--	ND	1.40	--		1
1,3-Butadiene	0.408	0.200	--	0.903	0.442	--		1
Bromomethane	ND	0.200	--	ND	0.777	--		1
Chloroethane	ND	0.200	--	ND	0.528	--		1
Ethanol	ND	5.00	--	ND	9.42	--		1
Vinyl bromide	ND	0.200	--	ND	0.874	--		1
Acetone	1.07	1.00	--	2.54	2.38	--		1
Trichlorofluoromethane	0.261	0.200	--	1.47	1.12	--		1
Isopropanol	0.707	0.500	--	1.74	1.23	--		1
Tertiary butyl Alcohol	ND	0.500	--	ND	1.52	--		1
Methylene chloride	ND	0.500	--	ND	1.74	--		1
3-Chloropropene	ND	0.200	--	ND	0.626	--		1
Carbon disulfide	ND	0.200	--	ND	0.623	--		1
Freon-113	ND	0.200	--	ND	1.53	--		1
trans-1,2-Dichloroethene	ND	0.200	--	ND	0.793	--		1
1,1-Dichloroethane	ND	0.200	--	ND	0.809	--		1
Methyl tert butyl ether	ND	0.200	--	ND	0.721	--		1
2-Butanone	ND	0.500	--	ND	1.47	--		1
Ethyl Acetate	ND	0.500	--	ND	1.80	--		1
Chloroform	ND	0.200	--	ND	0.977	--		1
Tetrahydrofuran	ND	0.500	--	ND	1.47	--		1

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316892
Report Date: 04/07/23

SAMPLE RESULTS

Lab ID: L2316892-02
Client ID: IA-4
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 14:45
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
1,2-Dichloroethane	ND	0.200	--	ND	0.809	--		1
n-Hexane	0.634	0.200	--	2.23	0.705	--		1
Benzene	1.05	0.200	--	3.35	0.639	--		1
Cyclohexane	ND	0.200	--	ND	0.688	--		1
1,2-Dichloropropane	ND	0.200	--	ND	0.924	--		1
Bromodichloromethane	ND	0.200	--	ND	1.34	--		1
1,4-Dioxane	ND	0.200	--	ND	0.721	--		1
2,2,4-Trimethylpentane	0.350	0.200	--	1.63	0.934	--		1
Heptane	0.288	0.200	--	1.18	0.820	--		1
cis-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
4-Methyl-2-pentanone	ND	0.500	--	ND	2.05	--		1
trans-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
1,1,2-Trichloroethane	ND	0.200	--	ND	1.09	--		1
Toluene	1.40	0.200	--	5.28	0.754	--		1
2-Hexanone	ND	0.200	--	ND	0.820	--		1
Dibromochloromethane	ND	0.200	--	ND	1.70	--		1
1,2-Dibromoethane	ND	0.200	--	ND	1.54	--		1
Chlorobenzene	ND	0.200	--	ND	0.921	--		1
Ethylbenzene	0.251	0.200	--	1.09	0.869	--		1
p/m-Xylene	0.737	0.400	--	3.20	1.74	--		1
Bromoform	ND	0.200	--	ND	2.07	--		1
Styrene	ND	0.200	--	ND	0.852	--		1
1,1,2,2-Tetrachloroethane	ND	0.200	--	ND	1.37	--		1
o-Xylene	0.283	0.200	--	1.23	0.869	--		1
4-Ethyltoluene	ND	0.200	--	ND	0.983	--		1
1,3,5-Trimethylbenzene	ND	0.200	--	ND	0.983	--		1

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316892
Report Date: 04/07/23

SAMPLE RESULTS

Lab ID: L2316892-02
Client ID: IA-4
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 14:45
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
1,2,4-Trimethylbenzene	ND	0.200	--	ND	0.983	--		1
Benzyl chloride	ND	0.200	--	ND	1.04	--		1
1,3-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,4-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,2-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,2,4-Trichlorobenzene	ND	0.200	--	ND	1.48	--		1
Hexachlorobutadiene	ND	0.200	--	ND	2.13	--		1

Internal Standard	% Recovery	Qualifier	Acceptance Criteria
1,4-Difluorobenzene	83		60-140
Bromochloromethane	88		60-140
chlorobenzene-d5	82		60-140

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316892
Report Date: 04/07/23

SAMPLE RESULTS

Lab ID: L2316892-02
Client ID: IA-4
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 14:45
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Air
Anaytical Method: 48,TO-15-SIM
Analytical Date: 04/06/23 18:46
Analyst: RAY

	ppbV			ug/m3				
Parameter	**Results**	**RL**	**MDL**	**Results**	**RL**	**MDL**	**Qualifier**	**Dilution Factor**
Volatile Organics in Air by SIM - Mansfield Lab								
Vinyl chloride	ND	0.020	--	ND	0.051	--		1
1,1-Dichloroethene	ND	0.020	--	ND	0.079	--		1
cis-1,2-Dichloroethene	ND	0.020	--	ND	0.079	--		1
1,1,1-Trichloroethane	ND	0.020	--	ND	0.109	--		1
Carbon tetrachloride	0.079	0.020	--	0.497	0.126	--		1
Trichloroethene	ND	0.020	--	ND	0.107	--		1
Tetrachloroethene	0.024	0.020	--	0.163	0.136	--		1

Internal Standard	**% Recovery**	**Qualifier**	**Acceptance Criteria**
1,4-difluorobenzene	85		60-140
bromochloromethane	88		60-140
chlorobenzene-d5	89		60-140

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316892
Report Date: 04/07/23

SAMPLE RESULTS

Lab ID: L2316892-03
Client ID: IA-5
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 14:35
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Air
Anaytical Method: 48,TO-15
Analytical Date: 04/06/23 19:25
Analyst: RAY

	ppbV			ug/m3				
Parameter	**Results**	**RL**	**MDL**	**Results**	**RL**	**MDL**	**Qualifier**	**Dilution Factor**
Volatile Organics in Air - Mansfield Lab								
Dichlorodifluoromethane	0.587	0.200	--	2.90	0.989	--		1
Chloromethane	0.524	0.200	--	1.08	0.413	--		1
Freon-114	ND	0.200	--	ND	1.40	--		1
1,3-Butadiene	ND	0.200	--	ND	0.442	--		1
Bromomethane	ND	0.200	--	ND	0.777	--		1
Chloroethane	ND	0.200	--	ND	0.528	--		1
Ethanol	ND	5.00	--	ND	9.42	--		1
Vinyl bromide	ND	0.200	--	ND	0.874	--		1
Acetone	5.85	1.00	--	13.9	2.38	--		1
Trichlorofluoromethane	0.260	0.200	--	1.46	1.12	--		1
Isopropanol	0.619	0.500	--	1.52	1.23	--		1
Tertiary butyl Alcohol	ND	0.500	--	ND	1.52	--		1
Methylene chloride	ND	0.500	--	ND	1.74	--		1
3-Chloropropene	ND	0.200	--	ND	0.626	--		1
Carbon disulfide	ND	0.200	--	ND	0.623	--		1
Freon-113	ND	0.200	--	ND	1.53	--		1
trans-1,2-Dichloroethene	ND	0.200	--	ND	0.793	--		1
1,1-Dichloroethane	ND	0.200	--	ND	0.809	--		1
Methyl tert butyl ether	ND	0.200	--	ND	0.721	--		1
2-Butanone	ND	0.500	--	ND	1.47	--		1
Ethyl Acetate	ND	0.500	--	ND	1.80	--		1
Chloroform	ND	0.200	--	ND	0.977	--		1
Tetrahydrofuran	ND	0.500	--	ND	1.47	--		1

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316892
Report Date: 04/07/23

SAMPLE RESULTS

Lab ID: L2316892-03
Client ID: IA-5
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 14:35
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
1,2-Dichloroethane	ND	0.200	--	ND	0.809	--		1
n-Hexane	ND	0.200	--	ND	0.705	--		1
Benzene	0.305	0.200	--	0.974	0.639	--		1
Cyclohexane	ND	0.200	--	ND	0.688	--		1
1,2-Dichloropropane	ND	0.200	--	ND	0.924	--		1
Bromodichloromethane	ND	0.200	--	ND	1.34	--		1
1,4-Dioxane	ND	0.200	--	ND	0.721	--		1
2,2,4-Trimethylpentane	ND	0.200	--	ND	0.934	--		1
Heptane	ND	0.200	--	ND	0.820	--		1
cis-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
4-Methyl-2-pentanone	ND	0.500	--	ND	2.05	--		1
trans-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
1,1,2-Trichloroethane	ND	0.200	--	ND	1.09	--		1
Toluene	0.317	0.200	--	1.19	0.754	--		1
2-Hexanone	ND	0.200	--	ND	0.820	--		1
Dibromochloromethane	ND	0.200	--	ND	1.70	--		1
1,2-Dibromoethane	ND	0.200	--	ND	1.54	--		1
Chlorobenzene	ND	0.200	--	ND	0.921	--		1
Ethylbenzene	ND	0.200	--	ND	0.869	--		1
p/m-Xylene	ND	0.400	--	ND	1.74	--		1
Bromoform	ND	0.200	--	ND	2.07	--		1
Styrene	ND	0.200	--	ND	0.852	--		1
1,1,2,2-Tetrachloroethane	ND	0.200	--	ND	1.37	--		1
o-Xylene	ND	0.200	--	ND	0.869	--		1
4-Ethyltoluene	ND	0.200	--	ND	0.983	--		1
1,3,5-Trimethylbenzene	ND	0.200	--	ND	0.983	--		1

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316892
Report Date: 04/07/23

SAMPLE RESULTS

Lab ID: L2316892-03
Client ID: IA-5
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 14:35
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
1,2,4-Trimethylbenzene	ND	0.200	--	ND	0.983	--		1
Benzyl chloride	ND	0.200	--	ND	1.04	--		1
1,3-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,4-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,2-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,2,4-Trichlorobenzene	ND	0.200	--	ND	1.48	--		1
Hexachlorobutadiene	ND	0.200	--	ND	2.13	--		1

Internal Standard	% Recovery	Qualifier	Acceptance Criteria
1,4-Difluorobenzene	85		60-140
Bromochloromethane	89		60-140
chlorobenzene-d5	82		60-140

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316892
Report Date: 04/07/23

SAMPLE RESULTS

Lab ID: L2316892-03
Client ID: IA-5
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 14:35
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Air
Anaytical Method: 48,TO-15-SIM
Analytical Date: 04/06/23 19:25
Analyst: RAY

	ppbV			ug/m3				
Parameter	**Results**	**RL**	**MDL**	**Results**	**RL**	**MDL**	**Qualifier**	**Dilution Factor**
Volatile Organics in Air by SIM - Mansfield Lab								
Vinyl chloride	ND	0.020	--	ND	0.051	--		1
1,1-Dichloroethene	ND	0.020	--	ND	0.079	--		1
cis-1,2-Dichloroethene	ND	0.020	--	ND	0.079	--		1
1,1,1-Trichloroethane	ND	0.020	--	ND	0.109	--		1
Carbon tetrachloride	0.080	0.020	--	0.503	0.126	--		1
Trichloroethene	ND	0.020	--	ND	0.107	--		1
Tetrachloroethene	ND	0.020	--	ND	0.136	--		1

Internal Standard	**% Recovery**	**Qualifier**	**Acceptance Criteria**
1,4-difluorobenzene	86		60-140
bromochloromethane	89		60-140
chlorobenzene-d5	89		60-140

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316892
Report Date: 04/07/23

SAMPLE RESULTS

Lab ID: L2316892-04
Client ID: IA-6
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 15:15
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Air
Anaytical Method: 48,TO-15
Analytical Date: 04/06/23 20:04
Analyst: RAY

	ppbV			ug/m3				
Parameter	**Results**	**RL**	**MDL**	**Results**	**RL**	**MDL**	**Qualifier**	**Dilution Factor**
Volatile Organics in Air - Mansfield Lab								
Dichlorodifluoromethane	0.561	0.200	--	2.77	0.989	--		1
Chloromethane	0.539	0.200	--	1.11	0.413	--		1
Freon-114	ND	0.200	--	ND	1.40	--		1
1,3-Butadiene	ND	0.200	--	ND	0.442	--		1
Bromomethane	ND	0.200	--	ND	0.777	--		1
Chloroethane	ND	0.200	--	ND	0.528	--		1
Ethanol	ND	5.00	--	ND	9.42	--		1
Vinyl bromide	ND	0.200	--	ND	0.874	--		1
Acetone	2.66	1.00	--	6.32	2.38	--		1
Trichlorofluoromethane	0.253	0.200	--	1.42	1.12	--		1
Isopropanol	ND	0.500	--	ND	1.23	--		1
Tertiary butyl Alcohol	ND	0.500	--	ND	1.52	--		1
Methylene chloride	8.44	0.500	--	29.3	1.74	--		1
3-Chloropropene	ND	0.200	--	ND	0.626	--		1
Carbon disulfide	ND	0.200	--	ND	0.623	--		1
Freon-113	ND	0.200	--	ND	1.53	--		1
trans-1,2-Dichloroethene	ND	0.200	--	ND	0.793	--		1
1,1-Dichloroethane	ND	0.200	--	ND	0.809	--		1
Methyl tert butyl ether	ND	0.200	--	ND	0.721	--		1
2-Butanone	ND	0.500	--	ND	1.47	--		1
Ethyl Acetate	ND	0.500	--	ND	1.80	--		1
Chloroform	ND	0.200	--	ND	0.977	--		1
Tetrahydrofuran	ND	0.500	--	ND	1.47	--		1

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316892
Report Date: 04/07/23

SAMPLE RESULTS

Lab ID: L2316892-04
Client ID: IA-6
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 15:15
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
1,2-Dichloroethane	ND	0.200	--	ND	0.809	--		1
n-Hexane	ND	0.200	--	ND	0.705	--		1
Benzene	0.277	0.200	--	0.885	0.639	--		1
Cyclohexane	ND	0.200	--	ND	0.688	--		1
1,2-Dichloropropane	ND	0.200	--	ND	0.924	--		1
Bromodichloromethane	ND	0.200	--	ND	1.34	--		1
1,4-Dioxane	ND	0.200	--	ND	0.721	--		1
2,2,4-Trimethylpentane	ND	0.200	--	ND	0.934	--		1
Heptane	ND	0.200	--	ND	0.820	--		1
cis-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
4-Methyl-2-pentanone	ND	0.500	--	ND	2.05	--		1
trans-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
1,1,2-Trichloroethane	ND	0.200	--	ND	1.09	--		1
Toluene	0.623	0.200	--	2.35	0.754	--		1
2-Hexanone	ND	0.200	--	ND	0.820	--		1
Dibromochloromethane	ND	0.200	--	ND	1.70	--		1
1,2-Dibromoethane	ND	0.200	--	ND	1.54	--		1
Chlorobenzene	ND	0.200	--	ND	0.921	--		1
Ethylbenzene	ND	0.200	--	ND	0.869	--		1
p/m-Xylene	ND	0.400	--	ND	1.74	--		1
Bromoform	ND	0.200	--	ND	2.07	--		1
Styrene	ND	0.200	--	ND	0.852	--		1
1,1,2,2-Tetrachloroethane	ND	0.200	--	ND	1.37	--		1
o-Xylene	ND	0.200	--	ND	0.869	--		1
4-Ethyltoluene	ND	0.200	--	ND	0.983	--		1
1,3,5-Trimethylbenzene	ND	0.200	--	ND	0.983	--		1

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316892
Report Date: 04/07/23

SAMPLE RESULTS

Lab ID: L2316892-04
Client ID: IA-6
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 15:15
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
1,2,4-Trimethylbenzene	ND	0.200	--	ND	0.983	--		1
Benzyl chloride	ND	0.200	--	ND	1.04	--		1
1,3-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,4-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,2-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,2,4-Trichlorobenzene	ND	0.200	--	ND	1.48	--		1
Hexachlorobutadiene	ND	0.200	--	ND	2.13	--		1

Internal Standard	% Recovery	Qualifier	Acceptance Criteria
1,4-Difluorobenzene	85		60-140
Bromochloromethane	89		60-140
chlorobenzene-d5	82		60-140

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316892
Report Date: 04/07/23

SAMPLE RESULTS

Lab ID: L2316892-04
Client ID: IA-6
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 15:15
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Air
Anaytical Method: 48,TO-15-SIM
Analytical Date: 04/06/23 20:04
Analyst: RAY

	ppbV			ug/m3				
Parameter	**Results**	**RL**	**MDL**	**Results**	**RL**	**MDL**	**Qualifier**	**Dilution Factor**
Volatile Organics in Air by SIM - Mansfield Lab								
Vinyl chloride	ND	0.020	--	ND	0.051	--		1
1,1-Dichloroethene	ND	0.020	--	ND	0.079	--		1
cis-1,2-Dichloroethene	ND	0.020	--	ND	0.079	--		1
1,1,1-Trichloroethane	ND	0.020	--	ND	0.109	--		1
Carbon tetrachloride	0.078	0.020	--	0.491	0.126	--		1
Trichloroethene	ND	0.020	--	ND	0.107	--		1
Tetrachloroethene	0.023	0.020	--	0.156	0.136	--		1

Internal Standard	**% Recovery**	**Qualifier**	**Acceptance Criteria**
1,4-difluorobenzene	87		60-140
bromochloromethane	89		60-140
chlorobenzene-d5	89		60-140

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316892
Report Date: 04/07/23

SAMPLE RESULTS

Lab ID: L2316892-05
Client ID: IA-7
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 15:05
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Air
Anaytical Method: 48,TO-15
Analytical Date: 04/06/23 20:44
Analyst: RAY

	ppbV			ug/m3				
Parameter	**Results**	**RL**	**MDL**	**Results**	**RL**	**MDL**	**Qualifier**	**Dilution Factor**
Volatile Organics in Air - Mansfield Lab								
Dichlorodifluoromethane	0.562	0.200	--	2.78	0.989	--		1
Chloromethane	0.513	0.200	--	1.06	0.413	--		1
Freon-114	ND	0.200	--	ND	1.40	--		1
1,3-Butadiene	ND	0.200	--	ND	0.442	--		1
Bromomethane	ND	0.200	--	ND	0.777	--		1
Chloroethane	ND	0.200	--	ND	0.528	--		1
Ethanol	ND	5.00	--	ND	9.42	--		1
Vinyl bromide	ND	0.200	--	ND	0.874	--		1
Acetone	2.30	1.00	--	5.46	2.38	--		1
Trichlorofluoromethane	0.263	0.200	--	1.48	1.12	--		1
Isopropanol	ND	0.500	--	ND	1.23	--		1
Tertiary butyl Alcohol	ND	0.500	--	ND	1.52	--		1
Methylene chloride	ND	0.500	--	ND	1.74	--		1
3-Chloropropene	ND	0.200	--	ND	0.626	--		1
Carbon disulfide	ND	0.200	--	ND	0.623	--		1
Freon-113	ND	0.200	--	ND	1.53	--		1
trans-1,2-Dichloroethene	ND	0.200	--	ND	0.793	--		1
1,1-Dichloroethane	ND	0.200	--	ND	0.809	--		1
Methyl tert butyl ether	ND	0.200	--	ND	0.721	--		1
2-Butanone	ND	0.500	--	ND	1.47	--		1
Ethyl Acetate	ND	0.500	--	ND	1.80	--		1
Chloroform	ND	0.200	--	ND	0.977	--		1
Tetrahydrofuran	ND	0.500	--	ND	1.47	--		1

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316892
Report Date: 04/07/23

SAMPLE RESULTS

Lab ID: L2316892-05
Client ID: IA-7
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 15:05
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
1,2-Dichloroethane	ND	0.200	--	ND	0.809	--		1
n-Hexane	ND	0.200	--	ND	0.705	--		1
Benzene	0.285	0.200	--	0.910	0.639	--		1
Cyclohexane	ND	0.200	--	ND	0.688	--		1
1,2-Dichloropropane	ND	0.200	--	ND	0.924	--		1
Bromodichloromethane	ND	0.200	--	ND	1.34	--		1
1,4-Dioxane	ND	0.200	--	ND	0.721	--		1
2,2,4-Trimethylpentane	ND	0.200	--	ND	0.934	--		1
Heptane	ND	0.200	--	ND	0.820	--		1
cis-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
4-Methyl-2-pentanone	ND	0.500	--	ND	2.05	--		1
trans-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
1,1,2-Trichloroethane	ND	0.200	--	ND	1.09	--		1
Toluene	0.294	0.200	--	1.11	0.754	--		1
2-Hexanone	ND	0.200	--	ND	0.820	--		1
Dibromochloromethane	ND	0.200	--	ND	1.70	--		1
1,2-Dibromoethane	ND	0.200	--	ND	1.54	--		1
Chlorobenzene	ND	0.200	--	ND	0.921	--		1
Ethylbenzene	ND	0.200	--	ND	0.869	--		1
p/m-Xylene	ND	0.400	--	ND	1.74	--		1
Bromoform	ND	0.200	--	ND	2.07	--		1
Styrene	ND	0.200	--	ND	0.852	--		1
1,1,2,2-Tetrachloroethane	ND	0.200	--	ND	1.37	--		1
o-Xylene	ND	0.200	--	ND	0.869	--		1
4-Ethyltoluene	ND	0.200	--	ND	0.983	--		1
1,3,5-Trimethylbenzene	ND	0.200	--	ND	0.983	--		1

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316892
Report Date: 04/07/23

SAMPLE RESULTS

Lab ID: L2316892-05
Client ID: IA-7
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 15:05
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
1,2,4-Trimethylbenzene	ND	0.200	--	ND	0.983	--		1
Benzyl chloride	ND	0.200	--	ND	1.04	--		1
1,3-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,4-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,2-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,2,4-Trichlorobenzene	ND	0.200	--	ND	1.48	--		1
Hexachlorobutadiene	ND	0.200	--	ND	2.13	--		1

Internal Standard	% Recovery	Qualifier	Acceptance Criteria
1,4-Difluorobenzene	86		60-140
Bromochloromethane	90		60-140
chlorobenzene-d5	83		60-140

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316892
Report Date: 04/07/23

SAMPLE RESULTS

Lab ID: L2316892-05
Client ID: IA-7
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 15:05
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Air
Anaytical Method: 48,TO-15-SIM
Analytical Date: 04/06/23 20:44
Analyst: RAY

	ppbV			ug/m3				
Parameter	**Results**	**RL**	**MDL**	**Results**	**RL**	**MDL**	**Qualifier**	**Dilution Factor**
Volatile Organics in Air by SIM - Mansfield Lab								
Vinyl chloride	ND	0.020	--	ND	0.051	--		1
1,1-Dichloroethene	ND	0.020	--	ND	0.079	--		1
cis-1,2-Dichloroethene	ND	0.020	--	ND	0.079	--		1
1,1,1-Trichloroethane	ND	0.020	--	ND	0.109	--		1
Carbon tetrachloride	0.070	0.020	--	0.440	0.126	--		1
Trichloroethene	ND	0.020	--	ND	0.107	--		1
Tetrachloroethene	ND	0.020	--	ND	0.136	--		1

Internal Standard	**% Recovery**	**Qualifier**	**Acceptance Criteria**
1,4-difluorobenzene	88		60-140
bromochloromethane	90		60-140
chlorobenzene-d5	90		60-140

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316892
Report Date: 04/07/23

SAMPLE RESULTS

Lab ID: L2316892-06
Client ID: IA-8
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 14:55
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Air
Anaytical Method: 48,TO-15
Analytical Date: 04/06/23 21:23
Analyst: RAY

	ppbV			ug/m3				
Parameter	**Results**	**RL**	**MDL**	**Results**	**RL**	**MDL**	**Qualifier**	**Dilution Factor**
Volatile Organics in Air - Mansfield Lab								
Dichlorodifluoromethane	0.568	0.200	--	2.81	0.989	--		1
Chloromethane	0.539	0.200	--	1.11	0.413	--		1
Freon-114	ND	0.200	--	ND	1.40	--		1
1,3-Butadiene	ND	0.200	--	ND	0.442	--		1
Bromomethane	ND	0.200	--	ND	0.777	--		1
Chloroethane	ND	0.200	--	ND	0.528	--		1
Ethanol	ND	5.00	--	ND	9.42	--		1
Vinyl bromide	ND	0.200	--	ND	0.874	--		1
Acetone	3.67	1.00	--	8.72	2.38	--		1
Trichlorofluoromethane	0.272	0.200	--	1.53	1.12	--		1
Isopropanol	ND	0.500	--	ND	1.23	--		1
Tertiary butyl Alcohol	ND	0.500	--	ND	1.52	--		1
Methylene chloride	ND	0.500	--	ND	1.74	--		1
3-Chloropropene	ND	0.200	--	ND	0.626	--		1
Carbon disulfide	ND	0.200	--	ND	0.623	--		1
Freon-113	ND	0.200	--	ND	1.53	--		1
trans-1,2-Dichloroethene	ND	0.200	--	ND	0.793	--		1
1,1-Dichloroethane	ND	0.200	--	ND	0.809	--		1
Methyl tert butyl ether	ND	0.200	--	ND	0.721	--		1
2-Butanone	ND	0.500	--	ND	1.47	--		1
Ethyl Acetate	ND	0.500	--	ND	1.80	--		1
Chloroform	ND	0.200	--	ND	0.977	--		1
Tetrahydrofuran	ND	0.500	--	ND	1.47	--		1

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316892
Report Date: 04/07/23

SAMPLE RESULTS

Lab ID: L2316892-06
Client ID: IA-8
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 14:55
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
1,2-Dichloroethane	ND	0.200	--	ND	0.809	--		1
n-Hexane	ND	0.200	--	ND	0.705	--		1
Benzene	ND	0.200	--	ND	0.639	--		1
Cyclohexane	ND	0.200	--	ND	0.688	--		1
1,2-Dichloropropane	ND	0.200	--	ND	0.924	--		1
Bromodichloromethane	ND	0.200	--	ND	1.34	--		1
1,4-Dioxane	ND	0.200	--	ND	0.721	--		1
2,2,4-Trimethylpentane	ND	0.200	--	ND	0.934	--		1
Heptane	ND	0.200	--	ND	0.820	--		1
cis-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
4-Methyl-2-pentanone	ND	0.500	--	ND	2.05	--		1
trans-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
1,1,2-Trichloroethane	ND	0.200	--	ND	1.09	--		1
Toluene	ND	0.200	--	ND	0.754	--		1
2-Hexanone	ND	0.200	--	ND	0.820	--		1
Dibromochloromethane	ND	0.200	--	ND	1.70	--		1
1,2-Dibromoethane	ND	0.200	--	ND	1.54	--		1
Chlorobenzene	ND	0.200	--	ND	0.921	--		1
Ethylbenzene	ND	0.200	--	ND	0.869	--		1
p/m-Xylene	ND	0.400	--	ND	1.74	--		1
Bromoform	ND	0.200	--	ND	2.07	--		1
Styrene	ND	0.200	--	ND	0.852	--		1
1,1,2,2-Tetrachloroethane	ND	0.200	--	ND	1.37	--		1
o-Xylene	ND	0.200	--	ND	0.869	--		1
4-Ethyltoluene	ND	0.200	--	ND	0.983	--		1
1,3,5-Trimethylbenzene	ND	0.200	--	ND	0.983	--		1

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316892
Report Date: 04/07/23

SAMPLE RESULTS

Lab ID: L2316892-06
Client ID: IA-8
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 14:55
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
1,2,4-Trimethylbenzene	ND	0.200	--	ND	0.983	--		1
Benzyl chloride	ND	0.200	--	ND	1.04	--		1
1,3-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,4-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,2-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,2,4-Trichlorobenzene	ND	0.200	--	ND	1.48	--		1
Hexachlorobutadiene	ND	0.200	--	ND	2.13	--		1

Internal Standard	% Recovery	Qualifier	Acceptance Criteria
1,4-Difluorobenzene	85		60-140
Bromochloromethane	90		60-140
chlorobenzene-d5	83		60-140

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316892
Report Date: 04/07/23

SAMPLE RESULTS

Lab ID: L2316892-06
Client ID: IA-8
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 14:55
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Air
Anaytical Method: 48,TO-15-SIM
Analytical Date: 04/06/23 21:23
Analyst: RAY

	ppbV			ug/m3				
Parameter	**Results**	**RL**	**MDL**	**Results**	**RL**	**MDL**	**Qualifier**	**Dilution Factor**
Volatile Organics in Air by SIM - Mansfield Lab								
Vinyl chloride	ND	0.020	--	ND	0.051	--		1
1,1-Dichloroethene	ND	0.020	--	ND	0.079	--		1
cis-1,2-Dichloroethene	ND	0.020	--	ND	0.079	--		1
1,1,1-Trichloroethane	ND	0.020	--	ND	0.109	--		1
Carbon tetrachloride	0.085	0.020	--	0.535	0.126	--		1
Trichloroethene	ND	0.020	--	ND	0.107	--		1
Tetrachloroethene	ND	0.020	--	ND	0.136	--		1

Internal Standard	**% Recovery**	**Qualifier**	**Acceptance Criteria**
1,4-difluorobenzene	87		60-140
bromochloromethane	90		60-140
chlorobenzene-d5	90		60-140

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316892
Report Date: 04/07/23

SAMPLE RESULTS

Lab ID: L2316892-07
Client ID: SSV-3
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 13:17
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil_Vapor
Anaytical Method: 48,TO-15
Analytical Date: 04/07/23 00:40
Analyst: RAY

	ppbV			ug/m3				
Parameter	**Results**	**RL**	**MDL**	**Results**	**RL**	**MDL**	**Qualifier**	**Dilution Factor**
Volatile Organics in Air - Mansfield Lab								
Dichlorodifluoromethane	5.04	0.200	--	24.9	0.989	--		1
Chloromethane	0.330	0.200	--	0.681	0.413	--		1
Freon-114	ND	0.200	--	ND	1.40	--		1
Vinyl chloride	ND	0.200	--	ND	0.511	--		1
1,3-Butadiene	ND	0.200	--	ND	0.442	--		1
Bromomethane	ND	0.200	--	ND	0.777	--		1
Chloroethane	ND	0.200	--	ND	0.528	--		1
Ethanol	ND	5.00	--	ND	9.42	--		1
Vinyl bromide	ND	0.200	--	ND	0.874	--		1
Acetone	4.46	1.00	--	10.6	2.38	--		1
Trichlorofluoromethane	0.248	0.200	--	1.39	1.12	--		1
Isopropanol	ND	0.500	--	ND	1.23	--		1
1,1-Dichloroethene	ND	0.200	--	ND	0.793	--		1
Tertiary butyl Alcohol	1.49	0.500	--	4.52	1.52	--		1
Methylene chloride	ND	0.500	--	ND	1.74	--		1
3-Chloropropene	ND	0.200	--	ND	0.626	--		1
Carbon disulfide	ND	0.200	--	ND	0.623	--		1
Freon-113	ND	0.200	--	ND	1.53	--		1
trans-1,2-Dichloroethene	ND	0.200	--	ND	0.793	--		1
1,1-Dichloroethane	ND	0.200	--	ND	0.809	--		1
Methyl tert butyl ether	ND	0.200	--	ND	0.721	--		1
2-Butanone	ND	0.500	--	ND	1.47	--		1
cis-1,2-Dichloroethene	ND	0.200	--	ND	0.793	--		1

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316892
Report Date: 04/07/23

SAMPLE RESULTS

Lab ID: L2316892-07
Client ID: SSV-3
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 13:17
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
Ethyl Acetate	ND	0.500	--	ND	1.80	--		1
Chloroform	ND	0.200	--	ND	0.977	--		1
Tetrahydrofuran	ND	0.500	--	ND	1.47	--		1
1,2-Dichloroethane	ND	0.200	--	ND	0.809	--		1
n-Hexane	ND	0.200	--	ND	0.705	--		1
1,1,1-Trichloroethane	ND	0.200	--	ND	1.09	--		1
Benzene	0.258	0.200	--	0.824	0.639	--		1
Carbon tetrachloride	ND	0.200	--	ND	1.26	--		1
Cyclohexane	ND	0.200	--	ND	0.688	--		1
1,2-Dichloropropane	ND	0.200	--	ND	0.924	--		1
Bromodichloromethane	ND	0.200	--	ND	1.34	--		1
1,4-Dioxane	ND	0.200	--	ND	0.721	--		1
Trichloroethene	ND	0.200	--	ND	1.07	--		1
2,2,4-Trimethylpentane	ND	0.200	--	ND	0.934	--		1
Heptane	ND	0.200	--	ND	0.820	--		1
cis-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
4-Methyl-2-pentanone	ND	0.500	--	ND	2.05	--		1
trans-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
1,1,2-Trichloroethane	ND	0.200	--	ND	1.09	--		1
Toluene	0.332	0.200	--	1.25	0.754	--		1
2-Hexanone	ND	0.200	--	ND	0.820	--		1
Dibromochloromethane	ND	0.200	--	ND	1.70	--		1
1,2-Dibromoethane	ND	0.200	--	ND	1.54	--		1
Tetrachloroethene	2.21	0.200	--	15.0	1.36	--		1
Chlorobenzene	ND	0.200	--	ND	0.921	--		1
Ethylbenzene	ND	0.200	--	ND	0.869	--		1

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316892
Report Date: 04/07/23

SAMPLE RESULTS

Lab ID: L2316892-07
Client ID: SSV-3
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 13:17
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
p/m-Xylene	0.599	0.400	--	2.60	1.74	--		1
Bromoform	ND	0.200	--	ND	2.07	--		1
Styrene	ND	0.200	--	ND	0.852	--		1
1,1,2,2-Tetrachloroethane	ND	0.200	--	ND	1.37	--		1
o-Xylene	0.356	0.200	--	1.55	0.869	--		1
4-Ethyltoluene	ND	0.200	--	ND	0.983	--		1
1,3,5-Trimethylbenzene	0.335	0.200	--	1.65	0.983	--		1
1,2,4-Trimethylbenzene	1.05	0.200	--	5.16	0.983	--		1
Benzyl chloride	ND	0.200	--	ND	1.04	--		1
1,3-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,4-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,2-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,2,4-Trichlorobenzene	ND	0.200	--	ND	1.48	--		1
Hexachlorobutadiene	ND	0.200	--	ND	2.13	--		1

Internal Standard	% Recovery	Qualifier	Acceptance Criteria
1,4-Difluorobenzene	90		60-140
Bromochloromethane	93		60-140
chlorobenzene-d5	88		60-140

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316892
Report Date: 04/07/23

SAMPLE RESULTS

Lab ID: L2316892-08
Client ID: SSV-4
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 14:25
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil_Vapor
Anaytical Method: 48,TO-15
Analytical Date: 04/07/23 01:19
Analyst: RAY

	ppbV			ug/m3				
Parameter	**Results**	**RL**	**MDL**	**Results**	**RL**	**MDL**	**Qualifier**	**Dilution Factor**
Volatile Organics in Air - Mansfield Lab								
Dichlorodifluoromethane	58.1	0.200	--	287	0.989	--		1
Chloromethane	ND	0.200	--	ND	0.413	--		1
Freon-114	ND	0.200	--	ND	1.40	--		1
Vinyl chloride	ND	0.200	--	ND	0.511	--		1
1,3-Butadiene	ND	0.200	--	ND	0.442	--		1
Bromomethane	ND	0.200	--	ND	0.777	--		1
Chloroethane	ND	0.200	--	ND	0.528	--		1
Ethanol	10.9	5.00	--	20.5	9.42	--		1
Vinyl bromide	ND	0.200	--	ND	0.874	--		1
Acetone	27.5	1.00	--	65.3	2.38	--		1
Trichlorofluoromethane	ND	0.200	--	ND	1.12	--		1
Isopropanol	3.41	0.500	--	8.38	1.23	--		1
1,1-Dichloroethene	ND	0.200	--	ND	0.793	--		1
Tertiary butyl Alcohol	1.01	0.500	--	3.06	1.52	--		1
Methylene chloride	ND	0.500	--	ND	1.74	--		1
3-Chloropropene	ND	0.200	--	ND	0.626	--		1
Carbon disulfide	0.953	0.200	--	2.97	0.623	--		1
Freon-113	ND	0.200	--	ND	1.53	--		1
trans-1,2-Dichloroethene	ND	0.200	--	ND	0.793	--		1
1,1-Dichloroethane	ND	0.200	--	ND	0.809	--		1
Methyl tert butyl ether	ND	0.200	--	ND	0.721	--		1
2-Butanone	6.84	0.500	--	20.2	1.47	--		1
cis-1,2-Dichloroethene	ND	0.200	--	ND	0.793	--		1

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316892
Report Date: 04/07/23

SAMPLE RESULTS

Lab ID: L2316892-08
Client ID: SSV-4
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 14:25
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
Ethyl Acetate	ND	0.500	--	ND	1.80	--		1
Chloroform	0.374	0.200	--	1.83	0.977	--		1
Tetrahydrofuran	ND	0.500	--	ND	1.47	--		1
1,2-Dichloroethane	ND	0.200	--	ND	0.809	--		1
n-Hexane	0.583	0.200	--	2.05	0.705	--		1
1,1,1-Trichloroethane	ND	0.200	--	ND	1.09	--		1
Benzene	0.450	0.200	--	1.44	0.639	--		1
Carbon tetrachloride	ND	0.200	--	ND	1.26	--		1
Cyclohexane	0.388	0.200	--	1.34	0.688	--		1
1,2-Dichloropropane	ND	0.200	--	ND	0.924	--		1
Bromodichloromethane	ND	0.200	--	ND	1.34	--		1
1,4-Dioxane	ND	0.200	--	ND	0.721	--		1
Trichloroethene	ND	0.200	--	ND	1.07	--		1
2,2,4-Trimethylpentane	0.664	0.200	--	3.10	0.934	--		1
Heptane	0.839	0.200	--	3.44	0.820	--		1
cis-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
4-Methyl-2-pentanone	ND	0.500	--	ND	2.05	--		1
trans-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
1,1,2-Trichloroethane	ND	0.200	--	ND	1.09	--		1
Toluene	1.78	0.200	--	6.71	0.754	--		1
2-Hexanone	ND	0.200	--	ND	0.820	--		1
Dibromochloromethane	ND	0.200	--	ND	1.70	--		1
1,2-Dibromoethane	ND	0.200	--	ND	1.54	--		1
Tetrachloroethene	0.513	0.200	--	3.48	1.36	--		1
Chlorobenzene	ND	0.200	--	ND	0.921	--		1
Ethylbenzene	0.835	0.200	--	3.63	0.869	--		1

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316892
Report Date: 04/07/23

SAMPLE RESULTS

Lab ID: L2316892-08
Client ID: SSV-4
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 14:25
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
p/m-Xylene	4.59	0.400	--	19.9	1.74	--		1
Bromoform	ND	0.200	--	ND	2.07	--		1
Styrene	ND	0.200	--	ND	0.852	--		1
1,1,2,2-Tetrachloroethane	ND	0.200	--	ND	1.37	--		1
o-Xylene	2.02	0.200	--	8.77	0.869	--		1
4-Ethyltoluene	0.333	0.200	--	1.64	0.983	--		1
1,3,5-Trimethylbenzene	0.641	0.200	--	3.15	0.983	--		1
1,2,4-Trimethylbenzene	1.62	0.200	--	7.96	0.983	--		1
Benzyl chloride	ND	0.200	--	ND	1.04	--		1
1,3-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,4-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,2-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,2,4-Trichlorobenzene	ND	0.200	--	ND	1.48	--		1
Hexachlorobutadiene	ND	0.200	--	ND	2.13	--		1

Internal Standard	% Recovery	Qualifier	Acceptance Criteria
1,4-Difluorobenzene	90		60-140
Bromochloromethane	93		60-140
chlorobenzene-d5	88		60-140

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316892
Report Date: 04/07/23

SAMPLE RESULTS

Lab ID: L2316892-09
Client ID: SSV-5
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 14:15
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil_Vapor
Anaytical Method: 48,TO-15
Analytical Date: 04/07/23 01:59
Analyst: RAY

	ppbV			ug/m3				
Parameter	**Results**	**RL**	**MDL**	**Results**	**RL**	**MDL**	**Qualifier**	**Dilution Factor**
Volatile Organics in Air - Mansfield Lab								
Dichlorodifluoromethane	0.761	0.200	--	3.76	0.989	--		1
Chloromethane	0.493	0.200	--	1.02	0.413	--		1
Freon-114	ND	0.200	--	ND	1.40	--		1
Vinyl chloride	ND	0.200	--	ND	0.511	--		1
1,3-Butadiene	ND	0.200	--	ND	0.442	--		1
Bromomethane	ND	0.200	--	ND	0.777	--		1
Chloroethane	ND	0.200	--	ND	0.528	--		1
Ethanol	ND	5.00	--	ND	9.42	--		1
Vinyl bromide	ND	0.200	--	ND	0.874	--		1
Acetone	74.9	1.00	--	178	2.38	--		1
Trichlorofluoromethane	0.258	0.200	--	1.45	1.12	--		1
Isopropanol	5.53	0.500	--	13.6	1.23	--		1
1,1-Dichloroethene	ND	0.200	--	ND	0.793	--		1
Tertiary butyl Alcohol	1.43	0.500	--	4.34	1.52	--		1
Methylene chloride	ND	0.500	--	ND	1.74	--		1
3-Chloropropene	ND	0.200	--	ND	0.626	--		1
Carbon disulfide	ND	0.200	--	ND	0.623	--		1
Freon-113	ND	0.200	--	ND	1.53	--		1
trans-1,2-Dichloroethene	ND	0.200	--	ND	0.793	--		1
1,1-Dichloroethane	ND	0.200	--	ND	0.809	--		1
Methyl tert butyl ether	ND	0.200	--	ND	0.721	--		1
2-Butanone	0.510	0.500	--	1.50	1.47	--		1
cis-1,2-Dichloroethene	ND	0.200	--	ND	0.793	--		1

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316892
Report Date: 04/07/23

SAMPLE RESULTS

Lab ID: L2316892-09
Client ID: SSV-5
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 14:15
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
Ethyl Acetate	ND	0.500	--	ND	1.80	--		1
Chloroform	ND	0.200	--	ND	0.977	--		1
Tetrahydrofuran	ND	0.500	--	ND	1.47	--		1
1,2-Dichloroethane	ND	0.200	--	ND	0.809	--		1
n-Hexane	ND	0.200	--	ND	0.705	--		1
1,1,1-Trichloroethane	ND	0.200	--	ND	1.09	--		1
Benzene	0.285	0.200	--	0.910	0.639	--		1
Carbon tetrachloride	ND	0.200	--	ND	1.26	--		1
Cyclohexane	ND	0.200	--	ND	0.688	--		1
1,2-Dichloropropane	ND	0.200	--	ND	0.924	--		1
Bromodichloromethane	ND	0.200	--	ND	1.34	--		1
1,4-Dioxane	ND	0.200	--	ND	0.721	--		1
Trichloroethene	ND	0.200	--	ND	1.07	--		1
2,2,4-Trimethylpentane	ND	0.200	--	ND	0.934	--		1
Heptane	ND	0.200	--	ND	0.820	--		1
cis-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
4-Methyl-2-pentanone	ND	0.500	--	ND	2.05	--		1
trans-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
1,1,2-Trichloroethane	ND	0.200	--	ND	1.09	--		1
Toluene	0.431	0.200	--	1.62	0.754	--		1
2-Hexanone	ND	0.200	--	ND	0.820	--		1
Dibromochloromethane	ND	0.200	--	ND	1.70	--		1
1,2-Dibromoethane	ND	0.200	--	ND	1.54	--		1
Tetrachloroethene	0.948	0.200	--	6.43	1.36	--		1
Chlorobenzene	ND	0.200	--	ND	0.921	--		1
Ethylbenzene	0.316	0.200	--	1.37	0.869	--		1

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316892
Report Date: 04/07/23

SAMPLE RESULTS

Lab ID: L2316892-09
Client ID: SSV-5
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 14:15
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
p/m-Xylene	2.30	0.400	--	9.99	1.74	--		1
Bromoform	ND	0.200	--	ND	2.07	--		1
Styrene	ND	0.200	--	ND	0.852	--		1
1,1,2,2-Tetrachloroethane	ND	0.200	--	ND	1.37	--		1
o-Xylene	0.865	0.200	--	3.76	0.869	--		1
4-Ethyltoluene	0.260	0.200	--	1.28	0.983	--		1
1,3,5-Trimethylbenzene	0.477	0.200	--	2.35	0.983	--		1
1,2,4-Trimethylbenzene	1.60	0.200	--	7.87	0.983	--		1
Benzyl chloride	ND	0.200	--	ND	1.04	--		1
1,3-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,4-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,2-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,2,4-Trichlorobenzene	ND	0.200	--	ND	1.48	--		1
Hexachlorobutadiene	ND	0.200	--	ND	2.13	--		1

Internal Standard	% Recovery	Qualifier	Acceptance Criteria
1,4-Difluorobenzene	93		60-140
Bromochloromethane	96		60-140
chlorobenzene-d5	89		60-140

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316892
Report Date: 04/07/23

SAMPLE RESULTS

Lab ID: L2316892-10
Client ID: SSV-6
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 13:20
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil_Vapor
Anaytical Method: 48,TO-15
Analytical Date: 04/07/23 02:38
Analyst: RAY

	ppbV			ug/m3				
Parameter	**Results**	**RL**	**MDL**	**Results**	**RL**	**MDL**	**Qualifier**	**Dilution Factor**
Volatile Organics in Air - Mansfield Lab								
Dichlorodifluoromethane	6.60	0.200	--	32.6	0.989	--		1
Chloromethane	ND	0.200	--	ND	0.413	--		1
Freon-114	0.570	0.200	--	3.98	1.40	--		1
Vinyl chloride	ND	0.200	--	ND	0.511	--		1
1,3-Butadiene	ND	0.200	--	ND	0.442	--		1
Bromomethane	ND	0.200	--	ND	0.777	--		1
Chloroethane	ND	0.200	--	ND	0.528	--		1
Ethanol	5.81	5.00	--	10.9	9.42	--		1
Vinyl bromide	ND	0.200	--	ND	0.874	--		1
Acetone	21.2	1.00	--	50.4	2.38	--		1
Trichlorofluoromethane	2.00	0.200	--	11.2	1.12	--		1
Isopropanol	0.911	0.500	--	2.24	1.23	--		1
1,1-Dichloroethene	ND	0.200	--	ND	0.793	--		1
Tertiary butyl Alcohol	0.639	0.500	--	1.94	1.52	--		1
Methylene chloride	ND	0.500	--	ND	1.74	--		1
3-Chloropropene	ND	0.200	--	ND	0.626	--		1
Carbon disulfide	1.25	0.200	--	3.89	0.623	--		1
Freon-113	ND	0.200	--	ND	1.53	--		1
trans-1,2-Dichloroethene	ND	0.200	--	ND	0.793	--		1
1,1-Dichloroethane	ND	0.200	--	ND	0.809	--		1
Methyl tert butyl ether	ND	0.200	--	ND	0.721	--		1
2-Butanone	1.82	0.500	--	5.37	1.47	--		1
cis-1,2-Dichloroethene	ND	0.200	--	ND	0.793	--		1

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316892
Report Date: 04/07/23

SAMPLE RESULTS

Lab ID: L2316892-10
Client ID: SSV-6
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 13:20
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
Ethyl Acetate	ND	0.500	--	ND	1.80	--		1
Chloroform	3.34	0.200	--	16.3	0.977	--		1
Tetrahydrofuran	ND	0.500	--	ND	1.47	--		1
1,2-Dichloroethane	ND	0.200	--	ND	0.809	--		1
n-Hexane	0.530	0.200	--	1.87	0.705	--		1
1,1,1-Trichloroethane	0.559	0.200	--	3.05	1.09	--		1
Benzene	0.513	0.200	--	1.64	0.639	--		1
Carbon tetrachloride	ND	0.200	--	ND	1.26	--		1
Cyclohexane	0.235	0.200	--	0.809	0.688	--		1
1,2-Dichloropropane	ND	0.200	--	ND	0.924	--		1
Bromodichloromethane	ND	0.200	--	ND	1.34	--		1
1,4-Dioxane	ND	0.200	--	ND	0.721	--		1
Trichloroethene	ND	0.200	--	ND	1.07	--		1
2,2,4-Trimethylpentane	ND	0.200	--	ND	0.934	--		1
Heptane	0.628	0.200	--	2.57	0.820	--		1
cis-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
4-Methyl-2-pentanone	ND	0.500	--	ND	2.05	--		1
trans-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
1,1,2-Trichloroethane	ND	0.200	--	ND	1.09	--		1
Toluene	0.702	0.200	--	2.65	0.754	--		1
2-Hexanone	ND	0.200	--	ND	0.820	--		1
Dibromochloromethane	ND	0.200	--	ND	1.70	--		1
1,2-Dibromoethane	ND	0.200	--	ND	1.54	--		1
Tetrachloroethene	1.90	0.200	--	12.9	1.36	--		1
Chlorobenzene	ND	0.200	--	ND	0.921	--		1
Ethylbenzene	0.646	0.200	--	2.81	0.869	--		1

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316892
Report Date: 04/07/23

SAMPLE RESULTS

Lab ID: L2316892-10
Client ID: SSV-6
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 13:20
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
p/m-Xylene	0.912	0.400	--	3.96	1.74	--		1
Bromoform	ND	0.200	--	ND	2.07	--		1
Styrene	ND	0.200	--	ND	0.852	--		1
1,1,2,2-Tetrachloroethane	ND	0.200	--	ND	1.37	--		1
o-Xylene	0.383	0.200	--	1.66	0.869	--		1
4-Ethyltoluene	ND	0.200	--	ND	0.983	--		1
1,3,5-Trimethylbenzene	0.306	0.200	--	1.50	0.983	--		1
1,2,4-Trimethylbenzene	0.776	0.200	--	3.81	0.983	--		1
Benzyl chloride	ND	0.200	--	ND	1.04	--		1
1,3-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,4-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,2-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,2,4-Trichlorobenzene	ND	0.200	--	ND	1.48	--		1
Hexachlorobutadiene	ND	0.200	--	ND	2.13	--		1

Internal Standard	% Recovery	Qualifier	Acceptance Criteria
1,4-Difluorobenzene	93		60-140
Bromochloromethane	96		60-140
chlorobenzene-d5	90		60-140

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316892
Report Date: 04/07/23

SAMPLE RESULTS

Lab ID: L2316892-11
Client ID: SSV-7
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 14:43
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil_Vapor
Anaytical Method: 48,TO-15
Analytical Date: 04/07/23 03:18
Analyst: RAY

	ppbV			ug/m3				
Parameter	**Results**	**RL**	**MDL**	**Results**	**RL**	**MDL**	**Qualifier**	**Dilution Factor**
Volatile Organics in Air - Mansfield Lab								
Dichlorodifluoromethane	1.07	0.200	--	5.29	0.989	--		1
Chloromethane	ND	0.200	--	ND	0.413	--		1
Freon-114	ND	0.200	--	ND	1.40	--		1
Vinyl chloride	ND	0.200	--	ND	0.511	--		1
1,3-Butadiene	ND	0.200	--	ND	0.442	--		1
Bromomethane	ND	0.200	--	ND	0.777	--		1
Chloroethane	ND	0.200	--	ND	0.528	--		1
Ethanol	10.2	5.00	--	19.2	9.42	--		1
Vinyl bromide	ND	0.200	--	ND	0.874	--		1
Acetone	9.09	1.00	--	21.6	2.38	--		1
Trichlorofluoromethane	1.18	0.200	--	6.63	1.12	--		1
Isopropanol	ND	0.500	--	ND	1.23	--		1
1,1-Dichloroethene	ND	0.200	--	ND	0.793	--		1
Tertiary butyl Alcohol	0.695	0.500	--	2.11	1.52	--		1
Methylene chloride	ND	0.500	--	ND	1.74	--		1
3-Chloropropene	ND	0.200	--	ND	0.626	--		1
Carbon disulfide	0.578	0.200	--	1.80	0.623	--		1
Freon-113	ND	0.200	--	ND	1.53	--		1
trans-1,2-Dichloroethene	ND	0.200	--	ND	0.793	--		1
1,1-Dichloroethane	ND	0.200	--	ND	0.809	--		1
Methyl tert butyl ether	ND	0.200	--	ND	0.721	--		1
2-Butanone	0.835	0.500	--	2.46	1.47	--		1
cis-1,2-Dichloroethene	ND	0.200	--	ND	0.793	--		1

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316892
Report Date: 04/07/23

SAMPLE RESULTS

Lab ID: L2316892-11
Client ID: SSV-7
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 14:43
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
Ethyl Acetate	ND	0.500	--	ND	1.80	--		1
Chloroform	0.256	0.200	--	1.25	0.977	--		1
Tetrahydrofuran	ND	0.500	--	ND	1.47	--		1
1,2-Dichloroethane	ND	0.200	--	ND	0.809	--		1
n-Hexane	ND	0.200	--	ND	0.705	--		1
1,1,1-Trichloroethane	ND	0.200	--	ND	1.09	--		1
Benzene	0.289	0.200	--	0.923	0.639	--		1
Carbon tetrachloride	ND	0.200	--	ND	1.26	--		1
Cyclohexane	ND	0.200	--	ND	0.688	--		1
1,2-Dichloropropane	ND	0.200	--	ND	0.924	--		1
Bromodichloromethane	ND	0.200	--	ND	1.34	--		1
1,4-Dioxane	ND	0.200	--	ND	0.721	--		1
Trichloroethene	ND	0.200	--	ND	1.07	--		1
2,2,4-Trimethylpentane	ND	0.200	--	ND	0.934	--		1
Heptane	ND	0.200	--	ND	0.820	--		1
cis-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
4-Methyl-2-pentanone	0.504	0.500	--	2.07	2.05	--		1
trans-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
1,1,2-Trichloroethane	ND	0.200	--	ND	1.09	--		1
Toluene	1.00	0.200	--	3.77	0.754	--		1
2-Hexanone	ND	0.200	--	ND	0.820	--		1
Dibromochloromethane	ND	0.200	--	ND	1.70	--		1
1,2-Dibromoethane	ND	0.200	--	ND	1.54	--		1
Tetrachloroethene	2.89	0.200	--	19.6	1.36	--		1
Chlorobenzene	ND	0.200	--	ND	0.921	--		1
Ethylbenzene	0.232	0.200	--	1.01	0.869	--		1

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316892
Report Date: 04/07/23

SAMPLE RESULTS

Lab ID: L2316892-11
Client ID: SSV-7
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 14:43
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
p/m-Xylene	0.573	0.400	--	2.49	1.74	--		1
Bromoform	ND	0.200	--	ND	2.07	--		1
Styrene	ND	0.200	--	ND	0.852	--		1
1,1,2,2-Tetrachloroethane	ND	0.200	--	ND	1.37	--		1
o-Xylene	0.209	0.200	--	0.908	0.869	--		1
4-Ethyltoluene	ND	0.200	--	ND	0.983	--		1
1,3,5-Trimethylbenzene	ND	0.200	--	ND	0.983	--		1
1,2,4-Trimethylbenzene	0.205	0.200	--	1.01	0.983	--		1
Benzyl chloride	ND	0.200	--	ND	1.04	--		1
1,3-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,4-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,2-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,2,4-Trichlorobenzene	ND	0.200	--	ND	1.48	--		1
Hexachlorobutadiene	ND	0.200	--	ND	2.13	--		1

Internal Standard	% Recovery	Qualifier	Acceptance Criteria
1,4-Difluorobenzene	92		60-140
Bromochloromethane	95		60-140
chlorobenzene-d5	88		60-140

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316892
Report Date: 04/07/23

SAMPLE RESULTS

Lab ID: L2316892-12
Client ID: SSV-8
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 14:55
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil_Vapor
Anaytical Method: 48,TO-15
Analytical Date: 04/07/23 03:57
Analyst: RAY

	ppbV			ug/m3				
Parameter	**Results**	**RL**	**MDL**	**Results**	**RL**	**MDL**	**Qualifier**	**Dilution Factor**
Volatile Organics in Air - Mansfield Lab								
Dichlorodifluoromethane	3.62	0.200	--	17.9	0.989	--		1
Chloromethane	ND	0.200	--	ND	0.413	--		1
Freon-114	ND	0.200	--	ND	1.40	--		1
Vinyl chloride	ND	0.200	--	ND	0.511	--		1
1,3-Butadiene	ND	0.200	--	ND	0.442	--		1
Bromomethane	ND	0.200	--	ND	0.777	--		1
Chloroethane	ND	0.200	--	ND	0.528	--		1
Ethanol	ND	5.00	--	ND	9.42	--		1
Vinyl bromide	ND	0.200	--	ND	0.874	--		1
Acetone	32.3	1.00	--	76.7	2.38	--		1
Trichlorofluoromethane	0.325	0.200	--	1.83	1.12	--		1
Isopropanol	ND	0.500	--	ND	1.23	--		1
1,1-Dichloroethene	ND	0.200	--	ND	0.793	--		1
Tertiary butyl Alcohol	1.34	0.500	--	4.06	1.52	--		1
Methylene chloride	ND	0.500	--	ND	1.74	--		1
3-Chloropropene	ND	0.200	--	ND	0.626	--		1
Carbon disulfide	1.63	0.200	--	5.08	0.623	--		1
Freon-113	ND	0.200	--	ND	1.53	--		1
trans-1,2-Dichloroethene	ND	0.200	--	ND	0.793	--		1
1,1-Dichloroethane	ND	0.200	--	ND	0.809	--		1
Methyl tert butyl ether	ND	0.200	--	ND	0.721	--		1
2-Butanone	1.24	0.500	--	3.66	1.47	--		1
cis-1,2-Dichloroethene	ND	0.200	--	ND	0.793	--		1

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316892
Report Date: 04/07/23

SAMPLE RESULTS

Lab ID: L2316892-12
Client ID: SSV-8
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 14:55
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
Ethyl Acetate	ND	0.500	--	ND	1.80	--		1
Chloroform	6.16	0.200	--	30.1	0.977	--		1
Tetrahydrofuran	ND	0.500	--	ND	1.47	--		1
1,2-Dichloroethane	ND	0.200	--	ND	0.809	--		1
n-Hexane	0.235	0.200	--	0.828	0.705	--		1
1,1,1-Trichloroethane	ND	0.200	--	ND	1.09	--		1
Benzene	1.81	0.200	--	5.78	0.639	--		1
Carbon tetrachloride	ND	0.200	--	ND	1.26	--		1
Cyclohexane	ND	0.200	--	ND	0.688	--		1
1,2-Dichloropropane	ND	0.200	--	ND	0.924	--		1
Bromodichloromethane	ND	0.200	--	ND	1.34	--		1
1,4-Dioxane	ND	0.200	--	ND	0.721	--		1
Trichloroethene	0.571	0.200	--	3.07	1.07	--		1
2,2,4-Trimethylpentane	ND	0.200	--	ND	0.934	--		1
Heptane	0.298	0.200	--	1.22	0.820	--		1
cis-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
4-Methyl-2-pentanone	ND	0.500	--	ND	2.05	--		1
trans-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
1,1,2-Trichloroethane	ND	0.200	--	ND	1.09	--		1
Toluene	3.02	0.200	--	11.4	0.754	--		1
2-Hexanone	ND	0.200	--	ND	0.820	--		1
Dibromochloromethane	ND	0.200	--	ND	1.70	--		1
1,2-Dibromoethane	ND	0.200	--	ND	1.54	--		1
Tetrachloroethene	3.25	0.200	--	22.0	1.36	--		1
Chlorobenzene	ND	0.200	--	ND	0.921	--		1
Ethylbenzene	0.418	0.200	--	1.82	0.869	--		1

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316892
Report Date: 04/07/23

SAMPLE RESULTS

Lab ID: L2316892-12
Client ID: SSV-8
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 14:55
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
p/m-Xylene	1.14	0.400	--	4.95	1.74	--		1
Bromoform	ND	0.200	--	ND	2.07	--		1
Styrene	ND	0.200	--	ND	0.852	--		1
1,1,2,2-Tetrachloroethane	ND	0.200	--	ND	1.37	--		1
o-Xylene	0.472	0.200	--	2.05	0.869	--		1
4-Ethyltoluene	ND	0.200	--	ND	0.983	--		1
1,3,5-Trimethylbenzene	ND	0.200	--	ND	0.983	--		1
1,2,4-Trimethylbenzene	0.220	0.200	--	1.08	0.983	--		1
Benzyl chloride	ND	0.200	--	ND	1.04	--		1
1,3-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,4-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,2-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,2,4-Trichlorobenzene	ND	0.200	--	ND	1.48	--		1
Hexachlorobutadiene	ND	0.200	--	ND	2.13	--		1

Internal Standard	% Recovery	Qualifier	Acceptance Criteria
1,4-Difluorobenzene	90		60-140
Bromochloromethane	93		60-140
chlorobenzene-d5	88		60-140

Project Name: 100 MAIN ST. **Lab Number:** L2316892

Project Number: 12461 **Report Date:** 04/07/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 48,TO-15
Analytical Date: 04/06/23 15:30

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab for sample(s): 01-12 Batch: WG1763671-4								
Dichlorodifluoromethane	ND	0.200	--	ND	0.989	--		1
Chloromethane	ND	0.200	--	ND	0.413	--		1
Freon-114	ND	0.200	--	ND	1.40	--		1
Vinyl chloride	ND	0.200	--	ND	0.511	--		1
1,3-Butadiene	ND	0.200	--	ND	0.442	--		1
Bromomethane	ND	0.200	--	ND	0.777	--		1
Chloroethane	ND	0.200	--	ND	0.528	--		1
Ethanol	ND	5.00	--	ND	9.42	--		1
Vinyl bromide	ND	0.200	--	ND	0.874	--		1
Acetone	ND	1.00	--	ND	2.38	--		1
Trichlorofluoromethane	ND	0.200	--	ND	1.12	--		1
Isopropanol	ND	0.500	--	ND	1.23	--		1
1,1-Dichloroethene	ND	0.200	--	ND	0.793	--		1
Tertiary butyl Alcohol	ND	0.500	--	ND	1.52	--		1
Methylene chloride	ND	0.500	--	ND	1.74	--		1
3-Chloropropene	ND	0.200	--	ND	0.626	--		1
Carbon disulfide	ND	0.200	--	ND	0.623	--		1
Freon-113	ND	0.200	--	ND	1.53	--		1
trans-1,2-Dichloroethene	ND	0.200	--	ND	0.793	--		1
1,1-Dichloroethane	ND	0.200	--	ND	0.809	--		1
Methyl tert butyl ether	ND	0.200	--	ND	0.721	--		1
2-Butanone	ND	0.500	--	ND	1.47	--		1
cis-1,2-Dichloroethene	ND	0.200	--	ND	0.793	--		1
Ethyl Acetate	ND	0.500	--	ND	1.80	--		1
Chloroform	ND	0.200	--	ND	0.977	--		1

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316892
Report Date: 04/07/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 48,TO-15
Analytical Date: 04/06/23 15:30

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab for sample(s): 01-12 Batch: WG1763671-4								
Tetrahydrofuran	ND	0.500	--	ND	1.47	--		1
1,2-Dichloroethane	ND	0.200	--	ND	0.809	--		1
n-Hexane	ND	0.200	--	ND	0.705	--		1
1,1,1-Trichloroethane	ND	0.200	--	ND	1.09	--		1
Benzene	ND	0.200	--	ND	0.639	--		1
Carbon tetrachloride	ND	0.200	--	ND	1.26	--		1
Cyclohexane	ND	0.200	--	ND	0.688	--		1
1,2-Dichloropropane	ND	0.200	--	ND	0.924	--		1
Bromodichloromethane	ND	0.200	--	ND	1.34	--		1
1,4-Dioxane	ND	0.200	--	ND	0.721	--		1
Trichloroethene	ND	0.200	--	ND	1.07	--		1
2,2,4-Trimethylpentane	ND	0.200	--	ND	0.934	--		1
Heptane	ND	0.200	--	ND	0.820	--		1
cis-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
4-Methyl-2-pentanone	ND	0.500	--	ND	2.05	--		1
trans-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
1,1,2-Trichloroethane	ND	0.200	--	ND	1.09	--		1
Toluene	ND	0.200	--	ND	0.754	--		1
2-Hexanone	ND	0.200	--	ND	0.820	--		1
Dibromochloromethane	ND	0.200	--	ND	1.70	--		1
1,2-Dibromoethane	ND	0.200	--	ND	1.54	--		1
Tetrachloroethene	ND	0.200	--	ND	1.36	--		1
Chlorobenzene	ND	0.200	--	ND	0.921	--		1
Ethylbenzene	ND	0.200	--	ND	0.869	--		1
p/m-Xylene	ND	0.400	--	ND	1.74	--		1

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316892
Report Date: 04/07/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 48,TO-15
Analytical Date: 04/06/23 15:30

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab for sample(s): 01-12 Batch: WG1763671-4								
Bromoform	ND	0.200	--	ND	2.07	--		1
Styrene	ND	0.200	--	ND	0.852	--		1
1,1,2,2-Tetrachloroethane	ND	0.200	--	ND	1.37	--		1
o-Xylene	ND	0.200	--	ND	0.869	--		1
4-Ethyltoluene	ND	0.200	--	ND	0.983	--		1
1,3,5-Trimethylbenzene	ND	0.200	--	ND	0.983	--		1
1,2,4-Trimethylbenzene	ND	0.200	--	ND	0.983	--		1
Benzyl chloride	ND	0.200	--	ND	1.04	--		1
1,3-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,4-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,2-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,2,4-Trichlorobenzene	ND	0.200	--	ND	1.48	--		1
Hexachlorobutadiene	ND	0.200	--	ND	2.13	--		1

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316892
Report Date: 04/07/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 48,TO-15-SIM
Analytical Date: 04/06/23 16:09

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air by SIM - Mansfield Lab for sample(s): 01-06 Batch: WG1763672-4								
Vinyl chloride	ND	0.020	--	ND	0.051	--		1
1,1-Dichloroethene	ND	0.020	--	ND	0.079	--		1
cis-1,2-Dichloroethene	ND	0.020	--	ND	0.079	--		1
1,1,1-Trichloroethane	ND	0.020	--	ND	0.109	--		1
Carbon tetrachloride	ND	0.020	--	ND	0.126	--		1
Trichloroethene	ND	0.020	--	ND	0.107	--		1
Tetrachloroethene	ND	0.020	--	ND	0.136	--		1

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316892
Report Date: 04/07/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics in Air - Mansfield Lab Associated sample(s): 01-12 Batch: WG1763671-3								
Dichlorodifluoromethane	109		-		70-130	-		
Chloromethane	98		-		70-130	-		
Freon-114	101		-		70-130	-		
Vinyl chloride	102		-		70-130	-		
1,3-Butadiene	97		-		70-130	-		
Bromomethane	99		-		70-130	-		
Chloroethane	98		-		70-130	-		
Ethanol	102		-		40-160	-		
Vinyl bromide	87		-		70-130	-		
Acetone	98		-		40-160	-		
Trichlorofluoromethane	110		-		70-130	-		
Isopropanol	90		-		40-160	-		
1,1-Dichloroethene	104		-		70-130	-		
Tertiary butyl Alcohol	89		-		70-130	-		
Methylene chloride	95		-		70-130	-		
3-Chloropropene	103		-		70-130	-		
Carbon disulfide	86		-		70-130	-		
Freon-113	97		-		70-130	-		
trans-1,2-Dichloroethene	99		-		70-130	-		
1,1-Dichloroethane	101		-		70-130	-		
Methyl tert butyl ether	89		-		70-130	-		
2-Butanone	100		-		70-130	-		
cis-1,2-Dichloroethene	108		-		70-130	-		

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316892
Report Date: 04/07/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics in Air - Mansfield Lab Associated sample(s): 01-12 Batch: WG1763671-3								
Ethyl Acetate	103		-		70-130	-		
Chloroform	110		-		70-130	-		
Tetrahydrofuran	99		-		70-130	-		
1,2-Dichloroethane	122		-		70-130	-		
n-Hexane	104		-		70-130	-		
1,1,1-Trichloroethane	118		-		70-130	-		
Benzene	97		-		70-130	-		
Carbon tetrachloride	126		-		70-130	-		
Cyclohexane	106		-		70-130	-		
1,2-Dichloropropane	106		-		70-130	-		
Bromodichloromethane	119		-		70-130	-		
1,4-Dioxane	107		-		70-130	-		
Trichloroethene	102		-		70-130	-		
2,2,4-Trimethylpentane	112		-		70-130	-		
Heptane	109		-		70-130	-		
cis-1,3-Dichloropropene	112		-		70-130	-		
4-Methyl-2-pentanone	114		-		70-130	-		
trans-1,3-Dichloropropene	100		-		70-130	-		
1,1,2-Trichloroethane	107		-		70-130	-		
Toluene	84		-		70-130	-		
2-Hexanone	92		-		70-130	-		
Dibromochloromethane	99		-		70-130	-		
1,2-Dibromoethane	92		-		70-130	-		

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316892
Report Date: 04/07/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics in Air - Mansfield Lab Associated sample(s): 01-12 Batch: WG1763671-3								
Tetrachloroethene	84		-		70-130	-		
Chlorobenzene	92		-		70-130	-		
Ethylbenzene	97		-		70-130	-		
p/m-Xylene	98		-		70-130	-		
Bromoform	101		-		70-130	-		
Styrene	93		-		70-130	-		
1,1,2,2-Tetrachloroethane	94		-		70-130	-		
o-Xylene	100		-		70-130	-		
4-Ethyltoluene	95		-		70-130	-		
1,3,5-Trimethylbenzene	98		-		70-130	-		
1,2,4-Trimethylbenzene	98		-		70-130	-		
Benzyl chloride	91		-		70-130	-		
1,3-Dichlorobenzene	89		-		70-130	-		
1,4-Dichlorobenzene	89		-		70-130	-		
1,2-Dichlorobenzene	91		-		70-130	-		
1,2,4-Trichlorobenzene	84		-		70-130	-		
Hexachlorobutadiene	88		-		70-130	-		

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316892
Report Date: 04/07/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics in Air by SIM - Mansfield Lab Associated sample(s): 01-06 Batch: WG1763672-3								
Vinyl chloride	100		-		70-130	-		25
1,1-Dichloroethene	104		-		70-130	-		25
cis-1,2-Dichloroethene	107		-		70-130	-		25
1,1,1-Trichloroethane	118		-		70-130	-		25
Carbon tetrachloride	122		-		70-130	-		25
Trichloroethene	97		-		70-130	-		25
Tetrachloroethene	85		-		70-130	-		25

Lab Duplicate Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316892
Report Date: 04/07/23

Parameter	Native Sample	Duplicate Sample	Units	RPD	Qual	RPD Limits
Volatile Organics in Air - Mansfield Lab Associated sample(s): 01-12 QC Batch ID: WG1763671-5 QC Sample: L2316892-06 Client ID: IA-8						
Dichlorodifluoromethane	0.568	0.574	ppbV	1		25
Chloromethane	0.539	0.533	ppbV	1		25
Freon-114	ND	ND	ppbV	NC		25
1,3-Butadiene	ND	ND	ppbV	NC		25
Bromomethane	ND	ND	ppbV	NC		25
Chloroethane	ND	ND	ppbV	NC		25
Ethanol	ND	ND	ppbV	NC		25
Vinyl bromide	ND	ND	ppbV	NC		25
Acetone	3.67	3.69	ppbV	1		25
Trichlorofluoromethane	0.272	0.269	ppbV	1		25
Isopropanol	ND	ND	ppbV	NC		25
Tertiary butyl Alcohol	ND	ND	ppbV	NC		25
Methylene chloride	ND	ND	ppbV	NC		25
3-Chloropropene	ND	ND	ppbV	NC		25
Carbon disulfide	ND	ND	ppbV	NC		25
Freon-113	ND	ND	ppbV	NC		25
trans-1,2-Dichloroethene	ND	ND	ppbV	NC		25
1,1-Dichloroethane	ND	ND	ppbV	NC		25
Methyl tert butyl ether	ND	ND	ppbV	NC		25
2-Butanone	ND	ND	ppbV	NC		25
Ethyl Acetate	ND	ND	ppbV	NC		25

Lab Duplicate Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316892
Report Date: 04/07/23

Parameter	Native Sample	Duplicate Sample	Units	RPD	Qual	RPD Limits
Volatile Organics in Air - Mansfield Lab Associated sample(s): 01-12 QC Batch ID: WG1763671-5 QC Sample: L2316892-06 Client ID: IA-8						
Chloroform	ND	ND	ppbV	NC		25
Tetrahydrofuran	ND	ND	ppbV	NC		25
1,2-Dichloroethane	ND	ND	ppbV	NC		25
n-Hexane	ND	ND	ppbV	NC		25
Benzene	ND	ND	ppbV	NC		25
Cyclohexane	ND	ND	ppbV	NC		25
1,2-Dichloropropane	ND	ND	ppbV	NC		25
Bromodichloromethane	ND	ND	ppbV	NC		25
1,4-Dioxane	ND	ND	ppbV	NC		25
2,2,4-Trimethylpentane	ND	ND	ppbV	NC		25
Heptane	ND	ND	ppbV	NC		25
cis-1,3-Dichloropropene	ND	ND	ppbV	NC		25
4-Methyl-2-pentanone	ND	ND	ppbV	NC		25
trans-1,3-Dichloropropene	ND	ND	ppbV	NC		25
1,1,2-Trichloroethane	ND	ND	ppbV	NC		25
Toluene	ND	ND	ppbV	NC		25
2-Hexanone	ND	ND	ppbV	NC		25
Dibromochloromethane	ND	ND	ppbV	NC		25
1,2-Dibromoethane	ND	ND	ppbV	NC		25
Chlorobenzene	ND	ND	ppbV	NC		25
Ethylbenzene	ND	ND	ppbV	NC		25

Lab Duplicate Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316892
Report Date: 04/07/23

Parameter	Native Sample	Duplicate Sample	Units	RPD	Qual	RPD Limits
Volatile Organics in Air - Mansfield Lab Associated sample(s): 01-12 QC Batch ID: WG1763671-5 QC Sample: L2316892-06 Client ID: IA-8						
p/m-Xylene	ND	ND	ppbV	NC		25
Bromoform	ND	ND	ppbV	NC		25
Styrene	ND	ND	ppbV	NC		25
1,1,2,2-Tetrachloroethane	ND	ND	ppbV	NC		25
o-Xylene	ND	ND	ppbV	NC		25
4-Ethyltoluene	ND	ND	ppbV	NC		25
1,3,5-Trimethylbenzene	ND	ND	ppbV	NC		25
1,2,4-Trimethylbenzene	ND	ND	ppbV	NC		25
Benzyl chloride	ND	ND	ppbV	NC		25
1,3-Dichlorobenzene	ND	ND	ppbV	NC		25
1,4-Dichlorobenzene	ND	ND	ppbV	NC		25
1,2-Dichlorobenzene	ND	ND	ppbV	NC		25
1,2,4-Trichlorobenzene	ND	ND	ppbV	NC		25
Hexachlorobutadiene	ND	ND	ppbV	NC		25
Volatile Organics in Air by SIM - Mansfield Lab Associated sample(s): 01-06 QC Batch ID: WG1763672-5 QC Sample: L2316892-06 Client ID: IA-8						
Vinyl chloride	ND	ND	ppbV	NC		25
1,1-Dichloroethene	ND	ND	ppbV	NC		25
cis-1,2-Dichloroethene	ND	ND	ppbV	NC		25
1,1,1-Trichloroethane	ND	ND	ppbV	NC		25
Carbon tetrachloride	0.085	0.081	ppbV	5		25
Trichloroethene	ND	ND	ppbV	NC		25
Tetrachloroethene	ND	ND	ppbV	NC		25

Project Name: 100 MAIN ST.

Lab Number: L2316892

Project Number: 12461

Report Date: 04/07/23

Canister and Flow Controller Information

Samplenum	Client ID	Media ID	Media Type	Date Prepared	Bottle Order	Cleaning Batch ID	Can Leak Check	Initial Pressure (in. Hg)	Pressure on Receipt (in. Hg)	Flow Controler Leak Chk	Flow Out mL/min	Flow In mL/min	% RPD
L2316892-01	IA-3	01009	Flow 2	02/23/23	415141		-	-	-	Pass	160	152	5
L2316892-01	IA-3	900	6.0L Can	02/23/23	415141	L2308322-04	Pass	-30.1	-4.1	-	-	-	-
L2316892-02	IA-4	01305	Flow 2	02/23/23	415141		-	-	-	Pass	160	154	4
L2316892-02	IA-4	2367	6.0L Can	02/23/23	415141	L2308322-03	Pass	-30.0	-6.3	-	-	-	-
L2316892-03	IA-5	01746	Flow 2	02/23/23	415141		-	-	-	Pass	160	160	0
L2316892-03	IA-5	3926	6.0L Can	02/23/23	415141	L2308322-04	Pass	-30.2	-6.5	-	-	-	-
L2316892-04	IA-6	01291	Flow 2	02/23/23	415141		-	-	-	Pass	160	147	8
L2316892-04	IA-6	3642	6.0L Can	02/23/23	415141	L2308322-04	Pass	-30.0	-6.6	-	-	-	-
L2316892-05	IA-7	0880	Flow 1	02/23/23	415141		-	-	-	Pass	160	160	0
L2316892-05	IA-7	897	6.0L Can	02/23/23	415141	L2308322-04	Pass	-30.1	-5.6	-	-	-	-
L2316892-06	IA-8	01519	Flow 2	02/23/23	415141		-	-	-	Pass	160	167	4
L2316892-06	IA-8	1552	6.0L Can	02/23/23	415141	L2308322-04	Pass	-30.1	-5.7	-	-	-	-
L2316892-07	SSV-3	01744	Flow 1	02/23/23	415141		-	-	-	Pass	200	209	4
L2316892-07	SSV-3	544	2.7L Can	02/23/23	415141	L2307578-01	Pass	-30.0	0.0	-	-	-	-
L2316892-08	SSV-4	0803	Flow 1	02/23/23	415141		-	-	-	Pass	200	205	2

Project Name: 100 MAIN ST.

Lab Number: L2316892

Project Number: 12461

Report Date: 04/07/23

Canister and Flow Controller Information

Samplenum	Client ID	Media ID	Media Type	Date Prepared	Bottle Order	Cleaning Batch ID	Can Leak Check	Initial Pressure (in. Hg)	Pressure on Receipt (in. Hg)	Flow Controler Leak Chk	Flow Out mL/min	Flow In mL/min	% RPD
L2316892-08	SSV-4	2864	2.7L Can	02/23/23	415141	L2308322-06	Pass	-29.7	-5.0	-	-	-	-
L2316892-09	SSV-5	0872	Flow 1	02/23/23	415141		-	-	-	Pass	200	201	0
L2316892-09	SSV-5	553	2.7L Can	02/23/23	415141	L2308322-06	Pass	-30.1	0.0	-	-	-	-
L2316892-10	SSV-6	01113	Flow 1	02/23/23	415141		-	-	-	Pass	200	205	2
L2316892-10	SSV-6	2356	2.7L Can	02/23/23	415141	L2308322-06	Pass	-30.1	-4.8	-	-	-	-
L2316892-11	SSV-7	0818	Flow 1	02/23/23	415141		-	-	-	Pass	200	205	2
L2316892-11	SSV-7	3095	2.7L Can	02/23/23	415141	L2308322-06	Pass	-29.9	-1.6	-	-	-	-
L2316892-12	SSV-8	01637	Flow 1	02/23/23	415141		-	-	-	Pass	200	207	3
L2316892-12	SSV-8	2045	2.7L Can	02/23/23	415141	L2308322-06	Pass	-29.9	-4.3	-	-	-	-

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2307578
Report Date: 04/07/23

Air Canister Certification Results

Lab ID: L2307578-01
Client ID: CAN 3896 SHELF16
Sample Location:

Date Collected: 02/10/23 22:00
Date Received: 02/11/23
Field Prep: Not Specified

Sample Depth:
Matrix: Air
Anaytical Method: 48,TO-15
Analytical Date: 02/11/23 23:28
Analyst: TJS

	ppbV			ug/m3				
Parameter	**Results**	**RL**	**MDL**	**Results**	**RL**	**MDL**	**Qualifier**	**Dilution Factor**
Volatile Organics in Air - Mansfield Lab								
Chlorodifluoromethane	ND	0.200	--	ND	0.707	--		1
Propylene	ND	0.500	--	ND	0.861	--		1
Propane	ND	0.500	--	ND	0.902	--		1
Dichlorodifluoromethane	ND	0.200	--	ND	0.989	--		1
Chloromethane	ND	0.200	--	ND	0.413	--		1
Freon-114	ND	0.200	--	ND	1.40	--		1
Methanol	ND	5.00	--	ND	6.55	--		1
Vinyl chloride	ND	0.200	--	ND	0.511	--		1
1,3-Butadiene	ND	0.200	--	ND	0.442	--		1
Butane	ND	0.200	--	ND	0.475	--		1
Bromomethane	ND	0.200	--	ND	0.777	--		1
Chloroethane	ND	0.200	--	ND	0.528	--		1
Ethanol	ND	5.00	--	ND	9.42	--		1
Dichlorofluoromethane	ND	0.200	--	ND	0.842	--		1
Vinyl bromide	ND	0.200	--	ND	0.874	--		1
Acrolein	ND	0.500	--	ND	1.15	--		1
Acetone	ND	1.00	--	ND	2.38	--		1
Acetonitrile	ND	0.200	--	ND	0.336	--		1
Trichlorofluoromethane	ND	0.200	--	ND	1.12	--		1
Isopropanol	ND	0.500	--	ND	1.23	--		1
Acrylonitrile	ND	0.500	--	ND	1.09	--		1
Pentane	ND	0.200	--	ND	0.590	--		1
Ethyl ether	ND	0.200	--	ND	0.606	--		1
1,1-Dichloroethene	ND	0.200	--	ND	0.793	--		1

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2307578
Report Date: 04/07/23

Air Canister Certification Results

Lab ID: L2307578-01
Client ID: CAN 3896 SHELF16
Sample Location:

Date Collected: 02/10/23 22:00
Date Received: 02/11/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
Tertiary butyl Alcohol	ND	0.500	--	ND	1.52	--		1
Methylene chloride	ND	0.500	--	ND	1.74	--		1
3-Chloropropene	ND	0.200	--	ND	0.626	--		1
Carbon disulfide	ND	0.200	--	ND	0.623	--		1
Freon-113	ND	0.200	--	ND	1.53	--		1
trans-1,2-Dichloroethene	ND	0.200	--	ND	0.793	--		1
1,1-Dichloroethane	ND	0.200	--	ND	0.809	--		1
Methyl tert butyl ether	ND	0.200	--	ND	0.721	--		1
Xylenes, total	ND	0.600	--	ND	0.869	--		1
Vinyl acetate	ND	1.00	--	ND	3.52	--		1
2-Butanone	ND	0.500	--	ND	1.47	--		1
cis-1,2-Dichloroethene	ND	0.200	--	ND	0.793	--		1
Ethyl Acetate	ND	0.500	--	ND	1.80	--		1
Chloroform	ND	0.200	--	ND	0.977	--		1
Tetrahydrofuran	ND	0.500	--	ND	1.47	--		1
2,2-Dichloropropane	ND	0.200	--	ND	0.924	--		1
1,2-Dichloroethane	ND	0.200	--	ND	0.809	--		1
n-Hexane	ND	0.200	--	ND	0.705	--		1
Diisopropyl ether	ND	0.200	--	ND	0.836	--		1
1,2-Dichloroethene (total)	ND	1.00	--	ND	1.00	--		1
tert-Butyl Ethyl Ether	ND	0.200	--	ND	0.836	--		1
1,1,1-Trichloroethane	ND	0.200	--	ND	1.09	--		1
1,1-Dichloropropene	ND	0.200	--	ND	0.908	--		1
Benzene	ND	0.200	--	ND	0.639	--		1
Carbon tetrachloride	ND	0.200	--	ND	1.26	--		1
Cyclohexane	ND	0.200	--	ND	0.688	--		1
tert-Amyl Methyl Ether	ND	0.200	--	ND	0.836	--		1

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2307578
Report Date: 04/07/23

Air Canister Certification Results

Lab ID: L2307578-01
Client ID: CAN 3896 SHELF16
Sample Location:

Date Collected: 02/10/23 22:00
Date Received: 02/11/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
Dibromomethane	ND	0.200	--	ND	1.42	--		1
1,2-Dichloropropane	ND	0.200	--	ND	0.924	--		1
Bromodichloromethane	ND	0.200	--	ND	1.34	--		1
1,4-Dioxane	ND	0.200	--	ND	0.721	--		1
Trichloroethene	ND	0.200	--	ND	1.07	--		1
2,2,4-Trimethylpentane	ND	0.200	--	ND	0.934	--		1
Methyl Methacrylate	ND	0.500	--	ND	2.05	--		1
Heptane	ND	0.200	--	ND	0.820	--		1
cis-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
4-Methyl-2-pentanone	ND	0.500	--	ND	2.05	--		1
trans-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
1,1,2-Trichloroethane	ND	0.200	--	ND	1.09	--		1
Toluene	ND	0.200	--	ND	0.754	--		1
1,3-Dichloropropane	ND	0.200	--	ND	0.924	--		1
2-Hexanone	ND	0.200	--	ND	0.820	--		1
Dibromochloromethane	ND	0.200	--	ND	1.70	--		1
1,2-Dibromoethane	ND	0.200	--	ND	1.54	--		1
Butyl acetate	ND	0.500	--	ND	2.38	--		1
Octane	ND	0.200	--	ND	0.934	--		1
Tetrachloroethene	ND	0.200	--	ND	1.36	--		1
1,1,1,2-Tetrachloroethane	ND	0.200	--	ND	1.37	--		1
Chlorobenzene	ND	0.200	--	ND	0.921	--		1
Ethylbenzene	ND	0.200	--	ND	0.869	--		1
p/m-Xylene	ND	0.400	--	ND	1.74	--		1
Bromoform	ND	0.200	--	ND	2.07	--		1
Styrene	ND	0.200	--	ND	0.852	--		1
1,1,2,2-Tetrachloroethane	ND	0.200	--	ND	1.37	--		1

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2307578
Report Date: 04/07/23

Air Canister Certification Results

Lab ID: L2307578-01
Client ID: CAN 3896 SHELF16
Sample Location:

Date Collected: 02/10/23 22:00
Date Received: 02/11/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
o-Xylene	ND	0.200	--	ND	0.869	--		1
1,2,3-Trichloropropane	ND	0.200	--	ND	1.21	--		1
Nonane	ND	0.200	--	ND	1.05	--		1
Isopropylbenzene	ND	0.200	--	ND	0.983	--		1
Bromobenzene	ND	0.200	--	ND	0.793	--		1
2-Chlorotoluene	ND	0.200	--	ND	1.04	--		1
n-Propylbenzene	ND	0.200	--	ND	0.983	--		1
4-Chlorotoluene	ND	0.200	--	ND	1.04	--		1
4-Ethyltoluene	ND	0.200	--	ND	0.983	--		1
1,3,5-Trimethylbenzene	ND	0.200	--	ND	0.983	--		1
tert-Butylbenzene	ND	0.200	--	ND	1.10	--		1
1,2,4-Trimethylbenzene	ND	0.200	--	ND	0.983	--		1
Decane	ND	0.200	--	ND	1.16	--		1
Benzyl chloride	ND	0.200	--	ND	1.04	--		1
1,3-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,4-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
sec-Butylbenzene	ND	0.200	--	ND	1.10	--		1
1,2,3-Trimethylbenzene	ND	0.200	--	ND	0.983	--		1
p-Isopropyltoluene	ND	0.200	--	ND	1.10	--		1
1,2-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
n-Butylbenzene	ND	0.200	--	ND	1.10	--		1
1,2-Dibromo-3-chloropropane	ND	0.200	--	ND	1.93	--		1
Undecane	ND	0.200	--	ND	1.28	--		1
Dodecane	ND	0.200	--	ND	1.39	--		1
1,2,4-Trichlorobenzene	ND	0.200	--	ND	1.48	--		1
Naphthalene	ND	0.200	--	ND	1.05	--		1
1,2,3-Trichlorobenzene	ND	0.200	--	ND	1.48	--		1

Project Name: BATCH CANISTER CERTIFICATION **Lab Number:** L2307578

Project Number: CANISTER QC BAT **Report Date:** 04/07/23

Air Canister Certification Results

Lab ID: L2307578-01
Client ID: CAN 3896 SHELF16
Sample Location:

Date Collected: 02/10/23 22:00
Date Received: 02/11/23
Field Prep: Not Specified

Sample Depth:

	ppbV			ug/m3				
Parameter	**Results**	**RL**	**MDL**	**Results**	**RL**	**MDL**	**Qualifier**	**Dilution Factor**
Volatile Organics in Air - Mansfield Lab								
Hexachlorobutadiene	ND	0.200	--	ND	2.13	--		1

	Results	**Qualifier**	**Units**	**RDL**	**Dilution Factor**
Tentatively Identified Compounds					

No Tentatively Identified Compounds

Internal Standard	**% Recovery**	**Qualifier**	**Acceptance Criteria**
1,4-Difluorobenzene	97		60-140
Bromochloromethane	98		60-140
chlorobenzene-d5	99		60-140

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2307578
Report Date: 04/07/23

Air Canister Certification Results

Lab ID: L2307578-01
Client ID: CAN 3896 SHELF16
Sample Location:

Date Collected: 02/10/23 22:00
Date Received: 02/11/23
Field Prep: Not Specified

Sample Depth:
Matrix: Air
Anaytical Method: 48,TO-15-SIM
Analytical Date: 02/11/23 23:28
Analyst: TJS

	ppbV			ug/m3				
Parameter	**Results**	**RL**	**MDL**	**Results**	**RL**	**MDL**	**Qualifier**	**Dilution Factor**
Volatile Organics in Air by SIM - Mansfield Lab								
Dichlorodifluoromethane	ND	0.200	--	ND	0.989	--		1
Chloromethane	ND	0.200	--	ND	0.413	--		1
Freon-114	ND	0.050	--	ND	0.349	--		1
Vinyl chloride	ND	0.020	--	ND	0.051	--		1
1,3-Butadiene	ND	0.020	--	ND	0.044	--		1
Bromomethane	ND	0.020	--	ND	0.078	--		1
Chloroethane	ND	0.100	--	ND	0.264	--		1
Acrolein	ND	0.050	--	ND	0.115	--		1
Acetone	ND	1.00	--	ND	2.38	--		1
Trichlorofluoromethane	ND	0.050	--	ND	0.281	--		1
Acrylonitrile	ND	0.500	--	ND	1.09	--		1
1,1-Dichloroethene	ND	0.020	--	ND	0.079	--		1
Methylene chloride	ND	0.500	--	ND	1.74	--		1
Freon-113	ND	0.050	--	ND	0.383	--		1
trans-1,2-Dichloroethene	ND	0.020	--	ND	0.079	--		1
1,1-Dichloroethane	ND	0.020	--	ND	0.081	--		1
Methyl tert butyl ether	ND	0.200	--	ND	0.721	--		1
2-Butanone	ND	0.500	--	ND	1.47	--		1
cis-1,2-Dichloroethene	ND	0.020	--	ND	0.079	--		1
Chloroform	ND	0.020	--	ND	0.098	--		1
1,2-Dichloroethane	ND	0.020	--	ND	0.081	--		1
1,1,1-Trichloroethane	ND	0.020	--	ND	0.109	--		1
Benzene	ND	0.100	--	ND	0.319	--		1
Carbon tetrachloride	ND	0.020	--	ND	0.126	--		1

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2307578
Report Date: 04/07/23

Air Canister Certification Results

Lab ID: L2307578-01
Client ID: CAN 3896 SHELF16
Sample Location:

Date Collected: 02/10/23 22:00
Date Received: 02/11/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air by SIM - Mansfield Lab								
1,2-Dichloropropane	ND	0.020	--	ND	0.092	--		1
Bromodichloromethane	ND	0.020	--	ND	0.134	--		1
1,4-Dioxane	ND	0.100	--	ND	0.360	--		1
Trichloroethene	ND	0.020	--	ND	0.107	--		1
cis-1,3-Dichloropropene	ND	0.020	--	ND	0.091	--		1
4-Methyl-2-pentanone	ND	0.500	--	ND	2.05	--		1
trans-1,3-Dichloropropene	ND	0.020	--	ND	0.091	--		1
1,1,2-Trichloroethane	ND	0.020	--	ND	0.109	--		1
Toluene	ND	0.100	--	ND	0.377	--		1
Dibromochloromethane	ND	0.020	--	ND	0.170	--		1
1,2-Dibromoethane	ND	0.020	--	ND	0.154	--		1
Tetrachloroethene	ND	0.020	--	ND	0.136	--		1
1,1,1,2-Tetrachloroethane	ND	0.020	--	ND	0.137	--		1
Chlorobenzene	ND	0.100	--	ND	0.461	--		1
Ethylbenzene	ND	0.020	--	ND	0.087	--		1
p/m-Xylene	ND	0.040	--	ND	0.174	--		1
Bromoform	ND	0.020	--	ND	0.207	--		1
Styrene	ND	0.020	--	ND	0.085	--		1
1,1,2,2-Tetrachloroethane	ND	0.020	--	ND	0.137	--		1
o-Xylene	ND	0.020	--	ND	0.087	--		1
Isopropylbenzene	ND	0.200	--	ND	0.983	--		1
4-Ethyltoluene	ND	0.020	--	ND	0.098	--		1
1,3,5-Trimethybenzene	ND	0.020	--	ND	0.098	--		1
1,2,4-Trimethylbenzene	ND	0.020	--	ND	0.098	--		1
Benzyl chloride	ND	0.100	--	ND	0.518	--		1
1,3-Dichlorobenzene	ND	0.020	--	ND	0.120	--		1
1,4-Dichlorobenzene	ND	0.020	--	ND	0.120	--		1

Project Name: BATCH CANISTER CERTIFICATION **Lab Number:** L2307578

Project Number: CANISTER QC BAT **Report Date:** 04/07/23

Air Canister Certification Results

Lab ID: L2307578-01
Client ID: CAN 3896 SHELF16
Sample Location:

Date Collected: 02/10/23 22:00
Date Received: 02/11/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air by SIM - Mansfield Lab								
sec-Butylbenzene	ND	0.200	--	ND	1.10	--		1
p-Isopropyltoluene	ND	0.200	--	ND	1.10	--		1
1,2-Dichlorobenzene	ND	0.020	--	ND	0.120	--		1
n-Butylbenzene	ND	0.200	--	ND	1.10	--		1
1,2,4-Trichlorobenzene	ND	0.050	--	ND	0.371	--		1
Naphthalene	ND	0.050	--	ND	0.262	--		1
1,2,3-Trichlorobenzene	ND	0.050	--	ND	0.371	--		1
Hexachlorobutadiene	ND	0.050	--	ND	0.533	--		1

Internal Standard	% Recovery	Qualifier	Acceptance Criteria
1,4-difluorobenzene	100		60-140
bromochloromethane	100		60-140
chlorobenzene-d5	100		60-140

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2308322
Report Date: 04/07/23

Air Canister Certification Results

Lab ID: L2308322-03
Client ID: CAN 2486 SHELF 46
Sample Location:

Date Collected: 02/15/23 18:00
Date Received: 02/16/23
Field Prep: Not Specified

Sample Depth:
Matrix: Air
Anaytical Method: 48,TO-15
Analytical Date: 02/16/23 19:55
Analyst: RAY

	ppbV			ug/m3				
Parameter	**Results**	**RL**	**MDL**	**Results**	**RL**	**MDL**	**Qualifier**	**Dilution Factor**
Volatile Organics in Air - Mansfield Lab								
Chlorodifluoromethane	ND	0.200	--	ND	0.707	--		1
Propylene	ND	0.500	--	ND	0.861	--		1
Propane	ND	0.500	--	ND	0.902	--		1
Dichlorodifluoromethane	ND	0.200	--	ND	0.989	--		1
Chloromethane	ND	0.200	--	ND	0.413	--		1
Freon-114	ND	0.200	--	ND	1.40	--		1
Methanol	ND	5.00	--	ND	6.55	--		1
Vinyl chloride	ND	0.200	--	ND	0.511	--		1
1,3-Butadiene	ND	0.200	--	ND	0.442	--		1
Butane	ND	0.200	--	ND	0.475	--		1
Bromomethane	ND	0.200	--	ND	0.777	--		1
Chloroethane	ND	0.200	--	ND	0.528	--		1
Ethanol	ND	5.00	--	ND	9.42	--		1
Dichlorofluoromethane	ND	0.200	--	ND	0.842	--		1
Vinyl bromide	ND	0.200	--	ND	0.874	--		1
Acrolein	ND	0.500	--	ND	1.15	--		1
Acetone	ND	1.00	--	ND	2.38	--		1
Acetonitrile	ND	0.200	--	ND	0.336	--		1
Trichlorofluoromethane	ND	0.200	--	ND	1.12	--		1
Isopropanol	ND	0.500	--	ND	1.23	--		1
Acrylonitrile	ND	0.500	--	ND	1.09	--		1
Pentane	ND	0.200	--	ND	0.590	--		1
Ethyl ether	ND	0.200	--	ND	0.606	--		1
1,1-Dichloroethene	ND	0.200	--	ND	0.793	--		1

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2308322
Report Date: 04/07/23

Air Canister Certification Results

Lab ID: L2308322-03
Client ID: CAN 2486 SHELF 46
Sample Location:

Date Collected: 02/15/23 18:00
Date Received: 02/16/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
Tertiary butyl Alcohol	ND	0.500	--	ND	1.52	--		1
Methylene chloride	ND	0.500	--	ND	1.74	--		1
3-Chloropropene	ND	0.200	--	ND	0.626	--		1
Carbon disulfide	ND	0.200	--	ND	0.623	--		1
Freon-113	ND	0.200	--	ND	1.53	--		1
trans-1,2-Dichloroethene	ND	0.200	--	ND	0.793	--		1
1,1-Dichloroethane	ND	0.200	--	ND	0.809	--		1
Methyl tert butyl ether	ND	0.200	--	ND	0.721	--		1
Vinyl acetate	ND	1.00	--	ND	3.52	--		1
2-Butanone	ND	0.500	--	ND	1.47	--		1
Xylenes, total	ND	0.600	--	ND	0.869	--		1
cis-1,2-Dichloroethene	ND	0.200	--	ND	0.793	--		1
Ethyl Acetate	ND	0.500	--	ND	1.80	--		1
Chloroform	ND	0.200	--	ND	0.977	--		1
Tetrahydrofuran	ND	0.500	--	ND	1.47	--		1
2,2-Dichloropropane	ND	0.200	--	ND	0.924	--		1
1,2-Dichloroethane	ND	0.200	--	ND	0.809	--		1
n-Hexane	ND	0.200	--	ND	0.705	--		1
Diisopropyl ether	ND	0.200	--	ND	0.836	--		1
tert-Butyl Ethyl Ether	ND	0.200	--	ND	0.836	--		1
1,2-Dichloroethene (total)	ND	1.00	--	ND	1.00	--		1
1,1,1-Trichloroethane	ND	0.200	--	ND	1.09	--		1
1,1-Dichloropropene	ND	0.200	--	ND	0.908	--		1
Benzene	ND	0.200	--	ND	0.639	--		1
Carbon tetrachloride	ND	0.200	--	ND	1.26	--		1
Cyclohexane	ND	0.200	--	ND	0.688	--		1
tert-Amyl Methyl Ether	ND	0.200	--	ND	0.836	--		1

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2308322
Report Date: 04/07/23

Air Canister Certification Results

Lab ID: L2308322-03
Client ID: CAN 2486 SHELF 46
Sample Location:

Date Collected: 02/15/23 18:00
Date Received: 02/16/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
Dibromomethane	ND	0.200	--	ND	1.42	--		1
1,2-Dichloropropane	ND	0.200	--	ND	0.924	--		1
Bromodichloromethane	ND	0.200	--	ND	1.34	--		1
1,4-Dioxane	ND	0.200	--	ND	0.721	--		1
Trichloroethene	ND	0.200	--	ND	1.07	--		1
2,2,4-Trimethylpentane	ND	0.200	--	ND	0.934	--		1
Methyl Methacrylate	ND	0.500	--	ND	2.05	--		1
Heptane	ND	0.200	--	ND	0.820	--		1
cis-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
4-Methyl-2-pentanone	ND	0.500	--	ND	2.05	--		1
trans-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
1,1,2-Trichloroethane	ND	0.200	--	ND	1.09	--		1
Toluene	ND	0.200	--	ND	0.754	--		1
1,3-Dichloropropane	ND	0.200	--	ND	0.924	--		1
2-Hexanone	ND	0.200	--	ND	0.820	--		1
Dibromochloromethane	ND	0.200	--	ND	1.70	--		1
1,2-Dibromoethane	ND	0.200	--	ND	1.54	--		1
Butyl acetate	ND	0.500	--	ND	2.38	--		1
Octane	ND	0.200	--	ND	0.934	--		1
Tetrachloroethene	ND	0.200	--	ND	1.36	--		1
1,1,1,2-Tetrachloroethane	ND	0.200	--	ND	1.37	--		1
Chlorobenzene	ND	0.200	--	ND	0.921	--		1
Ethylbenzene	ND	0.200	--	ND	0.869	--		1
p/m-Xylene	ND	0.400	--	ND	1.74	--		1
Bromoform	ND	0.200	--	ND	2.07	--		1
Styrene	ND	0.200	--	ND	0.852	--		1
1,1,2,2-Tetrachloroethane	ND	0.200	--	ND	1.37	--		1

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2308322
Report Date: 04/07/23

Air Canister Certification Results

Lab ID: L2308322-03
Client ID: CAN 2486 SHELF 46
Sample Location:

Date Collected: 02/15/23 18:00
Date Received: 02/16/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
o-Xylene	ND	0.200	--	ND	0.869	--		1
1,2,3-Trichloropropane	ND	0.200	--	ND	1.21	--		1
Nonane	ND	0.200	--	ND	1.05	--		1
Isopropylbenzene	ND	0.200	--	ND	0.983	--		1
Bromobenzene	ND	0.200	--	ND	0.793	--		1
2-Chlorotoluene	ND	0.200	--	ND	1.04	--		1
n-Propylbenzene	ND	0.200	--	ND	0.983	--		1
4-Chlorotoluene	ND	0.200	--	ND	1.04	--		1
4-Ethyltoluene	ND	0.200	--	ND	0.983	--		1
1,3,5-Trimethylbenzene	ND	0.200	--	ND	0.983	--		1
tert-Butylbenzene	ND	0.200	--	ND	1.10	--		1
1,2,4-Trimethylbenzene	ND	0.200	--	ND	0.983	--		1
Decane	ND	0.200	--	ND	1.16	--		1
Benzyl chloride	ND	0.200	--	ND	1.04	--		1
1,3-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,4-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
sec-Butylbenzene	ND	0.200	--	ND	1.10	--		1
p-Isopropyltoluene	ND	0.200	--	ND	1.10	--		1
1,2-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
n-Butylbenzene	ND	0.200	--	ND	1.10	--		1
1,2-Dibromo-3-chloropropane	ND	0.200	--	ND	1.93	--		1
Undecane	ND	0.200	--	ND	1.28	--		1
Dodecane	ND	0.200	--	ND	1.39	--		1
1,2,4-Trichlorobenzene	ND	0.200	--	ND	1.48	--		1
Naphthalene	ND	0.200	--	ND	1.05	--		1
1,2,3-Trichlorobenzene	ND	0.200	--	ND	1.48	--		1
Hexachlorobutadiene	ND	0.200	--	ND	2.13	--		1

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2308322
Report Date: 04/07/23

Air Canister Certification Results

Lab ID: L2308322-03
Client ID: CAN 2486 SHELF 46
Sample Location:

Date Collected: 02/15/23 18:00
Date Received: 02/16/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								

	Results	Qualifier	Units	RDL	Dilution Factor
Tentatively Identified Compounds					

No Tentatively Identified Compounds

Internal Standard	% Recovery	Qualifier	Acceptance Criteria
1,4-Difluorobenzene	100		60-140
Bromochloromethane	104		60-140
chlorobenzene-d5	100		60-140

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2308322
Report Date: 04/07/23

Air Canister Certification Results

Lab ID: L2308322-03
Client ID: CAN 2486 SHELF 46
Sample Location:

Date Collected: 02/15/23 18:00
Date Received: 02/16/23
Field Prep: Not Specified

Sample Depth:
Matrix: Air
Anaytical Method: 48,TO-15-SIM
Analytical Date: 02/16/23 19:55
Analyst: RAY

	ppbV			ug/m3				
Parameter	**Results**	**RL**	**MDL**	**Results**	**RL**	**MDL**	**Qualifier**	**Dilution Factor**
Volatile Organics in Air by SIM - Mansfield Lab								
Dichlorodifluoromethane	ND	0.200	--	ND	0.989	--		1
Chloromethane	ND	0.200	--	ND	0.413	--		1
Freon-114	ND	0.050	--	ND	0.349	--		1
Vinyl chloride	ND	0.020	--	ND	0.051	--		1
1,3-Butadiene	ND	0.020	--	ND	0.044	--		1
Bromomethane	ND	0.020	--	ND	0.078	--		1
Chloroethane	ND	0.100	--	ND	0.264	--		1
Acrolein	ND	0.050	--	ND	0.115	--		1
Acetone	ND	1.00	--	ND	2.38	--		1
Trichlorofluoromethane	ND	0.050	--	ND	0.281	--		1
Acrylonitrile	ND	0.500	--	ND	1.09	--		1
1,1-Dichloroethene	ND	0.020	--	ND	0.079	--		1
Methylene chloride	ND	0.500	--	ND	1.74	--		1
Freon-113	ND	0.050	--	ND	0.383	--		1
trans-1,2-Dichloroethene	ND	0.020	--	ND	0.079	--		1
1,1-Dichloroethane	ND	0.020	--	ND	0.081	--		1
Methyl tert butyl ether	ND	0.200	--	ND	0.721	--		1
2-Butanone	ND	0.500	--	ND	1.47	--		1
cis-1,2-Dichloroethene	ND	0.020	--	ND	0.079	--		1
Chloroform	ND	0.020	--	ND	0.098	--		1
1,2-Dichloroethane	ND	0.020	--	ND	0.081	--		1
1,1,1-Trichloroethane	ND	0.020	--	ND	0.109	--		1
Benzene	ND	0.100	--	ND	0.319	--		1
Carbon tetrachloride	ND	0.020	--	ND	0.126	--		1

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2308322
Report Date: 04/07/23

Air Canister Certification Results

Lab ID: L2308322-03
Client ID: CAN 2486 SHELF 46
Sample Location:

Date Collected: 02/15/23 18:00
Date Received: 02/16/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air by SIM - Mansfield Lab								
1,2-Dichloropropane	ND	0.020	--	ND	0.092	--		1
Bromodichloromethane	ND	0.020	--	ND	0.134	--		1
1,4-Dioxane	ND	0.100	--	ND	0.360	--		1
Trichloroethene	ND	0.020	--	ND	0.107	--		1
cis-1,3-Dichloropropene	ND	0.020	--	ND	0.091	--		1
4-Methyl-2-pentanone	ND	0.500	--	ND	2.05	--		1
trans-1,3-Dichloropropene	ND	0.020	--	ND	0.091	--		1
1,1,2-Trichloroethane	ND	0.020	--	ND	0.109	--		1
Toluene	ND	0.100	--	ND	0.377	--		1
Dibromochloromethane	ND	0.020	--	ND	0.170	--		1
1,2-Dibromoethane	ND	0.020	--	ND	0.154	--		1
Tetrachloroethene	ND	0.020	--	ND	0.136	--		1
1,1,1,2-Tetrachloroethane	ND	0.020	--	ND	0.137	--		1
Chlorobenzene	ND	0.100	--	ND	0.461	--		1
Ethylbenzene	ND	0.020	--	ND	0.087	--		1
p/m-Xylene	ND	0.040	--	ND	0.174	--		1
Bromoform	ND	0.020	--	ND	0.207	--		1
Styrene	ND	0.020	--	ND	0.085	--		1
1,1,2,2-Tetrachloroethane	ND	0.020	--	ND	0.137	--		1
o-Xylene	ND	0.020	--	ND	0.087	--		1
Isopropylbenzene	ND	0.200	--	ND	0.983	--		1
4-Ethyltoluene	ND	0.020	--	ND	0.098	--		1
1,3,5-Trimethybenzene	ND	0.020	--	ND	0.098	--		1
1,2,4-Trimethylbenzene	ND	0.020	--	ND	0.098	--		1
Benzyl chloride	ND	0.100	--	ND	0.518	--		1
1,3-Dichlorobenzene	ND	0.020	--	ND	0.120	--		1
1,4-Dichlorobenzene	ND	0.020	--	ND	0.120	--		1

Project Name: BATCH CANISTER CERTIFICATION **Lab Number:** L2308322

Project Number: CANISTER QC BAT **Report Date:** 04/07/23

Air Canister Certification Results

Lab ID: L2308322-03
Client ID: CAN 2486 SHELF 46
Sample Location:

Date Collected: 02/15/23 18:00
Date Received: 02/16/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air by SIM - Mansfield Lab								
sec-Butylbenzene	ND	0.200	--	ND	1.10	--		1
p-Isopropyltoluene	ND	0.200	--	ND	1.10	--		1
1,2-Dichlorobenzene	ND	0.020	--	ND	0.120	--		1
n-Butylbenzene	ND	0.200	--	ND	1.10	--		1
1,2,4-Trichlorobenzene	ND	0.050	--	ND	0.371	--		1
Naphthalene	ND	0.050	--	ND	0.262	--		1
1,2,3-Trichlorobenzene	ND	0.050	--	ND	0.371	--		1
Hexachlorobutadiene	ND	0.050	--	ND	0.533	--		1

Internal Standard	% Recovery	Qualifier	Acceptance Criteria
1,4-difluorobenzene	99		60-140
bromochloromethane	105		60-140
chlorobenzene-d5	98		60-140

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2308322
Report Date: 04/07/23

Air Canister Certification Results

Lab ID: L2308322-04
Client ID: CAN 1707 SHELF 47
Sample Location:

Date Collected: 02/15/23 18:00
Date Received: 02/16/23
Field Prep: Not Specified

Sample Depth:
Matrix: Air
Anaytical Method: 48,TO-15
Analytical Date: 02/16/23 20:34
Analyst: RAY

	ppbV			ug/m3				
Parameter	**Results**	**RL**	**MDL**	**Results**	**RL**	**MDL**	**Qualifier**	**Dilution Factor**
Volatile Organics in Air - Mansfield Lab								
Chlorodifluoromethane	ND	0.200	--	ND	0.707	--		1
Propylene	ND	0.500	--	ND	0.861	--		1
Propane	ND	0.500	--	ND	0.902	--		1
Dichlorodifluoromethane	ND	0.200	--	ND	0.989	--		1
Chloromethane	ND	0.200	--	ND	0.413	--		1
Freon-114	ND	0.200	--	ND	1.40	--		1
Methanol	ND	5.00	--	ND	6.55	--		1
Vinyl chloride	ND	0.200	--	ND	0.511	--		1
1,3-Butadiene	ND	0.200	--	ND	0.442	--		1
Butane	ND	0.200	--	ND	0.475	--		1
Bromomethane	ND	0.200	--	ND	0.777	--		1
Chloroethane	ND	0.200	--	ND	0.528	--		1
Ethanol	ND	5.00	--	ND	9.42	--		1
Dichlorofluoromethane	ND	0.200	--	ND	0.842	--		1
Vinyl bromide	ND	0.200	--	ND	0.874	--		1
Acrolein	ND	0.500	--	ND	1.15	--		1
Acetone	ND	1.00	--	ND	2.38	--		1
Acetonitrile	ND	0.200	--	ND	0.336	--		1
Trichlorofluoromethane	ND	0.200	--	ND	1.12	--		1
Isopropanol	ND	0.500	--	ND	1.23	--		1
Acrylonitrile	ND	0.500	--	ND	1.09	--		1
Pentane	ND	0.200	--	ND	0.590	--		1
Ethyl ether	ND	0.200	--	ND	0.606	--		1
1,1-Dichloroethene	ND	0.200	--	ND	0.793	--		1

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2308322
Report Date: 04/07/23

Air Canister Certification Results

Lab ID: L2308322-04
Client ID: CAN 1707 SHELF 47
Sample Location:

Date Collected: 02/15/23 18:00
Date Received: 02/16/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
Tertiary butyl Alcohol	ND	0.500	--	ND	1.52	--		1
Methylene chloride	ND	0.500	--	ND	1.74	--		1
3-Chloropropene	ND	0.200	--	ND	0.626	--		1
Carbon disulfide	ND	0.200	--	ND	0.623	--		1
Freon-113	ND	0.200	--	ND	1.53	--		1
trans-1,2-Dichloroethene	ND	0.200	--	ND	0.793	--		1
1,1-Dichloroethane	ND	0.200	--	ND	0.809	--		1
Methyl tert butyl ether	ND	0.200	--	ND	0.721	--		1
Vinyl acetate	ND	1.00	--	ND	3.52	--		1
Xylenes, total	ND	0.600	--	ND	0.869	--		1
2-Butanone	ND	0.500	--	ND	1.47	--		1
cis-1,2-Dichloroethene	ND	0.200	--	ND	0.793	--		1
Ethyl Acetate	ND	0.500	--	ND	1.80	--		1
Chloroform	ND	0.200	--	ND	0.977	--		1
Tetrahydrofuran	ND	0.500	--	ND	1.47	--		1
2,2-Dichloropropane	ND	0.200	--	ND	0.924	--		1
1,2-Dichloroethane	ND	0.200	--	ND	0.809	--		1
n-Hexane	ND	0.200	--	ND	0.705	--		1
Diisopropyl ether	ND	0.200	--	ND	0.836	--		1
tert-Butyl Ethyl Ether	ND	0.200	--	ND	0.836	--		1
1,2-Dichloroethene (total)	ND	1.00	--	ND	1.00	--		1
1,1,1-Trichloroethane	ND	0.200	--	ND	1.09	--		1
1,1-Dichloropropene	ND	0.200	--	ND	0.908	--		1
Benzene	ND	0.200	--	ND	0.639	--		1
Carbon tetrachloride	ND	0.200	--	ND	1.26	--		1
Cyclohexane	ND	0.200	--	ND	0.688	--		1
tert-Amyl Methyl Ether	ND	0.200	--	ND	0.836	--		1

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2308322
Report Date: 04/07/23

Air Canister Certification Results

Lab ID: L2308322-04
Client ID: CAN 1707 SHELF 47
Sample Location:

Date Collected: 02/15/23 18:00
Date Received: 02/16/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
Dibromomethane	ND	0.200	--	ND	1.42	--		1
1,2-Dichloropropane	ND	0.200	--	ND	0.924	--		1
Bromodichloromethane	ND	0.200	--	ND	1.34	--		1
1,4-Dioxane	ND	0.200	--	ND	0.721	--		1
Trichloroethene	ND	0.200	--	ND	1.07	--		1
2,2,4-Trimethylpentane	ND	0.200	--	ND	0.934	--		1
Methyl Methacrylate	ND	0.500	--	ND	2.05	--		1
Heptane	ND	0.200	--	ND	0.820	--		1
cis-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
4-Methyl-2-pentanone	ND	0.500	--	ND	2.05	--		1
trans-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
1,1,2-Trichloroethane	ND	0.200	--	ND	1.09	--		1
Toluene	ND	0.200	--	ND	0.754	--		1
1,3-Dichloropropane	ND	0.200	--	ND	0.924	--		1
2-Hexanone	ND	0.200	--	ND	0.820	--		1
Dibromochloromethane	ND	0.200	--	ND	1.70	--		1
1,2-Dibromoethane	ND	0.200	--	ND	1.54	--		1
Butyl acetate	ND	0.500	--	ND	2.38	--		1
Octane	ND	0.200	--	ND	0.934	--		1
Tetrachloroethene	ND	0.200	--	ND	1.36	--		1
1,1,1,2-Tetrachloroethane	ND	0.200	--	ND	1.37	--		1
Chlorobenzene	ND	0.200	--	ND	0.921	--		1
Ethylbenzene	ND	0.200	--	ND	0.869	--		1
p/m-Xylene	ND	0.400	--	ND	1.74	--		1
Bromoform	ND	0.200	--	ND	2.07	--		1
Styrene	ND	0.200	--	ND	0.852	--		1
1,1,2,2-Tetrachloroethane	ND	0.200	--	ND	1.37	--		1

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2308322
Report Date: 04/07/23

Air Canister Certification Results

Lab ID: L2308322-04
Client ID: CAN 1707 SHELF 47
Sample Location:

Date Collected: 02/15/23 18:00
Date Received: 02/16/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
o-Xylene	ND	0.200	--	ND	0.869	--		1
1,2,3-Trichloropropane	ND	0.200	--	ND	1.21	--		1
Nonane	ND	0.200	--	ND	1.05	--		1
Isopropylbenzene	ND	0.200	--	ND	0.983	--		1
Bromobenzene	ND	0.200	--	ND	0.793	--		1
2-Chlorotoluene	ND	0.200	--	ND	1.04	--		1
n-Propylbenzene	ND	0.200	--	ND	0.983	--		1
4-Chlorotoluene	ND	0.200	--	ND	1.04	--		1
4-Ethyltoluene	ND	0.200	--	ND	0.983	--		1
1,3,5-Trimethylbenzene	ND	0.200	--	ND	0.983	--		1
tert-Butylbenzene	ND	0.200	--	ND	1.10	--		1
1,2,4-Trimethylbenzene	ND	0.200	--	ND	0.983	--		1
Decane	ND	0.200	--	ND	1.16	--		1
Benzyl chloride	ND	0.200	--	ND	1.04	--		1
1,3-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,4-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
sec-Butylbenzene	ND	0.200	--	ND	1.10	--		1
p-Isopropyltoluene	ND	0.200	--	ND	1.10	--		1
1,2-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
n-Butylbenzene	ND	0.200	--	ND	1.10	--		1
1,2-Dibromo-3-chloropropane	ND	0.200	--	ND	1.93	--		1
Undecane	ND	0.200	--	ND	1.28	--		1
Dodecane	ND	0.200	--	ND	1.39	--		1
1,2,4-Trichlorobenzene	ND	0.200	--	ND	1.48	--		1
Naphthalene	ND	0.200	--	ND	1.05	--		1
1,2,3-Trichlorobenzene	ND	0.200	--	ND	1.48	--		1
Hexachlorobutadiene	ND	0.200	--	ND	2.13	--		1

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2308322
Report Date: 04/07/23

Air Canister Certification Results

Lab ID: L2308322-04
Client ID: CAN 1707 SHELF 47
Sample Location:

Date Collected: 02/15/23 18:00
Date Received: 02/16/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								

	Results	Qualifier	Units	RDL	Dilution Factor
Tentatively Identified Compounds					

No Tentatively Identified Compounds

Internal Standard	% Recovery	Qualifier	Acceptance Criteria
1,4-Difluorobenzene	99		60-140
Bromochloromethane	104		60-140
chlorobenzene-d5	99		60-140

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2308322
Report Date: 04/07/23

Air Canister Certification Results

Lab ID: L2308322-04
Client ID: CAN 1707 SHELF 47
Sample Location:

Date Collected: 02/15/23 18:00
Date Received: 02/16/23
Field Prep: Not Specified

Sample Depth:
Matrix: Air
Anaytical Method: 48,TO-15-SIM
Analytical Date: 02/16/23 20:34
Analyst: RAY

	ppbV			ug/m3				
Parameter	**Results**	**RL**	**MDL**	**Results**	**RL**	**MDL**	**Qualifier**	**Dilution Factor**
Volatile Organics in Air by SIM - Mansfield Lab								
Dichlorodifluoromethane	ND	0.200	--	ND	0.989	--		1
Chloromethane	ND	0.200	--	ND	0.413	--		1
Freon-114	ND	0.050	--	ND	0.349	--		1
Vinyl chloride	ND	0.020	--	ND	0.051	--		1
1,3-Butadiene	ND	0.020	--	ND	0.044	--		1
Bromomethane	ND	0.020	--	ND	0.078	--		1
Chloroethane	ND	0.100	--	ND	0.264	--		1
Acrolein	ND	0.050	--	ND	0.115	--		1
Acetone	ND	1.00	--	ND	2.38	--		1
Trichlorofluoromethane	ND	0.050	--	ND	0.281	--		1
Acrylonitrile	ND	0.500	--	ND	1.09	--		1
1,1-Dichloroethene	ND	0.020	--	ND	0.079	--		1
Methylene chloride	ND	0.500	--	ND	1.74	--		1
Freon-113	ND	0.050	--	ND	0.383	--		1
trans-1,2-Dichloroethene	ND	0.020	--	ND	0.079	--		1
1,1-Dichloroethane	ND	0.020	--	ND	0.081	--		1
Methyl tert butyl ether	ND	0.200	--	ND	0.721	--		1
2-Butanone	ND	0.500	--	ND	1.47	--		1
cis-1,2-Dichloroethene	ND	0.020	--	ND	0.079	--		1
Chloroform	ND	0.020	--	ND	0.098	--		1
1,2-Dichloroethane	ND	0.020	--	ND	0.081	--		1
1,1,1-Trichloroethane	ND	0.020	--	ND	0.109	--		1
Benzene	ND	0.100	--	ND	0.319	--		1
Carbon tetrachloride	ND	0.020	--	ND	0.126	--		1

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2308322
Report Date: 04/07/23

Air Canister Certification Results

Lab ID: L2308322-04
Client ID: CAN 1707 SHELF 47
Sample Location:

Date Collected: 02/15/23 18:00
Date Received: 02/16/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air by SIM - Mansfield Lab								
1,2-Dichloropropane	ND	0.020	--	ND	0.092	--		1
Bromodichloromethane	ND	0.020	--	ND	0.134	--		1
1,4-Dioxane	ND	0.100	--	ND	0.360	--		1
Trichloroethene	ND	0.020	--	ND	0.107	--		1
cis-1,3-Dichloropropene	ND	0.020	--	ND	0.091	--		1
4-Methyl-2-pentanone	ND	0.500	--	ND	2.05	--		1
trans-1,3-Dichloropropene	ND	0.020	--	ND	0.091	--		1
1,1,2-Trichloroethane	ND	0.020	--	ND	0.109	--		1
Toluene	ND	0.100	--	ND	0.377	--		1
Dibromochloromethane	ND	0.020	--	ND	0.170	--		1
1,2-Dibromoethane	ND	0.020	--	ND	0.154	--		1
Tetrachloroethene	ND	0.020	--	ND	0.136	--		1
1,1,1,2-Tetrachloroethane	ND	0.020	--	ND	0.137	--		1
Chlorobenzene	ND	0.100	--	ND	0.461	--		1
Ethylbenzene	ND	0.020	--	ND	0.087	--		1
p/m-Xylene	ND	0.040	--	ND	0.174	--		1
Bromoform	ND	0.020	--	ND	0.207	--		1
Styrene	ND	0.020	--	ND	0.085	--		1
1,1,2,2-Tetrachloroethane	ND	0.020	--	ND	0.137	--		1
o-Xylene	ND	0.020	--	ND	0.087	--		1
Isopropylbenzene	ND	0.200	--	ND	0.983	--		1
4-Ethyltoluene	ND	0.020	--	ND	0.098	--		1
1,3,5-Trimethybenzene	ND	0.020	--	ND	0.098	--		1
1,2,4-Trimethylbenzene	ND	0.020	--	ND	0.098	--		1
Benzyl chloride	ND	0.100	--	ND	0.518	--		1
1,3-Dichlorobenzene	ND	0.020	--	ND	0.120	--		1
1,4-Dichlorobenzene	ND	0.020	--	ND	0.120	--		1

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2308322
Report Date: 04/07/23

Air Canister Certification Results

Lab ID: L2308322-04
Client ID: CAN 1707 SHELF 47
Sample Location:

Date Collected: 02/15/23 18:00
Date Received: 02/16/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air by SIM - Mansfield Lab								
sec-Butylbenzene	ND	0.200	--	ND	1.10	--		1
p-Isopropyltoluene	ND	0.200	--	ND	1.10	--		1
1,2-Dichlorobenzene	ND	0.020	--	ND	0.120	--		1
n-Butylbenzene	ND	0.200	--	ND	1.10	--		1
1,2,4-Trichlorobenzene	ND	0.050	--	ND	0.371	--		1
Naphthalene	ND	0.050	--	ND	0.262	--		1
1,2,3-Trichlorobenzene	ND	0.050	--	ND	0.371	--		1
Hexachlorobutadiene	ND	0.050	--	ND	0.533	--		1

Internal Standard	% Recovery	Qualifier	Acceptance Criteria
1,4-difluorobenzene	98		60-140
bromochloromethane	105		60-140
chlorobenzene-d5	96		60-140

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2308322
Report Date: 04/07/23

Air Canister Certification Results

Lab ID: L2308322-06
Client ID: CAN 543 SHELF 14
Sample Location:

Date Collected: 02/16/23 10:00
Date Received: 02/16/23
Field Prep: Not Specified

Sample Depth:
Matrix: Air
Anaytical Method: 48,TO-15
Analytical Date: 02/16/23 21:51
Analyst: RAY

	ppbV			ug/m3				
Parameter	**Results**	**RL**	**MDL**	**Results**	**RL**	**MDL**	**Qualifier**	**Dilution Factor**
Volatile Organics in Air - Mansfield Lab								
Chlorodifluoromethane	ND	0.200	--	ND	0.707	--		1
Propylene	ND	0.500	--	ND	0.861	--		1
Propane	ND	0.500	--	ND	0.902	--		1
Dichlorodifluoromethane	ND	0.200	--	ND	0.989	--		1
Chloromethane	ND	0.200	--	ND	0.413	--		1
Freon-114	ND	0.200	--	ND	1.40	--		1
Methanol	ND	5.00	--	ND	6.55	--		1
Vinyl chloride	ND	0.200	--	ND	0.511	--		1
1,3-Butadiene	ND	0.200	--	ND	0.442	--		1
Butane	ND	0.200	--	ND	0.475	--		1
Bromomethane	ND	0.200	--	ND	0.777	--		1
Chloroethane	ND	0.200	--	ND	0.528	--		1
Ethanol	ND	5.00	--	ND	9.42	--		1
Dichlorofluoromethane	ND	0.200	--	ND	0.842	--		1
Vinyl bromide	ND	0.200	--	ND	0.874	--		1
Acrolein	ND	0.500	--	ND	1.15	--		1
Acetone	ND	1.00	--	ND	2.38	--		1
Acetonitrile	ND	0.200	--	ND	0.336	--		1
Trichlorofluoromethane	ND	0.200	--	ND	1.12	--		1
Isopropanol	ND	0.500	--	ND	1.23	--		1
Acrylonitrile	ND	0.500	--	ND	1.09	--		1
Pentane	ND	0.200	--	ND	0.590	--		1
Ethyl ether	ND	0.200	--	ND	0.606	--		1
1,1-Dichloroethene	ND	0.200	--	ND	0.793	--		1

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2308322
Report Date: 04/07/23

Air Canister Certification Results

Lab ID: L2308322-06
Client ID: CAN 543 SHELF 14
Sample Location:

Date Collected: 02/16/23 10:00
Date Received: 02/16/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
Tertiary butyl Alcohol	ND	0.500	--	ND	1.52	--		1
Methylene chloride	ND	0.500	--	ND	1.74	--		1
3-Chloropropene	ND	0.200	--	ND	0.626	--		1
Carbon disulfide	ND	0.200	--	ND	0.623	--		1
Freon-113	ND	0.200	--	ND	1.53	--		1
trans-1,2-Dichloroethene	ND	0.200	--	ND	0.793	--		1
1,1-Dichloroethane	ND	0.200	--	ND	0.809	--		1
Methyl tert butyl ether	ND	0.200	--	ND	0.721	--		1
Vinyl acetate	ND	1.00	--	ND	3.52	--		1
Xylenes, total	ND	0.600	--	ND	0.869	--		1
2-Butanone	ND	0.500	--	ND	1.47	--		1
cis-1,2-Dichloroethene	ND	0.200	--	ND	0.793	--		1
Ethyl Acetate	ND	0.500	--	ND	1.80	--		1
Chloroform	ND	0.200	--	ND	0.977	--		1
Tetrahydrofuran	ND	0.500	--	ND	1.47	--		1
2,2-Dichloropropane	ND	0.200	--	ND	0.924	--		1
1,2-Dichloroethane	ND	0.200	--	ND	0.809	--		1
n-Hexane	ND	0.200	--	ND	0.705	--		1
Diisopropyl ether	ND	0.200	--	ND	0.836	--		1
tert-Butyl Ethyl Ether	ND	0.200	--	ND	0.836	--		1
1,2-Dichloroethene (total)	ND	1.00	--	ND	1.00	--		1
1,1,1-Trichloroethane	ND	0.200	--	ND	1.09	--		1
1,1-Dichloropropene	ND	0.200	--	ND	0.908	--		1
Benzene	ND	0.200	--	ND	0.639	--		1
Carbon tetrachloride	ND	0.200	--	ND	1.26	--		1
Cyclohexane	ND	0.200	--	ND	0.688	--		1
tert-Amyl Methyl Ether	ND	0.200	--	ND	0.836	--		1

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2308322
Report Date: 04/07/23

Air Canister Certification Results

Lab ID: L2308322-06
Client ID: CAN 543 SHELF 14
Sample Location:

Date Collected: 02/16/23 10:00
Date Received: 02/16/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
Dibromomethane	ND	0.200	--	ND	1.42	--		1
1,2-Dichloropropane	ND	0.200	--	ND	0.924	--		1
Bromodichloromethane	ND	0.200	--	ND	1.34	--		1
1,4-Dioxane	ND	0.200	--	ND	0.721	--		1
Trichloroethene	ND	0.200	--	ND	1.07	--		1
2,2,4-Trimethylpentane	ND	0.200	--	ND	0.934	--		1
Methyl Methacrylate	ND	0.500	--	ND	2.05	--		1
Heptane	ND	0.200	--	ND	0.820	--		1
cis-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
4-Methyl-2-pentanone	ND	0.500	--	ND	2.05	--		1
trans-1,3-Dichloropropene	ND	0.200	--	ND	0.908	--		1
1,1,2-Trichloroethane	ND	0.200	--	ND	1.09	--		1
Toluene	ND	0.200	--	ND	0.754	--		1
1,3-Dichloropropane	ND	0.200	--	ND	0.924	--		1
2-Hexanone	ND	0.200	--	ND	0.820	--		1
Dibromochloromethane	ND	0.200	--	ND	1.70	--		1
1,2-Dibromoethane	ND	0.200	--	ND	1.54	--		1
Butyl acetate	ND	0.500	--	ND	2.38	--		1
Octane	ND	0.200	--	ND	0.934	--		1
Tetrachloroethene	ND	0.200	--	ND	1.36	--		1
1,1,1,2-Tetrachloroethane	ND	0.200	--	ND	1.37	--		1
Chlorobenzene	ND	0.200	--	ND	0.921	--		1
Ethylbenzene	ND	0.200	--	ND	0.869	--		1
p/m-Xylene	ND	0.400	--	ND	1.74	--		1
Bromoform	ND	0.200	--	ND	2.07	--		1
Styrene	ND	0.200	--	ND	0.852	--		1
1,1,2,2-Tetrachloroethane	ND	0.200	--	ND	1.37	--		1

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2308322
Report Date: 04/07/23

Air Canister Certification Results

Lab ID: L2308322-06
Client ID: CAN 543 SHELF 14
Sample Location:

Date Collected: 02/16/23 10:00
Date Received: 02/16/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								
o-Xylene	ND	0.200	--	ND	0.869	--		1
1,2,3-Trichloropropane	ND	0.200	--	ND	1.21	--		1
Nonane	ND	0.200	--	ND	1.05	--		1
Isopropylbenzene	ND	0.200	--	ND	0.983	--		1
Bromobenzene	ND	0.200	--	ND	0.793	--		1
2-Chlorotoluene	ND	0.200	--	ND	1.04	--		1
n-Propylbenzene	ND	0.200	--	ND	0.983	--		1
4-Chlorotoluene	ND	0.200	--	ND	1.04	--		1
4-Ethyltoluene	ND	0.200	--	ND	0.983	--		1
1,3,5-Trimethylbenzene	ND	0.200	--	ND	0.983	--		1
tert-Butylbenzene	ND	0.200	--	ND	1.10	--		1
1,2,4-Trimethylbenzene	ND	0.200	--	ND	0.983	--		1
Decane	ND	0.200	--	ND	1.16	--		1
Benzyl chloride	ND	0.200	--	ND	1.04	--		1
1,3-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
1,4-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
sec-Butylbenzene	ND	0.200	--	ND	1.10	--		1
p-Isopropyltoluene	ND	0.200	--	ND	1.10	--		1
1,2-Dichlorobenzene	ND	0.200	--	ND	1.20	--		1
n-Butylbenzene	ND	0.200	--	ND	1.10	--		1
1,2-Dibromo-3-chloropropane	ND	0.200	--	ND	1.93	--		1
Undecane	ND	0.200	--	ND	1.28	--		1
Dodecane	ND	0.200	--	ND	1.39	--		1
1,2,4-Trichlorobenzene	ND	0.200	--	ND	1.48	--		1
Naphthalene	ND	0.200	--	ND	1.05	--		1
1,2,3-Trichlorobenzene	ND	0.200	--	ND	1.48	--		1
Hexachlorobutadiene	ND	0.200	--	ND	2.13	--		1

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2308322
Report Date: 04/07/23

Air Canister Certification Results

Lab ID: L2308322-06
Client ID: CAN 543 SHELF 14
Sample Location:

Date Collected: 02/16/23 10:00
Date Received: 02/16/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air - Mansfield Lab								

	Results	Qualifier	Units	RDL	Dilution Factor
Tentatively Identified Compounds					

No Tentatively Identified Compounds

Internal Standard	% Recovery	Qualifier	Acceptance Criteria
1,4-Difluorobenzene	100		60-140
Bromochloromethane	106		60-140
chlorobenzene-d5	101		60-140

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2308322
Report Date: 04/07/23

Air Canister Certification Results

Lab ID: L2308322-06
Client ID: CAN 543 SHELF 14
Sample Location:

Date Collected: 02/16/23 10:00
Date Received: 02/16/23
Field Prep: Not Specified

Sample Depth:
Matrix: Air
Anaytical Method: 48,TO-15-SIM
Analytical Date: 02/16/23 21:51
Analyst: RAY

	ppbV			ug/m3				
Parameter	**Results**	**RL**	**MDL**	**Results**	**RL**	**MDL**	**Qualifier**	**Dilution Factor**
Volatile Organics in Air by SIM - Mansfield Lab								
Dichlorodifluoromethane	ND	0.200	--	ND	0.989	--		1
Chloromethane	ND	0.200	--	ND	0.413	--		1
Freon-114	ND	0.050	--	ND	0.349	--		1
Vinyl chloride	ND	0.020	--	ND	0.051	--		1
1,3-Butadiene	ND	0.020	--	ND	0.044	--		1
Bromomethane	ND	0.020	--	ND	0.078	--		1
Chloroethane	ND	0.100	--	ND	0.264	--		1
Acrolein	ND	0.050	--	ND	0.115	--		1
Acetone	ND	1.00	--	ND	2.38	--		1
Trichlorofluoromethane	ND	0.050	--	ND	0.281	--		1
Acrylonitrile	ND	0.500	--	ND	1.09	--		1
1,1-Dichloroethene	ND	0.020	--	ND	0.079	--		1
Methylene chloride	ND	0.500	--	ND	1.74	--		1
Freon-113	ND	0.050	--	ND	0.383	--		1
trans-1,2-Dichloroethene	ND	0.020	--	ND	0.079	--		1
1,1-Dichloroethane	ND	0.020	--	ND	0.081	--		1
Methyl tert butyl ether	ND	0.200	--	ND	0.721	--		1
2-Butanone	ND	0.500	--	ND	1.47	--		1
cis-1,2-Dichloroethene	ND	0.020	--	ND	0.079	--		1
Chloroform	ND	0.020	--	ND	0.098	--		1
1,2-Dichloroethane	ND	0.020	--	ND	0.081	--		1
1,1,1-Trichloroethane	ND	0.020	--	ND	0.109	--		1
Benzene	ND	0.100	--	ND	0.319	--		1
Carbon tetrachloride	ND	0.020	--	ND	0.126	--		1

Project Name: BATCH CANISTER CERTIFICATION
Project Number: CANISTER QC BAT
Lab Number: L2308322
Report Date: 04/07/23

Air Canister Certification Results

Lab ID: L2308322-06
Client ID: CAN 543 SHELF 14
Sample Location:

Date Collected: 02/16/23 10:00
Date Received: 02/16/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air by SIM - Mansfield Lab								
1,2-Dichloropropane	ND	0.020	--	ND	0.092	--		1
Bromodichloromethane	ND	0.020	--	ND	0.134	--		1
1,4-Dioxane	ND	0.100	--	ND	0.360	--		1
Trichloroethene	ND	0.020	--	ND	0.107	--		1
cis-1,3-Dichloropropene	ND	0.020	--	ND	0.091	--		1
4-Methyl-2-pentanone	ND	0.500	--	ND	2.05	--		1
trans-1,3-Dichloropropene	ND	0.020	--	ND	0.091	--		1
1,1,2-Trichloroethane	ND	0.020	--	ND	0.109	--		1
Toluene	ND	0.100	--	ND	0.377	--		1
Dibromochloromethane	ND	0.020	--	ND	0.170	--		1
1,2-Dibromoethane	ND	0.020	--	ND	0.154	--		1
Tetrachloroethene	ND	0.020	--	ND	0.136	--		1
1,1,1,2-Tetrachloroethane	ND	0.020	--	ND	0.137	--		1
Chlorobenzene	ND	0.100	--	ND	0.461	--		1
Ethylbenzene	ND	0.020	--	ND	0.087	--		1
p/m-Xylene	ND	0.040	--	ND	0.174	--		1
Bromoform	ND	0.020	--	ND	0.207	--		1
Styrene	ND	0.020	--	ND	0.085	--		1
1,1,2,2-Tetrachloroethane	ND	0.020	--	ND	0.137	--		1
o-Xylene	ND	0.020	--	ND	0.087	--		1
Isopropylbenzene	ND	0.200	--	ND	0.983	--		1
4-Ethyltoluene	ND	0.020	--	ND	0.098	--		1
1,3,5-Trimethybenzene	ND	0.020	--	ND	0.098	--		1
1,2,4-Trimethylbenzene	ND	0.020	--	ND	0.098	--		1
Benzyl chloride	ND	0.100	--	ND	0.518	--		1
1,3-Dichlorobenzene	ND	0.020	--	ND	0.120	--		1
1,4-Dichlorobenzene	ND	0.020	--	ND	0.120	--		1

Project Name: BATCH CANISTER CERTIFICATION **Lab Number:** L2308322

Project Number: CANISTER QC BAT **Report Date:** 04/07/23

Air Canister Certification Results

Lab ID: L2308322-06
Client ID: CAN 543 SHELF 14
Sample Location:

Date Collected: 02/16/23 10:00
Date Received: 02/16/23
Field Prep: Not Specified

Sample Depth:

Parameter	ppbV Results	ppbV RL	ppbV MDL	ug/m3 Results	ug/m3 RL	ug/m3 MDL	Qualifier	Dilution Factor
Volatile Organics in Air by SIM - Mansfield Lab								
sec-Butylbenzene	ND	0.200	--	ND	1.10	--		1
p-Isopropyltoluene	ND	0.200	--	ND	1.10	--		1
1,2-Dichlorobenzene	ND	0.020	--	ND	0.120	--		1
n-Butylbenzene	ND	0.200	--	ND	1.10	--		1
1,2,4-Trichlorobenzene	ND	0.050	--	ND	0.371	--		1
Naphthalene	ND	0.050	--	ND	0.262	--		1
1,2,3-Trichlorobenzene	ND	0.050	--	ND	0.371	--		1
Hexachlorobutadiene	ND	0.050	--	ND	0.533	--		1

Internal Standard	% Recovery	Qualifier	Acceptance Criteria
1,4-difluorobenzene	100		60-140
bromochloromethane	107		60-140
chlorobenzene-d5	99		60-140

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316892
Report Date: 04/07/23

Sample Receipt and Container Information

Were project specific reporting limits specified? YES

Cooler Information

Cooler	Custody Seal
N/A	Absent

Container Information

Container ID	Container Type	Cooler	Initial pH	Final pH	Temp deg C	Pres	Seal	Frozen Date/Time	Analysis(*)
L2316892-01A	Canister - 6 Liter	N/A	NA			Y	Absent		TO15-SIM(30),TO15-LL(30)
L2316892-02A	Canister - 6 Liter	N/A	NA			Y	Absent		TO15-LL(30),TO15-SIM(30)
L2316892-03A	Canister - 6 Liter	N/A	NA			Y	Absent		TO15-LL(30),TO15-SIM(30)
L2316892-04A	Canister - 6 Liter	N/A	NA			Y	Absent		TO15-LL(30),TO15-SIM(30)
L2316892-05A	Canister - 6 Liter	N/A	NA			Y	Absent		TO15-LL(30),TO15-SIM(30)
L2316892-06A	Canister - 6 Liter	N/A	NA			Y	Absent		TO15-LL(30),TO15-SIM(30)
L2316892-07A	Canister - 2.7 Liter	N/A	NA			Y	Absent		TO15-LL(30)
L2316892-08A	Canister - 2.7 Liter	N/A	NA			Y	Absent		TO15-LL(30)
L2316892-09A	Canister - 2.7 Liter	N/A	NA			Y	Absent		TO15-LL(30)
L2316892-10A	Canister - 2.7 Liter	N/A	NA			Y	Absent		TO15-LL(30)
L2316892-11A	Canister - 2.7 Liter	N/A	NA			Y	Absent		TO15-LL(30)
L2316892-12A	Canister - 2.7 Liter	N/A	NA			Y	Absent		TO15-LL(30)

*Values in parentheses indicate holding time in days

Project Name:	100 MAIN ST.	**Lab Number:**	L2316892
Project Number:	12461	**Report Date:**	04/07/23

GLOSSARY

Acronyms

DL	- Detection Limit: This value represents the level to which target analyte concentrations are reported as estimated values, when those target analyte concentrations are quantified below the limit of quantitation (LOQ). The DL includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.)
EDL	- Estimated Detection Limit: This value represents the level to which target analyte concentrations are reported as estimated values, when those target analyte concentrations are quantified below the reporting limit (RL). The EDL includes any adjustments from dilutions, concentrations or moisture content, where applicable. The use of EDLs is specific to the analysis of PAHs using Solid-Phase Microextraction (SPME).
EMPC	- Estimated Maximum Possible Concentration: The concentration that results from the signal present at the retention time of an analyte when the ions meet all of the identification criteria except the ion abundance ratio criteria. An EMPC is a worst-case estimate of the concentration.
EPA	- Environmental Protection Agency.
LCS	- Laboratory Control Sample: A sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes or a material containing known and verified amounts of analytes.
LCSD	- Laboratory Control Sample Duplicate: Refer to LCS.
LFB	- Laboratory Fortified Blank: A sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes or a material containing known and verified amounts of analytes.
LOD	- Limit of Detection: This value represents the level to which a target analyte can reliably be detected for a specific analyte in a specific matrix by a specific method. The LOD includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.)
LOQ	- Limit of Quantitation: The value at which an instrument can accurately measure an analyte at a specific concentration. The LOQ includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.) Limit of Quantitation: The value at which an instrument can accurately measure an analyte at a specific concentration. The LOQ includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.)
MDL	- Method Detection Limit: This value represents the level to which target analyte concentrations are reported as estimated values, when those target analyte concentrations are quantified below the reporting limit (RL). The MDL includes any adjustments from dilutions, concentrations or moisture content, where applicable.
MS	- Matrix Spike Sample: A sample prepared by adding a known mass of target analyte to a specified amount of matrix sample for which an independent estimate of target analyte concentration is available. For Method 332.0, the spike recovery is calculated using the native concentration, including estimated values.
MSD	- Matrix Spike Sample Duplicate: Refer to MS.
NA	- Not Applicable.
NC	- Not Calculated: Term is utilized when one or more of the results utilized in the calculation are non-detect at the parameter's reporting unit.
NDPA/DPA	- N-Nitrosodiphenylamine/Diphenylamine.
NI	- Not Ignitable.
NP	- Non-Plastic: Term is utilized for the analysis of Atterberg Limits in soil.
NR	- No Results: Term is utilized when 'No Target Compounds Requested' is reported for the analysis of Volatile or Semivolatile Organic TIC only requests.
RL	- Reporting Limit: The value at which an instrument can accurately measure an analyte at a specific concentration. The RL includes any adjustments from dilutions, concentrations or moisture content, where applicable.
RPD	- Relative Percent Difference: The results from matrix and/or matrix spike duplicates are primarily designed to assess the precision of analytical results in a given matrix and are expressed as relative percent difference (RPD). Values which are less than five times the reporting limit for any individual parameter are evaluated by utilizing the absolute difference between the values; although the RPD value will be provided in the report.
SRM	- Standard Reference Material: A reference sample of a known or certified value that is of the same or similar matrix as the associated field samples.
STLP	- Semi-dynamic Tank Leaching Procedure per EPA Method 1315.
TEF	- Toxic Equivalency Factors: The values assigned to each dioxin and furan to evaluate their toxicity relative to 2,3,7,8-TCDD.
TEQ	- Toxic Equivalent: The measure of a sample's toxicity derived by multiplying each dioxin and furan by its corresponding TEF and then summing the resulting values.
TIC	- Tentatively Identified Compound: A compound that has been identified to be present and is not part of the target compound list (TCL) for the method and/or program. All TICs are qualitatively identified and reported as estimated concentrations.

Report Format: Data Usability Report

Project Name:	100 MAIN ST.	**Lab Number:**	L2316892
Project Number:	12461	**Report Date:**	04/07/23

Footnotes

1 - The reference for this analyte should be considered modified since this analyte is absent from the target analyte list of the original method.

Terms

Analytical Method: Both the document from which the method originates and the analytical reference method. (Example: EPA 8260B is shown as 1,8260B.) The codes for the reference method documents are provided in the References section of the Addendum.

Chlordane: The target compound Chlordane (CAS No. 57-74-9) is reported for GC ECD analyses. Per EPA,this compound "refers to a mixture of chlordane isomers, other chlorinated hydrocarbons and numerous other components." (Reference: USEPA Toxicological Review of Chlordane, In Support of Summary Information on the Integrated Risk Information System (IRIS), December 1997.)

Difference: With respect to Total Oxidizable Precursor (TOP) Assay analysis, the difference is defined as the Post-Treatment value minus the Pre-Treatment value.

Final pH: As it pertains to Sample Receipt & Container Information section of the report, Final pH reflects pH of container determined after adjustment at the laboratory, if applicable. If no adjustment required, value reflects Initial pH.

Frozen Date/Time: With respect to Volatile Organics in soil, Frozen Date/Time reflects the date/time at which associated Reagent Water-preserved vials were initially frozen. Note: If frozen date/time is beyond 48 hours from sample collection, value will be reflected in 'bold'.

Gasoline Range Organics (GRO): Gasoline Range Organics (GRO) results include all chromatographic peaks eluting from Methyl tert butyl ether through Naphthalene, with the exception of GRO analysis in support of State of Ohio programs, which includes all chromatographic peaks eluting from Hexane through Dodecane.

Initial pH: As it pertains to Sample Receipt & Container Information section of the report, Initial pH reflects pH of container determined upon receipt, if applicable.

PAH Total: With respect to Alkylated PAH analyses, the 'PAHs, Total' result is defined as the summation of results for all or a subset of the following compounds: Naphthalene, C1-C4 Naphthalenes, 2-Methylnaphthalene, 1-Methylnaphthalene, Biphenyl, Acenaphthylene, Acenaphthene, Fluorene, C1-C3 Fluorenes, Phenanthrene, C1-C4 Phenanthrenes/Anthracenes, Anthracene, Fluoranthene, Pyrene, C1-C4 Fluoranthenes/Pyrenes, Benz(a)anthracene, Chrysene, C1-C4 Chrysenes, Benzo(b)fluoranthene, Benzo(j)+(k)fluoranthene, Benzo(e)pyrene, Benzo(a)pyrene, Perylene, Indeno(1,2,3-cd)pyrene, Dibenz(ah)+(ac)anthracene, Benzo(g,h,i)perylene. If a 'Total' result is requested, the results of its individual components will also be reported.

PFAS Total: With respect to PFAS analyses, the 'PFAS, Total (5)' result is defined as the summation of results for: PFHpA, PFHxS, PFOA, PFNA and PFOS. In addition, the 'PFAS, Total (6)' result is defined as the summation of results for: PFHpA, PFHxS, PFOA, PFNA, PFDA and PFOS. For MassDEP DW compliance analysis only, the 'PFAS, Total (6)' result is defined as the summation of results at or above the RL. Note: If a 'Total' result is requested, the results of its individual components will also be reported.

Total: With respect to Organic analyses, a 'Total' result is defined as the summation of results for individual isomers or Aroclors. If a 'Total' result is requested, the results of its individual components will also be reported. This is applicable to 'Total' results for methods 8260, 8081 and 8082.

Data Qualifiers

A - Spectra identified as "Aldol Condensates" are byproducts of the extraction/concentration procedures when acetone is introduced in the process.

B - The analyte was detected above the reporting limit in the associated method blank. Flag only applies to associated field samples that have detectable concentrations of the analyte at less than ten times (10x) the concentration found in the blank. For MCP-related projects, flag only applies to associated field samples that have detectable concentrations of the analyte at less than ten times (10x) the concentration found in the blank. For DOD-related projects, flag only applies to associated field samples that have detectable concentrations of the analyte at less than ten times (10x) the concentration found in the blank AND the analyte was detected above one-half the reporting limit (or above the reporting limit for common lab contaminants) in the associated method blank. For NJ-Air-related projects, flag only applies to associated field samples that have detectable concentrations of the analyte above the reporting limit. For NJ-related projects (excluding Air), flag only applies to associated field samples that have detectable concentrations of the analyte, which was detected above the reporting limit in the associated method blank or above five times the reporting limit for common lab contaminants (Phthalates, Acetone, Methylene Chloride, 2-Butanone).

C - Co-elution: The target analyte co-elutes with a known lab standard (i.e. surrogate, internal standards, etc.) for co-extracted analyses.

D - Concentration of analyte was quantified from diluted analysis. Flag only applies to field samples that have detectable concentrations of the analyte.

E - Concentration of analyte exceeds the range of the calibration curve and/or linear range of the instrument.

F - The ratio of quantifier ion response to qualifier ion response falls outside of the laboratory criteria. Results are considered to be an estimated maximum concentration.

G - The concentration may be biased high due to matrix interferences (i.e, co-elution) with non-target compound(s). The result should be considered estimated.

H - The analysis of pH was performed beyond the regulatory-required holding time of 15 minutes from the time of sample collection.

I - The lower value for the two columns has been reported due to obvious interference.

J - Estimated value. This represents an estimated concentration for Tentatively Identified Compounds (TICs).

M - Reporting Limit (RL) exceeds the MCP CAM Reporting Limit for this analyte.

Report Format: Data Usability Report

Project Name:	100 MAIN ST.	**Lab Number:**	L2316892
Project Number:	12461	**Report Date:**	04/07/23

Data Qualifiers

ND - Not detected at the reporting limit (RL) for the sample.

NJ - Presumptive evidence of compound. This represents an estimated concentration for Tentatively Identified Compounds (TICs), where the identification is based on a mass spectral library search.

P - The RPD between the results for the two columns exceeds the method-specified criteria.

Q - The quality control sample exceeds the associated acceptance criteria. For DOD-related projects, LCS and/or Continuing Calibration Standard exceedences are also qualified on all associated sample results. Note: This flag is not applicable for matrix spike recoveries when the sample concentration is greater than 4x the spike added or for batch duplicate RPD when the sample concentrations are less than 5x the RL. (Metals only.)

R - Analytical results are from sample re-analysis.

RE - Analytical results are from sample re-extraction.

S - Analytical results are from modified screening analysis.

V - The surrogate associated with this target analyte has a recovery outside the QC acceptance limits. (Applicable to MassDEP DW Compliance samples only.)

Z - The batch matrix spike and/or duplicate associated with this target analyte has a recovery/RPD outside the QC acceptance limits. (Applicable to MassDEP DW Compliance samples only.)

Report Format: Data Usability Report

Project Name: 100 MAIN ST. **Lab Number:** L2316892
Project Number: 12461 **Report Date:** 04/07/23

REFERENCES

48 Compendium of Methods for the Determination of Toxic Organic Compounds in Ambient Air. Second Edition. EPA/625/R-96/010b, January 1999.

LIMITATION OF LIABILITIES

Alpha Analytical performs services with reasonable care and diligence normal to the analytical testing laboratory industry. In the event of an error, the sole and exclusive responsibility of Alpha Analytical shall be to re-perform the work at it's own expense. In no event shall Alpha Analytical be held liable for any incidental, consequential or special damages, including but not limited to, damages in any way connected with the use of, interpretation of, information or analysis provided by Alpha Analytical.

We strongly urge our clients to comply with EPA protocol regarding sample volume, preservation, cooling, containers, sampling procedures, holding time and splitting of samples in the field.

Certification Information

The following analytes are not included in our Primary NELAP Scope of Accreditation:

Westborough Facility
EPA 624/624.1: m/p-xylene, o-xylene, Naphthalene
EPA 625/625.1: alpha-Terpineol
EPA 8260C/8260D: NPW: 1,2,4,5-Tetramethylbenzene; 4-Ethyltoluene, Azobenzene; SCM: Iodomethane (methyl iodide), 1,2,4,5-Tetramethylbenzene; 4-Ethyltoluene.
EPA 8270D/8270E: NPW: Dimethylnaphthalene,1,4-Diphenylhydrazine, alpha-Terpineol; SCM: Dimethylnaphthalene,1,4-Diphenylhydrazine.
SM4500: NPW: Amenable Cyanide; SCM: Total Phosphorus, TKN, NO2, NO3.

Mansfield Facility
SM 2540D: TSS
EPA 8082A: NPW: PCB: 1, 5, 31, 87,101, 110, 141, 151, 153, 180, 183, 187.
EPA TO-15: Halothane, 2,4,4-Trimethyl-2-pentene, 2,4,4-Trimethyl-1-pentene, Thiophene, 2-Methylthiophene, 3-Methylthiophene, 2-Ethylthiophene, 1,2,3-Trimethylbenzene, Indan, Indene, 1,2,4,5-Tetramethylbenzene, Benzothiophene, 1-Methylnaphthalene.
Biological Tissue Matrix: EPA 3050B

The following analytes are included in our Massachusetts DEP Scope of Accreditation

Westborough Facility:

Drinking Water
EPA 300.0: Chloride, Nitrate-N, Fluoride, Sulfate; **EPA 353.2**: Nitrate-N, Nitrite-N; **SM4500NO3-F**: Nitrate-N, Nitrite-N; **SM4500F-C, SM4500CN-CE, EPA 180.1, SM2130B, SM4500Cl-D, SM2320B, SM2540C, SM4500H-B, SM4500NO2-B**
EPA 332: Perchlorate; **EPA 524.2:** THMs and VOCs; **EPA 504.1:** EDB, DBCP.
Microbiology: **SM9215B; SM9223-P/A, SM9223B-Colilert-QT,SM9222D**.

Non-Potable Water
SM4500H,B, EPA 120.1, SM2510B, SM2540C, SM2320B, SM4500CL-E, SM4500F-BC, SM4500NH3-BH: Ammonia-N and Kjeldahl-N, **EPA 350.1**: Ammonia-N, **LACHAT 10-107-06-1-B**: Ammonia-N, **EPA 351.1, SM4500NO3-F, EPA 353.2**: Nitrate-N, **SM4500P-E, SM4500P-B, E, SM4500SO4-E, SM5220D, EPA 410.4, SM5210B, SM5310C, SM4500CL-D, EPA 1664, EPA 420.1, SM4500-CN-CE, SM2540D, EPA 300: Chloride, Sulfate, Nitrate.**
EPA 624.1: Volatile Halocarbons & Aromatics,
EPA 608.3: Chlordane, Toxaphene, Aldrin, alpha-BHC, beta-BHC, gamma-BHC, delta-BHC, Dieldrin, DDD, DDE, DDT, Endosulfan I, Endosulfan II, Endosulfan sulfate, Endrin, Endrin Aldehyde, Heptachlor, Heptachlor Epoxide, PCBs
EPA 625.1: SVOC (Acid/Base/Neutral Extractables), **EPA 600/4-81-045**: PCB-Oil.
Microbiology: **SM9223B-Colilert-QT; Enterolert-QT, SM9221E, EPA 1600, EPA 1603, SM9222D.**

Mansfield Facility:

Drinking Water
EPA 200.7: Al, Ba, Cd, Cr, Cu, Fe, Mn, Ni, Na, Ag, Ca, Zn. **EPA 200.8:** Al, Sb, As, Ba, Be, Cd, Cr, Cu, Pb, Mn, Ni, Se, Ag, TL, Zn. **EPA 245.1** Hg.
EPA 522, EPA 537.1.

Non-Potable Water
EPA 200.7: Al, Sb, As, Be, Cd, Ca, Cr, Co, Cu, Fe, Pb, Mg, Mn, Mo, Ni, K, Se, Ag, Na, Sr, TL, Ti, V, Zn.
EPA 200.8: Al, Sb, As, Be, Cd, Cr, Cu, Fe, Pb, Mn, Ni, K, Se, Ag, Na, TL, Zn.
EPA 245.1 Hg.
SM2340B

For a complete listing of analytes and methods, please contact your Alpha Project Manager.

AIR ANALYSIS

PAGE 1 OF 2

CHAIN OF CUSTODY

320 Forbes Blvd, Mansfield, MA 02048
TEL: 508-822-9300 FAX: 508-822-3288

Date Rec'd in Lab: 4/1/23

ALPHA Job #: L2316892

Client Information

Client: SESI
Address: 959 US46 Rt 3 S300
Parsippany NJ 07054
Phone: 973 8089050
Fax:
Email: SSG@sesi.org | JCS@sesi.org

☐ These samples have been previously analyzed by Alpha

Project Information

Project Name: 100 main St
Project Location: White Plains NY
Project #: 12461
Project Manager: Steve G. Jon Stuart
ALPHA Quote #:

Turn-Around Time

☑ Standard ☐ RUSH (only confirmed if pre-approved)

Date Due: Time:

Report Information - Data Deliverables

☐ FAX
☐ ADEx
Criteria Checker:
(Default based on Regulatory Criteria Indicated)
Other Formats:
☑ EMAIL (standard pdf report)
☐ Additional Deliverables:
Report to: (if different than Project Manager)

Billing Information

☐ Same as Client info PO #:

Renaissance Brw Mgmt
Attn: Kevin McNamus

Regulatory Requirements/Report Limits

State/Fed	Program	Res / Comm

Other Project Specific Requirements/Comments:

Project-Specific Target Compound List: ☐

ANALYSIS

All Columns Below Must Be Filled Out

ALPHA Lab ID (Lab Use Only)	Sample ID	COLLECTION End Date	Start Time	End Time	Initial Vacuum	Final Vacuum	Sample Matrix*	Sampler's Initials	Can Size	ID Can	ID - Flow Controller	TO-15	TO-15 SIM	APH Subset Non-petroleum HCs	Fixed Gases ☐	Sulfides & Mercaptans by TO-15	Sample Comments (i.e. PID)
16892-01	IA-3	3/30	1310	1340	30.00	5.52	AA	CB	6L	900	1009	✓					
02	IA-4		1415	1445	30.38	5.91	AA	CB	6L	7367	1305	✓					
03	IA-5		1405	1435	30.53	6.81	AA	CB	6L	3926	1746	✓					
04	IA-6		1445	1515	30.14	6.68	AA	CB	6L	3642	1291	✓					
05	IA-7		1435	1505	30.16	6.53	AA	CB	6L	897	880	✓					
06	IA-8		1425	1455	30.21	6.58	AA	CB	6L	1552	1519	✓					
07	SSV-3		1305	1317	30.04	6.52	SV	CB	2.7L	544	1744	✓					
08	SSV-4		1410	1425	29.66	5.21	SV	CB	2.7L	2864	803	✓					
09	SSV-5		1400	1415	29.93	4.54	SV	CB	2.7L	563	872	✓					
10	SSV-6	↓	1305	1320	29.81	3.77	SV	CB	2.7L	544	1744	✓					

*SAMPLE MATRIX CODES

AA = Ambient Air (Indoor/Outdoor)
SV = Soil Vapor/Landfill Gas/SVE
Other = Please Specify

Container Type

Please print clearly, legibly and completely. Samples can not be logged in and turnaround time clock will not start until any ambiguities are resolved. All samples submitted are subject to Alpha's Terms and Conditions. See reverse side.

Relinquished By:	Date/Time	Received By:	Date/Time:
	3/31/23 845	ADL	3/31/23 0:15
ADL	3/31/23 13:15		3.31.23 2100
	4/1/23 0010		4/1/23 0010
	4/1/23 0500		4/1/23 0500

AIR ANALYSIS

PAGE 2 OF 2

CHAIN OF CUSTODY

320 Forbes Blvd, Mansfield, MA 02048
TEL: 508-822-9300 FAX: 508-822-3288

Date Rec'd in Lab: 4/1/23

ALPHA Job #: L2316892

Client Information

Client: SESI
Address: 959 US46 Fl3 S300
Parsippany TroyHills NJ 07054
Phone: 973 808 4050
Fax:
Email: SSG@SESI.org/JCS@SESI.org

☐ These samples have been previously analyzed by Alpha

Project Information

Project Name: 100 main st
Project Location: White Plains NY
Project #: 12461
Project Manager: Steve G/Jon Stuart
ALPHA Quote #:

Turn-Around Time

☑ Standard ☐ RUSH (only confirmed if pre-approved!)

Date Due: Time:

Report Information - Data Deliverables

☐ FAX
☐ ADEx
Criteria Checker:
(Default based on Regulatory Criteria Indicated)
Other Formats:
☑ EMAIL (standard pdf report)
☐ Additional Deliverables:

Report to: (if different than Project Manager)

Billing Information

☐ Same as Client info PO #:

Renaissance Env Mgmt
Attn: Kevin McNamara

Regulatory Requirements/Report Limits

State/Fed	Program	Res / Comm

Other Project Specific Requirements/Comments:

Project-Specific Target Compound List: ☐

All Columns Below Must Be Filled Out

ALPHA Lab ID (Lab Use Only)	Sample ID	COLLECTION End Date	Start Time	End Time	Initial Vacuum	Final Vacuum	Sample Matrix*	Sampler's Initials	Can Size	ID Can	ID - Flow Controller	ANALYSIS TO-15	TO-15 SIM	APH Subset Non-petroleum HCs ☐	Fixed Gases	Sulfides & Mercaptans by TO-15	Sample Comments (i.e. PID)
11	SSV-7	3/30/23	1430	1443	30.26	6.02	SV	CB	2.7L	3095	818	✓					
12	SSV-8	↓	1440	1455	30.52	5.37	SV	CB	2.7L	2356	1113	✓					

*SAMPLE MATRIX CODES

AA = Ambient Air (Indoor/Outdoor)
SV = Soil Vapor/Landfill Gas/SVE
Other = Please Specify

Container Type

Please print clearly, legibly and completely. Samples can not be logged in and turnaround time clock will not start until any ambiguities are resolved. All samples submitted are subject to Alpha's Terms and Conditions. See reverse side.

Relinquished By:	Date/Time	Received By:	Date/Time:
	3/31/23 8:45	AAL	3/31/23 8:45
AAL	3/31/23 13:15		3.31.23 2100
	4/1/23 0000		4-1-23 0000
	4/1/23 0500		4/1/23 0500

ANALYTICAL REPORT

Lab Number:	L2316452
Client:	Soils Engineering Services, Inc. 959 Route 46E Parsippany, NJ 07054
ATTN:	Steven Gustems
Phone:	(973) 808-9050
Project Name:	100 MAIN ST
Project Number:	12461
Report Date:	04/12/23

The original project report/data package is held by Alpha Analytical. This report/data package is paginated and should be reproduced only in its entirety. Alpha Analytical holds no responsibility for results and/or data that are not consistent with the original.

Certifications & Approvals: MA (M-MA086), NH NELAP (2064), CT (PH-0574), IL (200077), ME (MA00086), MD (348), NJ (MA935), NY (11148), NC (25700/666), PA (68-03671), RI (LAO00065), TX (T104704476), VT (VT-0935), VA (460195), USDA (Permit #P330-17-00196).

Eight Walkup Drive, Westborough, MA 01581-1019
508-898-9220 (Fax) 508-898-9193 800-624-9220 - www.alphalab.com

Project Name: 100 MAIN ST
Project Number: 12461

Lab Number: L2316452
Report Date: 04/12/23

Alpha Sample ID	Client ID	Matrix	Sample Location	Collection Date/Time	Receive Date
L2316452-01	SB-34 (0.5-1)	SOIL	WHITEPLAINS, NY	03/29/23 09:15	03/29/23
L2316452-02	SB-33 (2-2.5)	SOIL	WHITEPLAINS, NY	03/29/23 08:50	03/29/23
L2316452-03	SB-35 (4-4.5)	SOIL	WHITEPLAINS, NY	03/29/23 12:30	03/29/23
L2316452-04	SB-36 (1-1.5)	SOIL	WHITEPLAINS, NY	03/29/23 13:00	03/29/23
L2316452-05	GW-2	WATER	WHITEPLAINS, NY	03/29/23 12:00	03/29/23

Project Name:	100 MAIN ST	**Lab Number:**	L2316452
Project Number:	12461	**Report Date:**	04/12/23

Case Narrative

The samples were received in accordance with the Chain of Custody and no significant deviations were encountered during the preparation or analysis unless otherwise noted. Sample Receipt, Container Information, and the Chain of Custody are located at the back of the report.

Results contained within this report relate only to the samples submitted under this Alpha Lab Number and meet NELAP requirements for all NELAP accredited parameters unless otherwise noted in the following narrative. The data presented in this report is organized by parameter (i.e. VOC, SVOC, etc.). Sample specific Quality Control data (i.e. Surrogate Spike Recovery) is reported at the end of the target analyte list for each individual sample, followed by the Laboratory Batch Quality Control at the end of each parameter. Tentatively Identified Compounds (TICs), if requested, are reported for compounds identified to be present and are not part of the method/program Target Compound List, even if only a subset of the TCL are being reported. If a sample was re-analyzed or re-extracted due to a required quality control corrective action and if both sets of data are reported, the Laboratory ID of the re-analysis or re-extraction is designated with an "R" or "RE", respectively.

When multiple Batch Quality Control elements are reported (e.g. more than one LCS), the associated samples for each element are noted in the grey shaded header line of each data table. Any Laboratory Batch, Sample Specific % recovery or RPD value that is outside the listed Acceptance Criteria is bolded in the report. In reference to questions H (CAM) or 4 (RCP) when "NO" is checked, the performance criteria for CAM and RCP methods allow for some quality control failures to occur and still be within method compliance. In these instances, the specific failure is not narrated but noted in the associated QC Outlier Summary Report, located directly after the Case Narrative. QC information is also incorporated in the Data Usability Assessment table (Format 11) of our Data Merger tool, where it can be reviewed in conjunction with the sample result, associated regulatory criteria and any associated data usability implications.

Soil/sediments, solids and tissues are reported on a dry weight basis unless otherwise noted. Definitions of all data qualifiers and acronyms used in this report are provided in the Glossary located at the back of the report.

HOLD POLICY - For samples submitted on hold, Alpha's policy is to hold samples (with the exception of Air canisters) free of charge for 21 calendar days from the date the project is completed. After 21 calendar days, we will dispose of all samples submitted including those put on hold unless you have contacted your Alpha Project Manager and made arrangements for Alpha to continue to hold the samples. Air canisters will be disposed after 3 business days from the date the project is completed.

Please contact Project Management at 800-624-9220 with any questions.

Project Name:	100 MAIN ST	**Lab Number:**	L2316452
Project Number:	12461	**Report Date:**	04/12/23

Case Narrative (continued)

Report Submission

April 12, 2023: This final report includes the results of all requested analyses.

April 06, 2023: This is a preliminary report.

April 05, 2023: This is a preliminary report.

All non-detect (ND) or estimated concentrations (J-qualified) have been quantitated to the limit noted in the MDL column.

Semivolatile Organics

The WG1760400-1 Method Blank, associated with L2316452-01 through -04, has a TIC detected. The results are qualified with a "B" for any associated samples that have detections of the same TIC.

The WG1761567-1 Method Blank, associated with L2316452-05, has TICs detected. The results are qualified with a "B" for any associated samples that have detections of the same TICs.

Total Metals

L2316452-01 through -05: The sample has elevated detection limits for all elements, with the exception of mercury, due to the dilution required by the sample matrix.

The WG1760797-1 Method Blank, associated with L2316452-01 through -04, has a concentration above the reporting limit for iron. Since the associated sample concentrations are greater than 10x the blank concentration, no corrective action is required.

I, the undersigned, attest under the pains and penalties of perjury that, to the best of my knowledge and belief and based upon my personal inquiry of those responsible for providing the information contained in this analytical report, such information is accurate and complete. This certificate of analysis is not complete unless this page accompanies any and all pages of this report.

Authorized Signature: Kelly Stenstrom

Title: Technical Director/Representative Date: 04/12/23

ORGANICS

VOLATILES

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-01
Client ID: SB-34 (0.5-1)
Sample Location: WHITEPLAINS, NY

Date Collected: 03/29/23 09:15
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8260D
Analytical Date: 03/31/23 00:11
Analyst: JIC
Percent Solids: 90%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Methylene chloride	ND		ug/kg	5.3	2.4	1
1,1-Dichloroethane	ND		ug/kg	1.1	0.15	1
Chloroform	ND		ug/kg	1.6	0.15	1
Carbon tetrachloride	ND		ug/kg	1.1	0.24	1
1,2-Dichloropropane	ND		ug/kg	1.1	0.13	1
Dibromochloromethane	ND		ug/kg	1.1	0.15	1
1,1,2-Trichloroethane	ND		ug/kg	1.1	0.28	1
Tetrachloroethene	ND		ug/kg	0.53	0.21	1
Chlorobenzene	ND		ug/kg	0.53	0.14	1
Trichlorofluoromethane	ND		ug/kg	4.3	0.74	1
1,2-Dichloroethane	ND		ug/kg	1.1	0.27	1
1,1,1-Trichloroethane	ND		ug/kg	0.53	0.18	1
Bromodichloromethane	ND		ug/kg	0.53	0.12	1
trans-1,3-Dichloropropene	ND		ug/kg	1.1	0.29	1
cis-1,3-Dichloropropene	ND		ug/kg	0.53	0.17	1
1,3-Dichloropropene, Total	ND		ug/kg	0.53	0.17	1
1,1-Dichloropropene	ND		ug/kg	0.53	0.17	1
Bromoform	ND		ug/kg	4.3	0.26	1
1,1,2,2-Tetrachloroethane	ND		ug/kg	0.53	0.18	1
Benzene	ND		ug/kg	0.53	0.18	1
Toluene	ND		ug/kg	1.1	0.58	1
Ethylbenzene	ND		ug/kg	1.1	0.15	1
Chloromethane	ND		ug/kg	4.3	0.99	1
Bromomethane	ND		ug/kg	2.1	0.62	1
Vinyl chloride	ND		ug/kg	1.1	0.36	1
Chloroethane	ND		ug/kg	2.1	0.48	1
1,1-Dichloroethene	ND		ug/kg	1.1	0.25	1
trans-1,2-Dichloroethene	ND		ug/kg	1.6	0.15	1

Project Name: 100 MAIN ST **Lab Number:** L2316452

Project Number: 12461 **Report Date:** 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-01 Date Collected: 03/29/23 09:15

Client ID: SB-34 (0.5-1) Date Received: 03/29/23

Sample Location: WHITEPLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Trichloroethene	ND		ug/kg	0.53	0.15	1
1,2-Dichlorobenzene	ND		ug/kg	2.1	0.15	1
1,3-Dichlorobenzene	ND		ug/kg	2.1	0.16	1
1,4-Dichlorobenzene	ND		ug/kg	2.1	0.18	1
Methyl tert butyl ether	ND		ug/kg	2.1	0.21	1
p/m-Xylene	ND		ug/kg	2.1	0.60	1
o-Xylene	ND		ug/kg	1.1	0.31	1
Xylenes, Total	ND		ug/kg	1.1	0.31	1
cis-1,2-Dichloroethene	ND		ug/kg	1.1	0.19	1
1,2-Dichloroethene, Total	ND		ug/kg	1.1	0.15	1
Dibromomethane	ND		ug/kg	2.1	0.25	1
Styrene	ND		ug/kg	1.1	0.21	1
Dichlorodifluoromethane	ND		ug/kg	11	0.98	1
Acetone	ND		ug/kg	11	5.1	1
Carbon disulfide	ND		ug/kg	11	4.8	1
2-Butanone	ND		ug/kg	11	2.4	1
Vinyl acetate	ND		ug/kg	11	2.3	1
4-Methyl-2-pentanone	ND		ug/kg	11	1.4	1
1,2,3-Trichloropropane	ND		ug/kg	2.1	0.14	1
2-Hexanone	ND		ug/kg	11	1.2	1
Bromochloromethane	ND		ug/kg	2.1	0.22	1
2,2-Dichloropropane	ND		ug/kg	2.1	0.22	1
1,2-Dibromoethane	ND		ug/kg	1.1	0.30	1
1,3-Dichloropropane	ND		ug/kg	2.1	0.18	1
1,1,1,2-Tetrachloroethane	ND		ug/kg	0.53	0.14	1
Bromobenzene	ND		ug/kg	2.1	0.15	1
n-Butylbenzene	ND		ug/kg	1.1	0.18	1
sec-Butylbenzene	ND		ug/kg	1.1	0.16	1
tert-Butylbenzene	ND		ug/kg	2.1	0.12	1
o-Chlorotoluene	ND		ug/kg	2.1	0.20	1
p-Chlorotoluene	ND		ug/kg	2.1	0.12	1
1,2-Dibromo-3-chloropropane	ND		ug/kg	3.2	1.1	1
Hexachlorobutadiene	ND		ug/kg	4.3	0.18	1
Isopropylbenzene	ND		ug/kg	1.1	0.12	1
p-Isopropyltoluene	ND		ug/kg	1.1	0.12	1
Naphthalene	ND		ug/kg	4.3	0.69	1
Acrylonitrile	ND		ug/kg	4.3	1.2	1

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-01
Client ID: SB-34 (0.5-1)
Sample Location: WHITEPLAINS, NY
Date Collected: 03/29/23 09:15
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
n-Propylbenzene	ND		ug/kg	1.1	0.18	1
1,2,3-Trichlorobenzene	ND		ug/kg	2.1	0.34	1
1,2,4-Trichlorobenzene	ND		ug/kg	2.1	0.29	1
1,3,5-Trimethylbenzene	ND		ug/kg	2.1	0.20	1
1,2,4-Trimethylbenzene	ND		ug/kg	2.1	0.36	1
1,4-Dioxane	ND		ug/kg	85	37.	1
p-Diethylbenzene	ND		ug/kg	2.1	0.19	1
p-Ethyltoluene	ND		ug/kg	2.1	0.41	1
1,2,4,5-Tetramethylbenzene	ND		ug/kg	2.1	0.20	1
Ethyl ether	ND		ug/kg	2.1	0.36	1
trans-1,4-Dichloro-2-butene	ND		ug/kg	5.3	1.5	1
Tentatively Identified Compounds						
Total TIC Compounds	9.41	J	ug/kg			1
Unknown	9.41	J	ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	106		70-130
Toluene-d8	94		70-130
4-Bromofluorobenzene	92		70-130
Dibromofluoromethane	116		70-130

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-02
Client ID: SB-33 (2-2.5)
Sample Location: WHITEPLAINS, NY

Date Collected: 03/29/23 08:50
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8260D
Analytical Date: 03/31/23 00:37
Analyst: JIC
Percent Solids: 94%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Methylene chloride	ND		ug/kg	4.8	2.2	1
1,1-Dichloroethane	ND		ug/kg	0.96	0.14	1
Chloroform	ND		ug/kg	1.4	0.13	1
Carbon tetrachloride	ND		ug/kg	0.96	0.22	1
1,2-Dichloropropane	ND		ug/kg	0.96	0.12	1
Dibromochloromethane	ND		ug/kg	0.96	0.13	1
1,1,2-Trichloroethane	ND		ug/kg	0.96	0.26	1
Tetrachloroethene	ND		ug/kg	0.48	0.19	1
Chlorobenzene	ND		ug/kg	0.48	0.12	1
Trichlorofluoromethane	ND		ug/kg	3.8	0.67	1
1,2-Dichloroethane	ND		ug/kg	0.96	0.25	1
1,1,1-Trichloroethane	ND		ug/kg	0.48	0.16	1
Bromodichloromethane	ND		ug/kg	0.48	0.10	1
trans-1,3-Dichloropropene	ND		ug/kg	0.96	0.26	1
cis-1,3-Dichloropropene	ND		ug/kg	0.48	0.15	1
1,3-Dichloropropene, Total	ND		ug/kg	0.48	0.15	1
1,1-Dichloropropene	ND		ug/kg	0.48	0.15	1
Bromoform	ND		ug/kg	3.8	0.24	1
1,1,2,2-Tetrachloroethane	ND		ug/kg	0.48	0.16	1
Benzene	ND		ug/kg	0.48	0.16	1
Toluene	ND		ug/kg	0.96	0.52	1
Ethylbenzene	ND		ug/kg	0.96	0.14	1
Chloromethane	ND		ug/kg	3.8	0.90	1
Bromomethane	ND		ug/kg	1.9	0.56	1
Vinyl chloride	ND		ug/kg	0.96	0.32	1
Chloroethane	ND		ug/kg	1.9	0.44	1
1,1-Dichloroethene	ND		ug/kg	0.96	0.23	1
trans-1,2-Dichloroethene	ND		ug/kg	1.4	0.13	1

Project Name: 100 MAIN ST **Lab Number:** L2316452

Project Number: 12461 **Report Date:** 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-02 Date Collected: 03/29/23 08:50

Client ID: SB-33 (2-2.5) Date Received: 03/29/23

Sample Location: WHITEPLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Trichloroethene	ND		ug/kg	0.48	0.13	1
1,2-Dichlorobenzene	ND		ug/kg	1.9	0.14	1
1,3-Dichlorobenzene	ND		ug/kg	1.9	0.14	1
1,4-Dichlorobenzene	ND		ug/kg	1.9	0.16	1
Methyl tert butyl ether	ND		ug/kg	1.9	0.19	1
p/m-Xylene	ND		ug/kg	1.9	0.54	1
o-Xylene	ND		ug/kg	0.96	0.28	1
Xylenes, Total	ND		ug/kg	0.96	0.28	1
cis-1,2-Dichloroethene	ND		ug/kg	0.96	0.17	1
1,2-Dichloroethene, Total	ND		ug/kg	0.96	0.13	1
Dibromomethane	ND		ug/kg	1.9	0.23	1
Styrene	ND		ug/kg	0.96	0.19	1
Dichlorodifluoromethane	ND		ug/kg	9.6	0.88	1
Acetone	ND		ug/kg	9.6	4.6	1
Carbon disulfide	ND		ug/kg	9.6	4.4	1
2-Butanone	ND		ug/kg	9.6	2.1	1
Vinyl acetate	ND		ug/kg	9.6	2.1	1
4-Methyl-2-pentanone	ND		ug/kg	9.6	1.2	1
1,2,3-Trichloropropane	ND		ug/kg	1.9	0.12	1
2-Hexanone	ND		ug/kg	9.6	1.1	1
Bromochloromethane	ND		ug/kg	1.9	0.20	1
2,2-Dichloropropane	ND		ug/kg	1.9	0.19	1
1,2-Dibromoethane	ND		ug/kg	0.96	0.27	1
1,3-Dichloropropane	ND		ug/kg	1.9	0.16	1
1,1,1,2-Tetrachloroethane	ND		ug/kg	0.48	0.13	1
Bromobenzene	ND		ug/kg	1.9	0.14	1
n-Butylbenzene	ND		ug/kg	0.96	0.16	1
sec-Butylbenzene	ND		ug/kg	0.96	0.14	1
tert-Butylbenzene	ND		ug/kg	1.9	0.11	1
o-Chlorotoluene	ND		ug/kg	1.9	0.18	1
p-Chlorotoluene	ND		ug/kg	1.9	0.10	1
1,2-Dibromo-3-chloropropane	ND		ug/kg	2.9	0.96	1
Hexachlorobutadiene	ND		ug/kg	3.8	0.16	1
Isopropylbenzene	ND		ug/kg	0.96	0.10	1
p-Isopropyltoluene	ND		ug/kg	0.96	0.10	1
Naphthalene	ND		ug/kg	3.8	0.62	1
Acrylonitrile	ND		ug/kg	3.8	1.1	1

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-02
Client ID: SB-33 (2-2.5)
Sample Location: WHITEPLAINS, NY
Date Collected: 03/29/23 08:50
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
n-Propylbenzene	ND		ug/kg	0.96	0.16	1
1,2,3-Trichlorobenzene	ND		ug/kg	1.9	0.31	1
1,2,4-Trichlorobenzene	ND		ug/kg	1.9	0.26	1
1,3,5-Trimethylbenzene	ND		ug/kg	1.9	0.18	1
1,2,4-Trimethylbenzene	ND		ug/kg	1.9	0.32	1
1,4-Dioxane	ND		ug/kg	77	34.	1
p-Diethylbenzene	ND		ug/kg	1.9	0.17	1
p-Ethyltoluene	ND		ug/kg	1.9	0.37	1
1,2,4,5-Tetramethylbenzene	ND		ug/kg	1.9	0.18	1
Ethyl ether	ND		ug/kg	1.9	0.33	1
trans-1,4-Dichloro-2-butene	ND		ug/kg	4.8	1.4	1
Tentatively Identified Compounds						
Total TIC Compounds	8.89	J	ug/kg			1
Unknown	8.89	J	ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	106		70-130
Toluene-d8	95		70-130
4-Bromofluorobenzene	90		70-130
Dibromofluoromethane	116		70-130

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-03
Client ID: SB-35 (4-4.5)
Sample Location: WHITEPLAINS, NY

Date Collected: 03/29/23 12:30
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8260D
Analytical Date: 03/31/23 01:02
Analyst: JIC
Percent Solids: 92%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Methylene chloride	ND		ug/kg	5.0	2.3	1
1,1-Dichloroethane	ND		ug/kg	1.0	0.15	1
Chloroform	ND		ug/kg	1.5	0.14	1
Carbon tetrachloride	ND		ug/kg	1.0	0.23	1
1,2-Dichloropropane	ND		ug/kg	1.0	0.12	1
Dibromochloromethane	ND		ug/kg	1.0	0.14	1
1,1,2-Trichloroethane	ND		ug/kg	1.0	0.27	1
Tetrachloroethene	ND		ug/kg	0.50	0.20	1
Chlorobenzene	ND		ug/kg	0.50	0.13	1
Trichlorofluoromethane	ND		ug/kg	4.0	0.70	1
1,2-Dichloroethane	ND		ug/kg	1.0	0.26	1
1,1,1-Trichloroethane	ND		ug/kg	0.50	0.17	1
Bromodichloromethane	ND		ug/kg	0.50	0.11	1
trans-1,3-Dichloropropene	ND		ug/kg	1.0	0.28	1
cis-1,3-Dichloropropene	ND		ug/kg	0.50	0.16	1
1,3-Dichloropropene, Total	ND		ug/kg	0.50	0.16	1
1,1-Dichloropropene	ND		ug/kg	0.50	0.16	1
Bromoform	ND		ug/kg	4.0	0.25	1
1,1,2,2-Tetrachloroethane	ND		ug/kg	0.50	0.17	1
Benzene	ND		ug/kg	0.50	0.17	1
Toluene	ND		ug/kg	1.0	0.55	1
Ethylbenzene	ND		ug/kg	1.0	0.14	1
Chloromethane	ND		ug/kg	4.0	0.94	1
Bromomethane	ND		ug/kg	2.0	0.58	1
Vinyl chloride	ND		ug/kg	1.0	0.34	1
Chloroethane	ND		ug/kg	2.0	0.46	1
1,1-Dichloroethene	ND		ug/kg	1.0	0.24	1
trans-1,2-Dichloroethene	ND		ug/kg	1.5	0.14	1

Project Name: 100 MAIN ST **Lab Number:** L2316452

Project Number: 12461 **Report Date:** 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-03 Date Collected: 03/29/23 12:30

Client ID: SB-35 (4-4.5) Date Received: 03/29/23

Sample Location: WHITEPLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Trichloroethene	ND		ug/kg	0.50	0.14	1
1,2-Dichlorobenzene	ND		ug/kg	2.0	0.14	1
1,3-Dichlorobenzene	ND		ug/kg	2.0	0.15	1
1,4-Dichlorobenzene	ND		ug/kg	2.0	0.17	1
Methyl tert butyl ether	ND		ug/kg	2.0	0.20	1
p/m-Xylene	ND		ug/kg	2.0	0.56	1
o-Xylene	ND		ug/kg	1.0	0.29	1
Xylenes, Total	ND		ug/kg	1.0	0.29	1
cis-1,2-Dichloroethene	ND		ug/kg	1.0	0.18	1
1,2-Dichloroethene, Total	ND		ug/kg	1.0	0.14	1
Dibromomethane	ND		ug/kg	2.0	0.24	1
Styrene	ND		ug/kg	1.0	0.20	1
Dichlorodifluoromethane	ND		ug/kg	10	0.92	1
Acetone	ND		ug/kg	10	4.8	1
Carbon disulfide	ND		ug/kg	10	4.6	1
2-Butanone	ND		ug/kg	10	2.2	1
Vinyl acetate	ND		ug/kg	10	2.2	1
4-Methyl-2-pentanone	ND		ug/kg	10	1.3	1
1,2,3-Trichloropropane	ND		ug/kg	2.0	0.13	1
2-Hexanone	ND		ug/kg	10	1.2	1
Bromochloromethane	ND		ug/kg	2.0	0.21	1
2,2-Dichloropropane	ND		ug/kg	2.0	0.20	1
1,2-Dibromoethane	ND		ug/kg	1.0	0.28	1
1,3-Dichloropropane	ND		ug/kg	2.0	0.17	1
1,1,1,2-Tetrachloroethane	ND		ug/kg	0.50	0.13	1
Bromobenzene	ND		ug/kg	2.0	0.15	1
n-Butylbenzene	ND		ug/kg	1.0	0.17	1
sec-Butylbenzene	ND		ug/kg	1.0	0.15	1
tert-Butylbenzene	ND		ug/kg	2.0	0.12	1
o-Chlorotoluene	ND		ug/kg	2.0	0.19	1
p-Chlorotoluene	ND		ug/kg	2.0	0.11	1
1,2-Dibromo-3-chloropropane	ND		ug/kg	3.0	1.0	1
Hexachlorobutadiene	ND		ug/kg	4.0	0.17	1
Isopropylbenzene	ND		ug/kg	1.0	0.11	1
p-Isopropyltoluene	ND		ug/kg	1.0	0.11	1
Naphthalene	ND		ug/kg	4.0	0.65	1
Acrylonitrile	ND		ug/kg	4.0	1.2	1

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-03
Client ID: SB-35 (4-4.5)
Sample Location: WHITEPLAINS, NY
Date Collected: 03/29/23 12:30
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
n-Propylbenzene	ND		ug/kg	1.0	0.17	1
1,2,3-Trichlorobenzene	ND		ug/kg	2.0	0.32	1
1,2,4-Trichlorobenzene	ND		ug/kg	2.0	0.27	1
1,3,5-Trimethylbenzene	ND		ug/kg	2.0	0.19	1
1,2,4-Trimethylbenzene	ND		ug/kg	2.0	0.34	1
1,4-Dioxane	ND		ug/kg	81	35.	1
p-Diethylbenzene	ND		ug/kg	2.0	0.18	1
p-Ethyltoluene	ND		ug/kg	2.0	0.39	1
1,2,4,5-Tetramethylbenzene	ND		ug/kg	2.0	0.19	1
Ethyl ether	ND		ug/kg	2.0	0.34	1
trans-1,4-Dichloro-2-butene	ND		ug/kg	5.0	1.4	1
Tentatively Identified Compounds						
Total TIC Compounds	8.60	J	ug/kg			1
Unknown	8.60	J	ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	105		70-130
Toluene-d8	95		70-130
4-Bromofluorobenzene	88		70-130
Dibromofluoromethane	120		70-130

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-04
Client ID: SB-36 (1-1.5)
Sample Location: WHITEPLAINS, NY

Date Collected: 03/29/23 13:00
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8260D
Analytical Date: 03/31/23 01:27
Analyst: JIC
Percent Solids: 85%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Methylene chloride	ND		ug/kg	5.5	2.5	1
1,1-Dichloroethane	ND		ug/kg	1.1	0.16	1
Chloroform	ND		ug/kg	1.7	0.16	1
Carbon tetrachloride	ND		ug/kg	1.1	0.26	1
1,2-Dichloropropane	ND		ug/kg	1.1	0.14	1
Dibromochloromethane	ND		ug/kg	1.1	0.16	1
1,1,2-Trichloroethane	ND		ug/kg	1.1	0.30	1
Tetrachloroethene	ND		ug/kg	0.55	0.22	1
Chlorobenzene	ND		ug/kg	0.55	0.14	1
Trichlorofluoromethane	ND		ug/kg	4.4	0.77	1
1,2-Dichloroethane	ND		ug/kg	1.1	0.28	1
1,1,1-Trichloroethane	ND		ug/kg	0.55	0.18	1
Bromodichloromethane	ND		ug/kg	0.55	0.12	1
trans-1,3-Dichloropropene	ND		ug/kg	1.1	0.30	1
cis-1,3-Dichloropropene	ND		ug/kg	0.55	0.18	1
1,3-Dichloropropene, Total	ND		ug/kg	0.55	0.18	1
1,1-Dichloropropene	ND		ug/kg	0.55	0.18	1
Bromoform	ND		ug/kg	4.4	0.27	1
1,1,2,2-Tetrachloroethane	ND		ug/kg	0.55	0.18	1
Benzene	ND		ug/kg	0.55	0.18	1
Toluene	ND		ug/kg	1.1	0.60	1
Ethylbenzene	ND		ug/kg	1.1	0.16	1
Chloromethane	ND		ug/kg	4.4	1.0	1
Bromomethane	ND		ug/kg	2.2	0.64	1
Vinyl chloride	ND		ug/kg	1.1	0.37	1
Chloroethane	ND		ug/kg	2.2	0.50	1
1,1-Dichloroethene	ND		ug/kg	1.1	0.26	1
trans-1,2-Dichloroethene	ND		ug/kg	1.7	0.15	1

Project Name: 100 MAIN ST **Lab Number:** L2316452

Project Number: 12461 **Report Date:** 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-04 Date Collected: 03/29/23 13:00

Client ID: SB-36 (1-1.5) Date Received: 03/29/23

Sample Location: WHITEPLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Trichloroethene	ND		ug/kg	0.55	0.15	1
1,2-Dichlorobenzene	ND		ug/kg	2.2	0.16	1
1,3-Dichlorobenzene	ND		ug/kg	2.2	0.16	1
1,4-Dichlorobenzene	ND		ug/kg	2.2	0.19	1
Methyl tert butyl ether	ND		ug/kg	2.2	0.22	1
p/m-Xylene	ND		ug/kg	2.2	0.62	1
o-Xylene	ND		ug/kg	1.1	0.32	1
Xylenes, Total	ND		ug/kg	1.1	0.32	1
cis-1,2-Dichloroethene	ND		ug/kg	1.1	0.19	1
1,2-Dichloroethene, Total	ND		ug/kg	1.1	0.15	1
Dibromomethane	ND		ug/kg	2.2	0.26	1
Styrene	ND		ug/kg	1.1	0.22	1
Dichlorodifluoromethane	ND		ug/kg	11	1.0	1
Acetone	ND		ug/kg	11	5.3	1
Carbon disulfide	ND		ug/kg	11	5.0	1
2-Butanone	ND		ug/kg	11	2.5	1
Vinyl acetate	ND		ug/kg	11	2.4	1
4-Methyl-2-pentanone	ND		ug/kg	11	1.4	1
1,2,3-Trichloropropane	ND		ug/kg	2.2	0.14	1
2-Hexanone	ND		ug/kg	11	1.3	1
Bromochloromethane	ND		ug/kg	2.2	0.23	1
2,2-Dichloropropane	ND		ug/kg	2.2	0.22	1
1,2-Dibromoethane	ND		ug/kg	1.1	0.31	1
1,3-Dichloropropane	ND		ug/kg	2.2	0.18	1
1,1,1,2-Tetrachloroethane	ND		ug/kg	0.55	0.15	1
Bromobenzene	ND		ug/kg	2.2	0.16	1
n-Butylbenzene	ND		ug/kg	1.1	0.18	1
sec-Butylbenzene	ND		ug/kg	1.1	0.16	1
tert-Butylbenzene	ND		ug/kg	2.2	0.13	1
o-Chlorotoluene	ND		ug/kg	2.2	0.21	1
p-Chlorotoluene	ND		ug/kg	2.2	0.12	1
1,2-Dibromo-3-chloropropane	ND		ug/kg	3.3	1.1	1
Hexachlorobutadiene	ND		ug/kg	4.4	0.19	1
Isopropylbenzene	ND		ug/kg	1.1	0.12	1
p-Isopropyltoluene	ND		ug/kg	1.1	0.12	1
Naphthalene	ND		ug/kg	4.4	0.72	1
Acrylonitrile	ND		ug/kg	4.4	1.3	1

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-04
Client ID: SB-36 (1-1.5)
Sample Location: WHITEPLAINS, NY
Date Collected: 03/29/23 13:00
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
n-Propylbenzene	ND		ug/kg	1.1	0.19	1
1,2,3-Trichlorobenzene	ND		ug/kg	2.2	0.36	1
1,2,4-Trichlorobenzene	ND		ug/kg	2.2	0.30	1
1,3,5-Trimethylbenzene	ND		ug/kg	2.2	0.21	1
1,2,4-Trimethylbenzene	ND		ug/kg	2.2	0.37	1
1,4-Dioxane	ND		ug/kg	89	39.	1
p-Diethylbenzene	ND		ug/kg	2.2	0.20	1
p-Ethyltoluene	ND		ug/kg	2.2	0.42	1
1,2,4,5-Tetramethylbenzene	ND		ug/kg	2.2	0.21	1
Ethyl ether	ND		ug/kg	2.2	0.38	1
trans-1,4-Dichloro-2-butene	ND		ug/kg	5.5	1.6	1
Tentatively Identified Compounds						
Total TIC Compounds	12.2	J	ug/kg			1
Unknown	2.28	J	ug/kg			1
Unknown	9.94	J	ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	106		70-130
Toluene-d8	95		70-130
4-Bromofluorobenzene	87		70-130
Dibromofluoromethane	119		70-130

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-05
Client ID: GW-2
Sample Location: WHITEPLAINS, NY

Date Collected: 03/29/23 12:00
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8260D
Analytical Date: 03/31/23 11:11
Analyst: PID

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Methylene chloride	ND		ug/l	2.5	0.70	1
1,1-Dichloroethane	ND		ug/l	2.5	0.70	1
Chloroform	ND		ug/l	2.5	0.70	1
Carbon tetrachloride	ND		ug/l	0.50	0.13	1
1,2-Dichloropropane	ND		ug/l	1.0	0.14	1
Dibromochloromethane	ND		ug/l	0.50	0.15	1
1,1,2-Trichloroethane	ND		ug/l	1.5	0.50	1
Tetrachloroethene	ND		ug/l	0.50	0.18	1
Chlorobenzene	ND		ug/l	2.5	0.70	1
Trichlorofluoromethane	ND		ug/l	2.5	0.70	1
1,2-Dichloroethane	ND		ug/l	0.50	0.13	1
1,1,1-Trichloroethane	ND		ug/l	2.5	0.70	1
Bromodichloromethane	ND		ug/l	0.50	0.19	1
trans-1,3-Dichloropropene	ND		ug/l	0.50	0.16	1
cis-1,3-Dichloropropene	ND		ug/l	0.50	0.14	1
1,3-Dichloropropene, Total	ND		ug/l	0.50	0.14	1
1,1-Dichloropropene	ND		ug/l	2.5	0.70	1
Bromoform	ND		ug/l	2.0	0.65	1
1,1,2,2-Tetrachloroethane	ND		ug/l	0.50	0.17	1
Benzene	ND		ug/l	0.50	0.16	1
Toluene	ND		ug/l	2.5	0.70	1
Ethylbenzene	ND		ug/l	2.5	0.70	1
Chloromethane	ND		ug/l	2.5	0.70	1
Bromomethane	ND		ug/l	2.5	0.70	1
Vinyl chloride	ND		ug/l	1.0	0.07	1
Chloroethane	ND		ug/l	2.5	0.70	1
1,1-Dichloroethene	ND		ug/l	0.50	0.17	1
trans-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST **Lab Number:** L2316452

Project Number: 12461 **Report Date:** 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-05 Date Collected: 03/29/23 12:00

Client ID: GW-2 Date Received: 03/29/23

Sample Location: WHITEPLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Trichloroethene	1.6		ug/l	0.50	0.18	1
1,2-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,3-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,4-Dichlorobenzene	ND		ug/l	2.5	0.70	1
Methyl tert butyl ether	ND		ug/l	2.5	0.70	1
p/m-Xylene	ND		ug/l	2.5	0.70	1
o-Xylene	ND		ug/l	2.5	0.70	1
Xylenes, Total	ND		ug/l	2.5	0.70	1
cis-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1
1,2-Dichloroethene, Total	ND		ug/l	2.5	0.70	1
Dibromomethane	ND		ug/l	5.0	1.0	1
1,2,3-Trichloropropane	ND		ug/l	2.5	0.70	1
Acrylonitrile	ND		ug/l	5.0	1.5	1
Styrene	ND		ug/l	2.5	0.70	1
Dichlorodifluoromethane	ND		ug/l	5.0	1.0	1
Acetone	14		ug/l	5.0	1.5	1
Carbon disulfide	ND		ug/l	5.0	1.0	1
2-Butanone	ND		ug/l	5.0	1.9	1
Vinyl acetate	ND		ug/l	5.0	1.0	1
4-Methyl-2-pentanone	ND		ug/l	5.0	1.0	1
2-Hexanone	ND		ug/l	5.0	1.0	1
Bromochloromethane	ND		ug/l	2.5	0.70	1
2,2-Dichloropropane	ND		ug/l	2.5	0.70	1
1,2-Dibromoethane	ND		ug/l	2.0	0.65	1
1,3-Dichloropropane	ND		ug/l	2.5	0.70	1
1,1,1,2-Tetrachloroethane	ND		ug/l	2.5	0.70	1
Bromobenzene	ND		ug/l	2.5	0.70	1
n-Butylbenzene	ND		ug/l	2.5	0.70	1
sec-Butylbenzene	ND		ug/l	2.5	0.70	1
tert-Butylbenzene	ND		ug/l	2.5	0.70	1
o-Chlorotoluene	ND		ug/l	2.5	0.70	1
p-Chlorotoluene	ND		ug/l	2.5	0.70	1
1,2-Dibromo-3-chloropropane	ND		ug/l	2.5	0.70	1
Hexachlorobutadiene	ND		ug/l	2.5	0.70	1
Isopropylbenzene	ND		ug/l	2.5	0.70	1
p-Isopropyltoluene	ND		ug/l	2.5	0.70	1
Naphthalene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-05
Client ID: GW-2
Sample Location: WHITEPLAINS, NY
Date Collected: 03/29/23 12:00
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
n-Propylbenzene	ND		ug/l	2.5	0.70	1
1,2,3-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,3,5-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,4-Dioxane	ND		ug/l	250	61.	1
p-Diethylbenzene	ND		ug/l	2.0	0.70	1
p-Ethyltoluene	ND		ug/l	2.0	0.70	1
1,2,4,5-Tetramethylbenzene	ND		ug/l	2.0	0.54	1
Ethyl ether	ND		ug/l	2.5	0.70	1
trans-1,4-Dichloro-2-butene	ND		ug/l	2.5	0.70	1

Tentatively Identified Compounds			
No Tentatively Identified Compounds	ND	ug/l	1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	112		70-130
Toluene-d8	103		70-130
4-Bromofluorobenzene	93		70-130
Dibromofluoromethane	113		70-130

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 03/30/23 22:03
Analyst: MKS

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by EPA 5035 Low - Westborough Lab for sample(s): 01-04 Batch: WG1761220-5					
Methylene chloride	ND		ug/kg	5.0	2.3
1,1-Dichloroethane	ND		ug/kg	1.0	0.14
Chloroform	ND		ug/kg	1.5	0.14
Carbon tetrachloride	ND		ug/kg	1.0	0.23
1,2-Dichloropropane	ND		ug/kg	1.0	0.12
Dibromochloromethane	ND		ug/kg	1.0	0.14
1,1,2-Trichloroethane	ND		ug/kg	1.0	0.27
Tetrachloroethene	ND		ug/kg	0.50	0.20
Chlorobenzene	ND		ug/kg	0.50	0.13
Trichlorofluoromethane	ND		ug/kg	4.0	0.70
1,2-Dichloroethane	ND		ug/kg	1.0	0.26
1,1,1-Trichloroethane	ND		ug/kg	0.50	0.17
Bromodichloromethane	ND		ug/kg	0.50	0.11
trans-1,3-Dichloropropene	ND		ug/kg	1.0	0.27
cis-1,3-Dichloropropene	ND		ug/kg	0.50	0.16
1,3-Dichloropropene, Total	ND		ug/kg	0.50	0.16
1,1-Dichloropropene	ND		ug/kg	0.50	0.16
Bromoform	ND		ug/kg	4.0	0.25
1,1,2,2-Tetrachloroethane	ND		ug/kg	0.50	0.17
Benzene	ND		ug/kg	0.50	0.17
Toluene	ND		ug/kg	1.0	0.54
Ethylbenzene	ND		ug/kg	1.0	0.14
Chloromethane	ND		ug/kg	4.0	0.93
Bromomethane	0.82	J	ug/kg	2.0	0.58
Vinyl chloride	ND		ug/kg	1.0	0.34
Chloroethane	ND		ug/kg	2.0	0.45
1,1-Dichloroethene	ND		ug/kg	1.0	0.24
trans-1,2-Dichloroethene	ND		ug/kg	1.5	0.14
Trichloroethene	ND		ug/kg	0.50	0.14

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 03/30/23 22:03
Analyst: MKS

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by EPA 5035 Low - Westborough Lab for sample(s): 01-04 Batch: WG1761220-5					
1,2-Dichlorobenzene	ND		ug/kg	2.0	0.14
1,3-Dichlorobenzene	ND		ug/kg	2.0	0.15
1,4-Dichlorobenzene	ND		ug/kg	2.0	0.17
Methyl tert butyl ether	ND		ug/kg	2.0	0.20
p/m-Xylene	ND		ug/kg	2.0	0.56
o-Xylene	ND		ug/kg	1.0	0.29
Xylenes, Total	ND		ug/kg	1.0	0.29
cis-1,2-Dichloroethene	ND		ug/kg	1.0	0.18
1,2-Dichloroethene, Total	ND		ug/kg	1.0	0.14
Dibromomethane	ND		ug/kg	2.0	0.24
Styrene	ND		ug/kg	1.0	0.20
Dichlorodifluoromethane	ND		ug/kg	10	0.92
Acetone	ND		ug/kg	10	4.8
Carbon disulfide	ND		ug/kg	10	4.6
2-Butanone	ND		ug/kg	10	2.2
Vinyl acetate	ND		ug/kg	10	2.2
4-Methyl-2-pentanone	ND		ug/kg	10	1.3
1,2,3-Trichloropropane	ND		ug/kg	2.0	0.13
2-Hexanone	ND		ug/kg	10	1.2
Bromochloromethane	ND		ug/kg	2.0	0.20
2,2-Dichloropropane	ND		ug/kg	2.0	0.20
1,2-Dibromoethane	ND		ug/kg	1.0	0.28
1,3-Dichloropropane	ND		ug/kg	2.0	0.17
1,1,1,2-Tetrachloroethane	ND		ug/kg	0.50	0.13
Bromobenzene	ND		ug/kg	2.0	0.14
n-Butylbenzene	ND		ug/kg	1.0	0.17
sec-Butylbenzene	ND		ug/kg	1.0	0.15
tert-Butylbenzene	ND		ug/kg	2.0	0.12
o-Chlorotoluene	ND		ug/kg	2.0	0.19

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 03/30/23 22:03
Analyst: MKS

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by EPA 5035 Low - Westborough Lab for sample(s): 01-04 Batch: WG1761220-5					
p-Chlorotoluene	ND		ug/kg	2.0	0.11
1,2-Dibromo-3-chloropropane	ND		ug/kg	3.0	1.0
Hexachlorobutadiene	ND		ug/kg	4.0	0.17
Isopropylbenzene	ND		ug/kg	1.0	0.11
p-Isopropyltoluene	ND		ug/kg	1.0	0.11
Naphthalene	ND		ug/kg	4.0	0.65
Acrylonitrile	ND		ug/kg	4.0	1.2
n-Propylbenzene	ND		ug/kg	1.0	0.17
1,2,3-Trichlorobenzene	ND		ug/kg	2.0	0.32
1,2,4-Trichlorobenzene	ND		ug/kg	2.0	0.27
1,3,5-Trimethylbenzene	ND		ug/kg	2.0	0.19
1,2,4-Trimethylbenzene	ND		ug/kg	2.0	0.33
1,4-Dioxane	ND		ug/kg	80	35.
p-Diethylbenzene	ND		ug/kg	2.0	0.18
p-Ethyltoluene	ND		ug/kg	2.0	0.38
1,2,4,5-Tetramethylbenzene	ND		ug/kg	2.0	0.19
Ethyl ether	ND		ug/kg	2.0	0.34
trans-1,4-Dichloro-2-butene	ND		ug/kg	5.0	1.4

Tentatively Identified Compounds			
Total TIC Compounds	15.0	J	ug/kg
Cyclotrisiloxane, Hexamethyl-	4.74	NJ	ug/kg
Unknown	7.55	J	ug/kg
Unknown	2.75	J	ug/kg

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 03/30/23 22:03
Analyst: MKS

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by EPA 5035 Low - Westborough Lab for sample(s): 01-04 Batch: WG1761220-5					

Surrogate	%Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	103		70-130
Toluene-d8	94		70-130
4-Bromofluorobenzene	96		70-130
Dibromofluoromethane	110		70-130

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 03/31/23 10:08
Analyst: PID

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by GC/MS - Westborough Lab for sample(s): 05 Batch: WG1761896-5					
Methylene chloride	ND		ug/l	2.5	0.70
1,1-Dichloroethane	ND		ug/l	2.5	0.70
Chloroform	ND		ug/l	2.5	0.70
Carbon tetrachloride	ND		ug/l	0.50	0.13
1,2-Dichloropropane	ND		ug/l	1.0	0.14
Dibromochloromethane	ND		ug/l	0.50	0.15
1,1,2-Trichloroethane	ND		ug/l	1.5	0.50
Tetrachloroethene	ND		ug/l	0.50	0.18
Chlorobenzene	ND		ug/l	2.5	0.70
Trichlorofluoromethane	ND		ug/l	2.5	0.70
1,2-Dichloroethane	ND		ug/l	0.50	0.13
1,1,1-Trichloroethane	ND		ug/l	2.5	0.70
Bromodichloromethane	ND		ug/l	0.50	0.19
trans-1,3-Dichloropropene	ND		ug/l	0.50	0.16
cis-1,3-Dichloropropene	ND		ug/l	0.50	0.14
1,3-Dichloropropene, Total	ND		ug/l	0.50	0.14
1,1-Dichloropropene	ND		ug/l	2.5	0.70
Bromoform	ND		ug/l	2.0	0.65
1,1,2,2-Tetrachloroethane	ND		ug/l	0.50	0.17
Benzene	ND		ug/l	0.50	0.16
Toluene	ND		ug/l	2.5	0.70
Ethylbenzene	ND		ug/l	2.5	0.70
Chloromethane	ND		ug/l	2.5	0.70
Bromomethane	ND		ug/l	2.5	0.70
Vinyl chloride	ND		ug/l	1.0	0.07
Chloroethane	ND		ug/l	2.5	0.70
1,1-Dichloroethene	ND		ug/l	0.50	0.17
trans-1,2-Dichloroethene	ND		ug/l	2.5	0.70
Trichloroethene	ND		ug/l	0.50	0.18

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 03/31/23 10:08
Analyst: PID

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by GC/MS - Westborough Lab for sample(s): 05 Batch: WG1761896-5					
1,2-Dichlorobenzene	ND		ug/l	2.5	0.70
1,3-Dichlorobenzene	ND		ug/l	2.5	0.70
1,4-Dichlorobenzene	ND		ug/l	2.5	0.70
Methyl tert butyl ether	ND		ug/l	2.5	0.70
p/m-Xylene	ND		ug/l	2.5	0.70
o-Xylene	ND		ug/l	2.5	0.70
Xylenes, Total	ND		ug/l	2.5	0.70
cis-1,2-Dichloroethene	ND		ug/l	2.5	0.70
1,2-Dichloroethene, Total	ND		ug/l	2.5	0.70
Dibromomethane	ND		ug/l	5.0	1.0
1,2,3-Trichloropropane	ND		ug/l	2.5	0.70
Acrylonitrile	ND		ug/l	5.0	1.5
Styrene	ND		ug/l	2.5	0.70
Dichlorodifluoromethane	ND		ug/l	5.0	1.0
Acetone	ND		ug/l	5.0	1.5
Carbon disulfide	ND		ug/l	5.0	1.0
2-Butanone	ND		ug/l	5.0	1.9
Vinyl acetate	ND		ug/l	5.0	1.0
4-Methyl-2-pentanone	ND		ug/l	5.0	1.0
2-Hexanone	ND		ug/l	5.0	1.0
Bromochloromethane	ND		ug/l	2.5	0.70
2,2-Dichloropropane	ND		ug/l	2.5	0.70
1,2-Dibromoethane	ND		ug/l	2.0	0.65
1,3-Dichloropropane	ND		ug/l	2.5	0.70
1,1,1,2-Tetrachloroethane	ND		ug/l	2.5	0.70
Bromobenzene	ND		ug/l	2.5	0.70
n-Butylbenzene	ND		ug/l	2.5	0.70
sec-Butylbenzene	ND		ug/l	2.5	0.70
tert-Butylbenzene	ND		ug/l	2.5	0.70

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 03/31/23 10:08
Analyst: PID

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by GC/MS - Westborough Lab for sample(s): 05 Batch: WG1761896-5					
o-Chlorotoluene	ND		ug/l	2.5	0.70
p-Chlorotoluene	ND		ug/l	2.5	0.70
1,2-Dibromo-3-chloropropane	ND		ug/l	2.5	0.70
Hexachlorobutadiene	ND		ug/l	2.5	0.70
Isopropylbenzene	ND		ug/l	2.5	0.70
p-Isopropyltoluene	ND		ug/l	2.5	0.70
Naphthalene	ND		ug/l	2.5	0.70
n-Propylbenzene	ND		ug/l	2.5	0.70
1,2,3-Trichlorobenzene	ND		ug/l	2.5	0.70
1,2,4-Trichlorobenzene	ND		ug/l	2.5	0.70
1,3,5-Trimethylbenzene	ND		ug/l	2.5	0.70
1,2,4-Trimethylbenzene	ND		ug/l	2.5	0.70
1,4-Dioxane	ND		ug/l	250	61.
p-Diethylbenzene	ND		ug/l	2.0	0.70
p-Ethyltoluene	ND		ug/l	2.0	0.70
1,2,4,5-Tetramethylbenzene	ND		ug/l	2.0	0.54
Ethyl ether	ND		ug/l	2.5	0.70
trans-1,4-Dichloro-2-butene	ND		ug/l	2.5	0.70

Tentatively Identified Compounds		
No Tentatively Identified Compounds	ND	ug/l

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 03/31/23 10:08
Analyst: PID

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by GC/MS - Westborough Lab for sample(s): 05 Batch: WG1761896-5					

Surrogate	%Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	116		70-130
Toluene-d8	100		70-130
4-Bromofluorobenzene	93		70-130
Dibromofluoromethane	106		70-130

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST

Project Number: 12461

Lab Number: L2316452

Report Date: 04/12/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by EPA 5035 Low - Westborough Lab Associated sample(s): 01-04 Batch: WG1761220-3 WG1761220-4								
Methylene chloride	87		86		70-130	1		30
1,1-Dichloroethane	94		96		70-130	2		30
Chloroform	105		106		70-130	1		30
Carbon tetrachloride	119		120		70-130	1		30
1,2-Dichloropropane	94		95		70-130	1		30
Dibromochloromethane	114		113		70-130	1		30
1,1,2-Trichloroethane	98		99		70-130	1		30
Tetrachloroethene	113		114		70-130	1		30
Chlorobenzene	103		102		70-130	1		30
Trichlorofluoromethane	119		120		70-139	1		30
1,2-Dichloroethane	98		98		70-130	0		30
1,1,1-Trichloroethane	112		115		70-130	3		30
Bromodichloromethane	106		108		70-130	2		30
trans-1,3-Dichloropropene	97		97		70-130	0		30
cis-1,3-Dichloropropene	103		102		70-130	1		30
1,1-Dichloropropene	103		106		70-130	3		30
Bromoform	100		103		70-130	3		30
1,1,2,2-Tetrachloroethane	90		88		70-130	2		30
Benzene	97		100		70-130	3		30
Toluene	97		98		70-130	1		30
Ethylbenzene	100		101		70-130	1		30
Chloromethane	72		73		52-130	1		30
Bromomethane	88		85		57-147	3		30

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST
Project Number: 12461

Lab Number: L2316452
Report Date: 04/12/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by EPA 5035 Low - Westborough Lab Associated sample(s): 01-04 Batch: WG1761220-3 WG1761220-4								
Vinyl chloride	78		78		67-130	0		30
Chloroethane	97		98		50-151	1		30
1,1-Dichloroethene	100		102		65-135	2		30
trans-1,2-Dichloroethene	100		102		70-130	2		30
Trichloroethene	111		114		70-130	3		30
1,2-Dichlorobenzene	98		100		70-130	2		30
1,3-Dichlorobenzene	99		102		70-130	3		30
1,4-Dichlorobenzene	99		101		70-130	2		30
Methyl tert butyl ether	100		100		66-130	0		30
p/m-Xylene	104		105		70-130	1		30
o-Xylene	106		106		70-130	0		30
cis-1,2-Dichloroethene	101		102		70-130	1		30
Dibromomethane	109		111		70-130	2		30
Styrene	109		109		70-130	0		30
Dichlorodifluoromethane	91		90		30-146	1		30
Acetone	112		110		54-140	2		30
Carbon disulfide	**146**	Q	**149**	Q	59-130	2		30
2-Butanone	114		113		70-130	1		30
Vinyl acetate	95		85		70-130	11		30
4-Methyl-2-pentanone	82		82		70-130	0		30
1,2,3-Trichloropropane	87		88		68-130	1		30
2-Hexanone	109		108		70-130	1		30
Bromochloromethane	111		112		70-130	1		30

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST

Project Number: 12461

Lab Number: L2316452

Report Date: 04/12/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by EPA 5035 Low - Westborough Lab Associated sample(s): 01-04 Batch: WG1761220-3 WG1761220-4								
2,2-Dichloropropane	97		100		70-130	3		30
1,2-Dibromoethane	108		106		70-130	2		30
1,3-Dichloropropane	98		96		69-130	2		30
1,1,1,2-Tetrachloroethane	115		116		70-130	1		30
Bromobenzene	100		100		70-130	0		30
n-Butylbenzene	100		102		70-130	2		30
sec-Butylbenzene	99		102		70-130	3		30
tert-Butylbenzene	101		102		70-130	1		30
o-Chlorotoluene	89		91		70-130	2		30
p-Chlorotoluene	89		92		70-130	3		30
1,2-Dibromo-3-chloropropane	100		101		68-130	1		30
Hexachlorobutadiene	102		102		67-130	0		30
Isopropylbenzene	97		99		70-130	2		30
p-Isopropyltoluene	101		104		70-130	3		30
Naphthalene	91		93		70-130	2		30
Acrylonitrile	92		96		70-130	4		30
n-Propylbenzene	94		97		70-130	3		30
1,2,3-Trichlorobenzene	98		99		70-130	1		30
1,2,4-Trichlorobenzene	99		99		70-130	0		30
1,3,5-Trimethylbenzene	97		99		70-130	2		30
1,2,4-Trimethylbenzene	97		99		70-130	2		30
1,4-Dioxane	109		107		65-136	2		30
p-Diethylbenzene	100		103		70-130	3		30

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST
Project Number: 12461

Lab Number: L2316452
Report Date: 04/12/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by EPA 5035 Low - Westborough Lab Associated sample(s): 01-04 Batch: WG1761220-3 WG1761220-4								
p-Ethyltoluene	96		99		70-130	3		30
1,2,4,5-Tetramethylbenzene	94		97		70-130	3		30
Ethyl ether	105		104		67-130	1		30
trans-1,4-Dichloro-2-butene	94		94		70-130	0		30

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
1,2-Dichloroethane-d4	104		102		70-130
Toluene-d8	96		97		70-130
4-Bromofluorobenzene	86		87		70-130
Dibromofluoromethane	112		111		70-130

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST

Project Number: 12461

Lab Number: L2316452

Report Date: 04/12/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by GC/MS - Westborough Lab Associated sample(s): 05 Batch: WG1761896-3 WG1761896-4								
Methylene chloride	110		100		70-130	10		20
1,1-Dichloroethane	110		110		70-130	0		20
Chloroform	110		110		70-130	0		20
Carbon tetrachloride	96		88		63-132	9		20
1,2-Dichloropropane	110		110		70-130	0		20
Dibromochloromethane	87		89		63-130	2		20
1,1,2-Trichloroethane	99		99		70-130	0		20
Tetrachloroethene	92		91		70-130	1		20
Chlorobenzene	100		100		75-130	0		20
Trichlorofluoromethane	120		110		62-150	9		20
1,2-Dichloroethane	100		100		70-130	0		20
1,1,1-Trichloroethane	100		95		67-130	5		20
Bromodichloromethane	100		100		67-130	0		20
trans-1,3-Dichloropropene	89		91		70-130	2		20
cis-1,3-Dichloropropene	100		98		70-130	2		20
1,1-Dichloropropene	110		100		70-130	10		20
Bromoform	85		80		54-136	6		20
1,1,2,2-Tetrachloroethane	100		100		67-130	0		20
Benzene	120		110		70-130	9		20
Toluene	100		98		70-130	2		20
Ethylbenzene	100		100		70-130	0		20
Chloromethane	120		110		64-130	9		20
Bromomethane	64		61		39-139	5		20

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST

Project Number: 12461

Lab Number: L2316452

Report Date: 04/12/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by GC/MS - Westborough Lab Associated sample(s): 05 Batch: WG1761896-3 WG1761896-4								
Vinyl chloride	130		120		55-140	8		20
Chloroethane	**150**	Q	**150**	Q	55-138	0		20
1,1-Dichloroethene	110		100		61-145	10		20
trans-1,2-Dichloroethene	100		110		70-130	10		20
Trichloroethene	100		100		70-130	0		20
1,2-Dichlorobenzene	110		100		70-130	10		20
1,3-Dichlorobenzene	110		100		70-130	10		20
1,4-Dichlorobenzene	100		100		70-130	0		20
Methyl tert butyl ether	98		94		63-130	4		20
p/m-Xylene	100		100		70-130	0		20
o-Xylene	100		100		70-130	0		20
cis-1,2-Dichloroethene	110		110		70-130	0		20
Dibromomethane	100		100		70-130	0		20
1,2,3-Trichloropropane	96		96		64-130	0		20
Acrylonitrile	100		100		70-130	0		20
Styrene	105		105		70-130	0		20
Dichlorodifluoromethane	130		110		36-147	17		20
Acetone	96		93		58-148	3		20
Carbon disulfide	120		110		51-130	9		20
2-Butanone	77		87		63-138	12		20
Vinyl acetate	120		110		70-130	9		20
4-Methyl-2-pentanone	84		83		59-130	1		20
2-Hexanone	82		87		57-130	6		20

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST

Project Number: 12461

Lab Number: L2316452

Report Date: 04/12/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by GC/MS - Westborough Lab Associated sample(s): 05 Batch: WG1761896-3 WG1761896-4								
Bromochloromethane	110		110		70-130	0		20
2,2-Dichloropropane	110		100		63-133	10		20
1,2-Dibromoethane	90		95		70-130	5		20
1,3-Dichloropropane	96		99		70-130	3		20
1,1,1,2-Tetrachloroethane	94		94		64-130	0		20
Bromobenzene	100		100		70-130	0		20
n-Butylbenzene	110		100		53-136	10		20
sec-Butylbenzene	100		97		70-130	3		20
tert-Butylbenzene	100		98		70-130	2		20
o-Chlorotoluene	110		100		70-130	10		20
p-Chlorotoluene	110		100		70-130	10		20
1,2-Dibromo-3-chloropropane	82		79		41-144	4		20
Hexachlorobutadiene	99		93		63-130	6		20
Isopropylbenzene	100		98		70-130	2		20
p-Isopropyltoluene	100		97		70-130	3		20
Naphthalene	99		98		70-130	1		20
n-Propylbenzene	110		100		69-130	10		20
1,2,3-Trichlorobenzene	100		100		70-130	0		20
1,2,4-Trichlorobenzene	100		100		70-130	0		20
1,3,5-Trimethylbenzene	100		97		64-130	3		20
1,2,4-Trimethylbenzene	100		99		70-130	1		20
1,4-Dioxane	84		84		56-162	0		20
p-Diethylbenzene	100		94		70-130	6		20

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST

Project Number: 12461

Lab Number: L2316452

Report Date: 04/12/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by GC/MS - Westborough Lab Associated sample(s): 05 Batch: WG1761896-3 WG1761896-4								
p-Ethyltoluene	100		100		70-130	0		20
1,2,4,5-Tetramethylbenzene	100		98		70-130	2		20
Ethyl ether	110		110		59-134	0		20
trans-1,4-Dichloro-2-butene	88		86		70-130	2		20

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
1,2-Dichloroethane-d4	116		104		70-130
Toluene-d8	101		101		70-130
4-Bromofluorobenzene	95		95		70-130
Dibromofluoromethane	108		102		70-130

SEMIVOLATILES

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-01
Client ID: SB-34 (0.5-1)
Sample Location: WHITEPLAINS, NY

Date Collected: 03/29/23 09:15
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8270E
Analytical Date: 03/31/23 08:14
Analyst: CMM
Percent Solids: 90%

Extraction Method: EPA 3546
Extraction Date: 03/30/23 13:52

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Acenaphthene	ND		ug/kg	140	19.	1
1,2,4-Trichlorobenzene	ND		ug/kg	180	21.	1
Hexachlorobenzene	ND		ug/kg	110	20.	1
Bis(2-chloroethyl)ether	ND		ug/kg	160	24.	1
2-Chloronaphthalene	ND		ug/kg	180	18.	1
1,2-Dichlorobenzene	ND		ug/kg	180	32.	1
1,3-Dichlorobenzene	ND		ug/kg	180	31.	1
1,4-Dichlorobenzene	ND		ug/kg	180	32.	1
3,3'-Dichlorobenzidine	ND		ug/kg	180	48.	1
2,4-Dinitrotoluene	ND		ug/kg	180	36.	1
2,6-Dinitrotoluene	ND		ug/kg	180	31.	1
Fluoranthene	35	J	ug/kg	110	21.	1
4-Chlorophenyl phenyl ether	ND		ug/kg	180	19.	1
4-Bromophenyl phenyl ether	ND		ug/kg	180	28.	1
Bis(2-chloroisopropyl)ether	ND		ug/kg	220	31.	1
Bis(2-chloroethoxy)methane	ND		ug/kg	200	18.	1
Hexachlorobutadiene	ND		ug/kg	180	26.	1
Hexachlorocyclopentadiene	ND		ug/kg	520	160	1
Hexachloroethane	ND		ug/kg	140	29.	1
Isophorone	ND		ug/kg	160	24.	1
Naphthalene	ND		ug/kg	180	22.	1
Nitrobenzene	ND		ug/kg	160	27.	1
NDPA/DPA	ND		ug/kg	140	21.	1
n-Nitrosodi-n-propylamine	ND		ug/kg	180	28.	1
Bis(2-ethylhexyl)phthalate	ND		ug/kg	180	63.	1
Butyl benzyl phthalate	ND		ug/kg	180	46.	1
Di-n-butylphthalate	ND		ug/kg	180	34.	1
Di-n-octylphthalate	ND		ug/kg	180	62.	1

Project Name: 100 MAIN ST **Lab Number:** L2316452

Project Number: 12461 **Report Date:** 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-01 Date Collected: 03/29/23 09:15

Client ID: SB-34 (0.5-1) Date Received: 03/29/23

Sample Location: WHITEPLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Diethyl phthalate	ND		ug/kg	180	17.	1
Dimethyl phthalate	ND		ug/kg	180	38.	1
Benzo(a)anthracene	24	J	ug/kg	110	20.	1
Benzo(a)pyrene	ND		ug/kg	140	44.	1
Benzo(b)fluoranthene	ND		ug/kg	110	30.	1
Benzo(k)fluoranthene	ND		ug/kg	110	29.	1
Chrysene	20	J	ug/kg	110	19.	1
Acenaphthylene	ND		ug/kg	140	28.	1
Anthracene	ND		ug/kg	110	35.	1
Benzo(ghi)perylene	ND		ug/kg	140	21.	1
Fluorene	ND		ug/kg	180	18.	1
Phenanthrene	ND		ug/kg	110	22.	1
Dibenzo(a,h)anthracene	ND		ug/kg	110	21.	1
Indeno(1,2,3-cd)pyrene	ND		ug/kg	140	25.	1
Pyrene	33	J	ug/kg	110	18.	1
Biphenyl	ND		ug/kg	410	24.	1
4-Chloroaniline	ND		ug/kg	180	33.	1
2-Nitroaniline	ND		ug/kg	180	35.	1
3-Nitroaniline	ND		ug/kg	180	34.	1
4-Nitroaniline	ND		ug/kg	180	75.	1
Dibenzofuran	ND		ug/kg	180	17.	1
2-Methylnaphthalene	ND		ug/kg	220	22.	1
1,2,4,5-Tetrachlorobenzene	ND		ug/kg	180	19.	1
Acetophenone	ND		ug/kg	180	22.	1
2,4,6-Trichlorophenol	ND		ug/kg	110	34.	1
p-Chloro-m-cresol	ND		ug/kg	180	27.	1
2-Chlorophenol	ND		ug/kg	180	21.	1
2,4-Dichlorophenol	ND		ug/kg	160	29.	1
2,4-Dimethylphenol	ND		ug/kg	180	60.	1
2-Nitrophenol	ND		ug/kg	390	68.	1
4-Nitrophenol	ND		ug/kg	250	74.	1
2,4-Dinitrophenol	ND		ug/kg	870	84.	1
4,6-Dinitro-o-cresol	ND		ug/kg	470	87.	1
Pentachlorophenol	ND		ug/kg	140	40.	1
Phenol	ND		ug/kg	180	27.	1
2-Methylphenol	ND		ug/kg	180	28.	1
3-Methylphenol/4-Methylphenol	ND		ug/kg	260	28.	1

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-01
Client ID: SB-34 (0.5-1)
Sample Location: WHITEPLAINS, NY
Date Collected: 03/29/23 09:15
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
2,4,5-Trichlorophenol	ND		ug/kg	180	35.	1
Benzoic Acid	ND		ug/kg	590	180	1
Benzyl Alcohol	ND		ug/kg	180	55.	1
Carbazole	ND		ug/kg	180	18.	1
1,4-Dioxane	ND		ug/kg	27	8.3	1
Tentatively Identified Compounds						
No Tentatively Identified Compounds	ND		ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	58		25-120
Phenol-d6	59		10-120
Nitrobenzene-d5	62		23-120
2-Fluorobiphenyl	53		30-120
2,4,6-Tribromophenol	50		10-136
4-Terphenyl-d14	50		18-120

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-02
Client ID: SB-33 (2-2.5)
Sample Location: WHITEPLAINS, NY

Date Collected: 03/29/23 08:50
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8270E
Analytical Date: 04/01/23 01:46
Analyst: CMM
Percent Solids: 94%

Extraction Method: EPA 3546
Extraction Date: 03/30/23 13:52

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Acenaphthene	ND		ug/kg	140	18.	1
1,2,4-Trichlorobenzene	ND		ug/kg	180	20.	1
Hexachlorobenzene	ND		ug/kg	110	20.	1
Bis(2-chloroethyl)ether	ND		ug/kg	160	24.	1
2-Chloronaphthalene	ND		ug/kg	180	18.	1
1,2-Dichlorobenzene	ND		ug/kg	180	32.	1
1,3-Dichlorobenzene	ND		ug/kg	180	30.	1
1,4-Dichlorobenzene	ND		ug/kg	180	31.	1
3,3'-Dichlorobenzidine	ND		ug/kg	180	47.	1
2,4-Dinitrotoluene	ND		ug/kg	180	35.	1
2,6-Dinitrotoluene	ND		ug/kg	180	30.	1
Fluoranthene	240		ug/kg	110	20.	1
4-Chlorophenyl phenyl ether	ND		ug/kg	180	19.	1
4-Bromophenyl phenyl ether	ND		ug/kg	180	27.	1
Bis(2-chloroisopropyl)ether	ND		ug/kg	210	30.	1
Bis(2-chloroethoxy)methane	ND		ug/kg	190	18.	1
Hexachlorobutadiene	ND		ug/kg	180	26.	1
Hexachlorocyclopentadiene	ND		ug/kg	510	160	1
Hexachloroethane	ND		ug/kg	140	29.	1
Isophorone	ND		ug/kg	160	23.	1
Naphthalene	ND		ug/kg	180	22.	1
Nitrobenzene	ND		ug/kg	160	26.	1
NDPA/DPA	ND		ug/kg	140	20.	1
n-Nitrosodi-n-propylamine	ND		ug/kg	180	27.	1
Bis(2-ethylhexyl)phthalate	ND		ug/kg	180	61.	1
Butyl benzyl phthalate	ND		ug/kg	180	45.	1
Di-n-butylphthalate	ND		ug/kg	180	34.	1
Di-n-octylphthalate	ND		ug/kg	180	60.	1

Project Name: 100 MAIN ST **Lab Number:** L2316452

Project Number: 12461 **Report Date:** 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-02 Date Collected: 03/29/23 08:50

Client ID: SB-33 (2-2.5) Date Received: 03/29/23

Sample Location: WHITEPLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Diethyl phthalate	ND		ug/kg	180	16.	1
Dimethyl phthalate	ND		ug/kg	180	37.	1
Benzo(a)anthracene	130		ug/kg	110	20.	1
Benzo(a)pyrene	130	J	ug/kg	140	43.	1
Benzo(b)fluoranthene	150		ug/kg	110	30.	1
Benzo(k)fluoranthene	51	J	ug/kg	110	28.	1
Chrysene	120		ug/kg	110	18.	1
Acenaphthylene	ND		ug/kg	140	27.	1
Anthracene	ND		ug/kg	110	34.	1
Benzo(ghi)perylene	82	J	ug/kg	140	21.	1
Fluorene	ND		ug/kg	180	17.	1
Phenanthrene	99	J	ug/kg	110	22.	1
Dibenzo(a,h)anthracene	ND		ug/kg	110	20.	1
Indeno(1,2,3-cd)pyrene	95	J	ug/kg	140	25.	1
Pyrene	220		ug/kg	110	18.	1
Biphenyl	ND		ug/kg	400	23.	1
4-Chloroaniline	ND		ug/kg	180	32.	1
2-Nitroaniline	ND		ug/kg	180	34.	1
3-Nitroaniline	ND		ug/kg	180	33.	1
4-Nitroaniline	ND		ug/kg	180	73.	1
Dibenzofuran	ND		ug/kg	180	17.	1
2-Methylnaphthalene	ND		ug/kg	210	21.	1
1,2,4,5-Tetrachlorobenzene	ND		ug/kg	180	18.	1
Acetophenone	ND		ug/kg	180	22.	1
2,4,6-Trichlorophenol	ND		ug/kg	110	34.	1
p-Chloro-m-cresol	ND		ug/kg	180	26.	1
2-Chlorophenol	ND		ug/kg	180	21.	1
2,4-Dichlorophenol	ND		ug/kg	160	28.	1
2,4-Dimethylphenol	ND		ug/kg	180	58.	1
2-Nitrophenol	ND		ug/kg	380	67.	1
4-Nitrophenol	ND		ug/kg	250	72.	1
2,4-Dinitrophenol	ND		ug/kg	850	82.	1
4,6-Dinitro-o-cresol	ND		ug/kg	460	85.	1
Pentachlorophenol	ND		ug/kg	140	39.	1
Phenol	ND		ug/kg	180	27.	1
2-Methylphenol	ND		ug/kg	180	27.	1
3-Methylphenol/4-Methylphenol	ND		ug/kg	260	28.	1

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-02
Client ID: SB-33 (2-2.5)
Sample Location: WHITEPLAINS, NY
Date Collected: 03/29/23 08:50
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
2,4,5-Trichlorophenol	ND		ug/kg	180	34.	1
Benzoic Acid	ND		ug/kg	570	180	1
Benzyl Alcohol	ND		ug/kg	180	54.	1
Carbazole	ND		ug/kg	180	17.	1
1,4-Dioxane	ND		ug/kg	26	8.1	1
Tentatively Identified Compounds						
No Tentatively Identified Compounds	ND		ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	71		25-120
Phenol-d6	75		10-120
Nitrobenzene-d5	76		23-120
2-Fluorobiphenyl	63		30-120
2,4,6-Tribromophenol	70		10-136
4-Terphenyl-d14	61		18-120

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-03
Client ID: SB-35 (4-4.5)
Sample Location: WHITEPLAINS, NY

Date Collected: 03/29/23 12:30
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8270E
Analytical Date: 03/31/23 06:13
Analyst: CMM
Percent Solids: 92%

Extraction Method: EPA 3546
Extraction Date: 03/30/23 13:52

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Acenaphthene	ND		ug/kg	140	18.	1
1,2,4-Trichlorobenzene	ND		ug/kg	180	20.	1
Hexachlorobenzene	ND		ug/kg	110	20.	1
Bis(2-chloroethyl)ether	ND		ug/kg	160	24.	1
2-Chloronaphthalene	ND		ug/kg	180	18.	1
1,2-Dichlorobenzene	ND		ug/kg	180	32.	1
1,3-Dichlorobenzene	ND		ug/kg	180	31.	1
1,4-Dichlorobenzene	ND		ug/kg	180	31.	1
3,3'-Dichlorobenzidine	ND		ug/kg	180	48.	1
2,4-Dinitrotoluene	ND		ug/kg	180	36.	1
2,6-Dinitrotoluene	ND		ug/kg	180	31.	1
Fluoranthene	ND		ug/kg	110	20.	1
4-Chlorophenyl phenyl ether	ND		ug/kg	180	19.	1
4-Bromophenyl phenyl ether	ND		ug/kg	180	27.	1
Bis(2-chloroisopropyl)ether	ND		ug/kg	210	30.	1
Bis(2-chloroethoxy)methane	ND		ug/kg	190	18.	1
Hexachlorobutadiene	ND		ug/kg	180	26.	1
Hexachlorocyclopentadiene	ND		ug/kg	510	160	1
Hexachloroethane	ND		ug/kg	140	29.	1
Isophorone	ND		ug/kg	160	23.	1
Naphthalene	ND		ug/kg	180	22.	1
Nitrobenzene	ND		ug/kg	160	26.	1
NDPA/DPA	ND		ug/kg	140	20.	1
n-Nitrosodi-n-propylamine	ND		ug/kg	180	28.	1
Bis(2-ethylhexyl)phthalate	ND		ug/kg	180	62.	1
Butyl benzyl phthalate	ND		ug/kg	180	45.	1
Di-n-butylphthalate	ND		ug/kg	180	34.	1
Di-n-octylphthalate	ND		ug/kg	180	61.	1

Project Name: 100 MAIN ST **Lab Number:** L2316452

Project Number: 12461 **Report Date:** 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-03 Date Collected: 03/29/23 12:30

Client ID: SB-35 (4-4.5) Date Received: 03/29/23

Sample Location: WHITEPLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Diethyl phthalate	ND		ug/kg	180	16.	1
Dimethyl phthalate	ND		ug/kg	180	38.	1
Benzo(a)anthracene	ND		ug/kg	110	20.	1
Benzo(a)pyrene	ND		ug/kg	140	44.	1
Benzo(b)fluoranthene	ND		ug/kg	110	30.	1
Benzo(k)fluoranthene	ND		ug/kg	110	28.	1
Chrysene	ND		ug/kg	110	18.	1
Acenaphthylene	ND		ug/kg	140	28.	1
Anthracene	ND		ug/kg	110	35.	1
Benzo(ghi)perylene	ND		ug/kg	140	21.	1
Fluorene	ND		ug/kg	180	17.	1
Phenanthrene	ND		ug/kg	110	22.	1
Dibenzo(a,h)anthracene	ND		ug/kg	110	21.	1
Indeno(1,2,3-cd)pyrene	ND		ug/kg	140	25.	1
Pyrene	ND		ug/kg	110	18.	1
Biphenyl	ND		ug/kg	410	23.	1
4-Chloroaniline	ND		ug/kg	180	32.	1
2-Nitroaniline	ND		ug/kg	180	34.	1
3-Nitroaniline	ND		ug/kg	180	34.	1
4-Nitroaniline	ND		ug/kg	180	74.	1
Dibenzofuran	ND		ug/kg	180	17.	1
2-Methylnaphthalene	ND		ug/kg	210	22.	1
1,2,4,5-Tetrachlorobenzene	ND		ug/kg	180	19.	1
Acetophenone	ND		ug/kg	180	22.	1
2,4,6-Trichlorophenol	ND		ug/kg	110	34.	1
p-Chloro-m-cresol	ND		ug/kg	180	27.	1
2-Chlorophenol	ND		ug/kg	180	21.	1
2,4-Dichlorophenol	ND		ug/kg	160	29.	1
2,4-Dimethylphenol	ND		ug/kg	180	59.	1
2-Nitrophenol	ND		ug/kg	380	67.	1
4-Nitrophenol	ND		ug/kg	250	73.	1
2,4-Dinitrophenol	ND		ug/kg	860	83.	1
4,6-Dinitro-o-cresol	ND		ug/kg	460	86.	1
Pentachlorophenol	ND		ug/kg	140	39.	1
Phenol	ND		ug/kg	180	27.	1
2-Methylphenol	ND		ug/kg	180	28.	1
3-Methylphenol/4-Methylphenol	ND		ug/kg	260	28.	1

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-03
Client ID: SB-35 (4-4.5)
Sample Location: WHITEPLAINS, NY
Date Collected: 03/29/23 12:30
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
2,4,5-Trichlorophenol	ND		ug/kg	180	34.	1
Benzoic Acid	ND		ug/kg	580	180	1
Benzyl Alcohol	ND		ug/kg	180	55.	1
Carbazole	ND		ug/kg	180	17.	1
1,4-Dioxane	ND		ug/kg	27	8.2	1
Tentatively Identified Compounds						
No Tentatively Identified Compounds	ND		ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	65		25-120
Phenol-d6	65		10-120
Nitrobenzene-d5	66		23-120
2-Fluorobiphenyl	62		30-120
2,4,6-Tribromophenol	60		10-136
4-Terphenyl-d14	53		18-120

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-04
Client ID: SB-36 (1-1.5)
Sample Location: WHITEPLAINS, NY

Date Collected: 03/29/23 13:00
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8270E
Analytical Date: 03/31/23 07:26
Analyst: CMM
Percent Solids: 85%

Extraction Method: EPA 3546
Extraction Date: 03/30/23 13:52

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Acenaphthene	ND		ug/kg	150	20.	1
1,2,4-Trichlorobenzene	ND		ug/kg	190	22.	1
Hexachlorobenzene	ND		ug/kg	110	21.	1
Bis(2-chloroethyl)ether	ND		ug/kg	170	26.	1
2-Chloronaphthalene	ND		ug/kg	190	19.	1
1,2-Dichlorobenzene	ND		ug/kg	190	34.	1
1,3-Dichlorobenzene	ND		ug/kg	190	33.	1
1,4-Dichlorobenzene	ND		ug/kg	190	33.	1
3,3'-Dichlorobenzidine	ND		ug/kg	190	51.	1
2,4-Dinitrotoluene	ND		ug/kg	190	38.	1
2,6-Dinitrotoluene	ND		ug/kg	190	33.	1
Fluoranthene	26	J	ug/kg	110	22.	1
4-Chlorophenyl phenyl ether	ND		ug/kg	190	20.	1
4-Bromophenyl phenyl ether	ND		ug/kg	190	29.	1
Bis(2-chloroisopropyl)ether	ND		ug/kg	230	32.	1
Bis(2-chloroethoxy)methane	ND		ug/kg	200	19.	1
Hexachlorobutadiene	ND		ug/kg	190	28.	1
Hexachlorocyclopentadiene	ND		ug/kg	540	170	1
Hexachloroethane	ND		ug/kg	150	31.	1
Isophorone	ND		ug/kg	170	25.	1
Naphthalene	ND		ug/kg	190	23.	1
Nitrobenzene	ND		ug/kg	170	28.	1
NDPA/DPA	ND		ug/kg	150	22.	1
n-Nitrosodi-n-propylamine	ND		ug/kg	190	29.	1
Bis(2-ethylhexyl)phthalate	ND		ug/kg	190	66.	1
Butyl benzyl phthalate	ND		ug/kg	190	48.	1
Di-n-butylphthalate	ND		ug/kg	190	36.	1
Di-n-octylphthalate	ND		ug/kg	190	65.	1

Project Name: 100 MAIN ST **Lab Number:** L2316452

Project Number: 12461 **Report Date:** 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-04 Date Collected: 03/29/23 13:00

Client ID: SB-36 (1-1.5) Date Received: 03/29/23

Sample Location: WHITEPLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Diethyl phthalate	ND		ug/kg	190	18.	1
Dimethyl phthalate	ND		ug/kg	190	40.	1
Benzo(a)anthracene	ND		ug/kg	110	21.	1
Benzo(a)pyrene	ND		ug/kg	150	46.	1
Benzo(b)fluoranthene	ND		ug/kg	110	32.	1
Benzo(k)fluoranthene	ND		ug/kg	110	30.	1
Chrysene	ND		ug/kg	110	20.	1
Acenaphthylene	ND		ug/kg	150	29.	1
Anthracene	ND		ug/kg	110	37.	1
Benzo(ghi)perylene	ND		ug/kg	150	22.	1
Fluorene	ND		ug/kg	190	18.	1
Phenanthrene	ND		ug/kg	110	23.	1
Dibenzo(a,h)anthracene	ND		ug/kg	110	22.	1
Indeno(1,2,3-cd)pyrene	ND		ug/kg	150	26.	1
Pyrene	26	J	ug/kg	110	19.	1
Biphenyl	ND		ug/kg	430	25.	1
4-Chloroaniline	ND		ug/kg	190	35.	1
2-Nitroaniline	ND		ug/kg	190	37.	1
3-Nitroaniline	ND		ug/kg	190	36.	1
4-Nitroaniline	ND		ug/kg	190	79.	1
Dibenzofuran	ND		ug/kg	190	18.	1
2-Methylnaphthalene	ND		ug/kg	230	23.	1
1,2,4,5-Tetrachlorobenzene	ND		ug/kg	190	20.	1
Acetophenone	ND		ug/kg	190	24.	1
2,4,6-Trichlorophenol	ND		ug/kg	110	36.	1
p-Chloro-m-cresol	ND		ug/kg	190	28.	1
2-Chlorophenol	ND		ug/kg	190	22.	1
2,4-Dichlorophenol	ND		ug/kg	170	31.	1
2,4-Dimethylphenol	ND		ug/kg	190	63.	1
2-Nitrophenol	ND		ug/kg	410	72.	1
4-Nitrophenol	ND		ug/kg	270	78.	1
2,4-Dinitrophenol	ND		ug/kg	920	89.	1
4,6-Dinitro-o-cresol	ND		ug/kg	500	92.	1
Pentachlorophenol	ND		ug/kg	150	42.	1
Phenol	ND		ug/kg	190	29.	1
2-Methylphenol	ND		ug/kg	190	30.	1
3-Methylphenol/4-Methylphenol	ND		ug/kg	270	30.	1

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-04
Client ID: SB-36 (1-1.5)
Sample Location: WHITEPLAINS, NY
Date Collected: 03/29/23 13:00
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
2,4,5-Trichlorophenol	ND		ug/kg	190	36.	1
Benzoic Acid	ND		ug/kg	620	190	1
Benzyl Alcohol	ND		ug/kg	190	58.	1
Carbazole	ND		ug/kg	190	18.	1
1,4-Dioxane	ND		ug/kg	28	8.8	1
Tentatively Identified Compounds						
No Tentatively Identified Compounds	ND		ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	58		25-120
Phenol-d6	56		10-120
Nitrobenzene-d5	58		23-120
2-Fluorobiphenyl	51		30-120
2,4,6-Tribromophenol	53		10-136
4-Terphenyl-d14	47		18-120

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-05
Client ID: GW-2
Sample Location: WHITEPLAINS, NY

Date Collected: 03/29/23 12:00
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E
Analytical Date: 04/03/23 17:37
Analyst: JG

Extraction Method: EPA 3510C
Extraction Date: 04/02/23 07:44

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
1,2,4-Trichlorobenzene	ND		ug/l	5.0	0.50	1
Bis(2-chloroethyl)ether	ND		ug/l	2.0	0.50	1
1,2-Dichlorobenzene	ND		ug/l	2.0	0.45	1
1,3-Dichlorobenzene	ND		ug/l	2.0	0.40	1
1,4-Dichlorobenzene	ND		ug/l	2.0	0.43	1
3,3'-Dichlorobenzidine	ND		ug/l	5.0	1.6	1
2,4-Dinitrotoluene	ND		ug/l	5.0	1.2	1
2,6-Dinitrotoluene	ND		ug/l	5.0	0.93	1
4-Chlorophenyl phenyl ether	ND		ug/l	2.0	0.49	1
4-Bromophenyl phenyl ether	ND		ug/l	2.0	0.38	1
Bis(2-chloroisopropyl)ether	ND		ug/l	2.0	0.53	1
Bis(2-chloroethoxy)methane	ND		ug/l	5.0	0.50	1
Hexachlorocyclopentadiene	ND		ug/l	20	0.69	1
Isophorone	ND		ug/l	5.0	1.2	1
Nitrobenzene	ND		ug/l	2.0	0.77	1
NDPA/DPA	ND		ug/l	2.0	0.42	1
n-Nitrosodi-n-propylamine	ND		ug/l	5.0	0.64	1
Bis(2-ethylhexyl)phthalate	2.0	J	ug/l	3.0	1.5	1
Butyl benzyl phthalate	ND		ug/l	5.0	1.2	1
Di-n-butylphthalate	ND		ug/l	5.0	0.39	1
Di-n-octylphthalate	ND		ug/l	5.0	1.3	1
Diethyl phthalate	ND		ug/l	5.0	0.38	1
Dimethyl phthalate	ND		ug/l	5.0	1.8	1
Biphenyl	ND		ug/l	2.0	0.46	1
4-Chloroaniline	ND		ug/l	5.0	1.1	1
2-Nitroaniline	ND		ug/l	5.0	0.50	1
3-Nitroaniline	ND		ug/l	5.0	0.81	1
4-Nitroaniline	ND		ug/l	5.0	0.80	1

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-05
Client ID: GW-2
Sample Location: WHITEPLAINS, NY
Date Collected: 03/29/23 12:00
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Dibenzofuran	ND		ug/l	2.0	0.50	1
1,2,4,5-Tetrachlorobenzene	ND		ug/l	10	0.44	1
Acetophenone	ND		ug/l	5.0	0.53	1
2,4,6-Trichlorophenol	ND		ug/l	5.0	0.61	1
p-Chloro-m-cresol	ND		ug/l	2.0	0.35	1
2-Chlorophenol	ND		ug/l	2.0	0.48	1
2,4-Dichlorophenol	ND		ug/l	5.0	0.41	1
2,4-Dimethylphenol	ND		ug/l	5.0	1.8	1
2-Nitrophenol	ND		ug/l	10	0.85	1
4-Nitrophenol	ND		ug/l	10	0.67	1
2,4-Dinitrophenol	ND		ug/l	20	6.6	1
4,6-Dinitro-o-cresol	ND		ug/l	10	1.8	1
Phenol	ND		ug/l	5.0	0.57	1
2-Methylphenol	ND		ug/l	5.0	0.49	1
3-Methylphenol/4-Methylphenol	ND		ug/l	5.0	0.48	1
2,4,5-Trichlorophenol	ND		ug/l	5.0	0.77	1
Benzoic Acid	16.	J	ug/l	50	2.6	1
Benzyl Alcohol	ND		ug/l	2.0	0.59	1
Carbazole	ND		ug/l	2.0	0.49	1

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-05
Client ID: GW-2
Sample Location: WHITEPLAINS, NY
Date Collected: 03/29/23 12:00
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Tentatively Identified Compounds						
Total TIC Compounds	139	J	ug/l			1
Unknown	2.91	J	ug/l			1
Unknown	15.9	JB	ug/l			1
Unknown	3.31	J	ug/l			1
Unknown	3.24	J	ug/l			1
Unknown	3.05	J	ug/l			1
Unknown	2.98	J	ug/l			1
Unknown	2.91	J	ug/l			1
Unknown	2.29	J	ug/l			1
Unknown	2.58	J	ug/l			1
Unknown	4.51	JB	ug/l			1
Unknown Alkane	5.64	J	ug/l			1
Unknown Alkane	4.65	J	ug/l			1
Unknown Amide	5.64	J	ug/l			1
Unknown Organic Acid	43.1	JB	ug/l			1
Unknown Organic Acid	36.5	JB	ug/l			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	35		21-120
Phenol-d6	29		10-120
Nitrobenzene-d5	55		23-120
2-Fluorobiphenyl	58		15-120
2,4,6-Tribromophenol	43		10-120
4-Terphenyl-d14	50		41-149

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-05
Client ID: GW-2
Sample Location: WHITEPLAINS, NY

Date Collected: 03/29/23 12:00
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E-SIM
Analytical Date: 04/04/23 07:51
Analyst: DV

Extraction Method: EPA 3510C
Extraction Date: 04/03/23 13:33

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS-SIM - Westborough Lab						
Acenaphthene	0.25		ug/l	0.10	0.01	1
2-Chloronaphthalene	ND		ug/l	0.20	0.02	1
Fluoranthene	2.8		ug/l	0.10	0.02	1
Hexachlorobutadiene	ND		ug/l	0.50	0.05	1
Naphthalene	0.60		ug/l	0.10	0.05	1
Benzo(a)anthracene	1.3		ug/l	0.10	0.02	1
Benzo(a)pyrene	1.5		ug/l	0.10	0.02	1
Benzo(b)fluoranthene	1.7		ug/l	0.10	0.01	1
Benzo(k)fluoranthene	0.59		ug/l	0.10	0.01	1
Chrysene	1.2		ug/l	0.10	0.01	1
Acenaphthylene	0.10		ug/l	0.10	0.01	1
Anthracene	0.49		ug/l	0.10	0.01	1
Benzo(ghi)perylene	0.85		ug/l	0.10	0.01	1
Fluorene	0.34		ug/l	0.10	0.01	1
Phenanthrene	1.8		ug/l	0.10	0.02	1
Dibenzo(a,h)anthracene	0.23		ug/l	0.10	0.01	1
Indeno(1,2,3-cd)pyrene	0.90		ug/l	0.10	0.01	1
Pyrene	2.5		ug/l	0.10	0.02	1
2-Methylnaphthalene	0.18		ug/l	0.10	0.02	1
Pentachlorophenol	0.10	J	ug/l	0.80	0.01	1
Hexachlorobenzene	ND		ug/l	0.80	0.01	1
Hexachloroethane	ND		ug/l	0.80	0.06	1

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-05
Client ID: GW-2
Sample Location: WHITEPLAINS, NY
Date Collected: 03/29/23 12:00
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS-SIM - Westborough Lab						

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	56		21-120
Phenol-d6	50		10-120
Nitrobenzene-d5	78		23-120
2-Fluorobiphenyl	65		15-120
2,4,6-Tribromophenol	80		10-120
4-Terphenyl-d14	62		41-149

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-05
Client ID: GW-2
Sample Location: WHITEPLAINS, NY

Date Collected: 03/29/23 12:00
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E-SIM
Analytical Date: 04/05/23 13:35
Analyst: TPR

Extraction Method: EPA 3510C
Extraction Date: 04/01/23 18:00

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
1,4 Dioxane by 8270E-SIM - Mansfield Lab						
1,4-Dioxane	ND		ng/l	136	30.8	1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,4-Dioxane-d8	57		15-110

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-05
Client ID: GW-2
Sample Location: WHITEPLAINS, NY

Date Collected: 03/29/23 12:00
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 144,1633
Analytical Date: 04/07/23 17:54
Analyst: RS

Extraction Method: EPA 1633
Extraction Date: 04/06/23 13:45

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Perfluorinated Alkyl Acids by EPA 1633 - Mansfield Lab						
Perfluorobutanoic Acid (PFBA)	57.5		ng/l	8.27	1.32	1
Perfluoropentanoic Acid (PFPeA)	134		ng/l	4.13	1.10	1
Perfluorobutanesulfonic Acid (PFBS)	10.4		ng/l	2.07	0.692	1
Perfluorohexanoic Acid (PFHxA)	138		ng/l	2.07	0.610	1
Perfluoroheptanoic Acid (PFHpA)	57.7		ng/l	2.07	0.413	1
Perfluorohexanesulfonic Acid (PFHxS)	4.44		ng/l	2.07	0.496	1
Perfluorooctanoic Acid (PFOA)	121		ng/l	2.07	0.899	1
1H,1H,2H,2H-Perfluorooctanesulfonic Acid (6:2FTS)	ND		ng/l	8.27	2.79	1
Perfluoroheptanesulfonic Acid (PFHpS)	ND		ng/l	2.07	0.558	1
Perfluorononanoic Acid (PFNA)	4.44		ng/l	2.07	0.651	1
Perfluorooctanesulfonic Acid (PFOS)	8.16		ng/l	2.07	0.940	1
Perfluorodecanoic Acid (PFDA)	ND		ng/l	2.07	0.837	1
1H,1H,2H,2H-Perfluorodecanesulfonic Acid (8:2FTS)	ND		ng/l	8.27	3.21	1
N-Methyl Perfluorooctanesulfonamidoacetic Acid (NMeFOSAA)	ND		ng/l	2.07	1.13	1
Perfluoroundecanoic Acid (PFUnA)	ND		ng/l	2.07	0.899	1
Perfluorodecanesulfonic Acid (PFDS)	ND		ng/l	2.07	0.475	1
Perfluorooctanesulfonamide (PFOSA)	ND		ng/l	2.07	0.558	1
N-Ethyl Perfluorooctanesulfonamidoacetic Acid (NEtFOSAA)	ND		ng/l	2.07	1.12	1
Perfluorododecanoic Acid (PFDoA)	ND		ng/l	2.07	0.951	1
Perfluorotridecanoic Acid (PFTrDA)	ND		ng/l	2.07	0.775	1
Perfluorotetradecanoic Acid (PFTeDA)	ND		ng/l	2.07	0.548	1
PFOA/PFOS, Total	129		ng/l	2.07	0.899	1

Project Name: 100 MAIN ST **Lab Number:** L2316452

Project Number: 12461 **Report Date:** 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-05 Date Collected: 03/29/23 12:00

Client ID: GW-2 Date Received: 03/29/23

Sample Location: WHITEPLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Perfluorinated Alkyl Acids by EPA 1633 - Mansfield Lab						

Surrogate	% Recovery	Qualifier	Acceptance Criteria
Perfluoro-n-[13C4]Butanoic Acid (13C4-PFBA)	93		20-150
Perfluoro-n-[13C5]Pentanoic Acid (13C5-PFPeA)	91		20-150
Perfluoro-1-[2,3,4-13C3]Butanesulfonic Acid (13C3-PFBS)	92		20-150
Perfluoro-n-[1,2,3,4,6-13C5]Hexanoic Acid (13C5-PFHxA)	89		20-150
Perfluoro-n-[1,2,3,4-13C4]Heptanoic Acid (13C4-PFHpA)	77		20-150
Perfluoro-1-[1,2,3-13C3]Hexanesulfonic Acid (13C3-PFHxS)	88		20-150
Perfluoro-n-[13C8]Octanoic Acid (13C8-PFOA)	88		20-150
1H,1H,2H,2H-Perfluoro-1-[1,2-13C2]Octanesulfonic Acid (13C2-6:2FTS)	98		20-150
Perfluoro-n-[13C9]Nonanoic Acid (13C9-PFNA)	82		20-150
Perfluoro-1-[13C8]Octanesulfonic Acid (13C8-PFOS)	80		20-150
Perfluoro-n-[1,2,3,4,5,6-13C6]Decanoic Acid (13C6-PFDA)	68		20-150
1H,1H,2H,2H-Perfluoro-1-[1,2-13C2]Decanesulfonic Acid (13C2-8:2FTS)	102		20-150
N-Methyl-d3-perfluoro-1-octanesulfonamidoacetic Acid (D3-NMeFOSAA)	90		20-150
Perfluoro-n-[1,2,3,4,5,6,7-13C7]Undecanoic Acid (13C7-PFUnA)	66		20-150
Perfluoro-1-[13C8]Octanesulfonamide (13C8-PFOSA)	43		20-150
N-Ethyl-d5-perfluoro-1-octanesulfonamidoacetic Acid (D5-NEtFOSAA)	51		20-150
Perfluoro-n-[1,2-13C2]Dodecanoic Acid (13C2-PFDoA)	45		20-150
Perfluoro-n-[1,2-13C2]Tetradecanoic Acid (13C2-PFTeDA)	31		20-150

Project Name: 100 MAIN ST
Project Number: 12461

Lab Number: L2316452
Report Date: 04/12/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 03/30/23 01:14
Analyst: IM

Extraction Method: EPA 3546
Extraction Date: 03/29/23 15:54

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 01-04 Batch: WG1760400-1					
Acenaphthene	ND		ug/kg	130	17.
1,2,4-Trichlorobenzene	ND		ug/kg	160	19.
Hexachlorobenzene	ND		ug/kg	99	18.
Bis(2-chloroethyl)ether	ND		ug/kg	150	22.
2-Chloronaphthalene	ND		ug/kg	160	16.
1,2-Dichlorobenzene	ND		ug/kg	160	30.
1,3-Dichlorobenzene	ND		ug/kg	160	28.
1,4-Dichlorobenzene	ND		ug/kg	160	29.
3,3'-Dichlorobenzidine	ND		ug/kg	160	44.
2,4-Dinitrotoluene	ND		ug/kg	160	33.
2,6-Dinitrotoluene	ND		ug/kg	160	28.
Fluoranthene	ND		ug/kg	99	19.
4-Chlorophenyl phenyl ether	ND		ug/kg	160	18.
4-Bromophenyl phenyl ether	ND		ug/kg	160	25.
Bis(2-chloroisopropyl)ether	ND		ug/kg	200	28.
Bis(2-chloroethoxy)methane	ND		ug/kg	180	16.
Hexachlorobutadiene	ND		ug/kg	160	24.
Hexachlorocyclopentadiene	ND		ug/kg	470	150
Hexachloroethane	ND		ug/kg	130	27.
Isophorone	ND		ug/kg	150	21.
Naphthalene	ND		ug/kg	160	20.
Nitrobenzene	ND		ug/kg	150	24.
NDPA/DPA	ND		ug/kg	130	19.
n-Nitrosodi-n-propylamine	ND		ug/kg	160	25.
Bis(2-ethylhexyl)phthalate	ND		ug/kg	160	57.
Butyl benzyl phthalate	ND		ug/kg	160	41.
Di-n-butylphthalate	ND		ug/kg	160	31.
Di-n-octylphthalate	ND		ug/kg	160	56.
Diethyl phthalate	ND		ug/kg	160	15.

Project Name: 100 MAIN ST
Project Number: 12461

Lab Number: L2316452
Report Date: 04/12/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 03/30/23 01:14
Analyst: IM

Extraction Method: EPA 3546
Extraction Date: 03/29/23 15:54

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 01-04 Batch: WG1760400-1					
Dimethyl phthalate	ND		ug/kg	160	34.
Benzo(a)anthracene	ND		ug/kg	99	18.
Benzo(a)pyrene	ND		ug/kg	130	40.
Benzo(b)fluoranthene	ND		ug/kg	99	28.
Benzo(k)fluoranthene	ND		ug/kg	99	26.
Chrysene	ND		ug/kg	99	17.
Acenaphthylene	ND		ug/kg	130	25.
Anthracene	ND		ug/kg	99	32.
Benzo(ghi)perylene	ND		ug/kg	130	19.
Fluorene	ND		ug/kg	160	16.
Phenanthrene	ND		ug/kg	99	20.
Dibenzo(a,h)anthracene	ND		ug/kg	99	19.
Indeno(1,2,3-cd)pyrene	ND		ug/kg	130	23.
Pyrene	ND		ug/kg	99	16.
Biphenyl	ND		ug/kg	370	21.
4-Chloroaniline	ND		ug/kg	160	30.
2-Nitroaniline	ND		ug/kg	160	32.
3-Nitroaniline	ND		ug/kg	160	31.
4-Nitroaniline	ND		ug/kg	160	68.
Dibenzofuran	ND		ug/kg	160	16.
2-Methylnaphthalene	ND		ug/kg	200	20.
1,2,4,5-Tetrachlorobenzene	ND		ug/kg	160	17.
Acetophenone	ND		ug/kg	160	20.
2,4,6-Trichlorophenol	ND		ug/kg	99	31.
p-Chloro-m-cresol	ND		ug/kg	160	24.
2-Chlorophenol	ND		ug/kg	160	19.
2,4-Dichlorophenol	ND		ug/kg	150	26.
2,4-Dimethylphenol	ND		ug/kg	160	54.
2-Nitrophenol	ND		ug/kg	360	62.

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 03/30/23 01:14
Analyst: IM

Extraction Method: EPA 3546
Extraction Date: 03/29/23 15:54

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 01-04 Batch: WG1760400-1					
4-Nitrophenol	ND		ug/kg	230	67.
2,4-Dinitrophenol	ND		ug/kg	790	77.
4,6-Dinitro-o-cresol	ND		ug/kg	430	79.
Pentachlorophenol	ND		ug/kg	130	36.
Phenol	ND		ug/kg	160	25.
2-Methylphenol	ND		ug/kg	160	25.
3-Methylphenol/4-Methylphenol	ND		ug/kg	240	26.
2,4,5-Trichlorophenol	ND		ug/kg	160	32.
Benzoic Acid	ND		ug/kg	530	170
Benzyl Alcohol	ND		ug/kg	160	50.
Carbazole	ND		ug/kg	160	16.
1,4-Dioxane	ND		ug/kg	25	7.6

Tentatively Identified Compounds			
Total TIC Compounds	328	J	ug/kg
Unknown	328	J	ug/kg

Surrogate	%Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	67		25-120
Phenol-d6	70		10-120
Nitrobenzene-d5	66		23-120
2-Fluorobiphenyl	64		30-120
2,4,6-Tribromophenol	67		10-136
4-Terphenyl-d14	70		18-120

Project Name: 100 MAIN ST
Project Number: 12461

Lab Number: L2316452
Report Date: 04/12/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 04/02/23 12:01
Analyst: CMM

Extraction Method: EPA 3510C
Extraction Date: 04/01/23 09:26

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 05 Batch: WG1761567-1					
Acenaphthene	ND		ug/l	2.0	0.44
1,2,4-Trichlorobenzene	ND		ug/l	5.0	0.50
Hexachlorobenzene	ND		ug/l	2.0	0.46
Bis(2-chloroethyl)ether	ND		ug/l	2.0	0.50
2-Chloronaphthalene	ND		ug/l	2.0	0.44
1,2-Dichlorobenzene	ND		ug/l	2.0	0.45
1,3-Dichlorobenzene	ND		ug/l	2.0	0.40
1,4-Dichlorobenzene	ND		ug/l	2.0	0.43
3,3'-Dichlorobenzidine	ND		ug/l	5.0	1.6
2,4-Dinitrotoluene	ND		ug/l	5.0	1.2
2,6-Dinitrotoluene	ND		ug/l	5.0	0.93
Fluoranthene	ND		ug/l	2.0	0.26
4-Chlorophenyl phenyl ether	ND		ug/l	2.0	0.49
4-Bromophenyl phenyl ether	ND		ug/l	2.0	0.38
Bis(2-chloroisopropyl)ether	ND		ug/l	2.0	0.53
Bis(2-chloroethoxy)methane	ND		ug/l	5.0	0.50
Hexachlorobutadiene	ND		ug/l	2.0	0.66
Hexachlorocyclopentadiene	ND		ug/l	20	0.69
Hexachloroethane	ND		ug/l	2.0	0.58
Isophorone	ND		ug/l	5.0	1.2
Naphthalene	ND		ug/l	2.0	0.46
Nitrobenzene	ND		ug/l	2.0	0.77
NDPA/DPA	ND		ug/l	2.0	0.42
n-Nitrosodi-n-propylamine	ND		ug/l	5.0	0.64
Bis(2-ethylhexyl)phthalate	ND		ug/l	3.0	1.5
Butyl benzyl phthalate	ND		ug/l	5.0	1.2
Di-n-butylphthalate	ND		ug/l	5.0	0.39
Di-n-octylphthalate	ND		ug/l	5.0	1.3
Diethyl phthalate	ND		ug/l	5.0	0.38

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 04/02/23 12:01
Analyst: CMM

Extraction Method: EPA 3510C
Extraction Date: 04/01/23 09:26

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 05 Batch: WG1761567-1					
Dimethyl phthalate	ND		ug/l	5.0	1.8
Benzo(a)anthracene	ND		ug/l	2.0	0.32
Benzo(a)pyrene	ND		ug/l	2.0	0.41
Benzo(b)fluoranthene	ND		ug/l	2.0	0.35
Benzo(k)fluoranthene	ND		ug/l	2.0	0.37
Chrysene	ND		ug/l	2.0	0.34
Acenaphthylene	ND		ug/l	2.0	0.46
Anthracene	ND		ug/l	2.0	0.33
Benzo(ghi)perylene	ND		ug/l	2.0	0.30
Fluorene	ND		ug/l	2.0	0.41
Phenanthrene	ND		ug/l	2.0	0.33
Dibenzo(a,h)anthracene	ND		ug/l	2.0	0.32
Indeno(1,2,3-cd)pyrene	ND		ug/l	2.0	0.40
Pyrene	ND		ug/l	2.0	0.28
Biphenyl	ND		ug/l	2.0	0.46
4-Chloroaniline	ND		ug/l	5.0	1.1
2-Nitroaniline	ND		ug/l	5.0	0.50
3-Nitroaniline	ND		ug/l	5.0	0.81
4-Nitroaniline	ND		ug/l	5.0	0.80
Dibenzofuran	ND		ug/l	2.0	0.50
2-Methylnaphthalene	ND		ug/l	2.0	0.45
1,2,4,5-Tetrachlorobenzene	ND		ug/l	10	0.44
Acetophenone	ND		ug/l	5.0	0.53
2,4,6-Trichlorophenol	ND		ug/l	5.0	0.61
p-Chloro-m-cresol	ND		ug/l	2.0	0.35
2-Chlorophenol	ND		ug/l	2.0	0.48
2,4-Dichlorophenol	ND		ug/l	5.0	0.41
2,4-Dimethylphenol	ND		ug/l	5.0	1.8
2-Nitrophenol	ND		ug/l	10	0.85

Project Name: 100 MAIN ST
Project Number: 12461

Lab Number: L2316452
Report Date: 04/12/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 04/02/23 12:01
Analyst: CMM

Extraction Method: EPA 3510C
Extraction Date: 04/01/23 09:26

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 05 Batch: WG1761567-1					
4-Nitrophenol	ND		ug/l	10	0.67
2,4-Dinitrophenol	ND		ug/l	20	6.6
4,6-Dinitro-o-cresol	ND		ug/l	10	1.8
Pentachlorophenol	ND		ug/l	10	1.8
Phenol	ND		ug/l	5.0	0.57
2-Methylphenol	ND		ug/l	5.0	0.49
3-Methylphenol/4-Methylphenol	ND		ug/l	5.0	0.48
2,4,5-Trichlorophenol	ND		ug/l	5.0	0.77
Benzoic Acid	ND		ug/l	50	2.6
Benzyl Alcohol	ND		ug/l	2.0	0.59
Carbazole	ND		ug/l	2.0	0.49

Tentatively Identified Compounds			
Total TIC Compounds	24.4	J	ug/l
Unknown	2.54	J	ug/l
Unknown	1.60	J	ug/l
Unknown	1.53	J	ug/l
Unknown Organic Acid	4.84	J	ug/l
Unknown	1.67	J	ug/l
Unknown Organic Acid	8.00	J	ug/l
Unknown	1.78	J	ug/l
Unknown	2.44	J	ug/l

Project Name: 100 MAIN ST
Project Number: 12461

Lab Number: L2316452
Report Date: 04/12/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 04/02/23 12:01
Analyst: CMM

Extraction Method: EPA 3510C
Extraction Date: 04/01/23 09:26

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 05 Batch: WG1761567-1					

Surrogate	%Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	66		21-120
Phenol-d6	51		10-120
Nitrobenzene-d5	89		23-120
2-Fluorobiphenyl	88		15-120
2,4,6-Tribromophenol	85		10-120
4-Terphenyl-d14	99		41-149

Project Name: 100 MAIN ST
Project Number: 12461

Lab Number: L2316452
Report Date: 04/12/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E-SIM
Analytical Date: 04/04/23 08:47
Analyst: TPR

Extraction Method: EPA 3510C
Extraction Date: 04/01/23 18:00

Parameter	Result	Qualifier	Units	RL	MDL
1,4 Dioxane by 8270E-SIM - Mansfield Lab for sample(s): 05 Batch: WG1761663-1					
1,4-Dioxane	ND		ng/l	150	33.9

Surrogate	%Recovery	Qualifier	Acceptance Criteria
1,4-Dioxane-d8	76		15-110

Project Name: 100 MAIN ST
Project Number: 12461

Lab Number: L2316452
Report Date: 04/12/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E-SIM
Analytical Date: 04/03/23 12:33
Analyst: JJW

Extraction Method: EPA 3510C
Extraction Date: 04/02/23 19:04

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS-SIM - Westborough Lab for sample(s): 05 Batch: WG1761839-1					
Acenaphthene	ND		ug/l	0.10	0.01
2-Chloronaphthalene	ND		ug/l	0.20	0.02
Fluoranthene	ND		ug/l	0.10	0.02
Hexachlorobutadiene	ND		ug/l	0.50	0.05
Naphthalene	ND		ug/l	0.10	0.05
Benzo(a)anthracene	0.02	J	ug/l	0.10	0.02
Benzo(a)pyrene	ND		ug/l	0.10	0.02
Benzo(b)fluoranthene	ND		ug/l	0.10	0.01
Benzo(k)fluoranthene	ND		ug/l	0.10	0.01
Chrysene	ND		ug/l	0.10	0.01
Acenaphthylene	ND		ug/l	0.10	0.01
Anthracene	ND		ug/l	0.10	0.01
Benzo(ghi)perylene	ND		ug/l	0.10	0.01
Fluorene	ND		ug/l	0.10	0.01
Phenanthrene	0.03	J	ug/l	0.10	0.02
Dibenzo(a,h)anthracene	ND		ug/l	0.10	0.01
Indeno(1,2,3-cd)pyrene	ND		ug/l	0.10	0.01
Pyrene	ND		ug/l	0.10	0.02
2-Methylnaphthalene	ND		ug/l	0.10	0.02
Pentachlorophenol	0.17	J	ug/l	0.80	0.01
Hexachlorobenzene	ND		ug/l	0.80	0.01
Hexachloroethane	ND		ug/l	0.80	0.06

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E-SIM
Analytical Date: 04/03/23 12:33
Analyst: JJW

Extraction Method: EPA 3510C
Extraction Date: 04/02/23 19:04

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS-SIM - Westborough Lab for sample(s): 05 Batch: WG1761839-1					

Surrogate	%Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	85		21-120
Phenol-d6	74		10-120
Nitrobenzene-d5	**122**	Q	23-120
2-Fluorobiphenyl	86		15-120
2,4,6-Tribromophenol	91		10-120
4-Terphenyl-d14	101		41-149

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 144,1633
Analytical Date: 04/07/23 12:58
Analyst: RS

Extraction Method: EPA 1633
Extraction Date: 04/06/23 13:45

Parameter	Result	Qualifier	Units	RL	MDL
Perfluorinated Alkyl Acids by EPA 1633 - Mansfield Lab for sample(s): 05 Batch: WG1763564-1					
Perfluorobutanoic Acid (PFBA)	ND		ng/l	6.27	1.00
Perfluoropentanoic Acid (PFPeA)	ND		ng/l	3.14	0.839
Perfluorobutanesulfonic Acid (PFBS)	ND		ng/l	1.57	0.525
Perfluorohexanoic Acid (PFHxA)	ND		ng/l	1.57	0.463
Perfluoroheptanoic Acid (PFHpA)	ND		ng/l	1.57	0.314
Perfluorohexanesulfonic Acid (PFHxS)	ND		ng/l	1.57	0.376
Perfluorooctanoic Acid (PFOA)	ND		ng/l	1.57	0.682
1H,1H,2H,2H-Perfluorooctanesulfonic Acid (6:2FTS)	ND		ng/l	6.27	2.12
Perfluoroheptanesulfonic Acid (PFHpS)	ND		ng/l	1.57	0.424
Perfluorononanoic Acid (PFNA)	ND		ng/l	1.57	0.494
Perfluorooctanesulfonic Acid (PFOS)	ND		ng/l	1.57	0.714
Perfluorodecanoic Acid (PFDA)	ND		ng/l	1.57	0.635
1H,1H,2H,2H-Perfluorodecanesulfonic Acid (8:2FTS)	ND		ng/l	6.27	2.44
N-Methyl Perfluorooctanesulfonamidoacetic Acid (NMeFOSAA)	ND		ng/l	1.57	0.855
Perfluoroundecanoic Acid (PFUnA)	ND		ng/l	1.57	0.682
Perfluorodecanesulfonic Acid (PFDS)	ND		ng/l	1.57	0.361
Perfluorooctanesulfonamide (PFOSA)	ND		ng/l	1.57	0.424
N-Ethyl Perfluorooctanesulfonamidoacetic Acid (NEtFOSAA)	ND		ng/l	1.57	0.847
Perfluorododecanoic Acid (PFDoA)	ND		ng/l	1.57	0.722
Perfluorotridecanoic Acid (PFTrDA)	ND		ng/l	1.57	0.588
Perfluorotetradecanoic Acid (PFTeDA)	ND		ng/l	1.57	0.416
PFOA/PFOS, Total	ND		ng/l	1.57	0.682

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 144,1633
Analytical Date: 04/07/23 12:58
Analyst: RS

Extraction Method: EPA 1633
Extraction Date: 04/06/23 13:45

Parameter	Result	Qualifier	Units	RL	MDL
Perfluorinated Alkyl Acids by EPA 1633 - Mansfield Lab for sample(s): 05 Batch: WG1763564-1					

Surrogate	%Recovery	Qualifier	Acceptance Criteria
Perfluoro-n-[13C4]Butanoic Acid (13C4-PFBA)	89		20-150
Perfluoro-n-[13C5]Pentanoic Acid (13C5-PFPeA)	93		20-150
Perfluoro-1-[2,3,4-13C3]Butanesulfonic Acid (13C3-PFBS)	97		20-150
Perfluoro-n-[1,2,3,4,6-13C5]Hexanoic Acid (13C5-PFHxA)	90		20-150
Perfluoro-n-[1,2,3,4-13C4]Heptanoic Acid (13C4-PFHpA)	75		20-150
Perfluoro-1-[1,2,3-13C3]Hexanesulfonic Acid (13C3-PFHxS)	89		20-150
Perfluoro-n-[13C8]Octanoic Acid (13C8-PFOA)	87		20-150
1H,1H,2H,2H-Perfluoro-1-[1,2-13C2]Octanesulfonic Acid (13C2-6:2FTS)	89		20-150
Perfluoro-n-[13C9]Nonanoic Acid (13C9-PFNA)	86		20-150
Perfluoro-1-[13C8]Octanesulfonic Acid (13C8-PFOS)	96		20-150
Perfluoro-n-[1,2,3,4,5,6-13C6]Decanoic Acid (13C6-PFDA)	91		20-150
1H,1H,2H,2H-Perfluoro-1-[1,2-13C2]Decanesulfonic Acid (13C2-8:2FTS)	99		20-150
N-Methyl-d3-perfluoro-1-octanesulfonamidoacetic Acid (D3-NMeFOSAA)	132		20-150
Perfluoro-n-[1,2,3,4,5,6,7-13C7]Undecanoic Acid (13C7-PFUnA)	85		20-150
Perfluoro-1-[13C8]Octanesulfonamide (13C8-PFOSA)	64		20-150
N-Ethyl-d5-perfluoro-1-octanesulfonamidoacetic Acid (D5-NEtFOSAA)	68		20-150
Perfluoro-n-[1,2-13C2]Dodecanoic Acid (13C2-PFDoA)	79		20-150
Perfluoro-n-[1,2-13C2]Tetradecanoic Acid (13C2-PFTeDA)	77		20-150

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST

Project Number: 12461

Lab Number: L2316452

Report Date: 04/12/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 01-04 Batch: WG1760400-2 WG1760400-3								
Acenaphthene	58		50		31-137	15		50
1,2,4-Trichlorobenzene	55		47		38-107	16		50
Hexachlorobenzene	57		49		40-140	15		50
Bis(2-chloroethyl)ether	62		52		40-140	18		50
2-Chloronaphthalene	57		50		40-140	13		50
1,2-Dichlorobenzene	56		45		40-140	22		50
1,3-Dichlorobenzene	56		45		40-140	22		50
1,4-Dichlorobenzene	54		46		28-104	16		50
3,3'-Dichlorobenzidine	54		46		40-140	16		50
2,4-Dinitrotoluene	61		52		40-132	16		50
2,6-Dinitrotoluene	57		52		40-140	9		50
Fluoranthene	60		51		40-140	16		50
4-Chlorophenyl phenyl ether	55		48		40-140	14		50
4-Bromophenyl phenyl ether	55		48		40-140	14		50
Bis(2-chloroisopropyl)ether	67		56		40-140	18		50
Bis(2-chloroethoxy)methane	64		55		40-117	15		50
Hexachlorobutadiene	47		42		40-140	11		50
Hexachlorocyclopentadiene	51		46		40-140	10		50
Hexachloroethane	56		47		40-140	17		50
Isophorone	62		54		40-140	14		50
Naphthalene	55		49		40-140	12		50
Nitrobenzene	66		55		40-140	18		50
NDPA/DPA	63		54		36-157	15		50

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST

Project Number: 12461

Lab Number: L2316452

Report Date: 04/12/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 01-04 Batch: WG1760400-2 WG1760400-3								
n-Nitrosodi-n-propylamine	66		57		32-121	15		50
Bis(2-ethylhexyl)phthalate	65		57		40-140	13		50
Butyl benzyl phthalate	68		58		40-140	16		50
Di-n-butylphthalate	63		55		40-140	14		50
Di-n-octylphthalate	65		57		40-140	13		50
Diethyl phthalate	64		54		40-140	17		50
Dimethyl phthalate	59		50		40-140	17		50
Benzo(a)anthracene	58		51		40-140	13		50
Benzo(a)pyrene	58		50		40-140	15		50
Benzo(b)fluoranthene	56		48		40-140	15		50
Benzo(k)fluoranthene	60		52		40-140	14		50
Chrysene	55		48		40-140	14		50
Acenaphthylene	60		51		40-140	16		50
Anthracene	58		51		40-140	13		50
Benzo(ghi)perylene	60		49		40-140	20		50
Fluorene	60		51		40-140	16		50
Phenanthrene	57		49		40-140	15		50
Dibenzo(a,h)anthracene	57		48		40-140	17		50
Indeno(1,2,3-cd)pyrene	64		54		40-140	17		50
Pyrene	61		51		35-142	18		50
Biphenyl	57		50		37-127	13		50
4-Chloroaniline	66		58		40-140	13		50
2-Nitroaniline	62		52		47-134	18		50

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST

Project Number: 12461

Lab Number: L2316452

Report Date: 04/12/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 01-04 Batch: WG1760400-2 WG1760400-3								
3-Nitroaniline	61		52		26-129	16		50
4-Nitroaniline	67		56		41-125	18		50
Dibenzofuran	59		50		40-140	17		50
2-Methylnaphthalene	55		48		40-140	14		50
1,2,4,5-Tetrachlorobenzene	54		48		40-117	12		50
Acetophenone	67		56		14-144	18		50
2,4,6-Trichlorophenol	56		50		30-130	11		50
p-Chloro-m-cresol	62		55		26-103	12		50
2-Chlorophenol	61		51		25-102	18		50
2,4-Dichlorophenol	63		52		30-130	19		50
2,4-Dimethylphenol	65		55		30-130	17		50
2-Nitrophenol	60		50		30-130	18		50
4-Nitrophenol	83		67		11-114	21		50
2,4-Dinitrophenol	62		51		4-130	19		50
4,6-Dinitro-o-cresol	69		58		10-130	17		50
Pentachlorophenol	61		50		17-109	20		50
Phenol	65		54		26-90	18		50
2-Methylphenol	67		54		30-130.	21		50
3-Methylphenol/4-Methylphenol	71		58		30-130	20		50
2,4,5-Trichlorophenol	61		53		30-130	14		50
Benzoic Acid	50		43		10-110	15		50
Benzyl Alcohol	70		59		40-140	17		50
Carbazole	61		**52**	Q	54-128	16		50

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST

Project Number: 12461

Lab Number: L2316452

Report Date: 04/12/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 01-04 Batch: WG1760400-2 WG1760400-3								
1,4-Dioxane	51		42		40-140	19		50

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
2-Fluorophenol	65		54		25-120
Phenol-d6	68		55		10-120
Nitrobenzene-d5	63		53		23-120
2-Fluorobiphenyl	57		49		30-120
2,4,6-Tribromophenol	60		51		10-136
4-Terphenyl-d14	59		49		18-120

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST
Project Number: 12461

Lab Number: L2316452
Report Date: 04/12/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 05 Batch: WG1761567-2 WG1761567-3								
Acenaphthene	80		74		37-111	8		30
1,2,4-Trichlorobenzene	82		78		39-98	5		30
Hexachlorobenzene	78		70		40-140	11		30
Bis(2-chloroethyl)ether	77		75		40-140	3		30
2-Chloronaphthalene	81		75		40-140	8		30
1,2-Dichlorobenzene	71		71		40-140	0		30
1,3-Dichlorobenzene	70		69		40-140	1		30
1,4-Dichlorobenzene	70		70		36-97	0		30
3,3'-Dichlorobenzidine	75		67		40-140	11		30
2,4-Dinitrotoluene	92		90		48-143	2		30
2,6-Dinitrotoluene	94		95		40-140	1		30
Fluoranthene	90		85		40-140	6		30
4-Chlorophenyl phenyl ether	89		80		40-140	11		30
4-Bromophenyl phenyl ether	85		75		40-140	13		30
Bis(2-chloroisopropyl)ether	113		107		40-140	5		30
Bis(2-chloroethoxy)methane	80		74		40-140	8		30
Hexachlorobutadiene	80		76		40-140	5		30
Hexachlorocyclopentadiene	72		68		40-140	6		30
Hexachloroethane	78		69		40-140	12		30
Isophorone	80		76		40-140	5		30
Naphthalene	75		73		40-140	3		30
Nitrobenzene	86		81		40-140	6		30
NDPA/DPA	97		84		40-140	14		30

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST
Project Number: 12461

Lab Number: L2316452
Report Date: 04/12/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 05 Batch: WG1761567-2 WG1761567-3								
n-Nitrosodi-n-propylamine	86		80		29-132	7		30
Bis(2-ethylhexyl)phthalate	106		96		40-140	10		30
Butyl benzyl phthalate	98		92		40-140	6		30
Di-n-butylphthalate	92		82		40-140	11		30
Di-n-octylphthalate	99		89		40-140	11		30
Diethyl phthalate	93		82		40-140	13		30
Dimethyl phthalate	91		82		40-140	10		30
Benzo(a)anthracene	94		87		40-140	8		30
Benzo(a)pyrene	90		84		40-140	7		30
Benzo(b)fluoranthene	89		78		40-140	13		30
Benzo(k)fluoranthene	88		80		40-140	10		30
Chrysene	90		80		40-140	12		30
Acenaphthylene	87		81		45-123	7		30
Anthracene	84		80		40-140	5		30
Benzo(ghi)perylene	82		71		40-140	14		30
Fluorene	90		81		40-140	11		30
Phenanthrene	84		75		40-140	11		30
Dibenzo(a,h)anthracene	83		75		40-140	10		30
Indeno(1,2,3-cd)pyrene	97		86		40-140	12		30
Pyrene	91		85		26-127	7		30
Biphenyl	98		91		40-140	7		30
4-Chloroaniline	83		86		40-140	4		30
2-Nitroaniline	90		86		52-143	5		30

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST
Project Number: 12461

Lab Number: L2316452
Report Date: 04/12/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 05 Batch: WG1761567-2 WG1761567-3								
3-Nitroaniline	80		69		25-145	15		30
4-Nitroaniline	86		80		51-143	7		30
Dibenzofuran	86		78		40-140	10		30
2-Methylnaphthalene	79		77		40-140	3		30
1,2,4,5-Tetrachlorobenzene	99		92		2-134	7		30
Acetophenone	89		88		39-129	1		30
2,4,6-Trichlorophenol	107		99		30-130	8		30
p-Chloro-m-cresol	89		84		23-97	6		30
2-Chlorophenol	81		83		27-123	2		30
2,4-Dichlorophenol	99		94		30-130	5		30
2,4-Dimethylphenol	78		70		30-130	11		30
2-Nitrophenol	118		110		30-130	7		30
4-Nitrophenol	**104**	Q	**93**	Q	10-80	11		30
2,4-Dinitrophenol	**156**	Q	**148**	Q	20-130	5		30
4,6-Dinitro-o-cresol	162		155		20-164	4		30
Pentachlorophenol	**107**	Q	95		9-103	12		30
Phenol	58		59		12-110	2		30
2-Methylphenol	79		72		30-130	9		30
3-Methylphenol/4-Methylphenol	84		82		30-130	2		30
2,4,5-Trichlorophenol	99		90		30-130	10		30
Benzoic Acid	84		75		10-164	11		30
Benzyl Alcohol	78		71		26-116	9		30
Carbazole	85		80		55-144	6		30

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST

Project Number: 12461

Lab Number: L2316452

Report Date: 04/12/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 05 Batch: WG1761567-2 WG1761567-3								

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
2-Fluorophenol	70		66		21-120
Phenol-d6	57		54		10-120
Nitrobenzene-d5	84		81		23-120
2-Fluorobiphenyl	85		80		15-120
2,4,6-Tribromophenol	91		78		10-120
4-Terphenyl-d14	89		83		41-149

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST

Project Number: 12461

Lab Number: L2316452

Report Date: 04/12/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
1,4 Dioxane by 8270E-SIM - Mansfield Lab Associated sample(s): 05 Batch: WG1761663-2 WG1761663-3								
1,4-Dioxane	106		107		40-140	1		30

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
1,4-Dioxane-d8	69		70		15-110

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST

Project Number: 12461

Lab Number: L2316452

Report Date: 04/12/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS-SIM - Westborough Lab Associated sample(s): 05 Batch: WG1761839-2 WG1761839-3								
Acenaphthene	76		79		40-140	4		40
2-Chloronaphthalene	75		80		40-140	6		40
Fluoranthene	89		87		40-140	2		40
Hexachlorobutadiene	70		75		40-140	7		40
Naphthalene	73		78		40-140	7		40
Benzo(a)anthracene	91		90		40-140	1		40
Benzo(a)pyrene	93		92		40-140	1		40
Benzo(b)fluoranthene	92		93		40-140	1		40
Benzo(k)fluoranthene	84		84		40-140	0		40
Chrysene	81		80		40-140	1		40
Acenaphthylene	88		92		40-140	4		40
Anthracene	89		91		40-140	2		40
Benzo(ghi)perylene	88		85		40-140	3		40
Fluorene	82		85		40-140	4		40
Phenanthrene	79		82		40-140	4		40
Dibenzo(a,h)anthracene	96		94		40-140	2		40
Indeno(1,2,3-cd)pyrene	101		98		40-140	3		40
Pyrene	88		86		40-140	2		40
2-Methylnaphthalene	74		79		40-140	7		40
Pentachlorophenol	101		92		40-140	9		40
Hexachlorobenzene	81		84		40-140	4		40
Hexachloroethane	76		82		40-140	8		40

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST
Project Number: 12461

Lab Number: L2316452
Report Date: 04/12/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS-SIM - Westborough Lab Associated sample(s): 05 Batch: WG1761839-2 WG1761839-3								

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
2-Fluorophenol	86		92		21-120
Phenol-d6	79		84		10-120
Nitrobenzene-d5	**121**	Q	**131**	Q	23-120
2-Fluorobiphenyl	80		86		15-120
2,4,6-Tribromophenol	96		94		10-120
4-Terphenyl-d14	92		89		41-149

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST
Project Number: 12461

Lab Number: L2316452
Report Date: 04/12/23

Parameter	Low Level LCS %Recovery	Qual	Low Level LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Perfluorinated Alkyl Acids by EPA 1633 - Mansfield Lab Associated sample(s): 05 Batch: WG1763564-2 LOW LEVEL								
Perfluorobutanoic Acid (PFBA)	103		-		40-150	-		30
Perfluoropentanoic Acid (PFPeA)	94		-		40-150	-		30
Perfluorobutanesulfonic Acid (PFBS)	90		-		40-150	-		30
Perfluorohexanoic Acid (PFHxA)	102		-		40-150	-		30
Perfluoroheptanoic Acid (PFHpA)	98		-		40-150	-		30
Perfluorohexanesulfonic Acid (PFHxS)	98		-		40-150	-		30
Perfluorooctanoic Acid (PFOA)	100		-		40-150	-		30
1H,1H,2H,2H-Perfluorooctanesulfonic Acid (6:2FTS)	96		-		40-150	-		30
Perfluoroheptanesulfonic Acid (PFHpS)	94		-		40-150	-		30
Perfluorononanoic Acid (PFNA)	85		-		40-150	-		30
Perfluorooctanesulfonic Acid (PFOS)	94		-		40-150	-		30
Perfluorodecanoic Acid (PFDA)	110		-		40-150	-		30
1H,1H,2H,2H-Perfluorodecanesulfonic Acid (8:2FTS)	101		-		40-150	-		30
N-Methyl Perfluorooctanesulfonamidoacetic Acid (NMeFOSAA)	118		-		40-150	-		30
Perfluoroundecanoic Acid (PFUnA)	78		-		40-150	-		30
Perfluorodecanesulfonic Acid (PFDS)	80		-		40-150	-		30
Perfluorooctanesulfonamide (PFOSA)	88		-		40-150	-		30
N-Ethyl Perfluorooctanesulfonamidoacetic Acid (NEtFOSAA)	102		-		40-150	-		30
Perfluorododecanoic Acid (PFDoA)	100		-		40-150	-		30
Perfluorotridecanoic Acid (PFTrDA)	100		-		40-150	-		30
Perfluorotetradecanoic Acid (PFTeDA)	98		-		40-150	-		30

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST

Project Number: 12461

Lab Number: L2316452

Report Date: 04/12/23

Parameter	Low Level LCS %Recovery	Qual	Low Level LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits

Perfluorinated Alkyl Acids by EPA 1633 - Mansfield Lab Associated sample(s): 05 Batch: WG1763564-2 LOW LEVEL

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
Perfluoro-n-[13C4]Butanoic Acid (13C4-PFBA)	87				20-150
Perfluoro-n-[13C5]Pentanoic Acid (13C5-PFPeA)	94				20-150
Perfluoro-1-[2,3,4-13C3]Butanesulfonic Acid (13C3-PFBS)	91				20-150
Perfluoro-n-[1,2,3,4,6-13C5]Hexanoic Acid (13C5-PFHxA)	90				20-150
Perfluoro-n-[1,2,3,4-13C4]Heptanoic Acid (13C4-PFHpA)	74				20-150
Perfluoro-1-[1,2,3-13C3]Hexanesulfonic Acid (13C3-PFHxS)	83				20-150
Perfluoro-n-[13C8]Octanoic Acid (13C8-PFOA)	84				20-150
1H,1H,2H,2H-Perfluoro-1-[1,2-13C2]Octanesulfonic Acid (13C2-6:2FTS)	84				20-150
Perfluoro-n-[13C9]Nonanoic Acid (13C9-PFNA)	87				20-150
Perfluoro-1-[13C8]Octanesulfonic Acid (13C8-PFOS)	86				20-150
Perfluoro-n-[1,2,3,4,5,6-13C6]Decanoic Acid (13C6-PFDA)	94				20-150
1H,1H,2H,2H-Perfluoro-1-[1,2-13C2]Decanesulfonic Acid (13C2-8:2FTS)	91				20-150
N-Methyl-d3-perfluoro-1-octanesulfonamidoacetic Acid (D3-NMeFOSAA)	94				20-150
Perfluoro-n-[1,2,3,4,5,6,7-13C7]Undecanoic Acid (13C7-PFUnA)	97				20-150
Perfluoro-1-[13C8]Octanesulfonamide (13C8-PFOSA)	60				20-150
N-Ethyl-d5-perfluoro-1-octanesulfonamidoacetic Acid (D5-NEtFOSAA)	62				20-150
Perfluoro-n-[1,2-13C2]Dodecanoic Acid (13C2-PFDoA)	83				20-150
Perfluoro-n-[1,2-13C2]Tetradecanoic Acid (13C2-PFTeDA)	66				20-150

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST
Project Number: 12461

Lab Number: L2316452
Report Date: 04/12/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Perfluorinated Alkyl Acids by EPA 1633 - Mansfield Lab Associated sample(s): 05 Batch: WG1763564-3								
Perfluorobutanoic Acid (PFBA)	88		-		40-150	-		30
Perfluoropentanoic Acid (PFPeA)	89		-		40-150	-		30
Perfluorobutanesulfonic Acid (PFBS)	86		-		40-150	-		30
Perfluorohexanoic Acid (PFHxA)	86		-		40-150	-		30
Perfluoroheptanoic Acid (PFHpA)	89		-		40-150	-		30
Perfluorohexanesulfonic Acid (PFHxS)	89		-		40-150	-		30
Perfluorooctanoic Acid (PFOA)	90		-		40-150	-		30
1H,1H,2H,2H-Perfluorooctanesulfonic Acid (6:2FTS)	89		-		40-150	-		30
Perfluoroheptanesulfonic Acid (PFHpS)	89		-		40-150	-		30
Perfluorononanoic Acid (PFNA)	103		-		40-150	-		30
Perfluorooctanesulfonic Acid (PFOS)	86		-		40-150	-		30
Perfluorodecanoic Acid (PFDA)	106		-		40-150	-		30
1H,1H,2H,2H-Perfluorodecanesulfonic Acid (8:2FTS)	85		-		40-150	-		30
N-Methyl Perfluorooctanesulfonamidoacetic Acid (NMeFOSAA)	98		-		40-150	-		30
Perfluoroundecanoic Acid (PFUnA)	84		-		40-150	-		30
Perfluorodecanesulfonic Acid (PFDS)	80		-		40-150	-		30
Perfluorooctanesulfonamide (PFOSA)	85		-		40-150	-		30
N-Ethyl Perfluorooctanesulfonamidoacetic Acid (NEtFOSAA)	96		-		40-150	-		30
Perfluorododecanoic Acid (PFDoA)	95		-		40-150	-		30
Perfluorotridecanoic Acid (PFTrDA)	86		-		40-150	-		30
Perfluorotetradecanoic Acid (PFTeDA)	88		-		40-150	-		30

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Perfluorinated Alkyl Acids by EPA 1633 - Mansfield Lab Associated sample(s): 05 Batch: WG1763564-3								

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
Perfluoro-n-[13C4]Butanoic Acid (13C4-PFBA)	89				20-150
Perfluoro-n-[13C5]Pentanoic Acid (13C5-PFPeA)	97				20-150
Perfluoro-1-[2,3,4-13C3]Butanesulfonic Acid (13C3-PFBS)	96				20-150
Perfluoro-n-[1,2,3,4,6-13C5]Hexanoic Acid (13C5-PFHxA)	100				20-150
Perfluoro-n-[1,2,3,4-13C4]Heptanoic Acid (13C4-PFHpA)	82				20-150
Perfluoro-1-[1,2,3-13C3]Hexanesulfonic Acid (13C3-PFHxS)	89				20-150
Perfluoro-n-[13C8]Octanoic Acid (13C8-PFOA)	83				20-150
1H,1H,2H,2H-Perfluoro-1-[1,2-13C2]Octanesulfonic Acid (13C2-6:2FTS)	89				20-150
Perfluoro-n-[13C9]Nonanoic Acid (13C9-PFNA)	81				20-150
Perfluoro-1-[13C8]Octanesulfonic Acid (13C8-PFOS)	94				20-150
Perfluoro-n-[1,2,3,4,5,6-13C6]Decanoic Acid (13C6-PFDA)	82				20-150
1H,1H,2H,2H-Perfluoro-1-[1,2-13C2]Decanesulfonic Acid (13C2-8:2FTS)	97				20-150
N-Methyl-d3-perfluoro-1-octanesulfonamidoacetic Acid (D3-NMeFOSAA)	102				20-150
Perfluoro-n-[1,2,3,4,5,6,7-13C7]Undecanoic Acid (13C7-PFUnA)	86				20-150
Perfluoro-1-[13C8]Octanesulfonamide (13C8-PFOSA)	65				20-150
N-Ethyl-d5-perfluoro-1-octanesulfonamidoacetic Acid (D5-NEtFOSAA)	71				20-150
Perfluoro-n-[1,2-13C2]Dodecanoic Acid (13C2-PFDoA)	74				20-150
Perfluoro-n-[1,2-13C2]Tetradecanoic Acid (13C2-PFTeDA)	78				20-150

PCBS

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-01
Client ID: SB-34 (0.5-1)
Sample Location: WHITEPLAINS, NY

Date Collected: 03/29/23 09:15
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8082A
Analytical Date: 04/01/23 15:02
Analyst: JM
Percent Solids: 90%

Extraction Method: EPA 3546
Extraction Date: 03/31/23 18:54
Cleanup Method: EPA 3665A
Cleanup Date: 04/01/23
Cleanup Method: EPA 3660B
Cleanup Date: 04/01/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/kg	35.2	3.12	1	A
Aroclor 1221	ND		ug/kg	35.2	3.52	1	A
Aroclor 1232	ND		ug/kg	35.2	7.46	1	A
Aroclor 1242	ND		ug/kg	35.2	4.74	1	A
Aroclor 1248	ND		ug/kg	35.2	5.28	1	A
Aroclor 1254	ND		ug/kg	35.2	3.85	1	A
Aroclor 1260	ND		ug/kg	35.2	6.50	1	B
Aroclor 1262	ND		ug/kg	35.2	4.47	1	A
Aroclor 1268	ND		ug/kg	35.2	3.64	1	A
PCBs, Total	ND		ug/kg	35.2	3.12	1	B

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	76		30-150	A
Decachlorobiphenyl	76		30-150	A
2,4,5,6-Tetrachloro-m-xylene	76		30-150	B
Decachlorobiphenyl	75		30-150	B

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-02
Client ID: SB-33 (2-2.5)
Sample Location: WHITEPLAINS, NY

Date Collected: 03/29/23 08:50
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8082A
Analytical Date: 04/01/23 15:10
Analyst: JM
Percent Solids: 94%

Extraction Method: EPA 3546
Extraction Date: 03/31/23 18:54
Cleanup Method: EPA 3665A
Cleanup Date: 04/01/23
Cleanup Method: EPA 3660B
Cleanup Date: 04/01/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/kg	33.7	3.00	1	A
Aroclor 1221	ND		ug/kg	33.7	3.38	1	A
Aroclor 1232	ND		ug/kg	33.7	7.15	1	A
Aroclor 1242	ND		ug/kg	33.7	4.55	1	A
Aroclor 1248	ND		ug/kg	33.7	5.06	1	A
Aroclor 1254	8.48	J	ug/kg	33.7	3.69	1	B
Aroclor 1260	ND		ug/kg	33.7	6.24	1	A
Aroclor 1262	ND		ug/kg	33.7	4.28	1	A
Aroclor 1268	ND		ug/kg	33.7	3.50	1	A
PCBs, Total	8.48	J	ug/kg	33.7	3.00	1	B

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	66		30-150	A
Decachlorobiphenyl	65		30-150	A
2,4,5,6-Tetrachloro-m-xylene	67		30-150	B
Decachlorobiphenyl	63		30-150	B

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-03
Client ID: SB-35 (4-4.5)
Sample Location: WHITEPLAINS, NY

Date Collected: 03/29/23 12:30
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8082A
Analytical Date: 04/01/23 15:18
Analyst: JM
Percent Solids: 92%

Extraction Method: EPA 3546
Extraction Date: 03/31/23 18:54
Cleanup Method: EPA 3665A
Cleanup Date: 04/01/23
Cleanup Method: EPA 3660B
Cleanup Date: 04/01/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/kg	35.7	3.17	1	A
Aroclor 1221	ND		ug/kg	35.7	3.57	1	A
Aroclor 1232	ND		ug/kg	35.7	7.56	1	A
Aroclor 1242	ND		ug/kg	35.7	4.81	1	A
Aroclor 1248	ND		ug/kg	35.7	5.35	1	A
Aroclor 1254	ND		ug/kg	35.7	3.90	1	A
Aroclor 1260	ND		ug/kg	35.7	6.59	1	A
Aroclor 1262	ND		ug/kg	35.7	4.53	1	A
Aroclor 1268	ND		ug/kg	35.7	3.70	1	A
PCBs, Total	ND		ug/kg	35.7	3.17	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	87		30-150	A
Decachlorobiphenyl	84		30-150	A
2,4,5,6-Tetrachloro-m-xylene	89		30-150	B
Decachlorobiphenyl	80		30-150	B

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-04
Client ID: SB-36 (1-1.5)
Sample Location: WHITEPLAINS, NY

Date Collected: 03/29/23 13:00
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8082A
Analytical Date: 04/01/23 15:26
Analyst: JM
Percent Solids: 85%

Extraction Method: EPA 3546
Extraction Date: 03/31/23 18:54
Cleanup Method: EPA 3665A
Cleanup Date: 04/01/23
Cleanup Method: EPA 3660B
Cleanup Date: 04/01/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/kg	37.3	3.31	1	A
Aroclor 1221	ND		ug/kg	37.3	3.73	1	A
Aroclor 1232	ND		ug/kg	37.3	7.90	1	A
Aroclor 1242	ND		ug/kg	37.3	5.02	1	A
Aroclor 1248	ND		ug/kg	37.3	5.59	1	A
Aroclor 1254	ND		ug/kg	37.3	4.08	1	A
Aroclor 1260	ND		ug/kg	37.3	6.88	1	A
Aroclor 1262	ND		ug/kg	37.3	4.73	1	A
Aroclor 1268	ND		ug/kg	37.3	3.86	1	B
PCBs, Total	ND		ug/kg	37.3	3.31	1	B

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	70		30-150	A
Decachlorobiphenyl	65		30-150	A
2,4,5,6-Tetrachloro-m-xylene	71		30-150	B
Decachlorobiphenyl	63		30-150	B

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-05
Client ID: GW-2
Sample Location: WHITEPLAINS, NY

Date Collected: 03/29/23 12:00
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8082A
Analytical Date: 04/03/23 09:52
Analyst: JM

Extraction Method: EPA 3510C
Extraction Date: 04/02/23 16:10
Cleanup Method: EPA 3665A
Cleanup Date: 04/02/23
Cleanup Method: EPA 3660B
Cleanup Date: 04/03/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/l	0.071	0.061	1	A
Aroclor 1221	ND		ug/l	0.071	0.061	1	A
Aroclor 1232	ND		ug/l	0.071	0.061	1	A
Aroclor 1242	ND		ug/l	0.071	0.061	1	A
Aroclor 1248	ND		ug/l	0.071	0.061	1	A
Aroclor 1254	ND		ug/l	0.071	0.061	1	A
Aroclor 1260	ND		ug/l	0.071	0.061	1	A
Aroclor 1262	ND		ug/l	0.071	0.061	1	A
Aroclor 1268	ND		ug/l	0.071	0.061	1	A
PCBs, Total	ND		ug/l	0.071	0.061	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	98		30-150	A
Decachlorobiphenyl	76		30-150	A
2,4,5,6-Tetrachloro-m-xylene	95		30-150	B
Decachlorobiphenyl	75		30-150	B

Project Name: 100 MAIN ST
Project Number: 12461

Lab Number: L2316452
Report Date: 04/12/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8082A
Analytical Date: 04/01/23 14:06
Analyst: ER

Extraction Method: EPA 3546
Extraction Date: 03/31/23 18:54
Cleanup Method: EPA 3665A
Cleanup Date: 04/01/23
Cleanup Method: EPA 3660B
Cleanup Date: 04/01/23

Parameter	Result	Qualifier	Units	RL	MDL	Column
Polychlorinated Biphenyls by GC - Westborough Lab for sample(s): 01-04 Batch: WG1761447-1						
Aroclor 1016	ND		ug/kg	31.5	2.79	A
Aroclor 1221	ND		ug/kg	31.5	3.15	A
Aroclor 1232	ND		ug/kg	31.5	6.67	A
Aroclor 1242	ND		ug/kg	31.5	4.24	A
Aroclor 1248	ND		ug/kg	31.5	4.72	A
Aroclor 1254	ND		ug/kg	31.5	3.44	A
Aroclor 1260	ND		ug/kg	31.5	5.81	A
Aroclor 1262	ND		ug/kg	31.5	4.00	A
Aroclor 1268	ND		ug/kg	31.5	3.26	A
PCBs, Total	ND		ug/kg	31.5	2.79	A

Surrogate	%Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	91		30-150	A
Decachlorobiphenyl	89		30-150	A
2,4,5,6-Tetrachloro-m-xylene	94		30-150	B
Decachlorobiphenyl	87		30-150	B

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8082A
Analytical Date: 04/03/23 08:59
Analyst: JM

Extraction Method: EPA 3510C
Extraction Date: 04/02/23 16:10
Cleanup Method: EPA 3665A
Cleanup Date: 04/02/23
Cleanup Method: EPA 3660B
Cleanup Date: 04/03/23

Parameter	Result	Qualifier	Units	RL	MDL	Column
Polychlorinated Biphenyls by GC - Westborough Lab for sample(s): 05 Batch: WG1761807-1						
Aroclor 1016	ND		ug/l	0.071	0.061	A
Aroclor 1221	ND		ug/l	0.071	0.061	A
Aroclor 1232	ND		ug/l	0.071	0.061	A
Aroclor 1242	ND		ug/l	0.071	0.061	A
Aroclor 1248	ND		ug/l	0.071	0.061	A
Aroclor 1254	ND		ug/l	0.071	0.061	A
Aroclor 1260	ND		ug/l	0.071	0.061	A
Aroclor 1262	ND		ug/l	0.071	0.061	A
Aroclor 1268	ND		ug/l	0.071	0.061	A
PCBs, Total	ND		ug/l	0.071	0.061	A

Surrogate	%Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	95		30-150	A
Decachlorobiphenyl	101		30-150	A
2,4,5,6-Tetrachloro-m-xylene	99		30-150	B
Decachlorobiphenyl	110		30-150	B

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST

Project Number: 12461

Lab Number: L2316452

Report Date: 04/12/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits	Column
Polychlorinated Biphenyls by GC - Westborough Lab Associated sample(s): 01-04 Batch: WG1761447-2 WG1761447-3									
Aroclor 1016	76		77		40-140	1		50	A
Aroclor 1260	70		72		40-140	3		50	A

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	81		80		30-150	A
Decachlorobiphenyl	77		77		30-150	A
2,4,5,6-Tetrachloro-m-xylene	83		80		30-150	B
Decachlorobiphenyl	73		72		30-150	B

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST

Project Number: 12461

Lab Number: L2316452

Report Date: 04/12/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits	Column
Polychlorinated Biphenyls by GC - Westborough Lab Associated sample(s): 05 Batch: WG1761807-2 WG1761807-3									
Aroclor 1016	94		92		40-140	2		50	A
Aroclor 1260	84		83		40-140	1		50	A

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	101		99		30-150	A
Decachlorobiphenyl	108		103		30-150	A
2,4,5,6-Tetrachloro-m-xylene	98		93		30-150	B
Decachlorobiphenyl	115		108		30-150	B

PESTICIDES

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-01
Client ID: SB-34 (0.5-1)
Sample Location: WHITEPLAINS, NY

Date Collected: 03/29/23 09:15
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8081B
Analytical Date: 04/03/23 16:30
Analyst: AAR
Percent Solids: 90%

Extraction Method: EPA 3546
Extraction Date: 03/31/23 18:31
Cleanup Method: EPA 3620B
Cleanup Date: 04/03/23
Cleanup Method: EPA 3660B
Cleanup Date: 04/03/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/kg	1.67	0.327	1	A
Lindane	ND		ug/kg	0.696	0.311	1	A
Alpha-BHC	ND		ug/kg	0.696	0.198	1	A
Beta-BHC	ND		ug/kg	1.67	0.633	1	A
Heptachlor	ND		ug/kg	0.835	0.374	1	A
Aldrin	ND		ug/kg	1.67	0.588	1	A
Heptachlor epoxide	ND		ug/kg	3.13	0.940	1	A
Endrin	ND		ug/kg	0.696	0.285	1	A
Endrin aldehyde	ND		ug/kg	2.09	0.731	1	A
Endrin ketone	ND		ug/kg	1.67	0.430	1	A
Dieldrin	ND		ug/kg	1.04	0.522	1	A
4,4'-DDE	1.15	J	ug/kg	1.67	0.386	1	B
4,4'-DDD	ND		ug/kg	1.67	0.596	1	A
4,4'-DDT	ND		ug/kg	1.67	1.34	1	B
Endosulfan I	ND		ug/kg	1.67	0.395	1	A
Endosulfan II	ND		ug/kg	1.67	0.558	1	A
Endosulfan sulfate	ND		ug/kg	0.696	0.331	1	A
Methoxychlor	ND		ug/kg	3.13	0.974	1	A
Toxaphene	ND		ug/kg	31.3	8.77	1	A
cis-Chlordane	ND		ug/kg	2.09	0.582	1	A
trans-Chlordane	ND		ug/kg	2.09	0.551	1	A
Chlordane	ND		ug/kg	13.9	5.53	1	A

Project Name: 100 MAIN ST **Lab Number:** L2316452

Project Number: 12461 **Report Date:** 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-01 Date Collected: 03/29/23 09:15

Client ID: SB-34 (0.5-1) Date Received: 03/29/23

Sample Location: WHITEPLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	62		30-150	A
Decachlorobiphenyl	61		30-150	A
2,4,5,6-Tetrachloro-m-xylene	60		30-150	B
Decachlorobiphenyl	56		30-150	B

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-02
Client ID: SB-33 (2-2.5)
Sample Location: WHITEPLAINS, NY

Date Collected: 03/29/23 08:50
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8081B
Analytical Date: 04/03/23 16:43
Analyst: AAR
Percent Solids: 94%

Extraction Method: EPA 3546
Extraction Date: 03/31/23 18:31
Cleanup Method: EPA 3620B
Cleanup Date: 04/03/23
Cleanup Method: EPA 3660B
Cleanup Date: 04/03/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/kg	1.69	0.332	1	A
Lindane	ND		ug/kg	0.706	0.315	1	A
Alpha-BHC	ND		ug/kg	0.706	0.200	1	A
Beta-BHC	ND		ug/kg	1.69	0.642	1	A
Heptachlor	ND		ug/kg	0.847	0.380	1	A
Aldrin	ND		ug/kg	1.69	0.596	1	A
Heptachlor epoxide	ND		ug/kg	3.18	0.953	1	A
Endrin	ND		ug/kg	0.706	0.289	1	A
Endrin aldehyde	ND		ug/kg	2.12	0.741	1	A
Endrin ketone	ND		ug/kg	1.69	0.436	1	A
Dieldrin	1.28		ug/kg	1.06	0.529	1	B
4,4'-DDE	1.01	J	ug/kg	1.69	0.392	1	A
4,4'-DDD	ND		ug/kg	1.69	0.604	1	B
4,4'-DDT	2.88		ug/kg	1.69	1.36	1	B
Endosulfan I	ND		ug/kg	1.69	0.400	1	A
Endosulfan II	ND		ug/kg	1.69	0.566	1	A
Endosulfan sulfate	ND		ug/kg	0.706	0.336	1	A
Methoxychlor	ND		ug/kg	3.18	0.988	1	A
Toxaphene	ND		ug/kg	31.8	8.89	1	A
cis-Chlordane	0.966	JIP	ug/kg	2.12	0.590	1	B
trans-Chlordane	2.63		ug/kg	2.12	0.559	1	B
Chlordane	ND		ug/kg	14.1	5.61	1	A

Project Name: 100 MAIN ST **Lab Number:** L2316452

Project Number: 12461 **Report Date:** 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-02 Date Collected: 03/29/23 08:50

Client ID: SB-33 (2-2.5) Date Received: 03/29/23

Sample Location: WHITEPLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	75		30-150	A
Decachlorobiphenyl	74		30-150	A
2,4,5,6-Tetrachloro-m-xylene	73		30-150	B
Decachlorobiphenyl	65		30-150	B

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-03
Client ID: SB-35 (4-4.5)
Sample Location: WHITEPLAINS, NY

Date Collected: 03/29/23 12:30
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8081B
Analytical Date: 04/03/23 16:55
Analyst: AAR
Percent Solids: 92%

Extraction Method: EPA 3546
Extraction Date: 03/31/23 18:31
Cleanup Method: EPA 3620B
Cleanup Date: 04/03/23
Cleanup Method: EPA 3660B
Cleanup Date: 04/03/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/kg	1.66	0.326	1	A
Lindane	ND		ug/kg	0.693	0.310	1	A
Alpha-BHC	ND		ug/kg	0.693	0.197	1	A
Beta-BHC	ND		ug/kg	1.66	0.631	1	A
Heptachlor	ND		ug/kg	0.832	0.373	1	A
Aldrin	ND		ug/kg	1.66	0.586	1	A
Heptachlor epoxide	ND		ug/kg	3.12	0.936	1	A
Endrin	ND		ug/kg	0.693	0.284	1	A
Endrin aldehyde	ND		ug/kg	2.08	0.728	1	A
Endrin ketone	ND		ug/kg	1.66	0.428	1	A
Dieldrin	ND		ug/kg	1.04	0.520	1	A
4,4'-DDE	ND		ug/kg	1.66	0.385	1	A
4,4'-DDD	ND		ug/kg	1.66	0.593	1	A
4,4'-DDT	ND		ug/kg	1.66	1.34	1	A
Endosulfan I	ND		ug/kg	1.66	0.393	1	A
Endosulfan II	ND		ug/kg	1.66	0.556	1	A
Endosulfan sulfate	ND		ug/kg	0.693	0.330	1	A
Methoxychlor	ND		ug/kg	3.12	0.971	1	A
Toxaphene	ND		ug/kg	31.2	8.74	1	A
cis-Chlordane	ND		ug/kg	2.08	0.580	1	A
trans-Chlordane	ND		ug/kg	2.08	0.549	1	A
Chlordane	ND		ug/kg	13.9	5.51	1	A

Project Name: 100 MAIN ST **Lab Number:** L2316452

Project Number: 12461 **Report Date:** 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-03 Date Collected: 03/29/23 12:30

Client ID: SB-35 (4-4.5) Date Received: 03/29/23

Sample Location: WHITEPLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	83		30-150	A
Decachlorobiphenyl	74		30-150	A
2,4,5,6-Tetrachloro-m-xylene	81		30-150	B
Decachlorobiphenyl	72		30-150	B

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-04
Client ID: SB-36 (1-1.5)
Sample Location: WHITEPLAINS, NY

Date Collected: 03/29/23 13:00
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8081B
Analytical Date: 04/03/23 17:08
Analyst: AAR
Percent Solids: 85%

Extraction Method: EPA 3546
Extraction Date: 03/31/23 18:31
Cleanup Method: EPA 3620B
Cleanup Date: 04/03/23
Cleanup Method: EPA 3660B
Cleanup Date: 04/03/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/kg	1.79	0.350	1	A
Lindane	ND		ug/kg	0.744	0.333	1	A
Alpha-BHC	ND		ug/kg	0.744	0.211	1	A
Beta-BHC	ND		ug/kg	1.79	0.677	1	A
Heptachlor	ND		ug/kg	0.893	0.400	1	A
Aldrin	ND		ug/kg	1.79	0.629	1	A
Heptachlor epoxide	ND		ug/kg	3.35	1.00	1	A
Endrin	ND		ug/kg	0.744	0.305	1	A
Endrin aldehyde	ND		ug/kg	2.23	0.781	1	A
Endrin ketone	ND		ug/kg	1.79	0.460	1	A
Dieldrin	ND		ug/kg	1.12	0.558	1	A
4,4'-DDE	ND		ug/kg	1.79	0.413	1	B
4,4'-DDD	ND		ug/kg	1.79	0.637	1	A
4,4'-DDT	ND		ug/kg	1.79	1.44	1	A
Endosulfan I	ND		ug/kg	1.79	0.422	1	A
Endosulfan II	ND		ug/kg	1.79	0.597	1	A
Endosulfan sulfate	ND		ug/kg	0.744	0.354	1	A
Methoxychlor	ND		ug/kg	3.35	1.04	1	A
Toxaphene	ND		ug/kg	33.5	9.38	1	A
cis-Chlordane	ND		ug/kg	2.23	0.622	1	A
trans-Chlordane	ND		ug/kg	2.23	0.589	1	A
Chlordane	ND		ug/kg	14.9	5.92	1	A

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-04
Client ID: SB-36 (1-1.5)
Sample Location: WHITEPLAINS, NY
Date Collected: 03/29/23 13:00
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	74		30-150	A
Decachlorobiphenyl	69		30-150	A
2,4,5,6-Tetrachloro-m-xylene	74		30-150	B
Decachlorobiphenyl	68		30-150	B

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-05
Client ID: GW-2
Sample Location: WHITEPLAINS, NY

Date Collected: 03/29/23 12:00
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8081B
Analytical Date: 04/03/23 19:37
Analyst: AAR

Extraction Method: EPA 3510C
Extraction Date: 04/02/23 08:30

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/l	0.014	0.003	1	A
Lindane	ND		ug/l	0.014	0.003	1	A
Alpha-BHC	ND		ug/l	0.014	0.003	1	A
Beta-BHC	ND		ug/l	0.014	0.004	1	A
Heptachlor	ND		ug/l	0.014	0.002	1	A
Aldrin	ND		ug/l	0.014	0.002	1	A
Heptachlor epoxide	ND		ug/l	0.014	0.003	1	A
Endrin	ND		ug/l	0.029	0.003	1	A
Endrin aldehyde	ND		ug/l	0.029	0.006	1	A
Endrin ketone	ND		ug/l	0.029	0.003	1	A
Dieldrin	ND		ug/l	0.029	0.003	1	A
4,4'-DDE	0.005	J	ug/l	0.029	0.003	1	A
4,4'-DDD	0.007	J	ug/l	0.029	0.003	1	B
4,4'-DDT	0.015	J	ug/l	0.029	0.003	1	B
Endosulfan I	ND		ug/l	0.014	0.002	1	A
Endosulfan II	ND		ug/l	0.029	0.004	1	A
Endosulfan sulfate	ND		ug/l	0.029	0.003	1	A
Methoxychlor	ND		ug/l	0.143	0.005	1	A
Toxaphene	ND		ug/l	0.143	0.045	1	A
cis-Chlordane	0.010	J	ug/l	0.014	0.005	1	B
trans-Chlordane	ND	IP	ug/l	0.014	0.004	1	B
Chlordane	0.177		ug/l	0.143	0.033	1	B

Project Name: 100 MAIN ST **Lab Number:** L2316452

Project Number: 12461 **Report Date:** 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-05 Date Collected: 03/29/23 12:00

Client ID: GW-2 Date Received: 03/29/23

Sample Location: WHITEPLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	57		30-150	A
Decachlorobiphenyl	59		30-150	A
2,4,5,6-Tetrachloro-m-xylene	53		30-150	B
Decachlorobiphenyl	54		30-150	B

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8081B
Analytical Date: 04/01/23 03:19
Analyst: AAR

Extraction Method: EPA 3546
Extraction Date: 03/31/23 05:47
Cleanup Method: EPA 3620B
Cleanup Date: 03/31/23
Cleanup Method: EPA 3660B
Cleanup Date: 03/31/23

Parameter	Result	Qualifier	Units	RL	MDL	Column
Organochlorine Pesticides by GC - Westborough Lab for sample(s): 01-04 Batch: WG1761112-1						
Delta-BHC	ND		ug/kg	1.51	0.295	A
Lindane	ND		ug/kg	0.628	0.281	A
Alpha-BHC	ND		ug/kg	0.628	0.178	A
Beta-BHC	ND		ug/kg	1.51	0.572	A
Heptachlor	ND		ug/kg	0.754	0.338	A
Aldrin	ND		ug/kg	1.51	0.531	A
Heptachlor epoxide	ND		ug/kg	2.83	0.848	A
Endrin	ND		ug/kg	0.628	0.258	A
Endrin aldehyde	ND		ug/kg	1.88	0.660	A
Endrin ketone	ND		ug/kg	1.51	0.388	A
Dieldrin	ND		ug/kg	0.942	0.471	A
4,4'-DDE	ND		ug/kg	1.51	0.349	A
4,4'-DDD	ND		ug/kg	1.51	0.538	A
4,4'-DDT	ND		ug/kg	1.51	1.21	A
Endosulfan I	ND		ug/kg	1.51	0.356	A
Endosulfan II	ND		ug/kg	1.51	0.504	A
Endosulfan sulfate	ND		ug/kg	0.628	0.299	A
Methoxychlor	ND		ug/kg	2.83	0.879	A
Toxaphene	ND		ug/kg	28.3	7.91	A
cis-Chlordane	ND		ug/kg	1.88	0.525	A
trans-Chlordane	ND		ug/kg	1.88	0.497	A
Chlordane	ND		ug/kg	12.6	4.99	A

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8081B
Analytical Date: 04/01/23 03:19
Analyst: AAR

Extraction Method: EPA 3546
Extraction Date: 03/31/23 05:47
Cleanup Method: EPA 3620B
Cleanup Date: 03/31/23
Cleanup Method: EPA 3660B
Cleanup Date: 03/31/23

Parameter	Result	Qualifier	Units	RL	MDL	Column
Organochlorine Pesticides by GC - Westborough Lab for sample(s): 01-04 Batch: WG1761112-1						

Surrogate	%Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	73		30-150	A
Decachlorobiphenyl	86		30-150	A
2,4,5,6-Tetrachloro-m-xylene	74		30-150	B
Decachlorobiphenyl	85		30-150	B

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8081B
Analytical Date: 04/03/23 12:17
Analyst: MMG

Extraction Method: EPA 3510C
Extraction Date: 04/01/23 19:02

Parameter	Result	Qualifier	Units	RL	MDL	Column
Organochlorine Pesticides by GC - Westborough Lab for sample(s): 05 Batch: WG1761667-1						
Delta-BHC	ND		ug/l	0.014	0.003	A
Lindane	ND		ug/l	0.014	0.003	A
Alpha-BHC	ND		ug/l	0.014	0.003	A
Beta-BHC	ND		ug/l	0.014	0.004	A
Heptachlor	ND		ug/l	0.014	0.002	A
Aldrin	ND		ug/l	0.014	0.002	A
Heptachlor epoxide	ND		ug/l	0.014	0.003	A
Endrin	ND		ug/l	0.029	0.003	A
Endrin aldehyde	ND		ug/l	0.029	0.006	A
Endrin ketone	ND		ug/l	0.029	0.003	A
Dieldrin	ND		ug/l	0.029	0.003	A
4,4'-DDE	ND		ug/l	0.029	0.003	A
4,4'-DDD	ND		ug/l	0.029	0.003	A
4,4'-DDT	ND		ug/l	0.029	0.003	A
Endosulfan I	ND		ug/l	0.014	0.002	A
Endosulfan II	ND		ug/l	0.029	0.004	A
Endosulfan sulfate	ND		ug/l	0.029	0.003	A
Methoxychlor	ND		ug/l	0.143	0.005	A
Toxaphene	ND		ug/l	0.143	0.045	A
cis-Chlordane	ND		ug/l	0.014	0.005	A
trans-Chlordane	ND		ug/l	0.014	0.004	A
Chlordane	ND		ug/l	0.143	0.033	A

Project Name: 100 MAIN ST
Project Number: 12461

Lab Number: L2316452
Report Date: 04/12/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8081B
Analytical Date: 04/03/23 12:17
Analyst: MMG

Extraction Method: EPA 3510C
Extraction Date: 04/01/23 19:02

Parameter	Result	Qualifier	Units	RL	MDL	Column
Organochlorine Pesticides by GC - Westborough Lab for sample(s): 05 Batch: WG1761667-1						

Surrogate	%Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	82		30-150	A
Decachlorobiphenyl	77		30-150	A
2,4,5,6-Tetrachloro-m-xylene	80		30-150	B
Decachlorobiphenyl	68		30-150	B

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST
Project Number: 12461

Lab Number: L2316452
Report Date: 04/12/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits	Column
Organochlorine Pesticides by GC - Westborough Lab Associated sample(s): 01-04 Batch: WG1761112-2 WG1761112-3									
Delta-BHC	53		80		30-150	**41**	Q	30	A
Lindane	52		78		30-150	**40**	Q	30	A
Alpha-BHC	54		82		30-150	**41**	Q	30	A
Beta-BHC	64		86		30-150	29		30	A
Heptachlor	54		80		30-150	**39**	Q	30	A
Aldrin	51		77		30-150	**41**	Q	30	A
Heptachlor epoxide	44		67		30-150	**41**	Q	30	A
Endrin	51		77		30-150	**41**	Q	30	A
Endrin aldehyde	40		59		30-150	**38**	Q	30	A
Endrin ketone	48		70		30-150	**37**	Q	30	A
Dieldrin	54		81		30-150	**40**	Q	30	A
4,4'-DDE	49		74		30-150	**41**	Q	30	A
4,4'-DDD	55		82		30-150	**39**	Q	30	A
4,4'-DDT	56		84		30-150	**40**	Q	30	A
Endosulfan I	50		76		30-150	**41**	Q	30	A
Endosulfan II	52		78		30-150	**40**	Q	30	A
Endosulfan sulfate	38		56		30-150	**38**	Q	30	A
Methoxychlor	60		90		30-150	**40**	Q	30	A
cis-Chlordane	52		80		30-150	**42**	Q	30	A
trans-Chlordane	64		96		30-150	**40**	Q	30	A

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST

Project Number: 12461

Lab Number: L2316452

Report Date: 04/12/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Organochlorine Pesticides by GC - Westborough Lab Associated sample(s): 01-04 Batch: WG1761112-2 WG1761112-3								

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	52		75		30-150	A
Decachlorobiphenyl	64		92		30-150	A
2,4,5,6-Tetrachloro-m-xylene	52		77		30-150	B
Decachlorobiphenyl	61		89		30-150	B

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST
Project Number: 12461

Lab Number: L2316452
Report Date: 04/12/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits	Column
Organochlorine Pesticides by GC - Westborough Lab Associated sample(s): 05 Batch: WG1761667-2 WG1761667-3									
Delta-BHC	68		66		30-150	3		20	A
Lindane	77		74		30-150	3		20	A
Alpha-BHC	86		83		30-150	4		20	A
Beta-BHC	74		72		30-150	3		20	A
Heptachlor	87		82		30-150	6		20	A
Aldrin	83		79		30-150	4		20	A
Heptachlor epoxide	85		81		30-150	5		20	A
Endrin	83		79		30-150	5		20	A
Endrin aldehyde	70		61		30-150	15		20	A
Endrin ketone	87		82		30-150	6		20	A
Dieldrin	91		87		30-150	5		20	A
4,4'-DDE	82		78		30-150	4		20	A
4,4'-DDD	88		84		30-150	4		20	A
4,4'-DDT	77		87		30-150	13		20	A
Endosulfan I	81		78		30-150	4		20	A
Endosulfan II	84		80		30-150	5		20	A
Endosulfan sulfate	81		78		30-150	4		20	A
Methoxychlor	90		85		30-150	5		20	A
cis-Chlordane	73		61		30-150	17		20	A
trans-Chlordane	93		88		30-150	6		20	A

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST

Project Number: 12461

Lab Number: L2316452

Report Date: 04/12/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Organochlorine Pesticides by GC - Westborough Lab Associated sample(s): 05 Batch: WG1761667-2 WG1761667-3								

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	79		80		30-150	A
Decachlorobiphenyl	81		74		30-150	A
2,4,5,6-Tetrachloro-m-xylene	77		77		30-150	B
Decachlorobiphenyl	66		64		30-150	B

METALS

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-01
Client ID: SB-34 (0.5-1)
Sample Location: WHITEPLAINS, NY
Date Collected: 03/29/23 09:15
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Percent Solids: 90%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	9290		mg/kg	8.63	2.33	2	04/04/23 08:55	04/04/23 18:52	EPA 3050B	1,6010D	AMW
Antimony, Total	ND		mg/kg	4.32	0.328	2	04/04/23 08:55	04/04/23 18:52	EPA 3050B	1,6010D	AMW
Arsenic, Total	2.34		mg/kg	0.863	0.180	2	04/04/23 08:55	04/04/23 18:52	EPA 3050B	1,6010D	AMW
Barium, Total	106		mg/kg	0.863	0.150	2	04/04/23 08:55	04/04/23 18:52	EPA 3050B	1,6010D	AMW
Beryllium, Total	ND		mg/kg	0.432	0.029	2	04/04/23 08:55	04/04/23 18:52	EPA 3050B	1,6010D	AMW
Cadmium, Total	0.166	J	mg/kg	0.863	0.085	2	04/04/23 08:55	04/04/23 18:52	EPA 3050B	1,6010D	AMW
Calcium, Total	6250		mg/kg	8.63	3.02	2	04/04/23 08:55	04/04/23 18:52	EPA 3050B	1,6010D	AMW
Chromium, Total	17.5		mg/kg	0.863	0.083	2	04/04/23 08:55	04/04/23 18:52	EPA 3050B	1,6010D	AMW
Cobalt, Total	7.87		mg/kg	1.73	0.143	2	04/04/23 08:55	04/04/23 18:52	EPA 3050B	1,6010D	AMW
Copper, Total	25.7		mg/kg	0.863	0.223	2	04/04/23 08:55	04/04/23 18:52	EPA 3050B	1,6010D	AMW
Iron, Total	14600		mg/kg	4.32	0.780	2	04/04/23 08:55	04/04/23 18:52	EPA 3050B	1,6010D	AMW
Lead, Total	56.3		mg/kg	4.32	0.231	2	04/04/23 08:55	04/04/23 18:52	EPA 3050B	1,6010D	AMW
Magnesium, Total	6580		mg/kg	8.63	1.33	2	04/04/23 08:55	04/04/23 18:52	EPA 3050B	1,6010D	AMW
Manganese, Total	490		mg/kg	0.863	0.137	2	04/04/23 08:55	04/04/23 18:52	EPA 3050B	1,6010D	AMW
Mercury, Total	0.076		mg/kg	0.071	0.046	1	04/04/23 09:25	04/04/23 13:47	EPA 7471B	1,7471B	ZNK
Nickel, Total	16.0		mg/kg	2.16	0.209	2	04/04/23 08:55	04/04/23 18:52	EPA 3050B	1,6010D	AMW
Potassium, Total	2960		mg/kg	216	12.4	2	04/04/23 08:55	04/04/23 18:52	EPA 3050B	1,6010D	AMW
Selenium, Total	ND		mg/kg	1.73	0.223	2	04/04/23 08:55	04/04/23 18:52	EPA 3050B	1,6010D	AMW
Silver, Total	ND		mg/kg	0.432	0.244	2	04/04/23 08:55	04/04/23 18:52	EPA 3050B	1,6010D	AMW
Sodium, Total	108	J	mg/kg	173	2.72	2	04/04/23 08:55	04/04/23 18:52	EPA 3050B	1,6010D	AMW
Thallium, Total	ND		mg/kg	1.73	0.272	2	04/04/23 08:55	04/04/23 18:52	EPA 3050B	1,6010D	AMW
Vanadium, Total	31.7		mg/kg	0.863	0.175	2	04/04/23 08:55	04/04/23 18:52	EPA 3050B	1,6010D	AMW
Zinc, Total	72.3		mg/kg	4.32	0.253	2	04/04/23 08:55	04/04/23 18:52	EPA 3050B	1,6010D	AMW

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-02
Client ID: SB-33 (2-2.5)
Sample Location: WHITEPLAINS, NY
Date Collected: 03/29/23 08:50
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Percent Solids: 94%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	7290		mg/kg	8.26	2.23	2	04/04/23 08:55	04/04/23 18:57	EPA 3050B	1,6010D	AMW
Antimony, Total	ND		mg/kg	4.13	0.314	2	04/04/23 08:55	04/04/23 18:57	EPA 3050B	1,6010D	AMW
Arsenic, Total	1.99		mg/kg	0.826	0.172	2	04/04/23 08:55	04/04/23 18:57	EPA 3050B	1,6010D	AMW
Barium, Total	76.4		mg/kg	0.826	0.144	2	04/04/23 08:55	04/04/23 18:57	EPA 3050B	1,6010D	AMW
Beryllium, Total	ND		mg/kg	0.413	0.027	2	04/04/23 08:55	04/04/23 18:57	EPA 3050B	1,6010D	AMW
Cadmium, Total	0.101	J	mg/kg	0.826	0.081	2	04/04/23 08:55	04/04/23 18:57	EPA 3050B	1,6010D	AMW
Calcium, Total	13700		mg/kg	8.26	2.89	2	04/04/23 08:55	04/04/23 18:57	EPA 3050B	1,6010D	AMW
Chromium, Total	16.0		mg/kg	0.826	0.079	2	04/04/23 08:55	04/04/23 18:57	EPA 3050B	1,6010D	AMW
Cobalt, Total	6.02		mg/kg	1.65	0.137	2	04/04/23 08:55	04/04/23 18:57	EPA 3050B	1,6010D	AMW
Copper, Total	22.7		mg/kg	0.826	0.213	2	04/04/23 08:55	04/04/23 18:57	EPA 3050B	1,6010D	AMW
Iron, Total	12100		mg/kg	4.13	0.745	2	04/04/23 08:55	04/04/23 18:57	EPA 3050B	1,6010D	AMW
Lead, Total	39.5		mg/kg	4.13	0.221	2	04/04/23 08:55	04/04/23 18:57	EPA 3050B	1,6010D	AMW
Magnesium, Total	6630		mg/kg	8.26	1.27	2	04/04/23 08:55	04/04/23 18:57	EPA 3050B	1,6010D	AMW
Manganese, Total	193		mg/kg	0.826	0.131	2	04/04/23 08:55	04/04/23 18:57	EPA 3050B	1,6010D	AMW
Mercury, Total	0.102		mg/kg	0.067	0.044	1	04/04/23 09:25	04/04/23 13:50	EPA 7471B	1,7471B	ZNK
Nickel, Total	12.7		mg/kg	2.06	0.200	2	04/04/23 08:55	04/04/23 18:57	EPA 3050B	1,6010D	AMW
Potassium, Total	2100		mg/kg	206	11.9	2	04/04/23 08:55	04/04/23 18:57	EPA 3050B	1,6010D	AMW
Selenium, Total	ND		mg/kg	1.65	0.213	2	04/04/23 08:55	04/04/23 18:57	EPA 3050B	1,6010D	AMW
Silver, Total	ND		mg/kg	0.413	0.234	2	04/04/23 08:55	04/04/23 18:57	EPA 3050B	1,6010D	AMW
Sodium, Total	182		mg/kg	165	2.60	2	04/04/23 08:55	04/04/23 18:57	EPA 3050B	1,6010D	AMW
Thallium, Total	0.295	J	mg/kg	1.65	0.260	2	04/04/23 08:55	04/04/23 18:57	EPA 3050B	1,6010D	AMW
Vanadium, Total	22.2		mg/kg	0.826	0.168	2	04/04/23 08:55	04/04/23 18:57	EPA 3050B	1,6010D	AMW
Zinc, Total	64.8		mg/kg	4.13	0.242	2	04/04/23 08:55	04/04/23 18:57	EPA 3050B	1,6010D	AMW

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-03
Client ID: SB-35 (4-4.5)
Sample Location: WHITEPLAINS, NY
Date Collected: 03/29/23 12:30
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Percent Solids: 92%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	4930		mg/kg	8.49	2.29	2	04/04/23 08:55	04/04/23 19:02	EPA 3050B	1,6010D	AMW
Antimony, Total	ND		mg/kg	4.25	0.323	2	04/04/23 08:55	04/04/23 19:02	EPA 3050B	1,6010D	AMW
Arsenic, Total	1.29		mg/kg	0.849	0.177	2	04/04/23 08:55	04/04/23 19:02	EPA 3050B	1,6010D	AMW
Barium, Total	37.7		mg/kg	0.849	0.148	2	04/04/23 08:55	04/04/23 19:02	EPA 3050B	1,6010D	AMW
Beryllium, Total	ND		mg/kg	0.425	0.028	2	04/04/23 08:55	04/04/23 19:02	EPA 3050B	1,6010D	AMW
Cadmium, Total	ND		mg/kg	0.849	0.083	2	04/04/23 08:55	04/04/23 19:02	EPA 3050B	1,6010D	AMW
Calcium, Total	19600		mg/kg	8.49	2.97	2	04/04/23 08:55	04/04/23 19:02	EPA 3050B	1,6010D	AMW
Chromium, Total	10.7		mg/kg	0.849	0.082	2	04/04/23 08:55	04/04/23 19:02	EPA 3050B	1,6010D	AMW
Cobalt, Total	4.93		mg/kg	1.70	0.141	2	04/04/23 08:55	04/04/23 19:02	EPA 3050B	1,6010D	AMW
Copper, Total	12.7		mg/kg	0.849	0.219	2	04/04/23 08:55	04/04/23 19:02	EPA 3050B	1,6010D	AMW
Iron, Total	9570		mg/kg	4.25	0.767	2	04/04/23 08:55	04/04/23 19:02	EPA 3050B	1,6010D	AMW
Lead, Total	6.20		mg/kg	4.25	0.228	2	04/04/23 08:55	04/04/23 19:02	EPA 3050B	1,6010D	AMW
Magnesium, Total	11800		mg/kg	8.49	1.31	2	04/04/23 08:55	04/04/23 19:02	EPA 3050B	1,6010D	AMW
Manganese, Total	157		mg/kg	0.849	0.135	2	04/04/23 08:55	04/04/23 19:02	EPA 3050B	1,6010D	AMW
Mercury, Total	ND		mg/kg	0.069	0.045	1	04/04/23 09:25	04/04/23 13:54	EPA 7471B	1,7471B	ZNK
Nickel, Total	9.63		mg/kg	2.12	0.206	2	04/04/23 08:55	04/04/23 19:02	EPA 3050B	1,6010D	AMW
Potassium, Total	1810		mg/kg	212	12.2	2	04/04/23 08:55	04/04/23 19:02	EPA 3050B	1,6010D	AMW
Selenium, Total	ND		mg/kg	1.70	0.219	2	04/04/23 08:55	04/04/23 19:02	EPA 3050B	1,6010D	AMW
Silver, Total	ND		mg/kg	0.425	0.240	2	04/04/23 08:55	04/04/23 19:02	EPA 3050B	1,6010D	AMW
Sodium, Total	128	J	mg/kg	170	2.68	2	04/04/23 08:55	04/04/23 19:02	EPA 3050B	1,6010D	AMW
Thallium, Total	0.357	J	mg/kg	1.70	0.268	2	04/04/23 08:55	04/04/23 19:02	EPA 3050B	1,6010D	AMW
Vanadium, Total	14.9		mg/kg	0.849	0.172	2	04/04/23 08:55	04/04/23 19:02	EPA 3050B	1,6010D	AMW
Zinc, Total	30.0		mg/kg	4.25	0.249	2	04/04/23 08:55	04/04/23 19:02	EPA 3050B	1,6010D	AMW

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-04
Client ID: SB-36 (1-1.5)
Sample Location: WHITEPLAINS, NY
Date Collected: 03/29/23 13:00
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Percent Solids: 85%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	5630		mg/kg	9.07	2.45	2	04/04/23 08:55	04/04/23 19:07	EPA 3050B	1,6010D	AMW
Antimony, Total	ND		mg/kg	4.54	0.345	2	04/04/23 08:55	04/04/23 19:07	EPA 3050B	1,6010D	AMW
Arsenic, Total	1.15		mg/kg	0.907	0.189	2	04/04/23 08:55	04/04/23 19:07	EPA 3050B	1,6010D	AMW
Barium, Total	47.5		mg/kg	0.907	0.158	2	04/04/23 08:55	04/04/23 19:07	EPA 3050B	1,6010D	AMW
Beryllium, Total	ND		mg/kg	0.454	0.030	2	04/04/23 08:55	04/04/23 19:07	EPA 3050B	1,6010D	AMW
Cadmium, Total	0.172	J	mg/kg	0.907	0.089	2	04/04/23 08:55	04/04/23 19:07	EPA 3050B	1,6010D	AMW
Calcium, Total	18600		mg/kg	9.07	3.17	2	04/04/23 08:55	04/04/23 19:07	EPA 3050B	1,6010D	AMW
Chromium, Total	11.4		mg/kg	0.907	0.087	2	04/04/23 08:55	04/04/23 19:07	EPA 3050B	1,6010D	AMW
Cobalt, Total	5.59		mg/kg	1.81	0.150	2	04/04/23 08:55	04/04/23 19:07	EPA 3050B	1,6010D	AMW
Copper, Total	16.0		mg/kg	0.907	0.234	2	04/04/23 08:55	04/04/23 19:07	EPA 3050B	1,6010D	AMW
Iron, Total	10500		mg/kg	4.54	0.819	2	04/04/23 08:55	04/04/23 19:07	EPA 3050B	1,6010D	AMW
Lead, Total	14.5		mg/kg	4.54	0.243	2	04/04/23 08:55	04/04/23 19:07	EPA 3050B	1,6010D	AMW
Magnesium, Total	12100		mg/kg	9.07	1.40	2	04/04/23 08:55	04/04/23 19:07	EPA 3050B	1,6010D	AMW
Manganese, Total	174		mg/kg	0.907	0.144	2	04/04/23 08:55	04/04/23 19:07	EPA 3050B	1,6010D	AMW
Mercury, Total	0.064	J	mg/kg	0.076	0.049	1	04/04/23 09:25	04/04/23 13:57	EPA 7471B	1,7471B	ZNK
Nickel, Total	10.5		mg/kg	2.27	0.220	2	04/04/23 08:55	04/04/23 19:07	EPA 3050B	1,6010D	AMW
Potassium, Total	1960		mg/kg	227	13.1	2	04/04/23 08:55	04/04/23 19:07	EPA 3050B	1,6010D	AMW
Selenium, Total	ND		mg/kg	1.81	0.234	2	04/04/23 08:55	04/04/23 19:07	EPA 3050B	1,6010D	AMW
Silver, Total	ND		mg/kg	0.454	0.257	2	04/04/23 08:55	04/04/23 19:07	EPA 3050B	1,6010D	AMW
Sodium, Total	111	J	mg/kg	181	2.86	2	04/04/23 08:55	04/04/23 19:07	EPA 3050B	1,6010D	AMW
Thallium, Total	0.349	J	mg/kg	1.81	0.286	2	04/04/23 08:55	04/04/23 19:07	EPA 3050B	1,6010D	AMW
Vanadium, Total	17.5		mg/kg	0.907	0.184	2	04/04/23 08:55	04/04/23 19:07	EPA 3050B	1,6010D	AMW
Zinc, Total	40.2		mg/kg	4.54	0.266	2	04/04/23 08:55	04/04/23 19:07	EPA 3050B	1,6010D	AMW

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-05
Client ID: GW-2
Sample Location: WHITEPLAINS, NY
Date Collected: 03/29/23 12:00
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	44.4		mg/l	0.100	0.0327	10	03/30/23 23:37	04/03/23 22:18	EPA 3005A	1,6020B	WKP
Antimony, Total	0.00550	J	mg/l	0.04000	0.00429	10	03/30/23 23:37	04/03/23 22:18	EPA 3005A	1,6020B	WKP
Arsenic, Total	0.01650		mg/l	0.00500	0.00165	10	03/30/23 23:37	04/03/23 22:18	EPA 3005A	1,6020B	WKP
Barium, Total	1.182		mg/l	0.00500	0.00173	10	03/30/23 23:37	04/03/23 22:18	EPA 3005A	1,6020B	WKP
Beryllium, Total	0.00206	J	mg/l	0.00500	0.00107	10	03/30/23 23:37	04/03/23 22:18	EPA 3005A	1,6020B	WKP
Cadmium, Total	0.00133	J	mg/l	0.00200	0.00059	10	03/30/23 23:37	04/03/23 22:18	EPA 3005A	1,6020B	WKP
Calcium, Total	430.		mg/l	1.00	0.394	10	03/30/23 23:37	04/03/23 22:18	EPA 3005A	1,6020B	WKP
Chromium, Total	0.3033		mg/l	0.01000	0.00178	10	03/30/23 23:37	04/03/23 22:18	EPA 3005A	1,6020B	WKP
Cobalt, Total	0.1018		mg/l	0.00500	0.00163	10	03/30/23 23:37	04/03/23 22:18	EPA 3005A	1,6020B	WKP
Copper, Total	0.2925		mg/l	0.01000	0.00384	10	03/30/23 23:37	04/03/23 22:18	EPA 3005A	1,6020B	WKP
Iron, Total	102.		mg/l	0.500	0.191	10	03/30/23 23:37	04/03/23 22:18	EPA 3005A	1,6020B	WKP
Lead, Total	0.2583		mg/l	0.01000	0.00343	10	03/30/23 23:37	04/03/23 22:18	EPA 3005A	1,6020B	WKP
Magnesium, Total	156.		mg/l	0.700	0.242	10	03/30/23 23:37	04/03/23 22:18	EPA 3005A	1,6020B	WKP
Manganese, Total	4.715		mg/l	0.01000	0.00440	10	03/30/23 23:37	04/03/23 22:18	EPA 3005A	1,6020B	WKP
Mercury, Total	0.00023		mg/l	0.00020	0.00009	1	04/03/23 11:56	04/03/23 20:37	EPA 7470A	1,7470A	ZNK
Nickel, Total	0.1448		mg/l	0.02000	0.00556	10	03/30/23 23:37	04/03/23 22:18	EPA 3005A	1,6020B	WKP
Potassium, Total	28.9		mg/l	1.00	0.309	10	03/30/23 23:37	04/03/23 22:18	EPA 3005A	1,6020B	WKP
Selenium, Total	0.0379	J	mg/l	0.0500	0.0173	10	03/30/23 23:37	04/03/23 22:18	EPA 3005A	1,6020B	WKP
Silver, Total	ND		mg/l	0.00400	0.00163	10	03/30/23 23:37	04/03/23 22:18	EPA 3005A	1,6020B	WKP
Sodium, Total	465.		mg/l	1.00	0.293	10	03/30/23 23:37	04/03/23 22:18	EPA 3005A	1,6020B	WKP
Thallium, Total	ND		mg/l	0.01000	0.00143	10	03/30/23 23:37	04/03/23 22:18	EPA 3005A	1,6020B	WKP
Vanadium, Total	0.1101		mg/l	0.05000	0.01570	10	03/30/23 23:37	04/03/23 22:18	EPA 3005A	1,6020B	WKP
Zinc, Total	0.4362		mg/l	0.1000	0.03410	10	03/30/23 23:37	04/03/23 22:18	EPA 3005A	1,6020B	WKP

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

Method Blank Analysis
Batch Quality Control

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
Total Metals - Mansfield Lab for sample(s): 05 Batch: WG1760668-1										
Aluminum, Total	ND		mg/l	0.0100	0.00327	1	03/30/23 23:37	03/31/23 13:52	1,6020B	NTB
Antimony, Total	ND		mg/l	0.00400	0.00042	1	03/30/23 23:37	03/31/23 13:52	1,6020B	NTB
Arsenic, Total	ND		mg/l	0.00050	0.00016	1	03/30/23 23:37	03/31/23 13:52	1,6020B	NTB
Barium, Total	ND		mg/l	0.00050	0.00017	1	03/30/23 23:37	03/31/23 13:52	1,6020B	NTB
Beryllium, Total	ND		mg/l	0.00050	0.00010	1	03/30/23 23:37	03/31/23 13:52	1,6020B	NTB
Cadmium, Total	ND		mg/l	0.00020	0.00005	1	03/30/23 23:37	03/31/23 13:52	1,6020B	NTB
Calcium, Total	ND		mg/l	0.100	0.0394	1	03/30/23 23:37	03/31/23 13:52	1,6020B	NTB
Chromium, Total	ND		mg/l	0.00100	0.00017	1	03/30/23 23:37	03/31/23 13:52	1,6020B	NTB
Cobalt, Total	ND		mg/l	0.00050	0.00016	1	03/30/23 23:37	03/31/23 13:52	1,6020B	NTB
Copper, Total	ND		mg/l	0.00100	0.00038	1	03/30/23 23:37	03/31/23 13:52	1,6020B	NTB
Iron, Total	ND		mg/l	0.0500	0.0191	1	03/30/23 23:37	03/31/23 13:52	1,6020B	NTB
Lead, Total	ND		mg/l	0.00100	0.00034	1	03/30/23 23:37	03/31/23 13:52	1,6020B	NTB
Magnesium, Total	ND		mg/l	0.0700	0.0242	1	03/30/23 23:37	03/31/23 13:52	1,6020B	NTB
Manganese, Total	ND		mg/l	0.00100	0.00044	1	03/30/23 23:37	03/31/23 13:52	1,6020B	NTB
Nickel, Total	ND		mg/l	0.00200	0.00055	1	03/30/23 23:37	03/31/23 13:52	1,6020B	NTB
Potassium, Total	ND		mg/l	0.100	0.0309	1	03/30/23 23:37	03/31/23 13:52	1,6020B	NTB
Selenium, Total	ND		mg/l	0.00500	0.00173	1	03/30/23 23:37	03/31/23 13:52	1,6020B	NTB
Silver, Total	ND		mg/l	0.00040	0.00016	1	03/30/23 23:37	03/31/23 13:52	1,6020B	NTB
Sodium, Total	ND		mg/l	0.100	0.0293	1	03/30/23 23:37	03/31/23 13:52	1,6020B	NTB
Thallium, Total	ND		mg/l	0.00100	0.00014	1	03/30/23 23:37	03/31/23 13:52	1,6020B	NTB
Vanadium, Total	ND		mg/l	0.00500	0.00157	1	03/30/23 23:37	03/31/23 13:52	1,6020B	NTB
Zinc, Total	ND		mg/l	0.01000	0.00341	1	03/30/23 23:37	03/31/23 13:52	1,6020B	NTB

Prep Information

Digestion Method: EPA 3005A

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
Total Metals - Mansfield Lab for sample(s): 01-04 Batch: WG1760797-1										
Aluminum, Total	ND		mg/kg	4.00	1.08	1	04/04/23 08:55	04/04/23 15:40	1,6010D	AMW
Antimony, Total	ND		mg/kg	2.00	0.152	1	04/04/23 08:55	04/04/23 11:07	1,6010D	JMF
Arsenic, Total	ND		mg/kg	0.400	0.083	1	04/04/23 08:55	04/04/23 11:07	1,6010D	JMF

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

Method Blank Analysis
Batch Quality Control

Barium, Total	ND		mg/kg	0.400	0.070	1	04/04/23 08:55	04/04/23 15:40	1,6010D	AMW
Beryllium, Total	ND		mg/kg	0.200	0.013	1	04/04/23 08:55	04/04/23 15:40	1,6010D	AMW
Cadmium, Total	ND		mg/kg	0.400	0.039	1	04/04/23 08:55	04/04/23 15:40	1,6010D	AMW
Calcium, Total	2.24	J	mg/kg	4.00	1.40	1	04/04/23 08:55	04/04/23 15:40	1,6010D	AMW
Chromium, Total	ND		mg/kg	0.400	0.038	1	04/04/23 08:55	04/04/23 15:40	1,6010D	AMW
Cobalt, Total	ND		mg/kg	0.800	0.066	1	04/04/23 08:55	04/04/23 15:40	1,6010D	AMW
Copper, Total	ND		mg/kg	0.400	0.103	1	04/04/23 08:55	04/04/23 15:40	1,6010D	AMW
Iron, Total	4.40		mg/kg	2.00	0.361	1	04/04/23 08:55	04/04/23 15:40	1,6010D	AMW
Lead, Total	ND		mg/kg	2.00	0.107	1	04/04/23 08:55	04/04/23 11:07	1,6010D	JMF
Magnesium, Total	ND		mg/kg	4.00	0.616	1	04/04/23 08:55	04/04/23 15:40	1,6010D	AMW
Manganese, Total	ND		mg/kg	0.400	0.064	1	04/04/23 08:55	04/04/23 15:40	1,6010D	AMW
Nickel, Total	ND		mg/kg	1.00	0.097	1	04/04/23 08:55	04/04/23 15:40	1,6010D	AMW
Potassium, Total	ND		mg/kg	100	5.76	1	04/04/23 08:55	04/04/23 15:40	1,6010D	AMW
Selenium, Total	ND		mg/kg	0.800	0.103	1	04/04/23 08:55	04/04/23 15:40	1,6010D	AMW
Silver, Total	ND		mg/kg	0.200	0.113	1	04/04/23 08:55	04/04/23 15:40	1,6010D	AMW
Sodium, Total	ND		mg/kg	80.0	1.26	1	04/04/23 08:55	04/04/23 15:40	1,6010D	AMW
Thallium, Total	ND		mg/kg	0.800	0.126	1	04/04/23 08:55	04/04/23 15:40	1,6010D	AMW
Vanadium, Total	ND		mg/kg	0.400	0.081	1	04/04/23 08:55	04/04/23 15:40	1,6010D	AMW
Zinc, Total	0.127	J	mg/kg	2.00	0.117	1	04/04/23 08:55	04/04/23 15:40	1,6010D	AMW

Prep Information

Digestion Method: EPA 3050B

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
Total Metals - Mansfield Lab for sample(s): 01-04 Batch: WG1760798-1										
Mercury, Total	ND		mg/kg	0.083	0.054	1	04/04/23 09:25	04/04/23 12:14	1,7471B	ZNK

Prep Information

Digestion Method: EPA 7471B

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

Method Blank Analysis
Batch Quality Control

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
Total Metals - Mansfield Lab for sample(s): 05 Batch: WG1761386-1										
Mercury, Total	ND		mg/l	0.00020	0.00009	1	04/03/23 11:56	04/03/23 19:34	1,7470A	ZNK

Prep Information

Digestion Method: EPA 7470A

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST

Project Number: 12461

Lab Number: L2316452

Report Date: 04/12/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 05 Batch: WG1760668-2								
Aluminum, Total	91		-		80-120	-		
Antimony, Total	90		-		80-120	-		
Arsenic, Total	101		-		80-120	-		
Barium, Total	96		-		80-120	-		
Beryllium, Total	99		-		80-120	-		
Cadmium, Total	99		-		80-120	-		
Calcium, Total	82		-		80-120	-		
Chromium, Total	95		-		80-120	-		
Cobalt, Total	97		-		80-120	-		
Copper, Total	99		-		80-120	-		
Iron, Total	100		-		80-120	-		
Lead, Total	99		-		80-120	-		
Magnesium, Total	91		-		80-120	-		
Manganese, Total	96		-		80-120	-		
Nickel, Total	98		-		80-120	-		
Potassium, Total	89		-		80-120	-		
Selenium, Total	97		-		80-120	-		
Silver, Total	101		-		80-120	-		
Sodium, Total	93		-		80-120	-		
Thallium, Total	110		-		80-120	-		
Vanadium, Total	92		-		80-120	-		

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST

Project Number: 12461

Lab Number: L2316452

Report Date: 04/12/23

Parameter	LCS %Recovery	LCSD %Recovery	%Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 05 Batch: WG1760668-2					
Zinc, Total	93	-	80-120	-	

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST

Project Number: 12461

Lab Number: L2316452

Report Date: 04/12/23

Parameter	LCS %Recovery	LCSD %Recovery	%Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-04 Batch: WG1760797-2 SRM Lot Number: D116-540					
Aluminum, Total	78	-	45-155	-	
Antimony, Total	163	-	2-205	-	
Arsenic, Total	98	-	82-119	-	
Barium, Total	91	-	82-118	-	
Beryllium, Total	98	-	82-118	-	
Cadmium, Total	100	-	82-118	-	
Calcium, Total	92	-	81-119	-	
Chromium, Total	98	-	81-118	-	
Cobalt, Total	100	-	83-117	-	
Copper, Total	100	-	83-117	-	
Iron, Total	102	-	58-142	-	
Lead, Total	96	-	83-117	-	
Magnesium, Total	93	-	75-125	-	
Manganese, Total	96	-	82-118	-	
Nickel, Total	100	-	82-118	-	
Potassium, Total	89	-	68-131	-	
Selenium, Total	107	-	78-122	-	
Silver, Total	101	-	79-121	-	
Sodium, Total	99	-	71-130	-	
Thallium, Total	103	-	80-120	-	
Vanadium, Total	98	-	78-122	-	

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST

Project Number: 12461

Lab Number: L2316452

Report Date: 04/12/23

Parameter	LCS %Recovery	LCSD %Recovery	%Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-04 Batch: WG1760797-2 SRM Lot Number: D116-540					
Zinc, Total	102	-	80-120	-	
Total Metals - Mansfield Lab Associated sample(s): 01-04 Batch: WG1760798-2 SRM Lot Number: D116-540					
Mercury, Total	82	-	58-142	-	
Total Metals - Mansfield Lab Associated sample(s): 05 Batch: WG1761386-2					
Mercury, Total	99	-	80-120	-	

Matrix Spike Analysis
Batch Quality Control

Project Name: 100 MAIN ST
Project Number: 12461

Lab Number: L2316452
Report Date: 04/12/23

Parameter	Native Sample	MS Added	MS Found	MS %Recovery	Qual	MSD Found	MSD %Recovery	Qual	Recovery Limits	RPD	Qual	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 05 QC Batch ID: WG1760668-3 WG1760668-4 QC Sample: L2316019-03 Client ID: MS Sample												
Aluminum, Total	0.009J	2	1.80	90		1.63	82		75-125	10		20
Antimony, Total	0.0006J	0.5	0.4292	86		0.4017	80		75-125	7		20
Arsenic, Total	0.00040J	0.12	0.1262	105		0.1141	95		75-125	10		20
Barium, Total	0.00590	2	1.910	95		1.768	88		75-125	8		20
Beryllium, Total	ND	0.05	0.04996	100		0.04479	90		75-125	11		20
Cadmium, Total	ND	0.053	0.05244	99		0.04817	91		75-125	8		20
Calcium, Total	498	10	512	**140**	Q	467	**0**	Q	75-125	9		20
Chromium, Total	ND	0.2	0.1898	95		0.1732	87		75-125	9		20
Cobalt, Total	ND	0.5	0.4744	95		0.4361	87		75-125	8		20
Copper, Total	ND	0.25	0.2464	98		0.2199	88		75-125	11		20
Iron, Total	0.750	1	1.70	95		1.57	82		75-125	8		20
Lead, Total	ND	0.53	0.5367	101		0.4929	93		75-125	9		20
Magnesium, Total	42.9	10	50.0	**71**	Q	45.8	**29**	Q	75-125	9		20
Manganese, Total	0.03339	0.5	0.5123	96		0.4711	88		75-125	8		20
Nickel, Total	ND	0.5	0.4823	96		0.4390	88		75-125	9		20
Potassium, Total	1.87	10	10.6	87		9.49	76		75-125	11		20
Selenium, Total	ND	0.12	0.123	102		0.111	92		75-125	10		20
Silver, Total	ND	0.05	0.04935	99		0.04525	90		75-125	9		20
Sodium, Total	11.2	10	18.8	76		17.1	**59**	Q	75-125	9		20
Thallium, Total	0.0002J	0.12	0.1290	108		0.1181	98		75-125	9		20
Vanadium, Total	ND	0.5	0.4644	93		0.4220	84		75-125	10		20

Matrix Spike Analysis
Batch Quality Control

Project Name: 100 MAIN ST
Project Number: 12461

Lab Number: L2316452
Report Date: 04/12/23

Parameter	Native Sample	MS Added	MS Found	MS %Recovery	MSD Found	MSD %Recovery	Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 05 QC Batch ID: WG1760668-3 WG1760668-4 QC Sample: L2316019-03 Client ID: MS Sample									
Zinc, Total	0.0095J	0.5	0.4692	94	0.4252	85	75-125	10	20

Matrix Spike Analysis
Batch Quality Control

Project Name: 100 MAIN ST
Project Number: 12461

Lab Number: L2316452
Report Date: 04/12/23

Parameter	Native Sample	MS Added	MS Found	MS %Recovery		MSD Found	MSD %Recovery	Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-04 QC Batch ID: WG1760797-3 QC Sample: L2317323-01 Client ID: MS Sample										
Aluminum, Total	6640	189	6720	**42**	Q	-	-	75-125	-	20
Antimony, Total	0.838J	47.3	40.7	86		-	-	75-125	-	20
Arsenic, Total	4.52	11.4	14.4	87		-	-	75-125	-	20
Barium, Total	31.9	189	200	89		-	-	75-125	-	20
Beryllium, Total	0.408	4.73	4.77	92		-	-	75-125	-	20
Cadmium, Total	0.148J	5.01	4.33	86		-	-	75-125	-	20
Calcium, Total	350	946	1250	95		-	-	75-125	-	20
Chromium, Total	13.2	18.9	27.5	76		-	-	75-125	-	20
Cobalt, Total	4.89	47.3	43.6	82		-	-	75-125	-	20
Copper, Total	22.0	23.6	39.4	**74**	Q	-	-	75-125	-	20
Iron, Total	18700	94.6	14500	**0**	Q	-	-	75-125	-	20
Lead, Total	13.5	50.1	53.8	80		-	-	75-125	-	20
Magnesium, Total	1850	946	2490	**68**	Q	-	-	75-125	-	20
Manganese, Total	144	47.3	172	**59**	Q	-	-	75-125	-	20
Nickel, Total	9.76	47.3	45.8	76		-	-	75-125	-	20
Potassium, Total	512	946	1290	82		-	-	75-125	-	20
Selenium, Total	ND	11.4	9.59	84		-	-	75-125	-	20
Silver, Total	0.187J	4.73	4.60	97		-	-	75-125	-	20
Sodium, Total	69.7J	946	946	100		-	-	75-125	-	20
Thallium, Total	ND	11.4	8.46	**74**	Q	-	-	75-125	-	20
Vanadium, Total	16.2	47.3	61.8	96		-	-	75-125	-	20

Matrix Spike Analysis
Batch Quality Control

Project Name: 100 MAIN ST
Project Number: 12461

Lab Number: L2316452
Report Date: 04/12/23

Parameter	Native Sample	MS Added	MS Found	MS %Recovery		MSD Found	MSD %Recovery	Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-04 QC Batch ID: WG1760797-3 QC Sample: L2317323-01 Client ID: MS Sample										
Zinc, Total	80.1	47.3	141	**129**	Q	-	-	75-125	-	20
Total Metals - Mansfield Lab Associated sample(s): 01-04 QC Batch ID: WG1760798-3 QC Sample: L2317323-01 Client ID: MS Sample										
Mercury, Total	1.10	1.58	2.68	100		-	-	80-120	-	20
Total Metals - Mansfield Lab Associated sample(s): 05 QC Batch ID: WG1761386-3 QC Sample: L2316682-07 Client ID: MS Sample										
Mercury, Total	ND	0.005	0.00492	98		-	-	75-125	-	20

Lab Duplicate Analysis
Batch Quality Control

Project Name: 100 MAIN ST
Project Number: 12461

Lab Number: L2316452
Report Date: 04/12/23

Parameter	Native Sample	Duplicate Sample	Units	RPD	Qual	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-04 QC Batch ID: WG1760797-4 QC Sample: L2317323-01 Client ID: DUP Sample						
Antimony, Total	0.838J	0.539J	mg/kg	NC		20
Arsenic, Total	4.52	5.60	mg/kg	**21**	Q	20
Total Metals - Mansfield Lab Associated sample(s): 01-04 QC Batch ID: WG1760798-4 QC Sample: L2317323-01 Client ID: DUP Sample						
Mercury, Total	1.10	1.73	mg/kg	**45**	Q	20
Total Metals - Mansfield Lab Associated sample(s): 05 QC Batch ID: WG1761386-4 QC Sample: L2316682-07 Client ID: DUP Sample						
Mercury, Total	ND	0.00011J	mg/l	NC		20

INORGANICS
&
MISCELLANEOUS

Project Name: 100 MAIN ST
Project Number: 12461

Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-01
Client ID: SB-34 (0.5-1)
Sample Location: WHITEPLAINS, NY

Date Collected: 03/29/23 09:15
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Solids, Total	90.2		%	0.100	NA	1	-	03/30/23 11:40	121,2540G	ROI
Cyanide, Total	ND		mg/kg	1.0	0.22	1	04/04/23 11:40	04/05/23 08:49	1,9010C/9012B	JER

Project Name: 100 MAIN ST
Project Number: 12461

Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-02
Client ID: SB-33 (2-2.5)
Sample Location: WHITEPLAINS, NY

Date Collected: 03/29/23 08:50
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Solids, Total	93.9		%	0.100	NA	1	-	03/30/23 11:40	121,2540G	ROI
Cyanide, Total	ND		mg/kg	1.0	0.21	1	04/04/23 11:40	04/05/23 09:14	1,9010C/9012B	JER

Project Name: 100 MAIN ST
Project Number: 12461

Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-03
Client ID: SB-35 (4-4.5)
Sample Location: WHITEPLAINS, NY

Date Collected: 03/29/23 12:30
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Solids, Total	92.4		%	0.100	NA	1	-	03/30/23 11:40	121,2540G	ROI
Cyanide, Total	ND		mg/kg	1.0	0.21	1	04/04/23 11:40	04/05/23 09:15	1,9010C/9012B	JER

Project Name: 100 MAIN ST
Project Number: 12461

Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-04
Client ID: SB-36 (1-1.5)
Sample Location: WHITEPLAINS, NY

Date Collected: 03/29/23 13:00
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Solids, Total	85.2		%	0.100	NA	1	-	03/30/23 11:40	121,2540G	ROI
Cyanide, Total	ND		mg/kg	1.1	0.24	1	04/04/23 11:40	04/05/23 09:16	1,9010C/9012B	JER

Project Name: 100 MAIN ST
Project Number: 12461

Lab Number: L2316452
Report Date: 04/12/23

SAMPLE RESULTS

Lab ID: L2316452-05
Client ID: GW-2
Sample Location: WHITEPLAINS, NY

Date Collected: 03/29/23 12:00
Date Received: 03/29/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Cyanide, Total	0.003	J	mg/l	0.005	0.001	1	04/03/23 06:50	04/03/23 15:45	1,9010C/9012B	JER

Project Name: 100 MAIN ST
Project Number: 12461
Lab Number: L2316452
Report Date: 04/12/23

Method Blank Analysis
Batch Quality Control

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab for sample(s): 05 Batch: WG1761845-1										
Cyanide, Total	ND		mg/l	0.005	0.001	1	04/03/23 06:50	04/03/23 15:27	1,9010C/9012B	JER
General Chemistry - Westborough Lab for sample(s): 01-04 Batch: WG1762401-1										
Cyanide, Total	ND		mg/kg	0.95	0.20	1	04/04/23 11:40	04/05/23 08:30	1,9010C/9012B	JER

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST

Project Number: 12461

Lab Number: L2316452

Report Date: 04/12/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
General Chemistry - Westborough Lab Associated sample(s): 05 Batch: WG1761845-2 WG1761845-3								
Cyanide, Total	104		110		85-115	6		20
General Chemistry - Westborough Lab Associated sample(s): 01-04 Batch: WG1762401-2 WG1762401-3								
Cyanide, Total	100		87		80-120	14		35

Matrix Spike Analysis
Batch Quality Control

Project Name: 100 MAIN ST
Project Number: 12461

Lab Number: L2316452
Report Date: 04/12/23

Parameter	Native Sample	MS Added	MS Found	MS %Recovery	Qual	MSD Found	MSD %Recovery	Qual	Recovery Limits	RPD	Qual	RPD Limits
General Chemistry - Westborough Lab Associated sample(s): 05 QC Batch ID: WG1761845-4 WG1761845-5 QC Sample: L2314807-01 Client ID: MS Sample												
Cyanide, Total	ND	0.2	0.226	113		0.218	109		80-120	4		20
General Chemistry - Westborough Lab Associated sample(s): 01-04 QC Batch ID: WG1762401-4 WG1762401-5 QC Sample: L2316548-07 Client ID: MS Sample												
Cyanide, Total	ND	10	10	100		10	101		75-125	1		35

Lab Duplicate Analysis

Batch Quality Control

Project Name: 100 MAIN ST

Project Number: 12461

Lab Number: L2316452

Report Date: 04/12/23

Parameter	Native Sample	Duplicate Sample	Units	RPD	Qual	RPD Limits
General Chemistry - Westborough Lab Associated sample(s): 01-04 QC Batch ID: WG1760627-1 QC Sample: L2316297-01 Client ID: DUP Sample						
Solids, Total	95.7	94.4	%	1		20

Project Name: 100 MAIN ST
Project Number: 12461

Lab Number: L2316452
Report Date: 04/12/23

Sample Receipt and Container Information

Were project specific reporting limits specified? YES

Cooler Information

Cooler	Custody Seal
A	Absent

Container Information

Container ID	Container Type	Cooler	Initial pH	Final pH	Temp deg C	Pres	Seal	Frozen Date/Time	Analysis(*)
L2316452-01A	5 gram Encore Sampler	A	NA		2.7	Y	Absent		NYTCL-8260HLW(14)
L2316452-01B	5 gram Encore Sampler	A	NA		2.7	Y	Absent		NYTCL-8260HLW(14)
L2316452-01C	5 gram Encore Sampler	A	NA		2.7	Y	Absent		NYTCL-8260HLW(14)
L2316452-01D	Metals Only-Glass 60mL/2oz unpreserved	A	NA		2.7	Y	Absent		BE-TI(180),BA-TI(180),AS-TI(180),AG-TI(180),TL-TI(180),AL-TI(180),NI-TI(180),CR-TI(180),PB-TI(180),CU-TI(180),SB-TI(180),SE-TI(180),ZN-TI(180),V-TI(180),CO-TI(180),MN-TI(180),FE-TI(180),HG-T(28),MG-TI(180),CD-TI(180),CA-TI(180),K-TI(180),NA-TI(180)
L2316452-01E	Plastic 2oz unpreserved for TS	A	NA		2.7	Y	Absent		TS(7)
L2316452-01F	Glass 250ml/8oz unpreserved	A	NA		2.7	Y	Absent		NYTCL-8270(14),TCN-9010(14),NYTCL-8081(14),NYTCL-8082(365)
L2316452-01X	Vial MeOH preserved split	A	NA		2.7	Y	Absent		NYTCL-8260HLW(14)
L2316452-01Y	Vial Water preserved split	A	NA		2.7	Y	Absent	30-MAR-23 06:52	NYTCL-8260HLW(14)
L2316452-01Z	Vial Water preserved split	A	NA		2.7	Y	Absent	30-MAR-23 06:52	NYTCL-8260HLW(14)
L2316452-02A	5 gram Encore Sampler	A	NA		2.7	Y	Absent		NYTCL-8260HLW(14)
L2316452-02B	5 gram Encore Sampler	A	NA		2.7	Y	Absent		NYTCL-8260HLW(14)
L2316452-02C	5 gram Encore Sampler	A	NA		2.7	Y	Absent		NYTCL-8260HLW(14)
L2316452-02D	Metals Only-Glass 60mL/2oz unpreserved	A	NA		2.7	Y	Absent		BE-TI(180),AS-TI(180),BA-TI(180),AG-TI(180),NI-TI(180),AL-TI(180),TL-TI(180),CR-TI(180),CU-TI(180),ZN-TI(180),PB-TI(180),SB-TI(180),SE-TI(180),V-TI(180),CO-TI(180),FE-TI(180),HG-T(28),MG-TI(180),MN-TI(180),CA-TI(180),NA-TI(180),CD-TI(180),K-TI(180)
L2316452-02E	Plastic 2oz unpreserved for TS	A	NA		2.7	Y	Absent		TS(7)
L2316452-02F	Glass 250ml/8oz unpreserved	A	NA		2.7	Y	Absent		NYTCL-8270(14),TCN-9010(14),NYTCL-8081(14),NYTCL-8082(365)
L2316452-02X	Vial MeOH preserved split	A	NA		2.7	Y	Absent		NYTCL-8260HLW(14)
L2316452-02Y	Vial Water preserved split	A	NA		2.7	Y	Absent	30-MAR-23 06:52	NYTCL-8260HLW(14)

*Values in parentheses indicate holding time in days

Container Information

Container ID	Container Type	Cooler	Initial pH	Final pH	Temp deg C	Pres	Seal	Frozen Date/Time	Analysis(*)
L2316452-02Z	Vial Water preserved split	A	NA		2.7	Y	Absent	30-MAR-23 06:52	NYTCL-8260HLW(14)
L2316452-03A	5 gram Encore Sampler	A	NA		2.7	Y	Absent		NYTCL-8260HLW(14)
L2316452-03B	5 gram Encore Sampler	A	NA		2.7	Y	Absent		NYTCL-8260HLW(14)
L2316452-03C	5 gram Encore Sampler	A	NA		2.7	Y	Absent		NYTCL-8260HLW(14)
L2316452-03D	Metals Only-Glass 60mL/2oz unpreserved	A	NA		2.7	Y	Absent		BE-TI(180),AS-TI(180),BA-TI(180),AG-TI(180),TL-TI(180),CR-TI(180),AL-TI(180),NI-TI(180),CU-TI(180),PB-TI(180),SE-TI(180),SB-TI(180),ZN-TI(180),CO-TI(180),V-TI(180),FE-TI(180),MG-TI(180),MN-TI(180),HG-T(28),CD-TI(180),K-TI(180),NA-TI(180),CA-TI(180)
L2316452-03E	Plastic 2oz unpreserved for TS	A	NA		2.7	Y	Absent		TS(7)
L2316452-03F	Glass 250ml/8oz unpreserved	A	NA		2.7	Y	Absent		TCN-9010(14),NYTCL-8270(14),NYTCL-8081(14),NYTCL-8082(365)
L2316452-03X	Vial MeOH preserved split	A	NA		2.7	Y	Absent		NYTCL-8260HLW(14)
L2316452-03Y	Vial Water preserved split	A	NA		2.7	Y	Absent	30-MAR-23 06:52	NYTCL-8260HLW(14)
L2316452-03Z	Vial Water preserved split	A	NA		2.7	Y	Absent	30-MAR-23 06:52	NYTCL-8260HLW(14)
L2316452-04A	5 gram Encore Sampler	A	NA		2.7	Y	Absent		NYTCL-8260HLW(14)
L2316452-04B	5 gram Encore Sampler	A	NA		2.7	Y	Absent		NYTCL-8260HLW(14)
L2316452-04C	5 gram Encore Sampler	A	NA		2.7	Y	Absent		NYTCL-8260HLW(14)
L2316452-04D	Metals Only-Glass 60mL/2oz unpreserved	A	NA		2.7	Y	Absent		BE-TI(180),AS-TI(180),BA-TI(180),AG-TI(180),AL-TI(180),TL-TI(180),CR-TI(180),NI-TI(180),PB-TI(180),CU-TI(180),SB-TI(180),SE-TI(180),ZN-TI(180),V-TI(180),CO-TI(180),HG-T(28),FE-TI(180),MN-TI(180),MG-TI(180),NA-TI(180),K-TI(180),CA-TI(180),CD-TI(180)
L2316452-04E	Plastic 2oz unpreserved for TS	A	NA		2.7	Y	Absent		TS(7)
L2316452-04F	Glass 250ml/8oz unpreserved	A	NA		2.7	Y	Absent		NYTCL-8270(14),TCN-9010(14),NYTCL-8081(14),NYTCL-8082(365)
L2316452-04X	Vial MeOH preserved split	A	NA		2.7	Y	Absent		NYTCL-8260HLW(14)
L2316452-04Y	Vial Water preserved split	A	NA		2.7	Y	Absent	30-MAR-23 06:52	NYTCL-8260HLW(14)
L2316452-04Z	Vial Water preserved split	A	NA		2.7	Y	Absent	30-MAR-23 06:52	NYTCL-8260HLW(14)
L2316452-05A	Vial HCl preserved	A	NA		2.7	Y	Absent		NYTCL-8260(14)
L2316452-05B	Vial HCl preserved	A	NA		2.7	Y	Absent		NYTCL-8260(14)
L2316452-05C	Vial HCl preserved	A	NA		2.7	Y	Absent		NYTCL-8260(14)
L2316452-05D	Amber 120ml unpreserved	A	7	7	2.7	Y	Absent		NYTCL-8081(7)

*Values in parentheses indicate holding time in days

Project Name: 100 MAIN ST
Project Number: 12461

Lab Number: L2316452
Report Date: 04/12/23

Container Information

Container ID	Container Type	Cooler	Initial pH	Final pH	Temp deg C	Pres	Seal	Frozen Date/Time	Analysis(*)
L2316452-05E	Amber 120ml unpreserved	A	7	7	2.7	Y	Absent		NYTCL-8081(7)
L2316452-05F	Amber 120ml unpreserved	A	7	7	2.7	Y	Absent		NYTCL-8082-LVI(365)
L2316452-05G	Amber 120ml unpreserved	A	7	7	2.7	Y	Absent		NYTCL-8082-LVI(365)
L2316452-05H	Plastic 250ml NaOH preserved	A	>12	>12	2.7	Y	Absent		TCN-9010(14)
L2316452-05I	Amber 250ml unpreserved	A	7	7	2.7	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)
L2316452-05J	Amber 250ml unpreserved	A	7	7	2.7	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)
L2316452-05K	Amber 250ml unpreserved	A	7	7	2.7	Y	Absent		A2-1,4-DIOXANE-SIM(7)
L2316452-05L	Amber 250ml unpreserved	A	7	7	2.7	Y	Absent		A2-1,4-DIOXANE-SIM(7)
L2316452-05M	Plastic 250ml HNO3 preserved	A	<2	<2	2.7	Y	Absent		BA-6020T(180),FE-6020T(180),SE-6020T(180),TL-6020T(180),CA-6020T(180),K-6020T(180),CR-6020T(180),NI-6020T(180),NA-6020T(180),CU-6020T(180),ZN-6020T(180),PB-6020T(180),BE-6020T(180),MN-6020T(180),AS-6020T(180),SB-6020T(180),V-6020T(180),AL-6020T(180),CD-6020T(180),AG-6020T(180),MG-6020T(180),HG-T(28),CO-6020T(180)
L2316452-05N	Plastic 500ml unpreserved	A	NA		2.7	Y	Absent		A2-NY-1633-DRAFT-21(28)
L2316452-05O	Plastic 500ml unpreserved	A	NA		2.7	Y	Absent		A2-NY-1633-DRAFT-21(28)
L2316452-05P	Plastic 500ml unpreserved	A	NA		2.7	Y	Absent		A2-NY-1633-DRAFT-21(28)

*Values in parentheses indicate holding time in days

Project Name: 100 MAIN ST
Project Number: 12461

Lab Number: L2316452
Report Date: 04/12/23

PFAS PARAMETER SUMMARY

Parameter	Acronym	CAS Number
PERFLUOROALKYL CARBOXYLIC ACIDS (PFCAs)		
Perfluorooctadecanoic Acid	PFODA	16517-11-6
Perfluorohexadecanoic Acid	PFHxDA	67905-19-5
Perfluorotetradecanoic Acid	PFTA/PFTeDA	376-06-7
Perfluorotridecanoic Acid	PFTrDA	72629-94-8
Perfluorododecanoic Acid	PFDoA	307-55-1
Perfluoroundecanoic Acid	PFUnA	2058-94-8
Perfluorodecanoic Acid	PFDA	335-76-2
Perfluorononanoic Acid	PFNA	375-95-1
Perfluorooctanoic Acid	PFOA	335-67-1
Perfluoroheptanoic Acid	PFHpA	375-85-9
Perfluorohexanoic Acid	PFHxA	307-24-4
Perfluoropentanoic Acid	PFPeA	2706-90-3
Perfluorobutanoic Acid	PFBA	375-22-4
PERFLUOROALKYL SULFONIC ACIDS (PFSAs)		
Perfluorododecanesulfonic Acid	PFDoDS/PFDoS	79780-39-5
Perfluorodecanesulfonic Acid	PFDS	335-77-3
Perfluorononanesulfonic Acid	PFNS	68259-12-1
Perfluorooctanesulfonic Acid	PFOS	1763-23-1
Perfluoroheptanesulfonic Acid	PFHpS	375-92-8
Perfluorohexanesulfonic Acid	PFHxS	355-46-4
Perfluoropentanesulfonic Acid	PFPeS	2706-91-4
Perfluorobutanesulfonic Acid	PFBS	375-73-5
Perfluoropropanesulfonic Acid	PFPrS	423-41-6
FLUOROTELOMERS		
1H,1H,2H,2H-Perfluorododecanesulfonic Acid	10:2FTS	120226-60-0
1H,1H,2H,2H-Perfluorodecanesulfonic Acid	8:2FTS	39108-34-4
1H,1H,2H,2H-Perfluorooctanesulfonic Acid	6:2FTS	27619-97-2
1H,1H,2H,2H-Perfluorohexanesulfonic Acid	4:2FTS	757124-72-4
PERFLUOROALKANE SULFONAMIDES (FASAs)		
Perfluorooctanesulfonamide	FOSA/PFOSA	754-91-6
N-Ethyl Perfluorooctane Sulfonamide	NEtFOSA	4151-50-2
N-Methyl Perfluorooctane Sulfonamide	NMeFOSA	31506-32-8
PERFLUOROALKANE SULFONYL SUBSTANCES		
N-Ethyl Perfluorooctanesulfonamido Ethanol	NEtFOSE	1691-99-2
N-Methyl Perfluorooctanesulfonamido Ethanol	NMeFOSE	24448-09-7
N-Ethyl Perfluorooctanesulfonamidoacetic Acid	NEtFOSAA	2991-50-6
N-Methyl Perfluorooctanesulfonamidoacetic Acid	NMeFOSAA	2355-31-9
PER- and POLYFLUOROALKYL ETHER CARBOXYLIC ACIDS		
2,3,3,3-Tetrafluoro-2-[1,1,2,2,3,3,3-Heptafluoropropoxy]-Propanoic Acid	HFPO-DA	13252-13-6
4,8-Dioxa-3h-Perfluorononanoic Acid	ADONA	919005-14-4
CHLORO-PERFLUOROALKYL SULFONIC ACIDS		
11-Chloroeicosafluoro-3-Oxaundecane-1-Sulfonic Acid	11Cl-PF3OUdS	763051-92-9
9-Chlorohexadecafluoro-3-Oxanone-1-Sulfonic Acid	9Cl-PF3ONS	756426-58-1
PERFLUOROETHER SULFONIC ACIDS (PFESAs)		
Perfluoro(2-Ethoxyethane)Sulfonic Acid	PFEESA	113507-82-7
PERFLUOROETHER/POLYETHER CARBOXYLIC ACIDS (PFPCAs)		
Perfluoro-3-Methoxypropanoic Acid	PFMPA	377-73-1
Perfluoro-4-Methoxybutanoic Acid	PFMBA	863090-89-5
Nonafluoro-3,6-Dioxaheptanoic Acid	NFDHA	151772-58-6

Project Name: 100 MAIN ST
Project Number: 12461

Lab Number: L2316452
Report Date: 04/12/23

PFAS PARAMETER SUMMARY

Parameter	Acronym	CAS Number
FLUOROTELOMER CARBOXYLIC ACIDS (FTCAs)		
3-Perfluoroheptyl Propanoic Acid	7:3FTCA	812-70-4
2H,2H,3H,3H-Perfluorooctanoic Acid	5:3FTCA	914637-49-3
3-Perfluoropropyl Propanoic Acid	3:3FTCA	356-02-5

Project Name:	100 MAIN ST	**Lab Number:**	L2316452
Project Number:	12461	**Report Date:**	04/12/23

GLOSSARY

Acronyms

DL	- Detection Limit: This value represents the level to which target analyte concentrations are reported as estimated values, when those target analyte concentrations are quantified below the limit of quantitation (LOQ). The DL includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.)
EDL	- Estimated Detection Limit: This value represents the level to which target analyte concentrations are reported as estimated values, when those target analyte concentrations are quantified below the reporting limit (RL). The EDL includes any adjustments from dilutions, concentrations or moisture content, where applicable. The use of EDLs is specific to the analysis of PAHs using Solid-Phase Microextraction (SPME).
EMPC	- Estimated Maximum Possible Concentration: The concentration that results from the signal present at the retention time of an analyte when the ions meet all of the identification criteria except the ion abundance ratio criteria. An EMPC is a worst-case estimate of the concentration.
EPA	- Environmental Protection Agency.
LCS	- Laboratory Control Sample: A sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes or a material containing known and verified amounts of analytes.
LCSD	- Laboratory Control Sample Duplicate: Refer to LCS.
LFB	- Laboratory Fortified Blank: A sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes or a material containing known and verified amounts of analytes.
LOD	- Limit of Detection: This value represents the level to which a target analyte can reliably be detected for a specific analyte in a specific matrix by a specific method. The LOD includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.)
LOQ	- Limit of Quantitation: The value at which an instrument can accurately measure an analyte at a specific concentration. The LOQ includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.) Limit of Quantitation: The value at which an instrument can accurately measure an analyte at a specific concentration. The LOQ includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.)
MDL	- Method Detection Limit: This value represents the level to which target analyte concentrations are reported as estimated values, when those target analyte concentrations are quantified below the reporting limit (RL). The MDL includes any adjustments from dilutions, concentrations or moisture content, where applicable.
MS	- Matrix Spike Sample: A sample prepared by adding a known mass of target analyte to a specified amount of matrix sample for which an independent estimate of target analyte concentration is available. For Method 332.0, the spike recovery is calculated using the native concentration, including estimated values.
MSD	- Matrix Spike Sample Duplicate: Refer to MS.
NA	- Not Applicable.
NC	- Not Calculated: Term is utilized when one or more of the results utilized in the calculation are non-detect at the parameter's reporting unit.
NDPA/DPA	- N-Nitrosodiphenylamine/Diphenylamine.
NI	- Not Ignitable.
NP	- Non-Plastic: Term is utilized for the analysis of Atterberg Limits in soil.
NR	- No Results: Term is utilized when 'No Target Compounds Requested' is reported for the analysis of Volatile or Semivolatile Organic TIC only requests.
RL	- Reporting Limit: The value at which an instrument can accurately measure an analyte at a specific concentration. The RL includes any adjustments from dilutions, concentrations or moisture content, where applicable.
RPD	- Relative Percent Difference: The results from matrix and/or matrix spike duplicates are primarily designed to assess the precision of analytical results in a given matrix and are expressed as relative percent difference (RPD). Values which are less than five times the reporting limit for any individual parameter are evaluated by utilizing the absolute difference between the values; although the RPD value will be provided in the report.
SRM	- Standard Reference Material: A reference sample of a known or certified value that is of the same or similar matrix as the associated field samples.
STLP	- Semi-dynamic Tank Leaching Procedure per EPA Method 1315.
TEF	- Toxic Equivalency Factors: The values assigned to each dioxin and furan to evaluate their toxicity relative to 2,3,7,8-TCDD.
TEQ	- Toxic Equivalent: The measure of a sample's toxicity derived by multiplying each dioxin and furan by its corresponding TEF and then summing the resulting values.
TIC	- Tentatively Identified Compound: A compound that has been identified to be present and is not part of the target compound list (TCL) for the method and/or program. All TICs are qualitatively identified and reported as estimated concentrations.

Report Format: DU Report with 'J' Qualifiers

Project Name:	100 MAIN ST	**Lab Number:**	L2316452
Project Number:	12461	**Report Date:**	04/12/23

Footnotes

1 - The reference for this analyte should be considered modified since this analyte is absent from the target analyte list of the original method.

Terms

Analytical Method: Both the document from which the method originates and the analytical reference method. (Example: EPA 8260B is shown as 1,8260B.) The codes for the reference method documents are provided in the References section of the Addendum.

Chlordane: The target compound Chlordane (CAS No. 57-74-9) is reported for GC ECD analyses. Per EPA,this compound "refers to a mixture of chlordane isomers, other chlorinated hydrocarbons and numerous other components." (Reference: USEPA Toxicological Review of Chlordane, In Support of Summary Information on the Integrated Risk Information System (IRIS), December 1997.)

Difference: With respect to Total Oxidizable Precursor (TOP) Assay analysis, the difference is defined as the Post-Treatment value minus the Pre-Treatment value.

Final pH: As it pertains to Sample Receipt & Container Information section of the report, Final pH reflects pH of container determined after adjustment at the laboratory, if applicable. If no adjustment required, value reflects Initial pH.

Frozen Date/Time: With respect to Volatile Organics in soil, Frozen Date/Time reflects the date/time at which associated Reagent Water-preserved vials were initially frozen. Note: If frozen date/time is beyond 48 hours from sample collection, value will be reflected in 'bold'.

Gasoline Range Organics (GRO): Gasoline Range Organics (GRO) results include all chromatographic peaks eluting from Methyl tert butyl ether through Naphthalene, with the exception of GRO analysis in support of State of Ohio programs, which includes all chromatographic peaks eluting from Hexane through Dodecane.

Initial pH: As it pertains to Sample Receipt & Container Information section of the report, Initial pH reflects pH of container determined upon receipt, if applicable.

PAH Total: With respect to Alkylated PAH analyses, the 'PAHs, Total' result is defined as the summation of results for all or a subset of the following compounds: Naphthalene, C1-C4 Naphthalenes, 2-Methylnaphthalene, 1-Methylnaphthalene, Biphenyl, Acenaphthylene, Acenaphthene, Fluorene, C1-C3 Fluorenes, Phenanthrene, C1-C4 Phenanthrenes/Anthracenes, Anthracene, Fluoranthene, Pyrene, C1-C4 Fluoranthenes/Pyrenes, Benz(a)anthracene, Chrysene, C1-C4 Chrysenes, Benzo(b)fluoranthene, Benzo(j)+(k)fluoranthene, Benzo(e)pyrene, Benzo(a)pyrene, Perylene, Indeno(1,2,3-cd)pyrene, Dibenz(ah)+(ac)anthracene, Benzo(g,h,i)perylene. If a 'Total' result is requested, the results of its individual components will also be reported.

PFAS Total: With respect to PFAS analyses, the 'PFAS, Total (5)' result is defined as the summation of results for: PFHpA, PFHxS, PFOA, PFNA and PFOS. In addition, the 'PFAS, Total (6)' result is defined as the summation of results for: PFHpA, PFHxS, PFOA, PFNA, PFDA and PFOS. For MassDEP DW compliance analysis only, the 'PFAS, Total (6)' result is defined as the summation of results at or above the RL. Note: If a 'Total' result is requested, the results of its individual components will also be reported.

Total: With respect to Organic analyses, a 'Total' result is defined as the summation of results for individual isomers or Aroclors. If a 'Total' result is requested, the results of its individual components will also be reported. This is applicable to 'Total' results for methods 8260, 8081 and 8082.

Data Qualifiers

A - Spectra identified as "Aldol Condensates" are byproducts of the extraction/concentration procedures when acetone is introduced in the process.

B - The analyte was detected above the reporting limit in the associated method blank. Flag only applies to associated field samples that have detectable concentrations of the analyte at less than ten times (10x) the concentration found in the blank. For MCP-related projects, flag only applies to associated field samples that have detectable concentrations of the analyte at less than ten times (10x) the concentration found in the blank. For DOD-related projects, flag only applies to associated field samples that have detectable concentrations of the analyte at less than ten times (10x) the concentration found in the blank AND the analyte was detected above one-half the reporting limit (or above the reporting limit for common lab contaminants) in the associated method blank. For NJ-Air-related projects, flag only applies to associated field samples that have detectable concentrations of the analyte above the reporting limit. For NJ-related projects (excluding Air), flag only applies to associated field samples that have detectable concentrations of the analyte, which was detected above the reporting limit in the associated method blank or above five times the reporting limit for common lab contaminants (Phthalates, Acetone, Methylene Chloride, 2-Butanone).

C - Co-elution: The target analyte co-elutes with a known lab standard (i.e. surrogate, internal standards, etc.) for co-extracted analyses.

D - Concentration of analyte was quantified from diluted analysis. Flag only applies to field samples that have detectable concentrations of the analyte.

E - Concentration of analyte exceeds the range of the calibration curve and/or linear range of the instrument.

F - The ratio of quantifier ion response to qualifier ion response falls outside of the laboratory criteria. Results are considered to be an estimated maximum concentration.

G - The concentration may be biased high due to matrix interferences (i.e, co-elution) with non-target compound(s). The result should be considered estimated.

H - The analysis of pH was performed beyond the regulatory-required holding time of 15 minutes from the time of sample collection.

I - The lower value for the two columns has been reported due to obvious interference.

J - Estimated value. The Target analyte concentration is below the quantitation limit (RL), but above the Method Detection Limit (MDL) or Estimated Detection Limit (EDL) for SPME-related analyses. This represents an estimated concentration for Tentatively

Report Format: DU Report with 'J' Qualifiers

Project Name:	100 MAIN ST	**Lab Number:**	L2316452
Project Number:	12461	**Report Date:**	04/12/23

Data Qualifiers

Identified Compounds (TICs).

M - Reporting Limit (RL) exceeds the MCP CAM Reporting Limit for this analyte.

ND - Not detected at the method detection limit (MDL) for the sample, or estimated detection limit (EDL) for SPME-related analyses.

NJ - Presumptive evidence of compound. This represents an estimated concentration for Tentatively Identified Compounds (TICs), where the identification is based on a mass spectral library search.

P - The RPD between the results for the two columns exceeds the method-specified criteria.

Q - The quality control sample exceeds the associated acceptance criteria. For DOD-related projects, LCS and/or Continuing Calibration Standard exceedences are also qualified on all associated sample results. Note: This flag is not applicable for matrix spike recoveries when the sample concentration is greater than 4x the spike added or for batch duplicate RPD when the sample concentrations are less than 5x the RL. (Metals only.)

R - Analytical results are from sample re-analysis.

RE - Analytical results are from sample re-extraction.

S - Analytical results are from modified screening analysis.

V - The surrogate associated with this target analyte has a recovery outside the QC acceptance limits. (Applicable to MassDEP DW Compliance samples only.)

Z - The batch matrix spike and/or duplicate associated with this target analyte has a recovery/RPD outside the QC acceptance limits. (Applicable to MassDEP DW Compliance samples only.)

Project Name:	100 MAIN ST	**Lab Number:**	L2316452
Project Number:	12461	**Report Date:**	04/12/23

REFERENCES

1 Test Methods for Evaluating Solid Waste: Physical/Chemical Methods. EPA SW-846. Third Edition. Updates I - VI, 2018.

121 Standard Methods for the Examination of Water and Wastewater. APHA-AWWA-WEF. Standard Methods Online.

144 Analysis of Per- and Polyfluoroalkyl Substances (PFAS) in Aqueous, Solid, Biosolids, and Tissue Samples by LC-MS/MS. Draft EPA Method 1633, EPA Document 821-D-22-001, June 2022.

LIMITATION OF LIABILITIES

Alpha Analytical performs services with reasonable care and diligence normal to the analytical testing laboratory industry. In the event of an error, the sole and exclusive responsibility of Alpha Analytical shall be to re-perform the work at it's own expense. In no event shall Alpha Analytical be held liable for any incidental, consequential or special damages, including but not limited to, damages in any way connected with the use of, interpretation of, information or analysis provided by Alpha Analytical.

We strongly urge our clients to comply with EPA protocol regarding sample volume, preservation, cooling, containers, sampling procedures, holding time and splitting of samples in the field.

Certification Information

The following analytes are not included in our Primary NELAP Scope of Accreditation:

Westborough Facility
EPA 624/624.1: m/p-xylene, o-xylene, Naphthalene
EPA 625/625.1: alpha-Terpineol
EPA 8260C/8260D: NPW: 1,2,4,5-Tetramethylbenzene; 4-Ethyltoluene, Azobenzene; SCM: Iodomethane (methyl iodide), 1,2,4,5-Tetramethylbenzene; 4-Ethyltoluene.
EPA 8270D/8270E: NPW: Dimethylnaphthalene,1,4-Diphenylhydrazine, alpha-Terpineol; SCM: Dimethylnaphthalene,1,4-Diphenylhydrazine.
SM4500: NPW: Amenable Cyanide; SCM: Total Phosphorus, TKN, NO2, NO3.

Mansfield Facility
SM 2540D: TSS
EPA 8082A: NPW: PCB: 1, 5, 31, 87,101, 110, 141, 151, 153, 180, 183, 187.
EPA TO-15: Halothane, 2,4,4-Trimethyl-2-pentene, 2,4,4-Trimethyl-1-pentene, Thiophene, 2-Methylthiophene, 3-Methylthiophene, 2-Ethylthiophene, 1,2,3-Trimethylbenzene, Indan, Indene, 1,2,4,5-Tetramethylbenzene, Benzothiophene, 1-Methylnaphthalene.
Biological Tissue Matrix: EPA 3050B

The following analytes are included in our Massachusetts DEP Scope of Accreditation

Westborough Facility:

Drinking Water
EPA 300.0: Chloride, Nitrate-N, Fluoride, Sulfate; **EPA 353.2**: Nitrate-N, Nitrite-N; **SM4500NO3-F**: Nitrate-N, Nitrite-N; **SM4500F-C, SM4500CN-CE, EPA 180.1, SM2130B, SM4500Cl-D, SM2320B, SM2540C, SM4500H-B, SM4500NO2-B**
EPA 332: Perchlorate; **EPA 524.2:** THMs and VOCs; **EPA 504.1:** EDB, DBCP.
Microbiology: **SM9215B; SM9223-P/A, SM9223B-Colilert-QT,SM9222D**.

Non-Potable Water
SM4500H,B, EPA 120.1, SM2510B, SM2540C, SM2320B, SM4500CL-E, SM4500F-BC, SM4500NH3-BH: Ammonia-N and Kjeldahl-N, **EPA 350.1**: Ammonia-N, **LACHAT 10-107-06-1-B**: Ammonia-N, **EPA 351.1, SM4500NO3-F, EPA 353.2**: Nitrate-N, **SM4500P-E, SM4500P-B, E, SM4500SO4-E, SM5220D, EPA 410.4, SM5210B, SM5310C, SM4500CL-D, EPA 1664, EPA 420.1, SM4500-CN-CE, SM2540D, EPA 300: Chloride, Sulfate, Nitrate.**
EPA 624.1: Volatile Halocarbons & Aromatics,
EPA 608.3: Chlordane, Toxaphene, Aldrin, alpha-BHC, beta-BHC, gamma-BHC, delta-BHC, Dieldrin, DDD, DDE, DDT, Endosulfan I, Endosulfan II, Endosulfan sulfate, Endrin, Endrin Aldehyde, Heptachlor, Heptachlor Epoxide, PCBs
EPA 625.1: SVOC (Acid/Base/Neutral Extractables), **EPA 600/4-81-045**: PCB-Oil.
Microbiology: **SM9223B-Colilert-QT; Enterolert-QT, SM9221E, EPA 1600, EPA 1603, SM9222D.**

Mansfield Facility:

Drinking Water
EPA 200.7: Al, Ba, Cd, Cr, Cu, Fe, Mn, Ni, Na, Ag, Ca, Zn. **EPA 200.8:** Al, Sb, As, Ba, Be, Cd, Cr, Cu, Pb, Mn, Ni, Se, Ag, TL, Zn. **EPA 245.1** Hg.
EPA 522, EPA 537.1.

Non-Potable Water
EPA 200.7: Al, Sb, As, Be, Cd, Ca, Cr, Co, Cu, Fe, Pb, Mg, Mn, Mo, Ni, K, Se, Ag, Na, Sr, TL, Ti, V, Zn.
EPA 200.8: Al, Sb, As, Be, Cd, Cr, Cu, Fe, Pb, Mn, Ni, K, Se, Ag, Na, TL, Zn.
EPA 245.1 Hg.
SM2340B

For a complete listing of analytes and methods, please contact your Alpha Project Manager.

NEW YORK CHAIN OF CUSTODY

ALPHA ANALYTICAL

Westborough, MA 01581
8 Walkup Dr.
TEL: 508-898-9220
FAX: 508-898-9193

Mansfield, MA 02048
320 Forbes Blvd
TEL: 508-822-9300
FAX: 508-822-3288

Service Centers
Mahwah, NJ 07430: 35 Whitney Rd, Suite 5
Albany, NY 12205: 14 Walker Way
Tonawanda, NY 14150: 275 Cooper Ave, Suite 105

Page 1 of 1

Date Rec'd in Lab: 3/30/23

ALPHA Job #: L2316452

Client Information

Client: SESI
Address: 959 US46 B135300
Parsippany NJ 07054
Phone: 973 808 9050
Fax:
Email: SSG@sesi.org / JCS@sesi.org

Project Information

Project Name: 100 Main St
Project Location: White Plains NY
Project #: 17461
(Use Project name as Project #): ☐
Project Manager: SteveGustems / Jon Stuart
ALPHAQuote #:

Turn-Around Time

Standard: ☑ Due Date:
Rush (only if pre approved): ☐ # of Days: 5

Deliverables

☐ ASP-A ☑ ASP-B
☐ EQuIS (1 File) ☑ EQuIS (4 File) NY
☐ Other

Regulatory Requirement

☐ NY TOGS ☐ NY Part 375
☑ AWQ Standards ☐ NY CP-51
☑ NY Restricted Use ☐ Other
☑ NY Unrestricted Use
☐ NYC Sewer Discharge

Billing Information

☐ Same as Client Info
PO # Renaissance ENV. Mgmt.
Attn: Kevin McManus

Disposal Site Information

Please identify below location of applicable disposal facilities.

Disposal Facility:
☐ NJ ☐ NY
☐ Other:

These samples have been previously analyzed by Alpha ☐

Other project specific requirements/comments:

Call 862 3636640 (Christian) For Chain Standards update

Please specify Metals or TAL.

ANALYSIS

Sample Filtration
☐ Done
☐ Lab to do
Preservation
☐ Lab to do
(Please Specify below)

ALPHA Lab ID (Lab Use Only)	Sample ID	Collection Date	Collection Time	Sample Matrix	Sampler's Initials	TCL+30/TAL	1-4 Dioxane	PFAS Method 1633	Total Bottle	Sample Specific Comments
16452-01	SB-34 (0.5-1)	3/29/23	915	Soil	CB	✓	✓			
02	SB-33 (2-2.5)		950		CB	✓	✓			
03	SB-35 (4-4.5)		1230		CB	✓	✓			
04	SB-36 (1-1.5)		1300		CB	✓	✓			
05	GW-2		1200	GW	CB	✓	✓	✓		Has Preservatives

Preservative Code:
A = None
B = HCl
C = HNO_3
D = H_2SO_4
E = NaOH
F = MeOH
G = $NaHSO_4$
H = $Na_2S_2O_3$
K/E = Zn Ac/NaOH
O = Other

Container Code
P = Plastic
A = Amber Glass
V = Vial
G = Glass
B = Bacteria Cup
C = Cube
O = Other
E = Encore
D = BOD Bottle

Westboro: Certification No: MA935
Mansfield: Certification No: MA015

Container Type	G/P	G/P	P
Preservative	X	X	X

Relinquished By:	Date/Time	Received By:	Date/Time
	03/29/23 1452	Tyler McKenna	3/29 14:52
Tyler McKenna	3/29 1836		3-29-23 2100
	3-29-23 0030		3-30-23 0030
	3051		3/30/23 0740

3-29-23 1240

Please print clearly, legibly and completely. Samples can not be logged in and turnaround time clock will not start until any ambiguities are resolved. BY EXECUTING THIS COC, THE CLIENT HAS READ AND AGREES TO BE BOUND BY ALPHA'S TERMS & CONDITIONS. (See reverse side.)

Form No: 01-25 HC (rev. 30-Sept-2013)

ANALYTICAL REPORT

Lab Number:	L2316865
Client:	Soils Engineering Services, Inc. 959 Route 46E Parsippany, NJ 07054
ATTN:	Steven Gustems
Phone:	(973) 808-9050
Project Name:	100 MAIN ST.
Project Number:	12461
Report Date:	04/20/23

The original project report/data package is held by Alpha Analytical. This report/data package is paginated and should be reproduced only in its entirety. Alpha Analytical holds no responsibility for results and/or data that are not consistent with the original.

Certifications & Approvals: MA (M-MA086), NH NELAP (2064), CT (PH-0574), IL (200077), ME (MA00086), MD (348), NJ (MA935), NY (11148), NC (25700/666), PA (68-03671), RI (LAO00065), TX (T104704476), VT (VT-0935), VA (460195), USDA (Permit #P330-17-00196).

Eight Walkup Drive, Westborough, MA 01581-1019
508-898-9220 (Fax) 508-898-9193 800-624-9220 - www.alphalab.com

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316865
Report Date: 04/20/23

Alpha Sample ID	Client ID	Matrix	Sample Location	Collection Date/Time	Receive Date
L2316865-01	GW-3	WATER	WHITE PLAINS, NY	03/30/23 13:00	03/31/23
L2316865-02	GW-4	WATER	WHITE PLAINS, NY	03/30/23 13:30	03/31/23
L2316865-03	GW-5	WATER	WHITE PLAINS, NY	03/30/23 10:30	03/31/23
L2316865-04	GW-6	WATER	WHITE PLAINS, NY	03/30/23 11:00	03/31/23
L2316865-05	GW-7	WATER	WHITE PLAINS, NY	03/30/23 11:30	03/31/23
L2316865-06	SB-37	SOIL	WHITE PLAINS, NY	03/30/23 11:40	03/31/23
L2316865-07	SB-38	SOIL	WHITE PLAINS, NY	03/30/23 11:15	03/31/23

Project Name:	100 MAIN ST.	**Lab Number:**	L2316865
Project Number:	12461	**Report Date:**	04/20/23

Case Narrative

The samples were received in accordance with the Chain of Custody and no significant deviations were encountered during the preparation or analysis unless otherwise noted. Sample Receipt, Container Information, and the Chain of Custody are located at the back of the report.

Results contained within this report relate only to the samples submitted under this Alpha Lab Number and meet NELAP requirements for all NELAP accredited parameters unless otherwise noted in the following narrative. The data presented in this report is organized by parameter (i.e. VOC, SVOC, etc.). Sample specific Quality Control data (i.e. Surrogate Spike Recovery) is reported at the end of the target analyte list for each individual sample, followed by the Laboratory Batch Quality Control at the end of each parameter. Tentatively Identified Compounds (TICs), if requested, are reported for compounds identified to be present and are not part of the method/program Target Compound List, even if only a subset of the TCL are being reported. If a sample was re-analyzed or re-extracted due to a required quality control corrective action and if both sets of data are reported, the Laboratory ID of the re-analysis or re-extraction is designated with an "R" or "RE", respectively.

When multiple Batch Quality Control elements are reported (e.g. more than one LCS), the associated samples for each element are noted in the grey shaded header line of each data table. Any Laboratory Batch, Sample Specific % recovery or RPD value that is outside the listed Acceptance Criteria is bolded in the report. In reference to questions H (CAM) or 4 (RCP) when "NO" is checked, the performance criteria for CAM and RCP methods allow for some quality control failures to occur and still be within method compliance. In these instances, the specific failure is not narrated but noted in the associated QC Outlier Summary Report, located directly after the Case Narrative. QC information is also incorporated in the Data Usability Assessment table (Format 11) of our Data Merger tool, where it can be reviewed in conjunction with the sample result, associated regulatory criteria and any associated data usability implications.

Soil/sediments, solids and tissues are reported on a dry weight basis unless otherwise noted. Definitions of all data qualifiers and acronyms used in this report are provided in the Glossary located at the back of the report.

HOLD POLICY - For samples submitted on hold, Alpha's policy is to hold samples (with the exception of Air canisters) free of charge for 21 calendar days from the date the project is completed. After 21 calendar days, we will dispose of all samples submitted including those put on hold unless you have contacted your Alpha Project Manager and made arrangements for Alpha to continue to hold the samples. Air canisters will be disposed after 3 business days from the date the project is completed.

Please contact Project Management at 800-624-9220 with any questions.

Project Name: 100 MAIN ST. **Lab Number:** L2316865
Project Number: 12461 **Report Date:** 04/20/23

Case Narrative (continued)

Report Submission
April 20, 2023: This final report includes the results of all requested analyses.
April 10, 2023: This is a preliminary report.
April 07, 2023: This is a preliminary report.

All non-detect (ND) or estimated concentrations (J-qualified) have been quantitated to the limit noted in the MDL column.

Sample Receipt
L2316865-02: The sample was received below the appropriate pH for the Total Cyanide - EPA 9010C/9012B analysis. The laboratory added additional NaOH to a pH >12.

Volatile Organics
L2316865-02 through -05: The pH was greater than two; however, the sample was analyzed within the method required holding time.

Semivolatile Organics
L2316865-02: The sample has elevated detection limits due to the limited sample volume utilized during extraction, as required by the sample matrix.
The WG1762197-1 Method Blank, associated with L2316865-01 through -05, has TICs detected. The results are qualified with a "B" for any associated samples that have detections of the same TICs.

Semivolatile Organics by SIM
L2316865-02: The sample has elevated detection limits due to the limited sample volume utilized during extraction, as required by the sample matrix.

PCBs

Project Name:	100 MAIN ST.	**Lab Number:**	L2316865
Project Number:	12461	**Report Date:**	04/20/23

Case Narrative (continued)

L2316865-01: The sample has elevated detection limits due to the limited sample volume utilized during extraction, as required by the sample matrix.

Total Metals

L2316865-01 through -07: The sample has elevated detection limits for all elements, with the exception of mercury, due to the dilution required by the sample matrix.

Cyanide, Total

The WG1763463-5 MSD recovery, performed on L2316865-05, is outside the acceptance criteria for cyanide, total (65%); however, the associated LCS recovery is within criteria. No further action was taken. The MS/MSD RPD is above the acceptance criteria for cyanide, total (39%).

I, the undersigned, attest under the pains and penalties of perjury that, to the best of my knowledge and belief and based upon my personal inquiry of those responsible for providing the information contained in this analytical report, such information is accurate and complete. This certificate of analysis is not complete unless this page accompanies any and all pages of this report.

Authorized Signature: Kelly Stenstrom

Title: Technical Director/Representative Date: 04/20/23

ORGANICS

VOLATILES

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-01 Date Collected: 03/30/23 13:00
Client ID: GW-3 Date Received: 03/31/23
Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8260D
Analytical Date: 04/05/23 11:36
Analyst: MKS

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Methylene chloride	ND		ug/l	2.5	0.70	1
1,1-Dichloroethane	ND		ug/l	2.5	0.70	1
Chloroform	ND		ug/l	2.5	0.70	1
Carbon tetrachloride	ND		ug/l	0.50	0.13	1
1,2-Dichloropropane	ND		ug/l	1.0	0.14	1
Dibromochloromethane	ND		ug/l	0.50	0.15	1
1,1,2-Trichloroethane	ND		ug/l	1.5	0.50	1
Tetrachloroethene	ND		ug/l	0.50	0.18	1
Chlorobenzene	ND		ug/l	2.5	0.70	1
Trichlorofluoromethane	ND		ug/l	2.5	0.70	1
1,2-Dichloroethane	ND		ug/l	0.50	0.13	1
1,1,1-Trichloroethane	ND		ug/l	2.5	0.70	1
Bromodichloromethane	ND		ug/l	0.50	0.19	1
trans-1,3-Dichloropropene	ND		ug/l	0.50	0.16	1
cis-1,3-Dichloropropene	ND		ug/l	0.50	0.14	1
1,3-Dichloropropene, Total	ND		ug/l	0.50	0.14	1
1,1-Dichloropropene	ND		ug/l	2.5	0.70	1
Bromoform	ND		ug/l	2.0	0.65	1
1,1,2,2-Tetrachloroethane	ND		ug/l	0.50	0.17	1
Benzene	ND		ug/l	0.50	0.16	1
Toluene	ND		ug/l	2.5	0.70	1
Ethylbenzene	ND		ug/l	2.5	0.70	1
Chloromethane	ND		ug/l	2.5	0.70	1
Bromomethane	ND		ug/l	2.5	0.70	1
Vinyl chloride	ND		ug/l	1.0	0.07	1
Chloroethane	ND		ug/l	2.5	0.70	1
1,1-Dichloroethene	ND		ug/l	0.50	0.17	1
trans-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-01 Date Collected: 03/30/23 13:00

Client ID: GW-3 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Trichloroethene	ND		ug/l	0.50	0.18	1
1,2-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,3-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,4-Dichlorobenzene	ND		ug/l	2.5	0.70	1
Methyl tert butyl ether	ND		ug/l	2.5	0.70	1
p/m-Xylene	ND		ug/l	2.5	0.70	1
o-Xylene	ND		ug/l	2.5	0.70	1
Xylenes, Total	ND		ug/l	2.5	0.70	1
cis-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1
1,2-Dichloroethene, Total	ND		ug/l	2.5	0.70	1
Dibromomethane	ND		ug/l	5.0	1.0	1
1,2,3-Trichloropropane	ND		ug/l	2.5	0.70	1
Acrylonitrile	ND		ug/l	5.0	1.5	1
Styrene	ND		ug/l	2.5	0.70	1
Dichlorodifluoromethane	ND		ug/l	5.0	1.0	1
Acetone	6.1		ug/l	5.0	1.5	1
Carbon disulfide	ND		ug/l	5.0	1.0	1
2-Butanone	ND		ug/l	5.0	1.9	1
Vinyl acetate	ND		ug/l	5.0	1.0	1
4-Methyl-2-pentanone	ND		ug/l	5.0	1.0	1
2-Hexanone	ND		ug/l	5.0	1.0	1
Bromochloromethane	ND		ug/l	2.5	0.70	1
2,2-Dichloropropane	ND		ug/l	2.5	0.70	1
1,2-Dibromoethane	ND		ug/l	2.0	0.65	1
1,3-Dichloropropane	ND		ug/l	2.5	0.70	1
1,1,1,2-Tetrachloroethane	ND		ug/l	2.5	0.70	1
Bromobenzene	ND		ug/l	2.5	0.70	1
n-Butylbenzene	ND		ug/l	2.5	0.70	1
sec-Butylbenzene	ND		ug/l	2.5	0.70	1
tert-Butylbenzene	ND		ug/l	2.5	0.70	1
o-Chlorotoluene	ND		ug/l	2.5	0.70	1
p-Chlorotoluene	ND		ug/l	2.5	0.70	1
1,2-Dibromo-3-chloropropane	ND		ug/l	2.5	0.70	1
Hexachlorobutadiene	ND		ug/l	2.5	0.70	1
Isopropylbenzene	ND		ug/l	2.5	0.70	1
p-Isopropyltoluene	ND		ug/l	2.5	0.70	1
Naphthalene	0.81	J	ug/l	2.5	0.70	1

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-01 Date Collected: 03/30/23 13:00

Client ID: GW-3 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
n-Propylbenzene	ND		ug/l	2.5	0.70	1
1,2,3-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,3,5-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,4-Dioxane	ND		ug/l	250	61.	1
p-Diethylbenzene	ND		ug/l	2.0	0.70	1
p-Ethyltoluene	ND		ug/l	2.0	0.70	1
1,2,4,5-Tetramethylbenzene	ND		ug/l	2.0	0.54	1
Ethyl ether	ND		ug/l	2.5	0.70	1
trans-1,4-Dichloro-2-butene	ND		ug/l	2.5	0.70	1
Tentatively Identified Compounds						
Total TIC Compounds	3.74	J	ug/l			1
Unknown	1.06	J	ug/l			1
Unknown	1.31	J	ug/l			1
Nonanal	1.37	NJ	ug/l			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	121		70-130
Toluene-d8	99		70-130
4-Bromofluorobenzene	92		70-130
Dibromofluoromethane	113		70-130

Project Name: 100 MAIN ST.
Lab Number: L2316865
Project Number: 12461
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-02
Client ID: GW-4
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 13:30
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8260D
Analytical Date: 04/05/23 11:59
Analyst: MKS

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Methylene chloride	ND		ug/l	2.5	0.70	1
1,1-Dichloroethane	ND		ug/l	2.5	0.70	1
Chloroform	ND		ug/l	2.5	0.70	1
Carbon tetrachloride	ND		ug/l	0.50	0.13	1
1,2-Dichloropropane	ND		ug/l	1.0	0.14	1
Dibromochloromethane	ND		ug/l	0.50	0.15	1
1,1,2-Trichloroethane	ND		ug/l	1.5	0.50	1
Tetrachloroethene	ND		ug/l	0.50	0.18	1
Chlorobenzene	ND		ug/l	2.5	0.70	1
Trichlorofluoromethane	ND		ug/l	2.5	0.70	1
1,2-Dichloroethane	ND		ug/l	0.50	0.13	1
1,1,1-Trichloroethane	4.1		ug/l	2.5	0.70	1
Bromodichloromethane	ND		ug/l	0.50	0.19	1
trans-1,3-Dichloropropene	ND		ug/l	0.50	0.16	1
cis-1,3-Dichloropropene	ND		ug/l	0.50	0.14	1
1,3-Dichloropropene, Total	ND		ug/l	0.50	0.14	1
1,1-Dichloropropene	ND		ug/l	2.5	0.70	1
Bromoform	ND		ug/l	2.0	0.65	1
1,1,2,2-Tetrachloroethane	ND		ug/l	0.50	0.17	1
Benzene	ND		ug/l	0.50	0.16	1
Toluene	ND		ug/l	2.5	0.70	1
Ethylbenzene	ND		ug/l	2.5	0.70	1
Chloromethane	ND		ug/l	2.5	0.70	1
Bromomethane	ND		ug/l	2.5	0.70	1
Vinyl chloride	ND		ug/l	1.0	0.07	1
Chloroethane	ND		ug/l	2.5	0.70	1
1,1-Dichloroethene	ND		ug/l	0.50	0.17	1
trans-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-02 Date Collected: 03/30/23 13:30

Client ID: GW-4 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Trichloroethene	ND		ug/l	0.50	0.18	1
1,2-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,3-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,4-Dichlorobenzene	ND		ug/l	2.5	0.70	1
Methyl tert butyl ether	ND		ug/l	2.5	0.70	1
p/m-Xylene	ND		ug/l	2.5	0.70	1
o-Xylene	ND		ug/l	2.5	0.70	1
Xylenes, Total	ND		ug/l	2.5	0.70	1
cis-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1
1,2-Dichloroethene, Total	ND		ug/l	2.5	0.70	1
Dibromomethane	ND		ug/l	5.0	1.0	1
1,2,3-Trichloropropane	ND		ug/l	2.5	0.70	1
Acrylonitrile	ND		ug/l	5.0	1.5	1
Styrene	ND		ug/l	2.5	0.70	1
Dichlorodifluoromethane	ND		ug/l	5.0	1.0	1
Acetone	9.2		ug/l	5.0	1.5	1
Carbon disulfide	ND		ug/l	5.0	1.0	1
2-Butanone	ND		ug/l	5.0	1.9	1
Vinyl acetate	ND		ug/l	5.0	1.0	1
4-Methyl-2-pentanone	ND		ug/l	5.0	1.0	1
2-Hexanone	ND		ug/l	5.0	1.0	1
Bromochloromethane	ND		ug/l	2.5	0.70	1
2,2-Dichloropropane	ND		ug/l	2.5	0.70	1
1,2-Dibromoethane	ND		ug/l	2.0	0.65	1
1,3-Dichloropropane	ND		ug/l	2.5	0.70	1
1,1,1,2-Tetrachloroethane	ND		ug/l	2.5	0.70	1
Bromobenzene	ND		ug/l	2.5	0.70	1
n-Butylbenzene	ND		ug/l	2.5	0.70	1
sec-Butylbenzene	ND		ug/l	2.5	0.70	1
tert-Butylbenzene	ND		ug/l	2.5	0.70	1
o-Chlorotoluene	ND		ug/l	2.5	0.70	1
p-Chlorotoluene	ND		ug/l	2.5	0.70	1
1,2-Dibromo-3-chloropropane	ND		ug/l	2.5	0.70	1
Hexachlorobutadiene	ND		ug/l	2.5	0.70	1
Isopropylbenzene	ND		ug/l	2.5	0.70	1
p-Isopropyltoluene	ND		ug/l	2.5	0.70	1
Naphthalene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-02 Date Collected: 03/30/23 13:30

Client ID: GW-4 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
n-Propylbenzene	ND		ug/l	2.5	0.70	1
1,2,3-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,3,5-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,4-Dioxane	ND		ug/l	250	61.	1
p-Diethylbenzene	ND		ug/l	2.0	0.70	1
p-Ethyltoluene	ND		ug/l	2.0	0.70	1
1,2,4,5-Tetramethylbenzene	ND		ug/l	2.0	0.54	1
Ethyl ether	ND		ug/l	2.5	0.70	1
trans-1,4-Dichloro-2-butene	ND		ug/l	2.5	0.70	1
Tentatively Identified Compounds						
Total TIC Compounds	3.00	J	ug/l			1
1-Propene, 2-methyl-	1.64	NJ	ug/l			1
Unknown	1.36	J	ug/l			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	120		70-130
Toluene-d8	99		70-130
4-Bromofluorobenzene	91		70-130
Dibromofluoromethane	112		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-03 Date Collected: 03/30/23 10:30
Client ID: GW-5 Date Received: 03/31/23
Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8260D
Analytical Date: 04/05/23 12:22
Analyst: MKS

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Methylene chloride	ND		ug/l	2.5	0.70	1
1,1-Dichloroethane	ND		ug/l	2.5	0.70	1
Chloroform	ND		ug/l	2.5	0.70	1
Carbon tetrachloride	ND		ug/l	0.50	0.13	1
1,2-Dichloropropane	ND		ug/l	1.0	0.14	1
Dibromochloromethane	ND		ug/l	0.50	0.15	1
1,1,2-Trichloroethane	ND		ug/l	1.5	0.50	1
Tetrachloroethene	1.1		ug/l	0.50	0.18	1
Chlorobenzene	ND		ug/l	2.5	0.70	1
Trichlorofluoromethane	ND		ug/l	2.5	0.70	1
1,2-Dichloroethane	ND		ug/l	0.50	0.13	1
1,1,1-Trichloroethane	ND		ug/l	2.5	0.70	1
Bromodichloromethane	ND		ug/l	0.50	0.19	1
trans-1,3-Dichloropropene	ND		ug/l	0.50	0.16	1
cis-1,3-Dichloropropene	ND		ug/l	0.50	0.14	1
1,3-Dichloropropene, Total	ND		ug/l	0.50	0.14	1
1,1-Dichloropropene	ND		ug/l	2.5	0.70	1
Bromoform	ND		ug/l	2.0	0.65	1
1,1,2,2-Tetrachloroethane	ND		ug/l	0.50	0.17	1
Benzene	ND		ug/l	0.50	0.16	1
Toluene	ND		ug/l	2.5	0.70	1
Ethylbenzene	ND		ug/l	2.5	0.70	1
Chloromethane	ND		ug/l	2.5	0.70	1
Bromomethane	ND		ug/l	2.5	0.70	1
Vinyl chloride	ND		ug/l	1.0	0.07	1
Chloroethane	ND		ug/l	2.5	0.70	1
1,1-Dichloroethene	ND		ug/l	0.50	0.17	1
trans-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-03 Date Collected: 03/30/23 10:30

Client ID: GW-5 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Trichloroethene	0.21	J	ug/l	0.50	0.18	1
1,2-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,3-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,4-Dichlorobenzene	ND		ug/l	2.5	0.70	1
Methyl tert butyl ether	ND		ug/l	2.5	0.70	1
p/m-Xylene	ND		ug/l	2.5	0.70	1
o-Xylene	ND		ug/l	2.5	0.70	1
Xylenes, Total	ND		ug/l	2.5	0.70	1
cis-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1
1,2-Dichloroethene, Total	ND		ug/l	2.5	0.70	1
Dibromomethane	ND		ug/l	5.0	1.0	1
1,2,3-Trichloropropane	ND		ug/l	2.5	0.70	1
Acrylonitrile	ND		ug/l	5.0	1.5	1
Styrene	ND		ug/l	2.5	0.70	1
Dichlorodifluoromethane	ND		ug/l	5.0	1.0	1
Acetone	1.7	J	ug/l	5.0	1.5	1
Carbon disulfide	ND		ug/l	5.0	1.0	1
2-Butanone	ND		ug/l	5.0	1.9	1
Vinyl acetate	ND		ug/l	5.0	1.0	1
4-Methyl-2-pentanone	ND		ug/l	5.0	1.0	1
2-Hexanone	ND		ug/l	5.0	1.0	1
Bromochloromethane	ND		ug/l	2.5	0.70	1
2,2-Dichloropropane	ND		ug/l	2.5	0.70	1
1,2-Dibromoethane	ND		ug/l	2.0	0.65	1
1,3-Dichloropropane	ND		ug/l	2.5	0.70	1
1,1,1,2-Tetrachloroethane	ND		ug/l	2.5	0.70	1
Bromobenzene	ND		ug/l	2.5	0.70	1
n-Butylbenzene	ND		ug/l	2.5	0.70	1
sec-Butylbenzene	ND		ug/l	2.5	0.70	1
tert-Butylbenzene	ND		ug/l	2.5	0.70	1
o-Chlorotoluene	ND		ug/l	2.5	0.70	1
p-Chlorotoluene	ND		ug/l	2.5	0.70	1
1,2-Dibromo-3-chloropropane	ND		ug/l	2.5	0.70	1
Hexachlorobutadiene	ND		ug/l	2.5	0.70	1
Isopropylbenzene	ND		ug/l	2.5	0.70	1
p-Isopropyltoluene	ND		ug/l	2.5	0.70	1
Naphthalene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-03 Date Collected: 03/30/23 10:30

Client ID: GW-5 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
n-Propylbenzene	ND		ug/l	2.5	0.70	1
1,2,3-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,3,5-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,4-Dioxane	ND		ug/l	250	61.	1
p-Diethylbenzene	ND		ug/l	2.0	0.70	1
p-Ethyltoluene	ND		ug/l	2.0	0.70	1
1,2,4,5-Tetramethylbenzene	ND		ug/l	2.0	0.54	1
Ethyl ether	ND		ug/l	2.5	0.70	1
trans-1,4-Dichloro-2-butene	ND		ug/l	2.5	0.70	1
Tentatively Identified Compounds						
Total TIC Compounds	1.01	J	ug/l			1
Unknown	1.01	J	ug/l			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	123		70-130
Toluene-d8	99		70-130
4-Bromofluorobenzene	90		70-130
Dibromofluoromethane	114		70-130

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-04
Client ID: GW-6
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 11:00
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8260D
Analytical Date: 04/05/23 12:45
Analyst: MKS

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Methylene chloride	ND		ug/l	2.5	0.70	1
1,1-Dichloroethane	ND		ug/l	2.5	0.70	1
Chloroform	12		ug/l	2.5	0.70	1
Carbon tetrachloride	ND		ug/l	0.50	0.13	1
1,2-Dichloropropane	ND		ug/l	1.0	0.14	1
Dibromochloromethane	ND		ug/l	0.50	0.15	1
1,1,2-Trichloroethane	ND		ug/l	1.5	0.50	1
Tetrachloroethene	0.96		ug/l	0.50	0.18	1
Chlorobenzene	ND		ug/l	2.5	0.70	1
Trichlorofluoromethane	ND		ug/l	2.5	0.70	1
1,2-Dichloroethane	ND		ug/l	0.50	0.13	1
1,1,1-Trichloroethane	ND		ug/l	2.5	0.70	1
Bromodichloromethane	ND		ug/l	0.50	0.19	1
trans-1,3-Dichloropropene	ND		ug/l	0.50	0.16	1
cis-1,3-Dichloropropene	ND		ug/l	0.50	0.14	1
1,3-Dichloropropene, Total	ND		ug/l	0.50	0.14	1
1,1-Dichloropropene	ND		ug/l	2.5	0.70	1
Bromoform	ND		ug/l	2.0	0.65	1
1,1,2,2-Tetrachloroethane	ND		ug/l	0.50	0.17	1
Benzene	ND		ug/l	0.50	0.16	1
Toluene	ND		ug/l	2.5	0.70	1
Ethylbenzene	ND		ug/l	2.5	0.70	1
Chloromethane	ND		ug/l	2.5	0.70	1
Bromomethane	ND		ug/l	2.5	0.70	1
Vinyl chloride	ND		ug/l	1.0	0.07	1
Chloroethane	ND		ug/l	2.5	0.70	1
1,1-Dichloroethene	ND		ug/l	0.50	0.17	1
trans-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-04 Date Collected: 03/30/23 11:00

Client ID: GW-6 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Trichloroethene	ND		ug/l	0.50	0.18	1
1,2-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,3-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,4-Dichlorobenzene	ND		ug/l	2.5	0.70	1
Methyl tert butyl ether	ND		ug/l	2.5	0.70	1
p/m-Xylene	ND		ug/l	2.5	0.70	1
o-Xylene	ND		ug/l	2.5	0.70	1
Xylenes, Total	ND		ug/l	2.5	0.70	1
cis-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1
1,2-Dichloroethene, Total	ND		ug/l	2.5	0.70	1
Dibromomethane	ND		ug/l	5.0	1.0	1
1,2,3-Trichloropropane	ND		ug/l	2.5	0.70	1
Acrylonitrile	ND		ug/l	5.0	1.5	1
Styrene	ND		ug/l	2.5	0.70	1
Dichlorodifluoromethane	3.0	J	ug/l	5.0	1.0	1
Acetone	ND		ug/l	5.0	1.5	1
Carbon disulfide	ND		ug/l	5.0	1.0	1
2-Butanone	ND		ug/l	5.0	1.9	1
Vinyl acetate	ND		ug/l	5.0	1.0	1
4-Methyl-2-pentanone	ND		ug/l	5.0	1.0	1
2-Hexanone	ND		ug/l	5.0	1.0	1
Bromochloromethane	ND		ug/l	2.5	0.70	1
2,2-Dichloropropane	ND		ug/l	2.5	0.70	1
1,2-Dibromoethane	ND		ug/l	2.0	0.65	1
1,3-Dichloropropane	ND		ug/l	2.5	0.70	1
1,1,1,2-Tetrachloroethane	ND		ug/l	2.5	0.70	1
Bromobenzene	ND		ug/l	2.5	0.70	1
n-Butylbenzene	ND		ug/l	2.5	0.70	1
sec-Butylbenzene	ND		ug/l	2.5	0.70	1
tert-Butylbenzene	ND		ug/l	2.5	0.70	1
o-Chlorotoluene	ND		ug/l	2.5	0.70	1
p-Chlorotoluene	ND		ug/l	2.5	0.70	1
1,2-Dibromo-3-chloropropane	ND		ug/l	2.5	0.70	1
Hexachlorobutadiene	ND		ug/l	2.5	0.70	1
Isopropylbenzene	ND		ug/l	2.5	0.70	1
p-Isopropyltoluene	ND		ug/l	2.5	0.70	1
Naphthalene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-04 Date Collected: 03/30/23 11:00

Client ID: GW-6 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
n-Propylbenzene	ND		ug/l	2.5	0.70	1
1,2,3-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,3,5-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,4-Dioxane	ND		ug/l	250	61.	1
p-Diethylbenzene	ND		ug/l	2.0	0.70	1
p-Ethyltoluene	ND		ug/l	2.0	0.70	1
1,2,4,5-Tetramethylbenzene	ND		ug/l	2.0	0.54	1
Ethyl ether	ND		ug/l	2.5	0.70	1
trans-1,4-Dichloro-2-butene	ND		ug/l	2.5	0.70	1
Tentatively Identified Compounds						
No Tentatively Identified Compounds	ND		ug/l			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	130		70-130
Toluene-d8	98		70-130
4-Bromofluorobenzene	91		70-130
Dibromofluoromethane	116		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-05
Client ID: GW-7
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 11:30
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8260D
Analytical Date: 04/05/23 13:09
Analyst: MKS

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Methylene chloride	ND		ug/l	2.5	0.70	1
1,1-Dichloroethane	ND		ug/l	2.5	0.70	1
Chloroform	5.3		ug/l	2.5	0.70	1
Carbon tetrachloride	ND		ug/l	0.50	0.13	1
1,2-Dichloropropane	ND		ug/l	1.0	0.14	1
Dibromochloromethane	ND		ug/l	0.50	0.15	1
1,1,2-Trichloroethane	ND		ug/l	1.5	0.50	1
Tetrachloroethene	0.53		ug/l	0.50	0.18	1
Chlorobenzene	ND		ug/l	2.5	0.70	1
Trichlorofluoromethane	ND		ug/l	2.5	0.70	1
1,2-Dichloroethane	ND		ug/l	0.50	0.13	1
1,1,1-Trichloroethane	ND		ug/l	2.5	0.70	1
Bromodichloromethane	ND		ug/l	0.50	0.19	1
trans-1,3-Dichloropropene	ND		ug/l	0.50	0.16	1
cis-1,3-Dichloropropene	ND		ug/l	0.50	0.14	1
1,3-Dichloropropene, Total	ND		ug/l	0.50	0.14	1
1,1-Dichloropropene	ND		ug/l	2.5	0.70	1
Bromoform	ND		ug/l	2.0	0.65	1
1,1,2,2-Tetrachloroethane	ND		ug/l	0.50	0.17	1
Benzene	ND		ug/l	0.50	0.16	1
Toluene	ND		ug/l	2.5	0.70	1
Ethylbenzene	ND		ug/l	2.5	0.70	1
Chloromethane	ND		ug/l	2.5	0.70	1
Bromomethane	ND		ug/l	2.5	0.70	1
Vinyl chloride	ND		ug/l	1.0	0.07	1
Chloroethane	ND		ug/l	2.5	0.70	1
1,1-Dichloroethene	ND		ug/l	0.50	0.17	1
trans-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-05 Date Collected: 03/30/23 11:30

Client ID: GW-7 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Trichloroethene	ND		ug/l	0.50	0.18	1
1,2-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,3-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,4-Dichlorobenzene	ND		ug/l	2.5	0.70	1
Methyl tert butyl ether	ND		ug/l	2.5	0.70	1
p/m-Xylene	ND		ug/l	2.5	0.70	1
o-Xylene	ND		ug/l	2.5	0.70	1
Xylenes, Total	ND		ug/l	2.5	0.70	1
cis-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1
1,2-Dichloroethene, Total	ND		ug/l	2.5	0.70	1
Dibromomethane	ND		ug/l	5.0	1.0	1
1,2,3-Trichloropropane	ND		ug/l	2.5	0.70	1
Acrylonitrile	ND		ug/l	5.0	1.5	1
Styrene	ND		ug/l	2.5	0.70	1
Dichlorodifluoromethane	2.6	J	ug/l	5.0	1.0	1
Acetone	3.0	J	ug/l	5.0	1.5	1
Carbon disulfide	ND		ug/l	5.0	1.0	1
2-Butanone	ND		ug/l	5.0	1.9	1
Vinyl acetate	ND		ug/l	5.0	1.0	1
4-Methyl-2-pentanone	ND		ug/l	5.0	1.0	1
2-Hexanone	ND		ug/l	5.0	1.0	1
Bromochloromethane	ND		ug/l	2.5	0.70	1
2,2-Dichloropropane	ND		ug/l	2.5	0.70	1
1,2-Dibromoethane	ND		ug/l	2.0	0.65	1
1,3-Dichloropropane	ND		ug/l	2.5	0.70	1
1,1,1,2-Tetrachloroethane	ND		ug/l	2.5	0.70	1
Bromobenzene	ND		ug/l	2.5	0.70	1
n-Butylbenzene	ND		ug/l	2.5	0.70	1
sec-Butylbenzene	ND		ug/l	2.5	0.70	1
tert-Butylbenzene	ND		ug/l	2.5	0.70	1
o-Chlorotoluene	ND		ug/l	2.5	0.70	1
p-Chlorotoluene	ND		ug/l	2.5	0.70	1
1,2-Dibromo-3-chloropropane	ND		ug/l	2.5	0.70	1
Hexachlorobutadiene	ND		ug/l	2.5	0.70	1
Isopropylbenzene	ND		ug/l	2.5	0.70	1
p-Isopropyltoluene	ND		ug/l	2.5	0.70	1
Naphthalene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-05 Date Collected: 03/30/23 11:30

Client ID: GW-7 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
n-Propylbenzene	ND		ug/l	2.5	0.70	1
1,2,3-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,3,5-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,4-Dioxane	ND		ug/l	250	61.	1
p-Diethylbenzene	ND		ug/l	2.0	0.70	1
p-Ethyltoluene	ND		ug/l	2.0	0.70	1
1,2,4,5-Tetramethylbenzene	ND		ug/l	2.0	0.54	1
Ethyl ether	ND		ug/l	2.5	0.70	1
trans-1,4-Dichloro-2-butene	ND		ug/l	2.5	0.70	1
Tentatively Identified Compounds						
Total TIC Compounds	1.54	J	ug/l			1
1-Propene, 2-methyl-	1.54	NJ	ug/l			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	123		70-130
Toluene-d8	100		70-130
4-Bromofluorobenzene	91		70-130
Dibromofluoromethane	113		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-06
Client ID: SB-37
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 11:40
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8260D
Analytical Date: 04/03/23 18:46
Analyst: JIC
Percent Solids: 92%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Methylene chloride	ND		ug/kg	4.7	2.2	1
1,1-Dichloroethane	ND		ug/kg	0.95	0.14	1
Chloroform	ND		ug/kg	1.4	0.13	1
Carbon tetrachloride	ND		ug/kg	0.95	0.22	1
1,2-Dichloropropane	ND		ug/kg	0.95	0.12	1
Dibromochloromethane	ND		ug/kg	0.95	0.13	1
1,1,2-Trichloroethane	ND		ug/kg	0.95	0.25	1
Tetrachloroethene	ND		ug/kg	0.47	0.19	1
Chlorobenzene	ND		ug/kg	0.47	0.12	1
Trichlorofluoromethane	ND		ug/kg	3.8	0.66	1
1,2-Dichloroethane	ND		ug/kg	0.95	0.24	1
1,1,1-Trichloroethane	ND		ug/kg	0.47	0.16	1
Bromodichloromethane	ND		ug/kg	0.47	0.10	1
trans-1,3-Dichloropropene	ND		ug/kg	0.95	0.26	1
cis-1,3-Dichloropropene	ND		ug/kg	0.47	0.15	1
1,3-Dichloropropene, Total	ND		ug/kg	0.47	0.15	1
1,1-Dichloropropene	ND		ug/kg	0.47	0.15	1
Bromoform	ND		ug/kg	3.8	0.23	1
1,1,2,2-Tetrachloroethane	ND		ug/kg	0.47	0.16	1
Benzene	0.21	J	ug/kg	0.47	0.16	1
Toluene	ND		ug/kg	0.95	0.52	1
Ethylbenzene	ND		ug/kg	0.95	0.13	1
Chloromethane	ND		ug/kg	3.8	0.88	1
Bromomethane	ND		ug/kg	1.9	0.55	1
Vinyl chloride	ND		ug/kg	0.95	0.32	1
Chloroethane	ND		ug/kg	1.9	0.43	1
1,1-Dichloroethene	ND		ug/kg	0.95	0.22	1
trans-1,2-Dichloroethene	ND		ug/kg	1.4	0.13	1

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-06 Date Collected: 03/30/23 11:40

Client ID: SB-37 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Trichloroethene	ND		ug/kg	0.47	0.13	1
1,2-Dichlorobenzene	ND		ug/kg	1.9	0.14	1
1,3-Dichlorobenzene	ND		ug/kg	1.9	0.14	1
1,4-Dichlorobenzene	ND		ug/kg	1.9	0.16	1
Methyl tert butyl ether	ND		ug/kg	1.9	0.19	1
p/m-Xylene	ND		ug/kg	1.9	0.53	1
o-Xylene	ND		ug/kg	0.95	0.28	1
Xylenes, Total	ND		ug/kg	0.95	0.28	1
cis-1,2-Dichloroethene	ND		ug/kg	0.95	0.17	1
1,2-Dichloroethene, Total	ND		ug/kg	0.95	0.13	1
Dibromomethane	ND		ug/kg	1.9	0.22	1
Styrene	ND		ug/kg	0.95	0.19	1
Dichlorodifluoromethane	ND		ug/kg	9.5	0.87	1
Acetone	21		ug/kg	9.5	4.6	1
Carbon disulfide	ND		ug/kg	9.5	4.3	1
2-Butanone	4.2	J	ug/kg	9.5	2.1	1
Vinyl acetate	ND		ug/kg	9.5	2.0	1
4-Methyl-2-pentanone	ND		ug/kg	9.5	1.2	1
1,2,3-Trichloropropane	ND		ug/kg	1.9	0.12	1
2-Hexanone	ND		ug/kg	9.5	1.1	1
Bromochloromethane	ND		ug/kg	1.9	0.19	1
2,2-Dichloropropane	ND		ug/kg	1.9	0.19	1
1,2-Dibromoethane	ND		ug/kg	0.95	0.26	1
1,3-Dichloropropane	ND		ug/kg	1.9	0.16	1
1,1,1,2-Tetrachloroethane	ND		ug/kg	0.47	0.12	1
Bromobenzene	ND		ug/kg	1.9	0.14	1
n-Butylbenzene	ND		ug/kg	0.95	0.16	1
sec-Butylbenzene	0.15	J	ug/kg	0.95	0.14	1
tert-Butylbenzene	0.15	J	ug/kg	1.9	0.11	1
o-Chlorotoluene	ND		ug/kg	1.9	0.18	1
p-Chlorotoluene	ND		ug/kg	1.9	0.10	1
1,2-Dibromo-3-chloropropane	ND		ug/kg	2.8	0.95	1
Hexachlorobutadiene	ND		ug/kg	3.8	0.16	1
Isopropylbenzene	ND		ug/kg	0.95	0.10	1
p-Isopropyltoluene	ND		ug/kg	0.95	0.10	1
Naphthalene	ND		ug/kg	3.8	0.62	1
Acrylonitrile	ND		ug/kg	3.8	1.1	1

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-06 Date Collected: 03/30/23 11:40

Client ID: SB-37 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
n-Propylbenzene	ND		ug/kg	0.95	0.16	1
1,2,3-Trichlorobenzene	ND		ug/kg	1.9	0.30	1
1,2,4-Trichlorobenzene	ND		ug/kg	1.9	0.26	1
1,3,5-Trimethylbenzene	ND		ug/kg	1.9	0.18	1
1,2,4-Trimethylbenzene	ND		ug/kg	1.9	0.32	1
1,4-Dioxane	ND		ug/kg	76	33.	1
p-Diethylbenzene	0.66	J	ug/kg	1.9	0.17	1
p-Ethyltoluene	ND		ug/kg	1.9	0.36	1
1,2,4,5-Tetramethylbenzene	0.58	J	ug/kg	1.9	0.18	1
Ethyl ether	ND		ug/kg	1.9	0.32	1
trans-1,4-Dichloro-2-butene	ND		ug/kg	4.7	1.3	1

Tentatively Identified Compounds				
Total TIC Compounds	362	J	ug/kg	1
Unknown Naphthalene	15.6	J	ug/kg	1
Unknown Indene	13.0	J	ug/kg	1
Unknown Naphthalene	13.3	J	ug/kg	1
Unknown	18.9	J	ug/kg	1
Unknown	20.9	J	ug/kg	1
Undecane, 2,6-dimethyl-	31.3	NJ	ug/kg	1
Unknown	18.1	J	ug/kg	1
Unknown Aromatic	20.6	J	ug/kg	1
Unknown	16.7	J	ug/kg	1
Unknown	19.3	J	ug/kg	1
Unknown	19.7	J	ug/kg	1
Unknown Alkane	28.7	J	ug/kg	1
Unknown Alkane	68.5	J	ug/kg	1
Unknown	36.0	J	ug/kg	1
trans-Decalin, 2-methyl-	21.1	NJ	ug/kg	1

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-06 Date Collected: 03/30/23 11:40

Client ID: SB-37 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	99		70-130
Toluene-d8	98		70-130
4-Bromofluorobenzene	95		70-130
Dibromofluoromethane	105		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-07 Date Collected: 03/30/23 11:15
Client ID: SB-38 Date Received: 03/31/23
Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8260D
Analytical Date: 04/03/23 18:20
Analyst: JIC
Percent Solids: 90%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Methylene chloride	ND		ug/kg	5.1	2.3	1
1,1-Dichloroethane	ND		ug/kg	1.0	0.15	1
Chloroform	ND		ug/kg	1.5	0.14	1
Carbon tetrachloride	ND		ug/kg	1.0	0.23	1
1,2-Dichloropropane	ND		ug/kg	1.0	0.13	1
Dibromochloromethane	ND		ug/kg	1.0	0.14	1
1,1,2-Trichloroethane	ND		ug/kg	1.0	0.27	1
Tetrachloroethene	ND		ug/kg	0.51	0.20	1
Chlorobenzene	ND		ug/kg	0.51	0.13	1
Trichlorofluoromethane	ND		ug/kg	4.1	0.71	1
1,2-Dichloroethane	ND		ug/kg	1.0	0.26	1
1,1,1-Trichloroethane	ND		ug/kg	0.51	0.17	1
Bromodichloromethane	ND		ug/kg	0.51	0.11	1
trans-1,3-Dichloropropene	ND		ug/kg	1.0	0.28	1
cis-1,3-Dichloropropene	ND		ug/kg	0.51	0.16	1
1,3-Dichloropropene, Total	ND		ug/kg	0.51	0.16	1
1,1-Dichloropropene	ND		ug/kg	0.51	0.16	1
Bromoform	ND		ug/kg	4.1	0.25	1
1,1,2,2-Tetrachloroethane	ND		ug/kg	0.51	0.17	1
Benzene	ND		ug/kg	0.51	0.17	1
Toluene	ND		ug/kg	1.0	0.55	1
Ethylbenzene	ND		ug/kg	1.0	0.14	1
Chloromethane	ND		ug/kg	4.1	0.95	1
Bromomethane	ND		ug/kg	2.0	0.59	1
Vinyl chloride	ND		ug/kg	1.0	0.34	1
Chloroethane	ND		ug/kg	2.0	0.46	1
1,1-Dichloroethene	ND		ug/kg	1.0	0.24	1
trans-1,2-Dichloroethene	ND		ug/kg	1.5	0.14	1

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-07 Date Collected: 03/30/23 11:15

Client ID: SB-38 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Trichloroethene	ND		ug/kg	0.51	0.14	1
1,2-Dichlorobenzene	ND		ug/kg	2.0	0.15	1
1,3-Dichlorobenzene	ND		ug/kg	2.0	0.15	1
1,4-Dichlorobenzene	ND		ug/kg	2.0	0.17	1
Methyl tert butyl ether	ND		ug/kg	2.0	0.20	1
p/m-Xylene	ND		ug/kg	2.0	0.57	1
o-Xylene	ND		ug/kg	1.0	0.30	1
Xylenes, Total	ND		ug/kg	1.0	0.30	1
cis-1,2-Dichloroethene	ND		ug/kg	1.0	0.18	1
1,2-Dichloroethene, Total	ND		ug/kg	1.0	0.14	1
Dibromomethane	ND		ug/kg	2.0	0.24	1
Styrene	0.43	J	ug/kg	1.0	0.20	1
Dichlorodifluoromethane	ND		ug/kg	10	0.93	1
Acetone	19		ug/kg	10	4.9	1
Carbon disulfide	ND		ug/kg	10	4.6	1
2-Butanone	4.0	J	ug/kg	10	2.3	1
Vinyl acetate	ND		ug/kg	10	2.2	1
4-Methyl-2-pentanone	2.5	J	ug/kg	10	1.3	1
1,2,3-Trichloropropane	ND		ug/kg	2.0	0.13	1
2-Hexanone	ND		ug/kg	10	1.2	1
Bromochloromethane	ND		ug/kg	2.0	0.21	1
2,2-Dichloropropane	ND		ug/kg	2.0	0.21	1
1,2-Dibromoethane	ND		ug/kg	1.0	0.28	1
1,3-Dichloropropane	ND		ug/kg	2.0	0.17	1
1,1,1,2-Tetrachloroethane	ND		ug/kg	0.51	0.13	1
Bromobenzene	ND		ug/kg	2.0	0.15	1
n-Butylbenzene	ND		ug/kg	1.0	0.17	1
sec-Butylbenzene	ND		ug/kg	1.0	0.15	1
tert-Butylbenzene	ND		ug/kg	2.0	0.12	1
o-Chlorotoluene	ND		ug/kg	2.0	0.20	1
p-Chlorotoluene	ND		ug/kg	2.0	0.11	1
1,2-Dibromo-3-chloropropane	ND		ug/kg	3.1	1.0	1
Hexachlorobutadiene	ND		ug/kg	4.1	0.17	1
Isopropylbenzene	ND		ug/kg	1.0	0.11	1
p-Isopropyltoluene	ND		ug/kg	1.0	0.11	1
Naphthalene	ND		ug/kg	4.1	0.66	1
Acrylonitrile	ND		ug/kg	4.1	1.2	1

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-07 Date Collected: 03/30/23 11:15

Client ID: SB-38 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
n-Propylbenzene	ND		ug/kg	1.0	0.17	1
1,2,3-Trichlorobenzene	ND		ug/kg	2.0	0.33	1
1,2,4-Trichlorobenzene	ND		ug/kg	2.0	0.28	1
1,3,5-Trimethylbenzene	ND		ug/kg	2.0	0.20	1
1,2,4-Trimethylbenzene	ND		ug/kg	2.0	0.34	1
1,4-Dioxane	ND		ug/kg	82	36.	1
p-Diethylbenzene	ND		ug/kg	2.0	0.18	1
p-Ethyltoluene	ND		ug/kg	2.0	0.39	1
1,2,4,5-Tetramethylbenzene	0.21	J	ug/kg	2.0	0.20	1
Ethyl ether	ND		ug/kg	2.0	0.35	1
trans-1,4-Dichloro-2-butene	ND		ug/kg	5.1	1.4	1

Tentatively Identified Compounds				
Total TIC Compounds	17.7	J	ug/kg	1
Unknown	2.25	J	ug/kg	1
Unknown Naphthalene	2.47	J	ug/kg	1
Unknown Naphthalene	2.44	J	ug/kg	1
Unknown	8.30	J	ug/kg	1
Unknown	2.25	J	ug/kg	1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	99		70-130
Toluene-d8	98		70-130
4-Bromofluorobenzene	88		70-130
Dibromofluoromethane	80		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 04/03/23 13:04
Analyst: AJK

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by EPA 5035 Low - Westborough Lab for sample(s): 06-07 Batch: WG1762421-5					
Methylene chloride	ND		ug/kg	5.0	2.3
1,1-Dichloroethane	ND		ug/kg	1.0	0.14
Chloroform	ND		ug/kg	1.5	0.14
Carbon tetrachloride	ND		ug/kg	1.0	0.23
1,2-Dichloropropane	ND		ug/kg	1.0	0.12
Dibromochloromethane	ND		ug/kg	1.0	0.14
1,1,2-Trichloroethane	ND		ug/kg	1.0	0.27
Tetrachloroethene	ND		ug/kg	0.50	0.20
Chlorobenzene	ND		ug/kg	0.50	0.13
Trichlorofluoromethane	ND		ug/kg	4.0	0.70
1,2-Dichloroethane	ND		ug/kg	1.0	0.26
1,1,1-Trichloroethane	ND		ug/kg	0.50	0.17
Bromodichloromethane	ND		ug/kg	0.50	0.11
trans-1,3-Dichloropropene	ND		ug/kg	1.0	0.27
cis-1,3-Dichloropropene	ND		ug/kg	0.50	0.16
1,3-Dichloropropene, Total	ND		ug/kg	0.50	0.16
1,1-Dichloropropene	ND		ug/kg	0.50	0.16
Bromoform	ND		ug/kg	4.0	0.25
1,1,2,2-Tetrachloroethane	ND		ug/kg	0.50	0.17
Benzene	ND		ug/kg	0.50	0.17
Toluene	ND		ug/kg	1.0	0.54
Ethylbenzene	ND		ug/kg	1.0	0.14
Chloromethane	ND		ug/kg	4.0	0.93
Bromomethane	0.77	J	ug/kg	2.0	0.58
Vinyl chloride	ND		ug/kg	1.0	0.34
Chloroethane	ND		ug/kg	2.0	0.45
1,1-Dichloroethene	ND		ug/kg	1.0	0.24
trans-1,2-Dichloroethene	ND		ug/kg	1.5	0.14
Trichloroethene	ND		ug/kg	0.50	0.14

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 04/03/23 13:04
Analyst: AJK

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by EPA 5035 Low - Westborough Lab for sample(s): 06-07 Batch: WG1762421-5					
1,2-Dichlorobenzene	ND		ug/kg	2.0	0.14
1,3-Dichlorobenzene	ND		ug/kg	2.0	0.15
1,4-Dichlorobenzene	ND		ug/kg	2.0	0.17
Methyl tert butyl ether	ND		ug/kg	2.0	0.20
p/m-Xylene	ND		ug/kg	2.0	0.56
o-Xylene	ND		ug/kg	1.0	0.29
Xylenes, Total	ND		ug/kg	1.0	0.29
cis-1,2-Dichloroethene	ND		ug/kg	1.0	0.18
1,2-Dichloroethene, Total	ND		ug/kg	1.0	0.14
Dibromomethane	ND		ug/kg	2.0	0.24
Styrene	0.41	J	ug/kg	1.0	0.20
Dichlorodifluoromethane	ND		ug/kg	10	0.92
Acetone	ND		ug/kg	10	4.8
Carbon disulfide	ND		ug/kg	10	4.6
2-Butanone	ND		ug/kg	10	2.2
Vinyl acetate	ND		ug/kg	10	2.2
4-Methyl-2-pentanone	ND		ug/kg	10	1.3
1,2,3-Trichloropropane	ND		ug/kg	2.0	0.13
2-Hexanone	ND		ug/kg	10	1.2
Bromochloromethane	ND		ug/kg	2.0	0.20
2,2-Dichloropropane	ND		ug/kg	2.0	0.20
1,2-Dibromoethane	ND		ug/kg	1.0	0.28
1,3-Dichloropropane	ND		ug/kg	2.0	0.17
1,1,1,2-Tetrachloroethane	ND		ug/kg	0.50	0.13
Bromobenzene	ND		ug/kg	2.0	0.14
n-Butylbenzene	ND		ug/kg	1.0	0.17
sec-Butylbenzene	ND		ug/kg	1.0	0.15
tert-Butylbenzene	ND		ug/kg	2.0	0.12
o-Chlorotoluene	ND		ug/kg	2.0	0.19

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 04/03/23 13:04
Analyst: AJK

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by EPA 5035 Low - Westborough Lab for sample(s): 06-07 Batch: WG1762421-5					
p-Chlorotoluene	ND		ug/kg	2.0	0.11
1,2-Dibromo-3-chloropropane	ND		ug/kg	3.0	1.0
Hexachlorobutadiene	ND		ug/kg	4.0	0.17
Isopropylbenzene	ND		ug/kg	1.0	0.11
p-Isopropyltoluene	ND		ug/kg	1.0	0.11
Naphthalene	ND		ug/kg	4.0	0.65
Acrylonitrile	ND		ug/kg	4.0	1.2
n-Propylbenzene	ND		ug/kg	1.0	0.17
1,2,3-Trichlorobenzene	ND		ug/kg	2.0	0.32
1,2,4-Trichlorobenzene	ND		ug/kg	2.0	0.27
1,3,5-Trimethylbenzene	ND		ug/kg	2.0	0.19
1,2,4-Trimethylbenzene	ND		ug/kg	2.0	0.33
1,4-Dioxane	ND		ug/kg	80	35.
p-Diethylbenzene	ND		ug/kg	2.0	0.18
p-Ethyltoluene	ND		ug/kg	2.0	0.38
1,2,4,5-Tetramethylbenzene	ND		ug/kg	2.0	0.19
Ethyl ether	ND		ug/kg	2.0	0.34
trans-1,4-Dichloro-2-butene	ND		ug/kg	5.0	1.4
Tentatively Identified Compounds					
No Tentatively Identified Compounds	ND		ug/kg		

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 04/03/23 13:04
Analyst: AJK

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by EPA 5035 Low - Westborough Lab for sample(s): 06-07 Batch: WG1762421-5					

Surrogate	%Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	90		70-130
Toluene-d8	99		70-130
4-Bromofluorobenzene	90		70-130
Dibromofluoromethane	97		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 04/05/23 08:31
Analyst: PID

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by GC/MS - Westborough Lab for sample(s): 01-05 Batch: WG1763545-5					
Methylene chloride	ND		ug/l	2.5	0.70
1,1-Dichloroethane	ND		ug/l	2.5	0.70
Chloroform	ND		ug/l	2.5	0.70
Carbon tetrachloride	ND		ug/l	0.50	0.13
1,2-Dichloropropane	ND		ug/l	1.0	0.14
Dibromochloromethane	ND		ug/l	0.50	0.15
1,1,2-Trichloroethane	ND		ug/l	1.5	0.50
Tetrachloroethene	ND		ug/l	0.50	0.18
Chlorobenzene	ND		ug/l	2.5	0.70
Trichlorofluoromethane	ND		ug/l	2.5	0.70
1,2-Dichloroethane	ND		ug/l	0.50	0.13
1,1,1-Trichloroethane	ND		ug/l	2.5	0.70
Bromodichloromethane	ND		ug/l	0.50	0.19
trans-1,3-Dichloropropene	ND		ug/l	0.50	0.16
cis-1,3-Dichloropropene	ND		ug/l	0.50	0.14
1,3-Dichloropropene, Total	ND		ug/l	0.50	0.14
1,1-Dichloropropene	ND		ug/l	2.5	0.70
Bromoform	ND		ug/l	2.0	0.65
1,1,2,2-Tetrachloroethane	ND		ug/l	0.50	0.17
Benzene	ND		ug/l	0.50	0.16
Toluene	ND		ug/l	2.5	0.70
Ethylbenzene	ND		ug/l	2.5	0.70
Chloromethane	ND		ug/l	2.5	0.70
Bromomethane	ND		ug/l	2.5	0.70
Vinyl chloride	ND		ug/l	1.0	0.07
Chloroethane	ND		ug/l	2.5	0.70
1,1-Dichloroethene	ND		ug/l	0.50	0.17
trans-1,2-Dichloroethene	ND		ug/l	2.5	0.70
Trichloroethene	ND		ug/l	0.50	0.18

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 04/05/23 08:31
Analyst: PID

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by GC/MS - Westborough Lab for sample(s): 01-05 Batch: WG1763545-5					
1,2-Dichlorobenzene	ND		ug/l	2.5	0.70
1,3-Dichlorobenzene	ND		ug/l	2.5	0.70
1,4-Dichlorobenzene	ND		ug/l	2.5	0.70
Methyl tert butyl ether	ND		ug/l	2.5	0.70
p/m-Xylene	ND		ug/l	2.5	0.70
o-Xylene	ND		ug/l	2.5	0.70
Xylenes, Total	ND		ug/l	2.5	0.70
cis-1,2-Dichloroethene	ND		ug/l	2.5	0.70
1,2-Dichloroethene, Total	ND		ug/l	2.5	0.70
Dibromomethane	ND		ug/l	5.0	1.0
1,2,3-Trichloropropane	ND		ug/l	2.5	0.70
Acrylonitrile	ND		ug/l	5.0	1.5
Styrene	ND		ug/l	2.5	0.70
Dichlorodifluoromethane	ND		ug/l	5.0	1.0
Acetone	ND		ug/l	5.0	1.5
Carbon disulfide	ND		ug/l	5.0	1.0
2-Butanone	ND		ug/l	5.0	1.9
Vinyl acetate	ND		ug/l	5.0	1.0
4-Methyl-2-pentanone	ND		ug/l	5.0	1.0
2-Hexanone	ND		ug/l	5.0	1.0
Bromochloromethane	ND		ug/l	2.5	0.70
2,2-Dichloropropane	ND		ug/l	2.5	0.70
1,2-Dibromoethane	ND		ug/l	2.0	0.65
1,3-Dichloropropane	ND		ug/l	2.5	0.70
1,1,1,2-Tetrachloroethane	ND		ug/l	2.5	0.70
Bromobenzene	ND		ug/l	2.5	0.70
n-Butylbenzene	ND		ug/l	2.5	0.70
sec-Butylbenzene	ND		ug/l	2.5	0.70
tert-Butylbenzene	ND		ug/l	2.5	0.70

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 04/05/23 08:31
Analyst: PID

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by GC/MS - Westborough Lab for sample(s): 01-05 Batch: WG1763545-5					
o-Chlorotoluene	ND		ug/l	2.5	0.70
p-Chlorotoluene	ND		ug/l	2.5	0.70
1,2-Dibromo-3-chloropropane	ND		ug/l	2.5	0.70
Hexachlorobutadiene	ND		ug/l	2.5	0.70
Isopropylbenzene	ND		ug/l	2.5	0.70
p-Isopropyltoluene	ND		ug/l	2.5	0.70
Naphthalene	ND		ug/l	2.5	0.70
n-Propylbenzene	ND		ug/l	2.5	0.70
1,2,3-Trichlorobenzene	ND		ug/l	2.5	0.70
1,2,4-Trichlorobenzene	ND		ug/l	2.5	0.70
1,3,5-Trimethylbenzene	ND		ug/l	2.5	0.70
1,2,4-Trimethylbenzene	ND		ug/l	2.5	0.70
1,4-Dioxane	ND		ug/l	250	61.
p-Diethylbenzene	ND		ug/l	2.0	0.70
p-Ethyltoluene	ND		ug/l	2.0	0.70
1,2,4,5-Tetramethylbenzene	ND		ug/l	2.0	0.54
Ethyl ether	ND		ug/l	2.5	0.70
trans-1,4-Dichloro-2-butene	ND		ug/l	2.5	0.70
Tentatively Identified Compounds					
No Tentatively Identified Compounds	ND		ug/l		

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 04/05/23 08:31
Analyst: PID

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by GC/MS - Westborough Lab for sample(s): 01-05 Batch: WG1763545-5					

Surrogate	%Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	121		70-130
Toluene-d8	100		70-130
4-Bromofluorobenzene	91		70-130
Dibromofluoromethane	115		70-130

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316865
Report Date: 04/20/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by EPA 5035 Low - Westborough Lab Associated sample(s): 06-07 Batch: WG1762421-3 WG1762421-4								
Methylene chloride	92		92		70-130	0		30
1,1-Dichloroethane	92		91		70-130	1		30
Chloroform	96		97		70-130	1		30
Carbon tetrachloride	98		100		70-130	2		30
1,2-Dichloropropane	95		94		70-130	1		30
Dibromochloromethane	96		99		70-130	3		30
1,1,2-Trichloroethane	94		94		70-130	0		30
Tetrachloroethene	99		100		70-130	1		30
Chlorobenzene	97		97		70-130	0		30
Trichlorofluoromethane	115		117		70-139	2		30
1,2-Dichloroethane	89		87		70-130	2		30
1,1,1-Trichloroethane	100		101		70-130	1		30
Bromodichloromethane	100		100		70-130	0		30
trans-1,3-Dichloropropene	92		92		70-130	0		30
cis-1,3-Dichloropropene	99		99		70-130	0		30
1,1-Dichloropropene	101		102		70-130	1		30
Bromoform	91		89		70-130	2		30
1,1,2,2-Tetrachloroethane	96		94		70-130	2		30
Benzene	98		99		70-130	1		30
Toluene	92		93		70-130	1		30
Ethylbenzene	93		94		70-130	1		30
Chloromethane	85		86		52-130	1		30
Bromomethane	**176**	Q	**176**	Q	57-147	0		30

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316865
Report Date: 04/20/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by EPA 5035 Low - Westborough Lab Associated sample(s): 06-07 Batch: WG1762421-3 WG1762421-4								
Vinyl chloride	107		109		67-130	2		30
Chloroethane	126		127		50-151	1		30
1,1-Dichloroethene	105		106		65-135	1		30
trans-1,2-Dichloroethene	99		100		70-130	1		30
Trichloroethene	106		107		70-130	1		30
1,2-Dichlorobenzene	96		95		70-130	1		30
1,3-Dichlorobenzene	96		94		70-130	2		30
1,4-Dichlorobenzene	95		93		70-130	2		30
Methyl tert butyl ether	87		87		66-130	0		30
p/m-Xylene	100		100		70-130	0		30
o-Xylene	97		97		70-130	0		30
cis-1,2-Dichloroethene	99		101		70-130	2		30
Dibromomethane	99		98		70-130	1		30
Styrene	94		95		70-130	1		30
Dichlorodifluoromethane	86		85		30-146	1		30
Acetone	76		70		54-140	8		30
Carbon disulfide	89		89		59-130	0		30
2-Butanone	75		70		70-130	7		30
Vinyl acetate	86		82		70-130	5		30
4-Methyl-2-pentanone	76		74		70-130	3		30
1,2,3-Trichloropropane	88		86		68-130	2		30
2-Hexanone	75		76		70-130	1		30
Bromochloromethane	97		96		70-130	1		30

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2316865

Report Date: 04/20/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by EPA 5035 Low - Westborough Lab Associated sample(s): 06-07 Batch: WG1762421-3 WG1762421-4								
2,2-Dichloropropane	94		92		70-130	2		30
1,2-Dibromoethane	98		96		70-130	2		30
1,3-Dichloropropane	92		91		69-130	1		30
1,1,1,2-Tetrachloroethane	93		94		70-130	1		30
Bromobenzene	92		91		70-130	1		30
n-Butylbenzene	101		100		70-130	1		30
sec-Butylbenzene	100		99		70-130	1		30
tert-Butylbenzene	96		95		70-130	1		30
o-Chlorotoluene	92		91		70-130	1		30
p-Chlorotoluene	92		91		70-130	1		30
1,2-Dibromo-3-chloropropane	94		92		68-130	2		30
Hexachlorobutadiene	91		92		67-130	1		30
Isopropylbenzene	96		96		70-130	0		30
p-Isopropyltoluene	98		97		70-130	1		30
Naphthalene	95		92		70-130	3		30
Acrylonitrile	85		85		70-130	0		30
n-Propylbenzene	96		95		70-130	1		30
1,2,3-Trichlorobenzene	99		95		70-130	4		30
1,2,4-Trichlorobenzene	97		95		70-130	2		30
1,3,5-Trimethylbenzene	94		94		70-130	0		30
1,2,4-Trimethylbenzene	94		93		70-130	1		30
1,4-Dioxane	90		91		65-136	1		30
p-Diethylbenzene	98		97		70-130	1		30

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by EPA 5035 Low - Westborough Lab Associated sample(s): 06-07 Batch: WG1762421-3 WG1762421-4								
p-Ethyltoluene	97		96		70-130	1		30
1,2,4,5-Tetramethylbenzene	95		93		70-130	2		30
Ethyl ether	119		120		67-130	1		30
trans-1,4-Dichloro-2-butene	87		84		70-130	4		30

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
1,2-Dichloroethane-d4	93		91		70-130
Toluene-d8	97		98		70-130
4-Bromofluorobenzene	89		88		70-130
Dibromofluoromethane	102		102		70-130

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316865
Report Date: 04/20/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by GC/MS - Westborough Lab Associated sample(s): 01-05 Batch: WG1763545-3 WG1763545-4								
Methylene chloride	110		100		70-130	10		20
1,1-Dichloroethane	120		120		70-130	0		20
Chloroform	110		110		70-130	0		20
Carbon tetrachloride	120		110		63-132	9		20
1,2-Dichloropropane	110		110		70-130	0		20
Dibromochloromethane	89		92		63-130	3		20
1,1,2-Trichloroethane	92		95		70-130	3		20
Tetrachloroethene	110		110		70-130	0		20
Chlorobenzene	100		100		75-130	0		20
Trichlorofluoromethane	140		140		62-150	0		20
1,2-Dichloroethane	110		120		70-130	9		20
1,1,1-Trichloroethane	120		120		67-130	0		20
Bromodichloromethane	100		100		67-130	0		20
trans-1,3-Dichloropropene	92		95		70-130	3		20
cis-1,3-Dichloropropene	97		99		70-130	2		20
1,1-Dichloropropene	110		110		70-130	0		20
Bromoform	81		87		54-136	7		20
1,1,2,2-Tetrachloroethane	79		87		67-130	10		20
Benzene	100		100		70-130	0		20
Toluene	99		99		70-130	0		20
Ethylbenzene	100		100		70-130	0		20
Chloromethane	110		110		64-130	0		20
Bromomethane	83		87		39-139	5		20

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316865
Report Date: 04/20/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by GC/MS - Westborough Lab Associated sample(s): 01-05 Batch: WG1763545-3 WG1763545-4								
Vinyl chloride	130		130		55-140	0		20
Chloroethane	**140**	Q	**140**	Q	55-138	0		20
1,1-Dichloroethene	120		120		61-145	0		20
trans-1,2-Dichloroethene	110		110		70-130	0		20
Trichloroethene	120		110		70-130	9		20
1,2-Dichlorobenzene	95		98		70-130	3		20
1,3-Dichlorobenzene	98		100		70-130	2		20
1,4-Dichlorobenzene	96		98		70-130	2		20
Methyl tert butyl ether	95		100		63-130	5		20
p/m-Xylene	100		105		70-130	5		20
o-Xylene	100		100		70-130	0		20
cis-1,2-Dichloroethene	110		110		70-130	0		20
Dibromomethane	92		97		70-130	5		20
1,2,3-Trichloropropane	82		90		64-130	9		20
Acrylonitrile	100		120		70-130	18		20
Styrene	100		100		70-130	0		20
Dichlorodifluoromethane	130		130		36-147	0		20
Acetone	86		100		58-148	15		20
Carbon disulfide	110		110		51-130	0		20
2-Butanone	85		81		63-138	5		20
Vinyl acetate	98		100		70-130	2		20
4-Methyl-2-pentanone	81		93		59-130	14		20
2-Hexanone	74		84		57-130	13		20

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316865
Report Date: 04/20/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by GC/MS - Westborough Lab Associated sample(s): 01-05 Batch: WG1763545-3 WG1763545-4								
Bromochloromethane	100		110		70-130	10		20
2,2-Dichloropropane	120		120		63-133	0		20
1,2-Dibromoethane	88		95		70-130	8		20
1,3-Dichloropropane	91		95		70-130	4		20
1,1,1,2-Tetrachloroethane	96		97		64-130	1		20
Bromobenzene	94		96		70-130	2		20
n-Butylbenzene	97		97		53-136	0		20
sec-Butylbenzene	99		100		70-130	1		20
tert-Butylbenzene	100		99		70-130	1		20
o-Chlorotoluene	96		96		70-130	0		20
p-Chlorotoluene	95		96		70-130	1		20
1,2-Dibromo-3-chloropropane	71		79		41-144	11		20
Hexachlorobutadiene	100		100		63-130	0		20
Isopropylbenzene	97		97		70-130	0		20
p-Isopropyltoluene	100		100		70-130	0		20
Naphthalene	70		81		70-130	15		20
n-Propylbenzene	98		97		69-130	1		20
1,2,3-Trichlorobenzene	85		94		70-130	10		20
1,2,4-Trichlorobenzene	89		96		70-130	8		20
1,3,5-Trimethylbenzene	96		96		64-130	0		20
1,2,4-Trimethylbenzene	93		95		70-130	2		20
1,4-Dioxane	96		110		56-162	14		20
p-Diethylbenzene	98		97		70-130	1		20

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2316865

Report Date: 04/20/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by GC/MS - Westborough Lab Associated sample(s): 01-05 Batch: WG1763545-3 WG1763545-4								
p-Ethyltoluene	97		97		70-130	0		20
1,2,4,5-Tetramethylbenzene	90		91		70-130	1		20
Ethyl ether	110		120		59-134	9		20
trans-1,4-Dichloro-2-butene	82		87		70-130	6		20

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
1,2-Dichloroethane-d4	121		124		70-130
Toluene-d8	103		102		70-130
4-Bromofluorobenzene	92		92		70-130
Dibromofluoromethane	108		108		70-130

SEMIVOLATILES

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-01
Client ID: GW-3
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 13:00
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E
Analytical Date: 04/04/23 04:18
Analyst: LJG

Extraction Method: EPA 3510C
Extraction Date: 04/03/23 15:58

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
1,2,4-Trichlorobenzene	ND		ug/l	5.0	0.50	1
Bis(2-chloroethyl)ether	ND		ug/l	2.0	0.50	1
1,2-Dichlorobenzene	ND		ug/l	2.0	0.45	1
1,3-Dichlorobenzene	ND		ug/l	2.0	0.40	1
1,4-Dichlorobenzene	ND		ug/l	2.0	0.43	1
3,3'-Dichlorobenzidine	ND		ug/l	5.0	1.6	1
2,4-Dinitrotoluene	ND		ug/l	5.0	1.2	1
2,6-Dinitrotoluene	ND		ug/l	5.0	0.93	1
4-Chlorophenyl phenyl ether	ND		ug/l	2.0	0.49	1
4-Bromophenyl phenyl ether	ND		ug/l	2.0	0.38	1
Bis(2-chloroisopropyl)ether	ND		ug/l	2.0	0.53	1
Bis(2-chloroethoxy)methane	ND		ug/l	5.0	0.50	1
Hexachlorocyclopentadiene	ND		ug/l	20	0.69	1
Isophorone	ND		ug/l	5.0	1.2	1
Nitrobenzene	ND		ug/l	2.0	0.77	1
NDPA/DPA	ND		ug/l	2.0	0.42	1
n-Nitrosodi-n-propylamine	ND		ug/l	5.0	0.64	1
Bis(2-ethylhexyl)phthalate	ND		ug/l	3.0	1.5	1
Butyl benzyl phthalate	ND		ug/l	5.0	1.2	1
Di-n-butylphthalate	2.3	J	ug/l	5.0	0.39	1
Di-n-octylphthalate	ND		ug/l	5.0	1.3	1
Diethyl phthalate	ND		ug/l	5.0	0.38	1
Dimethyl phthalate	ND		ug/l	5.0	1.8	1
Biphenyl	ND		ug/l	2.0	0.46	1
4-Chloroaniline	ND		ug/l	5.0	1.1	1
2-Nitroaniline	ND		ug/l	5.0	0.50	1
3-Nitroaniline	ND		ug/l	5.0	0.81	1
4-Nitroaniline	ND		ug/l	5.0	0.80	1

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-01 Date Collected: 03/30/23 13:00

Client ID: GW-3 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Dibenzofuran	ND		ug/l	2.0	0.50	1
1,2,4,5-Tetrachlorobenzene	ND		ug/l	10	0.44	1
Acetophenone	ND		ug/l	5.0	0.53	1
2,4,6-Trichlorophenol	ND		ug/l	5.0	0.61	1
p-Chloro-m-cresol	ND		ug/l	2.0	0.35	1
2-Chlorophenol	ND		ug/l	2.0	0.48	1
2,4-Dichlorophenol	ND		ug/l	5.0	0.41	1
2,4-Dimethylphenol	ND		ug/l	5.0	1.8	1
2-Nitrophenol	ND		ug/l	10	0.85	1
4-Nitrophenol	ND		ug/l	10	0.67	1
2,4-Dinitrophenol	ND		ug/l	20	6.6	1
4,6-Dinitro-o-cresol	ND		ug/l	10	1.8	1
Phenol	ND		ug/l	5.0	0.57	1
2-Methylphenol	ND		ug/l	5.0	0.49	1
3-Methylphenol/4-Methylphenol	ND		ug/l	5.0	0.48	1
2,4,5-Trichlorophenol	ND		ug/l	5.0	0.77	1
Benzoic Acid	10.	J	ug/l	50	2.6	1
Benzyl Alcohol	ND		ug/l	2.0	0.59	1
Carbazole	ND		ug/l	2.0	0.49	1

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-01 Date Collected: 03/30/23 13:00

Client ID: GW-3 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Tentatively Identified Compounds						
Total TIC Compounds	393	J	ug/l			1
Unknown	4.54	J	ug/l			1
Unknown	6.22	J	ug/l			1
Unknown	91.1	J	ug/l			1
Unknown	79.2	J	ug/l			1
Unknown	58.4	J	ug/l			1
Unknown	4.40	J	ug/l			1
Unknown	4.18	JB	ug/l			1
Unknown	6.84	JB	ug/l			1
Unknown	4.18	J	ug/l			1
Unknown	4.25	J	ug/l			1
Unknown	5.20	J	ug/l			1
Unknown	5.74	J	ug/l			1
Unknown	10.0	J	ug/l			1
Unknown Amide	9.24	J	ug/l			1
Unknown Organic Acid	100	JB	ug/l			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	72		21-120
Phenol-d6	59		10-120
Nitrobenzene-d5	81		23-120
2-Fluorobiphenyl	90		15-120
2,4,6-Tribromophenol	93		10-120
4-Terphenyl-d14	70		41-149

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-01
Client ID: GW-3
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 13:00
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E-SIM
Analytical Date: 04/04/23 10:52
Analyst: DV

Extraction Method: EPA 3510C
Extraction Date: 04/03/23 16:01

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS-SIM - Westborough Lab						
Acenaphthene	0.07	J	ug/l	0.10	0.01	1
2-Chloronaphthalene	ND		ug/l	0.20	0.02	1
Fluoranthene	0.22		ug/l	0.10	0.02	1
Hexachlorobutadiene	ND		ug/l	0.50	0.05	1
Naphthalene	0.18		ug/l	0.10	0.05	1
Benzo(a)anthracene	0.12		ug/l	0.10	0.02	1
Benzo(a)pyrene	0.10	J	ug/l	0.10	0.02	1
Benzo(b)fluoranthene	0.11		ug/l	0.10	0.01	1
Benzo(k)fluoranthene	0.04	J	ug/l	0.10	0.01	1
Chrysene	0.09	J	ug/l	0.10	0.01	1
Acenaphthylene	0.03	J	ug/l	0.10	0.01	1
Anthracene	0.06	J	ug/l	0.10	0.01	1
Benzo(ghi)perylene	0.07	J	ug/l	0.10	0.01	1
Fluorene	0.04	J	ug/l	0.10	0.01	1
Phenanthrene	0.18		ug/l	0.10	0.02	1
Dibenzo(a,h)anthracene	0.02	J	ug/l	0.10	0.01	1
Indeno(1,2,3-cd)pyrene	0.07	J	ug/l	0.10	0.01	1
Pyrene	0.20		ug/l	0.10	0.02	1
2-Methylnaphthalene	0.11		ug/l	0.10	0.02	1
Pentachlorophenol	0.09	J	ug/l	0.80	0.01	1
Hexachlorobenzene	ND		ug/l	0.80	0.01	1
Hexachloroethane	ND		ug/l	0.80	0.06	1

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-01 Date Collected: 03/30/23 13:00

Client ID: GW-3 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS-SIM - Westborough Lab						

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	76		21-120
Phenol-d6	71		10-120
Nitrobenzene-d5	106		23-120
2-Fluorobiphenyl	84		15-120
2,4,6-Tribromophenol	106		10-120
4-Terphenyl-d14	69		41-149

Project Name: 100 MAIN ST.
Lab Number: L2316865
Project Number: 12461
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-01
Client ID: GW-3
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 13:00
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E-SIM
Analytical Date: 04/05/23 16:09
Analyst: TPR

Extraction Method: EPA 3510C
Extraction Date: 04/04/23 11:35

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
1,4 Dioxane by 8270E-SIM - Mansfield Lab						
1,4-Dioxane	ND		ng/l	144	32.6	1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,4-Dioxane-d8	56		15-110

Project Name: 100 MAIN ST.
Lab Number: L2316865
Project Number: 12461
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-01
Client ID: GW-3
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 13:00
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 144,1633
Analytical Date: 04/19/23 20:52
Analyst: RS

Extraction Method: EPA 1633
Extraction Date: 04/19/23 06:53

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Perfluorinated Alkyl Acids by EPA 1633 - Mansfield Lab						
Perfluorobutanoic Acid (PFBA)	23.6		ng/l	6.25	1.00	1
Perfluoropentanoic Acid (PFPeA)	31.5		ng/l	3.12	0.836	1
Perfluorobutanesulfonic Acid (PFBS)	83.5		ng/l	1.56	0.523	1
Perfluorohexanoic Acid (PFHxA)	23.9		ng/l	1.56	0.461	1
Perfluoroheptanoic Acid (PFHpA)	16.2		ng/l	1.56	0.312	1
Perfluorohexanesulfonic Acid (PFHxS)	14.1		ng/l	1.56	0.375	1
Perfluorooctanoic Acid (PFOA)	26.3		ng/l	1.56	0.680	1
1H,1H,2H,2H-Perfluorooctanesulfonic Acid (6:2FTS)	7.42		ng/l	6.25	2.11	1
Perfluoroheptanesulfonic Acid (PFHpS)	ND		ng/l	1.56	0.422	1
Perfluorononanoic Acid (PFNA)	0.859	J	ng/l	1.56	0.492	1
Perfluorooctanesulfonic Acid (PFOS)	1.87		ng/l	1.56	0.711	1
Perfluorodecanoic Acid (PFDA)	1.48	J	ng/l	1.56	0.633	1
1H,1H,2H,2H-Perfluorodecanesulfonic Acid (8:2FTS)	ND		ng/l	6.25	2.43	1
N-Methyl Perfluorooctanesulfonamidoacetic Acid (NMeFOSAA)	ND		ng/l	1.56	0.852	1
Perfluoroundecanoic Acid (PFUnA)	ND		ng/l	1.56	0.680	1
Perfluorodecanesulfonic Acid (PFDS)	ND		ng/l	1.56	0.359	1
Perfluorooctanesulfonamide (PFOSA)	ND		ng/l	1.56	0.422	1
N-Ethyl Perfluorooctanesulfonamidoacetic Acid (NEtFOSAA)	ND		ng/l	1.56	0.844	1
Perfluorododecanoic Acid (PFDoA)	ND		ng/l	1.56	0.719	1
Perfluorotridecanoic Acid (PFTrDA)	ND		ng/l	1.56	0.586	1
Perfluorotetradecanoic Acid (PFTeDA)	ND		ng/l	1.56	0.414	1
PFOA/PFOS, Total	28.2		ng/l	1.56	0.680	1

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-01 Date Collected: 03/30/23 13:00

Client ID: GW-3 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Perfluorinated Alkyl Acids by EPA 1633 - Mansfield Lab						

Surrogate	% Recovery	Qualifier	Acceptance Criteria
Perfluoro-n-[13C4]Butanoic Acid (13C4-PFBA)	100		20-150
Perfluoro-n-[13C5]Pentanoic Acid (13C5-PFPeA)	89		20-150
Perfluoro-1-[2,3,4-13C3]Butanesulfonic Acid (13C3-PFBS)	94		20-150
Perfluoro-n-[1,2,3,4,6-13C5]Hexanoic Acid (13C5-PFHxA)	100		20-150
Perfluoro-n-[1,2,3,4-13C4]Heptanoic Acid (13C4-PFHpA)	91		20-150
Perfluoro-1-[1,2,3-13C3]Hexanesulfonic Acid (13C3-PFHxS)	97		20-150
Perfluoro-n-[13C8]Octanoic Acid (13C8-PFOA)	93		20-150
1H,1H,2H,2H-Perfluoro-1-[1,2-13C2]Octanesulfonic Acid (13C2-6:2FTS)	134		20-150
Perfluoro-n-[13C9]Nonanoic Acid (13C9-PFNA)	95		20-150
Perfluoro-1-[13C8]Octanesulfonic Acid (13C8-PFOS)	90		20-150
Perfluoro-n-[1,2,3,4,5,6-13C6]Decanoic Acid (13C6-PFDA)	88		20-150
1H,1H,2H,2H-Perfluoro-1-[1,2-13C2]Decanesulfonic Acid (13C2-8:2FTS)	132		20-150
N-Methyl-d3-perfluoro-1-octanesulfonamidoacetic Acid (D3-NMeFOSAA)	75		20-150
Perfluoro-n-[1,2,3,4,5,6,7-13C7]Undecanoic Acid (13C7-PFUnA)	82		20-150
Perfluoro-1-[13C8]Octanesulfonamide (13C8-PFOSA)	55		20-150
N-Ethyl-d5-perfluoro-1-octanesulfonamidoacetic Acid (D5-NEtFOSAA)	71		20-150
Perfluoro-n-[1,2-13C2]Dodecanoic Acid (13C2-PFDoA)	76		20-150
Perfluoro-n-[1,2-13C2]Tetradecanoic Acid (13C2-PFTeDA)	58		20-150

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-02
Client ID: GW-4
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 13:30
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E
Analytical Date: 04/04/23 12:55
Analyst: JG

Extraction Method: EPA 3510C
Extraction Date: 04/03/23 15:58

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
1,2,4-Trichlorobenzene	ND		ug/l	5.8	0.57	1
Bis(2-chloroethyl)ether	ND		ug/l	2.3	0.58	1
1,2-Dichlorobenzene	ND		ug/l	2.3	0.52	1
1,3-Dichlorobenzene	ND		ug/l	2.3	0.46	1
1,4-Dichlorobenzene	ND		ug/l	2.3	0.50	1
3,3'-Dichlorobenzidine	ND		ug/l	5.8	1.8	1
2,4-Dinitrotoluene	ND		ug/l	5.8	1.3	1
2,6-Dinitrotoluene	ND		ug/l	5.8	1.1	1
4-Chlorophenyl phenyl ether	ND		ug/l	2.3	0.56	1
4-Bromophenyl phenyl ether	ND		ug/l	2.3	0.43	1
Bis(2-chloroisopropyl)ether	ND		ug/l	2.3	0.60	1
Bis(2-chloroethoxy)methane	ND		ug/l	5.8	0.58	1
Hexachlorocyclopentadiene	ND		ug/l	23	0.79	1
Isophorone	ND		ug/l	5.8	1.4	1
Nitrobenzene	ND		ug/l	2.3	0.88	1
NDPA/DPA	ND		ug/l	2.3	0.48	1
n-Nitrosodi-n-propylamine	ND		ug/l	5.8	0.74	1
Bis(2-ethylhexyl)phthalate	ND		ug/l	3.4	1.8	1
Butyl benzyl phthalate	3.1	J	ug/l	5.8	1.3	1
Di-n-butylphthalate	1.5	J	ug/l	5.8	0.44	1
Di-n-octylphthalate	ND		ug/l	5.8	1.4	1
Diethyl phthalate	ND		ug/l	5.8	0.44	1
Dimethyl phthalate	ND		ug/l	5.8	2.1	1
Biphenyl	ND		ug/l	2.3	0.52	1
4-Chloroaniline	ND		ug/l	5.8	1.2	1
2-Nitroaniline	ND		ug/l	5.8	0.57	1
3-Nitroaniline	ND		ug/l	5.8	0.93	1
4-Nitroaniline	ND		ug/l	5.8	0.92	1

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-02 Date Collected: 03/30/23 13:30

Client ID: GW-4 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Dibenzofuran	ND		ug/l	2.3	0.57	1
1,2,4,5-Tetrachlorobenzene	ND		ug/l	11	0.50	1
Acetophenone	ND		ug/l	5.8	0.60	1
2,4,6-Trichlorophenol	ND		ug/l	5.8	0.70	1
p-Chloro-m-cresol	ND		ug/l	2.3	0.40	1
2-Chlorophenol	ND		ug/l	2.3	0.55	1
2,4-Dichlorophenol	ND		ug/l	5.8	0.47	1
2,4-Dimethylphenol	ND		ug/l	5.8	2.0	1
2-Nitrophenol	ND		ug/l	11	0.97	1
4-Nitrophenol	ND		ug/l	11	0.77	1
2,4-Dinitrophenol	ND		ug/l	23	7.6	1
4,6-Dinitro-o-cresol	ND		ug/l	11	2.1	1
Phenol	0.72	J	ug/l	5.8	0.65	1
2-Methylphenol	ND		ug/l	5.8	0.56	1
3-Methylphenol/4-Methylphenol	ND		ug/l	5.8	0.55	1
2,4,5-Trichlorophenol	ND		ug/l	5.8	0.89	1
Benzoic Acid	65.		ug/l	58	3.0	1
Benzyl Alcohol	31.		ug/l	2.3	0.68	1
Carbazole	ND		ug/l	2.3	0.56	1

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-02 Date Collected: 03/30/23 13:30

Client ID: GW-4 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Tentatively Identified Compounds						
Total TIC Compounds	427	J	ug/l			1
Unknown	36.5	J	ug/l			1
Unknown	13.1	J	ug/l			1
Unknown	12.7	J	ug/l			1
Unknown	23.7	J	ug/l			1
Unknown Organic Acid	15.2	J	ug/l			1
Unknown Organic Acid	87.5	J	ug/l			1
Unknown Alcohol	14.8	J	ug/l			1
Unknown	19.2	J	ug/l			1
Unknown	92.6	J	ug/l			1
Unknown Aldehyde	12.1	J	ug/l			1
Unknown	15.6	J	ug/l			1
Unknown	21.9	J	ug/l			1
Unknown Organic Acid	27.0	J	ug/l			1
Unknown	11.2	J	ug/l			1
Unknown	24.2	J	ug/l			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	79		21-120
Phenol-d6	69		10-120
Nitrobenzene-d5	91		23-120
2-Fluorobiphenyl	68		15-120
2,4,6-Tribromophenol	87		10-120
4-Terphenyl-d14	59		41-149

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-02
Client ID: GW-4
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 13:30
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E-SIM
Analytical Date: 04/04/23 11:09
Analyst: DV

Extraction Method: EPA 3510C
Extraction Date: 04/03/23 16:01

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS-SIM - Westborough Lab						
Acenaphthene	0.16		ug/l	0.11	0.02	1
2-Chloronaphthalene	ND		ug/l	0.23	0.02	1
Fluoranthene	0.15		ug/l	0.11	0.02	1
Hexachlorobutadiene	ND		ug/l	0.57	0.05	1
Naphthalene	0.37		ug/l	0.11	0.06	1
Benzo(a)anthracene	0.07	J	ug/l	0.11	0.02	1
Benzo(a)pyrene	0.05	J	ug/l	0.11	0.02	1
Benzo(b)fluoranthene	0.06	J	ug/l	0.11	0.01	1
Benzo(k)fluoranthene	0.02	J	ug/l	0.11	0.01	1
Chrysene	0.05	J	ug/l	0.11	0.01	1
Acenaphthylene	0.05	J	ug/l	0.11	0.01	1
Anthracene	0.14		ug/l	0.11	0.02	1
Benzo(ghi)perylene	0.03	J	ug/l	0.11	0.02	1
Fluorene	0.06	J	ug/l	0.11	0.02	1
Phenanthrene	0.18		ug/l	0.11	0.03	1
Dibenzo(a,h)anthracene	ND		ug/l	0.11	0.01	1
Indeno(1,2,3-cd)pyrene	0.03	J	ug/l	0.11	0.01	1
Pyrene	0.17		ug/l	0.11	0.02	1
2-Methylnaphthalene	0.19		ug/l	0.11	0.03	1
Pentachlorophenol	ND		ug/l	0.92	0.02	1
Hexachlorobenzene	ND		ug/l	0.92	0.01	1
Hexachloroethane	ND		ug/l	0.92	0.07	1

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-02 Date Collected: 03/30/23 13:30

Client ID: GW-4 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS-SIM - Westborough Lab						

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	79		21-120
Phenol-d6	77		10-120
Nitrobenzene-d5	106		23-120
2-Fluorobiphenyl	80		15-120
2,4,6-Tribromophenol	102		10-120
4-Terphenyl-d14	65		41-149

Project Name: 100 MAIN ST.
Lab Number: L2316865
Project Number: 12461
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-02
Client ID: GW-4
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 13:30
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E-SIM
Analytical Date: 04/05/23 16:33
Analyst: TPR

Extraction Method: EPA 3510C
Extraction Date: 04/04/23 11:35

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
1,4 Dioxane by 8270E-SIM - Mansfield Lab						
1,4-Dioxane	2030		ng/l	139	31.4	1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,4-Dioxane-d8	57		15-110

Project Name: 100 MAIN ST.
Lab Number: L2316865
Project Number: 12461
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-02
Client ID: GW-4
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 13:30
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 144,1633
Analytical Date: 04/19/23 21:05
Analyst: RS

Extraction Method: EPA 1633
Extraction Date: 04/19/23 06:53

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Perfluorinated Alkyl Acids by EPA 1633 - Mansfield Lab						
Perfluorobutanoic Acid (PFBA)	26.4		ng/l	6.41	1.02	1
Perfluoropentanoic Acid (PFPeA)	36.0		ng/l	3.20	0.857	1
Perfluorobutanesulfonic Acid (PFBS)	22.2		ng/l	1.60	0.536	1
Perfluorohexanoic Acid (PFHxA)	40.1		ng/l	1.60	0.472	1
Perfluoroheptanoic Acid (PFHpA)	17.4		ng/l	1.60	0.320	1
Perfluorohexanesulfonic Acid (PFHxS)	12.7		ng/l	1.60	0.384	1
Perfluorooctanoic Acid (PFOA)	31.8		ng/l	1.60	0.697	1
1H,1H,2H,2H-Perfluorooctanesulfonic Acid (6:2FTS)	58.6		ng/l	6.41	2.16	1
Perfluoroheptanesulfonic Acid (PFHpS)	0.961	J	ng/l	1.60	0.432	1
Perfluorononanoic Acid (PFNA)	1.20	J	ng/l	1.60	0.504	1
Perfluorooctanesulfonic Acid (PFOS)	10.9		ng/l	1.60	0.729	1
Perfluorodecanoic Acid (PFDA)	1.52	J	ng/l	1.60	0.649	1
1H,1H,2H,2H-Perfluorodecanesulfonic Acid (8:2FTS)	6.73		ng/l	6.41	2.49	1
N-Methyl Perfluorooctanesulfonamidoacetic Acid (NMeFOSAA)	ND		ng/l	1.60	0.873	1
Perfluoroundecanoic Acid (PFUnA)	ND		ng/l	1.60	0.697	1
Perfluorodecanesulfonic Acid (PFDS)	ND		ng/l	1.60	0.368	1
Perfluorooctanesulfonamide (PFOSA)	1.92		ng/l	1.60	0.432	1
N-Ethyl Perfluorooctanesulfonamidoacetic Acid (NEtFOSAA)	2.96		ng/l	1.60	0.865	1
Perfluorododecanoic Acid (PFDoA)	ND		ng/l	1.60	0.737	1
Perfluorotridecanoic Acid (PFTrDA)	ND		ng/l	1.60	0.600	1
Perfluorotetradecanoic Acid (PFTeDA)	ND		ng/l	1.60	0.424	1
PFOA/PFOS, Total	42.7		ng/l	1.60	0.697	1

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-02 Date Collected: 03/30/23 13:30

Client ID: GW-4 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Perfluorinated Alkyl Acids by EPA 1633 - Mansfield Lab						

Surrogate	% Recovery	Qualifier	Acceptance Criteria
Perfluoro-n-[13C4]Butanoic Acid (13C4-PFBA)	105		20-150
Perfluoro-n-[13C5]Pentanoic Acid (13C5-PFPeA)	97		20-150
Perfluoro-1-[2,3,4-13C3]Butanesulfonic Acid (13C3-PFBS)	105		20-150
Perfluoro-n-[1,2,3,4,6-13C5]Hexanoic Acid (13C5-PFHxA)	109		20-150
Perfluoro-n-[1,2,3,4-13C4]Heptanoic Acid (13C4-PFHpA)	101		20-150
Perfluoro-1-[1,2,3-13C3]Hexanesulfonic Acid (13C3-PFHxS)	103		20-150
Perfluoro-n-[13C8]Octanoic Acid (13C8-PFOA)	102		20-150
1H,1H,2H,2H-Perfluoro-1-[1,2-13C2]Octanesulfonic Acid (13C2-6:2FTS)	143		20-150
Perfluoro-n-[13C9]Nonanoic Acid (13C9-PFNA)	88		20-150
Perfluoro-1-[13C8]Octanesulfonic Acid (13C8-PFOS)	88		20-150
Perfluoro-n-[1,2,3,4,5,6-13C6]Decanoic Acid (13C6-PFDA)	87		20-150
1H,1H,2H,2H-Perfluoro-1-[1,2-13C2]Decanesulfonic Acid (13C2-8:2FTS)	137		20-150
N-Methyl-d3-perfluoro-1-octanesulfonamidoacetic Acid (D3-NMeFOSAA)	103		20-150
Perfluoro-n-[1,2,3,4,5,6,7-13C7]Undecanoic Acid (13C7-PFUnA)	95		20-150
Perfluoro-1-[13C8]Octanesulfonamide (13C8-PFOSA)	67		20-150
N-Ethyl-d5-perfluoro-1-octanesulfonamidoacetic Acid (D5-NEtFOSAA)	79		20-150
Perfluoro-n-[1,2-13C2]Dodecanoic Acid (13C2-PFDoA)	86		20-150
Perfluoro-n-[1,2-13C2]Tetradecanoic Acid (13C2-PFTeDA)	70		20-150

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-03
Client ID: GW-5
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 10:30
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E
Analytical Date: 04/04/23 13:21
Analyst: JG

Extraction Method: EPA 3510C
Extraction Date: 04/03/23 15:58

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
1,2,4-Trichlorobenzene	ND		ug/l	5.0	0.50	1
Bis(2-chloroethyl)ether	ND		ug/l	2.0	0.50	1
1,2-Dichlorobenzene	ND		ug/l	2.0	0.45	1
1,3-Dichlorobenzene	ND		ug/l	2.0	0.40	1
1,4-Dichlorobenzene	ND		ug/l	2.0	0.43	1
3,3'-Dichlorobenzidine	ND		ug/l	5.0	1.6	1
2,4-Dinitrotoluene	ND		ug/l	5.0	1.2	1
2,6-Dinitrotoluene	ND		ug/l	5.0	0.93	1
4-Chlorophenyl phenyl ether	ND		ug/l	2.0	0.49	1
4-Bromophenyl phenyl ether	ND		ug/l	2.0	0.38	1
Bis(2-chloroisopropyl)ether	ND		ug/l	2.0	0.53	1
Bis(2-chloroethoxy)methane	ND		ug/l	5.0	0.50	1
Hexachlorocyclopentadiene	ND		ug/l	20	0.69	1
Isophorone	ND		ug/l	5.0	1.2	1
Nitrobenzene	ND		ug/l	2.0	0.77	1
NDPA/DPA	ND		ug/l	2.0	0.42	1
n-Nitrosodi-n-propylamine	ND		ug/l	5.0	0.64	1
Bis(2-ethylhexyl)phthalate	ND		ug/l	3.0	1.5	1
Butyl benzyl phthalate	ND		ug/l	5.0	1.2	1
Di-n-butylphthalate	ND		ug/l	5.0	0.39	1
Di-n-octylphthalate	ND		ug/l	5.0	1.3	1
Diethyl phthalate	ND		ug/l	5.0	0.38	1
Dimethyl phthalate	ND		ug/l	5.0	1.8	1
Biphenyl	ND		ug/l	2.0	0.46	1
4-Chloroaniline	ND		ug/l	5.0	1.1	1
2-Nitroaniline	ND		ug/l	5.0	0.50	1
3-Nitroaniline	ND		ug/l	5.0	0.81	1
4-Nitroaniline	ND		ug/l	5.0	0.80	1

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-03 Date Collected: 03/30/23 10:30

Client ID: GW-5 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Dibenzofuran	ND		ug/l	2.0	0.50	1
1,2,4,5-Tetrachlorobenzene	ND		ug/l	10	0.44	1
Acetophenone	ND		ug/l	5.0	0.53	1
2,4,6-Trichlorophenol	ND		ug/l	5.0	0.61	1
p-Chloro-m-cresol	ND		ug/l	2.0	0.35	1
2-Chlorophenol	ND		ug/l	2.0	0.48	1
2,4-Dichlorophenol	ND		ug/l	5.0	0.41	1
2,4-Dimethylphenol	ND		ug/l	5.0	1.8	1
2-Nitrophenol	ND		ug/l	10	0.85	1
4-Nitrophenol	ND		ug/l	10	0.67	1
2,4-Dinitrophenol	ND		ug/l	20	6.6	1
4,6-Dinitro-o-cresol	ND		ug/l	10	1.8	1
Phenol	ND		ug/l	5.0	0.57	1
2-Methylphenol	ND		ug/l	5.0	0.49	1
3-Methylphenol/4-Methylphenol	ND		ug/l	5.0	0.48	1
2,4,5-Trichlorophenol	ND		ug/l	5.0	0.77	1
Benzoic Acid	9.3	J	ug/l	50	2.6	1
Benzyl Alcohol	ND		ug/l	2.0	0.59	1
Carbazole	ND		ug/l	2.0	0.49	1

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-03 Date Collected: 03/30/23 10:30

Client ID: GW-5 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Tentatively Identified Compounds						
Total TIC Compounds	79.0	J	ug/l			1
Unknown	4.94	J	ug/l			1
Unknown	3.05	J	ug/l			1
Unknown	2.36	J	ug/l			1
Unknown	3.85	JB	ug/l			1
Unknown	2.80	J	ug/l			1
Unknown	2.07	J	ug/l			1
Unknown	2.11	J	ug/l			1
Unknown	1.74	JB	ug/l			1
Unknown	4.25	J	ug/l			1
Unknown	1.93	J	ug/l			1
Unknown Alcohol	3.31	J	ug/l			1
Unknown Organic Acid	1.96	J	ug/l			1
Unknown Organic Acid	3.31	J	ug/l			1
Unknown Organic Acid	15.3	J	ug/l			1
Unknown Organic Acid	26.0	J	ug/l			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	63		21-120
Phenol-d6	53		10-120
Nitrobenzene-d5	79		23-120
2-Fluorobiphenyl	63		15-120
2,4,6-Tribromophenol	81		10-120
4-Terphenyl-d14	64		41-149

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-03
Client ID: GW-5
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 10:30
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E-SIM
Analytical Date: 04/04/23 11:25
Analyst: DV

Extraction Method: EPA 3510C
Extraction Date: 04/03/23 16:01

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS-SIM - Westborough Lab						
Acenaphthene	0.03	J	ug/l	0.10	0.01	1
2-Chloronaphthalene	ND		ug/l	0.20	0.02	1
Fluoranthene	0.17		ug/l	0.10	0.02	1
Hexachlorobutadiene	ND		ug/l	0.50	0.05	1
Naphthalene	ND		ug/l	0.10	0.05	1
Benzo(a)anthracene	0.09	J	ug/l	0.10	0.02	1
Benzo(a)pyrene	0.08	J	ug/l	0.10	0.02	1
Benzo(b)fluoranthene	0.09	J	ug/l	0.10	0.01	1
Benzo(k)fluoranthene	0.04	J	ug/l	0.10	0.01	1
Chrysene	0.06	J	ug/l	0.10	0.01	1
Acenaphthylene	0.01	J	ug/l	0.10	0.01	1
Anthracene	0.04	J	ug/l	0.10	0.01	1
Benzo(ghi)perylene	0.06	J	ug/l	0.10	0.01	1
Fluorene	0.03	J	ug/l	0.10	0.01	1
Phenanthrene	0.14		ug/l	0.10	0.02	1
Dibenzo(a,h)anthracene	0.02	J	ug/l	0.10	0.01	1
Indeno(1,2,3-cd)pyrene	0.06	J	ug/l	0.10	0.01	1
Pyrene	0.14		ug/l	0.10	0.02	1
2-Methylnaphthalene	ND		ug/l	0.10	0.02	1
Pentachlorophenol	ND		ug/l	0.80	0.01	1
Hexachlorobenzene	ND		ug/l	0.80	0.01	1
Hexachloroethane	ND		ug/l	0.80	0.06	1

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-03 Date Collected: 03/30/23 10:30

Client ID: GW-5 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS-SIM - Westborough Lab						

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	64		21-120
Phenol-d6	59		10-120
Nitrobenzene-d5	95		23-120
2-Fluorobiphenyl	74		15-120
2,4,6-Tribromophenol	92		10-120
4-Terphenyl-d14	68		41-149

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-03
Client ID: GW-5
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 10:30
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E-SIM
Analytical Date: 04/06/23 20:02
Analyst: TPR

Extraction Method: EPA 3510C
Extraction Date: 04/04/23 17:03

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
1,4 Dioxane by 8270E-SIM - Mansfield Lab						
1,4-Dioxane	ND		ng/l	136	30.8	1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,4-Dioxane-d8	38		15-110

Project Name: 100 MAIN ST.
Lab Number: L2316865
Project Number: 12461
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-03
Client ID: GW-5
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 10:30
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 144,1633
Analytical Date: 04/19/23 21:18
Analyst: RS

Extraction Method: EPA 1633
Extraction Date: 04/19/23 06:53

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Perfluorinated Alkyl Acids by EPA 1633 - Mansfield Lab						
Perfluorobutanoic Acid (PFBA)	5.69	J	ng/l	6.41	1.02	1
Perfluoropentanoic Acid (PFPeA)	8.33		ng/l	3.20	0.857	1
Perfluorobutanesulfonic Acid (PFBS)	2.24		ng/l	1.60	0.537	1
Perfluorohexanoic Acid (PFHxA)	4.65		ng/l	1.60	0.473	1
Perfluoroheptanoic Acid (PFHpA)	2.32	F	ng/l	1.60	0.320	1
Perfluorohexanesulfonic Acid (PFHxS)	3.60		ng/l	1.60	0.384	1
Perfluorooctanoic Acid (PFOA)	7.05		ng/l	1.60	0.697	1
1H,1H,2H,2H-Perfluorooctanesulfonic Acid (6:2FTS)	ND		ng/l	6.41	2.16	1
Perfluoroheptanesulfonic Acid (PFHpS)	ND		ng/l	1.60	0.432	1
Perfluorononanoic Acid (PFNA)	1.52	J	ng/l	1.60	0.505	1
Perfluorooctanesulfonic Acid (PFOS)	20.8		ng/l	1.60	0.729	1
Perfluorodecanoic Acid (PFDA)	1.12	JF	ng/l	1.60	0.649	1
1H,1H,2H,2H-Perfluorodecanesulfonic Acid (8:2FTS)	ND		ng/l	6.41	2.49	1
N-Methyl Perfluorooctanesulfonamidoacetic Acid (NMeFOSAA)	ND		ng/l	1.60	0.873	1
Perfluoroundecanoic Acid (PFUnA)	ND		ng/l	1.60	0.697	1
Perfluorodecanesulfonic Acid (PFDS)	0.481	J	ng/l	1.60	0.368	1
Perfluorooctanesulfonamide (PFOSA)	1.28	J	ng/l	1.60	0.432	1
N-Ethyl Perfluorooctanesulfonamidoacetic Acid (NEtFOSAA)	5.77		ng/l	1.60	0.865	1
Perfluorododecanoic Acid (PFDoA)	ND		ng/l	1.60	0.737	1
Perfluorotridecanoic Acid (PFTrDA)	ND		ng/l	1.60	0.601	1
Perfluorotetradecanoic Acid (PFTeDA)	ND		ng/l	1.60	0.424	1
PFOA/PFOS, Total	27.9		ng/l	1.60	0.697	1

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-03 Date Collected: 03/30/23 10:30

Client ID: GW-5 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Perfluorinated Alkyl Acids by EPA 1633 - Mansfield Lab						

Surrogate	% Recovery	Qualifier	Acceptance Criteria
Perfluoro-n-[13C4]Butanoic Acid (13C4-PFBA)	94		20-150
Perfluoro-n-[13C5]Pentanoic Acid (13C5-PFPeA)	90		20-150
Perfluoro-1-[2,3,4-13C3]Butanesulfonic Acid (13C3-PFBS)	90		20-150
Perfluoro-n-[1,2,3,4,6-13C5]Hexanoic Acid (13C5-PFHxA)	91		20-150
Perfluoro-n-[1,2,3,4-13C4]Heptanoic Acid (13C4-PFHpA)	83		20-150
Perfluoro-1-[1,2,3-13C3]Hexanesulfonic Acid (13C3-PFHxS)	91		20-150
Perfluoro-n-[13C8]Octanoic Acid (13C8-PFOA)	88		20-150
1H,1H,2H,2H-Perfluoro-1-[1,2-13C2]Octanesulfonic Acid (13C2-6:2FTS)	95		20-150
Perfluoro-n-[13C9]Nonanoic Acid (13C9-PFNA)	80		20-150
Perfluoro-1-[13C8]Octanesulfonic Acid (13C8-PFOS)	86		20-150
Perfluoro-n-[1,2,3,4,5,6-13C6]Decanoic Acid (13C6-PFDA)	96		20-150
1H,1H,2H,2H-Perfluoro-1-[1,2-13C2]Decanesulfonic Acid (13C2-8:2FTS)	105		20-150
N-Methyl-d3-perfluoro-1-octanesulfonamidoacetic Acid (D3-NMeFOSAA)	71		20-150
Perfluoro-n-[1,2,3,4,5,6,7-13C7]Undecanoic Acid (13C7-PFUnA)	89		20-150
Perfluoro-1-[13C8]Octanesulfonamide (13C8-PFOSA)	53		20-150
N-Ethyl-d5-perfluoro-1-octanesulfonamidoacetic Acid (D5-NEtFOSAA)	72		20-150
Perfluoro-n-[1,2-13C2]Dodecanoic Acid (13C2-PFDoA)	62		20-150
Perfluoro-n-[1,2-13C2]Tetradecanoic Acid (13C2-PFTeDA)	42		20-150

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-04
Client ID: GW-6
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 11:00
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E
Analytical Date: 04/04/23 13:46
Analyst: JG

Extraction Method: EPA 3510C
Extraction Date: 04/03/23 15:58

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
1,2,4-Trichlorobenzene	ND		ug/l	5.0	0.50	1
Bis(2-chloroethyl)ether	ND		ug/l	2.0	0.50	1
1,2-Dichlorobenzene	ND		ug/l	2.0	0.45	1
1,3-Dichlorobenzene	ND		ug/l	2.0	0.40	1
1,4-Dichlorobenzene	ND		ug/l	2.0	0.43	1
3,3'-Dichlorobenzidine	ND		ug/l	5.0	1.6	1
2,4-Dinitrotoluene	ND		ug/l	5.0	1.2	1
2,6-Dinitrotoluene	ND		ug/l	5.0	0.93	1
4-Chlorophenyl phenyl ether	ND		ug/l	2.0	0.49	1
4-Bromophenyl phenyl ether	ND		ug/l	2.0	0.38	1
Bis(2-chloroisopropyl)ether	ND		ug/l	2.0	0.53	1
Bis(2-chloroethoxy)methane	ND		ug/l	5.0	0.50	1
Hexachlorocyclopentadiene	ND		ug/l	20	0.69	1
Isophorone	ND		ug/l	5.0	1.2	1
Nitrobenzene	ND		ug/l	2.0	0.77	1
NDPA/DPA	ND		ug/l	2.0	0.42	1
n-Nitrosodi-n-propylamine	ND		ug/l	5.0	0.64	1
Bis(2-ethylhexyl)phthalate	ND		ug/l	3.0	1.5	1
Butyl benzyl phthalate	ND		ug/l	5.0	1.2	1
Di-n-butylphthalate	ND		ug/l	5.0	0.39	1
Di-n-octylphthalate	ND		ug/l	5.0	1.3	1
Diethyl phthalate	ND		ug/l	5.0	0.38	1
Dimethyl phthalate	ND		ug/l	5.0	1.8	1
Biphenyl	ND		ug/l	2.0	0.46	1
4-Chloroaniline	ND		ug/l	5.0	1.1	1
2-Nitroaniline	ND		ug/l	5.0	0.50	1
3-Nitroaniline	ND		ug/l	5.0	0.81	1
4-Nitroaniline	ND		ug/l	5.0	0.80	1

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-04 Date Collected: 03/30/23 11:00

Client ID: GW-6 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Dibenzofuran	ND		ug/l	2.0	0.50	1
1,2,4,5-Tetrachlorobenzene	ND		ug/l	10	0.44	1
Acetophenone	ND		ug/l	5.0	0.53	1
2,4,6-Trichlorophenol	ND		ug/l	5.0	0.61	1
p-Chloro-m-cresol	ND		ug/l	2.0	0.35	1
2-Chlorophenol	ND		ug/l	2.0	0.48	1
2,4-Dichlorophenol	ND		ug/l	5.0	0.41	1
2,4-Dimethylphenol	ND		ug/l	5.0	1.8	1
2-Nitrophenol	ND		ug/l	10	0.85	1
4-Nitrophenol	ND		ug/l	10	0.67	1
2,4-Dinitrophenol	ND		ug/l	20	6.6	1
4,6-Dinitro-o-cresol	ND		ug/l	10	1.8	1
Phenol	ND		ug/l	5.0	0.57	1
2-Methylphenol	ND		ug/l	5.0	0.49	1
3-Methylphenol/4-Methylphenol	ND		ug/l	5.0	0.48	1
2,4,5-Trichlorophenol	ND		ug/l	5.0	0.77	1
Benzoic Acid	ND		ug/l	50	2.6	1
Benzyl Alcohol	ND		ug/l	2.0	0.59	1
Carbazole	ND		ug/l	2.0	0.49	1

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-04 Date Collected: 03/30/23 11:00

Client ID: GW-6 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Tentatively Identified Compounds						
Total TIC Compounds	74.5	J	ug/l			1
Unknown	1.82	J	ug/l			1
Unknown	2.47	J	ug/l			1
Unknown	3.53	JB	ug/l			1
Unknown	1.64	J	ug/l			1
Unknown	1.56	JB	ug/l			1
Unknown	1.60	J	ug/l			1
Unknown	3.34	J	ug/l			1
Unknown	9.05	J	ug/l			1
Unknown	6.94	J	ug/l			1
Unknown Organic Acid	2.80	JB	ug/l			1
Unknown Organic Acid	14.8	J	ug/l			1
Unknown Organic Acid	24.9	J	ug/l			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	55		21-120
Phenol-d6	47		10-120
Nitrobenzene-d5	64		23-120
2-Fluorobiphenyl	51		15-120
2,4,6-Tribromophenol	72		10-120
4-Terphenyl-d14	57		41-149

Project Name: 100 MAIN ST.
Lab Number: L2316865
Project Number: 12461
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-04
Client ID: GW-6
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 11:00
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E-SIM
Analytical Date: 04/04/23 11:41
Analyst: DV

Extraction Method: EPA 3510C
Extraction Date: 04/03/23 16:01

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS-SIM - Westborough Lab						
Acenaphthene	ND		ug/l	0.10	0.01	1
2-Chloronaphthalene	ND		ug/l	0.20	0.02	1
Fluoranthene	ND		ug/l	0.10	0.02	1
Hexachlorobutadiene	ND		ug/l	0.50	0.05	1
Naphthalene	ND		ug/l	0.10	0.05	1
Benzo(a)anthracene	0.03	J	ug/l	0.10	0.02	1
Benzo(a)pyrene	ND		ug/l	0.10	0.02	1
Benzo(b)fluoranthene	ND		ug/l	0.10	0.01	1
Benzo(k)fluoranthene	ND		ug/l	0.10	0.01	1
Chrysene	ND		ug/l	0.10	0.01	1
Acenaphthylene	ND		ug/l	0.10	0.01	1
Anthracene	ND		ug/l	0.10	0.01	1
Benzo(ghi)perylene	ND		ug/l	0.10	0.01	1
Fluorene	ND		ug/l	0.10	0.01	1
Phenanthrene	ND		ug/l	0.10	0.02	1
Dibenzo(a,h)anthracene	ND		ug/l	0.10	0.01	1
Indeno(1,2,3-cd)pyrene	ND		ug/l	0.10	0.01	1
Pyrene	ND		ug/l	0.10	0.02	1
2-Methylnaphthalene	ND		ug/l	0.10	0.02	1
Pentachlorophenol	ND		ug/l	0.80	0.01	1
Hexachlorobenzene	ND		ug/l	0.80	0.01	1
Hexachloroethane	ND		ug/l	0.80	0.06	1

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-04 Date Collected: 03/30/23 11:00

Client ID: GW-6 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS-SIM - Westborough Lab						

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	60		21-120
Phenol-d6	57		10-120
Nitrobenzene-d5	82		23-120
2-Fluorobiphenyl	65		15-120
2,4,6-Tribromophenol	86		10-120
4-Terphenyl-d14	66		41-149

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-04
Client ID: GW-6
Sample Location: WHITE PLAINS, NY

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E-SIM
Analytical Date: 04/06/23 20:23
Analyst: TPR

Date Collected: 03/30/23 11:00
Date Received: 03/31/23
Field Prep: Not Specified

Extraction Method: EPA 3510C
Extraction Date: 04/04/23 17:03

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
1,4 Dioxane by 8270E-SIM - Mansfield Lab						
1,4-Dioxane	ND		ng/l	136	30.8	1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,4-Dioxane-d8	41		15-110

Project Name: 100 MAIN ST.
Lab Number: L2316865
Project Number: 12461
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-04
Client ID: GW-6
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 11:00
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 144,1633
Analytical Date: 04/19/23 21:31
Analyst: RS

Extraction Method: EPA 1633
Extraction Date: 04/19/23 06:53

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Perfluorinated Alkyl Acids by EPA 1633 - Mansfield Lab						
Perfluorobutanoic Acid (PFBA)	7.80		ng/l	6.24	0.998	1
Perfluoropentanoic Acid (PFPeA)	11.8		ng/l	3.12	0.834	1
Perfluorobutanesulfonic Acid (PFBS)	11.8		ng/l	1.56	0.522	1
Perfluorohexanoic Acid (PFHxA)	17.8		ng/l	1.56	0.460	1
Perfluoroheptanoic Acid (PFHpA)	7.25		ng/l	1.56	0.312	1
Perfluorohexanesulfonic Acid (PFHxS)	348		ng/l	1.56	0.374	1
Perfluorooctanoic Acid (PFOA)	23.9		ng/l	1.56	0.678	1
1H,1H,2H,2H-Perfluorooctanesulfonic Acid (6:2FTS)	ND		ng/l	6.24	2.10	1
Perfluoroheptanesulfonic Acid (PFHpS)	2.10		ng/l	1.56	0.421	1
Perfluorononanoic Acid (PFNA)	0.702	J	ng/l	1.56	0.491	1
Perfluorooctanesulfonic Acid (PFOS)	20.9		ng/l	1.56	0.710	1
Perfluorodecanoic Acid (PFDA)	ND		ng/l	1.56	0.632	1
1H,1H,2H,2H-Perfluorodecanesulfonic Acid (8:2FTS)	ND		ng/l	6.24	2.42	1
N-Methyl Perfluorooctanesulfonamidoacetic Acid (NMeFOSAA)	ND		ng/l	1.56	0.850	1
Perfluoroundecanoic Acid (PFUnA)	ND		ng/l	1.56	0.678	1
Perfluorodecanesulfonic Acid (PFDS)	ND		ng/l	1.56	0.359	1
Perfluorooctanesulfonamide (PFOSA)	ND		ng/l	1.56	0.421	1
N-Ethyl Perfluorooctanesulfonamidoacetic Acid (NEtFOSAA)	ND		ng/l	1.56	0.842	1
Perfluorododecanoic Acid (PFDoA)	ND		ng/l	1.56	0.718	1
Perfluorotridecanoic Acid (PFTrDA)	ND		ng/l	1.56	0.585	1
Perfluorotetradecanoic Acid (PFTeDA)	ND		ng/l	1.56	0.413	1
PFOA/PFOS, Total	44.8		ng/l	1.56	0.678	1

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-04 Date Collected: 03/30/23 11:00

Client ID: GW-6 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Perfluorinated Alkyl Acids by EPA 1633 - Mansfield Lab						

Surrogate	% Recovery	Qualifier	Acceptance Criteria
Perfluoro-n-[13C4]Butanoic Acid (13C4-PFBA)	93		20-150
Perfluoro-n-[13C5]Pentanoic Acid (13C5-PFPeA)	90		20-150
Perfluoro-1-[2,3,4-13C3]Butanesulfonic Acid (13C3-PFBS)	97		20-150
Perfluoro-n-[1,2,3,4,6-13C5]Hexanoic Acid (13C5-PFHxA)	97		20-150
Perfluoro-n-[1,2,3,4-13C4]Heptanoic Acid (13C4-PFHpA)	84		20-150
Perfluoro-1-[1,2,3-13C3]Hexanesulfonic Acid (13C3-PFHxS)	89		20-150
Perfluoro-n-[13C8]Octanoic Acid (13C8-PFOA)	94		20-150
1H,1H,2H,2H-Perfluoro-1-[1,2-13C2]Octanesulfonic Acid (13C2-6:2FTS)	104		20-150
Perfluoro-n-[13C9]Nonanoic Acid (13C9-PFNA)	75		20-150
Perfluoro-1-[13C8]Octanesulfonic Acid (13C8-PFOS)	86		20-150
Perfluoro-n-[1,2,3,4,5,6-13C6]Decanoic Acid (13C6-PFDA)	81		20-150
1H,1H,2H,2H-Perfluoro-1-[1,2-13C2]Decanesulfonic Acid (13C2-8:2FTS)	115		20-150
N-Methyl-d3-perfluoro-1-octanesulfonamidoacetic Acid (D3-NMeFOSAA)	69		20-150
Perfluoro-n-[1,2,3,4,5,6,7-13C7]Undecanoic Acid (13C7-PFUnA)	69		20-150
Perfluoro-1-[13C8]Octanesulfonamide (13C8-PFOSA)	48		20-150
N-Ethyl-d5-perfluoro-1-octanesulfonamidoacetic Acid (D5-NEtFOSAA)	69		20-150
Perfluoro-n-[1,2-13C2]Dodecanoic Acid (13C2-PFDoA)	62		20-150
Perfluoro-n-[1,2-13C2]Tetradecanoic Acid (13C2-PFTeDA)	32		20-150

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-05
Client ID: GW-7
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 11:30
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E
Analytical Date: 04/04/23 14:11
Analyst: JG

Extraction Method: EPA 3510C
Extraction Date: 04/03/23 15:58

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
1,2,4-Trichlorobenzene	ND		ug/l	5.3	0.53	1
Bis(2-chloroethyl)ether	ND		ug/l	2.1	0.53	1
1,2-Dichlorobenzene	ND		ug/l	2.1	0.48	1
1,3-Dichlorobenzene	ND		ug/l	2.1	0.43	1
1,4-Dichlorobenzene	ND		ug/l	2.1	0.46	1
3,3'-Dichlorobenzidine	ND		ug/l	5.3	1.7	1
2,4-Dinitrotoluene	ND		ug/l	5.3	1.2	1
2,6-Dinitrotoluene	ND		ug/l	5.3	0.98	1
4-Chlorophenyl phenyl ether	ND		ug/l	2.1	0.52	1
4-Bromophenyl phenyl ether	ND		ug/l	2.1	0.40	1
Bis(2-chloroisopropyl)ether	ND		ug/l	2.1	0.56	1
Bis(2-chloroethoxy)methane	ND		ug/l	5.3	0.53	1
Hexachlorocyclopentadiene	ND		ug/l	21	0.73	1
Isophorone	ND		ug/l	5.3	1.3	1
Nitrobenzene	ND		ug/l	2.1	0.82	1
NDPA/DPA	ND		ug/l	2.1	0.44	1
n-Nitrosodi-n-propylamine	ND		ug/l	5.3	0.68	1
Bis(2-ethylhexyl)phthalate	ND		ug/l	3.2	1.6	1
Butyl benzyl phthalate	4.4	J	ug/l	5.3	1.2	1
Di-n-butylphthalate	1.4	J	ug/l	5.3	0.41	1
Di-n-octylphthalate	ND		ug/l	5.3	1.3	1
Diethyl phthalate	ND		ug/l	5.3	0.40	1
Dimethyl phthalate	ND		ug/l	5.3	1.9	1
Biphenyl	ND		ug/l	2.1	0.48	1
4-Chloroaniline	ND		ug/l	5.3	1.1	1
2-Nitroaniline	ND		ug/l	5.3	0.53	1
3-Nitroaniline	ND		ug/l	5.3	0.86	1
4-Nitroaniline	ND		ug/l	5.3	0.85	1

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-05 Date Collected: 03/30/23 11:30

Client ID: GW-7 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Dibenzofuran	ND		ug/l	2.1	0.53	1
1,2,4,5-Tetrachlorobenzene	ND		ug/l	10	0.46	1
Acetophenone	ND		ug/l	5.3	0.56	1
2,4,6-Trichlorophenol	ND		ug/l	5.3	0.65	1
p-Chloro-m-cresol	ND		ug/l	2.1	0.37	1
2-Chlorophenol	ND		ug/l	2.1	0.51	1
2,4-Dichlorophenol	ND		ug/l	5.3	0.43	1
2,4-Dimethylphenol	ND		ug/l	5.3	1.9	1
2-Nitrophenol	ND		ug/l	10	0.90	1
4-Nitrophenol	ND		ug/l	10	0.71	1
2,4-Dinitrophenol	ND		ug/l	21	7.0	1
4,6-Dinitro-o-cresol	ND		ug/l	10	1.9	1
Phenol	ND		ug/l	5.3	0.60	1
2-Methylphenol	ND		ug/l	5.3	0.52	1
3-Methylphenol/4-Methylphenol	ND		ug/l	5.3	0.51	1
2,4,5-Trichlorophenol	ND		ug/l	5.3	0.82	1
Benzoic Acid	9.6	J	ug/l	53	2.8	1
Benzyl Alcohol	ND		ug/l	2.1	0.62	1
Carbazole	ND		ug/l	2.1	0.52	1

Tentatively Identified Compounds				
Total TIC Compounds	42.3	J	ug/l	1
Unknown	4.27	J	ug/l	1
Unknown	4.15	JB	ug/l	1
Unknown	1.58	J	ug/l	1
Unknown	1.92	JB	ug/l	1
Unknown	2.38	J	ug/l	1
Unknown	3.19	JB	ug/l	1
Unknown	2.88	J	ug/l	1
Unknown Organic Acid	2.12	JB	ug/l	1
Unknown Organic Acid	19.8	J	ug/l	1

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-05 Date Collected: 03/30/23 11:30

Client ID: GW-7 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	58		21-120
Phenol-d6	52		10-120
Nitrobenzene-d5	77		23-120
2-Fluorobiphenyl	63		15-120
2,4,6-Tribromophenol	57		10-120
4-Terphenyl-d14	50		41-149

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316865
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-05
Client ID: GW-7
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 11:30
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E-SIM
Analytical Date: 04/04/23 11:58
Analyst: DV

Extraction Method: EPA 3510C
Extraction Date: 04/03/23 16:01

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS-SIM - Westborough Lab						
Acenaphthene	ND		ug/l	0.10	0.02	1
2-Chloronaphthalene	ND		ug/l	0.21	0.02	1
Fluoranthene	0.02	J	ug/l	0.10	0.02	1
Hexachlorobutadiene	ND		ug/l	0.53	0.05	1
Naphthalene	ND		ug/l	0.10	0.05	1
Benzo(a)anthracene	0.02	J	ug/l	0.10	0.02	1
Benzo(a)pyrene	ND		ug/l	0.10	0.02	1
Benzo(b)fluoranthene	ND		ug/l	0.10	0.01	1
Benzo(k)fluoranthene	ND		ug/l	0.10	0.01	1
Chrysene	ND		ug/l	0.10	0.01	1
Acenaphthylene	ND		ug/l	0.10	0.01	1
Anthracene	ND		ug/l	0.10	0.02	1
Benzo(ghi)perylene	ND		ug/l	0.10	0.01	1
Fluorene	ND		ug/l	0.10	0.02	1
Phenanthrene	0.03	J	ug/l	0.10	0.03	1
Dibenzo(a,h)anthracene	ND		ug/l	0.10	0.01	1
Indeno(1,2,3-cd)pyrene	ND		ug/l	0.10	0.01	1
Pyrene	0.02	J	ug/l	0.10	0.02	1
2-Methylnaphthalene	ND		ug/l	0.10	0.02	1
Pentachlorophenol	ND		ug/l	0.85	0.02	1
Hexachlorobenzene	ND		ug/l	0.85	0.01	1
Hexachloroethane	ND		ug/l	0.85	0.07	1

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-05 Date Collected: 03/30/23 11:30

Client ID: GW-7 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS-SIM - Westborough Lab						

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	70		21-120
Phenol-d6	68		10-120
Nitrobenzene-d5	108		23-120
2-Fluorobiphenyl	83		15-120
2,4,6-Tribromophenol	87		10-120
4-Terphenyl-d14	71		41-149

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-05
Client ID: GW-7
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 11:30
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E-SIM
Analytical Date: 04/06/23 20:44
Analyst: TPR

Extraction Method: EPA 3510C
Extraction Date: 04/04/23 17:03

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
1,4 Dioxane by 8270E-SIM - Mansfield Lab						
1,4-Dioxane	ND		ng/l	136	30.8	1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,4-Dioxane-d8	45		15-110

Project Name: 100 MAIN ST.
Lab Number: L2316865
Project Number: 12461
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-05
Client ID: GW-7
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 11:30
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 144,1633
Analytical Date: 04/19/23 21:44
Analyst: RS

Extraction Method: EPA 1633
Extraction Date: 04/19/23 06:53

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Perfluorinated Alkyl Acids by EPA 1633 - Mansfield Lab						
Perfluorobutanoic Acid (PFBA)	8.47		ng/l	5.74	0.918	1
Perfluoropentanoic Acid (PFPeA)	9.47		ng/l	2.87	0.768	1
Perfluorobutanesulfonic Acid (PFBS)	6.82		ng/l	1.44	0.481	1
Perfluorohexanoic Acid (PFHxA)	11.0		ng/l	1.44	0.423	1
Perfluoroheptanoic Acid (PFHpA)	5.81		ng/l	1.44	0.287	1
Perfluorohexanesulfonic Acid (PFHxS)	26.3		ng/l	1.44	0.344	1
Perfluorooctanoic Acid (PFOA)	15.6		ng/l	1.44	0.624	1
1H,1H,2H,2H-Perfluorooctanesulfonic Acid (6:2FTS)	ND		ng/l	5.74	1.94	1
Perfluoroheptanesulfonic Acid (PFHpS)	0.646	J	ng/l	1.44	0.387	1
Perfluorononanoic Acid (PFNA)	1.58		ng/l	1.44	0.452	1
Perfluorooctanesulfonic Acid (PFOS)	23.0		ng/l	1.44	0.653	1
Perfluorodecanoic Acid (PFDA)	1.72		ng/l	1.44	0.581	1
1H,1H,2H,2H-Perfluorodecanesulfonic Acid (8:2FTS)	ND		ng/l	5.74	2.23	1
N-Methyl Perfluorooctanesulfonamidoacetic Acid (NMeFOSAA)	ND		ng/l	1.44	0.782	1
Perfluoroundecanoic Acid (PFUnA)	ND		ng/l	1.44	0.624	1
Perfluorodecanesulfonic Acid (PFDS)	ND		ng/l	1.44	0.330	1
Perfluorooctanesulfonamide (PFOSA)	ND		ng/l	1.44	0.387	1
N-Ethyl Perfluorooctanesulfonamidoacetic Acid (NEtFOSAA)	ND		ng/l	1.44	0.775	1
Perfluorododecanoic Acid (PFDoA)	ND		ng/l	1.44	0.660	1
Perfluorotridecanoic Acid (PFTrDA)	ND		ng/l	1.44	0.538	1
Perfluorotetradecanoic Acid (PFTeDA)	ND		ng/l	1.44	0.380	1
PFOA/PFOS, Total	38.6		ng/l	1.44	0.624	1

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-05 Date Collected: 03/30/23 11:30

Client ID: GW-7 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Perfluorinated Alkyl Acids by EPA 1633 - Mansfield Lab						

Surrogate	% Recovery	Qualifier	Acceptance Criteria
Perfluoro-n-[13C4]Butanoic Acid (13C4-PFBA)	95		20-150
Perfluoro-n-[13C5]Pentanoic Acid (13C5-PFPeA)	89		20-150
Perfluoro-1-[2,3,4-13C3]Butanesulfonic Acid (13C3-PFBS)	88		20-150
Perfluoro-n-[1,2,3,4,6-13C5]Hexanoic Acid (13C5-PFHxA)	97		20-150
Perfluoro-n-[1,2,3,4-13C4]Heptanoic Acid (13C4-PFHpA)	88		20-150
Perfluoro-1-[1,2,3-13C3]Hexanesulfonic Acid (13C3-PFHxS)	90		20-150
Perfluoro-n-[13C8]Octanoic Acid (13C8-PFOA)	92		20-150
1H,1H,2H,2H-Perfluoro-1-[1,2-13C2]Octanesulfonic Acid (13C2-6:2FTS)	106		20-150
Perfluoro-n-[13C9]Nonanoic Acid (13C9-PFNA)	80		20-150
Perfluoro-1-[13C8]Octanesulfonic Acid (13C8-PFOS)	88		20-150
Perfluoro-n-[1,2,3,4,5,6-13C6]Decanoic Acid (13C6-PFDA)	103		20-150
1H,1H,2H,2H-Perfluoro-1-[1,2-13C2]Decanesulfonic Acid (13C2-8:2FTS)	110		20-150
N-Methyl-d3-perfluoro-1-octanesulfonamidoacetic Acid (D3-NMeFOSAA)	81		20-150
Perfluoro-n-[1,2,3,4,5,6,7-13C7]Undecanoic Acid (13C7-PFUnA)	90		20-150
Perfluoro-1-[13C8]Octanesulfonamide (13C8-PFOSA)	53		20-150
N-Ethyl-d5-perfluoro-1-octanesulfonamidoacetic Acid (D5-NEtFOSAA)	80		20-150
Perfluoro-n-[1,2-13C2]Dodecanoic Acid (13C2-PFDoA)	74		20-150
Perfluoro-n-[1,2-13C2]Tetradecanoic Acid (13C2-PFTeDA)	55		20-150

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-06
Client ID: SB-37
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 11:40
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8270E
Analytical Date: 04/05/23 16:14
Analyst: IM
Percent Solids: 92%

Extraction Method: EPA 3546
Extraction Date: 04/04/23 07:59

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Acenaphthene	220		ug/kg	140	19.	1
1,2,4-Trichlorobenzene	ND		ug/kg	180	20.	1
Hexachlorobenzene	ND		ug/kg	110	20.	1
Bis(2-chloroethyl)ether	ND		ug/kg	160	24.	1
2-Chloronaphthalene	ND		ug/kg	180	18.	1
1,2-Dichlorobenzene	ND		ug/kg	180	32.	1
1,3-Dichlorobenzene	ND		ug/kg	180	31.	1
1,4-Dichlorobenzene	ND		ug/kg	180	31.	1
3,3'-Dichlorobenzidine	ND		ug/kg	180	48.	1
2,4-Dinitrotoluene	ND		ug/kg	180	36.	1
2,6-Dinitrotoluene	ND		ug/kg	180	31.	1
Fluoranthene	440		ug/kg	110	21.	1
4-Chlorophenyl phenyl ether	ND		ug/kg	180	19.	1
4-Bromophenyl phenyl ether	ND		ug/kg	180	27.	1
Bis(2-chloroisopropyl)ether	ND		ug/kg	220	31.	1
Bis(2-chloroethoxy)methane	ND		ug/kg	190	18.	1
Hexachlorobutadiene	ND		ug/kg	180	26.	1
Hexachlorocyclopentadiene	ND		ug/kg	510	160	1
Hexachloroethane	ND		ug/kg	140	29.	1
Isophorone	ND		ug/kg	160	23.	1
Naphthalene	48	J	ug/kg	180	22.	1
Nitrobenzene	ND		ug/kg	160	27.	1
NDPA/DPA	ND		ug/kg	140	20.	1
n-Nitrosodi-n-propylamine	ND		ug/kg	180	28.	1
Bis(2-ethylhexyl)phthalate	ND		ug/kg	180	62.	1
Butyl benzyl phthalate	ND		ug/kg	180	45.	1
Di-n-butylphthalate	ND		ug/kg	180	34.	1
Di-n-octylphthalate	ND		ug/kg	180	61.	1

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-06 Date Collected: 03/30/23 11:40

Client ID: SB-37 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Diethyl phthalate	ND		ug/kg	180	17.	1
Dimethyl phthalate	ND		ug/kg	180	38.	1
Benzo(a)anthracene	290		ug/kg	110	20.	1
Benzo(a)pyrene	330		ug/kg	140	44.	1
Benzo(b)fluoranthene	350		ug/kg	110	30.	1
Benzo(k)fluoranthene	150		ug/kg	110	29.	1
Chrysene	270		ug/kg	110	19.	1
Acenaphthylene	130	J	ug/kg	140	28.	1
Anthracene	140		ug/kg	110	35.	1
Benzo(ghi)perylene	ND		ug/kg	140	21.	1
Fluorene	260		ug/kg	180	17.	1
Phenanthrene	850		ug/kg	110	22.	1
Dibenzo(a,h)anthracene	ND		ug/kg	110	21.	1
Indeno(1,2,3-cd)pyrene	ND		ug/kg	140	25.	1
Pyrene	520		ug/kg	110	18.	1
Biphenyl	70	J	ug/kg	410	23.	1
4-Chloroaniline	ND		ug/kg	180	33.	1
2-Nitroaniline	ND		ug/kg	180	35.	1
3-Nitroaniline	ND		ug/kg	180	34.	1
4-Nitroaniline	ND		ug/kg	180	74.	1
Dibenzofuran	160	J	ug/kg	180	17.	1
2-Methylnaphthalene	150	J	ug/kg	220	22.	1
1,2,4,5-Tetrachlorobenzene	ND		ug/kg	180	19.	1
Acetophenone	ND		ug/kg	180	22.	1
2,4,6-Trichlorophenol	ND		ug/kg	110	34.	1
p-Chloro-m-cresol	ND		ug/kg	180	27.	1
2-Chlorophenol	ND		ug/kg	180	21.	1
2,4-Dichlorophenol	ND		ug/kg	160	29.	1
2,4-Dimethylphenol	ND		ug/kg	180	59.	1
2-Nitrophenol	ND		ug/kg	390	68.	1
4-Nitrophenol	ND		ug/kg	250	73.	1
2,4-Dinitrophenol	ND		ug/kg	860	84.	1
4,6-Dinitro-o-cresol	ND		ug/kg	470	86.	1
Pentachlorophenol	ND		ug/kg	140	40.	1
Phenol	ND		ug/kg	180	27.	1
2-Methylphenol	ND		ug/kg	180	28.	1
3-Methylphenol/4-Methylphenol	ND		ug/kg	260	28.	1

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-06 Date Collected: 03/30/23 11:40

Client ID: SB-37 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
2,4,5-Trichlorophenol	ND		ug/kg	180	34.	1
Benzoic Acid	ND		ug/kg	580	180	1
Benzyl Alcohol	ND		ug/kg	180	55.	1
Carbazole	96	J	ug/kg	180	17.	1
1,4-Dioxane	ND		ug/kg	27	8.3	1
Tentatively Identified Compounds						
Total TIC Compounds	20600	J	ug/kg			1
Unknown	2250	J	ug/kg			1
Unknown Alkane	932	J	ug/kg			1
Unknown Alkane	1440	J	ug/kg			1
Unknown Alkane	3240	J	ug/kg			1
Unknown Alkane	2040	J	ug/kg			1
Unknown Alkane	4440	J	ug/kg			1
Unknown Alkane	390	J	ug/kg			1
Unknown Alkane	1860	J	ug/kg			1
Unknown	269	J	ug/kg			1
Unknown Alkane	1070	J	ug/kg			1
Unknown	308	J	ug/kg			1
Unknown Naphthalene	2330	J	ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	63		25-120
Phenol-d6	92		10-120
Nitrobenzene-d5	85		23-120
2-Fluorobiphenyl	81		30-120
2,4,6-Tribromophenol	58		10-136
4-Terphenyl-d14	75		18-120

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-07
Client ID: SB-38
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 11:15
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8270E
Analytical Date: 04/05/23 17:36
Analyst: IM
Percent Solids: 90%

Extraction Method: EPA 3546
Extraction Date: 04/04/23 07:59

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Acenaphthene	ND		ug/kg	150	19.	1
1,2,4-Trichlorobenzene	ND		ug/kg	180	21.	1
Hexachlorobenzene	ND		ug/kg	110	20.	1
Bis(2-chloroethyl)ether	ND		ug/kg	160	25.	1
2-Chloronaphthalene	ND		ug/kg	180	18.	1
1,2-Dichlorobenzene	ND		ug/kg	180	33.	1
1,3-Dichlorobenzene	ND		ug/kg	180	32.	1
1,4-Dichlorobenzene	ND		ug/kg	180	32.	1
3,3'-Dichlorobenzidine	ND		ug/kg	180	49.	1
2,4-Dinitrotoluene	ND		ug/kg	180	37.	1
2,6-Dinitrotoluene	ND		ug/kg	180	32.	1
Fluoranthene	160		ug/kg	110	21.	1
4-Chlorophenyl phenyl ether	ND		ug/kg	180	20.	1
4-Bromophenyl phenyl ether	ND		ug/kg	180	28.	1
Bis(2-chloroisopropyl)ether	ND		ug/kg	220	31.	1
Bis(2-chloroethoxy)methane	ND		ug/kg	200	18.	1
Hexachlorobutadiene	ND		ug/kg	180	27.	1
Hexachlorocyclopentadiene	ND		ug/kg	520	170	1
Hexachloroethane	ND		ug/kg	150	30.	1
Isophorone	ND		ug/kg	160	24.	1
Naphthalene	ND		ug/kg	180	22.	1
Nitrobenzene	ND		ug/kg	160	27.	1
NDPA/DPA	ND		ug/kg	150	21.	1
n-Nitrosodi-n-propylamine	ND		ug/kg	180	28.	1
Bis(2-ethylhexyl)phthalate	ND		ug/kg	180	64.	1
Butyl benzyl phthalate	ND		ug/kg	180	46.	1
Di-n-butylphthalate	ND		ug/kg	180	35.	1
Di-n-octylphthalate	ND		ug/kg	180	62.	1

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-07 Date Collected: 03/30/23 11:15

Client ID: SB-38 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Diethyl phthalate	ND		ug/kg	180	17.	1
Dimethyl phthalate	ND		ug/kg	180	38.	1
Benzo(a)anthracene	200		ug/kg	110	21.	1
Benzo(a)pyrene	260		ug/kg	150	45.	1
Benzo(b)fluoranthene	320		ug/kg	110	31.	1
Benzo(k)fluoranthene	92	J	ug/kg	110	29.	1
Chrysene	200		ug/kg	110	19.	1
Acenaphthylene	ND		ug/kg	150	28.	1
Anthracene	ND		ug/kg	110	36.	1
Benzo(ghi)perylene	140	J	ug/kg	150	22.	1
Fluorene	ND		ug/kg	180	18.	1
Phenanthrene	53	J	ug/kg	110	22.	1
Dibenzo(a,h)anthracene	26	J	ug/kg	110	21.	1
Indeno(1,2,3-cd)pyrene	110	J	ug/kg	150	26.	1
Pyrene	180		ug/kg	110	18.	1
Biphenyl	ND		ug/kg	420	24.	1
4-Chloroaniline	ND		ug/kg	180	33.	1
2-Nitroaniline	ND		ug/kg	180	35.	1
3-Nitroaniline	ND		ug/kg	180	35.	1
4-Nitroaniline	ND		ug/kg	180	76.	1
Dibenzofuran	ND		ug/kg	180	17.	1
2-Methylnaphthalene	ND		ug/kg	220	22.	1
1,2,4,5-Tetrachlorobenzene	ND		ug/kg	180	19.	1
Acetophenone	ND		ug/kg	180	23.	1
2,4,6-Trichlorophenol	ND		ug/kg	110	35.	1
p-Chloro-m-cresol	ND		ug/kg	180	27.	1
2-Chlorophenol	ND		ug/kg	180	22.	1
2,4-Dichlorophenol	ND		ug/kg	160	30.	1
2,4-Dimethylphenol	ND		ug/kg	180	61.	1
2-Nitrophenol	ND		ug/kg	400	69.	1
4-Nitrophenol	ND		ug/kg	260	75.	1
2,4-Dinitrophenol	ND		ug/kg	880	86.	1
4,6-Dinitro-o-cresol	ND		ug/kg	480	88.	1
Pentachlorophenol	ND		ug/kg	150	40.	1
Phenol	ND		ug/kg	180	28.	1
2-Methylphenol	ND		ug/kg	180	28.	1
3-Methylphenol/4-Methylphenol	ND		ug/kg	260	29.	1

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-07 Date Collected: 03/30/23 11:15

Client ID: SB-38 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
2,4,5-Trichlorophenol	ND		ug/kg	180	35.	1
Benzoic Acid	ND		ug/kg	600	180	1
Benzyl Alcohol	ND		ug/kg	180	56.	1
Carbazole	ND		ug/kg	180	18.	1
1,4-Dioxane	ND		ug/kg	28	8.4	1
Tentatively Identified Compounds						
No Tentatively Identified Compounds	ND		ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	77		25-120
Phenol-d6	72		10-120
Nitrobenzene-d5	53		23-120
2-Fluorobiphenyl	72		30-120
2,4,6-Tribromophenol	69		10-136
4-Terphenyl-d14	53		18-120

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316865
Report Date: 04/20/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 04/04/23 02:24
Analyst: LJG

Extraction Method: EPA 3510C
Extraction Date: 04/03/23 15:58

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 01-05 Batch: WG1762197-1					
Acenaphthene	ND		ug/l	2.0	0.44
1,2,4-Trichlorobenzene	ND		ug/l	5.0	0.50
Hexachlorobenzene	ND		ug/l	2.0	0.46
Bis(2-chloroethyl)ether	ND		ug/l	2.0	0.50
2-Chloronaphthalene	ND		ug/l	2.0	0.44
1,2-Dichlorobenzene	ND		ug/l	2.0	0.45
1,3-Dichlorobenzene	ND		ug/l	2.0	0.40
1,4-Dichlorobenzene	ND		ug/l	2.0	0.43
3,3'-Dichlorobenzidine	ND		ug/l	5.0	1.6
2,4-Dinitrotoluene	ND		ug/l	5.0	1.2
2,6-Dinitrotoluene	ND		ug/l	5.0	0.93
Fluoranthene	ND		ug/l	2.0	0.26
4-Chlorophenyl phenyl ether	ND		ug/l	2.0	0.49
4-Bromophenyl phenyl ether	ND		ug/l	2.0	0.38
Bis(2-chloroisopropyl)ether	ND		ug/l	2.0	0.53
Bis(2-chloroethoxy)methane	ND		ug/l	5.0	0.50
Hexachlorobutadiene	ND		ug/l	2.0	0.66
Hexachlorocyclopentadiene	ND		ug/l	20	0.69
Hexachloroethane	ND		ug/l	2.0	0.58
Isophorone	ND		ug/l	5.0	1.2
Naphthalene	ND		ug/l	2.0	0.46
Nitrobenzene	ND		ug/l	2.0	0.77
NDPA/DPA	ND		ug/l	2.0	0.42
n-Nitrosodi-n-propylamine	ND		ug/l	5.0	0.64
Bis(2-ethylhexyl)phthalate	ND		ug/l	3.0	1.5
Butyl benzyl phthalate	ND		ug/l	5.0	1.2
Di-n-butylphthalate	ND		ug/l	5.0	0.39
Di-n-octylphthalate	ND		ug/l	5.0	1.3
Diethyl phthalate	ND		ug/l	5.0	0.38

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316865
Report Date: 04/20/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 04/04/23 02:24
Analyst: LJG

Extraction Method: EPA 3510C
Extraction Date: 04/03/23 15:58

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 01-05 Batch: WG1762197-1					
Dimethyl phthalate	ND		ug/l	5.0	1.8
Benzo(a)anthracene	ND		ug/l	2.0	0.32
Benzo(a)pyrene	ND		ug/l	2.0	0.41
Benzo(b)fluoranthene	ND		ug/l	2.0	0.35
Benzo(k)fluoranthene	ND		ug/l	2.0	0.37
Chrysene	ND		ug/l	2.0	0.34
Acenaphthylene	ND		ug/l	2.0	0.46
Anthracene	ND		ug/l	2.0	0.33
Benzo(ghi)perylene	ND		ug/l	2.0	0.30
Fluorene	ND		ug/l	2.0	0.41
Phenanthrene	ND		ug/l	2.0	0.33
Dibenzo(a,h)anthracene	ND		ug/l	2.0	0.32
Indeno(1,2,3-cd)pyrene	ND		ug/l	2.0	0.40
Pyrene	ND		ug/l	2.0	0.28
Biphenyl	ND		ug/l	2.0	0.46
4-Chloroaniline	ND		ug/l	5.0	1.1
2-Nitroaniline	ND		ug/l	5.0	0.50
3-Nitroaniline	ND		ug/l	5.0	0.81
4-Nitroaniline	ND		ug/l	5.0	0.80
Dibenzofuran	ND		ug/l	2.0	0.50
2-Methylnaphthalene	ND		ug/l	2.0	0.45
1,2,4,5-Tetrachlorobenzene	ND		ug/l	10	0.44
Acetophenone	ND		ug/l	5.0	0.53
2,4,6-Trichlorophenol	ND		ug/l	5.0	0.61
p-Chloro-m-cresol	ND		ug/l	2.0	0.35
2-Chlorophenol	ND		ug/l	2.0	0.48
2,4-Dichlorophenol	ND		ug/l	5.0	0.41
2,4-Dimethylphenol	ND		ug/l	5.0	1.8
2-Nitrophenol	ND		ug/l	10	0.85

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316865
Report Date: 04/20/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 04/04/23 02:24
Analyst: LJG

Extraction Method: EPA 3510C
Extraction Date: 04/03/23 15:58

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 01-05 Batch: WG1762197-1					
4-Nitrophenol	ND		ug/l	10	0.67
2,4-Dinitrophenol	ND		ug/l	20	6.6
4,6-Dinitro-o-cresol	ND		ug/l	10	1.8
Pentachlorophenol	ND		ug/l	10	1.8
Phenol	ND		ug/l	5.0	0.57
2-Methylphenol	ND		ug/l	5.0	0.49
3-Methylphenol/4-Methylphenol	ND		ug/l	5.0	0.48
2,4,5-Trichlorophenol	ND		ug/l	5.0	0.77
Benzoic Acid	ND		ug/l	50	2.6
Benzyl Alcohol	ND		ug/l	2.0	0.59
Carbazole	ND		ug/l	2.0	0.49

Tentatively Identified Compounds			
Total TIC Compounds	32.9	J	ug/l
Unknown	16.9	J	ug/l
Unknown Organic Acid	8.33	J	ug/l
Unknown	4.47	J	ug/l
Unknown	1.53	J	ug/l
Unknown	1.67	J	ug/l

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 04/04/23 02:24
Analyst: LJG

Extraction Method: EPA 3510C
Extraction Date: 04/03/23 15:58

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 01-05 Batch: WG1762197-1					

Surrogate	%Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	57		21-120
Phenol-d6	44		10-120
Nitrobenzene-d5	71		23-120
2-Fluorobiphenyl	84		15-120
2,4,6-Tribromophenol	90		10-120
4-Terphenyl-d14	87		41-149

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E-SIM
Analytical Date: 04/04/23 10:03
Analyst: DV

Extraction Method: EPA 3510C
Extraction Date: 04/03/23 16:01

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS-SIM - Westborough Lab for sample(s): 01-05 Batch: WG1762202-1					
Acenaphthene	ND		ug/l	0.10	0.01
2-Chloronaphthalene	ND		ug/l	0.20	0.02
Fluoranthene	ND		ug/l	0.10	0.02
Hexachlorobutadiene	ND		ug/l	0.50	0.05
Naphthalene	ND		ug/l	0.10	0.05
Benzo(a)anthracene	ND		ug/l	0.10	0.02
Benzo(a)pyrene	ND		ug/l	0.10	0.02
Benzo(b)fluoranthene	ND		ug/l	0.10	0.01
Benzo(k)fluoranthene	ND		ug/l	0.10	0.01
Chrysene	ND		ug/l	0.10	0.01
Acenaphthylene	ND		ug/l	0.10	0.01
Anthracene	ND		ug/l	0.10	0.01
Benzo(ghi)perylene	ND		ug/l	0.10	0.01
Fluorene	0.02	J	ug/l	0.10	0.01
Phenanthrene	ND		ug/l	0.10	0.02
Dibenzo(a,h)anthracene	ND		ug/l	0.10	0.01
Indeno(1,2,3-cd)pyrene	ND		ug/l	0.10	0.01
Pyrene	ND		ug/l	0.10	0.02
2-Methylnaphthalene	ND		ug/l	0.10	0.02
Pentachlorophenol	ND		ug/l	0.80	0.01
Hexachlorobenzene	ND		ug/l	0.80	0.01
Hexachloroethane	ND		ug/l	0.80	0.06

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316865
Report Date: 04/20/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E-SIM
Analytical Date: 04/04/23 10:03
Analyst: DV

Extraction Method: EPA 3510C
Extraction Date: 04/03/23 16:01

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS-SIM - Westborough Lab for sample(s): 01-05 Batch: WG1762202-1					

Surrogate	%Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	61		21-120
Phenol-d6	53		10-120
Nitrobenzene-d5	89		23-120
2-Fluorobiphenyl	72		15-120
2,4,6-Tribromophenol	80		10-120
4-Terphenyl-d14	79		41-149

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 04/05/23 00:44
Analyst: JG

Extraction Method: EPA 3546
Extraction Date: 04/04/23 07:59

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 06-07 Batch: WG1762412-1					
Acenaphthene	ND		ug/kg	130	17.
1,2,4-Trichlorobenzene	ND		ug/kg	160	19.
Hexachlorobenzene	ND		ug/kg	98	18.
Bis(2-chloroethyl)ether	ND		ug/kg	150	22.
2-Chloronaphthalene	ND		ug/kg	160	16.
1,2-Dichlorobenzene	ND		ug/kg	160	29.
1,3-Dichlorobenzene	ND		ug/kg	160	28.
1,4-Dichlorobenzene	ND		ug/kg	160	29.
3,3'-Dichlorobenzidine	ND		ug/kg	160	44.
2,4-Dinitrotoluene	ND		ug/kg	160	33.
2,6-Dinitrotoluene	ND		ug/kg	160	28.
Fluoranthene	ND		ug/kg	98	19.
4-Chlorophenyl phenyl ether	ND		ug/kg	160	18.
4-Bromophenyl phenyl ether	ND		ug/kg	160	25.
Bis(2-chloroisopropyl)ether	ND		ug/kg	200	28.
Bis(2-chloroethoxy)methane	ND		ug/kg	180	16.
Hexachlorobutadiene	ND		ug/kg	160	24.
Hexachlorocyclopentadiene	ND		ug/kg	470	150
Hexachloroethane	ND		ug/kg	130	26.
Isophorone	ND		ug/kg	150	21.
Naphthalene	ND		ug/kg	160	20.
Nitrobenzene	ND		ug/kg	150	24.
NDPA/DPA	ND		ug/kg	130	19.
n-Nitrosodi-n-propylamine	ND		ug/kg	160	25.
Bis(2-ethylhexyl)phthalate	ND		ug/kg	160	57.
Butyl benzyl phthalate	ND		ug/kg	160	41.
Di-n-butylphthalate	ND		ug/kg	160	31.
Di-n-octylphthalate	ND		ug/kg	160	56.
Diethyl phthalate	ND		ug/kg	160	15.

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 04/05/23 00:44
Analyst: JG

Extraction Method: EPA 3546
Extraction Date: 04/04/23 07:59

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 06-07 Batch: WG1762412-1					
Dimethyl phthalate	ND		ug/kg	160	34.
Benzo(a)anthracene	ND		ug/kg	98	18.
Benzo(a)pyrene	ND		ug/kg	130	40.
Benzo(b)fluoranthene	ND		ug/kg	98	28.
Benzo(k)fluoranthene	ND		ug/kg	98	26.
Chrysene	ND		ug/kg	98	17.
Acenaphthylene	ND		ug/kg	130	25.
Anthracene	ND		ug/kg	98	32.
Benzo(ghi)perylene	ND		ug/kg	130	19.
Fluorene	ND		ug/kg	160	16.
Phenanthrene	ND		ug/kg	98	20.
Dibenzo(a,h)anthracene	ND		ug/kg	98	19.
Indeno(1,2,3-cd)pyrene	ND		ug/kg	130	23.
Pyrene	ND		ug/kg	98	16.
Biphenyl	ND		ug/kg	370	21.
4-Chloroaniline	ND		ug/kg	160	30.
2-Nitroaniline	ND		ug/kg	160	32.
3-Nitroaniline	ND		ug/kg	160	31.
4-Nitroaniline	ND		ug/kg	160	68.
Dibenzofuran	ND		ug/kg	160	16.
2-Methylnaphthalene	ND		ug/kg	200	20.
1,2,4,5-Tetrachlorobenzene	ND		ug/kg	160	17.
Acetophenone	ND		ug/kg	160	20.
2,4,6-Trichlorophenol	ND		ug/kg	98	31.
p-Chloro-m-cresol	ND		ug/kg	160	24.
2-Chlorophenol	ND		ug/kg	160	19.
2,4-Dichlorophenol	ND		ug/kg	150	26.
2,4-Dimethylphenol	ND		ug/kg	160	54.
2-Nitrophenol	ND		ug/kg	350	62.

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 04/05/23 00:44
Analyst: JG

Extraction Method: EPA 3546
Extraction Date: 04/04/23 07:59

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 06-07 Batch: WG1762412-1					
4-Nitrophenol	ND		ug/kg	230	67.
2,4-Dinitrophenol	ND		ug/kg	790	76.
4,6-Dinitro-o-cresol	ND		ug/kg	430	79.
Pentachlorophenol	ND		ug/kg	130	36.
Phenol	ND		ug/kg	160	25.
2-Methylphenol	ND		ug/kg	160	25.
3-Methylphenol/4-Methylphenol	ND		ug/kg	240	26.
2,4,5-Trichlorophenol	ND		ug/kg	160	31.
Benzoic Acid	ND		ug/kg	530	160
Benzyl Alcohol	ND		ug/kg	160	50.
Carbazole	ND		ug/kg	160	16.
1,4-Dioxane	ND		ug/kg	24	7.5
Tentatively Identified Compounds					
No Tentatively Identified Compounds	ND		ug/kg		

Surrogate	%Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	68		25-120
Phenol-d6	67		10-120
Nitrobenzene-d5	58		23-120
2-Fluorobiphenyl	68		30-120
2,4,6-Tribromophenol	75		10-136
4-Terphenyl-d14	76		18-120

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E-SIM
Analytical Date: 04/05/23 11:32
Analyst: TPR

Extraction Method: EPA 3510C
Extraction Date: 04/04/23 11:35

Parameter	Result	Qualifier	Units	RL	MDL
1,4 Dioxane by 8270E-SIM - Mansfield Lab for sample(s): 01-02 Batch: WG1762494-1					
1,4-Dioxane	ND		ng/l	150	33.9

Surrogate	%Recovery	Qualifier	Acceptance Criteria
1,4-Dioxane-d8	60		15-110

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E-SIM
Analytical Date: 04/06/23 18:56
Analyst: TPR

Extraction Method: EPA 3510C
Extraction Date: 04/04/23 17:03

Parameter	Result	Qualifier	Units	RL	MDL
1,4 Dioxane by 8270E-SIM - Mansfield Lab for sample(s): 03-05 Batch: WG1762664-1					
1,4-Dioxane	ND		ng/l	150	33.9

Surrogate	%Recovery	Qualifier	Acceptance Criteria
1,4-Dioxane-d8	45		15-110

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 144,1633
Analytical Date: 04/19/23 20:01
Analyst: RS

Extraction Method: EPA 1633
Extraction Date: 04/19/23 06:53

Parameter	Result	Qualifier	Units	RL	MDL
Perfluorinated Alkyl Acids by EPA 1633 - Mansfield Lab for sample(s): 01-05 Batch: WG1768406-1					
Perfluorobutanoic Acid (PFBA)	ND		ng/l	6.40	1.02
Perfluoropentanoic Acid (PFPeA)	ND		ng/l	3.20	0.856
Perfluorobutanesulfonic Acid (PFBS)	ND		ng/l	1.60	0.536
Perfluorohexanoic Acid (PFHxA)	ND		ng/l	1.60	0.472
Perfluoroheptanoic Acid (PFHpA)	ND		ng/l	1.60	0.320
Perfluorohexanesulfonic Acid (PFHxS)	ND		ng/l	1.60	0.384
Perfluorooctanoic Acid (PFOA)	ND		ng/l	1.60	0.696
1H,1H,2H,2H-Perfluorooctanesulfonic Acid (6:2FTS)	ND		ng/l	6.40	2.16
Perfluoroheptanesulfonic Acid (PFHpS)	ND		ng/l	1.60	0.432
Perfluorononanoic Acid (PFNA)	ND		ng/l	1.60	0.504
Perfluorooctanesulfonic Acid (PFOS)	ND		ng/l	1.60	0.728
Perfluorodecanoic Acid (PFDA)	ND		ng/l	1.60	0.648
1H,1H,2H,2H-Perfluorodecanesulfonic Acid (8:2FTS)	ND		ng/l	6.40	2.49
N-Methyl Perfluorooctanesulfonamidoacetic Acid (NMeFOSAA)	ND		ng/l	1.60	0.872
Perfluoroundecanoic Acid (PFUnA)	ND		ng/l	1.60	0.696
Perfluorodecanesulfonic Acid (PFDS)	ND		ng/l	1.60	0.368
Perfluorooctanesulfonamide (PFOSA)	ND		ng/l	1.60	0.432
N-Ethyl Perfluorooctanesulfonamidoacetic Acid (NEtFOSAA)	ND		ng/l	1.60	0.864
Perfluorododecanoic Acid (PFDoA)	ND		ng/l	1.60	0.736
Perfluorotridecanoic Acid (PFTrDA)	ND		ng/l	1.60	0.600
Perfluorotetradecanoic Acid (PFTeDA)	ND		ng/l	1.60	0.424
PFOA/PFOS, Total	ND		ng/l	1.60	0.696

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 144,1633
Analytical Date: 04/19/23 20:01
Analyst: RS

Extraction Method: EPA 1633
Extraction Date: 04/19/23 06:53

Parameter	Result	Qualifier	Units	RL	MDL
Perfluorinated Alkyl Acids by EPA 1633 - Mansfield Lab for sample(s): 01-05 Batch: WG1768406-1					

Surrogate	%Recovery	Qualifier	Acceptance Criteria
Perfluoro-n-[13C4]Butanoic Acid (13C4-PFBA)	92		20-150
Perfluoro-n-[13C5]Pentanoic Acid (13C5-PFPeA)	92		20-150
Perfluoro-1-[2,3,4-13C3]Butanesulfonic Acid (13C3-PFBS)	95		20-150
Perfluoro-n-[1,2,3,4,6-13C5]Hexanoic Acid (13C5-PFHxA)	92		20-150
Perfluoro-n-[1,2,3,4-13C4]Heptanoic Acid (13C4-PFHpA)	86		20-150
Perfluoro-1-[1,2,3-13C3]Hexanesulfonic Acid (13C3-PFHxS)	92		20-150
Perfluoro-n-[13C8]Octanoic Acid (13C8-PFOA)	95		20-150
1H,1H,2H,2H-Perfluoro-1-[1,2-13C2]Octanesulfonic Acid (13C2-6:2FTS)	86		20-150
Perfluoro-n-[13C9]Nonanoic Acid (13C9-PFNA)	89		20-150
Perfluoro-1-[13C8]Octanesulfonic Acid (13C8-PFOS)	92		20-150
Perfluoro-n-[1,2,3,4,5,6-13C6]Decanoic Acid (13C6-PFDA)	97		20-150
1H,1H,2H,2H-Perfluoro-1-[1,2-13C2]Decanesulfonic Acid (13C2-8:2FTS)	84		20-150
N-Methyl-d3-perfluoro-1-octanesulfonamidoacetic Acid (D3-NMeFOSAA)	76		20-150
Perfluoro-n-[1,2,3,4,5,6,7-13C7]Undecanoic Acid (13C7-PFUnA)	90		20-150
Perfluoro-1-[13C8]Octanesulfonamide (13C8-PFOSA)	75		20-150
N-Ethyl-d5-perfluoro-1-octanesulfonamidoacetic Acid (D5-NEtFOSAA)	78		20-150
Perfluoro-n-[1,2-13C2]Dodecanoic Acid (13C2-PFDoA)	99		20-150
Perfluoro-n-[1,2-13C2]Tetradecanoic Acid (13C2-PFTeDA)	90		20-150

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316865
Report Date: 04/20/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 01-05 Batch: WG1762197-2 WG1762197-3								
Acenaphthene	70		61		37-111	14		30
1,2,4-Trichlorobenzene	78		75		39-98	4		30
Hexachlorobenzene	75		66		40-140	13		30
Bis(2-chloroethyl)ether	65		61		40-140	6		30
2-Chloronaphthalene	78		69		40-140	12		30
1,2-Dichlorobenzene	68		64		40-140	6		30
1,3-Dichlorobenzene	63		61		40-140	3		30
1,4-Dichlorobenzene	65		61		36-97	6		30
3,3'-Dichlorobenzidine	47		**38**	Q	40-140	21		30
2,4-Dinitrotoluene	87		77		48-143	12		30
2,6-Dinitrotoluene	93		82		40-140	13		30
Fluoranthene	81		71		40-140	13		30
4-Chlorophenyl phenyl ether	81		74		40-140	9		30
4-Bromophenyl phenyl ether	86		71		40-140	19		30
Bis(2-chloroisopropyl)ether	82		79		40-140	4		30
Bis(2-chloroethoxy)methane	66		63		40-140	5		30
Hexachlorobutadiene	80		73		40-140	9		30
Hexachlorocyclopentadiene	83		69		40-140	18		30
Hexachloroethane	64		64		40-140	0		30
Isophorone	65		64		40-140	2		30
Naphthalene	69		59		40-140	16		30
Nitrobenzene	69		66		40-140	4		30
NDPA/DPA	81		68		40-140	17		30

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316865
Report Date: 04/20/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 01-05 Batch: WG1762197-2 WG1762197-3								
n-Nitrosodi-n-propylamine	69		68		29-132	1		30
Bis(2-ethylhexyl)phthalate	77		69		40-140	11		30
Butyl benzyl phthalate	77		69		40-140	11		30
Di-n-butylphthalate	73		67		40-140	9		30
Di-n-octylphthalate	74		66		40-140	11		30
Diethyl phthalate	82		70		40-140	16		30
Dimethyl phthalate	88		78		40-140	12		30
Benzo(a)anthracene	81		70		40-140	15		30
Benzo(a)pyrene	74		66		40-140	11		30
Benzo(b)fluoranthene	72		64		40-140	12		30
Benzo(k)fluoranthene	74		65		40-140	13		30
Chrysene	76		69		40-140	10		30
Acenaphthylene	84		73		45-123	14		30
Anthracene	74		65		40-140	13		30
Benzo(ghi)perylene	72		63		40-140	13		30
Fluorene	79		68		40-140	15		30
Phenanthrene	72		63		40-140	13		30
Dibenzo(a,h)anthracene	74		66		40-140	11		30
Indeno(1,2,3-cd)pyrene	86		74		40-140	15		30
Pyrene	80		70		26-127	13		30
Biphenyl	90		80		40-140	12		30
4-Chloroaniline	55		53		40-140	4		30
2-Nitroaniline	88		77		52-143	13		30

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316865
Report Date: 04/20/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 01-05 Batch: WG1762197-2 WG1762197-3								
3-Nitroaniline	65		58		25-145	11		30
4-Nitroaniline	76		65		51-143	16		30
Dibenzofuran	79		67		40-140	16		30
2-Methylnaphthalene	72		65		40-140	10		30
1,2,4,5-Tetrachlorobenzene	100		93		2-134	7		30
Acetophenone	79		72		39-129	9		30
2,4,6-Trichlorophenol	108		97		30-130	11		30
p-Chloro-m-cresol	81		70		23-97	15		30
2-Chlorophenol	69		66		27-123	4		30
2,4-Dichlorophenol	91		84		30-130	8		30
2,4-Dimethylphenol	62		57		30-130	8		30
2-Nitrophenol	106		99		30-130	7		30
4-Nitrophenol	**88**	Q	71		10-80	21		30
2,4-Dinitrophenol	**132**	Q	**132**	Q	20-130	0		30
4,6-Dinitro-o-cresol	145		138		20-164	5		30
Pentachlorophenol	**109**	Q	99		9-103	10		30
Phenol	50		46		12-110	8		30
2-Methylphenol	69		61		30-130	12		30
3-Methylphenol/4-Methylphenol	72		65		30-130	10		30
2,4,5-Trichlorophenol	104		89		30-130	16		30
Benzoic Acid	74		87		10-164	16		30
Benzyl Alcohol	71		65		26-116	9		30
Carbazole	74		65		55-144	13		30

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 01-05 Batch: WG1762197-2 WG1762197-3								

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
2-Fluorophenol	64		60		21-120
Phenol-d6	52		46		10-120
Nitrobenzene-d5	75		72		23-120
2-Fluorobiphenyl	91		84		15-120
2,4,6-Tribromophenol	98		89		10-120
4-Terphenyl-d14	83		78		41-149

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316865
Report Date: 04/20/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS-SIM - Westborough Lab Associated sample(s): 01-05 Batch: WG1762202-2 WG1762202-3								
Acenaphthene	77		64		40-140	18		40
2-Chloronaphthalene	77		65		40-140	17		40
Fluoranthene	84		70		40-140	18		40
Hexachlorobutadiene	65		56		40-140	15		40
Naphthalene	73		62		40-140	16		40
Benzo(a)anthracene	91		75		40-140	19		40
Benzo(a)pyrene	89		73		40-140	20		40
Benzo(b)fluoranthene	86		70		40-140	21		40
Benzo(k)fluoranthene	89		73		40-140	20		40
Chrysene	85		70		40-140	19		40
Acenaphthylene	84		71		40-140	17		40
Anthracene	85		70		40-140	19		40
Benzo(ghi)perylene	90		74		40-140	20		40
Fluorene	80		68		40-140	16		40
Phenanthrene	78		65		40-140	18		40
Dibenzo(a,h)anthracene	91		75		40-140	19		40
Indeno(1,2,3-cd)pyrene	95		79		40-140	18		40
Pyrene	82		68		40-140	19		40
2-Methylnaphthalene	75		64		40-140	16		40
Pentachlorophenol	81		72		40-140	12		40
Hexachlorobenzene	66		55		40-140	18		40
Hexachloroethane	74		63		40-140	16		40

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316865
Report Date: 04/20/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS-SIM - Westborough Lab Associated sample(s): 01-05 Batch: WG1762202-2 WG1762202-3								

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
2-Fluorophenol	79		67		21-120
Phenol-d6	70		58		10-120
Nitrobenzene-d5	106		89		23-120
2-Fluorobiphenyl	83		70		15-120
2,4,6-Tribromophenol	110		91		10-120
4-Terphenyl-d14	81		67		41-149

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316865
Report Date: 04/20/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 06-07 Batch: WG1762412-2 WG1762412-3								
Acenaphthene	70		68		31-137	3		50
1,2,4-Trichlorobenzene	73		69		38-107	6		50
Hexachlorobenzene	83		80		40-140	4		50
Bis(2-chloroethyl)ether	71		71		40-140	0		50
2-Chloronaphthalene	72		72		40-140	0		50
1,2-Dichlorobenzene	68		68		40-140	0		50
1,3-Dichlorobenzene	68		66		40-140	3		50
1,4-Dichlorobenzene	66		64		28-104	3		50
3,3'-Dichlorobenzidine	57		55		40-140	4		50
2,4-Dinitrotoluene	79		76		40-132	4		50
2,6-Dinitrotoluene	75		74		40-140	1		50
Fluoranthene	77		75		40-140	3		50
4-Chlorophenyl phenyl ether	76		73		40-140	4		50
4-Bromophenyl phenyl ether	80		76		40-140	5		50
Bis(2-chloroisopropyl)ether	56		54		40-140	4		50
Bis(2-chloroethoxy)methane	70		68		40-117	3		50
Hexachlorobutadiene	68		66		40-140	3		50
Hexachlorocyclopentadiene	78		77		40-140	1		50
Hexachloroethane	57		55		40-140	4		50
Isophorone	64		64		40-140	0		50
Naphthalene	72		70		40-140	3		50
Nitrobenzene	64		61		40-140	5		50
NDPA/DPA	78		75		36-157	4		50

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316865
Report Date: 04/20/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 06-07 Batch: WG1762412-2 WG1762412-3								
n-Nitrosodi-n-propylamine	64		62		32-121	3		50
Bis(2-ethylhexyl)phthalate	76		70		40-140	8		50
Butyl benzyl phthalate	80		75		40-140	6		50
Di-n-butylphthalate	78		74		40-140	5		50
Di-n-octylphthalate	76		70		40-140	8		50
Diethyl phthalate	73		70		40-140	4		50
Dimethyl phthalate	73		73		40-140	0		50
Benzo(a)anthracene	75		72		40-140	4		50
Benzo(a)pyrene	89		84		40-140	6		50
Benzo(b)fluoranthene	80		75		40-140	6		50
Benzo(k)fluoranthene	82		80		40-140	2		50
Chrysene	74		70		40-140	6		50
Acenaphthylene	80		80		40-140	0		50
Anthracene	76		74		40-140	3		50
Benzo(ghi)perylene	76		72		40-140	5		50
Fluorene	75		72		40-140	4		50
Phenanthrene	74		72		40-140	3		50
Dibenzo(a,h)anthracene	78		76		40-140	3		50
Indeno(1,2,3-cd)pyrene	79		75		40-140	5		50
Pyrene	75		74		35-142	1		50
Biphenyl	75		74		37-127	1		50
4-Chloroaniline	52		45		40-140	14		50
2-Nitroaniline	77		76		47-134	1		50

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316865
Report Date: 04/20/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 06-07 Batch: WG1762412-2 WG1762412-3								
3-Nitroaniline	57		56		26-129	2		50
4-Nitroaniline	72		69		41-125	4		50
Dibenzofuran	76		73		40-140	4		50
2-Methylnaphthalene	73		71		40-140	3		50
1,2,4,5-Tetrachlorobenzene	75		76		40-117	1		50
Acetophenone	72		70		14-144	3		50
2,4,6-Trichlorophenol	80		80		30-130	0		50
p-Chloro-m-cresol	72		72		26-103	0		50
2-Chlorophenol	72		69		25-102	4		50
2,4-Dichlorophenol	76		74		30-130	3		50
2,4-Dimethylphenol	71		68		30-130	4		50
2-Nitrophenol	71		69		30-130	3		50
4-Nitrophenol	72		68		11-114	6		50
2,4-Dinitrophenol	67		70		4-130	4		50
4,6-Dinitro-o-cresol	84		81		10-130	4		50
Pentachlorophenol	88		86		17-109	2		50
Phenol	78		74		26-90	5		50
2-Methylphenol	72		69		30-130.	4		50
3-Methylphenol/4-Methylphenol	74		72		30-130	3		50
2,4,5-Trichlorophenol	83		82		30-130	1		50
Benzoic Acid	31		47		10-110	41		50
Benzyl Alcohol	71		68		40-140	4		50
Carbazole	80		75		54-128	6		50

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2316865

Report Date: 04/20/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 06-07 Batch: WG1762412-2 WG1762412-3								
1,4-Dioxane	45		40		40-140	12		50

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
2-Fluorophenol	75		73		25-120
Phenol-d6	75		72		10-120
Nitrobenzene-d5	66		63		23-120
2-Fluorobiphenyl	76		74		30-120
2,4,6-Tribromophenol	89		87		10-136
4-Terphenyl-d14	81		78		18-120

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2316865

Report Date: 04/20/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
1,4 Dioxane by 8270E-SIM - Mansfield Lab	Associated sample(s): 01-02		Batch: WG1762494-2 WG1762494-3					
1,4-Dioxane	112		112		40-140	0		30

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
1,4-Dioxane-d8	56		61		15-110

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2316865

Report Date: 04/20/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
1,4 Dioxane by 8270E-SIM - Mansfield Lab	Associated sample(s): 03-05		Batch: WG1762664-2	WG1762664-3				
1,4-Dioxane	112		113		40-140	1		30

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
1,4-Dioxane-d8	45		46		15-110

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316865
Report Date: 04/20/23

Parameter	Low Level LCS %Recovery	Qual	Low Level LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Perfluorinated Alkyl Acids by EPA 1633 - Mansfield Lab Associated sample(s): 01-05 Batch: WG1768406-2 LOW LEVEL								
Perfluorobutanoic Acid (PFBA)	88		-		40-150	-		30
Perfluoropentanoic Acid (PFPeA)	99		-		40-150	-		30
Perfluorobutanesulfonic Acid (PFBS)	107		-		40-150	-		30
Perfluorohexanoic Acid (PFHxA)	98		-		40-150	-		30
Perfluoroheptanoic Acid (PFHpA)	100		-		40-150	-		30
Perfluorohexanesulfonic Acid (PFHxS)	104		-		40-150	-		30
Perfluorooctanoic Acid (PFOA)	102		-		40-150	-		30
1H,1H,2H,2H-Perfluorooctanesulfonic Acid (6:2FTS)	106		-		40-150	-		30
Perfluoroheptanesulfonic Acid (PFHpS)	110		-		40-150	-		30
Perfluorononanoic Acid (PFNA)	98		-		40-150	-		30
Perfluorooctanesulfonic Acid (PFOS)	102		-		40-150	-		30
Perfluorodecanoic Acid (PFDA)	92		-		40-150	-		30
1H,1H,2H,2H-Perfluorodecanesulfonic Acid (8:2FTS)	88		-		40-150	-		30
N-Methyl Perfluorooctanesulfonamidoacetic Acid (NMeFOSAA)	100		-		40-150	-		30
Perfluoroundecanoic Acid (PFUnA)	100		-		40-150	-		30
Perfluorodecanesulfonic Acid (PFDS)	88		-		40-150	-		30
Perfluorooctanesulfonamide (PFOSA)	98		-		40-150	-		30
N-Ethyl Perfluorooctanesulfonamidoacetic Acid (NEtFOSAA)	102		-		40-150	-		30
Perfluorododecanoic Acid (PFDoA)	105		-		40-150	-		30
Perfluorotridecanoic Acid (PFTrDA)	105		-		40-150	-		30
Perfluorotetradecanoic Acid (PFTeDA)	108		-		40-150	-		30

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

Parameter	Low Level LCS %Recovery	Qual	Low Level LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits

Perfluorinated Alkyl Acids by EPA 1633 - Mansfield Lab Associated sample(s): 01-05 Batch: WG1768406-2 LOW LEVEL

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
Perfluoro-n-[13C4]Butanoic Acid (13C4-PFBA)	90				20-150
Perfluoro-n-[13C5]Pentanoic Acid (13C5-PFPeA)	91				20-150
Perfluoro-1-[2,3,4-13C3]Butanesulfonic Acid (13C3-PFBS)	94				20-150
Perfluoro-n-[1,2,3,4,6-13C5]Hexanoic Acid (13C5-PFHxA)	92				20-150
Perfluoro-n-[1,2,3,4-13C4]Heptanoic Acid (13C4-PFHpA)	82				20-150
Perfluoro-1-[1,2,3-13C3]Hexanesulfonic Acid (13C3-PFHxS)	90				20-150
Perfluoro-n-[13C8]Octanoic Acid (13C8-PFOA)	86				20-150
1H,1H,2H,2H-Perfluoro-1-[1,2-13C2]Octanesulfonic Acid (13C2-6:2FTS)	82				20-150
Perfluoro-n-[13C9]Nonanoic Acid (13C9-PFNA)	82				20-150
Perfluoro-1-[13C8]Octanesulfonic Acid (13C8-PFOS)	84				20-150
Perfluoro-n-[1,2,3,4,5,6-13C6]Decanoic Acid (13C6-PFDA)	97				20-150
1H,1H,2H,2H-Perfluoro-1-[1,2-13C2]Decanesulfonic Acid (13C2-8:2FTS)	88				20-150
N-Methyl-d3-perfluoro-1-octanesulfonamidoacetic Acid (D3-NMeFOSAA)	69				20-150
Perfluoro-n-[1,2,3,4,5,6,7-13C7]Undecanoic Acid (13C7-PFUnA)	79				20-150
Perfluoro-1-[13C8]Octanesulfonamide (13C8-PFOSA)	70				20-150
N-Ethyl-d5-perfluoro-1-octanesulfonamidoacetic Acid (D5-NEtFOSAA)	68				20-150
Perfluoro-n-[1,2-13C2]Dodecanoic Acid (13C2-PFDoA)	79				20-150
Perfluoro-n-[1,2-13C2]Tetradecanoic Acid (13C2-PFTeDA)	75				20-150

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316865
Report Date: 04/20/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Perfluorinated Alkyl Acids by EPA 1633 - Mansfield Lab Associated sample(s): 01-05 Batch: WG1768406-3								
Perfluorobutanoic Acid (PFBA)	98		-		40-150	-		30
Perfluoropentanoic Acid (PFPeA)	98		-		40-150	-		30
Perfluorobutanesulfonic Acid (PFBS)	99		-		40-150	-		30
Perfluorohexanoic Acid (PFHxA)	93		-		40-150	-		30
Perfluoroheptanoic Acid (PFHpA)	97		-		40-150	-		30
Perfluorohexanesulfonic Acid (PFHxS)	99		-		40-150	-		30
Perfluorooctanoic Acid (PFOA)	99		-		40-150	-		30
1H,1H,2H,2H-Perfluorooctanesulfonic Acid (6:2FTS)	104		-		40-150	-		30
Perfluoroheptanesulfonic Acid (PFHpS)	100		-		40-150	-		30
Perfluorononanoic Acid (PFNA)	97		-		40-150	-		30
Perfluorooctanesulfonic Acid (PFOS)	95		-		40-150	-		30
Perfluorodecanoic Acid (PFDA)	102		-		40-150	-		30
1H,1H,2H,2H-Perfluorodecanesulfonic Acid (8:2FTS)	108		-		40-150	-		30
N-Methyl Perfluorooctanesulfonamidoacetic Acid (NMeFOSAA)	106		-		40-150	-		30
Perfluoroundecanoic Acid (PFUnA)	95		-		40-150	-		30
Perfluorodecanesulfonic Acid (PFDS)	92		-		40-150	-		30
Perfluorooctanesulfonamide (PFOSA)	100		-		40-150	-		30
N-Ethyl Perfluorooctanesulfonamidoacetic Acid (NEtFOSAA)	108		-		40-150	-		30
Perfluorododecanoic Acid (PFDoA)	107		-		40-150	-		30
Perfluorotridecanoic Acid (PFTrDA)	96		-		40-150	-		30
Perfluorotetradecanoic Acid (PFTeDA)	109		-		40-150	-		30

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2316865

Report Date: 04/20/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Perfluorinated Alkyl Acids by EPA 1633 - Mansfield Lab Associated sample(s): 01-05 Batch: WG1768406-3								

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
Perfluoro-n-[13C4]Butanoic Acid (13C4-PFBA)	89				20-150
Perfluoro-n-[13C5]Pentanoic Acid (13C5-PFPeA)	87				20-150
Perfluoro-1-[2,3,4-13C3]Butanesulfonic Acid (13C3-PFBS)	90				20-150
Perfluoro-n-[1,2,3,4,6-13C5]Hexanoic Acid (13C5-PFHxA)	91				20-150
Perfluoro-n-[1,2,3,4-13C4]Heptanoic Acid (13C4-PFHpA)	82				20-150
Perfluoro-1-[1,2,3-13C3]Hexanesulfonic Acid (13C3-PFHxS)	86				20-150
Perfluoro-n-[13C8]Octanoic Acid (13C8-PFOA)	89				20-150
1H,1H,2H,2H-Perfluoro-1-[1,2-13C2]Octanesulfonic Acid (13C2-6:2FTS)	82				20-150
Perfluoro-n-[13C9]Nonanoic Acid (13C9-PFNA)	83				20-150
Perfluoro-1-[13C8]Octanesulfonic Acid (13C8-PFOS)	85				20-150
Perfluoro-n-[1,2,3,4,5,6-13C6]Decanoic Acid (13C6-PFDA)	94				20-150
1H,1H,2H,2H-Perfluoro-1-[1,2-13C2]Decanesulfonic Acid (13C2-8:2FTS)	79				20-150
N-Methyl-d3-perfluoro-1-octanesulfonamidoacetic Acid (D3-NMeFOSAA)	65				20-150
Perfluoro-n-[1,2,3,4,5,6,7-13C7]Undecanoic Acid (13C7-PFUnA)	91				20-150
Perfluoro-1-[13C8]Octanesulfonamide (13C8-PFOSA)	70				20-150
N-Ethyl-d5-perfluoro-1-octanesulfonamidoacetic Acid (D5-NEtFOSAA)	72				20-150
Perfluoro-n-[1,2-13C2]Dodecanoic Acid (13C2-PFDoA)	85				20-150
Perfluoro-n-[1,2-13C2]Tetradecanoic Acid (13C2-PFTeDA)	76				20-150

PCBS

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-01
Client ID: GW-3
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 13:00
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8082A
Analytical Date: 04/07/23 15:37
Analyst: RMP

Extraction Method: EPA 3510C
Extraction Date: 04/06/23 13:06
Cleanup Method: EPA 3665A
Cleanup Date: 04/06/23
Cleanup Method: EPA 3660B
Cleanup Date: 04/07/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/l	0.091	0.078	1	A
Aroclor 1221	ND		ug/l	0.091	0.078	1	A
Aroclor 1232	ND		ug/l	0.091	0.078	1	A
Aroclor 1242	ND		ug/l	0.091	0.078	1	A
Aroclor 1248	ND		ug/l	0.091	0.078	1	A
Aroclor 1254	ND		ug/l	0.091	0.078	1	A
Aroclor 1260	ND		ug/l	0.091	0.078	1	A
Aroclor 1262	ND		ug/l	0.091	0.078	1	A
Aroclor 1268	ND		ug/l	0.091	0.078	1	A
PCBs, Total	ND		ug/l	0.091	0.078	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	82		30-150	A
Decachlorobiphenyl	57		30-150	A
2,4,5,6-Tetrachloro-m-xylene	76		30-150	B
Decachlorobiphenyl	60		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-02
Client ID: GW-4
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 13:30
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8082A
Analytical Date: 04/07/23 15:46
Analyst: RMP

Extraction Method: EPA 3510C
Extraction Date: 04/06/23 13:06
Cleanup Method: EPA 3665A
Cleanup Date: 04/06/23
Cleanup Method: EPA 3660B
Cleanup Date: 04/07/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/l	0.081	0.069	1	A
Aroclor 1221	ND		ug/l	0.081	0.069	1	A
Aroclor 1232	ND		ug/l	0.081	0.069	1	A
Aroclor 1242	ND		ug/l	0.081	0.069	1	A
Aroclor 1248	ND		ug/l	0.081	0.069	1	A
Aroclor 1254	0.076	J	ug/l	0.081	0.069	1	B
Aroclor 1260	ND		ug/l	0.081	0.069	1	A
Aroclor 1262	ND		ug/l	0.081	0.069	1	A
Aroclor 1268	ND		ug/l	0.081	0.069	1	A
PCBs, Total	0.076	J	ug/l	0.081	0.069	1	B

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	84		30-150	A
Decachlorobiphenyl	55		30-150	A
2,4,5,6-Tetrachloro-m-xylene	80		30-150	B
Decachlorobiphenyl	59		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-03
Client ID: GW-5
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 10:30
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8082A
Analytical Date: 04/07/23 15:54
Analyst: RMP

Extraction Method: EPA 3510C
Extraction Date: 04/06/23 13:06
Cleanup Method: EPA 3665A
Cleanup Date: 04/06/23
Cleanup Method: EPA 3660B
Cleanup Date: 04/07/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/l	0.077	0.066	1	A
Aroclor 1221	ND		ug/l	0.077	0.066	1	A
Aroclor 1232	ND		ug/l	0.077	0.066	1	A
Aroclor 1242	ND		ug/l	0.077	0.066	1	A
Aroclor 1248	ND		ug/l	0.077	0.066	1	A
Aroclor 1254	0.075	J	ug/l	0.077	0.066	1	B
Aroclor 1260	ND		ug/l	0.077	0.066	1	A
Aroclor 1262	ND		ug/l	0.077	0.066	1	A
Aroclor 1268	ND		ug/l	0.077	0.066	1	A
PCBs, Total	0.075	J	ug/l	0.077	0.066	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	80		30-150	A
Decachlorobiphenyl	57		30-150	A
2,4,5,6-Tetrachloro-m-xylene	78		30-150	B
Decachlorobiphenyl	60		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-04
Client ID: GW-6
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 11:00
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8082A
Analytical Date: 04/05/23 15:26
Analyst: MEO

Extraction Method: EPA 3510C
Extraction Date: 04/04/23 23:32
Cleanup Method: EPA 3665A
Cleanup Date: 04/05/23
Cleanup Method: EPA 3660B
Cleanup Date: 04/05/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/l	0.071	0.061	1	A
Aroclor 1221	ND		ug/l	0.071	0.061	1	A
Aroclor 1232	ND		ug/l	0.071	0.061	1	A
Aroclor 1242	ND		ug/l	0.071	0.061	1	A
Aroclor 1248	ND		ug/l	0.071	0.061	1	A
Aroclor 1254	ND		ug/l	0.071	0.061	1	B
Aroclor 1260	ND		ug/l	0.071	0.061	1	A
Aroclor 1262	ND		ug/l	0.071	0.061	1	A
Aroclor 1268	ND		ug/l	0.071	0.061	1	A
PCBs, Total	ND		ug/l	0.071	0.061	1	B

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	91		30-150	A
Decachlorobiphenyl	60		30-150	A
2,4,5,6-Tetrachloro-m-xylene	85		30-150	B
Decachlorobiphenyl	60		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-05
Client ID: GW-7
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 11:30
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8082A
Analytical Date: 04/05/23 15:35
Analyst: MEO

Extraction Method: EPA 3510C
Extraction Date: 04/04/23 23:32
Cleanup Method: EPA 3665A
Cleanup Date: 04/05/23
Cleanup Method: EPA 3660B
Cleanup Date: 04/05/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/l	0.071	0.061	1	A
Aroclor 1221	ND		ug/l	0.071	0.061	1	A
Aroclor 1232	ND		ug/l	0.071	0.061	1	A
Aroclor 1242	ND		ug/l	0.071	0.061	1	A
Aroclor 1248	ND		ug/l	0.071	0.061	1	A
Aroclor 1254	ND		ug/l	0.071	0.061	1	B
Aroclor 1260	ND		ug/l	0.071	0.061	1	A
Aroclor 1262	ND		ug/l	0.071	0.061	1	A
Aroclor 1268	ND		ug/l	0.071	0.061	1	A
PCBs, Total	ND		ug/l	0.071	0.061	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	87		30-150	A
Decachlorobiphenyl	66		30-150	A
2,4,5,6-Tetrachloro-m-xylene	85		30-150	B
Decachlorobiphenyl	69		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-06
Client ID: SB-37
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 11:40
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8082A
Analytical Date: 04/07/23 01:27
Analyst: JM
Percent Solids: 92%

Extraction Method: EPA 3546
Extraction Date: 04/04/23 12:25
Cleanup Method: EPA 3665A
Cleanup Date: 04/06/23
Cleanup Method: EPA 3660B
Cleanup Date: 04/06/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/kg	35.9	3.18	1	A
Aroclor 1221	ND		ug/kg	35.9	3.59	1	A
Aroclor 1232	ND		ug/kg	35.9	7.60	1	A
Aroclor 1242	ND		ug/kg	35.9	4.83	1	A
Aroclor 1248	ND		ug/kg	35.9	5.38	1	A
Aroclor 1254	ND		ug/kg	35.9	3.92	1	A
Aroclor 1260	ND		ug/kg	35.9	6.63	1	A
Aroclor 1262	ND		ug/kg	35.9	4.55	1	A
Aroclor 1268	ND		ug/kg	35.9	3.72	1	B
PCBs, Total	ND		ug/kg	35.9	3.18	1	B

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	75		30-150	A
Decachlorobiphenyl	83		30-150	A
2,4,5,6-Tetrachloro-m-xylene	76		30-150	B
Decachlorobiphenyl	83		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-07
Client ID: SB-38
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 11:15
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8082A
Analytical Date: 04/06/23 23:27
Analyst: JM
Percent Solids: 90%

Extraction Method: EPA 3546
Extraction Date: 04/04/23 12:25
Cleanup Method: EPA 3665A
Cleanup Date: 04/06/23
Cleanup Method: EPA 3660B
Cleanup Date: 04/06/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/kg	35.1	3.12	1	A
Aroclor 1221	ND		ug/kg	35.1	3.52	1	A
Aroclor 1232	ND		ug/kg	35.1	7.44	1	A
Aroclor 1242	ND		ug/kg	35.1	4.73	1	A
Aroclor 1248	ND		ug/kg	35.1	5.26	1	A
Aroclor 1254	ND		ug/kg	35.1	3.84	1	A
Aroclor 1260	6.80	J	ug/kg	35.1	6.48	1	A
Aroclor 1262	ND		ug/kg	35.1	4.46	1	A
Aroclor 1268	ND		ug/kg	35.1	3.64	1	A
PCBs, Total	6.80	J	ug/kg	35.1	3.12	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	80		30-150	A
Decachlorobiphenyl	89		30-150	A
2,4,5,6-Tetrachloro-m-xylene	83		30-150	B
Decachlorobiphenyl	91		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8082A
Analytical Date: 04/06/23 22:30
Analyst: JM

Extraction Method: EPA 3546
Extraction Date: 04/04/23 12:25
Cleanup Method: EPA 3665A
Cleanup Date: 04/06/23
Cleanup Method: EPA 3660B
Cleanup Date: 04/06/23

Parameter	Result	Qualifier	Units	RL	MDL	Column
Polychlorinated Biphenyls by GC - Westborough Lab for sample(s): 06-07 Batch: WG1762579-1						
Aroclor 1016	ND		ug/kg	31.9	2.84	A
Aroclor 1221	ND		ug/kg	31.9	3.20	A
Aroclor 1232	ND		ug/kg	31.9	6.77	A
Aroclor 1242	ND		ug/kg	31.9	4.31	A
Aroclor 1248	ND		ug/kg	31.9	4.79	A
Aroclor 1254	ND		ug/kg	31.9	3.50	A
Aroclor 1260	ND		ug/kg	31.9	5.90	A
Aroclor 1262	ND		ug/kg	31.9	4.06	A
Aroclor 1268	ND		ug/kg	31.9	3.31	A
PCBs, Total	ND		ug/kg	31.9	2.84	A

Surrogate	%Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	93		30-150	A
Decachlorobiphenyl	101		30-150	A
2,4,5,6-Tetrachloro-m-xylene	97		30-150	B
Decachlorobiphenyl	102		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8082A
Analytical Date: 04/05/23 11:56
Analyst: MEO

Extraction Method: EPA 3510C
Extraction Date: 04/04/23 23:32
Cleanup Method: EPA 3665A
Cleanup Date: 04/05/23
Cleanup Method: EPA 3660B
Cleanup Date: 04/05/23

Parameter	Result	Qualifier	Units	RL	MDL	Column
Polychlorinated Biphenyls by GC - Westborough Lab for sample(s): 04-05 Batch: WG1762780-1						
Aroclor 1016	ND		ug/l	0.071	0.061	A
Aroclor 1221	ND		ug/l	0.071	0.061	A
Aroclor 1232	ND		ug/l	0.071	0.061	A
Aroclor 1242	ND		ug/l	0.071	0.061	A
Aroclor 1248	ND		ug/l	0.071	0.061	A
Aroclor 1260	ND		ug/l	0.071	0.061	A
Aroclor 1262	ND		ug/l	0.071	0.061	A
Aroclor 1268	ND		ug/l	0.071	0.061	A
PCBs, Total	0.070	J	ug/l	0.071	0.061	A
Aroclor 1254	0.070	J	ug/l	0.071	0.061	B

Surrogate	%Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	89		30-150	A
Decachlorobiphenyl	101		30-150	A
2,4,5,6-Tetrachloro-m-xylene	87		30-150	B
Decachlorobiphenyl	110		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8082A
Analytical Date: 04/07/23 13:35
Analyst: RMP

Extraction Method: EPA 3510C
Extraction Date: 04/06/23 12:11
Cleanup Method: EPA 3665A
Cleanup Date: 04/06/23
Cleanup Method: EPA 3660B
Cleanup Date: 04/07/23

Parameter	Result	Qualifier	Units	RL	MDL	Column
Polychlorinated Biphenyls by GC - Westborough Lab for sample(s): 01-03 Batch: WG1763583-1						
Aroclor 1016	ND		ug/l	0.071	0.061	A
Aroclor 1221	ND		ug/l	0.071	0.061	A
Aroclor 1232	ND		ug/l	0.071	0.061	A
Aroclor 1242	ND		ug/l	0.071	0.061	A
Aroclor 1248	ND		ug/l	0.071	0.061	A
Aroclor 1260	ND		ug/l	0.071	0.061	A
Aroclor 1262	ND		ug/l	0.071	0.061	A
Aroclor 1268	ND		ug/l	0.071	0.061	A
Aroclor 1254	ND		ug/l	0.071	0.061	B
PCBs, Total	ND		ug/l	0.071	0.061	B

Surrogate	%Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	86		30-150	A
Decachlorobiphenyl	91		30-150	A
2,4,5,6-Tetrachloro-m-xylene	80		30-150	B
Decachlorobiphenyl	98		30-150	B

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2316865

Report Date: 04/20/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits	Column
Polychlorinated Biphenyls by GC - Westborough Lab Associated sample(s): 06-07 Batch: WG1762579-2 WG1762579-3									
Aroclor 1016	98		89		40-140	10		50	A
Aroclor 1260	94		86		40-140	9		50	A

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	95		84		30-150	A
Decachlorobiphenyl	102		95		30-150	A
2,4,5,6-Tetrachloro-m-xylene	96		86		30-150	B
Decachlorobiphenyl	102		95		30-150	B

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2316865

Report Date: 04/20/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits	Column
Polychlorinated Biphenyls by GC - Westborough Lab Associated sample(s): 04-05 Batch: WG1762780-2 WG1762780-3									
Aroclor 1016	103		98		40-140	5		50	A
Aroclor 1260	95		91		40-140	4		50	A

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	89		89		30-150	A
Decachlorobiphenyl	103		99		30-150	A
2,4,5,6-Tetrachloro-m-xylene	89		84		30-150	B
Decachlorobiphenyl	112		104		30-150	B

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2316865

Report Date: 04/20/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits	Column
Polychlorinated Biphenyls by GC - Westborough Lab Associated sample(s): 01-03 Batch: WG1763583-2 WG1763583-3									
Aroclor 1016	113		90		40-140	23		50	A
Aroclor 1260	128		87		40-140	38		50	A

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	85		81		30-150	A
Decachlorobiphenyl	98		87		30-150	A
2,4,5,6-Tetrachloro-m-xylene	83		80		30-150	B
Decachlorobiphenyl	93		99		30-150	B

PESTICIDES

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-01
Client ID: GW-3
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 13:00
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8081B
Analytical Date: 04/05/23 18:39
Analyst: AKM

Extraction Method: EPA 3510C
Extraction Date: 04/04/23 18:11

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/l	0.014	0.003	1	A
Lindane	ND		ug/l	0.014	0.003	1	A
Alpha-BHC	ND	IP	ug/l	0.014	0.003	1	B
Beta-BHC	ND		ug/l	0.014	0.004	1	A
Heptachlor	ND		ug/l	0.014	0.002	1	A
Aldrin	ND		ug/l	0.014	0.002	1	A
Heptachlor epoxide	ND		ug/l	0.014	0.003	1	A
Endrin	ND		ug/l	0.029	0.003	1	A
Endrin aldehyde	ND		ug/l	0.029	0.006	1	A
Endrin ketone	ND		ug/l	0.029	0.003	1	A
Dieldrin	ND		ug/l	0.029	0.003	1	A
4,4'-DDE	ND		ug/l	0.029	0.003	1	A
4,4'-DDD	ND		ug/l	0.029	0.003	1	A
4,4'-DDT	ND		ug/l	0.029	0.003	1	A
Endosulfan I	ND		ug/l	0.014	0.002	1	A
Endosulfan II	ND		ug/l	0.029	0.004	1	A
Endosulfan sulfate	ND		ug/l	0.029	0.003	1	A
Methoxychlor	ND		ug/l	0.143	0.005	1	A
Toxaphene	ND		ug/l	0.143	0.045	1	A
cis-Chlordane	ND		ug/l	0.014	0.005	1	A
trans-Chlordane	ND		ug/l	0.014	0.004	1	A
Chlordane	ND		ug/l	0.143	0.033	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-01 Date Collected: 03/30/23 13:00

Client ID: GW-3 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	62		30-150	A
Decachlorobiphenyl	50		30-150	A
2,4,5,6-Tetrachloro-m-xylene	69		30-150	B
Decachlorobiphenyl	52		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-02
Client ID: GW-4
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 13:30
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8081B
Analytical Date: 04/05/23 18:51
Analyst: AKM

Extraction Method: EPA 3510C
Extraction Date: 04/04/23 18:11

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/l	0.014	0.003	1	A
Lindane	ND		ug/l	0.014	0.003	1	A
Alpha-BHC	ND		ug/l	0.014	0.003	1	A
Beta-BHC	ND		ug/l	0.014	0.004	1	A
Heptachlor	ND		ug/l	0.014	0.002	1	A
Aldrin	ND		ug/l	0.014	0.002	1	A
Heptachlor epoxide	ND		ug/l	0.014	0.003	1	A
Endrin	ND		ug/l	0.029	0.003	1	A
Endrin aldehyde	ND		ug/l	0.029	0.006	1	A
Endrin ketone	ND		ug/l	0.029	0.003	1	A
Dieldrin	ND		ug/l	0.029	0.003	1	A
4,4'-DDE	ND		ug/l	0.029	0.003	1	A
4,4'-DDD	ND		ug/l	0.029	0.003	1	A
4,4'-DDT	ND		ug/l	0.029	0.003	1	A
Endosulfan I	ND		ug/l	0.014	0.002	1	A
Endosulfan II	ND		ug/l	0.029	0.004	1	A
Endosulfan sulfate	ND		ug/l	0.029	0.003	1	A
Methoxychlor	ND		ug/l	0.143	0.005	1	A
Toxaphene	ND		ug/l	0.143	0.045	1	A
cis-Chlordane	ND		ug/l	0.014	0.005	1	A
trans-Chlordane	ND		ug/l	0.014	0.004	1	A
Chlordane	ND		ug/l	0.143	0.033	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-02 Date Collected: 03/30/23 13:30

Client ID: GW-4 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	68		30-150	A
Decachlorobiphenyl	70		30-150	A
2,4,5,6-Tetrachloro-m-xylene	64		30-150	B
Decachlorobiphenyl	68		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-03
Client ID: GW-5
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 10:30
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8081B
Analytical Date: 04/05/23 19:03
Analyst: AKM

Extraction Method: EPA 3510C
Extraction Date: 04/04/23 18:11

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/l	0.014	0.003	1	A
Lindane	ND		ug/l	0.014	0.003	1	A
Alpha-BHC	ND		ug/l	0.014	0.003	1	A
Beta-BHC	ND		ug/l	0.014	0.004	1	A
Heptachlor	ND		ug/l	0.014	0.002	1	A
Aldrin	ND		ug/l	0.014	0.002	1	A
Heptachlor epoxide	ND		ug/l	0.014	0.003	1	A
Endrin	ND		ug/l	0.029	0.003	1	A
Endrin aldehyde	ND		ug/l	0.029	0.006	1	A
Endrin ketone	ND		ug/l	0.029	0.003	1	A
Dieldrin	ND		ug/l	0.029	0.003	1	A
4,4'-DDE	ND		ug/l	0.029	0.003	1	A
4,4'-DDD	ND		ug/l	0.029	0.003	1	A
4,4'-DDT	ND	IP	ug/l	0.029	0.003	1	A
Endosulfan I	ND		ug/l	0.014	0.002	1	A
Endosulfan II	ND		ug/l	0.029	0.004	1	A
Endosulfan sulfate	ND		ug/l	0.029	0.003	1	A
Methoxychlor	ND		ug/l	0.143	0.005	1	A
Toxaphene	ND		ug/l	0.143	0.045	1	A
cis-Chlordane	ND		ug/l	0.014	0.005	1	A
trans-Chlordane	ND		ug/l	0.014	0.004	1	A
Chlordane	ND		ug/l	0.143	0.033	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-03 Date Collected: 03/30/23 10:30

Client ID: GW-5 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	65		30-150	A
Decachlorobiphenyl	67		30-150	A
2,4,5,6-Tetrachloro-m-xylene	67		30-150	B
Decachlorobiphenyl	58		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-04
Client ID: GW-6
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 11:00
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8081B
Analytical Date: 04/05/23 19:16
Analyst: AKM

Extraction Method: EPA 3510C
Extraction Date: 04/04/23 18:11

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/l	0.014	0.003	1	A
Lindane	ND		ug/l	0.014	0.003	1	A
Alpha-BHC	ND		ug/l	0.014	0.003	1	A
Beta-BHC	ND		ug/l	0.014	0.004	1	A
Heptachlor	ND		ug/l	0.014	0.002	1	A
Aldrin	ND		ug/l	0.014	0.002	1	A
Heptachlor epoxide	ND		ug/l	0.014	0.003	1	A
Endrin	ND		ug/l	0.029	0.003	1	A
Endrin aldehyde	ND		ug/l	0.029	0.006	1	A
Endrin ketone	ND		ug/l	0.029	0.003	1	A
Dieldrin	ND		ug/l	0.029	0.003	1	A
4,4'-DDE	ND		ug/l	0.029	0.003	1	A
4,4'-DDD	ND		ug/l	0.029	0.003	1	A
4,4'-DDT	ND	IP	ug/l	0.029	0.003	1	A
Endosulfan I	ND		ug/l	0.014	0.002	1	A
Endosulfan II	ND		ug/l	0.029	0.004	1	A
Endosulfan sulfate	ND		ug/l	0.029	0.003	1	A
Methoxychlor	ND		ug/l	0.143	0.005	1	A
Toxaphene	ND		ug/l	0.143	0.045	1	A
cis-Chlordane	ND		ug/l	0.014	0.005	1	A
trans-Chlordane	ND		ug/l	0.014	0.004	1	A
Chlordane	ND		ug/l	0.143	0.033	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-04 Date Collected: 03/30/23 11:00

Client ID: GW-6 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	71		30-150	A
Decachlorobiphenyl	58		30-150	A
2,4,5,6-Tetrachloro-m-xylene	65		30-150	B
Decachlorobiphenyl	48		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-05
Client ID: GW-7
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 11:30
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8081B
Analytical Date: 04/05/23 19:28
Analyst: AKM

Extraction Method: EPA 3510C
Extraction Date: 04/04/23 18:11

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/l	0.014	0.003	1	A
Lindane	ND		ug/l	0.014	0.003	1	A
Alpha-BHC	ND		ug/l	0.014	0.003	1	A
Beta-BHC	ND		ug/l	0.014	0.004	1	A
Heptachlor	ND		ug/l	0.014	0.002	1	A
Aldrin	ND		ug/l	0.014	0.002	1	A
Heptachlor epoxide	ND		ug/l	0.014	0.003	1	A
Endrin	ND		ug/l	0.029	0.003	1	A
Endrin aldehyde	ND		ug/l	0.029	0.006	1	A
Endrin ketone	ND		ug/l	0.029	0.003	1	A
Dieldrin	ND		ug/l	0.029	0.003	1	A
4,4'-DDE	ND		ug/l	0.029	0.003	1	A
4,4'-DDD	ND		ug/l	0.029	0.003	1	A
4,4'-DDT	0.004	JIP	ug/l	0.029	0.003	1	A
Endosulfan I	ND		ug/l	0.014	0.002	1	A
Endosulfan II	ND		ug/l	0.029	0.004	1	A
Endosulfan sulfate	ND		ug/l	0.029	0.003	1	A
Methoxychlor	ND		ug/l	0.143	0.005	1	A
Toxaphene	ND		ug/l	0.143	0.045	1	A
cis-Chlordane	ND		ug/l	0.014	0.005	1	A
trans-Chlordane	ND		ug/l	0.014	0.004	1	A
Chlordane	ND		ug/l	0.143	0.033	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-05 Date Collected: 03/30/23 11:30

Client ID: GW-7 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	60		30-150	A
Decachlorobiphenyl	49		30-150	A
2,4,5,6-Tetrachloro-m-xylene	62		30-150	B
Decachlorobiphenyl	47		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-06
Client ID: SB-37
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 11:40
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8081B
Analytical Date: 04/05/23 10:26
Analyst: AKM
Percent Solids: 92%

Extraction Method: EPA 3546
Extraction Date: 04/04/23 17:57
Cleanup Method: EPA 3620B
Cleanup Date: 04/05/23
Cleanup Method: EPA 3660B
Cleanup Date: 04/05/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/kg	1.70	0.332	1	A
Lindane	ND		ug/kg	0.707	0.316	1	A
Alpha-BHC	ND		ug/kg	0.707	0.201	1	A
Beta-BHC	ND		ug/kg	1.70	0.643	1	A
Heptachlor	ND		ug/kg	0.848	0.380	1	A
Aldrin	ND		ug/kg	1.70	0.597	1	A
Heptachlor epoxide	ND		ug/kg	3.18	0.954	1	A
Endrin	ND		ug/kg	0.707	0.290	1	A
Endrin aldehyde	ND		ug/kg	2.12	0.742	1	A
Endrin ketone	ND		ug/kg	1.70	0.437	1	A
Dieldrin	ND		ug/kg	1.06	0.530	1	A
4,4'-DDE	3.34		ug/kg	1.70	0.392	1	A
4,4'-DDD	2.19		ug/kg	1.70	0.605	1	B
4,4'-DDT	ND		ug/kg	1.70	1.36	1	A
Endosulfan I	ND		ug/kg	1.70	0.401	1	A
Endosulfan II	ND		ug/kg	1.70	0.567	1	A
Endosulfan sulfate	ND		ug/kg	0.707	0.336	1	A
Methoxychlor	ND		ug/kg	3.18	0.989	1	A
Toxaphene	ND		ug/kg	31.8	8.90	1	A
cis-Chlordane	ND		ug/kg	2.12	0.591	1	A
trans-Chlordane	ND		ug/kg	2.12	0.560	1	A
Chlordane	ND		ug/kg	14.1	5.62	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-06 Date Collected: 03/30/23 11:40

Client ID: SB-37 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	93		30-150	A
Decachlorobiphenyl	74		30-150	A
2,4,5,6-Tetrachloro-m-xylene	74		30-150	B
Decachlorobiphenyl	71		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-07
Client ID: SB-38
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 11:15
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8081B
Analytical Date: 04/05/23 10:38
Analyst: AKM
Percent Solids: 90%

Extraction Method: EPA 3546
Extraction Date: 04/04/23 17:57
Cleanup Method: EPA 3620B
Cleanup Date: 04/05/23
Cleanup Method: EPA 3660B
Cleanup Date: 04/05/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/kg	1.74	0.341	1	A
Lindane	ND		ug/kg	0.726	0.324	1	A
Alpha-BHC	ND		ug/kg	0.726	0.206	1	A
Beta-BHC	ND		ug/kg	1.74	0.660	1	A
Heptachlor	ND		ug/kg	0.871	0.390	1	A
Aldrin	ND		ug/kg	1.74	0.613	1	A
Heptachlor epoxide	ND		ug/kg	3.26	0.980	1	A
Endrin	ND		ug/kg	0.726	0.298	1	A
Endrin aldehyde	ND		ug/kg	2.18	0.762	1	A
Endrin ketone	ND		ug/kg	1.74	0.448	1	A
Dieldrin	1.76		ug/kg	1.09	0.544	1	B
4,4'-DDE	3.18		ug/kg	1.74	0.403	1	A
4,4'-DDD	5.74		ug/kg	1.74	0.621	1	A
4,4'-DDT	ND	IP	ug/kg	1.74	1.40	1	A
Endosulfan I	ND		ug/kg	1.74	0.411	1	A
Endosulfan II	ND		ug/kg	1.74	0.582	1	A
Endosulfan sulfate	ND		ug/kg	0.726	0.345	1	A
Methoxychlor	ND		ug/kg	3.26	1.02	1	A
Toxaphene	ND		ug/kg	32.6	9.14	1	A
cis-Chlordane	2.28	IP	ug/kg	2.18	0.607	1	B
trans-Chlordane	4.28		ug/kg	2.18	0.575	1	B
Chlordane	16.8		ug/kg	14.5	5.77	1	B

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-07 Date Collected: 03/30/23 11:15

Client ID: SB-38 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	84		30-150	A
Decachlorobiphenyl	57		30-150	A
2,4,5,6-Tetrachloro-m-xylene	82		30-150	B
Decachlorobiphenyl	63		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8081B
Analytical Date: 04/05/23 09:36
Analyst: AAR

Extraction Method: EPA 3546
Extraction Date: 04/04/23 17:57
Cleanup Method: EPA 3620B
Cleanup Date: 04/05/23
Cleanup Method: EPA 3660B
Cleanup Date: 04/05/23

Parameter	Result	Qualifier	Units	RL	MDL	Column
Organochlorine Pesticides by GC - Westborough Lab for sample(s): 06-07 Batch: WG1762700-1						
Delta-BHC	ND		ug/kg	1.57	0.308	A
Lindane	ND		ug/kg	0.655	0.293	A
Alpha-BHC	ND		ug/kg	0.655	0.186	A
Beta-BHC	ND		ug/kg	1.57	0.596	A
Heptachlor	ND		ug/kg	0.786	0.352	A
Aldrin	ND		ug/kg	1.57	0.553	A
Heptachlor epoxide	ND		ug/kg	2.95	0.884	A
Endrin	ND		ug/kg	0.655	0.268	A
Endrin aldehyde	ND		ug/kg	1.96	0.688	A
Endrin ketone	ND		ug/kg	1.57	0.405	A
Dieldrin	ND		ug/kg	0.982	0.491	A
4,4'-DDE	ND		ug/kg	1.57	0.363	A
4,4'-DDD	ND		ug/kg	1.57	0.560	A
4,4'-DDT	ND		ug/kg	1.57	1.26	A
Endosulfan I	ND		ug/kg	1.57	0.371	A
Endosulfan II	ND		ug/kg	1.57	0.525	A
Endosulfan sulfate	ND		ug/kg	0.655	0.312	A
Methoxychlor	ND		ug/kg	2.95	0.917	A
Toxaphene	ND		ug/kg	29.5	8.25	A
cis-Chlordane	ND		ug/kg	1.96	0.547	A
trans-Chlordane	ND		ug/kg	1.96	0.519	A
Chlordane	ND		ug/kg	13.1	5.21	A

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8081B
Analytical Date: 04/05/23 09:36
Analyst: AAR

Extraction Method: EPA 3546
Extraction Date: 04/04/23 17:57
Cleanup Method: EPA 3620B
Cleanup Date: 04/05/23
Cleanup Method: EPA 3660B
Cleanup Date: 04/05/23

Parameter	Result	Qualifier	Units	RL	MDL	Column
Organochlorine Pesticides by GC - Westborough Lab for sample(s): 06-07 Batch: WG1762700-1						

Surrogate	%Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	77		30-150	A
Decachlorobiphenyl	78		30-150	A
2,4,5,6-Tetrachloro-m-xylene	75		30-150	B
Decachlorobiphenyl	71		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8081B
Analytical Date: 04/05/23 18:03
Analyst: AKM

Extraction Method: EPA 3510C
Extraction Date: 04/04/23 18:11

Parameter	Result	Qualifier	Units	RL	MDL	Column
Organochlorine Pesticides by GC - Westborough Lab for sample(s): 01-05 Batch: WG1762707-1						
Delta-BHC	ND		ug/l	0.014	0.003	A
Lindane	ND		ug/l	0.014	0.003	A
Alpha-BHC	ND		ug/l	0.014	0.003	A
Beta-BHC	ND		ug/l	0.014	0.004	A
Heptachlor	ND		ug/l	0.014	0.002	A
Aldrin	ND		ug/l	0.014	0.002	A
Heptachlor epoxide	ND		ug/l	0.014	0.003	A
Endrin	ND		ug/l	0.029	0.003	A
Endrin aldehyde	ND		ug/l	0.029	0.006	A
Endrin ketone	ND		ug/l	0.029	0.003	A
Dieldrin	ND		ug/l	0.029	0.003	A
4,4'-DDE	ND		ug/l	0.029	0.003	A
4,4'-DDD	ND		ug/l	0.029	0.003	A
4,4'-DDT	0.009	JIP	ug/l	0.029	0.003	A
Endosulfan I	ND		ug/l	0.014	0.002	A
Endosulfan II	ND		ug/l	0.029	0.004	A
Endosulfan sulfate	ND		ug/l	0.029	0.003	A
Methoxychlor	ND		ug/l	0.143	0.005	A
Toxaphene	ND		ug/l	0.143	0.045	A
cis-Chlordane	ND		ug/l	0.014	0.005	A
trans-Chlordane	ND		ug/l	0.014	0.004	A
Chlordane	ND		ug/l	0.143	0.033	A

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8081B
Analytical Date: 04/05/23 18:03
Analyst: AKM

Extraction Method: EPA 3510C
Extraction Date: 04/04/23 18:11

Parameter	Result	Qualifier	Units	RL	MDL	Column
Organochlorine Pesticides by GC - Westborough Lab for sample(s): 01-05 Batch: WG1762707-1						

Surrogate	%Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	81		30-150	A
Decachlorobiphenyl	90		30-150	A
2,4,5,6-Tetrachloro-m-xylene	85		30-150	B
Decachlorobiphenyl	99		30-150	B

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2316865

Report Date: 04/20/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits	Column
Organochlorine Pesticides by GC - Westborough Lab Associated sample(s): 06-07 Batch: WG1762700-2 WG1762700-3									
Delta-BHC	83		87		30-150	5		30	A
Lindane	83		81		30-150	2		30	A
Alpha-BHC	90		89		30-150	1		30	A
Beta-BHC	80		81		30-150	1		30	A
Heptachlor	92		93		30-150	1		30	A
Aldrin	84		88		30-150	5		30	A
Heptachlor epoxide	80		81		30-150	1		30	A
Endrin	85		88		30-150	3		30	A
Endrin aldehyde	61		60		30-150	2		30	A
Endrin ketone	76		80		30-150	5		30	A
Dieldrin	92		94		30-150	2		30	A
4,4'-DDE	83		84		30-150	1		30	A
4,4'-DDD	92		93		30-150	1		30	A
4,4'-DDT	90		92		30-150	2		30	A
Endosulfan I	85		84		30-150	1		30	A
Endosulfan II	87		88		30-150	1		30	A
Endosulfan sulfate	59		63		30-150	7		30	A
Methoxychlor	85		89		30-150	5		30	A
cis-Chlordane	76		77		30-150	1		30	A
trans-Chlordane	98		100		30-150	2		30	A

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2316865

Report Date: 04/20/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Organochlorine Pesticides by GC - Westborough Lab Associated sample(s): 06-07 Batch: WG1762700-2 WG1762700-3								

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	84		85		30-150	A
Decachlorobiphenyl	78		78		30-150	A
2,4,5,6-Tetrachloro-m-xylene	81		79		30-150	B
Decachlorobiphenyl	78		78		30-150	B

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316865
Report Date: 04/20/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits	Column
Organochlorine Pesticides by GC - Westborough Lab Associated sample(s): 01-05 Batch: WG1762707-2 WG1762707-3									
Delta-BHC	69		66		30-150	4		20	A
Lindane	78		75		30-150	4		20	A
Alpha-BHC	80		75		30-150	7		20	A
Beta-BHC	78		76		30-150	3		20	A
Heptachlor	72		70		30-150	2		20	A
Aldrin	71		69		30-150	4		20	A
Heptachlor epoxide	79		76		30-150	3		20	A
Endrin	80		76		30-150	5		20	A
Endrin aldehyde	71		68		30-150	3		20	A
Endrin ketone	87		84		30-150	4		20	A
Dieldrin	86		81		30-150	6		20	A
4,4'-DDE	79		75		30-150	6		20	A
4,4'-DDD	87		83		30-150	5		20	A
4,4'-DDT	82		80		30-150	3		20	A
Endosulfan I	78		75		30-150	5		20	A
Endosulfan II	80		77		30-150	5		20	A
Endosulfan sulfate	80		74		30-150	7		20	A
Methoxychlor	84		82		30-150	3		20	A
cis-Chlordane	70		66		30-150	5		20	A
trans-Chlordane	87		83		30-150	4		20	A

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2316865

Report Date: 04/20/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits

Organochlorine Pesticides by GC - Westborough Lab Associated sample(s): 01-05 Batch: WG1762707-2 WG1762707-3

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	65		63		30-150	A
Decachlorobiphenyl	94		79		30-150	A
2,4,5,6-Tetrachloro-m-xylene	62		59		30-150	B
Decachlorobiphenyl	70		65		30-150	B

METALS

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-01 Date Collected: 03/30/23 13:00

Client ID: GW-3 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Water

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	32.4		mg/l	0.100	0.0327	10	04/02/23 08:09	04/05/23 19:45	EPA 3005A	1,6020B	WKP
Antimony, Total	ND		mg/l	0.04000	0.00429	10	04/02/23 08:09	04/05/23 19:45	EPA 3005A	1,6020B	WKP
Arsenic, Total	0.00427	J	mg/l	0.00500	0.00165	10	04/02/23 08:09	04/05/23 19:45	EPA 3005A	1,6020B	WKP
Barium, Total	0.7488		mg/l	0.00500	0.00173	10	04/02/23 08:09	04/05/23 19:45	EPA 3005A	1,6020B	WKP
Beryllium, Total	ND		mg/l	0.00500	0.00107	10	04/02/23 08:09	04/05/23 19:45	EPA 3005A	1,6020B	WKP
Cadmium, Total	ND		mg/l	0.00200	0.00059	10	04/02/23 08:09	04/05/23 19:45	EPA 3005A	1,6020B	WKP
Calcium, Total	335.		mg/l	1.00	0.394	10	04/02/23 08:09	04/05/23 19:45	EPA 3005A	1,6020B	WKP
Chromium, Total	0.1438		mg/l	0.01000	0.00178	10	04/02/23 08:09	04/05/23 19:45	EPA 3005A	1,6020B	WKP
Cobalt, Total	0.07232		mg/l	0.00500	0.00163	10	04/02/23 08:09	04/05/23 19:45	EPA 3005A	1,6020B	WKP
Copper, Total	0.1709		mg/l	0.01000	0.00384	10	04/02/23 08:09	04/05/23 19:45	EPA 3005A	1,6020B	WKP
Iron, Total	71.1		mg/l	0.500	0.191	10	04/02/23 08:09	04/05/23 19:45	EPA 3005A	1,6020B	WKP
Lead, Total	0.03912		mg/l	0.01000	0.00343	10	04/02/23 08:09	04/05/23 19:45	EPA 3005A	1,6020B	WKP
Magnesium, Total	116.		mg/l	0.700	0.242	10	04/02/23 08:09	04/05/23 19:45	EPA 3005A	1,6020B	WKP
Manganese, Total	2.103		mg/l	0.01000	0.00440	10	04/02/23 08:09	04/05/23 19:45	EPA 3005A	1,6020B	WKP
Mercury, Total	0.00011	J	mg/l	0.00020	0.00009	1	04/02/23 09:02	04/03/23 10:00	EPA 7470A	1,7470A	DMB
Nickel, Total	0.09479		mg/l	0.02000	0.00556	10	04/02/23 08:09	04/05/23 19:45	EPA 3005A	1,6020B	WKP
Potassium, Total	38.9		mg/l	1.00	0.309	10	04/02/23 08:09	04/05/23 19:45	EPA 3005A	1,6020B	WKP
Selenium, Total	ND		mg/l	0.0500	0.0173	10	04/02/23 08:09	04/05/23 19:45	EPA 3005A	1,6020B	WKP
Silver, Total	ND		mg/l	0.00400	0.00163	10	04/02/23 08:09	04/05/23 19:45	EPA 3005A	1,6020B	WKP
Sodium, Total	2780		mg/l	1.00	0.293	10	04/02/23 08:09	04/05/23 19:45	EPA 3005A	1,6020B	WKP
Thallium, Total	ND		mg/l	0.02000	0.00143	10	04/02/23 08:09	04/05/23 19:45	EPA 3005A	1,6020B	WKP
Vanadium, Total	0.08532		mg/l	0.05000	0.01570	10	04/02/23 08:09	04/05/23 19:45	EPA 3005A	1,6020B	WKP
Zinc, Total	0.5152		mg/l	0.1000	0.03410	10	04/02/23 08:09	04/05/23 19:45	EPA 3005A	1,6020B	WKP

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-02 Date Collected: 03/30/23 13:30

Client ID: GW-4 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Water

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	289.		mg/l	0.200	0.0654	10	04/02/23 08:09	04/05/23 20:38	EPA 3005A	1,6020B	WKP
Antimony, Total	ND		mg/l	0.08000	0.00858	10	04/02/23 08:09	04/05/23 20:38	EPA 3005A	1,6020B	WKP
Arsenic, Total	0.03794		mg/l	0.01000	0.00330	10	04/02/23 08:09	04/05/23 20:38	EPA 3005A	1,6020B	WKP
Barium, Total	10.69		mg/l	0.01000	0.00346	10	04/02/23 08:09	04/05/23 20:38	EPA 3005A	1,6020B	WKP
Beryllium, Total	0.01283		mg/l	0.01000	0.00214	10	04/02/23 08:09	04/05/23 20:38	EPA 3005A	1,6020B	WKP
Cadmium, Total	0.00735		mg/l	0.00400	0.00119	10	04/02/23 08:09	04/05/23 20:38	EPA 3005A	1,6020B	WKP
Calcium, Total	2710		mg/l	2.00	0.788	10	04/02/23 08:09	04/05/23 20:38	EPA 3005A	1,6020B	WKP
Chromium, Total	1.295		mg/l	0.02000	0.00356	10	04/02/23 08:09	04/05/23 20:38	EPA 3005A	1,6020B	WKP
Cobalt, Total	0.8204		mg/l	0.01000	0.00326	10	04/02/23 08:09	04/05/23 20:38	EPA 3005A	1,6020B	WKP
Copper, Total	1.818		mg/l	0.02000	0.00768	10	04/02/23 08:09	04/05/23 20:38	EPA 3005A	1,6020B	WKP
Iron, Total	389.		mg/l	1.00	0.382	10	04/02/23 08:09	04/05/23 20:38	EPA 3005A	1,6020B	WKP
Lead, Total	0.6328		mg/l	0.02000	0.00686	10	04/02/23 08:09	04/05/23 20:38	EPA 3005A	1,6020B	WKP
Magnesium, Total	854.		mg/l	1.40	0.484	10	04/02/23 08:09	04/05/23 20:38	EPA 3005A	1,6020B	WKP
Manganese, Total	25.42		mg/l	0.02000	0.00880	10	04/02/23 08:09	04/05/23 20:38	EPA 3005A	1,6020B	WKP
Mercury, Total	0.00117		mg/l	0.00020	0.00009	1	04/02/23 09:02	04/03/23 10:03	EPA 7470A	1,7470A	DMB
Nickel, Total	0.8966		mg/l	0.04000	0.01112	10	04/02/23 08:09	04/05/23 20:38	EPA 3005A	1,6020B	WKP
Potassium, Total	112.		mg/l	2.00	0.618	10	04/02/23 08:09	04/05/23 20:38	EPA 3005A	1,6020B	WKP
Selenium, Total	0.0614	J	mg/l	0.100	0.0346	10	04/02/23 08:09	04/05/23 20:38	EPA 3005A	1,6020B	WKP
Silver, Total	0.00724	J	mg/l	0.00800	0.00326	10	04/02/23 08:09	04/05/23 20:38	EPA 3005A	1,6020B	WKP
Sodium, Total	1250		mg/l	2.00	0.586	10	04/02/23 08:09	04/05/23 20:38	EPA 3005A	1,6020B	WKP
Thallium, Total	0.00723	J	mg/l	0.04000	0.00286	10	04/02/23 08:09	04/05/23 20:38	EPA 3005A	1,6020B	WKP
Vanadium, Total	0.3305		mg/l	0.1000	0.03140	10	04/02/23 08:09	04/05/23 20:38	EPA 3005A	1,6020B	WKP
Zinc, Total	1.378		mg/l	0.2000	0.06820	10	04/02/23 08:09	04/05/23 20:38	EPA 3005A	1,6020B	WKP

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-03 Date Collected: 03/30/23 10:30

Client ID: GW-5 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Water

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	91.8		mg/l	0.100	0.0327	10	04/02/23 08:09	04/05/23 20:43	EPA 3005A	1,6020B	WKP
Antimony, Total	ND		mg/l	0.04000	0.00429	10	04/02/23 08:09	04/05/23 20:43	EPA 3005A	1,6020B	WKP
Arsenic, Total	0.00697		mg/l	0.00500	0.00165	10	04/02/23 08:09	04/05/23 20:43	EPA 3005A	1,6020B	WKP
Barium, Total	2.409		mg/l	0.00500	0.00173	10	04/02/23 08:09	04/05/23 20:43	EPA 3005A	1,6020B	WKP
Beryllium, Total	0.00319	J	mg/l	0.00500	0.00107	10	04/02/23 08:09	04/05/23 20:43	EPA 3005A	1,6020B	WKP
Cadmium, Total	0.00356		mg/l	0.00200	0.00059	10	04/02/23 08:09	04/05/23 20:43	EPA 3005A	1,6020B	WKP
Calcium, Total	421.		mg/l	1.00	0.394	10	04/02/23 08:09	04/05/23 20:43	EPA 3005A	1,6020B	WKP
Chromium, Total	0.2518		mg/l	0.01000	0.00178	10	04/02/23 08:09	04/05/23 20:43	EPA 3005A	1,6020B	WKP
Cobalt, Total	0.2485		mg/l	0.00500	0.00163	10	04/02/23 08:09	04/05/23 20:43	EPA 3005A	1,6020B	WKP
Copper, Total	0.8200		mg/l	0.01000	0.00384	10	04/02/23 08:09	04/05/23 20:43	EPA 3005A	1,6020B	WKP
Iron, Total	182.		mg/l	0.500	0.191	10	04/02/23 08:09	04/05/23 20:43	EPA 3005A	1,6020B	WKP
Lead, Total	0.1665		mg/l	0.01000	0.00343	10	04/02/23 08:09	04/05/23 20:43	EPA 3005A	1,6020B	WKP
Magnesium, Total	237.		mg/l	0.700	0.242	10	04/02/23 08:09	04/05/23 20:43	EPA 3005A	1,6020B	WKP
Manganese, Total	26.10		mg/l	0.01000	0.00440	10	04/02/23 08:09	04/05/23 20:43	EPA 3005A	1,6020B	WKP
Mercury, Total	0.00023		mg/l	0.00020	0.00009	1	04/02/23 09:02	04/03/23 10:07	EPA 7470A	1,7470A	DMB
Nickel, Total	0.4374		mg/l	0.02000	0.00556	10	04/02/23 08:09	04/05/23 20:43	EPA 3005A	1,6020B	WKP
Potassium, Total	47.9		mg/l	1.00	0.309	10	04/02/23 08:09	04/05/23 20:43	EPA 3005A	1,6020B	WKP
Selenium, Total	ND		mg/l	0.0500	0.0173	10	04/02/23 08:09	04/05/23 20:43	EPA 3005A	1,6020B	WKP
Silver, Total	ND		mg/l	0.00400	0.00163	10	04/02/23 08:09	04/05/23 20:43	EPA 3005A	1,6020B	WKP
Sodium, Total	298.		mg/l	1.00	0.293	10	04/02/23 08:09	04/05/23 20:43	EPA 3005A	1,6020B	WKP
Thallium, Total	0.00397	J	mg/l	0.02000	0.00143	10	04/02/23 08:09	04/05/23 20:43	EPA 3005A	1,6020B	WKP
Vanadium, Total	0.1642		mg/l	0.05000	0.01570	10	04/02/23 08:09	04/05/23 20:43	EPA 3005A	1,6020B	WKP
Zinc, Total	0.5685		mg/l	0.1000	0.03410	10	04/02/23 08:09	04/05/23 20:43	EPA 3005A	1,6020B	WKP

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-04 Date Collected: 03/30/23 11:00

Client ID: GW-6 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Water

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	104.		mg/l	0.100	0.0327	10	04/02/23 08:09	04/05/23 20:48	EPA 3005A	1,6020B	WKP
Antimony, Total	ND		mg/l	0.04000	0.00429	10	04/02/23 08:09	04/05/23 20:48	EPA 3005A	1,6020B	WKP
Arsenic, Total	0.01194		mg/l	0.00500	0.00165	10	04/02/23 08:09	04/05/23 20:48	EPA 3005A	1,6020B	WKP
Barium, Total	2.435		mg/l	0.00500	0.00173	10	04/02/23 08:09	04/05/23 20:48	EPA 3005A	1,6020B	WKP
Beryllium, Total	0.00517		mg/l	0.00500	0.00107	10	04/02/23 08:09	04/05/23 20:48	EPA 3005A	1,6020B	WKP
Cadmium, Total	0.00535		mg/l	0.00200	0.00059	10	04/02/23 08:09	04/05/23 20:48	EPA 3005A	1,6020B	WKP
Calcium, Total	901.		mg/l	1.00	0.394	10	04/02/23 08:09	04/05/23 20:48	EPA 3005A	1,6020B	WKP
Chromium, Total	0.2910		mg/l	0.01000	0.00178	10	04/02/23 08:09	04/05/23 20:48	EPA 3005A	1,6020B	WKP
Cobalt, Total	0.3068		mg/l	0.00500	0.00163	10	04/02/23 08:09	04/05/23 20:48	EPA 3005A	1,6020B	WKP
Copper, Total	0.7318		mg/l	0.01000	0.00384	10	04/02/23 08:09	04/05/23 20:48	EPA 3005A	1,6020B	WKP
Iron, Total	215.		mg/l	0.500	0.191	10	04/02/23 08:09	04/05/23 20:48	EPA 3005A	1,6020B	WKP
Lead, Total	0.2014		mg/l	0.01000	0.00343	10	04/02/23 08:09	04/05/23 20:48	EPA 3005A	1,6020B	WKP
Magnesium, Total	368.		mg/l	0.700	0.242	10	04/02/23 08:09	04/05/23 20:48	EPA 3005A	1,6020B	WKP
Manganese, Total	5.809		mg/l	0.01000	0.00440	10	04/02/23 08:09	04/05/23 20:48	EPA 3005A	1,6020B	WKP
Mercury, Total	0.00021		mg/l	0.00020	0.00009	1	04/02/23 09:02	04/03/23 10:10	EPA 7470A	1,7470A	DMB
Nickel, Total	0.3388		mg/l	0.02000	0.00556	10	04/02/23 08:09	04/05/23 20:48	EPA 3005A	1,6020B	WKP
Potassium, Total	58.2		mg/l	1.00	0.309	10	04/02/23 08:09	04/05/23 20:48	EPA 3005A	1,6020B	WKP
Selenium, Total	ND		mg/l	0.0500	0.0173	10	04/02/23 08:09	04/05/23 20:48	EPA 3005A	1,6020B	WKP
Silver, Total	ND		mg/l	0.00400	0.00163	10	04/02/23 08:09	04/05/23 20:48	EPA 3005A	1,6020B	WKP
Sodium, Total	614.		mg/l	1.00	0.293	10	04/02/23 08:09	04/05/23 20:48	EPA 3005A	1,6020B	WKP
Thallium, Total	0.00221	J	mg/l	0.02000	0.00143	10	04/02/23 08:09	04/05/23 20:48	EPA 3005A	1,6020B	WKP
Vanadium, Total	0.1861		mg/l	0.05000	0.01570	10	04/02/23 08:09	04/05/23 20:48	EPA 3005A	1,6020B	WKP
Zinc, Total	0.6281		mg/l	0.1000	0.03410	10	04/02/23 08:09	04/05/23 20:48	EPA 3005A	1,6020B	WKP

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-05 Date Collected: 03/30/23 11:30

Client ID: GW-7 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Water

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	80.7		mg/l	0.100	0.0327	10	04/02/23 08:09	04/05/23 20:53	EPA 3005A	1,6020B	WKP
Antimony, Total	ND		mg/l	0.04000	0.00429	10	04/02/23 08:09	04/05/23 20:53	EPA 3005A	1,6020B	WKP
Arsenic, Total	0.01024		mg/l	0.00500	0.00165	10	04/02/23 08:09	04/05/23 20:53	EPA 3005A	1,6020B	WKP
Barium, Total	1.417		mg/l	0.00500	0.00173	10	04/02/23 08:09	04/05/23 20:53	EPA 3005A	1,6020B	WKP
Beryllium, Total	0.00320	J	mg/l	0.00500	0.00107	10	04/02/23 08:09	04/05/23 20:53	EPA 3005A	1,6020B	WKP
Cadmium, Total	0.00335		mg/l	0.00200	0.00059	10	04/02/23 08:09	04/05/23 20:53	EPA 3005A	1,6020B	WKP
Calcium, Total	669.		mg/l	1.00	0.394	10	04/02/23 08:09	04/05/23 20:53	EPA 3005A	1,6020B	WKP
Chromium, Total	0.6136		mg/l	0.01000	0.00178	10	04/02/23 08:09	04/05/23 20:53	EPA 3005A	1,6020B	WKP
Cobalt, Total	0.2404		mg/l	0.00500	0.00163	10	04/02/23 08:09	04/05/23 20:53	EPA 3005A	1,6020B	WKP
Copper, Total	0.6191		mg/l	0.01000	0.00384	10	04/02/23 08:09	04/05/23 20:53	EPA 3005A	1,6020B	WKP
Iron, Total	208.		mg/l	0.500	0.191	10	04/02/23 08:09	04/05/23 20:53	EPA 3005A	1,6020B	WKP
Lead, Total	0.1180		mg/l	0.01000	0.00343	10	04/02/23 08:09	04/05/23 20:53	EPA 3005A	1,6020B	WKP
Magnesium, Total	281.		mg/l	0.700	0.242	10	04/02/23 08:09	04/05/23 20:53	EPA 3005A	1,6020B	WKP
Manganese, Total	9.712		mg/l	0.01000	0.00440	10	04/02/23 08:09	04/05/23 20:53	EPA 3005A	1,6020B	WKP
Mercury, Total	0.00016	J	mg/l	0.00020	0.00009	1	04/02/23 09:02	04/03/23 10:13	EPA 7470A	1,7470A	DMB
Nickel, Total	0.4006		mg/l	0.02000	0.00556	10	04/02/23 08:09	04/05/23 20:53	EPA 3005A	1,6020B	WKP
Potassium, Total	43.0		mg/l	1.00	0.309	10	04/02/23 08:09	04/05/23 20:53	EPA 3005A	1,6020B	WKP
Selenium, Total	ND		mg/l	0.0500	0.0173	10	04/02/23 08:09	04/05/23 20:53	EPA 3005A	1,6020B	WKP
Silver, Total	ND		mg/l	0.00400	0.00163	10	04/02/23 08:09	04/05/23 20:53	EPA 3005A	1,6020B	WKP
Sodium, Total	710.		mg/l	1.00	0.293	10	04/02/23 08:09	04/05/23 20:53	EPA 3005A	1,6020B	WKP
Thallium, Total	0.00165	J	mg/l	0.02000	0.00143	10	04/02/23 08:09	04/05/23 20:53	EPA 3005A	1,6020B	WKP
Vanadium, Total	0.1598		mg/l	0.05000	0.01570	10	04/02/23 08:09	04/05/23 20:53	EPA 3005A	1,6020B	WKP
Zinc, Total	0.5281		mg/l	0.1000	0.03410	10	04/02/23 08:09	04/05/23 20:53	EPA 3005A	1,6020B	WKP

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-06 Date Collected: 03/30/23 11:40

Client ID: SB-37 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Soil

Percent Solids: 92%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	8070		mg/kg	8.30	2.24	2	04/05/23 17:34	04/06/23 13:13	EPA 3050B	1,6010D	DHL
Antimony, Total	ND		mg/kg	4.15	0.315	2	04/05/23 17:34	04/06/23 13:13	EPA 3050B	1,6010D	DHL
Arsenic, Total	2.18		mg/kg	0.830	0.172	2	04/05/23 17:34	04/06/23 13:13	EPA 3050B	1,6010D	DHL
Barium, Total	71.0		mg/kg	0.830	0.144	2	04/05/23 17:34	04/06/23 13:13	EPA 3050B	1,6010D	DHL
Beryllium, Total	0.244	J	mg/kg	0.415	0.027	2	04/05/23 17:34	04/06/23 13:13	EPA 3050B	1,6010D	DHL
Cadmium, Total	0.129	J	mg/kg	0.830	0.081	2	04/05/23 17:34	04/06/23 13:13	EPA 3050B	1,6010D	DHL
Calcium, Total	21000		mg/kg	8.30	2.90	2	04/05/23 17:34	04/06/23 13:13	EPA 3050B	1,6010D	DHL
Chromium, Total	15.8		mg/kg	0.830	0.080	2	04/05/23 17:34	04/06/23 13:13	EPA 3050B	1,6010D	DHL
Cobalt, Total	5.34		mg/kg	1.66	0.138	2	04/05/23 17:34	04/06/23 13:13	EPA 3050B	1,6010D	DHL
Copper, Total	20.1		mg/kg	0.830	0.214	2	04/05/23 17:34	04/06/23 13:13	EPA 3050B	1,6010D	DHL
Iron, Total	14400		mg/kg	4.15	0.749	2	04/05/23 17:34	04/06/23 13:13	EPA 3050B	1,6010D	DHL
Lead, Total	40.3		mg/kg	4.15	0.222	2	04/05/23 17:34	04/06/23 13:13	EPA 3050B	1,6010D	DHL
Magnesium, Total	7250		mg/kg	8.30	1.28	2	04/05/23 17:34	04/06/23 13:13	EPA 3050B	1,6010D	DHL
Manganese, Total	254		mg/kg	0.830	0.132	2	04/05/23 17:34	04/06/23 13:13	EPA 3050B	1,6010D	DHL
Mercury, Total	0.089		mg/kg	0.075	0.049	1	04/05/23 18:12	04/05/23 22:19	EPA 7471B	1,7471B	TAA
Nickel, Total	10.9		mg/kg	2.07	0.201	2	04/05/23 17:34	04/06/23 13:13	EPA 3050B	1,6010D	DHL
Potassium, Total	1820		mg/kg	207	11.9	2	04/05/23 17:34	04/06/23 13:13	EPA 3050B	1,6010D	DHL
Selenium, Total	ND		mg/kg	1.66	0.214	2	04/05/23 17:34	04/06/23 13:13	EPA 3050B	1,6010D	DHL
Silver, Total	ND		mg/kg	0.415	0.235	2	04/05/23 17:34	04/06/23 13:13	EPA 3050B	1,6010D	DHL
Sodium, Total	185		mg/kg	166	2.61	2	04/05/23 17:34	04/06/23 13:13	EPA 3050B	1,6010D	DHL
Thallium, Total	ND		mg/kg	1.66	0.261	2	04/05/23 17:34	04/06/23 13:13	EPA 3050B	1,6010D	DHL
Vanadium, Total	24.9		mg/kg	0.830	0.168	2	04/05/23 17:34	04/06/23 13:13	EPA 3050B	1,6010D	DHL
Zinc, Total	45.1		mg/kg	4.15	0.243	2	04/05/23 17:34	04/06/23 13:13	EPA 3050B	1,6010D	DHL

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-07 Date Collected: 03/30/23 11:15

Client ID: SB-38 Date Received: 03/31/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Soil

Percent Solids: 90%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	7270		mg/kg	8.40	2.27	2	04/05/23 17:34	04/06/23 13:16	EPA 3050B	1,6010D	DHL
Antimony, Total	ND		mg/kg	4.20	0.319	2	04/05/23 17:34	04/06/23 13:16	EPA 3050B	1,6010D	DHL
Arsenic, Total	2.16		mg/kg	0.840	0.175	2	04/05/23 17:34	04/06/23 13:16	EPA 3050B	1,6010D	DHL
Barium, Total	85.3		mg/kg	0.840	0.146	2	04/05/23 17:34	04/06/23 13:16	EPA 3050B	1,6010D	DHL
Beryllium, Total	0.220	J	mg/kg	0.420	0.028	2	04/05/23 17:34	04/06/23 13:16	EPA 3050B	1,6010D	DHL
Cadmium, Total	0.176	J	mg/kg	0.840	0.082	2	04/05/23 17:34	04/06/23 13:16	EPA 3050B	1,6010D	DHL
Calcium, Total	13700		mg/kg	8.40	2.94	2	04/05/23 17:34	04/06/23 13:16	EPA 3050B	1,6010D	DHL
Chromium, Total	17.0		mg/kg	0.840	0.081	2	04/05/23 17:34	04/06/23 13:16	EPA 3050B	1,6010D	DHL
Cobalt, Total	5.74		mg/kg	1.68	0.139	2	04/05/23 17:34	04/06/23 13:16	EPA 3050B	1,6010D	DHL
Copper, Total	26.8		mg/kg	0.840	0.217	2	04/05/23 17:34	04/06/23 13:16	EPA 3050B	1,6010D	DHL
Iron, Total	14700		mg/kg	4.20	0.759	2	04/05/23 17:34	04/06/23 13:16	EPA 3050B	1,6010D	DHL
Lead, Total	60.7		mg/kg	4.20	0.225	2	04/05/23 17:34	04/06/23 13:16	EPA 3050B	1,6010D	DHL
Magnesium, Total	5410		mg/kg	8.40	1.29	2	04/05/23 17:34	04/06/23 13:16	EPA 3050B	1,6010D	DHL
Manganese, Total	206		mg/kg	0.840	0.134	2	04/05/23 17:34	04/06/23 13:16	EPA 3050B	1,6010D	DHL
Mercury, Total	0.092		mg/kg	0.071	0.046	1	04/05/23 18:12	04/05/23 22:22	EPA 7471B	1,7471B	TAA
Nickel, Total	11.7		mg/kg	2.10	0.203	2	04/05/23 17:34	04/06/23 13:16	EPA 3050B	1,6010D	DHL
Potassium, Total	1770		mg/kg	210	12.1	2	04/05/23 17:34	04/06/23 13:16	EPA 3050B	1,6010D	DHL
Selenium, Total	0.223	J	mg/kg	1.68	0.217	2	04/05/23 17:34	04/06/23 13:16	EPA 3050B	1,6010D	DHL
Silver, Total	ND		mg/kg	0.420	0.238	2	04/05/23 17:34	04/06/23 13:16	EPA 3050B	1,6010D	DHL
Sodium, Total	201		mg/kg	168	2.65	2	04/05/23 17:34	04/06/23 13:16	EPA 3050B	1,6010D	DHL
Thallium, Total	ND		mg/kg	1.68	0.265	2	04/05/23 17:34	04/06/23 13:16	EPA 3050B	1,6010D	DHL
Vanadium, Total	25.0		mg/kg	0.840	0.170	2	04/05/23 17:34	04/06/23 13:16	EPA 3050B	1,6010D	DHL
Zinc, Total	66.9		mg/kg	4.20	0.246	2	04/05/23 17:34	04/06/23 13:16	EPA 3050B	1,6010D	DHL

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

Method Blank Analysis
Batch Quality Control

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
Total Metals - Mansfield Lab for sample(s): 01-05 Batch: WG1761715-1										
Aluminum, Total	ND		mg/l	0.0100	0.00327	1	04/02/23 08:09	04/03/23 20:36	1,6020B	NTB
Antimony, Total	ND		mg/l	0.00400	0.00042	1	04/02/23 08:09	04/03/23 20:36	1,6020B	NTB
Arsenic, Total	ND		mg/l	0.00050	0.00016	1	04/02/23 08:09	04/03/23 20:36	1,6020B	NTB
Barium, Total	ND		mg/l	0.00050	0.00017	1	04/02/23 08:09	04/03/23 20:36	1,6020B	NTB
Beryllium, Total	ND		mg/l	0.00050	0.00010	1	04/02/23 08:09	04/03/23 20:36	1,6020B	NTB
Cadmium, Total	ND		mg/l	0.00020	0.00005	1	04/02/23 08:09	04/03/23 20:36	1,6020B	NTB
Calcium, Total	ND		mg/l	0.100	0.0394	1	04/02/23 08:09	04/03/23 20:36	1,6020B	NTB
Chromium, Total	ND		mg/l	0.00100	0.00017	1	04/02/23 08:09	04/03/23 20:36	1,6020B	NTB
Cobalt, Total	ND		mg/l	0.00050	0.00016	1	04/02/23 08:09	04/03/23 20:36	1,6020B	NTB
Copper, Total	ND		mg/l	0.00100	0.00038	1	04/02/23 08:09	04/03/23 20:36	1,6020B	NTB
Iron, Total	ND		mg/l	0.0500	0.0191	1	04/02/23 08:09	04/03/23 20:36	1,6020B	NTB
Lead, Total	ND		mg/l	0.00100	0.00034	1	04/02/23 08:09	04/03/23 20:36	1,6020B	NTB
Magnesium, Total	ND		mg/l	0.0700	0.0242	1	04/02/23 08:09	04/03/23 20:36	1,6020B	NTB
Manganese, Total	ND		mg/l	0.00100	0.00044	1	04/02/23 08:09	04/03/23 20:36	1,6020B	NTB
Nickel, Total	ND		mg/l	0.00200	0.00055	1	04/02/23 08:09	04/03/23 20:36	1,6020B	NTB
Potassium, Total	ND		mg/l	0.100	0.0309	1	04/02/23 08:09	04/03/23 20:36	1,6020B	NTB
Selenium, Total	ND		mg/l	0.00500	0.00173	1	04/02/23 08:09	04/03/23 20:36	1,6020B	NTB
Silver, Total	ND		mg/l	0.00040	0.00016	1	04/02/23 08:09	04/03/23 20:36	1,6020B	NTB
Sodium, Total	ND		mg/l	0.100	0.0293	1	04/02/23 08:09	04/03/23 20:36	1,6020B	NTB
Thallium, Total	0.00026	J	mg/l	0.00200	0.00014	1	04/02/23 08:09	04/03/23 20:36	1,6020B	NTB
Vanadium, Total	ND		mg/l	0.00500	0.00157	1	04/02/23 08:09	04/03/23 20:36	1,6020B	NTB
Zinc, Total	ND		mg/l	0.01000	0.00341	1	04/02/23 08:09	04/03/23 20:36	1,6020B	NTB

Prep Information

Digestion Method: EPA 3005A

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
Total Metals - Mansfield Lab for sample(s): 01-05 Batch: WG1761718-1										
Mercury, Total	ND		mg/l	0.00020	0.00009	1	04/02/23 09:02	04/03/23 09:16	1,7470A	DMB

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

Method Blank Analysis
Batch Quality Control

Prep Information

Digestion Method: EPA 7470A

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
Total Metals - Mansfield Lab for sample(s): 06-07 Batch: WG1762100-1										
Aluminum, Total	ND		mg/kg	4.00	1.08	1	04/05/23 17:34	04/06/23 07:31	1,6010D	DHL
Antimony, Total	ND		mg/kg	2.00	0.152	1	04/05/23 17:34	04/06/23 07:31	1,6010D	DHL
Arsenic, Total	ND		mg/kg	0.400	0.083	1	04/05/23 17:34	04/06/23 07:31	1,6010D	DHL
Barium, Total	ND		mg/kg	0.400	0.070	1	04/05/23 17:34	04/06/23 07:31	1,6010D	DHL
Beryllium, Total	ND		mg/kg	0.200	0.013	1	04/05/23 17:34	04/06/23 07:31	1,6010D	DHL
Cadmium, Total	ND		mg/kg	0.400	0.039	1	04/05/23 17:34	04/06/23 07:31	1,6010D	DHL
Calcium, Total	ND		mg/kg	4.00	1.40	1	04/05/23 17:34	04/06/23 07:31	1,6010D	DHL
Chromium, Total	0.119	J	mg/kg	0.400	0.038	1	04/05/23 17:34	04/06/23 07:31	1,6010D	DHL
Cobalt, Total	ND		mg/kg	0.800	0.066	1	04/05/23 17:34	04/06/23 07:31	1,6010D	DHL
Copper, Total	ND		mg/kg	0.400	0.103	1	04/05/23 17:34	04/06/23 07:31	1,6010D	DHL
Iron, Total	0.519	J	mg/kg	2.00	0.361	1	04/05/23 17:34	04/06/23 07:31	1,6010D	DHL
Lead, Total	ND		mg/kg	2.00	0.107	1	04/05/23 17:34	04/06/23 07:31	1,6010D	DHL
Magnesium, Total	ND		mg/kg	4.00	0.616	1	04/05/23 17:34	04/06/23 07:31	1,6010D	DHL
Manganese, Total	ND		mg/kg	0.400	0.064	1	04/05/23 17:34	04/06/23 07:31	1,6010D	DHL
Nickel, Total	ND		mg/kg	1.00	0.097	1	04/05/23 17:34	04/06/23 07:31	1,6010D	DHL
Potassium, Total	ND		mg/kg	100	5.76	1	04/05/23 17:34	04/06/23 07:31	1,6010D	DHL
Selenium, Total	ND		mg/kg	0.800	0.103	1	04/05/23 17:34	04/06/23 07:31	1,6010D	DHL
Silver, Total	ND		mg/kg	0.200	0.113	1	04/05/23 17:34	04/06/23 07:31	1,6010D	DHL
Sodium, Total	ND		mg/kg	80.0	1.26	1	04/05/23 17:34	04/06/23 07:31	1,6010D	DHL
Thallium, Total	ND		mg/kg	0.800	0.126	1	04/05/23 17:34	04/06/23 07:31	1,6010D	DHL
Vanadium, Total	ND		mg/kg	0.400	0.081	1	04/05/23 17:34	04/06/23 07:31	1,6010D	DHL
Zinc, Total	ND		mg/kg	2.00	0.117	1	04/05/23 17:34	04/06/23 07:31	1,6010D	DHL

Prep Information

Digestion Method: EPA 3050B

Project Name: 100 MAIN ST. **Lab Number:** L2316865

Project Number: 12461 **Report Date:** 04/20/23

Method Blank Analysis
Batch Quality Control

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
Total Metals - Mansfield Lab for sample(s): 06-07 Batch: WG1762103-1										
Mercury, Total	ND		mg/kg	0.083	0.054	1	04/05/23 18:12	04/05/23 21:42	1,7471B	TAA

Prep Information

Digestion Method: EPA 7471B

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2316865

Report Date: 04/20/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-05 Batch: WG1761715-2								
Aluminum, Total	100		-		80-120	-		
Antimony, Total	92		-		80-120	-		
Arsenic, Total	104		-		80-120	-		
Barium, Total	104		-		80-120	-		
Beryllium, Total	103		-		80-120	-		
Cadmium, Total	102		-		80-120	-		
Calcium, Total	88		-		80-120	-		
Chromium, Total	96		-		80-120	-		
Cobalt, Total	97		-		80-120	-		
Copper, Total	99		-		80-120	-		
Iron, Total	98		-		80-120	-		
Lead, Total	98		-		80-120	-		
Magnesium, Total	91		-		80-120	-		
Manganese, Total	100		-		80-120	-		
Nickel, Total	96		-		80-120	-		
Potassium, Total	100		-		80-120	-		
Selenium, Total	104		-		80-120	-		
Silver, Total	103		-		80-120	-		
Sodium, Total	91		-		80-120	-		
Thallium, Total	107		-		80-120	-		
Vanadium, Total	95		-		80-120	-		

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2316865

Report Date: 04/20/23

Parameter	LCS %Recovery	LCSD %Recovery	%Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-05 Batch: WG1761715-2					
Zinc, Total	94	-	80-120	-	
Total Metals - Mansfield Lab Associated sample(s): 01-05 Batch: WG1761718-2					
Mercury, Total	98	-	80-120	-	

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2316865

Report Date: 04/20/23

Parameter	LCS %Recovery	LCSD %Recovery	%Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 06-07 Batch: WG1762100-2 SRM Lot Number: D116-540					
Aluminum, Total	89	-	45-155	-	
Antimony, Total	203	-	2-205	-	
Arsenic, Total	115	-	82-119	-	
Barium, Total	104	-	82-118	-	
Beryllium, Total	110	-	82-118	-	
Cadmium, Total	108	-	82-118	-	
Calcium, Total	104	-	81-119	-	
Chromium, Total	106	-	81-118	-	
Cobalt, Total	104	-	83-117	-	
Copper, Total	106	-	83-117	-	
Iron, Total	112	-	58-142	-	
Lead, Total	116	-	83-117	-	
Magnesium, Total	97	-	75-125	-	
Manganese, Total	105	-	82-118	-	
Nickel, Total	106	-	82-118	-	
Potassium, Total	96	-	68-131	-	
Selenium, Total	114	-	78-122	-	
Silver, Total	111	-	79-121	-	
Sodium, Total	102	-	71-130	-	
Thallium, Total	113	-	80-120	-	
Vanadium, Total	109	-	78-122	-	

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2316865

Report Date: 04/20/23

Parameter	LCS %Recovery	LCSD %Recovery	%Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 06-07 Batch: WG1762100-2 SRM Lot Number: D116-540					
Zinc, Total	107	-	80-120	-	
Total Metals - Mansfield Lab Associated sample(s): 06-07 Batch: WG1762103-2 SRM Lot Number: D116-540					
Mercury, Total	99	-	58-142	-	

Matrix Spike Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316865
Report Date: 04/20/23

Parameter	Native Sample	MS Added	MS Found	MS %Recovery	Qual	MSD Found	MSD %Recovery	Qual	Recovery Limits	RPD	Qual	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-05 QC Batch ID: WG1761715-3 QC Sample: L2316596-01 Client ID: MS Sample												
Aluminum, Total	0.013	2	2.02	100		-	-		75-125	-		20
Antimony, Total	0.0006J	0.5	0.5736	115		-	-		75-125	-		20
Arsenic, Total	0.00047J	0.12	0.1225	102		-	-		75-125	-		20
Barium, Total	0.2522	2	2.340	104		-	-		75-125	-		20
Beryllium, Total	ND	0.05	0.05219	104		-	-		75-125	-		20
Cadmium, Total	ND	0.053	0.05344	101		-	-		75-125	-		20
Calcium, Total	196	10	222	**260**	Q	-	-		75-125	-		20
Chromium, Total	0.0005J	0.2	0.1896	95		-	-		75-125	-		20
Cobalt, Total	0.0021	0.5	0.4748	94		-	-		75-125	-		20
Copper, Total	0.0012	0.25	0.2399	95		-	-		75-125	-		20
Iron, Total	0.237	1	1.20	96		-	-		75-125	-		20
Lead, Total	ND	0.53	0.5254	99		-	-		75-125	-		20
Magnesium, Total	19.9	10	29.0	91		-	-		75-125	-		20
Manganese, Total	4.420	0.5	4.748	**66**	Q	-	-		75-125	-		20
Nickel, Total	0.0046	0.5	0.4654	92		-	-		75-125	-		20
Potassium, Total	20.0	10	31.3	113		-	-		75-125	-		20
Selenium, Total	ND	0.12	0.115	96		-	-		75-125	-		20
Silver, Total	ND	0.05	0.05048	101		-	-		75-125	-		20
Sodium, Total	83.9	10	86.5	**26**	Q	-	-		75-125	-		20
Thallium, Total	0.0003J	0.12	0.1261	105		-	-		75-125	-		20
Vanadium, Total	ND	0.5	0.4769	95		-	-		75-125	-		20

Matrix Spike Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316865
Report Date: 04/20/23

Parameter	Native Sample	MS Added	MS Found	MS %Recovery	MSD Found	MSD %Recovery	Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-05 QC Batch ID: WG1761715-3 QC Sample: L2316596-01 Client ID: MS Sample									
Zinc, Total	ND	0.5	0.4653	93	-	-	75-125	-	20
Total Metals - Mansfield Lab Associated sample(s): 01-05 QC Batch ID: WG1761718-3 QC Sample: L2316684-01 Client ID: MS Sample									
Mercury, Total	ND	0.005	0.00484	97	-	-	75-125	-	20

Matrix Spike Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316865
Report Date: 04/20/23

Parameter	Native Sample	MS Added	MS Found	MS %Recovery		MSD Found	MSD %Recovery		Recovery Limits	RPD		RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 06-07 QC Batch ID: WG1762100-3 WG1762100-4 QC Sample: L2317033-03 Client ID: MS Sample												
Aluminum, Total	12200	167	11200	**0**	Q	11800	**0**	Q	75-125	5		20
Antimony, Total	ND	41.9	41.6	99		42.4	102		75-125	2		20
Arsenic, Total	2.05	10	12.5	104		13.1	110		75-125	5		20
Barium, Total	126	167	273	88		278	91		75-125	2		20
Beryllium, Total	0.242J	4.19	4.23	101		4.31	103		75-125	2		20
Cadmium, Total	ND	4.44	4.05	91		4.12	93		75-125	2		20
Calcium, Total	5350	837	2010	**0**	Q	2980	**0**	Q	75-125	**39**	Q	20
Chromium, Total	24.8	16.7	37.7	77		38.8	84		75-125	3		20
Cobalt, Total	6.57	41.9	43.4	88		44.3	90		75-125	2		20
Copper, Total	19.3	20.9	38.7	93		39.2	95		75-125	1		20
Iron, Total	22000	83.7	20000	**0**	Q	21100	**0**	Q	75-125	5		20
Lead, Total	9.64	44.4	53.0	98		54.7	102		75-125	3		20
Magnesium, Total	7940	837	6190	**0**	Q	6450	**0**	Q	75-125	4		20
Manganese, Total	160	41.9	180	**48**	Q	190	**72**	Q	75-125	5		20
Nickel, Total	14.7	41.9	49.0	82		50.6	86		75-125	3		20
Potassium, Total	7440	837	7830	**46**	Q	7940	**60**	Q	75-125	1		20
Selenium, Total	0.520J	10	11.1	110		11.6	116		75-125	4		20
Silver, Total	ND	4.19	3.82	91		3.94	94		75-125	3		20
Sodium, Total	184	837	958	92		986	96		75-125	3		20
Thallium, Total	ND	10	8.09	80		8.26	82		75-125	2		20
Vanadium, Total	38.4	41.9	73.9	85		76.3	91		75-125	3		20

Matrix Spike Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316865
Report Date: 04/20/23

Parameter	Native Sample	MS Added	MS Found	MS %Recovery	MSD Found	MSD %Recovery	Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 06-07 QC Batch ID: WG1762100-3 WG1762100-4 QC Sample: L2317033-03 Client ID: MS Sample									
Zinc, Total	53.4	41.9	85.6	77	88.9	85	75-125	4	20
Total Metals - Mansfield Lab Associated sample(s): 06-07 QC Batch ID: WG1762103-3 WG1762103-4 QC Sample: L2317033-03 Client ID: MS Sample									
Mercury, Total	ND	1.39	1.37	98	1.51	96	80-120	10	20

Lab Duplicate Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2316865

Report Date: 04/20/23

Parameter	Native Sample	Duplicate Sample	Units	RPD	Qual	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-05 QC Batch ID: WG1761715-4 QC Sample: L2316596-01 Client ID: DUP Sample						
Arsenic, Total	0.00047J	0.00051	mg/l	NC		20
Total Metals - Mansfield Lab Associated sample(s): 01-05 QC Batch ID: WG1761718-4 QC Sample: L2316684-01 Client ID: DUP Sample						
Mercury, Total	ND	ND	mg/l	NC		20

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Serial Dilution Analysis
Batch Quality Control

Lab Number: L2316865
Report Date: 04/20/23

Parameter	Native Sample	Serial Dilution	Units	% D	Qual	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 06-07 QC Batch ID: WG1762100-6 QC Sample: L2317033-03 Client ID: DUP Sample						
Aluminum, Total	12200	11700	mg/kg	4		20
Barium, Total	126	122	mg/kg	3		20
Calcium, Total	5350	5280	mg/kg	1		20
Chromium, Total	24.8	22.6	mg/kg	9		20
Iron, Total	22000	22400	mg/kg	2		20
Magnesium, Total	7940	7100	mg/kg	11		20
Manganese, Total	160	156	mg/kg	3		20
Potassium, Total	7440	7020	mg/kg	6		20
Vanadium, Total	38.4	34.6	mg/kg	10		20

INORGANICS
&
MISCELLANEOUS

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316865
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-01
Client ID: GW-3
Sample Location: WHITE PLAINS, NY

Sample Depth:
Matrix: Water

Date Collected: 03/30/23 13:00
Date Received: 03/31/23
Field Prep: Not Specified

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Cyanide, Total	0.009		mg/l	0.005	0.001	1	04/06/23 11:40	04/06/23 15:54	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316865
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-02
Client ID: GW-4
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 13:30
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Cyanide, Total	0.002	J	mg/l	0.005	0.001	1	04/06/23 11:40	04/06/23 15:55	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316865
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-03
Client ID: GW-5
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 10:30
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Cyanide, Total	0.002	J	mg/l	0.005	0.001	1	04/07/23 05:10	04/07/23 12:00	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316865
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-04
Client ID: GW-6
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 11:00
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Cyanide, Total	0.005		mg/l	0.005	0.001	1	04/07/23 05:10	04/07/23 12:05	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316865
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-05
Client ID: GW-7
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 11:30
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Cyanide, Total	0.003	J	mg/l	0.005	0.001	1	04/06/23 11:40	04/06/23 15:56	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316865
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-06
Client ID: SB-37
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 11:40
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Solids, Total	91.6		%	0.100	NA	1	-	04/01/23 13:19	121,2540G	ROI
Cyanide, Total	ND		mg/kg	1.0	0.22	1	04/07/23 05:10	04/07/23 12:33	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316865
Report Date: 04/20/23

SAMPLE RESULTS

Lab ID: L2316865-07
Client ID: SB-38
Sample Location: WHITE PLAINS, NY

Date Collected: 03/30/23 11:15
Date Received: 03/31/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Solids, Total	90.3		%	0.100	NA	1	-	04/01/23 13:19	121,2540G	ROI
Cyanide, Total	ND		mg/kg	1.0	0.22	1	04/07/23 05:10	04/07/23 12:34	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

Method Blank Analysis
Batch Quality Control

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab for sample(s): 03-04 Batch: WG1763265-1										
Cyanide, Total	ND		mg/l	0.005	0.001	1	04/07/23 05:10	04/07/23 11:54	1,9010C/9012B	JER
General Chemistry - Westborough Lab for sample(s): 01-02,05 Batch: WG1763463-1										
Cyanide, Total	0.001	J	mg/l	0.005	0.001	1	04/06/23 11:40	04/06/23 15:50	1,9010C/9012B	JER
General Chemistry - Westborough Lab for sample(s): 06-07 Batch: WG1763780-1										
Cyanide, Total	ND		mg/kg	0.88	0.19	1	04/07/23 05:10	04/07/23 12:13	1,9010C/9012B	JER

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2316865

Report Date: 04/20/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
General Chemistry - Westborough Lab Associated sample(s): 03-04 Batch: WG1763265-2 WG1763265-3								
Cyanide, Total	106		112		85-115	6		20
General Chemistry - Westborough Lab Associated sample(s): 01-02,05 Batch: WG1763463-2 WG1763463-3								
Cyanide, Total	95		103		85-115	8		20
General Chemistry - Westborough Lab Associated sample(s): 06-07 Batch: WG1763780-2 WG1763780-3								
Cyanide, Total	90		90		80-120	0		35

Matrix Spike Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2316865
Report Date: 04/20/23

Parameter	Native Sample	MS Added	MS Found	MS %Recovery	Qual	MSD Found	MSD %Recovery	Qual	Recovery Limits	RPD	Qual	RPD Limits
General Chemistry - Westborough Lab Associated sample(s): 03-04 QC Batch ID: WG1763265-4 WG1763265-5 QC Sample: L2316865-03 Client ID: GW-5												
Cyanide, Total	0.002J	0.2	0.219	110		0.222	111		80-120	1		20
General Chemistry - Westborough Lab Associated sample(s): 01-02,05 QC Batch ID: WG1763463-4 WG1763463-5 QC Sample: L2316865-05 Client ID: GW-7												
Cyanide, Total	0.003J	0.2	0.192	96		0.130	**65**	Q	80-120	**39**	Q	20
General Chemistry - Westborough Lab Associated sample(s): 06-07 QC Batch ID: WG1763780-4 WG1763780-5 QC Sample: L2316864-06 Client ID: MS Sample												
Cyanide, Total	ND	11	11	100		12	110		75-125	10		35

Lab Duplicate Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2316865

Report Date: 04/20/23

Parameter	Native Sample	Duplicate Sample	Units	RPD	Qual	RPD Limits
General Chemistry - Westborough Lab Associated sample(s): 06-07 QC Batch ID: WG1761547-1 QC Sample: L2316889-02 Client ID: DUP Sample						
Solids, Total	70.2	72.6	%	3		20

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316865
Report Date: 04/20/23

Sample Receipt and Container Information

Were project specific reporting limits specified? YES

Cooler Information

Cooler	Custody Seal
A	Absent
B	Absent

Container Information

Container ID	Container Type	Cooler	Initial pH	Final pH	Temp deg C	Pres	Seal	Frozen Date/Time	Analysis(*)
L2316865-01A	Vial HCl preserved	A	NA		3.1	Y	Absent		NYTCL-8260(14)
L2316865-01B	Vial HCl preserved	A	NA		3.1	Y	Absent		NYTCL-8260(14)
L2316865-01C	Vial HCl preserved	A	NA		3.1	Y	Absent		NYTCL-8260(14)
L2316865-01D	Plastic 250ml HNO3 preserved	A	<2	<2	3.1	Y	Absent		TL-6020T(180),BA-6020T(180),FE-6020T(180),SE-6020T(180),K-6020T(180),CR-6020T(180),NI-6020T(180),CA-6020T(180),CU-6020T(180),NA-6020T(180),ZN-6020T(180),PB-6020T(180),MN-6020T(180),BE-6020T(180),SB-6020T(180),V-6020T(180),AS-6020T(180),MG-6020T(180),HG-T(28),CD-6020T(180),AG-6020T(180),AL-6020T(180),CO-6020T(180)
L2316865-01E	Plastic 250ml NaOH preserved	A	>12	>12	3.1	Y	Absent		TCN-9010(14)
L2316865-01F	Amber 120ml unpreserved	A	7	7	3.1	Y	Absent		NYTCL-8082-LVI(365)
L2316865-01G	Amber 120ml unpreserved	A	7	7	3.1	Y	Absent		NYTCL-8082-LVI(365)
L2316865-01H	Amber 120ml unpreserved	A	7	7	3.1	Y	Absent		NYTCL-8081(7)
L2316865-01I	Amber 120ml unpreserved	A	7	7	3.1	Y	Absent		NYTCL-8081(7)
L2316865-01J	Amber 250ml unpreserved	A	7	7	3.1	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)
L2316865-01K	Amber 250ml unpreserved	A	7	7	3.1	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)
L2316865-01L	Amber 250ml unpreserved	A	7	7	3.1	Y	Absent		A2-1,4-DIOXANE-SIM(7)
L2316865-01M	Amber 250ml unpreserved	A	7	7	3.1	Y	Absent		A2-1,4-DIOXANE-SIM(7)
L2316865-01N	Plastic 500ml unpreserved	A	NA		3.1	Y	Absent		A2-NY-1633-DRAFT-21(28)
L2316865-01O	Plastic 500ml unpreserved	A	NA		3.1	Y	Absent		A2-NY-1633-DRAFT-21(28)
L2316865-01P	Plastic 500ml unpreserved	A	NA		3.1	Y	Absent		A2-NY-1633-DRAFT-21(28)
L2316865-02A	Vial HCl preserved	A	NA		3.1	Y	Absent		NYTCL-8260(14)
L2316865-02B	Vial HCl preserved	A	NA		3.1	Y	Absent		NYTCL-8260(14)

*Values in parentheses indicate holding time in days

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316865
Report Date: 04/20/23

Container Information

Container ID	Container Type	Cooler	Initial pH	Final pH	Temp deg C	Pres	Seal	Frozen Date/Time	Analysis(*)
L2316865-02C	Vial HCl preserved	A	NA		3.1	Y	Absent		NYTCL-8260(14)
L2316865-02D	Plastic 250ml HNO3 preserved	A	<2	<2	3.1	Y	Absent		BA-6020T(180),TL-6020T(180),FE-6020T(180),SE-6020T(180),CA-6020T(180),K-6020T(180),CR-6020T(180),NI-6020T(180),NA-6020T(180),CU-6020T(180),ZN-6020T(180),PB-6020T(180),BE-6020T(180),MN-6020T(180),V-6020T(180),AS-6020T(180),SB-6020T(180),AG-6020T(180),HG-T(28),AL-6020T(180),MG-6020T(180),CD-6020T(180),CO-6020T(180)
L2316865-02E	Plastic 250ml NaOH preserved split	A	7	>12	3.1	N	Absent		TCN-9010(14)
L2316865-02F	Amber 120ml unpreserved	A	7	7	3.1	Y	Absent		NYTCL-8082-LVI(365)
L2316865-02G	Amber 120ml unpreserved	A	7	7	3.1	Y	Absent		NYTCL-8082-LVI(365)
L2316865-02H	Amber 120ml unpreserved	A	7	7	3.1	Y	Absent		NYTCL-8081(7)
L2316865-02I	Amber 120ml unpreserved	A	7	7	3.1	Y	Absent		NYTCL-8081(7)
L2316865-02J	Amber 250ml unpreserved	A	7	7	3.1	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)
L2316865-02K	Amber 250ml unpreserved	A	7	7	3.1	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)
L2316865-02L	Amber 250ml unpreserved	A	7	7	3.1	Y	Absent		A2-1,4-DIOXANE-SIM(7)
L2316865-02M	Plastic 500ml unpreserved	A	NA		3.1	Y	Absent		A2-NY-1633-DRAFT-21(28)
L2316865-02N	Plastic 500ml unpreserved	A	NA		3.1	Y	Absent		A2-NY-1633-DRAFT-21(28)
L2316865-02O	Plastic 500ml unpreserved	A	NA		3.1	Y	Absent		A2-NY-1633-DRAFT-21(28)
L2316865-03A	Vial HCl preserved	A	NA		3.1	Y	Absent		NYTCL-8260(14)
L2316865-03B	Vial HCl preserved	A	NA		3.1	Y	Absent		NYTCL-8260(14)
L2316865-03C	Vial HCl preserved	A	NA		3.1	Y	Absent		NYTCL-8260(14)
L2316865-03D	Plastic 250ml HNO3 preserved	A	<2	<2	3.1	Y	Absent		FE-6020T(180),SE-6020T(180),TL-6020T(180),BA-6020T(180),CA-6020T(180),NI-6020T(180),K-6020T(180),CR-6020T(180),CU-6020T(180),ZN-6020T(180),NA-6020T(180),PB-6020T(180),BE-6020T(180),MN-6020T(180),AS-6020T(180),SB-6020T(180),V-6020T(180),HG-T(28),AL-6020T(180),AG-6020T(180),MG-6020T(180),CD-6020T(180),CO-6020T(180)
L2316865-03E	Plastic 250ml NaOH preserved	A	>12	>12	3.1	Y	Absent		TCN-9010(14)
L2316865-03F	Amber 120ml unpreserved	A	7	7	3.1	Y	Absent		NYTCL-8082-LVI(365)
L2316865-03G	Amber 120ml unpreserved	A	7	7	3.1	Y	Absent		NYTCL-8082-LVI(365)
L2316865-03H	Amber 120ml unpreserved	A	7	7	3.1	Y	Absent		NYTCL-8081(7)

*Values in parentheses indicate holding time in days

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316865
Report Date: 04/20/23

Container Information

Container ID	Container Type	Cooler	Initial pH	Final pH	Temp deg C	Pres	Seal	Frozen Date/Time	Analysis(*)
L2316865-03I	Amber 120ml unpreserved	A	7	7	3.1	Y	Absent		NYTCL-8081(7)
L2316865-03J	Amber 250ml unpreserved	A	7	7	3.1	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)
L2316865-03K	Amber 250ml unpreserved	A	7	7	3.1	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)
L2316865-03L	Amber 250ml unpreserved	A	7	7	3.1	Y	Absent		A2-1,4-DIOXANE-SIM(7)
L2316865-03M	Amber 250ml unpreserved	A	7	7	3.1	Y	Absent		A2-1,4-DIOXANE-SIM(7)
L2316865-03N	Plastic 500ml unpreserved	A	NA		3.1	Y	Absent		A2-NY-1633-DRAFT-21(28)
L2316865-03O	Plastic 500ml unpreserved	A	NA		3.1	Y	Absent		A2-NY-1633-DRAFT-21(28)
L2316865-03P	Plastic 500ml unpreserved	A	NA		3.1	Y	Absent		A2-NY-1633-DRAFT-21(28)
L2316865-04A	Vial HCl preserved	B	NA		3.0	Y	Absent		NYTCL-8260(14)
L2316865-04B	Vial HCl preserved	B	NA		3.0	Y	Absent		NYTCL-8260(14)
L2316865-04C	Vial HCl preserved	B	NA		3.0	Y	Absent		NYTCL-8260(14)
L2316865-04D	Plastic 250ml HNO3 preserved	B	<2	<2	3.0	Y	Absent		BA-6020T(180),SE-6020T(180),FE-6020T(180),TL-6020T(180),K-6020T(180),CR-6020T(180),CA-6020T(180),NI-6020T(180),CU-6020T(180),ZN-6020T(180),NA-6020T(180),PB-6020T(180),MN-6020T(180),BE-6020T(180),V-6020T(180),AS-6020T(180),SB-6020T(180),AG-6020T(180),AL-6020T(180),CD-6020T(180),MG-6020T(180),HG-T(28),CO-6020T(180)
L2316865-04E	Plastic 250ml NaOH preserved	B	>12	>12	3.0	Y	Absent		TCN-9010(14)
L2316865-04F	Amber 120ml unpreserved	B	7	7	3.0	Y	Absent		NYTCL-8082-LVI(365)
L2316865-04G	Amber 120ml unpreserved	B	7	7	3.0	Y	Absent		NYTCL-8082-LVI(365)
L2316865-04H	Amber 120ml unpreserved	B	7	7	3.0	Y	Absent		NYTCL-8081(7)
L2316865-04I	Amber 120ml unpreserved	B	7	7	3.0	Y	Absent		NYTCL-8081(7)
L2316865-04J	Amber 250ml unpreserved	B	7	7	3.0	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)
L2316865-04K	Amber 250ml unpreserved	B	7	7	3.0	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)
L2316865-04L	Amber 250ml unpreserved	B	7	7	3.0	Y	Absent		A2-1,4-DIOXANE-SIM(7)
L2316865-04M	Amber 250ml unpreserved	B	7	7	3.0	Y	Absent		A2-1,4-DIOXANE-SIM(7)
L2316865-04N	Plastic 500ml unpreserved	B	NA		3.0	Y	Absent		A2-NY-1633-DRAFT-21(28)
L2316865-04O	Plastic 500ml unpreserved	B	NA		3.0	Y	Absent		A2-NY-1633-DRAFT-21(28)
L2316865-04P	Plastic 500ml unpreserved	B	NA		3.0	Y	Absent		A2-NY-1633-DRAFT-21(28)

*Values in parentheses indicate holding time in days

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316865
Report Date: 04/20/23

Container Information

Container ID	Container Type	Cooler	Initial pH	Final pH	Temp deg C	Pres	Seal	Frozen Date/Time	Analysis(*)
L2316865-05A	Vial HCl preserved	B	NA		3.0	Y	Absent		NYTCL-8260(14)
L2316865-05B	Vial HCl preserved	B	NA		3.0	Y	Absent		NYTCL-8260(14)
L2316865-05C	Vial HCl preserved	B	NA		3.0	Y	Absent		NYTCL-8260(14)
L2316865-05D	Plastic 250ml HNO3 preserved	B	<2	<2	3.0	Y	Absent		TL-6020T(180),BA-6020T(180),FE-6020T(180),SE-6020T(180),CA-6020T(180),NI-6020T(180),K-6020T(180),CR-6020T(180),ZN-6020T(180),CU-6020T(180),NA-6020T(180),PB-6020T(180),MN-6020T(180),BE-6020T(180),AS-6020T(180),SB-6020T(180),V-6020T(180),AG-6020T(180),CD-6020T(180),HG-T(28),AL-6020T(180),MG-6020T(180),CO-6020T(180)
L2316865-05E	Plastic 250ml NaOH preserved	B	>12	>12	3.0	Y	Absent		TCN-9010(14)
L2316865-05F	Amber 120ml unpreserved	B	7	7	3.0	Y	Absent		NYTCL-8082-LVI(365)
L2316865-05G	Amber 120ml unpreserved	B	7	7	3.0	Y	Absent		NYTCL-8082-LVI(365)
L2316865-05H	Amber 120ml unpreserved	B	7	7	3.0	Y	Absent		NYTCL-8081(7)
L2316865-05I	Amber 120ml unpreserved	B	7	7	3.0	Y	Absent		NYTCL-8081(7)
L2316865-05J	Amber 250ml unpreserved	B	7	7	3.0	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)
L2316865-05K	Amber 250ml unpreserved	B	7	7	3.0	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)
L2316865-05L	Amber 250ml unpreserved	B	7	7	3.0	Y	Absent		A2-1,4-DIOXANE-SIM(7)
L2316865-05M	Amber 250ml unpreserved	B	7	7	3.0	Y	Absent		A2-1,4-DIOXANE-SIM(7)
L2316865-05N	Plastic 500ml unpreserved	B	NA		3.0	Y	Absent		A2-NY-1633-DRAFT-21(28)
L2316865-05O	Plastic 500ml unpreserved	B	NA		3.0	Y	Absent		A2-NY-1633-DRAFT-21(28)
L2316865-05P	Plastic 500ml unpreserved	B	NA		3.0	Y	Absent		A2-NY-1633-DRAFT-21(28)
L2316865-06A	5 gram Encore Sampler	B	NA		3.0	Y	Absent		NYTCL-8260HLW(14)
L2316865-06B	5 gram Encore Sampler	B	NA		3.0	Y	Absent		NYTCL-8260HLW(14)
L2316865-06C	5 gram Encore Sampler	B	NA		3.0	Y	Absent		NYTCL-8260HLW(14)
L2316865-06D	Plastic 2oz unpreserved for TS	B	NA		3.0	Y	Absent		TS(7)
L2316865-06E	Glass 60mL/2oz unpreserved	B	NA		3.0	Y	Absent		BE-TI(180),BA-TI(180),AS-TI(180),AG-TI(180),CR-TI(180),NI-TI(180),AL-TI(180),TL-TI(180),SB-TI(180),ZN-TI(180),SE-TI(180),PB-TI(180),CU-TI(180),V-TI(180),CO-TI(180),MN-TI(180),HG-T(28),FE-TI(180),MG-TI(180),NA-TI(180),CA-TI(180),CD-TI(180),K-TI(180)

*Values in parentheses indicate holding time in days

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316865
Report Date: 04/20/23

Container Information

Container ID	Container Type	Cooler	Initial pH	Final pH	Temp deg C	Pres	Seal	Frozen Date/Time	Analysis(*)
L2316865-06F	Glass 250ml/8oz unpreserved	B	NA		3.0	Y	Absent		TCN-9010(14),NYTCL-8270(14),NYTCL-8081(14),NYTCL-8082(365)
L2316865-06X	Vial MeOH preserved split	B	NA		3.0	Y	Absent		NYTCL-8260HLW(14)
L2316865-06Y	Vial Water preserved split	B	NA		3.0	Y	Absent	01-APR-23 09:17	NYTCL-8260HLW(14)
L2316865-06Z	Vial Water preserved split	B	NA		3.0	Y	Absent	01-APR-23 09:17	NYTCL-8260HLW(14)
L2316865-07A	5 gram Encore Sampler	B	NA		3.0	Y	Absent		NYTCL-8260HLW(14)
L2316865-07B	5 gram Encore Sampler	B	NA		3.0	Y	Absent		NYTCL-8260HLW(14)
L2316865-07C	5 gram Encore Sampler	B	NA		3.0	Y	Absent		NYTCL-8260HLW(14)
L2316865-07D	Plastic 2oz unpreserved for TS	B	NA		3.0	Y	Absent		TS(7)
L2316865-07E	Glass 60mL/2oz unpreserved	B	NA		3.0	Y	Absent		BE-TI(180),AS-TI(180),BA-TI(180),AG-TI(180),AL-TI(180),CR-TI(180),NI-TI(180),TL-TI(180),PB-TI(180),SB-TI(180),CU-TI(180),SE-TI(180),ZN-TI(180),CO-TI(180),V-TI(180),FE-TI(180),MG-TI(180),HG-T(28),MN-TI(180),NA-TI(180),CD-TI(180),K-TI(180),CA-TI(180)
L2316865-07F	Glass 250ml/8oz unpreserved	B	NA		3.0	Y	Absent		TCN-9010(14),NYTCL-8270(14),NYTCL-8081(14),NYTCL-8082(365)
L2316865-07X	Vial MeOH preserved split	B	NA		3.0	Y	Absent		NYTCL-8260HLW(14)
L2316865-07Y	Vial Water preserved split	B	NA		3.0	Y	Absent	01-APR-23 09:17	NYTCL-8260HLW(14)
L2316865-07Z	Vial Water preserved split	B	NA		3.0	Y	Absent	01-APR-23 09:17	NYTCL-8260HLW(14)

*Values in parentheses indicate holding time in days

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316865
Report Date: 04/20/23

PFAS PARAMETER SUMMARY

Parameter	Acronym	CAS Number
PERFLUOROALKYL CARBOXYLIC ACIDS (PFCAs)		
Perfluorooctadecanoic Acid	PFODA	16517-11-6
Perfluorohexadecanoic Acid	PFHxDA	67905-19-5
Perfluorotetradecanoic Acid	PFTA/PFTeDA	376-06-7
Perfluorotridecanoic Acid	PFTrDA	72629-94-8
Perfluorododecanoic Acid	PFDoA	307-55-1
Perfluoroundecanoic Acid	PFUnA	2058-94-8
Perfluorodecanoic Acid	PFDA	335-76-2
Perfluorononanoic Acid	PFNA	375-95-1
Perfluorooctanoic Acid	PFOA	335-67-1
Perfluoroheptanoic Acid	PFHpA	375-85-9
Perfluorohexanoic Acid	PFHxA	307-24-4
Perfluoropentanoic Acid	PFPeA	2706-90-3
Perfluorobutanoic Acid	PFBA	375-22-4
PERFLUOROALKYL SULFONIC ACIDS (PFSAs)		
Perfluorododecanesulfonic Acid	PFDoDS/PFDoS	79780-39-5
Perfluorodecanesulfonic Acid	PFDS	335-77-3
Perfluorononanesulfonic Acid	PFNS	68259-12-1
Perfluorooctanesulfonic Acid	PFOS	1763-23-1
Perfluoroheptanesulfonic Acid	PFHpS	375-92-8
Perfluorohexanesulfonic Acid	PFHxS	355-46-4
Perfluoropentanesulfonic Acid	PFPeS	2706-91-4
Perfluorobutanesulfonic Acid	PFBS	375-73-5
Perfluoropropanesulfonic Acid	PFPrS	423-41-6
FLUOROTELOMERS		
1H,1H,2H,2H-Perfluorododecanesulfonic Acid	10:2FTS	120226-60-0
1H,1H,2H,2H-Perfluorodecanesulfonic Acid	8:2FTS	39108-34-4
1H,1H,2H,2H-Perfluorooctanesulfonic Acid	6:2FTS	27619-97-2
1H,1H,2H,2H-Perfluorohexanesulfonic Acid	4:2FTS	757124-72-4
PERFLUOROALKANE SULFONAMIDES (FASAs)		
Perfluorooctanesulfonamide	FOSA/PFOSA	754-91-6
N-Ethyl Perfluorooctane Sulfonamide	NEtFOSA	4151-50-2
N-Methyl Perfluorooctane Sulfonamide	NMeFOSA	31506-32-8
PERFLUOROALKANE SULFONYL SUBSTANCES		
N-Ethyl Perfluorooctanesulfonamido Ethanol	NEtFOSE	1691-99-2
N-Methyl Perfluorooctanesulfonamido Ethanol	NMeFOSE	24448-09-7
N-Ethyl Perfluorooctanesulfonamidoacetic Acid	NEtFOSAA	2991-50-6
N-Methyl Perfluorooctanesulfonamidoacetic Acid	NMeFOSAA	2355-31-9
PER- and POLYFLUOROALKYL ETHER CARBOXYLIC ACIDS		
2,3,3,3-Tetrafluoro-2-[1,1,2,2,3,3,3-Heptafluoropropoxy]-Propanoic Acid	HFPO-DA	13252-13-6
4,8-Dioxa-3h-Perfluorononanoic Acid	ADONA	919005-14-4
CHLORO-PERFLUOROALKYL SULFONIC ACIDS		
11-Chloroeicosafluoro-3-Oxaundecane-1-Sulfonic Acid	11Cl-PF3OUdS	763051-92-9
9-Chlorohexadecafluoro-3-Oxanone-1-Sulfonic Acid	9Cl-PF3ONS	756426-58-1
PERFLUOROETHER SULFONIC ACIDS (PFESAs)		
Perfluoro(2-Ethoxyethane)Sulfonic Acid	PFEESA	113507-82-7
PERFLUOROETHER/POLYETHER CARBOXYLIC ACIDS (PFPCAs)		
Perfluoro-3-Methoxypropanoic Acid	PFMPA	377-73-1
Perfluoro-4-Methoxybutanoic Acid	PFMBA	863090-89-5
Nonafluoro-3,6-Dioxaheptanoic Acid	NFDHA	151772-58-6

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2316865
Report Date: 04/20/23

PFAS PARAMETER SUMMARY

Parameter	Acronym	CAS Number
FLUOROTELOMER CARBOXYLIC ACIDS (FTCAs)		
3-Perfluoroheptyl Propanoic Acid	7:3FTCA	812-70-4
2H,2H,3H,3H-Perfluorooctanoic Acid	5:3FTCA	914637-49-3
3-Perfluoropropyl Propanoic Acid	3:3FTCA	356-02-5

Project Name:	100 MAIN ST.	**Lab Number:**	L2316865
Project Number:	12461	**Report Date:**	04/20/23

GLOSSARY

Acronyms

DL	- Detection Limit: This value represents the level to which target analyte concentrations are reported as estimated values, when those target analyte concentrations are quantified below the limit of quantitation (LOQ). The DL includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.)
EDL	- Estimated Detection Limit: This value represents the level to which target analyte concentrations are reported as estimated values, when those target analyte concentrations are quantified below the reporting limit (RL). The EDL includes any adjustments from dilutions, concentrations or moisture content, where applicable. The use of EDLs is specific to the analysis of PAHs using Solid-Phase Microextraction (SPME).
EMPC	- Estimated Maximum Possible Concentration: The concentration that results from the signal present at the retention time of an analyte when the ions meet all of the identification criteria except the ion abundance ratio criteria. An EMPC is a worst-case estimate of the concentration.
EPA	- Environmental Protection Agency.
LCS	- Laboratory Control Sample: A sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes or a material containing known and verified amounts of analytes.
LCSD	- Laboratory Control Sample Duplicate: Refer to LCS.
LFB	- Laboratory Fortified Blank: A sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes or a material containing known and verified amounts of analytes.
LOD	- Limit of Detection: This value represents the level to which a target analyte can reliably be detected for a specific analyte in a specific matrix by a specific method. The LOD includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.)
LOQ	- Limit of Quantitation: The value at which an instrument can accurately measure an analyte at a specific concentration. The LOQ includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.) Limit of Quantitation: The value at which an instrument can accurately measure an analyte at a specific concentration. The LOQ includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.)
MDL	- Method Detection Limit: This value represents the level to which target analyte concentrations are reported as estimated values, when those target analyte concentrations are quantified below the reporting limit (RL). The MDL includes any adjustments from dilutions, concentrations or moisture content, where applicable.
MS	- Matrix Spike Sample: A sample prepared by adding a known mass of target analyte to a specified amount of matrix sample for which an independent estimate of target analyte concentration is available. For Method 332.0, the spike recovery is calculated using the native concentration, including estimated values.
MSD	- Matrix Spike Sample Duplicate: Refer to MS.
NA	- Not Applicable.
NC	- Not Calculated: Term is utilized when one or more of the results utilized in the calculation are non-detect at the parameter's reporting unit.
NDPA/DPA	- N-Nitrosodiphenylamine/Diphenylamine.
NI	- Not Ignitable.
NP	- Non-Plastic: Term is utilized for the analysis of Atterberg Limits in soil.
NR	- No Results: Term is utilized when 'No Target Compounds Requested' is reported for the analysis of Volatile or Semivolatile Organic TIC only requests.
RL	- Reporting Limit: The value at which an instrument can accurately measure an analyte at a specific concentration. The RL includes any adjustments from dilutions, concentrations or moisture content, where applicable.
RPD	- Relative Percent Difference: The results from matrix and/or matrix spike duplicates are primarily designed to assess the precision of analytical results in a given matrix and are expressed as relative percent difference (RPD). Values which are less than five times the reporting limit for any individual parameter are evaluated by utilizing the absolute difference between the values; although the RPD value will be provided in the report.
SRM	- Standard Reference Material: A reference sample of a known or certified value that is of the same or similar matrix as the associated field samples.
STLP	- Semi-dynamic Tank Leaching Procedure per EPA Method 1315.
TEF	- Toxic Equivalency Factors: The values assigned to each dioxin and furan to evaluate their toxicity relative to 2,3,7,8-TCDD.
TEQ	- Toxic Equivalent: The measure of a sample's toxicity derived by multiplying each dioxin and furan by its corresponding TEF and then summing the resulting values.
TIC	- Tentatively Identified Compound: A compound that has been identified to be present and is not part of the target compound list (TCL) for the method and/or program. All TICs are qualitatively identified and reported as estimated concentrations.

Report Format: DU Report with 'J' Qualifiers

Project Name:	100 MAIN ST.	**Lab Number:**	L2316865
Project Number:	12461	**Report Date:**	04/20/23

Footnotes

1 - The reference for this analyte should be considered modified since this analyte is absent from the target analyte list of the original method.

Terms

Analytical Method: Both the document from which the method originates and the analytical reference method. (Example: EPA 8260B is shown as 1,8260B.) The codes for the reference method documents are provided in the References section of the Addendum.

Chlordane: The target compound Chlordane (CAS No. 57-74-9) is reported for GC ECD analyses. Per EPA,this compound "refers to a mixture of chlordane isomers, other chlorinated hydrocarbons and numerous other components." (Reference: USEPA Toxicological Review of Chlordane, In Support of Summary Information on the Integrated Risk Information System (IRIS), December 1997.)

Difference: With respect to Total Oxidizable Precursor (TOP) Assay analysis, the difference is defined as the Post-Treatment value minus the Pre-Treatment value.

Final pH: As it pertains to Sample Receipt & Container Information section of the report, Final pH reflects pH of container determined after adjustment at the laboratory, if applicable. If no adjustment required, value reflects Initial pH.

Frozen Date/Time: With respect to Volatile Organics in soil, Frozen Date/Time reflects the date/time at which associated Reagent Water-preserved vials were initially frozen. Note: If frozen date/time is beyond 48 hours from sample collection, value will be reflected in 'bold'.

Gasoline Range Organics (GRO): Gasoline Range Organics (GRO) results include all chromatographic peaks eluting from Methyl tert butyl ether through Naphthalene, with the exception of GRO analysis in support of State of Ohio programs, which includes all chromatographic peaks eluting from Hexane through Dodecane.

Initial pH: As it pertains to Sample Receipt & Container Information section of the report, Initial pH reflects pH of container determined upon receipt, if applicable.

PAH Total: With respect to Alkylated PAH analyses, the 'PAHs, Total' result is defined as the summation of results for all or a subset of the following compounds: Naphthalene, C1-C4 Naphthalenes, 2-Methylnaphthalene, 1-Methylnaphthalene, Biphenyl, Acenaphthylene, Acenaphthene, Fluorene, C1-C3 Fluorenes, Phenanthrene, C1-C4 Phenanthrenes/Anthracenes, Anthracene, Fluoranthene, Pyrene, C1-C4 Fluoranthenes/Pyrenes, Benz(a)anthracene, Chrysene, C1-C4 Chrysenes, Benzo(b)fluoranthene, Benzo(j)+(k)fluoranthene, Benzo(e)pyrene, Benzo(a)pyrene, Perylene, Indeno(1,2,3-cd)pyrene, Dibenz(ah)+(ac)anthracene, Benzo(g,h,i)perylene. If a 'Total' result is requested, the results of its individual components will also be reported.

PFAS Total: With respect to PFAS analyses, the 'PFAS, Total (5)' result is defined as the summation of results for: PFHpA, PFHxS, PFOA, PFNA and PFOS. In addition, the 'PFAS, Total (6)' result is defined as the summation of results for: PFHpA, PFHxS, PFOA, PFNA, PFDA and PFOS. For MassDEP DW compliance analysis only, the 'PFAS, Total (6)' result is defined as the summation of results at or above the RL. Note: If a 'Total' result is requested, the results of its individual components will also be reported.

Total: With respect to Organic analyses, a 'Total' result is defined as the summation of results for individual isomers or Aroclors. If a 'Total' result is requested, the results of its individual components will also be reported. This is applicable to 'Total' results for methods 8260, 8081 and 8082.

Data Qualifiers

A - Spectra identified as "Aldol Condensates" are byproducts of the extraction/concentration procedures when acetone is introduced in the process.

B - The analyte was detected above the reporting limit in the associated method blank. Flag only applies to associated field samples that have detectable concentrations of the analyte at less than ten times (10x) the concentration found in the blank. For MCP-related projects, flag only applies to associated field samples that have detectable concentrations of the analyte at less than ten times (10x) the concentration found in the blank. For DOD-related projects, flag only applies to associated field samples that have detectable concentrations of the analyte at less than ten times (10x) the concentration found in the blank AND the analyte was detected above one-half the reporting limit (or above the reporting limit for common lab contaminants) in the associated method blank. For NJ-Air-related projects, flag only applies to associated field samples that have detectable concentrations of the analyte above the reporting limit. For NJ-related projects (excluding Air), flag only applies to associated field samples that have detectable concentrations of the analyte, which was detected above the reporting limit in the associated method blank or above five times the reporting limit for common lab contaminants (Phthalates, Acetone, Methylene Chloride, 2-Butanone).

C - Co-elution: The target analyte co-elutes with a known lab standard (i.e. surrogate, internal standards, etc.) for co-extracted analyses.

D - Concentration of analyte was quantified from diluted analysis. Flag only applies to field samples that have detectable concentrations of the analyte.

E - Concentration of analyte exceeds the range of the calibration curve and/or linear range of the instrument.

F - The ratio of quantifier ion response to qualifier ion response falls outside of the laboratory criteria. Results are considered to be an estimated maximum concentration.

G - The concentration may be biased high due to matrix interferences (i.e, co-elution) with non-target compound(s). The result should be considered estimated.

H - The analysis of pH was performed beyond the regulatory-required holding time of 15 minutes from the time of sample collection.

I - The lower value for the two columns has been reported due to obvious interference.

J - Estimated value. The Target analyte concentration is below the quantitation limit (RL), but above the Method Detection Limit (MDL) or Estimated Detection Limit (EDL) for SPME-related analyses. This represents an estimated concentration for Tentatively

Report Format: DU Report with 'J' Qualifiers

Project Name:	100 MAIN ST.	**Lab Number:**	L2316865
Project Number:	12461	**Report Date:**	04/20/23

Data Qualifiers

Identified Compounds (TICs).

M - Reporting Limit (RL) exceeds the MCP CAM Reporting Limit for this analyte.

ND - Not detected at the method detection limit (MDL) for the sample, or estimated detection limit (EDL) for SPME-related analyses.

NJ - Presumptive evidence of compound. This represents an estimated concentration for Tentatively Identified Compounds (TICs), where the identification is based on a mass spectral library search.

P - The RPD between the results for the two columns exceeds the method-specified criteria.

Q - The quality control sample exceeds the associated acceptance criteria. For DOD-related projects, LCS and/or Continuing Calibration Standard exceedences are also qualified on all associated sample results. Note: This flag is not applicable for matrix spike recoveries when the sample concentration is greater than 4x the spike added or for batch duplicate RPD when the sample concentrations are less than 5x the RL. (Metals only.)

R - Analytical results are from sample re-analysis.

RE - Analytical results are from sample re-extraction.

S - Analytical results are from modified screening analysis.

V - The surrogate associated with this target analyte has a recovery outside the QC acceptance limits. (Applicable to MassDEP DW Compliance samples only.)

Z - The batch matrix spike and/or duplicate associated with this target analyte has a recovery/RPD outside the QC acceptance limits. (Applicable to MassDEP DW Compliance samples only.)

Report Format: DU Report with 'J' Qualifiers

Project Name:	100 MAIN ST.	**Lab Number:**	L2316865
Project Number:	12461	**Report Date:**	04/20/23

REFERENCES

1 Test Methods for Evaluating Solid Waste: Physical/Chemical Methods. EPA SW-846. Third Edition. Updates I - VI, 2018.

121 Standard Methods for the Examination of Water and Wastewater. APHA-AWWA-WEF. Standard Methods Online.

144 Analysis of Per- and Polyfluoroalkyl Substances (PFAS) in Aqueous, Solid, Biosolids, and Tissue Samples by LC-MS/MS. Draft EPA Method 1633, EPA Document 821-D-22-001, June 2022.

LIMITATION OF LIABILITIES

Alpha Analytical performs services with reasonable care and diligence normal to the analytical testing laboratory industry. In the event of an error, the sole and exclusive responsibility of Alpha Analytical shall be to re-perform the work at it's own expense. In no event shall Alpha Analytical be held liable for any incidental, consequential or special damages, including but not limited to, damages in any way connected with the use of, interpretation of, information or analysis provided by Alpha Analytical.

We strongly urge our clients to comply with EPA protocol regarding sample volume, preservation, cooling, containers, sampling procedures, holding time and splitting of samples in the field.

Certification Information

The following analytes are not included in our Primary NELAP Scope of Accreditation:

Westborough Facility
EPA 624/624.1: m/p-xylene, o-xylene, Naphthalene
EPA 625/625.1: alpha-Terpineol
EPA 8260C/8260D: NPW: 1,2,4,5-Tetramethylbenzene; 4-Ethyltoluene, Azobenzene; SCM: Iodomethane (methyl iodide), 1,2,4,5-Tetramethylbenzene; 4-Ethyltoluene.
EPA 8270D/8270E: NPW: Dimethylnaphthalene,1,4-Diphenylhydrazine, alpha-Terpineol; SCM: Dimethylnaphthalene,1,4-Diphenylhydrazine.
SM4500: NPW: Amenable Cyanide; SCM: Total Phosphorus, TKN, NO2, NO3.

Mansfield Facility
SM 2540D: TSS
EPA 8082A: NPW: PCB: 1, 5, 31, 87,101, 110, 141, 151, 153, 180, 183, 187.
EPA TO-15: Halothane, 2,4,4-Trimethyl-2-pentene, 2,4,4-Trimethyl-1-pentene, Thiophene, 2-Methylthiophene, 3-Methylthiophene, 2-Ethylthiophene, 1,2,3-Trimethylbenzene, Indan, Indene, 1,2,4,5-Tetramethylbenzene, Benzothiophene, 1-Methylnaphthalene.
Biological Tissue Matrix: EPA 3050B

The following analytes are included in our Massachusetts DEP Scope of Accreditation

Westborough Facility:

Drinking Water
EPA 300.0: Chloride, Nitrate-N, Fluoride, Sulfate; **EPA 353.2**: Nitrate-N, Nitrite-N; **SM4500NO3-F**: Nitrate-N, Nitrite-N; **SM4500F-C, SM4500CN-CE, EPA 180.1, SM2130B, SM4500Cl-D, SM2320B, SM2540C, SM4500H-B, SM4500NO2-B**
EPA 332: Perchlorate; **EPA 524.2:** THMs and VOCs; **EPA 504.1:** EDB, DBCP.
Microbiology: **SM9215B; SM9223-P/A, SM9223B-Colilert-QT,SM9222D**.

Non-Potable Water
SM4500H,B, EPA 120.1, SM2510B, SM2540C, SM2320B, SM4500CL-E, SM4500F-BC, SM4500NH3-BH: Ammonia-N and Kjeldahl-N, **EPA 350.1**: Ammonia-N, **LACHAT 10-107-06-1-B**: Ammonia-N, **EPA 351.1, SM4500NO3-F, EPA 353.2**: Nitrate-N, **SM4500P-E, SM4500P-B, E, SM4500SO4-E, SM5220D, EPA 410.4, SM5210B, SM5310C, SM4500CL-D, EPA 1664, EPA 420.1, SM4500-CN-CE, SM2540D, EPA 300: Chloride, Sulfate, Nitrate.**
EPA 624.1: Volatile Halocarbons & Aromatics,
EPA 608.3: Chlordane, Toxaphene, Aldrin, alpha-BHC, beta-BHC, gamma-BHC, delta-BHC, Dieldrin, DDD, DDE, DDT, Endosulfan I, Endosulfan II, Endosulfan sulfate, Endrin, Endrin Aldehyde, Heptachlor, Heptachlor Epoxide, PCBs
EPA 625.1: SVOC (Acid/Base/Neutral Extractables), **EPA 600/4-81-045**: PCB-Oil.
Microbiology: **SM9223B-Colilert-QT; Enterolert-QT, SM9221E, EPA 1600, EPA 1603, SM9222D.**

Mansfield Facility:

Drinking Water
EPA 200.7: Al, Ba, Cd, Cr, Cu, Fe, Mn, Ni, Na, Ag, Ca, Zn. **EPA 200.8:** Al, Sb, As, Ba, Be, Cd, Cr, Cu, Pb, Mn, Ni, Se, Ag, TL, Zn. **EPA 245.1** Hg.
EPA 522, EPA 537.1.

Non-Potable Water
EPA 200.7: Al, Sb, As, Be, Cd, Ca, Cr, Co, Cu, Fe, Pb, Mg, Mn, Mo, Ni, K, Se, Ag, Na, Sr, TL, Ti, V, Zn.
EPA 200.8: Al, Sb, As, Be, Cd, Cr, Cu, Fe, Pb, Mn, Ni, K, Se, Ag, Na, TL, Zn.
EPA 245.1 Hg.
SM2340B

For a complete listing of analytes and methods, please contact your Alpha Project Manager.

NEW YORK CHAIN OF CUSTODY

ALPHA ANALYTICAL

Westborough, MA 01581
8 Walkup Dr.
TEL: 508-898-9220
FAX: 508-898-9193

Mansfield, MA 02048
320 Forbes Blvd
TEL: 508-822-9300
FAX: 508-822-3288

Service Centers
Mahwah, NJ 07430: 35 Whitney Rd, Suite 5
Albany, NY 12205: 14 Walker Way
Tonawanda, NY 14150: 275 Cooper Ave, Suite 105

Page 1 of 1

Date Rec'd in Lab: 3/31/23

ALPHA Job #: L2316865

Client Information

Client: SESI
Address: 959 US 46 E 3 S300
Parsippany NJ 07054
Phone: 973 808 9050
Fax:
Email: ssg@sesi.org | jcs@sesi.org

Project Information

Project Name: 100 Main St
Project Location: White Plains NY
Project #: 12461
(Use Project name as Project #) ☐
Project Manager: Steve Gustems | Jon Stuart
ALPHAQuote #:

Turn-Around Time

Standard ☑ Due Date:
Rush (only if pre approved) ☐ # of Days: 5

These samples have been previously analyzed by Alpha ☐

Other project specific requirements/comments:

Please specify Metals or TAL.

Deliverables

☐ ASP-A ☑ ASP-B
☐ EQuIS (1 File) ☑ EQuIS (4 File) NY
☐ Other

Regulatory Requirement

☐ NY TOGS ☐ NY Part 375
☑ AWQ Standards ☐ NY CP-51
☑ NY Restricted Use ☐ Other
☑ NY Unrestricted Use
☐ NYC Sewer Discharge

Billing Information

☐ Same as Client Info
PO # Renaissance Env Mgmt
Attn: Kevin McManus

Disposal Site Information

Please identify below location of applicable disposal facilities.

Disposal Facility:
☐ NJ ☐ NY
☐ Other:

Sample Filtration

☐ Done
☐ Lab to do
Preservation
☐ Lab to do
(Please Specify below)

ALPHA Lab ID (Lab Use Only)	Sample ID	Collection Date	Collection Time	Sample Matrix	Sampler's Initials	TCL+30 TAL	1-4 Dioxane	PFAS Method 1633	Total Bottle	Sample Specific Comments
L2316865-01	GW-3	3/30/23	1300	GW	CB	✓	✓	✓		
02	GW-4		1330	GW	CB	✓	✓	✓		
03	GW-5		1030	GW	CB	✓	✓	✓		
04	GW-6		1100	GW	CB	✓	✓	✓		
05	GW-7		1130	GW	CB	✓	✓	✓		
06	SB-37		1140	Soil	CB	✓	✓			
07	SB-38		1115	Soil	CB	✓	✓			

Container Type: P/G P/G P
Preservative:

Preservative Code:
A = None
B = HCl
C = HNO_3
D = H_2SO_4
E = NaOH
F = MeOH
G = $NaHSO_4$
H = $Na_2S_2O_3$
K/E = Zn Ac/NaOH
O = Other

Container Code
P = Plastic
A = Amber Glass
V = Vial
G = Glass
B = Bacteria Cup
C = Cube
O = Other
E = Encore
D = BOD Bottle

Westboro: Certification No: MA935
Mansfield: Certification No: MA015

Relinquished By:	Date/Time	Received By:	Date/Time
	03/31/23	AAL	3/31/23 8:35
AAL	03/31/23 13:15	Paul Maggella	3/31/23 16:45
Paul Maggella 3/31/23		Chris Mena AAL	3/31/23 2100
Chris Mena AAL 3/31/23	2300		3/31/23 23:30

Please print clearly, legibly and completely. Samples can not be logged in and turnaround time clock will not start until any ambiguities are resolved. BY EXECUTING THIS COC, THE CLIENT HAS READ AND AGREES TO BE BOUND BY ALPHA'S TERMS & CONDITIONS. (See reverse side.)

ANALYTICAL REPORT

Lab Number:	L2318715
Client:	Soils Engineering Services, Inc. 959 Route 46E Parsippany, NJ 07054
ATTN:	Steven Gustems
Phone:	(973) 808-9050
Project Name:	100 MAIN ST.
Project Number:	12461:1
Report Date:	04/24/23

The original project report/data package is held by Alpha Analytical. This report/data package is paginated and should be reproduced only in its entirety. Alpha Analytical holds no responsibility for results and/or data that are not consistent with the original.

Certifications & Approvals: MA (M-MA086), NH NELAP (2064), CT (PH-0574), IL (200077), ME (MA00086), MD (348), NJ (MA935), NY (11148), NC (25700/666), PA (68-03671), RI (LAO00065), TX (T104704476), VT (VT-0935), VA (460195), USDA (Permit #P330-17-00196).

Eight Walkup Drive, Westborough, MA 01581-1019
508-898-9220 (Fax) 508-898-9193 800-624-9220 - www.alphalab.com

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

Alpha Sample ID	Client ID	Matrix	Sample Location	Collection Date/Time	Receive Date
L2318715-01	GW-8	WATER	WHITE PLAINS, NY	04/07/23 08:15	04/07/23
L2318715-02	GW-9	WATER	WHITE PLAINS, NY	04/07/23 13:45	04/07/23
L2318715-03	SB-8G (1.5-2)	SOIL	WHITE PLAINS, NY	04/07/23 10:45	04/07/23
L2318715-04	SB-20G (2.5-3)	SOIL	WHITE PLAINS, NY	04/07/23 14:30	04/07/23
L2318715-05	SB-21G (0.5-1)	SOIL	WHITE PLAINS, NY	04/07/23 14:15	04/07/23

Project Name:	100 MAIN ST.	**Lab Number:**	L2318715
Project Number:	12461:1	**Report Date:**	04/24/23

Case Narrative

The samples were received in accordance with the Chain of Custody and no significant deviations were encountered during the preparation or analysis unless otherwise noted. Sample Receipt, Container Information, and the Chain of Custody are located at the back of the report.

Results contained within this report relate only to the samples submitted under this Alpha Lab Number and meet NELAP requirements for all NELAP accredited parameters unless otherwise noted in the following narrative. The data presented in this report is organized by parameter (i.e. VOC, SVOC, etc.). Sample specific Quality Control data (i.e. Surrogate Spike Recovery) is reported at the end of the target analyte list for each individual sample, followed by the Laboratory Batch Quality Control at the end of each parameter. Tentatively Identified Compounds (TICs), if requested, are reported for compounds identified to be present and are not part of the method/program Target Compound List, even if only a subset of the TCL are being reported. If a sample was re-analyzed or re-extracted due to a required quality control corrective action and if both sets of data are reported, the Laboratory ID of the re-analysis or re-extraction is designated with an "R" or "RE", respectively.

When multiple Batch Quality Control elements are reported (e.g. more than one LCS), the associated samples for each element are noted in the grey shaded header line of each data table. Any Laboratory Batch, Sample Specific % recovery or RPD value that is outside the listed Acceptance Criteria is bolded in the report. In reference to questions H (CAM) or 4 (RCP) when "NO" is checked, the performance criteria for CAM and RCP methods allow for some quality control failures to occur and still be within method compliance. In these instances, the specific failure is not narrated but noted in the associated QC Outlier Summary Report, located directly after the Case Narrative. QC information is also incorporated in the Data Usability Assessment table (Format 11) of our Data Merger tool, where it can be reviewed in conjunction with the sample result, associated regulatory criteria and any associated data usability implications.

Soil/sediments, solids and tissues are reported on a dry weight basis unless otherwise noted. Definitions of all data qualifiers and acronyms used in this report are provided in the Glossary located at the back of the report.

HOLD POLICY - For samples submitted on hold, Alpha's policy is to hold samples (with the exception of Air canisters) free of charge for 21 calendar days from the date the project is completed. After 21 calendar days, we will dispose of all samples submitted including those put on hold unless you have contacted your Alpha Project Manager and made arrangements for Alpha to continue to hold the samples. Air canisters will be disposed after 3 business days from the date the project is completed.

Please contact Project Management at 800-624-9220 with any questions.

Project Name: 100 MAIN ST. **Lab Number:** L2318715
Project Number: 12461:1 **Report Date:** 04/24/23

Case Narrative (continued)

Report Submission

April 24, 2023: This final report includes the results of all requested analyses.

April 17, 2023: This is a preliminary report.

April 14, 2023: This is a preliminary report.

All non-detect (ND) or estimated concentrations (J-qualified) have been quantitated to the limit noted in the MDL column.

Sample Receipt

L2318715-02: The sample was received above the appropriate pH for the Total Metals analysis. The laboratory added additional HNO3 to a pH <2.

Volatile Organics

L2318715-02: The pH was greater than two; however, the sample was analyzed within the method required holding time.

Semivolatile Organics

The WG1765509-1 Method Blank, associated with L2318715-01 and -02, has TIC(s) detected. The results are qualified with a "B" for any associated samples that have detections of the same TIC(s).

The WG1766042-2/-3 LCS/LCSD recoveries, associated with L2318715-03 through -05, are below the acceptance criteria for benzoic acid (0%/0%); however, it has been identified as a "difficult" analyte. The results of the associated samples are reported.

Semivolatile Organics by SIM

L2318715-02D: The sample has elevated detection limits due to the dilution required by the sample matrix.

Project Name: 100 MAIN ST. **Lab Number:** L2318715
Project Number: 12461:1 **Report Date:** 04/24/23

Case Narrative (continued)

1,4-Dioxane by 8270-SIM

L2318715-02D: The sample has an elevated detection limit due to the dilution required by the sample matrix.

Perfluorinated Alkyl Acids by 1633

L2318715-03, WG1767336-1, WG1767336-2, and WG1767336-3: Extracted Internal Standard recoveries were outside the acceptance criteria for individual analytes. Please refer to the surrogate section of the report for details.

Total Metals

L2318715-02: The sample has elevated detection limits for all elements, due to the prep dilution required by the sample matrix.

L2318715-03 through -05: The sample has elevated detection limits for all elements, with the exception of mercury, due to the dilution required by the sample matrix.

Cyanide, Total

The WG1766659-2/-3 LCS/LCSD recoveries for cyanide, total (73%/71%), associated with L2318715-03 and -05, are outside our in-house acceptance criteria, but within the vendor-certified acceptance limits. The results of the original analyses are reported.

The WG1766661-2/-3 LCS/LCSD recoveries for cyanide, total (73%/71%), associated with L2318715-04, are outside our in-house acceptance criteria, but within the vendor-certified acceptance limits. The results of the original analyses are reported.

I, the undersigned, attest under the pains and penalties of perjury that, to the best of my knowledge and belief and based upon my personal inquiry of those responsible for providing the information contained in this analytical report, such information is accurate and complete. This certificate of analysis is not complete unless this page accompanies any and all pages of this report.

Authorized Signature: Tiffani Morrissey - Tiffani Morrissey

Title: Technical Director/Representative Date: 04/24/23

ORGANICS

VOLATILES

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-01
Client ID: GW-8
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 08:15
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8260D
Analytical Date: 04/12/23 16:16
Analyst: LAC

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Methylene chloride	ND		ug/l	2.5	0.70	1
1,1-Dichloroethane	ND		ug/l	2.5	0.70	1
Chloroform	ND		ug/l	2.5	0.70	1
Carbon tetrachloride	ND		ug/l	0.50	0.13	1
1,2-Dichloropropane	ND		ug/l	1.0	0.14	1
Dibromochloromethane	ND		ug/l	0.50	0.15	1
1,1,2-Trichloroethane	ND		ug/l	1.5	0.50	1
Tetrachloroethene	ND		ug/l	0.50	0.18	1
Chlorobenzene	ND		ug/l	2.5	0.70	1
Trichlorofluoromethane	ND		ug/l	2.5	0.70	1
1,2-Dichloroethane	ND		ug/l	0.50	0.13	1
1,1,1-Trichloroethane	ND		ug/l	2.5	0.70	1
Bromodichloromethane	ND		ug/l	0.50	0.19	1
trans-1,3-Dichloropropene	ND		ug/l	0.50	0.16	1
cis-1,3-Dichloropropene	ND		ug/l	0.50	0.14	1
1,3-Dichloropropene, Total	ND		ug/l	0.50	0.14	1
1,1-Dichloropropene	ND		ug/l	2.5	0.70	1
Bromoform	ND		ug/l	2.0	0.65	1
1,1,2,2-Tetrachloroethane	ND		ug/l	0.50	0.17	1
Benzene	0.24	J	ug/l	0.50	0.16	1
Toluene	ND		ug/l	2.5	0.70	1
Ethylbenzene	1.4	J	ug/l	2.5	0.70	1
Chloromethane	ND		ug/l	2.5	0.70	1
Bromomethane	ND		ug/l	2.5	0.70	1
Vinyl chloride	ND		ug/l	1.0	0.07	1
Chloroethane	ND		ug/l	2.5	0.70	1
1,1-Dichloroethene	ND		ug/l	0.50	0.17	1
trans-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-01 Date Collected: 04/07/23 08:15

Client ID: GW-8 Date Received: 04/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Trichloroethene	ND		ug/l	0.50	0.18	1
1,2-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,3-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,4-Dichlorobenzene	ND		ug/l	2.5	0.70	1
Methyl tert butyl ether	ND		ug/l	2.5	0.70	1
p/m-Xylene	ND		ug/l	2.5	0.70	1
o-Xylene	ND		ug/l	2.5	0.70	1
Xylenes, Total	ND		ug/l	2.5	0.70	1
cis-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1
1,2-Dichloroethene, Total	ND		ug/l	2.5	0.70	1
Dibromomethane	ND		ug/l	5.0	1.0	1
1,2,3-Trichloropropane	ND		ug/l	2.5	0.70	1
Acrylonitrile	ND		ug/l	5.0	1.5	1
Styrene	16		ug/l	2.5	0.70	1
Dichlorodifluoromethane	ND		ug/l	5.0	1.0	1
Acetone	72		ug/l	5.0	1.5	1
Carbon disulfide	ND		ug/l	5.0	1.0	1
2-Butanone	42		ug/l	5.0	1.9	1
Vinyl acetate	ND		ug/l	5.0	1.0	1
4-Methyl-2-pentanone	ND		ug/l	5.0	1.0	1
2-Hexanone	ND		ug/l	5.0	1.0	1
Bromochloromethane	ND		ug/l	2.5	0.70	1
2,2-Dichloropropane	ND		ug/l	2.5	0.70	1
1,2-Dibromoethane	ND		ug/l	2.0	0.65	1
1,3-Dichloropropane	ND		ug/l	2.5	0.70	1
1,1,1,2-Tetrachloroethane	ND		ug/l	2.5	0.70	1
Bromobenzene	ND		ug/l	2.5	0.70	1
n-Butylbenzene	ND		ug/l	2.5	0.70	1
sec-Butylbenzene	ND		ug/l	2.5	0.70	1
tert-Butylbenzene	ND		ug/l	2.5	0.70	1
o-Chlorotoluene	ND		ug/l	2.5	0.70	1
p-Chlorotoluene	ND		ug/l	2.5	0.70	1
1,2-Dibromo-3-chloropropane	ND		ug/l	2.5	0.70	1
Hexachlorobutadiene	ND		ug/l	2.5	0.70	1
Isopropylbenzene	ND		ug/l	2.5	0.70	1
p-Isopropyltoluene	ND		ug/l	2.5	0.70	1
Naphthalene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-01 Date Collected: 04/07/23 08:15

Client ID: GW-8 Date Received: 04/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
n-Propylbenzene	ND		ug/l	2.5	0.70	1
1,2,3-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,3,5-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,4-Dioxane	ND		ug/l	250	61.	1
p-Diethylbenzene	ND		ug/l	2.0	0.70	1
p-Ethyltoluene	ND		ug/l	2.0	0.70	1
1,2,4,5-Tetramethylbenzene	ND		ug/l	2.0	0.54	1
Ethyl ether	ND		ug/l	2.5	0.70	1
trans-1,4-Dichloro-2-butene	ND		ug/l	2.5	0.70	1
Tentatively Identified Compounds						
Total TIC Compounds	5.86	J	ug/l			1
Unknown	3.34	J	ug/l			1
Unknown	2.52	J	ug/l			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	100		70-130
Toluene-d8	94		70-130
4-Bromofluorobenzene	85		70-130
Dibromofluoromethane	110		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-02
Client ID: GW-9
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 13:45
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8260D
Analytical Date: 04/12/23 16:38
Analyst: LAC

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Methylene chloride	ND		ug/l	2.5	0.70	1
1,1-Dichloroethane	ND		ug/l	2.5	0.70	1
Chloroform	ND		ug/l	2.5	0.70	1
Carbon tetrachloride	ND		ug/l	0.50	0.13	1
1,2-Dichloropropane	ND		ug/l	1.0	0.14	1
Dibromochloromethane	ND		ug/l	0.50	0.15	1
1,1,2-Trichloroethane	ND		ug/l	1.5	0.50	1
Tetrachloroethene	ND		ug/l	0.50	0.18	1
Chlorobenzene	ND		ug/l	2.5	0.70	1
Trichlorofluoromethane	ND		ug/l	2.5	0.70	1
1,2-Dichloroethane	ND		ug/l	0.50	0.13	1
1,1,1-Trichloroethane	ND		ug/l	2.5	0.70	1
Bromodichloromethane	ND		ug/l	0.50	0.19	1
trans-1,3-Dichloropropene	ND		ug/l	0.50	0.16	1
cis-1,3-Dichloropropene	ND		ug/l	0.50	0.14	1
1,3-Dichloropropene, Total	ND		ug/l	0.50	0.14	1
1,1-Dichloropropene	ND		ug/l	2.5	0.70	1
Bromoform	ND		ug/l	2.0	0.65	1
1,1,2,2-Tetrachloroethane	ND		ug/l	0.50	0.17	1
Benzene	ND		ug/l	0.50	0.16	1
Toluene	ND		ug/l	2.5	0.70	1
Ethylbenzene	ND		ug/l	2.5	0.70	1
Chloromethane	ND		ug/l	2.5	0.70	1
Bromomethane	ND		ug/l	2.5	0.70	1
Vinyl chloride	ND		ug/l	1.0	0.07	1
Chloroethane	ND		ug/l	2.5	0.70	1
1,1-Dichloroethene	ND		ug/l	0.50	0.17	1
trans-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-02 Date Collected: 04/07/23 13:45

Client ID: GW-9 Date Received: 04/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Trichloroethene	ND		ug/l	0.50	0.18	1
1,2-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,3-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,4-Dichlorobenzene	ND		ug/l	2.5	0.70	1
Methyl tert butyl ether	ND		ug/l	2.5	0.70	1
p/m-Xylene	ND		ug/l	2.5	0.70	1
o-Xylene	ND		ug/l	2.5	0.70	1
Xylenes, Total	ND		ug/l	2.5	0.70	1
cis-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1
1,2-Dichloroethene, Total	ND		ug/l	2.5	0.70	1
Dibromomethane	ND		ug/l	5.0	1.0	1
1,2,3-Trichloropropane	ND		ug/l	2.5	0.70	1
Acrylonitrile	ND		ug/l	5.0	1.5	1
Styrene	8.3		ug/l	2.5	0.70	1
Dichlorodifluoromethane	ND		ug/l	5.0	1.0	1
Acetone	11		ug/l	5.0	1.5	1
Carbon disulfide	ND		ug/l	5.0	1.0	1
2-Butanone	3.3	J	ug/l	5.0	1.9	1
Vinyl acetate	ND		ug/l	5.0	1.0	1
4-Methyl-2-pentanone	ND		ug/l	5.0	1.0	1
2-Hexanone	ND		ug/l	5.0	1.0	1
Bromochloromethane	ND		ug/l	2.5	0.70	1
2,2-Dichloropropane	ND		ug/l	2.5	0.70	1
1,2-Dibromoethane	ND		ug/l	2.0	0.65	1
1,3-Dichloropropane	ND		ug/l	2.5	0.70	1
1,1,1,2-Tetrachloroethane	ND		ug/l	2.5	0.70	1
Bromobenzene	ND		ug/l	2.5	0.70	1
n-Butylbenzene	ND		ug/l	2.5	0.70	1
sec-Butylbenzene	ND		ug/l	2.5	0.70	1
tert-Butylbenzene	ND		ug/l	2.5	0.70	1
o-Chlorotoluene	ND		ug/l	2.5	0.70	1
p-Chlorotoluene	ND		ug/l	2.5	0.70	1
1,2-Dibromo-3-chloropropane	ND		ug/l	2.5	0.70	1
Hexachlorobutadiene	ND		ug/l	2.5	0.70	1
Isopropylbenzene	ND		ug/l	2.5	0.70	1
p-Isopropyltoluene	ND		ug/l	2.5	0.70	1
Naphthalene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-02 Date Collected: 04/07/23 13:45

Client ID: GW-9 Date Received: 04/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
n-Propylbenzene	ND		ug/l	2.5	0.70	1
1,2,3-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,3,5-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,4-Dioxane	ND		ug/l	250	61.	1
p-Diethylbenzene	ND		ug/l	2.0	0.70	1
p-Ethyltoluene	ND		ug/l	2.0	0.70	1
1,2,4,5-Tetramethylbenzene	ND		ug/l	2.0	0.54	1
Ethyl ether	ND		ug/l	2.5	0.70	1
trans-1,4-Dichloro-2-butene	ND		ug/l	2.5	0.70	1
Tentatively Identified Compounds						
Total TIC Compounds	10.4	J	ug/l			1
Unknown Aromatic	1.10	J	ug/l			1
Unknown	1.40	J	ug/l			1
Unknown Aromatic	2.00	J	ug/l			1
Unknown Naphthalene	1.68	J	ug/l			1
Unknown Naphthalene	1.35	J	ug/l			1
Unknown	1.23	J	ug/l			1
Unknown Aromatic	1.67	J	ug/l			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	107		70-130
Toluene-d8	95		70-130
4-Bromofluorobenzene	85		70-130
Dibromofluoromethane	108		70-130

Project Name: 100 MAIN ST.
Lab Number: L2318715
Project Number: 12461:1
Report Date: 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-03
Client ID: SB-8G (1.5-2)
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 10:45
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8260D
Analytical Date: 04/12/23 15:33
Analyst: AJK
Percent Solids: 88%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Methylene chloride	ND		ug/kg	5.4	2.5	1
1,1-Dichloroethane	ND		ug/kg	1.1	0.16	1
Chloroform	ND		ug/kg	1.6	0.15	1
Carbon tetrachloride	ND		ug/kg	1.1	0.25	1
1,2-Dichloropropane	ND		ug/kg	1.1	0.14	1
Dibromochloromethane	ND		ug/kg	1.1	0.15	1
1,1,2-Trichloroethane	ND		ug/kg	1.1	0.29	1
Tetrachloroethene	0.44	J	ug/kg	0.54	0.21	1
Chlorobenzene	ND		ug/kg	0.54	0.14	1
Trichlorofluoromethane	ND		ug/kg	4.3	0.75	1
1,2-Dichloroethane	ND		ug/kg	1.1	0.28	1
1,1,1-Trichloroethane	ND		ug/kg	0.54	0.18	1
Bromodichloromethane	ND		ug/kg	0.54	0.12	1
trans-1,3-Dichloropropene	ND		ug/kg	1.1	0.30	1
cis-1,3-Dichloropropene	ND		ug/kg	0.54	0.17	1
1,3-Dichloropropene, Total	ND		ug/kg	0.54	0.17	1
1,1-Dichloropropene	ND		ug/kg	0.54	0.17	1
Bromoform	ND		ug/kg	4.3	0.27	1
1,1,2,2-Tetrachloroethane	ND		ug/kg	0.54	0.18	1
Benzene	ND		ug/kg	0.54	0.18	1
Toluene	ND		ug/kg	1.1	0.59	1
Ethylbenzene	ND		ug/kg	1.1	0.15	1
Chloromethane	ND		ug/kg	4.3	1.0	1
Bromomethane	ND		ug/kg	2.2	0.63	1
Vinyl chloride	ND		ug/kg	1.1	0.36	1
Chloroethane	ND		ug/kg	2.2	0.49	1
1,1-Dichloroethene	ND		ug/kg	1.1	0.26	1
trans-1,2-Dichloroethene	ND		ug/kg	1.6	0.15	1

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-03 Date Collected: 04/07/23 10:45

Client ID: SB-8G (1.5-2) Date Received: 04/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Trichloroethene	ND		ug/kg	0.54	0.15	1
1,2-Dichlorobenzene	ND		ug/kg	2.2	0.16	1
1,3-Dichlorobenzene	ND		ug/kg	2.2	0.16	1
1,4-Dichlorobenzene	ND		ug/kg	2.2	0.18	1
Methyl tert butyl ether	ND		ug/kg	2.2	0.22	1
p/m-Xylene	ND		ug/kg	2.2	0.61	1
o-Xylene	ND		ug/kg	1.1	0.32	1
Xylenes, Total	ND		ug/kg	1.1	0.32	1
cis-1,2-Dichloroethene	ND		ug/kg	1.1	0.19	1
1,2-Dichloroethene, Total	ND		ug/kg	1.1	0.15	1
Dibromomethane	ND		ug/kg	2.2	0.26	1
Styrene	ND		ug/kg	1.1	0.21	1
Dichlorodifluoromethane	ND		ug/kg	11	0.99	1
Acetone	ND		ug/kg	11	5.2	1
Carbon disulfide	ND		ug/kg	11	4.9	1
2-Butanone	ND		ug/kg	11	2.4	1
Vinyl acetate	ND		ug/kg	11	2.3	1
4-Methyl-2-pentanone	ND		ug/kg	11	1.4	1
1,2,3-Trichloropropane	ND		ug/kg	2.2	0.14	1
2-Hexanone	ND		ug/kg	11	1.3	1
Bromochloromethane	ND		ug/kg	2.2	0.22	1
2,2-Dichloropropane	ND		ug/kg	2.2	0.22	1
1,2-Dibromoethane	ND		ug/kg	1.1	0.30	1
1,3-Dichloropropane	ND		ug/kg	2.2	0.18	1
1,1,1,2-Tetrachloroethane	ND		ug/kg	0.54	0.14	1
Bromobenzene	ND		ug/kg	2.2	0.16	1
n-Butylbenzene	ND		ug/kg	1.1	0.18	1
sec-Butylbenzene	ND		ug/kg	1.1	0.16	1
tert-Butylbenzene	ND		ug/kg	2.2	0.13	1
o-Chlorotoluene	ND		ug/kg	2.2	0.21	1
p-Chlorotoluene	ND		ug/kg	2.2	0.12	1
1,2-Dibromo-3-chloropropane	ND		ug/kg	3.2	1.1	1
Hexachlorobutadiene	ND		ug/kg	4.3	0.18	1
Isopropylbenzene	ND		ug/kg	1.1	0.12	1
p-Isopropyltoluene	ND		ug/kg	1.1	0.12	1
Naphthalene	ND		ug/kg	4.3	0.70	1
Acrylonitrile	ND		ug/kg	4.3	1.2	1

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-03 Date Collected: 04/07/23 10:45

Client ID: SB-8G (1.5-2) Date Received: 04/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
n-Propylbenzene	ND		ug/kg	1.1	0.18	1
1,2,3-Trichlorobenzene	ND		ug/kg	2.2	0.35	1
1,2,4-Trichlorobenzene	ND		ug/kg	2.2	0.30	1
1,3,5-Trimethylbenzene	ND		ug/kg	2.2	0.21	1
1,2,4-Trimethylbenzene	ND		ug/kg	2.2	0.36	1
1,4-Dioxane	ND		ug/kg	87	38.	1
p-Diethylbenzene	ND		ug/kg	2.2	0.19	1
p-Ethyltoluene	ND		ug/kg	2.2	0.42	1
1,2,4,5-Tetramethylbenzene	ND		ug/kg	2.2	0.21	1
Ethyl ether	ND		ug/kg	2.2	0.37	1
trans-1,4-Dichloro-2-butene	ND		ug/kg	5.4	1.5	1
Tentatively Identified Compounds						
No Tentatively Identified Compounds	ND		ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	112		70-130
Toluene-d8	93		70-130
4-Bromofluorobenzene	92		70-130
Dibromofluoromethane	109		70-130

Project Name: 100 MAIN ST.
Lab Number: L2318715
Project Number: 12461:1
Report Date: 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-04
Client ID: SB-20G (2.5-3)
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 14:30
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8260D
Analytical Date: 04/12/23 15:53
Analyst: AJK
Percent Solids: 93%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Methylene chloride	ND		ug/kg	5.7	2.6	1
1,1-Dichloroethane	ND		ug/kg	1.1	0.16	1
Chloroform	ND		ug/kg	1.7	0.16	1
Carbon tetrachloride	ND		ug/kg	1.1	0.26	1
1,2-Dichloropropane	ND		ug/kg	1.1	0.14	1
Dibromochloromethane	ND		ug/kg	1.1	0.16	1
1,1,2-Trichloroethane	ND		ug/kg	1.1	0.30	1
Tetrachloroethene	ND		ug/kg	0.57	0.22	1
Chlorobenzene	ND		ug/kg	0.57	0.14	1
Trichlorofluoromethane	ND		ug/kg	4.5	0.79	1
1,2-Dichloroethane	ND		ug/kg	1.1	0.29	1
1,1,1-Trichloroethane	ND		ug/kg	0.57	0.19	1
Bromodichloromethane	ND		ug/kg	0.57	0.12	1
trans-1,3-Dichloropropene	ND		ug/kg	1.1	0.31	1
cis-1,3-Dichloropropene	ND		ug/kg	0.57	0.18	1
1,3-Dichloropropene, Total	ND		ug/kg	0.57	0.18	1
1,1-Dichloropropene	ND		ug/kg	0.57	0.18	1
Bromoform	ND		ug/kg	4.5	0.28	1
1,1,2,2-Tetrachloroethane	ND		ug/kg	0.57	0.19	1
Benzene	ND		ug/kg	0.57	0.19	1
Toluene	ND		ug/kg	1.1	0.62	1
Ethylbenzene	ND		ug/kg	1.1	0.16	1
Chloromethane	ND		ug/kg	4.5	1.0	1
Bromomethane	ND		ug/kg	2.3	0.66	1
Vinyl chloride	ND		ug/kg	1.1	0.38	1
Chloroethane	ND		ug/kg	2.3	0.51	1
1,1-Dichloroethene	ND		ug/kg	1.1	0.27	1
trans-1,2-Dichloroethene	ND		ug/kg	1.7	0.16	1

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-04 Date Collected: 04/07/23 14:30

Client ID: SB-20G (2.5-3) Date Received: 04/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Trichloroethene	ND		ug/kg	0.57	0.16	1
1,2-Dichlorobenzene	ND		ug/kg	2.3	0.16	1
1,3-Dichlorobenzene	ND		ug/kg	2.3	0.17	1
1,4-Dichlorobenzene	ND		ug/kg	2.3	0.19	1
Methyl tert butyl ether	ND		ug/kg	2.3	0.23	1
p/m-Xylene	ND		ug/kg	2.3	0.64	1
o-Xylene	ND		ug/kg	1.1	0.33	1
Xylenes, Total	ND		ug/kg	1.1	0.33	1
cis-1,2-Dichloroethene	ND		ug/kg	1.1	0.20	1
1,2-Dichloroethene, Total	ND		ug/kg	1.1	0.16	1
Dibromomethane	ND		ug/kg	2.3	0.27	1
Styrene	ND		ug/kg	1.1	0.22	1
Dichlorodifluoromethane	ND		ug/kg	11	1.0	1
Acetone	ND		ug/kg	11	5.5	1
Carbon disulfide	ND		ug/kg	11	5.2	1
2-Butanone	3.0	J	ug/kg	11	2.5	1
Vinyl acetate	ND		ug/kg	11	2.4	1
4-Methyl-2-pentanone	ND		ug/kg	11	1.4	1
1,2,3-Trichloropropane	ND		ug/kg	2.3	0.14	1
2-Hexanone	ND		ug/kg	11	1.3	1
Bromochloromethane	ND		ug/kg	2.3	0.23	1
2,2-Dichloropropane	ND		ug/kg	2.3	0.23	1
1,2-Dibromoethane	ND		ug/kg	1.1	0.32	1
1,3-Dichloropropane	ND		ug/kg	2.3	0.19	1
1,1,1,2-Tetrachloroethane	ND		ug/kg	0.57	0.15	1
Bromobenzene	ND		ug/kg	2.3	0.16	1
n-Butylbenzene	ND		ug/kg	1.1	0.19	1
sec-Butylbenzene	ND		ug/kg	1.1	0.16	1
tert-Butylbenzene	ND		ug/kg	2.3	0.13	1
o-Chlorotoluene	ND		ug/kg	2.3	0.22	1
p-Chlorotoluene	ND		ug/kg	2.3	0.12	1
1,2-Dibromo-3-chloropropane	ND		ug/kg	3.4	1.1	1
Hexachlorobutadiene	ND		ug/kg	4.5	0.19	1
Isopropylbenzene	ND		ug/kg	1.1	0.12	1
p-Isopropyltoluene	ND		ug/kg	1.1	0.12	1
Naphthalene	ND		ug/kg	4.5	0.74	1
Acrylonitrile	ND		ug/kg	4.5	1.3	1

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-04 Date Collected: 04/07/23 14:30

Client ID: SB-20G (2.5-3) Date Received: 04/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
n-Propylbenzene	ND		ug/kg	1.1	0.19	1
1,2,3-Trichlorobenzene	ND		ug/kg	2.3	0.36	1
1,2,4-Trichlorobenzene	ND		ug/kg	2.3	0.31	1
1,3,5-Trimethylbenzene	ND		ug/kg	2.3	0.22	1
1,2,4-Trimethylbenzene	ND		ug/kg	2.3	0.38	1
1,4-Dioxane	ND		ug/kg	91	40.	1
p-Diethylbenzene	ND		ug/kg	2.3	0.20	1
p-Ethyltoluene	ND		ug/kg	2.3	0.44	1
1,2,4,5-Tetramethylbenzene	ND		ug/kg	2.3	0.22	1
Ethyl ether	ND		ug/kg	2.3	0.39	1
trans-1,4-Dichloro-2-butene	ND		ug/kg	5.7	1.6	1
Tentatively Identified Compounds						
No Tentatively Identified Compounds	ND		ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	112		70-130
Toluene-d8	91		70-130
4-Bromofluorobenzene	88		70-130
Dibromofluoromethane	108		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-05
Client ID: SB-21G (0.5-1)
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 14:15
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8260D
Analytical Date: 04/12/23 16:13
Analyst: AJK
Percent Solids: 92%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Methylene chloride	ND		ug/kg	5.3	2.4	1
1,1-Dichloroethane	ND		ug/kg	1.0	0.15	1
Chloroform	ND		ug/kg	1.6	0.15	1
Carbon tetrachloride	ND		ug/kg	1.0	0.24	1
1,2-Dichloropropane	ND		ug/kg	1.0	0.13	1
Dibromochloromethane	ND		ug/kg	1.0	0.15	1
1,1,2-Trichloroethane	ND		ug/kg	1.0	0.28	1
Tetrachloroethene	ND		ug/kg	0.53	0.21	1
Chlorobenzene	ND		ug/kg	0.53	0.13	1
Trichlorofluoromethane	ND		ug/kg	4.2	0.73	1
1,2-Dichloroethane	ND		ug/kg	1.0	0.27	1
1,1,1-Trichloroethane	ND		ug/kg	0.53	0.18	1
Bromodichloromethane	ND		ug/kg	0.53	0.12	1
trans-1,3-Dichloropropene	ND		ug/kg	1.0	0.29	1
cis-1,3-Dichloropropene	ND		ug/kg	0.53	0.17	1
1,3-Dichloropropene, Total	ND		ug/kg	0.53	0.17	1
1,1-Dichloropropene	ND		ug/kg	0.53	0.17	1
Bromoform	ND		ug/kg	4.2	0.26	1
1,1,2,2-Tetrachloroethane	ND		ug/kg	0.53	0.18	1
Benzene	ND		ug/kg	0.53	0.18	1
Toluene	ND		ug/kg	1.0	0.57	1
Ethylbenzene	ND		ug/kg	1.0	0.15	1
Chloromethane	ND		ug/kg	4.2	0.98	1
Bromomethane	ND		ug/kg	2.1	0.61	1
Vinyl chloride	ND		ug/kg	1.0	0.35	1
Chloroethane	ND		ug/kg	2.1	0.48	1
1,1-Dichloroethene	ND		ug/kg	1.0	0.25	1
trans-1,2-Dichloroethene	ND		ug/kg	1.6	0.14	1

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-05 Date Collected: 04/07/23 14:15

Client ID: SB-21G (0.5-1) Date Received: 04/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Trichloroethene	ND		ug/kg	0.53	0.14	1
1,2-Dichlorobenzene	ND		ug/kg	2.1	0.15	1
1,3-Dichlorobenzene	ND		ug/kg	2.1	0.16	1
1,4-Dichlorobenzene	ND		ug/kg	2.1	0.18	1
Methyl tert butyl ether	ND		ug/kg	2.1	0.21	1
p/m-Xylene	ND		ug/kg	2.1	0.59	1
o-Xylene	ND		ug/kg	1.0	0.31	1
Xylenes, Total	ND		ug/kg	1.0	0.31	1
cis-1,2-Dichloroethene	ND		ug/kg	1.0	0.18	1
1,2-Dichloroethene, Total	ND		ug/kg	1.0	0.14	1
Dibromomethane	ND		ug/kg	2.1	0.25	1
Styrene	ND		ug/kg	1.0	0.21	1
Dichlorodifluoromethane	ND		ug/kg	10	0.97	1
Acetone	ND		ug/kg	10	5.1	1
Carbon disulfide	ND		ug/kg	10	4.8	1
2-Butanone	ND		ug/kg	10	2.3	1
Vinyl acetate	ND		ug/kg	10	2.3	1
4-Methyl-2-pentanone	ND		ug/kg	10	1.4	1
1,2,3-Trichloropropane	ND		ug/kg	2.1	0.13	1
2-Hexanone	ND		ug/kg	10	1.2	1
Bromochloromethane	ND		ug/kg	2.1	0.22	1
2,2-Dichloropropane	ND		ug/kg	2.1	0.21	1
1,2-Dibromoethane	ND		ug/kg	1.0	0.29	1
1,3-Dichloropropane	ND		ug/kg	2.1	0.18	1
1,1,1,2-Tetrachloroethane	ND		ug/kg	0.53	0.14	1
Bromobenzene	ND		ug/kg	2.1	0.15	1
n-Butylbenzene	ND		ug/kg	1.0	0.18	1
sec-Butylbenzene	ND		ug/kg	1.0	0.15	1
tert-Butylbenzene	ND		ug/kg	2.1	0.12	1
o-Chlorotoluene	ND		ug/kg	2.1	0.20	1
p-Chlorotoluene	ND		ug/kg	2.1	0.11	1
1,2-Dibromo-3-chloropropane	ND		ug/kg	3.2	1.0	1
Hexachlorobutadiene	ND		ug/kg	4.2	0.18	1
Isopropylbenzene	ND		ug/kg	1.0	0.12	1
p-Isopropyltoluene	ND		ug/kg	1.0	0.12	1
Naphthalene	ND		ug/kg	4.2	0.69	1
Acrylonitrile	ND		ug/kg	4.2	1.2	1

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-05 Date Collected: 04/07/23 14:15

Client ID: SB-21G (0.5-1) Date Received: 04/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
n-Propylbenzene	ND		ug/kg	1.0	0.18	1
1,2,3-Trichlorobenzene	ND		ug/kg	2.1	0.34	1
1,2,4-Trichlorobenzene	ND		ug/kg	2.1	0.29	1
1,3,5-Trimethylbenzene	ND		ug/kg	2.1	0.20	1
1,2,4-Trimethylbenzene	ND		ug/kg	2.1	0.35	1
1,4-Dioxane	ND		ug/kg	84	37.	1
p-Diethylbenzene	ND		ug/kg	2.1	0.19	1
p-Ethyltoluene	ND		ug/kg	2.1	0.40	1
1,2,4,5-Tetramethylbenzene	ND		ug/kg	2.1	0.20	1
Ethyl ether	ND		ug/kg	2.1	0.36	1
trans-1,4-Dichloro-2-butene	ND		ug/kg	5.3	1.5	1
Tentatively Identified Compounds						
No Tentatively Identified Compounds	ND		ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	114		70-130
Toluene-d8	91		70-130
4-Bromofluorobenzene	87		70-130
Dibromofluoromethane	111		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 04/12/23 09:42
Analyst: PID

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by GC/MS - Westborough Lab for sample(s): 01-02 Batch: WG1766310-5					
Methylene chloride	ND		ug/l	2.5	0.70
1,1-Dichloroethane	ND		ug/l	2.5	0.70
Chloroform	ND		ug/l	2.5	0.70
Carbon tetrachloride	ND		ug/l	0.50	0.13
1,2-Dichloropropane	ND		ug/l	1.0	0.14
Dibromochloromethane	ND		ug/l	0.50	0.15
1,1,2-Trichloroethane	ND		ug/l	1.5	0.50
Tetrachloroethene	ND		ug/l	0.50	0.18
Chlorobenzene	ND		ug/l	2.5	0.70
Trichlorofluoromethane	ND		ug/l	2.5	0.70
1,2-Dichloroethane	ND		ug/l	0.50	0.13
1,1,1-Trichloroethane	ND		ug/l	2.5	0.70
Bromodichloromethane	ND		ug/l	0.50	0.19
trans-1,3-Dichloropropene	ND		ug/l	0.50	0.16
cis-1,3-Dichloropropene	ND		ug/l	0.50	0.14
1,3-Dichloropropene, Total	ND		ug/l	0.50	0.14
1,1-Dichloropropene	ND		ug/l	2.5	0.70
Bromoform	ND		ug/l	2.0	0.65
1,1,2,2-Tetrachloroethane	ND		ug/l	0.50	0.17
Benzene	ND		ug/l	0.50	0.16
Toluene	ND		ug/l	2.5	0.70
Ethylbenzene	ND		ug/l	2.5	0.70
Chloromethane	ND		ug/l	2.5	0.70
Bromomethane	ND		ug/l	2.5	0.70
Vinyl chloride	ND		ug/l	1.0	0.07
Chloroethane	ND		ug/l	2.5	0.70
1,1-Dichloroethene	ND		ug/l	0.50	0.17
trans-1,2-Dichloroethene	ND		ug/l	2.5	0.70
Trichloroethene	ND		ug/l	0.50	0.18

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 04/12/23 09:42
Analyst: PID

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by GC/MS - Westborough Lab for sample(s): 01-02 Batch: WG1766310-5					
1,2-Dichlorobenzene	ND		ug/l	2.5	0.70
1,3-Dichlorobenzene	ND		ug/l	2.5	0.70
1,4-Dichlorobenzene	ND		ug/l	2.5	0.70
Methyl tert butyl ether	ND		ug/l	2.5	0.70
p/m-Xylene	ND		ug/l	2.5	0.70
o-Xylene	ND		ug/l	2.5	0.70
Xylenes, Total	ND		ug/l	2.5	0.70
cis-1,2-Dichloroethene	ND		ug/l	2.5	0.70
1,2-Dichloroethene, Total	ND		ug/l	2.5	0.70
Dibromomethane	ND		ug/l	5.0	1.0
1,2,3-Trichloropropane	ND		ug/l	2.5	0.70
Acrylonitrile	ND		ug/l	5.0	1.5
Styrene	ND		ug/l	2.5	0.70
Dichlorodifluoromethane	ND		ug/l	5.0	1.0
Acetone	ND		ug/l	5.0	1.5
Carbon disulfide	ND		ug/l	5.0	1.0
2-Butanone	ND		ug/l	5.0	1.9
Vinyl acetate	ND		ug/l	5.0	1.0
4-Methyl-2-pentanone	ND		ug/l	5.0	1.0
2-Hexanone	ND		ug/l	5.0	1.0
Bromochloromethane	ND		ug/l	2.5	0.70
2,2-Dichloropropane	ND		ug/l	2.5	0.70
1,2-Dibromoethane	ND		ug/l	2.0	0.65
1,3-Dichloropropane	ND		ug/l	2.5	0.70
1,1,1,2-Tetrachloroethane	ND		ug/l	2.5	0.70
Bromobenzene	ND		ug/l	2.5	0.70
n-Butylbenzene	ND		ug/l	2.5	0.70
sec-Butylbenzene	ND		ug/l	2.5	0.70
tert-Butylbenzene	ND		ug/l	2.5	0.70

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 04/12/23 09:42
Analyst: PID

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by GC/MS - Westborough Lab for sample(s): 01-02 Batch: WG1766310-5					
o-Chlorotoluene	ND		ug/l	2.5	0.70
p-Chlorotoluene	ND		ug/l	2.5	0.70
1,2-Dibromo-3-chloropropane	ND		ug/l	2.5	0.70
Hexachlorobutadiene	ND		ug/l	2.5	0.70
Isopropylbenzene	ND		ug/l	2.5	0.70
p-Isopropyltoluene	ND		ug/l	2.5	0.70
Naphthalene	ND		ug/l	2.5	0.70
n-Propylbenzene	ND		ug/l	2.5	0.70
1,2,3-Trichlorobenzene	ND		ug/l	2.5	0.70
1,2,4-Trichlorobenzene	ND		ug/l	2.5	0.70
1,3,5-Trimethylbenzene	ND		ug/l	2.5	0.70
1,2,4-Trimethylbenzene	ND		ug/l	2.5	0.70
1,4-Dioxane	ND		ug/l	250	61.
p-Diethylbenzene	ND		ug/l	2.0	0.70
p-Ethyltoluene	ND		ug/l	2.0	0.70
1,2,4,5-Tetramethylbenzene	ND		ug/l	2.0	0.54
Ethyl ether	ND		ug/l	2.5	0.70
trans-1,4-Dichloro-2-butene	ND		ug/l	2.5	0.70
Tentatively Identified Compounds					
No Tentatively Identified Compounds	ND		ug/l		

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 04/12/23 09:42
Analyst: PID

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by GC/MS - Westborough Lab for sample(s): 01-02 Batch: WG1766310-5					

Surrogate	%Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	107		70-130
Toluene-d8	96		70-130
4-Bromofluorobenzene	89		70-130
Dibromofluoromethane	106		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 04/12/23 10:54
Analyst: AJK

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by EPA 5035 Low - Westborough Lab for sample(s): 03-05 Batch: WG1766413-5					
Methylene chloride	ND		ug/kg	5.0	2.3
1,1-Dichloroethane	ND		ug/kg	1.0	0.14
Chloroform	ND		ug/kg	1.5	0.14
Carbon tetrachloride	ND		ug/kg	1.0	0.23
1,2-Dichloropropane	ND		ug/kg	1.0	0.12
Dibromochloromethane	ND		ug/kg	1.0	0.14
1,1,2-Trichloroethane	ND		ug/kg	1.0	0.27
Tetrachloroethene	ND		ug/kg	0.50	0.20
Chlorobenzene	ND		ug/kg	0.50	0.13
Trichlorofluoromethane	ND		ug/kg	4.0	0.70
1,2-Dichloroethane	ND		ug/kg	1.0	0.26
1,1,1-Trichloroethane	ND		ug/kg	0.50	0.17
Bromodichloromethane	ND		ug/kg	0.50	0.11
trans-1,3-Dichloropropene	ND		ug/kg	1.0	0.27
cis-1,3-Dichloropropene	ND		ug/kg	0.50	0.16
1,3-Dichloropropene, Total	ND		ug/kg	0.50	0.16
1,1-Dichloropropene	ND		ug/kg	0.50	0.16
Bromoform	ND		ug/kg	4.0	0.25
1,1,2,2-Tetrachloroethane	ND		ug/kg	0.50	0.17
Benzene	ND		ug/kg	0.50	0.17
Toluene	ND		ug/kg	1.0	0.54
Ethylbenzene	ND		ug/kg	1.0	0.14
Chloromethane	ND		ug/kg	4.0	0.93
Bromomethane	ND		ug/kg	2.0	0.58
Vinyl chloride	ND		ug/kg	1.0	0.34
Chloroethane	ND		ug/kg	2.0	0.45
1,1-Dichloroethene	ND		ug/kg	1.0	0.24
trans-1,2-Dichloroethene	ND		ug/kg	1.5	0.14
Trichloroethene	ND		ug/kg	0.50	0.14

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 04/12/23 10:54
Analyst: AJK

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by EPA 5035 Low - Westborough Lab for sample(s): 03-05 Batch: WG1766413-5					
1,2-Dichlorobenzene	ND		ug/kg	2.0	0.14
1,3-Dichlorobenzene	ND		ug/kg	2.0	0.15
1,4-Dichlorobenzene	ND		ug/kg	2.0	0.17
Methyl tert butyl ether	ND		ug/kg	2.0	0.20
p/m-Xylene	ND		ug/kg	2.0	0.56
o-Xylene	ND		ug/kg	1.0	0.29
Xylenes, Total	ND		ug/kg	1.0	0.29
cis-1,2-Dichloroethene	ND		ug/kg	1.0	0.18
1,2-Dichloroethene, Total	ND		ug/kg	1.0	0.14
Dibromomethane	ND		ug/kg	2.0	0.24
Styrene	ND		ug/kg	1.0	0.20
Dichlorodifluoromethane	ND		ug/kg	10	0.92
Acetone	ND		ug/kg	10	4.8
Carbon disulfide	ND		ug/kg	10	4.6
2-Butanone	ND		ug/kg	10	2.2
Vinyl acetate	ND		ug/kg	10	2.2
4-Methyl-2-pentanone	ND		ug/kg	10	1.3
1,2,3-Trichloropropane	ND		ug/kg	2.0	0.13
2-Hexanone	ND		ug/kg	10	1.2
Bromochloromethane	ND		ug/kg	2.0	0.20
2,2-Dichloropropane	ND		ug/kg	2.0	0.20
1,2-Dibromoethane	ND		ug/kg	1.0	0.28
1,3-Dichloropropane	ND		ug/kg	2.0	0.17
1,1,1,2-Tetrachloroethane	ND		ug/kg	0.50	0.13
Bromobenzene	ND		ug/kg	2.0	0.14
n-Butylbenzene	ND		ug/kg	1.0	0.17
sec-Butylbenzene	ND		ug/kg	1.0	0.15
tert-Butylbenzene	ND		ug/kg	2.0	0.12
o-Chlorotoluene	ND		ug/kg	2.0	0.19

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 04/12/23 10:54
Analyst: AJK

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by EPA 5035 Low - Westborough Lab for sample(s): 03-05 Batch: WG1766413-5					
p-Chlorotoluene	ND		ug/kg	2.0	0.11
1,2-Dibromo-3-chloropropane	ND		ug/kg	3.0	1.0
Hexachlorobutadiene	ND		ug/kg	4.0	0.17
Isopropylbenzene	ND		ug/kg	1.0	0.11
p-Isopropyltoluene	ND		ug/kg	1.0	0.11
Naphthalene	ND		ug/kg	4.0	0.65
Acrylonitrile	ND		ug/kg	4.0	1.2
n-Propylbenzene	ND		ug/kg	1.0	0.17
1,2,3-Trichlorobenzene	ND		ug/kg	2.0	0.32
1,2,4-Trichlorobenzene	ND		ug/kg	2.0	0.27
1,3,5-Trimethylbenzene	ND		ug/kg	2.0	0.19
1,2,4-Trimethylbenzene	ND		ug/kg	2.0	0.33
1,4-Dioxane	ND		ug/kg	80	35.
p-Diethylbenzene	ND		ug/kg	2.0	0.18
p-Ethyltoluene	ND		ug/kg	2.0	0.38
1,2,4,5-Tetramethylbenzene	ND		ug/kg	2.0	0.19
Ethyl ether	ND		ug/kg	2.0	0.34
trans-1,4-Dichloro-2-butene	ND		ug/kg	5.0	1.4

Tentatively Identified Compounds			
Total TIC Compounds	3.24	J	ug/kg
Unknown	3.24	J	ug/kg

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 04/12/23 10:54
Analyst: AJK

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by EPA 5035 Low - Westborough Lab for sample(s): 03-05 Batch: WG1766413-5					

Surrogate	%Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	109		70-130
Toluene-d8	94		70-130
4-Bromofluorobenzene	91		70-130
Dibromofluoromethane	105		70-130

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by GC/MS - Westborough Lab Associated sample(s): 01-02 Batch: WG1766310-3 WG1766310-4								
Methylene chloride	92		85		70-130	8		20
1,1-Dichloroethane	100		97		70-130	3		20
Chloroform	88		93		70-130	6		20
Carbon tetrachloride	78		78		63-132	0		20
1,2-Dichloropropane	100		100		70-130	0		20
Dibromochloromethane	78		80		63-130	3		20
1,1,2-Trichloroethane	87		91		70-130	4		20
Tetrachloroethene	82		82		70-130	0		20
Chlorobenzene	93		92		75-130	1		20
Trichlorofluoromethane	84		77		62-150	9		20
1,2-Dichloroethane	99		90		70-130	10		20
1,1,1-Trichloroethane	87		92		67-130	6		20
Bromodichloromethane	85		87		67-130	2		20
trans-1,3-Dichloropropene	77		78		70-130	1		20
cis-1,3-Dichloropropene	88		85		70-130	3		20
1,1-Dichloropropene	94		94		70-130	0		20
Bromoform	73		70		54-136	4		20
1,1,2,2-Tetrachloroethane	91		90		67-130	1		20
Benzene	97		92		70-130	5		20
Toluene	92		90		70-130	2		20
Ethylbenzene	92		92		70-130	0		20
Chloromethane	110		94		64-130	16		20
Bromomethane	52		48		39-139	8		20

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by GC/MS - Westborough Lab Associated sample(s): 01-02 Batch: WG1766310-3 WG1766310-4								
Vinyl chloride	100		94		55-140	6		20
Chloroethane	**140**	Q	120		55-138	15		20
1,1-Dichloroethene	96		86		61-145	11		20
trans-1,2-Dichloroethene	96		89		70-130	8		20
Trichloroethene	90		90		70-130	0		20
1,2-Dichlorobenzene	94		89		70-130	5		20
1,3-Dichlorobenzene	91		89		70-130	2		20
1,4-Dichlorobenzene	89		88		70-130	1		20
Methyl tert butyl ether	96		84		63-130	13		20
p/m-Xylene	85		90		70-130	6		20
o-Xylene	85		90		70-130	6		20
cis-1,2-Dichloroethene	100		99		70-130	1		20
Dibromomethane	94		94		70-130	0		20
1,2,3-Trichloropropane	83		83		64-130	0		20
Acrylonitrile	120		110		70-130	9		20
Styrene	90		90		70-130	0		20
Dichlorodifluoromethane	72		62		36-147	15		20
Acetone	89		86		58-148	3		20
Carbon disulfide	100		88		51-130	13		20
2-Butanone	85		82		63-138	4		20
Vinyl acetate	130		130		70-130	0		20
4-Methyl-2-pentanone	85		92		59-130	8		20
2-Hexanone	78		84		57-130	7		20

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461:1

Lab Number: L2318715

Report Date: 04/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by GC/MS - Westborough Lab Associated sample(s): 01-02 Batch: WG1766310-3 WG1766310-4								
Bromochloromethane	93		97		70-130	4		20
2,2-Dichloropropane	86		84		63-133	2		20
1,2-Dibromoethane	83		86		70-130	4		20
1,3-Dichloropropane	87		90		70-130	3		20
1,1,1,2-Tetrachloroethane	82		81		64-130	1		20
Bromobenzene	90		86		70-130	5		20
n-Butylbenzene	96		93		53-136	3		20
sec-Butylbenzene	86		83		70-130	4		20
tert-Butylbenzene	89		88		70-130	1		20
o-Chlorotoluene	96		93		70-130	3		20
p-Chlorotoluene	94		90		70-130	4		20
1,2-Dibromo-3-chloropropane	71		70		41-144	1		20
Hexachlorobutadiene	80		80		63-130	0		20
Isopropylbenzene	86		82		70-130	5		20
p-Isopropyltoluene	90		89		70-130	1		20
Naphthalene	90		87		70-130	3		20
n-Propylbenzene	94		90		69-130	4		20
1,2,3-Trichlorobenzene	90		85		70-130	6		20
1,2,4-Trichlorobenzene	86		85		70-130	1		20
1,3,5-Trimethylbenzene	89		87		64-130	2		20
1,2,4-Trimethylbenzene	91		89		70-130	2		20
1,4-Dioxane	104		106		56-162	2		20
p-Diethylbenzene	92		90		70-130	2		20

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461:1

Lab Number: L2318715

Report Date: 04/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by GC/MS - Westborough Lab Associated sample(s): 01-02 Batch: WG1766310-3 WG1766310-4								
p-Ethyltoluene	92		88		70-130	4		20
1,2,4,5-Tetramethylbenzene	97		94		70-130	3		20
Ethyl ether	100		92		59-134	8		20
trans-1,4-Dichloro-2-butene	84		87		70-130	4		20

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
1,2-Dichloroethane-d4	113		98		70-130
Toluene-d8	102		101		70-130
4-Bromofluorobenzene	95		89		70-130
Dibromofluoromethane	102		105		70-130

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by EPA 5035 Low - Westborough Lab Associated sample(s): 03-05 Batch: WG1766413-3 WG1766413-4								
Methylene chloride	95		96		70-130	1		30
1,1-Dichloroethane	98		97		70-130	1		30
Chloroform	103		101		70-130	2		30
Carbon tetrachloride	91		92		70-130	1		30
1,2-Dichloropropane	100		99		70-130	1		30
Dibromochloromethane	99		100		70-130	1		30
1,1,2-Trichloroethane	94		95		70-130	1		30
Tetrachloroethene	93		95		70-130	2		30
Chlorobenzene	93		96		70-130	3		30
Trichlorofluoromethane	102		101		70-139	1		30
1,2-Dichloroethane	106		103		70-130	3		30
1,1,1-Trichloroethane	100		100		70-130	0		30
Bromodichloromethane	105		105		70-130	0		30
trans-1,3-Dichloropropene	92		93		70-130	1		30
cis-1,3-Dichloropropene	106		105		70-130	1		30
1,1-Dichloropropene	94		94		70-130	0		30
Bromoform	90		90		70-130	0		30
1,1,2,2-Tetrachloroethane	83		81		70-130	2		30
Benzene	99		100		70-130	1		30
Toluene	83		87		70-130	5		30
Ethylbenzene	85		87		70-130	2		30
Chloromethane	99		99		52-130	0		30
Bromomethane	99		100		57-147	1		30

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461:1

Lab Number: L2318715

Report Date: 04/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by EPA 5035 Low - Westborough Lab Associated sample(s): 03-05 Batch: WG1766413-3 WG1766413-4								
Vinyl chloride	96		96		67-130	0		30
Chloroethane	96		97		50-151	1		30
1,1-Dichloroethene	96		94		65-135	2		30
trans-1,2-Dichloroethene	98		101		70-130	3		30
Trichloroethene	100		101		70-130	1		30
1,2-Dichlorobenzene	93		94		70-130	1		30
1,3-Dichlorobenzene	90		92		70-130	2		30
1,4-Dichlorobenzene	91		92		70-130	1		30
Methyl tert butyl ether	115		110		66-130	4		30
p/m-Xylene	89		92		70-130	3		30
o-Xylene	92		95		70-130	3		30
cis-1,2-Dichloroethene	103		103		70-130	0		30
Dibromomethane	111		106		70-130	5		30
Styrene	93		95		70-130	2		30
Dichlorodifluoromethane	92		93		30-146	1		30
Acetone	112		90		54-140	22		30
Carbon disulfide	102		101		59-130	1		30
2-Butanone	82		72		70-130	13		30
Vinyl acetate	85		81		70-130	5		30
4-Methyl-2-pentanone	82		76		70-130	8		30
1,2,3-Trichloropropane	83		82		68-130	1		30
2-Hexanone	74		70		70-130	6		30
Bromochloromethane	118		115		70-130	3		30

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by EPA 5035 Low - Westborough Lab Associated sample(s): 03-05 Batch: WG1766413-3 WG1766413-4								
2,2-Dichloropropane	92		92		70-130	0		30
1,2-Dibromoethane	100		97		70-130	3		30
1,3-Dichloropropane	94		94		69-130	0		30
1,1,1,2-Tetrachloroethane	98		102		70-130	4		30
Bromobenzene	91		95		70-130	4		30
n-Butylbenzene	79		80		70-130	1		30
sec-Butylbenzene	79		81		70-130	3		30
tert-Butylbenzene	80		84		70-130	5		30
o-Chlorotoluene	98		101		70-130	3		30
p-Chlorotoluene	81		84		70-130	4		30
1,2-Dibromo-3-chloropropane	82		74		68-130	10		30
Hexachlorobutadiene	84		82		67-130	2		30
Isopropylbenzene	80		83		70-130	4		30
p-Isopropyltoluene	83		84		70-130	1		30
Naphthalene	89		85		70-130	5		30
Acrylonitrile	85		73		70-130	15		30
n-Propylbenzene	79		82		70-130	4		30
1,2,3-Trichlorobenzene	97		95		70-130	2		30
1,2,4-Trichlorobenzene	96		95		70-130	1		30
1,3,5-Trimethylbenzene	84		87		70-130	4		30
1,2,4-Trimethylbenzene	84		87		70-130	4		30
1,4-Dioxane	90		77		65-136	16		30
p-Diethylbenzene	82		84		70-130	2		30

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by EPA 5035 Low - Westborough Lab Associated sample(s): 03-05 Batch: WG1766413-3 WG1766413-4								
p-Ethyltoluene	83		86		70-130	4		30
1,2,4,5-Tetramethylbenzene	89		90		70-130	1		30
Ethyl ether	108		110		67-130	2		30
trans-1,4-Dichloro-2-butene	76		71		70-130	7		30

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
1,2-Dichloroethane-d4	106		100		70-130
Toluene-d8	92		94		70-130
4-Bromofluorobenzene	89		90		70-130
Dibromofluoromethane	111		109		70-130

SEMIVOLATILES

Project Name: 100 MAIN ST.
Project Number: 12461:1
Lab Number: L2318715
Report Date: 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-01
Client ID: GW-8
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 08:15
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E
Analytical Date: 04/12/23 09:32
Analyst: JG

Extraction Method: EPA 3510C
Extraction Date: 04/11/23 23:34

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
1,2,4-Trichlorobenzene	ND		ug/l	5.0	0.50	1
Bis(2-chloroethyl)ether	ND		ug/l	2.0	0.50	1
1,2-Dichlorobenzene	ND		ug/l	2.0	0.45	1
1,3-Dichlorobenzene	ND		ug/l	2.0	0.40	1
1,4-Dichlorobenzene	ND		ug/l	2.0	0.43	1
3,3'-Dichlorobenzidine	ND		ug/l	5.0	1.6	1
2,4-Dinitrotoluene	ND		ug/l	5.0	1.2	1
2,6-Dinitrotoluene	ND		ug/l	5.0	0.93	1
4-Chlorophenyl phenyl ether	ND		ug/l	2.0	0.49	1
4-Bromophenyl phenyl ether	ND		ug/l	2.0	0.38	1
Bis(2-chloroisopropyl)ether	ND		ug/l	2.0	0.53	1
Bis(2-chloroethoxy)methane	ND		ug/l	5.0	0.50	1
Hexachlorocyclopentadiene	ND		ug/l	20	0.69	1
Isophorone	ND		ug/l	5.0	1.2	1
Nitrobenzene	ND		ug/l	2.0	0.77	1
NDPA/DPA	ND		ug/l	2.0	0.42	1
n-Nitrosodi-n-propylamine	ND		ug/l	5.0	0.64	1
Bis(2-ethylhexyl)phthalate	ND		ug/l	3.0	1.5	1
Butyl benzyl phthalate	ND		ug/l	5.0	1.2	1
Di-n-butylphthalate	ND		ug/l	5.0	0.39	1
Di-n-octylphthalate	ND		ug/l	5.0	1.3	1
Diethyl phthalate	ND		ug/l	5.0	0.38	1
Dimethyl phthalate	ND		ug/l	5.0	1.8	1
Biphenyl	ND		ug/l	2.0	0.46	1
4-Chloroaniline	ND		ug/l	5.0	1.1	1
2-Nitroaniline	ND		ug/l	5.0	0.50	1
3-Nitroaniline	ND		ug/l	5.0	0.81	1
4-Nitroaniline	ND		ug/l	5.0	0.80	1

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-01 Date Collected: 04/07/23 08:15

Client ID: GW-8 Date Received: 04/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Dibenzofuran	ND		ug/l	2.0	0.50	1
1,2,4,5-Tetrachlorobenzene	ND		ug/l	10	0.44	1
Acetophenone	1.5	J	ug/l	5.0	0.53	1
2,4,6-Trichlorophenol	ND		ug/l	5.0	0.61	1
p-Chloro-m-cresol	ND		ug/l	2.0	0.35	1
2-Chlorophenol	ND		ug/l	2.0	0.48	1
2,4-Dichlorophenol	ND		ug/l	5.0	0.41	1
2,4-Dimethylphenol	ND		ug/l	5.0	1.8	1
2-Nitrophenol	ND		ug/l	10	0.85	1
4-Nitrophenol	ND		ug/l	10	0.67	1
2,4-Dinitrophenol	ND		ug/l	20	6.6	1
4,6-Dinitro-o-cresol	ND		ug/l	10	1.8	1
Phenol	0.72	J	ug/l	5.0	0.57	1
2-Methylphenol	ND		ug/l	5.0	0.49	1
3-Methylphenol/4-Methylphenol	ND		ug/l	5.0	0.48	1
2,4,5-Trichlorophenol	ND		ug/l	5.0	0.77	1
Benzoic Acid	88.		ug/l	50	2.6	1
Benzyl Alcohol	0.69	J	ug/l	2.0	0.59	1
Carbazole	ND		ug/l	2.0	0.49	1

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-01 Date Collected: 04/07/23 08:15

Client ID: GW-8 Date Received: 04/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Tentatively Identified Compounds						
Total TIC Compounds	190	J	ug/l			1
Unknown	7.31	J	ug/l			1
Unknown	11.8	J	ug/l			1
Unknown	8.22	JB	ug/l			1
Unknown	6.76	JB	ug/l			1
Unknown	6.25	J	ug/l			1
Unknown	13.6	J	ug/l			1
Unknown	4.54	J	ug/l			1
Unknown	17.8	J	ug/l			1
Unknown Alkene	14.2	J	ug/l			1
Unknown Organic Acid	4.18	J	ug/l			1
Unknown Organic Acid	6.14	J	ug/l			1
Unknown Organic Acid	4.07	J	ug/l			1
Unknown Organic Acid	36.5	JB	ug/l			1
Unknown Organic Acid	48.8	JB	ug/l			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	60		21-120
Phenol-d6	47		10-120
Nitrobenzene-d5	75		23-120
2-Fluorobiphenyl	69		15-120
2,4,6-Tribromophenol	108		10-120
4-Terphenyl-d14	80		41-149

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-01
Client ID: GW-8
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 08:15
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E-SIM
Analytical Date: 04/12/23 16:35
Analyst: DV

Extraction Method: EPA 3510C
Extraction Date: 04/11/23 23:37

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS-SIM - Westborough Lab						
Acenaphthene	0.06	J	ug/l	0.10	0.01	1
2-Chloronaphthalene	ND		ug/l	0.20	0.02	1
Fluoranthene	0.03	J	ug/l	0.10	0.02	1
Hexachlorobutadiene	ND		ug/l	0.50	0.05	1
Naphthalene	0.05	J	ug/l	0.10	0.05	1
Benzo(a)anthracene	ND		ug/l	0.10	0.02	1
Benzo(a)pyrene	ND		ug/l	0.10	0.02	1
Benzo(b)fluoranthene	ND		ug/l	0.10	0.01	1
Benzo(k)fluoranthene	ND		ug/l	0.10	0.01	1
Chrysene	ND		ug/l	0.10	0.01	1
Acenaphthylene	ND		ug/l	0.10	0.01	1
Anthracene	0.06	J	ug/l	0.10	0.01	1
Benzo(ghi)perylene	ND		ug/l	0.10	0.01	1
Fluorene	ND		ug/l	0.10	0.01	1
Phenanthrene	0.04	J	ug/l	0.10	0.02	1
Dibenzo(a,h)anthracene	ND		ug/l	0.10	0.01	1
Indeno(1,2,3-cd)pyrene	ND		ug/l	0.10	0.01	1
Pyrene	0.03	J	ug/l	0.10	0.02	1
2-Methylnaphthalene	0.03	J	ug/l	0.10	0.02	1
Pentachlorophenol	0.16	J	ug/l	0.80	0.01	1
Hexachlorobenzene	ND		ug/l	0.80	0.01	1
Hexachloroethane	ND		ug/l	0.80	0.06	1

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-01 Date Collected: 04/07/23 08:15

Client ID: GW-8 Date Received: 04/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS-SIM - Westborough Lab						

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	59		21-120
Phenol-d6	51		10-120
Nitrobenzene-d5	89		23-120
2-Fluorobiphenyl	78		15-120
2,4,6-Tribromophenol	117		10-120
4-Terphenyl-d14	89		41-149

Project Name: 100 MAIN ST.
Lab Number: L2318715
Project Number: 12461:1
Report Date: 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-01
Client ID: GW-8
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 08:15
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E-SIM
Analytical Date: 04/14/23 23:48
Analyst: TPR

Extraction Method: EPA 3510C
Extraction Date: 04/13/23 17:30

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
1,4 Dioxane by 8270E-SIM - Mansfield Lab						
1,4-Dioxane	0.147		ug/l	0.134	0.0303	1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,4-Dioxane-d8	53		15-110

Project Name: 100 MAIN ST.
Lab Number: L2318715
Project Number: 12461:1
Report Date: 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-01
Client ID: GW-8
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 08:15
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 144,1633
Analytical Date: 04/21/23 18:54
Analyst: JW

Extraction Method: EPA 1633
Extraction Date: 04/20/23 11:40

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Perfluorinated Alkyl Acids by EPA 1633 - Mansfield Lab						
Perfluorobutanoic Acid (PFBA)	4.00	J	ng/l	6.16	0.986	1
Perfluoropentanoic Acid (PFPeA)	3.54		ng/l	3.08	0.824	1
Perfluorobutanesulfonic Acid (PFBS)	3.70		ng/l	1.54	0.516	1
Perfluorohexanoic Acid (PFHxA)	4.00		ng/l	1.54	0.454	1
Perfluoroheptanoic Acid (PFHpA)	1.54		ng/l	1.54	0.308	1
Perfluorohexanesulfonic Acid (PFHxS)	3.93		ng/l	1.54	0.370	1
Perfluorooctanoic Acid (PFOA)	7.40		ng/l	1.54	0.670	1
1H,1H,2H,2H-Perfluorooctanesulfonic Acid (6:2FTS)	ND		ng/l	6.16	2.08	1
Perfluoroheptanesulfonic Acid (PFHpS)	ND		ng/l	1.54	0.416	1
Perfluorononanoic Acid (PFNA)	ND		ng/l	1.54	0.485	1
Perfluorooctanesulfonic Acid (PFOS)	11.6		ng/l	1.54	0.701	1
Perfluorodecanoic Acid (PFDA)	ND		ng/l	1.54	0.624	1
1H,1H,2H,2H-Perfluorodecanesulfonic Acid (8:2FTS)	ND		ng/l	6.16	2.40	1
N-Methyl Perfluorooctanesulfonamidoacetic Acid (NMeFOSAA)	ND		ng/l	1.54	0.840	1
Perfluoroundecanoic Acid (PFUnA)	ND		ng/l	1.54	0.670	1
Perfluorodecanesulfonic Acid (PFDS)	ND		ng/l	1.54	0.354	1
Perfluorooctanesulfonamide (PFOSA)	ND		ng/l	1.54	0.416	1
N-Ethyl Perfluorooctanesulfonamidoacetic Acid (NEtFOSAA)	2.46	F	ng/l	1.54	0.832	1
Perfluorododecanoic Acid (PFDoA)	ND		ng/l	1.54	0.709	1
Perfluorotridecanoic Acid (PFTrDA)	ND		ng/l	1.54	0.578	1
Perfluorotetradecanoic Acid (PFTeDA)	ND		ng/l	1.54	0.408	1
PFOA/PFOS, Total	19.0		ng/l	1.54	0.670	1

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-01 Date Collected: 04/07/23 08:15

Client ID: GW-8 Date Received: 04/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Perfluorinated Alkyl Acids by EPA 1633 - Mansfield Lab						

Surrogate	% Recovery	Qualifier	Acceptance Criteria
Perfluoro-n-[13C4]Butanoic Acid (13C4-PFBA)	98		20-150
Perfluoro-n-[13C5]Pentanoic Acid (13C5-PFPeA)	86		20-150
Perfluoro-1-[2,3,4-13C3]Butanesulfonic Acid (13C3-PFBS)	94		20-150
Perfluoro-n-[1,2,3,4,6-13C5]Hexanoic Acid (13C5-PFHxA)	97		20-150
Perfluoro-n-[1,2,3,4-13C4]Heptanoic Acid (13C4-PFHpA)	97		20-150
Perfluoro-1-[1,2,3-13C3]Hexanesulfonic Acid (13C3-PFHxS)	97		20-150
Perfluoro-n-[13C8]Octanoic Acid (13C8-PFOA)	91		20-150
1H,1H,2H,2H-Perfluoro-1-[1,2-13C2]Octanesulfonic Acid (13C2-6:2FTS)	149		20-150
Perfluoro-n-[13C9]Nonanoic Acid (13C9-PFNA)	103		20-150
Perfluoro-1-[13C8]Octanesulfonic Acid (13C8-PFOS)	100		20-150
Perfluoro-n-[1,2,3,4,5,6-13C6]Decanoic Acid (13C6-PFDA)	100		20-150
1H,1H,2H,2H-Perfluoro-1-[1,2-13C2]Decanesulfonic Acid (13C2-8:2FTS)	149		20-150
N-Methyl-d3-perfluoro-1-octanesulfonamidoacetic Acid (D3-NMeFOSAA)	80		20-150
Perfluoro-n-[1,2,3,4,5,6,7-13C7]Undecanoic Acid (13C7-PFUnA)	81		20-150
Perfluoro-1-[13C8]Octanesulfonamide (13C8-PFOSA)	53		20-150
N-Ethyl-d5-perfluoro-1-octanesulfonamidoacetic Acid (D5-NEtFOSAA)	74		20-150
Perfluoro-n-[1,2-13C2]Dodecanoic Acid (13C2-PFDoA)	69		20-150
Perfluoro-n-[1,2-13C2]Tetradecanoic Acid (13C2-PFTeDA)	46		20-150

Project Name: 100 MAIN ST.
Project Number: 12461:1
Lab Number: L2318715
Report Date: 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-02
Client ID: GW-9
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 13:45
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E
Analytical Date: 04/12/23 09:57
Analyst: JG

Extraction Method: EPA 3510C
Extraction Date: 04/11/23 23:34

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
1,2,4-Trichlorobenzene	ND		ug/l	5.0	0.50	1
Bis(2-chloroethyl)ether	ND		ug/l	2.0	0.50	1
1,2-Dichlorobenzene	ND		ug/l	2.0	0.45	1
1,3-Dichlorobenzene	ND		ug/l	2.0	0.40	1
1,4-Dichlorobenzene	ND		ug/l	2.0	0.43	1
3,3'-Dichlorobenzidine	ND		ug/l	5.0	1.6	1
2,4-Dinitrotoluene	ND		ug/l	5.0	1.2	1
2,6-Dinitrotoluene	ND		ug/l	5.0	0.93	1
4-Chlorophenyl phenyl ether	ND		ug/l	2.0	0.49	1
4-Bromophenyl phenyl ether	ND		ug/l	2.0	0.38	1
Bis(2-chloroisopropyl)ether	ND		ug/l	2.0	0.53	1
Bis(2-chloroethoxy)methane	ND		ug/l	5.0	0.50	1
Hexachlorocyclopentadiene	ND		ug/l	20	0.69	1
Isophorone	ND		ug/l	5.0	1.2	1
Nitrobenzene	ND		ug/l	2.0	0.77	1
NDPA/DPA	ND		ug/l	2.0	0.42	1
n-Nitrosodi-n-propylamine	ND		ug/l	5.0	0.64	1
Bis(2-ethylhexyl)phthalate	ND		ug/l	3.0	1.5	1
Butyl benzyl phthalate	ND		ug/l	5.0	1.2	1
Di-n-butylphthalate	ND		ug/l	5.0	0.39	1
Di-n-octylphthalate	ND		ug/l	5.0	1.3	1
Diethyl phthalate	ND		ug/l	5.0	0.38	1
Dimethyl phthalate	ND		ug/l	5.0	1.8	1
Biphenyl	ND		ug/l	2.0	0.46	1
4-Chloroaniline	ND		ug/l	5.0	1.1	1
2-Nitroaniline	ND		ug/l	5.0	0.50	1
3-Nitroaniline	ND		ug/l	5.0	0.81	1
4-Nitroaniline	ND		ug/l	5.0	0.80	1

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-02 Date Collected: 04/07/23 13:45

Client ID: GW-9 Date Received: 04/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Dibenzofuran	0.89	J	ug/l	2.0	0.50	1
1,2,4,5-Tetrachlorobenzene	ND		ug/l	10	0.44	1
Acetophenone	0.93	J	ug/l	5.0	0.53	1
2,4,6-Trichlorophenol	ND		ug/l	5.0	0.61	1
p-Chloro-m-cresol	ND		ug/l	2.0	0.35	1
2-Chlorophenol	ND		ug/l	2.0	0.48	1
2,4-Dichlorophenol	ND		ug/l	5.0	0.41	1
2,4-Dimethylphenol	ND		ug/l	5.0	1.8	1
2-Nitrophenol	ND		ug/l	10	0.85	1
4-Nitrophenol	ND		ug/l	10	0.67	1
2,4-Dinitrophenol	ND		ug/l	20	6.6	1
4,6-Dinitro-o-cresol	ND		ug/l	10	1.8	1
Phenol	1.2	J	ug/l	5.0	0.57	1
2-Methylphenol	ND		ug/l	5.0	0.49	1
3-Methylphenol/4-Methylphenol	ND		ug/l	5.0	0.48	1
2,4,5-Trichlorophenol	ND		ug/l	5.0	0.77	1
Benzoic Acid	150		ug/l	50	2.6	1
Benzyl Alcohol	2.1		ug/l	2.0	0.59	1
Carbazole	1.5	J	ug/l	2.0	0.49	1

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-02 Date Collected: 04/07/23 13:45

Client ID: GW-9 Date Received: 04/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Tentatively Identified Compounds						
Total TIC Compounds	194	J	ug/l			1
Unknown	35.1	J	ug/l			1
Unknown	26.1	J	ug/l			1
Unknown	9.49	J	ug/l			1
Unknown	19.5	J	ug/l			1
Unknown	8.25	JB	ug/l			1
Unknown	7.02	JB	ug/l			1
Unknown	11.0	J	ug/l			1
Unknown Naphthalene	8.76	J	ug/l			1
Unknown Naphthalene	10.2	J	ug/l			1
Unknown Organic Acid	5.20	J	ug/l			1
Unknown Organic Acid	15.4	JB	ug/l			1
Unknown Organic Acid	12.2	JB	ug/l			1
Unknown PAH	10.6	J	ug/l			1
Unknown PAH	6.98	J	ug/l			1
Unknown PAH	7.89	J	ug/l			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	64		21-120
Phenol-d6	52		10-120
Nitrobenzene-d5	79		23-120
2-Fluorobiphenyl	73		15-120
2,4,6-Tribromophenol	**121**	Q	10-120
4-Terphenyl-d14	80		41-149

Project Name: 100 MAIN ST.
Lab Number: L2318715
Project Number: 12461:1
Report Date: 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-02
Client ID: GW-9
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 13:45
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 144,1633
Analytical Date: 04/21/23 19:07
Analyst: JW

Extraction Method: EPA 1633
Extraction Date: 04/20/23 11:40

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Perfluorinated Alkyl Acids by EPA 1633 - Mansfield Lab						
Perfluorobutanoic Acid (PFBA)	13.4		ng/l	6.38	1.02	1
Perfluoropentanoic Acid (PFPeA)	37.4		ng/l	3.19	0.853	1
Perfluorobutanesulfonic Acid (PFBS)	4.46		ng/l	1.59	0.534	1
Perfluorohexanoic Acid (PFHxA)	40.8		ng/l	1.59	0.470	1
Perfluoroheptanoic Acid (PFHpA)	9.32		ng/l	1.59	0.319	1
Perfluorohexanesulfonic Acid (PFHxS)	9.80		ng/l	1.59	0.382	1
Perfluorooctanoic Acid (PFOA)	29.0		ng/l	1.59	0.693	1
1H,1H,2H,2H-Perfluorooctanesulfonic Acid (6:2FTS)	4.30	J	ng/l	6.38	2.15	1
Perfluoroheptanesulfonic Acid (PFHpS)	0.638	J	ng/l	1.59	0.430	1
Perfluorononanoic Acid (PFNA)	2.07		ng/l	1.59	0.502	1
Perfluorooctanesulfonic Acid (PFOS)	24.1		ng/l	1.59	0.725	1
Perfluorodecanoic Acid (PFDA)	0.717	JF	ng/l	1.59	0.645	1
1H,1H,2H,2H-Perfluorodecanesulfonic Acid (8:2FTS)	ND		ng/l	6.38	2.48	1
N-Methyl Perfluorooctanesulfonamidoacetic Acid (NMeFOSAA)	ND		ng/l	1.59	0.869	1
Perfluoroundecanoic Acid (PFUnA)	ND		ng/l	1.59	0.693	1
Perfluorodecanesulfonic Acid (PFDS)	0.558	J	ng/l	1.59	0.366	1
Perfluorooctanesulfonamide (PFOSA)	0.638	J	ng/l	1.59	0.430	1
N-Ethyl Perfluorooctanesulfonamidoacetic Acid (NEtFOSAA)	7.89		ng/l	1.59	0.861	1
Perfluorododecanoic Acid (PFDoA)	ND		ng/l	1.59	0.733	1
Perfluorotridecanoic Acid (PFTrDA)	ND		ng/l	1.59	0.598	1
Perfluorotetradecanoic Acid (PFTeDA)	ND		ng/l	1.59	0.422	1
PFOA/PFOS, Total	53.1		ng/l	1.59	0.693	1

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-02 Date Collected: 04/07/23 13:45

Client ID: GW-9 Date Received: 04/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Perfluorinated Alkyl Acids by EPA 1633 - Mansfield Lab						

Surrogate	% Recovery	Qualifier	Acceptance Criteria
Perfluoro-n-[13C4]Butanoic Acid (13C4-PFBA)	104		20-150
Perfluoro-n-[13C5]Pentanoic Acid (13C5-PFPeA)	104		20-150
Perfluoro-1-[2,3,4-13C3]Butanesulfonic Acid (13C3-PFBS)	106		20-150
Perfluoro-n-[1,2,3,4,6-13C5]Hexanoic Acid (13C5-PFHxA)	110		20-150
Perfluoro-n-[1,2,3,4-13C4]Heptanoic Acid (13C4-PFHpA)	104		20-150
Perfluoro-1-[1,2,3-13C3]Hexanesulfonic Acid (13C3-PFHxS)	103		20-150
Perfluoro-n-[13C8]Octanoic Acid (13C8-PFOA)	102		20-150
1H,1H,2H,2H-Perfluoro-1-[1,2-13C2]Octanesulfonic Acid (13C2-6:2FTS)	111		20-150
Perfluoro-n-[13C9]Nonanoic Acid (13C9-PFNA)	97		20-150
Perfluoro-1-[13C8]Octanesulfonic Acid (13C8-PFOS)	99		20-150
Perfluoro-n-[1,2,3,4,5,6-13C6]Decanoic Acid (13C6-PFDA)	102		20-150
1H,1H,2H,2H-Perfluoro-1-[1,2-13C2]Decanesulfonic Acid (13C2-8:2FTS)	122		20-150
N-Methyl-d3-perfluoro-1-octanesulfonamidoacetic Acid (D3-NMeFOSAA)	79		20-150
Perfluoro-n-[1,2,3,4,5,6,7-13C7]Undecanoic Acid (13C7-PFUnA)	92		20-150
Perfluoro-1-[13C8]Octanesulfonamide (13C8-PFOSA)	74		20-150
N-Ethyl-d5-perfluoro-1-octanesulfonamidoacetic Acid (D5-NEtFOSAA)	75		20-150
Perfluoro-n-[1,2-13C2]Dodecanoic Acid (13C2-PFDoA)	67		20-150
Perfluoro-n-[1,2-13C2]Tetradecanoic Acid (13C2-PFTeDA)	58		20-150

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-02 D
Client ID: GW-9
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 13:45
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E-SIM
Analytical Date: 04/12/23 18:29
Analyst: DV

Extraction Method: EPA 3510C
Extraction Date: 04/11/23 23:37

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS-SIM - Westborough Lab						
Acenaphthene	1.8		ug/l	0.50	0.07	5
2-Chloronaphthalene	ND		ug/l	1.0	0.09	5
Fluoranthene	14		ug/l	0.50	0.10	5
Hexachlorobutadiene	ND		ug/l	2.5	0.23	5
Naphthalene	1.1		ug/l	0.50	0.24	5
Benzo(a)anthracene	6.1		ug/l	0.50	0.10	5
Benzo(a)pyrene	6.4		ug/l	0.50	0.08	5
Benzo(b)fluoranthene	7.2		ug/l	0.50	0.06	5
Benzo(k)fluoranthene	2.4		ug/l	0.50	0.04	5
Chrysene	5.5		ug/l	0.50	0.06	5
Acenaphthylene	0.20	J	ug/l	0.50	0.06	5
Anthracene	2.9		ug/l	0.50	0.07	5
Benzo(ghi)perylene	3.6		ug/l	0.50	0.07	5
Fluorene	2.0		ug/l	0.50	0.07	5
Phenanthrene	11		ug/l	0.50	0.12	5
Dibenzo(a,h)anthracene	0.93		ug/l	0.50	0.06	5
Indeno(1,2,3-cd)pyrene	3.7		ug/l	0.50	0.06	5
Pyrene	12		ug/l	0.50	0.10	5
2-Methylnaphthalene	3.4		ug/l	0.50	0.11	5
Pentachlorophenol	ND		ug/l	4.0	0.07	5
Hexachlorobenzene	ND		ug/l	4.0	0.05	5
Hexachloroethane	ND		ug/l	4.0	0.32	5

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-02 D
Client ID: GW-9
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 13:45
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS-SIM - Westborough Lab						

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	69		21-120
Phenol-d6	61		10-120
Nitrobenzene-d5	97		23-120
2-Fluorobiphenyl	92		15-120
2,4,6-Tribromophenol	**131**	Q	10-120
4-Terphenyl-d14	95		41-149

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-02 D
Client ID: GW-9
Sample Location: WHITE PLAINS, NY

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E-SIM
Analytical Date: 04/15/23 00:11
Analyst: TPR

Date Collected: 04/07/23 13:45
Date Received: 04/07/23
Field Prep: Not Specified

Extraction Method: EPA 3510C
Extraction Date: 04/13/23 17:30

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
1,4 Dioxane by 8270E-SIM - Mansfield Lab						
1,4-Dioxane	ND		ug/l	6.70	1.51	50

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,4-Dioxane-d8	56		15-110

Project Name: 100 MAIN ST.
Project Number: 12461:1
Lab Number: L2318715
Report Date: 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-03
Client ID: SB-8G (1.5-2)
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 10:45
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8270E
Analytical Date: 04/14/23 05:53
Analyst: IM
Percent Solids: 88%

Extraction Method: EPA 3546
Extraction Date: 04/13/23 00:43

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Acenaphthene	ND		ug/kg	150	19.	1
1,2,4-Trichlorobenzene	ND		ug/kg	180	21.	1
Hexachlorobenzene	ND		ug/kg	110	21.	1
Bis(2-chloroethyl)ether	ND		ug/kg	160	25.	1
2-Chloronaphthalene	ND		ug/kg	180	18.	1
1,2-Dichlorobenzene	ND		ug/kg	180	33.	1
1,3-Dichlorobenzene	ND		ug/kg	180	32.	1
1,4-Dichlorobenzene	ND		ug/kg	180	32.	1
3,3'-Dichlorobenzidine	ND		ug/kg	180	49.	1
2,4-Dinitrotoluene	ND		ug/kg	180	37.	1
2,6-Dinitrotoluene	ND		ug/kg	180	32.	1
Fluoranthene	25	J	ug/kg	110	21.	1
4-Chlorophenyl phenyl ether	ND		ug/kg	180	20.	1
4-Bromophenyl phenyl ether	ND		ug/kg	180	28.	1
Bis(2-chloroisopropyl)ether	ND		ug/kg	220	31.	1
Bis(2-chloroethoxy)methane	ND		ug/kg	200	18.	1
Hexachlorobutadiene	ND		ug/kg	180	27.	1
Hexachlorocyclopentadiene	ND		ug/kg	530	170	1
Hexachloroethane	ND		ug/kg	150	30.	1
Isophorone	ND		ug/kg	160	24.	1
Naphthalene	ND		ug/kg	180	22.	1
Nitrobenzene	ND		ug/kg	160	27.	1
NDPA/DPA	ND		ug/kg	150	21.	1
n-Nitrosodi-n-propylamine	ND		ug/kg	180	28.	1
Bis(2-ethylhexyl)phthalate	ND		ug/kg	180	64.	1
Butyl benzyl phthalate	ND		ug/kg	180	46.	1
Di-n-butylphthalate	ND		ug/kg	180	35.	1
Di-n-octylphthalate	ND		ug/kg	180	63.	1

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-03 Date Collected: 04/07/23 10:45

Client ID: SB-8G (1.5-2) Date Received: 04/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Diethyl phthalate	ND		ug/kg	180	17.	1
Dimethyl phthalate	ND		ug/kg	180	39.	1
Benzo(a)anthracene	ND		ug/kg	110	21.	1
Benzo(a)pyrene	ND		ug/kg	150	45.	1
Benzo(b)fluoranthene	ND		ug/kg	110	31.	1
Benzo(k)fluoranthene	ND		ug/kg	110	29.	1
Chrysene	ND		ug/kg	110	19.	1
Acenaphthylene	ND		ug/kg	150	28.	1
Anthracene	ND		ug/kg	110	36.	1
Benzo(ghi)perylene	ND		ug/kg	150	22.	1
Fluorene	ND		ug/kg	180	18.	1
Phenanthrene	ND		ug/kg	110	22.	1
Dibenzo(a,h)anthracene	ND		ug/kg	110	21.	1
Indeno(1,2,3-cd)pyrene	ND		ug/kg	150	26.	1
Pyrene	22	J	ug/kg	110	18.	1
Biphenyl	ND		ug/kg	420	24.	1
4-Chloroaniline	ND		ug/kg	180	34.	1
2-Nitroaniline	ND		ug/kg	180	36.	1
3-Nitroaniline	ND		ug/kg	180	35.	1
4-Nitroaniline	ND		ug/kg	180	76.	1
Dibenzofuran	ND		ug/kg	180	17.	1
2-Methylnaphthalene	ND		ug/kg	220	22.	1
1,2,4,5-Tetrachlorobenzene	ND		ug/kg	180	19.	1
Acetophenone	ND		ug/kg	180	23.	1
2,4,6-Trichlorophenol	ND		ug/kg	110	35.	1
p-Chloro-m-cresol	ND		ug/kg	180	27.	1
2-Chlorophenol	ND		ug/kg	180	22.	1
2,4-Dichlorophenol	ND		ug/kg	160	30.	1
2,4-Dimethylphenol	ND		ug/kg	180	61.	1
2-Nitrophenol	ND		ug/kg	400	69.	1
4-Nitrophenol	ND		ug/kg	260	75.	1
2,4-Dinitrophenol	ND		ug/kg	880	86.	1
4,6-Dinitro-o-cresol	ND		ug/kg	480	88.	1
Pentachlorophenol	ND		ug/kg	150	40.	1
Phenol	ND		ug/kg	180	28.	1
2-Methylphenol	ND		ug/kg	180	28.	1
3-Methylphenol/4-Methylphenol	ND		ug/kg	260	29.	1

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-03 Date Collected: 04/07/23 10:45

Client ID: SB-8G (1.5-2) Date Received: 04/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
2,4,5-Trichlorophenol	ND		ug/kg	180	35.	1
Benzoic Acid	ND		ug/kg	600	190	1
Benzyl Alcohol	ND		ug/kg	180	56.	1
Carbazole	ND		ug/kg	180	18.	1
1,4-Dioxane	ND		ug/kg	28	8.5	1
Tentatively Identified Compounds						
Total TIC Compounds	1590	J	ug/kg			1
Unknown	660	J	ug/kg			1
Unknown	932	J	ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	72		25-120
Phenol-d6	81		10-120
Nitrobenzene-d5	80		23-120
2-Fluorobiphenyl	58		30-120
2,4,6-Tribromophenol	51		10-136
4-Terphenyl-d14	55		18-120

Project Name: 100 MAIN ST.
Lab Number: L2318715
Project Number: 12461:1
Report Date: 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-03
Client ID: SB-8G (1.5-2)
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 10:45
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 144,1633
Analytical Date: 04/19/23 00:01
Analyst: JW
Percent Solids: 88%

Extraction Method: EPA 1633
Extraction Date: 04/17/23 05:00
Cleanup Method: EPA 1633
Cleanup Date: 04/18/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Perfluorinated Alkyl Acids by EPA 1633 - Mansfield Lab						
Perfluorobutanoic Acid (PFBA)	ND		ng/g	0.781	0.049	1
Perfluoropentanoic Acid (PFPeA)	ND		ng/g	0.391	0.055	1
Perfluorobutanesulfonic Acid (PFBS)	ND		ng/g	0.195	0.042	1
Perfluorohexanoic Acid (PFHxA)	ND		ng/g	0.195	0.045	1
Perfluoroheptanoic Acid (PFHpA)	ND		ng/g	0.195	0.023	1
Perfluorohexanesulfonic Acid (PFHxS)	ND		ng/g	0.195	0.058	1
Perfluorooctanoic Acid (PFOA)	ND		ng/g	0.195	0.051	1
1H,1H,2H,2H-Perfluorooctanesulfonic Acid (6:2FTS)	ND		ng/g	0.781	0.274	1
Perfluoroheptanesulfonic Acid (PFHpS)	ND		ng/g	0.195	0.036	1
Perfluorononanoic Acid (PFNA)	ND		ng/g	0.195	0.077	1
Perfluorooctanesulfonic Acid (PFOS)	0.148	JF	ng/g	0.195	0.077	1
Perfluorodecanoic Acid (PFDA)	ND		ng/g	0.195	0.073	1
1H,1H,2H,2H-Perfluorodecanesulfonic Acid (8:2FTS)	ND		ng/g	0.781	0.378	1
N-Methyl Perfluorooctanesulfonamidoacetic Acid (NMeFOSAA)	ND		ng/g	0.195	0.098	1
Perfluoroundecanoic Acid (PFUnA)	ND		ng/g	0.195	0.050	1
Perfluorodecanesulfonic Acid (PFDS)	ND		ng/g	0.195	0.031	1
Perfluorooctanesulfonamide (PFOSA)	ND		ng/g	0.195	0.042	1
N-Ethyl Perfluorooctanesulfonamidoacetic Acid (NEtFOSAA)	ND		ng/g	0.195	0.081	1
Perfluorododecanoic Acid (PFDoA)	ND		ng/g	0.195	0.040	1
Perfluorotridecanoic Acid (PFTrDA)	ND		ng/g	0.195	0.052	1
Perfluorotetradecanoic Acid (PFTeDA)	ND		ng/g	0.195	0.104	1
PFOA/PFOS, Total	0.148	J	ng/g	0.195	0.051	1

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-03 Date Collected: 04/07/23 10:45

Client ID: SB-8G (1.5-2) Date Received: 04/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Perfluorinated Alkyl Acids by EPA 1633 - Mansfield Lab						

Surrogate	% Recovery	Qualifier	Acceptance Criteria
Perfluoro-n-[13C4]Butanoic Acid (13C4-PFBA)	89		20-150
Perfluoro-n-[13C5]Pentanoic Acid (13C5-PFPeA)	101		20-150
Perfluoro-1-[2,3,4-13C3]Butanesulfonic Acid (13C3-PFBS)	85		20-150
Perfluoro-n-[1,2,3,4,6-13C5]Hexanoic Acid (13C5-PFHxA)	94		20-150
Perfluoro-n-[1,2,3,4-13C4]Heptanoic Acid (13C4-PFHpA)	77		20-150
Perfluoro-1-[1,2,3-13C3]Hexanesulfonic Acid (13C3-PFHxS)	88		20-150
Perfluoro-n-[13C8]Octanoic Acid (13C8-PFOA)	68		20-150
1H,1H,2H,2H-Perfluoro-1-[1,2-13C2]Octanesulfonic Acid (13C2-6:2FTS)	87		20-150
Perfluoro-n-[13C9]Nonanoic Acid (13C9-PFNA)	91		20-150
Perfluoro-1-[13C8]Octanesulfonic Acid (13C8-PFOS)	87		20-150
Perfluoro-n-[1,2,3,4,5,6-13C6]Decanoic Acid (13C6-PFDA)	93		20-150
1H,1H,2H,2H-Perfluoro-1-[1,2-13C2]Decanesulfonic Acid (13C2-8:2FTS)	81		20-150
N-Methyl-d3-perfluoro-1-octanesulfonamidoacetic Acid (D3-NMeFOSAA)	**154**	Q	20-150
Perfluoro-n-[1,2,3,4,5,6,7-13C7]Undecanoic Acid (13C7-PFUnA)	94		20-150
Perfluoro-1-[13C8]Octanesulfonamide (13C8-PFOSA)	79		20-150
N-Ethyl-d5-perfluoro-1-octanesulfonamidoacetic Acid (D5-NEtFOSAA)	128		20-150
Perfluoro-n-[1,2-13C2]Dodecanoic Acid (13C2-PFDoA)	82		20-150
Perfluoro-n-[1,2-13C2]Tetradecanoic Acid (13C2-PFTeDA)	88		20-150

Project Name: 100 MAIN ST.
Project Number: 12461:1
Lab Number: L2318715
Report Date: 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-04
Client ID: SB-20G (2.5-3)
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 14:30
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8270E
Analytical Date: 04/14/23 06:17
Analyst: IM
Percent Solids: 93%

Extraction Method: EPA 3546
Extraction Date: 04/13/23 00:43

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Acenaphthene	ND		ug/kg	140	18.	1
1,2,4-Trichlorobenzene	ND		ug/kg	180	20.	1
Hexachlorobenzene	ND		ug/kg	110	20.	1
Bis(2-chloroethyl)ether	ND		ug/kg	160	24.	1
2-Chloronaphthalene	ND		ug/kg	180	18.	1
1,2-Dichlorobenzene	ND		ug/kg	180	32.	1
1,3-Dichlorobenzene	ND		ug/kg	180	30.	1
1,4-Dichlorobenzene	ND		ug/kg	180	31.	1
3,3'-Dichlorobenzidine	ND		ug/kg	180	47.	1
2,4-Dinitrotoluene	ND		ug/kg	180	35.	1
2,6-Dinitrotoluene	ND		ug/kg	180	30.	1
Fluoranthene	91	J	ug/kg	110	20.	1
4-Chlorophenyl phenyl ether	ND		ug/kg	180	19.	1
4-Bromophenyl phenyl ether	ND		ug/kg	180	27.	1
Bis(2-chloroisopropyl)ether	ND		ug/kg	210	30.	1
Bis(2-chloroethoxy)methane	ND		ug/kg	190	18.	1
Hexachlorobutadiene	ND		ug/kg	180	26.	1
Hexachlorocyclopentadiene	ND		ug/kg	510	160	1
Hexachloroethane	ND		ug/kg	140	29.	1
Isophorone	ND		ug/kg	160	23.	1
Naphthalene	ND		ug/kg	180	22.	1
Nitrobenzene	ND		ug/kg	160	26.	1
NDPA/DPA	ND		ug/kg	140	20.	1
n-Nitrosodi-n-propylamine	ND		ug/kg	180	27.	1
Bis(2-ethylhexyl)phthalate	ND		ug/kg	180	61.	1
Butyl benzyl phthalate	ND		ug/kg	180	45.	1
Di-n-butylphthalate	ND		ug/kg	180	34.	1
Di-n-octylphthalate	ND		ug/kg	180	60.	1

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-04 Date Collected: 04/07/23 14:30

Client ID: SB-20G (2.5-3) Date Received: 04/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Diethyl phthalate	ND		ug/kg	180	16.	1
Dimethyl phthalate	ND		ug/kg	180	37.	1
Benzo(a)anthracene	53	J	ug/kg	110	20.	1
Benzo(a)pyrene	52	J	ug/kg	140	43.	1
Benzo(b)fluoranthene	62	J	ug/kg	110	30.	1
Benzo(k)fluoranthene	ND		ug/kg	110	28.	1
Chrysene	49	J	ug/kg	110	18.	1
Acenaphthylene	ND		ug/kg	140	27.	1
Anthracene	ND		ug/kg	110	34.	1
Benzo(ghi)perylene	32	J	ug/kg	140	21.	1
Fluorene	ND		ug/kg	180	17.	1
Phenanthrene	44	J	ug/kg	110	22.	1
Dibenzo(a,h)anthracene	ND		ug/kg	110	20.	1
Indeno(1,2,3-cd)pyrene	35	J	ug/kg	140	25.	1
Pyrene	83	J	ug/kg	110	18.	1
Biphenyl	ND		ug/kg	400	23.	1
4-Chloroaniline	ND		ug/kg	180	32.	1
2-Nitroaniline	ND		ug/kg	180	34.	1
3-Nitroaniline	ND		ug/kg	180	33.	1
4-Nitroaniline	ND		ug/kg	180	73.	1
Dibenzofuran	ND		ug/kg	180	17.	1
2-Methylnaphthalene	ND		ug/kg	210	21.	1
1,2,4,5-Tetrachlorobenzene	ND		ug/kg	180	18.	1
Acetophenone	ND		ug/kg	180	22.	1
2,4,6-Trichlorophenol	ND		ug/kg	110	34.	1
p-Chloro-m-cresol	ND		ug/kg	180	26.	1
2-Chlorophenol	ND		ug/kg	180	21.	1
2,4-Dichlorophenol	ND		ug/kg	160	28.	1
2,4-Dimethylphenol	ND		ug/kg	180	58.	1
2-Nitrophenol	ND		ug/kg	380	66.	1
4-Nitrophenol	ND		ug/kg	250	72.	1
2,4-Dinitrophenol	ND		ug/kg	850	82.	1
4,6-Dinitro-o-cresol	ND		ug/kg	460	85.	1
Pentachlorophenol	ND		ug/kg	140	39.	1
Phenol	ND		ug/kg	180	27.	1
2-Methylphenol	ND		ug/kg	180	27.	1
3-Methylphenol/4-Methylphenol	ND		ug/kg	250	28.	1

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-04 Date Collected: 04/07/23 14:30

Client ID: SB-20G (2.5-3) Date Received: 04/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
2,4,5-Trichlorophenol	ND		ug/kg	180	34.	1
Benzoic Acid	ND		ug/kg	570	180	1
Benzyl Alcohol	ND		ug/kg	180	54.	1
Carbazole	ND		ug/kg	180	17.	1
1,4-Dioxane	ND		ug/kg	26	8.1	1
Tentatively Identified Compounds						
Total TIC Compounds	467	J	ug/kg			1
Unknown	467	J	ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	**20**	Q	25-120
Phenol-d6	62		10-120
Nitrobenzene-d5	78		23-120
2-Fluorobiphenyl	56		30-120
2,4,6-Tribromophenol	11		10-136
4-Terphenyl-d14	49		18-120

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-05
Client ID: SB-21G (0.5-1)
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 14:15
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8270E
Analytical Date: 04/14/23 07:28
Analyst: IM
Percent Solids: 92%

Extraction Method: EPA 3546
Extraction Date: 04/13/23 00:43

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Acenaphthene	ND		ug/kg	140	19.	1
1,2,4-Trichlorobenzene	ND		ug/kg	180	20.	1
Hexachlorobenzene	ND		ug/kg	110	20.	1
Bis(2-chloroethyl)ether	ND		ug/kg	160	24.	1
2-Chloronaphthalene	ND		ug/kg	180	18.	1
1,2-Dichlorobenzene	ND		ug/kg	180	32.	1
1,3-Dichlorobenzene	ND		ug/kg	180	31.	1
1,4-Dichlorobenzene	ND		ug/kg	180	31.	1
3,3'-Dichlorobenzidine	ND		ug/kg	180	48.	1
2,4-Dinitrotoluene	ND		ug/kg	180	36.	1
2,6-Dinitrotoluene	ND		ug/kg	180	31.	1
Fluoranthene	190		ug/kg	110	21.	1
4-Chlorophenyl phenyl ether	ND		ug/kg	180	19.	1
4-Bromophenyl phenyl ether	ND		ug/kg	180	27.	1
Bis(2-chloroisopropyl)ether	ND		ug/kg	220	31.	1
Bis(2-chloroethoxy)methane	ND		ug/kg	190	18.	1
Hexachlorobutadiene	ND		ug/kg	180	26.	1
Hexachlorocyclopentadiene	ND		ug/kg	510	160	1
Hexachloroethane	ND		ug/kg	140	29.	1
Isophorone	ND		ug/kg	160	23.	1
Naphthalene	ND		ug/kg	180	22.	1
Nitrobenzene	ND		ug/kg	160	26.	1
NDPA/DPA	ND		ug/kg	140	20.	1
n-Nitrosodi-n-propylamine	ND		ug/kg	180	28.	1
Bis(2-ethylhexyl)phthalate	ND		ug/kg	180	62.	1
Butyl benzyl phthalate	ND		ug/kg	180	45.	1
Di-n-butylphthalate	ND		ug/kg	180	34.	1
Di-n-octylphthalate	ND		ug/kg	180	61.	1

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-05 Date Collected: 04/07/23 14:15

Client ID: SB-21G (0.5-1) Date Received: 04/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Diethyl phthalate	ND		ug/kg	180	17.	1
Dimethyl phthalate	ND		ug/kg	180	38.	1
Benzo(a)anthracene	110		ug/kg	110	20.	1
Benzo(a)pyrene	100	J	ug/kg	140	44.	1
Benzo(b)fluoranthene	120		ug/kg	110	30.	1
Benzo(k)fluoranthene	39	J	ug/kg	110	29.	1
Chrysene	92	J	ug/kg	110	19.	1
Acenaphthylene	ND		ug/kg	140	28.	1
Anthracene	ND		ug/kg	110	35.	1
Benzo(ghi)perylene	62	J	ug/kg	140	21.	1
Fluorene	ND		ug/kg	180	17.	1
Phenanthrene	110		ug/kg	110	22.	1
Dibenzo(a,h)anthracene	ND		ug/kg	110	21.	1
Indeno(1,2,3-cd)pyrene	68	J	ug/kg	140	25.	1
Pyrene	180		ug/kg	110	18.	1
Biphenyl	ND		ug/kg	410	23.	1
4-Chloroaniline	ND		ug/kg	180	33.	1
2-Nitroaniline	ND		ug/kg	180	35.	1
3-Nitroaniline	ND		ug/kg	180	34.	1
4-Nitroaniline	ND		ug/kg	180	74.	1
Dibenzofuran	ND		ug/kg	180	17.	1
2-Methylnaphthalene	ND		ug/kg	220	22.	1
1,2,4,5-Tetrachlorobenzene	ND		ug/kg	180	19.	1
Acetophenone	ND		ug/kg	180	22.	1
2,4,6-Trichlorophenol	ND		ug/kg	110	34.	1
p-Chloro-m-cresol	ND		ug/kg	180	27.	1
2-Chlorophenol	ND		ug/kg	180	21.	1
2,4-Dichlorophenol	ND		ug/kg	160	29.	1
2,4-Dimethylphenol	ND		ug/kg	180	59.	1
2-Nitrophenol	ND		ug/kg	390	68.	1
4-Nitrophenol	ND		ug/kg	250	73.	1
2,4-Dinitrophenol	ND		ug/kg	860	84.	1
4,6-Dinitro-o-cresol	ND		ug/kg	470	86.	1
Pentachlorophenol	ND		ug/kg	140	40.	1
Phenol	ND		ug/kg	180	27.	1
2-Methylphenol	ND		ug/kg	180	28.	1
3-Methylphenol/4-Methylphenol	ND		ug/kg	260	28.	1

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-05 Date Collected: 04/07/23 14:15

Client ID: SB-21G (0.5-1) Date Received: 04/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
2,4,5-Trichlorophenol	ND		ug/kg	180	34.	1
Benzoic Acid	ND		ug/kg	580	180	1
Benzyl Alcohol	ND		ug/kg	180	55.	1
Carbazole	ND		ug/kg	180	17.	1
1,4-Dioxane	ND		ug/kg	27	8.3	1
Tentatively Identified Compounds						
Total TIC Compounds	154	J	ug/kg			1
Unknown	154	J	ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	61		25-120
Phenol-d6	67		10-120
Nitrobenzene-d5	67		23-120
2-Fluorobiphenyl	48		30-120
2,4,6-Tribromophenol	45		10-136
4-Terphenyl-d14	45		18-120

Project Name: 100 MAIN ST.
Project Number: 12461:1
Lab Number: L2318715
Report Date: 04/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 04/12/23 08:16
Analyst: JG

Extraction Method: EPA 3510C
Extraction Date: 04/11/23 23:34

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 01-02 Batch: WG1765509-1					
Acenaphthene	ND		ug/l	2.0	0.44
1,2,4-Trichlorobenzene	ND		ug/l	5.0	0.50
Hexachlorobenzene	ND		ug/l	2.0	0.46
Bis(2-chloroethyl)ether	ND		ug/l	2.0	0.50
2-Chloronaphthalene	ND		ug/l	2.0	0.44
1,2-Dichlorobenzene	ND		ug/l	2.0	0.45
1,3-Dichlorobenzene	ND		ug/l	2.0	0.40
1,4-Dichlorobenzene	ND		ug/l	2.0	0.43
3,3'-Dichlorobenzidine	ND		ug/l	5.0	1.6
2,4-Dinitrotoluene	ND		ug/l	5.0	1.2
2,6-Dinitrotoluene	ND		ug/l	5.0	0.93
Fluoranthene	ND		ug/l	2.0	0.26
4-Chlorophenyl phenyl ether	ND		ug/l	2.0	0.49
4-Bromophenyl phenyl ether	ND		ug/l	2.0	0.38
Bis(2-chloroisopropyl)ether	ND		ug/l	2.0	0.53
Bis(2-chloroethoxy)methane	ND		ug/l	5.0	0.50
Hexachlorobutadiene	ND		ug/l	2.0	0.66
Hexachlorocyclopentadiene	ND		ug/l	20	0.69
Hexachloroethane	ND		ug/l	2.0	0.58
Isophorone	ND		ug/l	5.0	1.2
Naphthalene	ND		ug/l	2.0	0.46
Nitrobenzene	ND		ug/l	2.0	0.77
NDPA/DPA	ND		ug/l	2.0	0.42
n-Nitrosodi-n-propylamine	ND		ug/l	5.0	0.64
Bis(2-ethylhexyl)phthalate	ND		ug/l	3.0	1.5
Butyl benzyl phthalate	ND		ug/l	5.0	1.2
Di-n-butylphthalate	ND		ug/l	5.0	0.39
Di-n-octylphthalate	ND		ug/l	5.0	1.3
Diethyl phthalate	ND		ug/l	5.0	0.38

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 04/12/23 08:16
Analyst: JG

Extraction Method: EPA 3510C
Extraction Date: 04/11/23 23:34

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 01-02 Batch: WG1765509-1					
Dimethyl phthalate	ND		ug/l	5.0	1.8
Benzo(a)anthracene	ND		ug/l	2.0	0.32
Benzo(a)pyrene	ND		ug/l	2.0	0.41
Benzo(b)fluoranthene	ND		ug/l	2.0	0.35
Benzo(k)fluoranthene	ND		ug/l	2.0	0.37
Chrysene	ND		ug/l	2.0	0.34
Acenaphthylene	ND		ug/l	2.0	0.46
Anthracene	ND		ug/l	2.0	0.33
Benzo(ghi)perylene	ND		ug/l	2.0	0.30
Fluorene	ND		ug/l	2.0	0.41
Phenanthrene	ND		ug/l	2.0	0.33
Dibenzo(a,h)anthracene	ND		ug/l	2.0	0.32
Indeno(1,2,3-cd)pyrene	ND		ug/l	2.0	0.40
Pyrene	ND		ug/l	2.0	0.28
Biphenyl	ND		ug/l	2.0	0.46
4-Chloroaniline	ND		ug/l	5.0	1.1
2-Nitroaniline	ND		ug/l	5.0	0.50
3-Nitroaniline	ND		ug/l	5.0	0.81
4-Nitroaniline	ND		ug/l	5.0	0.80
Dibenzofuran	ND		ug/l	2.0	0.50
2-Methylnaphthalene	ND		ug/l	2.0	0.45
1,2,4,5-Tetrachlorobenzene	ND		ug/l	10	0.44
Acetophenone	ND		ug/l	5.0	0.53
2,4,6-Trichlorophenol	ND		ug/l	5.0	0.61
p-Chloro-m-cresol	ND		ug/l	2.0	0.35
2-Chlorophenol	ND		ug/l	2.0	0.48
2,4-Dichlorophenol	ND		ug/l	5.0	0.41
2,4-Dimethylphenol	ND		ug/l	5.0	1.8
2-Nitrophenol	ND		ug/l	10	0.85

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 04/12/23 08:16
Analyst: JG

Extraction Method: EPA 3510C
Extraction Date: 04/11/23 23:34

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 01-02 Batch: WG1765509-1					
4-Nitrophenol	ND		ug/l	10	0.67
2,4-Dinitrophenol	ND		ug/l	20	6.6
4,6-Dinitro-o-cresol	ND		ug/l	10	1.8
Pentachlorophenol	ND		ug/l	10	1.8
Phenol	ND		ug/l	5.0	0.57
2-Methylphenol	ND		ug/l	5.0	0.49
3-Methylphenol/4-Methylphenol	ND		ug/l	5.0	0.48
2,4,5-Trichlorophenol	ND		ug/l	5.0	0.77
Benzoic Acid	ND		ug/l	50	2.6
Benzyl Alcohol	ND		ug/l	2.0	0.59
Carbazole	ND		ug/l	2.0	0.49

Tentatively Identified Compounds			
Total TIC Compounds	22.3	J	ug/l
Unknown Organic Acid	4.62	J	ug/l
Unknown	4.47	J	ug/l
Unknown Alcohol	2.00	J	ug/l
Unknown	1.64	J	ug/l
Unknown	5.05	J	ug/l
Unknown Organic Acid	2.94	J	ug/l
Unknown	1.56	J	ug/l

Project Name: 100 MAIN ST.
Project Number: 12461:1
Lab Number: L2318715
Report Date: 04/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 04/12/23 08:16
Analyst: JG

Extraction Method: EPA 3510C
Extraction Date: 04/11/23 23:34

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 01-02 Batch: WG1765509-1					

Surrogate	%Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	42		21-120
Phenol-d6	34		10-120
Nitrobenzene-d5	56		23-120
2-Fluorobiphenyl	58		15-120
2,4,6-Tribromophenol	88		10-120
4-Terphenyl-d14	78		41-149

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E-SIM
Analytical Date: 04/12/23 11:23
Analyst: DV

Extraction Method: EPA 3510C
Extraction Date: 04/11/23 23:37

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS-SIM - Westborough Lab for sample(s): 01-02 Batch: WG1765510-1					
Acenaphthene	ND		ug/l	0.10	0.01
2-Chloronaphthalene	ND		ug/l	0.20	0.02
Fluoranthene	ND		ug/l	0.10	0.02
Hexachlorobutadiene	ND		ug/l	0.50	0.05
Naphthalene	ND		ug/l	0.10	0.05
Benzo(a)anthracene	ND		ug/l	0.10	0.02
Benzo(a)pyrene	ND		ug/l	0.10	0.02
Benzo(b)fluoranthene	ND		ug/l	0.10	0.01
Benzo(k)fluoranthene	ND		ug/l	0.10	0.01
Chrysene	ND		ug/l	0.10	0.01
Acenaphthylene	ND		ug/l	0.10	0.01
Anthracene	ND		ug/l	0.10	0.01
Benzo(ghi)perylene	ND		ug/l	0.10	0.01
Fluorene	ND		ug/l	0.10	0.01
Phenanthrene	ND		ug/l	0.10	0.02
Dibenzo(a,h)anthracene	ND		ug/l	0.10	0.01
Indeno(1,2,3-cd)pyrene	ND		ug/l	0.10	0.01
Pyrene	ND		ug/l	0.10	0.02
2-Methylnaphthalene	ND		ug/l	0.10	0.02
Pentachlorophenol	0.12	J	ug/l	0.80	0.01
Hexachlorobenzene	ND		ug/l	0.80	0.01
Hexachloroethane	ND		ug/l	0.80	0.06

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E-SIM
Analytical Date: 04/12/23 11:23
Analyst: DV

Extraction Method: EPA 3510C
Extraction Date: 04/11/23 23:37

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS-SIM - Westborough Lab for sample(s): 01-02 Batch: WG1765510-1					

Surrogate	%Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	43		21-120
Phenol-d6	38		10-120
Nitrobenzene-d5	64		23-120
2-Fluorobiphenyl	65		15-120
2,4,6-Tribromophenol	81		10-120
4-Terphenyl-d14	81		41-149

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 04/14/23 00:39
Analyst: IM

Extraction Method: EPA 3546
Extraction Date: 04/13/23 00:42

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 03-05 Batch: WG1766042-1					
Acenaphthene	ND		ug/kg	130	17.
1,2,4-Trichlorobenzene	ND		ug/kg	160	18.
Hexachlorobenzene	ND		ug/kg	97	18.
Bis(2-chloroethyl)ether	ND		ug/kg	150	22.
2-Chloronaphthalene	ND		ug/kg	160	16.
1,2-Dichlorobenzene	ND		ug/kg	160	29.
1,3-Dichlorobenzene	ND		ug/kg	160	28.
1,4-Dichlorobenzene	ND		ug/kg	160	28.
3,3'-Dichlorobenzidine	ND		ug/kg	160	43.
2,4-Dinitrotoluene	ND		ug/kg	160	32.
2,6-Dinitrotoluene	ND		ug/kg	160	28.
Fluoranthene	ND		ug/kg	97	19.
4-Chlorophenyl phenyl ether	ND		ug/kg	160	17.
4-Bromophenyl phenyl ether	ND		ug/kg	160	25.
Bis(2-chloroisopropyl)ether	ND		ug/kg	190	28.
Bis(2-chloroethoxy)methane	ND		ug/kg	180	16.
Hexachlorobutadiene	ND		ug/kg	160	24.
Hexachlorocyclopentadiene	ND		ug/kg	460	150
Hexachloroethane	ND		ug/kg	130	26.
Isophorone	ND		ug/kg	150	21.
Naphthalene	ND		ug/kg	160	20.
Nitrobenzene	ND		ug/kg	150	24.
NDPA/DPA	ND		ug/kg	130	18.
n-Nitrosodi-n-propylamine	ND		ug/kg	160	25.
Bis(2-ethylhexyl)phthalate	ND		ug/kg	160	56.
Butyl benzyl phthalate	ND		ug/kg	160	41.
Di-n-butylphthalate	ND		ug/kg	160	31.
Di-n-octylphthalate	ND		ug/kg	160	55.
Diethyl phthalate	ND		ug/kg	160	15.

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 04/14/23 00:39
Analyst: IM

Extraction Method: EPA 3546
Extraction Date: 04/13/23 00:42

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 03-05 Batch: WG1766042-1					
Dimethyl phthalate	ND		ug/kg	160	34.
Benzo(a)anthracene	ND		ug/kg	97	18.
Benzo(a)pyrene	ND		ug/kg	130	40.
Benzo(b)fluoranthene	ND		ug/kg	97	27.
Benzo(k)fluoranthene	ND		ug/kg	97	26.
Chrysene	ND		ug/kg	97	17.
Acenaphthylene	ND		ug/kg	130	25.
Anthracene	ND		ug/kg	97	32.
Benzo(ghi)perylene	ND		ug/kg	130	19.
Fluorene	ND		ug/kg	160	16.
Phenanthrene	ND		ug/kg	97	20.
Dibenzo(a,h)anthracene	ND		ug/kg	97	19.
Indeno(1,2,3-cd)pyrene	ND		ug/kg	130	23.
Pyrene	ND		ug/kg	97	16.
Biphenyl	ND		ug/kg	370	21.
4-Chloroaniline	ND		ug/kg	160	30.
2-Nitroaniline	ND		ug/kg	160	31.
3-Nitroaniline	ND		ug/kg	160	31.
4-Nitroaniline	ND		ug/kg	160	67.
Dibenzofuran	ND		ug/kg	160	15.
2-Methylnaphthalene	ND		ug/kg	190	20.
1,2,4,5-Tetrachlorobenzene	ND		ug/kg	160	17.
Acetophenone	ND		ug/kg	160	20.
2,4,6-Trichlorophenol	ND		ug/kg	97	31.
p-Chloro-m-cresol	ND		ug/kg	160	24.
2-Chlorophenol	ND		ug/kg	160	19.
2,4-Dichlorophenol	ND		ug/kg	150	26.
2,4-Dimethylphenol	ND		ug/kg	160	54.
2-Nitrophenol	ND		ug/kg	350	61.

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 04/14/23 00:39
Analyst: IM

Extraction Method: EPA 3546
Extraction Date: 04/13/23 00:42

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 03-05 Batch: WG1766042-1					
4-Nitrophenol	ND		ug/kg	230	66.
2,4-Dinitrophenol	ND		ug/kg	780	76.
4,6-Dinitro-o-cresol	ND		ug/kg	420	78.
Pentachlorophenol	ND		ug/kg	130	36.
Phenol	ND		ug/kg	160	24.
2-Methylphenol	ND		ug/kg	160	25.
3-Methylphenol/4-Methylphenol	ND		ug/kg	230	25.
2,4,5-Trichlorophenol	ND		ug/kg	160	31.
Benzoic Acid	ND		ug/kg	530	160
Benzyl Alcohol	ND		ug/kg	160	50.
Carbazole	ND		ug/kg	160	16.
1,4-Dioxane	ND		ug/kg	24	7.5
Tentatively Identified Compounds					
No Tentatively Identified Compounds	ND		ug/kg		

Surrogate	%Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	70		25-120
Phenol-d6	74		10-120
Nitrobenzene-d5	71		23-120
2-Fluorobiphenyl	56		30-120
2,4,6-Tribromophenol	55		10-136
4-Terphenyl-d14	54		18-120

Project Name: 100 MAIN ST.
Project Number: 12461:1
Lab Number: L2318715
Report Date: 04/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E-SIM
Analytical Date: 04/14/23 22:38
Analyst: TPR

Extraction Method: EPA 3510C
Extraction Date: 04/13/23 17:30

Parameter	Result	Qualifier	Units	RL	MDL
1,4 Dioxane by 8270E-SIM - Mansfield Lab for sample(s): 01-02 Batch: WG1766451-1					
1,4-Dioxane	ND		ug/l	0.150	0.0339

Surrogate	%Recovery	Qualifier	Acceptance Criteria
1,4-Dioxane-d8	55		15-110

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 144,1633
Analytical Date: 04/18/23 20:37
Analyst: JW

Extraction Method: EPA 1633
Extraction Date: 04/17/23 05:00
Cleanup Method: EPA 1633
Cleanup Date: 04/18/23

Parameter	Result	Qualifier	Units	RL	MDL
Perfluorinated Alkyl Acids by EPA 1633 - Mansfield Lab for sample(s): 03 Batch: WG1767336-1					
Perfluorobutanoic Acid (PFBA)	ND		ng/g	0.800	0.050
Perfluoropentanoic Acid (PFPeA)	ND		ng/g	0.400	0.056
Perfluorobutanesulfonic Acid (PFBS)	ND		ng/g	0.200	0.043
Perfluorohexanoic Acid (PFHxA)	ND		ng/g	0.200	0.046
Perfluoroheptanoic Acid (PFHpA)	ND		ng/g	0.200	0.023
Perfluorohexanesulfonic Acid (PFHxS)	ND		ng/g	0.200	0.059
Perfluorooctanoic Acid (PFOA)	ND		ng/g	0.200	0.052
1H,1H,2H,2H-Perfluorooctanesulfonic Acid (6:2FTS)	ND		ng/g	0.800	0.280
Perfluoroheptanesulfonic Acid (PFHpS)	ND		ng/g	0.200	0.037
Perfluorononanoic Acid (PFNA)	ND		ng/g	0.200	0.078
Perfluorooctanesulfonic Acid (PFOS)	ND		ng/g	0.200	0.079
Perfluorodecanoic Acid (PFDA)	ND		ng/g	0.200	0.075
1H,1H,2H,2H-Perfluorodecanesulfonic Acid (8:2FTS)	ND		ng/g	0.800	0.387
N-Methyl Perfluorooctanesulfonamidoacetic Acid (NMeFOSAA)	ND		ng/g	0.200	0.100
Perfluoroundecanoic Acid (PFUnA)	ND		ng/g	0.200	0.051
Perfluorodecanesulfonic Acid (PFDS)	ND		ng/g	0.200	0.032
Perfluorooctanesulfonamide (PFOSA)	ND		ng/g	0.200	0.043
N-Ethyl Perfluorooctanesulfonamidoacetic Acid (NEtFOSAA)	ND		ng/g	0.200	0.082
Perfluorododecanoic Acid (PFDoA)	ND		ng/g	0.200	0.041
Perfluorotridecanoic Acid (PFTrDA)	ND		ng/g	0.200	0.053
Perfluorotetradecanoic Acid (PFTeDA)	ND		ng/g	0.200	0.106
PFOA/PFOS, Total	ND		ng/g	0.200	0.052

Project Name: 100 MAIN ST.
Project Number: 12461:1
Lab Number: L2318715
Report Date: 04/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 144,1633
Analytical Date: 04/18/23 20:37
Analyst: JW

Extraction Method: EPA 1633
Extraction Date: 04/17/23 05:00
Cleanup Method: EPA 1633
Cleanup Date: 04/18/23

Parameter	Result	Qualifier	Units	RL	MDL
Perfluorinated Alkyl Acids by EPA 1633 - Mansfield Lab for sample(s): 03 Batch: WG1767336-1					

Surrogate	%Recovery	Qualifier	Acceptance Criteria
Perfluoro-n-[13C4]Butanoic Acid (13C4-PFBA)	79		20-150
Perfluoro-n-[13C5]Pentanoic Acid (13C5-PFPeA)	75		20-150
Perfluoro-1-[2,3,4-13C3]Butanesulfonic Acid (13C3-PFBS)	75		20-150
Perfluoro-n-[1,2,3,4,6-13C5]Hexanoic Acid (13C5-PFHxA)	82		20-150
Perfluoro-n-[1,2,3,4-13C4]Heptanoic Acid (13C4-PFHpA)	66		20-150
Perfluoro-1-[1,2,3-13C3]Hexanesulfonic Acid (13C3-PFHxS)	82		20-150
Perfluoro-n-[13C8]Octanoic Acid (13C8-PFOA)	66		20-150
1H,1H,2H,2H-Perfluoro-1-[1,2-13C2]Octanesulfonic Acid (13C2-6:2FTS)	79		20-150
Perfluoro-n-[13C9]Nonanoic Acid (13C9-PFNA)	88		20-150
Perfluoro-1-[13C8]Octanesulfonic Acid (13C8-PFOS)	84		20-150
Perfluoro-n-[1,2,3,4,5,6-13C6]Decanoic Acid (13C6-PFDA)	78		20-150
1H,1H,2H,2H-Perfluoro-1-[1,2-13C2]Decanesulfonic Acid (13C2-8:2FTS)	83		20-150
N-Methyl-d3-perfluoro-1-octanesulfonamidoacetic Acid (D3-NMeFOSAA)	**164**	Q	20-150
Perfluoro-n-[1,2,3,4,5,6,7-13C7]Undecanoic Acid (13C7-PFUnA)	74		20-150
Perfluoro-1-[13C8]Octanesulfonamide (13C8-PFOSA)	80		20-150
N-Ethyl-d5-perfluoro-1-octanesulfonamidoacetic Acid (D5-NEtFOSAA)	114		20-150
Perfluoro-n-[1,2-13C2]Dodecanoic Acid (13C2-PFDoA)	62		20-150
Perfluoro-n-[1,2-13C2]Tetradecanoic Acid (13C2-PFTeDA)	52		20-150

Project Name: 100 MAIN ST.
Project Number: 12461:1
Lab Number: L2318715
Report Date: 04/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 144,1633
Analytical Date: 04/21/23 13:55
Analyst: JW

Extraction Method: EPA 1633
Extraction Date: 04/20/23 11:40

Parameter	Result	Qualifier	Units	RL	MDL
Perfluorinated Alkyl Acids by EPA 1633 - Mansfield Lab for sample(s): 01-02 Batch: WG1769021-1					
Perfluorobutanoic Acid (PFBA)	ND		ng/l	6.40	1.02
Perfluoropentanoic Acid (PFPeA)	ND		ng/l	3.20	0.856
Perfluorobutanesulfonic Acid (PFBS)	ND		ng/l	1.60	0.536
Perfluorohexanoic Acid (PFHxA)	ND		ng/l	1.60	0.472
Perfluoroheptanoic Acid (PFHpA)	ND		ng/l	1.60	0.320
Perfluorohexanesulfonic Acid (PFHxS)	ND		ng/l	1.60	0.384
Perfluorooctanoic Acid (PFOA)	ND		ng/l	1.60	0.696
1H,1H,2H,2H-Perfluorooctanesulfonic Acid (6:2FTS)	ND		ng/l	6.40	2.16
Perfluoroheptanesulfonic Acid (PFHpS)	ND		ng/l	1.60	0.432
Perfluorononanoic Acid (PFNA)	ND		ng/l	1.60	0.504
Perfluorooctanesulfonic Acid (PFOS)	ND		ng/l	1.60	0.728
Perfluorodecanoic Acid (PFDA)	ND		ng/l	1.60	0.648
1H,1H,2H,2H-Perfluorodecanesulfonic Acid (8:2FTS)	ND		ng/l	6.40	2.49
N-Methyl Perfluorooctanesulfonamidoacetic Acid (NMeFOSAA)	ND		ng/l	1.60	0.872
Perfluoroundecanoic Acid (PFUnA)	ND		ng/l	1.60	0.696
Perfluorodecanesulfonic Acid (PFDS)	ND		ng/l	1.60	0.368
Perfluorooctanesulfonamide (PFOSA)	ND		ng/l	1.60	0.432
N-Ethyl Perfluorooctanesulfonamidoacetic Acid (NEtFOSAA)	ND		ng/l	1.60	0.864
Perfluorododecanoic Acid (PFDoA)	ND		ng/l	1.60	0.736
Perfluorotridecanoic Acid (PFTrDA)	ND		ng/l	1.60	0.600
Perfluorotetradecanoic Acid (PFTeDA)	ND		ng/l	1.60	0.424
PFOA/PFOS, Total	ND		ng/l	1.60	0.696

Project Name: 100 MAIN ST.
Project Number: 12461:1
Lab Number: L2318715
Report Date: 04/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 144,1633
Analytical Date: 04/21/23 13:55
Analyst: JW

Extraction Method: EPA 1633
Extraction Date: 04/20/23 11:40

Parameter	Result	Qualifier	Units	RL	MDL
Perfluorinated Alkyl Acids by EPA 1633 - Mansfield Lab for sample(s): 01-02 Batch: WG1769021-1					

Surrogate	%Recovery	Qualifier	Acceptance Criteria
Perfluoro-n-[13C4]Butanoic Acid (13C4-PFBA)	93		20-150
Perfluoro-n-[13C5]Pentanoic Acid (13C5-PFPeA)	95		20-150
Perfluoro-1-[2,3,4-13C3]Butanesulfonic Acid (13C3-PFBS)	96		20-150
Perfluoro-n-[1,2,3,4,6-13C5]Hexanoic Acid (13C5-PFHxA)	96		20-150
Perfluoro-n-[1,2,3,4-13C4]Heptanoic Acid (13C4-PFHpA)	88		20-150
Perfluoro-1-[1,2,3-13C3]Hexanesulfonic Acid (13C3-PFHxS)	93		20-150
Perfluoro-n-[13C8]Octanoic Acid (13C8-PFOA)	95		20-150
1H,1H,2H,2H-Perfluoro-1-[1,2-13C2]Octanesulfonic Acid (13C2-6:2FTS)	86		20-150
Perfluoro-n-[13C9]Nonanoic Acid (13C9-PFNA)	103		20-150
Perfluoro-1-[13C8]Octanesulfonic Acid (13C8-PFOS)	91		20-150
Perfluoro-n-[1,2,3,4,5,6-13C6]Decanoic Acid (13C6-PFDA)	94		20-150
1H,1H,2H,2H-Perfluoro-1-[1,2-13C2]Decanesulfonic Acid (13C2-8:2FTS)	82		20-150
N-Methyl-d3-perfluoro-1-octanesulfonamidoacetic Acid (D3-NMeFOSAA)	66		20-150
Perfluoro-n-[1,2,3,4,5,6,7-13C7]Undecanoic Acid (13C7-PFUnA)	82		20-150
Perfluoro-1-[13C8]Octanesulfonamide (13C8-PFOSA)	73		20-150
N-Ethyl-d5-perfluoro-1-octanesulfonamidoacetic Acid (D5-NEtFOSAA)	73		20-150
Perfluoro-n-[1,2-13C2]Dodecanoic Acid (13C2-PFDoA)	83		20-150
Perfluoro-n-[1,2-13C2]Tetradecanoic Acid (13C2-PFTeDA)	78		20-150

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 01-02 Batch: WG1765509-2 WG1765509-3								
Acenaphthene	67		76		37-111	13		30
1,2,4-Trichlorobenzene	55		70		39-98	24		30
Hexachlorobenzene	68		79		40-140	15		30
Bis(2-chloroethyl)ether	57		77		40-140	30		30
2-Chloronaphthalene	62		75		40-140	19		30
1,2-Dichlorobenzene	46		67		40-140	**37**	Q	30
1,3-Dichlorobenzene	45		64		40-140	**35**	Q	30
1,4-Dichlorobenzene	46		65		36-97	**34**	Q	30
3,3'-Dichlorobenzidine	79		55		40-140	**36**	Q	30
2,4-Dinitrotoluene	83		93		48-143	11		30
2,6-Dinitrotoluene	78		96		40-140	21		30
Fluoranthene	76		80		40-140	5		30
4-Chlorophenyl phenyl ether	72		78		40-140	8		30
4-Bromophenyl phenyl ether	74		80		40-140	8		30
Bis(2-chloroisopropyl)ether	62		83		40-140	29		30
Bis(2-chloroethoxy)methane	64		80		40-140	22		30
Hexachlorobutadiene	52		67		40-140	25		30
Hexachlorocyclopentadiene	67		83		40-140	21		30
Hexachloroethane	47		69		40-140	**38**	Q	30
Isophorone	62		79		40-140	24		30
Naphthalene	56		70		40-140	22		30
Nitrobenzene	63		84		40-140	29		30
NDPA/DPA	73		79		40-140	8		30

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 01-02 Batch: WG1765509-2 WG1765509-3								
n-Nitrosodi-n-propylamine	61		79		29-132	26		30
Bis(2-ethylhexyl)phthalate	113		110		40-140	3		30
Butyl benzyl phthalate	118		122		40-140	3		30
Di-n-butylphthalate	94		98		40-140	4		30
Di-n-octylphthalate	113		107		40-140	5		30
Diethyl phthalate	85		91		40-140	7		30
Dimethyl phthalate	78		87		40-140	11		30
Benzo(a)anthracene	84		86		40-140	2		30
Benzo(a)pyrene	86		84		40-140	2		30
Benzo(b)fluoranthene	84		85		40-140	1		30
Benzo(k)fluoranthene	81		85		40-140	5		30
Chrysene	77		79		40-140	3		30
Acenaphthylene	68		82		45-123	19		30
Anthracene	76		79		40-140	4		30
Benzo(ghi)perylene	90		88		40-140	2		30
Fluorene	71		80		40-140	12		30
Phenanthrene	72		75		40-140	4		30
Dibenzo(a,h)anthracene	92		91		40-140	1		30
Indeno(1,2,3-cd)pyrene	98		98		40-140	0		30
Pyrene	72		75		26-127	4		30
Biphenyl	62		74		40-140	18		30
4-Chloroaniline	56		58		40-140	4		30
2-Nitroaniline	90		101		52-143	12		30

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 01-02 Batch: WG1765509-2 WG1765509-3								
3-Nitroaniline	77		73		25-145	5		30
4-Nitroaniline	77		84		51-143	9		30
Dibenzofuran	68		77		40-140	12		30
2-Methylnaphthalene	62		75		40-140	19		30
1,2,4,5-Tetrachlorobenzene	58		70		2-134	19		30
Acetophenone	58		78		39-129	29		30
2,4,6-Trichlorophenol	85		97		30-130	13		30
p-Chloro-m-cresol	80		92		23-97	14		30
2-Chlorophenol	61		82		27-123	29		30
2,4-Dichlorophenol	74		89		30-130	18		30
2,4-Dimethylphenol	56		72		30-130	25		30
2-Nitrophenol	92		120		30-130	26		30
4-Nitrophenol	77		**87**	Q	10-80	12		30
2,4-Dinitrophenol	101		102		20-130	1		30
4,6-Dinitro-o-cresol	119		130		20-164	9		30
Pentachlorophenol	76		85		9-103	11		30
Phenol	46		59		12-110	25		30
2-Methylphenol	62		79		30-130	24		30
3-Methylphenol/4-Methylphenol	68		81		30-130	17		30
2,4,5-Trichlorophenol	82		94		30-130	14		30
Benzoic Acid	55		42		10-164	27		30
Benzyl Alcohol	63		81		26-116	25		30
Carbazole	79		81		55-144	3		30

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 01-02 Batch: WG1765509-2 WG1765509-3								

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
2-Fluorophenol	51		70		21-120
Phenol-d6	48		62		10-120
Nitrobenzene-d5	66		87		23-120
2-Fluorobiphenyl	65		77		15-120
2,4,6-Tribromophenol	104		116		10-120
4-Terphenyl-d14	73		79		41-149

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461:1

Lab Number: L2318715

Report Date: 04/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS-SIM - Westborough Lab Associated sample(s): 01-02 Batch: WG1765510-2 WG1765510-3								
Acenaphthene	76		84		40-140	10		40
2-Chloronaphthalene	69		79		40-140	14		40
Fluoranthene	92		90		40-140	2		40
Hexachlorobutadiene	55		70		40-140	24		40
Naphthalene	62		76		40-140	20		40
Benzo(a)anthracene	99		100		40-140	1		40
Benzo(a)pyrene	97		98		40-140	1		40
Benzo(b)fluoranthene	95		98		40-140	3		40
Benzo(k)fluoranthene	93		95		40-140	2		40
Chrysene	93		93		40-140	0		40
Acenaphthylene	77		84		40-140	9		40
Anthracene	88		92		40-140	4		40
Benzo(ghi)perylene	100		104		40-140	4		40
Fluorene	80		85		40-140	6		40
Phenanthrene	82		85		40-140	4		40
Dibenzo(a,h)anthracene	100		103		40-140	3		40
Indeno(1,2,3-cd)pyrene	108		110		40-140	2		40
Pyrene	91		88		40-140	3		40
2-Methylnaphthalene	67		78		40-140	15		40
Pentachlorophenol	74		79		40-140	7		40
Hexachlorobenzene	70		76		40-140	8		40
Hexachloroethane	52		73		40-140	34		40

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461:1

Lab Number: L2318715

Report Date: 04/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS-SIM - Westborough Lab Associated sample(s): 01-02 Batch: WG1765510-2 WG1765510-3								

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
2-Fluorophenol	58		73		21-120
Phenol-d6	54		63		10-120
Nitrobenzene-d5	76		95		23-120
2-Fluorobiphenyl	71		79		15-120
2,4,6-Tribromophenol	107		107		10-120
4-Terphenyl-d14	83		80		41-149

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 03-05 Batch: WG1766042-2 WG1766042-3								
Acenaphthene	60		59		31-137	2		50
1,2,4-Trichlorobenzene	56		55		38-107	2		50
Hexachlorobenzene	52		52		40-140	0		50
Bis(2-chloroethyl)ether	72		70		40-140	3		50
2-Chloronaphthalene	56		56		40-140	0		50
1,2-Dichlorobenzene	59		57		40-140	3		50
1,3-Dichlorobenzene	57		56		40-140	2		50
1,4-Dichlorobenzene	59		56		28-104	5		50
3,3'-Dichlorobenzidine	52		50		40-140	4		50
2,4-Dinitrotoluene	58		59		40-132	2		50
2,6-Dinitrotoluene	52		52		40-140	0		50
Fluoranthene	58		59		40-140	2		50
4-Chlorophenyl phenyl ether	53		53		40-140	0		50
4-Bromophenyl phenyl ether	52		51		40-140	2		50
Bis(2-chloroisopropyl)ether	90		90		40-140	0		50
Bis(2-chloroethoxy)methane	72		73		40-117	1		50
Hexachlorobutadiene	48		46		40-140	4		50
Hexachlorocyclopentadiene	47		48		40-140	2		50
Hexachloroethane	64		63		40-140	2		50
Isophorone	70		70		40-140	0		50
Naphthalene	60		59		40-140	2		50
Nitrobenzene	75		76		40-140	1		50
NDPA/DPA	59		60		36-157	2		50

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 03-05 Batch: WG1766042-2 WG1766042-3								
n-Nitrosodi-n-propylamine	78		80		32-121	3		50
Bis(2-ethylhexyl)phthalate	75		76		40-140	1		50
Butyl benzyl phthalate	70		71		40-140	1		50
Di-n-butylphthalate	69		71		40-140	3		50
Di-n-octylphthalate	74		78		40-140	5		50
Diethyl phthalate	65		63		40-140	3		50
Dimethyl phthalate	53		57		40-140	7		50
Benzo(a)anthracene	61		61		40-140	0		50
Benzo(a)pyrene	61		62		40-140	2		50
Benzo(b)fluoranthene	58		58		40-140	0		50
Benzo(k)fluoranthene	57		59		40-140	3		50
Chrysene	59		60		40-140	2		50
Acenaphthylene	59		63		40-140	7		50
Anthracene	58		61		40-140	5		50
Benzo(ghi)perylene	58		62		40-140	7		50
Fluorene	58		58		40-140	0		50
Phenanthrene	57		57		40-140	0		50
Dibenzo(a,h)anthracene	55		55		40-140	0		50
Indeno(1,2,3-cd)pyrene	59		59		40-140	0		50
Pyrene	59		60		35-142	2		50
Biphenyl	55		55		37-127	0		50
4-Chloroaniline	61		77		40-140	23		50
2-Nitroaniline	59		61		47-134	3		50

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 03-05 Batch: WG1766042-2 WG1766042-3								
3-Nitroaniline	53		50		26-129	6		50
4-Nitroaniline	66		64		41-125	3		50
Dibenzofuran	59		59		40-140	0		50
2-Methylnaphthalene	55		56		40-140	2		50
1,2,4,5-Tetrachlorobenzene	51		51		40-117	0		50
Acetophenone	72		71		14-144	1		50
2,4,6-Trichlorophenol	54		54		30-130	0		50
p-Chloro-m-cresol	66		68		26-103	3		50
2-Chlorophenol	66		65		25-102	2		50
2,4-Dichlorophenol	61		61		30-130	0		50
2,4-Dimethylphenol	67		68		30-130	1		50
2-Nitrophenol	60		61		30-130	2		50
4-Nitrophenol	86		88		11-114	2		50
2,4-Dinitrophenol	30		30		4-130	0		50
4,6-Dinitro-o-cresol	59		60		10-130	2		50
Pentachlorophenol	51		49		17-109	4		50
Phenol	76		74		26-90	3		50
2-Methylphenol	69		68		30-130.	1		50
3-Methylphenol/4-Methylphenol	70		69		30-130	1		50
2,4,5-Trichlorophenol	56		55		30-130	2		50
Benzoic Acid	**0**	Q	**0**	Q	10-110	NC		50
Benzyl Alcohol	80		79		40-140	1		50
Carbazole	63		62		54-128	2		50

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 03-05 Batch: WG1766042-2 WG1766042-3								
1,4-Dioxane	53		49		40-140	8		50

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
2-Fluorophenol	72		71		25-120
Phenol-d6	79		77		10-120
Nitrobenzene-d5	75		73		23-120
2-Fluorobiphenyl	54		53		30-120
2,4,6-Tribromophenol	55		55		10-136
4-Terphenyl-d14	50		51		18-120

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461:1

Lab Number: L2318715

Report Date: 04/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
1,4 Dioxane by 8270E-SIM - Mansfield Lab	Associated sample(s): 01-02		Batch: WG1766451-2 WG1766451-3					
1,4-Dioxane	106		109		40-140	3		30

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
1,4-Dioxane-d8	51		59		15-110

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

Parameter	Low Level LCS %Recovery	Qual	Low Level LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Perfluorinated Alkyl Acids by EPA 1633 - Mansfield Lab Associated sample(s): 03 Batch: WG1767336-2 LOW LEVEL								
Perfluorobutanoic Acid (PFBA)	101		-		40-150	-		30
Perfluoropentanoic Acid (PFPeA)	100		-		40-150	-		30
Perfluorobutanesulfonic Acid (PFBS)	101		-		40-150	-		30
Perfluorohexanoic Acid (PFHxA)	92		-		40-150	-		30
Perfluoroheptanoic Acid (PFHpA)	118		-		40-150	-		30
Perfluorohexanesulfonic Acid (PFHxS)	93		-		40-150	-		30
Perfluorooctanoic Acid (PFOA)	128		-		40-150	-		30
1H,1H,2H,2H-Perfluorooctanesulfonic Acid (6:2FTS)	108		-		40-150	-		30
Perfluoroheptanesulfonic Acid (PFHpS)	136		-		40-150	-		30
Perfluorononanoic Acid (PFNA)	88		-		40-150	-		30
Perfluorooctanesulfonic Acid (PFOS)	137		-		40-150	-		30
Perfluorodecanoic Acid (PFDA)	100		-		40-150	-		30
1H,1H,2H,2H-Perfluorodecanesulfonic Acid (8:2FTS)	110		-		40-150	-		30
N-Methyl Perfluorooctanesulfonamidoacetic Acid (NMeFOSAA)	110		-		40-150	-		30
Perfluoroundecanoic Acid (PFUnA)	95		-		40-150	-		30
Perfluorodecanesulfonic Acid (PFDS)	114		-		40-150	-		30
Perfluorooctanesulfonamide (PFOSA)	95		-		40-150	-		30
N-Ethyl Perfluorooctanesulfonamidoacetic Acid (NEtFOSAA)	120		-		40-150	-		30
Perfluorododecanoic Acid (PFDoA)	98		-		40-150	-		30
Perfluorotridecanoic Acid (PFTrDA)	85		-		40-150	-		30
Perfluorotetradecanoic Acid (PFTeDA)	80		-		40-150	-		30

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

Parameter	Low Level LCS %Recovery	Qual	Low Level LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Perfluorinated Alkyl Acids by EPA 1633 - Mansfield Lab Associated sample(s): 03 Batch: WG1767336-2 LOW LEVEL								

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
Perfluoro-n-[13C4]Butanoic Acid (13C4-PFBA)	90				20-150
Perfluoro-n-[13C5]Pentanoic Acid (13C5-PFPeA)	96				20-150
Perfluoro-1-[2,3,4-13C3]Butanesulfonic Acid (13C3-PFBS)	88				20-150
Perfluoro-n-[1,2,3,4,6-13C5]Hexanoic Acid (13C5-PFHxA)	103				20-150
Perfluoro-n-[1,2,3,4-13C4]Heptanoic Acid (13C4-PFHpA)	81				20-150
Perfluoro-1-[1,2,3-13C3]Hexanesulfonic Acid (13C3-PFHxS)	100				20-150
Perfluoro-n-[13C8]Octanoic Acid (13C8-PFOA)	70				20-150
1H,1H,2H,2H-Perfluoro-1-[1,2-13C2]Octanesulfonic Acid (13C2-6:2FTS)	87				20-150
Perfluoro-n-[13C9]Nonanoic Acid (13C9-PFNA)	94				20-150
Perfluoro-1-[13C8]Octanesulfonic Acid (13C8-PFOS)	90				20-150
Perfluoro-n-[1,2,3,4,5,6-13C6]Decanoic Acid (13C6-PFDA)	91				20-150
1H,1H,2H,2H-Perfluoro-1-[1,2-13C2]Decanesulfonic Acid (13C2-8:2FTS)	92				20-150
N-Methyl-d3-perfluoro-1-octanesulfonamidoacetic Acid (D3-NMeFOSAA)	**192**	Q			20-150
Perfluoro-n-[1,2,3,4,5,6,7-13C7]Undecanoic Acid (13C7-PFUnA)	97				20-150
Perfluoro-1-[13C8]Octanesulfonamide (13C8-PFOSA)	90				20-150
N-Ethyl-d5-perfluoro-1-octanesulfonamidoacetic Acid (D5-NEtFOSAA)	134				20-150
Perfluoro-n-[1,2-13C2]Dodecanoic Acid (13C2-PFDoA)	81				20-150
Perfluoro-n-[1,2-13C2]Tetradecanoic Acid (13C2-PFTeDA)	64				20-150

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Perfluorinated Alkyl Acids by EPA 1633 - Mansfield Lab Associated sample(s): 03 Batch: WG1767336-3								
Perfluorobutanoic Acid (PFBA)	103		-		40-150	-		30
Perfluoropentanoic Acid (PFPeA)	101		-		40-150	-		30
Perfluorobutanesulfonic Acid (PFBS)	94		-		40-150	-		30
Perfluorohexanoic Acid (PFHxA)	97		-		40-150	-		30
Perfluoroheptanoic Acid (PFHpA)	116		-		40-150	-		30
Perfluorohexanesulfonic Acid (PFHxS)	101		-		40-150	-		30
Perfluorooctanoic Acid (PFOA)	119		-		40-150	-		30
1H,1H,2H,2H-Perfluorooctanesulfonic Acid (6:2FTS)	109		-		40-150	-		30
Perfluoroheptanesulfonic Acid (PFHpS)	131		-		40-150	-		30
Perfluorononanoic Acid (PFNA)	90		-		40-150	-		30
Perfluorooctanesulfonic Acid (PFOS)	118		-		40-150	-		30
Perfluorodecanoic Acid (PFDA)	97		-		40-150	-		30
1H,1H,2H,2H-Perfluorodecanesulfonic Acid (8:2FTS)	116		-		40-150	-		30
N-Methyl Perfluorooctanesulfonamidoacetic Acid (NMeFOSAA)	108		-		40-150	-		30
Perfluoroundecanoic Acid (PFUnA)	101		-		40-150	-		30
Perfluorodecanesulfonic Acid (PFDS)	112		-		40-150	-		30
Perfluorooctanesulfonamide (PFOSA)	88		-		40-150	-		30
N-Ethyl Perfluorooctanesulfonamidoacetic Acid (NEtFOSAA)	104		-		40-150	-		30
Perfluorododecanoic Acid (PFDoA)	99		-		40-150	-		30
Perfluorotridecanoic Acid (PFTrDA)	82		-		40-150	-		30
Perfluorotetradecanoic Acid (PFTeDA)	103		-		40-150	-		30

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461:1

Lab Number: L2318715

Report Date: 04/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Perfluorinated Alkyl Acids by EPA 1633 - Mansfield Lab Associated sample(s): 03 Batch: WG1767336-3								

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
Perfluoro-n-[13C4]Butanoic Acid (13C4-PFBA)	83				20-150
Perfluoro-n-[13C5]Pentanoic Acid (13C5-PFPeA)	84				20-150
Perfluoro-1-[2,3,4-13C3]Butanesulfonic Acid (13C3-PFBS)	83				20-150
Perfluoro-n-[1,2,3,4,6-13C5]Hexanoic Acid (13C5-PFHxA)	87				20-150
Perfluoro-n-[1,2,3,4-13C4]Heptanoic Acid (13C4-PFHpA)	70				20-150
Perfluoro-1-[1,2,3-13C3]Hexanesulfonic Acid (13C3-PFHxS)	82				20-150
Perfluoro-n-[13C8]Octanoic Acid (13C8-PFOA)	70				20-150
1H,1H,2H,2H-Perfluoro-1-[1,2-13C2]Octanesulfonic Acid (13C2-6:2FTS)	83				20-150
Perfluoro-n-[13C9]Nonanoic Acid (13C9-PFNA)	88				20-150
Perfluoro-1-[13C8]Octanesulfonic Acid (13C8-PFOS)	86				20-150
Perfluoro-n-[1,2,3,4,5,6-13C6]Decanoic Acid (13C6-PFDA)	88				20-150
1H,1H,2H,2H-Perfluoro-1-[1,2-13C2]Decanesulfonic Acid (13C2-8:2FTS)	86				20-150
N-Methyl-d3-perfluoro-1-octanesulfonamidoacetic Acid (D3-NMeFOSAA)	**173**	Q			20-150
Perfluoro-n-[1,2,3,4,5,6,7-13C7]Undecanoic Acid (13C7-PFUnA)	79				20-150
Perfluoro-1-[13C8]Octanesulfonamide (13C8-PFOSA)	81				20-150
N-Ethyl-d5-perfluoro-1-octanesulfonamidoacetic Acid (D5-NEtFOSAA)	120				20-150
Perfluoro-n-[1,2-13C2]Dodecanoic Acid (13C2-PFDoA)	74				20-150
Perfluoro-n-[1,2-13C2]Tetradecanoic Acid (13C2-PFTeDA)	60				20-150

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461:1

Lab Number: L2318715

Report Date: 04/24/23

Parameter	Low Level LCS %Recovery	Qual	Low Level LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Perfluorinated Alkyl Acids by EPA 1633 - Mansfield Lab Associated sample(s): 01-02 Batch: WG1769021-2 LOW LEVEL								
Perfluorobutanoic Acid (PFBA)	91		-		40-150	-		30
Perfluoropentanoic Acid (PFPeA)	92		-		40-150	-		30
Perfluorobutanesulfonic Acid (PFBS)	96		-		40-150	-		30
Perfluorohexanoic Acid (PFHxA)	102		-		40-150	-		30
Perfluoroheptanoic Acid (PFHpA)	98		-		40-150	-		30
Perfluorohexanesulfonic Acid (PFHxS)	90		-		40-150	-		30
Perfluorooctanoic Acid (PFOA)	98		-		40-150	-		30
1H,1H,2H,2H-Perfluorooctanesulfonic Acid (6:2FTS)	93		-		40-150	-		30
Perfluoroheptanesulfonic Acid (PFHpS)	94		-		40-150	-		30
Perfluorononanoic Acid (PFNA)	100		-		40-150	-		30
Perfluorooctanesulfonic Acid (PFOS)	92		-		40-150	-		30
Perfluorodecanoic Acid (PFDA)	90		-		40-150	-		30
1H,1H,2H,2H-Perfluorodecanesulfonic Acid (8:2FTS)	101		-		40-150	-		30
N-Methyl Perfluorooctanesulfonamidoacetic Acid (NMeFOSAA)	70		-		40-150	-		30
Perfluoroundecanoic Acid (PFUnA)	95		-		40-150	-		30
Perfluorodecanesulfonic Acid (PFDS)	83		-		40-150	-		30
Perfluorooctanesulfonamide (PFOSA)	95		-		40-150	-		30
N-Ethyl Perfluorooctanesulfonamidoacetic Acid (NEtFOSAA)	80		-		40-150	-		30
Perfluorododecanoic Acid (PFDoA)	88		-		40-150	-		30
Perfluorotridecanoic Acid (PFTrDA)	92		-		40-150	-		30
Perfluorotetradecanoic Acid (PFTeDA)	88		-		40-150	-		30

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461:1

Lab Number: L2318715

Report Date: 04/24/23

Parameter	Low Level LCS %Recovery	Qual	Low Level LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits

Perfluorinated Alkyl Acids by EPA 1633 - Mansfield Lab Associated sample(s): 01-02 Batch: WG1769021-2 LOW LEVEL

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
Perfluoro-n-[13C4]Butanoic Acid (13C4-PFBA)	90				20-150
Perfluoro-n-[13C5]Pentanoic Acid (13C5-PFPeA)	95				20-150
Perfluoro-1-[2,3,4-13C3]Butanesulfonic Acid (13C3-PFBS)	99				20-150
Perfluoro-n-[1,2,3,4,6-13C5]Hexanoic Acid (13C5-PFHxA)	90				20-150
Perfluoro-n-[1,2,3,4-13C4]Heptanoic Acid (13C4-PFHpA)	88				20-150
Perfluoro-1-[1,2,3-13C3]Hexanesulfonic Acid (13C3-PFHxS)	90				20-150
Perfluoro-n-[13C8]Octanoic Acid (13C8-PFOA)	90				20-150
1H,1H,2H,2H-Perfluoro-1-[1,2-13C2]Octanesulfonic Acid (13C2-6:2FTS)	84				20-150
Perfluoro-n-[13C9]Nonanoic Acid (13C9-PFNA)	87				20-150
Perfluoro-1-[13C8]Octanesulfonic Acid (13C8-PFOS)	85				20-150
Perfluoro-n-[1,2,3,4,5,6-13C6]Decanoic Acid (13C6-PFDA)	92				20-150
1H,1H,2H,2H-Perfluoro-1-[1,2-13C2]Decanesulfonic Acid (13C2-8:2FTS)	81				20-150
N-Methyl-d3-perfluoro-1-octanesulfonamidoacetic Acid (D3-NMeFOSAA)	66				20-150
Perfluoro-n-[1,2,3,4,5,6,7-13C7]Undecanoic Acid (13C7-PFUnA)	85				20-150
Perfluoro-1-[13C8]Octanesulfonamide (13C8-PFOSA)	69				20-150
N-Ethyl-d5-perfluoro-1-octanesulfonamidoacetic Acid (D5-NEtFOSAA)	70				20-150
Perfluoro-n-[1,2-13C2]Dodecanoic Acid (13C2-PFDoA)	79				20-150
Perfluoro-n-[1,2-13C2]Tetradecanoic Acid (13C2-PFTeDA)	82				20-150

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Perfluorinated Alkyl Acids by EPA 1633 - Mansfield Lab Associated sample(s): 01-02 Batch: WG1769021-3								
Perfluorobutanoic Acid (PFBA)	105		-		40-150	-		30
Perfluoropentanoic Acid (PFPeA)	99		-		40-150	-		30
Perfluorobutanesulfonic Acid (PFBS)	103		-		40-150	-		30
Perfluorohexanoic Acid (PFHxA)	105		-		40-150	-		30
Perfluoroheptanoic Acid (PFHpA)	108		-		40-150	-		30
Perfluorohexanesulfonic Acid (PFHxS)	101		-		40-150	-		30
Perfluorooctanoic Acid (PFOA)	107		-		40-150	-		30
1H,1H,2H,2H-Perfluorooctanesulfonic Acid (6:2FTS)	98		-		40-150	-		30
Perfluoroheptanesulfonic Acid (PFHpS)	112		-		40-150	-		30
Perfluorononanoic Acid (PFNA)	95		-		40-150	-		30
Perfluorooctanesulfonic Acid (PFOS)	103		-		40-150	-		30
Perfluorodecanoic Acid (PFDA)	111		-		40-150	-		30
1H,1H,2H,2H-Perfluorodecanesulfonic Acid (8:2FTS)	105		-		40-150	-		30
N-Methyl Perfluorooctanesulfonamidoacetic Acid (NMeFOSAA)	109		-		40-150	-		30
Perfluoroundecanoic Acid (PFUnA)	94		-		40-150	-		30
Perfluorodecanesulfonic Acid (PFDS)	94		-		40-150	-		30
Perfluorooctanesulfonamide (PFOSA)	104		-		40-150	-		30
N-Ethyl Perfluorooctanesulfonamidoacetic Acid (NEtFOSAA)	96		-		40-150	-		30
Perfluorododecanoic Acid (PFDoA)	93		-		40-150	-		30
Perfluorotridecanoic Acid (PFTrDA)	94		-		40-150	-		30
Perfluorotetradecanoic Acid (PFTeDA)	115		-		40-150	-		30

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461:1

Lab Number: L2318715

Report Date: 04/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits

Perfluorinated Alkyl Acids by EPA 1633 - Mansfield Lab Associated sample(s): 01-02 Batch: WG1769021-3

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
Perfluoro-n-[13C4]Butanoic Acid (13C4-PFBA)	88				20-150
Perfluoro-n-[13C5]Pentanoic Acid (13C5-PFPeA)	86				20-150
Perfluoro-1-[2,3,4-13C3]Butanesulfonic Acid (13C3-PFBS)	91				20-150
Perfluoro-n-[1,2,3,4,6-13C5]Hexanoic Acid (13C5-PFHxA)	90				20-150
Perfluoro-n-[1,2,3,4-13C4]Heptanoic Acid (13C4-PFHpA)	78				20-150
Perfluoro-1-[1,2,3-13C3]Hexanesulfonic Acid (13C3-PFHxS)	87				20-150
Perfluoro-n-[13C8]Octanoic Acid (13C8-PFOA)	86				20-150
1H,1H,2H,2H-Perfluoro-1-[1,2-13C2]Octanesulfonic Acid (13C2-6:2FTS)	86				20-150
Perfluoro-n-[13C9]Nonanoic Acid (13C9-PFNA)	94				20-150
Perfluoro-1-[13C8]Octanesulfonic Acid (13C8-PFOS)	84				20-150
Perfluoro-n-[1,2,3,4,5,6-13C6]Decanoic Acid (13C6-PFDA)	98				20-150
1H,1H,2H,2H-Perfluoro-1-[1,2-13C2]Decanesulfonic Acid (13C2-8:2FTS)	81				20-150
N-Methyl-d3-perfluoro-1-octanesulfonamidoacetic Acid (D3-NMeFOSAA)	60				20-150
Perfluoro-n-[1,2,3,4,5,6,7-13C7]Undecanoic Acid (13C7-PFUnA)	100				20-150
Perfluoro-1-[13C8]Octanesulfonamide (13C8-PFOSA)	68				20-150
N-Ethyl-d5-perfluoro-1-octanesulfonamidoacetic Acid (D5-NEtFOSAA)	70				20-150
Perfluoro-n-[1,2-13C2]Dodecanoic Acid (13C2-PFDoA)	94				20-150
Perfluoro-n-[1,2-13C2]Tetradecanoic Acid (13C2-PFTeDA)	73				20-150

PCBS

Project Name: 100 MAIN ST.
Lab Number: L2318715
Project Number: 12461:1
Report Date: 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-01
Client ID: GW-8
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 08:15
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8082A
Analytical Date: 04/13/23 21:03
Analyst: RMP

Extraction Method: EPA 3510C
Extraction Date: 04/12/23 07:38
Cleanup Method: EPA 3665A
Cleanup Date: 04/13/23
Cleanup Method: EPA 3660B
Cleanup Date: 04/13/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/l	0.071	0.061	1	A
Aroclor 1221	ND		ug/l	0.071	0.061	1	A
Aroclor 1232	ND		ug/l	0.071	0.061	1	A
Aroclor 1242	ND		ug/l	0.071	0.061	1	A
Aroclor 1248	ND		ug/l	0.071	0.061	1	A
Aroclor 1254	ND		ug/l	0.071	0.061	1	A
Aroclor 1260	ND		ug/l	0.071	0.061	1	A
Aroclor 1262	ND		ug/l	0.071	0.061	1	A
Aroclor 1268	ND		ug/l	0.071	0.061	1	A
PCBs, Total	ND		ug/l	0.071	0.061	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	91		30-150	A
Decachlorobiphenyl	81		30-150	A
2,4,5,6-Tetrachloro-m-xylene	91		30-150	B
Decachlorobiphenyl	65		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461:1
Lab Number: L2318715
Report Date: 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-02
Client ID: GW-9
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 13:45
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8082A
Analytical Date: 04/13/23 21:12
Analyst: RMP

Extraction Method: EPA 3510C
Extraction Date: 04/12/23 07:38
Cleanup Method: EPA 3665A
Cleanup Date: 04/13/23
Cleanup Method: EPA 3660B
Cleanup Date: 04/13/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/l	0.071	0.061	1	A
Aroclor 1221	ND		ug/l	0.071	0.061	1	A
Aroclor 1232	ND		ug/l	0.071	0.061	1	A
Aroclor 1242	ND		ug/l	0.071	0.061	1	A
Aroclor 1248	ND		ug/l	0.071	0.061	1	A
Aroclor 1254	ND		ug/l	0.071	0.061	1	A
Aroclor 1260	ND		ug/l	0.071	0.061	1	A
Aroclor 1262	ND		ug/l	0.071	0.061	1	A
Aroclor 1268	ND		ug/l	0.071	0.061	1	A
PCBs, Total	ND		ug/l	0.071	0.061	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	95		30-150	A
Decachlorobiphenyl	97		30-150	A
2,4,5,6-Tetrachloro-m-xylene	85		30-150	B
Decachlorobiphenyl	98		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461:1
Lab Number: L2318715
Report Date: 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-03
Client ID: SB-8G (1.5-2)
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 10:45
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8082A
Analytical Date: 04/14/23 11:02
Analyst: MEO
Percent Solids: 88%

Extraction Method: EPA 3546
Extraction Date: 04/13/23 01:37
Cleanup Method: EPA 3665A
Cleanup Date: 04/13/23
Cleanup Method: EPA 3660B
Cleanup Date: 04/14/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/kg	36.0	3.20	1	A
Aroclor 1221	ND		ug/kg	36.0	3.61	1	A
Aroclor 1232	ND		ug/kg	36.0	7.63	1	A
Aroclor 1242	ND		ug/kg	36.0	4.85	1	A
Aroclor 1248	ND		ug/kg	36.0	5.40	1	A
Aroclor 1254	ND		ug/kg	36.0	3.94	1	A
Aroclor 1260	ND		ug/kg	36.0	6.65	1	A
Aroclor 1262	ND		ug/kg	36.0	4.57	1	A
Aroclor 1268	ND		ug/kg	36.0	3.73	1	A
PCBs, Total	ND		ug/kg	36.0	3.20	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	54		30-150	A
Decachlorobiphenyl	45		30-150	A
2,4,5,6-Tetrachloro-m-xylene	50		30-150	B
Decachlorobiphenyl	**420**	Q	30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461:1
Lab Number: L2318715
Report Date: 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-04
Client ID: SB-20G (2.5-3)
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 14:30
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8082A
Analytical Date: 04/14/23 11:14
Analyst: MEO
Percent Solids: 93%

Extraction Method: EPA 3546
Extraction Date: 04/13/23 01:37
Cleanup Method: EPA 3665A
Cleanup Date: 04/13/23
Cleanup Method: EPA 3660B
Cleanup Date: 04/14/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/kg	34.0	3.02	1	A
Aroclor 1221	ND		ug/kg	34.0	3.40	1	A
Aroclor 1232	ND		ug/kg	34.0	7.20	1	A
Aroclor 1242	ND		ug/kg	34.0	4.58	1	A
Aroclor 1248	ND		ug/kg	34.0	5.10	1	A
Aroclor 1254	ND		ug/kg	34.0	3.72	1	A
Aroclor 1260	ND		ug/kg	34.0	6.28	1	A
Aroclor 1262	ND		ug/kg	34.0	4.31	1	A
Aroclor 1268	ND		ug/kg	34.0	3.52	1	A
PCBs, Total	ND		ug/kg	34.0	3.02	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	58		30-150	A
Decachlorobiphenyl	48		30-150	A
2,4,5,6-Tetrachloro-m-xylene	57		30-150	B
Decachlorobiphenyl	56		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461:1
Lab Number: L2318715
Report Date: 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-05
Client ID: SB-21G (0.5-1)
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 14:15
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8082A
Analytical Date: 04/14/23 11:27
Analyst: MEO
Percent Solids: 92%

Extraction Method: EPA 3546
Extraction Date: 04/13/23 01:37
Cleanup Method: EPA 3665A
Cleanup Date: 04/13/23
Cleanup Method: EPA 3660B
Cleanup Date: 04/14/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/kg	34.6	3.08	1	A
Aroclor 1221	ND		ug/kg	34.6	3.47	1	A
Aroclor 1232	ND		ug/kg	34.6	7.35	1	A
Aroclor 1242	ND		ug/kg	34.6	4.67	1	A
Aroclor 1248	ND		ug/kg	34.6	5.20	1	A
Aroclor 1254	ND		ug/kg	34.6	3.79	1	A
Aroclor 1260	ND		ug/kg	34.6	6.40	1	A
Aroclor 1262	ND		ug/kg	34.6	4.40	1	A
Aroclor 1268	ND		ug/kg	34.6	3.59	1	A
PCBs, Total	ND		ug/kg	34.6	3.08	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	48		30-150	A
Decachlorobiphenyl	40		30-150	A
2,4,5,6-Tetrachloro-m-xylene	44		30-150	B
Decachlorobiphenyl	43		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461:1
Lab Number: L2318715
Report Date: 04/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8082A
Analytical Date: 04/12/23 10:17
Analyst: JM

Extraction Method: EPA 3510C
Extraction Date: 04/12/23 04:01
Cleanup Method: EPA 3665A
Cleanup Date: 04/12/23
Cleanup Method: EPA 3660B
Cleanup Date: 04/12/23

Parameter	Result	Qualifier	Units	RL	MDL	Column
Polychlorinated Biphenyls by GC - Westborough Lab for sample(s): 01-02 Batch: WG1765560-1						
Aroclor 1016	ND		ug/l	0.071	0.061	A
Aroclor 1221	ND		ug/l	0.071	0.061	A
Aroclor 1232	ND		ug/l	0.071	0.061	A
Aroclor 1242	ND		ug/l	0.071	0.061	A
Aroclor 1248	ND		ug/l	0.071	0.061	A
Aroclor 1254	ND		ug/l	0.071	0.061	A
Aroclor 1260	ND		ug/l	0.071	0.061	A
Aroclor 1262	ND		ug/l	0.071	0.061	A
Aroclor 1268	ND		ug/l	0.071	0.061	A
PCBs, Total	ND		ug/l	0.071	0.061	A

Surrogate	%Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	113		30-150	A
Decachlorobiphenyl	103		30-150	A
2,4,5,6-Tetrachloro-m-xylene	102		30-150	B
Decachlorobiphenyl	101		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461:1
Lab Number: L2318715
Report Date: 04/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8082A
Analytical Date: 04/13/23 10:20
Analyst: ER

Extraction Method: EPA 3546
Extraction Date: 04/12/23 21:54
Cleanup Method: EPA 3665A
Cleanup Date: 04/13/23
Cleanup Method: EPA 3660B
Cleanup Date: 04/13/23

Parameter	Result	Qualifier	Units	RL	MDL	Column
Polychlorinated Biphenyls by GC - Westborough Lab for sample(s): 03-05 Batch: WG1766021-1						
Aroclor 1016	ND		ug/kg	32.9	2.92	A
Aroclor 1221	ND		ug/kg	32.9	3.30	A
Aroclor 1232	ND		ug/kg	32.9	6.97	A
Aroclor 1242	ND		ug/kg	32.9	4.43	A
Aroclor 1248	ND		ug/kg	32.9	4.93	A
Aroclor 1254	ND		ug/kg	32.9	3.60	A
Aroclor 1260	ND		ug/kg	32.9	6.08	A
Aroclor 1262	ND		ug/kg	32.9	4.18	A
Aroclor 1268	ND		ug/kg	32.9	3.41	A
PCBs, Total	ND		ug/kg	32.9	2.92	A

Surrogate	%Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	83		30-150	A
Decachlorobiphenyl	94		30-150	A
2,4,5,6-Tetrachloro-m-xylene	86		30-150	B
Decachlorobiphenyl	99		30-150	B

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461:1

Lab Number: L2318715

Report Date: 04/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits	Column
Polychlorinated Biphenyls by GC - Westborough Lab Associated sample(s): 01-02 Batch: WG1765560-2 WG1765560-3									
Aroclor 1016	83		89		40-140	6		50	A
Aroclor 1260	76		81		40-140	6		50	A

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	92		97		30-150	A
Decachlorobiphenyl	91		96		30-150	A
2,4,5,6-Tetrachloro-m-xylene	80		85		30-150	B
Decachlorobiphenyl	93		100		30-150	B

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits	Column
Polychlorinated Biphenyls by GC - Westborough Lab Associated sample(s): 03-05 Batch: WG1766021-2 WG1766021-3									
Aroclor 1016	88		86		40-140	2		50	A
Aroclor 1260	87		84		40-140	4		50	A

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	82		78		30-150	A
Decachlorobiphenyl	90		87		30-150	A
2,4,5,6-Tetrachloro-m-xylene	83		79		30-150	B
Decachlorobiphenyl	94		92		30-150	B

PESTICIDES

Project Name: 100 MAIN ST.
Project Number: 12461:1
Lab Number: L2318715
Report Date: 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-01
Client ID: GW-8
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 08:15
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8081B
Analytical Date: 04/10/23 21:00
Analyst: AAR

Extraction Method: EPA 3510C
Extraction Date: 04/10/23 00:36

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/l	0.014	0.003	1	A
Lindane	ND		ug/l	0.014	0.003	1	A
Alpha-BHC	ND		ug/l	0.014	0.003	1	A
Beta-BHC	ND		ug/l	0.014	0.004	1	A
Heptachlor	ND		ug/l	0.014	0.002	1	A
Aldrin	ND		ug/l	0.014	0.002	1	A
Heptachlor epoxide	ND		ug/l	0.014	0.003	1	A
Endrin	ND		ug/l	0.029	0.003	1	A
Endrin aldehyde	ND		ug/l	0.029	0.006	1	A
Endrin ketone	ND		ug/l	0.029	0.003	1	A
Dieldrin	ND		ug/l	0.029	0.003	1	A
4,4'-DDE	ND		ug/l	0.029	0.003	1	A
4,4'-DDD	ND		ug/l	0.029	0.003	1	A
4,4'-DDT	ND		ug/l	0.029	0.003	1	A
Endosulfan I	ND		ug/l	0.014	0.002	1	A
Endosulfan II	ND		ug/l	0.029	0.004	1	A
Endosulfan sulfate	ND		ug/l	0.029	0.003	1	A
Methoxychlor	ND		ug/l	0.143	0.005	1	A
Toxaphene	ND		ug/l	0.143	0.045	1	A
cis-Chlordane	ND		ug/l	0.014	0.005	1	A
trans-Chlordane	ND		ug/l	0.014	0.004	1	A
Chlordane	ND		ug/l	0.143	0.033	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-01 Date Collected: 04/07/23 08:15

Client ID: GW-8 Date Received: 04/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	71		30-150	A
Decachlorobiphenyl	79		30-150	A
2,4,5,6-Tetrachloro-m-xylene	63		30-150	B
Decachlorobiphenyl	71		30-150	B

Project Name: 100 MAIN ST.
Lab Number: L2318715
Project Number: 12461:1
Report Date: 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-02
Client ID: GW-9
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 13:45
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8081B
Analytical Date: 04/10/23 21:21
Analyst: AAR

Extraction Method: EPA 3510C
Extraction Date: 04/10/23 00:36

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/l	0.014	0.003	1	A
Lindane	ND		ug/l	0.014	0.003	1	A
Alpha-BHC	ND		ug/l	0.014	0.003	1	A
Beta-BHC	ND		ug/l	0.014	0.004	1	A
Heptachlor	ND		ug/l	0.014	0.002	1	A
Aldrin	ND		ug/l	0.014	0.002	1	A
Heptachlor epoxide	ND		ug/l	0.014	0.003	1	A
Endrin	ND		ug/l	0.029	0.003	1	A
Endrin aldehyde	ND		ug/l	0.029	0.006	1	A
Endrin ketone	ND		ug/l	0.029	0.003	1	A
Dieldrin	ND		ug/l	0.029	0.003	1	A
4,4'-DDE	ND		ug/l	0.029	0.003	1	A
4,4'-DDD	ND		ug/l	0.029	0.003	1	A
4,4'-DDT	ND		ug/l	0.029	0.003	1	A
Endosulfan I	ND		ug/l	0.014	0.002	1	A
Endosulfan II	ND		ug/l	0.029	0.004	1	A
Endosulfan sulfate	ND		ug/l	0.029	0.003	1	A
Methoxychlor	ND		ug/l	0.143	0.005	1	A
Toxaphene	ND		ug/l	0.143	0.045	1	A
cis-Chlordane	ND		ug/l	0.014	0.005	1	A
trans-Chlordane	ND		ug/l	0.014	0.004	1	A
Chlordane	ND		ug/l	0.143	0.033	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-02 Date Collected: 04/07/23 13:45

Client ID: GW-9 Date Received: 04/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	77		30-150	A
Decachlorobiphenyl	85		30-150	A
2,4,5,6-Tetrachloro-m-xylene	80		30-150	B
Decachlorobiphenyl	129		30-150	B

Project Name: 100 MAIN ST.
Lab Number: L2318715
Project Number: 12461:1
Report Date: 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-03
Client ID: SB-8G (1.5-2)
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 10:45
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8081B
Analytical Date: 04/14/23 09:34
Analyst: AKM
Percent Solids: 88%

Extraction Method: EPA 3546
Extraction Date: 04/13/23 11:04
Cleanup Method: EPA 3620B
Cleanup Date: 04/14/23
Cleanup Method: EPA 3660B
Cleanup Date: 04/14/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/kg	1.82	0.357	1	A
Lindane	ND		ug/kg	0.759	0.339	1	A
Alpha-BHC	ND		ug/kg	0.759	0.216	1	A
Beta-BHC	ND		ug/kg	1.82	0.691	1	A
Heptachlor	ND		ug/kg	0.911	0.408	1	A
Aldrin	ND		ug/kg	1.82	0.642	1	A
Heptachlor epoxide	ND		ug/kg	3.42	1.02	1	A
Endrin	ND		ug/kg	0.759	0.311	1	A
Endrin aldehyde	ND		ug/kg	2.28	0.797	1	A
Endrin ketone	ND		ug/kg	1.82	0.469	1	A
Dieldrin	ND		ug/kg	1.14	0.569	1	A
4,4'-DDE	ND		ug/kg	1.82	0.421	1	A
4,4'-DDD	ND		ug/kg	1.82	0.650	1	A
4,4'-DDT	ND		ug/kg	1.82	1.46	1	A
Endosulfan I	ND		ug/kg	1.82	0.430	1	A
Endosulfan II	ND		ug/kg	1.82	0.609	1	A
Endosulfan sulfate	ND		ug/kg	0.759	0.361	1	A
Methoxychlor	ND		ug/kg	3.42	1.06	1	A
Toxaphene	ND		ug/kg	34.2	9.57	1	A
cis-Chlordane	ND		ug/kg	2.28	0.635	1	A
trans-Chlordane	ND		ug/kg	2.28	0.601	1	A
Chlordane	ND		ug/kg	15.2	6.04	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-03 Date Collected: 04/07/23 10:45

Client ID: SB-8G (1.5-2) Date Received: 04/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	79		30-150	A
Decachlorobiphenyl	98		30-150	A
2,4,5,6-Tetrachloro-m-xylene	76		30-150	B
Decachlorobiphenyl	95		30-150	B

Project Name: 100 MAIN ST.
Lab Number: L2318715
Project Number: 12461:1
Report Date: 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-04
Client ID: SB-20G (2.5-3)
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 14:30
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8081B
Analytical Date: 04/14/23 09:46
Analyst: AKM
Percent Solids: 93%

Extraction Method: EPA 3546
Extraction Date: 04/13/23 11:04
Cleanup Method: EPA 3620B
Cleanup Date: 04/14/23
Cleanup Method: EPA 3660B
Cleanup Date: 04/14/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/kg	1.68	0.329	1	A
Lindane	ND		ug/kg	0.701	0.313	1	A
Alpha-BHC	ND		ug/kg	0.701	0.199	1	A
Beta-BHC	ND		ug/kg	1.68	0.638	1	A
Heptachlor	ND		ug/kg	0.841	0.377	1	A
Aldrin	ND		ug/kg	1.68	0.592	1	A
Heptachlor epoxide	ND		ug/kg	3.15	0.946	1	A
Endrin	ND		ug/kg	0.701	0.287	1	A
Endrin aldehyde	ND		ug/kg	2.10	0.736	1	A
Endrin ketone	ND		ug/kg	1.68	0.433	1	A
Dieldrin	ND		ug/kg	1.05	0.526	1	A
4,4'-DDE	ND		ug/kg	1.68	0.389	1	A
4,4'-DDD	ND		ug/kg	1.68	0.600	1	A
4,4'-DDT	ND		ug/kg	1.68	1.35	1	A
Endosulfan I	ND		ug/kg	1.68	0.397	1	A
Endosulfan II	ND		ug/kg	1.68	0.562	1	A
Endosulfan sulfate	ND		ug/kg	0.701	0.334	1	A
Methoxychlor	ND		ug/kg	3.15	0.981	1	A
Toxaphene	ND		ug/kg	31.5	8.83	1	A
cis-Chlordane	ND		ug/kg	2.10	0.586	1	A
trans-Chlordane	ND		ug/kg	2.10	0.555	1	A
Chlordane	ND		ug/kg	14.0	5.57	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-04 Date Collected: 04/07/23 14:30

Client ID: SB-20G (2.5-3) Date Received: 04/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	79		30-150	A
Decachlorobiphenyl	91		30-150	A
2,4,5,6-Tetrachloro-m-xylene	78		30-150	B
Decachlorobiphenyl	89		30-150	B

Project Name: 100 MAIN ST.
Lab Number: L2318715
Project Number: 12461:1
Report Date: 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-05
Client ID: SB-21G (0.5-1)
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 14:15
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8081B
Analytical Date: 04/14/23 09:57
Analyst: AKM
Percent Solids: 92%

Extraction Method: EPA 3546
Extraction Date: 04/13/23 11:04
Cleanup Method: EPA 3620B
Cleanup Date: 04/14/23
Cleanup Method: EPA 3660B
Cleanup Date: 04/14/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/kg	1.73	0.340	1	A
Lindane	ND		ug/kg	0.722	0.323	1	A
Alpha-BHC	ND		ug/kg	0.722	0.205	1	A
Beta-BHC	ND		ug/kg	1.73	0.658	1	A
Heptachlor	ND		ug/kg	0.867	0.389	1	A
Aldrin	ND		ug/kg	1.73	0.610	1	A
Heptachlor epoxide	ND		ug/kg	3.25	0.975	1	A
Endrin	ND		ug/kg	0.722	0.296	1	A
Endrin aldehyde	ND		ug/kg	2.17	0.759	1	A
Endrin ketone	ND		ug/kg	1.73	0.446	1	A
Dieldrin	ND		ug/kg	1.08	0.542	1	A
4,4'-DDE	ND		ug/kg	1.73	0.401	1	A
4,4'-DDD	ND		ug/kg	1.73	0.618	1	A
4,4'-DDT	ND	IP	ug/kg	1.73	1.39	1	A
Endosulfan I	ND		ug/kg	1.73	0.410	1	A
Endosulfan II	ND		ug/kg	1.73	0.580	1	A
Endosulfan sulfate	ND		ug/kg	0.722	0.344	1	A
Methoxychlor	ND		ug/kg	3.25	1.01	1	A
Toxaphene	ND		ug/kg	32.5	9.10	1	A
cis-Chlordane	ND		ug/kg	2.17	0.604	1	A
trans-Chlordane	ND		ug/kg	2.17	0.572	1	A
Chlordane	ND		ug/kg	14.4	5.74	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-05 Date Collected: 04/07/23 14:15

Client ID: SB-21G (0.5-1) Date Received: 04/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	90		30-150	A
Decachlorobiphenyl	103		30-150	A
2,4,5,6-Tetrachloro-m-xylene	87		30-150	B
Decachlorobiphenyl	100		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461:1
Lab Number: L2318715
Report Date: 04/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8081B
Analytical Date: 04/10/23 19:10
Analyst: AAR

Extraction Method: EPA 3510C
Extraction Date: 04/09/23 21:30

Parameter	Result	Qualifier	Units	RL	MDL	Column
Organochlorine Pesticides by GC - Westborough Lab for sample(s): 01-02 Batch: WG1764542-1						
Delta-BHC	ND		ug/l	0.014	0.003	A
Lindane	ND		ug/l	0.014	0.003	A
Alpha-BHC	ND		ug/l	0.014	0.003	A
Beta-BHC	ND		ug/l	0.014	0.004	A
Heptachlor	ND		ug/l	0.014	0.002	A
Aldrin	ND		ug/l	0.014	0.002	A
Heptachlor epoxide	ND		ug/l	0.014	0.003	A
Endrin	ND		ug/l	0.029	0.003	A
Endrin aldehyde	ND		ug/l	0.029	0.006	A
Endrin ketone	ND		ug/l	0.029	0.003	A
Dieldrin	ND		ug/l	0.029	0.003	A
4,4'-DDE	ND		ug/l	0.029	0.003	A
4,4'-DDD	ND		ug/l	0.029	0.003	A
4,4'-DDT	ND		ug/l	0.029	0.003	A
Endosulfan I	ND		ug/l	0.014	0.002	A
Endosulfan II	ND		ug/l	0.029	0.004	A
Endosulfan sulfate	ND		ug/l	0.029	0.003	A
Methoxychlor	ND		ug/l	0.143	0.005	A
Toxaphene	ND		ug/l	0.143	0.045	A
cis-Chlordane	ND		ug/l	0.014	0.005	A
trans-Chlordane	ND		ug/l	0.014	0.004	A
Chlordane	ND		ug/l	0.143	0.033	A

Project Name: 100 MAIN ST.
Project Number: 12461:1
Lab Number: L2318715
Report Date: 04/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8081B
Analytical Date: 04/10/23 19:10
Analyst: AAR

Extraction Method: EPA 3510C
Extraction Date: 04/09/23 21:30

Parameter	Result	Qualifier	Units	RL	MDL	Column
Organochlorine Pesticides by GC - Westborough Lab for sample(s): 01-02 Batch: WG1764542-1						

Surrogate	%Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	82		30-150	A
Decachlorobiphenyl	99		30-150	A
2,4,5,6-Tetrachloro-m-xylene	82		30-150	B
Decachlorobiphenyl	97		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8081B
Analytical Date: 04/13/23 16:24
Analyst: AAR

Extraction Method: EPA 3546
Extraction Date: 04/12/23 18:23
Cleanup Method: EPA 3620B
Cleanup Date: 04/13/23
Cleanup Method: EPA 3660B
Cleanup Date: 04/13/23

Parameter	Result	Qualifier	Units	RL	MDL	Column
Organochlorine Pesticides by GC - Westborough Lab for sample(s): 03-05 Batch: WG1765996-1						
Delta-BHC	ND		ug/kg	1.60	0.312	A
Lindane	ND		ug/kg	0.665	0.297	A
Alpha-BHC	ND		ug/kg	0.665	0.189	A
Beta-BHC	ND		ug/kg	1.60	0.605	A
Heptachlor	ND		ug/kg	0.798	0.358	A
Aldrin	ND		ug/kg	1.60	0.562	A
Heptachlor epoxide	ND		ug/kg	2.99	0.898	A
Endrin	ND		ug/kg	0.665	0.273	A
Endrin aldehyde	ND		ug/kg	1.99	0.698	A
Endrin ketone	ND		ug/kg	1.60	0.411	A
Dieldrin	ND		ug/kg	0.997	0.499	A
4,4'-DDE	ND		ug/kg	1.60	0.369	A
4,4'-DDD	ND		ug/kg	1.60	0.569	A
4,4'-DDT	ND		ug/kg	1.60	1.28	A
Endosulfan I	ND		ug/kg	1.60	0.377	A
Endosulfan II	ND		ug/kg	1.60	0.533	A
Endosulfan sulfate	ND		ug/kg	0.665	0.316	A
Methoxychlor	ND		ug/kg	2.99	0.931	A
Toxaphene	ND		ug/kg	29.9	8.38	A
cis-Chlordane	ND		ug/kg	1.99	0.556	A
trans-Chlordane	ND		ug/kg	1.99	0.526	A
Chlordane	ND		ug/kg	13.3	5.28	A

Project Name: 100 MAIN ST.
Project Number: 12461:1
Lab Number: L2318715
Report Date: 04/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8081B
Analytical Date: 04/13/23 16:24
Analyst: AAR

Extraction Method: EPA 3546
Extraction Date: 04/12/23 18:23
Cleanup Method: EPA 3620B
Cleanup Date: 04/13/23
Cleanup Method: EPA 3660B
Cleanup Date: 04/13/23

Parameter	Result	Qualifier	Units	RL	MDL	Column
Organochlorine Pesticides by GC - Westborough Lab for sample(s): 03-05 Batch: WG1765996-1						

Surrogate	%Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	76		30-150	A
Decachlorobiphenyl	97		30-150	A
2,4,5,6-Tetrachloro-m-xylene	76		30-150	B
Decachlorobiphenyl	89		30-150	B

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits	Column
Organochlorine Pesticides by GC - Westborough Lab Associated sample(s): 01-02 Batch: WG1764542-2 WG1764542-3									
Delta-BHC	76		77		30-150	1		20	A
Lindane	84		84		30-150	1		20	A
Alpha-BHC	93		85		30-150	9		20	A
Beta-BHC	100		88		30-150	13		20	A
Heptachlor	88		85		30-150	4		20	A
Aldrin	77		78		30-150	0		20	A
Heptachlor epoxide	80		85		30-150	5		20	A
Endrin	82		86		30-150	5		20	A
Endrin aldehyde	60		61		30-150	1		20	A
Endrin ketone	95		95		30-150	1		20	A
Dieldrin	88		90		30-150	2		20	A
4,4'-DDE	79		78		30-150	1		20	A
4,4'-DDD	88		91		30-150	4		20	A
4,4'-DDT	82		86		30-150	6		20	A
Endosulfan I	84		129		30-150	**43**	Q	20	A
Endosulfan II	85		85		30-150	0		20	A
Endosulfan sulfate	82		84		30-150	2		20	A
Methoxychlor	92		103		30-150	11		20	A
cis-Chlordane	72		71		30-150	2		20	A
trans-Chlordane	83		94		30-150	12		20	A

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461:1

Lab Number: L2318715

Report Date: 04/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Organochlorine Pesticides by GC - Westborough Lab Associated sample(s): 01-02 Batch: WG1764542-2 WG1764542-3								

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	87		82		30-150	A
Decachlorobiphenyl	108		104		30-150	A
2,4,5,6-Tetrachloro-m-xylene	85		81		30-150	B
Decachlorobiphenyl	106		100		30-150	B

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461:1

Lab Number: L2318715

Report Date: 04/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits	Column
Organochlorine Pesticides by GC - Westborough Lab Associated sample(s): 03-05 Batch: WG1765996-2 WG1765996-3									
Delta-BHC	94		96		30-150	2		30	A
Lindane	90		96		30-150	6		30	A
Alpha-BHC	93		100		30-150	7		30	A
Beta-BHC	109		100		30-150	9		30	A
Heptachlor	95		99		30-150	4		30	A
Aldrin	94		98		30-150	4		30	A
Heptachlor epoxide	86		91		30-150	6		30	A
Endrin	93		101		30-150	8		30	A
Endrin aldehyde	71		78		30-150	9		30	A
Endrin ketone	88		102		30-150	15		30	A
Dieldrin	97		108		30-150	11		30	A
4,4'-DDE	91		99		30-150	8		30	A
4,4'-DDD	99		108		30-150	9		30	A
4,4'-DDT	88		101		30-150	14		30	A
Endosulfan I	90		97		30-150	7		30	A
Endosulfan II	91		101		30-150	10		30	A
Endosulfan sulfate	70		81		30-150	15		30	A
Methoxychlor	96		105		30-150	9		30	A
cis-Chlordane	82		88		30-150	7		30	A
trans-Chlordane	102		113		30-150	10		30	A

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461:1

Lab Number: L2318715

Report Date: 04/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits

Organochlorine Pesticides by GC - Westborough Lab Associated sample(s): 03-05 Batch: WG1765996-2 WG1765996-3

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	80		80		30-150	A
Decachlorobiphenyl	88		109		30-150	A
2,4,5,6-Tetrachloro-m-xylene	82		78		30-150	B
Decachlorobiphenyl	90		97		30-150	B

METALS

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-01 Date Collected: 04/07/23 08:15

Client ID: GW-8 Date Received: 04/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Water

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	94.7		mg/l	0.0100	0.00327	1	04/10/23 14:55	04/11/23 22:49	EPA 3005A	1,6020B	NTB
Antimony, Total	ND		mg/l	0.00400	0.00042	1	04/10/23 14:55	04/11/23 22:49	EPA 3005A	1,6020B	NTB
Arsenic, Total	0.01571		mg/l	0.00050	0.00016	1	04/10/23 14:55	04/11/23 22:49	EPA 3005A	1,6020B	NTB
Barium, Total	1.934		mg/l	0.00050	0.00017	1	04/10/23 14:55	04/11/23 22:49	EPA 3005A	1,6020B	NTB
Beryllium, Total	0.00322		mg/l	0.00050	0.00010	1	04/10/23 14:55	04/11/23 22:49	EPA 3005A	1,6020B	NTB
Cadmium, Total	0.00134		mg/l	0.00020	0.00005	1	04/10/23 14:55	04/11/23 22:49	EPA 3005A	1,6020B	NTB
Calcium, Total	660.		mg/l	0.500	0.197	5	04/10/23 14:55	04/13/23 17:43	EPA 3005A	1,6020B	NTB
Chromium, Total	0.2350		mg/l	0.00100	0.00017	1	04/10/23 14:55	04/11/23 22:49	EPA 3005A	1,6020B	NTB
Cobalt, Total	0.1141		mg/l	0.00050	0.00016	1	04/10/23 14:55	04/11/23 22:49	EPA 3005A	1,6020B	NTB
Copper, Total	0.4770		mg/l	0.00100	0.00038	1	04/10/23 14:55	04/11/23 22:49	EPA 3005A	1,6020B	NTB
Iron, Total	172.		mg/l	0.0500	0.0191	1	04/10/23 14:55	04/11/23 22:49	EPA 3005A	1,6020B	NTB
Lead, Total	0.08821		mg/l	0.00100	0.00034	1	04/10/23 14:55	04/11/23 22:49	EPA 3005A	1,6020B	NTB
Magnesium, Total	267.		mg/l	0.0700	0.0242	1	04/10/23 14:55	04/11/23 22:49	EPA 3005A	1,6020B	NTB
Manganese, Total	4.584		mg/l	0.00100	0.00044	1	04/10/23 14:55	04/11/23 22:49	EPA 3005A	1,6020B	NTB
Mercury, Total	0.00022		mg/l	0.00020	0.00009	1	04/10/23 15:50	04/12/23 13:26	EPA 7470A	1,7470A	DMB
Nickel, Total	0.1790		mg/l	0.00200	0.00055	1	04/10/23 14:55	04/11/23 22:49	EPA 3005A	1,6020B	NTB
Potassium, Total	83.6		mg/l	0.100	0.0309	1	04/10/23 14:55	04/11/23 22:49	EPA 3005A	1,6020B	NTB
Selenium, Total	0.0297		mg/l	0.00500	0.00173	1	04/10/23 14:55	04/11/23 22:49	EPA 3005A	1,6020B	NTB
Silver, Total	0.00051		mg/l	0.00040	0.00016	1	04/10/23 14:55	04/11/23 22:49	EPA 3005A	1,6020B	NTB
Sodium, Total	223.		mg/l	0.100	0.0293	1	04/10/23 14:55	04/11/23 22:49	EPA 3005A	1,6020B	NTB
Thallium, Total	0.00150		mg/l	0.00100	0.00014	1	04/10/23 14:55	04/11/23 22:49	EPA 3005A	1,6020B	NTB
Vanadium, Total	0.1720		mg/l	0.00500	0.00157	1	04/10/23 14:55	04/11/23 22:49	EPA 3005A	1,6020B	NTB
Zinc, Total	0.3881		mg/l	0.01000	0.00341	1	04/10/23 14:55	04/11/23 22:49	EPA 3005A	1,6020B	NTB

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-02 Date Collected: 04/07/23 13:45

Client ID: GW-9 Date Received: 04/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Water

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	105.		mg/l	0.0200	0.00654	1	04/10/23 14:55	04/11/23 22:54	EPA 3005A	1,6020B	NTB
Antimony, Total	ND		mg/l	0.00800	0.00085	1	04/10/23 14:55	04/11/23 22:54	EPA 3005A	1,6020B	NTB
Arsenic, Total	0.02629		mg/l	0.00100	0.00033	1	04/10/23 14:55	04/11/23 22:54	EPA 3005A	1,6020B	NTB
Barium, Total	2.441		mg/l	0.00100	0.00034	1	04/10/23 14:55	04/11/23 22:54	EPA 3005A	1,6020B	NTB
Beryllium, Total	0.00359		mg/l	0.00100	0.00021	1	04/10/23 14:55	04/11/23 22:54	EPA 3005A	1,6020B	NTB
Cadmium, Total	0.00303		mg/l	0.00040	0.00011	1	04/10/23 14:55	04/11/23 22:54	EPA 3005A	1,6020B	NTB
Calcium, Total	2260		mg/l	2.00	0.788	10	04/10/23 14:55	04/13/23 17:48	EPA 3005A	1,6020B	NTB
Chromium, Total	0.4531		mg/l	0.00200	0.00035	1	04/10/23 14:55	04/11/23 22:54	EPA 3005A	1,6020B	NTB
Cobalt, Total	0.1180		mg/l	0.00100	0.00032	1	04/10/23 14:55	04/11/23 22:54	EPA 3005A	1,6020B	NTB
Copper, Total	0.4260		mg/l	0.00200	0.00076	1	04/10/23 14:55	04/11/23 22:54	EPA 3005A	1,6020B	NTB
Iron, Total	205.		mg/l	0.100	0.0382	1	04/10/23 14:55	04/11/23 22:54	EPA 3005A	1,6020B	NTB
Lead, Total	0.2130		mg/l	0.00200	0.00068	1	04/10/23 14:55	04/11/23 22:54	EPA 3005A	1,6020B	NTB
Magnesium, Total	190.		mg/l	0.140	0.0484	1	04/10/23 14:55	04/11/23 22:54	EPA 3005A	1,6020B	NTB
Manganese, Total	9.555		mg/l	0.00200	0.00088	1	04/10/23 14:55	04/11/23 22:54	EPA 3005A	1,6020B	NTB
Mercury, Total	0.00188		mg/l	0.00100	0.00045	1	04/10/23 15:50	04/12/23 13:30	EPA 7470A	1,7470A	DMB
Nickel, Total	0.2069		mg/l	0.00400	0.00111	1	04/10/23 14:55	04/11/23 22:54	EPA 3005A	1,6020B	NTB
Potassium, Total	97.1		mg/l	0.200	0.0618	1	04/10/23 14:55	04/11/23 22:54	EPA 3005A	1,6020B	NTB
Selenium, Total	0.0422		mg/l	0.0100	0.00346	1	04/10/23 14:55	04/11/23 22:54	EPA 3005A	1,6020B	NTB
Silver, Total	0.00064	J	mg/l	0.00080	0.00032	1	04/10/23 14:55	04/11/23 22:54	EPA 3005A	1,6020B	NTB
Sodium, Total	480.		mg/l	0.200	0.0586	1	04/10/23 14:55	04/11/23 22:54	EPA 3005A	1,6020B	NTB
Thallium, Total	0.00137	J	mg/l	0.00200	0.00028	1	04/10/23 14:55	04/11/23 22:54	EPA 3005A	1,6020B	NTB
Vanadium, Total	0.2414		mg/l	0.01000	0.00314	1	04/10/23 14:55	04/11/23 22:54	EPA 3005A	1,6020B	NTB
Zinc, Total	0.4350		mg/l	0.02000	0.00682	1	04/10/23 14:55	04/11/23 22:54	EPA 3005A	1,6020B	NTB

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-03 Date Collected: 04/07/23 10:45

Client ID: SB-8G (1.5-2) Date Received: 04/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Soil

Percent Solids: 88%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	5490		mg/kg	8.86	2.39	2	04/10/23 23:29	04/11/23 10:46	EPA 3050B	1,6010D	DHL
Antimony, Total	ND		mg/kg	4.43	0.337	2	04/10/23 23:29	04/11/23 10:46	EPA 3050B	1,6010D	DHL
Arsenic, Total	0.794	J	mg/kg	0.886	0.184	2	04/10/23 23:29	04/11/23 10:46	EPA 3050B	1,6010D	DHL
Barium, Total	43.8		mg/kg	0.886	0.154	2	04/10/23 23:29	04/11/23 10:46	EPA 3050B	1,6010D	DHL
Beryllium, Total	ND		mg/kg	0.443	0.029	2	04/10/23 23:29	04/11/23 10:46	EPA 3050B	1,6010D	DHL
Cadmium, Total	0.137	J	mg/kg	0.886	0.087	2	04/10/23 23:29	04/11/23 10:46	EPA 3050B	1,6010D	DHL
Calcium, Total	11000		mg/kg	8.86	3.10	2	04/10/23 23:29	04/11/23 10:46	EPA 3050B	1,6010D	DHL
Chromium, Total	13.2		mg/kg	0.886	0.085	2	04/10/23 23:29	04/11/23 10:46	EPA 3050B	1,6010D	DHL
Cobalt, Total	5.19		mg/kg	1.77	0.147	2	04/10/23 23:29	04/11/23 10:46	EPA 3050B	1,6010D	DHL
Copper, Total	15.6		mg/kg	0.886	0.229	2	04/10/23 23:29	04/11/23 10:46	EPA 3050B	1,6010D	DHL
Iron, Total	12300		mg/kg	4.43	0.800	2	04/10/23 23:29	04/11/23 10:46	EPA 3050B	1,6010D	DHL
Lead, Total	5.00		mg/kg	4.43	0.238	2	04/10/23 23:29	04/11/23 10:46	EPA 3050B	1,6010D	DHL
Magnesium, Total	8810		mg/kg	8.86	1.36	2	04/10/23 23:29	04/11/23 10:46	EPA 3050B	1,6010D	DHL
Manganese, Total	161		mg/kg	0.886	0.141	2	04/10/23 23:29	04/11/23 10:46	EPA 3050B	1,6010D	DHL
Mercury, Total	ND		mg/kg	0.072	0.047	1	04/11/23 00:38	04/13/23 13:29	EPA 7471B	1,7471B	ZNK
Nickel, Total	10.6		mg/kg	2.22	0.214	2	04/10/23 23:29	04/11/23 10:46	EPA 3050B	1,6010D	DHL
Potassium, Total	2030		mg/kg	222	12.8	2	04/10/23 23:29	04/11/23 10:46	EPA 3050B	1,6010D	DHL
Selenium, Total	ND		mg/kg	1.77	0.229	2	04/10/23 23:29	04/11/23 10:46	EPA 3050B	1,6010D	DHL
Silver, Total	ND		mg/kg	0.443	0.251	2	04/10/23 23:29	04/11/23 10:46	EPA 3050B	1,6010D	DHL
Sodium, Total	105	J	mg/kg	177	2.79	2	04/10/23 23:29	04/11/23 10:46	EPA 3050B	1,6010D	DHL
Thallium, Total	0.619	J	mg/kg	1.77	0.279	2	04/10/23 23:29	04/11/23 10:46	EPA 3050B	1,6010D	DHL
Vanadium, Total	18.5		mg/kg	0.886	0.180	2	04/10/23 23:29	04/11/23 10:46	EPA 3050B	1,6010D	DHL
Zinc, Total	26.6		mg/kg	4.43	0.260	2	04/10/23 23:29	04/11/23 10:46	EPA 3050B	1,6010D	DHL

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-04 Date Collected: 04/07/23 14:30

Client ID: SB-20G (2.5-3) Date Received: 04/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Soil

Percent Solids: 93%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	5620		mg/kg	8.50	2.30	2	04/10/23 23:29	04/11/23 10:49	EPA 3050B	1,6010D	DHL
Antimony, Total	ND		mg/kg	4.25	0.323	2	04/10/23 23:29	04/11/23 10:49	EPA 3050B	1,6010D	DHL
Arsenic, Total	0.636	J	mg/kg	0.850	0.177	2	04/10/23 23:29	04/11/23 10:49	EPA 3050B	1,6010D	DHL
Barium, Total	48.8		mg/kg	0.850	0.148	2	04/10/23 23:29	04/11/23 10:49	EPA 3050B	1,6010D	DHL
Beryllium, Total	ND		mg/kg	0.425	0.028	2	04/10/23 23:29	04/11/23 10:49	EPA 3050B	1,6010D	DHL
Cadmium, Total	0.164	J	mg/kg	0.850	0.083	2	04/10/23 23:29	04/11/23 10:49	EPA 3050B	1,6010D	DHL
Calcium, Total	6590		mg/kg	8.50	2.98	2	04/10/23 23:29	04/11/23 10:49	EPA 3050B	1,6010D	DHL
Chromium, Total	11.7		mg/kg	0.850	0.082	2	04/10/23 23:29	04/11/23 10:49	EPA 3050B	1,6010D	DHL
Cobalt, Total	4.83		mg/kg	1.70	0.141	2	04/10/23 23:29	04/11/23 10:49	EPA 3050B	1,6010D	DHL
Copper, Total	14.6		mg/kg	0.850	0.219	2	04/10/23 23:29	04/11/23 10:49	EPA 3050B	1,6010D	DHL
Iron, Total	11500		mg/kg	4.25	0.768	2	04/10/23 23:29	04/11/23 10:49	EPA 3050B	1,6010D	DHL
Lead, Total	11.0		mg/kg	4.25	0.228	2	04/10/23 23:29	04/11/23 10:49	EPA 3050B	1,6010D	DHL
Magnesium, Total	5870		mg/kg	8.50	1.31	2	04/10/23 23:29	04/11/23 10:49	EPA 3050B	1,6010D	DHL
Manganese, Total	172		mg/kg	0.850	0.135	2	04/10/23 23:29	04/11/23 10:49	EPA 3050B	1,6010D	DHL
Mercury, Total	ND		mg/kg	0.072	0.047	1	04/11/23 00:38	04/13/23 13:32	EPA 7471B	1,7471B	ZNK
Nickel, Total	9.68		mg/kg	2.13	0.206	2	04/10/23 23:29	04/11/23 10:49	EPA 3050B	1,6010D	DHL
Potassium, Total	3000		mg/kg	213	12.2	2	04/10/23 23:29	04/11/23 10:49	EPA 3050B	1,6010D	DHL
Selenium, Total	ND		mg/kg	1.70	0.219	2	04/10/23 23:29	04/11/23 10:49	EPA 3050B	1,6010D	DHL
Silver, Total	ND		mg/kg	0.425	0.241	2	04/10/23 23:29	04/11/23 10:49	EPA 3050B	1,6010D	DHL
Sodium, Total	202		mg/kg	170	2.68	2	04/10/23 23:29	04/11/23 10:49	EPA 3050B	1,6010D	DHL
Thallium, Total	0.623	J	mg/kg	1.70	0.268	2	04/10/23 23:29	04/11/23 10:49	EPA 3050B	1,6010D	DHL
Vanadium, Total	16.5		mg/kg	0.850	0.173	2	04/10/23 23:29	04/11/23 10:49	EPA 3050B	1,6010D	DHL
Zinc, Total	35.2		mg/kg	4.25	0.249	2	04/10/23 23:29	04/11/23 10:49	EPA 3050B	1,6010D	DHL

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-05 Date Collected: 04/07/23 14:15

Client ID: SB-21G (0.5-1) Date Received: 04/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Soil

Percent Solids: 92%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	6280		mg/kg	8.32	2.25	2	04/10/23 23:29	04/11/23 10:52	EPA 3050B	1,6010D	DHL
Antimony, Total	ND		mg/kg	4.16	0.316	2	04/10/23 23:29	04/11/23 10:52	EPA 3050B	1,6010D	DHL
Arsenic, Total	0.990		mg/kg	0.832	0.173	2	04/10/23 23:29	04/11/23 10:52	EPA 3050B	1,6010D	DHL
Barium, Total	52.3		mg/kg	0.832	0.145	2	04/10/23 23:29	04/11/23 10:52	EPA 3050B	1,6010D	DHL
Beryllium, Total	ND		mg/kg	0.416	0.028	2	04/10/23 23:29	04/11/23 10:52	EPA 3050B	1,6010D	DHL
Cadmium, Total	0.178	J	mg/kg	0.832	0.082	2	04/10/23 23:29	04/11/23 10:52	EPA 3050B	1,6010D	DHL
Calcium, Total	13300		mg/kg	8.32	2.91	2	04/10/23 23:29	04/11/23 10:52	EPA 3050B	1,6010D	DHL
Chromium, Total	13.1		mg/kg	0.832	0.080	2	04/10/23 23:29	04/11/23 10:52	EPA 3050B	1,6010D	DHL
Cobalt, Total	4.89		mg/kg	1.66	0.138	2	04/10/23 23:29	04/11/23 10:52	EPA 3050B	1,6010D	DHL
Copper, Total	15.7		mg/kg	0.832	0.215	2	04/10/23 23:29	04/11/23 10:52	EPA 3050B	1,6010D	DHL
Iron, Total	12400		mg/kg	4.16	0.752	2	04/10/23 23:29	04/11/23 10:52	EPA 3050B	1,6010D	DHL
Lead, Total	15.4		mg/kg	4.16	0.223	2	04/10/23 23:29	04/11/23 10:52	EPA 3050B	1,6010D	DHL
Magnesium, Total	9400		mg/kg	8.32	1.28	2	04/10/23 23:29	04/11/23 10:52	EPA 3050B	1,6010D	DHL
Manganese, Total	189		mg/kg	0.832	0.132	2	04/10/23 23:29	04/11/23 10:52	EPA 3050B	1,6010D	DHL
Mercury, Total	ND		mg/kg	0.076	0.049	1	04/11/23 00:38	04/13/23 13:35	EPA 7471B	1,7471B	ZNK
Nickel, Total	10.5		mg/kg	2.08	0.201	2	04/10/23 23:29	04/11/23 10:52	EPA 3050B	1,6010D	DHL
Potassium, Total	2090		mg/kg	208	12.0	2	04/10/23 23:29	04/11/23 10:52	EPA 3050B	1,6010D	DHL
Selenium, Total	ND		mg/kg	1.66	0.215	2	04/10/23 23:29	04/11/23 10:52	EPA 3050B	1,6010D	DHL
Silver, Total	ND		mg/kg	0.416	0.236	2	04/10/23 23:29	04/11/23 10:52	EPA 3050B	1,6010D	DHL
Sodium, Total	142	J	mg/kg	166	2.62	2	04/10/23 23:29	04/11/23 10:52	EPA 3050B	1,6010D	DHL
Thallium, Total	0.603	J	mg/kg	1.66	0.262	2	04/10/23 23:29	04/11/23 10:52	EPA 3050B	1,6010D	DHL
Vanadium, Total	18.0		mg/kg	0.832	0.169	2	04/10/23 23:29	04/11/23 10:52	EPA 3050B	1,6010D	DHL
Zinc, Total	36.6		mg/kg	4.16	0.244	2	04/10/23 23:29	04/11/23 10:52	EPA 3050B	1,6010D	DHL

Project Name: 100 MAIN ST. **Lab Number:** L2318715

Project Number: 12461:1 **Report Date:** 04/24/23

Method Blank Analysis
Batch Quality Control

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
Total Metals - Mansfield Lab for sample(s): 01-02 Batch: WG1764776-1										
Aluminum, Total	ND		mg/l	0.0100	0.00327	1	04/10/23 14:55	04/11/23 14:06	1,6020B	NTB
Antimony, Total	ND		mg/l	0.00400	0.00042	1	04/10/23 14:55	04/11/23 14:06	1,6020B	NTB
Arsenic, Total	ND		mg/l	0.00050	0.00016	1	04/10/23 14:55	04/11/23 14:06	1,6020B	NTB
Barium, Total	0.00030	J	mg/l	0.00050	0.00017	1	04/10/23 14:55	04/11/23 14:06	1,6020B	NTB
Beryllium, Total	ND		mg/l	0.00050	0.00010	1	04/10/23 14:55	04/11/23 14:06	1,6020B	NTB
Cadmium, Total	ND		mg/l	0.00020	0.00005	1	04/10/23 14:55	04/11/23 14:06	1,6020B	NTB
Calcium, Total	ND		mg/l	0.100	0.0394	1	04/10/23 14:55	04/11/23 14:06	1,6020B	NTB
Chromium, Total	ND		mg/l	0.00100	0.00017	1	04/10/23 14:55	04/11/23 14:06	1,6020B	NTB
Cobalt, Total	ND		mg/l	0.00050	0.00016	1	04/10/23 14:55	04/11/23 14:06	1,6020B	NTB
Copper, Total	ND		mg/l	0.00100	0.00038	1	04/10/23 14:55	04/11/23 14:06	1,6020B	NTB
Iron, Total	0.0455	J	mg/l	0.0500	0.0191	1	04/10/23 14:55	04/11/23 14:06	1,6020B	NTB
Lead, Total	ND		mg/l	0.00100	0.00034	1	04/10/23 14:55	04/11/23 14:06	1,6020B	NTB
Magnesium, Total	ND		mg/l	0.0700	0.0242	1	04/10/23 14:55	04/11/23 14:06	1,6020B	NTB
Manganese, Total	ND		mg/l	0.00100	0.00044	1	04/10/23 14:55	04/11/23 14:06	1,6020B	NTB
Nickel, Total	ND		mg/l	0.00200	0.00055	1	04/10/23 14:55	04/11/23 14:06	1,6020B	NTB
Potassium, Total	ND		mg/l	0.100	0.0309	1	04/10/23 14:55	04/11/23 14:06	1,6020B	NTB
Selenium, Total	ND		mg/l	0.00500	0.00173	1	04/10/23 14:55	04/11/23 14:06	1,6020B	NTB
Silver, Total	ND		mg/l	0.00040	0.00016	1	04/10/23 14:55	04/11/23 14:06	1,6020B	NTB
Sodium, Total	ND		mg/l	0.100	0.0293	1	04/10/23 14:55	04/11/23 14:06	1,6020B	NTB
Thallium, Total	ND		mg/l	0.00100	0.00014	1	04/10/23 14:55	04/11/23 14:06	1,6020B	NTB
Vanadium, Total	ND		mg/l	0.00500	0.00157	1	04/10/23 14:55	04/11/23 14:06	1,6020B	NTB
Zinc, Total	ND		mg/l	0.01000	0.00341	1	04/10/23 14:55	04/11/23 14:06	1,6020B	NTB

Prep Information

Digestion Method: EPA 3005A

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
Total Metals - Mansfield Lab for sample(s): 01-02 Batch: WG1764779-1										
Mercury, Total	ND		mg/l	0.00020	0.00009	1	04/10/23 15:50	04/12/23 12:26	1,7470A	DMB

Project Name: 100 MAIN ST.
Project Number: 12461:1
Lab Number: L2318715
Report Date: 04/24/23

Method Blank Analysis
Batch Quality Control

Prep Information

Digestion Method: EPA 7470A

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
Total Metals - Mansfield Lab for sample(s): 03-05 Batch: WG1764793-1										
Aluminum, Total	ND		mg/kg	4.00	1.08	1	04/10/23 23:29	04/11/23 08:12	1,6010D	DHL
Antimony, Total	ND		mg/kg	2.00	0.152	1	04/10/23 23:29	04/11/23 08:12	1,6010D	DHL
Arsenic, Total	ND		mg/kg	0.400	0.083	1	04/10/23 23:29	04/11/23 08:12	1,6010D	DHL
Barium, Total	ND		mg/kg	0.400	0.070	1	04/10/23 23:29	04/11/23 08:12	1,6010D	DHL
Beryllium, Total	ND		mg/kg	0.200	0.013	1	04/10/23 23:29	04/11/23 08:12	1,6010D	DHL
Cadmium, Total	ND		mg/kg	0.400	0.039	1	04/10/23 23:29	04/11/23 08:12	1,6010D	DHL
Calcium, Total	ND		mg/kg	4.00	1.40	1	04/10/23 23:29	04/11/23 08:12	1,6010D	DHL
Chromium, Total	0.121	J	mg/kg	0.400	0.038	1	04/10/23 23:29	04/11/23 08:12	1,6010D	DHL
Cobalt, Total	ND		mg/kg	0.800	0.066	1	04/10/23 23:29	04/11/23 08:12	1,6010D	DHL
Copper, Total	ND		mg/kg	0.400	0.103	1	04/10/23 23:29	04/11/23 08:12	1,6010D	DHL
Iron, Total	0.417	J	mg/kg	2.00	0.361	1	04/10/23 23:29	04/11/23 08:12	1,6010D	DHL
Lead, Total	ND		mg/kg	2.00	0.107	1	04/10/23 23:29	04/11/23 08:12	1,6010D	DHL
Magnesium, Total	ND		mg/kg	4.00	0.616	1	04/10/23 23:29	04/11/23 08:12	1,6010D	DHL
Manganese, Total	ND		mg/kg	0.400	0.064	1	04/10/23 23:29	04/11/23 08:12	1,6010D	DHL
Nickel, Total	ND		mg/kg	1.00	0.097	1	04/10/23 23:29	04/11/23 08:12	1,6010D	DHL
Potassium, Total	ND		mg/kg	100	5.76	1	04/10/23 23:29	04/11/23 08:12	1,6010D	DHL
Selenium, Total	ND		mg/kg	0.800	0.103	1	04/10/23 23:29	04/11/23 08:12	1,6010D	DHL
Silver, Total	ND		mg/kg	0.200	0.113	1	04/10/23 23:29	04/11/23 08:12	1,6010D	DHL
Sodium, Total	6.11	J	mg/kg	80.0	1.26	1	04/10/23 23:29	04/11/23 08:12	1,6010D	DHL
Thallium, Total	ND		mg/kg	0.800	0.126	1	04/10/23 23:29	04/11/23 08:12	1,6010D	DHL
Vanadium, Total	ND		mg/kg	0.400	0.081	1	04/10/23 23:29	04/11/23 08:12	1,6010D	DHL
Zinc, Total	ND		mg/kg	2.00	0.117	1	04/10/23 23:29	04/11/23 08:12	1,6010D	DHL

Prep Information

Digestion Method: EPA 3050B

Project Name: 100 MAIN ST.
Project Number: 12461:1
Lab Number: L2318715
Report Date: 04/24/23

Method Blank Analysis
Batch Quality Control

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
Total Metals - Mansfield Lab for sample(s): 03-05 Batch: WG1764800-1										
Mercury, Total	ND		mg/kg	0.083	0.054	1	04/11/23 00:38	04/12/23 08:50	1,7471B	DMB

Prep Information

Digestion Method: EPA 7471B

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461:1

Lab Number: L2318715

Report Date: 04/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-02 Batch: WG1764776-2								
Aluminum, Total	92		-		80-120	-		
Antimony, Total	88		-		80-120	-		
Arsenic, Total	91		-		80-120	-		
Barium, Total	90		-		80-120	-		
Beryllium, Total	98		-		80-120	-		
Cadmium, Total	95		-		80-120	-		
Calcium, Total	96		-		80-120	-		
Chromium, Total	87		-		80-120	-		
Cobalt, Total	99		-		80-120	-		
Copper, Total	94		-		80-120	-		
Iron, Total	95		-		80-120	-		
Lead, Total	92		-		80-120	-		
Magnesium, Total	86		-		80-120	-		
Manganese, Total	88		-		80-120	-		
Nickel, Total	92		-		80-120	-		
Potassium, Total	92		-		80-120	-		
Selenium, Total	92		-		80-120	-		
Silver, Total	86		-		80-120	-		
Sodium, Total	89		-		80-120	-		
Thallium, Total	92		-		80-120	-		
Vanadium, Total	87		-		80-120	-		

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461:1

Lab Number: L2318715

Report Date: 04/24/23

Parameter	LCS %Recovery	LCSD %Recovery	%Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-02 Batch: WG1764776-2					
Zinc, Total	91	-	80-120	-	
Total Metals - Mansfield Lab Associated sample(s): 01-02 Batch: WG1764779-2					
Mercury, Total	100	-	80-120	-	

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461:1

Lab Number: L2318715

Report Date: 04/24/23

Parameter	LCS %Recovery	LCSD %Recovery	%Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 03-05 Batch: WG1764793-2 SRM Lot Number: D116-540					
Aluminum, Total	100	-	45-155	-	
Antimony, Total	192	-	2-205	-	
Arsenic, Total	111	-	82-119	-	
Barium, Total	108	-	82-118	-	
Beryllium, Total	112	-	82-118	-	
Cadmium, Total	113	-	82-118	-	
Calcium, Total	105	-	81-119	-	
Chromium, Total	114	-	81-118	-	
Cobalt, Total	113	-	83-117	-	
Copper, Total	111	-	83-117	-	
Iron, Total	119	-	58-142	-	
Lead, Total	108	-	83-117	-	
Magnesium, Total	109	-	75-125	-	
Manganese, Total	106	-	82-118	-	
Nickel, Total	115	-	82-118	-	
Potassium, Total	105	-	68-131	-	
Selenium, Total	112	-	78-122	-	
Silver, Total	115	-	79-121	-	
Sodium, Total	102	-	71-130	-	
Thallium, Total	111	-	80-120	-	
Vanadium, Total	114	-	78-122	-	

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461:1

Lab Number: L2318715

Report Date: 04/24/23

Parameter	LCS %Recovery	LCSD %Recovery	%Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 03-05 Batch: WG1764793-2 SRM Lot Number: D116-540					
Zinc, Total	115	-	80-120	-	
Total Metals - Mansfield Lab Associated sample(s): 03-05 Batch: WG1764800-2 SRM Lot Number: D116-540					
Mercury, Total	92	-	58-142	-	

Matrix Spike Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

Parameter	Native Sample	MS Added	MS Found	MS %Recovery	Qual	MSD Found	MSD %Recovery	Qual	Recovery Limits	RPD	Qual	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-02 QC Batch ID: WG1764776-3 QC Sample: L2317427-01 Client ID: MS Sample												
Aluminum, Total	0.714	2	2.66	97		-	-		75-125	-		20
Antimony, Total	0.00146J	0.5	0.4898	98		-	-		75-125	-		20
Arsenic, Total	0.00071	0.12	0.1120	93		-	-		75-125	-		20
Barium, Total	0.02105	2	1.920	95		-	-		75-125	-		20
Beryllium, Total	0.00050	0.05	0.05221	103		-	-		75-125	-		20
Cadmium, Total	0.00308	0.053	0.05543	99		-	-		75-125	-		20
Calcium, Total	6.85	10	16.0	92		-	-		75-125	-		20
Chromium, Total	0.02066	0.2	0.2021	91		-	-		75-125	-		20
Cobalt, Total	0.01590	0.5	0.4956	96		-	-		75-125	-		20
Copper, Total	0.6030	0.25	0.7960	77		-	-		75-125	-		20
Iron, Total	11.4	1	11.3	**0**	Q	-	-		75-125	-		20
Lead, Total	0.1005	0.53	0.5963	94		-	-		75-125	-		20
Magnesium, Total	1.35	10	10.4	90		-	-		75-125	-		20
Manganese, Total	0.08855	0.5	0.5559	93		-	-		75-125	-		20
Nickel, Total	0.07750	0.5	0.5679	98		-	-		75-125	-		20
Potassium, Total	0.805	10	10.0	92		-	-		75-125	-		20
Selenium, Total	ND	0.12	0.114	95		-	-		75-125	-		20
Silver, Total	0.00624	0.05	0.05018	88		-	-		75-125	-		20
Sodium, Total	2.15	10	11.6	94		-	-		75-125	-		20
Thallium, Total	ND	0.12	0.09859	82		-	-		75-125	-		20
Vanadium, Total	0.00524	0.5	0.4546	90		-	-		75-125	-		20

Matrix Spike Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

Parameter	Native Sample	MS Added	MS Found	MS %Recovery	MSD Found	MSD %Recovery	Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-02 QC Batch ID: WG1764776-3 QC Sample: L2317427-01 Client ID: MS Sample									
Zinc, Total	0.5250	0.5	1.000	95	-	-	75-125	-	20
Total Metals - Mansfield Lab Associated sample(s): 01-02 QC Batch ID: WG1764779-3 QC Sample: L2318471-01 Client ID: MS Sample									
Mercury, Total	ND	0.005	0.00492	98	-	-	75-125	-	20

Matrix Spike Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

Parameter	Native Sample	MS Added	MS Found	MS %Recovery		MSD Found	MSD %Recovery	Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 03-05 QC Batch ID: WG1764793-3 QC Sample: L2317084-60 Client ID: MS Sample										
Aluminum, Total	6930	227	7930	**440**	Q	-	-	75-125	-	20
Antimony, Total	0.960J	56.8	53.4	94		-	-	75-125	-	20
Arsenic, Total	33.1	13.6	41.0	**58**	Q	-	-	75-125	-	20
Barium, Total	286	227	486	88		-	-	75-125	-	20
Beryllium, Total	0.496	5.68	5.95	96		-	-	75-125	-	20
Cadmium, Total	0.200J	6.02	5.07	84		-	-	75-125	-	20
Calcium, Total	22800	1140	27900	**449**	Q	-	-	75-125	-	20
Chromium, Total	23.4	22.7	39.7	**72**	Q	-	-	75-125	-	20
Cobalt, Total	6.60	56.8	54.6	84		-	-	75-125	-	20
Copper, Total	71.1	28.4	93.8	80		-	-	75-125	-	20
Iron, Total	11200	114	11200	**0**	Q	-	-	75-125	-	20
Lead, Total	778	60.2	860	**136**	Q	-	-	75-125	-	20
Magnesium, Total	1730	1140	2910	104		-	-	75-125	-	20
Manganese, Total	206	56.8	259	93		-	-	75-125	-	20
Nickel, Total	16.3	56.8	61.8	80		-	-	75-125	-	20
Potassium, Total	1040	1140	2250	106		-	-	75-125	-	20
Selenium, Total	3.07	13.6	18.2	111		-	-	75-125	-	20
Silver, Total	0.597	5.68	7.21	116		-	-	75-125	-	20
Sodium, Total	976	1140	2000	90		-	-	75-125	-	20
Thallium, Total	ND	13.6	13.4	98		-	-	75-125	-	20
Vanadium, Total	29.8	56.8	77.9	85		-	-	75-125	-	20

Matrix Spike Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

Parameter	Native Sample	MS Added	MS Found	MS %Recovery		MSD Found	MSD %Recovery	Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 03-05 QC Batch ID: WG1764793-3 QC Sample: L2317084-60 Client ID: MS Sample										
Zinc, Total	176	56.8	179	**5**	Q	-	-	75-125	-	20
Total Metals - Mansfield Lab Associated sample(s): 03-05 QC Batch ID: WG1764800-3 QC Sample: L2317084-44 Client ID: MS Sample										
Mercury, Total	ND	1.5	1.86	**124**	Q	-	-	80-120	-	20

Lab Duplicate Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461:1

Lab Number: L2318715

Report Date: 04/24/23

Parameter	Native Sample	Duplicate Sample	Units	RPD	Qual	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-02 QC Batch ID: WG1764776-4 QC Sample: L2317427-01 Client ID: DUP Sample						
Aluminum, Total	0.714	0.737	mg/l	3		20
Antimony, Total	0.00146J	0.00181J	mg/l	NC		20
Arsenic, Total	0.00071	0.00077	mg/l	8		20
Barium, Total	0.02105	0.02142	mg/l	2		20
Beryllium, Total	0.00050	0.00050	mg/l	0		20
Cadmium, Total	0.00308	0.00319	mg/l	3		20
Calcium, Total	6.85	7.02	mg/l	2		20
Chromium, Total	0.02066	0.02120	mg/l	3		20
Cobalt, Total	0.01590	0.01618	mg/l	2		20
Copper, Total	0.6030	0.6128	mg/l	2		20
Iron, Total	11.4	11.7	mg/l	3		20
Lead, Total	0.1005	0.1034	mg/l	3		20
Magnesium, Total	1.35	1.38	mg/l	2		20
Manganese, Total	0.08855	0.08994	mg/l	2		20
Nickel, Total	0.07750	0.07800	mg/l	1		20
Potassium, Total	0.805	0.788	mg/l	2		20
Selenium, Total	ND	ND	mg/l	NC		20
Silver, Total	0.00624	0.00624	mg/l	0		20
Sodium, Total	2.15	2.20	mg/l	2		20

Lab Duplicate Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

Parameter	Native Sample	Duplicate Sample	Units	RPD		RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-02 QC Batch ID: WG1764776-4 QC Sample: L2317427-01 Client ID: DUP Sample						
Thallium, Total	ND	0.00027J	mg/l	NC		20
Vanadium, Total	0.00524	0.00548	mg/l	4		20
Zinc, Total	0.5250	0.5548	mg/l	6		20
Total Metals - Mansfield Lab Associated sample(s): 01-02 QC Batch ID: WG1764779-4 QC Sample: L2318471-01 Client ID: DUP Sample						
Mercury, Total	ND	ND	mg/l	NC		20
Total Metals - Mansfield Lab Associated sample(s): 03-05 QC Batch ID: WG1764793-4 QC Sample: L2317084-60 Client ID: DUP Sample						
Lead, Total	778	1590	mg/kg	**69**	Q	20
Total Metals - Mansfield Lab Associated sample(s): 03-05 QC Batch ID: WG1764800-4 QC Sample: L2317084-44 Client ID: DUP Sample						
Mercury, Total	ND	0.120	mg/kg	NC		20

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Serial Dilution Analysis
Batch Quality Control

Lab Number: L2318715
Report Date: 04/24/23

Parameter	Native Sample	Serial Dilution	Units	% D	Qual	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 03-05 QC Batch ID: WG1764793-6 QC Sample: L2317084-60 Client ID: DUP Sample						
Lead, Total	778	757	mg/kg	3		20

INORGANICS
&
MISCELLANEOUS

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-01
Client ID: GW-8
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 08:15
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Cyanide, Total	ND		mg/l	0.005	0.001	1	04/13/23 10:50	04/13/23 14:47	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-02
Client ID: GW-9
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 13:45
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Cyanide, Total	0.002	J	mg/l	0.005	0.001	1	04/13/23 10:50	04/13/23 16:04	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-03
Client ID: SB-8G (1.5-2)
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 10:45
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Solids, Total	87.8		%	0.100	NA	1	-	04/08/23 12:38	121,2540G	ROI
Cyanide, Total	ND		mg/kg	1.1	0.23	1	04/14/23 13:30	04/14/23 16:50	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-04
Client ID: SB-20G (2.5-3)
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 14:30
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Solids, Total	93.4		%	0.100	NA	1	-	04/08/23 12:38	121,2540G	ROI
Cyanide, Total	ND		mg/kg	1.0	0.22	1	04/14/23 13:30	04/14/23 17:08	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

SAMPLE RESULTS

Lab ID: L2318715-05
Client ID: SB-21G (0.5-1)
Sample Location: WHITE PLAINS, NY

Date Collected: 04/07/23 14:15
Date Received: 04/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Solids, Total	92.2		%	0.100	NA	1	-	04/08/23 12:38	121,2540G	ROI
Cyanide, Total	ND		mg/kg	1.0	0.22	1	04/14/23 13:30	04/14/23 16:51	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461:1
Lab Number: L2318715
Report Date: 04/24/23

Method Blank Analysis
Batch Quality Control

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab for sample(s): 01-02 Batch: WG1766249-1										
Cyanide, Total	ND		mg/l	0.005	0.001	1	04/13/23 10:50	04/13/23 14:19	1,9010C/9012B	JER
General Chemistry - Westborough Lab for sample(s): 03,05 Batch: WG1766659-1										
Cyanide, Total	ND		mg/kg	0.97	0.21	1	04/14/23 13:30	04/14/23 16:44	1,9010C/9012B	JER
General Chemistry - Westborough Lab for sample(s): 04 Batch: WG1766661-1										
Cyanide, Total	ND		mg/kg	0.97	0.21	1	04/14/23 13:30	04/14/23 16:44	1,9010C/9012B	JER

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461:1

Lab Number: L2318715

Report Date: 04/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
General Chemistry - Westborough Lab Associated sample(s): 01-02 Batch: WG1766249-2 WG1766249-3								
Cyanide, Total	92		89		85-115	3		20
General Chemistry - Westborough Lab Associated sample(s): 03,05 Batch: WG1766659-2 WG1766659-3								
Cyanide, Total	**73**	Q	**71**	Q	80-120	5		35
General Chemistry - Westborough Lab Associated sample(s): 04 Batch: WG1766661-2 WG1766661-3								
Cyanide, Total	**73**	Q	**71**	Q	80-120	5		35

Matrix Spike Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

Parameter	Native Sample	MS Added	MS Found	MS %Recovery	Qual	MSD Found	MSD %Recovery	Qual	Recovery Limits	RPD	Qual	RPD Limits
General Chemistry - Westborough Lab Associated sample(s): 01-02 QC Batch ID: WG1766249-4 WG1766249-5 QC Sample: L2318715-01 Client ID: GW-8												
Cyanide, Total	ND	0.2	0.179	90		0.179	90		80-120	0		20
General Chemistry - Westborough Lab Associated sample(s): 03,05 QC Batch ID: WG1766659-4 WG1766659-5 QC Sample: L2318763-02 Client ID: MS Sample												
Cyanide, Total	ND	12	12	97		12	95		75-125	2		35
General Chemistry - Westborough Lab Associated sample(s): 04 QC Batch ID: WG1766661-4 WG1766661-5 QC Sample: L2317880-01 Client ID: MS Sample												
Cyanide, Total	ND	13	13	97		13	97		75-125	0		35

Lab Duplicate Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461:1

Lab Number: L2318715

Report Date: 04/24/23

Parameter	Native Sample	Duplicate Sample	Units	RPD	Qual	RPD Limits
General Chemistry - Westborough Lab Associated sample(s): 03-05 QC Batch ID: WG1764291-1 QC Sample: L2318071-03 Client ID: DUP Sample						
Solids, Total	93.1	92.7	%	0		20

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

Sample Receipt and Container Information

Were project specific reporting limits specified? YES

Cooler Information

Cooler	Custody Seal
A	Absent
B	Absent

Container Information

Container ID	Container Type	Cooler	Initial pH	Final pH	Temp deg C	Pres	Seal	Frozen Date/Time	Analysis(*)
L2318715-01A	Vial HCl preserved	B	NA		3.2	Y	Absent		NYTCL-8260(14)
L2318715-01B	Vial HCl preserved	B	NA		3.2	Y	Absent		NYTCL-8260(14)
L2318715-01C	Vial HCl preserved	B	NA		3.2	Y	Absent		NYTCL-8260(14)
L2318715-01D	Plastic 250ml HNO3 preserved	B	<2	<2	3.2	Y	Absent		BA-6020T(180),TL-6020T(180),SE-6020T(180),FE-6020T(180),CR-6020T(180),K-6020T(180),CA-6020T(180),NI-6020T(180),NA-6020T(180),ZN-6020T(180),CU-6020T(180),PB-6020T(180),MN-6020T(180),BE-6020T(180),AS-6020T(180),SB-6020T(180),V-6020T(180),AG-6020T(180),CD-6020T(180),MG-6020T(180),AL-6020T(180),HG-T(28),CO-6020T(180)
L2318715-01E	Plastic 250ml NaOH preserved	B	>12	>12	3.2	Y	Absent		TCN-9010(14)
L2318715-01F	Amber 120ml unpreserved	B	8	8	3.2	Y	Absent		NYTCL-8081(7)
L2318715-01G	Amber 120ml unpreserved	B	8	8	3.2	Y	Absent		NYTCL-8081(7)
L2318715-01H	Amber 120ml unpreserved	B	8	8	3.2	Y	Absent		NYTCL-8082-LVI(365)
L2318715-01J	Amber 120ml unpreserved	B	8	8	3.2	Y	Absent		NYTCL-8082-LVI(365)
L2318715-01K	Amber 250ml unpreserved	B	8	8	3.2	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)
L2318715-01L	Amber 250ml unpreserved	B	8	8	3.2	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)
L2318715-01M	Amber 250ml unpreserved	B	8	8	3.2	Y	Absent		A2-14-DIOXANESIM-PPB(7)
L2318715-01N	Amber 250ml unpreserved	B	8	8	3.2	Y	Absent		A2-14-DIOXANESIM-PPB(7)
L2318715-01P	Plastic 500ml unpreserved	A	NA		2.3	Y	Absent		A2-NY-1633-DRAFT-21(28)
L2318715-01Q	Plastic 500ml unpreserved	A	NA		2.3	Y	Absent		A2-NY-1633-DRAFT-21(28)
L2318715-01R	Plastic 500ml unpreserved	A	NA		2.3	Y	Absent		A2-NY-1633-DRAFT-21(28)
L2318715-02A	Vial HCl preserved	B	NA		3.2	Y	Absent		NYTCL-8260(14)
L2318715-02B	Vial HCl preserved	B	NA		3.2	Y	Absent		NYTCL-8260(14)

*Values in parentheses indicate holding time in days

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

Container Information

Container ID	Container Type	Cooler	Initial pH	Final pH	Temp deg C	Pres	Seal	Frozen Date/Time	Analysis(*)
L2318715-02C	Vial HCl preserved	B	NA		3.2	Y	Absent		NYTCL-8260(14)
L2318715-02D	Plastic 250ml HNO3 preserved	B	6	<2	3.2	N	Absent		TL-6020T(180),BA-6020T(180),FE-6020T(180),SE-6020T(180),CR-6020T(180),K-6020T(180),CA-6020T(180),NI-6020T(180),NA-6020T(180),ZN-6020T(180),CU-6020T(180),PB-6020T(180),BE-6020T(180),MN-6020T(180),SB-6020T(180),AS-6020T(180),V-6020T(180),AG-6020T(180),MG-6020T(180),CD-6020T(180),HG-T(28),AL-6020T(180),CO-6020T(180)
L2318715-02E	Plastic 250ml NaOH preserved	B	>12	>12	3.2	Y	Absent		TCN-9010(14)
L2318715-02F	Amber 120ml unpreserved	B	12	12	3.2	Y	Absent		NYTCL-8081(7)
L2318715-02G	Amber 120ml unpreserved	B	12	12	3.2	Y	Absent		NYTCL-8081(7)
L2318715-02H	Amber 120ml unpreserved	B	12	12	3.2	Y	Absent		NYTCL-8082-LVI(365)
L2318715-02J	Amber 120ml unpreserved	B	12	12	3.2	Y	Absent		NYTCL-8082-LVI(365)
L2318715-02K	Amber 250ml unpreserved	B	12	12	3.2	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)
L2318715-02L	Amber 250ml unpreserved	B	12	12	3.2	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)
L2318715-02M	Amber 250ml unpreserved	B	12	12	3.2	Y	Absent		A2-14-DIOXANESIM-PPB(7)
L2318715-02N	Amber 250ml unpreserved	B	12	12	3.2	Y	Absent		A2-14-DIOXANESIM-PPB(7)
L2318715-02P	Plastic 500ml unpreserved	A	NA		2.3	Y	Absent		A2-NY-1633-DRAFT-21(28)
L2318715-02Q	Plastic 500ml unpreserved	A	NA		2.3	Y	Absent		A2-NY-1633-DRAFT-21(28)
L2318715-02R	Plastic 500ml unpreserved	A	NA		2.3	Y	Absent		A2-NY-1633-DRAFT-21(28)
L2318715-03A	5 gram Encore Sampler	B	NA		3.2	Y	Absent		NYTCL-8260HLW(14)
L2318715-03B	5 gram Encore Sampler	B	NA		3.2	Y	Absent		NYTCL-8260HLW(14)
L2318715-03C	5 gram Encore Sampler	B	NA		3.2	Y	Absent		NYTCL-8260HLW(14)
L2318715-03D	Plastic 2oz unpreserved for TS	B	NA		3.2	Y	Absent		TS(7)
L2318715-03E	Plastic 2oz unpreserved for TS	A	NA		2.3	Y	Absent		TS(7)
L2318715-03F	Metals Only-Glass 60mL/2oz unpreserved	B	NA		3.2	Y	Absent		BE-TI(180),AS-TI(180),BA-TI(180),AG-TI(180),TL-TI(180),CR-TI(180),AL-TI(180),NI-TI(180),SB-TI(180),SE-TI(180),ZN-TI(180),CU-TI(180),PB-TI(180),V-TI(180),CO-TI(180),HG-T(28),MN-TI(180),FE-TI(180),MG-TI(180),CA-TI(180),NA-TI(180),CD-TI(180),K-TI(180)
L2318715-03G	Plastic 8oz unpreserved	A	NA		2.3	Y	Absent		A2-NY-1633-DRAFT-21(90)

*Values in parentheses indicate holding time in days

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

Container Information

Container ID	Container Type	Cooler	Initial pH	Final pH	Temp deg C	Pres	Seal	Frozen Date/Time	Analysis(*)
L2318715-03H	Glass 250ml/8oz unpreserved	B	NA		3.2	Y	Absent		NYTCL-8270(14),TCN-9010(14),NYTCL-8081(14),NYTCL-8082(365)
L2318715-03X	Vial MeOH preserved split	B	NA		3.2	Y	Absent		NYTCL-8260HLW(14)
L2318715-03Y	Vial Water preserved split	B	NA		3.2	Y	Absent	08-APR-23 14:33	NYTCL-8260HLW(14)
L2318715-03Z	Vial Water preserved split	B	NA		3.2	Y	Absent	08-APR-23 14:33	NYTCL-8260HLW(14)
L2318715-04A	5 gram Encore Sampler	B	NA		3.2	Y	Absent		NYTCL-8260HLW(14)
L2318715-04B	5 gram Encore Sampler	B	NA		3.2	Y	Absent		NYTCL-8260HLW(14)
L2318715-04C	5 gram Encore Sampler	B	NA		3.2	Y	Absent		NYTCL-8260HLW(14)
L2318715-04D	Plastic 2oz unpreserved for TS	B	NA		3.2	Y	Absent		TS(7)
L2318715-04E	Metals Only-Glass 60mL/2oz unpreserved	B	NA		3.2	Y	Absent		BE-TI(180),BA-TI(180),AS-TI(180),AG-TI(180),CR-TI(180),NI-TI(180),TL-TI(180),AL-TI(180),SB-TI(180),SE-TI(180),ZN-TI(180),CU-TI(180),PB-TI(180),V-TI(180),CO-TI(180),MN-TI(180),HG-T(28),FE-TI(180),MG-TI(180),NA-TI(180),K-TI(180),CA-TI(180),CD-TI(180)
L2318715-04F	Glass 250ml/8oz unpreserved	B	NA		3.2	Y	Absent		NYTCL-8270(14),TCN-9010(14),NYTCL-8081(14),NYTCL-8082(365)
L2318715-04X	Vial MeOH preserved split	B	NA		3.2	Y	Absent		NYTCL-8260HLW(14)
L2318715-04Y	Vial Water preserved split	B	NA		3.2	Y	Absent	08-APR-23 14:33	NYTCL-8260HLW(14)
L2318715-04Z	Vial Water preserved split	B	NA		3.2	Y	Absent	08-APR-23 14:33	NYTCL-8260HLW(14)
L2318715-05A	5 gram Encore Sampler	B	NA		3.2	Y	Absent		NYTCL-8260HLW(14)
L2318715-05B	5 gram Encore Sampler	B	NA		3.2	Y	Absent		NYTCL-8260HLW(14)
L2318715-05C	5 gram Encore Sampler	B	NA		3.2	Y	Absent		NYTCL-8260HLW(14)
L2318715-05D	Plastic 2oz unpreserved for TS	B	NA		3.2	Y	Absent		TS(7)
L2318715-05E	Metals Only-Glass 60mL/2oz unpreserved	B	NA		3.2	Y	Absent		BE-TI(180),AS-TI(180),BA-TI(180),AG-TI(180),TL-TI(180),CR-TI(180),NI-TI(180),AL-TI(180),SE-TI(180),PB-TI(180),SB-TI(180),ZN-TI(180),CU-TI(180),V-TI(180),CO-TI(180),HG-T(28),MG-TI(180),FE-TI(180),MN-TI(180),NA-TI(180),K-TI(180),CD-TI(180),CA-TI(180)
L2318715-05F	Glass 250ml/8oz unpreserved	B	NA		3.2	Y	Absent		TCN-9010(14),NYTCL-8270(14),NYTCL-8081(14),NYTCL-8082(365)
L2318715-05X	Vial MeOH preserved split	B	NA		3.2	Y	Absent		NYTCL-8260HLW(14)
L2318715-05Y	Vial Water preserved split	B	NA		3.2	Y	Absent	08-APR-23 14:33	NYTCL-8260HLW(14)
L2318715-05Z	Vial Water preserved split	B	NA		3.2	Y	Absent	08-APR-23 14:33	NYTCL-8260HLW(14)

*Values in parentheses indicate holding time in days

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

PFAS PARAMETER SUMMARY

Parameter	Acronym	CAS Number
PERFLUOROALKYL CARBOXYLIC ACIDS (PFCAs)		
Perfluorooctadecanoic Acid	PFODA	16517-11-6
Perfluorohexadecanoic Acid	PFHxDA	67905-19-5
Perfluorotetradecanoic Acid	PFTA/PFTeDA	376-06-7
Perfluorotridecanoic Acid	PFTrDA	72629-94-8
Perfluorododecanoic Acid	PFDoA	307-55-1
Perfluoroundecanoic Acid	PFUnA	2058-94-8
Perfluorodecanoic Acid	PFDA	335-76-2
Perfluorononanoic Acid	PFNA	375-95-1
Perfluorooctanoic Acid	PFOA	335-67-1
Perfluoroheptanoic Acid	PFHpA	375-85-9
Perfluorohexanoic Acid	PFHxA	307-24-4
Perfluoropentanoic Acid	PFPeA	2706-90-3
Perfluorobutanoic Acid	PFBA	375-22-4
PERFLUOROALKYL SULFONIC ACIDS (PFSAs)		
Perfluorododecanesulfonic Acid	PFDoDS/PFDoS	79780-39-5
Perfluorodecanesulfonic Acid	PFDS	335-77-3
Perfluorononanesulfonic Acid	PFNS	68259-12-1
Perfluorooctanesulfonic Acid	PFOS	1763-23-1
Perfluoroheptanesulfonic Acid	PFHpS	375-92-8
Perfluorohexanesulfonic Acid	PFHxS	355-46-4
Perfluoropentanesulfonic Acid	PFPeS	2706-91-4
Perfluorobutanesulfonic Acid	PFBS	375-73-5
Perfluoropropanesulfonic Acid	PFPrS	423-41-6
FLUOROTELOMERS		
1H,1H,2H,2H-Perfluorododecanesulfonic Acid	10:2FTS	120226-60-0
1H,1H,2H,2H-Perfluorodecanesulfonic Acid	8:2FTS	39108-34-4
1H,1H,2H,2H-Perfluorooctanesulfonic Acid	6:2FTS	27619-97-2
1H,1H,2H,2H-Perfluorohexanesulfonic Acid	4:2FTS	757124-72-4
PERFLUOROALKANE SULFONAMIDES (FASAs)		
Perfluorooctanesulfonamide	FOSA/PFOSA	754-91-6
N-Ethyl Perfluorooctane Sulfonamide	NEtFOSA	4151-50-2
N-Methyl Perfluorooctane Sulfonamide	NMeFOSA	31506-32-8
PERFLUOROALKANE SULFONYL SUBSTANCES		
N-Ethyl Perfluorooctanesulfonamido Ethanol	NEtFOSE	1691-99-2
N-Methyl Perfluorooctanesulfonamido Ethanol	NMeFOSE	24448-09-7
N-Ethyl Perfluorooctanesulfonamidoacetic Acid	NEtFOSAA	2991-50-6
N-Methyl Perfluorooctanesulfonamidoacetic Acid	NMeFOSAA	2355-31-9
PER- and POLYFLUOROALKYL ETHER CARBOXYLIC ACIDS		
2,3,3,3-Tetrafluoro-2-[1,1,2,2,3,3,3-Heptafluoropropoxy]-Propanoic Acid	HFPO-DA	13252-13-6
4,8-Dioxa-3h-Perfluorononanoic Acid	ADONA	919005-14-4
CHLORO-PERFLUOROALKYL SULFONIC ACIDS		
11-Chloroeicosafluoro-3-Oxaundecane-1-Sulfonic Acid	11Cl-PF3OUdS	763051-92-9
9-Chlorohexadecafluoro-3-Oxanone-1-Sulfonic Acid	9Cl-PF3ONS	756426-58-1
PERFLUOROETHER SULFONIC ACIDS (PFESAs)		
Perfluoro(2-Ethoxyethane)Sulfonic Acid	PFEESA	113507-82-7
PERFLUOROETHER/POLYETHER CARBOXYLIC ACIDS (PFPCAs)		
Perfluoro-3-Methoxypropanoic Acid	PFMPA	377-73-1
Perfluoro-4-Methoxybutanoic Acid	PFMBA	863090-89-5
Nonafluoro-3,6-Dioxaheptanoic Acid	NFDHA	151772-58-6

Project Name: 100 MAIN ST.
Project Number: 12461:1

Lab Number: L2318715
Report Date: 04/24/23

PFAS PARAMETER SUMMARY

Parameter	Acronym	CAS Number
FLUOROTELOMER CARBOXYLIC ACIDS (FTCAs)		
3-Perfluoroheptyl Propanoic Acid	7:3FTCA	812-70-4
2H,2H,3H,3H-Perfluorooctanoic Acid	5:3FTCA	914637-49-3
3-Perfluoropropyl Propanoic Acid	3:3FTCA	356-02-5

Project Name:	100 MAIN ST.	**Lab Number:**	L2318715
Project Number:	12461:1	**Report Date:**	04/24/23

GLOSSARY

Acronyms

DL - Detection Limit: This value represents the level to which target analyte concentrations are reported as estimated values, when those target analyte concentrations are quantified below the limit of quantitation (LOQ). The DL includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.)

EDL - Estimated Detection Limit: This value represents the level to which target analyte concentrations are reported as estimated values, when those target analyte concentrations are quantified below the reporting limit (RL). The EDL includes any adjustments from dilutions, concentrations or moisture content, where applicable. The use of EDLs is specific to the analysis of PAHs using Solid-Phase Microextraction (SPME).

EMPC - Estimated Maximum Possible Concentration: The concentration that results from the signal present at the retention time of an analyte when the ions meet all of the identification criteria except the ion abundance ratio criteria. An EMPC is a worst-case estimate of the concentration.

EPA - Environmental Protection Agency.

LCS - Laboratory Control Sample: A sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes or a material containing known and verified amounts of analytes.

LCSD - Laboratory Control Sample Duplicate: Refer to LCS.

LFB - Laboratory Fortified Blank: A sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes or a material containing known and verified amounts of analytes.

LOD - Limit of Detection: This value represents the level to which a target analyte can reliably be detected for a specific analyte in a specific matrix by a specific method. The LOD includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.)

LOQ - Limit of Quantitation: The value at which an instrument can accurately measure an analyte at a specific concentration. The LOQ includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.)

Limit of Quantitation: The value at which an instrument can accurately measure an analyte at a specific concentration. The LOQ includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.)

MDL - Method Detection Limit: This value represents the level to which target analyte concentrations are reported as estimated values, when those target analyte concentrations are quantified below the reporting limit (RL). The MDL includes any adjustments from dilutions, concentrations or moisture content, where applicable.

MS - Matrix Spike Sample: A sample prepared by adding a known mass of target analyte to a specified amount of matrix sample for which an independent estimate of target analyte concentration is available. For Method 332.0, the spike recovery is calculated using the native concentration, including estimated values.

MSD - Matrix Spike Sample Duplicate: Refer to MS.

NA - Not Applicable.

NC - Not Calculated: Term is utilized when one or more of the results utilized in the calculation are non-detect at the parameter's reporting unit.

NDPA/DPA - N-Nitrosodiphenylamine/Diphenylamine.

NI - Not Ignitable.

NP - Non-Plastic: Term is utilized for the analysis of Atterberg Limits in soil.

NR - No Results: Term is utilized when 'No Target Compounds Requested' is reported for the analysis of Volatile or Semivolatile Organic TIC only requests.

RL - Reporting Limit: The value at which an instrument can accurately measure an analyte at a specific concentration. The RL includes any adjustments from dilutions, concentrations or moisture content, where applicable.

RPD - Relative Percent Difference: The results from matrix and/or matrix spike duplicates are primarily designed to assess the precision of analytical results in a given matrix and are expressed as relative percent difference (RPD). Values which are less than five times the reporting limit for any individual parameter are evaluated by utilizing the absolute difference between the values; although the RPD value will be provided in the report.

SRM - Standard Reference Material: A reference sample of a known or certified value that is of the same or similar matrix as the associated field samples.

STLP - Semi-dynamic Tank Leaching Procedure per EPA Method 1315.

TEF - Toxic Equivalency Factors: The values assigned to each dioxin and furan to evaluate their toxicity relative to 2,3,7,8-TCDD.

TEQ - Toxic Equivalent: The measure of a sample's toxicity derived by multiplying each dioxin and furan by its corresponding TEF and then summing the resulting values.

TIC - Tentatively Identified Compound: A compound that has been identified to be present and is not part of the target compound list (TCL) for the method and/or program. All TICs are qualitatively identified and reported as estimated concentrations.

Report Format: DU Report with 'J' Qualifiers

Project Name:	100 MAIN ST.	**Lab Number:**	L2318715
Project Number:	12461:1	**Report Date:**	04/24/23

Footnotes

1 - The reference for this analyte should be considered modified since this analyte is absent from the target analyte list of the original method.

Terms

Analytical Method: Both the document from which the method originates and the analytical reference method. (Example: EPA 8260B is shown as 1,8260B.) The codes for the reference method documents are provided in the References section of the Addendum.

Chlordane: The target compound Chlordane (CAS No. 57-74-9) is reported for GC ECD analyses. Per EPA,this compound "refers to a mixture of chlordane isomers, other chlorinated hydrocarbons and numerous other components." (Reference: USEPA Toxicological Review of Chlordane, In Support of Summary Information on the Integrated Risk Information System (IRIS), December 1997.)

Difference: With respect to Total Oxidizable Precursor (TOP) Assay analysis, the difference is defined as the Post-Treatment value minus the Pre-Treatment value.

Final pH: As it pertains to Sample Receipt & Container Information section of the report, Final pH reflects pH of container determined after adjustment at the laboratory, if applicable. If no adjustment required, value reflects Initial pH.

Frozen Date/Time: With respect to Volatile Organics in soil, Frozen Date/Time reflects the date/time at which associated Reagent Water-preserved vials were initially frozen. Note: If frozen date/time is beyond 48 hours from sample collection, value will be reflected in 'bold'.

Gasoline Range Organics (GRO): Gasoline Range Organics (GRO) results include all chromatographic peaks eluting from Methyl tert butyl ether through Naphthalene, with the exception of GRO analysis in support of State of Ohio programs, which includes all chromatographic peaks eluting from Hexane through Dodecane.

Initial pH: As it pertains to Sample Receipt & Container Information section of the report, Initial pH reflects pH of container determined upon receipt, if applicable.

PAH Total: With respect to Alkylated PAH analyses, the 'PAHs, Total' result is defined as the summation of results for all or a subset of the following compounds: Naphthalene, C1-C4 Naphthalenes, 2-Methylnaphthalene, 1-Methylnaphthalene, Biphenyl, Acenaphthylene, Acenaphthene, Fluorene, C1-C3 Fluorenes, Phenanthrene, C1-C4 Phenanthrenes/Anthracenes, Anthracene, Fluoranthene, Pyrene, C1-C4 Fluoranthenes/Pyrenes, Benz(a)anthracene, Chrysene, C1-C4 Chrysenes, Benzo(b)fluoranthene, Benzo(j)+(k)fluoranthene, Benzo(e)pyrene, Benzo(a)pyrene, Perylene, Indeno(1,2,3-cd)pyrene, Dibenz(ah)+(ac)anthracene, Benzo(g,h,i)perylene. If a 'Total' result is requested, the results of its individual components will also be reported.

PFAS Total: With respect to PFAS analyses, the 'PFAS, Total (5)' result is defined as the summation of results for: PFHpA, PFHxS, PFOA, PFNA and PFOS. In addition, the 'PFAS, Total (6)' result is defined as the summation of results for: PFHpA, PFHxS, PFOA, PFNA, PFDA and PFOS. For MassDEP DW compliance analysis only, the 'PFAS, Total (6)' result is defined as the summation of results at or above the RL. Note: If a 'Total' result is requested, the results of its individual components will also be reported.

Total: With respect to Organic analyses, a 'Total' result is defined as the summation of results for individual isomers or Aroclors. If a 'Total' result is requested, the results of its individual components will also be reported. This is applicable to 'Total' results for methods 8260, 8081 and 8082.

Data Qualifiers

A - Spectra identified as "Aldol Condensates" are byproducts of the extraction/concentration procedures when acetone is introduced in the process.

B - The analyte was detected above the reporting limit in the associated method blank. Flag only applies to associated field samples that have detectable concentrations of the analyte at less than ten times (10x) the concentration found in the blank. For MCP-related projects, flag only applies to associated field samples that have detectable concentrations of the analyte at less than ten times (10x) the concentration found in the blank. For DOD-related projects, flag only applies to associated field samples that have detectable concentrations of the analyte at less than ten times (10x) the concentration found in the blank AND the analyte was detected above one-half the reporting limit (or above the reporting limit for common lab contaminants) in the associated method blank. For NJ-Air-related projects, flag only applies to associated field samples that have detectable concentrations of the analyte above the reporting limit. For NJ-related projects (excluding Air), flag only applies to associated field samples that have detectable concentrations of the analyte, which was detected above the reporting limit in the associated method blank or above five times the reporting limit for common lab contaminants (Phthalates, Acetone, Methylene Chloride, 2-Butanone).

C - Co-elution: The target analyte co-elutes with a known lab standard (i.e. surrogate, internal standards, etc.) for co-extracted analyses.

D - Concentration of analyte was quantified from diluted analysis. Flag only applies to field samples that have detectable concentrations of the analyte.

E - Concentration of analyte exceeds the range of the calibration curve and/or linear range of the instrument.

F - The ratio of quantifier ion response to qualifier ion response falls outside of the laboratory criteria. Results are considered to be an estimated maximum concentration.

G - The concentration may be biased high due to matrix interferences (i.e, co-elution) with non-target compound(s). The result should be considered estimated.

H - The analysis of pH was performed beyond the regulatory-required holding time of 15 minutes from the time of sample collection.

I - The lower value for the two columns has been reported due to obvious interference.

J - Estimated value. The Target analyte concentration is below the quantitation limit (RL), but above the Method Detection Limit (MDL) or Estimated Detection Limit (EDL) for SPME-related analyses. This represents an estimated concentration for Tentatively

Report Format: DU Report with 'J' Qualifiers

Project Name:	100 MAIN ST.	**Lab Number:**	L2318715
Project Number:	12461:1	**Report Date:**	04/24/23

Data Qualifiers

Identified Compounds (TICs).

M - Reporting Limit (RL) exceeds the MCP CAM Reporting Limit for this analyte.

ND - Not detected at the method detection limit (MDL) for the sample, or estimated detection limit (EDL) for SPME-related analyses.

NJ - Presumptive evidence of compound. This represents an estimated concentration for Tentatively Identified Compounds (TICs), where the identification is based on a mass spectral library search.

P - The RPD between the results for the two columns exceeds the method-specified criteria.

Q - The quality control sample exceeds the associated acceptance criteria. For DOD-related projects, LCS and/or Continuing Calibration Standard exceedences are also qualified on all associated sample results. Note: This flag is not applicable for matrix spike recoveries when the sample concentration is greater than 4x the spike added or for batch duplicate RPD when the sample concentrations are less than 5x the RL. (Metals only.)

R - Analytical results are from sample re-analysis.

RE - Analytical results are from sample re-extraction.

S - Analytical results are from modified screening analysis.

V - The surrogate associated with this target analyte has a recovery outside the QC acceptance limits. (Applicable to MassDEP DW Compliance samples only.)

Z - The batch matrix spike and/or duplicate associated with this target analyte has a recovery/RPD outside the QC acceptance limits. (Applicable to MassDEP DW Compliance samples only.)

Report Format: DU Report with 'J' Qualifiers

Project Name:	100 MAIN ST.	**Lab Number:**	L2318715
Project Number:	12461:1	**Report Date:**	04/24/23

REFERENCES

1 Test Methods for Evaluating Solid Waste: Physical/Chemical Methods. EPA SW-846. Third Edition. Updates I - VI, 2018.

121 Standard Methods for the Examination of Water and Wastewater. APHA-AWWA-WEF. Standard Methods Online.

144 Analysis of Per- and Polyfluoroalkyl Substances (PFAS) in Aqueous, Solid, Biosolids, and Tissue Samples by LC-MS/MS. Draft EPA Method 1633, EPA Document 821-D-22-001, June 2022.

LIMITATION OF LIABILITIES

Alpha Analytical performs services with reasonable care and diligence normal to the analytical testing laboratory industry. In the event of an error, the sole and exclusive responsibility of Alpha Analytical shall be to re-perform the work at it's own expense. In no event shall Alpha Analytical be held liable for any incidental, consequential or special damages, including but not limited to, damages in any way connected with the use of, interpretation of, information or analysis provided by Alpha Analytical.

We strongly urge our clients to comply with EPA protocol regarding sample volume, preservation, cooling, containers, sampling procedures, holding time and splitting of samples in the field.

Certification Information

The following analytes are not included in our Primary NELAP Scope of Accreditation:

Westborough Facility
EPA 624/624.1: m/p-xylene, o-xylene, Naphthalene
EPA 625/625.1: alpha-Terpineol
EPA 8260C/8260D: NPW: 1,2,4,5-Tetramethylbenzene; 4-Ethyltoluene, Azobenzene; SCM: Iodomethane (methyl iodide), 1,2,4,5-Tetramethylbenzene; 4-Ethyltoluene.
EPA 8270D/8270E: NPW: Dimethylnaphthalene,1,4-Diphenylhydrazine, alpha-Terpineol; SCM: Dimethylnaphthalene,1,4-Diphenylhydrazine.
SM4500: NPW: Amenable Cyanide; SCM: Total Phosphorus, TKN, NO2, NO3.

Mansfield Facility
SM 2540D: TSS
EPA 8082A: NPW: PCB: 1, 5, 31, 87,101, 110, 141, 151, 153, 180, 183, 187.
EPA TO-15: Halothane, 2,4,4-Trimethyl-2-pentene, 2,4,4-Trimethyl-1-pentene, Thiophene, 2-Methylthiophene, 3-Methylthiophene, 2-Ethylthiophene, 1,2,3-Trimethylbenzene, Indan, Indene, 1,2,4,5-Tetramethylbenzene, Benzothiophene, 1-Methylnaphthalene.
Biological Tissue Matrix: EPA 3050B

The following analytes are included in our Massachusetts DEP Scope of Accreditation

Westborough Facility:

Drinking Water
EPA 300.0: Chloride, Nitrate-N, Fluoride, Sulfate; **EPA 353.2**: Nitrate-N, Nitrite-N; **SM4500NO3-F**: Nitrate-N, Nitrite-N; **SM4500F-C, SM4500CN-CE, EPA 180.1, SM2130B, SM4500Cl-D, SM2320B, SM2540C, SM4500H-B, SM4500NO2-B**
EPA 332: Perchlorate; **EPA 524.2:** THMs and VOCs; **EPA 504.1:** EDB, DBCP.
Microbiology: **SM9215B; SM9223-P/A, SM9223B-Colilert-QT,SM9222D**.

Non-Potable Water
SM4500H,B, EPA 120.1, SM2510B, SM2540C, SM2320B, SM4500CL-E, SM4500F-BC, SM4500NH3-BH: Ammonia-N and Kjeldahl-N, **EPA 350.1**: Ammonia-N, **LACHAT 10-107-06-1-B**: Ammonia-N, **EPA 351.1, SM4500NO3-F, EPA 353.2**: Nitrate-N, **SM4500P-E, SM4500P-B, E, SM4500SO4-E, SM5220D, EPA 410.4, SM5210B, SM5310C, SM4500CL-D, EPA 1664, EPA 420.1, SM4500-CN-CE, SM2540D, EPA 300: Chloride, Sulfate, Nitrate.**
EPA 624.1: Volatile Halocarbons & Aromatics,
EPA 608.3: Chlordane, Toxaphene, Aldrin, alpha-BHC, beta-BHC, gamma-BHC, delta-BHC, Dieldrin, DDD, DDE, DDT, Endosulfan I, Endosulfan II, Endosulfan sulfate, Endrin, Endrin Aldehyde, Heptachlor, Heptachlor Epoxide, PCBs
EPA 625.1: SVOC (Acid/Base/Neutral Extractables), **EPA 600/4-81-045**: PCB-Oil.
Microbiology: **SM9223B-Colilert-QT; Enterolert-QT, SM9221E, EPA 1600, EPA 1603, SM9222D.**

Mansfield Facility:

Drinking Water
EPA 200.7: Al, Ba, Cd, Cr, Cu, Fe, Mn, Ni, Na, Ag, Ca, Zn. **EPA 200.8:** Al, Sb, As, Ba, Be, Cd, Cr, Cu, Pb, Mn, Ni, Se, Ag, TL, Zn. **EPA 245.1** Hg.
EPA 522, EPA 537.1.

Non-Potable Water
EPA 200.7: Al, Sb, As, Be, Cd, Ca, Cr, Co, Cu, Fe, Pb, Mg, Mn, Mo, Ni, K, Se, Ag, Na, Sr, TL, Ti, V, Zn.
EPA 200.8: Al, Sb, As, Be, Cd, Cr, Cu, Fe, Pb, Mn, Ni, K, Se, Ag, Na, TL, Zn.
EPA 245.1 Hg.
SM2340B

For a complete listing of analytes and methods, please contact your Alpha Project Manager.

NEW YORK CHAIN OF CUSTODY

ALPHA ANALYTICAL

Westborough, MA 01581
8 Walkup Dr.
TEL: 508-898-9220
FAX: 508-898-9193

Mansfield, MA 02048
320 Forbes Blvd
TEL: 508-822-9300
FAX: 508-822-3288

Service Centers
Mahwah, NJ 07430: 35 Whitney Rd, Suite 5
Albany, NY 12205: 14 Walker Way
Tonawanda, NY 14150: 275 Cooper Ave, Suite 105

Page 1 of 1

Date Rec'd in Lab: 04/07/23

ALPHA Job #: L2318715

Client Information
Client: GESI
Address: 959 US46 Fl3 Ste300
Parsippany, NJ 07054
Phone: 973 808 9050
Fax:
Email: JCS@gesi.org

Project Information
Project Name: 100 Main St
Project Location: White Plains NY
Project #: 1746181
(Use Project name as Project #)
Project Manager: Jon Stuart
ALPHAQuote #:

Turn-Around Time
Standard ☑ Due Date:
Rush (only if pre approved) ☐ # of Days:

Deliverables
☐ ASP-A ☑ ASP-B
☐ EQuIS (1 File) ☑ EQuIS (4 File) NY
☐ Other

Regulatory Requirement
☐ NY TOGS ☐ NY Part 375
☑ AWQ Standards ☐ NY CP-51
☑ NY Restricted Use ☐ Other
☑ NY Unrestricted Use
☐ NYC Sewer Discharge

Billing Information
☐ Same as Client Info
PO # Renaissance Env Mgmt
Attn: Kevin McNamus

Disposal Site Information
Please identify below location of applicable disposal facilities.
Disposal Facility:
☐ NJ ☐ NY
☐ Other:

These samples have been previously analyzed by Alpha ☐

Other project specific requirements/comments:

Please specify Metals or TAL.

ANALYSIS

Sample Filtration
☐ Done
☐ Lab to do
Preservation
☐ Lab to do
(Please Specify below)

Total Bottle

ALPHA Lab ID (Lab Use Only)	Sample ID	Collection Date	Collection Time	Sample Matrix	Sampler's Initials	TCL+30 TAL	1-4 Dioxane	PFAS Method 1633	Sample Specific Comments
18715 -01	GW-8	4/7/23	815	GW	CB	✓	✓	✓	Preservatives
-02	GW-9		1345	GW	CB	✓	✓	✓	Preservatives
-03	SB-8G (1.5-2)		1045	Soil	CB	✓	✓	✓	
-04	SB-20G (2.5-3)		1430	Soil	CB	✓	✓		
-05	SB-21G (0.5-1)	↓	1415	Soil	CB	✓	✓		

Preservative Code:
A = None
B = HCl
C = HNO_3
D = H_2SO_4
E = NaOH
F = MeOH
G = $NaHSO_4$
H = $Na_2S_2O_3$
K/E = Zn Ac/NaOH
O = Other

Container Code
P = Plastic
A = Amber Glass
V = Vial
G = Glass
B = Bacteria Cup
C = Cube
O = Other
E = Encore
D = BOD Bottle

Westboro: Certification No: MA935
Mansfield: Certification No: MA015

Container Type	P/G	P/G	P						
Preservative	/	/	/						

Relinquished By:	Date/Time	Received By:	Date/Time
	04/07/23		4/7/23 15:10
	4/7/23 17:50		4/7/23
	4/7/23		4/7/23 18:30
	4/7/23 2350		4/7/23 2392

Please print clearly, legibly and completely. Samples can not be logged in and turnaround time clock will not start until any ambiguities are resolved. BY EXECUTING THIS COC, THE CLIENT HAS READ AND AGREES TO BE BOUND BY ALPHA'S TERMS & CONDITIONS. (See reverse side.)

(Rev. 30-Sept-2013)

ANALYTICAL REPORT

Lab Number:	L2331226
Client:	Soils Engineering Services, Inc. 959 Route 46E Parsippany, NJ 07054
ATTN:	Steven Gustems
Phone:	(973) 808-9050
Project Name:	100 MAIN ST.
Project Number:	12461
Report Date:	06/13/23

The original project report/data package is held by Alpha Analytical. This report/data package is paginated and should be reproduced only in its entirety. Alpha Analytical holds no responsibility for results and/or data that are not consistent with the original.

Certifications & Approvals: MA (M-MA086), NH NELAP (2064), CT (PH-0826), IL (200077), IN (C-MA-03), KY (KY98045), ME (MA00086), MD (348), NJ (MA935), NY (11148), NC (25700/666), OH (CL108), OR (MA-1316), PA (68-03671), RI (LAO00065), TX (T104704476), VT (VT-0935), VA (460195), USDA (Permit #525-23-122-91930).

Eight Walkup Drive, Westborough, MA 01581-1019
508-898-9220 (Fax) 508-898-9193 800-624-9220 - www.alphalab.com

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331226
Report Date: 06/13/23

Alpha Sample ID	Client ID	Matrix	Sample Location	Collection Date/Time	Receive Date
L2331226-01	SB-20G (1.5-2)	SOIL	WHITE PLAINS, NY	06/05/23 10:00	06/05/23
L2331226-02	SB-21G (9-9.5)	SOIL	WHITE PLAINS, NY	06/05/23 11:15	06/05/23
L2331226-03	SB-21G (12-12.5)	SOIL	WHITE PLAINS, NY	06/05/23 11:20	06/05/23
L2331226-04	SB-22G (7-7.5)	SOIL	WHITE PLAINS, NY	06/05/23 12:15	06/05/23
L2331226-05	SB-23G (9.5-10)	SOIL	WHITE PLAINS, NY	06/05/23 12:50	06/05/23
L2331226-06	SB-24G (7.5-8)	SOIL	WHITE PLAINS, NY	06/05/23 12:30	06/05/23
L2331226-07	SB-25G (9.5-10)	SOIL	WHITE PLAINS, NY	06/05/23 10:40	06/05/23
L2331226-08	GW-10	WATER	WHITE PLAINS, NY	06/05/23 12:00	06/05/23
L2331226-09	GW-11	WATER	WHITE PLAINS, NY	06/05/23 13:20	06/05/23

Project Name:	100 MAIN ST.	**Lab Number:**	L2331226
Project Number:	12461	**Report Date:**	06/13/23

Case Narrative

The samples were received in accordance with the Chain of Custody and no significant deviations were encountered during the preparation or analysis unless otherwise noted. Sample Receipt, Container Information, and the Chain of Custody are located at the back of the report.

Results contained within this report relate only to the samples submitted under this Alpha Lab Number and meet NELAP requirements for all NELAP accredited parameters unless otherwise noted in the following narrative. The data presented in this report is organized by parameter (i.e. VOC, SVOC, etc.). Sample specific Quality Control data (i.e. Surrogate Spike Recovery) is reported at the end of the target analyte list for each individual sample, followed by the Laboratory Batch Quality Control at the end of each parameter. Tentatively Identified Compounds (TICs), if requested, are reported for compounds identified to be present and are not part of the method/program Target Compound List, even if only a subset of the TCL are being reported. If a sample was re-analyzed or re-extracted due to a required quality control corrective action and if both sets of data are reported, the Laboratory ID of the re-analysis or re-extraction is designated with an "R" or "RE", respectively.

When multiple Batch Quality Control elements are reported (e.g. more than one LCS), the associated samples for each element are noted in the grey shaded header line of each data table. Any Laboratory Batch, Sample Specific % recovery or RPD value that is outside the listed Acceptance Criteria is bolded in the report. In reference to questions H (CAM) or 4 (RCP) when "NO" is checked, the performance criteria for CAM and RCP methods allow for some quality control failures to occur and still be within method compliance. In these instances, the specific failure is not narrated but noted in the associated QC Outlier Summary Report, located directly after the Case Narrative. QC information is also incorporated in the Data Usability Assessment table (Format 11) of our Data Merger tool, where it can be reviewed in conjunction with the sample result, associated regulatory criteria and any associated data usability implications.

Soil/sediments, solids and tissues are reported on a dry weight basis unless otherwise noted. Definitions of all data qualifiers and acronyms used in this report are provided in the Glossary located at the back of the report.

HOLD POLICY - For samples submitted on hold, Alpha's policy is to hold samples (with the exception of Air canisters) free of charge for 21 calendar days from the date the project is completed. After 21 calendar days, we will dispose of all samples submitted including those put on hold unless you have contacted your Alpha Project Manager and made arrangements for Alpha to continue to hold the samples. Air canisters will be disposed after 3 business days from the date the project is completed.

Please contact Project Management at 800-624-9220 with any questions.

Project Name:	100 MAIN ST.	**Lab Number:**	L2331226
Project Number:	12461	**Report Date:**	06/13/23

Case Narrative (continued)

Report Submission

All non-detect (ND) or estimated concentrations (J-qualified) have been quantitated to the limit noted in the MDL column.

Volatile Organics

L2331226-02: The sample was analyzed as a High Level Methanol in order to quantitate results within the calibration range. The result should be considered estimated, and is qualified with an E flag, for any compound that exceeded the calibration on the initial Low Level analysis. The results of both analyses are reported. Differences were noted between the results of the analyses which have been attributed to vial discrepancies.
L2331226-02: The surrogate recovery is outside the acceptance criteria for 4-bromofluorobenzene (136%); however, the sample was not re-analyzed due to coelution with an obvious interference. A copy of the chromatogram is included as an attachment to this report.
L2331226-08 and -09: The pH was greater than two; however, the sample was analyzed within the method required holding time.
The WG1788684-5 Method Blank, associated with L2331226-01 and -05, has a concentration above the reporting limit for Bromomethane. Since the associated sample concentrations are either greater than 10x the blank concentration or non-detect to the RL for this target analyte, no corrective action is required. Any results detected below the reporting limit are qualified with a "B".

Total Metals

L2331226-01 through -07: The sample has elevated detection limits for all elements, with the exception of mercury, due to the dilution required by the sample matrix.

I, the undersigned, attest under the pains and penalties of perjury that, to the best of my knowledge and belief and based upon my personal inquiry of those responsible for providing the information contained in this analytical report, such information is accurate and complete. This certificate of analysis is not complete unless this page accompanies any and all pages of this report.

Authorized Signature: Tiffani Morrissey - Tiffani Morrissey

Title: Technical Director/Representative Date: 06/13/23

ORGANICS

VOLATILES

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-01
Client ID: SB-20G (1.5-2)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 10:00
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8260D
Analytical Date: 06/08/23 00:24
Analyst: MKS
Percent Solids: 94%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Methylene chloride	ND		ug/kg	5.2	2.4	1
1,1-Dichloroethane	ND		ug/kg	1.0	0.15	1
Chloroform	ND		ug/kg	1.6	0.14	1
Carbon tetrachloride	ND		ug/kg	1.0	0.24	1
1,2-Dichloropropane	ND		ug/kg	1.0	0.13	1
Dibromochloromethane	ND		ug/kg	1.0	0.14	1
1,1,2-Trichloroethane	ND		ug/kg	1.0	0.28	1
Tetrachloroethene	ND		ug/kg	0.52	0.20	1
Chlorobenzene	ND		ug/kg	0.52	0.13	1
Trichlorofluoromethane	ND		ug/kg	4.2	0.72	1
1,2-Dichloroethane	ND		ug/kg	1.0	0.27	1
1,1,1-Trichloroethane	ND		ug/kg	0.52	0.17	1
Bromodichloromethane	ND		ug/kg	0.52	0.11	1
trans-1,3-Dichloropropene	ND		ug/kg	1.0	0.28	1
cis-1,3-Dichloropropene	ND		ug/kg	0.52	0.16	1
1,3-Dichloropropene, Total	ND		ug/kg	0.52	0.16	1
1,1-Dichloropropene	ND		ug/kg	0.52	0.16	1
Bromoform	ND		ug/kg	4.2	0.26	1
1,1,2,2-Tetrachloroethane	ND		ug/kg	0.52	0.17	1
Benzene	ND		ug/kg	0.52	0.17	1
Toluene	ND		ug/kg	1.0	0.57	1
Ethylbenzene	ND		ug/kg	1.0	0.15	1
Chloromethane	ND		ug/kg	4.2	0.97	1
Bromomethane	ND		ug/kg	2.1	0.60	1
Vinyl chloride	ND		ug/kg	1.0	0.35	1
Chloroethane	ND		ug/kg	2.1	0.47	1
1,1-Dichloroethene	ND		ug/kg	1.0	0.25	1
trans-1,2-Dichloroethene	ND		ug/kg	1.6	0.14	1

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-01 Date Collected: 06/05/23 10:00

Client ID: SB-20G (1.5-2) Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Trichloroethene	ND		ug/kg	0.52	0.14	1
1,2-Dichlorobenzene	ND		ug/kg	2.1	0.15	1
1,3-Dichlorobenzene	ND		ug/kg	2.1	0.15	1
1,4-Dichlorobenzene	ND		ug/kg	2.1	0.18	1
Methyl tert butyl ether	ND		ug/kg	2.1	0.21	1
p/m-Xylene	ND		ug/kg	2.1	0.58	1
o-Xylene	ND		ug/kg	1.0	0.30	1
Xylenes, Total	ND		ug/kg	1.0	0.30	1
cis-1,2-Dichloroethene	ND		ug/kg	1.0	0.18	1
1,2-Dichloroethene, Total	ND		ug/kg	1.0	0.14	1
Dibromomethane	ND		ug/kg	2.1	0.25	1
Styrene	ND		ug/kg	1.0	0.20	1
Dichlorodifluoromethane	ND		ug/kg	10	0.95	1
Acetone	9.0	J	ug/kg	10	5.0	1
Carbon disulfide	ND		ug/kg	10	4.7	1
2-Butanone	4.3	J	ug/kg	10	2.3	1
Vinyl acetate	ND		ug/kg	10	2.2	1
4-Methyl-2-pentanone	ND		ug/kg	10	1.3	1
1,2,3-Trichloropropane	ND		ug/kg	2.1	0.13	1
2-Hexanone	ND		ug/kg	10	1.2	1
Bromochloromethane	ND		ug/kg	2.1	0.21	1
2,2-Dichloropropane	ND		ug/kg	2.1	0.21	1
1,2-Dibromoethane	ND		ug/kg	1.0	0.29	1
1,3-Dichloropropane	ND		ug/kg	2.1	0.17	1
1,1,1,2-Tetrachloroethane	ND		ug/kg	0.52	0.14	1
Bromobenzene	ND		ug/kg	2.1	0.15	1
n-Butylbenzene	ND		ug/kg	1.0	0.17	1
sec-Butylbenzene	ND		ug/kg	1.0	0.15	1
tert-Butylbenzene	ND		ug/kg	2.1	0.12	1
o-Chlorotoluene	ND		ug/kg	2.1	0.20	1
p-Chlorotoluene	ND		ug/kg	2.1	0.11	1
1,2-Dibromo-3-chloropropane	ND		ug/kg	3.1	1.0	1
Hexachlorobutadiene	ND		ug/kg	4.2	0.18	1
Isopropylbenzene	ND		ug/kg	1.0	0.11	1
p-Isopropyltoluene	ND		ug/kg	1.0	0.11	1
Naphthalene	ND		ug/kg	4.2	0.68	1
Acrylonitrile	ND		ug/kg	4.2	1.2	1

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-01 Date Collected: 06/05/23 10:00

Client ID: SB-20G (1.5-2) Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
n-Propylbenzene	ND		ug/kg	1.0	0.18	1
1,2,3-Trichlorobenzene	ND		ug/kg	2.1	0.34	1
1,2,4-Trichlorobenzene	ND		ug/kg	2.1	0.28	1
1,3,5-Trimethylbenzene	ND		ug/kg	2.1	0.20	1
1,2,4-Trimethylbenzene	ND		ug/kg	2.1	0.35	1
1,4-Dioxane	ND		ug/kg	83	36.	1
p-Diethylbenzene	ND		ug/kg	2.1	0.18	1
p-Ethyltoluene	ND		ug/kg	2.1	0.40	1
1,2,4,5-Tetramethylbenzene	ND		ug/kg	2.1	0.20	1
Ethyl ether	ND		ug/kg	2.1	0.36	1
trans-1,4-Dichloro-2-butene	ND		ug/kg	5.2	1.5	1
Tentatively Identified Compounds						
Total TIC Compounds	21.6	J	ug/kg			1
Unknown	21.6	J	ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	**135**	Q	70-130
Toluene-d8	91		70-130
4-Bromofluorobenzene	87		70-130
Dibromofluoromethane	125		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-02
Client ID: SB-21G (9-9.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 11:15
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8260D
Analytical Date: 06/08/23 18:00
Analyst: JIC
Percent Solids: 91%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Methylene chloride	ND		ug/kg	5.2	2.4	1
1,1-Dichloroethane	ND		ug/kg	1.0	0.15	1
Chloroform	ND		ug/kg	1.6	0.14	1
Carbon tetrachloride	ND		ug/kg	1.0	0.24	1
1,2-Dichloropropane	ND		ug/kg	1.0	0.13	1
Dibromochloromethane	ND		ug/kg	1.0	0.14	1
1,1,2-Trichloroethane	ND		ug/kg	1.0	0.28	1
Tetrachloroethene	ND		ug/kg	0.52	0.20	1
Chlorobenzene	ND		ug/kg	0.52	0.13	1
Trichlorofluoromethane	ND		ug/kg	4.1	0.72	1
1,2-Dichloroethane	ND		ug/kg	1.0	0.27	1
1,1,1-Trichloroethane	ND		ug/kg	0.52	0.17	1
Bromodichloromethane	ND		ug/kg	0.52	0.11	1
trans-1,3-Dichloropropene	ND		ug/kg	1.0	0.28	1
cis-1,3-Dichloropropene	ND		ug/kg	0.52	0.16	1
1,3-Dichloropropene, Total	ND		ug/kg	0.52	0.16	1
1,1-Dichloropropene	ND		ug/kg	0.52	0.16	1
Bromoform	ND		ug/kg	4.1	0.25	1
1,1,2,2-Tetrachloroethane	ND		ug/kg	0.52	0.17	1
Benzene	ND		ug/kg	0.52	0.17	1
Toluene	ND		ug/kg	1.0	0.56	1
Ethylbenzene	ND		ug/kg	1.0	0.15	1
Chloromethane	ND		ug/kg	4.1	0.97	1
Bromomethane	ND		ug/kg	2.1	0.60	1
Vinyl chloride	ND		ug/kg	1.0	0.35	1
Chloroethane	ND		ug/kg	2.1	0.47	1
1,1-Dichloroethene	ND		ug/kg	1.0	0.25	1
trans-1,2-Dichloroethene	ND		ug/kg	1.6	0.14	1

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-02 Date Collected: 06/05/23 11:15

Client ID: SB-21G (9-9.5) Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Trichloroethene	ND		ug/kg	0.52	0.14	1
1,2-Dichlorobenzene	ND		ug/kg	2.1	0.15	1
1,3-Dichlorobenzene	ND		ug/kg	2.1	0.15	1
1,4-Dichlorobenzene	ND		ug/kg	2.1	0.18	1
Methyl tert butyl ether	ND		ug/kg	2.1	0.21	1
p/m-Xylene	ND		ug/kg	2.1	0.58	1
o-Xylene	ND		ug/kg	1.0	0.30	1
Xylenes, Total	ND		ug/kg	1.0	0.30	1
cis-1,2-Dichloroethene	ND		ug/kg	1.0	0.18	1
1,2-Dichloroethene, Total	ND		ug/kg	1.0	0.14	1
Dibromomethane	ND		ug/kg	2.1	0.25	1
Styrene	ND		ug/kg	1.0	0.20	1
Dichlorodifluoromethane	ND		ug/kg	10	0.95	1
Acetone	91		ug/kg	10	5.0	1
Carbon disulfide	ND		ug/kg	10	4.7	1
2-Butanone	9.6	J	ug/kg	10	2.3	1
Vinyl acetate	ND		ug/kg	10	2.2	1
4-Methyl-2-pentanone	ND		ug/kg	10	1.3	1
1,2,3-Trichloropropane	ND		ug/kg	2.1	0.13	1
2-Hexanone	ND		ug/kg	10	1.2	1
Bromochloromethane	ND		ug/kg	2.1	0.21	1
2,2-Dichloropropane	ND		ug/kg	2.1	0.21	1
1,2-Dibromoethane	ND		ug/kg	1.0	0.29	1
1,3-Dichloropropane	ND		ug/kg	2.1	0.17	1
1,1,1,2-Tetrachloroethane	ND		ug/kg	0.52	0.14	1
Bromobenzene	ND		ug/kg	2.1	0.15	1
n-Butylbenzene	ND		ug/kg	1.0	0.17	1
sec-Butylbenzene	ND		ug/kg	1.0	0.15	1
tert-Butylbenzene	ND		ug/kg	2.1	0.12	1
o-Chlorotoluene	ND		ug/kg	2.1	0.20	1
p-Chlorotoluene	ND		ug/kg	2.1	0.11	1
1,2-Dibromo-3-chloropropane	ND		ug/kg	3.1	1.0	1
Hexachlorobutadiene	ND		ug/kg	4.1	0.18	1
Isopropylbenzene	ND		ug/kg	1.0	0.11	1
p-Isopropyltoluene	1000	E	ug/kg	1.0	0.11	1
Naphthalene	ND		ug/kg	4.1	0.67	1
Acrylonitrile	ND		ug/kg	4.1	1.2	1

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-02 Date Collected: 06/05/23 11:15

Client ID: SB-21G (9-9.5) Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
n-Propylbenzene	ND		ug/kg	1.0	0.18	1
1,2,3-Trichlorobenzene	ND		ug/kg	2.1	0.33	1
1,2,4-Trichlorobenzene	ND		ug/kg	2.1	0.28	1
1,3,5-Trimethylbenzene	0.44	J	ug/kg	2.1	0.20	1
1,2,4-Trimethylbenzene	ND		ug/kg	2.1	0.35	1
1,4-Dioxane	ND		ug/kg	83	36.	1
p-Diethylbenzene	ND		ug/kg	2.1	0.18	1
p-Ethyltoluene	ND		ug/kg	2.1	0.40	1
1,2,4,5-Tetramethylbenzene	ND		ug/kg	2.1	0.20	1
Ethyl ether	ND		ug/kg	2.1	0.35	1
trans-1,4-Dichloro-2-butene	ND		ug/kg	5.2	1.5	1
Tentatively Identified Compounds						
Total TIC Compounds	20.7	J	ug/kg			1
Unknown	20.7	J	ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	100		70-130
Toluene-d8	103		70-130
4-Bromofluorobenzene	104		70-130
Dibromofluoromethane	94		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-02
Client ID: SB-21G (9-9.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 11:15
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8260D
Analytical Date: 06/09/23 17:55
Analyst: JIC
Percent Solids: 91%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 High - Westborough Lab						
Methylene chloride	ND		ug/kg	300	140	1
1,1-Dichloroethane	ND		ug/kg	60	8.7	1
Chloroform	ND		ug/kg	90	8.4	1
Carbon tetrachloride	ND		ug/kg	60	14.	1
1,2-Dichloropropane	ND		ug/kg	60	7.5	1
Dibromochloromethane	ND		ug/kg	60	8.4	1
1,1,2-Trichloroethane	ND		ug/kg	60	16.	1
Tetrachloroethene	ND		ug/kg	30	12.	1
Chlorobenzene	ND		ug/kg	30	7.6	1
Trichlorofluoromethane	ND		ug/kg	240	42.	1
1,2-Dichloroethane	ND		ug/kg	60	15.	1
1,1,1-Trichloroethane	ND		ug/kg	30	10.	1
Bromodichloromethane	ND		ug/kg	30	6.6	1
trans-1,3-Dichloropropene	ND		ug/kg	60	16.	1
cis-1,3-Dichloropropene	ND		ug/kg	30	9.5	1
1,3-Dichloropropene, Total	ND		ug/kg	30	9.5	1
1,1-Dichloropropene	ND		ug/kg	30	9.6	1
Bromoform	ND		ug/kg	240	15.	1
1,1,2,2-Tetrachloroethane	ND		ug/kg	30	10.	1
Benzene	ND		ug/kg	30	10.	1
Toluene	ND		ug/kg	60	33.	1
Ethylbenzene	ND		ug/kg	60	8.5	1
Chloromethane	ND		ug/kg	240	56.	1
Bromomethane	ND		ug/kg	120	35.	1
Vinyl chloride	ND		ug/kg	60	20.	1
Chloroethane	ND		ug/kg	120	27.	1
1,1-Dichloroethene	ND		ug/kg	60	14.	1
trans-1,2-Dichloroethene	ND		ug/kg	90	8.2	1

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-02 Date Collected: 06/05/23 11:15

Client ID: SB-21G (9-9.5) Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 High - Westborough Lab						
Trichloroethene	ND		ug/kg	30	8.2	1
1,2-Dichlorobenzene	ND		ug/kg	120	8.7	1
1,3-Dichlorobenzene	ND		ug/kg	120	8.9	1
1,4-Dichlorobenzene	ND		ug/kg	120	10.	1
Methyl tert butyl ether	ND		ug/kg	120	12.	1
p/m-Xylene	ND		ug/kg	120	34.	1
o-Xylene	ND		ug/kg	60	18.	1
Xylenes, Total	ND		ug/kg	60	18.	1
cis-1,2-Dichloroethene	ND		ug/kg	60	10.	1
1,2-Dichloroethene, Total	ND		ug/kg	60	8.2	1
Dibromomethane	ND		ug/kg	120	14.	1
Styrene	ND		ug/kg	60	12.	1
Dichlorodifluoromethane	ND		ug/kg	600	55.	1
Acetone	ND		ug/kg	600	290	1
Carbon disulfide	ND		ug/kg	600	270	1
2-Butanone	ND		ug/kg	600	130	1
Vinyl acetate	ND		ug/kg	600	130	1
4-Methyl-2-pentanone	ND		ug/kg	600	77.	1
1,2,3-Trichloropropane	ND		ug/kg	120	7.6	1
2-Hexanone	ND		ug/kg	600	71.	1
Bromochloromethane	ND		ug/kg	120	12.	1
2,2-Dichloropropane	ND		ug/kg	120	12.	1
1,2-Dibromoethane	ND		ug/kg	60	17.	1
1,3-Dichloropropane	ND		ug/kg	120	10.	1
1,1,1,2-Tetrachloroethane	ND		ug/kg	30	8.0	1
Bromobenzene	ND		ug/kg	120	8.7	1
n-Butylbenzene	ND		ug/kg	60	10.	1
sec-Butylbenzene	ND		ug/kg	60	8.8	1
tert-Butylbenzene	ND		ug/kg	120	7.1	1
o-Chlorotoluene	ND		ug/kg	120	12.	1
p-Chlorotoluene	ND		ug/kg	120	6.5	1
1,2-Dibromo-3-chloropropane	ND		ug/kg	180	60.	1
Hexachlorobutadiene	ND		ug/kg	240	10.	1
Isopropylbenzene	ND		ug/kg	60	6.6	1
p-Isopropyltoluene	2500		ug/kg	60	6.6	1
Naphthalene	ND		ug/kg	240	39.	1
Acrylonitrile	ND		ug/kg	240	69.	1

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-02 Date Collected: 06/05/23 11:15

Client ID: SB-21G (9-9.5) Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 High - Westborough Lab						
n-Propylbenzene	ND		ug/kg	60	10.	1
1,2,3-Trichlorobenzene	ND		ug/kg	120	19.	1
1,2,4-Trichlorobenzene	ND		ug/kg	120	16.	1
1,3,5-Trimethylbenzene	ND		ug/kg	120	12.	1
1,2,4-Trimethylbenzene	ND		ug/kg	120	20.	1
1,4-Dioxane	ND		ug/kg	4800	2100	1
p-Diethylbenzene	ND		ug/kg	120	11.	1
p-Ethyltoluene	ND		ug/kg	120	23.	1
1,2,4,5-Tetramethylbenzene	ND		ug/kg	120	12.	1
Ethyl ether	ND		ug/kg	120	20.	1
trans-1,4-Dichloro-2-butene	ND		ug/kg	300	86.	1
Tentatively Identified Compounds						
Total TIC Compounds	8440	J	ug/kg			1
Unknown	324	J	ug/kg			1
Unknown	333	J	ug/kg			1
Unknown	674	J	ug/kg			1
Unknown	386	J	ug/kg			1
Unknown Naphthalene	284	J	ug/kg			1
Unknown Alkane	2570	J	ug/kg			1
Unknown	260	J	ug/kg			1
Unknown	324	J	ug/kg			1
Unknown	2960	J	ug/kg			1
Unknown	322	J	ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	100		70-130
Toluene-d8	99		70-130
4-Bromofluorobenzene	**136**	Q	70-130
Dibromofluoromethane	115		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-03
Client ID: SB-21G (12-12.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 11:20
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8260D
Analytical Date: 06/08/23 10:51
Analyst: AJK
Percent Solids: 82%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Methylene chloride	ND		ug/kg	5.5	2.5	1
1,1-Dichloroethane	ND		ug/kg	1.1	0.16	1
Chloroform	ND		ug/kg	1.6	0.15	1
Carbon tetrachloride	ND		ug/kg	1.1	0.25	1
1,2-Dichloropropane	ND		ug/kg	1.1	0.14	1
Dibromochloromethane	ND		ug/kg	1.1	0.15	1
1,1,2-Trichloroethane	ND		ug/kg	1.1	0.29	1
Tetrachloroethene	ND		ug/kg	0.55	0.21	1
Chlorobenzene	ND		ug/kg	0.55	0.14	1
Trichlorofluoromethane	ND		ug/kg	4.4	0.76	1
1,2-Dichloroethane	ND		ug/kg	1.1	0.28	1
1,1,1-Trichloroethane	ND		ug/kg	0.55	0.18	1
Bromodichloromethane	ND		ug/kg	0.55	0.12	1
trans-1,3-Dichloropropene	ND		ug/kg	1.1	0.30	1
cis-1,3-Dichloropropene	ND		ug/kg	0.55	0.17	1
1,3-Dichloropropene, Total	ND		ug/kg	0.55	0.17	1
1,1-Dichloropropene	ND		ug/kg	0.55	0.17	1
Bromoform	ND		ug/kg	4.4	0.27	1
1,1,2,2-Tetrachloroethane	ND		ug/kg	0.55	0.18	1
Benzene	ND		ug/kg	0.55	0.18	1
Toluene	ND		ug/kg	1.1	0.59	1
Ethylbenzene	ND		ug/kg	1.1	0.15	1
Chloromethane	ND		ug/kg	4.4	1.0	1
Bromomethane	ND		ug/kg	2.2	0.63	1
Vinyl chloride	ND		ug/kg	1.1	0.36	1
Chloroethane	ND		ug/kg	2.2	0.49	1
1,1-Dichloroethene	ND		ug/kg	1.1	0.26	1
trans-1,2-Dichloroethene	ND		ug/kg	1.6	0.15	1

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-03 Date Collected: 06/05/23 11:20

Client ID: SB-21G (12-12.5) Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Trichloroethene	ND		ug/kg	0.55	0.15	1
1,2-Dichlorobenzene	ND		ug/kg	2.2	0.16	1
1,3-Dichlorobenzene	ND		ug/kg	2.2	0.16	1
1,4-Dichlorobenzene	ND		ug/kg	2.2	0.19	1
Methyl tert butyl ether	ND		ug/kg	2.2	0.22	1
p/m-Xylene	ND		ug/kg	2.2	0.61	1
o-Xylene	ND		ug/kg	1.1	0.32	1
Xylenes, Total	ND		ug/kg	1.1	0.32	1
cis-1,2-Dichloroethene	ND		ug/kg	1.1	0.19	1
1,2-Dichloroethene, Total	ND		ug/kg	1.1	0.15	1
Dibromomethane	ND		ug/kg	2.2	0.26	1
Styrene	ND		ug/kg	1.1	0.21	1
Dichlorodifluoromethane	ND		ug/kg	11	1.0	1
Acetone	9.0	J	ug/kg	11	5.2	1
Carbon disulfide	ND		ug/kg	11	5.0	1
2-Butanone	4.6	J	ug/kg	11	2.4	1
Vinyl acetate	ND		ug/kg	11	2.3	1
4-Methyl-2-pentanone	ND		ug/kg	11	1.4	1
1,2,3-Trichloropropane	ND		ug/kg	2.2	0.14	1
2-Hexanone	ND		ug/kg	11	1.3	1
Bromochloromethane	ND		ug/kg	2.2	0.22	1
2,2-Dichloropropane	ND		ug/kg	2.2	0.22	1
1,2-Dibromoethane	ND		ug/kg	1.1	0.30	1
1,3-Dichloropropane	ND		ug/kg	2.2	0.18	1
1,1,1,2-Tetrachloroethane	ND		ug/kg	0.55	0.14	1
Bromobenzene	ND		ug/kg	2.2	0.16	1
n-Butylbenzene	ND		ug/kg	1.1	0.18	1
sec-Butylbenzene	ND		ug/kg	1.1	0.16	1
tert-Butylbenzene	ND		ug/kg	2.2	0.13	1
o-Chlorotoluene	ND		ug/kg	2.2	0.21	1
p-Chlorotoluene	ND		ug/kg	2.2	0.12	1
1,2-Dibromo-3-chloropropane	ND		ug/kg	3.3	1.1	1
Hexachlorobutadiene	ND		ug/kg	4.4	0.18	1
Isopropylbenzene	ND		ug/kg	1.1	0.12	1
p-Isopropyltoluene	0.56	J	ug/kg	1.1	0.12	1
Naphthalene	ND		ug/kg	4.4	0.71	1
Acrylonitrile	ND		ug/kg	4.4	1.2	1

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-03 Date Collected: 06/05/23 11:20

Client ID: SB-21G (12-12.5) Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
n-Propylbenzene	ND		ug/kg	1.1	0.19	1
1,2,3-Trichlorobenzene	ND		ug/kg	2.2	0.35	1
1,2,4-Trichlorobenzene	ND		ug/kg	2.2	0.30	1
1,3,5-Trimethylbenzene	ND		ug/kg	2.2	0.21	1
1,2,4-Trimethylbenzene	ND		ug/kg	2.2	0.36	1
1,4-Dioxane	ND		ug/kg	87	38.	1
p-Diethylbenzene	ND		ug/kg	2.2	0.19	1
p-Ethyltoluene	ND		ug/kg	2.2	0.42	1
1,2,4,5-Tetramethylbenzene	ND		ug/kg	2.2	0.21	1
Ethyl ether	ND		ug/kg	2.2	0.37	1
trans-1,4-Dichloro-2-butene	ND		ug/kg	5.5	1.6	1
Tentatively Identified Compounds						
Total TIC Compounds	10.9	J	ug/kg			1
Cyclotrisiloxane, Hexamethyl-	6.67	NJ	ug/kg			1
Unknown	4.20	J	ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	99		70-130
Toluene-d8	105		70-130
4-Bromofluorobenzene	107		70-130
Dibromofluoromethane	93		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-04
Client ID: SB-22G (7-7.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 12:15
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8260D
Analytical Date: 06/08/23 11:30
Analyst: AJK
Percent Solids: 80%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Methylene chloride	ND		ug/kg	6.7	3.0	1
1,1-Dichloroethane	ND		ug/kg	1.3	0.19	1
Chloroform	ND		ug/kg	2.0	0.19	1
Carbon tetrachloride	ND		ug/kg	1.3	0.31	1
1,2-Dichloropropane	ND		ug/kg	1.3	0.17	1
Dibromochloromethane	ND		ug/kg	1.3	0.19	1
1,1,2-Trichloroethane	ND		ug/kg	1.3	0.36	1
Tetrachloroethene	ND		ug/kg	0.67	0.26	1
Chlorobenzene	ND		ug/kg	0.67	0.17	1
Trichlorofluoromethane	ND		ug/kg	5.3	0.93	1
1,2-Dichloroethane	ND		ug/kg	1.3	0.34	1
1,1,1-Trichloroethane	ND		ug/kg	0.67	0.22	1
Bromodichloromethane	ND		ug/kg	0.67	0.14	1
trans-1,3-Dichloropropene	ND		ug/kg	1.3	0.36	1
cis-1,3-Dichloropropene	ND		ug/kg	0.67	0.21	1
1,3-Dichloropropene, Total	ND		ug/kg	0.67	0.21	1
1,1-Dichloropropene	ND		ug/kg	0.67	0.21	1
Bromoform	ND		ug/kg	5.3	0.33	1
1,1,2,2-Tetrachloroethane	ND		ug/kg	0.67	0.22	1
Benzene	ND		ug/kg	0.67	0.22	1
Toluene	ND		ug/kg	1.3	0.72	1
Ethylbenzene	ND		ug/kg	1.3	0.19	1
Chloromethane	ND		ug/kg	5.3	1.2	1
Bromomethane	ND		ug/kg	2.7	0.77	1
Vinyl chloride	ND		ug/kg	1.3	0.45	1
Chloroethane	ND		ug/kg	2.7	0.60	1
1,1-Dichloroethene	ND		ug/kg	1.3	0.32	1
trans-1,2-Dichloroethene	ND		ug/kg	2.0	0.18	1

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-04 Date Collected: 06/05/23 12:15

Client ID: SB-22G (7-7.5) Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Trichloroethene	ND		ug/kg	0.67	0.18	1
1,2-Dichlorobenzene	ND		ug/kg	2.7	0.19	1
1,3-Dichlorobenzene	ND		ug/kg	2.7	0.20	1
1,4-Dichlorobenzene	ND		ug/kg	2.7	0.23	1
Methyl tert butyl ether	ND		ug/kg	2.7	0.27	1
p/m-Xylene	ND		ug/kg	2.7	0.75	1
o-Xylene	ND		ug/kg	1.3	0.39	1
Xylenes, Total	ND		ug/kg	1.3	0.39	1
cis-1,2-Dichloroethene	ND		ug/kg	1.3	0.23	1
1,2-Dichloroethene, Total	ND		ug/kg	1.3	0.18	1
Dibromomethane	ND		ug/kg	2.7	0.32	1
Styrene	13		ug/kg	1.3	0.26	1
Dichlorodifluoromethane	ND		ug/kg	13	1.2	1
Acetone	19		ug/kg	13	6.4	1
Carbon disulfide	ND		ug/kg	13	6.1	1
2-Butanone	8.0	J	ug/kg	13	3.0	1
Vinyl acetate	ND		ug/kg	13	2.9	1
4-Methyl-2-pentanone	ND		ug/kg	13	1.7	1
1,2,3-Trichloropropane	ND		ug/kg	2.7	0.17	1
2-Hexanone	ND		ug/kg	13	1.6	1
Bromochloromethane	ND		ug/kg	2.7	0.27	1
2,2-Dichloropropane	ND		ug/kg	2.7	0.27	1
1,2-Dibromoethane	ND		ug/kg	1.3	0.37	1
1,3-Dichloropropane	ND		ug/kg	2.7	0.22	1
1,1,1,2-Tetrachloroethane	ND		ug/kg	0.67	0.18	1
Bromobenzene	ND		ug/kg	2.7	0.19	1
n-Butylbenzene	ND		ug/kg	1.3	0.22	1
sec-Butylbenzene	ND		ug/kg	1.3	0.19	1
tert-Butylbenzene	ND		ug/kg	2.7	0.16	1
o-Chlorotoluene	ND		ug/kg	2.7	0.25	1
p-Chlorotoluene	ND		ug/kg	2.7	0.14	1
1,2-Dibromo-3-chloropropane	ND		ug/kg	4.0	1.3	1
Hexachlorobutadiene	ND		ug/kg	5.3	0.22	1
Isopropylbenzene	ND		ug/kg	1.3	0.14	1
p-Isopropyltoluene	ND		ug/kg	1.3	0.14	1
Naphthalene	ND		ug/kg	5.3	0.87	1
Acrylonitrile	ND		ug/kg	5.3	1.5	1

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-04 Date Collected: 06/05/23 12:15

Client ID: SB-22G (7-7.5) Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
n-Propylbenzene	ND		ug/kg	1.3	0.23	1
1,2,3-Trichlorobenzene	ND		ug/kg	2.7	0.43	1
1,2,4-Trichlorobenzene	ND		ug/kg	2.7	0.36	1
1,3,5-Trimethylbenzene	ND		ug/kg	2.7	0.26	1
1,2,4-Trimethylbenzene	ND		ug/kg	2.7	0.44	1
1,4-Dioxane	ND		ug/kg	110	47.	1
p-Diethylbenzene	ND		ug/kg	2.7	0.24	1
p-Ethyltoluene	ND		ug/kg	2.7	0.51	1
1,2,4,5-Tetramethylbenzene	0.64	J	ug/kg	2.7	0.25	1
Ethyl ether	ND		ug/kg	2.7	0.45	1
trans-1,4-Dichloro-2-butene	ND		ug/kg	6.7	1.9	1

Tentatively Identified Compounds						
Total TIC Compounds	73.6	J	ug/kg			1
Cyclotrisiloxane, Hexamethyl-	7.82	NJ	ug/kg			1
Unknown Alkane	5.44	J	ug/kg			1
Unknown Aromatic	6.68	J	ug/kg			1
Unknown	5.69	J	ug/kg			1
Unknown	7.92	J	ug/kg			1
Unknown Naphthalene	7.04	J	ug/kg			1
Unknown Aromatic	5.91	J	ug/kg			1
Unknown	5.67	J	ug/kg			1
Unknown Alkane	9.90	J	ug/kg			1
Unknown Alkane	11.5	J	ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	101		70-130
Toluene-d8	103		70-130
4-Bromofluorobenzene	109		70-130
Dibromofluoromethane	95		70-130

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-05
Client ID: SB-23G (9.5-10)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 12:50
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8260D
Analytical Date: 06/08/23 01:46
Analyst: MKS
Percent Solids: 87%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Methylene chloride	ND		ug/kg	5.7	2.6	1
1,1-Dichloroethane	ND		ug/kg	1.1	0.17	1
Chloroform	ND		ug/kg	1.7	0.16	1
Carbon tetrachloride	ND		ug/kg	1.1	0.26	1
1,2-Dichloropropane	ND		ug/kg	1.1	0.14	1
Dibromochloromethane	ND		ug/kg	1.1	0.16	1
1,1,2-Trichloroethane	ND		ug/kg	1.1	0.31	1
Tetrachloroethene	ND		ug/kg	0.57	0.22	1
Chlorobenzene	ND		ug/kg	0.57	0.14	1
Trichlorofluoromethane	ND		ug/kg	4.6	0.80	1
1,2-Dichloroethane	ND		ug/kg	1.1	0.29	1
1,1,1-Trichloroethane	ND		ug/kg	0.57	0.19	1
Bromodichloromethane	ND		ug/kg	0.57	0.12	1
trans-1,3-Dichloropropene	ND		ug/kg	1.1	0.31	1
cis-1,3-Dichloropropene	ND		ug/kg	0.57	0.18	1
1,3-Dichloropropene, Total	ND		ug/kg	0.57	0.18	1
1,1-Dichloropropene	ND		ug/kg	0.57	0.18	1
Bromoform	ND		ug/kg	4.6	0.28	1
1,1,2,2-Tetrachloroethane	ND		ug/kg	0.57	0.19	1
Benzene	ND		ug/kg	0.57	0.19	1
Toluene	ND		ug/kg	1.1	0.62	1
Ethylbenzene	ND		ug/kg	1.1	0.16	1
Chloromethane	ND		ug/kg	4.6	1.1	1
Bromomethane	ND		ug/kg	2.3	0.67	1
Vinyl chloride	ND		ug/kg	1.1	0.38	1
Chloroethane	ND		ug/kg	2.3	0.52	1
1,1-Dichloroethene	ND		ug/kg	1.1	0.27	1
trans-1,2-Dichloroethene	ND		ug/kg	1.7	0.16	1

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-05 Date Collected: 06/05/23 12:50

Client ID: SB-23G (9.5-10) Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Trichloroethene	ND		ug/kg	0.57	0.16	1
1,2-Dichlorobenzene	ND		ug/kg	2.3	0.16	1
1,3-Dichlorobenzene	ND		ug/kg	2.3	0.17	1
1,4-Dichlorobenzene	ND		ug/kg	2.3	0.20	1
Methyl tert butyl ether	ND		ug/kg	2.3	0.23	1
p/m-Xylene	ND		ug/kg	2.3	0.64	1
o-Xylene	ND		ug/kg	1.1	0.33	1
Xylenes, Total	ND		ug/kg	1.1	0.33	1
cis-1,2-Dichloroethene	ND		ug/kg	1.1	0.20	1
1,2-Dichloroethene, Total	ND		ug/kg	1.1	0.16	1
Dibromomethane	ND		ug/kg	2.3	0.27	1
Styrene	0.27	J	ug/kg	1.1	0.22	1
Dichlorodifluoromethane	ND		ug/kg	11	1.0	1
Acetone	6.6	J	ug/kg	11	5.5	1
Carbon disulfide	ND		ug/kg	11	5.2	1
2-Butanone	4.8	J	ug/kg	11	2.5	1
Vinyl acetate	ND		ug/kg	11	2.5	1
4-Methyl-2-pentanone	ND		ug/kg	11	1.5	1
1,2,3-Trichloropropane	ND		ug/kg	2.3	0.14	1
2-Hexanone	ND		ug/kg	11	1.4	1
Bromochloromethane	ND		ug/kg	2.3	0.24	1
2,2-Dichloropropane	ND		ug/kg	2.3	0.23	1
1,2-Dibromoethane	ND		ug/kg	1.1	0.32	1
1,3-Dichloropropane	ND		ug/kg	2.3	0.19	1
1,1,1,2-Tetrachloroethane	ND		ug/kg	0.57	0.15	1
Bromobenzene	ND		ug/kg	2.3	0.17	1
n-Butylbenzene	ND		ug/kg	1.1	0.19	1
sec-Butylbenzene	ND		ug/kg	1.1	0.17	1
tert-Butylbenzene	ND		ug/kg	2.3	0.14	1
o-Chlorotoluene	ND		ug/kg	2.3	0.22	1
p-Chlorotoluene	ND		ug/kg	2.3	0.12	1
1,2-Dibromo-3-chloropropane	ND		ug/kg	3.4	1.1	1
Hexachlorobutadiene	ND		ug/kg	4.6	0.19	1
Isopropylbenzene	ND		ug/kg	1.1	0.12	1
p-Isopropyltoluene	ND		ug/kg	1.1	0.12	1
Naphthalene	ND		ug/kg	4.6	0.75	1
Acrylonitrile	ND		ug/kg	4.6	1.3	1

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-05 Date Collected: 06/05/23 12:50

Client ID: SB-23G (9.5-10) Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
n-Propylbenzene	ND		ug/kg	1.1	0.20	1
1,2,3-Trichlorobenzene	ND		ug/kg	2.3	0.37	1
1,2,4-Trichlorobenzene	ND		ug/kg	2.3	0.31	1
1,3,5-Trimethylbenzene	ND		ug/kg	2.3	0.22	1
1,2,4-Trimethylbenzene	ND		ug/kg	2.3	0.38	1
1,4-Dioxane	ND		ug/kg	92	40.	1
p-Diethylbenzene	ND		ug/kg	2.3	0.20	1
p-Ethyltoluene	ND		ug/kg	2.3	0.44	1
1,2,4,5-Tetramethylbenzene	ND		ug/kg	2.3	0.22	1
Ethyl ether	ND		ug/kg	2.3	0.39	1
trans-1,4-Dichloro-2-butene	ND		ug/kg	5.7	1.6	1
Tentatively Identified Compounds						
Total TIC Compounds	21.9	J	ug/kg			1
Unknown	21.9	J	ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	**132**	Q	70-130
Toluene-d8	88		70-130
4-Bromofluorobenzene	86		70-130
Dibromofluoromethane	128		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-06
Client ID: SB-24G (7.5-8)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 12:30
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8260D
Analytical Date: 06/08/23 10:41
Analyst: AJK
Percent Solids: 85%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Methylene chloride	ND		ug/kg	5.6	2.5	1
1,1-Dichloroethane	ND		ug/kg	1.1	0.16	1
Chloroform	ND		ug/kg	1.7	0.16	1
Carbon tetrachloride	ND		ug/kg	1.1	0.26	1
1,2-Dichloropropane	ND		ug/kg	1.1	0.14	1
Dibromochloromethane	ND		ug/kg	1.1	0.16	1
1,1,2-Trichloroethane	ND		ug/kg	1.1	0.30	1
Tetrachloroethene	ND		ug/kg	0.56	0.22	1
Chlorobenzene	ND		ug/kg	0.56	0.14	1
Trichlorofluoromethane	ND		ug/kg	4.4	0.77	1
1,2-Dichloroethane	ND		ug/kg	1.1	0.29	1
1,1,1-Trichloroethane	ND		ug/kg	0.56	0.18	1
Bromodichloromethane	ND		ug/kg	0.56	0.12	1
trans-1,3-Dichloropropene	ND		ug/kg	1.1	0.30	1
cis-1,3-Dichloropropene	ND		ug/kg	0.56	0.18	1
1,3-Dichloropropene, Total	ND		ug/kg	0.56	0.18	1
1,1-Dichloropropene	ND		ug/kg	0.56	0.18	1
Bromoform	ND		ug/kg	4.4	0.27	1
1,1,2,2-Tetrachloroethane	ND		ug/kg	0.56	0.18	1
Benzene	ND		ug/kg	0.56	0.18	1
Toluene	ND		ug/kg	1.1	0.60	1
Ethylbenzene	ND		ug/kg	1.1	0.16	1
Chloromethane	ND		ug/kg	4.4	1.0	1
Bromomethane	ND		ug/kg	2.2	0.65	1
Vinyl chloride	ND		ug/kg	1.1	0.37	1
Chloroethane	ND		ug/kg	2.2	0.50	1
1,1-Dichloroethene	ND		ug/kg	1.1	0.26	1
trans-1,2-Dichloroethene	ND		ug/kg	1.7	0.15	1

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-06 Date Collected: 06/05/23 12:30

Client ID: SB-24G (7.5-8) Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Trichloroethene	ND		ug/kg	0.56	0.15	1
1,2-Dichlorobenzene	ND		ug/kg	2.2	0.16	1
1,3-Dichlorobenzene	ND		ug/kg	2.2	0.16	1
1,4-Dichlorobenzene	ND		ug/kg	2.2	0.19	1
Methyl tert butyl ether	ND		ug/kg	2.2	0.22	1
p/m-Xylene	ND		ug/kg	2.2	0.62	1
o-Xylene	ND		ug/kg	1.1	0.32	1
Xylenes, Total	ND		ug/kg	1.1	0.32	1
cis-1,2-Dichloroethene	ND		ug/kg	1.1	0.19	1
1,2-Dichloroethene, Total	ND		ug/kg	1.1	0.15	1
Dibromomethane	ND		ug/kg	2.2	0.26	1
Styrene	ND		ug/kg	1.1	0.22	1
Dichlorodifluoromethane	ND		ug/kg	11	1.0	1
Acetone	ND		ug/kg	11	5.4	1
Carbon disulfide	ND		ug/kg	11	5.1	1
2-Butanone	ND		ug/kg	11	2.5	1
Vinyl acetate	ND		ug/kg	11	2.4	1
4-Methyl-2-pentanone	ND		ug/kg	11	1.4	1
1,2,3-Trichloropropane	ND		ug/kg	2.2	0.14	1
2-Hexanone	ND		ug/kg	11	1.3	1
Bromochloromethane	ND		ug/kg	2.2	0.23	1
2,2-Dichloropropane	ND		ug/kg	2.2	0.22	1
1,2-Dibromoethane	ND		ug/kg	1.1	0.31	1
1,3-Dichloropropane	ND		ug/kg	2.2	0.18	1
1,1,1,2-Tetrachloroethane	ND		ug/kg	0.56	0.15	1
Bromobenzene	ND		ug/kg	2.2	0.16	1
n-Butylbenzene	ND		ug/kg	1.1	0.18	1
sec-Butylbenzene	ND		ug/kg	1.1	0.16	1
tert-Butylbenzene	ND		ug/kg	2.2	0.13	1
o-Chlorotoluene	ND		ug/kg	2.2	0.21	1
p-Chlorotoluene	ND		ug/kg	2.2	0.12	1
1,2-Dibromo-3-chloropropane	ND		ug/kg	3.3	1.1	1
Hexachlorobutadiene	ND		ug/kg	4.4	0.19	1
Isopropylbenzene	ND		ug/kg	1.1	0.12	1
p-Isopropyltoluene	ND		ug/kg	1.1	0.12	1
Naphthalene	ND		ug/kg	4.4	0.72	1
Acrylonitrile	ND		ug/kg	4.4	1.3	1

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-06 Date Collected: 06/05/23 12:30

Client ID: SB-24G (7.5-8) Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
n-Propylbenzene	ND		ug/kg	1.1	0.19	1
1,2,3-Trichlorobenzene	ND		ug/kg	2.2	0.36	1
1,2,4-Trichlorobenzene	ND		ug/kg	2.2	0.30	1
1,3,5-Trimethylbenzene	ND		ug/kg	2.2	0.21	1
1,2,4-Trimethylbenzene	ND		ug/kg	2.2	0.37	1
1,4-Dioxane	ND		ug/kg	89	39.	1
p-Diethylbenzene	ND		ug/kg	2.2	0.20	1
p-Ethyltoluene	ND		ug/kg	2.2	0.43	1
1,2,4,5-Tetramethylbenzene	ND		ug/kg	2.2	0.21	1
Ethyl ether	ND		ug/kg	2.2	0.38	1
trans-1,4-Dichloro-2-butene	ND		ug/kg	5.6	1.6	1
Tentatively Identified Compounds						
No Tentatively Identified Compounds	ND		ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	101		70-130
Toluene-d8	100		70-130
4-Bromofluorobenzene	104		70-130
Dibromofluoromethane	104		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-07
Client ID: SB-25G (9.5-10)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 10:40
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8260D
Analytical Date: 06/08/23 12:09
Analyst: AJK
Percent Solids: 92%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Methylene chloride	ND		ug/kg	5.5	2.5	1
1,1-Dichloroethane	ND		ug/kg	1.1	0.16	1
Chloroform	ND		ug/kg	1.6	0.15	1
Carbon tetrachloride	ND		ug/kg	1.1	0.25	1
1,2-Dichloropropane	ND		ug/kg	1.1	0.14	1
Dibromochloromethane	ND		ug/kg	1.1	0.15	1
1,1,2-Trichloroethane	ND		ug/kg	1.1	0.29	1
Tetrachloroethene	ND		ug/kg	0.55	0.22	1
Chlorobenzene	ND		ug/kg	0.55	0.14	1
Trichlorofluoromethane	ND		ug/kg	4.4	0.76	1
1,2-Dichloroethane	ND		ug/kg	1.1	0.28	1
1,1,1-Trichloroethane	ND		ug/kg	0.55	0.18	1
Bromodichloromethane	ND		ug/kg	0.55	0.12	1
trans-1,3-Dichloropropene	ND		ug/kg	1.1	0.30	1
cis-1,3-Dichloropropene	ND		ug/kg	0.55	0.17	1
1,3-Dichloropropene, Total	ND		ug/kg	0.55	0.17	1
1,1-Dichloropropene	ND		ug/kg	0.55	0.18	1
Bromoform	ND		ug/kg	4.4	0.27	1
1,1,2,2-Tetrachloroethane	ND		ug/kg	0.55	0.18	1
Benzene	ND		ug/kg	0.55	0.18	1
Toluene	ND		ug/kg	1.1	0.60	1
Ethylbenzene	ND		ug/kg	1.1	0.16	1
Chloromethane	ND		ug/kg	4.4	1.0	1
Bromomethane	ND		ug/kg	2.2	0.64	1
Vinyl chloride	ND		ug/kg	1.1	0.37	1
Chloroethane	ND		ug/kg	2.2	0.50	1
1,1-Dichloroethene	ND		ug/kg	1.1	0.26	1
trans-1,2-Dichloroethene	ND		ug/kg	1.6	0.15	1

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-07 Date Collected: 06/05/23 10:40

Client ID: SB-25G (9.5-10) Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Trichloroethene	ND		ug/kg	0.55	0.15	1
1,2-Dichlorobenzene	ND		ug/kg	2.2	0.16	1
1,3-Dichlorobenzene	ND		ug/kg	2.2	0.16	1
1,4-Dichlorobenzene	ND		ug/kg	2.2	0.19	1
Methyl tert butyl ether	ND		ug/kg	2.2	0.22	1
p/m-Xylene	ND		ug/kg	2.2	0.62	1
o-Xylene	ND		ug/kg	1.1	0.32	1
Xylenes, Total	ND		ug/kg	1.1	0.32	1
cis-1,2-Dichloroethene	ND		ug/kg	1.1	0.19	1
1,2-Dichloroethene, Total	ND		ug/kg	1.1	0.15	1
Dibromomethane	ND		ug/kg	2.2	0.26	1
Styrene	ND		ug/kg	1.1	0.22	1
Dichlorodifluoromethane	ND		ug/kg	11	1.0	1
Acetone	43		ug/kg	11	5.3	1
Carbon disulfide	ND		ug/kg	11	5.0	1
2-Butanone	13		ug/kg	11	2.4	1
Vinyl acetate	ND		ug/kg	11	2.4	1
4-Methyl-2-pentanone	ND		ug/kg	11	1.4	1
1,2,3-Trichloropropane	ND		ug/kg	2.2	0.14	1
2-Hexanone	ND		ug/kg	11	1.3	1
Bromochloromethane	ND		ug/kg	2.2	0.22	1
2,2-Dichloropropane	ND		ug/kg	2.2	0.22	1
1,2-Dibromoethane	ND		ug/kg	1.1	0.31	1
1,3-Dichloropropane	ND		ug/kg	2.2	0.18	1
1,1,1,2-Tetrachloroethane	ND		ug/kg	0.55	0.14	1
Bromobenzene	ND		ug/kg	2.2	0.16	1
n-Butylbenzene	ND		ug/kg	1.1	0.18	1
sec-Butylbenzene	ND		ug/kg	1.1	0.16	1
tert-Butylbenzene	ND		ug/kg	2.2	0.13	1
o-Chlorotoluene	ND		ug/kg	2.2	0.21	1
p-Chlorotoluene	ND		ug/kg	2.2	0.12	1
1,2-Dibromo-3-chloropropane	ND		ug/kg	3.3	1.1	1
Hexachlorobutadiene	ND		ug/kg	4.4	0.19	1
Isopropylbenzene	ND		ug/kg	1.1	0.12	1
p-Isopropyltoluene	ND		ug/kg	1.1	0.12	1
Naphthalene	ND		ug/kg	4.4	0.72	1
Acrylonitrile	ND		ug/kg	4.4	1.3	1

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-07 Date Collected: 06/05/23 10:40

Client ID: SB-25G (9.5-10) Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
n-Propylbenzene	ND		ug/kg	1.1	0.19	1
1,2,3-Trichlorobenzene	ND		ug/kg	2.2	0.35	1
1,2,4-Trichlorobenzene	ND		ug/kg	2.2	0.30	1
1,3,5-Trimethylbenzene	ND		ug/kg	2.2	0.21	1
1,2,4-Trimethylbenzene	ND		ug/kg	2.2	0.37	1
1,4-Dioxane	ND		ug/kg	88	39.	1
p-Diethylbenzene	ND		ug/kg	2.2	0.20	1
p-Ethyltoluene	ND		ug/kg	2.2	0.42	1
1,2,4,5-Tetramethylbenzene	ND		ug/kg	2.2	0.21	1
Ethyl ether	ND		ug/kg	2.2	0.38	1
trans-1,4-Dichloro-2-butene	ND		ug/kg	5.5	1.6	1

Tentatively Identified Compounds				
Total TIC Compounds	8.84	J	ug/kg	1
Cyclotrisiloxane, Hexamethyl-	6.02	NJ	ug/kg	1
Unknown	2.82	J	ug/kg	1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	100		70-130
Toluene-d8	105		70-130
4-Bromofluorobenzene	111		70-130
Dibromofluoromethane	94		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-08 Date Collected: 06/05/23 12:00
Client ID: GW-10 Date Received: 06/05/23
Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8260D
Analytical Date: 06/07/23 23:47
Analyst: MJV

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Methylene chloride	ND		ug/l	2.5	0.70	1
1,1-Dichloroethane	ND		ug/l	2.5	0.70	1
Chloroform	ND		ug/l	2.5	0.70	1
Carbon tetrachloride	ND		ug/l	0.50	0.13	1
1,2-Dichloropropane	ND		ug/l	1.0	0.14	1
Dibromochloromethane	ND		ug/l	0.50	0.15	1
1,1,2-Trichloroethane	ND		ug/l	1.5	0.50	1
Tetrachloroethene	ND		ug/l	0.50	0.18	1
Chlorobenzene	ND		ug/l	2.5	0.70	1
Trichlorofluoromethane	ND		ug/l	2.5	0.70	1
1,2-Dichloroethane	ND		ug/l	0.50	0.13	1
1,1,1-Trichloroethane	ND		ug/l	2.5	0.70	1
Bromodichloromethane	ND		ug/l	0.50	0.19	1
trans-1,3-Dichloropropene	ND		ug/l	0.50	0.16	1
cis-1,3-Dichloropropene	ND		ug/l	0.50	0.14	1
1,3-Dichloropropene, Total	ND		ug/l	0.50	0.14	1
1,1-Dichloropropene	ND		ug/l	2.5	0.70	1
Bromoform	ND		ug/l	2.0	0.65	1
1,1,2,2-Tetrachloroethane	ND		ug/l	0.50	0.17	1
Benzene	ND		ug/l	0.50	0.16	1
Toluene	ND		ug/l	2.5	0.70	1
Ethylbenzene	ND		ug/l	2.5	0.70	1
Chloromethane	ND		ug/l	2.5	0.70	1
Bromomethane	ND		ug/l	2.5	0.70	1
Vinyl chloride	ND		ug/l	1.0	0.07	1
Chloroethane	ND		ug/l	2.5	0.70	1
1,1-Dichloroethene	ND		ug/l	0.50	0.17	1
trans-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-08 Date Collected: 06/05/23 12:00

Client ID: GW-10 Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Trichloroethene	ND		ug/l	0.50	0.18	1
1,2-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,3-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,4-Dichlorobenzene	ND		ug/l	2.5	0.70	1
Methyl tert butyl ether	ND		ug/l	2.5	0.70	1
p/m-Xylene	ND		ug/l	2.5	0.70	1
o-Xylene	ND		ug/l	2.5	0.70	1
Xylenes, Total	ND		ug/l	2.5	0.70	1
cis-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1
1,2-Dichloroethene, Total	ND		ug/l	2.5	0.70	1
Dibromomethane	ND		ug/l	5.0	1.0	1
1,2,3-Trichloropropane	ND		ug/l	2.5	0.70	1
Acrylonitrile	ND		ug/l	5.0	1.5	1
Styrene	ND		ug/l	2.5	0.70	1
Dichlorodifluoromethane	ND		ug/l	5.0	1.0	1
Acetone	2.2	J	ug/l	5.0	1.5	1
Carbon disulfide	ND		ug/l	5.0	1.0	1
2-Butanone	ND		ug/l	5.0	1.9	1
Vinyl acetate	ND		ug/l	5.0	1.0	1
4-Methyl-2-pentanone	ND		ug/l	5.0	1.0	1
2-Hexanone	ND		ug/l	5.0	1.0	1
Bromochloromethane	ND		ug/l	2.5	0.70	1
2,2-Dichloropropane	ND		ug/l	2.5	0.70	1
1,2-Dibromoethane	ND		ug/l	2.0	0.65	1
1,3-Dichloropropane	ND		ug/l	2.5	0.70	1
1,1,1,2-Tetrachloroethane	ND		ug/l	2.5	0.70	1
Bromobenzene	ND		ug/l	2.5	0.70	1
n-Butylbenzene	ND		ug/l	2.5	0.70	1
sec-Butylbenzene	ND		ug/l	2.5	0.70	1
tert-Butylbenzene	ND		ug/l	2.5	0.70	1
o-Chlorotoluene	ND		ug/l	2.5	0.70	1
p-Chlorotoluene	ND		ug/l	2.5	0.70	1
1,2-Dibromo-3-chloropropane	ND		ug/l	2.5	0.70	1
Hexachlorobutadiene	ND		ug/l	2.5	0.70	1
Isopropylbenzene	ND		ug/l	2.5	0.70	1
p-Isopropyltoluene	ND		ug/l	2.5	0.70	1
Naphthalene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-08 Date Collected: 06/05/23 12:00

Client ID: GW-10 Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
n-Propylbenzene	ND		ug/l	2.5	0.70	1
1,2,3-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,3,5-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,4-Dioxane	ND		ug/l	250	61.	1
p-Diethylbenzene	ND		ug/l	2.0	0.70	1
p-Ethyltoluene	ND		ug/l	2.0	0.70	1
1,2,4,5-Tetramethylbenzene	ND		ug/l	2.0	0.54	1
Ethyl ether	ND		ug/l	2.5	0.70	1
trans-1,4-Dichloro-2-butene	ND		ug/l	2.5	0.70	1
Tentatively Identified Compounds						
No Tentatively Identified Compounds	ND		ug/l			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	121		70-130
Toluene-d8	98		70-130
4-Bromofluorobenzene	97		70-130
Dibromofluoromethane	109		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-09
Client ID: GW-11
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 13:20
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8260D
Analytical Date: 06/08/23 00:09
Analyst: MJV

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Methylene chloride	ND		ug/l	2.5	0.70	1
1,1-Dichloroethane	ND		ug/l	2.5	0.70	1
Chloroform	ND		ug/l	2.5	0.70	1
Carbon tetrachloride	ND		ug/l	0.50	0.13	1
1,2-Dichloropropane	ND		ug/l	1.0	0.14	1
Dibromochloromethane	ND		ug/l	0.50	0.15	1
1,1,2-Trichloroethane	ND		ug/l	1.5	0.50	1
Tetrachloroethene	ND		ug/l	0.50	0.18	1
Chlorobenzene	ND		ug/l	2.5	0.70	1
Trichlorofluoromethane	ND		ug/l	2.5	0.70	1
1,2-Dichloroethane	ND		ug/l	0.50	0.13	1
1,1,1-Trichloroethane	ND		ug/l	2.5	0.70	1
Bromodichloromethane	ND		ug/l	0.50	0.19	1
trans-1,3-Dichloropropene	ND		ug/l	0.50	0.16	1
cis-1,3-Dichloropropene	ND		ug/l	0.50	0.14	1
1,3-Dichloropropene, Total	ND		ug/l	0.50	0.14	1
1,1-Dichloropropene	ND		ug/l	2.5	0.70	1
Bromoform	ND		ug/l	2.0	0.65	1
1,1,2,2-Tetrachloroethane	ND		ug/l	0.50	0.17	1
Benzene	ND		ug/l	0.50	0.16	1
Toluene	ND		ug/l	2.5	0.70	1
Ethylbenzene	ND		ug/l	2.5	0.70	1
Chloromethane	ND		ug/l	2.5	0.70	1
Bromomethane	ND		ug/l	2.5	0.70	1
Vinyl chloride	ND		ug/l	1.0	0.07	1
Chloroethane	ND		ug/l	2.5	0.70	1
1,1-Dichloroethene	ND		ug/l	0.50	0.17	1
trans-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-09 Date Collected: 06/05/23 13:20

Client ID: GW-11 Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Trichloroethene	ND		ug/l	0.50	0.18	1
1,2-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,3-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,4-Dichlorobenzene	ND		ug/l	2.5	0.70	1
Methyl tert butyl ether	ND		ug/l	2.5	0.70	1
p/m-Xylene	ND		ug/l	2.5	0.70	1
o-Xylene	ND		ug/l	2.5	0.70	1
Xylenes, Total	ND		ug/l	2.5	0.70	1
cis-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1
1,2-Dichloroethene, Total	ND		ug/l	2.5	0.70	1
Dibromomethane	ND		ug/l	5.0	1.0	1
1,2,3-Trichloropropane	ND		ug/l	2.5	0.70	1
Acrylonitrile	ND		ug/l	5.0	1.5	1
Styrene	ND		ug/l	2.5	0.70	1
Dichlorodifluoromethane	ND		ug/l	5.0	1.0	1
Acetone	ND		ug/l	5.0	1.5	1
Carbon disulfide	ND		ug/l	5.0	1.0	1
2-Butanone	ND		ug/l	5.0	1.9	1
Vinyl acetate	ND		ug/l	5.0	1.0	1
4-Methyl-2-pentanone	ND		ug/l	5.0	1.0	1
2-Hexanone	ND		ug/l	5.0	1.0	1
Bromochloromethane	ND		ug/l	2.5	0.70	1
2,2-Dichloropropane	ND		ug/l	2.5	0.70	1
1,2-Dibromoethane	ND		ug/l	2.0	0.65	1
1,3-Dichloropropane	ND		ug/l	2.5	0.70	1
1,1,1,2-Tetrachloroethane	ND		ug/l	2.5	0.70	1
Bromobenzene	ND		ug/l	2.5	0.70	1
n-Butylbenzene	ND		ug/l	2.5	0.70	1
sec-Butylbenzene	ND		ug/l	2.5	0.70	1
tert-Butylbenzene	ND		ug/l	2.5	0.70	1
o-Chlorotoluene	ND		ug/l	2.5	0.70	1
p-Chlorotoluene	ND		ug/l	2.5	0.70	1
1,2-Dibromo-3-chloropropane	ND		ug/l	2.5	0.70	1
Hexachlorobutadiene	ND		ug/l	2.5	0.70	1
Isopropylbenzene	ND		ug/l	2.5	0.70	1
p-Isopropyltoluene	ND		ug/l	2.5	0.70	1
Naphthalene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-09 Date Collected: 06/05/23 13:20

Client ID: GW-11 Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
n-Propylbenzene	ND		ug/l	2.5	0.70	1
1,2,3-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,3,5-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,4-Dioxane	ND		ug/l	250	61.	1
p-Diethylbenzene	ND		ug/l	2.0	0.70	1
p-Ethyltoluene	ND		ug/l	2.0	0.70	1
1,2,4,5-Tetramethylbenzene	ND		ug/l	2.0	0.54	1
Ethyl ether	ND		ug/l	2.5	0.70	1
trans-1,4-Dichloro-2-butene	ND		ug/l	2.5	0.70	1
Tentatively Identified Compounds						
No Tentatively Identified Compounds	ND		ug/l			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	112		70-130
Toluene-d8	99		70-130
4-Bromofluorobenzene	97		70-130
Dibromofluoromethane	94		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 06/07/23 19:06
Analyst: TMS

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by GC/MS - Westborough Lab for sample(s): 08-09 Batch: WG1788648-5					
Methylene chloride	ND		ug/l	2.5	0.70
1,1-Dichloroethane	ND		ug/l	2.5	0.70
Chloroform	ND		ug/l	2.5	0.70
Carbon tetrachloride	ND		ug/l	0.50	0.13
1,2-Dichloropropane	ND		ug/l	1.0	0.14
Dibromochloromethane	ND		ug/l	0.50	0.15
1,1,2-Trichloroethane	ND		ug/l	1.5	0.50
Tetrachloroethene	ND		ug/l	0.50	0.18
Chlorobenzene	ND		ug/l	2.5	0.70
Trichlorofluoromethane	ND		ug/l	2.5	0.70
1,2-Dichloroethane	ND		ug/l	0.50	0.13
1,1,1-Trichloroethane	ND		ug/l	2.5	0.70
Bromodichloromethane	ND		ug/l	0.50	0.19
trans-1,3-Dichloropropene	ND		ug/l	0.50	0.16
cis-1,3-Dichloropropene	ND		ug/l	0.50	0.14
1,3-Dichloropropene, Total	ND		ug/l	0.50	0.14
1,1-Dichloropropene	ND		ug/l	2.5	0.70
Bromoform	ND		ug/l	2.0	0.65
1,1,2,2-Tetrachloroethane	ND		ug/l	0.50	0.17
Benzene	ND		ug/l	0.50	0.16
Toluene	ND		ug/l	2.5	0.70
Ethylbenzene	ND		ug/l	2.5	0.70
Chloromethane	ND		ug/l	2.5	0.70
Bromomethane	ND		ug/l	2.5	0.70
Vinyl chloride	ND		ug/l	1.0	0.07
Chloroethane	ND		ug/l	2.5	0.70
1,1-Dichloroethene	ND		ug/l	0.50	0.17
trans-1,2-Dichloroethene	ND		ug/l	2.5	0.70
Trichloroethene	ND		ug/l	0.50	0.18

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 06/07/23 19:06
Analyst: TMS

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by GC/MS - Westborough Lab for sample(s): 08-09 Batch: WG1788648-5					
1,2-Dichlorobenzene	ND		ug/l	2.5	0.70
1,3-Dichlorobenzene	ND		ug/l	2.5	0.70
1,4-Dichlorobenzene	ND		ug/l	2.5	0.70
Methyl tert butyl ether	ND		ug/l	2.5	0.70
p/m-Xylene	ND		ug/l	2.5	0.70
o-Xylene	ND		ug/l	2.5	0.70
Xylenes, Total	ND		ug/l	2.5	0.70
cis-1,2-Dichloroethene	ND		ug/l	2.5	0.70
1,2-Dichloroethene, Total	ND		ug/l	2.5	0.70
Dibromomethane	ND		ug/l	5.0	1.0
1,2,3-Trichloropropane	ND		ug/l	2.5	0.70
Acrylonitrile	ND		ug/l	5.0	1.5
Styrene	ND		ug/l	2.5	0.70
Dichlorodifluoromethane	ND		ug/l	5.0	1.0
Acetone	ND		ug/l	5.0	1.5
Carbon disulfide	ND		ug/l	5.0	1.0
2-Butanone	ND		ug/l	5.0	1.9
Vinyl acetate	ND		ug/l	5.0	1.0
4-Methyl-2-pentanone	ND		ug/l	5.0	1.0
2-Hexanone	ND		ug/l	5.0	1.0
Bromochloromethane	ND		ug/l	2.5	0.70
2,2-Dichloropropane	ND		ug/l	2.5	0.70
1,2-Dibromoethane	ND		ug/l	2.0	0.65
1,3-Dichloropropane	ND		ug/l	2.5	0.70
1,1,1,2-Tetrachloroethane	ND		ug/l	2.5	0.70
Bromobenzene	ND		ug/l	2.5	0.70
n-Butylbenzene	ND		ug/l	2.5	0.70
sec-Butylbenzene	ND		ug/l	2.5	0.70
tert-Butylbenzene	ND		ug/l	2.5	0.70

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 06/07/23 19:06
Analyst: TMS

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by GC/MS - Westborough Lab for sample(s): 08-09 Batch: WG1788648-5					
o-Chlorotoluene	ND		ug/l	2.5	0.70
p-Chlorotoluene	ND		ug/l	2.5	0.70
1,2-Dibromo-3-chloropropane	ND		ug/l	2.5	0.70
Hexachlorobutadiene	ND		ug/l	2.5	0.70
Isopropylbenzene	ND		ug/l	2.5	0.70
p-Isopropyltoluene	ND		ug/l	2.5	0.70
Naphthalene	ND		ug/l	2.5	0.70
n-Propylbenzene	ND		ug/l	2.5	0.70
1,2,3-Trichlorobenzene	ND		ug/l	2.5	0.70
1,2,4-Trichlorobenzene	ND		ug/l	2.5	0.70
1,3,5-Trimethylbenzene	ND		ug/l	2.5	0.70
1,2,4-Trimethylbenzene	ND		ug/l	2.5	0.70
1,4-Dioxane	ND		ug/l	250	61.
p-Diethylbenzene	ND		ug/l	2.0	0.70
p-Ethyltoluene	ND		ug/l	2.0	0.70
1,2,4,5-Tetramethylbenzene	ND		ug/l	2.0	0.54
Ethyl ether	ND		ug/l	2.5	0.70
trans-1,4-Dichloro-2-butene	ND		ug/l	2.5	0.70

Tentatively Identified Compounds

No Tentatively Identified Compounds ND ug/l

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 06/07/23 19:06
Analyst: TMS

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by GC/MS - Westborough Lab for sample(s): 08-09 Batch: WG1788648-5					

Surrogate	%Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	108		70-130
Toluene-d8	97		70-130
4-Bromofluorobenzene	99		70-130
Dibromofluoromethane	97		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 06/07/23 18:00
Analyst: MKS

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by EPA 5035 Low - Westborough Lab for sample(s): 01,05 Batch: WG1788684-5					
Methylene chloride	ND		ug/kg	5.0	2.3
1,1-Dichloroethane	ND		ug/kg	1.0	0.14
Chloroform	ND		ug/kg	1.5	0.14
Carbon tetrachloride	ND		ug/kg	1.0	0.23
1,2-Dichloropropane	ND		ug/kg	1.0	0.12
Dibromochloromethane	ND		ug/kg	1.0	0.14
1,1,2-Trichloroethane	ND		ug/kg	1.0	0.27
Tetrachloroethene	ND		ug/kg	0.50	0.20
Chlorobenzene	ND		ug/kg	0.50	0.13
Trichlorofluoromethane	ND		ug/kg	4.0	0.70
1,2-Dichloroethane	ND		ug/kg	1.0	0.26
1,1,1-Trichloroethane	ND		ug/kg	0.50	0.17
Bromodichloromethane	ND		ug/kg	0.50	0.11
trans-1,3-Dichloropropene	ND		ug/kg	1.0	0.27
cis-1,3-Dichloropropene	ND		ug/kg	0.50	0.16
1,3-Dichloropropene, Total	ND		ug/kg	0.50	0.16
1,1-Dichloropropene	ND		ug/kg	0.50	0.16
Bromoform	ND		ug/kg	4.0	0.25
1,1,2,2-Tetrachloroethane	ND		ug/kg	0.50	0.17
Benzene	ND		ug/kg	0.50	0.17
Toluene	ND		ug/kg	1.0	0.54
Ethylbenzene	ND		ug/kg	1.0	0.14
Chloromethane	ND		ug/kg	4.0	0.93
Bromomethane	3.7		ug/kg	2.0	0.58
Vinyl chloride	ND		ug/kg	1.0	0.34
Chloroethane	ND		ug/kg	2.0	0.45
1,1-Dichloroethene	ND		ug/kg	1.0	0.24
trans-1,2-Dichloroethene	ND		ug/kg	1.5	0.14
Trichloroethene	ND		ug/kg	0.50	0.14

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 06/07/23 18:00
Analyst: MKS

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by EPA 5035 Low - Westborough Lab for sample(s): 01,05 Batch: WG1788684-5					
1,2-Dichlorobenzene	ND		ug/kg	2.0	0.14
1,3-Dichlorobenzene	ND		ug/kg	2.0	0.15
1,4-Dichlorobenzene	ND		ug/kg	2.0	0.17
Methyl tert butyl ether	ND		ug/kg	2.0	0.20
p/m-Xylene	ND		ug/kg	2.0	0.56
o-Xylene	ND		ug/kg	1.0	0.29
Xylenes, Total	ND		ug/kg	1.0	0.29
cis-1,2-Dichloroethene	ND		ug/kg	1.0	0.18
1,2-Dichloroethene, Total	ND		ug/kg	1.0	0.14
Dibromomethane	ND		ug/kg	2.0	0.24
Styrene	ND		ug/kg	1.0	0.20
Dichlorodifluoromethane	ND		ug/kg	10	0.92
Acetone	ND		ug/kg	10	4.8
Carbon disulfide	ND		ug/kg	10	4.6
2-Butanone	ND		ug/kg	10	2.2
Vinyl acetate	ND		ug/kg	10	2.2
4-Methyl-2-pentanone	ND		ug/kg	10	1.3
1,2,3-Trichloropropane	ND		ug/kg	2.0	0.13
2-Hexanone	ND		ug/kg	10	1.2
Bromochloromethane	ND		ug/kg	2.0	0.20
2,2-Dichloropropane	ND		ug/kg	2.0	0.20
1,2-Dibromoethane	ND		ug/kg	1.0	0.28
1,3-Dichloropropane	ND		ug/kg	2.0	0.17
1,1,1,2-Tetrachloroethane	ND		ug/kg	0.50	0.13
Bromobenzene	ND		ug/kg	2.0	0.14
n-Butylbenzene	ND		ug/kg	1.0	0.17
sec-Butylbenzene	ND		ug/kg	1.0	0.15
tert-Butylbenzene	ND		ug/kg	2.0	0.12
o-Chlorotoluene	ND		ug/kg	2.0	0.19

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 06/07/23 18:00
Analyst: MKS

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by EPA 5035 Low - Westborough Lab for sample(s): 01,05 Batch: WG1788684-5					
p-Chlorotoluene	ND		ug/kg	2.0	0.11
1,2-Dibromo-3-chloropropane	ND		ug/kg	3.0	1.0
Hexachlorobutadiene	ND		ug/kg	4.0	0.17
Isopropylbenzene	ND		ug/kg	1.0	0.11
p-Isopropyltoluene	ND		ug/kg	1.0	0.11
Naphthalene	ND		ug/kg	4.0	0.65
Acrylonitrile	ND		ug/kg	4.0	1.2
n-Propylbenzene	ND		ug/kg	1.0	0.17
1,2,3-Trichlorobenzene	ND		ug/kg	2.0	0.32
1,2,4-Trichlorobenzene	ND		ug/kg	2.0	0.27
1,3,5-Trimethylbenzene	ND		ug/kg	2.0	0.19
1,2,4-Trimethylbenzene	ND		ug/kg	2.0	0.33
1,4-Dioxane	ND		ug/kg	80	35.
p-Diethylbenzene	ND		ug/kg	2.0	0.18
p-Ethyltoluene	ND		ug/kg	2.0	0.38
1,2,4,5-Tetramethylbenzene	ND		ug/kg	2.0	0.19
Ethyl ether	ND		ug/kg	2.0	0.34
trans-1,4-Dichloro-2-butene	ND		ug/kg	5.0	1.4

Tentatively Identified Compounds

Total TIC Compounds	61.2	J	ug/kg
Ethane, 1,1-Difluoro-	27.7	NJ	ug/kg
Unknown	11.3	J	ug/kg
Unknown	19.8	J	ug/kg
Unknown	2.37	J	ug/kg

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 06/07/23 18:00
Analyst: MKS

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by EPA 5035 Low - Westborough Lab for sample(s): 01,05 Batch: WG1788684-5					

Surrogate	%Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	125		70-130
Toluene-d8	86		70-130
4-Bromofluorobenzene	87		70-130
Dibromofluoromethane	122		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 06/08/23 09:23
Analyst: AJK

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by EPA 5035 Low - Westborough Lab for sample(s): 06 Batch: WG1788865-5					
Methylene chloride	ND		ug/kg	5.0	2.3
1,1-Dichloroethane	ND		ug/kg	1.0	0.14
Chloroform	ND		ug/kg	1.5	0.14
Carbon tetrachloride	ND		ug/kg	1.0	0.23
1,2-Dichloropropane	ND		ug/kg	1.0	0.12
Dibromochloromethane	ND		ug/kg	1.0	0.14
1,1,2-Trichloroethane	ND		ug/kg	1.0	0.27
Tetrachloroethene	ND		ug/kg	0.50	0.20
Chlorobenzene	ND		ug/kg	0.50	0.13
Trichlorofluoromethane	ND		ug/kg	4.0	0.70
1,2-Dichloroethane	ND		ug/kg	1.0	0.26
1,1,1-Trichloroethane	ND		ug/kg	0.50	0.17
Bromodichloromethane	ND		ug/kg	0.50	0.11
trans-1,3-Dichloropropene	ND		ug/kg	1.0	0.27
cis-1,3-Dichloropropene	ND		ug/kg	0.50	0.16
1,3-Dichloropropene, Total	ND		ug/kg	0.50	0.16
1,1-Dichloropropene	ND		ug/kg	0.50	0.16
Bromoform	ND		ug/kg	4.0	0.25
1,1,2,2-Tetrachloroethane	ND		ug/kg	0.50	0.17
Benzene	ND		ug/kg	0.50	0.17
Toluene	ND		ug/kg	1.0	0.54
Ethylbenzene	ND		ug/kg	1.0	0.14
Chloromethane	ND		ug/kg	4.0	0.93
Bromomethane	ND		ug/kg	2.0	0.58
Vinyl chloride	ND		ug/kg	1.0	0.34
Chloroethane	ND		ug/kg	2.0	0.45
1,1-Dichloroethene	ND		ug/kg	1.0	0.24
trans-1,2-Dichloroethene	ND		ug/kg	1.5	0.14
Trichloroethene	ND		ug/kg	0.50	0.14

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 06/08/23 09:23
Analyst: AJK

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by EPA 5035 Low - Westborough Lab for sample(s): 06 Batch: WG1788865-5					
1,2-Dichlorobenzene	ND		ug/kg	2.0	0.14
1,3-Dichlorobenzene	ND		ug/kg	2.0	0.15
1,4-Dichlorobenzene	ND		ug/kg	2.0	0.17
Methyl tert butyl ether	ND		ug/kg	2.0	0.20
p/m-Xylene	ND		ug/kg	2.0	0.56
o-Xylene	ND		ug/kg	1.0	0.29
Xylenes, Total	ND		ug/kg	1.0	0.29
cis-1,2-Dichloroethene	ND		ug/kg	1.0	0.18
1,2-Dichloroethene, Total	ND		ug/kg	1.0	0.14
Dibromomethane	ND		ug/kg	2.0	0.24
Styrene	ND		ug/kg	1.0	0.20
Dichlorodifluoromethane	ND		ug/kg	10	0.92
Acetone	ND		ug/kg	10	4.8
Carbon disulfide	ND		ug/kg	10	4.6
2-Butanone	ND		ug/kg	10	2.2
Vinyl acetate	ND		ug/kg	10	2.2
4-Methyl-2-pentanone	ND		ug/kg	10	1.3
1,2,3-Trichloropropane	ND		ug/kg	2.0	0.13
2-Hexanone	ND		ug/kg	10	1.2
Bromochloromethane	ND		ug/kg	2.0	0.20
2,2-Dichloropropane	ND		ug/kg	2.0	0.20
1,2-Dibromoethane	ND		ug/kg	1.0	0.28
1,3-Dichloropropane	ND		ug/kg	2.0	0.17
1,1,1,2-Tetrachloroethane	ND		ug/kg	0.50	0.13
Bromobenzene	ND		ug/kg	2.0	0.14
n-Butylbenzene	ND		ug/kg	1.0	0.17
sec-Butylbenzene	ND		ug/kg	1.0	0.15
tert-Butylbenzene	ND		ug/kg	2.0	0.12
o-Chlorotoluene	ND		ug/kg	2.0	0.19

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 06/08/23 09:23
Analyst: AJK

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by EPA 5035 Low - Westborough Lab for sample(s): 06 Batch: WG1788865-5					
p-Chlorotoluene	ND		ug/kg	2.0	0.11
1,2-Dibromo-3-chloropropane	ND		ug/kg	3.0	1.0
Hexachlorobutadiene	ND		ug/kg	4.0	0.17
Isopropylbenzene	ND		ug/kg	1.0	0.11
p-Isopropyltoluene	ND		ug/kg	1.0	0.11
Naphthalene	ND		ug/kg	4.0	0.65
Acrylonitrile	ND		ug/kg	4.0	1.2
n-Propylbenzene	ND		ug/kg	1.0	0.17
1,2,3-Trichlorobenzene	ND		ug/kg	2.0	0.32
1,2,4-Trichlorobenzene	ND		ug/kg	2.0	0.27
1,3,5-Trimethylbenzene	ND		ug/kg	2.0	0.19
1,2,4-Trimethylbenzene	ND		ug/kg	2.0	0.33
1,4-Dioxane	ND		ug/kg	80	35.
p-Diethylbenzene	ND		ug/kg	2.0	0.18
p-Ethyltoluene	ND		ug/kg	2.0	0.38
1,2,4,5-Tetramethylbenzene	ND		ug/kg	2.0	0.19
Ethyl ether	ND		ug/kg	2.0	0.34
trans-1,4-Dichloro-2-butene	ND		ug/kg	5.0	1.4

Tentatively Identified Compounds			
Total TIC Compounds	2.16	J	ug/kg
Unknown	2.16	J	ug/kg

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 06/08/23 09:23
Analyst: AJK

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by EPA 5035 Low - Westborough Lab for sample(s): 06 Batch: WG1788865-5					

Surrogate	%Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	103		70-130
Toluene-d8	100		70-130
4-Bromofluorobenzene	100		70-130
Dibromofluoromethane	103		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 06/08/23 10:12
Analyst: AJK

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by EPA 5035 Low - Westborough Lab for sample(s): 02-04,07 Batch: WG1789312-5					
Methylene chloride	ND		ug/kg	5.0	2.3
1,1-Dichloroethane	ND		ug/kg	1.0	0.14
Chloroform	ND		ug/kg	1.5	0.14
Carbon tetrachloride	ND		ug/kg	1.0	0.23
1,2-Dichloropropane	ND		ug/kg	1.0	0.12
Dibromochloromethane	ND		ug/kg	1.0	0.14
1,1,2-Trichloroethane	ND		ug/kg	1.0	0.27
Tetrachloroethene	ND		ug/kg	0.50	0.20
Chlorobenzene	ND		ug/kg	0.50	0.13
Trichlorofluoromethane	ND		ug/kg	4.0	0.70
1,2-Dichloroethane	ND		ug/kg	1.0	0.26
1,1,1-Trichloroethane	ND		ug/kg	0.50	0.17
Bromodichloromethane	ND		ug/kg	0.50	0.11
trans-1,3-Dichloropropene	ND		ug/kg	1.0	0.27
cis-1,3-Dichloropropene	ND		ug/kg	0.50	0.16
1,3-Dichloropropene, Total	ND		ug/kg	0.50	0.16
1,1-Dichloropropene	ND		ug/kg	0.50	0.16
Bromoform	ND		ug/kg	4.0	0.25
1,1,2,2-Tetrachloroethane	ND		ug/kg	0.50	0.17
Benzene	ND		ug/kg	0.50	0.17
Toluene	ND		ug/kg	1.0	0.54
Ethylbenzene	ND		ug/kg	1.0	0.14
Chloromethane	ND		ug/kg	4.0	0.93
Bromomethane	ND		ug/kg	2.0	0.58
Vinyl chloride	ND		ug/kg	1.0	0.34
Chloroethane	ND		ug/kg	2.0	0.45
1,1-Dichloroethene	ND		ug/kg	1.0	0.24
trans-1,2-Dichloroethene	ND		ug/kg	1.5	0.14
Trichloroethene	ND		ug/kg	0.50	0.14

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 06/08/23 10:12
Analyst: AJK

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by EPA 5035 Low - Westborough Lab for sample(s): 02-04,07 Batch: WG1789312-5					
1,2-Dichlorobenzene	ND		ug/kg	2.0	0.14
1,3-Dichlorobenzene	ND		ug/kg	2.0	0.15
1,4-Dichlorobenzene	ND		ug/kg	2.0	0.17
Methyl tert butyl ether	ND		ug/kg	2.0	0.20
p/m-Xylene	ND		ug/kg	2.0	0.56
o-Xylene	ND		ug/kg	1.0	0.29
Xylenes, Total	ND		ug/kg	1.0	0.29
cis-1,2-Dichloroethene	ND		ug/kg	1.0	0.18
1,2-Dichloroethene, Total	ND		ug/kg	1.0	0.14
Dibromomethane	ND		ug/kg	2.0	0.24
Styrene	ND		ug/kg	1.0	0.20
Dichlorodifluoromethane	ND		ug/kg	10	0.92
Acetone	ND		ug/kg	10	4.8
Carbon disulfide	ND		ug/kg	10	4.6
2-Butanone	ND		ug/kg	10	2.2
Vinyl acetate	ND		ug/kg	10	2.2
4-Methyl-2-pentanone	ND		ug/kg	10	1.3
1,2,3-Trichloropropane	ND		ug/kg	2.0	0.13
2-Hexanone	ND		ug/kg	10	1.2
Bromochloromethane	ND		ug/kg	2.0	0.20
2,2-Dichloropropane	ND		ug/kg	2.0	0.20
1,2-Dibromoethane	ND		ug/kg	1.0	0.28
1,3-Dichloropropane	ND		ug/kg	2.0	0.17
1,1,1,2-Tetrachloroethane	ND		ug/kg	0.50	0.13
Bromobenzene	ND		ug/kg	2.0	0.14
n-Butylbenzene	ND		ug/kg	1.0	0.17
sec-Butylbenzene	ND		ug/kg	1.0	0.15
tert-Butylbenzene	ND		ug/kg	2.0	0.12
o-Chlorotoluene	ND		ug/kg	2.0	0.19

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 06/08/23 10:12
Analyst: AJK

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by EPA 5035 Low - Westborough Lab for sample(s): 02-04,07 Batch: WG1789312-5					
p-Chlorotoluene	ND		ug/kg	2.0	0.11
1,2-Dibromo-3-chloropropane	ND		ug/kg	3.0	1.0
Hexachlorobutadiene	ND		ug/kg	4.0	0.17
Isopropylbenzene	ND		ug/kg	1.0	0.11
p-Isopropyltoluene	ND		ug/kg	1.0	0.11
Naphthalene	ND		ug/kg	4.0	0.65
Acrylonitrile	ND		ug/kg	4.0	1.2
n-Propylbenzene	ND		ug/kg	1.0	0.17
1,2,3-Trichlorobenzene	ND		ug/kg	2.0	0.32
1,2,4-Trichlorobenzene	ND		ug/kg	2.0	0.27
1,3,5-Trimethylbenzene	ND		ug/kg	2.0	0.19
1,2,4-Trimethylbenzene	ND		ug/kg	2.0	0.33
1,4-Dioxane	ND		ug/kg	80	35.
p-Diethylbenzene	ND		ug/kg	2.0	0.18
p-Ethyltoluene	ND		ug/kg	2.0	0.38
1,2,4,5-Tetramethylbenzene	ND		ug/kg	2.0	0.19
Ethyl ether	ND		ug/kg	2.0	0.34
trans-1,4-Dichloro-2-butene	ND		ug/kg	5.0	1.4

Tentatively Identified Compounds

Total TIC Compounds	9.08	J	ug/kg
Unknown	2.37	J	ug/kg
Cyclotrisiloxane, Hexamethyl-	6.71	NJ	ug/kg

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 06/08/23 10:12
Analyst: AJK

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by EPA 5035 Low - Westborough Lab for sample(s): 02-04,07 Batch: WG1789312-5					

Surrogate	%Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	97		70-130
Toluene-d8	103		70-130
4-Bromofluorobenzene	108		70-130
Dibromofluoromethane	91		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 06/09/23 08:51
Analyst: MKS

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by EPA 5035 High - Westborough Lab for sample(s): 02 Batch: WG1790043-5					
Methylene chloride	ND		ug/kg	250	110
1,1-Dichloroethane	ND		ug/kg	50	7.2
Chloroform	ND		ug/kg	75	7.0
Carbon tetrachloride	ND		ug/kg	50	12.
1,2-Dichloropropane	ND		ug/kg	50	6.2
Dibromochloromethane	ND		ug/kg	50	7.0
1,1,2-Trichloroethane	ND		ug/kg	50	13.
Tetrachloroethene	ND		ug/kg	25	9.8
Chlorobenzene	ND		ug/kg	25	6.4
Trichlorofluoromethane	ND		ug/kg	200	35.
1,2-Dichloroethane	ND		ug/kg	50	13.
1,1,1-Trichloroethane	ND		ug/kg	25	8.4
Bromodichloromethane	ND		ug/kg	25	5.4
trans-1,3-Dichloropropene	ND		ug/kg	50	14.
cis-1,3-Dichloropropene	ND		ug/kg	25	7.9
1,3-Dichloropropene, Total	ND		ug/kg	25	7.9
1,1-Dichloropropene	ND		ug/kg	25	8.0
Bromoform	ND		ug/kg	200	12.
1,1,2,2-Tetrachloroethane	ND		ug/kg	25	8.3
Benzene	ND		ug/kg	25	8.3
Toluene	ND		ug/kg	50	27.
Ethylbenzene	ND		ug/kg	50	7.0
Chloromethane	ND		ug/kg	200	47.
Bromomethane	ND		ug/kg	100	29.
Vinyl chloride	ND		ug/kg	50	17.
Chloroethane	ND		ug/kg	100	23.
1,1-Dichloroethene	ND		ug/kg	50	12.
trans-1,2-Dichloroethene	ND		ug/kg	75	6.8
Trichloroethene	ND		ug/kg	25	6.8

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 06/09/23 08:51
Analyst: MKS

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by EPA 5035 High - Westborough Lab for sample(s): 02 Batch: WG1790043-5					
1,2-Dichlorobenzene	ND		ug/kg	100	7.2
1,3-Dichlorobenzene	ND		ug/kg	100	7.4
1,4-Dichlorobenzene	ND		ug/kg	100	8.6
Methyl tert butyl ether	ND		ug/kg	100	10.
p/m-Xylene	ND		ug/kg	100	28.
o-Xylene	ND		ug/kg	50	14.
Xylenes, Total	ND		ug/kg	50	14.
cis-1,2-Dichloroethene	ND		ug/kg	50	8.8
1,2-Dichloroethene, Total	ND		ug/kg	50	6.8
Dibromomethane	ND		ug/kg	100	12.
Styrene	ND		ug/kg	50	9.8
Dichlorodifluoromethane	ND		ug/kg	500	46.
Acetone	ND		ug/kg	500	240
Carbon disulfide	ND		ug/kg	500	230
2-Butanone	ND		ug/kg	500	110
Vinyl acetate	ND		ug/kg	500	110
4-Methyl-2-pentanone	ND		ug/kg	500	64.
1,2,3-Trichloropropane	ND		ug/kg	100	6.4
2-Hexanone	ND		ug/kg	500	59.
Bromochloromethane	ND		ug/kg	100	10.
2,2-Dichloropropane	ND		ug/kg	100	10.
1,2-Dibromoethane	ND		ug/kg	50	14.
1,3-Dichloropropane	ND		ug/kg	100	8.4
1,1,1,2-Tetrachloroethane	ND		ug/kg	25	6.6
Bromobenzene	ND		ug/kg	100	7.2
n-Butylbenzene	ND		ug/kg	50	8.4
sec-Butylbenzene	ND		ug/kg	50	7.3
tert-Butylbenzene	ND		ug/kg	100	5.9
o-Chlorotoluene	ND		ug/kg	100	9.6

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 06/09/23 08:51
Analyst: MKS

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by EPA 5035 High - Westborough Lab for sample(s): 02 Batch: WG1790043-5					
p-Chlorotoluene	ND		ug/kg	100	5.4
1,2-Dibromo-3-chloropropane	ND		ug/kg	150	50.
Hexachlorobutadiene	ND		ug/kg	200	8.4
Isopropylbenzene	ND		ug/kg	50	5.4
p-Isopropyltoluene	ND		ug/kg	50	5.4
Naphthalene	ND		ug/kg	200	32.
Acrylonitrile	ND		ug/kg	200	58.
n-Propylbenzene	ND		ug/kg	50	8.6
1,2,3-Trichlorobenzene	ND		ug/kg	100	16.
1,2,4-Trichlorobenzene	ND		ug/kg	100	14.
1,3,5-Trimethylbenzene	ND		ug/kg	100	9.6
1,2,4-Trimethylbenzene	ND		ug/kg	100	17.
1,4-Dioxane	ND		ug/kg	4000	1800
p-Diethylbenzene	ND		ug/kg	100	8.8
p-Ethyltoluene	ND		ug/kg	100	19.
1,2,4,5-Tetramethylbenzene	ND		ug/kg	100	9.6
Ethyl ether	ND		ug/kg	100	17.
trans-1,4-Dichloro-2-butene	ND		ug/kg	250	71.

Tentatively Identified Compounds

Total TIC Compounds	106	J	ug/kg
Unknown	106	J	ug/kg

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 06/09/23 08:51
Analyst: MKS

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by EPA 5035 High - Westborough Lab for sample(s): 02 Batch: WG1790043-5					

Surrogate	%Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	101		70-130
Toluene-d8	97		70-130
4-Bromofluorobenzene	102		70-130
Dibromofluoromethane	104		70-130

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331226
Report Date: 06/13/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by GC/MS - Westborough Lab Associated sample(s): 08-09 Batch: WG1788648-3 WG1788648-4								
Methylene chloride	94		95		70-130	1		20
1,1-Dichloroethane	96		100		70-130	4		20
Chloroform	87		91		70-130	4		20
Carbon tetrachloride	90		94		63-132	4		20
1,2-Dichloropropane	98		95		70-130	3		20
Dibromochloromethane	90		94		63-130	4		20
1,1,2-Trichloroethane	93		99		70-130	6		20
Tetrachloroethene	99		99		70-130	0		20
Chlorobenzene	94		98		75-130	4		20
Trichlorofluoromethane	100		110		62-150	10		20
1,2-Dichloroethane	90		91		70-130	1		20
1,1,1-Trichloroethane	93		90		67-130	3		20
Bromodichloromethane	92		95		67-130	3		20
trans-1,3-Dichloropropene	94		97		70-130	3		20
cis-1,3-Dichloropropene	94		96		70-130	2		20
1,1-Dichloropropene	98		97		70-130	1		20
Bromoform	88		93		54-136	6		20
1,1,2,2-Tetrachloroethane	94		99		67-130	5		20
Benzene	100		97		70-130	3		20
Toluene	96		98		70-130	2		20
Ethylbenzene	97		100		70-130	3		20
Chloromethane	95		98		64-130	3		20
Bromomethane	95		100		39-139	5		20

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331226
Report Date: 06/13/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by GC/MS - Westborough Lab Associated sample(s): 08-09 Batch: WG1788648-3 WG1788648-4								
Vinyl chloride	100		100		55-140	0		20
Chloroethane	120		120		55-138	0		20
1,1-Dichloroethene	100		110		61-145	10		20
trans-1,2-Dichloroethene	95		95		70-130	0		20
Trichloroethene	83		89		70-130	7		20
1,2-Dichlorobenzene	95		100		70-130	5		20
1,3-Dichlorobenzene	98		100		70-130	2		20
1,4-Dichlorobenzene	95		97		70-130	2		20
Methyl tert butyl ether	90		91		63-130	1		20
p/m-Xylene	95		100		70-130	5		20
o-Xylene	100		100		70-130	0		20
cis-1,2-Dichloroethene	98		100		70-130	2		20
Dibromomethane	94		91		70-130	3		20
1,2,3-Trichloropropane	91		96		64-130	5		20
Acrylonitrile	92		93		70-130	1		20
Styrene	100		100		70-130	0		20
Dichlorodifluoromethane	100		100		36-147	0		20
Acetone	92		99		58-148	7		20
Carbon disulfide	100		100		51-130	0		20
2-Butanone	75		90		63-138	18		20
Vinyl acetate	96		100		70-130	4		20
4-Methyl-2-pentanone	84		93		59-130	10		20
2-Hexanone	85		93		57-130	9		20

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331226
Report Date: 06/13/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by GC/MS - Westborough Lab Associated sample(s): 08-09 Batch: WG1788648-3 WG1788648-4								
Bromochloromethane	90		95		70-130	5		20
2,2-Dichloropropane	91		96		63-133	5		20
1,2-Dibromoethane	90		96		70-130	6		20
1,3-Dichloropropane	94		98		70-130	4		20
1,1,1,2-Tetrachloroethane	97		97		64-130	0		20
Bromobenzene	96		99		70-130	3		20
n-Butylbenzene	96		100		53-136	4		20
sec-Butylbenzene	96		99		70-130	3		20
tert-Butylbenzene	94		98		70-130	4		20
o-Chlorotoluene	100		100		70-130	0		20
p-Chlorotoluene	96		99		70-130	3		20
1,2-Dibromo-3-chloropropane	82		86		41-144	5		20
Hexachlorobutadiene	98		99		63-130	1		20
Isopropylbenzene	97		100		70-130	3		20
p-Isopropyltoluene	95		99		70-130	4		20
Naphthalene	92		97		70-130	5		20
n-Propylbenzene	99		100		69-130	1		20
1,2,3-Trichlorobenzene	91		96		70-130	5		20
1,2,4-Trichlorobenzene	94		98		70-130	4		20
1,3,5-Trimethylbenzene	97		99		64-130	2		20
1,2,4-Trimethylbenzene	98		100		70-130	2		20
1,4-Dioxane	84		84		56-162	0		20
p-Diethylbenzene	94		98		70-130	4		20

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331226

Report Date: 06/13/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by GC/MS - Westborough Lab Associated sample(s): 08-09 Batch: WG1788648-3 WG1788648-4								
p-Ethyltoluene	100		100		70-130	0		20
1,2,4,5-Tetramethylbenzene	91		96		70-130	5		20
Ethyl ether	89		100		59-134	12		20
trans-1,4-Dichloro-2-butene	87		92		70-130	6		20

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
1,2-Dichloroethane-d4	93		98		70-130
Toluene-d8	101		103		70-130
4-Bromofluorobenzene	100		101		70-130
Dibromofluoromethane	100		97		70-130

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331226
Report Date: 06/13/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by EPA 5035 Low - Westborough Lab Associated sample(s): 01,05 Batch: WG1788684-3 WG1788684-4								
Methylene chloride	**69**	Q	**69**	Q	70-130	0		30
1,1-Dichloroethane	88		89		70-130	1		30
Chloroform	113		110		70-130	3		30
Carbon tetrachloride	100		97		70-130	3		30
1,2-Dichloropropane	100		98		70-130	2		30
Dibromochloromethane	104		105		70-130	1		30
1,1,2-Trichloroethane	98		99		70-130	1		30
Tetrachloroethene	102		102		70-130	0		30
Chlorobenzene	99		99		70-130	0		30
Trichlorofluoromethane	70		**65**	Q	70-139	7		30
1,2-Dichloroethane	117		111		70-130	5		30
1,1,1-Trichloroethane	108		106		70-130	2		30
Bromodichloromethane	120		121		70-130	1		30
trans-1,3-Dichloropropene	98		99		70-130	1		30
cis-1,3-Dichloropropene	115		115		70-130	0		30
1,1-Dichloropropene	91		91		70-130	0		30
Bromoform	93		95		70-130	2		30
1,1,2,2-Tetrachloroethane	83		83		70-130	0		30
Benzene	94		94		70-130	0		30
Toluene	83		85		70-130	2		30
Ethylbenzene	94		95		70-130	1		30
Chloromethane	66		64		52-130	3		30
Bromomethane	74		70		57-147	6		30

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331226
Report Date: 06/13/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by EPA 5035 Low - Westborough Lab Associated sample(s): 01,05 Batch: WG1788684-3 WG1788684-4								
Vinyl chloride	**62**	Q	**58**	Q	67-130	7		30
Chloroethane	56		51		50-151	9		30
1,1-Dichloroethene	**63**	Q	**60**	Q	65-135	5		30
trans-1,2-Dichloroethene	80		80		70-130	0		30
Trichloroethene	111		110		70-130	1		30
1,2-Dichlorobenzene	93		96		70-130	3		30
1,3-Dichlorobenzene	94		96		70-130	2		30
1,4-Dichlorobenzene	94		95		70-130	1		30
Methyl tert butyl ether	94		97		66-130	3		30
p/m-Xylene	96		98		70-130	2		30
o-Xylene	97		98		70-130	1		30
cis-1,2-Dichloroethene	97		95		70-130	2		30
Dibromomethane	115		113		70-130	2		30
Styrene	100		100		70-130	0		30
Dichlorodifluoromethane	63		63		30-146	0		30
Acetone	94		96		54-140	2		30
Carbon disulfide	**56**	Q	**53**	Q	59-130	6		30
2-Butanone	116		114		70-130	2		30
Vinyl acetate	109		101		70-130	8		30
4-Methyl-2-pentanone	86		83		70-130	4		30
1,2,3-Trichloropropane	82		83		68-130	1		30
2-Hexanone	95		92		70-130	3		30
Bromochloromethane	103		105		70-130	2		30

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331226
Report Date: 06/13/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by EPA 5035 Low - Westborough Lab Associated sample(s): 01,05 Batch: WG1788684-3 WG1788684-4								
2,2-Dichloropropane	102		100		70-130	2		30
1,2-Dibromoethane	99		99		70-130	0		30
1,3-Dichloropropane	92		92		69-130	0		30
1,1,1,2-Tetrachloroethane	109		109		70-130	0		30
Bromobenzene	92		92		70-130	0		30
n-Butylbenzene	90		94		70-130	4		30
sec-Butylbenzene	87		89		70-130	2		30
tert-Butylbenzene	86		89		70-130	3		30
o-Chlorotoluene	85		88		70-130	3		30
p-Chlorotoluene	87		88		70-130	1		30
1,2-Dibromo-3-chloropropane	89		93		68-130	4		30
Hexachlorobutadiene	100		102		67-130	2		30
Isopropylbenzene	82		84		70-130	2		30
p-Isopropyltoluene	88		91		70-130	3		30
Naphthalene	84		86		70-130	2		30
Acrylonitrile	98		92		70-130	6		30
n-Propylbenzene	85		86		70-130	1		30
1,2,3-Trichlorobenzene	100		101		70-130	1		30
1,2,4-Trichlorobenzene	100		102		70-130	2		30
1,3,5-Trimethylbenzene	85		88		70-130	3		30
1,2,4-Trimethylbenzene	86		86		70-130	0		30
1,4-Dioxane	121		112		65-136	8		30
p-Diethylbenzene	90		92		70-130	2		30

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331226

Report Date: 06/13/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by EPA 5035 Low - Westborough Lab Associated sample(s): 01,05 Batch: WG1788684-3 WG1788684-4								
p-Ethyltoluene	86		88		70-130	2		30
1,2,4,5-Tetramethylbenzene	84		86		70-130	2		30
Ethyl ether	**66**	Q	**64**	Q	67-130	3		30
trans-1,4-Dichloro-2-butene	90		96		70-130	6		30

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
1,2-Dichloroethane-d4	117		114		70-130
Toluene-d8	88		87		70-130
4-Bromofluorobenzene	84		85		70-130
Dibromofluoromethane	114		112		70-130

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331226

Report Date: 06/13/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by EPA 5035 Low - Westborough Lab Associated sample(s): 06 Batch: WG1788865-3 WG1788865-4								
Methylene chloride	96		96		70-130	0		30
1,1-Dichloroethane	102		101		70-130	1		30
Chloroform	101		103		70-130	2		30
Carbon tetrachloride	101		99		70-130	2		30
1,2-Dichloropropane	99		98		70-130	1		30
Dibromochloromethane	93		93		70-130	0		30
1,1,2-Trichloroethane	92		91		70-130	1		30
Tetrachloroethene	100		98		70-130	2		30
Chlorobenzene	97		98		70-130	1		30
Trichlorofluoromethane	104		103		70-139	1		30
1,2-Dichloroethane	95		95		70-130	0		30
1,1,1-Trichloroethane	105		105		70-130	0		30
Bromodichloromethane	99		100		70-130	1		30
trans-1,3-Dichloropropene	93		94		70-130	1		30
cis-1,3-Dichloropropene	101		101		70-130	0		30
1,1-Dichloropropene	105		104		70-130	1		30
Bromoform	89		88		70-130	1		30
1,1,2,2-Tetrachloroethane	87		86		70-130	1		30
Benzene	102		102		70-130	0		30
Toluene	97		98		70-130	1		30
Ethylbenzene	100		100		70-130	0		30
Chloromethane	102		100		52-130	2		30
Bromomethane	119		120		57-147	1		30

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331226
Report Date: 06/13/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by EPA 5035 Low - Westborough Lab Associated sample(s): 06 Batch: WG1788865-3 WG1788865-4								
Vinyl chloride	98		97		67-130	1		30
Chloroethane	110		110		50-151	0		30
1,1-Dichloroethene	105		105		65-135	0		30
trans-1,2-Dichloroethene	105		104		70-130	1		30
Trichloroethene	105		106		70-130	1		30
1,2-Dichlorobenzene	96		96		70-130	0		30
1,3-Dichlorobenzene	99		99		70-130	0		30
1,4-Dichlorobenzene	95		96		70-130	1		30
Methyl tert butyl ether	94		94		66-130	0		30
p/m-Xylene	100		100		70-130	0		30
o-Xylene	99		99		70-130	0		30
cis-1,2-Dichloroethene	103		103		70-130	0		30
Dibromomethane	96		96		70-130	0		30
Styrene	101		102		70-130	1		30
Dichlorodifluoromethane	104		102		30-146	2		30
Acetone	76		75		54-140	1		30
Carbon disulfide	102		101		59-130	1		30
2-Butanone	70		**69**	Q	70-130	1		30
Vinyl acetate	78		73		70-130	7		30
4-Methyl-2-pentanone	84		85		70-130	1		30
1,2,3-Trichloropropane	86		86		68-130	0		30
2-Hexanone	74		72		70-130	3		30
Bromochloromethane	99		99		70-130	0		30

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331226
Report Date: 06/13/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by EPA 5035 Low - Westborough Lab Associated sample(s): 06 Batch: WG1788865-3 WG1788865-4								
2,2-Dichloropropane	107		105		70-130	2		30
1,2-Dibromoethane	96		95		70-130	1		30
1,3-Dichloropropane	92		92		69-130	0		30
1,1,1,2-Tetrachloroethane	96		96		70-130	0		30
Bromobenzene	95		96		70-130	1		30
n-Butylbenzene	99		99		70-130	0		30
sec-Butylbenzene	99		99		70-130	0		30
tert-Butylbenzene	98		98		70-130	0		30
o-Chlorotoluene	98		99		70-130	1		30
p-Chlorotoluene	97		98		70-130	1		30
1,2-Dibromo-3-chloropropane	84		84		68-130	0		30
Hexachlorobutadiene	101		100		67-130	1		30
Isopropylbenzene	99		99		70-130	0		30
p-Isopropyltoluene	99		99		70-130	0		30
Naphthalene	91		91		70-130	0		30
Acrylonitrile	77		77		70-130	0		30
n-Propylbenzene	102		102		70-130	0		30
1,2,3-Trichlorobenzene	98		98		70-130	0		30
1,2,4-Trichlorobenzene	100		101		70-130	1		30
1,3,5-Trimethylbenzene	96		96		70-130	0		30
1,2,4-Trimethylbenzene	97		98		70-130	1		30
1,4-Dioxane	86		86		65-136	0		30
p-Diethylbenzene	98		98		70-130	0		30

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331226

Report Date: 06/13/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by EPA 5035 Low - Westborough Lab Associated sample(s): 06 Batch: WG1788865-3 WG1788865-4								
p-Ethyltoluene	100		100		70-130	0		30
1,2,4,5-Tetramethylbenzene	99		99		70-130	0		30
Ethyl ether	95		96		67-130	1		30
trans-1,4-Dichloro-2-butene	95		91		70-130	4		30

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
1,2-Dichloroethane-d4	91		91		70-130
Toluene-d8	100		100		70-130
4-Bromofluorobenzene	100		101		70-130
Dibromofluoromethane	98		98		70-130

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331226
Report Date: 06/13/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by EPA 5035 Low - Westborough Lab Associated sample(s): 02-04,07 Batch: WG1789312-3 WG1789312-4								
Methylene chloride	85		85		70-130	0		30
1,1-Dichloroethane	91		90		70-130	1		30
Chloroform	89		87		70-130	2		30
Carbon tetrachloride	84		82		70-130	2		30
1,2-Dichloropropane	92		91		70-130	1		30
Dibromochloromethane	93		91		70-130	2		30
1,1,2-Trichloroethane	95		93		70-130	2		30
Tetrachloroethene	89		86		70-130	3		30
Chlorobenzene	92		91		70-130	1		30
Trichlorofluoromethane	87		84		70-139	4		30
1,2-Dichloroethane	90		88		70-130	2		30
1,1,1-Trichloroethane	88		86		70-130	2		30
Bromodichloromethane	89		88		70-130	1		30
trans-1,3-Dichloropropene	94		93		70-130	1		30
cis-1,3-Dichloropropene	92		91		70-130	1		30
1,1-Dichloropropene	92		89		70-130	3		30
Bromoform	89		88		70-130	1		30
1,1,2,2-Tetrachloroethane	98		94		70-130	4		30
Benzene	91		89		70-130	2		30
Toluene	92		90		70-130	2		30
Ethylbenzene	94		93		70-130	1		30
Chloromethane	88		86		52-130	2		30
Bromomethane	81		82		57-147	1		30

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331226

Report Date: 06/13/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by EPA 5035 Low - Westborough Lab Associated sample(s): 02-04,07 Batch: WG1789312-3 WG1789312-4								
Vinyl chloride	89		86		67-130	3		30
Chloroethane	94		92		50-151	2		30
1,1-Dichloroethene	88		84		65-135	5		30
trans-1,2-Dichloroethene	87		86		70-130	1		30
Trichloroethene	92		91		70-130	1		30
1,2-Dichlorobenzene	93		93		70-130	0		30
1,3-Dichlorobenzene	94		94		70-130	0		30
1,4-Dichlorobenzene	93		93		70-130	0		30
Methyl tert butyl ether	89		86		66-130	3		30
p/m-Xylene	94		93		70-130	1		30
o-Xylene	94		93		70-130	1		30
cis-1,2-Dichloroethene	87		85		70-130	2		30
Dibromomethane	87		86		70-130	1		30
Styrene	96		95		70-130	1		30
Dichlorodifluoromethane	76		74		30-146	3		30
Acetone	95		88		54-140	8		30
Carbon disulfide	84		82		59-130	2		30
2-Butanone	92		86		70-130	7		30
Vinyl acetate	82		76		70-130	8		30
4-Methyl-2-pentanone	104		95		70-130	9		30
1,2,3-Trichloropropane	98		95		68-130	3		30
2-Hexanone	106		96		70-130	10		30
Bromochloromethane	88		86		70-130	2		30

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331226

Report Date: 06/13/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by EPA 5035 Low - Westborough Lab Associated sample(s): 02-04,07 Batch: WG1789312-3 WG1789312-4								
2,2-Dichloropropane	87		85		70-130	2		30
1,2-Dibromoethane	94		91		70-130	3		30
1,3-Dichloropropane	95		93		69-130	2		30
1,1,1,2-Tetrachloroethane	91		90		70-130	1		30
Bromobenzene	92		93		70-130	1		30
n-Butylbenzene	98		97		70-130	1		30
sec-Butylbenzene	98		97		70-130	1		30
tert-Butylbenzene	95		95		70-130	0		30
o-Chlorotoluene	98		98		70-130	0		30
p-Chlorotoluene	98		99		70-130	1		30
1,2-Dibromo-3-chloropropane	88		84		68-130	5		30
Hexachlorobutadiene	92		92		67-130	0		30
Isopropylbenzene	96		97		70-130	1		30
p-Isopropyltoluene	96		95		70-130	1		30
Naphthalene	103		100		70-130	3		30
Acrylonitrile	98		92		70-130	6		30
n-Propylbenzene	100		99		70-130	1		30
1,2,3-Trichlorobenzene	92		92		70-130	0		30
1,2,4-Trichlorobenzene	99		98		70-130	1		30
1,3,5-Trimethylbenzene	97		97		70-130	0		30
1,2,4-Trimethylbenzene	98		98		70-130	0		30
1,4-Dioxane	96		86		65-136	11		30
p-Diethylbenzene	98		97		70-130	1		30

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331226

Report Date: 06/13/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by EPA 5035 Low - Westborough Lab Associated sample(s): 02-04,07 Batch: WG1789312-3 WG1789312-4								
p-Ethyltoluene	99		99		70-130	0		30
1,2,4,5-Tetramethylbenzene	100		99		70-130	1		30
Ethyl ether	89		88		67-130	1		30
trans-1,4-Dichloro-2-butene	105		101		70-130	4		30

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
1,2-Dichloroethane-d4	101		99		70-130
Toluene-d8	103		103		70-130
4-Bromofluorobenzene	106		107		70-130
Dibromofluoromethane	96		95		70-130

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331226
Report Date: 06/13/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by EPA 5035 High - Westborough Lab Associated sample(s): 02 Batch: WG1790043-3 WG1790043-4								
Methylene chloride	98		98		70-130	0		30
1,1-Dichloroethane	104		103		70-130	1		30
Chloroform	105		104		70-130	1		30
Carbon tetrachloride	104		103		70-130	1		30
1,2-Dichloropropane	101		102		70-130	1		30
Dibromochloromethane	94		94		70-130	0		30
1,1,2-Trichloroethane	93		93		70-130	0		30
Tetrachloroethene	102		101		70-130	1		30
Chlorobenzene	100		99		70-130	1		30
Trichlorofluoromethane	108		106		70-139	2		30
1,2-Dichloroethane	97		96		70-130	1		30
1,1,1-Trichloroethane	109		107		70-130	2		30
Bromodichloromethane	101		102		70-130	1		30
trans-1,3-Dichloropropene	95		97		70-130	2		30
cis-1,3-Dichloropropene	104		103		70-130	1		30
1,1-Dichloropropene	109		106		70-130	3		30
Bromoform	91		91		70-130	0		30
1,1,2,2-Tetrachloroethane	89		88		70-130	1		30
Benzene	105		104		70-130	1		30
Toluene	99		99		70-130	0		30
Ethylbenzene	103		102		70-130	1		30
Chloromethane	104		101		52-130	3		30
Bromomethane	124		124		57-147	0		30

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331226
Report Date: 06/13/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by EPA 5035 High - Westborough Lab Associated sample(s): 02 Batch: WG1790043-3 WG1790043-4								
Vinyl chloride	101		100		67-130	1		30
Chloroethane	114		114		50-151	0		30
1,1-Dichloroethene	109		107		65-135	2		30
trans-1,2-Dichloroethene	107		107		70-130	0		30
Trichloroethene	108		107		70-130	1		30
1,2-Dichlorobenzene	99		99		70-130	0		30
1,3-Dichlorobenzene	101		100		70-130	1		30
1,4-Dichlorobenzene	98		98		70-130	0		30
Methyl tert butyl ether	95		96		66-130	1		30
p/m-Xylene	102		102		70-130	0		30
o-Xylene	101		102		70-130	1		30
cis-1,2-Dichloroethene	107		105		70-130	2		30
Dibromomethane	98		98		70-130	0		30
Styrene	104		104		70-130	0		30
Dichlorodifluoromethane	107		105		30-146	2		30
Acetone	65		65		54-140	0		30
Carbon disulfide	105		103		59-130	2		30
2-Butanone	**66**	Q	**59**	Q	70-130	11		30
Vinyl acetate	81		78		70-130	4		30
4-Methyl-2-pentanone	85		85		70-130	0		30
1,2,3-Trichloropropane	87		87		68-130	0		30
2-Hexanone	74		71		70-130	4		30
Bromochloromethane	101		102		70-130	1		30

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331226

Report Date: 06/13/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by EPA 5035 High - Westborough Lab Associated sample(s): 02 Batch: WG1790043-3 WG1790043-4								
2,2-Dichloropropane	110		105		70-130	5		30
1,2-Dibromoethane	96		97		70-130	1		30
1,3-Dichloropropane	94		93		69-130	1		30
1,1,1,2-Tetrachloroethane	99		98		70-130	1		30
Bromobenzene	98		98		70-130	0		30
n-Butylbenzene	103		102		70-130	1		30
sec-Butylbenzene	103		103		70-130	0		30
tert-Butylbenzene	102		102		70-130	0		30
o-Chlorotoluene	102		101		70-130	1		30
p-Chlorotoluene	100		101		70-130	1		30
1,2-Dibromo-3-chloropropane	84		86		68-130	2		30
Hexachlorobutadiene	104		104		67-130	0		30
Isopropylbenzene	103		102		70-130	1		30
p-Isopropyltoluene	103		103		70-130	0		30
Naphthalene	92		92		70-130	0		30
Acrylonitrile	77		78		70-130	1		30
n-Propylbenzene	105		105		70-130	0		30
1,2,3-Trichlorobenzene	98		100		70-130	2		30
1,2,4-Trichlorobenzene	102		103		70-130	1		30
1,3,5-Trimethylbenzene	99		98		70-130	1		30
1,2,4-Trimethylbenzene	101		100		70-130	1		30
1,4-Dioxane	84		84		65-136	0		30
p-Diethylbenzene	102		101		70-130	1		30

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331226

Report Date: 06/13/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by EPA 5035 High - Westborough Lab Associated sample(s): 02 Batch: WG1790043-3 WG1790043-4								
p-Ethyltoluene	104		102		70-130	2		30
1,2,4,5-Tetramethylbenzene	102		102		70-130	0		30
Ethyl ether	97		97		67-130	0		30
trans-1,4-Dichloro-2-butene	86		95		70-130	10		30

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
1,2-Dichloroethane-d4	90		91		70-130
Toluene-d8	99		99		70-130
4-Bromofluorobenzene	101		101		70-130
Dibromofluoromethane	99		98		70-130

SEMIVOLATILES

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-01
Client ID: SB-20G (1.5-2)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 10:00
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8270E
Analytical Date: 06/07/23 15:44
Analyst: EK
Percent Solids: 94%

Extraction Method: EPA 3546
Extraction Date: 06/06/23 15:47

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Acenaphthene	ND		ug/kg	140	18.	1
1,2,4-Trichlorobenzene	ND		ug/kg	170	20.	1
Hexachlorobenzene	ND		ug/kg	100	20.	1
Bis(2-chloroethyl)ether	ND		ug/kg	160	24.	1
2-Chloronaphthalene	ND		ug/kg	170	17.	1
1,2-Dichlorobenzene	ND		ug/kg	170	31.	1
1,3-Dichlorobenzene	ND		ug/kg	170	30.	1
1,4-Dichlorobenzene	ND		ug/kg	170	30.	1
3,3'-Dichlorobenzidine	ND		ug/kg	170	46.	1
2,4-Dinitrotoluene	ND		ug/kg	170	35.	1
2,6-Dinitrotoluene	ND		ug/kg	170	30.	1
Fluoranthene	180		ug/kg	100	20.	1
4-Chlorophenyl phenyl ether	ND		ug/kg	170	19.	1
4-Bromophenyl phenyl ether	ND		ug/kg	170	27.	1
Bis(2-chloroisopropyl)ether	ND		ug/kg	210	30.	1
Bis(2-chloroethoxy)methane	ND		ug/kg	190	18.	1
Hexachlorobutadiene	ND		ug/kg	170	26.	1
Hexachlorocyclopentadiene	ND		ug/kg	500	160	1
Hexachloroethane	ND		ug/kg	140	28.	1
Isophorone	ND		ug/kg	160	23.	1
Naphthalene	ND		ug/kg	170	21.	1
Nitrobenzene	ND		ug/kg	160	26.	1
NDPA/DPA	ND		ug/kg	140	20.	1
n-Nitrosodi-n-propylamine	ND		ug/kg	170	27.	1
Bis(2-ethylhexyl)phthalate	ND		ug/kg	170	60.	1
Butyl benzyl phthalate	ND		ug/kg	170	44.	1
Di-n-butylphthalate	ND		ug/kg	170	33.	1
Di-n-octylphthalate	ND		ug/kg	170	59.	1

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-01 Date Collected: 06/05/23 10:00

Client ID: SB-20G (1.5-2) Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Diethyl phthalate	ND		ug/kg	170	16.	1
Dimethyl phthalate	ND		ug/kg	170	37.	1
Benzo(a)anthracene	83	J	ug/kg	100	20.	1
Benzo(a)pyrene	76	J	ug/kg	140	43.	1
Benzo(b)fluoranthene	88	J	ug/kg	100	29.	1
Benzo(k)fluoranthene	30	J	ug/kg	100	28.	1
Chrysene	74	J	ug/kg	100	18.	1
Acenaphthylene	ND		ug/kg	140	27.	1
Anthracene	44	J	ug/kg	100	34.	1
Benzo(ghi)perylene	42	J	ug/kg	140	20.	1
Fluorene	ND		ug/kg	170	17.	1
Phenanthrene	150		ug/kg	100	21.	1
Dibenzo(a,h)anthracene	ND		ug/kg	100	20.	1
Indeno(1,2,3-cd)pyrene	37	J	ug/kg	140	24.	1
Pyrene	170		ug/kg	100	17.	1
Biphenyl	ND		ug/kg	400	23.	1
4-Chloroaniline	ND		ug/kg	170	32.	1
2-Nitroaniline	ND		ug/kg	170	34.	1
3-Nitroaniline	ND		ug/kg	170	33.	1
4-Nitroaniline	ND		ug/kg	170	72.	1
Dibenzofuran	ND		ug/kg	170	16.	1
2-Methylnaphthalene	ND		ug/kg	210	21.	1
1,2,4,5-Tetrachlorobenzene	ND		ug/kg	170	18.	1
Acetophenone	ND		ug/kg	170	22.	1
2,4,6-Trichlorophenol	ND		ug/kg	100	33.	1
p-Chloro-m-cresol	ND		ug/kg	170	26.	1
2-Chlorophenol	ND		ug/kg	170	21.	1
2,4-Dichlorophenol	ND		ug/kg	160	28.	1
2,4-Dimethylphenol	ND		ug/kg	170	58.	1
2-Nitrophenol	ND		ug/kg	380	66.	1
4-Nitrophenol	ND		ug/kg	240	71.	1
2,4-Dinitrophenol	ND		ug/kg	840	81.	1
4,6-Dinitro-o-cresol	ND		ug/kg	450	84.	1
Pentachlorophenol	ND		ug/kg	140	38.	1
Phenol	ND		ug/kg	170	26.	1
2-Methylphenol	ND		ug/kg	170	27.	1
3-Methylphenol/4-Methylphenol	ND		ug/kg	250	27.	1

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-01 Date Collected: 06/05/23 10:00

Client ID: SB-20G (1.5-2) Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
2,4,5-Trichlorophenol	ND		ug/kg	170	34.	1
Benzoic Acid	ND		ug/kg	570	180	1
Benzyl Alcohol	ND		ug/kg	170	54.	1
Carbazole	20	J	ug/kg	170	17.	1
1,4-Dioxane	ND		ug/kg	26	8.0	1
Tentatively Identified Compounds						
No Tentatively Identified Compounds	ND		ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	48		25-120
Phenol-d6	55		10-120
Nitrobenzene-d5	57		23-120
2-Fluorobiphenyl	53		30-120
2,4,6-Tribromophenol	40		10-136
4-Terphenyl-d14	62		18-120

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-02
Client ID: SB-21G (9-9.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 11:15
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8270E
Analytical Date: 06/07/23 16:01
Analyst: EK
Percent Solids: 91%

Extraction Method: EPA 3546
Extraction Date: 06/06/23 15:47

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Acenaphthene	ND		ug/kg	140	19.	1
1,2,4-Trichlorobenzene	ND		ug/kg	180	20.	1
Hexachlorobenzene	ND		ug/kg	110	20.	1
Bis(2-chloroethyl)ether	ND		ug/kg	160	24.	1
2-Chloronaphthalene	ND		ug/kg	180	18.	1
1,2-Dichlorobenzene	ND		ug/kg	180	32.	1
1,3-Dichlorobenzene	ND		ug/kg	180	31.	1
1,4-Dichlorobenzene	ND		ug/kg	180	31.	1
3,3'-Dichlorobenzidine	ND		ug/kg	180	48.	1
2,4-Dinitrotoluene	ND		ug/kg	180	36.	1
2,6-Dinitrotoluene	ND		ug/kg	180	31.	1
Fluoranthene	57	J	ug/kg	110	21.	1
4-Chlorophenyl phenyl ether	ND		ug/kg	180	19.	1
4-Bromophenyl phenyl ether	ND		ug/kg	180	27.	1
Bis(2-chloroisopropyl)ether	ND		ug/kg	220	31.	1
Bis(2-chloroethoxy)methane	ND		ug/kg	190	18.	1
Hexachlorobutadiene	ND		ug/kg	180	26.	1
Hexachlorocyclopentadiene	ND		ug/kg	510	160	1
Hexachloroethane	ND		ug/kg	140	29.	1
Isophorone	ND		ug/kg	160	23.	1
Naphthalene	ND		ug/kg	180	22.	1
Nitrobenzene	ND		ug/kg	160	26.	1
NDPA/DPA	ND		ug/kg	140	20.	1
n-Nitrosodi-n-propylamine	ND		ug/kg	180	28.	1
Bis(2-ethylhexyl)phthalate	ND		ug/kg	180	62.	1
Butyl benzyl phthalate	ND		ug/kg	180	45.	1
Di-n-butylphthalate	ND		ug/kg	180	34.	1
Di-n-octylphthalate	ND		ug/kg	180	61.	1

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-02 Date Collected: 06/05/23 11:15

Client ID: SB-21G (9-9.5) Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Diethyl phthalate	ND		ug/kg	180	17.	1
Dimethyl phthalate	ND		ug/kg	180	38.	1
Benzo(a)anthracene	33	J	ug/kg	110	20.	1
Benzo(a)pyrene	ND		ug/kg	140	44.	1
Benzo(b)fluoranthene	43	J	ug/kg	110	30.	1
Benzo(k)fluoranthene	ND		ug/kg	110	29.	1
Chrysene	29	J	ug/kg	110	19.	1
Acenaphthylene	ND		ug/kg	140	28.	1
Anthracene	ND		ug/kg	110	35.	1
Benzo(ghi)perylene	ND		ug/kg	140	21.	1
Fluorene	ND		ug/kg	180	17.	1
Phenanthrene	28	J	ug/kg	110	22.	1
Dibenzo(a,h)anthracene	ND		ug/kg	110	21.	1
Indeno(1,2,3-cd)pyrene	ND		ug/kg	140	25.	1
Pyrene	48	J	ug/kg	110	18.	1
Biphenyl	ND		ug/kg	410	23.	1
4-Chloroaniline	ND		ug/kg	180	33.	1
2-Nitroaniline	ND		ug/kg	180	35.	1
3-Nitroaniline	ND		ug/kg	180	34.	1
4-Nitroaniline	ND		ug/kg	180	74.	1
Dibenzofuran	ND		ug/kg	180	17.	1
2-Methylnaphthalene	ND		ug/kg	220	22.	1
1,2,4,5-Tetrachlorobenzene	ND		ug/kg	180	19.	1
Acetophenone	ND		ug/kg	180	22.	1
2,4,6-Trichlorophenol	ND		ug/kg	110	34.	1
p-Chloro-m-cresol	ND		ug/kg	180	27.	1
2-Chlorophenol	ND		ug/kg	180	21.	1
2,4-Dichlorophenol	ND		ug/kg	160	29.	1
2,4-Dimethylphenol	ND		ug/kg	180	59.	1
2-Nitrophenol	ND		ug/kg	390	68.	1
4-Nitrophenol	ND		ug/kg	250	73.	1
2,4-Dinitrophenol	ND		ug/kg	860	84.	1
4,6-Dinitro-o-cresol	ND		ug/kg	470	86.	1
Pentachlorophenol	ND		ug/kg	140	40.	1
Phenol	ND		ug/kg	180	27.	1
2-Methylphenol	ND		ug/kg	180	28.	1
3-Methylphenol/4-Methylphenol	ND		ug/kg	260	28.	1

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-02 Date Collected: 06/05/23 11:15

Client ID: SB-21G (9-9.5) Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
2,4,5-Trichlorophenol	ND		ug/kg	180	34.	1
Benzoic Acid	ND		ug/kg	580	180	1
Benzyl Alcohol	ND		ug/kg	180	55.	1
Carbazole	ND		ug/kg	180	17.	1
1,4-Dioxane	ND		ug/kg	27	8.2	1
Tentatively Identified Compounds						
Total TIC Compounds	29300	J	ug/kg			1
Unknown	436	J	ug/kg			1
Unknown	422	J	ug/kg			1
Unknown Phenol	1730	J	ug/kg			1
Unknown	509	J	ug/kg			1
Unknown	820	J	ug/kg			1
Unknown	1670	J	ug/kg			1
Unknown	486	J	ug/kg			1
Unknown	362	J	ug/kg			1
Unknown	1730	J	ug/kg			1
Unknown	19800	J	ug/kg			1
Unknown	392	J	ug/kg			1
Unknown	593	J	ug/kg			1
Unknown	380	J	ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	85		25-120
Phenol-d6	75		10-120
Nitrobenzene-d5	85		23-120
2-Fluorobiphenyl	72		30-120
2,4,6-Tribromophenol	76		10-136
4-Terphenyl-d14	73		18-120

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-03
Client ID: SB-21G (12-12.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 11:20
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8270E
Analytical Date: 06/07/23 16:18
Analyst: EK
Percent Solids: 82%

Extraction Method: EPA 3546
Extraction Date: 06/06/23 15:48

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Acenaphthene	ND		ug/kg	160	21.	1
1,2,4-Trichlorobenzene	ND		ug/kg	200	23.	1
Hexachlorobenzene	ND		ug/kg	120	23.	1
Bis(2-chloroethyl)ether	ND		ug/kg	180	27.	1
2-Chloronaphthalene	ND		ug/kg	200	20.	1
1,2-Dichlorobenzene	ND		ug/kg	200	36.	1
1,3-Dichlorobenzene	ND		ug/kg	200	35.	1
1,4-Dichlorobenzene	ND		ug/kg	200	35.	1
3,3'-Dichlorobenzidine	ND		ug/kg	200	54.	1
2,4-Dinitrotoluene	ND		ug/kg	200	40.	1
2,6-Dinitrotoluene	ND		ug/kg	200	35.	1
Fluoranthene	ND		ug/kg	120	23.	1
4-Chlorophenyl phenyl ether	ND		ug/kg	200	22.	1
4-Bromophenyl phenyl ether	ND		ug/kg	200	31.	1
Bis(2-chloroisopropyl)ether	ND		ug/kg	240	34.	1
Bis(2-chloroethoxy)methane	ND		ug/kg	220	20.	1
Hexachlorobutadiene	ND		ug/kg	200	30.	1
Hexachlorocyclopentadiene	ND		ug/kg	580	180	1
Hexachloroethane	ND		ug/kg	160	33.	1
Isophorone	ND		ug/kg	180	26.	1
Naphthalene	ND		ug/kg	200	24.	1
Nitrobenzene	ND		ug/kg	180	30.	1
NDPA/DPA	ND		ug/kg	160	23.	1
n-Nitrosodi-n-propylamine	ND		ug/kg	200	31.	1
Bis(2-ethylhexyl)phthalate	ND		ug/kg	200	70.	1
Butyl benzyl phthalate	ND		ug/kg	200	51.	1
Di-n-butylphthalate	ND		ug/kg	200	38.	1
Di-n-octylphthalate	ND		ug/kg	200	69.	1

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-03 Date Collected: 06/05/23 11:20

Client ID: SB-21G (12-12.5) Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Diethyl phthalate	ND		ug/kg	200	19.	1
Dimethyl phthalate	ND		ug/kg	200	42.	1
Benzo(a)anthracene	ND		ug/kg	120	23.	1
Benzo(a)pyrene	ND		ug/kg	160	49.	1
Benzo(b)fluoranthene	ND		ug/kg	120	34.	1
Benzo(k)fluoranthene	ND		ug/kg	120	32.	1
Chrysene	ND		ug/kg	120	21.	1
Acenaphthylene	ND		ug/kg	160	31.	1
Anthracene	ND		ug/kg	120	39.	1
Benzo(ghi)perylene	ND		ug/kg	160	24.	1
Fluorene	ND		ug/kg	200	20.	1
Phenanthrene	ND		ug/kg	120	24.	1
Dibenzo(a,h)anthracene	ND		ug/kg	120	23.	1
Indeno(1,2,3-cd)pyrene	ND		ug/kg	160	28.	1
Pyrene	ND		ug/kg	120	20.	1
Biphenyl	ND		ug/kg	460	26.	1
4-Chloroaniline	ND		ug/kg	200	37.	1
2-Nitroaniline	ND		ug/kg	200	39.	1
3-Nitroaniline	ND		ug/kg	200	38.	1
4-Nitroaniline	ND		ug/kg	200	84.	1
Dibenzofuran	ND		ug/kg	200	19.	1
2-Methylnaphthalene	ND		ug/kg	240	24.	1
1,2,4,5-Tetrachlorobenzene	ND		ug/kg	200	21.	1
Acetophenone	ND		ug/kg	200	25.	1
2,4,6-Trichlorophenol	ND		ug/kg	120	38.	1
p-Chloro-m-cresol	ND		ug/kg	200	30.	1
2-Chlorophenol	ND		ug/kg	200	24.	1
2,4-Dichlorophenol	ND		ug/kg	180	32.	1
2,4-Dimethylphenol	ND		ug/kg	200	66.	1
2-Nitrophenol	ND		ug/kg	440	76.	1
4-Nitrophenol	ND		ug/kg	280	82.	1
2,4-Dinitrophenol	ND		ug/kg	970	94.	1
4,6-Dinitro-o-cresol	ND		ug/kg	520	97.	1
Pentachlorophenol	ND		ug/kg	160	44.	1
Phenol	ND		ug/kg	200	30.	1
2-Methylphenol	ND		ug/kg	200	31.	1
3-Methylphenol/4-Methylphenol	ND		ug/kg	290	32.	1

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-03 Date Collected: 06/05/23 11:20

Client ID: SB-21G (12-12.5) Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
2,4,5-Trichlorophenol	ND		ug/kg	200	39.	1
Benzoic Acid	ND		ug/kg	650	200	1
Benzyl Alcohol	ND		ug/kg	200	62.	1
Carbazole	ND		ug/kg	200	20.	1
1,4-Dioxane	ND		ug/kg	30	9.3	1
Tentatively Identified Compounds						
No Tentatively Identified Compounds	ND		ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	72		25-120
Phenol-d6	63		10-120
Nitrobenzene-d5	66		23-120
2-Fluorobiphenyl	67		30-120
2,4,6-Tribromophenol	72		10-136
4-Terphenyl-d14	51		18-120

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-04
Client ID: SB-22G (7-7.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 12:15
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8270E
Analytical Date: 06/07/23 16:35
Analyst: EK
Percent Solids: 80%

Extraction Method: EPA 3546
Extraction Date: 06/06/23 15:48

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Acenaphthene	ND		ug/kg	170	22.	1
1,2,4-Trichlorobenzene	ND		ug/kg	210	24.	1
Hexachlorobenzene	ND		ug/kg	120	23.	1
Bis(2-chloroethyl)ether	ND		ug/kg	190	28.	1
2-Chloronaphthalene	ND		ug/kg	210	21.	1
1,2-Dichlorobenzene	ND		ug/kg	210	38.	1
1,3-Dichlorobenzene	ND		ug/kg	210	36.	1
1,4-Dichlorobenzene	ND		ug/kg	210	36.	1
3,3'-Dichlorobenzidine	ND		ug/kg	210	56.	1
2,4-Dinitrotoluene	ND		ug/kg	210	42.	1
2,6-Dinitrotoluene	ND		ug/kg	210	36.	1
Fluoranthene	27	J	ug/kg	120	24.	1
4-Chlorophenyl phenyl ether	ND		ug/kg	210	22.	1
4-Bromophenyl phenyl ether	ND		ug/kg	210	32.	1
Bis(2-chloroisopropyl)ether	ND		ug/kg	250	36.	1
Bis(2-chloroethoxy)methane	ND		ug/kg	230	21.	1
Hexachlorobutadiene	ND		ug/kg	210	31.	1
Hexachlorocyclopentadiene	ND		ug/kg	600	190	1
Hexachloroethane	ND		ug/kg	170	34.	1
Isophorone	ND		ug/kg	190	27.	1
Naphthalene	ND		ug/kg	210	25.	1
Nitrobenzene	ND		ug/kg	190	31.	1
NDPA/DPA	ND		ug/kg	170	24.	1
n-Nitrosodi-n-propylamine	ND		ug/kg	210	32.	1
Bis(2-ethylhexyl)phthalate	ND		ug/kg	210	72.	1
Butyl benzyl phthalate	ND		ug/kg	210	53.	1
Di-n-butylphthalate	ND		ug/kg	210	40.	1
Di-n-octylphthalate	ND		ug/kg	210	71.	1

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-04 Date Collected: 06/05/23 12:15

Client ID: SB-22G (7-7.5) Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Diethyl phthalate	ND		ug/kg	210	19.	1
Dimethyl phthalate	ND		ug/kg	210	44.	1
Benzo(a)anthracene	ND		ug/kg	120	24.	1
Benzo(a)pyrene	ND		ug/kg	170	51.	1
Benzo(b)fluoranthene	ND		ug/kg	120	35.	1
Benzo(k)fluoranthene	ND		ug/kg	120	33.	1
Chrysene	ND		ug/kg	120	22.	1
Acenaphthylene	ND		ug/kg	170	32.	1
Anthracene	140		ug/kg	120	41.	1
Benzo(ghi)perylene	ND		ug/kg	170	25.	1
Fluorene	410		ug/kg	210	20.	1
Phenanthrene	890		ug/kg	120	25.	1
Dibenzo(a,h)anthracene	ND		ug/kg	120	24.	1
Indeno(1,2,3-cd)pyrene	ND		ug/kg	170	29.	1
Pyrene	50	J	ug/kg	120	21.	1
Biphenyl	ND		ug/kg	480	27.	1
4-Chloroaniline	ND		ug/kg	210	38.	1
2-Nitroaniline	ND		ug/kg	210	40.	1
3-Nitroaniline	ND		ug/kg	210	39.	1
4-Nitroaniline	ND		ug/kg	210	87.	1
Dibenzofuran	160	J	ug/kg	210	20.	1
2-Methylnaphthalene	ND		ug/kg	250	25.	1
1,2,4,5-Tetrachlorobenzene	ND		ug/kg	210	22.	1
Acetophenone	ND		ug/kg	210	26.	1
2,4,6-Trichlorophenol	ND		ug/kg	120	40.	1
p-Chloro-m-cresol	ND		ug/kg	210	31.	1
2-Chlorophenol	ND		ug/kg	210	25.	1
2,4-Dichlorophenol	ND		ug/kg	190	34.	1
2,4-Dimethylphenol	ND		ug/kg	210	69.	1
2-Nitrophenol	ND		ug/kg	450	79.	1
4-Nitrophenol	ND		ug/kg	290	85.	1
2,4-Dinitrophenol	ND		ug/kg	1000	98.	1
4,6-Dinitro-o-cresol	ND		ug/kg	540	100	1
Pentachlorophenol	ND		ug/kg	170	46.	1
Phenol	ND		ug/kg	210	32.	1
2-Methylphenol	ND		ug/kg	210	32.	1
3-Methylphenol/4-Methylphenol	ND		ug/kg	300	33.	1

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-04 Date Collected: 06/05/23 12:15

Client ID: SB-22G (7-7.5) Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
2,4,5-Trichlorophenol	ND		ug/kg	210	40.	1
Benzoic Acid	ND		ug/kg	680	210	1
Benzyl Alcohol	ND		ug/kg	210	64.	1
Carbazole	ND		ug/kg	210	20.	1
1,4-Dioxane	ND		ug/kg	31	9.6	1
Tentatively Identified Compounds						
Total TIC Compounds	14400	J	ug/kg			1
Unknown Alkane	340	J	ug/kg			1
Unknown Naphthalene	357	J	ug/kg			1
Unknown Alkane	1100	J	ug/kg			1
Unknown Alkane	2650	J	ug/kg			1
Unknown	576	J	ug/kg			1
Unknown Alkane	1670	J	ug/kg			1
Unknown	382	J	ug/kg			1
Unknown Alkane	1670	J	ug/kg			1
Unknown Alkane	3960	J	ug/kg			1
Unknown	574	J	ug/kg			1
Unknown	217	J	ug/kg			1
Unknown	901	J	ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	53		25-120
Phenol-d6	55		10-120
Nitrobenzene-d5	56		23-120
2-Fluorobiphenyl	58		30-120
2,4,6-Tribromophenol	52		10-136
4-Terphenyl-d14	60		18-120

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-05
Client ID: SB-23G (9.5-10)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 12:50
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8270E
Analytical Date: 06/07/23 16:52
Analyst: EK
Percent Solids: 87%

Extraction Method: EPA 3546
Extraction Date: 06/06/23 15:48

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Acenaphthene	ND		ug/kg	150	19.	1
1,2,4-Trichlorobenzene	ND		ug/kg	190	21.	1
Hexachlorobenzene	ND		ug/kg	110	21.	1
Bis(2-chloroethyl)ether	ND		ug/kg	170	25.	1
2-Chloronaphthalene	ND		ug/kg	190	18.	1
1,2-Dichlorobenzene	ND		ug/kg	190	34.	1
1,3-Dichlorobenzene	ND		ug/kg	190	32.	1
1,4-Dichlorobenzene	ND		ug/kg	190	33.	1
3,3'-Dichlorobenzidine	ND		ug/kg	190	50.	1
2,4-Dinitrotoluene	ND		ug/kg	190	37.	1
2,6-Dinitrotoluene	ND		ug/kg	190	32.	1
Fluoranthene	ND		ug/kg	110	21.	1
4-Chlorophenyl phenyl ether	ND		ug/kg	190	20.	1
4-Bromophenyl phenyl ether	ND		ug/kg	190	28.	1
Bis(2-chloroisopropyl)ether	ND		ug/kg	220	32.	1
Bis(2-chloroethoxy)methane	ND		ug/kg	200	19.	1
Hexachlorobutadiene	ND		ug/kg	190	27.	1
Hexachlorocyclopentadiene	ND		ug/kg	530	170	1
Hexachloroethane	ND		ug/kg	150	30.	1
Isophorone	ND		ug/kg	170	24.	1
Naphthalene	ND		ug/kg	190	23.	1
Nitrobenzene	ND		ug/kg	170	28.	1
NDPA/DPA	ND		ug/kg	150	21.	1
n-Nitrosodi-n-propylamine	ND		ug/kg	190	29.	1
Bis(2-ethylhexyl)phthalate	ND		ug/kg	190	65.	1
Butyl benzyl phthalate	ND		ug/kg	190	47.	1
Di-n-butylphthalate	ND		ug/kg	190	35.	1
Di-n-octylphthalate	ND		ug/kg	190	64.	1

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-05 Date Collected: 06/05/23 12:50

Client ID: SB-23G (9.5-10) Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Diethyl phthalate	ND		ug/kg	190	17.	1
Dimethyl phthalate	ND		ug/kg	190	39.	1
Benzo(a)anthracene	ND		ug/kg	110	21.	1
Benzo(a)pyrene	ND		ug/kg	150	46.	1
Benzo(b)fluoranthene	ND		ug/kg	110	31.	1
Benzo(k)fluoranthene	ND		ug/kg	110	30.	1
Chrysene	ND		ug/kg	110	19.	1
Acenaphthylene	ND		ug/kg	150	29.	1
Anthracene	ND		ug/kg	110	36.	1
Benzo(ghi)perylene	ND		ug/kg	150	22.	1
Fluorene	ND		ug/kg	190	18.	1
Phenanthrene	ND		ug/kg	110	23.	1
Dibenzo(a,h)anthracene	ND		ug/kg	110	22.	1
Indeno(1,2,3-cd)pyrene	ND		ug/kg	150	26.	1
Pyrene	ND		ug/kg	110	18.	1
Biphenyl	ND		ug/kg	430	24.	1
4-Chloroaniline	ND		ug/kg	190	34.	1
2-Nitroaniline	ND		ug/kg	190	36.	1
3-Nitroaniline	ND		ug/kg	190	35.	1
4-Nitroaniline	ND		ug/kg	190	77.	1
Dibenzofuran	ND		ug/kg	190	18.	1
2-Methylnaphthalene	ND		ug/kg	220	22.	1
1,2,4,5-Tetrachlorobenzene	ND		ug/kg	190	20.	1
Acetophenone	ND		ug/kg	190	23.	1
2,4,6-Trichlorophenol	ND		ug/kg	110	35.	1
p-Chloro-m-cresol	ND		ug/kg	190	28.	1
2-Chlorophenol	ND		ug/kg	190	22.	1
2,4-Dichlorophenol	ND		ug/kg	170	30.	1
2,4-Dimethylphenol	ND		ug/kg	190	62.	1
2-Nitrophenol	ND		ug/kg	400	70.	1
4-Nitrophenol	ND		ug/kg	260	76.	1
2,4-Dinitrophenol	ND		ug/kg	900	87.	1
4,6-Dinitro-o-cresol	ND		ug/kg	490	90.	1
Pentachlorophenol	ND		ug/kg	150	41.	1
Phenol	ND		ug/kg	190	28.	1
2-Methylphenol	ND		ug/kg	190	29.	1
3-Methylphenol/4-Methylphenol	ND		ug/kg	270	29.	1

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-05 Date Collected: 06/05/23 12:50

Client ID: SB-23G (9.5-10) Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
2,4,5-Trichlorophenol	ND		ug/kg	190	36.	1
Benzoic Acid	ND		ug/kg	600	190	1
Benzyl Alcohol	ND		ug/kg	190	57.	1
Carbazole	ND		ug/kg	190	18.	1
1,4-Dioxane	ND		ug/kg	28	8.6	1
Tentatively Identified Compounds						
No Tentatively Identified Compounds	ND		ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	84		25-120
Phenol-d6	78		10-120
Nitrobenzene-d5	77		23-120
2-Fluorobiphenyl	83		30-120
2,4,6-Tribromophenol	82		10-136
4-Terphenyl-d14	72		18-120

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-06
Client ID: SB-24G (7.5-8)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 12:30
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8270E
Analytical Date: 06/07/23 17:08
Analyst: EK
Percent Solids: 85%

Extraction Method: EPA 3546
Extraction Date: 06/06/23 15:48

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Acenaphthene	ND		ug/kg	150	20.	1
1,2,4-Trichlorobenzene	ND		ug/kg	190	22.	1
Hexachlorobenzene	ND		ug/kg	120	22.	1
Bis(2-chloroethyl)ether	ND		ug/kg	170	26.	1
2-Chloronaphthalene	ND		ug/kg	190	19.	1
1,2-Dichlorobenzene	ND		ug/kg	190	35.	1
1,3-Dichlorobenzene	ND		ug/kg	190	33.	1
1,4-Dichlorobenzene	ND		ug/kg	190	34.	1
3,3'-Dichlorobenzidine	ND		ug/kg	190	51.	1
2,4-Dinitrotoluene	ND		ug/kg	190	39.	1
2,6-Dinitrotoluene	ND		ug/kg	190	33.	1
Fluoranthene	100	J	ug/kg	120	22.	1
4-Chlorophenyl phenyl ether	ND		ug/kg	190	21.	1
4-Bromophenyl phenyl ether	ND		ug/kg	190	30.	1
Bis(2-chloroisopropyl)ether	ND		ug/kg	230	33.	1
Bis(2-chloroethoxy)methane	ND		ug/kg	210	19.	1
Hexachlorobutadiene	ND		ug/kg	190	28.	1
Hexachlorocyclopentadiene	ND		ug/kg	550	180	1
Hexachloroethane	ND		ug/kg	150	31.	1
Isophorone	ND		ug/kg	170	25.	1
Naphthalene	ND		ug/kg	190	24.	1
Nitrobenzene	ND		ug/kg	170	29.	1
NDPA/DPA	ND		ug/kg	150	22.	1
n-Nitrosodi-n-propylamine	ND		ug/kg	190	30.	1
Bis(2-ethylhexyl)phthalate	ND		ug/kg	190	67.	1
Butyl benzyl phthalate	ND		ug/kg	190	49.	1
Di-n-butylphthalate	ND		ug/kg	190	37.	1
Di-n-octylphthalate	ND		ug/kg	190	66.	1

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-06 Date Collected: 06/05/23 12:30

Client ID: SB-24G (7.5-8) Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Diethyl phthalate	ND		ug/kg	190	18.	1
Dimethyl phthalate	ND		ug/kg	190	40.	1
Benzo(a)anthracene	66	J	ug/kg	120	22.	1
Benzo(a)pyrene	62	J	ug/kg	150	47.	1
Benzo(b)fluoranthene	70	J	ug/kg	120	32.	1
Benzo(k)fluoranthene	ND		ug/kg	120	31.	1
Chrysene	57	J	ug/kg	120	20.	1
Acenaphthylene	ND		ug/kg	150	30.	1
Anthracene	ND		ug/kg	120	38.	1
Benzo(ghi)perylene	43	J	ug/kg	150	23.	1
Fluorene	ND		ug/kg	190	19.	1
Phenanthrene	49	J	ug/kg	120	24.	1
Dibenzo(a,h)anthracene	ND		ug/kg	120	22.	1
Indeno(1,2,3-cd)pyrene	30	J	ug/kg	150	27.	1
Pyrene	120		ug/kg	120	19.	1
Biphenyl	ND		ug/kg	440	25.	1
4-Chloroaniline	ND		ug/kg	190	35.	1
2-Nitroaniline	ND		ug/kg	190	37.	1
3-Nitroaniline	ND		ug/kg	190	36.	1
4-Nitroaniline	ND		ug/kg	190	80.	1
Dibenzofuran	ND		ug/kg	190	18.	1
2-Methylnaphthalene	ND		ug/kg	230	23.	1
1,2,4,5-Tetrachlorobenzene	ND		ug/kg	190	20.	1
Acetophenone	ND		ug/kg	190	24.	1
2,4,6-Trichlorophenol	ND		ug/kg	120	37.	1
p-Chloro-m-cresol	ND		ug/kg	190	29.	1
2-Chlorophenol	ND		ug/kg	190	23.	1
2,4-Dichlorophenol	ND		ug/kg	170	31.	1
2,4-Dimethylphenol	ND		ug/kg	190	64.	1
2-Nitrophenol	ND		ug/kg	420	73.	1
4-Nitrophenol	ND		ug/kg	270	79.	1
2,4-Dinitrophenol	ND		ug/kg	930	90.	1
4,6-Dinitro-o-cresol	ND		ug/kg	500	93.	1
Pentachlorophenol	ND		ug/kg	150	42.	1
Phenol	ND		ug/kg	190	29.	1
2-Methylphenol	ND		ug/kg	190	30.	1
3-Methylphenol/4-Methylphenol	ND		ug/kg	280	30.	1

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-06 Date Collected: 06/05/23 12:30

Client ID: SB-24G (7.5-8) Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
2,4,5-Trichlorophenol	ND		ug/kg	190	37.	1
Benzoic Acid	ND		ug/kg	630	200	1
Benzyl Alcohol	ND		ug/kg	190	59.	1
Carbazole	ND		ug/kg	190	19.	1
1,4-Dioxane	ND		ug/kg	29	8.9	1
Tentatively Identified Compounds						
No Tentatively Identified Compounds	ND		ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	68		25-120
Phenol-d6	63		10-120
Nitrobenzene-d5	67		23-120
2-Fluorobiphenyl	61		30-120
2,4,6-Tribromophenol	68		10-136
4-Terphenyl-d14	59		18-120

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-07
Client ID: SB-25G (9.5-10)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 10:40
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8270E
Analytical Date: 06/07/23 17:25
Analyst: EK
Percent Solids: 92%

Extraction Method: EPA 3546
Extraction Date: 06/06/23 15:48

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Acenaphthene	ND		ug/kg	140	19.	1
1,2,4-Trichlorobenzene	ND		ug/kg	180	21.	1
Hexachlorobenzene	ND		ug/kg	110	20.	1
Bis(2-chloroethyl)ether	ND		ug/kg	160	25.	1
2-Chloronaphthalene	ND		ug/kg	180	18.	1
1,2-Dichlorobenzene	ND		ug/kg	180	32.	1
1,3-Dichlorobenzene	ND		ug/kg	180	31.	1
1,4-Dichlorobenzene	ND		ug/kg	180	32.	1
3,3'-Dichlorobenzidine	ND		ug/kg	180	48.	1
2,4-Dinitrotoluene	ND		ug/kg	180	36.	1
2,6-Dinitrotoluene	ND		ug/kg	180	31.	1
Fluoranthene	270		ug/kg	110	21.	1
4-Chlorophenyl phenyl ether	ND		ug/kg	180	19.	1
4-Bromophenyl phenyl ether	ND		ug/kg	180	28.	1
Bis(2-chloroisopropyl)ether	ND		ug/kg	220	31.	1
Bis(2-chloroethoxy)methane	ND		ug/kg	200	18.	1
Hexachlorobutadiene	ND		ug/kg	180	26.	1
Hexachlorocyclopentadiene	ND		ug/kg	520	160	1
Hexachloroethane	ND		ug/kg	140	29.	1
Isophorone	ND		ug/kg	160	24.	1
Naphthalene	ND		ug/kg	180	22.	1
Nitrobenzene	ND		ug/kg	160	27.	1
NDPA/DPA	ND		ug/kg	140	21.	1
n-Nitrosodi-n-propylamine	ND		ug/kg	180	28.	1
Bis(2-ethylhexyl)phthalate	ND		ug/kg	180	63.	1
Butyl benzyl phthalate	ND		ug/kg	180	46.	1
Di-n-butylphthalate	ND		ug/kg	180	34.	1
Di-n-octylphthalate	ND		ug/kg	180	62.	1

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-07 Date Collected: 06/05/23 10:40

Client ID: SB-25G (9.5-10) Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Diethyl phthalate	ND		ug/kg	180	17.	1
Dimethyl phthalate	ND		ug/kg	180	38.	1
Benzo(a)anthracene	130		ug/kg	110	20.	1
Benzo(a)pyrene	140		ug/kg	140	44.	1
Benzo(b)fluoranthene	160		ug/kg	110	30.	1
Benzo(k)fluoranthene	78	J	ug/kg	110	29.	1
Chrysene	120		ug/kg	110	19.	1
Acenaphthylene	36	J	ug/kg	140	28.	1
Anthracene	39	J	ug/kg	110	35.	1
Benzo(ghi)perylene	100	J	ug/kg	140	21.	1
Fluorene	ND		ug/kg	180	18.	1
Phenanthrene	150		ug/kg	110	22.	1
Dibenzo(a,h)anthracene	25	J	ug/kg	110	21.	1
Indeno(1,2,3-cd)pyrene	86	J	ug/kg	140	25.	1
Pyrene	240		ug/kg	110	18.	1
Biphenyl	ND		ug/kg	410	24.	1
4-Chloroaniline	ND		ug/kg	180	33.	1
2-Nitroaniline	ND		ug/kg	180	35.	1
3-Nitroaniline	ND		ug/kg	180	34.	1
4-Nitroaniline	ND		ug/kg	180	75.	1
Dibenzofuran	ND		ug/kg	180	17.	1
2-Methylnaphthalene	ND		ug/kg	220	22.	1
1,2,4,5-Tetrachlorobenzene	ND		ug/kg	180	19.	1
Acetophenone	ND		ug/kg	180	22.	1
2,4,6-Trichlorophenol	ND		ug/kg	110	34.	1
p-Chloro-m-cresol	ND		ug/kg	180	27.	1
2-Chlorophenol	ND		ug/kg	180	21.	1
2,4-Dichlorophenol	ND		ug/kg	160	29.	1
2,4-Dimethylphenol	ND		ug/kg	180	60.	1
2-Nitrophenol	ND		ug/kg	390	68.	1
4-Nitrophenol	ND		ug/kg	250	74.	1
2,4-Dinitrophenol	ND		ug/kg	870	84.	1
4,6-Dinitro-o-cresol	ND		ug/kg	470	87.	1
Pentachlorophenol	ND		ug/kg	140	40.	1
Phenol	ND		ug/kg	180	27.	1
2-Methylphenol	ND		ug/kg	180	28.	1
3-Methylphenol/4-Methylphenol	ND		ug/kg	260	28.	1

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-07 Date Collected: 06/05/23 10:40

Client ID: SB-25G (9.5-10) Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
2,4,5-Trichlorophenol	ND		ug/kg	180	35.	1
Benzoic Acid	ND		ug/kg	590	180	1
Benzyl Alcohol	ND		ug/kg	180	56.	1
Carbazole	26	J	ug/kg	180	18.	1
1,4-Dioxane	ND		ug/kg	27	8.3	1
Tentatively Identified Compounds						
Total TIC Compounds	662	J	ug/kg			1
Unknown	662	J	ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	**18**	Q	25-120
Phenol-d6	56		10-120
Nitrobenzene-d5	81		23-120
2-Fluorobiphenyl	72		30-120
2,4,6-Tribromophenol	10		10-136
4-Terphenyl-d14	74		18-120

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-08
Client ID: GW-10
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 12:00
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E
Analytical Date: 06/10/23 12:34
Analyst: CMM

Extraction Method: EPA 3510C
Extraction Date: 06/08/23 11:26

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
1,2,4-Trichlorobenzene	ND		ug/l	5.0	0.50	1
Bis(2-chloroethyl)ether	ND		ug/l	2.0	0.50	1
1,2-Dichlorobenzene	ND		ug/l	2.0	0.45	1
1,3-Dichlorobenzene	ND		ug/l	2.0	0.40	1
1,4-Dichlorobenzene	ND		ug/l	2.0	0.43	1
3,3'-Dichlorobenzidine	ND		ug/l	5.0	1.6	1
2,4-Dinitrotoluene	ND		ug/l	5.0	1.2	1
2,6-Dinitrotoluene	ND		ug/l	5.0	0.93	1
4-Chlorophenyl phenyl ether	ND		ug/l	2.0	0.49	1
4-Bromophenyl phenyl ether	ND		ug/l	2.0	0.38	1
Bis(2-chloroisopropyl)ether	ND		ug/l	2.0	0.53	1
Bis(2-chloroethoxy)methane	ND		ug/l	5.0	0.50	1
Hexachlorocyclopentadiene	ND		ug/l	20	0.69	1
Isophorone	ND		ug/l	5.0	1.2	1
Nitrobenzene	ND		ug/l	2.0	0.77	1
NDPA/DPA	ND		ug/l	2.0	0.42	1
n-Nitrosodi-n-propylamine	ND		ug/l	5.0	0.64	1
Bis(2-ethylhexyl)phthalate	ND		ug/l	3.0	1.5	1
Butyl benzyl phthalate	ND		ug/l	5.0	1.2	1
Di-n-butylphthalate	ND		ug/l	5.0	0.39	1
Di-n-octylphthalate	ND		ug/l	5.0	1.3	1
Diethyl phthalate	ND		ug/l	5.0	0.38	1
Dimethyl phthalate	ND		ug/l	5.0	1.8	1
Biphenyl	ND		ug/l	2.0	0.46	1
4-Chloroaniline	ND		ug/l	5.0	1.1	1
2-Nitroaniline	ND		ug/l	5.0	0.50	1
3-Nitroaniline	ND		ug/l	5.0	0.81	1
4-Nitroaniline	ND		ug/l	5.0	0.80	1

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-08 Date Collected: 06/05/23 12:00

Client ID: GW-10 Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Dibenzofuran	ND		ug/l	2.0	0.50	1
1,2,4,5-Tetrachlorobenzene	ND		ug/l	10	0.44	1
Acetophenone	ND		ug/l	5.0	0.53	1
2,4,6-Trichlorophenol	ND		ug/l	5.0	0.61	1
p-Chloro-m-cresol	ND		ug/l	2.0	0.35	1
2-Chlorophenol	ND		ug/l	2.0	0.48	1
2,4-Dichlorophenol	ND		ug/l	5.0	0.41	1
2,4-Dimethylphenol	ND		ug/l	5.0	1.8	1
2-Nitrophenol	ND		ug/l	10	0.85	1
4-Nitrophenol	ND		ug/l	10	0.67	1
2,4-Dinitrophenol	ND		ug/l	20	6.6	1
4,6-Dinitro-o-cresol	ND		ug/l	10	1.8	1
Phenol	ND		ug/l	5.0	0.57	1
2-Methylphenol	ND		ug/l	5.0	0.49	1
3-Methylphenol/4-Methylphenol	ND		ug/l	5.0	0.48	1
2,4,5-Trichlorophenol	ND		ug/l	5.0	0.77	1
Benzoic Acid	ND		ug/l	50	2.6	1
Benzyl Alcohol	ND		ug/l	2.0	0.59	1
Carbazole	ND		ug/l	2.0	0.49	1

Tentatively Identified Compounds				
Total TIC Compounds	67.2	J	ug/l	1
Unknown	7.16	J	ug/l	1
Cyclic Octaatomic Sulfur	3.16	NJ	ug/l	1
Unknown	3.38	J	ug/l	1
Unknown	11.2	J	ug/l	1
Unknown Organic Acid	7.34	J	ug/l	1
Unknown	1.71	J	ug/l	1
Unknown Organic Acid	14.5	J	ug/l	1
Unknown	4.87	J	ug/l	1
Unknown	2.44	J	ug/l	1
Unknown	11.4	J	ug/l	1

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-08 Date Collected: 06/05/23 12:00

Client ID: GW-10 Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	54		21-120
Phenol-d6	46		10-120
Nitrobenzene-d5	68		23-120
2-Fluorobiphenyl	81		15-120
2,4,6-Tribromophenol	99		10-120
4-Terphenyl-d14	72		41-149

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-08
Client ID: GW-10
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 12:00
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E-SIM
Analytical Date: 06/09/23 15:12
Analyst: AH

Extraction Method: EPA 3510C
Extraction Date: 06/08/23 11:26

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS-SIM - Westborough Lab						
Acenaphthene	0.04	J	ug/l	0.10	0.01	1
2-Chloronaphthalene	ND		ug/l	0.20	0.02	1
Fluoranthene	0.12		ug/l	0.10	0.02	1
Hexachlorobutadiene	ND		ug/l	0.50	0.05	1
Naphthalene	0.26		ug/l	0.10	0.05	1
Benzo(a)anthracene	0.03	J	ug/l	0.10	0.02	1
Benzo(a)pyrene	0.02	J	ug/l	0.10	0.02	1
Benzo(b)fluoranthene	0.02	J	ug/l	0.10	0.01	1
Benzo(k)fluoranthene	0.01	J	ug/l	0.10	0.01	1
Chrysene	0.03	J	ug/l	0.10	0.01	1
Acenaphthylene	0.02	J	ug/l	0.10	0.01	1
Anthracene	0.06	J	ug/l	0.10	0.01	1
Benzo(ghi)perylene	ND		ug/l	0.10	0.01	1
Fluorene	0.05	J	ug/l	0.10	0.01	1
Phenanthrene	0.25		ug/l	0.10	0.02	1
Dibenzo(a,h)anthracene	ND		ug/l	0.10	0.01	1
Indeno(1,2,3-cd)pyrene	ND		ug/l	0.10	0.01	1
Pyrene	0.14		ug/l	0.10	0.02	1
2-Methylnaphthalene	0.08	J	ug/l	0.10	0.02	1
Pentachlorophenol	ND		ug/l	0.80	0.01	1
Hexachlorobenzene	ND		ug/l	0.80	0.01	1
Hexachloroethane	ND		ug/l	0.80	0.06	1

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-08 Date Collected: 06/05/23 12:00

Client ID: GW-10 Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS-SIM - Westborough Lab						

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	49		21-120
Phenol-d6	45		10-120
Nitrobenzene-d5	69		23-120
2-Fluorobiphenyl	76		15-120
2,4,6-Tribromophenol	110		10-120
4-Terphenyl-d14	79		41-149

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-09
Client ID: GW-11
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 13:20
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E
Analytical Date: 06/10/23 12:57
Analyst: CMM

Extraction Method: EPA 3510C
Extraction Date: 06/08/23 11:26

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
1,2,4-Trichlorobenzene	ND		ug/l	5.0	0.50	1
Bis(2-chloroethyl)ether	ND		ug/l	2.0	0.50	1
1,2-Dichlorobenzene	ND		ug/l	2.0	0.45	1
1,3-Dichlorobenzene	ND		ug/l	2.0	0.40	1
1,4-Dichlorobenzene	ND		ug/l	2.0	0.43	1
3,3'-Dichlorobenzidine	ND		ug/l	5.0	1.6	1
2,4-Dinitrotoluene	ND		ug/l	5.0	1.2	1
2,6-Dinitrotoluene	ND		ug/l	5.0	0.93	1
4-Chlorophenyl phenyl ether	ND		ug/l	2.0	0.49	1
4-Bromophenyl phenyl ether	ND		ug/l	2.0	0.38	1
Bis(2-chloroisopropyl)ether	ND		ug/l	2.0	0.53	1
Bis(2-chloroethoxy)methane	ND		ug/l	5.0	0.50	1
Hexachlorocyclopentadiene	ND		ug/l	20	0.69	1
Isophorone	ND		ug/l	5.0	1.2	1
Nitrobenzene	ND		ug/l	2.0	0.77	1
NDPA/DPA	ND		ug/l	2.0	0.42	1
n-Nitrosodi-n-propylamine	ND		ug/l	5.0	0.64	1
Bis(2-ethylhexyl)phthalate	ND		ug/l	3.0	1.5	1
Butyl benzyl phthalate	ND		ug/l	5.0	1.2	1
Di-n-butylphthalate	ND		ug/l	5.0	0.39	1
Di-n-octylphthalate	ND		ug/l	5.0	1.3	1
Diethyl phthalate	ND		ug/l	5.0	0.38	1
Dimethyl phthalate	ND		ug/l	5.0	1.8	1
Biphenyl	ND		ug/l	2.0	0.46	1
4-Chloroaniline	ND		ug/l	5.0	1.1	1
2-Nitroaniline	ND		ug/l	5.0	0.50	1
3-Nitroaniline	ND		ug/l	5.0	0.81	1
4-Nitroaniline	ND		ug/l	5.0	0.80	1

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-09 Date Collected: 06/05/23 13:20

Client ID: GW-11 Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Dibenzofuran	ND		ug/l	2.0	0.50	1
1,2,4,5-Tetrachlorobenzene	ND		ug/l	10	0.44	1
Acetophenone	ND		ug/l	5.0	0.53	1
2,4,6-Trichlorophenol	ND		ug/l	5.0	0.61	1
p-Chloro-m-cresol	ND		ug/l	2.0	0.35	1
2-Chlorophenol	ND		ug/l	2.0	0.48	1
2,4-Dichlorophenol	ND		ug/l	5.0	0.41	1
2,4-Dimethylphenol	ND		ug/l	5.0	1.8	1
2-Nitrophenol	ND		ug/l	10	0.85	1
4-Nitrophenol	ND		ug/l	10	0.67	1
2,4-Dinitrophenol	ND		ug/l	20	6.6	1
4,6-Dinitro-o-cresol	ND		ug/l	10	1.8	1
Phenol	ND		ug/l	5.0	0.57	1
2-Methylphenol	ND		ug/l	5.0	0.49	1
3-Methylphenol/4-Methylphenol	ND		ug/l	5.0	0.48	1
2,4,5-Trichlorophenol	ND		ug/l	5.0	0.77	1
Benzoic Acid	ND		ug/l	50	2.6	1
Benzyl Alcohol	ND		ug/l	2.0	0.59	1
Carbazole	ND		ug/l	2.0	0.49	1

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-09 Date Collected: 06/05/23 13:20

Client ID: GW-11 Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Tentatively Identified Compounds						
Total TIC Compounds	66.1	J	ug/l			1
Unknown	2.00	J	ug/l			1
Unknown	3.53	J	ug/l			1
Unknown	2.44	J	ug/l			1
Unknown Organic Acid	9.05	J	ug/l			1
Unknown	3.93	J	ug/l			1
Unknown	6.65	J	ug/l			1
Unknown	10.2	J	ug/l			1
Unknown	1.49	J	ug/l			1
Unknown	10.3	J	ug/l			1
Unknown	1.96	J	ug/l			1
Unknown Organic Acid	14.5	J	ug/l			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	50		21-120
Phenol-d6	45		10-120
Nitrobenzene-d5	68		23-120
2-Fluorobiphenyl	81		15-120
2,4,6-Tribromophenol	95		10-120
4-Terphenyl-d14	79		41-149

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-09
Client ID: GW-11
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 13:20
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E-SIM
Analytical Date: 06/09/23 15:28
Analyst: AH

Extraction Method: EPA 3510C
Extraction Date: 06/08/23 11:26

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS-SIM - Westborough Lab						
Acenaphthene	ND		ug/l	0.10	0.01	1
2-Chloronaphthalene	ND		ug/l	0.20	0.02	1
Fluoranthene	0.05	J	ug/l	0.10	0.02	1
Hexachlorobutadiene	ND		ug/l	0.50	0.05	1
Naphthalene	ND		ug/l	0.10	0.05	1
Benzo(a)anthracene	0.02	J	ug/l	0.10	0.02	1
Benzo(a)pyrene	ND		ug/l	0.10	0.02	1
Benzo(b)fluoranthene	0.01	J	ug/l	0.10	0.01	1
Benzo(k)fluoranthene	0.01	J	ug/l	0.10	0.01	1
Chrysene	0.01	J	ug/l	0.10	0.01	1
Acenaphthylene	0.02	J	ug/l	0.10	0.01	1
Anthracene	0.03	J	ug/l	0.10	0.01	1
Benzo(ghi)perylene	ND		ug/l	0.10	0.01	1
Fluorene	0.03	J	ug/l	0.10	0.01	1
Phenanthrene	0.11		ug/l	0.10	0.02	1
Dibenzo(a,h)anthracene	ND		ug/l	0.10	0.01	1
Indeno(1,2,3-cd)pyrene	ND		ug/l	0.10	0.01	1
Pyrene	ND		ug/l	0.10	0.02	1
2-Methylnaphthalene	ND		ug/l	0.10	0.02	1
Pentachlorophenol	ND		ug/l	0.80	0.01	1
Hexachlorobenzene	0.03	J	ug/l	0.80	0.01	1
Hexachloroethane	ND		ug/l	0.80	0.06	1

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-09 Date Collected: 06/05/23 13:20

Client ID: GW-11 Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS-SIM - Westborough Lab						

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	47		21-120
Phenol-d6	43		10-120
Nitrobenzene-d5	70		23-120
2-Fluorobiphenyl	77		15-120
2,4,6-Tribromophenol	105		10-120
4-Terphenyl-d14	85		41-149

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331226
Report Date: 06/13/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 06/07/23 09:51
Analyst: SLR

Extraction Method: EPA 3546
Extraction Date: 06/06/23 15:47

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 01-07 Batch: WG1787902-1					
Acenaphthene	ND		ug/kg	130	17.
1,2,4-Trichlorobenzene	ND		ug/kg	160	18.
Hexachlorobenzene	ND		ug/kg	97	18.
Bis(2-chloroethyl)ether	ND		ug/kg	150	22.
2-Chloronaphthalene	ND		ug/kg	160	16.
1,2-Dichlorobenzene	ND		ug/kg	160	29.
1,3-Dichlorobenzene	ND		ug/kg	160	28.
1,4-Dichlorobenzene	ND		ug/kg	160	28.
3,3'-Dichlorobenzidine	ND		ug/kg	160	43.
2,4-Dinitrotoluene	ND		ug/kg	160	32.
2,6-Dinitrotoluene	ND		ug/kg	160	28.
Fluoranthene	ND		ug/kg	97	19.
4-Chlorophenyl phenyl ether	ND		ug/kg	160	17.
4-Bromophenyl phenyl ether	ND		ug/kg	160	25.
Bis(2-chloroisopropyl)ether	ND		ug/kg	190	28.
Bis(2-chloroethoxy)methane	ND		ug/kg	180	16.
Hexachlorobutadiene	ND		ug/kg	160	24.
Hexachlorocyclopentadiene	ND		ug/kg	460	150
Hexachloroethane	ND		ug/kg	130	26.
Isophorone	ND		ug/kg	150	21.
Naphthalene	ND		ug/kg	160	20.
Nitrobenzene	ND		ug/kg	150	24.
NDPA/DPA	ND		ug/kg	130	18.
n-Nitrosodi-n-propylamine	ND		ug/kg	160	25.
Bis(2-ethylhexyl)phthalate	ND		ug/kg	160	56.
Butyl benzyl phthalate	ND		ug/kg	160	41.
Di-n-butylphthalate	ND		ug/kg	160	31.
Di-n-octylphthalate	ND		ug/kg	160	55.
Diethyl phthalate	ND		ug/kg	160	15.

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331226
Report Date: 06/13/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 06/07/23 09:51
Analyst: SLR

Extraction Method: EPA 3546
Extraction Date: 06/06/23 15:47

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 01-07 Batch: WG1787902-1					
Dimethyl phthalate	ND		ug/kg	160	34.
Benzo(a)anthracene	ND		ug/kg	97	18.
Benzo(a)pyrene	ND		ug/kg	130	40.
Benzo(b)fluoranthene	ND		ug/kg	97	27.
Benzo(k)fluoranthene	ND		ug/kg	97	26.
Chrysene	ND		ug/kg	97	17.
Acenaphthylene	ND		ug/kg	130	25.
Anthracene	ND		ug/kg	97	32.
Benzo(ghi)perylene	ND		ug/kg	130	19.
Fluorene	ND		ug/kg	160	16.
Phenanthrene	ND		ug/kg	97	20.
Dibenzo(a,h)anthracene	ND		ug/kg	97	19.
Indeno(1,2,3-cd)pyrene	ND		ug/kg	130	23.
Pyrene	ND		ug/kg	97	16.
Biphenyl	ND		ug/kg	370	21.
4-Chloroaniline	ND		ug/kg	160	30.
2-Nitroaniline	ND		ug/kg	160	31.
3-Nitroaniline	ND		ug/kg	160	31.
4-Nitroaniline	ND		ug/kg	160	67.
Dibenzofuran	ND		ug/kg	160	15.
2-Methylnaphthalene	ND		ug/kg	190	20.
1,2,4,5-Tetrachlorobenzene	ND		ug/kg	160	17.
Acetophenone	ND		ug/kg	160	20.
2,4,6-Trichlorophenol	ND		ug/kg	97	31.
p-Chloro-m-cresol	ND		ug/kg	160	24.
2-Chlorophenol	ND		ug/kg	160	19.
2,4-Dichlorophenol	ND		ug/kg	150	26.
2,4-Dimethylphenol	ND		ug/kg	160	54.
2-Nitrophenol	ND		ug/kg	350	61.

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 06/07/23 09:51
Analyst: SLR

Extraction Method: EPA 3546
Extraction Date: 06/06/23 15:47

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 01-07 Batch: WG1787902-1					
4-Nitrophenol	ND		ug/kg	230	66.
2,4-Dinitrophenol	ND		ug/kg	780	76.
4,6-Dinitro-o-cresol	ND		ug/kg	420	78.
Pentachlorophenol	ND		ug/kg	130	36.
Phenol	ND		ug/kg	160	24.
2-Methylphenol	ND		ug/kg	160	25.
3-Methylphenol/4-Methylphenol	ND		ug/kg	230	25.
2,4,5-Trichlorophenol	ND		ug/kg	160	31.
Benzoic Acid	ND		ug/kg	520	160
Benzyl Alcohol	ND		ug/kg	160	50.
Carbazole	ND		ug/kg	160	16.
1,4-Dioxane	ND		ug/kg	24	7.5
Tentatively Identified Compounds					
No Tentatively Identified Compounds	ND		ug/kg		

Surrogate	%Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	77		25-120
Phenol-d6	74		10-120
Nitrobenzene-d5	80		23-120
2-Fluorobiphenyl	71		30-120
2,4,6-Tribromophenol	69		10-136
4-Terphenyl-d14	72		18-120

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331226
Report Date: 06/13/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 06/09/23 15:55
Analyst: JG

Extraction Method: EPA 3510C
Extraction Date: 06/08/23 11:26

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 08-09 Batch: WG1788810-1					
Acenaphthene	ND		ug/l	2.0	0.44
1,2,4-Trichlorobenzene	ND		ug/l	5.0	0.50
Hexachlorobenzene	ND		ug/l	2.0	0.46
Bis(2-chloroethyl)ether	ND		ug/l	2.0	0.50
2-Chloronaphthalene	ND		ug/l	2.0	0.44
1,2-Dichlorobenzene	ND		ug/l	2.0	0.45
1,3-Dichlorobenzene	ND		ug/l	2.0	0.40
1,4-Dichlorobenzene	ND		ug/l	2.0	0.43
3,3'-Dichlorobenzidine	ND		ug/l	5.0	1.6
2,4-Dinitrotoluene	ND		ug/l	5.0	1.2
2,6-Dinitrotoluene	ND		ug/l	5.0	0.93
Fluoranthene	ND		ug/l	2.0	0.26
4-Chlorophenyl phenyl ether	ND		ug/l	2.0	0.49
4-Bromophenyl phenyl ether	ND		ug/l	2.0	0.38
Bis(2-chloroisopropyl)ether	ND		ug/l	2.0	0.53
Bis(2-chloroethoxy)methane	ND		ug/l	5.0	0.50
Hexachlorobutadiene	ND		ug/l	2.0	0.66
Hexachlorocyclopentadiene	ND		ug/l	20	0.69
Hexachloroethane	ND		ug/l	2.0	0.58
Isophorone	ND		ug/l	5.0	1.2
Naphthalene	ND		ug/l	2.0	0.46
Nitrobenzene	ND		ug/l	2.0	0.77
NDPA/DPA	ND		ug/l	2.0	0.42
n-Nitrosodi-n-propylamine	ND		ug/l	5.0	0.64
Bis(2-ethylhexyl)phthalate	ND		ug/l	3.0	1.5
Butyl benzyl phthalate	ND		ug/l	5.0	1.2
Di-n-butylphthalate	ND		ug/l	5.0	0.39
Di-n-octylphthalate	ND		ug/l	5.0	1.3
Diethyl phthalate	ND		ug/l	5.0	0.38

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 06/09/23 15:55
Analyst: JG

Extraction Method: EPA 3510C
Extraction Date: 06/08/23 11:26

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 08-09 Batch: WG1788810-1					
Dimethyl phthalate	ND		ug/l	5.0	1.8
Benzo(a)anthracene	ND		ug/l	2.0	0.32
Benzo(a)pyrene	ND		ug/l	2.0	0.41
Benzo(b)fluoranthene	ND		ug/l	2.0	0.35
Benzo(k)fluoranthene	ND		ug/l	2.0	0.37
Chrysene	ND		ug/l	2.0	0.34
Acenaphthylene	ND		ug/l	2.0	0.46
Anthracene	ND		ug/l	2.0	0.33
Benzo(ghi)perylene	ND		ug/l	2.0	0.30
Fluorene	ND		ug/l	2.0	0.41
Phenanthrene	ND		ug/l	2.0	0.33
Dibenzo(a,h)anthracene	ND		ug/l	2.0	0.32
Indeno(1,2,3-cd)pyrene	ND		ug/l	2.0	0.40
Pyrene	ND		ug/l	2.0	0.28
Biphenyl	ND		ug/l	2.0	0.46
4-Chloroaniline	ND		ug/l	5.0	1.1
2-Nitroaniline	ND		ug/l	5.0	0.50
3-Nitroaniline	ND		ug/l	5.0	0.81
4-Nitroaniline	ND		ug/l	5.0	0.80
Dibenzofuran	ND		ug/l	2.0	0.50
2-Methylnaphthalene	ND		ug/l	2.0	0.45
1,2,4,5-Tetrachlorobenzene	ND		ug/l	10	0.44
Acetophenone	ND		ug/l	5.0	0.53
2,4,6-Trichlorophenol	ND		ug/l	5.0	0.61
p-Chloro-m-cresol	ND		ug/l	2.0	0.35
2-Chlorophenol	ND		ug/l	2.0	0.48
2,4-Dichlorophenol	ND		ug/l	5.0	0.41
2,4-Dimethylphenol	ND		ug/l	5.0	1.8
2-Nitrophenol	ND		ug/l	10	0.85

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331226
Report Date: 06/13/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 06/09/23 15:55
Analyst: JG

Extraction Method: EPA 3510C
Extraction Date: 06/08/23 11:26

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 08-09 Batch: WG1788810-1					
4-Nitrophenol	ND		ug/l	10	0.67
2,4-Dinitrophenol	ND		ug/l	20	6.6
4,6-Dinitro-o-cresol	ND		ug/l	10	1.8
Pentachlorophenol	ND		ug/l	10	1.8
Phenol	ND		ug/l	5.0	0.57
2-Methylphenol	ND		ug/l	5.0	0.49
3-Methylphenol/4-Methylphenol	ND		ug/l	5.0	0.48
2,4,5-Trichlorophenol	ND		ug/l	5.0	0.77
Benzoic Acid	ND		ug/l	50	2.6
Benzyl Alcohol	ND		ug/l	2.0	0.59
Carbazole	ND		ug/l	2.0	0.49

Tentatively Identified Compounds			
Total TIC Compounds	50.2	J	ug/l
Unknown	11.2	J	ug/l
Unknown Organic Acid	6.18	J	ug/l
Unknown	2.58	J	ug/l
Unknown	3.82	J	ug/l
Unknown	9.67	J	ug/l
Unknown	1.74	J	ug/l
Unknown Organic Acid	13.3	J	ug/l

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 06/09/23 15:55
Analyst: JG

Extraction Method: EPA 3510C
Extraction Date: 06/08/23 11:26

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 08-09 Batch: WG1788810-1					

Surrogate	%Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	27		21-120
Phenol-d6	24		10-120
Nitrobenzene-d5	41		23-120
2-Fluorobiphenyl	38		15-120
2,4,6-Tribromophenol	33		10-120
4-Terphenyl-d14	49		41-149

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E-SIM
Analytical Date: 06/09/23 12:59
Analyst: AH

Extraction Method: EPA 3510C
Extraction Date: 06/08/23 11:26

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS-SIM - Westborough Lab for sample(s): 08-09 Batch: WG1788814-1					
Acenaphthene	ND		ug/l	0.10	0.01
2-Chloronaphthalene	ND		ug/l	0.20	0.02
Fluoranthene	ND		ug/l	0.10	0.02
Hexachlorobutadiene	ND		ug/l	0.50	0.05
Naphthalene	ND		ug/l	0.10	0.05
Benzo(a)anthracene	ND		ug/l	0.10	0.02
Benzo(a)pyrene	ND		ug/l	0.10	0.02
Benzo(b)fluoranthene	ND		ug/l	0.10	0.01
Benzo(k)fluoranthene	ND		ug/l	0.10	0.01
Chrysene	ND		ug/l	0.10	0.01
Acenaphthylene	ND		ug/l	0.10	0.01
Anthracene	ND		ug/l	0.10	0.01
Benzo(ghi)perylene	ND		ug/l	0.10	0.01
Fluorene	ND		ug/l	0.10	0.01
Phenanthrene	ND		ug/l	0.10	0.02
Dibenzo(a,h)anthracene	ND		ug/l	0.10	0.01
Indeno(1,2,3-cd)pyrene	ND		ug/l	0.10	0.01
Pyrene	ND		ug/l	0.10	0.02
2-Methylnaphthalene	ND		ug/l	0.10	0.02
Pentachlorophenol	ND		ug/l	0.80	0.01
Hexachlorobenzene	ND		ug/l	0.80	0.01
Hexachloroethane	ND		ug/l	0.80	0.06

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E-SIM
Analytical Date: 06/09/23 12:59
Analyst: AH

Extraction Method: EPA 3510C
Extraction Date: 06/08/23 11:26

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS-SIM - Westborough Lab for sample(s): 08-09 Batch: WG1788814-1					

Surrogate	%Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	29		21-120
Phenol-d6	26		10-120
Nitrobenzene-d5	47		23-120
2-Fluorobiphenyl	52		15-120
2,4,6-Tribromophenol	58		10-120
4-Terphenyl-d14	59		41-149

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331226

Report Date: 06/13/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 01-07 Batch: WG1787902-2 WG1787902-3								
Acenaphthene	66		65		31-137	2		50
1,2,4-Trichlorobenzene	61		60		38-107	2		50
Hexachlorobenzene	63		61		40-140	3		50
Bis(2-chloroethyl)ether	61		60		40-140	2		50
2-Chloronaphthalene	65		64		40-140	2		50
1,2-Dichlorobenzene	63		61		40-140	3		50
1,3-Dichlorobenzene	61		62		40-140	2		50
1,4-Dichlorobenzene	60		61		28-104	2		50
3,3'-Dichlorobenzidine	64		62		40-140	3		50
2,4-Dinitrotoluene	98		94		40-132	4		50
2,6-Dinitrotoluene	81		78		40-140	4		50
Fluoranthene	72		68		40-140	6		50
4-Chlorophenyl phenyl ether	67		65		40-140	3		50
4-Bromophenyl phenyl ether	66		63		40-140	5		50
Bis(2-chloroisopropyl)ether	62		61		40-140	2		50
Bis(2-chloroethoxy)methane	63		62		40-117	2		50
Hexachlorobutadiene	63		63		40-140	0		50
Hexachlorocyclopentadiene	**16**	Q	**18**	Q	40-140	12		50
Hexachloroethane	66		65		40-140	2		50
Isophorone	61		60		40-140	2		50
Naphthalene	64		64		40-140	0		50
Nitrobenzene	69		67		40-140	3		50
NDPA/DPA	70		67		36-157	4		50

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331226

Report Date: 06/13/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 01-07 Batch: WG1787902-2 WG1787902-3								
n-Nitrosodi-n-propylamine	64		64		32-121	0		50
Bis(2-ethylhexyl)phthalate	90		88		40-140	2		50
Butyl benzyl phthalate	82		74		40-140	10		50
Di-n-butylphthalate	82		80		40-140	2		50
Di-n-octylphthalate	94		93		40-140	1		50
Diethyl phthalate	71		69		40-140	3		50
Dimethyl phthalate	66		65		40-140	2		50
Benzo(a)anthracene	74		74		40-140	0		50
Benzo(a)pyrene	79		79		40-140	0		50
Benzo(b)fluoranthene	68		69		40-140	1		50
Benzo(k)fluoranthene	77		74		40-140	4		50
Chrysene	72		71		40-140	1		50
Acenaphthylene	70		69		40-140	1		50
Anthracene	73		73		40-140	0		50
Benzo(ghi)perylene	76		72		40-140	5		50
Fluorene	66		64		40-140	3		50
Phenanthrene	70		70		40-140	0		50
Dibenzo(a,h)anthracene	72		69		40-140	4		50
Indeno(1,2,3-cd)pyrene	76		73		40-140	4		50
Pyrene	70		68		35-142	3		50
Biphenyl	66		64		37-127	3		50
4-Chloroaniline	47		42		40-140	11		50
2-Nitroaniline	84		82		47-134	2		50

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331226
Report Date: 06/13/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 01-07 Batch: WG1787902-2 WG1787902-3								
3-Nitroaniline	67		64		26-129	5		50
4-Nitroaniline	72		66		41-125	9		50
Dibenzofuran	68		65		40-140	5		50
2-Methylnaphthalene	66		66		40-140	0		50
1,2,4,5-Tetrachlorobenzene	64		64		40-117	0		50
Acetophenone	69		68		14-144	1		50
2,4,6-Trichlorophenol	72		69		30-130	4		50
p-Chloro-m-cresol	74		74		26-103	0		50
2-Chlorophenol	68		68		25-102	0		50
2,4-Dichlorophenol	69		68		30-130	1		50
2,4-Dimethylphenol	64		65		30-130	2		50
2-Nitrophenol	86		84		30-130	2		50
4-Nitrophenol	63		61		11-114	3		50
2,4-Dinitrophenol	41		41		4-130	0		50
4,6-Dinitro-o-cresol	83		79		10-130	5		50
Pentachlorophenol	42		41		17-109	2		50
Phenol	66		65		26-90	2		50
2-Methylphenol	64		62		30-130.	3		50
3-Methylphenol/4-Methylphenol	65		63		30-130	3		50
2,4,5-Trichlorophenol	72		72		30-130	0		50
Benzoic Acid	16		17		10-110	6		50
Benzyl Alcohol	66		66		40-140	0		50
Carbazole	72		71		54-128	1		50

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331226
Report Date: 06/13/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 01-07 Batch: WG1787902-2 WG1787902-3								
1,4-Dioxane	55		52		40-140	6		50

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
2-Fluorophenol	71		71		25-120
Phenol-d6	68		69		10-120
Nitrobenzene-d5	70		72		23-120
2-Fluorobiphenyl	63		64		30-120
2,4,6-Tribromophenol	66		62		10-136
4-Terphenyl-d14	63		61		18-120

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331226
Report Date: 06/13/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 08-09 Batch: WG1788810-2 WG1788810-3								
Acenaphthene	70		64		37-111	9		30
1,2,4-Trichlorobenzene	65		60		39-98	8		30
Hexachlorobenzene	67		57		40-140	16		30
Bis(2-chloroethyl)ether	72		67		40-140	7		30
2-Chloronaphthalene	65		58		40-140	11		30
1,2-Dichlorobenzene	68		67		40-140	1		30
1,3-Dichlorobenzene	67		67		40-140	0		30
1,4-Dichlorobenzene	66		66		36-97	0		30
3,3'-Dichlorobenzidine	55		46		40-140	18		30
2,4-Dinitrotoluene	88		74		48-143	17		30
2,6-Dinitrotoluene	76		66		40-140	14		30
Fluoranthene	72		62		40-140	15		30
4-Chlorophenyl phenyl ether	64		56		40-140	13		30
4-Bromophenyl phenyl ether	63		54		40-140	15		30
Bis(2-chloroisopropyl)ether	82		78		40-140	5		30
Bis(2-chloroethoxy)methane	76		68		40-140	11		30
Hexachlorobutadiene	48		46		40-140	4		30
Hexachlorocyclopentadiene	56		52		40-140	7		30
Hexachloroethane	72		72		40-140	0		30
Isophorone	63		59		40-140	7		30
Naphthalene	66		62		40-140	6		30
Nitrobenzene	66		64		40-140	3		30
NDPA/DPA	77		64		40-140	18		30

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331226

Report Date: 06/13/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 08-09 Batch: WG1788810-2 WG1788810-3								
n-Nitrosodi-n-propylamine	64		61		29-132	5		30
Bis(2-ethylhexyl)phthalate	124		109		40-140	13		30
Butyl benzyl phthalate	100		85		40-140	16		30
Di-n-butylphthalate	98		84		40-140	15		30
Di-n-octylphthalate	114		101		40-140	12		30
Diethyl phthalate	93		78		40-140	18		30
Dimethyl phthalate	75		64		40-140	16		30
Benzo(a)anthracene	78		69		40-140	12		30
Benzo(a)pyrene	85		75		40-140	13		30
Benzo(b)fluoranthene	82		74		40-140	10		30
Benzo(k)fluoranthene	77		67		40-140	14		30
Chrysene	77		67		40-140	14		30
Acenaphthylene	70		63		45-123	11		30
Anthracene	79		69		40-140	14		30
Benzo(ghi)perylene	93		79		40-140	16		30
Fluorene	74		64		40-140	14		30
Phenanthrene	81		71		40-140	13		30
Dibenzo(a,h)anthracene	89		77		40-140	14		30
Indeno(1,2,3-cd)pyrene	86		72		40-140	18		30
Pyrene	73		61		26-127	18		30
Biphenyl	62		57		40-140	8		30
4-Chloroaniline	51		**39**	Q	40-140	27		30
2-Nitroaniline	78		67		52-143	15		30

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331226
Report Date: 06/13/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 08-09 Batch: WG1788810-2 WG1788810-3								
3-Nitroaniline	78		60		25-145	26		30
4-Nitroaniline	84		68		51-143	21		30
Dibenzofuran	73		64		40-140	13		30
2-Methylnaphthalene	69		64		40-140	8		30
1,2,4,5-Tetrachlorobenzene	48		46		2-134	4		30
Acetophenone	58		56		39-129	4		30
2,4,6-Trichlorophenol	62		53		30-130	16		30
p-Chloro-m-cresol	69		58		23-97	17		30
2-Chlorophenol	72		70		27-123	3		30
2,4-Dichlorophenol	73		67		30-130	9		30
2,4-Dimethylphenol	58		42		30-130	**32**	Q	30
2-Nitrophenol	82		78		30-130	5		30
4-Nitrophenol	**89**	Q	74		10-80	18		30
2,4-Dinitrophenol	74		62		20-130	18		30
4,6-Dinitro-o-cresol	88		70		20-164	23		30
Pentachlorophenol	77		63		9-103	20		30
Phenol	51		49		12-110	4		30
2-Methylphenol	65		57		30-130	13		30
3-Methylphenol/4-Methylphenol	66		60		30-130	10		30
2,4,5-Trichlorophenol	65		56		30-130	15		30
Benzoic Acid	61		66		10-164	8		30
Benzyl Alcohol	56		53		26-116	6		30
Carbazole	83		72		55-144	14		30

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331226
Report Date: 06/13/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 08-09 Batch: WG1788810-2 WG1788810-3								

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
2-Fluorophenol	59		57		21-120
Phenol-d6	53		50		10-120
Nitrobenzene-d5	72		69		23-120
2-Fluorobiphenyl	60		57		15-120
2,4,6-Tribromophenol	82		70		10-120
4-Terphenyl-d14	66		57		41-149

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331226
Report Date: 06/13/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS-SIM - Westborough Lab Associated sample(s): 08-09 Batch: WG1788814-2 WG1788814-3								
Acenaphthene	69		64		40-140	8		40
2-Chloronaphthalene	78		73		40-140	7		40
Fluoranthene	84		71		40-140	17		40
Hexachlorobutadiene	88		87		40-140	1		40
Naphthalene	68		66		40-140	3		40
Benzo(a)anthracene	81		72		40-140	12		40
Benzo(a)pyrene	86		76		40-140	12		40
Benzo(b)fluoranthene	87		68		40-140	25		40
Benzo(k)fluoranthene	84		77		40-140	9		40
Chrysene	76		68		40-140	11		40
Acenaphthylene	80		74		40-140	8		40
Anthracene	75		66		40-140	13		40
Benzo(ghi)perylene	71		66		40-140	7		40
Fluorene	75		68		40-140	10		40
Phenanthrene	71		62		40-140	14		40
Dibenzo(a,h)anthracene	75		70		40-140	7		40
Indeno(1,2,3-cd)pyrene	70		65		40-140	7		40
Pyrene	84		72		40-140	15		40
2-Methylnaphthalene	75		72		40-140	4		40
Pentachlorophenol	101		91		40-140	10		40
Hexachlorobenzene	83		75		40-140	10		40
Hexachloroethane	61		62		40-140	2		40

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331226
Report Date: 06/13/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS-SIM - Westborough Lab Associated sample(s): 08-09 Batch: WG1788814-2 WG1788814-3								

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
2-Fluorophenol	59		58		21-120
Phenol-d6	52		50		10-120
Nitrobenzene-d5	74		73		23-120
2-Fluorobiphenyl	80		74		15-120
2,4,6-Tribromophenol	**126**	Q	108		10-120
4-Terphenyl-d14	88		76		41-149

PCBS

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-01
Client ID: SB-20G (1.5-2)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 10:00
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8082A
Analytical Date: 06/08/23 00:58
Analyst: JM
Percent Solids: 94%

Extraction Method: EPA 3546
Extraction Date: 06/06/23 14:29
Cleanup Method: EPA 3665A
Cleanup Date: 06/07/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/07/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/kg	50.0	4.44	1	A
Aroclor 1221	ND		ug/kg	50.0	5.01	1	A
Aroclor 1232	ND		ug/kg	50.0	10.6	1	A
Aroclor 1242	ND		ug/kg	50.0	6.74	1	A
Aroclor 1248	ND		ug/kg	50.0	7.50	1	A
Aroclor 1254	ND		ug/kg	50.0	5.47	1	A
Aroclor 1260	ND		ug/kg	50.0	9.24	1	A
Aroclor 1262	ND		ug/kg	50.0	6.35	1	A
Aroclor 1268	ND		ug/kg	50.0	5.18	1	A
PCBs, Total	ND		ug/kg	50.0	4.44	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	59		30-150	A
Decachlorobiphenyl	45		30-150	A
2,4,5,6-Tetrachloro-m-xylene	104		30-150	B
Decachlorobiphenyl	51		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-02
Client ID: SB-21G (9-9.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 11:15
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8082A
Analytical Date: 06/08/23 02:27
Analyst: JM
Percent Solids: 91%

Extraction Method: EPA 3546
Extraction Date: 06/06/23 14:29
Cleanup Method: EPA 3665A
Cleanup Date: 06/07/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/07/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/kg	53.4	4.74	1	A
Aroclor 1221	ND		ug/kg	53.4	5.35	1	A
Aroclor 1232	ND		ug/kg	53.4	11.3	1	A
Aroclor 1242	ND		ug/kg	53.4	7.20	1	A
Aroclor 1248	ND		ug/kg	53.4	8.01	1	A
Aroclor 1254	ND		ug/kg	53.4	5.84	1	A
Aroclor 1260	ND		ug/kg	53.4	9.87	1	A
Aroclor 1262	ND		ug/kg	53.4	6.78	1	A
Aroclor 1268	ND		ug/kg	53.4	5.54	1	A
PCBs, Total	ND		ug/kg	53.4	4.74	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	58		30-150	A
Decachlorobiphenyl	48		30-150	A
2,4,5,6-Tetrachloro-m-xylene	57		30-150	B
Decachlorobiphenyl	52		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-03
Client ID: SB-21G (12-12.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 11:20
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8082A
Analytical Date: 06/08/23 02:40
Analyst: JM
Percent Solids: 82%

Extraction Method: EPA 3546
Extraction Date: 06/06/23 14:29
Cleanup Method: EPA 3665A
Cleanup Date: 06/07/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/07/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/kg	55.4	4.92	1	A
Aroclor 1221	ND		ug/kg	55.4	5.55	1	A
Aroclor 1232	ND		ug/kg	55.4	11.7	1	A
Aroclor 1242	ND		ug/kg	55.4	7.47	1	A
Aroclor 1248	ND		ug/kg	55.4	8.31	1	A
Aroclor 1254	ND		ug/kg	55.4	6.06	1	A
Aroclor 1260	ND		ug/kg	55.4	10.2	1	A
Aroclor 1262	ND		ug/kg	55.4	7.04	1	A
Aroclor 1268	ND		ug/kg	55.4	5.74	1	A
PCBs, Total	ND		ug/kg	55.4	4.92	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	55		30-150	A
Decachlorobiphenyl	45		30-150	A
2,4,5,6-Tetrachloro-m-xylene	62		30-150	B
Decachlorobiphenyl	48		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-04
Client ID: SB-22G (7-7.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 12:15
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8082A
Analytical Date: 06/08/23 02:53
Analyst: JM
Percent Solids: 80%

Extraction Method: EPA 3546
Extraction Date: 06/06/23 14:29
Cleanup Method: EPA 3665A
Cleanup Date: 06/07/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/07/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/kg	61.9	5.50	1	A
Aroclor 1221	ND		ug/kg	61.9	6.21	1	A
Aroclor 1232	ND		ug/kg	61.9	13.1	1	A
Aroclor 1242	ND		ug/kg	61.9	8.35	1	A
Aroclor 1248	ND		ug/kg	61.9	9.29	1	A
Aroclor 1254	ND		ug/kg	61.9	6.78	1	A
Aroclor 1260	ND		ug/kg	61.9	11.4	1	A
Aroclor 1262	ND		ug/kg	61.9	7.87	1	A
Aroclor 1268	ND		ug/kg	61.9	6.42	1	A
PCBs, Total	ND		ug/kg	61.9	5.50	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	54		30-150	A
Decachlorobiphenyl	54		30-150	A
2,4,5,6-Tetrachloro-m-xylene	52		30-150	B
Decachlorobiphenyl	55		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-05
Client ID: SB-23G (9.5-10)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 12:50
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8082A
Analytical Date: 06/08/23 03:06
Analyst: JM
Percent Solids: 87%

Extraction Method: EPA 3546
Extraction Date: 06/06/23 14:29
Cleanup Method: EPA 3665A
Cleanup Date: 06/07/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/07/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/kg	52.5	4.66	1	A
Aroclor 1221	ND		ug/kg	52.5	5.26	1	A
Aroclor 1232	ND		ug/kg	52.5	11.1	1	A
Aroclor 1242	ND		ug/kg	52.5	7.08	1	A
Aroclor 1248	ND		ug/kg	52.5	7.88	1	A
Aroclor 1254	ND		ug/kg	52.5	5.75	1	A
Aroclor 1260	ND		ug/kg	52.5	9.71	1	A
Aroclor 1262	ND		ug/kg	52.5	6.67	1	A
Aroclor 1268	ND		ug/kg	52.5	5.44	1	A
PCBs, Total	ND		ug/kg	52.5	4.66	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	63		30-150	A
Decachlorobiphenyl	50		30-150	A
2,4,5,6-Tetrachloro-m-xylene	116		30-150	B
Decachlorobiphenyl	55		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-06
Client ID: SB-24G (7.5-8)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 12:30
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8082A
Analytical Date: 06/08/23 03:57
Analyst: JM
Percent Solids: 85%

Extraction Method: EPA 3546
Extraction Date: 06/06/23 14:29
Cleanup Method: EPA 3665A
Cleanup Date: 06/07/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/07/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/kg	55.6	4.94	1	A
Aroclor 1221	ND		ug/kg	55.6	5.58	1	A
Aroclor 1232	ND		ug/kg	55.6	11.8	1	A
Aroclor 1242	ND		ug/kg	55.6	7.50	1	A
Aroclor 1248	ND		ug/kg	55.6	8.35	1	A
Aroclor 1254	ND		ug/kg	55.6	6.09	1	A
Aroclor 1260	ND		ug/kg	55.6	10.3	1	A
Aroclor 1262	ND		ug/kg	55.6	7.07	1	A
Aroclor 1268	ND		ug/kg	55.6	5.76	1	A
PCBs, Total	ND		ug/kg	55.6	4.94	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	50		30-150	A
Decachlorobiphenyl	42		30-150	A
2,4,5,6-Tetrachloro-m-xylene	60		30-150	B
Decachlorobiphenyl	46		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-07
Client ID: SB-25G (9.5-10)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 10:40
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8082A
Analytical Date: 06/08/23 04:10
Analyst: JM
Percent Solids: 92%

Extraction Method: EPA 3546
Extraction Date: 06/06/23 14:29
Cleanup Method: EPA 3665A
Cleanup Date: 06/07/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/07/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/kg	50.4	4.48	1	A
Aroclor 1221	ND		ug/kg	50.4	5.06	1	A
Aroclor 1232	ND		ug/kg	50.4	10.7	1	A
Aroclor 1242	ND		ug/kg	50.4	6.80	1	A
Aroclor 1248	ND		ug/kg	50.4	7.57	1	A
Aroclor 1254	ND		ug/kg	50.4	5.52	1	A
Aroclor 1260	ND		ug/kg	50.4	9.32	1	A
Aroclor 1262	ND		ug/kg	50.4	6.41	1	A
Aroclor 1268	ND		ug/kg	50.4	5.23	1	A
PCBs, Total	ND		ug/kg	50.4	4.48	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	58		30-150	A
Decachlorobiphenyl	47		30-150	A
2,4,5,6-Tetrachloro-m-xylene	58		30-150	B
Decachlorobiphenyl	51		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-08
Client ID: GW-10
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 12:00
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8082A
Analytical Date: 06/08/23 09:12
Analyst: JM

Extraction Method: EPA 3510C
Extraction Date: 06/07/23 08:59
Cleanup Method: EPA 3665A
Cleanup Date: 06/07/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/08/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/l	0.071	0.061	1	A
Aroclor 1221	ND		ug/l	0.071	0.061	1	A
Aroclor 1232	ND		ug/l	0.071	0.061	1	A
Aroclor 1242	ND		ug/l	0.071	0.061	1	A
Aroclor 1248	ND		ug/l	0.071	0.061	1	A
Aroclor 1254	ND		ug/l	0.071	0.061	1	A
Aroclor 1260	ND		ug/l	0.071	0.061	1	A
Aroclor 1262	ND		ug/l	0.071	0.061	1	A
Aroclor 1268	ND		ug/l	0.071	0.061	1	A
PCBs, Total	ND		ug/l	0.071	0.061	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	60		30-150	A
Decachlorobiphenyl	34		30-150	A
2,4,5,6-Tetrachloro-m-xylene	61		30-150	B
Decachlorobiphenyl	35		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-09
Client ID: GW-11
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 13:20
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8082A
Analytical Date: 06/08/23 09:21
Analyst: JM

Extraction Method: EPA 3510C
Extraction Date: 06/07/23 08:59
Cleanup Method: EPA 3665A
Cleanup Date: 06/07/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/08/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/l	0.071	0.061	1	A
Aroclor 1221	ND		ug/l	0.071	0.061	1	A
Aroclor 1232	ND		ug/l	0.071	0.061	1	A
Aroclor 1242	ND		ug/l	0.071	0.061	1	A
Aroclor 1248	ND		ug/l	0.071	0.061	1	A
Aroclor 1254	ND		ug/l	0.071	0.061	1	A
Aroclor 1260	ND		ug/l	0.071	0.061	1	A
Aroclor 1262	ND		ug/l	0.071	0.061	1	A
Aroclor 1268	ND		ug/l	0.071	0.061	1	A
PCBs, Total	ND		ug/l	0.071	0.061	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	64		30-150	A
Decachlorobiphenyl	31		30-150	A
2,4,5,6-Tetrachloro-m-xylene	62		30-150	B
Decachlorobiphenyl	32		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8082A
Analytical Date: 06/08/23 03:18
Analyst: JM

Extraction Method: EPA 3546
Extraction Date: 06/06/23 14:29
Cleanup Method: EPA 3665A
Cleanup Date: 06/07/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/07/23

Parameter	Result	Qualifier	Units	RL	MDL	Column
Polychlorinated Biphenyls by GC - Westborough Lab for sample(s): 01-07 Batch: WG1787848-1						
Aroclor 1016	ND		ug/kg	49.0	4.35	A
Aroclor 1221	ND		ug/kg	49.0	4.91	A
Aroclor 1232	ND		ug/kg	49.0	10.4	A
Aroclor 1242	ND		ug/kg	49.0	6.60	A
Aroclor 1248	ND		ug/kg	49.0	7.34	A
Aroclor 1254	ND		ug/kg	49.0	5.36	A
Aroclor 1260	ND		ug/kg	49.0	9.05	A
Aroclor 1262	ND		ug/kg	49.0	6.22	A
Aroclor 1268	ND		ug/kg	49.0	5.07	A
PCBs, Total	ND		ug/kg	49.0	4.35	A

Surrogate	%Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	61		30-150	A
Decachlorobiphenyl	55		30-150	A
2,4,5,6-Tetrachloro-m-xylene	62		30-150	B
Decachlorobiphenyl	56		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8082A
Analytical Date: 06/08/23 08:38
Analyst: JM

Extraction Method: EPA 3510C
Extraction Date: 06/07/23 08:59
Cleanup Method: EPA 3665A
Cleanup Date: 06/07/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/08/23

Parameter	Result	Qualifier	Units	RL	MDL	Column
Polychlorinated Biphenyls by GC - Westborough Lab for sample(s): 08-09 Batch: WG1788165-1						
Aroclor 1016	ND		ug/l	0.071	0.061	A
Aroclor 1221	ND		ug/l	0.071	0.061	A
Aroclor 1232	ND		ug/l	0.071	0.061	A
Aroclor 1242	ND		ug/l	0.071	0.061	A
Aroclor 1248	ND		ug/l	0.071	0.061	A
Aroclor 1254	ND		ug/l	0.071	0.061	A
Aroclor 1260	ND		ug/l	0.071	0.061	A
Aroclor 1262	ND		ug/l	0.071	0.061	A
Aroclor 1268	ND		ug/l	0.071	0.061	A
PCBs, Total	ND		ug/l	0.071	0.061	A

Surrogate	%Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	68		30-150	A
Decachlorobiphenyl	68		30-150	A
2,4,5,6-Tetrachloro-m-xylene	66		30-150	B
Decachlorobiphenyl	66		30-150	B

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits	Column
Polychlorinated Biphenyls by GC - Westborough Lab Associated sample(s): 01-07 Batch: WG1787848-2 WG1787848-3									
Aroclor 1016	61		57		40-140	7		50	A
Aroclor 1260	59		54		40-140	9		50	A

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	63		59		30-150	A
Decachlorobiphenyl	53		52		30-150	A
2,4,5,6-Tetrachloro-m-xylene	64		60		30-150	B
Decachlorobiphenyl	57		53		30-150	B

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits	Column
Polychlorinated Biphenyls by GC - Westborough Lab Associated sample(s): 08-09 Batch: WG1788165-2 WG1788165-3									
Aroclor 1016	73		78		40-140	7		50	A
Aroclor 1260	58		65		40-140	11		50	A

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	70		73		30-150	A
Decachlorobiphenyl	69		73		30-150	A
2,4,5,6-Tetrachloro-m-xylene	67		69		30-150	B
Decachlorobiphenyl	68		74		30-150	B

PESTICIDES

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-01
Client ID: SB-20G (1.5-2)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 10:00
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8081B
Analytical Date: 06/07/23 16:31
Analyst: MMG
Percent Solids: 94%

Extraction Method: EPA 3546
Extraction Date: 06/06/23 15:03
Cleanup Method: EPA 3620B
Cleanup Date: 06/07/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/07/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/kg	1.69	0.330	1	A
Lindane	ND		ug/kg	0.703	0.314	1	A
Alpha-BHC	ND		ug/kg	0.703	0.200	1	A
Beta-BHC	ND		ug/kg	1.69	0.639	1	A
Heptachlor	ND		ug/kg	0.843	0.378	1	A
Aldrin	ND		ug/kg	1.69	0.594	1	A
Heptachlor epoxide	ND		ug/kg	3.16	0.949	1	A
Endrin	ND		ug/kg	0.703	0.288	1	A
Endrin aldehyde	ND		ug/kg	2.11	0.738	1	A
Endrin ketone	ND		ug/kg	1.69	0.434	1	A
Dieldrin	ND		ug/kg	1.05	0.527	1	A
4,4'-DDE	ND		ug/kg	1.69	0.390	1	A
4,4'-DDD	ND		ug/kg	1.69	0.602	1	A
4,4'-DDT	ND		ug/kg	1.69	1.36	1	A
Endosulfan I	ND		ug/kg	1.69	0.398	1	A
Endosulfan II	ND		ug/kg	1.69	0.564	1	A
Endosulfan sulfate	ND		ug/kg	0.703	0.334	1	A
Methoxychlor	ND		ug/kg	3.16	0.984	1	A
Toxaphene	ND		ug/kg	31.6	8.85	1	A
cis-Chlordane	ND		ug/kg	2.11	0.587	1	A
trans-Chlordane	ND		ug/kg	2.11	0.556	1	A
Chlordane	ND		ug/kg	14.0	5.59	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-01 Date Collected: 06/05/23 10:00

Client ID: SB-20G (1.5-2) Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	75		30-150	A
Decachlorobiphenyl	75		30-150	A
2,4,5,6-Tetrachloro-m-xylene	75		30-150	B
Decachlorobiphenyl	76		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-02
Client ID: SB-21G (9-9.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 11:15
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8081B
Analytical Date: 06/07/23 16:42
Analyst: MMG
Percent Solids: 91%

Extraction Method: EPA 3546
Extraction Date: 06/06/23 15:03
Cleanup Method: EPA 3620B
Cleanup Date: 06/07/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/07/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/kg	1.70	0.333	1	A
Lindane	ND		ug/kg	0.708	0.316	1	A
Alpha-BHC	ND		ug/kg	0.708	0.201	1	A
Beta-BHC	ND		ug/kg	1.70	0.644	1	A
Heptachlor	ND		ug/kg	0.849	0.381	1	A
Aldrin	ND		ug/kg	1.70	0.598	1	A
Heptachlor epoxide	ND		ug/kg	3.18	0.956	1	A
Endrin	ND		ug/kg	0.708	0.290	1	A
Endrin aldehyde	ND		ug/kg	2.12	0.743	1	A
Endrin ketone	ND		ug/kg	1.70	0.437	1	A
Dieldrin	ND		ug/kg	1.06	0.531	1	A
4,4'-DDE	ND		ug/kg	1.70	0.393	1	A
4,4'-DDD	ND		ug/kg	1.70	0.606	1	A
4,4'-DDT	ND		ug/kg	1.70	1.37	1	A
Endosulfan I	ND		ug/kg	1.70	0.401	1	A
Endosulfan II	ND		ug/kg	1.70	0.568	1	A
Endosulfan sulfate	ND		ug/kg	0.708	0.337	1	A
Methoxychlor	ND		ug/kg	3.18	0.991	1	A
Toxaphene	ND		ug/kg	31.8	8.92	1	A
cis-Chlordane	ND		ug/kg	2.12	0.592	1	A
trans-Chlordane	ND		ug/kg	2.12	0.561	1	A
Chlordane	ND		ug/kg	14.2	5.63	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-02 Date Collected: 06/05/23 11:15

Client ID: SB-21G (9-9.5) Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	**216**	Q	30-150	A
Decachlorobiphenyl	85		30-150	A
2,4,5,6-Tetrachloro-m-xylene	81		30-150	B
Decachlorobiphenyl	93		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-03
Client ID: SB-21G (12-12.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 11:20
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8081B
Analytical Date: 06/07/23 16:54
Analyst: MMG
Percent Solids: 82%

Extraction Method: EPA 3546
Extraction Date: 06/06/23 15:11
Cleanup Method: EPA 3620B
Cleanup Date: 06/07/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/07/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/kg	1.87	0.366	1	A
Lindane	ND		ug/kg	0.778	0.348	1	A
Alpha-BHC	ND		ug/kg	0.778	0.221	1	A
Beta-BHC	ND		ug/kg	1.87	0.708	1	A
Heptachlor	ND		ug/kg	0.934	0.419	1	A
Aldrin	ND		ug/kg	1.87	0.658	1	A
Heptachlor epoxide	ND		ug/kg	3.50	1.05	1	A
Endrin	ND		ug/kg	0.778	0.319	1	A
Endrin aldehyde	ND		ug/kg	2.34	0.817	1	A
Endrin ketone	ND		ug/kg	1.87	0.481	1	A
Dieldrin	ND		ug/kg	1.17	0.584	1	A
4,4'-DDE	ND		ug/kg	1.87	0.432	1	A
4,4'-DDD	ND		ug/kg	1.87	0.666	1	A
4,4'-DDT	ND		ug/kg	1.87	1.50	1	A
Endosulfan I	ND		ug/kg	1.87	0.441	1	A
Endosulfan II	ND		ug/kg	1.87	0.624	1	A
Endosulfan sulfate	ND		ug/kg	0.778	0.370	1	A
Methoxychlor	ND		ug/kg	3.50	1.09	1	A
Toxaphene	ND		ug/kg	35.0	9.81	1	A
cis-Chlordane	ND		ug/kg	2.34	0.651	1	A
trans-Chlordane	ND		ug/kg	2.34	0.616	1	A
Chlordane	ND		ug/kg	15.6	6.19	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-03 Date Collected: 06/05/23 11:20

Client ID: SB-21G (12-12.5) Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	80		30-150	A
Decachlorobiphenyl	86		30-150	A
2,4,5,6-Tetrachloro-m-xylene	78		30-150	B
Decachlorobiphenyl	87		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-04
Client ID: SB-22G (7-7.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 12:15
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8081B
Analytical Date: 06/07/23 17:05
Analyst: MMG
Percent Solids: 80%

Extraction Method: EPA 3546
Extraction Date: 06/06/23 15:11
Cleanup Method: EPA 3620B
Cleanup Date: 06/07/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/07/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/kg	1.94	0.381	1	A
Lindane	ND		ug/kg	0.810	0.362	1	A
Alpha-BHC	ND		ug/kg	0.810	0.230	1	A
Beta-BHC	ND		ug/kg	1.94	0.738	1	A
Heptachlor	ND		ug/kg	0.973	0.436	1	A
Aldrin	ND		ug/kg	1.94	0.685	1	A
Heptachlor epoxide	ND		ug/kg	3.65	1.09	1	A
Endrin	ND		ug/kg	0.810	0.332	1	A
Endrin aldehyde	ND		ug/kg	2.43	0.851	1	A
Endrin ketone	ND		ug/kg	1.94	0.501	1	A
Dieldrin	ND		ug/kg	1.22	0.608	1	A
4,4'-DDE	ND		ug/kg	1.94	0.450	1	A
4,4'-DDD	ND		ug/kg	1.94	0.694	1	A
4,4'-DDT	ND		ug/kg	1.94	1.56	1	A
Endosulfan I	ND		ug/kg	1.94	0.460	1	A
Endosulfan II	ND		ug/kg	1.94	0.650	1	A
Endosulfan sulfate	ND		ug/kg	0.810	0.386	1	A
Methoxychlor	ND		ug/kg	3.65	1.13	1	A
Toxaphene	ND		ug/kg	36.5	10.2	1	A
cis-Chlordane	ND		ug/kg	2.43	0.678	1	A
trans-Chlordane	ND		ug/kg	2.43	0.642	1	A
Chlordane	ND		ug/kg	16.2	6.44	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-04 Date Collected: 06/05/23 12:15

Client ID: SB-22G (7-7.5) Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	101		30-150	A
Decachlorobiphenyl	83		30-150	A
2,4,5,6-Tetrachloro-m-xylene	69		30-150	B
Decachlorobiphenyl	86		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-05
Client ID: SB-23G (9.5-10)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 12:50
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8081B
Analytical Date: 06/07/23 17:17
Analyst: MMG
Percent Solids: 87%

Extraction Method: EPA 3546
Extraction Date: 06/06/23 15:11
Cleanup Method: EPA 3620B
Cleanup Date: 06/07/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/07/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/kg	1.80	0.352	1	A
Lindane	ND		ug/kg	0.749	0.335	1	A
Alpha-BHC	ND		ug/kg	0.749	0.213	1	A
Beta-BHC	ND		ug/kg	1.80	0.682	1	A
Heptachlor	ND		ug/kg	0.899	0.403	1	A
Aldrin	ND		ug/kg	1.80	0.633	1	A
Heptachlor epoxide	ND		ug/kg	3.37	1.01	1	A
Endrin	ND		ug/kg	0.749	0.307	1	A
Endrin aldehyde	ND		ug/kg	2.25	0.787	1	A
Endrin ketone	ND		ug/kg	1.80	0.463	1	A
Dieldrin	ND		ug/kg	1.12	0.562	1	A
4,4'-DDE	ND		ug/kg	1.80	0.416	1	A
4,4'-DDD	ND		ug/kg	1.80	0.641	1	A
4,4'-DDT	ND		ug/kg	1.80	1.45	1	A
Endosulfan I	ND		ug/kg	1.80	0.425	1	A
Endosulfan II	ND		ug/kg	1.80	0.601	1	A
Endosulfan sulfate	ND		ug/kg	0.749	0.357	1	A
Methoxychlor	ND		ug/kg	3.37	1.05	1	A
Toxaphene	ND		ug/kg	33.7	9.44	1	A
cis-Chlordane	ND		ug/kg	2.25	0.626	1	A
trans-Chlordane	ND		ug/kg	2.25	0.593	1	A
Chlordane	ND		ug/kg	15.0	5.96	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-05 Date Collected: 06/05/23 12:50

Client ID: SB-23G (9.5-10) Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	78		30-150	A
Decachlorobiphenyl	84		30-150	A
2,4,5,6-Tetrachloro-m-xylene	75		30-150	B
Decachlorobiphenyl	83		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-06
Client ID: SB-24G (7.5-8)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 12:30
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8081B
Analytical Date: 06/07/23 17:28
Analyst: MMG
Percent Solids: 85%

Extraction Method: EPA 3546
Extraction Date: 06/06/23 15:11
Cleanup Method: EPA 3620B
Cleanup Date: 06/07/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/07/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/kg	1.80	0.353	1	A
Lindane	ND		ug/kg	0.751	0.336	1	A
Alpha-BHC	ND		ug/kg	0.751	0.213	1	A
Beta-BHC	ND		ug/kg	1.80	0.684	1	A
Heptachlor	ND		ug/kg	0.902	0.404	1	A
Aldrin	ND		ug/kg	1.80	0.635	1	A
Heptachlor epoxide	ND		ug/kg	3.38	1.01	1	A
Endrin	ND		ug/kg	0.751	0.308	1	A
Endrin aldehyde	ND		ug/kg	2.25	0.789	1	A
Endrin ketone	ND		ug/kg	1.80	0.464	1	A
Dieldrin	ND		ug/kg	1.13	0.564	1	A
4,4'-DDE	ND		ug/kg	1.80	0.417	1	A
4,4'-DDD	ND		ug/kg	1.80	0.643	1	A
4,4'-DDT	ND		ug/kg	1.80	1.45	1	A
Endosulfan I	ND		ug/kg	1.80	0.426	1	A
Endosulfan II	ND		ug/kg	1.80	0.603	1	A
Endosulfan sulfate	ND		ug/kg	0.751	0.358	1	A
Methoxychlor	ND		ug/kg	3.38	1.05	1	A
Toxaphene	ND		ug/kg	33.8	9.47	1	A
cis-Chlordane	ND		ug/kg	2.25	0.628	1	A
trans-Chlordane	ND		ug/kg	2.25	0.595	1	A
Chlordane	ND		ug/kg	15.0	5.97	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-06 Date Collected: 06/05/23 12:30

Client ID: SB-24G (7.5-8) Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	67		30-150	A
Decachlorobiphenyl	71		30-150	A
2,4,5,6-Tetrachloro-m-xylene	65		30-150	B
Decachlorobiphenyl	73		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-07
Client ID: SB-25G (9.5-10)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 10:40
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8081B
Analytical Date: 06/07/23 17:40
Analyst: MMG
Percent Solids: 92%

Extraction Method: EPA 3546
Extraction Date: 06/06/23 15:11
Cleanup Method: EPA 3620B
Cleanup Date: 06/07/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/07/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/kg	1.72	0.336	1	A
Lindane	ND		ug/kg	0.715	0.320	1	A
Alpha-BHC	ND		ug/kg	0.715	0.203	1	A
Beta-BHC	ND		ug/kg	1.72	0.650	1	A
Heptachlor	ND		ug/kg	0.858	0.384	1	A
Aldrin	ND		ug/kg	1.72	0.604	1	A
Heptachlor epoxide	ND		ug/kg	3.22	0.965	1	A
Endrin	ND		ug/kg	0.715	0.293	1	A
Endrin aldehyde	ND		ug/kg	2.14	0.750	1	A
Endrin ketone	ND		ug/kg	1.72	0.442	1	A
Dieldrin	ND		ug/kg	1.07	0.536	1	A
4,4'-DDE	ND		ug/kg	1.72	0.397	1	A
4,4'-DDD	ND		ug/kg	1.72	0.612	1	A
4,4'-DDT	ND		ug/kg	1.72	1.38	1	A
Endosulfan I	ND		ug/kg	1.72	0.405	1	A
Endosulfan II	ND		ug/kg	1.72	0.573	1	A
Endosulfan sulfate	ND		ug/kg	0.715	0.340	1	A
Methoxychlor	ND		ug/kg	3.22	1.00	1	A
Toxaphene	ND		ug/kg	32.2	9.01	1	A
cis-Chlordane	ND		ug/kg	2.14	0.598	1	A
trans-Chlordane	ND		ug/kg	2.14	0.566	1	A
Chlordane	ND		ug/kg	14.3	5.68	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-07 Date Collected: 06/05/23 10:40

Client ID: SB-25G (9.5-10) Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	72		30-150	A
Decachlorobiphenyl	77		30-150	A
2,4,5,6-Tetrachloro-m-xylene	70		30-150	B
Decachlorobiphenyl	78		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-08
Client ID: GW-10
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 12:00
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8081B
Analytical Date: 06/08/23 08:33
Analyst: AKM

Extraction Method: EPA 3510C
Extraction Date: 06/07/23 08:21

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/l	0.014	0.003	1	A
Lindane	ND		ug/l	0.014	0.003	1	A
Alpha-BHC	ND		ug/l	0.014	0.003	1	A
Beta-BHC	ND		ug/l	0.014	0.004	1	A
Heptachlor	ND		ug/l	0.014	0.002	1	A
Aldrin	ND		ug/l	0.014	0.002	1	A
Heptachlor epoxide	ND		ug/l	0.014	0.003	1	A
Endrin	ND		ug/l	0.029	0.003	1	A
Endrin aldehyde	ND		ug/l	0.029	0.006	1	A
Endrin ketone	ND		ug/l	0.029	0.003	1	A
Dieldrin	ND		ug/l	0.029	0.003	1	A
4,4'-DDE	ND		ug/l	0.029	0.003	1	A
4,4'-DDD	ND		ug/l	0.029	0.003	1	A
4,4'-DDT	ND		ug/l	0.029	0.003	1	A
Endosulfan I	ND		ug/l	0.014	0.002	1	A
Endosulfan II	ND		ug/l	0.029	0.004	1	A
Endosulfan sulfate	ND		ug/l	0.029	0.003	1	A
Methoxychlor	ND		ug/l	0.143	0.005	1	A
Toxaphene	ND		ug/l	0.143	0.045	1	A
cis-Chlordane	ND		ug/l	0.014	0.005	1	A
trans-Chlordane	ND		ug/l	0.014	0.004	1	A
Chlordane	ND		ug/l	0.143	0.033	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-08 Date Collected: 06/05/23 12:00

Client ID: GW-10 Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	47		30-150	A
Decachlorobiphenyl	33		30-150	A
2,4,5,6-Tetrachloro-m-xylene	48		30-150	B
Decachlorobiphenyl	31		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-09
Client ID: GW-11
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 13:20
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8081B
Analytical Date: 06/08/23 08:44
Analyst: AKM

Extraction Method: EPA 3510C
Extraction Date: 06/07/23 08:21

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/l	0.014	0.003	1	A
Lindane	ND		ug/l	0.014	0.003	1	A
Alpha-BHC	ND		ug/l	0.014	0.003	1	A
Beta-BHC	ND		ug/l	0.014	0.004	1	A
Heptachlor	ND		ug/l	0.014	0.002	1	A
Aldrin	ND		ug/l	0.014	0.002	1	A
Heptachlor epoxide	ND		ug/l	0.014	0.003	1	A
Endrin	ND		ug/l	0.029	0.003	1	A
Endrin aldehyde	ND		ug/l	0.029	0.006	1	A
Endrin ketone	ND		ug/l	0.029	0.003	1	A
Dieldrin	ND		ug/l	0.029	0.003	1	A
4,4'-DDE	ND		ug/l	0.029	0.003	1	A
4,4'-DDD	ND		ug/l	0.029	0.003	1	A
4,4'-DDT	ND		ug/l	0.029	0.003	1	A
Endosulfan I	ND		ug/l	0.014	0.002	1	A
Endosulfan II	ND		ug/l	0.029	0.004	1	A
Endosulfan sulfate	ND		ug/l	0.029	0.003	1	A
Methoxychlor	ND		ug/l	0.143	0.005	1	A
Toxaphene	ND		ug/l	0.143	0.045	1	A
cis-Chlordane	ND		ug/l	0.014	0.005	1	A
trans-Chlordane	ND		ug/l	0.014	0.004	1	A
Chlordane	ND		ug/l	0.143	0.033	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-09 Date Collected: 06/05/23 13:20

Client ID: GW-11 Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	46		30-150	A
Decachlorobiphenyl	30		30-150	A
2,4,5,6-Tetrachloro-m-xylene	44		30-150	B
Decachlorobiphenyl	**26**	Q	30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8081B
Analytical Date: 06/07/23 14:13
Analyst: MMG

Extraction Method: EPA 3546
Extraction Date: 06/06/23 15:03
Cleanup Method: EPA 3620B
Cleanup Date: 06/07/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/07/23

Parameter	Result	Qualifier	Units	RL	MDL	Column
Organochlorine Pesticides by GC - Westborough Lab for sample(s): 01-07 Batch: WG1787868-1						
Delta-BHC	ND		ug/kg	1.57	0.307	A
Lindane	ND		ug/kg	0.653	0.292	A
Alpha-BHC	ND		ug/kg	0.653	0.185	A
Beta-BHC	ND		ug/kg	1.57	0.594	A
Heptachlor	ND		ug/kg	0.783	0.351	A
Aldrin	ND		ug/kg	1.57	0.552	A
Heptachlor epoxide	ND		ug/kg	2.94	0.881	A
Endrin	ND		ug/kg	0.653	0.268	A
Endrin aldehyde	ND		ug/kg	1.96	0.685	A
Endrin ketone	ND		ug/kg	1.57	0.403	A
Dieldrin	ND		ug/kg	0.979	0.490	A
4,4'-DDE	ND		ug/kg	1.57	0.362	A
4,4'-DDD	ND		ug/kg	1.57	0.559	A
4,4'-DDT	ND		ug/kg	1.57	1.26	A
Endosulfan I	ND		ug/kg	1.57	0.370	A
Endosulfan II	ND		ug/kg	1.57	0.523	A
Endosulfan sulfate	ND		ug/kg	0.653	0.311	A
Methoxychlor	ND		ug/kg	2.94	0.914	A
Toxaphene	ND		ug/kg	29.4	8.22	A
cis-Chlordane	ND		ug/kg	1.96	0.546	A
trans-Chlordane	ND		ug/kg	1.96	0.517	A
Chlordane	ND		ug/kg	13.0	5.19	A

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8081B
Analytical Date: 06/07/23 14:13
Analyst: MMG

Extraction Method: EPA 3546
Extraction Date: 06/06/23 15:03
Cleanup Method: EPA 3620B
Cleanup Date: 06/07/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/07/23

Parameter	Result	Qualifier	Units	RL	MDL	Column
Organochlorine Pesticides by GC - Westborough Lab for sample(s): 01-07 Batch: WG1787868-1						

Surrogate	%Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	78		30-150	A
Decachlorobiphenyl	78		30-150	A
2,4,5,6-Tetrachloro-m-xylene	77		30-150	B
Decachlorobiphenyl	81		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8081B
Analytical Date: 06/07/23 16:58
Analyst: MMG

Extraction Method: EPA 3510C
Extraction Date: 06/07/23 01:56

Parameter	Result	Qualifier	Units	RL	MDL	Column
Organochlorine Pesticides by GC - Westborough Lab for sample(s): 08-09 Batch: WG1788020-1						
Delta-BHC	ND		ug/l	0.014	0.003	A
Lindane	ND		ug/l	0.014	0.003	A
Alpha-BHC	ND		ug/l	0.014	0.003	A
Beta-BHC	ND		ug/l	0.014	0.004	A
Heptachlor	ND		ug/l	0.014	0.002	A
Aldrin	ND		ug/l	0.014	0.002	A
Heptachlor epoxide	ND		ug/l	0.014	0.003	A
Endrin	ND		ug/l	0.029	0.003	A
Endrin aldehyde	ND		ug/l	0.029	0.006	A
Endrin ketone	ND		ug/l	0.029	0.003	A
Dieldrin	ND		ug/l	0.029	0.003	A
4,4'-DDE	ND		ug/l	0.029	0.003	A
4,4'-DDD	ND		ug/l	0.029	0.003	A
4,4'-DDT	ND		ug/l	0.029	0.003	A
Endosulfan I	ND		ug/l	0.014	0.002	A
Endosulfan II	ND		ug/l	0.029	0.004	A
Endosulfan sulfate	ND		ug/l	0.029	0.003	A
Methoxychlor	ND		ug/l	0.143	0.005	A
Toxaphene	ND		ug/l	0.143	0.045	A
cis-Chlordane	ND		ug/l	0.014	0.005	A
trans-Chlordane	ND		ug/l	0.014	0.004	A
Chlordane	ND		ug/l	0.143	0.033	A

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8081B
Analytical Date: 06/07/23 16:58
Analyst: MMG

Extraction Method: EPA 3510C
Extraction Date: 06/07/23 01:56

Parameter	Result	Qualifier	Units	RL	MDL	Column
Organochlorine Pesticides by GC - Westborough Lab for sample(s): 08-09 Batch: WG1788020-1						

Surrogate	%Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	46		30-150	A
Decachlorobiphenyl	52		30-150	A
2,4,5,6-Tetrachloro-m-xylene	45		30-150	B
Decachlorobiphenyl	49		30-150	B

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331226
Report Date: 06/13/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits	Column
Organochlorine Pesticides by GC - Westborough Lab Associated sample(s): 01-07 Batch: WG1787868-2 WG1787868-3									
Delta-BHC	93		86		30-150	8		30	A
Lindane	85		78		30-150	9		30	A
Alpha-BHC	89		82		30-150	8		30	A
Beta-BHC	94		88		30-150	7		30	A
Heptachlor	85		78		30-150	9		30	A
Aldrin	86		79		30-150	8		30	A
Heptachlor epoxide	81		75		30-150	8		30	A
Endrin	86		79		30-150	8		30	A
Endrin aldehyde	70		65		30-150	7		30	A
Endrin ketone	85		81		30-150	5		30	A
Dieldrin	93		85		30-150	9		30	A
4,4'-DDE	84		78		30-150	7		30	A
4,4'-DDD	91		84		30-150	8		30	A
4,4'-DDT	93		87		30-150	7		30	A
Endosulfan I	83		77		30-150	8		30	A
Endosulfan II	88		81		30-150	8		30	A
Endosulfan sulfate	80		75		30-150	6		30	A
Methoxychlor	82		79		30-150	4		30	A
cis-Chlordane	92		85		30-150	8		30	A
trans-Chlordane	96		89		30-150	8		30	A

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331226

Report Date: 06/13/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits

Organochlorine Pesticides by GC - Westborough Lab Associated sample(s): 01-07 Batch: WG1787868-2 WG1787868-3

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	75		71		30-150	A
Decachlorobiphenyl	74		76		30-150	A
2,4,5,6-Tetrachloro-m-xylene	74		70		30-150	B
Decachlorobiphenyl	76		77		30-150	B

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331226
Report Date: 06/13/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits	Column
Organochlorine Pesticides by GC - Westborough Lab Associated sample(s): 08-09 Batch: WG1788020-2 WG1788020-3									
Delta-BHC	62		64		30-150	3		20	A
Lindane	60		61		30-150	2		20	A
Alpha-BHC	62		66		30-150	5		20	A
Beta-BHC	66		71		30-150	7		20	A
Heptachlor	61		64		30-150	5		20	A
Aldrin	58		58		30-150	1		20	A
Heptachlor epoxide	59		61		30-150	2		20	A
Endrin	59		62		30-150	5		20	A
Endrin aldehyde	51		58		30-150	12		20	A
Endrin ketone	64		67		30-150	5		20	A
Dieldrin	63		65		30-150	3		20	A
4,4'-DDE	59		60		30-150	1		20	A
4,4'-DDD	63		65		30-150	3		20	A
4,4'-DDT	62		105		30-150	**52**	Q	20	A
Endosulfan I	60		71		30-150	17		20	A
Endosulfan II	61		63		30-150	4		20	A
Endosulfan sulfate	58		60		30-150	4		20	A
Methoxychlor	68		74		30-150	9		20	A
cis-Chlordane	64		63		30-150	2		20	A
trans-Chlordane	68		73		30-150	8		20	A

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331226

Report Date: 06/13/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Organochlorine Pesticides by GC - Westborough Lab Associated sample(s): 08-09 Batch: WG1788020-2 WG1788020-3								

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	55		56		30-150	A
Decachlorobiphenyl	63		65		30-150	A
2,4,5,6-Tetrachloro-m-xylene	54		55		30-150	B
Decachlorobiphenyl	61		63		30-150	B

METALS

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-01 Date Collected: 06/05/23 10:00

Client ID: SB-20G (1.5-2) Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Soil

Percent Solids: 94%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	6380		mg/kg	8.28	2.24	2	06/09/23 06:30	06/12/23 17:14	EPA 3050B	1,6010D	TAA
Antimony, Total	ND		mg/kg	4.14	0.315	2	06/09/23 06:30	06/12/23 17:14	EPA 3050B	1,6010D	TAA
Arsenic, Total	0.590	J	mg/kg	0.828	0.172	2	06/09/23 06:30	06/12/23 17:14	EPA 3050B	1,6010D	TAA
Barium, Total	56.8		mg/kg	0.828	0.144	2	06/09/23 06:30	06/12/23 17:14	EPA 3050B	1,6010D	TAA
Beryllium, Total	0.373	J	mg/kg	0.414	0.027	2	06/09/23 06:30	06/12/23 17:14	EPA 3050B	1,6010D	TAA
Cadmium, Total	0.172	J	mg/kg	0.828	0.081	2	06/09/23 06:30	06/12/23 17:14	EPA 3050B	1,6010D	TAA
Calcium, Total	17700		mg/kg	8.28	2.90	2	06/09/23 06:30	06/12/23 17:14	EPA 3050B	1,6010D	TAA
Chromium, Total	14.0		mg/kg	0.828	0.080	2	06/09/23 06:30	06/12/23 17:14	EPA 3050B	1,6010D	TAA
Cobalt, Total	6.10		mg/kg	1.66	0.138	2	06/09/23 06:30	06/12/23 17:14	EPA 3050B	1,6010D	TAA
Copper, Total	15.0		mg/kg	0.828	0.214	2	06/09/23 06:30	06/12/23 17:14	EPA 3050B	1,6010D	TAA
Iron, Total	12900		mg/kg	4.14	0.748	2	06/09/23 06:30	06/12/23 17:14	EPA 3050B	1,6010D	TAA
Lead, Total	4.66		mg/kg	4.14	0.222	2	06/09/23 06:30	06/12/23 17:14	EPA 3050B	1,6010D	TAA
Magnesium, Total	10900		mg/kg	8.28	1.28	2	06/09/23 06:30	06/12/23 17:14	EPA 3050B	1,6010D	TAA
Manganese, Total	179		mg/kg	0.828	0.132	2	06/09/23 06:30	06/12/23 17:14	EPA 3050B	1,6010D	TAA
Mercury, Total	ND		mg/kg	0.067	0.044	1	06/09/23 11:00	06/13/23 15:08	EPA 7471B	1,7471B	DMB
Nickel, Total	11.5		mg/kg	2.07	0.200	2	06/09/23 06:30	06/12/23 17:14	EPA 3050B	1,6010D	TAA
Potassium, Total	2770		mg/kg	207	11.9	2	06/09/23 06:30	06/12/23 17:14	EPA 3050B	1,6010D	TAA
Selenium, Total	ND		mg/kg	1.66	0.214	2	06/09/23 06:30	06/12/23 17:14	EPA 3050B	1,6010D	TAA
Silver, Total	ND		mg/kg	0.414	0.234	2	06/09/23 06:30	06/12/23 17:14	EPA 3050B	1,6010D	TAA
Sodium, Total	168		mg/kg	166	2.61	2	06/09/23 06:30	06/12/23 17:14	EPA 3050B	1,6010D	TAA
Thallium, Total	ND		mg/kg	1.66	0.261	2	06/09/23 06:30	06/12/23 17:14	EPA 3050B	1,6010D	TAA
Vanadium, Total	20.4		mg/kg	0.828	0.168	2	06/09/23 06:30	06/12/23 17:14	EPA 3050B	1,6010D	TAA
Zinc, Total	31.9		mg/kg	4.14	0.243	2	06/09/23 06:30	06/12/23 17:14	EPA 3050B	1,6010D	TAA

Project Name: 100 MAIN ST.
Lab Number: L2331226
Project Number: 12461
Report Date: 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-02
Client ID: SB-21G (9-9.5)
Sample Location: WHITE PLAINS, NY
Date Collected: 06/05/23 11:15
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Percent Solids: 91%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	9780		mg/kg	8.59	2.32	2	06/09/23 06:30	06/12/23 17:16	EPA 3050B	1,6010D	TAA
Antimony, Total	ND		mg/kg	4.30	0.326	2	06/09/23 06:30	06/12/23 17:16	EPA 3050B	1,6010D	TAA
Arsenic, Total	0.602	J	mg/kg	0.859	0.179	2	06/09/23 06:30	06/12/23 17:16	EPA 3050B	1,6010D	TAA
Barium, Total	74.9		mg/kg	0.859	0.150	2	06/09/23 06:30	06/12/23 17:16	EPA 3050B	1,6010D	TAA
Beryllium, Total	0.578		mg/kg	0.430	0.028	2	06/09/23 06:30	06/12/23 17:16	EPA 3050B	1,6010D	TAA
Cadmium, Total	0.144	J	mg/kg	0.859	0.084	2	06/09/23 06:30	06/12/23 17:16	EPA 3050B	1,6010D	TAA
Calcium, Total	7350		mg/kg	8.59	3.01	2	06/09/23 06:30	06/12/23 17:16	EPA 3050B	1,6010D	TAA
Chromium, Total	18.8		mg/kg	0.859	0.083	2	06/09/23 06:30	06/12/23 17:16	EPA 3050B	1,6010D	TAA
Cobalt, Total	8.14		mg/kg	1.72	0.143	2	06/09/23 06:30	06/12/23 17:16	EPA 3050B	1,6010D	TAA
Copper, Total	15.7		mg/kg	0.859	0.222	2	06/09/23 06:30	06/12/23 17:16	EPA 3050B	1,6010D	TAA
Iron, Total	17500		mg/kg	4.30	0.776	2	06/09/23 06:30	06/12/23 17:16	EPA 3050B	1,6010D	TAA
Lead, Total	4.18	J	mg/kg	4.30	0.230	2	06/09/23 06:30	06/12/23 17:16	EPA 3050B	1,6010D	TAA
Magnesium, Total	6420		mg/kg	8.59	1.32	2	06/09/23 06:30	06/12/23 17:16	EPA 3050B	1,6010D	TAA
Manganese, Total	160		mg/kg	0.859	0.137	2	06/09/23 06:30	06/12/23 17:16	EPA 3050B	1,6010D	TAA
Mercury, Total	ND		mg/kg	0.069	0.045	1	06/09/23 11:00	06/13/23 15:12	EPA 7471B	1,7471B	DMB
Nickel, Total	14.2		mg/kg	2.15	0.208	2	06/09/23 06:30	06/12/23 17:16	EPA 3050B	1,6010D	TAA
Potassium, Total	3830		mg/kg	215	12.4	2	06/09/23 06:30	06/12/23 17:16	EPA 3050B	1,6010D	TAA
Selenium, Total	ND		mg/kg	1.72	0.222	2	06/09/23 06:30	06/12/23 17:16	EPA 3050B	1,6010D	TAA
Silver, Total	ND		mg/kg	0.430	0.243	2	06/09/23 06:30	06/12/23 17:16	EPA 3050B	1,6010D	TAA
Sodium, Total	158	J	mg/kg	172	2.71	2	06/09/23 06:30	06/12/23 17:16	EPA 3050B	1,6010D	TAA
Thallium, Total	ND		mg/kg	1.72	0.271	2	06/09/23 06:30	06/12/23 17:16	EPA 3050B	1,6010D	TAA
Vanadium, Total	27.7		mg/kg	0.859	0.174	2	06/09/23 06:30	06/12/23 17:16	EPA 3050B	1,6010D	TAA
Zinc, Total	41.0		mg/kg	4.30	0.252	2	06/09/23 06:30	06/12/23 17:16	EPA 3050B	1,6010D	TAA

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-03 Date Collected: 06/05/23 11:20

Client ID: SB-21G (12-12.5) Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Soil

Percent Solids: 82%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	5380		mg/kg	9.42	2.54	2	06/09/23 06:30	06/12/23 18:01	EPA 3050B	1,6010D	TAA
Antimony, Total	ND		mg/kg	4.71	0.358	2	06/09/23 06:30	06/12/23 18:01	EPA 3050B	1,6010D	TAA
Arsenic, Total	0.489	J	mg/kg	0.942	0.196	2	06/09/23 06:30	06/12/23 18:01	EPA 3050B	1,6010D	TAA
Barium, Total	49.1		mg/kg	0.942	0.164	2	06/09/23 06:30	06/12/23 18:01	EPA 3050B	1,6010D	TAA
Beryllium, Total	0.305	J	mg/kg	0.471	0.031	2	06/09/23 06:30	06/12/23 18:01	EPA 3050B	1,6010D	TAA
Cadmium, Total	0.150	J	mg/kg	0.942	0.092	2	06/09/23 06:30	06/12/23 18:01	EPA 3050B	1,6010D	TAA
Calcium, Total	20400		mg/kg	9.42	3.30	2	06/09/23 06:30	06/12/23 18:01	EPA 3050B	1,6010D	TAA
Chromium, Total	12.2		mg/kg	0.942	0.091	2	06/09/23 06:30	06/12/23 18:01	EPA 3050B	1,6010D	TAA
Cobalt, Total	5.62		mg/kg	1.88	0.156	2	06/09/23 06:30	06/12/23 18:01	EPA 3050B	1,6010D	TAA
Copper, Total	14.4		mg/kg	0.942	0.243	2	06/09/23 06:30	06/12/23 18:01	EPA 3050B	1,6010D	TAA
Iron, Total	11800		mg/kg	4.71	0.851	2	06/09/23 06:30	06/12/23 18:01	EPA 3050B	1,6010D	TAA
Lead, Total	2.30	J	mg/kg	4.71	0.252	2	06/09/23 06:30	06/12/23 18:01	EPA 3050B	1,6010D	TAA
Magnesium, Total	12800		mg/kg	9.42	1.45	2	06/09/23 06:30	06/12/23 18:01	EPA 3050B	1,6010D	TAA
Manganese, Total	204		mg/kg	0.942	0.150	2	06/09/23 06:30	06/12/23 18:01	EPA 3050B	1,6010D	TAA
Mercury, Total	ND		mg/kg	0.077	0.050	1	06/09/23 11:00	06/13/23 15:15	EPA 7471B	1,7471B	DMB
Nickel, Total	10.2		mg/kg	2.36	0.228	2	06/09/23 06:30	06/12/23 18:01	EPA 3050B	1,6010D	TAA
Potassium, Total	2350		mg/kg	236	13.6	2	06/09/23 06:30	06/12/23 18:01	EPA 3050B	1,6010D	TAA
Selenium, Total	ND		mg/kg	1.88	0.243	2	06/09/23 06:30	06/12/23 18:01	EPA 3050B	1,6010D	TAA
Silver, Total	ND		mg/kg	0.471	0.267	2	06/09/23 06:30	06/12/23 18:01	EPA 3050B	1,6010D	TAA
Sodium, Total	139	J	mg/kg	188	2.97	2	06/09/23 06:30	06/12/23 18:01	EPA 3050B	1,6010D	TAA
Thallium, Total	ND		mg/kg	1.88	0.297	2	06/09/23 06:30	06/12/23 18:01	EPA 3050B	1,6010D	TAA
Vanadium, Total	17.3		mg/kg	0.942	0.191	2	06/09/23 06:30	06/12/23 18:01	EPA 3050B	1,6010D	TAA
Zinc, Total	27.9		mg/kg	4.71	0.276	2	06/09/23 06:30	06/12/23 18:01	EPA 3050B	1,6010D	TAA

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-04 Date Collected: 06/05/23 12:15

Client ID: SB-22G (7-7.5) Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Soil

Percent Solids: 80%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	12500		mg/kg	9.86	2.66	2	06/09/23 06:30	06/12/23 18:04	EPA 3050B	1,6010D	TAA
Antimony, Total	ND		mg/kg	4.93	0.375	2	06/09/23 06:30	06/12/23 18:04	EPA 3050B	1,6010D	TAA
Arsenic, Total	0.846	J	mg/kg	0.986	0.205	2	06/09/23 06:30	06/12/23 18:04	EPA 3050B	1,6010D	TAA
Barium, Total	87.2		mg/kg	0.986	0.172	2	06/09/23 06:30	06/12/23 18:04	EPA 3050B	1,6010D	TAA
Beryllium, Total	0.646		mg/kg	0.493	0.033	2	06/09/23 06:30	06/12/23 18:04	EPA 3050B	1,6010D	TAA
Cadmium, Total	0.201	J	mg/kg	0.986	0.097	2	06/09/23 06:30	06/12/23 18:04	EPA 3050B	1,6010D	TAA
Calcium, Total	2120		mg/kg	9.86	3.45	2	06/09/23 06:30	06/12/23 18:04	EPA 3050B	1,6010D	TAA
Chromium, Total	22.2		mg/kg	0.986	0.095	2	06/09/23 06:30	06/12/23 18:04	EPA 3050B	1,6010D	TAA
Cobalt, Total	10.0		mg/kg	1.97	0.164	2	06/09/23 06:30	06/12/23 18:04	EPA 3050B	1,6010D	TAA
Copper, Total	22.6		mg/kg	0.986	0.254	2	06/09/23 06:30	06/12/23 18:04	EPA 3050B	1,6010D	TAA
Iron, Total	20600		mg/kg	4.93	0.890	2	06/09/23 06:30	06/12/23 18:04	EPA 3050B	1,6010D	TAA
Lead, Total	4.63	J	mg/kg	4.93	0.264	2	06/09/23 06:30	06/12/23 18:04	EPA 3050B	1,6010D	TAA
Magnesium, Total	6370		mg/kg	9.86	1.52	2	06/09/23 06:30	06/12/23 18:04	EPA 3050B	1,6010D	TAA
Manganese, Total	249		mg/kg	0.986	0.157	2	06/09/23 06:30	06/12/23 18:04	EPA 3050B	1,6010D	TAA
Mercury, Total	ND		mg/kg	0.081	0.053	1	06/09/23 11:00	06/13/23 15:18	EPA 7471B	1,7471B	DMB
Nickel, Total	18.7		mg/kg	2.46	0.239	2	06/09/23 06:30	06/12/23 18:04	EPA 3050B	1,6010D	TAA
Potassium, Total	4630		mg/kg	246	14.2	2	06/09/23 06:30	06/12/23 18:04	EPA 3050B	1,6010D	TAA
Selenium, Total	ND		mg/kg	1.97	0.254	2	06/09/23 06:30	06/12/23 18:04	EPA 3050B	1,6010D	TAA
Silver, Total	ND		mg/kg	0.493	0.279	2	06/09/23 06:30	06/12/23 18:04	EPA 3050B	1,6010D	TAA
Sodium, Total	231		mg/kg	197	3.11	2	06/09/23 06:30	06/12/23 18:04	EPA 3050B	1,6010D	TAA
Thallium, Total	ND		mg/kg	1.97	0.311	2	06/09/23 06:30	06/12/23 18:04	EPA 3050B	1,6010D	TAA
Vanadium, Total	33.7		mg/kg	0.986	0.200	2	06/09/23 06:30	06/12/23 18:04	EPA 3050B	1,6010D	TAA
Zinc, Total	48.5		mg/kg	4.93	0.289	2	06/09/23 06:30	06/12/23 18:04	EPA 3050B	1,6010D	TAA

Project Name: 100 MAIN ST.
Lab Number: L2331226
Project Number: 12461
Report Date: 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-05
Client ID: SB-23G (9.5-10)
Sample Location: WHITE PLAINS, NY
Date Collected: 06/05/23 12:50
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Percent Solids: 87%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	5180		mg/kg	8.75	2.36	2	06/09/23 06:30	06/12/23 18:07	EPA 3050B	1,6010D	TAA
Antimony, Total	ND		mg/kg	4.37	0.332	2	06/09/23 06:30	06/12/23 18:07	EPA 3050B	1,6010D	TAA
Arsenic, Total	0.564	J	mg/kg	0.875	0.182	2	06/09/23 06:30	06/12/23 18:07	EPA 3050B	1,6010D	TAA
Barium, Total	48.7		mg/kg	0.875	0.152	2	06/09/23 06:30	06/12/23 18:07	EPA 3050B	1,6010D	TAA
Beryllium, Total	0.305	J	mg/kg	0.437	0.029	2	06/09/23 06:30	06/12/23 18:07	EPA 3050B	1,6010D	TAA
Cadmium, Total	0.114	J	mg/kg	0.875	0.086	2	06/09/23 06:30	06/12/23 18:07	EPA 3050B	1,6010D	TAA
Calcium, Total	20000		mg/kg	8.75	3.06	2	06/09/23 06:30	06/12/23 18:07	EPA 3050B	1,6010D	TAA
Chromium, Total	12.4		mg/kg	0.875	0.084	2	06/09/23 06:30	06/12/23 18:07	EPA 3050B	1,6010D	TAA
Cobalt, Total	5.65		mg/kg	1.75	0.145	2	06/09/23 06:30	06/12/23 18:07	EPA 3050B	1,6010D	TAA
Copper, Total	14.4		mg/kg	0.875	0.226	2	06/09/23 06:30	06/12/23 18:07	EPA 3050B	1,6010D	TAA
Iron, Total	11400		mg/kg	4.37	0.790	2	06/09/23 06:30	06/12/23 18:07	EPA 3050B	1,6010D	TAA
Lead, Total	2.55	J	mg/kg	4.37	0.234	2	06/09/23 06:30	06/12/23 18:07	EPA 3050B	1,6010D	TAA
Magnesium, Total	11700		mg/kg	8.75	1.35	2	06/09/23 06:30	06/12/23 18:07	EPA 3050B	1,6010D	TAA
Manganese, Total	202		mg/kg	0.875	0.139	2	06/09/23 06:30	06/12/23 18:07	EPA 3050B	1,6010D	TAA
Mercury, Total	ND		mg/kg	0.073	0.048	1	06/09/23 11:00	06/13/23 15:28	EPA 7471B	1,7471B	DMB
Nickel, Total	11.3		mg/kg	2.19	0.212	2	06/09/23 06:30	06/12/23 18:07	EPA 3050B	1,6010D	TAA
Potassium, Total	2300		mg/kg	219	12.6	2	06/09/23 06:30	06/12/23 18:07	EPA 3050B	1,6010D	TAA
Selenium, Total	ND		mg/kg	1.75	0.226	2	06/09/23 06:30	06/12/23 18:07	EPA 3050B	1,6010D	TAA
Silver, Total	ND		mg/kg	0.437	0.248	2	06/09/23 06:30	06/12/23 18:07	EPA 3050B	1,6010D	TAA
Sodium, Total	133	J	mg/kg	175	2.76	2	06/09/23 06:30	06/12/23 18:07	EPA 3050B	1,6010D	TAA
Thallium, Total	ND		mg/kg	1.75	0.276	2	06/09/23 06:30	06/12/23 18:07	EPA 3050B	1,6010D	TAA
Vanadium, Total	17.3		mg/kg	0.875	0.178	2	06/09/23 06:30	06/12/23 18:07	EPA 3050B	1,6010D	TAA
Zinc, Total	25.3		mg/kg	4.37	0.256	2	06/09/23 06:30	06/12/23 18:07	EPA 3050B	1,6010D	TAA

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-06 Date Collected: 06/05/23 12:30

Client ID: SB-24G (7.5-8) Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Soil

Percent Solids: 85%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	8440		mg/kg	9.16	2.47	2	06/09/23 06:30	06/12/23 18:09	EPA 3050B	1,6010D	TAA
Antimony, Total	ND		mg/kg	4.58	0.348	2	06/09/23 06:30	06/12/23 18:09	EPA 3050B	1,6010D	TAA
Arsenic, Total	0.755	J	mg/kg	0.916	0.190	2	06/09/23 06:30	06/12/23 18:09	EPA 3050B	1,6010D	TAA
Barium, Total	58.7		mg/kg	0.916	0.159	2	06/09/23 06:30	06/12/23 18:09	EPA 3050B	1,6010D	TAA
Beryllium, Total	0.445	J	mg/kg	0.458	0.030	2	06/09/23 06:30	06/12/23 18:09	EPA 3050B	1,6010D	TAA
Cadmium, Total	0.171	J	mg/kg	0.916	0.090	2	06/09/23 06:30	06/12/23 18:09	EPA 3050B	1,6010D	TAA
Calcium, Total	1820		mg/kg	9.16	3.21	2	06/09/23 06:30	06/12/23 18:09	EPA 3050B	1,6010D	TAA
Chromium, Total	15.5		mg/kg	0.916	0.088	2	06/09/23 06:30	06/12/23 18:09	EPA 3050B	1,6010D	TAA
Cobalt, Total	6.73		mg/kg	1.83	0.152	2	06/09/23 06:30	06/12/23 18:09	EPA 3050B	1,6010D	TAA
Copper, Total	15.1		mg/kg	0.916	0.236	2	06/09/23 06:30	06/12/23 18:09	EPA 3050B	1,6010D	TAA
Iron, Total	14800		mg/kg	4.58	0.827	2	06/09/23 06:30	06/12/23 18:09	EPA 3050B	1,6010D	TAA
Lead, Total	3.20	J	mg/kg	4.58	0.246	2	06/09/23 06:30	06/12/23 18:09	EPA 3050B	1,6010D	TAA
Magnesium, Total	3950		mg/kg	9.16	1.41	2	06/09/23 06:30	06/12/23 18:09	EPA 3050B	1,6010D	TAA
Manganese, Total	226		mg/kg	0.916	0.146	2	06/09/23 06:30	06/12/23 18:09	EPA 3050B	1,6010D	TAA
Mercury, Total	ND		mg/kg	0.074	0.048	1	06/09/23 11:00	06/13/23 15:32	EPA 7471B	1,7471B	DMB
Nickel, Total	13.0		mg/kg	2.29	0.222	2	06/09/23 06:30	06/12/23 18:09	EPA 3050B	1,6010D	TAA
Potassium, Total	2630		mg/kg	229	13.2	2	06/09/23 06:30	06/12/23 18:09	EPA 3050B	1,6010D	TAA
Selenium, Total	ND		mg/kg	1.83	0.236	2	06/09/23 06:30	06/12/23 18:09	EPA 3050B	1,6010D	TAA
Silver, Total	ND		mg/kg	0.458	0.259	2	06/09/23 06:30	06/12/23 18:09	EPA 3050B	1,6010D	TAA
Sodium, Total	111	J	mg/kg	183	2.89	2	06/09/23 06:30	06/12/23 18:09	EPA 3050B	1,6010D	TAA
Thallium, Total	ND		mg/kg	1.83	0.289	2	06/09/23 06:30	06/12/23 18:09	EPA 3050B	1,6010D	TAA
Vanadium, Total	23.0		mg/kg	0.916	0.186	2	06/09/23 06:30	06/12/23 18:09	EPA 3050B	1,6010D	TAA
Zinc, Total	29.4		mg/kg	4.58	0.268	2	06/09/23 06:30	06/12/23 18:09	EPA 3050B	1,6010D	TAA

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-07 Date Collected: 06/05/23 10:40

Client ID: SB-25G (9.5-10) Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Soil

Percent Solids: 92%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	6240		mg/kg	8.67	2.34	2	06/09/23 06:30	06/12/23 18:12	EPA 3050B	1,6010D	TAA
Antimony, Total	ND		mg/kg	4.33	0.329	2	06/09/23 06:30	06/12/23 18:12	EPA 3050B	1,6010D	TAA
Arsenic, Total	0.698	J	mg/kg	0.867	0.180	2	06/09/23 06:30	06/12/23 18:12	EPA 3050B	1,6010D	TAA
Barium, Total	49.4		mg/kg	0.867	0.151	2	06/09/23 06:30	06/12/23 18:12	EPA 3050B	1,6010D	TAA
Beryllium, Total	0.332	J	mg/kg	0.433	0.029	2	06/09/23 06:30	06/12/23 18:12	EPA 3050B	1,6010D	TAA
Cadmium, Total	0.683	J	mg/kg	0.867	0.085	2	06/09/23 06:30	06/12/23 18:12	EPA 3050B	1,6010D	TAA
Calcium, Total	12200		mg/kg	8.67	3.03	2	06/09/23 06:30	06/12/23 18:12	EPA 3050B	1,6010D	TAA
Chromium, Total	13.4		mg/kg	0.867	0.083	2	06/09/23 06:30	06/12/23 18:12	EPA 3050B	1,6010D	TAA
Cobalt, Total	5.66		mg/kg	1.73	0.144	2	06/09/23 06:30	06/12/23 18:12	EPA 3050B	1,6010D	TAA
Copper, Total	14.1		mg/kg	0.867	0.224	2	06/09/23 06:30	06/12/23 18:12	EPA 3050B	1,6010D	TAA
Iron, Total	12100		mg/kg	4.33	0.783	2	06/09/23 06:30	06/12/23 18:12	EPA 3050B	1,6010D	TAA
Lead, Total	12.8		mg/kg	4.33	0.232	2	06/09/23 06:30	06/12/23 18:12	EPA 3050B	1,6010D	TAA
Magnesium, Total	8370		mg/kg	8.67	1.33	2	06/09/23 06:30	06/12/23 18:12	EPA 3050B	1,6010D	TAA
Manganese, Total	142		mg/kg	0.867	0.138	2	06/09/23 06:30	06/12/23 18:12	EPA 3050B	1,6010D	TAA
Mercury, Total	ND		mg/kg	0.070	0.046	1	06/09/23 11:00	06/13/23 15:35	EPA 7471B	1,7471B	DMB
Nickel, Total	10.9		mg/kg	2.17	0.210	2	06/09/23 06:30	06/12/23 18:12	EPA 3050B	1,6010D	TAA
Potassium, Total	2000		mg/kg	217	12.5	2	06/09/23 06:30	06/12/23 18:12	EPA 3050B	1,6010D	TAA
Selenium, Total	ND		mg/kg	1.73	0.224	2	06/09/23 06:30	06/12/23 18:12	EPA 3050B	1,6010D	TAA
Silver, Total	ND		mg/kg	0.433	0.245	2	06/09/23 06:30	06/12/23 18:12	EPA 3050B	1,6010D	TAA
Sodium, Total	128	J	mg/kg	173	2.73	2	06/09/23 06:30	06/12/23 18:12	EPA 3050B	1,6010D	TAA
Thallium, Total	ND		mg/kg	1.73	0.273	2	06/09/23 06:30	06/12/23 18:12	EPA 3050B	1,6010D	TAA
Vanadium, Total	19.7		mg/kg	0.867	0.176	2	06/09/23 06:30	06/12/23 18:12	EPA 3050B	1,6010D	TAA
Zinc, Total	33.0		mg/kg	4.33	0.254	2	06/09/23 06:30	06/12/23 18:12	EPA 3050B	1,6010D	TAA

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-08 Date Collected: 06/05/23 12:00

Client ID: GW-10 Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Water

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	56.6		mg/l	0.0100	0.00327	1	06/07/23 23:00	06/08/23 16:41	EPA 3005A	1,6020B	SMV
Antimony, Total	ND		mg/l	0.00400	0.00042	1	06/07/23 23:00	06/08/23 16:41	EPA 3005A	1,6020B	SMV
Arsenic, Total	0.00826		mg/l	0.00050	0.00016	1	06/07/23 23:00	06/08/23 16:41	EPA 3005A	1,6020B	SMV
Barium, Total	1.905		mg/l	0.00050	0.00017	1	06/07/23 23:00	06/08/23 16:41	EPA 3005A	1,6020B	SMV
Beryllium, Total	0.00189		mg/l	0.00050	0.00010	1	06/07/23 23:00	06/08/23 16:41	EPA 3005A	1,6020B	SMV
Cadmium, Total	0.00155		mg/l	0.00020	0.00005	1	06/07/23 23:00	06/08/23 16:41	EPA 3005A	1,6020B	SMV
Calcium, Total	480.		mg/l	1.00	0.394	10	06/07/23 23:00	06/08/23 17:56	EPA 3005A	1,6020B	SMV
Chromium, Total	0.1772		mg/l	0.00100	0.00017	1	06/07/23 23:00	06/08/23 16:41	EPA 3005A	1,6020B	SMV
Cobalt, Total	0.07862		mg/l	0.00050	0.00016	1	06/07/23 23:00	06/08/23 16:41	EPA 3005A	1,6020B	SMV
Copper, Total	0.2346		mg/l	0.00100	0.00038	1	06/07/23 23:00	06/08/23 16:41	EPA 3005A	1,6020B	SMV
Iron, Total	124.		mg/l	0.0500	0.0191	1	06/07/23 23:00	06/08/23 16:41	EPA 3005A	1,6020B	SMV
Lead, Total	0.06899		mg/l	0.00100	0.00034	1	06/07/23 23:00	06/08/23 16:41	EPA 3005A	1,6020B	SMV
Magnesium, Total	152.		mg/l	0.0700	0.0242	1	06/07/23 23:00	06/08/23 16:41	EPA 3005A	1,6020B	SMV
Manganese, Total	4.414		mg/l	0.00100	0.00044	1	06/07/23 23:00	06/08/23 16:41	EPA 3005A	1,6020B	SMV
Mercury, Total	ND		mg/l	0.00020	0.00009	1	06/08/23 00:15	06/13/23 14:15	EPA 7470A	1,7470A	DMB
Nickel, Total	0.1234		mg/l	0.00200	0.00055	1	06/07/23 23:00	06/08/23 16:41	EPA 3005A	1,6020B	SMV
Potassium, Total	38.5		mg/l	0.100	0.0309	1	06/07/23 23:00	06/08/23 16:41	EPA 3005A	1,6020B	SMV
Selenium, Total	0.00812		mg/l	0.00500	0.00173	1	06/07/23 23:00	06/08/23 16:41	EPA 3005A	1,6020B	SMV
Silver, Total	0.00036	J	mg/l	0.00040	0.00016	1	06/07/23 23:00	06/08/23 16:41	EPA 3005A	1,6020B	SMV
Sodium, Total	160.		mg/l	0.100	0.0293	1	06/07/23 23:00	06/08/23 16:41	EPA 3005A	1,6020B	SMV
Thallium, Total	0.00135		mg/l	0.00100	0.00014	1	06/07/23 23:00	06/08/23 16:41	EPA 3005A	1,6020B	SMV
Vanadium, Total	0.1295		mg/l	0.00500	0.00157	1	06/07/23 23:00	06/08/23 16:41	EPA 3005A	1,6020B	SMV
Zinc, Total	0.2455		mg/l	0.01000	0.00341	1	06/07/23 23:00	06/08/23 16:41	EPA 3005A	1,6020B	SMV

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-09 Date Collected: 06/05/23 13:20

Client ID: GW-11 Date Received: 06/05/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Water

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	102.		mg/l	0.0100	0.00327	1	06/07/23 23:00	06/08/23 16:46	EPA 3005A	1,6020B	SMV
Antimony, Total	ND		mg/l	0.00400	0.00042	1	06/07/23 23:00	06/08/23 16:46	EPA 3005A	1,6020B	SMV
Arsenic, Total	0.01544		mg/l	0.00050	0.00016	1	06/07/23 23:00	06/08/23 16:46	EPA 3005A	1,6020B	SMV
Barium, Total	4.007		mg/l	0.00050	0.00017	1	06/07/23 23:00	06/08/23 16:46	EPA 3005A	1,6020B	SMV
Beryllium, Total	0.00242		mg/l	0.00050	0.00010	1	06/07/23 23:00	06/08/23 16:46	EPA 3005A	1,6020B	SMV
Cadmium, Total	0.00363		mg/l	0.00020	0.00005	1	06/07/23 23:00	06/08/23 16:46	EPA 3005A	1,6020B	SMV
Calcium, Total	980.		mg/l	1.00	0.394	10	06/07/23 23:00	06/08/23 18:01	EPA 3005A	1,6020B	SMV
Chromium, Total	0.2727		mg/l	0.00100	0.00017	1	06/07/23 23:00	06/08/23 16:46	EPA 3005A	1,6020B	SMV
Cobalt, Total	0.1616		mg/l	0.00050	0.00016	1	06/07/23 23:00	06/08/23 16:46	EPA 3005A	1,6020B	SMV
Copper, Total	0.6209		mg/l	0.00100	0.00038	1	06/07/23 23:00	06/08/23 16:46	EPA 3005A	1,6020B	SMV
Iron, Total	260.		mg/l	0.0500	0.0191	1	06/07/23 23:00	06/08/23 16:46	EPA 3005A	1,6020B	SMV
Lead, Total	0.1640		mg/l	0.00100	0.00034	1	06/07/23 23:00	06/08/23 16:46	EPA 3005A	1,6020B	SMV
Magnesium, Total	297.		mg/l	0.0700	0.0242	1	06/07/23 23:00	06/08/23 16:46	EPA 3005A	1,6020B	SMV
Manganese, Total	22.69		mg/l	0.01000	0.00440	10	06/07/23 23:00	06/08/23 18:01	EPA 3005A	1,6020B	SMV
Mercury, Total	ND		mg/l	0.00020	0.00009	1	06/08/23 00:15	06/13/23 14:19	EPA 7470A	1,7470A	DMB
Nickel, Total	0.3389		mg/l	0.00200	0.00055	1	06/07/23 23:00	06/08/23 16:46	EPA 3005A	1,6020B	SMV
Potassium, Total	83.1		mg/l	0.100	0.0309	1	06/07/23 23:00	06/08/23 16:46	EPA 3005A	1,6020B	SMV
Selenium, Total	0.0143		mg/l	0.00500	0.00173	1	06/07/23 23:00	06/08/23 16:46	EPA 3005A	1,6020B	SMV
Silver, Total	0.00114		mg/l	0.00040	0.00016	1	06/07/23 23:00	06/08/23 16:46	EPA 3005A	1,6020B	SMV
Sodium, Total	337.		mg/l	0.100	0.0293	1	06/07/23 23:00	06/08/23 16:46	EPA 3005A	1,6020B	SMV
Thallium, Total	0.00366		mg/l	0.00100	0.00014	1	06/07/23 23:00	06/08/23 16:46	EPA 3005A	1,6020B	SMV
Vanadium, Total	0.2260		mg/l	0.00500	0.00157	1	06/07/23 23:00	06/08/23 16:46	EPA 3005A	1,6020B	SMV
Zinc, Total	0.4108		mg/l	0.01000	0.00341	1	06/07/23 23:00	06/08/23 16:46	EPA 3005A	1,6020B	SMV

Project Name: 100 MAIN ST. **Lab Number:** L2331226

Project Number: 12461 **Report Date:** 06/13/23

Method Blank Analysis
Batch Quality Control

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
Total Metals - Mansfield Lab for sample(s): 08-09 Batch: WG1788389-1										
Aluminum, Total	ND		mg/l	0.0100	0.00327	1	06/07/23 23:00	06/08/23 14:06	1,6020B	SMV
Antimony, Total	ND		mg/l	0.00400	0.00042	1	06/07/23 23:00	06/08/23 14:06	1,6020B	SMV
Arsenic, Total	ND		mg/l	0.00050	0.00016	1	06/07/23 23:00	06/08/23 14:06	1,6020B	SMV
Barium, Total	ND		mg/l	0.00050	0.00017	1	06/07/23 23:00	06/08/23 14:06	1,6020B	SMV
Beryllium, Total	ND		mg/l	0.00050	0.00010	1	06/07/23 23:00	06/08/23 14:06	1,6020B	SMV
Cadmium, Total	ND		mg/l	0.00020	0.00005	1	06/07/23 23:00	06/08/23 14:06	1,6020B	SMV
Calcium, Total	ND		mg/l	0.100	0.0394	1	06/07/23 23:00	06/08/23 14:06	1,6020B	SMV
Chromium, Total	ND		mg/l	0.00100	0.00017	1	06/07/23 23:00	06/08/23 14:06	1,6020B	SMV
Cobalt, Total	ND		mg/l	0.00050	0.00016	1	06/07/23 23:00	06/08/23 14:06	1,6020B	SMV
Copper, Total	ND		mg/l	0.00100	0.00038	1	06/07/23 23:00	06/08/23 14:06	1,6020B	SMV
Iron, Total	ND		mg/l	0.0500	0.0191	1	06/07/23 23:00	06/08/23 14:06	1,6020B	SMV
Lead, Total	ND		mg/l	0.00100	0.00034	1	06/07/23 23:00	06/08/23 14:06	1,6020B	SMV
Magnesium, Total	ND		mg/l	0.0700	0.0242	1	06/07/23 23:00	06/08/23 14:06	1,6020B	SMV
Manganese, Total	ND		mg/l	0.00100	0.00044	1	06/07/23 23:00	06/08/23 14:06	1,6020B	SMV
Nickel, Total	ND		mg/l	0.00200	0.00055	1	06/07/23 23:00	06/08/23 14:06	1,6020B	SMV
Potassium, Total	ND		mg/l	0.100	0.0309	1	06/07/23 23:00	06/08/23 14:06	1,6020B	SMV
Selenium, Total	ND		mg/l	0.00500	0.00173	1	06/07/23 23:00	06/08/23 14:06	1,6020B	SMV
Silver, Total	ND		mg/l	0.00040	0.00016	1	06/07/23 23:00	06/08/23 14:06	1,6020B	SMV
Sodium, Total	0.0708	J	mg/l	0.100	0.0293	1	06/07/23 23:00	06/08/23 14:06	1,6020B	SMV
Thallium, Total	ND		mg/l	0.00100	0.00014	1	06/07/23 23:00	06/08/23 14:06	1,6020B	SMV
Vanadium, Total	ND		mg/l	0.00500	0.00157	1	06/07/23 23:00	06/08/23 14:06	1,6020B	SMV
Zinc, Total	ND		mg/l	0.01000	0.00341	1	06/07/23 23:00	06/08/23 14:06	1,6020B	SMV

Prep Information

Digestion Method: EPA 3005A

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
Total Metals - Mansfield Lab for sample(s): 08-09 Batch: WG1788391-1										
Mercury, Total	ND		mg/l	0.00020	0.00009	1	06/08/23 00:15	06/08/23 19:35	1,7470A	DJR

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

Method Blank Analysis
Batch Quality Control

Prep Information

Digestion Method: EPA 7470A

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
Total Metals - Mansfield Lab for sample(s): 01-07 Batch: WG1788822-1										
Aluminum, Total	ND		mg/kg	4.00	1.08	1	06/09/23 06:30	06/12/23 16:36	1,6010D	TAA
Antimony, Total	ND		mg/kg	2.00	0.152	1	06/09/23 06:30	06/12/23 16:36	1,6010D	TAA
Arsenic, Total	ND		mg/kg	0.400	0.083	1	06/09/23 06:30	06/12/23 16:36	1,6010D	TAA
Barium, Total	ND		mg/kg	0.400	0.070	1	06/09/23 06:30	06/12/23 16:36	1,6010D	TAA
Beryllium, Total	ND		mg/kg	0.200	0.013	1	06/09/23 06:30	06/12/23 16:36	1,6010D	TAA
Cadmium, Total	ND		mg/kg	0.400	0.039	1	06/09/23 06:30	06/12/23 16:36	1,6010D	TAA
Calcium, Total	ND		mg/kg	4.00	1.40	1	06/09/23 06:30	06/12/23 16:36	1,6010D	TAA
Chromium, Total	0.047	J	mg/kg	0.400	0.038	1	06/09/23 06:30	06/12/23 16:36	1,6010D	TAA
Cobalt, Total	ND		mg/kg	0.800	0.066	1	06/09/23 06:30	06/12/23 16:36	1,6010D	TAA
Copper, Total	ND		mg/kg	0.400	0.103	1	06/09/23 06:30	06/12/23 16:36	1,6010D	TAA
Iron, Total	ND		mg/kg	2.00	0.361	1	06/09/23 06:30	06/12/23 16:36	1,6010D	TAA
Lead, Total	ND		mg/kg	2.00	0.107	1	06/09/23 06:30	06/12/23 16:36	1,6010D	TAA
Magnesium, Total	ND		mg/kg	4.00	0.616	1	06/09/23 06:30	06/12/23 16:36	1,6010D	TAA
Manganese, Total	ND		mg/kg	0.400	0.064	1	06/09/23 06:30	06/12/23 16:36	1,6010D	TAA
Nickel, Total	ND		mg/kg	1.00	0.097	1	06/09/23 06:30	06/12/23 16:36	1,6010D	TAA
Potassium, Total	ND		mg/kg	100	5.76	1	06/09/23 06:30	06/12/23 16:36	1,6010D	TAA
Selenium, Total	ND		mg/kg	0.800	0.103	1	06/09/23 06:30	06/12/23 16:36	1,6010D	TAA
Silver, Total	ND		mg/kg	0.200	0.113	1	06/09/23 06:30	06/12/23 16:36	1,6010D	TAA
Sodium, Total	2.51	J	mg/kg	80.0	1.26	1	06/09/23 06:30	06/12/23 16:36	1,6010D	TAA
Thallium, Total	ND		mg/kg	0.800	0.126	1	06/09/23 06:30	06/12/23 16:36	1,6010D	TAA
Vanadium, Total	ND		mg/kg	0.400	0.081	1	06/09/23 06:30	06/12/23 16:36	1,6010D	TAA
Zinc, Total	ND		mg/kg	2.00	0.117	1	06/09/23 06:30	06/12/23 16:36	1,6010D	TAA

Prep Information

Digestion Method: EPA 3050B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

Method Blank Analysis
Batch Quality Control

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
Total Metals - Mansfield Lab for sample(s): 01-07 Batch: WG1788823-1										
Mercury, Total	ND		mg/kg	0.083	0.054	1	06/09/23 11:00	06/13/23 14:34	1,7471B	DMB

Prep Information

Digestion Method: EPA 7471B

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331226

Report Date: 06/13/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 08-09 Batch: WG1788389-2								
Aluminum, Total	114		-		80-120	-		
Antimony, Total	84		-		80-120	-		
Arsenic, Total	93		-		80-120	-		
Barium, Total	97		-		80-120	-		
Beryllium, Total	101		-		80-120	-		
Cadmium, Total	98		-		80-120	-		
Calcium, Total	104		-		80-120	-		
Chromium, Total	100		-		80-120	-		
Cobalt, Total	96		-		80-120	-		
Copper, Total	98		-		80-120	-		
Iron, Total	96		-		80-120	-		
Lead, Total	92		-		80-120	-		
Magnesium, Total	110		-		80-120	-		
Manganese, Total	103		-		80-120	-		
Nickel, Total	96		-		80-120	-		
Potassium, Total	112		-		80-120	-		
Selenium, Total	91		-		80-120	-		
Silver, Total	98		-		80-120	-		
Sodium, Total	112		-		80-120	-		
Thallium, Total	96		-		80-120	-		
Vanadium, Total	101		-		80-120	-		

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331226

Report Date: 06/13/23

Parameter	LCS %Recovery	LCSD %Recovery	%Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 08-09 Batch: WG1788389-2					
Zinc, Total	98	-	80-120	-	
Total Metals - Mansfield Lab Associated sample(s): 08-09 Batch: WG1788391-2					
Mercury, Total	98	-	80-120	-	

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331226

Report Date: 06/13/23

Parameter	LCS %Recovery	LCSD %Recovery	%Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-07 Batch: WG1788822-2 SRM Lot Number: D119-540					
Aluminum, Total	76	-	48-152	-	
Antimony, Total	119	-	10-190	-	
Arsenic, Total	99	-	83-117	-	
Barium, Total	101	-	82-118	-	
Beryllium, Total	103	-	83-117	-	
Cadmium, Total	104	-	82-117	-	
Calcium, Total	98	-	81-118	-	
Chromium, Total	102	-	82-119	-	
Cobalt, Total	103	-	83-117	-	
Copper, Total	102	-	84-116	-	
Iron, Total	95	-	60-140	-	
Lead, Total	103	-	82-118	-	
Magnesium, Total	94	-	76-124	-	
Manganese, Total	109	-	82-118	-	
Nickel, Total	102	-	82-117	-	
Potassium, Total	96	-	70-130	-	
Selenium, Total	104	-	79-121	-	
Silver, Total	105	-	80-120	-	
Sodium, Total	104	-	74-126	-	
Thallium, Total	108	-	81-119	-	
Vanadium, Total	101	-	79-121	-	

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331226

Report Date: 06/13/23

Parameter	LCS %Recovery	LCSD %Recovery	%Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-07 Batch: WG1788822-2 SRM Lot Number: D119-540					
Zinc, Total	99	-	80-120	-	
Total Metals - Mansfield Lab Associated sample(s): 01-07 Batch: WG1788823-2 SRM Lot Number: D119-540					
Mercury, Total	97	-	73-127	-	

Matrix Spike Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331226
Report Date: 06/13/23

Parameter	Native Sample	MS Added	MS Found	MS %Recovery	Qual	MSD Found	MSD %Recovery	Qual	Recovery Limits	RPD	Qual	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 08-09 QC Batch ID: WG1788389-3 QC Sample: L2329184-06 Client ID: MS Sample												
Aluminum, Total	0.031	2	2.39	118		-	-		75-125	-		20
Antimony, Total	ND	0.5	0.4451	89		-	-		75-125	-		20
Arsenic, Total	0.00104	0.12	0.1237	102		-	-		75-125	-		20
Barium, Total	0.01447	2	2.094	104		-	-		75-125	-		20
Beryllium, Total	ND	0.05	0.05370	107		-	-		75-125	-		20
Cadmium, Total	ND	0.053	0.05519	104		-	-		75-125	-		20
Calcium, Total	10.6	10	23.4	**128**	Q	-	-		75-125	-		20
Chromium, Total	0.00019J	0.2	0.2154	108		-	-		75-125	-		20
Cobalt, Total	0.0003J	0.5	0.5160	103		-	-		75-125	-		20
Copper, Total	0.00072J	0.25	0.2681	107		-	-		75-125	-		20
Iron, Total	0.482	1	1.46	98		-	-		75-125	-		20
Lead, Total	ND	0.53	0.5184	98		-	-		75-125	-		20
Magnesium, Total	2.18	10	13.7	115		-	-		75-125	-		20
Manganese, Total	0.1070	0.5	0.6663	112		-	-		75-125	-		20
Nickel, Total	0.0007J	0.5	0.5192	104		-	-		75-125	-		20
Potassium, Total	1.49	10	13.4	119		-	-		75-125	-		20
Selenium, Total	ND	0.12	0.128	107		-	-		75-125	-		20
Silver, Total	ND	0.05	0.05201	104		-	-		75-125	-		20
Sodium, Total	18.6	10	32.3	**137**	Q	-	-		75-125	-		20
Thallium, Total	0.0001J	0.12	0.1223	102		-	-		75-125	-		20
Vanadium, Total	ND	0.5	0.5363	107		-	-		75-125	-		20

Matrix Spike Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331226
Report Date: 06/13/23

Parameter	Native Sample	MS Added	MS Found	MS %Recovery	MSD Found	MSD %Recovery	Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 08-09 QC Batch ID: WG1788389-3 QC Sample: L2329184-06 Client ID: MS Sample									
Zinc, Total	ND	0.5	0.5355	107	-	-	75-125	-	20
Total Metals - Mansfield Lab Associated sample(s): 08-09 QC Batch ID: WG1788391-3 QC Sample: L2331684-01 Client ID: MS Sample									
Mercury, Total	ND	0.005	0.00484	97	-	-	75-125	-	20

Matrix Spike Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331226
Report Date: 06/13/23

Parameter	Native Sample	MS Added	MS Found	MS %Recovery		MSD Found	MSD %Recovery	Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-07 QC Batch ID: WG1788822-3 QC Sample: L2331172-01 Client ID: MS Sample										
Aluminum, Total	2660	176	3800	**647**	Q	-	-	75-125	-	20
Antimony, Total	0.338J	44	30.7	**70**	Q	-	-	75-125	-	20
Arsenic, Total	2.93	10.6	13.1	96		-	-	75-125	-	20
Barium, Total	2.46	176	172	96		-	-	75-125	-	20
Beryllium, Total	0.171J	4.4	4.58	104		-	-	75-125	-	20
Cadmium, Total	0.175J	4.67	4.68	100		-	-	75-125	-	20
Calcium, Total	45.6	881	923	100		-	-	75-125	-	20
Chromium, Total	35.0	17.6	58.0	**130**	Q	-	-	75-125	-	20
Cobalt, Total	2.25	44	44.1	95		-	-	75-125	-	20
Copper, Total	1.85	22	23.7	99		-	-	75-125	-	20
Iron, Total	10800	88.1	12900	**2380**	Q	-	-	75-125	-	20
Lead, Total	3.82J	46.7	49.1	105		-	-	75-125	-	20
Magnesium, Total	212	881	1240	117		-	-	75-125	-	20
Manganese, Total	12.4	44	53.2	93		-	-	75-125	-	20
Nickel, Total	11.8	44	51.1	89		-	-	75-125	-	20
Potassium, Total	794	881	2310	**172**	Q	-	-	75-125	-	20
Selenium, Total	ND	10.6	9.73	92		-	-	75-125	-	20
Silver, Total	ND	4.4	4.21	96		-	-	75-125	-	20
Sodium, Total	42.0J	881	955	108		-	-	75-125	-	20
Thallium, Total	ND	10.6	10.1	96		-	-	75-125	-	20
Vanadium, Total	27.8	44	76.8	111		-	-	75-125	-	20

Matrix Spike Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331226
Report Date: 06/13/23

Parameter	Native Sample	MS Added	MS Found	MS %Recovery		MSD Found	MSD %Recovery	Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-07 QC Batch ID: WG1788822-3 QC Sample: L2331172-01 Client ID: MS Sample										
Zinc, Total	41.5	44	66.1	**56**	Q	-	-	75-125	-	20
Total Metals - Mansfield Lab Associated sample(s): 01-07 QC Batch ID: WG1788823-3 QC Sample: L2331172-01 Client ID: MS Sample										
Mercury, Total	ND	1.45	1.47	101		-	-	80-120	-	20

Lab Duplicate Analysis

Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331226
Report Date: 06/13/23

Parameter	Native Sample	Duplicate Sample	Units	RPD	Qual	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 08-09 QC Batch ID: WG1788389-4 QC Sample: L2329184-06 Client ID: DUP Sample						
Arsenic, Total	0.00104	0.00112	mg/l	7		20
Barium, Total	0.01447	0.01516	mg/l	5		20
Cadmium, Total	ND	ND	mg/l	NC		20
Chromium, Total	0.00019J	0.00018J	mg/l	NC		20
Copper, Total	0.00072J	0.00048J	mg/l	NC		20
Lead, Total	ND	ND	mg/l	NC		20
Manganese, Total	0.1070	0.1139	mg/l	6		20
Selenium, Total	ND	ND	mg/l	NC		20
Silver, Total	ND	ND	mg/l	NC		20
Zinc, Total	ND	ND	mg/l	NC		20
Total Metals - Mansfield Lab Associated sample(s): 08-09 QC Batch ID: WG1788391-4 QC Sample: L2331684-01 Client ID: DUP Sample						
Mercury, Total	ND	ND	mg/l	NC		20

Lab Duplicate Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331226

Report Date: 06/13/23

Parameter	Native Sample	Duplicate Sample	Units	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-07 QC Batch ID: WG1788822-4 QC Sample: L2331172-01 Client ID: DUP Sample					
Aluminum, Total	2660	2760	mg/kg	4	20
Antimony, Total	0.338J	0.584J	mg/kg	NC	20
Arsenic, Total	2.93	2.96	mg/kg	1	20
Barium, Total	2.46	2.33	mg/kg	5	20
Beryllium, Total	0.171J	0.180J	mg/kg	NC	20
Cadmium, Total	0.175J	0.152J	mg/kg	NC	20
Calcium, Total	45.6	39.5	mg/kg	14	20
Chromium, Total	35.0	35.2	mg/kg	1	20
Cobalt, Total	2.25	2.09	mg/kg	7	20
Copper, Total	1.85	1.82	mg/kg	2	20
Iron, Total	10800	10900	mg/kg	1	20
Lead, Total	3.82J	3.73J	mg/kg	NC	20
Magnesium, Total	212	230	mg/kg	8	20
Manganese, Total	12.4	11.9	mg/kg	4	20
Nickel, Total	11.8	10.4	mg/kg	13	20
Potassium, Total	794	834	mg/kg	5	20
Selenium, Total	ND	ND	mg/kg	NC	20
Silver, Total	ND	ND	mg/kg	NC	20
Sodium, Total	42.0J	41.6J	mg/kg	NC	20

Lab Duplicate Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331226

Report Date: 06/13/23

Parameter	Native Sample	Duplicate Sample	Units	RPD		RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-07 QC Batch ID: WG1788822-4 QC Sample: L2331172-01 Client ID: DUP Sample						
Thallium, Total	ND	ND	mg/kg	NC		20
Vanadium, Total	27.8	28.3	mg/kg	2		20
Zinc, Total	41.5	25.5	mg/kg	**48**	Q	20

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Serial Dilution Analysis
Batch Quality Control

Lab Number: L2331226
Report Date: 06/13/23

Parameter	Native Sample	Serial Dilution	Units	% D	Qual	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-07 QC Batch ID: WG1788822-6 QC Sample: L2331172-01 Client ID: DUP Sample						
Aluminum, Total	2660	3020	mg/kg	14		20
Chromium, Total	35.0	40.0	mg/kg	14		20
Iron, Total	10800	12500	mg/kg	16		20
Vanadium, Total	27.8	31.4	mg/kg	13		20

INORGANICS
&
MISCELLANEOUS

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331226
Report Date: 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-01
Client ID: SB-20G (1.5-2)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 10:00
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Solids, Total	93.5		%	0.100	NA	1	-	06/06/23 13:46	121,2540G	ROI
Cyanide, Total	ND		mg/kg	0.98	0.21	1	06/08/23 10:00	06/08/23 13:52	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331226
Report Date: 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-02
Client ID: SB-21G (9-9.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 11:15
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Solids, Total	90.5		%	0.100	NA	1	-	06/06/23 13:46	121,2540G	ROI
Cyanide, Total	ND		mg/kg	1.1	0.22	1	06/08/23 10:00	06/08/23 13:53	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331226
Report Date: 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-03
Client ID: SB-21G (12-12.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 11:20
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Solids, Total	82.2		%	0.100	NA	1	-	06/06/23 13:46	121,2540G	ROI
Cyanide, Total	ND		mg/kg	1.1	0.24	1	06/08/23 10:00	06/08/23 13:54	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331226
Report Date: 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-04
Client ID: SB-22G (7-7.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 12:15
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Solids, Total	79.6		%	0.100	NA	1	-	06/06/23 13:46	121,2540G	ROI
Cyanide, Total	ND		mg/kg	1.2	0.26	1	06/08/23 10:00	06/08/23 13:55	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331226
Report Date: 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-05
Client ID: SB-23G (9.5-10)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 12:50
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Solids, Total	86.6		%	0.100	NA	1	-	06/06/23 13:46	121,2540G	ROI
Cyanide, Total	ND		mg/kg	1.2	0.24	1	06/08/23 10:00	06/08/23 13:56	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331226
Report Date: 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-06
Client ID: SB-24G (7.5-8)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 12:30
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Solids, Total	84.6		%	0.100	NA	1	-	06/06/23 13:46	121,2540G	ROI
Cyanide, Total	ND		mg/kg	1.1	0.24	1	06/08/23 10:00	06/08/23 13:57	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331226
Report Date: 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-07
Client ID: SB-25G (9.5-10)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 10:40
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Solids, Total	91.5		%	0.100	NA	1	-	06/06/23 13:46	121,2540G	ROI
Cyanide, Total	ND		mg/kg	1.0	0.22	1	06/08/23 10:00	06/08/23 14:08	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331226
Report Date: 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-08
Client ID: GW-10
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 12:00
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Cyanide, Total	0.003	J	mg/l	0.005	0.001	1	06/06/23 14:10	06/06/23 17:29	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331226
Report Date: 06/13/23

SAMPLE RESULTS

Lab ID: L2331226-09
Client ID: GW-11
Sample Location: WHITE PLAINS, NY

Date Collected: 06/05/23 13:20
Date Received: 06/05/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Cyanide, Total	ND		mg/l	0.005	0.001	1	06/06/23 14:10	06/06/23 17:32	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331226
Report Date: 06/13/23

Method Blank Analysis
Batch Quality Control

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab for sample(s): 08-09 Batch: WG1787768-1										
Cyanide, Total	0.001	J	mg/l	0.005	0.001	1	06/06/23 14:10	06/06/23 16:45	1,9010C/9012B	JER
General Chemistry - Westborough Lab for sample(s): 01-06 Batch: WG1788662-1										
Cyanide, Total	ND		mg/kg	0.84	0.18	1	06/08/23 10:00	06/08/23 13:36	1,9010C/9012B	JER
General Chemistry - Westborough Lab for sample(s): 07 Batch: WG1788664-1										
Cyanide, Total	ND		mg/kg	0.84	0.18	1	06/08/23 10:00	06/08/23 13:36	1,9010C/9012B	JER

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331226

Report Date: 06/13/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
General Chemistry - Westborough Lab Associated sample(s): 08-09 Batch: WG1787768-2 WG1787768-3								
Cyanide, Total	92		92		85-115	0		20
General Chemistry - Westborough Lab Associated sample(s): 01-06 Batch: WG1788662-2 WG1788662-3								
Cyanide, Total	106		93		80-120	14		35
General Chemistry - Westborough Lab Associated sample(s): 07 Batch: WG1788664-2 WG1788664-3								
Cyanide, Total	106		93		80-120	14		35

Matrix Spike Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331226
Report Date: 06/13/23

Parameter	Native Sample	MS Added	MS Found	MS %Recovery	Qual	MSD Found	MSD %Recovery	Qual	Recovery Limits	RPD	Qual	RPD Limits
General Chemistry - Westborough Lab Associated sample(s): 08-09 QC Batch ID: WG1787768-4 WG1787768-5 QC Sample: L2331226-08 Client ID: GW-10												
Cyanide, Total	0.003J	0.2	0.221	110		0.182	91		80-120	19		20
General Chemistry - Westborough Lab Associated sample(s): 01-06 QC Batch ID: WG1788662-4 WG1788662-5 QC Sample: L2331199-01 Client ID: MS Sample												
Cyanide, Total	0.40J	11	13	110		13	110		75-125	0		35
General Chemistry - Westborough Lab Associated sample(s): 07 QC Batch ID: WG1788664-4 WG1788664-5 QC Sample: L2331226-07 Client ID: SB-25G (9.5-10)												
Cyanide, Total	ND	10	12	120		12	120		75-125	0		35

Lab Duplicate Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331226

Report Date: 06/13/23

Parameter	Native Sample	Duplicate Sample	Units	RPD	Qual	RPD Limits
General Chemistry - Westborough Lab Associated sample(s): 01-07 QC Batch ID: WG1787678-1 QC Sample: L2330934-01 Client ID: DUP Sample						
Solids, Total	72.2	72.8	%	1		20

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331226
Report Date: 06/13/23

Sample Receipt and Container Information

Were project specific reporting limits specified? YES

Cooler Information

Cooler	Custody Seal
A	Absent

Container Information

Container ID	Container Type	Cooler	Initial pH	Final pH	Temp deg C	Pres	Seal	Frozen Date/Time	Analysis(*)
L2331226-01A	5 gram Encore Sampler	A	NA		2.3	Y	Absent		NYTCL-8260HLW(14)
L2331226-01B	5 gram Encore Sampler	A	NA		2.3	Y	Absent		NYTCL-8260HLW(14)
L2331226-01C	5 gram Encore Sampler	A	NA		2.3	Y	Absent		NYTCL-8260HLW(14)
L2331226-01D	Metals Only-Glass 60mL/2oz unpreserved	A	NA		2.3	Y	Absent		BE-TI(180),BA-TI(180),AS-TI(180),AG-TI(180),NI-TI(180),AL-TI(180),TL-TI(180),CR-TI(180),PB-TI(180),SB-TI(180),CU-TI(180),ZN-TI(180),SE-TI(180),CO-TI(180),V-TI(180),FE-TI(180),MG-TI(180),HG-T(28),MN-TI(180),K-TI(180),CA-TI(180),CD-TI(180),NA-TI(180)
L2331226-01E	Plastic 2oz unpreserved for TS	A	NA		2.3	Y	Absent		TS(7)
L2331226-01F	Glass 250ml/8oz unpreserved	A	NA		2.3	Y	Absent		NYTCL-8270(14),TCN-9010(14),NYTCL-8081(14),NYTCL-8082(365)
L2331226-01X	Vial MeOH preserved split	A	NA		2.3	Y	Absent		NYTCL-8260HLW(14)
L2331226-01Y	Vial Water preserved split	A	NA		2.3	Y	Absent	06-JUN-23 14:48	NYTCL-8260HLW(14)
L2331226-01Z	Vial Water preserved split	A	NA		2.3	Y	Absent	06-JUN-23 14:48	NYTCL-8260HLW(14)
L2331226-02A	5 gram Encore Sampler	A	NA		2.3	Y	Absent		NYTCL-8260H(14),NYTCL-8260HLW(14)
L2331226-02B	5 gram Encore Sampler	A	NA		2.3	Y	Absent		NYTCL-8260H(14),NYTCL-8260HLW(14)
L2331226-02C	5 gram Encore Sampler	A	NA		2.3	Y	Absent		NYTCL-8260H(14),NYTCL-8260HLW(14)
L2331226-02D	Metals Only-Glass 60mL/2oz unpreserved	A	NA		2.3	Y	Absent		BE-TI(180),BA-TI(180),AS-TI(180),AG-TI(180),CR-TI(180),TL-TI(180),AL-TI(180),NI-TI(180),SE-TI(180),ZN-TI(180),SB-TI(180),PB-TI(180),CU-TI(180),CO-TI(180),V-TI(180),MN-TI(180),HG-T(28),MG-TI(180),FE-TI(180),K-TI(180),NA-TI(180),CA-TI(180),CD-TI(180)
L2331226-02E	Plastic 2oz unpreserved for TS	A	NA		2.3	Y	Absent		TS(7)
L2331226-02F	Glass 250ml/8oz unpreserved	A	NA		2.3	Y	Absent		NYTCL-8270(14),TCN-9010(14),NYTCL-8081(14),NYTCL-8082(365)
L2331226-02X	Vial MeOH preserved split	A	NA		2.3	Y	Absent		NYTCL-8260H(14),NYTCL-8260HLW(14)
L2331226-02Y	Vial Water preserved split	A	NA		2.3	Y	Absent	06-JUN-23 14:48	NYTCL-8260H(14),NYTCL-8260HLW(14)

*Values in parentheses indicate holding time in days

Container Information

Container ID	Container Type	Cooler	Initial pH	Final pH	Temp deg C	Pres	Seal	Frozen Date/Time	Analysis(*)
L2331226-02Z	Vial Water preserved split	A	NA		2.3	Y	Absent	06-JUN-23 14:48	NYTCL-8260H(14),NYTCL-8260HLW(14)
L2331226-03A	5 gram Encore Sampler	A	NA		2.3	Y	Absent		NYTCL-8260HLW(14)
L2331226-03B	5 gram Encore Sampler	A	NA		2.3	Y	Absent		NYTCL-8260HLW(14)
L2331226-03C	5 gram Encore Sampler	A	NA		2.3	Y	Absent		NYTCL-8260HLW(14)
L2331226-03D	Metals Only-Glass 60mL/2oz unpreserved	A	NA		2.3	Y	Absent		BE-TI(180),AS-TI(180),BA-TI(180),AG-TI(180),NI-TI(180),AL-TI(180),TL-TI(180),CR-TI(180),CU-TI(180),SE-TI(180),PB-TI(180),SB-TI(180),ZN-TI(180),CO-TI(180),V-TI(180),FE-TI(180),MG-TI(180),HG-T(28),MN-TI(180),NA-TI(180),CA-TI(180),K-TI(180),CD-TI(180)
L2331226-03E	Plastic 2oz unpreserved for TS	A	NA		2.3	Y	Absent		TS(7)
L2331226-03F	Glass 250ml/8oz unpreserved	A	NA		2.3	Y	Absent		NYTCL-8270(14),TCN-9010(14),NYTCL-8081(14),NYTCL-8082(365)
L2331226-03X	Vial MeOH preserved split	A	NA		2.3	Y	Absent		NYTCL-8260HLW(14)
L2331226-03Y	Vial Water preserved split	A	NA		2.3	Y	Absent	06-JUN-23 14:48	NYTCL-8260HLW(14)
L2331226-03Z	Vial Water preserved split	A	NA		2.3	Y	Absent	06-JUN-23 14:48	NYTCL-8260HLW(14)
L2331226-04A	5 gram Encore Sampler	A	NA		2.3	Y	Absent		NYTCL-8260HLW(14)
L2331226-04B	5 gram Encore Sampler	A	NA		2.3	Y	Absent		NYTCL-8260HLW(14)
L2331226-04C	5 gram Encore Sampler	A	NA		2.3	Y	Absent		NYTCL-8260HLW(14)
L2331226-04D	Metals Only-Glass 60mL/2oz unpreserved	A	NA		2.3	Y	Absent		BE-TI(180),BA-TI(180),AS-TI(180),AG-TI(180),NI-TI(180),TL-TI(180),AL-TI(180),CR-TI(180),PB-TI(180),SE-TI(180),SB-TI(180),ZN-TI(180),CU-TI(180),CO-TI(180),V-TI(180),FE-TI(180),MG-TI(180),HG-T(28),MN-TI(180),CA-TI(180),CD-TI(180),NA-TI(180),K-TI(180)
L2331226-04E	Plastic 2oz unpreserved for TS	A	NA		2.3	Y	Absent		TS(7)
L2331226-04F	Glass 250ml/8oz unpreserved	A	NA		2.3	Y	Absent		NYTCL-8270(14),TCN-9010(14),NYTCL-8081(14),NYTCL-8082(365)
L2331226-04X	Vial MeOH preserved split	A	NA		2.3	Y	Absent		NYTCL-8260HLW(14)
L2331226-04Y	Vial Water preserved split	A	NA		2.3	Y	Absent	06-JUN-23 14:48	NYTCL-8260HLW(14)
L2331226-04Z	Vial Water preserved split	A	NA		2.3	Y	Absent	06-JUN-23 14:48	NYTCL-8260HLW(14)
L2331226-05A	5 gram Encore Sampler	A	NA		2.3	Y	Absent		NYTCL-8260HLW(14)
L2331226-05B	5 gram Encore Sampler	A	NA		2.3	Y	Absent		NYTCL-8260HLW(14)
L2331226-05C	5 gram Encore Sampler	A	NA		2.3	Y	Absent		NYTCL-8260HLW(14)

*Values in parentheses indicate holding time in days

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331226
Report Date: 06/13/23

Container Information

Container ID	Container Type	Cooler	Initial pH	Final pH	Temp deg C	Pres	Seal	Frozen Date/Time	Analysis(*)
L2331226-05D	Metals Only-Glass 60mL/2oz unpreserved	A	NA		2.3	Y	Absent		BE-TI(180),AS-TI(180),BA-TI(180),AG-TI(180),NI-TI(180),CR-TI(180),TL-TI(180),AL-TI(180),PB-TI(180),SB-TI(180),CU-TI(180),SE-TI(180),ZN-TI(180),CO-TI(180),V-TI(180),MG-TI(180),HG-T(28),FE-TI(180),MN-TI(180),K-TI(180),NA-TI(180),CA-TI(180),CD-TI(180)
L2331226-05E	Plastic 2oz unpreserved for TS	A	NA		2.3	Y	Absent		TS(7)
L2331226-05F	Glass 250ml/8oz unpreserved	A	NA		2.3	Y	Absent		NYTCL-8270(14),TCN-9010(14),NYTCL-8081(14),NYTCL-8082(365)
L2331226-05X	Vial MeOH preserved split	A	NA		2.3	Y	Absent		NYTCL-8260HLW(14)
L2331226-05Y	Vial Water preserved split	A	NA		2.3	Y	Absent	06-JUN-23 14:48	NYTCL-8260HLW(14)
L2331226-05Z	Vial Water preserved split	A	NA		2.3	Y	Absent	06-JUN-23 14:48	NYTCL-8260HLW(14)
L2331226-06A	5 gram Encore Sampler	A	NA		2.3	Y	Absent		NYTCL-8260HLW(14)
L2331226-06B	5 gram Encore Sampler	A	NA		2.3	Y	Absent		NYTCL-8260HLW(14)
L2331226-06C	5 gram Encore Sampler	A	NA		2.3	Y	Absent		NYTCL-8260HLW(14)
L2331226-06D	Metals Only-Glass 60mL/2oz unpreserved	A	NA		2.3	Y	Absent		BE-TI(180),AS-TI(180),BA-TI(180),AG-TI(180),TL-TI(180),NI-TI(180),AL-TI(180),CR-TI(180),SB-TI(180),PB-TI(180),ZN-TI(180),CU-TI(180),SE-TI(180),V-TI(180),CO-TI(180),MN-TI(180),FE-TI(180),HG-T(28),MG-TI(180),CD-TI(180),K-TI(180),CA-TI(180),NA-TI(180)
L2331226-06E	Plastic 2oz unpreserved for TS	A	NA		2.3	Y	Absent		TS(7)
L2331226-06F	Glass 250ml/8oz unpreserved	A	NA		2.3	Y	Absent		NYTCL-8270(14),TCN-9010(14),NYTCL-8081(14),NYTCL-8082(365)
L2331226-06X	Vial MeOH preserved split	A	NA		2.3	Y	Absent		NYTCL-8260HLW(14)
L2331226-06Y	Vial Water preserved split	A	NA		2.3	Y	Absent	06-JUN-23 14:48	NYTCL-8260HLW(14)
L2331226-06Z	Vial Water preserved split	A	NA		2.3	Y	Absent	06-JUN-23 14:48	NYTCL-8260HLW(14)
L2331226-07A	5 gram Encore Sampler	A	NA		2.3	Y	Absent		NYTCL-8260HLW(14)
L2331226-07B	5 gram Encore Sampler	A	NA		2.3	Y	Absent		NYTCL-8260HLW(14)
L2331226-07C	5 gram Encore Sampler	A	NA		2.3	Y	Absent		NYTCL-8260HLW(14)
L2331226-07D	Metals Only-Glass 60mL/2oz unpreserved	A	NA		2.3	Y	Absent		BE-TI(180),BA-TI(180),AS-TI(180),AG-TI(180),TL-TI(180),NI-TI(180),AL-TI(180),CR-TI(180),CU-TI(180),SB-TI(180),SE-TI(180),ZN-TI(180),PB-TI(180),V-TI(180),CO-TI(180),MN-TI(180),MG-TI(180),HG-T(28),FE-TI(180),NA-TI(180),K-TI(180),CA-TI(180),CD-TI(180)
L2331226-07E	Plastic 2oz unpreserved for TS	A	NA		2.3	Y	Absent		TS(7)

*Values in parentheses indicate holding time in days

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331226
Report Date: 06/13/23

Container Information

Container ID	Container Type	Cooler	Initial pH	Final pH	Temp deg C	Pres	Seal	Frozen Date/Time	Analysis(*)
L2331226-07F	Glass 250ml/8oz unpreserved	A	NA		2.3	Y	Absent		TCN-9010(14),NYTCL-8270(14),NYTCL-8081(14),NYTCL-8082(365)
L2331226-07X	Vial MeOH preserved split	A	NA		2.3	Y	Absent		NYTCL-8260HLW(14)
L2331226-07Y	Vial Water preserved split	A	NA		2.3	Y	Absent	06-JUN-23 14:48	NYTCL-8260HLW(14)
L2331226-07Z	Vial Water preserved split	A	NA		2.3	Y	Absent	06-JUN-23 14:48	NYTCL-8260HLW(14)
L2331226-08A	Vial HCl preserved	A	NA		2.3	Y	Absent		NYTCL-8260(14)
L2331226-08B	Vial HCl preserved	A	NA		2.3	Y	Absent		NYTCL-8260(14)
L2331226-08C	Vial HCl preserved	A	NA		2.3	Y	Absent		NYTCL-8260(14)
L2331226-08D	Amber 120ml unpreserved	A	7	7	2.3	Y	Absent		NYTCL-8081(7)
L2331226-08E	Amber 120ml unpreserved	A	7	7	2.3	Y	Absent		NYTCL-8081(7)
L2331226-08F	Amber 120ml unpreserved	A	7	7	2.3	Y	Absent		NYTCL-8082-LVI(365)
L2331226-08G	Amber 120ml unpreserved	A	7	7	2.3	Y	Absent		NYTCL-8082-LVI(365)
L2331226-08H	Plastic 250ml NaOH preserved	A	>12	>12	2.3	Y	Absent		TCN-9010(14)
L2331226-08I	Amber 250ml unpreserved	A	7	7	2.3	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)
L2331226-08J	Amber 250ml unpreserved	A	7	7	2.3	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)
L2331226-08K	Plastic 250ml HNO3 preserved	A	<2	<2	2.3	Y	Absent		TL-6020T(180),FE-6020T(180),SE-6020T(180),BA-6020T(180),CA-6020T(180),CR-6020T(180),K-6020T(180),NI-6020T(180),NA-6020T(180),CU-6020T(180),ZN-6020T(180),PB-6020T(180),BE-6020T(180),MN-6020T(180),SB-6020T(180),V-6020T(180),AS-6020T(180),HG-T(28),CD-6020T(180),AG-6020T(180),AL-6020T(180),MG-6020T(180),CO-6020T(180)
L2331226-09A	Vial HCl preserved	A	NA		2.3	Y	Absent		NYTCL-8260(14)
L2331226-09B	Vial HCl preserved	A	NA		2.3	Y	Absent		NYTCL-8260(14)
L2331226-09C	Vial HCl preserved	A	NA		2.3	Y	Absent		NYTCL-8260(14)
L2331226-09D	Amber 120ml unpreserved	A	7	7	2.3	Y	Absent		NYTCL-8081(7)
L2331226-09E	Amber 120ml unpreserved	A	7	7	2.3	Y	Absent		NYTCL-8081(7)
L2331226-09F	Amber 120ml unpreserved	A	7	7	2.3	Y	Absent		NYTCL-8082-LVI(365)
L2331226-09G	Amber 120ml unpreserved	A	7	7	2.3	Y	Absent		NYTCL-8082-LVI(365)
L2331226-09H	Plastic 250ml NaOH preserved	A	>12	>12	2.3	Y	Absent		TCN-9010(14)
L2331226-09I	Amber 250ml unpreserved	A	7	7	2.3	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)

*Values in parentheses indicate holding time in days

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331226
Report Date: 06/13/23

Container Information

Container ID	Container Type	Cooler	Initial pH	Final pH	Temp deg C	Pres	Seal	Frozen Date/Time	Analysis(*)
L2331226-09J	Amber 250ml unpreserved	A	7	7	2.3	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)
L2331226-09K	Plastic 250ml HNO3 preserved	A	<2	<2	2.3	Y	Absent		BA-6020T(180),SE-6020T(180),FE-6020T(180),TL-6020T(180),CR-6020T(180),K-6020T(180),NI-6020T(180),CA-6020T(180),CU-6020T(180),NA-6020T(180),ZN-6020T(180),PB-6020T(180),MN-6020T(180),BE-6020T(180),AS-6020T(180),SB-6020T(180),V-6020T(180),AL-6020T(180),CD-6020T(180),HG-T(28),AG-6020T(180),MG-6020T(180),CO-6020T(180)

*Values in parentheses indicate holding time in days

Project Name:	100 MAIN ST.	**Lab Number:**	L2331226
Project Number:	12461	**Report Date:**	06/13/23

GLOSSARY

Acronyms

DL	- Detection Limit: This value represents the level to which target analyte concentrations are reported as estimated values, when those target analyte concentrations are quantified below the limit of quantitation (LOQ). The DL includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.)
EDL	- Estimated Detection Limit: This value represents the level to which target analyte concentrations are reported as estimated values, when those target analyte concentrations are quantified below the reporting limit (RL). The EDL includes any adjustments from dilutions, concentrations or moisture content, where applicable. The use of EDLs is specific to the analysis of PAHs using Solid-Phase Microextraction (SPME).
EMPC	- Estimated Maximum Possible Concentration: The concentration that results from the signal present at the retention time of an analyte when the ions meet all of the identification criteria except the ion abundance ratio criteria. An EMPC is a worst-case estimate of the concentration.
EPA	- Environmental Protection Agency.
LCS	- Laboratory Control Sample: A sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes or a material containing known and verified amounts of analytes.
LCSD	- Laboratory Control Sample Duplicate: Refer to LCS.
LFB	- Laboratory Fortified Blank: A sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes or a material containing known and verified amounts of analytes.
LOD	- Limit of Detection: This value represents the level to which a target analyte can reliably be detected for a specific analyte in a specific matrix by a specific method. The LOD includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.)
LOQ	- Limit of Quantitation: The value at which an instrument can accurately measure an analyte at a specific concentration. The LOQ includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.) Limit of Quantitation: The value at which an instrument can accurately measure an analyte at a specific concentration. The LOQ includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.)
MDL	- Method Detection Limit: This value represents the level to which target analyte concentrations are reported as estimated values, when those target analyte concentrations are quantified below the reporting limit (RL). The MDL includes any adjustments from dilutions, concentrations or moisture content, where applicable.
MS	- Matrix Spike Sample: A sample prepared by adding a known mass of target analyte to a specified amount of matrix sample for which an independent estimate of target analyte concentration is available. For Method 332.0, the spike recovery is calculated using the native concentration, including estimated values.
MSD	- Matrix Spike Sample Duplicate: Refer to MS.
NA	- Not Applicable.
NC	- Not Calculated: Term is utilized when one or more of the results utilized in the calculation are non-detect at the parameter's reporting unit.
NDPA/DPA	- N-Nitrosodiphenylamine/Diphenylamine.
NI	- Not Ignitable.
NP	- Non-Plastic: Term is utilized for the analysis of Atterberg Limits in soil.
NR	- No Results: Term is utilized when 'No Target Compounds Requested' is reported for the analysis of Volatile or Semivolatile Organic TIC only requests.
RL	- Reporting Limit: The value at which an instrument can accurately measure an analyte at a specific concentration. The RL includes any adjustments from dilutions, concentrations or moisture content, where applicable.
RPD	- Relative Percent Difference: The results from matrix and/or matrix spike duplicates are primarily designed to assess the precision of analytical results in a given matrix and are expressed as relative percent difference (RPD). Values which are less than five times the reporting limit for any individual parameter are evaluated by utilizing the absolute difference between the values; although the RPD value will be provided in the report.
SRM	- Standard Reference Material: A reference sample of a known or certified value that is of the same or similar matrix as the associated field samples.
STLP	- Semi-dynamic Tank Leaching Procedure per EPA Method 1315.
TEF	- Toxic Equivalency Factors: The values assigned to each dioxin and furan to evaluate their toxicity relative to 2,3,7,8-TCDD.
TEQ	- Toxic Equivalent: The measure of a sample's toxicity derived by multiplying each dioxin and furan by its corresponding TEF and then summing the resulting values.
TIC	- Tentatively Identified Compound: A compound that has been identified to be present and is not part of the target compound list (TCL) for the method and/or program. All TICs are qualitatively identified and reported as estimated concentrations.

Report Format: DU Report with 'J' Qualifiers

Project Name:	100 MAIN ST.	**Lab Number:**	L2331226
Project Number:	12461	**Report Date:**	06/13/23

Footnotes

1 - The reference for this analyte should be considered modified since this analyte is absent from the target analyte list of the original method.

Terms

Analytical Method: Both the document from which the method originates and the analytical reference method. (Example: EPA 8260B is shown as 1,8260B.) The codes for the reference method documents are provided in the References section of the Addendum.

Chlordane: The target compound Chlordane (CAS No. 57-74-9) is reported for GC ECD analyses. Per EPA,this compound "refers to a mixture of chlordane isomers, other chlorinated hydrocarbons and numerous other components." (Reference: USEPA Toxicological Review of Chlordane, In Support of Summary Information on the Integrated Risk Information System (IRIS), December 1997.)

Difference: With respect to Total Oxidizable Precursor (TOP) Assay analysis, the difference is defined as the Post-Treatment value minus the Pre-Treatment value.

Final pH: As it pertains to Sample Receipt & Container Information section of the report, Final pH reflects pH of container determined after adjustment at the laboratory, if applicable. If no adjustment required, value reflects Initial pH.

Frozen Date/Time: With respect to Volatile Organics in soil, Frozen Date/Time reflects the date/time at which associated Reagent Water-preserved vials were initially frozen. Note: If frozen date/time is beyond 48 hours from sample collection, value will be reflected in 'bold'.

Gasoline Range Organics (GRO): Gasoline Range Organics (GRO) results include all chromatographic peaks eluting from Methyl tert butyl ether through Naphthalene, with the exception of GRO analysis in support of State of Ohio programs, which includes all chromatographic peaks eluting from Hexane through Dodecane.

Initial pH: As it pertains to Sample Receipt & Container Information section of the report, Initial pH reflects pH of container determined upon receipt, if applicable.

PAH Total: With respect to Alkylated PAH analyses, the 'PAHs, Total' result is defined as the summation of results for all or a subset of the following compounds: Naphthalene, C1-C4 Naphthalenes, 2-Methylnaphthalene, 1-Methylnaphthalene, Biphenyl, Acenaphthylene, Acenaphthene, Fluorene, C1-C3 Fluorenes, Phenanthrene, C1-C4 Phenanthrenes/Anthracenes, Anthracene, Fluoranthene, Pyrene, C1-C4 Fluoranthenes/Pyrenes, Benz(a)anthracene, Chrysene, C1-C4 Chrysenes, Benzo(b)fluoranthene, Benzo(j)+(k)fluoranthene, Benzo(e)pyrene, Benzo(a)pyrene, Perylene, Indeno(1,2,3-cd)pyrene, Dibenz(ah)+(ac)anthracene, Benzo(g,h,i)perylene. If a 'Total' result is requested, the results of its individual components will also be reported.

PFAS Total: With respect to PFAS analyses, the 'PFAS, Total (5)' result is defined as the summation of results for: PFHpA, PFHxS, PFOA, PFNA and PFOS. In addition, the 'PFAS, Total (6)' result is defined as the summation of results for: PFHpA, PFHxS, PFOA, PFNA, PFDA and PFOS. For MassDEP DW compliance analysis only, the 'PFAS, Total (6)' result is defined as the summation of results at or above the RL. Note: If a 'Total' result is requested, the results of its individual components will also be reported.

Total: With respect to Organic analyses, a 'Total' result is defined as the summation of results for individual isomers or Aroclors. If a 'Total' result is requested, the results of its individual components will also be reported. This is applicable to 'Total' results for methods 8260, 8081 and 8082.

Data Qualifiers

A - Spectra identified as "Aldol Condensates" are byproducts of the extraction/concentration procedures when acetone is introduced in the process.

B - The analyte was detected above the reporting limit in the associated method blank. Flag only applies to associated field samples that have detectable concentrations of the analyte at less than ten times (10x) the concentration found in the blank. For MCP-related projects, flag only applies to associated field samples that have detectable concentrations of the analyte at less than ten times (10x) the concentration found in the blank. For DOD-related projects, flag only applies to associated field samples that have detectable concentrations of the analyte at less than ten times (10x) the concentration found in the blank AND the analyte was detected above one-half the reporting limit (or above the reporting limit for common lab contaminants) in the associated method blank. For NJ-Air-related projects, flag only applies to associated field samples that have detectable concentrations of the analyte above the reporting limit. For NJ-related projects (excluding Air), flag only applies to associated field samples that have detectable concentrations of the analyte, which was detected above the reporting limit in the associated method blank or above five times the reporting limit for common lab contaminants (Phthalates, Acetone, Methylene Chloride, 2-Butanone).

C - Co-elution: The target analyte co-elutes with a known lab standard (i.e. surrogate, internal standards, etc.) for co-extracted analyses.

D - Concentration of analyte was quantified from diluted analysis. Flag only applies to field samples that have detectable concentrations of the analyte.

E - Concentration of analyte exceeds the range of the calibration curve and/or linear range of the instrument.

F - The ratio of quantifier ion response to qualifier ion response falls outside of the laboratory criteria. Results are considered to be an estimated maximum concentration.

G - The concentration may be biased high due to matrix interferences (i.e, co-elution) with non-target compound(s). The result should be considered estimated.

H - The analysis of pH was performed beyond the regulatory-required holding time of 15 minutes from the time of sample collection.

I - The lower value for the two columns has been reported due to obvious interference.

J - Estimated value. The Target analyte concentration is below the quantitation limit (RL), but above the Method Detection Limit (MDL) or Estimated Detection Limit (EDL) for SPME-related analyses. This represents an estimated concentration for Tentatively

Report Format: DU Report with 'J' Qualifiers

Project Name:	100 MAIN ST.	**Lab Number:**	L2331226
Project Number:	12461	**Report Date:**	06/13/23

Data Qualifiers

Identified Compounds (TICs).

M - Reporting Limit (RL) exceeds the MCP CAM Reporting Limit for this analyte.

ND - Not detected at the method detection limit (MDL) for the sample, or estimated detection limit (EDL) for SPME-related analyses.

NJ - Presumptive evidence of compound. This represents an estimated concentration for Tentatively Identified Compounds (TICs), where the identification is based on a mass spectral library search.

P - The RPD between the results for the two columns exceeds the method-specified criteria.

Q - The quality control sample exceeds the associated acceptance criteria. For DOD-related projects, LCS and/or Continuing Calibration Standard exceedences are also qualified on all associated sample results. Note: This flag is not applicable for matrix spike recoveries when the sample concentration is greater than 4x the spike added or for batch duplicate RPD when the sample concentrations are less than 5x the RL. (Metals only.)

R - Analytical results are from sample re-analysis.

RE - Analytical results are from sample re-extraction.

S - Analytical results are from modified screening analysis.

V - The surrogate associated with this target analyte has a recovery outside the QC acceptance limits. (Applicable to MassDEP DW Compliance samples only.)

Z - The batch matrix spike and/or duplicate associated with this target analyte has a recovery/RPD outside the QC acceptance limits. (Applicable to MassDEP DW Compliance samples only.)

Report Format: DU Report with 'J' Qualifiers

Project Name:	100 MAIN ST.	**Lab Number:**	L2331226
Project Number:	12461	**Report Date:**	06/13/23

REFERENCES

1 Test Methods for Evaluating Solid Waste: Physical/Chemical Methods. EPA SW-846. Third Edition. Updates I - VI, 2018.

121 Standard Methods for the Examination of Water and Wastewater. APHA-AWWA-WEF. Standard Methods Online.

LIMITATION OF LIABILITIES

Alpha Analytical performs services with reasonable care and diligence normal to the analytical testing laboratory industry. In the event of an error, the sole and exclusive responsibility of Alpha Analytical shall be to re-perform the work at it's own expense. In no event shall Alpha Analytical be held liable for any incidental, consequential or special damages, including but not limited to, damages in any way connected with the use of, interpretation of, information or analysis provided by Alpha Analytical.

We strongly urge our clients to comply with EPA protocol regarding sample volume, preservation, cooling, containers, sampling procedures, holding time and splitting of samples in the field.

Certification Information

The following analytes are not included in our Primary NELAP Scope of Accreditation:

Westborough Facility
EPA 624/624.1: m/p-xylene, o-xylene, Naphthalene
EPA 625/625.1: alpha-Terpineol
EPA 8260C/8260D: NPW: 1,2,4,5-Tetramethylbenzene; 4-Ethyltoluene, Azobenzene; SCM: Iodomethane (methyl iodide), 1,2,4,5-Tetramethylbenzene; 4-Ethyltoluene.
EPA 8270D/8270E: NPW: Dimethylnaphthalene,1,4-Diphenylhydrazine, alpha-Terpineol; SCM: Dimethylnaphthalene,1,4-Diphenylhydrazine.
SM4500: NPW: Amenable Cyanide; SCM: Total Phosphorus, TKN, NO2, NO3.

Mansfield Facility
SM 2540D: TSS
EPA 8082A: NPW: PCB: 1, 5, 31, 87,101, 110, 141, 151, 153, 180, 183, 187.
EPA TO-15: Halothane, 2,4,4-Trimethyl-2-pentene, 2,4,4-Trimethyl-1-pentene, Thiophene, 2-Methylthiophene, 3-Methylthiophene, 2-Ethylthiophene, 1,2,3-Trimethylbenzene, Indan, Indene, 1,2,4,5-Tetramethylbenzene, Benzothiophene, 1-Methylnaphthalene.
Biological Tissue Matrix: EPA 3050B

The following analytes are included in our Massachusetts DEP Scope of Accreditation

Westborough Facility:

Drinking Water
EPA 300.0: Chloride, Nitrate-N, Fluoride, Sulfate; **EPA 353.2**: Nitrate-N, Nitrite-N; **SM4500NO3-F**: Nitrate-N, Nitrite-N; **SM4500F-C, SM4500CN-CE, EPA 180.1, SM2130B, SM4500Cl-D, SM2320B, SM2540C, SM4500H-B, SM4500NO2-B**
EPA 332: Perchlorate; **EPA 524.2:** THMs and VOCs; **EPA 504.1:** EDB, DBCP.
Microbiology: **SM9215B; SM9223-P/A, SM9223B-Colilert-QT,SM9222D**.

Non-Potable Water
SM4500H,B, EPA 120.1, SM2510B, SM2540C, SM2320B, SM4500CL-E, SM4500F-BC, SM4500NH3-BH: Ammonia-N and Kjeldahl-N, **EPA 350.1**: Ammonia-N, **LACHAT 10-107-06-1-B**: Ammonia-N, **EPA 351.1, SM4500NO3-F, EPA 353.2**: Nitrate-N, **SM4500P-E, SM4500P-B, E, SM4500SO4-E, SM5220D, EPA 410.4, SM5210B, SM5310C, SM4500CL-D, EPA 1664, EPA 420.1, SM4500-CN-CE, SM2540D, EPA 300: Chloride, Sulfate, Nitrate.**
EPA 624.1: Volatile Halocarbons & Aromatics,
EPA 608.3: Chlordane, Toxaphene, Aldrin, alpha-BHC, beta-BHC, gamma-BHC, delta-BHC, Dieldrin, DDD, DDE, DDT, Endosulfan I, Endosulfan II, Endosulfan sulfate, Endrin, Endrin Aldehyde, Heptachlor, Heptachlor Epoxide, PCBs
EPA 625.1: SVOC (Acid/Base/Neutral Extractables), **EPA 600/4-81-045**: PCB-Oil.
Microbiology: **SM9223B-Colilert-QT; Enterolert-QT, SM9221E, EPA 1600, EPA 1603, SM9222D.**

Mansfield Facility:

Drinking Water
EPA 200.7: Al, Ba, Cd, Cr, Cu, Fe, Mn, Ni, Na, Ag, Ca, Zn. **EPA 200.8:** Al, Sb, As, Ba, Be, Cd, Cr, Cu, Pb, Mn, Ni, Se, Ag, TL, Zn. **EPA 245.1** Hg.
EPA 522, EPA 537.1.

Non-Potable Water
EPA 200.7: Al, Sb, As, Be, Cd, Ca, Cr, Co, Cu, Fe, Pb, Mg, Mn, Mo, Ni, K, Se, Ag, Na, Sr, TL, Ti, V, Zn.
EPA 200.8: Al, Sb, As, Be, Cd, Cr, Cu, Fe, Pb, Mn, Ni, K, Se, Ag, Na, TL, Zn.
EPA 245.1 Hg.
SM2340B

For a complete listing of analytes and methods, please contact your Alpha Project Manager.

NEW YORK CHAIN OF CUSTODY

ALPHA ANALYTICAL

Westborough, MA 01581
8 Walkup Dr.
TEL: 508-898-9220
FAX: 508-898-9193

Mansfield, MA 02048
320 Forbes Blvd
TEL: 508-822-9300
FAX: 508-822-3288

Service Centers
Mahwah, NJ 07430: 35 Whitney Rd, Suite 5
Albany, NY 12205: 14 Walker Way
Tonawanda, NY 14150: 275 Cooper Ave, Suite 105

Page 1 of 1

Date Rec'd in Lab: 6/5/23

ALPHA Job #: L2331226

Client Information

Client: SESI
Address: 959 US 46 Fl 3 S300
Parsippany NJ 07054
Phone: 973 808 9050
Fax:
Email: JCS@SESI.org

Project Information

Project Name: 100 Main St
Project Location: White Plains NY
Project #: 12461
(Use Project name as Project #) ☐
Project Manager: Jon Stuart
ALPHAQuote #:

Turn-Around Time

Standard ☑ Due Date:
Rush (only if pre approved) ☐ # of Days:

Deliverables

☐ ASP-A ☑ ASP-B
☐ EQuIS (1 File) ☐ EQuIS (4 File)
☐ Other

Regulatory Requirement

☐ NY TOGS ☐ NY Part 375
☑ AWQ Standards ☐ NY CP-51
☐ NY Restricted Use ☐ Other
☑ NY Unrestricted Use
☐ NYC Sewer Discharge

Billing Information

☑ Same as Client Info
PO # Renaissance Env. Mgmt.
Attn: Kevin McManus

Disposal Site Information

Please identify below location of applicable disposal facilities.
Disposal Facility:
☐ NJ ☐ NY
☐ Other:

These samples have been previously analyzed by Alpha ☐

Other project specific requirements/comments:

Please specify Metals or TAL.

ANALYSIS

TCL+30 ITAL

Sample Filtration
☐ Done
☐ Lab to do
Preservation
☐ Lab to do
(Please Specify below)

Total Bottle

ALPHA Lab ID (Lab Use Only)	Sample ID	Collection Date	Collection Time	Sample Matrix	Sampler's Initials	Sample Specific Comments
31226-01	SB-206(1.5-7)	6/5/23	10:00	S	CB	
02	SB-216(9-9.5)		11:15	S	CB	
03	SB-216(17-17.5)		11:20	S	CB	
04	SB-226(7-7.5)		12:15	S	CB	
05	SB-236(9.5-10)		12:50	S	CB	
06	SB-246(7.5-8)		12:30	S	CB	
07	SB-256(9.5-10)		10:40	S	CB	
08	GW-10		12:00	GW	CB	
09	GW-11		13:20	GW	CB	

Preservative Code:
A = None
B = HCl
C = HNO_3
D = H_2SO_4
E = NaOH
F = MeOH
G = $NaHSO_4$
H = $Na_2S_2O_3$
K/E = Zn Ac/NaOH
O = Other

Container Code
P = Plastic
A = Amber Glass
V = Vial
G = Glass
B = Bacteria Cup
C = Cube
O = Other
E = Encore
D = BOD Bottle

Westboro: Certification No: MA935
Mansfield: Certification No: MA015

Container Type	C/P											
Preservative	None											

Relinquished By:	Date/Time	Received By:	Date/Time
	06/05/23 1355		06/05/23 1355
	06/05/23 1830		6/5/23 18:40
	06/05/23		6/5/23 21:40
	6/5/23 23:30		6/5/23 23:30

Please print clearly, legibly and completely. Samples can not be logged in and turnaround time clock will not start until any ambiguities are resolved. BY EXECUTING THIS COC, THE CLIENT HAS READ AND AGREES TO BE BOUND BY ALPHA'S TERMS & CONDITIONS. (See reverse side.)

Form No: 01-25 HC (rev. 30-Sept-2013)

Quantitation Report (QT/LSC Reviewed)

Data Path : I:\VOLATILES\VOA104\2023\230609A\
Data File : V04230609A26.D
Acq On : 9 Jun 2023 5:55 pm
Operator : VOA104:JIC
Sample : L2331226-02,31H,5.02,5,0.100,,X
Misc : WG1790043,ICAL19908
ALS Vial : 26 Sample Multiplier: 1

Quant Time: Jun 12 06:47:50 2023
Quant Method : I:\VOLATILES\VOA104\2023\230609A\V104_230407N_8260.m
Quant Title : VOLATILES BY GC/MS
QLast Update : Tue Apr 11 16:51:00 2023
Response via : Initial Calibration

Sub List : 8260-NYTCL - Megamix plus Diox30609A\\V04230609A01.D•



ANALYTICAL REPORT

Lab Number:	L2331480
Client:	Soils Engineering Services, Inc. 959 Route 46E Parsippany, NJ 07054
ATTN:	Steven Gustems
Phone:	(973) 808-9050
Project Name:	100 MAIN ST.
Project Number:	12461
Report Date:	06/16/23

The original project report/data package is held by Alpha Analytical. This report/data package is paginated and should be reproduced only in its entirety. Alpha Analytical holds no responsibility for results and/or data that are not consistent with the original.

Certifications & Approvals: MA (M-MA086), NH NELAP (2064), CT (PH-0826), IL (200077), IN (C-MA-03), KY (KY98045), ME (MA00086), MD (348), NJ (MA935), NY (11148), NC (25700/666), OH (CL108), OR (MA-1316), PA (68-03671), RI (LAO00065), TX (T104704476), VT (VT-0935), VA (460195), USDA (Permit #525-23-122-91930).

Eight Walkup Drive, Westborough, MA 01581-1019
508-898-9220 (Fax) 508-898-9193 800-624-9220 - www.alphalab.com

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331480
Report Date: 06/16/23

Alpha Sample ID	Client ID	Matrix	Sample Location	Collection Date/Time	Receive Date
L2331480-01	SB-28S(2-2.5)	SOIL	WHITE PLAINS, NY	06/06/23 09:30	06/06/23
L2331480-02	SB-29S(1-1.5)	SOIL	WHITE PLAINS, NY	06/06/23 10:15	06/06/23
L2331480-03	SB-30S(7-7.5)	SOIL	WHITE PLAINS, NY	06/06/23 10:30	06/06/23
L2331480-04	SB-30S(1.5-2)	SOIL	WHITE PLAINS, NY	06/06/23 10:40	06/06/23
L2331480-05	SB-31S(0.5-1)	SOIL	WHITE PLAINS, NY	06/06/23 10:55	06/06/23
L2331480-06	GW-12	WATER	WHITE PLAINS, NY	06/06/23 09:50	06/06/23
L2331480-07	GW-13	WATER	WHITE PLAINS, NY	06/06/23 11:20	06/06/23
L2331480-08	SB-32S(3-3.5)	SOIL	WHITE PLAINS, NY	06/06/23 12:15	06/06/23

Project Name:	100 MAIN ST.	**Lab Number:**	L2331480
Project Number:	12461	**Report Date:**	06/16/23

Case Narrative

The samples were received in accordance with the Chain of Custody and no significant deviations were encountered during the preparation or analysis unless otherwise noted. Sample Receipt, Container Information, and the Chain of Custody are located at the back of the report.

Results contained within this report relate only to the samples submitted under this Alpha Lab Number and meet NELAP requirements for all NELAP accredited parameters unless otherwise noted in the following narrative. The data presented in this report is organized by parameter (i.e. VOC, SVOC, etc.). Sample specific Quality Control data (i.e. Surrogate Spike Recovery) is reported at the end of the target analyte list for each individual sample, followed by the Laboratory Batch Quality Control at the end of each parameter. Tentatively Identified Compounds (TICs), if requested, are reported for compounds identified to be present and are not part of the method/program Target Compound List, even if only a subset of the TCL are being reported. If a sample was re-analyzed or re-extracted due to a required quality control corrective action and if both sets of data are reported, the Laboratory ID of the re-analysis or re-extraction is designated with an "R" or "RE", respectively.

When multiple Batch Quality Control elements are reported (e.g. more than one LCS), the associated samples for each element are noted in the grey shaded header line of each data table. Any Laboratory Batch, Sample Specific % recovery or RPD value that is outside the listed Acceptance Criteria is bolded in the report. In reference to questions H (CAM) or 4 (RCP) when "NO" is checked, the performance criteria for CAM and RCP methods allow for some quality control failures to occur and still be within method compliance. In these instances, the specific failure is not narrated but noted in the associated QC Outlier Summary Report, located directly after the Case Narrative. QC information is also incorporated in the Data Usability Assessment table (Format 11) of our Data Merger tool, where it can be reviewed in conjunction with the sample result, associated regulatory criteria and any associated data usability implications.

Soil/sediments, solids and tissues are reported on a dry weight basis unless otherwise noted. Definitions of all data qualifiers and acronyms used in this report are provided in the Glossary located at the back of the report.

HOLD POLICY - For samples submitted on hold, Alpha's policy is to hold samples (with the exception of Air canisters) free of charge for 21 calendar days from the date the project is completed. After 21 calendar days, we will dispose of all samples submitted including those put on hold unless you have contacted your Alpha Project Manager and made arrangements for Alpha to continue to hold the samples. Air canisters will be disposed after 3 business days from the date the project is completed.

Please contact Project Management at 800-624-9220 with any questions.

Project Name: 100 MAIN ST. **Lab Number:** L2331480
Project Number: 12461 **Report Date:** 06/16/23

Case Narrative (continued)

Report Submission

All non-detect (ND) or estimated concentrations (J-qualified) have been quantitated to the limit noted in the MDL column.

Semivolatile Organics

The WG1789052-2/-3 LCS/LCSD recoveries, associated with L2331480-06 and -07, are below the acceptance criteria for 4-chloroaniline (0%/0%) and benzoic acid (0%/0%); however, it has been identified as a "difficult" analyte. The results of the associated samples are reported.

Total Metals

L2331480-01 through -05 and -08: The sample has elevated detection limits for all elements, with the exception of mercury, due to the dilution required by the sample matrix.

Cyanide, Total

The WG1788885-5 MSD recovery, performed on L2331480-06, is outside the acceptance criteria for cyanide, total (63%); however, the associated LCS recovery is within criteria. No further action was taken. The MS/MSD RPD for cyanide, total (43%) is above the acceptance criteria.

I, the undersigned, attest under the pains and penalties of perjury that, to the best of my knowledge and belief and based upon my personal inquiry of those responsible for providing the information contained in this analytical report, such information is accurate and complete. This certificate of analysis is not complete unless this page accompanies any and all pages of this report.

Authorized Signature: Cristin Walker

Title: Technical Director/Representative Date: 06/16/23

ORGANICS

VOLATILES

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-01
Client ID: SB-28S(2-2.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/06/23 09:30
Date Received: 06/06/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8260D
Analytical Date: 06/09/23 14:10
Analyst: AJK
Percent Solids: 92%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Methylene chloride	ND		ug/kg	4.9	2.2	1
1,1-Dichloroethane	ND		ug/kg	0.97	0.14	1
Chloroform	ND		ug/kg	1.5	0.14	1
Carbon tetrachloride	ND		ug/kg	0.97	0.22	1
1,2-Dichloropropane	ND		ug/kg	0.97	0.12	1
Dibromochloromethane	ND		ug/kg	0.97	0.14	1
1,1,2-Trichloroethane	ND		ug/kg	0.97	0.26	1
Tetrachloroethene	ND		ug/kg	0.49	0.19	1
Chlorobenzene	ND		ug/kg	0.49	0.12	1
Trichlorofluoromethane	ND		ug/kg	3.9	0.68	1
1,2-Dichloroethane	ND		ug/kg	0.97	0.25	1
1,1,1-Trichloroethane	ND		ug/kg	0.49	0.16	1
Bromodichloromethane	ND		ug/kg	0.49	0.11	1
trans-1,3-Dichloropropene	ND		ug/kg	0.97	0.26	1
cis-1,3-Dichloropropene	ND		ug/kg	0.49	0.15	1
1,3-Dichloropropene, Total	ND		ug/kg	0.49	0.15	1
1,1-Dichloropropene	ND		ug/kg	0.49	0.15	1
Bromoform	ND		ug/kg	3.9	0.24	1
1,1,2,2-Tetrachloroethane	ND		ug/kg	0.49	0.16	1
Benzene	ND		ug/kg	0.49	0.16	1
Toluene	ND		ug/kg	0.97	0.53	1
Ethylbenzene	ND		ug/kg	0.97	0.14	1
Chloromethane	ND		ug/kg	3.9	0.91	1
Bromomethane	ND		ug/kg	1.9	0.56	1
Vinyl chloride	ND		ug/kg	0.97	0.33	1
Chloroethane	ND		ug/kg	1.9	0.44	1
1,1-Dichloroethene	ND		ug/kg	0.97	0.23	1
trans-1,2-Dichloroethene	ND		ug/kg	1.5	0.13	1

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-01 Date Collected: 06/06/23 09:30

Client ID: SB-28S(2-2.5) Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Trichloroethene	ND		ug/kg	0.49	0.13	1
1,2-Dichlorobenzene	ND		ug/kg	1.9	0.14	1
1,3-Dichlorobenzene	ND		ug/kg	1.9	0.14	1
1,4-Dichlorobenzene	ND		ug/kg	1.9	0.17	1
Methyl tert butyl ether	ND		ug/kg	1.9	0.20	1
p/m-Xylene	ND		ug/kg	1.9	0.54	1
o-Xylene	ND		ug/kg	0.97	0.28	1
Xylenes, Total	ND		ug/kg	0.97	0.28	1
cis-1,2-Dichloroethene	ND		ug/kg	0.97	0.17	1
1,2-Dichloroethene, Total	ND		ug/kg	0.97	0.13	1
Dibromomethane	ND		ug/kg	1.9	0.23	1
Styrene	ND		ug/kg	0.97	0.19	1
Dichlorodifluoromethane	ND		ug/kg	9.7	0.89	1
Acetone	53		ug/kg	9.7	4.7	1
Carbon disulfide	ND		ug/kg	9.7	4.4	1
2-Butanone	11		ug/kg	9.7	2.2	1
Vinyl acetate	ND		ug/kg	9.7	2.1	1
4-Methyl-2-pentanone	ND		ug/kg	9.7	1.2	1
1,2,3-Trichloropropane	ND		ug/kg	1.9	0.12	1
2-Hexanone	ND		ug/kg	9.7	1.1	1
Bromochloromethane	ND		ug/kg	1.9	0.20	1
2,2-Dichloropropane	ND		ug/kg	1.9	0.20	1
1,2-Dibromoethane	ND		ug/kg	0.97	0.27	1
1,3-Dichloropropane	ND		ug/kg	1.9	0.16	1
1,1,1,2-Tetrachloroethane	ND		ug/kg	0.49	0.13	1
Bromobenzene	ND		ug/kg	1.9	0.14	1
n-Butylbenzene	ND		ug/kg	0.97	0.16	1
sec-Butylbenzene	ND		ug/kg	0.97	0.14	1
tert-Butylbenzene	ND		ug/kg	1.9	0.11	1
o-Chlorotoluene	ND		ug/kg	1.9	0.19	1
p-Chlorotoluene	ND		ug/kg	1.9	0.10	1
1,2-Dibromo-3-chloropropane	ND		ug/kg	2.9	0.97	1
Hexachlorobutadiene	ND		ug/kg	3.9	0.16	1
Isopropylbenzene	ND		ug/kg	0.97	0.11	1
p-Isopropyltoluene	ND		ug/kg	0.97	0.11	1
Naphthalene	ND		ug/kg	3.9	0.63	1
Acrylonitrile	ND		ug/kg	3.9	1.1	1

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-01 Date Collected: 06/06/23 09:30

Client ID: SB-28S(2-2.5) Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
n-Propylbenzene	ND		ug/kg	0.97	0.17	1
1,2,3-Trichlorobenzene	ND		ug/kg	1.9	0.31	1
1,2,4-Trichlorobenzene	ND		ug/kg	1.9	0.26	1
1,3,5-Trimethylbenzene	ND		ug/kg	1.9	0.19	1
1,2,4-Trimethylbenzene	ND		ug/kg	1.9	0.32	1
1,4-Dioxane	ND		ug/kg	78	34.	1
p-Diethylbenzene	ND		ug/kg	1.9	0.17	1
p-Ethyltoluene	ND		ug/kg	1.9	0.37	1
1,2,4,5-Tetramethylbenzene	ND		ug/kg	1.9	0.19	1
Ethyl ether	ND		ug/kg	1.9	0.33	1
trans-1,4-Dichloro-2-butene	ND		ug/kg	4.9	1.4	1
Tentatively Identified Compounds						
Total TIC Compounds	37.8	J	ug/kg			1
Unknown Naphthalene	3.65	J	ug/kg			1
Unknown	4.98	J	ug/kg			1
Unknown	6.77	J	ug/kg			1
Unknown Alkane	3.01	J	ug/kg			1
Unknown Aromatic	3.02	J	ug/kg			1
Unknown	2.71	J	ug/kg			1
Unknown	4.26	J	ug/kg			1
Unknown	2.78	J	ug/kg			1
Unknown	2.88	J	ug/kg			1
Unknown	3.71	J	ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	101		70-130
Toluene-d8	102		70-130
4-Bromofluorobenzene	101		70-130
Dibromofluoromethane	97		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-02
Client ID: SB-29S(1-1.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/06/23 10:15
Date Received: 06/06/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8260D
Analytical Date: 06/09/23 14:36
Analyst: AJK
Percent Solids: 93%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Methylene chloride	ND		ug/kg	5.3	2.4	1
1,1-Dichloroethane	ND		ug/kg	1.0	0.15	1
Chloroform	ND		ug/kg	1.6	0.15	1
Carbon tetrachloride	ND		ug/kg	1.0	0.24	1
1,2-Dichloropropane	ND		ug/kg	1.0	0.13	1
Dibromochloromethane	ND		ug/kg	1.0	0.15	1
1,1,2-Trichloroethane	ND		ug/kg	1.0	0.28	1
Tetrachloroethene	ND		ug/kg	0.53	0.21	1
Chlorobenzene	ND		ug/kg	0.53	0.13	1
Trichlorofluoromethane	ND		ug/kg	4.2	0.73	1
1,2-Dichloroethane	ND		ug/kg	1.0	0.27	1
1,1,1-Trichloroethane	ND		ug/kg	0.53	0.18	1
Bromodichloromethane	ND		ug/kg	0.53	0.11	1
trans-1,3-Dichloropropene	ND		ug/kg	1.0	0.29	1
cis-1,3-Dichloropropene	ND		ug/kg	0.53	0.17	1
1,3-Dichloropropene, Total	ND		ug/kg	0.53	0.17	1
1,1-Dichloropropene	ND		ug/kg	0.53	0.17	1
Bromoform	ND		ug/kg	4.2	0.26	1
1,1,2,2-Tetrachloroethane	ND		ug/kg	0.53	0.17	1
Benzene	ND		ug/kg	0.53	0.17	1
Toluene	ND		ug/kg	1.0	0.57	1
Ethylbenzene	ND		ug/kg	1.0	0.15	1
Chloromethane	ND		ug/kg	4.2	0.98	1
Bromomethane	ND		ug/kg	2.1	0.61	1
Vinyl chloride	ND		ug/kg	1.0	0.35	1
Chloroethane	ND		ug/kg	2.1	0.48	1
1,1-Dichloroethene	ND		ug/kg	1.0	0.25	1
trans-1,2-Dichloroethene	ND		ug/kg	1.6	0.14	1

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-02 Date Collected: 06/06/23 10:15

Client ID: SB-29S(1-1.5) Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Trichloroethene	ND		ug/kg	0.53	0.14	1
1,2-Dichlorobenzene	ND		ug/kg	2.1	0.15	1
1,3-Dichlorobenzene	ND		ug/kg	2.1	0.16	1
1,4-Dichlorobenzene	ND		ug/kg	2.1	0.18	1
Methyl tert butyl ether	ND		ug/kg	2.1	0.21	1
p/m-Xylene	ND		ug/kg	2.1	0.59	1
o-Xylene	ND		ug/kg	1.0	0.31	1
Xylenes, Total	ND		ug/kg	1.0	0.31	1
cis-1,2-Dichloroethene	ND		ug/kg	1.0	0.18	1
1,2-Dichloroethene, Total	ND		ug/kg	1.0	0.14	1
Dibromomethane	ND		ug/kg	2.1	0.25	1
Styrene	ND		ug/kg	1.0	0.21	1
Dichlorodifluoromethane	ND		ug/kg	10	0.96	1
Acetone	ND		ug/kg	10	5.1	1
Carbon disulfide	ND		ug/kg	10	4.8	1
2-Butanone	3.2	J	ug/kg	10	2.3	1
Vinyl acetate	ND		ug/kg	10	2.3	1
4-Methyl-2-pentanone	ND		ug/kg	10	1.3	1
1,2,3-Trichloropropane	ND		ug/kg	2.1	0.13	1
2-Hexanone	ND		ug/kg	10	1.2	1
Bromochloromethane	ND		ug/kg	2.1	0.22	1
2,2-Dichloropropane	ND		ug/kg	2.1	0.21	1
1,2-Dibromoethane	ND		ug/kg	1.0	0.29	1
1,3-Dichloropropane	ND		ug/kg	2.1	0.18	1
1,1,1,2-Tetrachloroethane	ND		ug/kg	0.53	0.14	1
Bromobenzene	ND		ug/kg	2.1	0.15	1
n-Butylbenzene	ND		ug/kg	1.0	0.18	1
sec-Butylbenzene	ND		ug/kg	1.0	0.15	1
tert-Butylbenzene	ND		ug/kg	2.1	0.12	1
o-Chlorotoluene	ND		ug/kg	2.1	0.20	1
p-Chlorotoluene	ND		ug/kg	2.1	0.11	1
1,2-Dibromo-3-chloropropane	ND		ug/kg	3.2	1.0	1
Hexachlorobutadiene	ND		ug/kg	4.2	0.18	1
Isopropylbenzene	ND		ug/kg	1.0	0.11	1
p-Isopropyltoluene	ND		ug/kg	1.0	0.11	1
Naphthalene	ND		ug/kg	4.2	0.68	1
Acrylonitrile	ND		ug/kg	4.2	1.2	1

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-02 Date Collected: 06/06/23 10:15

Client ID: SB-29S(1-1.5) Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
n-Propylbenzene	ND		ug/kg	1.0	0.18	1
1,2,3-Trichlorobenzene	ND		ug/kg	2.1	0.34	1
1,2,4-Trichlorobenzene	ND		ug/kg	2.1	0.29	1
1,3,5-Trimethylbenzene	ND		ug/kg	2.1	0.20	1
1,2,4-Trimethylbenzene	ND		ug/kg	2.1	0.35	1
1,4-Dioxane	ND		ug/kg	84	37.	1
p-Diethylbenzene	ND		ug/kg	2.1	0.19	1
p-Ethyltoluene	ND		ug/kg	2.1	0.40	1
1,2,4,5-Tetramethylbenzene	ND		ug/kg	2.1	0.20	1
Ethyl ether	ND		ug/kg	2.1	0.36	1
trans-1,4-Dichloro-2-butene	ND		ug/kg	5.3	1.5	1
Tentatively Identified Compounds						
Total TIC Compounds	2.70	J	ug/kg			1
Unknown Alkane	2.70	J	ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	103		70-130
Toluene-d8	102		70-130
4-Bromofluorobenzene	99		70-130
Dibromofluoromethane	96		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-03
Client ID: SB-30S(7-7.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/06/23 10:30
Date Received: 06/06/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8260D
Analytical Date: 06/09/23 15:02
Analyst: AJK
Percent Solids: 89%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Methylene chloride	ND		ug/kg	5.3	2.4	1
1,1-Dichloroethane	ND		ug/kg	1.0	0.15	1
Chloroform	ND		ug/kg	1.6	0.15	1
Carbon tetrachloride	ND		ug/kg	1.0	0.24	1
1,2-Dichloropropane	ND		ug/kg	1.0	0.13	1
Dibromochloromethane	ND		ug/kg	1.0	0.15	1
1,1,2-Trichloroethane	ND		ug/kg	1.0	0.28	1
Tetrachloroethene	ND		ug/kg	0.53	0.21	1
Chlorobenzene	ND		ug/kg	0.53	0.13	1
Trichlorofluoromethane	ND		ug/kg	4.2	0.73	1
1,2-Dichloroethane	ND		ug/kg	1.0	0.27	1
1,1,1-Trichloroethane	ND		ug/kg	0.53	0.18	1
Bromodichloromethane	ND		ug/kg	0.53	0.11	1
trans-1,3-Dichloropropene	ND		ug/kg	1.0	0.29	1
cis-1,3-Dichloropropene	ND		ug/kg	0.53	0.17	1
1,3-Dichloropropene, Total	ND		ug/kg	0.53	0.17	1
1,1-Dichloropropene	ND		ug/kg	0.53	0.17	1
Bromoform	ND		ug/kg	4.2	0.26	1
1,1,2,2-Tetrachloroethane	ND		ug/kg	0.53	0.17	1
Benzene	ND		ug/kg	0.53	0.17	1
Toluene	ND		ug/kg	1.0	0.57	1
Ethylbenzene	ND		ug/kg	1.0	0.15	1
Chloromethane	ND		ug/kg	4.2	0.98	1
Bromomethane	ND		ug/kg	2.1	0.61	1
Vinyl chloride	ND		ug/kg	1.0	0.35	1
Chloroethane	ND		ug/kg	2.1	0.48	1
1,1-Dichloroethene	ND		ug/kg	1.0	0.25	1
trans-1,2-Dichloroethene	ND		ug/kg	1.6	0.14	1

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-03 Date Collected: 06/06/23 10:30

Client ID: SB-30S(7-7.5) Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Trichloroethene	ND		ug/kg	0.53	0.14	1
1,2-Dichlorobenzene	ND		ug/kg	2.1	0.15	1
1,3-Dichlorobenzene	ND		ug/kg	2.1	0.16	1
1,4-Dichlorobenzene	ND		ug/kg	2.1	0.18	1
Methyl tert butyl ether	ND		ug/kg	2.1	0.21	1
p/m-Xylene	ND		ug/kg	2.1	0.59	1
o-Xylene	ND		ug/kg	1.0	0.31	1
Xylenes, Total	ND		ug/kg	1.0	0.31	1
cis-1,2-Dichloroethene	ND		ug/kg	1.0	0.18	1
1,2-Dichloroethene, Total	ND		ug/kg	1.0	0.14	1
Dibromomethane	ND		ug/kg	2.1	0.25	1
Styrene	ND		ug/kg	1.0	0.21	1
Dichlorodifluoromethane	ND		ug/kg	10	0.96	1
Acetone	32		ug/kg	10	5.1	1
Carbon disulfide	ND		ug/kg	10	4.8	1
2-Butanone	7.6	J	ug/kg	10	2.3	1
Vinyl acetate	ND		ug/kg	10	2.3	1
4-Methyl-2-pentanone	ND		ug/kg	10	1.3	1
1,2,3-Trichloropropane	ND		ug/kg	2.1	0.13	1
2-Hexanone	ND		ug/kg	10	1.2	1
Bromochloromethane	ND		ug/kg	2.1	0.22	1
2,2-Dichloropropane	ND		ug/kg	2.1	0.21	1
1,2-Dibromoethane	ND		ug/kg	1.0	0.29	1
1,3-Dichloropropane	ND		ug/kg	2.1	0.18	1
1,1,1,2-Tetrachloroethane	ND		ug/kg	0.53	0.14	1
Bromobenzene	ND		ug/kg	2.1	0.15	1
n-Butylbenzene	ND		ug/kg	1.0	0.18	1
sec-Butylbenzene	ND		ug/kg	1.0	0.15	1
tert-Butylbenzene	ND		ug/kg	2.1	0.12	1
o-Chlorotoluene	ND		ug/kg	2.1	0.20	1
p-Chlorotoluene	ND		ug/kg	2.1	0.11	1
1,2-Dibromo-3-chloropropane	ND		ug/kg	3.2	1.0	1
Hexachlorobutadiene	ND		ug/kg	4.2	0.18	1
Isopropylbenzene	ND		ug/kg	1.0	0.11	1
p-Isopropyltoluene	ND		ug/kg	1.0	0.11	1
Naphthalene	ND		ug/kg	4.2	0.68	1
Acrylonitrile	ND		ug/kg	4.2	1.2	1

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-03 Date Collected: 06/06/23 10:30

Client ID: SB-30S(7-7.5) Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
n-Propylbenzene	ND		ug/kg	1.0	0.18	1
1,2,3-Trichlorobenzene	ND		ug/kg	2.1	0.34	1
1,2,4-Trichlorobenzene	ND		ug/kg	2.1	0.29	1
1,3,5-Trimethylbenzene	ND		ug/kg	2.1	0.20	1
1,2,4-Trimethylbenzene	ND		ug/kg	2.1	0.35	1
1,4-Dioxane	ND		ug/kg	84	37.	1
p-Diethylbenzene	ND		ug/kg	2.1	0.19	1
p-Ethyltoluene	ND		ug/kg	2.1	0.40	1
1,2,4,5-Tetramethylbenzene	ND		ug/kg	2.1	0.20	1
Ethyl ether	ND		ug/kg	2.1	0.36	1
trans-1,4-Dichloro-2-butene	ND		ug/kg	5.3	1.5	1
Tentatively Identified Compounds						
Total TIC Compounds	591	J	ug/kg			1
Unknown	79.9	J	ug/kg			1
Unknown	35.5	J	ug/kg			1
Unknown	119	J	ug/kg			1
Unknown Cyclohexane	35.9	J	ug/kg			1
Unknown Naphthalene	58.6	J	ug/kg			1
Unknown	69.7	J	ug/kg			1
Unknown	32.6	J	ug/kg			1
Unknown	44.2	J	ug/kg			1
Unknown Alkane	40.3	J	ug/kg			1
Unknown Naphthalene	75.2	J	ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	100		70-130
Toluene-d8	101		70-130
4-Bromofluorobenzene	112		70-130
Dibromofluoromethane	96		70-130

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-04
Client ID: SB-30S(1.5-2)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/06/23 10:40
Date Received: 06/06/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8260D
Analytical Date: 06/09/23 15:28
Analyst: AJK
Percent Solids: 92%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Methylene chloride	ND		ug/kg	5.8	2.6	1
1,1-Dichloroethane	ND		ug/kg	1.2	0.17	1
Chloroform	ND		ug/kg	1.7	0.16	1
Carbon tetrachloride	ND		ug/kg	1.2	0.26	1
1,2-Dichloropropane	ND		ug/kg	1.2	0.14	1
Dibromochloromethane	ND		ug/kg	1.2	0.16	1
1,1,2-Trichloroethane	ND		ug/kg	1.2	0.31	1
Tetrachloroethene	ND		ug/kg	0.58	0.23	1
Chlorobenzene	ND		ug/kg	0.58	0.15	1
Trichlorofluoromethane	ND		ug/kg	4.6	0.80	1
1,2-Dichloroethane	ND		ug/kg	1.2	0.30	1
1,1,1-Trichloroethane	ND		ug/kg	0.58	0.19	1
Bromodichloromethane	ND		ug/kg	0.58	0.12	1
trans-1,3-Dichloropropene	ND		ug/kg	1.2	0.32	1
cis-1,3-Dichloropropene	ND		ug/kg	0.58	0.18	1
1,3-Dichloropropene, Total	ND		ug/kg	0.58	0.18	1
1,1-Dichloropropene	ND		ug/kg	0.58	0.18	1
Bromoform	ND		ug/kg	4.6	0.28	1
1,1,2,2-Tetrachloroethane	ND		ug/kg	0.58	0.19	1
Benzene	ND		ug/kg	0.58	0.19	1
Toluene	ND		ug/kg	1.2	0.63	1
Ethylbenzene	ND		ug/kg	1.2	0.16	1
Chloromethane	ND		ug/kg	4.6	1.1	1
Bromomethane	ND		ug/kg	2.3	0.67	1
Vinyl chloride	ND		ug/kg	1.2	0.39	1
Chloroethane	ND		ug/kg	2.3	0.52	1
1,1-Dichloroethene	ND		ug/kg	1.2	0.27	1
trans-1,2-Dichloroethene	ND		ug/kg	1.7	0.16	1

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-04 Date Collected: 06/06/23 10:40

Client ID: SB-30S(1.5-2) Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Trichloroethene	ND		ug/kg	0.58	0.16	1
1,2-Dichlorobenzene	ND		ug/kg	2.3	0.17	1
1,3-Dichlorobenzene	ND		ug/kg	2.3	0.17	1
1,4-Dichlorobenzene	ND		ug/kg	2.3	0.20	1
Methyl tert butyl ether	ND		ug/kg	2.3	0.23	1
p/m-Xylene	ND		ug/kg	2.3	0.65	1
o-Xylene	ND		ug/kg	1.2	0.34	1
Xylenes, Total	ND		ug/kg	1.2	0.34	1
cis-1,2-Dichloroethene	ND		ug/kg	1.2	0.20	1
1,2-Dichloroethene, Total	ND		ug/kg	1.2	0.16	1
Dibromomethane	ND		ug/kg	2.3	0.27	1
Styrene	ND		ug/kg	1.2	0.23	1
Dichlorodifluoromethane	ND		ug/kg	12	1.0	1
Acetone	ND		ug/kg	12	5.6	1
Carbon disulfide	ND		ug/kg	12	5.2	1
2-Butanone	ND		ug/kg	12	2.6	1
Vinyl acetate	ND		ug/kg	12	2.5	1
4-Methyl-2-pentanone	ND		ug/kg	12	1.5	1
1,2,3-Trichloropropane	ND		ug/kg	2.3	0.15	1
2-Hexanone	ND		ug/kg	12	1.4	1
Bromochloromethane	ND		ug/kg	2.3	0.24	1
2,2-Dichloropropane	ND		ug/kg	2.3	0.23	1
1,2-Dibromoethane	ND		ug/kg	1.2	0.32	1
1,3-Dichloropropane	ND		ug/kg	2.3	0.19	1
1,1,1,2-Tetrachloroethane	ND		ug/kg	0.58	0.15	1
Bromobenzene	ND		ug/kg	2.3	0.17	1
n-Butylbenzene	ND		ug/kg	1.2	0.19	1
sec-Butylbenzene	ND		ug/kg	1.2	0.17	1
tert-Butylbenzene	ND		ug/kg	2.3	0.14	1
o-Chlorotoluene	ND		ug/kg	2.3	0.22	1
p-Chlorotoluene	ND		ug/kg	2.3	0.12	1
1,2-Dibromo-3-chloropropane	ND		ug/kg	3.5	1.2	1
Hexachlorobutadiene	ND		ug/kg	4.6	0.20	1
Isopropylbenzene	ND		ug/kg	1.2	0.12	1
p-Isopropyltoluene	ND		ug/kg	1.2	0.12	1
Naphthalene	ND		ug/kg	4.6	0.75	1
Acrylonitrile	ND		ug/kg	4.6	1.3	1

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-04 Date Collected: 06/06/23 10:40

Client ID: SB-30S(1.5-2) Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
n-Propylbenzene	ND		ug/kg	1.2	0.20	1
1,2,3-Trichlorobenzene	ND		ug/kg	2.3	0.37	1
1,2,4-Trichlorobenzene	ND		ug/kg	2.3	0.31	1
1,3,5-Trimethylbenzene	ND		ug/kg	2.3	0.22	1
1,2,4-Trimethylbenzene	ND		ug/kg	2.3	0.38	1
1,4-Dioxane	ND		ug/kg	92	40.	1
p-Diethylbenzene	ND		ug/kg	2.3	0.20	1
p-Ethyltoluene	ND		ug/kg	2.3	0.44	1
1,2,4,5-Tetramethylbenzene	ND		ug/kg	2.3	0.22	1
Ethyl ether	ND		ug/kg	2.3	0.39	1
trans-1,4-Dichloro-2-butene	ND		ug/kg	5.8	1.6	1
Tentatively Identified Compounds						
Total TIC Compounds	2.91	J	ug/kg			1
Unknown	2.91	J	ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	98		70-130
Toluene-d8	101		70-130
4-Bromofluorobenzene	99		70-130
Dibromofluoromethane	95		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-05
Client ID: SB-31S(0.5-1)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/06/23 10:55
Date Received: 06/06/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8260D
Analytical Date: 06/09/23 15:54
Analyst: AJK
Percent Solids: 89%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Methylene chloride	ND		ug/kg	5.2	2.4	1
1,1-Dichloroethane	ND		ug/kg	1.0	0.15	1
Chloroform	ND		ug/kg	1.6	0.14	1
Carbon tetrachloride	ND		ug/kg	1.0	0.24	1
1,2-Dichloropropane	ND		ug/kg	1.0	0.13	1
Dibromochloromethane	ND		ug/kg	1.0	0.14	1
1,1,2-Trichloroethane	ND		ug/kg	1.0	0.28	1
Tetrachloroethene	ND		ug/kg	0.52	0.20	1
Chlorobenzene	ND		ug/kg	0.52	0.13	1
Trichlorofluoromethane	ND		ug/kg	4.2	0.72	1
1,2-Dichloroethane	ND		ug/kg	1.0	0.27	1
1,1,1-Trichloroethane	ND		ug/kg	0.52	0.17	1
Bromodichloromethane	ND		ug/kg	0.52	0.11	1
trans-1,3-Dichloropropene	ND		ug/kg	1.0	0.28	1
cis-1,3-Dichloropropene	ND		ug/kg	0.52	0.16	1
1,3-Dichloropropene, Total	ND		ug/kg	0.52	0.16	1
1,1-Dichloropropene	ND		ug/kg	0.52	0.16	1
Bromoform	ND		ug/kg	4.2	0.26	1
1,1,2,2-Tetrachloroethane	ND		ug/kg	0.52	0.17	1
Benzene	ND		ug/kg	0.52	0.17	1
Toluene	ND		ug/kg	1.0	0.56	1
Ethylbenzene	ND		ug/kg	1.0	0.15	1
Chloromethane	ND		ug/kg	4.2	0.97	1
Bromomethane	ND		ug/kg	2.1	0.60	1
Vinyl chloride	ND		ug/kg	1.0	0.35	1
Chloroethane	ND		ug/kg	2.1	0.47	1
1,1-Dichloroethene	ND		ug/kg	1.0	0.25	1
trans-1,2-Dichloroethene	ND		ug/kg	1.6	0.14	1

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-05 Date Collected: 06/06/23 10:55

Client ID: SB-31S(0.5-1) Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Trichloroethene	ND		ug/kg	0.52	0.14	1
1,2-Dichlorobenzene	ND		ug/kg	2.1	0.15	1
1,3-Dichlorobenzene	ND		ug/kg	2.1	0.15	1
1,4-Dichlorobenzene	ND		ug/kg	2.1	0.18	1
Methyl tert butyl ether	ND		ug/kg	2.1	0.21	1
p/m-Xylene	ND		ug/kg	2.1	0.58	1
o-Xylene	ND		ug/kg	1.0	0.30	1
Xylenes, Total	ND		ug/kg	1.0	0.30	1
cis-1,2-Dichloroethene	ND		ug/kg	1.0	0.18	1
1,2-Dichloroethene, Total	ND		ug/kg	1.0	0.14	1
Dibromomethane	ND		ug/kg	2.1	0.25	1
Styrene	ND		ug/kg	1.0	0.20	1
Dichlorodifluoromethane	ND		ug/kg	10	0.95	1
Acetone	ND		ug/kg	10	5.0	1
Carbon disulfide	ND		ug/kg	10	4.7	1
2-Butanone	ND		ug/kg	10	2.3	1
Vinyl acetate	ND		ug/kg	10	2.2	1
4-Methyl-2-pentanone	ND		ug/kg	10	1.3	1
1,2,3-Trichloropropane	ND		ug/kg	2.1	0.13	1
2-Hexanone	ND		ug/kg	10	1.2	1
Bromochloromethane	ND		ug/kg	2.1	0.21	1
2,2-Dichloropropane	ND		ug/kg	2.1	0.21	1
1,2-Dibromoethane	ND		ug/kg	1.0	0.29	1
1,3-Dichloropropane	ND		ug/kg	2.1	0.17	1
1,1,1,2-Tetrachloroethane	ND		ug/kg	0.52	0.14	1
Bromobenzene	ND		ug/kg	2.1	0.15	1
n-Butylbenzene	ND		ug/kg	1.0	0.17	1
sec-Butylbenzene	ND		ug/kg	1.0	0.15	1
tert-Butylbenzene	ND		ug/kg	2.1	0.12	1
o-Chlorotoluene	ND		ug/kg	2.1	0.20	1
p-Chlorotoluene	ND		ug/kg	2.1	0.11	1
1,2-Dibromo-3-chloropropane	ND		ug/kg	3.1	1.0	1
Hexachlorobutadiene	ND		ug/kg	4.2	0.18	1
Isopropylbenzene	ND		ug/kg	1.0	0.11	1
p-Isopropyltoluene	ND		ug/kg	1.0	0.11	1
Naphthalene	ND		ug/kg	4.2	0.68	1
Acrylonitrile	ND		ug/kg	4.2	1.2	1

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-05 Date Collected: 06/06/23 10:55

Client ID: SB-31S(0.5-1) Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
n-Propylbenzene	ND		ug/kg	1.0	0.18	1
1,2,3-Trichlorobenzene	ND		ug/kg	2.1	0.33	1
1,2,4-Trichlorobenzene	ND		ug/kg	2.1	0.28	1
1,3,5-Trimethylbenzene	ND		ug/kg	2.1	0.20	1
1,2,4-Trimethylbenzene	ND		ug/kg	2.1	0.35	1
1,4-Dioxane	ND		ug/kg	83	36.	1
p-Diethylbenzene	ND		ug/kg	2.1	0.18	1
p-Ethyltoluene	ND		ug/kg	2.1	0.40	1
1,2,4,5-Tetramethylbenzene	ND		ug/kg	2.1	0.20	1
Ethyl ether	ND		ug/kg	2.1	0.35	1
trans-1,4-Dichloro-2-butene	ND		ug/kg	5.2	1.5	1
Tentatively Identified Compounds						
No Tentatively Identified Compounds	ND		ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	100		70-130
Toluene-d8	103		70-130
4-Bromofluorobenzene	99		70-130
Dibromofluoromethane	95		70-130

Project Name: 100 MAIN ST.
Lab Number: L2331480
Project Number: 12461
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-06
Client ID: GW-12
Sample Location: WHITE PLAINS, NY

Date Collected: 06/06/23 09:50
Date Received: 06/06/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8260D
Analytical Date: 06/09/23 15:38
Analyst: MJV

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Methylene chloride	ND		ug/l	2.5	0.70	1
1,1-Dichloroethane	ND		ug/l	2.5	0.70	1
Chloroform	ND		ug/l	2.5	0.70	1
Carbon tetrachloride	ND		ug/l	0.50	0.13	1
1,2-Dichloropropane	ND		ug/l	1.0	0.14	1
Dibromochloromethane	ND		ug/l	0.50	0.15	1
1,1,2-Trichloroethane	ND		ug/l	1.5	0.50	1
Tetrachloroethene	ND		ug/l	0.50	0.18	1
Chlorobenzene	ND		ug/l	2.5	0.70	1
Trichlorofluoromethane	ND		ug/l	2.5	0.70	1
1,2-Dichloroethane	ND		ug/l	0.50	0.13	1
1,1,1-Trichloroethane	ND		ug/l	2.5	0.70	1
Bromodichloromethane	ND		ug/l	0.50	0.19	1
trans-1,3-Dichloropropene	ND		ug/l	0.50	0.16	1
cis-1,3-Dichloropropene	ND		ug/l	0.50	0.14	1
1,3-Dichloropropene, Total	ND		ug/l	0.50	0.14	1
1,1-Dichloropropene	ND		ug/l	2.5	0.70	1
Bromoform	ND		ug/l	2.0	0.65	1
1,1,2,2-Tetrachloroethane	ND		ug/l	0.50	0.17	1
Benzene	ND		ug/l	0.50	0.16	1
Toluene	ND		ug/l	2.5	0.70	1
Ethylbenzene	ND		ug/l	2.5	0.70	1
Chloromethane	ND		ug/l	2.5	0.70	1
Bromomethane	ND		ug/l	2.5	0.70	1
Vinyl chloride	ND		ug/l	1.0	0.07	1
Chloroethane	ND		ug/l	2.5	0.70	1
1,1-Dichloroethene	ND		ug/l	0.50	0.17	1
trans-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-06 Date Collected: 06/06/23 09:50

Client ID: GW-12 Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Trichloroethene	ND		ug/l	0.50	0.18	1
1,2-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,3-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,4-Dichlorobenzene	ND		ug/l	2.5	0.70	1
Methyl tert butyl ether	ND		ug/l	2.5	0.70	1
p/m-Xylene	ND		ug/l	2.5	0.70	1
o-Xylene	ND		ug/l	2.5	0.70	1
Xylenes, Total	ND		ug/l	2.5	0.70	1
cis-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1
1,2-Dichloroethene, Total	ND		ug/l	2.5	0.70	1
Dibromomethane	ND		ug/l	5.0	1.0	1
1,2,3-Trichloropropane	ND		ug/l	2.5	0.70	1
Acrylonitrile	ND		ug/l	5.0	1.5	1
Styrene	ND		ug/l	2.5	0.70	1
Dichlorodifluoromethane	ND		ug/l	5.0	1.0	1
Acetone	3.0	J	ug/l	5.0	1.5	1
Carbon disulfide	ND		ug/l	5.0	1.0	1
2-Butanone	ND		ug/l	5.0	1.9	1
Vinyl acetate	ND		ug/l	5.0	1.0	1
4-Methyl-2-pentanone	ND		ug/l	5.0	1.0	1
2-Hexanone	ND		ug/l	5.0	1.0	1
Bromochloromethane	ND		ug/l	2.5	0.70	1
2,2-Dichloropropane	ND		ug/l	2.5	0.70	1
1,2-Dibromoethane	ND		ug/l	2.0	0.65	1
1,3-Dichloropropane	ND		ug/l	2.5	0.70	1
1,1,1,2-Tetrachloroethane	ND		ug/l	2.5	0.70	1
Bromobenzene	ND		ug/l	2.5	0.70	1
n-Butylbenzene	ND		ug/l	2.5	0.70	1
sec-Butylbenzene	ND		ug/l	2.5	0.70	1
tert-Butylbenzene	ND		ug/l	2.5	0.70	1
o-Chlorotoluene	ND		ug/l	2.5	0.70	1
p-Chlorotoluene	ND		ug/l	2.5	0.70	1
1,2-Dibromo-3-chloropropane	ND		ug/l	2.5	0.70	1
Hexachlorobutadiene	ND		ug/l	2.5	0.70	1
Isopropylbenzene	ND		ug/l	2.5	0.70	1
p-Isopropyltoluene	ND		ug/l	2.5	0.70	1
Naphthalene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-06 Date Collected: 06/06/23 09:50

Client ID: GW-12 Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
n-Propylbenzene	ND		ug/l	2.5	0.70	1
1,2,3-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,3,5-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,4-Dioxane	ND		ug/l	250	61.	1
p-Diethylbenzene	ND		ug/l	2.0	0.70	1
p-Ethyltoluene	ND		ug/l	2.0	0.70	1
1,2,4,5-Tetramethylbenzene	ND		ug/l	2.0	0.54	1
Ethyl ether	ND		ug/l	2.5	0.70	1
trans-1,4-Dichloro-2-butene	ND		ug/l	2.5	0.70	1
Tentatively Identified Compounds						
No Tentatively Identified Compounds	ND		ug/l			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	117		70-130
Toluene-d8	97		70-130
4-Bromofluorobenzene	96		70-130
Dibromofluoromethane	102		70-130

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-07
Client ID: GW-13
Sample Location: WHITE PLAINS, NY

Date Collected: 06/06/23 11:20
Date Received: 06/06/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8260D
Analytical Date: 06/09/23 16:00
Analyst: MJV

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Methylene chloride	ND		ug/l	2.5	0.70	1
1,1-Dichloroethane	ND		ug/l	2.5	0.70	1
Chloroform	7.0		ug/l	2.5	0.70	1
Carbon tetrachloride	ND		ug/l	0.50	0.13	1
1,2-Dichloropropane	ND		ug/l	1.0	0.14	1
Dibromochloromethane	ND		ug/l	0.50	0.15	1
1,1,2-Trichloroethane	ND		ug/l	1.5	0.50	1
Tetrachloroethene	0.88		ug/l	0.50	0.18	1
Chlorobenzene	ND		ug/l	2.5	0.70	1
Trichlorofluoromethane	ND		ug/l	2.5	0.70	1
1,2-Dichloroethane	ND		ug/l	0.50	0.13	1
1,1,1-Trichloroethane	ND		ug/l	2.5	0.70	1
Bromodichloromethane	ND		ug/l	0.50	0.19	1
trans-1,3-Dichloropropene	ND		ug/l	0.50	0.16	1
cis-1,3-Dichloropropene	ND		ug/l	0.50	0.14	1
1,3-Dichloropropene, Total	ND		ug/l	0.50	0.14	1
1,1-Dichloropropene	ND		ug/l	2.5	0.70	1
Bromoform	ND		ug/l	2.0	0.65	1
1,1,2,2-Tetrachloroethane	ND		ug/l	0.50	0.17	1
Benzene	ND		ug/l	0.50	0.16	1
Toluene	ND		ug/l	2.5	0.70	1
Ethylbenzene	ND		ug/l	2.5	0.70	1
Chloromethane	ND		ug/l	2.5	0.70	1
Bromomethane	ND		ug/l	2.5	0.70	1
Vinyl chloride	ND		ug/l	1.0	0.07	1
Chloroethane	ND		ug/l	2.5	0.70	1
1,1-Dichloroethene	ND		ug/l	0.50	0.17	1
trans-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-07 Date Collected: 06/06/23 11:20

Client ID: GW-13 Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Trichloroethene	ND		ug/l	0.50	0.18	1
1,2-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,3-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,4-Dichlorobenzene	ND		ug/l	2.5	0.70	1
Methyl tert butyl ether	ND		ug/l	2.5	0.70	1
p/m-Xylene	ND		ug/l	2.5	0.70	1
o-Xylene	ND		ug/l	2.5	0.70	1
Xylenes, Total	ND		ug/l	2.5	0.70	1
cis-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1
1,2-Dichloroethene, Total	ND		ug/l	2.5	0.70	1
Dibromomethane	ND		ug/l	5.0	1.0	1
1,2,3-Trichloropropane	ND		ug/l	2.5	0.70	1
Acrylonitrile	ND		ug/l	5.0	1.5	1
Styrene	ND		ug/l	2.5	0.70	1
Dichlorodifluoromethane	3.6	J	ug/l	5.0	1.0	1
Acetone	ND		ug/l	5.0	1.5	1
Carbon disulfide	ND		ug/l	5.0	1.0	1
2-Butanone	ND		ug/l	5.0	1.9	1
Vinyl acetate	ND		ug/l	5.0	1.0	1
4-Methyl-2-pentanone	ND		ug/l	5.0	1.0	1
2-Hexanone	ND		ug/l	5.0	1.0	1
Bromochloromethane	ND		ug/l	2.5	0.70	1
2,2-Dichloropropane	ND		ug/l	2.5	0.70	1
1,2-Dibromoethane	ND		ug/l	2.0	0.65	1
1,3-Dichloropropane	ND		ug/l	2.5	0.70	1
1,1,1,2-Tetrachloroethane	ND		ug/l	2.5	0.70	1
Bromobenzene	ND		ug/l	2.5	0.70	1
n-Butylbenzene	ND		ug/l	2.5	0.70	1
sec-Butylbenzene	ND		ug/l	2.5	0.70	1
tert-Butylbenzene	ND		ug/l	2.5	0.70	1
o-Chlorotoluene	ND		ug/l	2.5	0.70	1
p-Chlorotoluene	ND		ug/l	2.5	0.70	1
1,2-Dibromo-3-chloropropane	ND		ug/l	2.5	0.70	1
Hexachlorobutadiene	ND		ug/l	2.5	0.70	1
Isopropylbenzene	ND		ug/l	2.5	0.70	1
p-Isopropyltoluene	ND		ug/l	2.5	0.70	1
Naphthalene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-07 Date Collected: 06/06/23 11:20

Client ID: GW-13 Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
n-Propylbenzene	ND		ug/l	2.5	0.70	1
1,2,3-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,3,5-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,4-Dioxane	ND		ug/l	250	61.	1
p-Diethylbenzene	ND		ug/l	2.0	0.70	1
p-Ethyltoluene	ND		ug/l	2.0	0.70	1
1,2,4,5-Tetramethylbenzene	ND		ug/l	2.0	0.54	1
Ethyl ether	ND		ug/l	2.5	0.70	1
trans-1,4-Dichloro-2-butene	ND		ug/l	2.5	0.70	1
Tentatively Identified Compounds						
No Tentatively Identified Compounds	ND		ug/l			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	108		70-130
Toluene-d8	98		70-130
4-Bromofluorobenzene	96		70-130
Dibromofluoromethane	104		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-08
Client ID: SB-32S(3-3.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/06/23 12:15
Date Received: 06/06/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8260D
Analytical Date: 06/09/23 16:20
Analyst: AJK
Percent Solids: 93%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Methylene chloride	ND		ug/kg	4.6	2.1	1
1,1-Dichloroethane	ND		ug/kg	0.93	0.13	1
Chloroform	ND		ug/kg	1.4	0.13	1
Carbon tetrachloride	ND		ug/kg	0.93	0.21	1
1,2-Dichloropropane	ND		ug/kg	0.93	0.12	1
Dibromochloromethane	ND		ug/kg	0.93	0.13	1
1,1,2-Trichloroethane	ND		ug/kg	0.93	0.25	1
Tetrachloroethene	ND		ug/kg	0.46	0.18	1
Chlorobenzene	ND		ug/kg	0.46	0.12	1
Trichlorofluoromethane	ND		ug/kg	3.7	0.64	1
1,2-Dichloroethane	ND		ug/kg	0.93	0.24	1
1,1,1-Trichloroethane	ND		ug/kg	0.46	0.15	1
Bromodichloromethane	ND		ug/kg	0.46	0.10	1
trans-1,3-Dichloropropene	ND		ug/kg	0.93	0.25	1
cis-1,3-Dichloropropene	ND		ug/kg	0.46	0.15	1
1,3-Dichloropropene, Total	ND		ug/kg	0.46	0.15	1
1,1-Dichloropropene	ND		ug/kg	0.46	0.15	1
Bromoform	ND		ug/kg	3.7	0.23	1
1,1,2,2-Tetrachloroethane	ND		ug/kg	0.46	0.15	1
Benzene	ND		ug/kg	0.46	0.15	1
Toluene	ND		ug/kg	0.93	0.50	1
Ethylbenzene	ND		ug/kg	0.93	0.13	1
Chloromethane	ND		ug/kg	3.7	0.86	1
Bromomethane	ND		ug/kg	1.8	0.54	1
Vinyl chloride	ND		ug/kg	0.93	0.31	1
Chloroethane	ND		ug/kg	1.8	0.42	1
1,1-Dichloroethene	ND		ug/kg	0.93	0.22	1
trans-1,2-Dichloroethene	ND		ug/kg	1.4	0.13	1

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-08 Date Collected: 06/06/23 12:15

Client ID: SB-32S(3-3.5) Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Trichloroethene	ND		ug/kg	0.46	0.13	1
1,2-Dichlorobenzene	ND		ug/kg	1.8	0.13	1
1,3-Dichlorobenzene	ND		ug/kg	1.8	0.14	1
1,4-Dichlorobenzene	ND		ug/kg	1.8	0.16	1
Methyl tert butyl ether	ND		ug/kg	1.8	0.19	1
p/m-Xylene	ND		ug/kg	1.8	0.52	1
o-Xylene	ND		ug/kg	0.93	0.27	1
Xylenes, Total	ND		ug/kg	0.93	0.27	1
cis-1,2-Dichloroethene	ND		ug/kg	0.93	0.16	1
1,2-Dichloroethene, Total	ND		ug/kg	0.93	0.13	1
Dibromomethane	ND		ug/kg	1.8	0.22	1
Styrene	ND		ug/kg	0.93	0.18	1
Dichlorodifluoromethane	ND		ug/kg	9.3	0.85	1
Acetone	28		ug/kg	9.3	4.5	1
Carbon disulfide	ND		ug/kg	9.3	4.2	1
2-Butanone	6.9	J	ug/kg	9.3	2.0	1
Vinyl acetate	ND		ug/kg	9.3	2.0	1
4-Methyl-2-pentanone	ND		ug/kg	9.3	1.2	1
1,2,3-Trichloropropane	ND		ug/kg	1.8	0.12	1
2-Hexanone	ND		ug/kg	9.3	1.1	1
Bromochloromethane	ND		ug/kg	1.8	0.19	1
2,2-Dichloropropane	ND		ug/kg	1.8	0.19	1
1,2-Dibromoethane	ND		ug/kg	0.93	0.26	1
1,3-Dichloropropane	ND		ug/kg	1.8	0.15	1
1,1,1,2-Tetrachloroethane	ND		ug/kg	0.46	0.12	1
Bromobenzene	ND		ug/kg	1.8	0.13	1
n-Butylbenzene	ND		ug/kg	0.93	0.15	1
sec-Butylbenzene	ND		ug/kg	0.93	0.14	1
tert-Butylbenzene	ND		ug/kg	1.8	0.11	1
o-Chlorotoluene	ND		ug/kg	1.8	0.18	1
p-Chlorotoluene	ND		ug/kg	1.8	0.10	1
1,2-Dibromo-3-chloropropane	ND		ug/kg	2.8	0.92	1
Hexachlorobutadiene	ND		ug/kg	3.7	0.16	1
Isopropylbenzene	ND		ug/kg	0.93	0.10	1
p-Isopropyltoluene	ND		ug/kg	0.93	0.10	1
Naphthalene	ND		ug/kg	3.7	0.60	1
Acrylonitrile	ND		ug/kg	3.7	1.1	1

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-08 Date Collected: 06/06/23 12:15

Client ID: SB-32S(3-3.5) Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
n-Propylbenzene	ND		ug/kg	0.93	0.16	1
1,2,3-Trichlorobenzene	ND		ug/kg	1.8	0.30	1
1,2,4-Trichlorobenzene	ND		ug/kg	1.8	0.25	1
1,3,5-Trimethylbenzene	ND		ug/kg	1.8	0.18	1
1,2,4-Trimethylbenzene	ND		ug/kg	1.8	0.31	1
1,4-Dioxane	ND		ug/kg	74	32.	1
p-Diethylbenzene	ND		ug/kg	1.8	0.16	1
p-Ethyltoluene	ND		ug/kg	1.8	0.36	1
1,2,4,5-Tetramethylbenzene	ND		ug/kg	1.8	0.18	1
Ethyl ether	ND		ug/kg	1.8	0.32	1
trans-1,4-Dichloro-2-butene	ND		ug/kg	4.6	1.3	1
Tentatively Identified Compounds						
Total TIC Compounds	54.4	J	ug/kg			1
Unknown	5.66	J	ug/kg			1
Unknown Cyclohexane	6.68	J	ug/kg			1
Unknown	5.84	J	ug/kg			1
Unknown	4.24	J	ug/kg			1
Unknown	8.78	J	ug/kg			1
Unknown	4.68	J	ug/kg			1
Unknown	6.22	J	ug/kg			1
2-Methyladamantane	4.72	NJ	ug/kg			1
Unknown	4.14	J	ug/kg			1
Unknown	3.47	J	ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	99		70-130
Toluene-d8	103		70-130
4-Bromofluorobenzene	100		70-130
Dibromofluoromethane	96		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 06/09/23 08:57
Analyst: MKS

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by EPA 5035 Low - Westborough Lab for sample(s): 01-05,08 Batch: WG1789904-5					
Methylene chloride	ND		ug/kg	5.0	2.3
1,1-Dichloroethane	ND		ug/kg	1.0	0.14
Chloroform	ND		ug/kg	1.5	0.14
Carbon tetrachloride	ND		ug/kg	1.0	0.23
1,2-Dichloropropane	ND		ug/kg	1.0	0.12
Dibromochloromethane	ND		ug/kg	1.0	0.14
1,1,2-Trichloroethane	ND		ug/kg	1.0	0.27
Tetrachloroethene	ND		ug/kg	0.50	0.20
Chlorobenzene	ND		ug/kg	0.50	0.13
Trichlorofluoromethane	ND		ug/kg	4.0	0.70
1,2-Dichloroethane	ND		ug/kg	1.0	0.26
1,1,1-Trichloroethane	ND		ug/kg	0.50	0.17
Bromodichloromethane	ND		ug/kg	0.50	0.11
trans-1,3-Dichloropropene	ND		ug/kg	1.0	0.27
cis-1,3-Dichloropropene	ND		ug/kg	0.50	0.16
1,3-Dichloropropene, Total	ND		ug/kg	0.50	0.16
1,1-Dichloropropene	ND		ug/kg	0.50	0.16
Bromoform	ND		ug/kg	4.0	0.25
1,1,2,2-Tetrachloroethane	ND		ug/kg	0.50	0.17
Benzene	ND		ug/kg	0.50	0.17
Toluene	ND		ug/kg	1.0	0.54
Ethylbenzene	ND		ug/kg	1.0	0.14
Chloromethane	ND		ug/kg	4.0	0.93
Bromomethane	ND		ug/kg	2.0	0.58
Vinyl chloride	ND		ug/kg	1.0	0.34
Chloroethane	ND		ug/kg	2.0	0.45
1,1-Dichloroethene	ND		ug/kg	1.0	0.24
trans-1,2-Dichloroethene	ND		ug/kg	1.5	0.14
Trichloroethene	ND		ug/kg	0.50	0.14

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 06/09/23 08:57
Analyst: MKS

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by EPA 5035 Low - Westborough Lab for sample(s): 01-05,08 Batch: WG1789904-5					
1,2-Dichlorobenzene	ND		ug/kg	2.0	0.14
1,3-Dichlorobenzene	ND		ug/kg	2.0	0.15
1,4-Dichlorobenzene	ND		ug/kg	2.0	0.17
Methyl tert butyl ether	ND		ug/kg	2.0	0.20
p/m-Xylene	ND		ug/kg	2.0	0.56
o-Xylene	ND		ug/kg	1.0	0.29
Xylenes, Total	ND		ug/kg	1.0	0.29
cis-1,2-Dichloroethene	ND		ug/kg	1.0	0.18
1,2-Dichloroethene, Total	ND		ug/kg	1.0	0.14
Dibromomethane	ND		ug/kg	2.0	0.24
Styrene	ND		ug/kg	1.0	0.20
Dichlorodifluoromethane	ND		ug/kg	10	0.92
Acetone	ND		ug/kg	10	4.8
Carbon disulfide	ND		ug/kg	10	4.6
2-Butanone	ND		ug/kg	10	2.2
Vinyl acetate	ND		ug/kg	10	2.2
4-Methyl-2-pentanone	ND		ug/kg	10	1.3
1,2,3-Trichloropropane	ND		ug/kg	2.0	0.13
2-Hexanone	ND		ug/kg	10	1.2
Bromochloromethane	ND		ug/kg	2.0	0.20
2,2-Dichloropropane	ND		ug/kg	2.0	0.20
1,2-Dibromoethane	ND		ug/kg	1.0	0.28
1,3-Dichloropropane	ND		ug/kg	2.0	0.17
1,1,1,2-Tetrachloroethane	ND		ug/kg	0.50	0.13
Bromobenzene	ND		ug/kg	2.0	0.14
n-Butylbenzene	ND		ug/kg	1.0	0.17
sec-Butylbenzene	ND		ug/kg	1.0	0.15
tert-Butylbenzene	ND		ug/kg	2.0	0.12
o-Chlorotoluene	ND		ug/kg	2.0	0.19

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 06/09/23 08:57
Analyst: MKS

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by EPA 5035 Low - Westborough Lab for sample(s): 01-05,08 Batch: WG1789904-5					
p-Chlorotoluene	ND		ug/kg	2.0	0.11
1,2-Dibromo-3-chloropropane	ND		ug/kg	3.0	1.0
Hexachlorobutadiene	ND		ug/kg	4.0	0.17
Isopropylbenzene	ND		ug/kg	1.0	0.11
p-Isopropyltoluene	ND		ug/kg	1.0	0.11
Naphthalene	ND		ug/kg	4.0	0.65
Acrylonitrile	ND		ug/kg	4.0	1.2
n-Propylbenzene	ND		ug/kg	1.0	0.17
1,2,3-Trichlorobenzene	ND		ug/kg	2.0	0.32
1,2,4-Trichlorobenzene	ND		ug/kg	2.0	0.27
1,3,5-Trimethylbenzene	ND		ug/kg	2.0	0.19
1,2,4-Trimethylbenzene	ND		ug/kg	2.0	0.33
1,4-Dioxane	ND		ug/kg	80	35.
p-Diethylbenzene	ND		ug/kg	2.0	0.18
p-Ethyltoluene	ND		ug/kg	2.0	0.38
1,2,4,5-Tetramethylbenzene	ND		ug/kg	2.0	0.19
Ethyl ether	ND		ug/kg	2.0	0.34
trans-1,4-Dichloro-2-butene	ND		ug/kg	5.0	1.4

Tentatively Identified Compounds

Total TIC Compounds	6.89	J	ug/kg
Unknown	2.24	J	ug/kg
Unknown	4.65	J	ug/kg

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 06/09/23 08:57
Analyst: MKS

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by EPA 5035 Low - Westborough Lab for sample(s): 01-05,08 Batch: WG1789904-5					

Surrogate	%Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	97		70-130
Toluene-d8	103		70-130
4-Bromofluorobenzene	96		70-130
Dibromofluoromethane	93		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 06/09/23 08:21
Analyst: PID

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by GC/MS - Westborough Lab for sample(s): 06-07 Batch: WG1790164-5					
Methylene chloride	ND		ug/l	2.5	0.70
1,1-Dichloroethane	ND		ug/l	2.5	0.70
Chloroform	ND		ug/l	2.5	0.70
Carbon tetrachloride	ND		ug/l	0.50	0.13
1,2-Dichloropropane	ND		ug/l	1.0	0.14
Dibromochloromethane	ND		ug/l	0.50	0.15
1,1,2-Trichloroethane	ND		ug/l	1.5	0.50
Tetrachloroethene	ND		ug/l	0.50	0.18
Chlorobenzene	ND		ug/l	2.5	0.70
Trichlorofluoromethane	ND		ug/l	2.5	0.70
1,2-Dichloroethane	ND		ug/l	0.50	0.13
1,1,1-Trichloroethane	ND		ug/l	2.5	0.70
Bromodichloromethane	ND		ug/l	0.50	0.19
trans-1,3-Dichloropropene	ND		ug/l	0.50	0.16
cis-1,3-Dichloropropene	ND		ug/l	0.50	0.14
1,3-Dichloropropene, Total	ND		ug/l	0.50	0.14
1,1-Dichloropropene	ND		ug/l	2.5	0.70
Bromoform	ND		ug/l	2.0	0.65
1,1,2,2-Tetrachloroethane	ND		ug/l	0.50	0.17
Benzene	ND		ug/l	0.50	0.16
Toluene	ND		ug/l	2.5	0.70
Ethylbenzene	ND		ug/l	2.5	0.70
Chloromethane	ND		ug/l	2.5	0.70
Bromomethane	ND		ug/l	2.5	0.70
Vinyl chloride	ND		ug/l	1.0	0.07
Chloroethane	ND		ug/l	2.5	0.70
1,1-Dichloroethene	ND		ug/l	0.50	0.17
trans-1,2-Dichloroethene	ND		ug/l	2.5	0.70
Trichloroethene	ND		ug/l	0.50	0.18

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 06/09/23 08:21
Analyst: PID

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by GC/MS - Westborough Lab for sample(s): 06-07 Batch: WG1790164-5					
1,2-Dichlorobenzene	ND		ug/l	2.5	0.70
1,3-Dichlorobenzene	ND		ug/l	2.5	0.70
1,4-Dichlorobenzene	ND		ug/l	2.5	0.70
Methyl tert butyl ether	ND		ug/l	2.5	0.70
p/m-Xylene	ND		ug/l	2.5	0.70
o-Xylene	ND		ug/l	2.5	0.70
Xylenes, Total	ND		ug/l	2.5	0.70
cis-1,2-Dichloroethene	ND		ug/l	2.5	0.70
1,2-Dichloroethene, Total	ND		ug/l	2.5	0.70
Dibromomethane	ND		ug/l	5.0	1.0
1,2,3-Trichloropropane	ND		ug/l	2.5	0.70
Acrylonitrile	ND		ug/l	5.0	1.5
Styrene	ND		ug/l	2.5	0.70
Dichlorodifluoromethane	ND		ug/l	5.0	1.0
Acetone	ND		ug/l	5.0	1.5
Carbon disulfide	ND		ug/l	5.0	1.0
2-Butanone	ND		ug/l	5.0	1.9
Vinyl acetate	ND		ug/l	5.0	1.0
4-Methyl-2-pentanone	ND		ug/l	5.0	1.0
2-Hexanone	ND		ug/l	5.0	1.0
Bromochloromethane	ND		ug/l	2.5	0.70
2,2-Dichloropropane	ND		ug/l	2.5	0.70
1,2-Dibromoethane	ND		ug/l	2.0	0.65
1,3-Dichloropropane	ND		ug/l	2.5	0.70
1,1,1,2-Tetrachloroethane	ND		ug/l	2.5	0.70
Bromobenzene	ND		ug/l	2.5	0.70
n-Butylbenzene	ND		ug/l	2.5	0.70
sec-Butylbenzene	ND		ug/l	2.5	0.70
tert-Butylbenzene	ND		ug/l	2.5	0.70

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 06/09/23 08:21
Analyst: PID

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by GC/MS - Westborough Lab for sample(s): 06-07 Batch: WG1790164-5					
o-Chlorotoluene	ND		ug/l	2.5	0.70
p-Chlorotoluene	ND		ug/l	2.5	0.70
1,2-Dibromo-3-chloropropane	ND		ug/l	2.5	0.70
Hexachlorobutadiene	ND		ug/l	2.5	0.70
Isopropylbenzene	ND		ug/l	2.5	0.70
p-Isopropyltoluene	ND		ug/l	2.5	0.70
Naphthalene	ND		ug/l	2.5	0.70
n-Propylbenzene	ND		ug/l	2.5	0.70
1,2,3-Trichlorobenzene	ND		ug/l	2.5	0.70
1,2,4-Trichlorobenzene	ND		ug/l	2.5	0.70
1,3,5-Trimethylbenzene	ND		ug/l	2.5	0.70
1,2,4-Trimethylbenzene	ND		ug/l	2.5	0.70
1,4-Dioxane	ND		ug/l	250	61.
p-Diethylbenzene	ND		ug/l	2.0	0.70
p-Ethyltoluene	ND		ug/l	2.0	0.70
1,2,4,5-Tetramethylbenzene	ND		ug/l	2.0	0.54
Ethyl ether	ND		ug/l	2.5	0.70
trans-1,4-Dichloro-2-butene	ND		ug/l	2.5	0.70
Tentatively Identified Compounds					
No Tentatively Identified Compounds	ND		ug/l		

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 06/09/23 08:21
Analyst: PID

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by GC/MS - Westborough Lab for sample(s): 06-07 Batch: WG1790164-5					

Surrogate	%Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	102		70-130
Toluene-d8	96		70-130
4-Bromofluorobenzene	96		70-130
Dibromofluoromethane	110		70-130

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331480
Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by EPA 5035 Low - Westborough Lab Associated sample(s): 01-05,08 Batch: WG1789904-3 WG1789904-4								
Methylene chloride	81		80		70-130	1		30
1,1-Dichloroethane	90		89		70-130	1		30
Chloroform	87		86		70-130	1		30
Carbon tetrachloride	76		76		70-130	0		30
1,2-Dichloropropane	91		90		70-130	1		30
Dibromochloromethane	82		83		70-130	1		30
1,1,2-Trichloroethane	95		94		70-130	1		30
Tetrachloroethene	85		85		70-130	0		30
Chlorobenzene	91		91		70-130	0		30
Trichlorofluoromethane	82		83		70-139	1		30
1,2-Dichloroethane	86		86		70-130	0		30
1,1,1-Trichloroethane	78		79		70-130	1		30
Bromodichloromethane	88		88		70-130	0		30
trans-1,3-Dichloropropene	92		92		70-130	0		30
cis-1,3-Dichloropropene	90		90		70-130	0		30
1,1-Dichloropropene	82		82		70-130	0		30
Bromoform	89		90		70-130	1		30
1,1,2,2-Tetrachloroethane	91		90		70-130	1		30
Benzene	90		90		70-130	0		30
Toluene	88		88		70-130	0		30
Ethylbenzene	90		90		70-130	0		30
Chloromethane	88		86		52-130	2		30
Bromomethane	98		97		57-147	1		30

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331480

Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by EPA 5035 Low - Westborough Lab Associated sample(s): 01-05,08 Batch: WG1789904-3 WG1789904-4								
Vinyl chloride	75		74		67-130	1		30
Chloroethane	88		88		50-151	0		30
1,1-Dichloroethene	79		78		65-135	1		30
trans-1,2-Dichloroethene	89		88		70-130	1		30
Trichloroethene	83		84		70-130	1		30
1,2-Dichlorobenzene	92		90		70-130	2		30
1,3-Dichlorobenzene	92		90		70-130	2		30
1,4-Dichlorobenzene	91		90		70-130	1		30
Methyl tert butyl ether	88		89		66-130	1		30
p/m-Xylene	92		92		70-130	0		30
o-Xylene	92		92		70-130	0		30
cis-1,2-Dichloroethene	87		88		70-130	1		30
Dibromomethane	87		88		70-130	1		30
Styrene	92		91		70-130	1		30
Dichlorodifluoromethane	71		70		30-146	1		30
Acetone	82		80		54-140	2		30
Carbon disulfide	78		77		59-130	1		30
2-Butanone	88		90		70-130	2		30
Vinyl acetate	92		88		70-130	4		30
4-Methyl-2-pentanone	87		90		70-130	3		30
1,2,3-Trichloropropane	89		89		68-130	0		30
2-Hexanone	90		91		70-130	1		30
Bromochloromethane	91		91		70-130	0		30

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331480

Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by EPA 5035 Low - Westborough Lab Associated sample(s): 01-05,08 Batch: WG1789904-3 WG1789904-4								
2,2-Dichloropropane	85		84		70-130	1		30
1,2-Dibromoethane	84		85		70-130	1		30
1,3-Dichloropropane	92		94		69-130	2		30
1,1,1,2-Tetrachloroethane	90		91		70-130	1		30
Bromobenzene	89		88		70-130	1		30
n-Butylbenzene	94		92		70-130	2		30
sec-Butylbenzene	92		91		70-130	1		30
tert-Butylbenzene	90		88		70-130	2		30
o-Chlorotoluene	89		88		70-130	1		30
p-Chlorotoluene	90		89		70-130	1		30
1,2-Dibromo-3-chloropropane	83		84		68-130	1		30
Hexachlorobutadiene	89		90		67-130	1		30
Isopropylbenzene	90		89		70-130	1		30
p-Isopropyltoluene	91		89		70-130	2		30
Naphthalene	85		86		70-130	1		30
Acrylonitrile	93		94		70-130	1		30
n-Propylbenzene	92		92		70-130	0		30
1,2,3-Trichlorobenzene	90		90		70-130	0		30
1,2,4-Trichlorobenzene	94		93		70-130	1		30
1,3,5-Trimethylbenzene	90		88		70-130	2		30
1,2,4-Trimethylbenzene	89		88		70-130	1		30
1,4-Dioxane	87		78		65-136	11		30
p-Diethylbenzene	92		90		70-130	2		30

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by EPA 5035 Low - Westborough Lab Associated sample(s): 01-05,08 Batch: WG1789904-3 WG1789904-4								
p-Ethyltoluene	91		90		70-130	1		30
1,2,4,5-Tetramethylbenzene	89		88		70-130	1		30
Ethyl ether	90		92		67-130	2		30
trans-1,4-Dichloro-2-butene	90		92		70-130	2		30

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
1,2-Dichloroethane-d4	97		98		70-130
Toluene-d8	102		103		70-130
4-Bromofluorobenzene	99		99		70-130
Dibromofluoromethane	94		95		70-130

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331480
Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by GC/MS - Westborough Lab Associated sample(s): 06-07 Batch: WG1790164-3 WG1790164-4								
Methylene chloride	100		100		70-130	0		20
1,1-Dichloroethane	100		100		70-130	0		20
Chloroform	100		100		70-130	0		20
Carbon tetrachloride	95		98		63-132	3		20
1,2-Dichloropropane	99		99		70-130	0		20
Dibromochloromethane	88		89		63-130	1		20
1,1,2-Trichloroethane	93		91		70-130	2		20
Tetrachloroethene	98		99		70-130	1		20
Chlorobenzene	97		97		75-130	0		20
Trichlorofluoromethane	100		100		62-150	0		20
1,2-Dichloroethane	98		99		70-130	1		20
1,1,1-Trichloroethane	100		100		67-130	0		20
Bromodichloromethane	95		95		67-130	0		20
trans-1,3-Dichloropropene	89		92		70-130	3		20
cis-1,3-Dichloropropene	91		89		70-130	2		20
1,1-Dichloropropene	100		100		70-130	0		20
Bromoform	81		82		54-136	1		20
1,1,2,2-Tetrachloroethane	89		91		67-130	2		20
Benzene	100		100		70-130	0		20
Toluene	97		98		70-130	1		20
Ethylbenzene	100		100		70-130	0		20
Chloromethane	100		99		64-130	1		20
Bromomethane	100		100		39-139	0		20

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331480
Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by GC/MS - Westborough Lab Associated sample(s): 06-07 Batch: WG1790164-3 WG1790164-4								
Vinyl chloride	100		100		55-140	0		20
Chloroethane	120		110		55-138	9		20
1,1-Dichloroethene	98		100		61-145	2		20
trans-1,2-Dichloroethene	100		100		70-130	0		20
Trichloroethene	99		97		70-130	2		20
1,2-Dichlorobenzene	97		98		70-130	1		20
1,3-Dichlorobenzene	100		100		70-130	0		20
1,4-Dichlorobenzene	98		98		70-130	0		20
Methyl tert butyl ether	89		93		63-130	4		20
p/m-Xylene	100		100		70-130	0		20
o-Xylene	100		100		70-130	0		20
cis-1,2-Dichloroethene	100		100		70-130	0		20
Dibromomethane	94		95		70-130	1		20
1,2,3-Trichloropropane	85		90		64-130	6		20
Acrylonitrile	83		95		70-130	13		20
Styrene	100		105		70-130	5		20
Dichlorodifluoromethane	98		97		36-147	1		20
Acetone	80		83		58-148	4		20
Carbon disulfide	100		100		51-130	0		20
2-Butanone	65		71		63-138	9		20
Vinyl acetate	98		97		70-130	1		20
4-Methyl-2-pentanone	73		76		59-130	4		20
2-Hexanone	74		78		57-130	5		20

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331480
Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by GC/MS - Westborough Lab Associated sample(s): 06-07 Batch: WG1790164-3 WG1790164-4								
Bromochloromethane	99		99		70-130	0		20
2,2-Dichloropropane	100		100		63-133	0		20
1,2-Dibromoethane	86		91		70-130	6		20
1,3-Dichloropropane	91		93		70-130	2		20
1,1,1,2-Tetrachloroethane	94		96		64-130	2		20
Bromobenzene	97		99		70-130	2		20
n-Butylbenzene	96		100		53-136	4		20
sec-Butylbenzene	98		100		70-130	2		20
tert-Butylbenzene	96		98		70-130	2		20
o-Chlorotoluene	100		100		70-130	0		20
p-Chlorotoluene	98		100		70-130	2		20
1,2-Dibromo-3-chloropropane	72		80		41-144	11		20
Hexachlorobutadiene	92		99		63-130	7		20
Isopropylbenzene	99		100		70-130	1		20
p-Isopropyltoluene	96		100		70-130	4		20
Naphthalene	84		87		70-130	4		20
n-Propylbenzene	100		100		69-130	0		20
1,2,3-Trichlorobenzene	87		90		70-130	3		20
1,2,4-Trichlorobenzene	91		94		70-130	3		20
1,3,5-Trimethylbenzene	99		100		64-130	1		20
1,2,4-Trimethylbenzene	100		100		70-130	0		20
1,4-Dioxane	80		82		56-162	2		20
p-Diethylbenzene	93		97		70-130	4		20

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331480

Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by GC/MS - Westborough Lab Associated sample(s): 06-07 Batch: WG1790164-3 WG1790164-4								
p-Ethyltoluene	100		100		70-130	0		20
1,2,4,5-Tetramethylbenzene	91		96		70-130	5		20
Ethyl ether	92		99		59-134	7		20
trans-1,4-Dichloro-2-butene	80		82		70-130	2		20

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
1,2-Dichloroethane-d4	94		98		70-130
Toluene-d8	101		99		70-130
4-Bromofluorobenzene	101		100		70-130
Dibromofluoromethane	99		100		70-130

SEMIVOLATILES

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-01
Client ID: SB-28S(2-2.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/06/23 09:30
Date Received: 06/06/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8270E
Analytical Date: 06/12/23 06:52
Analyst: IM
Percent Solids: 92%

Extraction Method: EPA 3546
Extraction Date: 06/07/23 19:12

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Acenaphthene	ND		ug/kg	140	18.	1
1,2,4-Trichlorobenzene	ND		ug/kg	180	20.	1
Hexachlorobenzene	ND		ug/kg	110	20.	1
Bis(2-chloroethyl)ether	ND		ug/kg	160	24.	1
2-Chloronaphthalene	ND		ug/kg	180	18.	1
1,2-Dichlorobenzene	ND		ug/kg	180	32.	1
1,3-Dichlorobenzene	ND		ug/kg	180	31.	1
1,4-Dichlorobenzene	ND		ug/kg	180	31.	1
3,3'-Dichlorobenzidine	ND		ug/kg	180	47.	1
2,4-Dinitrotoluene	ND		ug/kg	180	36.	1
2,6-Dinitrotoluene	ND		ug/kg	180	30.	1
Fluoranthene	420		ug/kg	110	20.	1
4-Chlorophenyl phenyl ether	ND		ug/kg	180	19.	1
4-Bromophenyl phenyl ether	ND		ug/kg	180	27.	1
Bis(2-chloroisopropyl)ether	ND		ug/kg	210	30.	1
Bis(2-chloroethoxy)methane	ND		ug/kg	190	18.	1
Hexachlorobutadiene	ND		ug/kg	180	26.	1
Hexachlorocyclopentadiene	ND		ug/kg	510	160	1
Hexachloroethane	ND		ug/kg	140	29.	1
Isophorone	ND		ug/kg	160	23.	1
Naphthalene	ND		ug/kg	180	22.	1
Nitrobenzene	ND		ug/kg	160	26.	1
NDPA/DPA	ND		ug/kg	140	20.	1
n-Nitrosodi-n-propylamine	ND		ug/kg	180	28.	1
Bis(2-ethylhexyl)phthalate	ND		ug/kg	180	62.	1
Butyl benzyl phthalate	ND		ug/kg	180	45.	1
Di-n-butylphthalate	ND		ug/kg	180	34.	1
Di-n-octylphthalate	ND		ug/kg	180	60.	1

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-01 Date Collected: 06/06/23 09:30

Client ID: SB-28S(2-2.5) Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Diethyl phthalate	ND		ug/kg	180	16.	1
Dimethyl phthalate	ND		ug/kg	180	37.	1
Benzo(a)anthracene	220		ug/kg	110	20.	1
Benzo(a)pyrene	280		ug/kg	140	43.	1
Benzo(b)fluoranthene	260		ug/kg	110	30.	1
Benzo(k)fluoranthene	140		ug/kg	110	28.	1
Chrysene	220		ug/kg	110	18.	1
Acenaphthylene	41	J	ug/kg	140	28.	1
Anthracene	62	J	ug/kg	110	35.	1
Benzo(ghi)perylene	180		ug/kg	140	21.	1
Fluorene	ND		ug/kg	180	17.	1
Phenanthrene	190		ug/kg	110	22.	1
Dibenzo(a,h)anthracene	42	J	ug/kg	110	20.	1
Indeno(1,2,3-cd)pyrene	150		ug/kg	140	25.	1
Pyrene	400		ug/kg	110	18.	1
Biphenyl	ND		ug/kg	410	23.	1
4-Chloroaniline	ND		ug/kg	180	32.	1
2-Nitroaniline	ND		ug/kg	180	34.	1
3-Nitroaniline	ND		ug/kg	180	34.	1
4-Nitroaniline	ND		ug/kg	180	74.	1
Dibenzofuran	ND		ug/kg	180	17.	1
2-Methylnaphthalene	ND		ug/kg	210	22.	1
1,2,4,5-Tetrachlorobenzene	ND		ug/kg	180	19.	1
Acetophenone	ND		ug/kg	180	22.	1
2,4,6-Trichlorophenol	ND		ug/kg	110	34.	1
p-Chloro-m-cresol	ND		ug/kg	180	26.	1
2-Chlorophenol	ND		ug/kg	180	21.	1
2,4-Dichlorophenol	ND		ug/kg	160	29.	1
2,4-Dimethylphenol	ND		ug/kg	180	59.	1
2-Nitrophenol	ND		ug/kg	380	67.	1
4-Nitrophenol	ND		ug/kg	250	73.	1
2,4-Dinitrophenol	ND		ug/kg	860	83.	1
4,6-Dinitro-o-cresol	ND		ug/kg	460	86.	1
Pentachlorophenol	ND		ug/kg	140	39.	1
Phenol	ND		ug/kg	180	27.	1
2-Methylphenol	ND		ug/kg	180	28.	1
3-Methylphenol/4-Methylphenol	ND		ug/kg	260	28.	1

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-01 Date Collected: 06/06/23 09:30

Client ID: SB-28S(2-2.5) Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
2,4,5-Trichlorophenol	ND		ug/kg	180	34.	1
Benzoic Acid	ND		ug/kg	580	180	1
Benzyl Alcohol	ND		ug/kg	180	54.	1
Carbazole	24	J	ug/kg	180	17.	1
1,4-Dioxane	ND		ug/kg	27	8.2	1
Tentatively Identified Compounds						
No Tentatively Identified Compounds	ND		ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	88		25-120
Phenol-d6	88		10-120
Nitrobenzene-d5	72		23-120
2-Fluorobiphenyl	73		30-120
2,4,6-Tribromophenol	77		10-136
4-Terphenyl-d14	71		18-120

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-02
Client ID: SB-29S(1-1.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/06/23 10:15
Date Received: 06/06/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8270E
Analytical Date: 06/12/23 06:35
Analyst: IM
Percent Solids: 93%

Extraction Method: EPA 3546
Extraction Date: 06/07/23 19:12

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Acenaphthene	ND		ug/kg	140	18.	1
1,2,4-Trichlorobenzene	ND		ug/kg	180	20.	1
Hexachlorobenzene	ND		ug/kg	100	20.	1
Bis(2-chloroethyl)ether	ND		ug/kg	160	24.	1
2-Chloronaphthalene	ND		ug/kg	180	17.	1
1,2-Dichlorobenzene	ND		ug/kg	180	31.	1
1,3-Dichlorobenzene	ND		ug/kg	180	30.	1
1,4-Dichlorobenzene	ND		ug/kg	180	30.	1
3,3'-Dichlorobenzidine	ND		ug/kg	180	46.	1
2,4-Dinitrotoluene	ND		ug/kg	180	35.	1
2,6-Dinitrotoluene	ND		ug/kg	180	30.	1
Fluoranthene	200		ug/kg	100	20.	1
4-Chlorophenyl phenyl ether	ND		ug/kg	180	19.	1
4-Bromophenyl phenyl ether	ND		ug/kg	180	27.	1
Bis(2-chloroisopropyl)ether	ND		ug/kg	210	30.	1
Bis(2-chloroethoxy)methane	ND		ug/kg	190	18.	1
Hexachlorobutadiene	ND		ug/kg	180	26.	1
Hexachlorocyclopentadiene	ND		ug/kg	500	160	1
Hexachloroethane	ND		ug/kg	140	28.	1
Isophorone	ND		ug/kg	160	23.	1
Naphthalene	ND		ug/kg	180	21.	1
Nitrobenzene	ND		ug/kg	160	26.	1
NDPA/DPA	ND		ug/kg	140	20.	1
n-Nitrosodi-n-propylamine	ND		ug/kg	180	27.	1
Bis(2-ethylhexyl)phthalate	ND		ug/kg	180	61.	1
Butyl benzyl phthalate	ND		ug/kg	180	44.	1
Di-n-butylphthalate	ND		ug/kg	180	33.	1
Di-n-octylphthalate	ND		ug/kg	180	60.	1

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-02 Date Collected: 06/06/23 10:15

Client ID: SB-29S(1-1.5) Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Diethyl phthalate	ND		ug/kg	180	16.	1
Dimethyl phthalate	ND		ug/kg	180	37.	1
Benzo(a)anthracene	120		ug/kg	100	20.	1
Benzo(a)pyrene	130	J	ug/kg	140	43.	1
Benzo(b)fluoranthene	140		ug/kg	100	29.	1
Benzo(k)fluoranthene	54	J	ug/kg	100	28.	1
Chrysene	100		ug/kg	100	18.	1
Acenaphthylene	ND		ug/kg	140	27.	1
Anthracene	ND		ug/kg	100	34.	1
Benzo(ghi)perylene	84	J	ug/kg	140	20.	1
Fluorene	ND		ug/kg	180	17.	1
Phenanthrene	98	J	ug/kg	100	21.	1
Dibenzo(a,h)anthracene	21	J	ug/kg	100	20.	1
Indeno(1,2,3-cd)pyrene	75	J	ug/kg	140	24.	1
Pyrene	180		ug/kg	100	17.	1
Biphenyl	ND		ug/kg	400	23.	1
4-Chloroaniline	ND		ug/kg	180	32.	1
2-Nitroaniline	ND		ug/kg	180	34.	1
3-Nitroaniline	ND		ug/kg	180	33.	1
4-Nitroaniline	ND		ug/kg	180	72.	1
Dibenzofuran	ND		ug/kg	180	16.	1
2-Methylnaphthalene	ND		ug/kg	210	21.	1
1,2,4,5-Tetrachlorobenzene	ND		ug/kg	180	18.	1
Acetophenone	ND		ug/kg	180	22.	1
2,4,6-Trichlorophenol	ND		ug/kg	100	33.	1
p-Chloro-m-cresol	ND		ug/kg	180	26.	1
2-Chlorophenol	ND		ug/kg	180	21.	1
2,4-Dichlorophenol	ND		ug/kg	160	28.	1
2,4-Dimethylphenol	ND		ug/kg	180	58.	1
2-Nitrophenol	ND		ug/kg	380	66.	1
4-Nitrophenol	ND		ug/kg	240	71.	1
2,4-Dinitrophenol	ND		ug/kg	840	82.	1
4,6-Dinitro-o-cresol	ND		ug/kg	460	84.	1
Pentachlorophenol	ND		ug/kg	140	38.	1
Phenol	ND		ug/kg	180	26.	1
2-Methylphenol	ND		ug/kg	180	27.	1
3-Methylphenol/4-Methylphenol	ND		ug/kg	250	27.	1

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-02 Date Collected: 06/06/23 10:15

Client ID: SB-29S(1-1.5) Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
2,4,5-Trichlorophenol	ND		ug/kg	180	34.	1
Benzoic Acid	ND		ug/kg	570	180	1
Benzyl Alcohol	ND		ug/kg	180	54.	1
Carbazole	ND		ug/kg	180	17.	1
1,4-Dioxane	ND		ug/kg	26	8.0	1
Tentatively Identified Compounds						
No Tentatively Identified Compounds	ND		ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	73		25-120
Phenol-d6	81		10-120
Nitrobenzene-d5	54		23-120
2-Fluorobiphenyl	63		30-120
2,4,6-Tribromophenol	48		10-136
4-Terphenyl-d14	69		18-120

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-03
Client ID: SB-30S(7-7.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/06/23 10:30
Date Received: 06/06/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8270E
Analytical Date: 06/12/23 06:18
Analyst: IM
Percent Solids: 89%

Extraction Method: EPA 3546
Extraction Date: 06/07/23 19:12

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Acenaphthene	ND		ug/kg	150	19.	1
1,2,4-Trichlorobenzene	ND		ug/kg	190	21.	1
Hexachlorobenzene	ND		ug/kg	110	21.	1
Bis(2-chloroethyl)ether	ND		ug/kg	170	25.	1
2-Chloronaphthalene	ND		ug/kg	190	18.	1
1,2-Dichlorobenzene	ND		ug/kg	190	33.	1
1,3-Dichlorobenzene	ND		ug/kg	190	32.	1
1,4-Dichlorobenzene	ND		ug/kg	190	32.	1
3,3'-Dichlorobenzidine	ND		ug/kg	190	50.	1
2,4-Dinitrotoluene	ND		ug/kg	190	37.	1
2,6-Dinitrotoluene	ND		ug/kg	190	32.	1
Fluoranthene	65	J	ug/kg	110	21.	1
4-Chlorophenyl phenyl ether	ND		ug/kg	190	20.	1
4-Bromophenyl phenyl ether	ND		ug/kg	190	28.	1
Bis(2-chloroisopropyl)ether	ND		ug/kg	220	32.	1
Bis(2-chloroethoxy)methane	ND		ug/kg	200	19.	1
Hexachlorobutadiene	ND		ug/kg	190	27.	1
Hexachlorocyclopentadiene	ND		ug/kg	530	170	1
Hexachloroethane	ND		ug/kg	150	30.	1
Isophorone	ND		ug/kg	170	24.	1
Naphthalene	ND		ug/kg	190	23.	1
Nitrobenzene	ND		ug/kg	170	28.	1
NDPA/DPA	ND		ug/kg	150	21.	1
n-Nitrosodi-n-propylamine	ND		ug/kg	190	29.	1
Bis(2-ethylhexyl)phthalate	ND		ug/kg	190	64.	1
Butyl benzyl phthalate	ND		ug/kg	190	47.	1
Di-n-butylphthalate	ND		ug/kg	190	35.	1
Di-n-octylphthalate	ND		ug/kg	190	63.	1

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-03 Date Collected: 06/06/23 10:30

Client ID: SB-30S(7-7.5) Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Diethyl phthalate	ND		ug/kg	190	17.	1
Dimethyl phthalate	ND		ug/kg	190	39.	1
Benzo(a)anthracene	42	J	ug/kg	110	21.	1
Benzo(a)pyrene	46	J	ug/kg	150	45.	1
Benzo(b)fluoranthene	45	J	ug/kg	110	31.	1
Benzo(k)fluoranthene	ND		ug/kg	110	30.	1
Chrysene	37	J	ug/kg	110	19.	1
Acenaphthylene	ND		ug/kg	150	29.	1
Anthracene	ND		ug/kg	110	36.	1
Benzo(ghi)perylene	29	J	ug/kg	150	22.	1
Fluorene	ND		ug/kg	190	18.	1
Phenanthrene	40	J	ug/kg	110	23.	1
Dibenzo(a,h)anthracene	ND		ug/kg	110	22.	1
Indeno(1,2,3-cd)pyrene	26	J	ug/kg	150	26.	1
Pyrene	64	J	ug/kg	110	18.	1
Biphenyl	ND		ug/kg	420	24.	1
4-Chloroaniline	ND		ug/kg	190	34.	1
2-Nitroaniline	ND		ug/kg	190	36.	1
3-Nitroaniline	ND		ug/kg	190	35.	1
4-Nitroaniline	ND		ug/kg	190	77.	1
Dibenzofuran	ND		ug/kg	190	18.	1
2-Methylnaphthalene	ND		ug/kg	220	22.	1
1,2,4,5-Tetrachlorobenzene	ND		ug/kg	190	19.	1
Acetophenone	ND		ug/kg	190	23.	1
2,4,6-Trichlorophenol	ND		ug/kg	110	35.	1
p-Chloro-m-cresol	ND		ug/kg	190	28.	1
2-Chlorophenol	ND		ug/kg	190	22.	1
2,4-Dichlorophenol	ND		ug/kg	170	30.	1
2,4-Dimethylphenol	ND		ug/kg	190	61.	1
2-Nitrophenol	ND		ug/kg	400	70.	1
4-Nitrophenol	ND		ug/kg	260	76.	1
2,4-Dinitrophenol	ND		ug/kg	890	87.	1
4,6-Dinitro-o-cresol	ND		ug/kg	480	89.	1
Pentachlorophenol	ND		ug/kg	150	41.	1
Phenol	ND		ug/kg	190	28.	1
2-Methylphenol	ND		ug/kg	190	29.	1
3-Methylphenol/4-Methylphenol	41	J	ug/kg	270	29.	1

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-03 Date Collected: 06/06/23 10:30

Client ID: SB-30S(7-7.5) Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
2,4,5-Trichlorophenol	ND		ug/kg	190	36.	1
Benzoic Acid	ND		ug/kg	600	190	1
Benzyl Alcohol	ND		ug/kg	190	57.	1
Carbazole	ND		ug/kg	190	18.	1
1,4-Dioxane	ND		ug/kg	28	8.6	1
Tentatively Identified Compounds						
No Tentatively Identified Compounds	ND		ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	74		25-120
Phenol-d6	71		10-120
Nitrobenzene-d5	48		23-120
2-Fluorobiphenyl	57		30-120
2,4,6-Tribromophenol	56		10-136
4-Terphenyl-d14	57		18-120

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-04
Client ID: SB-30S(1.5-2)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/06/23 10:40
Date Received: 06/06/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8270E
Analytical Date: 06/12/23 06:01
Analyst: IM
Percent Solids: 92%

Extraction Method: EPA 3546
Extraction Date: 06/07/23 19:12

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Acenaphthene	ND		ug/kg	140	18.	1
1,2,4-Trichlorobenzene	ND		ug/kg	180	20.	1
Hexachlorobenzene	ND		ug/kg	110	20.	1
Bis(2-chloroethyl)ether	ND		ug/kg	160	24.	1
2-Chloronaphthalene	ND		ug/kg	180	18.	1
1,2-Dichlorobenzene	ND		ug/kg	180	32.	1
1,3-Dichlorobenzene	ND		ug/kg	180	31.	1
1,4-Dichlorobenzene	ND		ug/kg	180	31.	1
3,3'-Dichlorobenzidine	ND		ug/kg	180	48.	1
2,4-Dinitrotoluene	ND		ug/kg	180	36.	1
2,6-Dinitrotoluene	ND		ug/kg	180	31.	1
Fluoranthene	94	J	ug/kg	110	20.	1
4-Chlorophenyl phenyl ether	ND		ug/kg	180	19.	1
4-Bromophenyl phenyl ether	ND		ug/kg	180	27.	1
Bis(2-chloroisopropyl)ether	ND		ug/kg	220	31.	1
Bis(2-chloroethoxy)methane	ND		ug/kg	190	18.	1
Hexachlorobutadiene	ND		ug/kg	180	26.	1
Hexachlorocyclopentadiene	ND		ug/kg	510	160	1
Hexachloroethane	ND		ug/kg	140	29.	1
Isophorone	ND		ug/kg	160	23.	1
Naphthalene	ND		ug/kg	180	22.	1
Nitrobenzene	ND		ug/kg	160	26.	1
NDPA/DPA	ND		ug/kg	140	20.	1
n-Nitrosodi-n-propylamine	ND		ug/kg	180	28.	1
Bis(2-ethylhexyl)phthalate	ND		ug/kg	180	62.	1
Butyl benzyl phthalate	ND		ug/kg	180	45.	1
Di-n-butylphthalate	ND		ug/kg	180	34.	1
Di-n-octylphthalate	ND		ug/kg	180	61.	1

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-04 Date Collected: 06/06/23 10:40

Client ID: SB-30S(1.5-2) Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Diethyl phthalate	ND		ug/kg	180	17.	1
Dimethyl phthalate	ND		ug/kg	180	38.	1
Benzo(a)anthracene	59	J	ug/kg	110	20.	1
Benzo(a)pyrene	72	J	ug/kg	140	44.	1
Benzo(b)fluoranthene	86	J	ug/kg	110	30.	1
Benzo(k)fluoranthene	ND		ug/kg	110	29.	1
Chrysene	58	J	ug/kg	110	19.	1
Acenaphthylene	ND		ug/kg	140	28.	1
Anthracene	ND		ug/kg	110	35.	1
Benzo(ghi)perylene	54	J	ug/kg	140	21.	1
Fluorene	ND		ug/kg	180	17.	1
Phenanthrene	51	J	ug/kg	110	22.	1
Dibenzo(a,h)anthracene	ND		ug/kg	110	21.	1
Indeno(1,2,3-cd)pyrene	41	J	ug/kg	140	25.	1
Pyrene	88	J	ug/kg	110	18.	1
Biphenyl	ND		ug/kg	410	23.	1
4-Chloroaniline	ND		ug/kg	180	33.	1
2-Nitroaniline	ND		ug/kg	180	34.	1
3-Nitroaniline	ND		ug/kg	180	34.	1
4-Nitroaniline	ND		ug/kg	180	74.	1
Dibenzofuran	ND		ug/kg	180	17.	1
2-Methylnaphthalene	ND		ug/kg	220	22.	1
1,2,4,5-Tetrachlorobenzene	ND		ug/kg	180	19.	1
Acetophenone	ND		ug/kg	180	22.	1
2,4,6-Trichlorophenol	ND		ug/kg	110	34.	1
p-Chloro-m-cresol	ND		ug/kg	180	27.	1
2-Chlorophenol	ND		ug/kg	180	21.	1
2,4-Dichlorophenol	ND		ug/kg	160	29.	1
2,4-Dimethylphenol	ND		ug/kg	180	59.	1
2-Nitrophenol	ND		ug/kg	390	67.	1
4-Nitrophenol	ND		ug/kg	250	73.	1
2,4-Dinitrophenol	ND		ug/kg	860	84.	1
4,6-Dinitro-o-cresol	ND		ug/kg	470	86.	1
Pentachlorophenol	ND		ug/kg	140	39.	1
Phenol	ND		ug/kg	180	27.	1
2-Methylphenol	ND		ug/kg	180	28.	1
3-Methylphenol/4-Methylphenol	ND		ug/kg	260	28.	1

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-04 Date Collected: 06/06/23 10:40

Client ID: SB-30S(1.5-2) Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
2,4,5-Trichlorophenol	ND		ug/kg	180	34.	1
Benzoic Acid	ND		ug/kg	580	180	1
Benzyl Alcohol	ND		ug/kg	180	55.	1
Carbazole	ND		ug/kg	180	17.	1
1,4-Dioxane	ND		ug/kg	27	8.2	1
Tentatively Identified Compounds						
No Tentatively Identified Compounds	ND		ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	78		25-120
Phenol-d6	76		10-120
Nitrobenzene-d5	57		23-120
2-Fluorobiphenyl	64		30-120
2,4,6-Tribromophenol	59		10-136
4-Terphenyl-d14	63		18-120

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-05
Client ID: SB-31S(0.5-1)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/06/23 10:55
Date Received: 06/06/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8270E
Analytical Date: 06/12/23 05:44
Analyst: IM
Percent Solids: 89%

Extraction Method: EPA 3546
Extraction Date: 06/07/23 19:12

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Acenaphthene	35	J	ug/kg	150	19.	1
1,2,4-Trichlorobenzene	ND		ug/kg	190	21.	1
Hexachlorobenzene	ND		ug/kg	110	21.	1
Bis(2-chloroethyl)ether	ND		ug/kg	170	25.	1
2-Chloronaphthalene	ND		ug/kg	190	18.	1
1,2-Dichlorobenzene	ND		ug/kg	190	34.	1
1,3-Dichlorobenzene	ND		ug/kg	190	32.	1
1,4-Dichlorobenzene	ND		ug/kg	190	33.	1
3,3'-Dichlorobenzidine	ND		ug/kg	190	50.	1
2,4-Dinitrotoluene	ND		ug/kg	190	37.	1
2,6-Dinitrotoluene	ND		ug/kg	190	32.	1
Fluoranthene	560		ug/kg	110	22.	1
4-Chlorophenyl phenyl ether	ND		ug/kg	190	20.	1
4-Bromophenyl phenyl ether	ND		ug/kg	190	28.	1
Bis(2-chloroisopropyl)ether	ND		ug/kg	220	32.	1
Bis(2-chloroethoxy)methane	ND		ug/kg	200	19.	1
Hexachlorobutadiene	ND		ug/kg	190	27.	1
Hexachlorocyclopentadiene	ND		ug/kg	540	170	1
Hexachloroethane	ND		ug/kg	150	30.	1
Isophorone	ND		ug/kg	170	24.	1
Naphthalene	ND		ug/kg	190	23.	1
Nitrobenzene	ND		ug/kg	170	28.	1
NDPA/DPA	ND		ug/kg	150	21.	1
n-Nitrosodi-n-propylamine	ND		ug/kg	190	29.	1
Bis(2-ethylhexyl)phthalate	ND		ug/kg	190	65.	1
Butyl benzyl phthalate	ND		ug/kg	190	47.	1
Di-n-butylphthalate	ND		ug/kg	190	36.	1
Di-n-octylphthalate	ND		ug/kg	190	64.	1

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-05 Date Collected: 06/06/23 10:55

Client ID: SB-31S(0.5-1) Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Diethyl phthalate	ND		ug/kg	190	17.	1
Dimethyl phthalate	ND		ug/kg	190	39.	1
Benzo(a)anthracene	300		ug/kg	110	21.	1
Benzo(a)pyrene	320		ug/kg	150	46.	1
Benzo(b)fluoranthene	360		ug/kg	110	32.	1
Benzo(k)fluoranthene	100	J	ug/kg	110	30.	1
Chrysene	270		ug/kg	110	19.	1
Acenaphthylene	ND		ug/kg	150	29.	1
Anthracene	100	J	ug/kg	110	36.	1
Benzo(ghi)perylene	220		ug/kg	150	22.	1
Fluorene	34	J	ug/kg	190	18.	1
Phenanthrene	370		ug/kg	110	23.	1
Dibenzo(a,h)anthracene	49	J	ug/kg	110	22.	1
Indeno(1,2,3-cd)pyrene	180		ug/kg	150	26.	1
Pyrene	480		ug/kg	110	19.	1
Biphenyl	ND		ug/kg	430	24.	1
4-Chloroaniline	ND		ug/kg	190	34.	1
2-Nitroaniline	ND		ug/kg	190	36.	1
3-Nitroaniline	ND		ug/kg	190	35.	1
4-Nitroaniline	ND		ug/kg	190	78.	1
Dibenzofuran	ND		ug/kg	190	18.	1
2-Methylnaphthalene	ND		ug/kg	220	23.	1
1,2,4,5-Tetrachlorobenzene	ND		ug/kg	190	20.	1
Acetophenone	ND		ug/kg	190	23.	1
2,4,6-Trichlorophenol	ND		ug/kg	110	36.	1
p-Chloro-m-cresol	ND		ug/kg	190	28.	1
2-Chlorophenol	ND		ug/kg	190	22.	1
2,4-Dichlorophenol	ND		ug/kg	170	30.	1
2,4-Dimethylphenol	ND		ug/kg	190	62.	1
2-Nitrophenol	ND		ug/kg	400	70.	1
4-Nitrophenol	ND		ug/kg	260	76.	1
2,4-Dinitrophenol	ND		ug/kg	900	87.	1
4,6-Dinitro-o-cresol	ND		ug/kg	490	90.	1
Pentachlorophenol	ND		ug/kg	150	41.	1
Phenol	ND		ug/kg	190	28.	1
2-Methylphenol	ND		ug/kg	190	29.	1
3-Methylphenol/4-Methylphenol	ND		ug/kg	270	29.	1

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-05 Date Collected: 06/06/23 10:55

Client ID: SB-31S(0.5-1) Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
2,4,5-Trichlorophenol	ND		ug/kg	190	36.	1
Benzoic Acid	ND		ug/kg	610	190	1
Benzyl Alcohol	ND		ug/kg	190	57.	1
Carbazole	48	J	ug/kg	190	18.	1
1,4-Dioxane	ND		ug/kg	28	8.6	1
Tentatively Identified Compounds						
No Tentatively Identified Compounds	ND		ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	86		25-120
Phenol-d6	89		10-120
Nitrobenzene-d5	58		23-120
2-Fluorobiphenyl	72		30-120
2,4,6-Tribromophenol	56		10-136
4-Terphenyl-d14	69		18-120

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-06
Client ID: GW-12
Sample Location: WHITE PLAINS, NY

Date Collected: 06/06/23 09:50
Date Received: 06/06/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E
Analytical Date: 06/12/23 04:48
Analyst: JG

Extraction Method: EPA 3510C
Extraction Date: 06/09/23 02:24

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
1,2,4-Trichlorobenzene	ND		ug/l	5.0	0.50	1
Bis(2-chloroethyl)ether	ND		ug/l	2.0	0.50	1
1,2-Dichlorobenzene	ND		ug/l	2.0	0.45	1
1,3-Dichlorobenzene	ND		ug/l	2.0	0.40	1
1,4-Dichlorobenzene	ND		ug/l	2.0	0.43	1
3,3'-Dichlorobenzidine	ND		ug/l	5.0	1.6	1
2,4-Dinitrotoluene	ND		ug/l	5.0	1.2	1
2,6-Dinitrotoluene	ND		ug/l	5.0	0.93	1
4-Chlorophenyl phenyl ether	ND		ug/l	2.0	0.49	1
4-Bromophenyl phenyl ether	ND		ug/l	2.0	0.38	1
Bis(2-chloroisopropyl)ether	ND		ug/l	2.0	0.53	1
Bis(2-chloroethoxy)methane	ND		ug/l	5.0	0.50	1
Hexachlorocyclopentadiene	ND		ug/l	20	0.69	1
Isophorone	ND		ug/l	5.0	1.2	1
Nitrobenzene	ND		ug/l	2.0	0.77	1
NDPA/DPA	ND		ug/l	2.0	0.42	1
n-Nitrosodi-n-propylamine	ND		ug/l	5.0	0.64	1
Bis(2-ethylhexyl)phthalate	ND		ug/l	3.0	1.5	1
Butyl benzyl phthalate	ND		ug/l	5.0	1.2	1
Di-n-butylphthalate	ND		ug/l	5.0	0.39	1
Di-n-octylphthalate	ND		ug/l	5.0	1.3	1
Diethyl phthalate	ND		ug/l	5.0	0.38	1
Dimethyl phthalate	ND		ug/l	5.0	1.8	1
Biphenyl	ND		ug/l	2.0	0.46	1
4-Chloroaniline	ND		ug/l	5.0	1.1	1
2-Nitroaniline	ND		ug/l	5.0	0.50	1
3-Nitroaniline	ND		ug/l	5.0	0.81	1
4-Nitroaniline	ND		ug/l	5.0	0.80	1

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-06 Date Collected: 06/06/23 09:50

Client ID: GW-12 Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Dibenzofuran	ND		ug/l	2.0	0.50	1
1,2,4,5-Tetrachlorobenzene	ND		ug/l	10	0.44	1
Acetophenone	ND		ug/l	5.0	0.53	1
2,4,6-Trichlorophenol	ND		ug/l	5.0	0.61	1
p-Chloro-m-cresol	ND		ug/l	2.0	0.35	1
2-Chlorophenol	ND		ug/l	2.0	0.48	1
2,4-Dichlorophenol	ND		ug/l	5.0	0.41	1
2,4-Dimethylphenol	ND		ug/l	5.0	1.8	1
2-Nitrophenol	ND		ug/l	10	0.85	1
4-Nitrophenol	ND		ug/l	10	0.67	1
2,4-Dinitrophenol	ND		ug/l	20	6.6	1
4,6-Dinitro-o-cresol	ND		ug/l	10	1.8	1
Phenol	ND		ug/l	5.0	0.57	1
2-Methylphenol	ND		ug/l	5.0	0.49	1
3-Methylphenol/4-Methylphenol	ND		ug/l	5.0	0.48	1
2,4,5-Trichlorophenol	ND		ug/l	5.0	0.77	1
Benzoic Acid	9.3	J	ug/l	50	2.6	1
Benzyl Alcohol	ND		ug/l	2.0	0.59	1
Carbazole	ND		ug/l	2.0	0.49	1

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-06 Date Collected: 06/06/23 09:50

Client ID: GW-12 Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Tentatively Identified Compounds						
Total TIC Compounds	58.7	J	ug/l			1
Unknown	4.98	J	ug/l			1
Unknown	1.53	J	ug/l			1
Unknown	6.29	J	ug/l			1
Unknown	1.82	J	ug/l			1
Unknown	2.62	J	ug/l			1
Unknown Organic Acid	6.00	J	ug/l			1
Unknown	1.78	J	ug/l			1
Unknown	2.25	J	ug/l			1
Unknown	10.1	J	ug/l			1
Unknown	2.47	J	ug/l			1
Unknown	3.74	J	ug/l			1
Unknown	3.64	J	ug/l			1
Unknown Organic Acid	11.5	J	ug/l			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	34		21-120
Phenol-d6	26		10-120
Nitrobenzene-d5	55		23-120
2-Fluorobiphenyl	42		15-120
2,4,6-Tribromophenol	50		10-120
4-Terphenyl-d14	48		41-149

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-06
Client ID: GW-12
Sample Location: WHITE PLAINS, NY

Date Collected: 06/06/23 09:50
Date Received: 06/06/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E-SIM
Analytical Date: 06/11/23 00:25
Analyst: RP

Extraction Method: EPA 3510C
Extraction Date: 06/09/23 02:27

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS-SIM - Westborough Lab						
Acenaphthene	0.04	J	ug/l	0.10	0.01	1
2-Chloronaphthalene	ND		ug/l	0.20	0.02	1
Fluoranthene	0.10	J	ug/l	0.10	0.02	1
Hexachlorobutadiene	ND		ug/l	0.50	0.05	1
Naphthalene	0.06	J	ug/l	0.10	0.05	1
Benzo(a)anthracene	0.02	J	ug/l	0.10	0.02	1
Benzo(a)pyrene	0.02	J	ug/l	0.10	0.02	1
Benzo(b)fluoranthene	0.02	J	ug/l	0.10	0.01	1
Benzo(k)fluoranthene	0.01	J	ug/l	0.10	0.01	1
Chrysene	0.02	J	ug/l	0.10	0.01	1
Acenaphthylene	0.02	J	ug/l	0.10	0.01	1
Anthracene	0.06	J	ug/l	0.10	0.01	1
Benzo(ghi)perylene	ND		ug/l	0.10	0.01	1
Fluorene	0.14		ug/l	0.10	0.01	1
Phenanthrene	0.33		ug/l	0.10	0.02	1
Dibenzo(a,h)anthracene	ND		ug/l	0.10	0.01	1
Indeno(1,2,3-cd)pyrene	0.01	J	ug/l	0.10	0.01	1
Pyrene	0.14		ug/l	0.10	0.02	1
2-Methylnaphthalene	0.23		ug/l	0.10	0.02	1
Pentachlorophenol	ND		ug/l	0.80	0.01	1
Hexachlorobenzene	ND		ug/l	0.80	0.01	1
Hexachloroethane	ND		ug/l	0.80	0.06	1

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-06 Date Collected: 06/06/23 09:50

Client ID: GW-12 Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS-SIM - Westborough Lab						

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	42		21-120
Phenol-d6	35		10-120
Nitrobenzene-d5	75		23-120
2-Fluorobiphenyl	66		15-120
2,4,6-Tribromophenol	99		10-120
4-Terphenyl-d14	68		41-149

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-07
Client ID: GW-13
Sample Location: WHITE PLAINS, NY

Date Collected: 06/06/23 11:20
Date Received: 06/06/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E
Analytical Date: 06/12/23 05:11
Analyst: JG

Extraction Method: EPA 3510C
Extraction Date: 06/09/23 02:24

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
1,2,4-Trichlorobenzene	ND		ug/l	5.0	0.50	1
Bis(2-chloroethyl)ether	ND		ug/l	2.0	0.50	1
1,2-Dichlorobenzene	ND		ug/l	2.0	0.45	1
1,3-Dichlorobenzene	ND		ug/l	2.0	0.40	1
1,4-Dichlorobenzene	ND		ug/l	2.0	0.43	1
3,3'-Dichlorobenzidine	ND		ug/l	5.0	1.6	1
2,4-Dinitrotoluene	ND		ug/l	5.0	1.2	1
2,6-Dinitrotoluene	ND		ug/l	5.0	0.93	1
4-Chlorophenyl phenyl ether	ND		ug/l	2.0	0.49	1
4-Bromophenyl phenyl ether	ND		ug/l	2.0	0.38	1
Bis(2-chloroisopropyl)ether	ND		ug/l	2.0	0.53	1
Bis(2-chloroethoxy)methane	ND		ug/l	5.0	0.50	1
Hexachlorocyclopentadiene	ND		ug/l	20	0.69	1
Isophorone	ND		ug/l	5.0	1.2	1
Nitrobenzene	ND		ug/l	2.0	0.77	1
NDPA/DPA	ND		ug/l	2.0	0.42	1
n-Nitrosodi-n-propylamine	ND		ug/l	5.0	0.64	1
Bis(2-ethylhexyl)phthalate	ND		ug/l	3.0	1.5	1
Butyl benzyl phthalate	ND		ug/l	5.0	1.2	1
Di-n-butylphthalate	ND		ug/l	5.0	0.39	1
Di-n-octylphthalate	ND		ug/l	5.0	1.3	1
Diethyl phthalate	ND		ug/l	5.0	0.38	1
Dimethyl phthalate	ND		ug/l	5.0	1.8	1
Biphenyl	ND		ug/l	2.0	0.46	1
4-Chloroaniline	ND		ug/l	5.0	1.1	1
2-Nitroaniline	ND		ug/l	5.0	0.50	1
3-Nitroaniline	ND		ug/l	5.0	0.81	1
4-Nitroaniline	ND		ug/l	5.0	0.80	1

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-07 Date Collected: 06/06/23 11:20

Client ID: GW-13 Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Dibenzofuran	ND		ug/l	2.0	0.50	1
1,2,4,5-Tetrachlorobenzene	ND		ug/l	10	0.44	1
Acetophenone	ND		ug/l	5.0	0.53	1
2,4,6-Trichlorophenol	ND		ug/l	5.0	0.61	1
p-Chloro-m-cresol	ND		ug/l	2.0	0.35	1
2-Chlorophenol	ND		ug/l	2.0	0.48	1
2,4-Dichlorophenol	ND		ug/l	5.0	0.41	1
2,4-Dimethylphenol	ND		ug/l	5.0	1.8	1
2-Nitrophenol	ND		ug/l	10	0.85	1
4-Nitrophenol	ND		ug/l	10	0.67	1
2,4-Dinitrophenol	ND		ug/l	20	6.6	1
4,6-Dinitro-o-cresol	ND		ug/l	10	1.8	1
Phenol	ND		ug/l	5.0	0.57	1
2-Methylphenol	ND		ug/l	5.0	0.49	1
3-Methylphenol/4-Methylphenol	ND		ug/l	5.0	0.48	1
2,4,5-Trichlorophenol	ND		ug/l	5.0	0.77	1
Benzoic Acid	7.8	J	ug/l	50	2.6	1
Benzyl Alcohol	ND		ug/l	2.0	0.59	1
Carbazole	ND		ug/l	2.0	0.49	1

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-07 Date Collected: 06/06/23 11:20

Client ID: GW-13 Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Tentatively Identified Compounds						
Total TIC Compounds	78.1	J	ug/l			1
Unknown	3.42	J	ug/l			1
Unknown	4.18	J	ug/l			1
Unknown	7.93	J	ug/l			1
Unknown	2.14	J	ug/l			1
Unknown Organic Acid	10.4	J	ug/l			1
Unknown Organic Acid	1.78	J	ug/l			1
Unknown	2.54	J	ug/l			1
Unknown	3.45	J	ug/l			1
Unknown	1.67	J	ug/l			1
Unknown	4.73	J	ug/l			1
Unknown	5.96	J	ug/l			1
Unknown Organic Acid	1.53	J	ug/l			1
Unknown Organic Acid	13.6	J	ug/l			1
Unknown	13.2	J	ug/l			1
Unknown	1.56	J	ug/l			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	47		21-120
Phenol-d6	35		10-120
Nitrobenzene-d5	65		23-120
2-Fluorobiphenyl	53		15-120
2,4,6-Tribromophenol	67		10-120
4-Terphenyl-d14	67		41-149

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-07
Client ID: GW-13
Sample Location: WHITE PLAINS, NY

Date Collected: 06/06/23 11:20
Date Received: 06/06/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E-SIM
Analytical Date: 06/11/23 00:42
Analyst: RP

Extraction Method: EPA 3510C
Extraction Date: 06/09/23 02:27

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS-SIM - Westborough Lab						
Acenaphthene	0.02	J	ug/l	0.10	0.01	1
2-Chloronaphthalene	ND		ug/l	0.20	0.02	1
Fluoranthene	0.03	J	ug/l	0.10	0.02	1
Hexachlorobutadiene	ND		ug/l	0.50	0.05	1
Naphthalene	ND		ug/l	0.10	0.05	1
Benzo(a)anthracene	ND		ug/l	0.10	0.02	1
Benzo(a)pyrene	ND		ug/l	0.10	0.02	1
Benzo(b)fluoranthene	0.01	J	ug/l	0.10	0.01	1
Benzo(k)fluoranthene	0.01	J	ug/l	0.10	0.01	1
Chrysene	0.01	J	ug/l	0.10	0.01	1
Acenaphthylene	0.02	J	ug/l	0.10	0.01	1
Anthracene	0.02	J	ug/l	0.10	0.01	1
Benzo(ghi)perylene	ND		ug/l	0.10	0.01	1
Fluorene	0.03	J	ug/l	0.10	0.01	1
Phenanthrene	0.05	J	ug/l	0.10	0.02	1
Dibenzo(a,h)anthracene	ND		ug/l	0.10	0.01	1
Indeno(1,2,3-cd)pyrene	ND		ug/l	0.10	0.01	1
Pyrene	0.03	J	ug/l	0.10	0.02	1
2-Methylnaphthalene	0.03	J	ug/l	0.10	0.02	1
Pentachlorophenol	ND		ug/l	0.80	0.01	1
Hexachlorobenzene	ND		ug/l	0.80	0.01	1
Hexachloroethane	ND		ug/l	0.80	0.06	1

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-07 Date Collected: 06/06/23 11:20

Client ID: GW-13 Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS-SIM - Westborough Lab						

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	52		21-120
Phenol-d6	43		10-120
Nitrobenzene-d5	92		23-120
2-Fluorobiphenyl	83		15-120
2,4,6-Tribromophenol	**128**	Q	10-120
4-Terphenyl-d14	91		41-149

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-08
Client ID: SB-32S(3-3.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/06/23 12:15
Date Received: 06/06/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8270E
Analytical Date: 06/12/23 05:27
Analyst: IM
Percent Solids: 93%

Extraction Method: EPA 3546
Extraction Date: 06/07/23 19:12

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Acenaphthene	ND		ug/kg	140	18.	1
1,2,4-Trichlorobenzene	ND		ug/kg	170	20.	1
Hexachlorobenzene	ND		ug/kg	100	19.	1
Bis(2-chloroethyl)ether	ND		ug/kg	160	23.	1
2-Chloronaphthalene	ND		ug/kg	170	17.	1
1,2-Dichlorobenzene	ND		ug/kg	170	31.	1
1,3-Dichlorobenzene	ND		ug/kg	170	30.	1
1,4-Dichlorobenzene	ND		ug/kg	170	30.	1
3,3'-Dichlorobenzidine	ND		ug/kg	170	46.	1
2,4-Dinitrotoluene	ND		ug/kg	170	34.	1
2,6-Dinitrotoluene	ND		ug/kg	170	30.	1
Fluoranthene	270		ug/kg	100	20.	1
4-Chlorophenyl phenyl ether	ND		ug/kg	170	18.	1
4-Bromophenyl phenyl ether	ND		ug/kg	170	26.	1
Bis(2-chloroisopropyl)ether	ND		ug/kg	210	30.	1
Bis(2-chloroethoxy)methane	ND		ug/kg	190	17.	1
Hexachlorobutadiene	ND		ug/kg	170	25.	1
Hexachlorocyclopentadiene	ND		ug/kg	490	160	1
Hexachloroethane	ND		ug/kg	140	28.	1
Isophorone	ND		ug/kg	160	22.	1
Naphthalene	ND		ug/kg	170	21.	1
Nitrobenzene	ND		ug/kg	160	26.	1
NDPA/DPA	ND		ug/kg	140	20.	1
n-Nitrosodi-n-propylamine	ND		ug/kg	170	27.	1
Bis(2-ethylhexyl)phthalate	ND		ug/kg	170	60.	1
Butyl benzyl phthalate	ND		ug/kg	170	44.	1
Di-n-butylphthalate	ND		ug/kg	170	33.	1
Di-n-octylphthalate	ND		ug/kg	170	59.	1

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-08 Date Collected: 06/06/23 12:15

Client ID: SB-32S(3-3.5) Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Diethyl phthalate	ND		ug/kg	170	16.	1
Dimethyl phthalate	ND		ug/kg	170	36.	1
Benzo(a)anthracene	240		ug/kg	100	19.	1
Benzo(a)pyrene	240		ug/kg	140	42.	1
Benzo(b)fluoranthene	190		ug/kg	100	29.	1
Benzo(k)fluoranthene	93	J	ug/kg	100	28.	1
Chrysene	210		ug/kg	100	18.	1
Acenaphthylene	39	J	ug/kg	140	27.	1
Anthracene	51	J	ug/kg	100	34.	1
Benzo(ghi)perylene	110	J	ug/kg	140	20.	1
Fluorene	ND		ug/kg	170	17.	1
Phenanthrene	81	J	ug/kg	100	21.	1
Dibenzo(a,h)anthracene	33	J	ug/kg	100	20.	1
Indeno(1,2,3-cd)pyrene	95	J	ug/kg	140	24.	1
Pyrene	390		ug/kg	100	17.	1
Biphenyl	ND		ug/kg	390	22.	1
4-Chloroaniline	ND		ug/kg	170	31.	1
2-Nitroaniline	ND		ug/kg	170	33.	1
3-Nitroaniline	ND		ug/kg	170	33.	1
4-Nitroaniline	ND		ug/kg	170	72.	1
Dibenzofuran	ND		ug/kg	170	16.	1
2-Methylnaphthalene	ND		ug/kg	210	21.	1
1,2,4,5-Tetrachlorobenzene	ND		ug/kg	170	18.	1
Acetophenone	ND		ug/kg	170	21.	1
2,4,6-Trichlorophenol	ND		ug/kg	100	33.	1
p-Chloro-m-cresol	ND		ug/kg	170	26.	1
2-Chlorophenol	ND		ug/kg	170	20.	1
2,4-Dichlorophenol	ND		ug/kg	160	28.	1
2,4-Dimethylphenol	ND		ug/kg	170	57.	1
2-Nitrophenol	ND		ug/kg	370	65.	1
4-Nitrophenol	ND		ug/kg	240	70.	1
2,4-Dinitrophenol	ND		ug/kg	830	81.	1
4,6-Dinitro-o-cresol	ND		ug/kg	450	83.	1
Pentachlorophenol	ND		ug/kg	140	38.	1
Phenol	ND		ug/kg	170	26.	1
2-Methylphenol	ND		ug/kg	170	27.	1
3-Methylphenol/4-Methylphenol	ND		ug/kg	250	27.	1

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-08 Date Collected: 06/06/23 12:15

Client ID: SB-32S(3-3.5) Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
2,4,5-Trichlorophenol	ND		ug/kg	170	33.	1
Benzoic Acid	ND		ug/kg	560	180	1
Benzyl Alcohol	ND		ug/kg	170	53.	1
Carbazole	ND		ug/kg	170	17.	1
1,4-Dioxane	ND		ug/kg	26	8.0	1
Tentatively Identified Compounds						
No Tentatively Identified Compounds	ND		ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	71		25-120
Phenol-d6	68		10-120
Nitrobenzene-d5	41		23-120
2-Fluorobiphenyl	54		30-120
2,4,6-Tribromophenol	56		10-136
4-Terphenyl-d14	54		18-120

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 06/08/23 08:04
Analyst: IM

Extraction Method: EPA 3546
Extraction Date: 06/07/23 13:58

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 01-05,08 Batch: WG1788357-1					
Acenaphthene	ND		ug/kg	130	17.
1,2,4-Trichlorobenzene	ND		ug/kg	160	18.
Hexachlorobenzene	ND		ug/kg	97	18.
Bis(2-chloroethyl)ether	ND		ug/kg	140	22.
2-Chloronaphthalene	ND		ug/kg	160	16.
1,2-Dichlorobenzene	ND		ug/kg	160	29.
1,3-Dichlorobenzene	ND		ug/kg	160	28.
1,4-Dichlorobenzene	ND		ug/kg	160	28.
3,3'-Dichlorobenzidine	ND		ug/kg	160	43.
2,4-Dinitrotoluene	ND		ug/kg	160	32.
2,6-Dinitrotoluene	ND		ug/kg	160	28.
Fluoranthene	ND		ug/kg	97	19.
4-Chlorophenyl phenyl ether	ND		ug/kg	160	17.
4-Bromophenyl phenyl ether	ND		ug/kg	160	25.
Bis(2-chloroisopropyl)ether	ND		ug/kg	190	28.
Bis(2-chloroethoxy)methane	ND		ug/kg	170	16.
Hexachlorobutadiene	ND		ug/kg	160	24.
Hexachlorocyclopentadiene	ND		ug/kg	460	150
Hexachloroethane	ND		ug/kg	130	26.
Isophorone	ND		ug/kg	140	21.
Naphthalene	ND		ug/kg	160	20.
Nitrobenzene	ND		ug/kg	140	24.
NDPA/DPA	ND		ug/kg	130	18.
n-Nitrosodi-n-propylamine	ND		ug/kg	160	25.
Bis(2-ethylhexyl)phthalate	ND		ug/kg	160	56.
Butyl benzyl phthalate	ND		ug/kg	160	41.
Di-n-butylphthalate	ND		ug/kg	160	31.
Di-n-octylphthalate	ND		ug/kg	160	55.
Diethyl phthalate	ND		ug/kg	160	15.

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 06/08/23 08:04
Analyst: IM

Extraction Method: EPA 3546
Extraction Date: 06/07/23 13:58

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 01-05,08 Batch: WG1788357-1					
Dimethyl phthalate	ND		ug/kg	160	34.
Benzo(a)anthracene	ND		ug/kg	97	18.
Benzo(a)pyrene	ND		ug/kg	130	40.
Benzo(b)fluoranthene	ND		ug/kg	97	27.
Benzo(k)fluoranthene	ND		ug/kg	97	26.
Chrysene	ND		ug/kg	97	17.
Acenaphthylene	ND		ug/kg	130	25.
Anthracene	ND		ug/kg	97	32.
Benzo(ghi)perylene	ND		ug/kg	130	19.
Fluorene	ND		ug/kg	160	16.
Phenanthrene	ND		ug/kg	97	20.
Dibenzo(a,h)anthracene	ND		ug/kg	97	19.
Indeno(1,2,3-cd)pyrene	ND		ug/kg	130	22.
Pyrene	ND		ug/kg	97	16.
Biphenyl	ND		ug/kg	370	21.
4-Chloroaniline	ND		ug/kg	160	29.
2-Nitroaniline	ND		ug/kg	160	31.
3-Nitroaniline	ND		ug/kg	160	30.
4-Nitroaniline	ND		ug/kg	160	67.
Dibenzofuran	ND		ug/kg	160	15.
2-Methylnaphthalene	ND		ug/kg	190	20.
1,2,4,5-Tetrachlorobenzene	ND		ug/kg	160	17.
Acetophenone	ND		ug/kg	160	20.
2,4,6-Trichlorophenol	ND		ug/kg	97	31.
p-Chloro-m-cresol	ND		ug/kg	160	24.
2-Chlorophenol	ND		ug/kg	160	19.
2,4-Dichlorophenol	ND		ug/kg	140	26.
2,4-Dimethylphenol	ND		ug/kg	160	53.
2-Nitrophenol	ND		ug/kg	350	61.

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 06/08/23 08:04
Analyst: IM

Extraction Method: EPA 3546
Extraction Date: 06/07/23 13:58

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 01-05,08 Batch: WG1788357-1					
4-Nitrophenol	ND		ug/kg	230	66.
2,4-Dinitrophenol	ND		ug/kg	780	76.
4,6-Dinitro-o-cresol	ND		ug/kg	420	78.
Pentachlorophenol	ND		ug/kg	130	36.
Phenol	ND		ug/kg	160	24.
2-Methylphenol	ND		ug/kg	160	25.
3-Methylphenol/4-Methylphenol	ND		ug/kg	230	25.
2,4,5-Trichlorophenol	ND		ug/kg	160	31.
Benzoic Acid	ND		ug/kg	520	160
Benzyl Alcohol	ND		ug/kg	160	50.
Carbazole	ND		ug/kg	160	16.
1,4-Dioxane	ND		ug/kg	24	7.4
Tentatively Identified Compounds					
No Tentatively Identified Compounds	ND		ug/kg		

Surrogate	%Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	65		25-120
Phenol-d6	65		10-120
Nitrobenzene-d5	61		23-120
2-Fluorobiphenyl	67		30-120
2,4,6-Tribromophenol	76		10-136
4-Terphenyl-d14	73		18-120

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 06/11/23 17:06
Analyst: ALS

Extraction Method: EPA 3510C
Extraction Date: 06/09/23 02:24

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 06-07 Batch: WG1789052-1					
Acenaphthene	ND		ug/l	2.0	0.44
1,2,4-Trichlorobenzene	ND		ug/l	5.0	0.50
Hexachlorobenzene	ND		ug/l	2.0	0.46
Bis(2-chloroethyl)ether	ND		ug/l	2.0	0.50
2-Chloronaphthalene	ND		ug/l	2.0	0.44
1,2-Dichlorobenzene	ND		ug/l	2.0	0.45
1,3-Dichlorobenzene	ND		ug/l	2.0	0.40
1,4-Dichlorobenzene	ND		ug/l	2.0	0.43
3,3'-Dichlorobenzidine	ND		ug/l	5.0	1.6
2,4-Dinitrotoluene	ND		ug/l	5.0	1.2
2,6-Dinitrotoluene	ND		ug/l	5.0	0.93
Fluoranthene	ND		ug/l	2.0	0.26
4-Chlorophenyl phenyl ether	ND		ug/l	2.0	0.49
4-Bromophenyl phenyl ether	ND		ug/l	2.0	0.38
Bis(2-chloroisopropyl)ether	ND		ug/l	2.0	0.53
Bis(2-chloroethoxy)methane	ND		ug/l	5.0	0.50
Hexachlorobutadiene	ND		ug/l	2.0	0.66
Hexachlorocyclopentadiene	ND		ug/l	20	0.69
Hexachloroethane	ND		ug/l	2.0	0.58
Isophorone	ND		ug/l	5.0	1.2
Naphthalene	ND		ug/l	2.0	0.46
Nitrobenzene	ND		ug/l	2.0	0.77
NDPA/DPA	ND		ug/l	2.0	0.42
n-Nitrosodi-n-propylamine	ND		ug/l	5.0	0.64
Bis(2-ethylhexyl)phthalate	ND		ug/l	3.0	1.5
Butyl benzyl phthalate	ND		ug/l	5.0	1.2
Di-n-butylphthalate	ND		ug/l	5.0	0.39
Di-n-octylphthalate	ND		ug/l	5.0	1.3
Diethyl phthalate	ND		ug/l	5.0	0.38

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 06/11/23 17:06
Analyst: ALS

Extraction Method: EPA 3510C
Extraction Date: 06/09/23 02:24

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 06-07 Batch: WG1789052-1					
Dimethyl phthalate	ND		ug/l	5.0	1.8
Benzo(a)anthracene	ND		ug/l	2.0	0.32
Benzo(a)pyrene	ND		ug/l	2.0	0.41
Benzo(b)fluoranthene	ND		ug/l	2.0	0.35
Benzo(k)fluoranthene	ND		ug/l	2.0	0.37
Chrysene	ND		ug/l	2.0	0.34
Acenaphthylene	ND		ug/l	2.0	0.46
Anthracene	ND		ug/l	2.0	0.33
Benzo(ghi)perylene	ND		ug/l	2.0	0.30
Fluorene	ND		ug/l	2.0	0.41
Phenanthrene	ND		ug/l	2.0	0.33
Dibenzo(a,h)anthracene	ND		ug/l	2.0	0.32
Indeno(1,2,3-cd)pyrene	ND		ug/l	2.0	0.40
Pyrene	ND		ug/l	2.0	0.28
Biphenyl	ND		ug/l	2.0	0.46
4-Chloroaniline	ND		ug/l	5.0	1.1
2-Nitroaniline	ND		ug/l	5.0	0.50
3-Nitroaniline	ND		ug/l	5.0	0.81
4-Nitroaniline	ND		ug/l	5.0	0.80
Dibenzofuran	ND		ug/l	2.0	0.50
2-Methylnaphthalene	ND		ug/l	2.0	0.45
1,2,4,5-Tetrachlorobenzene	ND		ug/l	10	0.44
Acetophenone	ND		ug/l	5.0	0.53
2,4,6-Trichlorophenol	ND		ug/l	5.0	0.61
p-Chloro-m-cresol	ND		ug/l	2.0	0.35
2-Chlorophenol	ND		ug/l	2.0	0.48
2,4-Dichlorophenol	ND		ug/l	5.0	0.41
2,4-Dimethylphenol	ND		ug/l	5.0	1.8
2-Nitrophenol	ND		ug/l	10	0.85

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 06/11/23 17:06
Analyst: ALS

Extraction Method: EPA 3510C
Extraction Date: 06/09/23 02:24

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 06-07 Batch: WG1789052-1					
4-Nitrophenol	ND		ug/l	10	0.67
2,4-Dinitrophenol	ND		ug/l	20	6.6
4,6-Dinitro-o-cresol	ND		ug/l	10	1.8
Pentachlorophenol	ND		ug/l	10	1.8
Phenol	ND		ug/l	5.0	0.57
2-Methylphenol	ND		ug/l	5.0	0.49
3-Methylphenol/4-Methylphenol	ND		ug/l	5.0	0.48
2,4,5-Trichlorophenol	ND		ug/l	5.0	0.77
Benzoic Acid	ND		ug/l	50	2.6
Benzyl Alcohol	ND		ug/l	2.0	0.59
Carbazole	ND		ug/l	2.0	0.49

Tentatively Identified Compounds			
Total TIC Compounds	46.5	J	ug/l
Unknown Organic Acid	3.53	J	ug/l
Unknown	1.56	J	ug/l
Unknown	1.45	J	ug/l
Unknown	5.09	J	ug/l
Unknown Cycloalkane	13.3	J	ug/l
Unknown	16.0	J	ug/l
Unknown	2.98	J	ug/l
Unknown	2.62	J	ug/l

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 06/11/23 17:06
Analyst: ALS

Extraction Method: EPA 3510C
Extraction Date: 06/09/23 02:24

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 06-07 Batch: WG1789052-1					

Surrogate	%Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	56		21-120
Phenol-d6	37		10-120
Nitrobenzene-d5	76		23-120
2-Fluorobiphenyl	82		15-120
2,4,6-Tribromophenol	106		10-120
4-Terphenyl-d14	82		41-149

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E-SIM
Analytical Date: 06/09/23 17:58
Analyst: AH

Extraction Method: EPA 3510C
Extraction Date: 06/09/23 02:27

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS-SIM - Westborough Lab for sample(s): 06-07 Batch: WG1789053-1					
Acenaphthene	ND		ug/l	0.10	0.01
2-Chloronaphthalene	ND		ug/l	0.20	0.02
Fluoranthene	ND		ug/l	0.10	0.02
Hexachlorobutadiene	ND		ug/l	0.50	0.05
Naphthalene	ND		ug/l	0.10	0.05
Benzo(a)anthracene	ND		ug/l	0.10	0.02
Benzo(a)pyrene	ND		ug/l	0.10	0.02
Benzo(b)fluoranthene	ND		ug/l	0.10	0.01
Benzo(k)fluoranthene	ND		ug/l	0.10	0.01
Chrysene	ND		ug/l	0.10	0.01
Acenaphthylene	ND		ug/l	0.10	0.01
Anthracene	ND		ug/l	0.10	0.01
Benzo(ghi)perylene	ND		ug/l	0.10	0.01
Fluorene	0.02	J	ug/l	0.10	0.01
Phenanthrene	0.03	J	ug/l	0.10	0.02
Dibenzo(a,h)anthracene	ND		ug/l	0.10	0.01
Indeno(1,2,3-cd)pyrene	ND		ug/l	0.10	0.01
Pyrene	ND		ug/l	0.10	0.02
2-Methylnaphthalene	ND		ug/l	0.10	0.02
Pentachlorophenol	ND		ug/l	0.80	0.01
Hexachlorobenzene	ND		ug/l	0.80	0.01
Hexachloroethane	ND		ug/l	0.80	0.06

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E-SIM
Analytical Date: 06/09/23 17:58
Analyst: AH

Extraction Method: EPA 3510C
Extraction Date: 06/09/23 02:27

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS-SIM - Westborough Lab for sample(s): 06-07 Batch: WG1789053-1					

Surrogate	%Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	49		21-120
Phenol-d6	38		10-120
Nitrobenzene-d5	77		23-120
2-Fluorobiphenyl	84		15-120
2,4,6-Tribromophenol	118		10-120
4-Terphenyl-d14	83		41-149

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331480
Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 01-05,08 Batch: WG1788357-2 WG1788357-3								
Acenaphthene	74		82		31-137	10		50
1,2,4-Trichlorobenzene	74		78		38-107	5		50
Hexachlorobenzene	83		90		40-140	8		50
Bis(2-chloroethyl)ether	69		72		40-140	4		50
2-Chloronaphthalene	75		84		40-140	11		50
1,2-Dichlorobenzene	72		76		40-140	5		50
1,3-Dichlorobenzene	72		75		40-140	4		50
1,4-Dichlorobenzene	70		75		28-104	7		50
3,3'-Dichlorobenzidine	61		72		40-140	17		50
2,4-Dinitrotoluene	80		88		40-132	10		50
2,6-Dinitrotoluene	82		92		40-140	11		50
Fluoranthene	80		87		40-140	8		50
4-Chlorophenyl phenyl ether	75		82		40-140	9		50
4-Bromophenyl phenyl ether	82		88		40-140	7		50
Bis(2-chloroisopropyl)ether	82		88		40-140	7		50
Bis(2-chloroethoxy)methane	72		78		40-117	8		50
Hexachlorobutadiene	72		78		40-140	8		50
Hexachlorocyclopentadiene	53		63		40-140	17		50
Hexachloroethane	71		74		40-140	4		50
Isophorone	74		81		40-140	9		50
Naphthalene	74		82		40-140	10		50
Nitrobenzene	74		81		40-140	9		50
NDPA/DPA	80		87		36-157	8		50

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331480

Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 01-05,08 Batch: WG1788357-2 WG1788357-3								
n-Nitrosodi-n-propylamine	74		79		32-121	7		50
Bis(2-ethylhexyl)phthalate	80		88		40-140	10		50
Butyl benzyl phthalate	85		90		40-140	6		50
Di-n-butylphthalate	82		87		40-140	6		50
Di-n-octylphthalate	84		91		40-140	8		50
Diethyl phthalate	77		84		40-140	9		50
Dimethyl phthalate	78		88		40-140	12		50
Benzo(a)anthracene	75		85		40-140	13		50
Benzo(a)pyrene	85		91		40-140	7		50
Benzo(b)fluoranthene	80		87		40-140	8		50
Benzo(k)fluoranthene	76		80		40-140	5		50
Chrysene	74		83		40-140	11		50
Acenaphthylene	85		95		40-140	11		50
Anthracene	79		87		40-140	10		50
Benzo(ghi)perylene	74		77		40-140	4		50
Fluorene	78		86		40-140	10		50
Phenanthrene	74		82		40-140	10		50
Dibenzo(a,h)anthracene	72		75		40-140	4		50
Indeno(1,2,3-cd)pyrene	80		83		40-140	4		50
Pyrene	80		86		35-142	7		50
Biphenyl	78		87		37-127	11		50
4-Chloroaniline	65		81		40-140	22		50
2-Nitroaniline	85		98		47-134	14		50

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331480

Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 01-05,08 Batch: WG1788357-2 WG1788357-3								
3-Nitroaniline	72		85		26-129	17		50
4-Nitroaniline	79		90		41-125	13		50
Dibenzofuran	76		85		40-140	11		50
2-Methylnaphthalene	79		87		40-140	10		50
1,2,4,5-Tetrachlorobenzene	76		83		40-117	9		50
Acetophenone	74		81		14-144	9		50
2,4,6-Trichlorophenol	80		92		30-130	14		50
p-Chloro-m-cresol	82		95		26-103	15		50
2-Chlorophenol	76		82		25-102	8		50
2,4-Dichlorophenol	79		88		30-130	11		50
2,4-Dimethylphenol	81		90		30-130	11		50
2-Nitrophenol	77		84		30-130	9		50
4-Nitrophenol	88		101		11-114	14		50
2,4-Dinitrophenol	54		66		4-130	20		50
4,6-Dinitro-o-cresol	83		92		10-130	10		50
Pentachlorophenol	75		85		17-109	13		50
Phenol	75		85		26-90	13		50
2-Methylphenol	76		86		30-130.	12		50
3-Methylphenol/4-Methylphenol	82		94		30-130	14		50
2,4,5-Trichlorophenol	81		91		30-130	12		50
Benzoic Acid	23		34		10-110	39		50
Benzyl Alcohol	73		82		40-140	12		50
Carbazole	79		87		54-128	10		50

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331480
Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 01-05,08 Batch: WG1788357-2 WG1788357-3								
1,4-Dioxane	54		58		40-140	7		50

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
2-Fluorophenol	74		80		25-120
Phenol-d6	74		82		10-120
Nitrobenzene-d5	72		79		23-120
2-Fluorobiphenyl	75		81		30-120
2,4,6-Tribromophenol	83		89		10-136
4-Terphenyl-d14	75		80		18-120

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331480
Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 06-07 Batch: WG1789052-2 WG1789052-3								
Acenaphthene	69		77		37-111	11		30
1,2,4-Trichlorobenzene	72		83		39-98	14		30
Hexachlorobenzene	85		97		40-140	13		30
Bis(2-chloroethyl)ether	57		77		40-140	30		30
2-Chloronaphthalene	79		86		40-140	8		30
1,2-Dichlorobenzene	68		75		40-140	10		30
1,3-Dichlorobenzene	65		72		40-140	10		30
1,4-Dichlorobenzene	69		74		36-97	7		30
3,3'-Dichlorobenzidine	76		83		40-140	9		30
2,4-Dinitrotoluene	73		86		48-143	16		30
2,6-Dinitrotoluene	86		93		40-140	8		30
Fluoranthene	77		85		40-140	10		30
4-Chlorophenyl phenyl ether	74		86		40-140	15		30
4-Bromophenyl phenyl ether	79		90		40-140	13		30
Bis(2-chloroisopropyl)ether	54		60		40-140	11		30
Bis(2-chloroethoxy)methane	61		73		40-140	18		30
Hexachlorobutadiene	77		82		40-140	6		30
Hexachlorocyclopentadiene	73		76		40-140	4		30
Hexachloroethane	66		69		40-140	4		30
Isophorone	64		75		40-140	16		30
Naphthalene	70		76		40-140	8		30
Nitrobenzene	66		77		40-140	15		30
NDPA/DPA	73		84		40-140	14		30

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331480
Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 06-07 Batch: WG1789052-2 WG1789052-3								
n-Nitrosodi-n-propylamine	69		77		29-132	11		30
Bis(2-ethylhexyl)phthalate	90		102		40-140	13		30
Butyl benzyl phthalate	84		94		40-140	11		30
Di-n-butylphthalate	79		89		40-140	12		30
Di-n-octylphthalate	85		96		40-140	12		30
Diethyl phthalate	75		87		40-140	15		30
Dimethyl phthalate	87		93		40-140	7		30
Benzo(a)anthracene	74		84		40-140	13		30
Benzo(a)pyrene	84		94		40-140	11		30
Benzo(b)fluoranthene	76		81		40-140	6		30
Benzo(k)fluoranthene	76		92		40-140	19		30
Chrysene	78		86		40-140	10		30
Acenaphthylene	89		96		45-123	8		30
Anthracene	78		84		40-140	7		30
Benzo(ghi)perylene	75		81		40-140	8		30
Fluorene	74		83		40-140	11		30
Phenanthrene	75		81		40-140	8		30
Dibenzo(a,h)anthracene	74		78		40-140	5		30
Indeno(1,2,3-cd)pyrene	67		75		40-140	11		30
Pyrene	76		86		26-127	12		30
Biphenyl	76		83		40-140	9		30
4-Chloroaniline	**0**	Q	**0**	Q	40-140	NC		30
2-Nitroaniline	87		94		52-143	8		30

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331480
Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 06-07 Batch: WG1789052-2 WG1789052-3								
3-Nitroaniline	56		68		25-145	19		30
4-Nitroaniline	68		79		51-143	15		30
Dibenzofuran	75		84		40-140	11		30
2-Methylnaphthalene	77		84		40-140	9		30
1,2,4,5-Tetrachlorobenzene	72		80		2-134	11		30
Acetophenone	60		70		39-129	15		30
2,4,6-Trichlorophenol	90		85		30-130	6		30
p-Chloro-m-cresol	78		90		23-97	14		30
2-Chlorophenol	66		77		27-123	15		30
2,4-Dichlorophenol	82		90		30-130	9		30
2,4-Dimethylphenol	78		78		30-130	0		30
2-Nitrophenol	74		84		30-130	13		30
4-Nitrophenol	66		70		10-80	6		30
2,4-Dinitrophenol	66		67		20-130	2		30
4,6-Dinitro-o-cresol	88		94		20-164	7		30
Pentachlorophenol	85		86		9-103	1		30
Phenol	38		46		12-110	19		30
2-Methylphenol	64		68		30-130	6		30
3-Methylphenol/4-Methylphenol	66		71		30-130	7		30
2,4,5-Trichlorophenol	92		111		30-130	19		30
Benzoic Acid	**0**	Q	**0**	Q	10-164	NC		30
Benzyl Alcohol	31		48		26-116	**43**	Q	30
Carbazole	79		87		55-144	10		30

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331480
Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 06-07 Batch: WG1789052-2 WG1789052-3								

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
2-Fluorophenol	53		61		21-120
Phenol-d6	41		48		10-120
Nitrobenzene-d5	71		77		23-120
2-Fluorobiphenyl	86		91		15-120
2,4,6-Tribromophenol	109		115		10-120
4-Terphenyl-d14	81		87		41-149

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331480

Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS-SIM - Westborough Lab Associated sample(s): 06-07 Batch: WG1789053-2 WG1789053-3								
Acenaphthene	69		78		40-140	12		40
2-Chloronaphthalene	78		87		40-140	11		40
Fluoranthene	80		90		40-140	12		40
Hexachlorobutadiene	86		98		40-140	13		40
Naphthalene	66		76		40-140	14		40
Benzo(a)anthracene	79		88		40-140	11		40
Benzo(a)pyrene	82		93		40-140	13		40
Benzo(b)fluoranthene	83		90		40-140	8		40
Benzo(k)fluoranthene	78		88		40-140	12		40
Chrysene	71		81		40-140	13		40
Acenaphthylene	83		93		40-140	11		40
Anthracene	74		82		40-140	10		40
Benzo(ghi)perylene	73		81		40-140	10		40
Fluorene	75		84		40-140	11		40
Phenanthrene	68		76		40-140	11		40
Dibenzo(a,h)anthracene	76		85		40-140	11		40
Indeno(1,2,3-cd)pyrene	70		79		40-140	12		40
Pyrene	81		91		40-140	12		40
2-Methylnaphthalene	74		85		40-140	14		40
Pentachlorophenol	94		96		40-140	2		40
Hexachlorobenzene	81		92		40-140	13		40
Hexachloroethane	62		70		40-140	12		40

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331480

Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits

Semivolatile Organics by GC/MS-SIM - Westborough Lab Associated sample(s): 06-07 Batch: WG1789053-2 WG1789053-3

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
2-Fluorophenol	52		59		21-120
Phenol-d6	44		50		10-120
Nitrobenzene-d5	77		87		23-120
2-Fluorobiphenyl	82		92		15-120
2,4,6-Tribromophenol	**128**	Q	**140**	Q	10-120
4-Terphenyl-d14	90		98		41-149

PCBS

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-01
Client ID: SB-28S(2-2.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/06/23 09:30
Date Received: 06/06/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8082A
Analytical Date: 06/08/23 09:56
Analyst: JM
Percent Solids: 92%

Extraction Method: EPA 3546
Extraction Date: 06/07/23 19:26
Cleanup Method: EPA 3665A
Cleanup Date: 06/08/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/08/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/kg	53.1	4.72	1	A
Aroclor 1221	ND		ug/kg	53.1	5.32	1	A
Aroclor 1232	ND		ug/kg	53.1	11.3	1	A
Aroclor 1242	ND		ug/kg	53.1	7.16	1	A
Aroclor 1248	ND		ug/kg	53.1	7.97	1	A
Aroclor 1254	ND		ug/kg	53.1	5.81	1	A
Aroclor 1260	ND		ug/kg	53.1	9.82	1	A
Aroclor 1262	ND		ug/kg	53.1	6.75	1	A
Aroclor 1268	ND		ug/kg	53.1	5.50	1	A
PCBs, Total	ND		ug/kg	53.1	4.72	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	53		30-150	A
Decachlorobiphenyl	44		30-150	A
2,4,5,6-Tetrachloro-m-xylene	52		30-150	B
Decachlorobiphenyl	45		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-02
Client ID: SB-29S(1-1.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/06/23 10:15
Date Received: 06/06/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8082A
Analytical Date: 06/08/23 10:05
Analyst: JM
Percent Solids: 93%

Extraction Method: EPA 3546
Extraction Date: 06/07/23 19:26
Cleanup Method: EPA 3665A
Cleanup Date: 06/08/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/08/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/kg	50.4	4.47	1	A
Aroclor 1221	ND		ug/kg	50.4	5.05	1	A
Aroclor 1232	ND		ug/kg	50.4	10.7	1	A
Aroclor 1242	ND		ug/kg	50.4	6.79	1	A
Aroclor 1248	ND		ug/kg	50.4	7.56	1	A
Aroclor 1254	ND		ug/kg	50.4	5.51	1	A
Aroclor 1260	ND		ug/kg	50.4	9.31	1	A
Aroclor 1262	ND		ug/kg	50.4	6.40	1	A
Aroclor 1268	ND		ug/kg	50.4	5.22	1	A
PCBs, Total	ND		ug/kg	50.4	4.47	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	55		30-150	A
Decachlorobiphenyl	43		30-150	A
2,4,5,6-Tetrachloro-m-xylene	65		30-150	B
Decachlorobiphenyl	45		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-03
Client ID: SB-30S(7-7.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/06/23 10:30
Date Received: 06/06/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8082A
Analytical Date: 06/08/23 10:15
Analyst: JM
Percent Solids: 89%

Extraction Method: EPA 3546
Extraction Date: 06/07/23 19:26
Cleanup Method: EPA 3665A
Cleanup Date: 06/08/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/08/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/kg	51.9	4.60	1	A
Aroclor 1221	ND		ug/kg	51.9	5.20	1	A
Aroclor 1232	ND		ug/kg	51.9	11.0	1	A
Aroclor 1242	ND		ug/kg	51.9	6.99	1	A
Aroclor 1248	ND		ug/kg	51.9	7.78	1	A
Aroclor 1254	ND		ug/kg	51.9	5.67	1	A
Aroclor 1260	ND		ug/kg	51.9	9.58	1	A
Aroclor 1262	ND		ug/kg	51.9	6.59	1	A
Aroclor 1268	ND		ug/kg	51.9	5.37	1	A
PCBs, Total	ND		ug/kg	51.9	4.60	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	57		30-150	A
Decachlorobiphenyl	49		30-150	A
2,4,5,6-Tetrachloro-m-xylene	58		30-150	B
Decachlorobiphenyl	49		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-04
Client ID: SB-30S(1.5-2)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/06/23 10:40
Date Received: 06/06/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8082A
Analytical Date: 06/08/23 10:25
Analyst: JM
Percent Solids: 92%

Extraction Method: EPA 3546
Extraction Date: 06/07/23 19:26
Cleanup Method: EPA 3665A
Cleanup Date: 06/08/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/08/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/kg	51.7	4.59	1	A
Aroclor 1221	ND		ug/kg	51.7	5.18	1	A
Aroclor 1232	ND		ug/kg	51.7	11.0	1	A
Aroclor 1242	ND		ug/kg	51.7	6.97	1	A
Aroclor 1248	ND		ug/kg	51.7	7.76	1	A
Aroclor 1254	ND		ug/kg	51.7	5.66	1	A
Aroclor 1260	ND		ug/kg	51.7	9.56	1	A
Aroclor 1262	ND		ug/kg	51.7	6.57	1	A
Aroclor 1268	ND		ug/kg	51.7	5.36	1	A
PCBs, Total	ND		ug/kg	51.7	4.59	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	60		30-150	A
Decachlorobiphenyl	48		30-150	A
2,4,5,6-Tetrachloro-m-xylene	70		30-150	B
Decachlorobiphenyl	48		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-05
Client ID: SB-31S(0.5-1)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/06/23 10:55
Date Received: 06/06/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8082A
Analytical Date: 06/08/23 10:35
Analyst: JM
Percent Solids: 89%

Extraction Method: EPA 3546
Extraction Date: 06/07/23 19:26
Cleanup Method: EPA 3665A
Cleanup Date: 06/08/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/08/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/kg	55.6	4.94	1	A
Aroclor 1221	ND		ug/kg	55.6	5.57	1	A
Aroclor 1232	ND		ug/kg	55.6	11.8	1	A
Aroclor 1242	ND		ug/kg	55.6	7.50	1	A
Aroclor 1248	ND		ug/kg	55.6	8.34	1	A
Aroclor 1254	ND		ug/kg	55.6	6.09	1	A
Aroclor 1260	ND		ug/kg	55.6	10.3	1	A
Aroclor 1262	ND		ug/kg	55.6	7.07	1	A
Aroclor 1268	ND		ug/kg	55.6	5.76	1	A
PCBs, Total	ND		ug/kg	55.6	4.94	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	61		30-150	A
Decachlorobiphenyl	50		30-150	A
2,4,5,6-Tetrachloro-m-xylene	73		30-150	B
Decachlorobiphenyl	52		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-06
Client ID: GW-12
Sample Location: WHITE PLAINS, NY

Date Collected: 06/06/23 09:50
Date Received: 06/06/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8082A
Analytical Date: 06/11/23 15:45
Analyst: ER

Extraction Method: EPA 3510C
Extraction Date: 06/10/23 00:54
Cleanup Method: EPA 3665A
Cleanup Date: 06/10/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/10/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/l	0.071	0.061	1	A
Aroclor 1221	ND		ug/l	0.071	0.061	1	A
Aroclor 1232	ND		ug/l	0.071	0.061	1	A
Aroclor 1242	ND		ug/l	0.071	0.061	1	A
Aroclor 1248	ND		ug/l	0.071	0.061	1	A
Aroclor 1254	ND		ug/l	0.071	0.061	1	A
Aroclor 1260	ND		ug/l	0.071	0.061	1	A
Aroclor 1262	ND		ug/l	0.071	0.061	1	A
Aroclor 1268	ND		ug/l	0.071	0.061	1	A
PCBs, Total	ND		ug/l	0.071	0.061	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	70		30-150	A
Decachlorobiphenyl	75		30-150	A
2,4,5,6-Tetrachloro-m-xylene	71		30-150	B
Decachlorobiphenyl	78		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-07
Client ID: GW-13
Sample Location: WHITE PLAINS, NY

Date Collected: 06/06/23 11:20
Date Received: 06/06/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8082A
Analytical Date: 06/12/23 10:41
Analyst: JM

Extraction Method: EPA 3510C
Extraction Date: 06/10/23 00:54
Cleanup Method: EPA 3665A
Cleanup Date: 06/10/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/10/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/l	0.071	0.061	1	A
Aroclor 1221	ND		ug/l	0.071	0.061	1	A
Aroclor 1232	ND		ug/l	0.071	0.061	1	A
Aroclor 1242	ND		ug/l	0.071	0.061	1	A
Aroclor 1248	ND		ug/l	0.071	0.061	1	A
Aroclor 1254	ND		ug/l	0.071	0.061	1	A
Aroclor 1260	ND		ug/l	0.071	0.061	1	A
Aroclor 1262	ND		ug/l	0.071	0.061	1	A
Aroclor 1268	ND		ug/l	0.071	0.061	1	A
PCBs, Total	ND		ug/l	0.071	0.061	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	63		30-150	A
Decachlorobiphenyl	64		30-150	A
2,4,5,6-Tetrachloro-m-xylene	59		30-150	B
Decachlorobiphenyl	63		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-08
Client ID: SB-32S(3-3.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/06/23 12:15
Date Received: 06/06/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8082A
Analytical Date: 06/08/23 10:44
Analyst: JM
Percent Solids: 93%

Extraction Method: EPA 3546
Extraction Date: 06/07/23 19:26
Cleanup Method: EPA 3665A
Cleanup Date: 06/08/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/08/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/kg	53.0	4.71	1	A
Aroclor 1221	ND		ug/kg	53.0	5.32	1	A
Aroclor 1232	ND		ug/kg	53.0	11.2	1	A
Aroclor 1242	ND		ug/kg	53.0	7.15	1	A
Aroclor 1248	ND		ug/kg	53.0	7.96	1	A
Aroclor 1254	12.3	J	ug/kg	53.0	5.80	1	A
Aroclor 1260	ND		ug/kg	53.0	9.80	1	A
Aroclor 1262	ND		ug/kg	53.0	6.74	1	A
Aroclor 1268	ND		ug/kg	53.0	5.50	1	A
PCBs, Total	12.3	J	ug/kg	53.0	4.71	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	65		30-150	A
Decachlorobiphenyl	56		30-150	A
2,4,5,6-Tetrachloro-m-xylene	66		30-150	B
Decachlorobiphenyl	58		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331480
Report Date: 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8082A
Analytical Date: 06/08/23 09:46
Analyst: JM

Extraction Method: EPA 3546
Extraction Date: 06/07/23 12:42
Cleanup Method: EPA 3665A
Cleanup Date: 06/08/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/08/23

Parameter	Result	Qualifier	Units	RL	MDL	Column
Polychlorinated Biphenyls by GC - Westborough Lab for sample(s): 01-05,08 Batch: WG1788322-1						
Aroclor 1016	ND		ug/kg	48.3	4.29	A
Aroclor 1221	ND		ug/kg	48.3	4.84	A
Aroclor 1232	ND		ug/kg	48.3	10.2	A
Aroclor 1242	ND		ug/kg	48.3	6.51	A
Aroclor 1248	ND		ug/kg	48.3	7.25	A
Aroclor 1254	ND		ug/kg	48.3	5.28	A
Aroclor 1260	ND		ug/kg	48.3	8.93	A
Aroclor 1262	ND		ug/kg	48.3	6.14	A
Aroclor 1268	ND		ug/kg	48.3	5.00	A
PCBs, Total	ND		ug/kg	48.3	4.29	A

Surrogate	%Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	71		30-150	A
Decachlorobiphenyl	66		30-150	A
2,4,5,6-Tetrachloro-m-xylene	72		30-150	B
Decachlorobiphenyl	67		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8082A
Analytical Date: 06/11/23 14:12
Analyst: ER

Extraction Method: EPA 3510C
Extraction Date: 06/10/23 00:51
Cleanup Method: EPA 3665A
Cleanup Date: 06/10/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/10/23

Parameter	Result	Qualifier	Units	RL	MDL	Column
Polychlorinated Biphenyls by GC - Westborough Lab for sample(s): 06-07 Batch: WG1789532-1						
Aroclor 1016	ND		ug/l	0.071	0.061	A
Aroclor 1221	ND		ug/l	0.071	0.061	A
Aroclor 1232	ND		ug/l	0.071	0.061	A
Aroclor 1242	ND		ug/l	0.071	0.061	A
Aroclor 1248	ND		ug/l	0.071	0.061	A
Aroclor 1254	ND		ug/l	0.071	0.061	A
Aroclor 1260	ND		ug/l	0.071	0.061	A
Aroclor 1262	ND		ug/l	0.071	0.061	A
Aroclor 1268	ND		ug/l	0.071	0.061	A
PCBs, Total	ND		ug/l	0.071	0.061	A

Surrogate	%Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	57		30-150	A
Decachlorobiphenyl	67		30-150	A
2,4,5,6-Tetrachloro-m-xylene	52		30-150	B
Decachlorobiphenyl	62		30-150	B

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331480
Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits	Column
Polychlorinated Biphenyls by GC - Westborough Lab Associated sample(s): 01-05,08 Batch: WG1788322-2 WG1788322-3									
Aroclor 1016	72		71		40-140	1		50	A
Aroclor 1260	68		68		40-140	0		50	A

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	70		73		30-150	A
Decachlorobiphenyl	63		66		30-150	A
2,4,5,6-Tetrachloro-m-xylene	68		72		30-150	B
Decachlorobiphenyl	61		65		30-150	B

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits	Column
Polychlorinated Biphenyls by GC - Westborough Lab Associated sample(s): 06-07 Batch: WG1789532-2 WG1789532-3									
Aroclor 1016	66		55		40-140	18		50	A
Aroclor 1260	65		56		40-140	15		50	A

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	65		53		30-150	A
Decachlorobiphenyl	74		63		30-150	A
2,4,5,6-Tetrachloro-m-xylene	60		50		30-150	B
Decachlorobiphenyl	72		66		30-150	B

PESTICIDES

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-01
Client ID: SB-28S(2-2.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/06/23 09:30
Date Received: 06/06/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8081B
Analytical Date: 06/10/23 18:43
Analyst: EJL
Percent Solids: 92%

Extraction Method: EPA 3546
Extraction Date: 06/07/23 19:43
Cleanup Method: EPA 3620B
Cleanup Date: 06/10/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/10/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/kg	1.71	0.334	1	A
Lindane	ND		ug/kg	0.711	0.318	1	A
Alpha-BHC	ND		ug/kg	0.711	0.202	1	A
Beta-BHC	ND		ug/kg	1.71	0.647	1	A
Heptachlor	ND		ug/kg	0.854	0.383	1	A
Aldrin	ND		ug/kg	1.71	0.601	1	A
Heptachlor epoxide	ND		ug/kg	3.20	0.960	1	A
Endrin	ND		ug/kg	0.711	0.292	1	A
Endrin aldehyde	ND		ug/kg	2.13	0.747	1	A
Endrin ketone	ND		ug/kg	1.71	0.440	1	A
Dieldrin	ND		ug/kg	1.07	0.534	1	A
4,4'-DDE	1.26	J	ug/kg	1.71	0.395	1	A
4,4'-DDD	3.42		ug/kg	1.71	0.609	1	A
4,4'-DDT	1.43	J	ug/kg	1.71	1.37	1	B
Endosulfan I	ND		ug/kg	1.71	0.403	1	A
Endosulfan II	ND		ug/kg	1.71	0.570	1	A
Endosulfan sulfate	ND		ug/kg	0.711	0.339	1	A
Methoxychlor	ND		ug/kg	3.20	0.996	1	A
Toxaphene	ND		ug/kg	32.0	8.96	1	A
cis-Chlordane	0.817	J	ug/kg	2.13	0.595	1	B
trans-Chlordane	1.62	JIP	ug/kg	2.13	0.563	1	A
Chlordane	ND		ug/kg	14.2	5.66	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-01 Date Collected: 06/06/23 09:30

Client ID: SB-28S(2-2.5) Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	57		30-150	A
Decachlorobiphenyl	50		30-150	A
2,4,5,6-Tetrachloro-m-xylene	55		30-150	B
Decachlorobiphenyl	64		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-02
Client ID: SB-29S(1-1.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/06/23 10:15
Date Received: 06/06/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8081B
Analytical Date: 06/10/23 18:55
Analyst: EJL
Percent Solids: 93%

Extraction Method: EPA 3546
Extraction Date: 06/07/23 19:43
Cleanup Method: EPA 3620B
Cleanup Date: 06/10/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/10/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/kg	1.69	0.332	1	A
Lindane	ND		ug/kg	0.705	0.315	1	A
Alpha-BHC	ND		ug/kg	0.705	0.200	1	A
Beta-BHC	ND		ug/kg	1.69	0.642	1	A
Heptachlor	ND		ug/kg	0.846	0.380	1	A
Aldrin	ND		ug/kg	1.69	0.596	1	A
Heptachlor epoxide	ND		ug/kg	3.17	0.952	1	A
Endrin	ND		ug/kg	0.705	0.289	1	A
Endrin aldehyde	ND		ug/kg	2.12	0.741	1	A
Endrin ketone	ND		ug/kg	1.69	0.436	1	A
Dieldrin	ND		ug/kg	1.06	0.529	1	A
4,4'-DDE	0.726	J	ug/kg	1.69	0.392	1	A
4,4'-DDD	ND		ug/kg	1.69	0.604	1	A
4,4'-DDT	3.40		ug/kg	1.69	1.36	1	A
Endosulfan I	ND		ug/kg	1.69	0.400	1	A
Endosulfan II	ND		ug/kg	1.69	0.566	1	A
Endosulfan sulfate	ND		ug/kg	0.705	0.336	1	A
Methoxychlor	ND		ug/kg	3.17	0.988	1	A
Toxaphene	ND		ug/kg	31.7	8.89	1	A
cis-Chlordane	0.638	J	ug/kg	2.12	0.590	1	A
trans-Chlordane	1.27	J	ug/kg	2.12	0.559	1	A
Chlordane	ND		ug/kg	14.1	5.61	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-02 Date Collected: 06/06/23 10:15

Client ID: SB-29S(1-1.5) Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	72		30-150	A
Decachlorobiphenyl	69		30-150	A
2,4,5,6-Tetrachloro-m-xylene	69		30-150	B
Decachlorobiphenyl	79		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-03
Client ID: SB-30S(7-7.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/06/23 10:30
Date Received: 06/06/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8081B
Analytical Date: 06/10/23 19:08
Analyst: EJL
Percent Solids: 89%

Extraction Method: EPA 3546
Extraction Date: 06/07/23 19:43
Cleanup Method: EPA 3620B
Cleanup Date: 06/10/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/10/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/kg	1.74	0.341	1	A
Lindane	ND		ug/kg	0.725	0.324	1	A
Alpha-BHC	ND		ug/kg	0.725	0.206	1	A
Beta-BHC	ND		ug/kg	1.74	0.660	1	A
Heptachlor	ND		ug/kg	0.870	0.390	1	A
Aldrin	ND		ug/kg	1.74	0.613	1	A
Heptachlor epoxide	ND		ug/kg	3.26	0.979	1	A
Endrin	ND		ug/kg	0.725	0.297	1	A
Endrin aldehyde	ND		ug/kg	2.18	0.762	1	A
Endrin ketone	ND		ug/kg	1.74	0.448	1	A
Dieldrin	ND		ug/kg	1.09	0.544	1	A
4,4'-DDE	0.411	J	ug/kg	1.74	0.402	1	A
4,4'-DDD	0.849	J	ug/kg	1.74	0.621	1	A
4,4'-DDT	ND		ug/kg	1.74	1.40	1	A
Endosulfan I	ND		ug/kg	1.74	0.411	1	A
Endosulfan II	ND		ug/kg	1.74	0.582	1	A
Endosulfan sulfate	ND		ug/kg	0.725	0.345	1	A
Methoxychlor	ND		ug/kg	3.26	1.02	1	A
Toxaphene	ND		ug/kg	32.6	9.14	1	A
cis-Chlordane	ND		ug/kg	2.18	0.606	1	A
trans-Chlordane	ND	IP	ug/kg	2.18	0.574	1	B
Chlordane	ND		ug/kg	14.5	5.77	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-03 Date Collected: 06/06/23 10:30

Client ID: SB-30S(7-7.5) Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	61		30-150	A
Decachlorobiphenyl	59		30-150	A
2,4,5,6-Tetrachloro-m-xylene	58		30-150	B
Decachlorobiphenyl	70		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-04
Client ID: SB-30S(1.5-2)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/06/23 10:40
Date Received: 06/06/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8081B
Analytical Date: 06/10/23 19:21
Analyst: EJL
Percent Solids: 92%

Extraction Method: EPA 3546
Extraction Date: 06/07/23 19:43
Cleanup Method: EPA 3620B
Cleanup Date: 06/10/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/10/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/kg	1.63	0.319	1	A
Lindane	ND		ug/kg	0.678	0.303	1	A
Alpha-BHC	ND		ug/kg	0.678	0.192	1	A
Beta-BHC	ND		ug/kg	1.63	0.617	1	A
Heptachlor	ND		ug/kg	0.814	0.365	1	A
Aldrin	ND		ug/kg	1.63	0.573	1	A
Heptachlor epoxide	ND		ug/kg	3.05	0.915	1	A
Endrin	ND		ug/kg	0.678	0.278	1	A
Endrin aldehyde	ND		ug/kg	2.03	0.712	1	A
Endrin ketone	ND		ug/kg	1.63	0.419	1	A
Dieldrin	ND		ug/kg	1.02	0.508	1	A
4,4'-DDE	ND		ug/kg	1.63	0.376	1	A
4,4'-DDD	ND		ug/kg	1.63	0.580	1	A
4,4'-DDT	ND		ug/kg	1.63	1.31	1	B
Endosulfan I	ND		ug/kg	1.63	0.384	1	A
Endosulfan II	ND		ug/kg	1.63	0.544	1	A
Endosulfan sulfate	ND		ug/kg	0.678	0.323	1	A
Methoxychlor	ND		ug/kg	3.05	0.949	1	A
Toxaphene	ND		ug/kg	30.5	8.54	1	A
cis-Chlordane	ND		ug/kg	2.03	0.567	1	A
trans-Chlordane	ND		ug/kg	2.03	0.537	1	A
Chlordane	ND		ug/kg	13.6	5.39	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-04 Date Collected: 06/06/23 10:40

Client ID: SB-30S(1.5-2) Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	63		30-150	A
Decachlorobiphenyl	57		30-150	A
2,4,5,6-Tetrachloro-m-xylene	58		30-150	B
Decachlorobiphenyl	70		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-05
Client ID: SB-31S(0.5-1)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/06/23 10:55
Date Received: 06/06/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8081B
Analytical Date: 06/10/23 19:33
Analyst: EJL
Percent Solids: 89%

Extraction Method: EPA 3546
Extraction Date: 06/07/23 19:43
Cleanup Method: EPA 3620B
Cleanup Date: 06/10/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/10/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/kg	1.78	0.348	1	A
Lindane	ND		ug/kg	0.740	0.331	1	A
Alpha-BHC	ND		ug/kg	0.740	0.210	1	A
Beta-BHC	ND		ug/kg	1.78	0.673	1	A
Heptachlor	ND		ug/kg	0.888	0.398	1	A
Aldrin	ND		ug/kg	1.78	0.625	1	A
Heptachlor epoxide	ND		ug/kg	3.33	0.999	1	A
Endrin	ND		ug/kg	0.740	0.303	1	A
Endrin aldehyde	ND		ug/kg	2.22	0.777	1	A
Endrin ketone	ND		ug/kg	1.78	0.457	1	A
Dieldrin	ND		ug/kg	1.11	0.555	1	A
4,4'-DDE	ND		ug/kg	1.78	0.411	1	A
4,4'-DDD	ND		ug/kg	1.78	0.633	1	A
4,4'-DDT	1.49	J	ug/kg	1.78	1.43	1	A
Endosulfan I	ND		ug/kg	1.78	0.420	1	A
Endosulfan II	ND		ug/kg	1.78	0.593	1	A
Endosulfan sulfate	ND		ug/kg	0.740	0.352	1	A
Methoxychlor	ND		ug/kg	3.33	1.04	1	A
Toxaphene	ND		ug/kg	33.3	9.32	1	A
cis-Chlordane	ND		ug/kg	2.22	0.618	1	B
trans-Chlordane	1.13	J	ug/kg	2.22	0.586	1	B
Chlordane	ND		ug/kg	14.8	5.88	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-05 Date Collected: 06/06/23 10:55

Client ID: SB-31S(0.5-1) Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	67		30-150	A
Decachlorobiphenyl	64		30-150	A
2,4,5,6-Tetrachloro-m-xylene	63		30-150	B
Decachlorobiphenyl	74		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-06
Client ID: GW-12
Sample Location: WHITE PLAINS, NY

Date Collected: 06/06/23 09:50
Date Received: 06/06/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8081B
Analytical Date: 06/12/23 09:25
Analyst: AKM

Extraction Method: EPA 3510C
Extraction Date: 06/11/23 00:51

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/l	0.014	0.003	1	A
Lindane	ND		ug/l	0.014	0.003	1	A
Alpha-BHC	ND		ug/l	0.014	0.003	1	A
Beta-BHC	ND		ug/l	0.014	0.004	1	A
Heptachlor	ND		ug/l	0.014	0.002	1	A
Aldrin	ND		ug/l	0.014	0.002	1	A
Heptachlor epoxide	ND		ug/l	0.014	0.003	1	A
Endrin	ND		ug/l	0.029	0.003	1	A
Endrin aldehyde	ND		ug/l	0.029	0.006	1	A
Endrin ketone	ND		ug/l	0.029	0.003	1	A
Dieldrin	ND		ug/l	0.029	0.003	1	A
4,4'-DDE	ND		ug/l	0.029	0.003	1	A
4,4'-DDD	ND		ug/l	0.029	0.003	1	A
4,4'-DDT	ND		ug/l	0.029	0.003	1	A
Endosulfan I	ND		ug/l	0.014	0.002	1	A
Endosulfan II	ND		ug/l	0.029	0.004	1	A
Endosulfan sulfate	ND		ug/l	0.029	0.003	1	A
Methoxychlor	ND		ug/l	0.143	0.005	1	A
Toxaphene	ND		ug/l	0.143	0.045	1	A
cis-Chlordane	ND		ug/l	0.014	0.005	1	A
trans-Chlordane	ND		ug/l	0.014	0.004	1	A
Chlordane	ND		ug/l	0.143	0.033	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-06 Date Collected: 06/06/23 09:50

Client ID: GW-12 Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	66		30-150	A
Decachlorobiphenyl	71		30-150	A
2,4,5,6-Tetrachloro-m-xylene	65		30-150	B
Decachlorobiphenyl	73		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-07
Client ID: GW-13
Sample Location: WHITE PLAINS, NY

Date Collected: 06/06/23 11:20
Date Received: 06/06/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8081B
Analytical Date: 06/12/23 09:36
Analyst: AKM

Extraction Method: EPA 3510C
Extraction Date: 06/11/23 00:51

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/l	0.014	0.003	1	A
Lindane	ND		ug/l	0.014	0.003	1	A
Alpha-BHC	ND		ug/l	0.014	0.003	1	A
Beta-BHC	ND		ug/l	0.014	0.004	1	A
Heptachlor	ND		ug/l	0.014	0.002	1	A
Aldrin	ND		ug/l	0.014	0.002	1	A
Heptachlor epoxide	ND		ug/l	0.014	0.003	1	A
Endrin	ND		ug/l	0.029	0.003	1	A
Endrin aldehyde	ND		ug/l	0.029	0.006	1	A
Endrin ketone	ND		ug/l	0.029	0.003	1	A
Dieldrin	ND		ug/l	0.029	0.003	1	A
4,4'-DDE	ND		ug/l	0.029	0.003	1	A
4,4'-DDD	ND		ug/l	0.029	0.003	1	A
4,4'-DDT	ND		ug/l	0.029	0.003	1	A
Endosulfan I	ND		ug/l	0.014	0.002	1	A
Endosulfan II	ND		ug/l	0.029	0.004	1	A
Endosulfan sulfate	ND		ug/l	0.029	0.003	1	A
Methoxychlor	ND		ug/l	0.143	0.005	1	A
Toxaphene	ND		ug/l	0.143	0.045	1	A
cis-Chlordane	ND		ug/l	0.014	0.005	1	A
trans-Chlordane	ND		ug/l	0.014	0.004	1	A
Chlordane	ND		ug/l	0.143	0.033	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-07 Date Collected: 06/06/23 11:20

Client ID: GW-13 Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	64		30-150	A
Decachlorobiphenyl	62		30-150	A
2,4,5,6-Tetrachloro-m-xylene	60		30-150	B
Decachlorobiphenyl	58		30-150	B

Project Name: 100 MAIN ST.
Lab Number: L2331480
Project Number: 12461
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-08
Client ID: SB-32S(3-3.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/06/23 12:15
Date Received: 06/06/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8081B
Analytical Date: 06/10/23 19:46
Analyst: EJL
Percent Solids: 93%

Extraction Method: EPA 3546
Extraction Date: 06/07/23 19:43
Cleanup Method: EPA 3620B
Cleanup Date: 06/10/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/10/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/kg	1.68	0.329	1	A
Lindane	ND		ug/kg	0.699	0.312	1	A
Alpha-BHC	ND		ug/kg	0.699	0.198	1	A
Beta-BHC	ND		ug/kg	1.68	0.636	1	A
Heptachlor	ND		ug/kg	0.839	0.376	1	A
Aldrin	ND		ug/kg	1.68	0.591	1	A
Heptachlor epoxide	ND		ug/kg	3.15	0.944	1	A
Endrin	ND		ug/kg	0.699	0.287	1	A
Endrin aldehyde	ND		ug/kg	2.10	0.734	1	A
Endrin ketone	ND		ug/kg	1.68	0.432	1	A
Dieldrin	ND		ug/kg	1.05	0.524	1	A
4,4'-DDE	ND		ug/kg	1.68	0.388	1	A
4,4'-DDD	1.01	J	ug/kg	1.68	0.598	1	A
4,4'-DDT	ND		ug/kg	1.68	1.35	1	B
Endosulfan I	ND		ug/kg	1.68	0.396	1	A
Endosulfan II	ND		ug/kg	1.68	0.561	1	A
Endosulfan sulfate	ND		ug/kg	0.699	0.333	1	A
Methoxychlor	ND		ug/kg	3.15	0.979	1	A
Toxaphene	ND		ug/kg	31.5	8.81	1	A
cis-Chlordane	ND		ug/kg	2.10	0.584	1	B
trans-Chlordane	1.12	J	ug/kg	2.10	0.554	1	B
Chlordane	ND		ug/kg	14.0	5.56	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-08 Date Collected: 06/06/23 12:15

Client ID: SB-32S(3-3.5) Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	64		30-150	A
Decachlorobiphenyl	57		30-150	A
2,4,5,6-Tetrachloro-m-xylene	60		30-150	B
Decachlorobiphenyl	70		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8081B
Analytical Date: 06/10/23 14:10
Analyst: MMG

Extraction Method: EPA 3546
Extraction Date: 06/07/23 19:43
Cleanup Method: EPA 3620B
Cleanup Date: 06/10/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/10/23

Parameter	Result	Qualifier	Units	RL	MDL	Column
Organochlorine Pesticides by GC - Westborough Lab for sample(s): 01-05,08 Batch: WG1788485-1						
Delta-BHC	ND		ug/kg	1.56	0.306	A
Lindane	ND		ug/kg	0.651	0.291	A
Alpha-BHC	ND		ug/kg	0.651	0.185	A
Beta-BHC	ND		ug/kg	1.56	0.592	A
Heptachlor	ND		ug/kg	0.781	0.350	A
Aldrin	ND		ug/kg	1.56	0.550	A
Heptachlor epoxide	ND		ug/kg	2.93	0.878	A
Endrin	ND		ug/kg	0.651	0.267	A
Endrin aldehyde	ND		ug/kg	1.95	0.683	A
Endrin ketone	ND		ug/kg	1.56	0.402	A
Dieldrin	ND		ug/kg	0.976	0.488	A
4,4'-DDE	ND		ug/kg	1.56	0.361	A
4,4'-DDD	ND		ug/kg	1.56	0.557	A
4,4'-DDT	ND		ug/kg	1.56	1.26	A
Endosulfan I	ND		ug/kg	1.56	0.369	A
Endosulfan II	ND		ug/kg	1.56	0.522	A
Endosulfan sulfate	ND		ug/kg	0.651	0.310	A
Methoxychlor	ND		ug/kg	2.93	0.911	A
Toxaphene	ND		ug/kg	29.3	8.20	A
cis-Chlordane	ND		ug/kg	1.95	0.544	A
trans-Chlordane	ND		ug/kg	1.95	0.515	A
Chlordane	ND		ug/kg	13.0	5.17	A

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8081B
Analytical Date: 06/10/23 14:10
Analyst: MMG

Extraction Method: EPA 3546
Extraction Date: 06/07/23 19:43
Cleanup Method: EPA 3620B
Cleanup Date: 06/10/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/10/23

Parameter	Result	Qualifier	Units	RL	MDL	Column
Organochlorine Pesticides by GC - Westborough Lab for sample(s): 01-05,08 Batch: WG1788485-1						

Surrogate	%Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	74		30-150	A
Decachlorobiphenyl	105		30-150	A
2,4,5,6-Tetrachloro-m-xylene	72		30-150	B
Decachlorobiphenyl	93		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8081B
Analytical Date: 06/12/23 08:51
Analyst: AKM

Extraction Method: EPA 3510C
Extraction Date: 06/11/23 00:51

Parameter	Result	Qualifier	Units	RL	MDL	Column
Organochlorine Pesticides by GC - Westborough Lab for sample(s): 06-07 Batch: WG1789785-1						
Delta-BHC	ND		ug/l	0.014	0.003	A
Lindane	ND		ug/l	0.014	0.003	A
Alpha-BHC	ND		ug/l	0.014	0.003	A
Beta-BHC	ND		ug/l	0.014	0.004	A
Heptachlor	ND		ug/l	0.014	0.002	A
Aldrin	ND		ug/l	0.014	0.002	A
Heptachlor epoxide	ND		ug/l	0.014	0.003	A
Endrin	ND		ug/l	0.029	0.003	A
Endrin aldehyde	ND		ug/l	0.029	0.006	A
Endrin ketone	ND		ug/l	0.029	0.003	A
Dieldrin	ND		ug/l	0.029	0.003	A
4,4'-DDE	ND		ug/l	0.029	0.003	A
4,4'-DDD	ND		ug/l	0.029	0.003	A
4,4'-DDT	ND		ug/l	0.029	0.003	A
Endosulfan I	ND		ug/l	0.014	0.002	A
Endosulfan II	ND		ug/l	0.029	0.004	A
Endosulfan sulfate	ND		ug/l	0.029	0.003	A
Methoxychlor	ND		ug/l	0.143	0.005	A
Toxaphene	ND		ug/l	0.143	0.045	A
cis-Chlordane	ND		ug/l	0.014	0.005	A
trans-Chlordane	ND		ug/l	0.014	0.004	A
Chlordane	ND		ug/l	0.143	0.033	A

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8081B
Analytical Date: 06/12/23 08:51
Analyst: AKM

Extraction Method: EPA 3510C
Extraction Date: 06/11/23 00:51

Parameter	Result	Qualifier	Units	RL	MDL	Column
Organochlorine Pesticides by GC - Westborough Lab for sample(s): 06-07 Batch: WG1789785-1						

Surrogate	%Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	54		30-150	A
Decachlorobiphenyl	74		30-150	A
2,4,5,6-Tetrachloro-m-xylene	54		30-150	B
Decachlorobiphenyl	72		30-150	B

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331480

Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits	Column
Organochlorine Pesticides by GC - Westborough Lab Associated sample(s): 01-05,08 Batch: WG1788485-2 WG1788485-3									
Delta-BHC	94		97		30-150	3		30	A
Lindane	87		90		30-150	3		30	A
Alpha-BHC	88		91		30-150	3		30	A
Beta-BHC	88		90		30-150	2		30	A
Heptachlor	93		95		30-150	2		30	A
Aldrin	93		96		30-150	3		30	A
Heptachlor epoxide	90		93		30-150	3		30	A
Endrin	91		94		30-150	3		30	A
Endrin aldehyde	81		84		30-150	4		30	A
Endrin ketone	96		99		30-150	3		30	A
Dieldrin	99		102		30-150	3		30	A
4,4'-DDE	97		100		30-150	3		30	A
4,4'-DDD	100		103		30-150	3		30	A
4,4'-DDT	94		96		30-150	2		30	A
Endosulfan I	88		91		30-150	3		30	A
Endosulfan II	90		93		30-150	3		30	A
Endosulfan sulfate	90		94		30-150	4		30	A
Methoxychlor	94		96		30-150	2		30	A
cis-Chlordane	97		100		30-150	3		30	A
trans-Chlordane	103		106		30-150	3		30	A

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331480
Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits

Organochlorine Pesticides by GC - Westborough Lab Associated sample(s): 01-05,08 Batch: WG1788485-2 WG1788485-3

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	76		78		30-150	A
Decachlorobiphenyl	107		110		30-150	A
2,4,5,6-Tetrachloro-m-xylene	75		76		30-150	B
Decachlorobiphenyl	95		97		30-150	B

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331480
Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits	Column
Organochlorine Pesticides by GC - Westborough Lab Associated sample(s): 06-07 Batch: WG1789785-2 WG1789785-3									
Delta-BHC	57		71		30-150	**22**	Q	20	A
Lindane	58		69		30-150	17		20	A
Alpha-BHC	61		72		30-150	16		20	A
Beta-BHC	61		74		30-150	20		20	A
Heptachlor	61		71		30-150	16		20	A
Aldrin	59		69		30-150	16		20	A
Heptachlor epoxide	58		68		30-150	16		20	A
Endrin	59		69		30-150	17		20	A
Endrin aldehyde	54		64		30-150	17		20	A
Endrin ketone	63		74		30-150	15		20	A
Dieldrin	63		74		30-150	17		20	A
4,4'-DDE	58		68		30-150	16		20	A
4,4'-DDD	64		76		30-150	17		20	A
4,4'-DDT	71		82		30-150	14		20	A
Endosulfan I	59		69		30-150	15		20	A
Endosulfan II	61		72		30-150	17		20	A
Endosulfan sulfate	59		68		30-150	15		20	A
Methoxychlor	78		87		30-150	11		20	A
cis-Chlordane	63		74		30-150	16		20	A
trans-Chlordane	73		86		30-150	16		20	A

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331480

Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits

Organochlorine Pesticides by GC - Westborough Lab Associated sample(s): 06-07 Batch: WG1789785-2 WG1789785-3

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	53		63		30-150	A
Decachlorobiphenyl	70		79		30-150	A
2,4,5,6-Tetrachloro-m-xylene	52		62		30-150	B
Decachlorobiphenyl	68		76		30-150	B

METALS

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-01 Date Collected: 06/06/23 09:30

Client ID: SB-28S(2-2.5) Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Soil

Percent Solids: 92%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	8550		mg/kg	8.47	2.29	2	06/09/23 12:00	06/13/23 12:27	EPA 3050B	1,6010D	DHL
Antimony, Total	1.33	J	mg/kg	4.24	0.322	2	06/09/23 12:00	06/13/23 12:27	EPA 3050B	1,6010D	DHL
Arsenic, Total	1.77		mg/kg	0.847	0.176	2	06/09/23 12:00	06/13/23 12:27	EPA 3050B	1,6010D	DHL
Barium, Total	83.9		mg/kg	0.847	0.147	2	06/09/23 12:00	06/13/23 12:27	EPA 3050B	1,6010D	DHL
Beryllium, Total	0.500		mg/kg	0.424	0.028	2	06/09/23 12:00	06/13/23 12:27	EPA 3050B	1,6010D	DHL
Cadmium, Total	0.214	J	mg/kg	0.847	0.083	2	06/09/23 12:00	06/13/23 12:27	EPA 3050B	1,6010D	DHL
Calcium, Total	9620		mg/kg	8.47	2.96	2	06/09/23 12:00	06/13/23 12:27	EPA 3050B	1,6010D	DHL
Chromium, Total	21.4		mg/kg	0.847	0.081	2	06/09/23 12:00	06/13/23 12:27	EPA 3050B	1,6010D	DHL
Cobalt, Total	6.30		mg/kg	1.69	0.141	2	06/09/23 12:00	06/13/23 12:27	EPA 3050B	1,6010D	DHL
Copper, Total	32.4		mg/kg	0.847	0.218	2	06/09/23 12:00	06/13/23 12:27	EPA 3050B	1,6010D	DHL
Iron, Total	15200		mg/kg	4.24	0.765	2	06/09/23 12:00	06/13/23 12:27	EPA 3050B	1,6010D	DHL
Lead, Total	132		mg/kg	4.24	0.227	2	06/09/23 12:00	06/13/23 12:27	EPA 3050B	1,6010D	DHL
Magnesium, Total	6990		mg/kg	8.47	1.30	2	06/09/23 12:00	06/13/23 12:27	EPA 3050B	1,6010D	DHL
Manganese, Total	184		mg/kg	0.847	0.135	2	06/09/23 12:00	06/13/23 12:27	EPA 3050B	1,6010D	DHL
Mercury, Total	0.659		mg/kg	0.071	0.046	1	06/09/23 12:39	06/13/23 17:25	EPA 7471B	1,7471B	DMB
Nickel, Total	13.4		mg/kg	2.12	0.205	2	06/09/23 12:00	06/13/23 12:27	EPA 3050B	1,6010D	DHL
Potassium, Total	1690		mg/kg	212	12.2	2	06/09/23 12:00	06/13/23 12:27	EPA 3050B	1,6010D	DHL
Selenium, Total	ND		mg/kg	1.69	0.218	2	06/09/23 12:00	06/13/23 12:27	EPA 3050B	1,6010D	DHL
Silver, Total	0.270	J	mg/kg	0.424	0.240	2	06/09/23 12:00	06/13/23 12:27	EPA 3050B	1,6010D	DHL
Sodium, Total	253		mg/kg	169	2.67	2	06/09/23 12:00	06/13/23 12:27	EPA 3050B	1,6010D	DHL
Thallium, Total	0.494	J	mg/kg	1.69	0.267	2	06/09/23 12:00	06/13/23 12:27	EPA 3050B	1,6010D	DHL
Vanadium, Total	28.9		mg/kg	0.847	0.172	2	06/09/23 12:00	06/13/23 12:27	EPA 3050B	1,6010D	DHL
Zinc, Total	90.0		mg/kg	4.24	0.248	2	06/09/23 12:00	06/13/23 12:27	EPA 3050B	1,6010D	DHL

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-02 Date Collected: 06/06/23 10:15

Client ID: SB-29S(1-1.5) Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Soil

Percent Solids: 93%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	6920		mg/kg	8.32	2.24	2	06/09/23 12:00	06/13/23 12:32	EPA 3050B	1,6010D	DHL
Antimony, Total	0.723	J	mg/kg	4.16	0.316	2	06/09/23 12:00	06/13/23 12:32	EPA 3050B	1,6010D	DHL
Arsenic, Total	1.39		mg/kg	0.832	0.173	2	06/09/23 12:00	06/13/23 12:32	EPA 3050B	1,6010D	DHL
Barium, Total	60.1		mg/kg	0.832	0.145	2	06/09/23 12:00	06/13/23 12:32	EPA 3050B	1,6010D	DHL
Beryllium, Total	0.459		mg/kg	0.416	0.027	2	06/09/23 12:00	06/13/23 12:32	EPA 3050B	1,6010D	DHL
Cadmium, Total	0.151	J	mg/kg	0.832	0.082	2	06/09/23 12:00	06/13/23 12:32	EPA 3050B	1,6010D	DHL
Calcium, Total	5880		mg/kg	8.32	2.91	2	06/09/23 12:00	06/13/23 12:32	EPA 3050B	1,6010D	DHL
Chromium, Total	13.3		mg/kg	0.832	0.080	2	06/09/23 12:00	06/13/23 12:32	EPA 3050B	1,6010D	DHL
Cobalt, Total	6.20		mg/kg	1.66	0.138	2	06/09/23 12:00	06/13/23 12:32	EPA 3050B	1,6010D	DHL
Copper, Total	25.7		mg/kg	0.832	0.214	2	06/09/23 12:00	06/13/23 12:32	EPA 3050B	1,6010D	DHL
Iron, Total	13300		mg/kg	4.16	0.751	2	06/09/23 12:00	06/13/23 12:32	EPA 3050B	1,6010D	DHL
Lead, Total	54.4		mg/kg	4.16	0.223	2	06/09/23 12:00	06/13/23 12:32	EPA 3050B	1,6010D	DHL
Magnesium, Total	5420		mg/kg	8.32	1.28	2	06/09/23 12:00	06/13/23 12:32	EPA 3050B	1,6010D	DHL
Manganese, Total	218		mg/kg	0.832	0.132	2	06/09/23 12:00	06/13/23 12:32	EPA 3050B	1,6010D	DHL
Mercury, Total	0.102		mg/kg	0.071	0.046	1	06/09/23 12:39	06/13/23 17:35	EPA 7471B	1,7471B	DMB
Nickel, Total	11.6		mg/kg	2.08	0.201	2	06/09/23 12:00	06/13/23 12:32	EPA 3050B	1,6010D	DHL
Potassium, Total	1530		mg/kg	208	12.0	2	06/09/23 12:00	06/13/23 12:32	EPA 3050B	1,6010D	DHL
Selenium, Total	ND		mg/kg	1.66	0.214	2	06/09/23 12:00	06/13/23 12:32	EPA 3050B	1,6010D	DHL
Silver, Total	ND		mg/kg	0.416	0.235	2	06/09/23 12:00	06/13/23 12:32	EPA 3050B	1,6010D	DHL
Sodium, Total	121	J	mg/kg	166	2.62	2	06/09/23 12:00	06/13/23 12:32	EPA 3050B	1,6010D	DHL
Thallium, Total	0.543	J	mg/kg	1.66	0.262	2	06/09/23 12:00	06/13/23 12:32	EPA 3050B	1,6010D	DHL
Vanadium, Total	19.9		mg/kg	0.832	0.169	2	06/09/23 12:00	06/13/23 12:32	EPA 3050B	1,6010D	DHL
Zinc, Total	58.6		mg/kg	4.16	0.244	2	06/09/23 12:00	06/13/23 12:32	EPA 3050B	1,6010D	DHL

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-03 Date Collected: 06/06/23 10:30

Client ID: SB-30S(7-7.5) Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Soil

Percent Solids: 89%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	5490		mg/kg	8.84	2.39	2	06/09/23 12:00	06/13/23 12:36	EPA 3050B	1,6010D	DHL
Antimony, Total	0.968	J	mg/kg	4.42	0.336	2	06/09/23 12:00	06/13/23 12:36	EPA 3050B	1,6010D	DHL
Arsenic, Total	1.40		mg/kg	0.884	0.184	2	06/09/23 12:00	06/13/23 12:36	EPA 3050B	1,6010D	DHL
Barium, Total	47.2		mg/kg	0.884	0.154	2	06/09/23 12:00	06/13/23 12:36	EPA 3050B	1,6010D	DHL
Beryllium, Total	0.418	J	mg/kg	0.442	0.029	2	06/09/23 12:00	06/13/23 12:36	EPA 3050B	1,6010D	DHL
Cadmium, Total	0.088	J	mg/kg	0.884	0.087	2	06/09/23 12:00	06/13/23 12:36	EPA 3050B	1,6010D	DHL
Calcium, Total	3730		mg/kg	8.84	3.10	2	06/09/23 12:00	06/13/23 12:36	EPA 3050B	1,6010D	DHL
Chromium, Total	11.5		mg/kg	0.884	0.085	2	06/09/23 12:00	06/13/23 12:36	EPA 3050B	1,6010D	DHL
Cobalt, Total	4.08		mg/kg	1.77	0.147	2	06/09/23 12:00	06/13/23 12:36	EPA 3050B	1,6010D	DHL
Copper, Total	17.0		mg/kg	0.884	0.228	2	06/09/23 12:00	06/13/23 12:36	EPA 3050B	1,6010D	DHL
Iron, Total	9790		mg/kg	4.42	0.799	2	06/09/23 12:00	06/13/23 12:36	EPA 3050B	1,6010D	DHL
Lead, Total	38.0		mg/kg	4.42	0.237	2	06/09/23 12:00	06/13/23 12:36	EPA 3050B	1,6010D	DHL
Magnesium, Total	2910		mg/kg	8.84	1.36	2	06/09/23 12:00	06/13/23 12:36	EPA 3050B	1,6010D	DHL
Manganese, Total	149		mg/kg	0.884	0.141	2	06/09/23 12:00	06/13/23 12:36	EPA 3050B	1,6010D	DHL
Mercury, Total	0.059	J	mg/kg	0.080	0.052	1	06/09/23 12:39	06/13/23 17:39	EPA 7471B	1,7471B	DMB
Nickel, Total	8.96		mg/kg	2.21	0.214	2	06/09/23 12:00	06/13/23 12:36	EPA 3050B	1,6010D	DHL
Potassium, Total	1290		mg/kg	221	12.7	2	06/09/23 12:00	06/13/23 12:36	EPA 3050B	1,6010D	DHL
Selenium, Total	ND		mg/kg	1.77	0.228	2	06/09/23 12:00	06/13/23 12:36	EPA 3050B	1,6010D	DHL
Silver, Total	ND		mg/kg	0.442	0.250	2	06/09/23 12:00	06/13/23 12:36	EPA 3050B	1,6010D	DHL
Sodium, Total	142	J	mg/kg	177	2.79	2	06/09/23 12:00	06/13/23 12:36	EPA 3050B	1,6010D	DHL
Thallium, Total	0.422	J	mg/kg	1.77	0.279	2	06/09/23 12:00	06/13/23 12:36	EPA 3050B	1,6010D	DHL
Vanadium, Total	16.0		mg/kg	0.884	0.180	2	06/09/23 12:00	06/13/23 12:36	EPA 3050B	1,6010D	DHL
Zinc, Total	35.2		mg/kg	4.42	0.259	2	06/09/23 12:00	06/13/23 12:36	EPA 3050B	1,6010D	DHL

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-04 Date Collected: 06/06/23 10:40

Client ID: SB-30S(1.5-2) Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Soil

Percent Solids: 92%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	6930		mg/kg	8.26	2.23	2	06/09/23 12:00	06/13/23 12:41	EPA 3050B	1,6010D	DHL
Antimony, Total	0.945	J	mg/kg	4.13	0.314	2	06/09/23 12:00	06/13/23 12:41	EPA 3050B	1,6010D	DHL
Arsenic, Total	1.64		mg/kg	0.826	0.172	2	06/09/23 12:00	06/13/23 12:41	EPA 3050B	1,6010D	DHL
Barium, Total	59.0		mg/kg	0.826	0.144	2	06/09/23 12:00	06/13/23 12:41	EPA 3050B	1,6010D	DHL
Beryllium, Total	0.425		mg/kg	0.413	0.027	2	06/09/23 12:00	06/13/23 12:41	EPA 3050B	1,6010D	DHL
Cadmium, Total	0.147	J	mg/kg	0.826	0.081	2	06/09/23 12:00	06/13/23 12:41	EPA 3050B	1,6010D	DHL
Calcium, Total	5630		mg/kg	8.26	2.89	2	06/09/23 12:00	06/13/23 12:41	EPA 3050B	1,6010D	DHL
Chromium, Total	15.1		mg/kg	0.826	0.079	2	06/09/23 12:00	06/13/23 12:41	EPA 3050B	1,6010D	DHL
Cobalt, Total	7.27		mg/kg	1.65	0.137	2	06/09/23 12:00	06/13/23 12:41	EPA 3050B	1,6010D	DHL
Copper, Total	24.2		mg/kg	0.826	0.213	2	06/09/23 12:00	06/13/23 12:41	EPA 3050B	1,6010D	DHL
Iron, Total	14100		mg/kg	4.13	0.746	2	06/09/23 12:00	06/13/23 12:41	EPA 3050B	1,6010D	DHL
Lead, Total	51.0		mg/kg	4.13	0.221	2	06/09/23 12:00	06/13/23 12:41	EPA 3050B	1,6010D	DHL
Magnesium, Total	5300		mg/kg	8.26	1.27	2	06/09/23 12:00	06/13/23 12:41	EPA 3050B	1,6010D	DHL
Manganese, Total	181		mg/kg	0.826	0.131	2	06/09/23 12:00	06/13/23 12:41	EPA 3050B	1,6010D	DHL
Mercury, Total	0.144		mg/kg	0.078	0.051	1	06/09/23 12:39	06/13/23 17:42	EPA 7471B	1,7471B	DMB
Nickel, Total	12.8		mg/kg	2.06	0.200	2	06/09/23 12:00	06/13/23 12:41	EPA 3050B	1,6010D	DHL
Potassium, Total	1520		mg/kg	206	11.9	2	06/09/23 12:00	06/13/23 12:41	EPA 3050B	1,6010D	DHL
Selenium, Total	ND		mg/kg	1.65	0.213	2	06/09/23 12:00	06/13/23 12:41	EPA 3050B	1,6010D	DHL
Silver, Total	ND		mg/kg	0.413	0.234	2	06/09/23 12:00	06/13/23 12:41	EPA 3050B	1,6010D	DHL
Sodium, Total	149	J	mg/kg	165	2.60	2	06/09/23 12:00	06/13/23 12:41	EPA 3050B	1,6010D	DHL
Thallium, Total	0.516	J	mg/kg	1.65	0.260	2	06/09/23 12:00	06/13/23 12:41	EPA 3050B	1,6010D	DHL
Vanadium, Total	27.8		mg/kg	0.826	0.168	2	06/09/23 12:00	06/13/23 12:41	EPA 3050B	1,6010D	DHL
Zinc, Total	50.3		mg/kg	4.13	0.242	2	06/09/23 12:00	06/13/23 12:41	EPA 3050B	1,6010D	DHL

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-05 Date Collected: 06/06/23 10:55

Client ID: SB-31S(0.5-1) Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Soil

Percent Solids: 89%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	7140		mg/kg	8.82	2.38	2	06/09/23 12:00	06/13/23 12:45	EPA 3050B	1,6010D	DHL
Antimony, Total	0.787	J	mg/kg	4.41	0.335	2	06/09/23 12:00	06/13/23 12:45	EPA 3050B	1,6010D	DHL
Arsenic, Total	1.28		mg/kg	0.882	0.183	2	06/09/23 12:00	06/13/23 12:45	EPA 3050B	1,6010D	DHL
Barium, Total	56.3		mg/kg	0.882	0.153	2	06/09/23 12:00	06/13/23 12:45	EPA 3050B	1,6010D	DHL
Beryllium, Total	0.458		mg/kg	0.441	0.029	2	06/09/23 12:00	06/13/23 12:45	EPA 3050B	1,6010D	DHL
Cadmium, Total	0.148	J	mg/kg	0.882	0.086	2	06/09/23 12:00	06/13/23 12:45	EPA 3050B	1,6010D	DHL
Calcium, Total	11200		mg/kg	8.82	3.09	2	06/09/23 12:00	06/13/23 12:45	EPA 3050B	1,6010D	DHL
Chromium, Total	14.9		mg/kg	0.882	0.085	2	06/09/23 12:00	06/13/23 12:45	EPA 3050B	1,6010D	DHL
Cobalt, Total	6.44		mg/kg	1.76	0.146	2	06/09/23 12:00	06/13/23 12:45	EPA 3050B	1,6010D	DHL
Copper, Total	22.8		mg/kg	0.882	0.228	2	06/09/23 12:00	06/13/23 12:45	EPA 3050B	1,6010D	DHL
Iron, Total	14000		mg/kg	4.41	0.796	2	06/09/23 12:00	06/13/23 12:45	EPA 3050B	1,6010D	DHL
Lead, Total	27.8		mg/kg	4.41	0.236	2	06/09/23 12:00	06/13/23 12:45	EPA 3050B	1,6010D	DHL
Magnesium, Total	7060		mg/kg	8.82	1.36	2	06/09/23 12:00	06/13/23 12:45	EPA 3050B	1,6010D	DHL
Manganese, Total	199		mg/kg	0.882	0.140	2	06/09/23 12:00	06/13/23 12:45	EPA 3050B	1,6010D	DHL
Mercury, Total	ND		mg/kg	0.087	0.057	1	06/09/23 12:39	06/13/23 17:45	EPA 7471B	1,7471B	DMB
Nickel, Total	12.2		mg/kg	2.20	0.213	2	06/09/23 12:00	06/13/23 12:45	EPA 3050B	1,6010D	DHL
Potassium, Total	1790		mg/kg	220	12.7	2	06/09/23 12:00	06/13/23 12:45	EPA 3050B	1,6010D	DHL
Selenium, Total	ND		mg/kg	1.76	0.228	2	06/09/23 12:00	06/13/23 12:45	EPA 3050B	1,6010D	DHL
Silver, Total	ND		mg/kg	0.441	0.250	2	06/09/23 12:00	06/13/23 12:45	EPA 3050B	1,6010D	DHL
Sodium, Total	249		mg/kg	176	2.78	2	06/09/23 12:00	06/13/23 12:45	EPA 3050B	1,6010D	DHL
Thallium, Total	0.391	J	mg/kg	1.76	0.278	2	06/09/23 12:00	06/13/23 12:45	EPA 3050B	1,6010D	DHL
Vanadium, Total	22.5		mg/kg	0.882	0.179	2	06/09/23 12:00	06/13/23 12:45	EPA 3050B	1,6010D	DHL
Zinc, Total	48.2		mg/kg	4.41	0.258	2	06/09/23 12:00	06/13/23 12:45	EPA 3050B	1,6010D	DHL

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-06 Date Collected: 06/06/23 09:50

Client ID: GW-12 Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Water

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	66.6		mg/l	0.0100	0.00327	1	06/09/23 03:48	06/13/23 14:26	EPA 3005A	1,6020B	EGW
Antimony, Total	0.00047	J	mg/l	0.00400	0.00042	1	06/09/23 03:48	06/13/23 14:26	EPA 3005A	1,6020B	EGW
Arsenic, Total	0.00640		mg/l	0.00050	0.00016	1	06/09/23 03:48	06/13/23 14:26	EPA 3005A	1,6020B	EGW
Barium, Total	1.586		mg/l	0.00050	0.00017	1	06/09/23 03:48	06/13/23 14:26	EPA 3005A	1,6020B	EGW
Beryllium, Total	0.00200		mg/l	0.00050	0.00010	1	06/09/23 03:48	06/13/23 14:26	EPA 3005A	1,6020B	EGW
Cadmium, Total	0.00106		mg/l	0.00020	0.00005	1	06/09/23 03:48	06/13/23 14:26	EPA 3005A	1,6020B	EGW
Calcium, Total	617.		mg/l	1.00	0.394	10	06/09/23 03:48	06/13/23 14:42	EPA 3005A	1,6020B	EGW
Chromium, Total	0.1193		mg/l	0.00100	0.00017	1	06/09/23 03:48	06/13/23 14:26	EPA 3005A	1,6020B	EGW
Cobalt, Total	0.09748		mg/l	0.00050	0.00016	1	06/09/23 03:48	06/13/23 14:26	EPA 3005A	1,6020B	EGW
Copper, Total	0.2168		mg/l	0.00100	0.00038	1	06/09/23 03:48	06/13/23 14:26	EPA 3005A	1,6020B	EGW
Iron, Total	108.		mg/l	0.0500	0.0191	1	06/09/23 03:48	06/13/23 14:26	EPA 3005A	1,6020B	EGW
Lead, Total	0.1252		mg/l	0.00100	0.00034	1	06/09/23 03:48	06/13/23 14:26	EPA 3005A	1,6020B	EGW
Magnesium, Total	166.		mg/l	0.0700	0.0242	1	06/09/23 03:48	06/13/23 14:26	EPA 3005A	1,6020B	EGW
Manganese, Total	2.550		mg/l	0.00100	0.00044	1	06/09/23 03:48	06/13/23 14:26	EPA 3005A	1,6020B	EGW
Mercury, Total	0.00032		mg/l	0.00020	0.00009	1	06/09/23 04:40	06/13/23 10:26	EPA 7470A	1,7470A	DMB
Nickel, Total	0.1464		mg/l	0.00200	0.00055	1	06/09/23 03:48	06/13/23 14:26	EPA 3005A	1,6020B	EGW
Potassium, Total	52.2		mg/l	0.100	0.0309	1	06/09/23 03:48	06/13/23 16:22	EPA 3005A	1,6020B	EGW
Selenium, Total	0.0448		mg/l	0.00500	0.00173	1	06/09/23 03:48	06/13/23 14:26	EPA 3005A	1,6020B	EGW
Silver, Total	0.00081		mg/l	0.00040	0.00016	1	06/09/23 03:48	06/13/23 14:26	EPA 3005A	1,6020B	EGW
Sodium, Total	458.		mg/l	1.00	0.293	10	06/09/23 03:48	06/13/23 14:42	EPA 3005A	1,6020B	EGW
Thallium, Total	0.00159		mg/l	0.00100	0.00014	1	06/09/23 03:48	06/13/23 14:26	EPA 3005A	1,6020B	EGW
Vanadium, Total	0.1064		mg/l	0.00500	0.00157	1	06/09/23 03:48	06/13/23 14:26	EPA 3005A	1,6020B	EGW
Zinc, Total	0.3451		mg/l	0.01000	0.00341	1	06/09/23 03:48	06/13/23 14:26	EPA 3005A	1,6020B	EGW

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-07 Date Collected: 06/06/23 11:20

Client ID: GW-13 Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Water

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	64.4		mg/l	0.0100	0.00327	1	06/09/23 03:48	06/13/23 11:40	EPA 3005A	1,6020B	EGW
Antimony, Total	ND		mg/l	0.00400	0.00042	1	06/09/23 03:48	06/13/23 11:40	EPA 3005A	1,6020B	EGW
Arsenic, Total	0.00550		mg/l	0.00050	0.00016	1	06/09/23 03:48	06/14/23 19:06	EPA 3005A	1,6020B	WKP
Barium, Total	1.620		mg/l	0.00050	0.00017	1	06/09/23 03:48	06/13/23 11:40	EPA 3005A	1,6020B	EGW
Beryllium, Total	0.00203		mg/l	0.00050	0.00010	1	06/09/23 03:48	06/13/23 11:40	EPA 3005A	1,6020B	EGW
Cadmium, Total	0.00185		mg/l	0.00020	0.00005	1	06/09/23 03:48	06/13/23 11:40	EPA 3005A	1,6020B	EGW
Calcium, Total	283.		mg/l	1.00	0.394	10	06/09/23 03:48	06/14/23 20:04	EPA 3005A	1,6020B	WKP
Chromium, Total	0.08265		mg/l	0.00100	0.00017	1	06/09/23 03:48	06/13/23 11:40	EPA 3005A	1,6020B	EGW
Cobalt, Total	0.1484		mg/l	0.00050	0.00016	1	06/09/23 03:48	06/13/23 11:40	EPA 3005A	1,6020B	EGW
Copper, Total	0.2458		mg/l	0.00100	0.00038	1	06/09/23 03:48	06/13/23 11:40	EPA 3005A	1,6020B	EGW
Iron, Total	103.		mg/l	0.0500	0.0191	1	06/09/23 03:48	06/13/23 11:40	EPA 3005A	1,6020B	EGW
Lead, Total	0.1190		mg/l	0.00100	0.00034	1	06/09/23 03:48	06/13/23 11:40	EPA 3005A	1,6020B	EGW
Magnesium, Total	148.		mg/l	0.0700	0.0242	1	06/09/23 03:48	06/13/23 11:40	EPA 3005A	1,6020B	EGW
Manganese, Total	6.738		mg/l	0.00100	0.00044	1	06/09/23 03:48	06/13/23 11:40	EPA 3005A	1,6020B	EGW
Mercury, Total	0.00032		mg/l	0.00020	0.00009	1	06/09/23 04:40	06/13/23 10:29	EPA 7470A	1,7470A	DMB
Nickel, Total	0.2960		mg/l	0.00200	0.00055	1	06/09/23 03:48	06/13/23 11:40	EPA 3005A	1,6020B	EGW
Potassium, Total	37.8		mg/l	0.100	0.0309	1	06/09/23 03:48	06/13/23 11:40	EPA 3005A	1,6020B	EGW
Selenium, Total	0.0512		mg/l	0.00500	0.00173	1	06/09/23 03:48	06/13/23 11:40	EPA 3005A	1,6020B	EGW
Silver, Total	0.00051		mg/l	0.00040	0.00016	1	06/09/23 03:48	06/13/23 11:40	EPA 3005A	1,6020B	EGW
Sodium, Total	606.		mg/l	1.00	0.293	10	06/09/23 03:48	06/14/23 20:04	EPA 3005A	1,6020B	WKP
Thallium, Total	0.00179		mg/l	0.00100	0.00014	1	06/09/23 03:48	06/13/23 11:40	EPA 3005A	1,6020B	EGW
Vanadium, Total	0.09737		mg/l	0.00500	0.00157	1	06/09/23 03:48	06/13/23 11:40	EPA 3005A	1,6020B	EGW
Zinc, Total	0.3912		mg/l	0.01000	0.00341	1	06/09/23 03:48	06/13/23 11:40	EPA 3005A	1,6020B	EGW

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-08 Date Collected: 06/06/23 12:15

Client ID: SB-32S(3-3.5) Date Received: 06/06/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Soil

Percent Solids: 93%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	5460		mg/kg	8.16	2.20	2	06/09/23 12:00	06/13/23 12:49	EPA 3050B	1,6010D	DHL
Antimony, Total	0.653	J	mg/kg	4.08	0.310	2	06/09/23 12:00	06/13/23 12:49	EPA 3050B	1,6010D	DHL
Arsenic, Total	1.26		mg/kg	0.816	0.170	2	06/09/23 12:00	06/13/23 12:49	EPA 3050B	1,6010D	DHL
Barium, Total	50.4		mg/kg	0.816	0.142	2	06/09/23 12:00	06/13/23 12:49	EPA 3050B	1,6010D	DHL
Beryllium, Total	0.399	J	mg/kg	0.408	0.027	2	06/09/23 12:00	06/13/23 12:49	EPA 3050B	1,6010D	DHL
Cadmium, Total	0.080	J	mg/kg	0.816	0.080	2	06/09/23 12:00	06/13/23 12:49	EPA 3050B	1,6010D	DHL
Calcium, Total	3580		mg/kg	8.16	2.86	2	06/09/23 12:00	06/13/23 12:49	EPA 3050B	1,6010D	DHL
Chromium, Total	11.2		mg/kg	0.816	0.078	2	06/09/23 12:00	06/13/23 12:49	EPA 3050B	1,6010D	DHL
Cobalt, Total	4.27		mg/kg	1.63	0.136	2	06/09/23 12:00	06/13/23 12:49	EPA 3050B	1,6010D	DHL
Copper, Total	17.2		mg/kg	0.816	0.211	2	06/09/23 12:00	06/13/23 12:49	EPA 3050B	1,6010D	DHL
Iron, Total	10100		mg/kg	4.08	0.737	2	06/09/23 12:00	06/13/23 12:49	EPA 3050B	1,6010D	DHL
Lead, Total	33.6		mg/kg	4.08	0.219	2	06/09/23 12:00	06/13/23 12:49	EPA 3050B	1,6010D	DHL
Magnesium, Total	3330		mg/kg	8.16	1.26	2	06/09/23 12:00	06/13/23 12:49	EPA 3050B	1,6010D	DHL
Manganese, Total	188		mg/kg	0.816	0.130	2	06/09/23 12:00	06/13/23 12:49	EPA 3050B	1,6010D	DHL
Mercury, Total	0.087		mg/kg	0.077	0.051	1	06/09/23 12:39	06/13/23 17:49	EPA 7471B	1,7471B	DMB
Nickel, Total	8.97		mg/kg	2.04	0.198	2	06/09/23 12:00	06/13/23 12:49	EPA 3050B	1,6010D	DHL
Potassium, Total	1320		mg/kg	204	11.8	2	06/09/23 12:00	06/13/23 12:49	EPA 3050B	1,6010D	DHL
Selenium, Total	ND		mg/kg	1.63	0.211	2	06/09/23 12:00	06/13/23 12:49	EPA 3050B	1,6010D	DHL
Silver, Total	ND		mg/kg	0.408	0.231	2	06/09/23 12:00	06/13/23 12:49	EPA 3050B	1,6010D	DHL
Sodium, Total	102	J	mg/kg	163	2.57	2	06/09/23 12:00	06/13/23 12:49	EPA 3050B	1,6010D	DHL
Thallium, Total	0.498	J	mg/kg	1.63	0.257	2	06/09/23 12:00	06/13/23 12:49	EPA 3050B	1,6010D	DHL
Vanadium, Total	17.5		mg/kg	0.816	0.166	2	06/09/23 12:00	06/13/23 12:49	EPA 3050B	1,6010D	DHL
Zinc, Total	37.3		mg/kg	4.08	0.239	2	06/09/23 12:00	06/13/23 12:49	EPA 3050B	1,6010D	DHL

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

Method Blank Analysis
Batch Quality Control

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
Total Metals - Mansfield Lab for sample(s): 01-05,08 Batch: WG1788880-1										
Aluminum, Total	ND		mg/kg	4.00	1.08	1	06/09/23 12:00	06/13/23 11:24	1,6010D	DHL
Antimony, Total	ND		mg/kg	2.00	0.152	1	06/09/23 12:00	06/13/23 11:24	1,6010D	DHL
Arsenic, Total	ND		mg/kg	0.400	0.083	1	06/09/23 12:00	06/13/23 11:24	1,6010D	DHL
Barium, Total	ND		mg/kg	0.400	0.070	1	06/09/23 12:00	06/13/23 11:24	1,6010D	DHL
Beryllium, Total	ND		mg/kg	0.200	0.013	1	06/09/23 12:00	06/13/23 11:24	1,6010D	DHL
Cadmium, Total	ND		mg/kg	0.400	0.039	1	06/09/23 12:00	06/13/23 11:24	1,6010D	DHL
Calcium, Total	2.78	J	mg/kg	4.00	1.40	1	06/09/23 12:00	06/13/23 11:24	1,6010D	DHL
Chromium, Total	ND		mg/kg	0.400	0.038	1	06/09/23 12:00	06/13/23 11:24	1,6010D	DHL
Cobalt, Total	ND		mg/kg	0.800	0.066	1	06/09/23 12:00	06/13/23 11:24	1,6010D	DHL
Copper, Total	ND		mg/kg	0.400	0.103	1	06/09/23 12:00	06/13/23 11:24	1,6010D	DHL
Iron, Total	ND		mg/kg	2.00	0.361	1	06/09/23 12:00	06/13/23 11:24	1,6010D	DHL
Lead, Total	ND		mg/kg	2.00	0.107	1	06/09/23 12:00	06/13/23 11:24	1,6010D	DHL
Magnesium, Total	ND		mg/kg	4.00	0.616	1	06/09/23 12:00	06/13/23 11:24	1,6010D	DHL
Manganese, Total	ND		mg/kg	0.400	0.064	1	06/09/23 12:00	06/13/23 11:24	1,6010D	DHL
Nickel, Total	ND		mg/kg	1.00	0.097	1	06/09/23 12:00	06/13/23 11:24	1,6010D	DHL
Potassium, Total	ND		mg/kg	100	5.76	1	06/09/23 12:00	06/13/23 11:24	1,6010D	DHL
Selenium, Total	ND		mg/kg	0.800	0.103	1	06/09/23 12:00	06/13/23 11:24	1,6010D	DHL
Silver, Total	ND		mg/kg	0.200	0.113	1	06/09/23 12:00	06/13/23 11:24	1,6010D	DHL
Sodium, Total	1.97	J	mg/kg	80.0	1.26	1	06/09/23 12:00	06/13/23 11:24	1,6010D	DHL
Thallium, Total	0.130	J	mg/kg	0.800	0.126	1	06/09/23 12:00	06/13/23 11:24	1,6010D	DHL
Vanadium, Total	ND		mg/kg	0.400	0.081	1	06/09/23 12:00	06/13/23 11:24	1,6010D	DHL
Zinc, Total	ND		mg/kg	2.00	0.117	1	06/09/23 12:00	06/13/23 11:24	1,6010D	DHL

Prep Information

Digestion Method: EPA 3050B

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
Total Metals - Mansfield Lab for sample(s): 01-05,08 Batch: WG1788881-1										
Mercury, Total	ND		mg/kg	0.083	0.054	1	06/09/23 12:39	06/13/23 16:33	1,7471B	DMB

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

Method Blank Analysis
Batch Quality Control

Prep Information

Digestion Method: EPA 7471B

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
Total Metals - Mansfield Lab for sample(s): 06-07 Batch: WG1788886-1										
Aluminum, Total	ND		mg/l	0.0100	0.00327	1	06/09/23 03:48	06/12/23 11:42	1,6020B	EGW
Antimony, Total	ND		mg/l	0.00400	0.00042	1	06/09/23 03:48	06/12/23 11:42	1,6020B	EGW
Arsenic, Total	ND		mg/l	0.00050	0.00016	1	06/09/23 03:48	06/12/23 11:42	1,6020B	EGW
Barium, Total	ND		mg/l	0.00050	0.00017	1	06/09/23 03:48	06/12/23 11:42	1,6020B	EGW
Beryllium, Total	ND		mg/l	0.00050	0.00010	1	06/09/23 03:48	06/12/23 11:42	1,6020B	EGW
Cadmium, Total	ND		mg/l	0.00020	0.00005	1	06/09/23 03:48	06/12/23 11:42	1,6020B	EGW
Calcium, Total	ND		mg/l	0.100	0.0394	1	06/09/23 03:48	06/12/23 11:42	1,6020B	EGW
Chromium, Total	ND		mg/l	0.00100	0.00017	1	06/09/23 03:48	06/12/23 11:42	1,6020B	EGW
Cobalt, Total	ND		mg/l	0.00050	0.00016	1	06/09/23 03:48	06/12/23 11:42	1,6020B	EGW
Copper, Total	ND		mg/l	0.00100	0.00038	1	06/09/23 03:48	06/12/23 11:42	1,6020B	EGW
Iron, Total	ND		mg/l	0.0500	0.0191	1	06/09/23 03:48	06/12/23 11:42	1,6020B	EGW
Lead, Total	ND		mg/l	0.00100	0.00034	1	06/09/23 03:48	06/12/23 11:42	1,6020B	EGW
Magnesium, Total	ND		mg/l	0.0700	0.0242	1	06/09/23 03:48	06/12/23 11:42	1,6020B	EGW
Manganese, Total	ND		mg/l	0.00100	0.00044	1	06/09/23 03:48	06/12/23 11:42	1,6020B	EGW
Nickel, Total	ND		mg/l	0.00200	0.00055	1	06/09/23 03:48	06/12/23 11:42	1,6020B	EGW
Potassium, Total	ND		mg/l	0.100	0.0309	1	06/09/23 03:48	06/12/23 11:42	1,6020B	EGW
Selenium, Total	ND		mg/l	0.00500	0.00173	1	06/09/23 03:48	06/12/23 11:42	1,6020B	EGW
Silver, Total	ND		mg/l	0.00040	0.00016	1	06/09/23 03:48	06/12/23 11:42	1,6020B	EGW
Sodium, Total	ND		mg/l	0.100	0.0293	1	06/09/23 03:48	06/12/23 11:42	1,6020B	EGW
Thallium, Total	ND		mg/l	0.00100	0.00014	1	06/09/23 03:48	06/12/23 11:42	1,6020B	EGW
Vanadium, Total	ND		mg/l	0.00500	0.00157	1	06/09/23 03:48	06/12/23 11:42	1,6020B	EGW
Zinc, Total	ND		mg/l	0.01000	0.00341	1	06/09/23 03:48	06/12/23 11:42	1,6020B	EGW

Prep Information

Digestion Method: EPA 3005A

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

Method Blank Analysis
Batch Quality Control

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
Total Metals - Mansfield Lab for sample(s): 06-07 Batch: WG1788892-1										
Mercury, Total	ND		mg/l	0.00020	0.00009	1	06/09/23 04:40	06/13/23 10:06	1,7470A	DMB

Prep Information

Digestion Method: EPA 7470A

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331480

Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-05,08 Batch: WG1788880-2 SRM Lot Number: D119-540								
Aluminum, Total	80		-		48-152	-		
Antimony, Total	123		-		10-190	-		
Arsenic, Total	100		-		83-117	-		
Barium, Total	97		-		82-118	-		
Beryllium, Total	96		-		83-117	-		
Cadmium, Total	93		-		82-117	-		
Calcium, Total	98		-		81-118	-		
Chromium, Total	100		-		82-119	-		
Cobalt, Total	97		-		83-117	-		
Copper, Total	102		-		84-116	-		
Iron, Total	105		-		60-140	-		
Lead, Total	103		-		82-118	-		
Magnesium, Total	98		-		76-124	-		
Manganese, Total	101		-		82-118	-		
Nickel, Total	97		-		82-117	-		
Potassium, Total	92		-		70-130	-		
Selenium, Total	104		-		79-121	-		
Silver, Total	104		-		80-120	-		
Sodium, Total	103		-		74-126	-		
Thallium, Total	99		-		81-119	-		
Vanadium, Total	101		-		79-121	-		

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331480

Report Date: 06/16/23

Parameter	LCS %Recovery	LCSD %Recovery	%Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-05,08 Batch: WG1788880-2 SRM Lot Number: D119-540					
Zinc, Total	97	-	80-120	-	
Total Metals - Mansfield Lab Associated sample(s): 01-05,08 Batch: WG1788881-2 SRM Lot Number: D119-540					
Mercury, Total	94	-	73-127	-	

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331480

Report Date: 06/16/23

Parameter	LCS %Recovery	LCSD %Recovery	%Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 06-07 Batch: WG1788886-2					
Aluminum, Total	108	-	80-120	-	
Antimony, Total	92	-	80-120	-	
Arsenic, Total	117	-	80-120	-	
Barium, Total	106	-	80-120	-	
Beryllium, Total	110	-	80-120	-	
Cadmium, Total	105	-	80-120	-	
Calcium, Total	108	-	80-120	-	
Chromium, Total	112	-	80-120	-	
Cobalt, Total	112	-	80-120	-	
Copper, Total	116	-	80-120	-	
Iron, Total	113	-	80-120	-	
Lead, Total	108	-	80-120	-	
Magnesium, Total	97	-	80-120	-	
Manganese, Total	112	-	80-120	-	
Nickel, Total	113	-	80-120	-	
Potassium, Total	101	-	80-120	-	
Selenium, Total	110	-	80-120	-	
Silver, Total	110	-	80-120	-	
Sodium, Total	99	-	80-120	-	
Thallium, Total	111	-	80-120	-	
Vanadium, Total	112	-	80-120	-	

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331480

Report Date: 06/16/23

Parameter	LCS %Recovery	LCSD %Recovery	%Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 06-07 Batch: WG1788886-2					
Zinc, Total	110	-	80-120	-	
Total Metals - Mansfield Lab Associated sample(s): 06-07 Batch: WG1788892-2					
Mercury, Total	91	-	80-120	-	

Matrix Spike Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331480
Report Date: 06/16/23

Parameter	Native Sample	MS Added	MS Found	MS %Recovery	Qual	MSD Found	MSD %Recovery	Qual	Recovery Limits	RPD	Qual	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-05,08 QC Batch ID: WG1788880-3 QC Sample: L2331451-04 Client ID: MS Sample												
Aluminum, Total	4960	213	6430	**690**	Q	-	-		75-125	-		20
Antimony, Total	3.30J	53.2	48.4	91		-	-		75-125	-		20
Arsenic, Total	4.35	12.8	16.5	95		-	-		75-125	-		20
Barium, Total	158	213	403	115		-	-		75-125	-		20
Beryllium, Total	0.575	5.32	6.14	104		-	-		75-125	-		20
Cadmium, Total	0.821J	5.64	6.17	109		-	-		75-125	-		20
Calcium, Total	28100	1060	48600	**1920**	Q	-	-		75-125	-		20
Chromium, Total	18.0	21.3	43.8	121		-	-		75-125	-		20
Cobalt, Total	5.96	53.2	58.2	98		-	-		75-125	-		20
Copper, Total	70.9	26.6	96.1	95		-	-		75-125	-		20
Iron, Total	19600	106	17600	**0**	Q	-	-		75-125	-		20
Lead, Total	557	56.4	404	**0**	Q	-	-		75-125	-		20
Magnesium, Total	5020	1060	5280	**24**	Q	-	-		75-125	-		20
Manganese, Total	244	53.2	385	**265**	Q	-	-		75-125	-		20
Nickel, Total	23.9	53.2	73.8	94		-	-		75-125	-		20
Potassium, Total	818	1060	2260	**135**	Q	-	-		75-125	-		20
Selenium, Total	ND	12.8	12.1	95		-	-		75-125	-		20
Silver, Total	ND	5.32	5.47	103		-	-		75-125	-		20
Sodium, Total	338	1060	1510	110		-	-		75-125	-		20
Thallium, Total	0.344J	12.8	12.4	97		-	-		75-125	-		20
Vanadium, Total	23.8	53.2	79.7	105		-	-		75-125	-		20

Matrix Spike Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331480
Report Date: 06/16/23

Parameter	Native Sample	MS Added	MS Found	MS %Recovery		MSD Found	MSD %Recovery	Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-05,08 QC Batch ID: WG1788880-3 QC Sample: L2331451-04 Client ID: MS Sample										
Zinc, Total	1540	53.2	548	**0**	Q	-	-	75-125	-	20
Total Metals - Mansfield Lab Associated sample(s): 01-05,08 QC Batch ID: WG1788881-3 QC Sample: L2330005-01 Client ID: MS Sample										
Mercury, Total	ND	1.66	1.66	100		-	-	80-120	-	20

Matrix Spike Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331480
Report Date: 06/16/23

Parameter	Native Sample	MS Added	MS Found	MS %Recovery	MSD Found	MSD %Recovery	Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 06-07 QC Batch ID: WG1788886-3 QC Sample: L2331306-07 Client ID: MS Sample									
Aluminum, Total	ND	2	2.18	109	-	-	75-125	-	20
Antimony, Total	ND	0.5	0.4803	96	-	-	75-125	-	20
Arsenic, Total	ND	0.12	0.1409	117	-	-	75-125	-	20
Barium, Total	0.00043J	2	2.160	108	-	-	75-125	-	20
Beryllium, Total	ND	0.05	0.05554	111	-	-	75-125	-	20
Cadmium, Total	ND	0.053	0.05789	109	-	-	75-125	-	20
Calcium, Total	ND	10	10.4	104	-	-	75-125	-	20
Chromium, Total	ND	0.2	0.2258	113	-	-	75-125	-	20
Cobalt, Total	ND	0.5	0.5670	113	-	-	75-125	-	20
Copper, Total	0.00041J	0.25	0.2907	116	-	-	75-125	-	20
Iron, Total	ND	1	1.15	115	-	-	75-125	-	20
Lead, Total	ND	0.53	0.5985	113	-	-	75-125	-	20
Magnesium, Total	ND	10	10.0	100	-	-	75-125	-	20
Manganese, Total	ND	0.5	0.5659	113	-	-	75-125	-	20
Nickel, Total	ND	0.5	0.5764	115	-	-	75-125	-	20
Potassium, Total	ND	10	10.1	101	-	-	75-125	-	20
Selenium, Total	ND	0.12	0.139	116	-	-	75-125	-	20
Silver, Total	ND	0.05	0.05524	110	-	-	75-125	-	20
Sodium, Total	ND	10	10.2	102	-	-	75-125	-	20
Thallium, Total	ND	0.12	0.1392	116	-	-	75-125	-	20
Vanadium, Total	ND	0.5	0.5632	113	-	-	75-125	-	20

Matrix Spike Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331480
Report Date: 06/16/23

Parameter	Native Sample	MS Added	MS Found	MS %Recovery	MSD Found	MSD %Recovery	Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 06-07 QC Batch ID: WG1788886-3 QC Sample: L2331306-07 Client ID: MS Sample									
Zinc, Total	ND	0.5	0.5599	112	-	-	75-125	-	20
Total Metals - Mansfield Lab Associated sample(s): 06-07 QC Batch ID: WG1788892-3 WG1788892-4 QC Sample: L2329835-07 Client ID: MS Sample									
Mercury, Total	0.00221	0.005	0.00681	92	0.00684	93	75-125	0	20

Lab Duplicate Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331480
Report Date: 06/16/23

Parameter	Native Sample	Duplicate Sample	Units	RPD	Qual	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-05,08 QC Batch ID: WG1788880-4 QC Sample: L2331451-04 Client ID: DUP Sample						
Aluminum, Total	4960	4780	mg/kg	4		20
Antimony, Total	3.30J	3.29J	mg/kg	NC		20
Arsenic, Total	4.35	4.40	mg/kg	1		20
Barium, Total	158	185	mg/kg	16		20
Beryllium, Total	0.575	0.448J	mg/kg	NC		20
Cadmium, Total	0.821J	0.806J	mg/kg	NC		20
Calcium, Total	28100	30300	mg/kg	8		20
Chromium, Total	18.0	18.6	mg/kg	3		20
Cobalt, Total	5.96	5.30	mg/kg	12		20
Copper, Total	70.9	68.8	mg/kg	3		20
Iron, Total	19600	17900	mg/kg	9		20
Lead, Total	557	504	mg/kg	10		20
Magnesium, Total	5020	5410	mg/kg	7		20
Manganese, Total	244	235	mg/kg	4		20
Nickel, Total	23.9	19.6	mg/kg	20		20
Potassium, Total	818	777	mg/kg	5		20
Selenium, Total	ND	ND	mg/kg	NC		20
Silver, Total	ND	ND	mg/kg	NC		20
Sodium, Total	338	365	mg/kg	8		20

Lab Duplicate Analysis

Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331480
Report Date: 06/16/23

Parameter	Native Sample	Duplicate Sample	Units	RPD		RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-05,08 QC Batch ID: WG1788880-4 QC Sample: L2331451-04 Client ID: DUP Sample						
Thallium, Total	0.344J	ND	mg/kg	NC		20
Vanadium, Total	23.8	22.3	mg/kg	7		20
Zinc, Total	1540	613	mg/kg	**86**	Q	20
Total Metals - Mansfield Lab Associated sample(s): 01-05,08 QC Batch ID: WG1788881-4 QC Sample: L2330005-01 Client ID: DUP Sample						
Mercury, Total	ND	ND	mg/kg	NC		20

Lab Duplicate Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331480
Report Date: 06/16/23

Parameter	Native Sample	Duplicate Sample	Units	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 06-07 QC Batch ID: WG1788886-4 QC Sample: L2331306-07 Client ID: DUP Sample					
Aluminum, Total	ND	ND	mg/l	NC	20
Antimony, Total	ND	0.00057J	mg/l	NC	20
Arsenic, Total	ND	ND	mg/l	NC	20
Barium, Total	0.00043J	0.00049J	mg/l	NC	20
Beryllium, Total	ND	ND	mg/l	NC	20
Cadmium, Total	ND	ND	mg/l	NC	20
Calcium, Total	ND	ND	mg/l	NC	20
Chromium, Total	ND	ND	mg/l	NC	20
Cobalt, Total	ND	ND	mg/l	NC	20
Copper, Total	0.00041J	ND	mg/l	NC	20
Iron, Total	ND	ND	mg/l	NC	20
Lead, Total	ND	ND	mg/l	NC	20
Magnesium, Total	ND	ND	mg/l	NC	20
Manganese, Total	ND	ND	mg/l	NC	20
Nickel, Total	ND	ND	mg/l	NC	20
Potassium, Total	ND	ND	mg/l	NC	20
Selenium, Total	ND	ND	mg/l	NC	20
Silver, Total	ND	ND	mg/l	NC	20
Sodium, Total	ND	ND	mg/l	NC	20

Lab Duplicate Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331480

Report Date: 06/16/23

Parameter	Native Sample	Duplicate Sample	Units	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 06-07 QC Batch ID: WG1788886-4 QC Sample: L2331306-07 Client ID: DUP Sample					
Thallium, Total	ND	0.00041J	mg/l	NC	20
Vanadium, Total	ND	ND	mg/l	NC	20
Zinc, Total	ND	ND	mg/l	NC	20

INORGANICS
&
MISCELLANEOUS

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331480
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-01
Client ID: SB-28S(2-2.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/06/23 09:30
Date Received: 06/06/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Solids, Total	92.0		%	0.100	NA	1	-	06/08/23 09:55	121,2540G	ROI
Cyanide, Total	ND		mg/kg	1.0	0.22	1	06/08/23 10:00	06/08/23 14:14	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331480
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-02
Client ID: SB-29S(1-1.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/06/23 10:15
Date Received: 06/06/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Solids, Total	93.2		%	0.100	NA	1	-	06/08/23 09:55	121,2540G	ROI
Cyanide, Total	ND		mg/kg	1.0	0.21	1	06/08/23 16:00	06/09/23 12:54	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331480
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-03
Client ID: SB-30S(7-7.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/06/23 10:30
Date Received: 06/06/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Solids, Total	88.6		%	0.100	NA	1	-	06/08/23 09:55	121,2540G	ROI
Cyanide, Total	0.24	J	mg/kg	1.0	0.22	1	06/08/23 16:00	06/09/23 12:55	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331480
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-04
Client ID: SB-30S(1.5-2)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/06/23 10:40
Date Received: 06/06/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Solids, Total	92.3		%	0.100	NA	1	-	06/08/23 09:55	121,2540G	ROI
Cyanide, Total	ND		mg/kg	1.0	0.22	1	06/08/23 16:00	06/09/23 12:56	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331480
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-05
Client ID: SB-31S(0.5-1)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/06/23 10:55
Date Received: 06/06/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Solids, Total	88.8		%	0.100	NA	1	-	06/08/23 09:55	121,2540G	ROI
Cyanide, Total	ND		mg/kg	1.0	0.22	1	06/08/23 16:00	06/09/23 12:57	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331480
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-06
Client ID: GW-12
Sample Location: WHITE PLAINS, NY

Sample Depth:
Matrix: Water

Date Collected: 06/06/23 09:50
Date Received: 06/06/23
Field Prep: Not Specified

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Cyanide, Total	0.001	J	mg/l	0.005	0.001	1	06/08/23 16:00	06/09/23 12:29	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331480
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-07
Client ID: GW-13
Sample Location: WHITE PLAINS, NY

Date Collected: 06/06/23 11:20
Date Received: 06/06/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Cyanide, Total	0.004	J	mg/l	0.005	0.001	1	06/08/23 16:00	06/09/23 12:32	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331480
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331480-08
Client ID: SB-32S(3-3.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/06/23 12:15
Date Received: 06/06/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Solids, Total	93.3		%	0.100	NA	1	-	06/08/23 09:55	121,2540G	ROI
Cyanide, Total	ND		mg/kg	1.0	0.22	1	06/08/23 16:00	06/09/23 12:58	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331480
Report Date: 06/16/23

Method Blank Analysis
Batch Quality Control

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab for sample(s): 01 Batch: WG1788664-1										
Cyanide, Total	ND		mg/kg	0.84	0.18	1	06/08/23 10:00	06/08/23 13:36	1,9010C/9012B	JER
General Chemistry - Westborough Lab for sample(s): 02-05,08 Batch: WG1788815-1										
Cyanide, Total	ND		mg/kg	0.87	0.18	1	06/08/23 16:00	06/09/23 12:35	1,9010C/9012B	JER
General Chemistry - Westborough Lab for sample(s): 06-07 Batch: WG1788885-1										
Cyanide, Total	ND		mg/l	0.005	0.001	1	06/08/23 16:00	06/09/23 12:17	1,9010C/9012B	JER

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331480

Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
General Chemistry - Westborough Lab Associated sample(s): 01 Batch: WG1788664-2 WG1788664-3								
Cyanide, Total	106		93		80-120	14		35
General Chemistry - Westborough Lab Associated sample(s): 02-05,08 Batch: WG1788815-2 WG1788815-3								
Cyanide, Total	99		104		80-120	4		35
General Chemistry - Westborough Lab Associated sample(s): 06-07 Batch: WG1788885-2 WG1788885-3								
Cyanide, Total	104		107		85-115	3		20

Matrix Spike Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331480
Report Date: 06/16/23

Parameter	Native Sample	MS Added	MS Found	MS %Recovery	Qual	MSD Found	MSD %Recovery	Qual	Recovery Limits	RPD	Qual	RPD Limits
General Chemistry - Westborough Lab Associated sample(s): 01 QC Batch ID: WG1788664-4 WG1788664-5 QC Sample: L2331226-07 Client ID: MS Sample												
Cyanide, Total	ND	10	12	120		12	120		75-125	0		35
General Chemistry - Westborough Lab Associated sample(s): 02-05,08 QC Batch ID: WG1788815-4 WG1788815-5 QC Sample: L2332000-02 Client ID: MS Sample												
Cyanide, Total	ND	12	12	96		11	94		75-125	9		35
General Chemistry - Westborough Lab Associated sample(s): 06-07 QC Batch ID: WG1788885-4 WG1788885-5 QC Sample: L2331480-06 Client ID: GW-12												
Cyanide, Total	0.001J	0.2	0.195	98		0.126	**63**	Q	80-120	**43**	Q	20

Lab Duplicate Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331480

Report Date: 06/16/23

Parameter	Native Sample	Duplicate Sample	Units	RPD	Qual	RPD Limits
General Chemistry - Westborough Lab Associated sample(s): 01-05,08 QC Batch ID: WG1788651-1 QC Sample: L2331480-01 Client ID: SB-28S(2-2.5)						
Solids, Total	92.0	91.5	%	1		20

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331480
Report Date: 06/16/23

Sample Receipt and Container Information

Were project specific reporting limits specified? YES

Cooler Information

Cooler	Custody Seal
A	Absent

Container Information

Container ID	Container Type	Cooler	Initial pH	Final pH	Temp deg C	Pres	Seal	Frozen Date/Time	Analysis(*)
L2331480-01A	5 gram Encore Sampler	A	NA		2.9	Y	Absent		NYTCL-8260HLW(14)
L2331480-01B	5 gram Encore Sampler	A	NA		2.9	Y	Absent		NYTCL-8260HLW(14)
L2331480-01C	5 gram Encore Sampler	A	NA		2.9	Y	Absent		NYTCL-8260HLW(14)
L2331480-01D	Plastic 2oz unpreserved for TS	A	NA		2.9	Y	Absent		TS(7)
L2331480-01E	Metals Only-Glass 60mL/2oz unpreserved	A	NA		2.9	Y	Absent		BE-TI(180),AS-TI(180),BA-TI(180),AG-TI(180),AL-TI(180),CR-TI(180),TL-TI(180),NI-TI(180),CU-TI(180),PB-TI(180),SE-TI(180),SB-TI(180),ZN-TI(180),CO-TI(180),V-TI(180),HG-T(28),MN-TI(180),MG-TI(180),FE-TI(180),K-TI(180),NA-TI(180),CA-TI(180),CD-TI(180)
L2331480-01F	Glass 250ml/8oz unpreserved	A	NA		2.9	Y	Absent		NYTCL-8270(14),TCN-9010(14),NYTCL-8081(14),NYTCL-8082(365)
L2331480-01X	Vial MeOH preserved split	A	NA		2.9	Y	Absent		NYTCL-8260HLW(14)
L2331480-01Y	Vial Water preserved split	A	NA		2.9	Y	Absent	08-JUN-23 01:30	NYTCL-8260HLW(14)
L2331480-01Z	Vial Water preserved split	A	NA		2.9	Y	Absent	08-JUN-23 01:30	NYTCL-8260HLW(14)
L2331480-02A	5 gram Encore Sampler	A	NA		2.9	Y	Absent		NYTCL-8260HLW(14)
L2331480-02B	5 gram Encore Sampler	A	NA		2.9	Y	Absent		NYTCL-8260HLW(14)
L2331480-02C	5 gram Encore Sampler	A	NA		2.9	Y	Absent		NYTCL-8260HLW(14)
L2331480-02D	Plastic 2oz unpreserved for TS	A	NA		2.9	Y	Absent		TS(7)
L2331480-02E	Metals Only-Glass 60mL/2oz unpreserved	A	NA		2.9	Y	Absent		BE-TI(180),AS-TI(180),BA-TI(180),AG-TI(180),CR-TI(180),TL-TI(180),AL-TI(180),NI-TI(180),PB-TI(180),SE-TI(180),ZN-TI(180),CU-TI(180),SB-TI(180),CO-TI(180),V-TI(180),FE-TI(180),HG-T(28),MG-TI(180),MN-TI(180),NA-TI(180),CA-TI(180),K-TI(180),CD-TI(180)
L2331480-02F	Glass 250ml/8oz unpreserved	A	NA		2.9	Y	Absent		NYTCL-8270(14),TCN-9010(14),NYTCL-8081(14),NYTCL-8082(365)
L2331480-02X	Vial MeOH preserved split	A	NA		2.9	Y	Absent		NYTCL-8260HLW(14)
L2331480-02Y	Vial Water preserved split	A	NA		2.9	Y	Absent	08-JUN-23 01:30	NYTCL-8260HLW(14)

*Values in parentheses indicate holding time in days

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331480
Report Date: 06/16/23

Container Information

Container ID	Container Type	Cooler	Initial pH	Final pH	Temp deg C	Pres	Seal	Frozen Date/Time	Analysis(*)
L2331480-02Z	Vial Water preserved split	A	NA		2.9	Y	Absent	08-JUN-23 01:30	NYTCL-8260HLW(14)
L2331480-03A	5 gram Encore Sampler	A	NA		2.9	Y	Absent		NYTCL-8260HLW(14)
L2331480-03B	5 gram Encore Sampler	A	NA		2.9	Y	Absent		NYTCL-8260HLW(14)
L2331480-03C	5 gram Encore Sampler	A	NA		2.9	Y	Absent		NYTCL-8260HLW(14)
L2331480-03D	Plastic 2oz unpreserved for TS	A	NA		2.9	Y	Absent		TS(7)
L2331480-03E	Metals Only-Glass 60mL/2oz unpreserved	A	NA		2.9	Y	Absent		BE-TI(180),AS-TI(180),BA-TI(180),AG-TI(180),AL-TI(180),NI-TI(180),CR-TI(180),TL-TI(180),CU-TI(180),PB-TI(180),ZN-TI(180),SB-TI(180),SE-TI(180),CO-TI(180),V-TI(180),MN-TI(180),HG-T(28),FE-TI(180),MG-TI(180),K-TI(180),NA-TI(180),CD-TI(180),CA-TI(180)
L2331480-03F	Glass 250ml/8oz unpreserved	A	NA		2.9	Y	Absent		TCN-9010(14),NYTCL-8270(14),NYTCL-8081(14),NYTCL-8082(365)
L2331480-03X	Vial MeOH preserved split	A	NA		2.9	Y	Absent		NYTCL-8260HLW(14)
L2331480-03Y	Vial Water preserved split	A	NA		2.9	Y	Absent	08-JUN-23 01:30	NYTCL-8260HLW(14)
L2331480-03Z	Vial Water preserved split	A	NA		2.9	Y	Absent	08-JUN-23 01:30	NYTCL-8260HLW(14)
L2331480-04A	5 gram Encore Sampler	A	NA		2.9	Y	Absent		NYTCL-8260HLW(14)
L2331480-04B	5 gram Encore Sampler	A	NA		2.9	Y	Absent		NYTCL-8260HLW(14)
L2331480-04C	5 gram Encore Sampler	A	NA		2.9	Y	Absent		NYTCL-8260HLW(14)
L2331480-04D	Plastic 2oz unpreserved for TS	A	NA		2.9	Y	Absent		TS(7)
L2331480-04E	Metals Only-Glass 60mL/2oz unpreserved	A	NA		2.9	Y	Absent		BE-TI(180),AS-TI(180),BA-TI(180),AG-TI(180),CR-TI(180),NI-TI(180),AL-TI(180),TL-TI(180),PB-TI(180),CU-TI(180),SB-TI(180),SE-TI(180),ZN-TI(180),CO-TI(180),V-TI(180),MG-TI(180),MN-TI(180),HG-T(28),FE-TI(180),NA-TI(180),CD-TI(180),CA-TI(180),K-TI(180)
L2331480-04F	Glass 250ml/8oz unpreserved	A	NA		2.9	Y	Absent		NYTCL-8270(14),TCN-9010(14),NYTCL-8081(14),NYTCL-8082(365)
L2331480-04X	Vial MeOH preserved split	A	NA		2.9	Y	Absent		NYTCL-8260HLW(14)
L2331480-04Y	Vial Water preserved split	A	NA		2.9	Y	Absent	08-JUN-23 01:30	NYTCL-8260HLW(14)
L2331480-04Z	Vial Water preserved split	A	NA		2.9	Y	Absent	08-JUN-23 01:30	NYTCL-8260HLW(14)
L2331480-05A	5 gram Encore Sampler	A	NA		2.9	Y	Absent		NYTCL-8260HLW(14)
L2331480-05B	5 gram Encore Sampler	A	NA		2.9	Y	Absent		NYTCL-8260HLW(14)
L2331480-05C	5 gram Encore Sampler	A	NA		2.9	Y	Absent		NYTCL-8260HLW(14)
L2331480-05D	Plastic 2oz unpreserved for TS	A	NA		2.9	Y	Absent		TS(7)

*Values in parentheses indicate holding time in days

Container Information

Container ID	Container Type	Cooler	Initial pH	Final pH	Temp deg C	Pres	Seal	Frozen Date/Time	Analysis(*)
L2331480-05E	Metals Only-Glass 60mL/2oz unpreserved	A	NA		2.9	Y	Absent		BE-TI(180),BA-TI(180),AS-TI(180),AG-TI(180),NI-TI(180),CR-TI(180),TL-TI(180),AL-TI(180),PB-TI(180),ZN-TI(180),CU-TI(180),SB-TI(180),SE-TI(180),CO-TI(180),V-TI(180),MN-TI(180),HG-T(28),FE-TI(180),MG-TI(180),K-TI(180),CA-TI(180),CD-TI(180),NA-TI(180)
L2331480-05F	Glass 250ml/8oz unpreserved	A	NA		2.9	Y	Absent		NYTCL-8270(14),TCN-9010(14),NYTCL-8081(14),NYTCL-8082(365)
L2331480-05X	Vial MeOH preserved split	A	NA		2.9	Y	Absent		NYTCL-8260HLW(14)
L2331480-05Y	Vial Water preserved split	A	NA		2.9	Y	Absent	08-JUN-23 01:30	NYTCL-8260HLW(14)
L2331480-05Z	Vial Water preserved split	A	NA		2.9	Y	Absent	08-JUN-23 01:30	NYTCL-8260HLW(14)
L2331480-06A	Vial HCl preserved	A	NA		2.9	Y	Absent		NYTCL-8260(14)
L2331480-06B	Vial HCl preserved	A	NA		2.9	Y	Absent		NYTCL-8260(14)
L2331480-06C	Vial HCl preserved	A	NA		2.9	Y	Absent		NYTCL-8260(14)
L2331480-06D	Amber 120ml unpreserved	A	7	7	2.9	Y	Absent		NYTCL-8081(7)
L2331480-06E	Amber 120ml unpreserved	A	7	7	2.9	Y	Absent		NYTCL-8081(7)
L2331480-06F	Amber 120ml unpreserved	A	7	7	2.9	Y	Absent		NYTCL-8082-LVI(365)
L2331480-06G	Amber 120ml unpreserved	A	7	7	2.9	Y	Absent		NYTCL-8082-LVI(365)
L2331480-06H	Plastic 250ml HNO3 preserved	A	<2	<2	2.9	Y	Absent		BA-6020T(180),FE-6020T(180),TL-6020T(180),SE-6020T(180),CR-6020T(180),NI-6020T(180),K-6020T(180),CA-6020T(180),NA-6020T(180),ZN-6020T(180),CU-6020T(180),PB-6020T(180),BE-6020T(180),MN-6020T(180),SB-6020T(180),V-6020T(180),AS-6020T(180),HG-T(28),AL-6020T(180),MG-6020T(180),AG-6020T(180),CD-6020T(180),CO-6020T(180)
L2331480-06I	Plastic 250ml NaOH preserved	A	>12	>12	2.9	Y	Absent		TCN-9010(14)
L2331480-06J	Amber 250ml unpreserved	A	7	7	2.9	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)
L2331480-06K	Amber 250ml unpreserved	A	7	7	2.9	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)
L2331480-07A	Vial HCl preserved	A	NA		2.9	Y	Absent		NYTCL-8260(14)
L2331480-07B	Vial HCl preserved	A	NA		2.9	Y	Absent		NYTCL-8260(14)
L2331480-07C	Vial HCl preserved	A	NA		2.9	Y	Absent		NYTCL-8260(14)
L2331480-07D	Amber 120ml unpreserved	A	7	7	2.9	Y	Absent		NYTCL-8081(7)
L2331480-07E	Amber 120ml unpreserved	A	7	7	2.9	Y	Absent		NYTCL-8081(7)

*Values in parentheses indicate holding time in days

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331480
Report Date: 06/16/23

Container Information

Container ID	Container Type	Cooler	Initial pH	Final pH	Temp deg C	Pres	Seal	Frozen Date/Time	Analysis(*)
L2331480-07F	Amber 120ml unpreserved	A	7	7	2.9	Y	Absent		NYTCL-8082-LVI(365)
L2331480-07G	Amber 120ml unpreserved	A	7	7	2.9	Y	Absent		NYTCL-8082-LVI(365)
L2331480-07H	Plastic 250ml HNO3 preserved	A	<2	<2	2.9	Y	Absent		BA-6020T(180),FE-6020T(180),SE-6020T(180),TL-6020T(180),K-6020T(180),NI-6020T(180),CA-6020T(180),CR-6020T(180),ZN-6020T(180),CU-6020T(180),NA-6020T(180),PB-6020T(180),MN-6020T(180),BE-6020T(180),SB-6020T(180),V-6020T(180),AS-6020T(180),AL-6020T(180),HG-T(28),MG-6020T(180),AG-6020T(180),CD-6020T(180),CO-6020T(180)
L2331480-07I	Plastic 250ml NaOH preserved	A	>12	>12	2.9	Y	Absent		TCN-9010(14)
L2331480-07J	Amber 250ml unpreserved	A	7	7	2.9	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)
L2331480-07K	Amber 250ml unpreserved	A	7	7	2.9	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)
L2331480-08A	5 gram Encore Sampler	A	NA		2.9	Y	Absent		NYTCL-8260HLW(14)
L2331480-08B	5 gram Encore Sampler	A	NA		2.9	Y	Absent		NYTCL-8260HLW(14)
L2331480-08C	5 gram Encore Sampler	A	NA		2.9	Y	Absent		NYTCL-8260HLW(14)
L2331480-08D	Plastic 2oz unpreserved for TS	A	NA		2.9	Y	Absent		TS(7)
L2331480-08E	Metals Only-Glass 60mL/2oz unpreserved	A	NA		2.9	Y	Absent		BE-TI(180),AS-TI(180),BA-TI(180),AG-TI(180),NI-TI(180),TL-TI(180),AL-TI(180),CR-TI(180),SB-TI(180),CU-TI(180),SE-TI(180),PB-TI(180),ZN-TI(180),CO-TI(180),V-TI(180),HG-T(28),MG-TI(180),FE-TI(180),MN-TI(180),K-TI(180),NA-TI(180),CA-TI(180),CD-TI(180)
L2331480-08F	Glass 250ml/8oz unpreserved	A	NA		2.9	Y	Absent		NYTCL-8270(14),TCN-9010(14),NYTCL-8081(14),NYTCL-8082(365)
L2331480-08X	Vial MeOH preserved split	A	NA		2.9	Y	Absent		NYTCL-8260HLW(14)
L2331480-08Y	Vial Water preserved split	A	NA		2.9	Y	Absent	08-JUN-23 01:30	NYTCL-8260HLW(14)
L2331480-08Z	Vial Water preserved split	A	NA		2.9	Y	Absent	08-JUN-23 01:30	NYTCL-8260HLW(14)

*Values in parentheses indicate holding time in days

Project Name:	100 MAIN ST.	**Lab Number:**	L2331480
Project Number:	12461	**Report Date:**	06/16/23

GLOSSARY

Acronyms

DL	- Detection Limit: This value represents the level to which target analyte concentrations are reported as estimated values, when those target analyte concentrations are quantified below the limit of quantitation (LOQ). The DL includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.)
EDL	- Estimated Detection Limit: This value represents the level to which target analyte concentrations are reported as estimated values, when those target analyte concentrations are quantified below the reporting limit (RL). The EDL includes any adjustments from dilutions, concentrations or moisture content, where applicable. The use of EDLs is specific to the analysis of PAHs using Solid-Phase Microextraction (SPME).
EMPC	- Estimated Maximum Possible Concentration: The concentration that results from the signal present at the retention time of an analyte when the ions meet all of the identification criteria except the ion abundance ratio criteria. An EMPC is a worst-case estimate of the concentration.
EPA	- Environmental Protection Agency.
LCS	- Laboratory Control Sample: A sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes or a material containing known and verified amounts of analytes.
LCSD	- Laboratory Control Sample Duplicate: Refer to LCS.
LFB	- Laboratory Fortified Blank: A sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes or a material containing known and verified amounts of analytes.
LOD	- Limit of Detection: This value represents the level to which a target analyte can reliably be detected for a specific analyte in a specific matrix by a specific method. The LOD includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.)
LOQ	- Limit of Quantitation: The value at which an instrument can accurately measure an analyte at a specific concentration. The LOQ includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.) Limit of Quantitation: The value at which an instrument can accurately measure an analyte at a specific concentration. The LOQ includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.)
MDL	- Method Detection Limit: This value represents the level to which target analyte concentrations are reported as estimated values, when those target analyte concentrations are quantified below the reporting limit (RL). The MDL includes any adjustments from dilutions, concentrations or moisture content, where applicable.
MS	- Matrix Spike Sample: A sample prepared by adding a known mass of target analyte to a specified amount of matrix sample for which an independent estimate of target analyte concentration is available. For Method 332.0, the spike recovery is calculated using the native concentration, including estimated values.
MSD	- Matrix Spike Sample Duplicate: Refer to MS.
NA	- Not Applicable.
NC	- Not Calculated: Term is utilized when one or more of the results utilized in the calculation are non-detect at the parameter's reporting unit.
NDPA/DPA	- N-Nitrosodiphenylamine/Diphenylamine.
NI	- Not Ignitable.
NP	- Non-Plastic: Term is utilized for the analysis of Atterberg Limits in soil.
NR	- No Results: Term is utilized when 'No Target Compounds Requested' is reported for the analysis of Volatile or Semivolatile Organic TIC only requests.
RL	- Reporting Limit: The value at which an instrument can accurately measure an analyte at a specific concentration. The RL includes any adjustments from dilutions, concentrations or moisture content, where applicable.
RPD	- Relative Percent Difference: The results from matrix and/or matrix spike duplicates are primarily designed to assess the precision of analytical results in a given matrix and are expressed as relative percent difference (RPD). Values which are less than five times the reporting limit for any individual parameter are evaluated by utilizing the absolute difference between the values; although the RPD value will be provided in the report.
SRM	- Standard Reference Material: A reference sample of a known or certified value that is of the same or similar matrix as the associated field samples.
STLP	- Semi-dynamic Tank Leaching Procedure per EPA Method 1315.
TEF	- Toxic Equivalency Factors: The values assigned to each dioxin and furan to evaluate their toxicity relative to 2,3,7,8-TCDD.
TEQ	- Toxic Equivalent: The measure of a sample's toxicity derived by multiplying each dioxin and furan by its corresponding TEF and then summing the resulting values.
TIC	- Tentatively Identified Compound: A compound that has been identified to be present and is not part of the target compound list (TCL) for the method and/or program. All TICs are qualitatively identified and reported as estimated concentrations.

Report Format: DU Report with 'J' Qualifiers

Project Name:	100 MAIN ST.	**Lab Number:**	L2331480
Project Number:	12461	**Report Date:**	06/16/23

Footnotes

1 - The reference for this analyte should be considered modified since this analyte is absent from the target analyte list of the original method.

Terms

Analytical Method: Both the document from which the method originates and the analytical reference method. (Example: EPA 8260B is shown as 1,8260B.) The codes for the reference method documents are provided in the References section of the Addendum.

Chlordane: The target compound Chlordane (CAS No. 57-74-9) is reported for GC ECD analyses. Per EPA,this compound "refers to a mixture of chlordane isomers, other chlorinated hydrocarbons and numerous other components." (Reference: USEPA Toxicological Review of Chlordane, In Support of Summary Information on the Integrated Risk Information System (IRIS), December 1997.)

Difference: With respect to Total Oxidizable Precursor (TOP) Assay analysis, the difference is defined as the Post-Treatment value minus the Pre-Treatment value.

Final pH: As it pertains to Sample Receipt & Container Information section of the report, Final pH reflects pH of container determined after adjustment at the laboratory, if applicable. If no adjustment required, value reflects Initial pH.

Frozen Date/Time: With respect to Volatile Organics in soil, Frozen Date/Time reflects the date/time at which associated Reagent Water-preserved vials were initially frozen. Note: If frozen date/time is beyond 48 hours from sample collection, value will be reflected in 'bold'.

Gasoline Range Organics (GRO): Gasoline Range Organics (GRO) results include all chromatographic peaks eluting from Methyl tert butyl ether through Naphthalene, with the exception of GRO analysis in support of State of Ohio programs, which includes all chromatographic peaks eluting from Hexane through Dodecane.

Initial pH: As it pertains to Sample Receipt & Container Information section of the report, Initial pH reflects pH of container determined upon receipt, if applicable.

PAH Total: With respect to Alkylated PAH analyses, the 'PAHs, Total' result is defined as the summation of results for all or a subset of the following compounds: Naphthalene, C1-C4 Naphthalenes, 2-Methylnaphthalene, 1-Methylnaphthalene, Biphenyl, Acenaphthylene, Acenaphthene, Fluorene, C1-C3 Fluorenes, Phenanthrene, C1-C4 Phenanthrenes/Anthracenes, Anthracene, Fluoranthene, Pyrene, C1-C4 Fluoranthenes/Pyrenes, Benz(a)anthracene, Chrysene, C1-C4 Chrysenes, Benzo(b)fluoranthene, Benzo(j)+(k)fluoranthene, Benzo(e)pyrene, Benzo(a)pyrene, Perylene, Indeno(1,2,3-cd)pyrene, Dibenz(ah)+(ac)anthracene, Benzo(g,h,i)perylene. If a 'Total' result is requested, the results of its individual components will also be reported.

PFAS Total: With respect to PFAS analyses, the 'PFAS, Total (5)' result is defined as the summation of results for: PFHpA, PFHxS, PFOA, PFNA and PFOS. In addition, the 'PFAS, Total (6)' result is defined as the summation of results for: PFHpA, PFHxS, PFOA, PFNA, PFDA and PFOS. For MassDEP DW compliance analysis only, the 'PFAS, Total (6)' result is defined as the summation of results at or above the RL. Note: If a 'Total' result is requested, the results of its individual components will also be reported.

Total: With respect to Organic analyses, a 'Total' result is defined as the summation of results for individual isomers or Aroclors. If a 'Total' result is requested, the results of its individual components will also be reported. This is applicable to 'Total' results for methods 8260, 8081 and 8082.

Data Qualifiers

A - Spectra identified as "Aldol Condensates" are byproducts of the extraction/concentration procedures when acetone is introduced in the process.

B - The analyte was detected above the reporting limit in the associated method blank. Flag only applies to associated field samples that have detectable concentrations of the analyte at less than ten times (10x) the concentration found in the blank. For MCP-related projects, flag only applies to associated field samples that have detectable concentrations of the analyte at less than ten times (10x) the concentration found in the blank. For DOD-related projects, flag only applies to associated field samples that have detectable concentrations of the analyte at less than ten times (10x) the concentration found in the blank AND the analyte was detected above one-half the reporting limit (or above the reporting limit for common lab contaminants) in the associated method blank. For NJ-Air-related projects, flag only applies to associated field samples that have detectable concentrations of the analyte above the reporting limit. For NJ-related projects (excluding Air), flag only applies to associated field samples that have detectable concentrations of the analyte, which was detected above the reporting limit in the associated method blank or above five times the reporting limit for common lab contaminants (Phthalates, Acetone, Methylene Chloride, 2-Butanone).

C - Co-elution: The target analyte co-elutes with a known lab standard (i.e. surrogate, internal standards, etc.) for co-extracted analyses.

D - Concentration of analyte was quantified from diluted analysis. Flag only applies to field samples that have detectable concentrations of the analyte.

E - Concentration of analyte exceeds the range of the calibration curve and/or linear range of the instrument.

F - The ratio of quantifier ion response to qualifier ion response falls outside of the laboratory criteria. Results are considered to be an estimated maximum concentration.

G - The concentration may be biased high due to matrix interferences (i.e, co-elution) with non-target compound(s). The result should be considered estimated.

H - The analysis of pH was performed beyond the regulatory-required holding time of 15 minutes from the time of sample collection.

I - The lower value for the two columns has been reported due to obvious interference.

J - Estimated value. The Target analyte concentration is below the quantitation limit (RL), but above the Method Detection Limit (MDL) or Estimated Detection Limit (EDL) for SPME-related analyses. This represents an estimated concentration for Tentatively

Report Format: DU Report with 'J' Qualifiers

Project Name:	100 MAIN ST.	**Lab Number:**	L2331480
Project Number:	12461	**Report Date:**	06/16/23

Data Qualifiers

Identified Compounds (TICs).

M - Reporting Limit (RL) exceeds the MCP CAM Reporting Limit for this analyte.

ND - Not detected at the method detection limit (MDL) for the sample, or estimated detection limit (EDL) for SPME-related analyses.

NJ - Presumptive evidence of compound. This represents an estimated concentration for Tentatively Identified Compounds (TICs), where the identification is based on a mass spectral library search.

P - The RPD between the results for the two columns exceeds the method-specified criteria.

Q - The quality control sample exceeds the associated acceptance criteria. For DOD-related projects, LCS and/or Continuing Calibration Standard exceedences are also qualified on all associated sample results. Note: This flag is not applicable for matrix spike recoveries when the sample concentration is greater than 4x the spike added or for batch duplicate RPD when the sample concentrations are less than 5x the RL. (Metals only.)

R - Analytical results are from sample re-analysis.

RE - Analytical results are from sample re-extraction.

S - Analytical results are from modified screening analysis.

V - The surrogate associated with this target analyte has a recovery outside the QC acceptance limits. (Applicable to MassDEP DW Compliance samples only.)

Z - The batch matrix spike and/or duplicate associated with this target analyte has a recovery/RPD outside the QC acceptance limits. (Applicable to MassDEP DW Compliance samples only.)

Project Name: 100 MAIN ST. **Lab Number:** L2331480

Project Number: 12461 **Report Date:** 06/16/23

REFERENCES

1 Test Methods for Evaluating Solid Waste: Physical/Chemical Methods. EPA SW-846. Third Edition. Updates I - VI, 2018.

121 Standard Methods for the Examination of Water and Wastewater. APHA-AWWA-WEF. Standard Methods Online.

LIMITATION OF LIABILITIES

Alpha Analytical performs services with reasonable care and diligence normal to the analytical testing laboratory industry. In the event of an error, the sole and exclusive responsibility of Alpha Analytical shall be to re-perform the work at it's own expense. In no event shall Alpha Analytical be held liable for any incidental, consequential or special damages, including but not limited to, damages in any way connected with the use of, interpretation of, information or analysis provided by Alpha Analytical.

We strongly urge our clients to comply with EPA protocol regarding sample volume, preservation, cooling, containers, sampling procedures, holding time and splitting of samples in the field.

Certification Information

The following analytes are not included in our Primary NELAP Scope of Accreditation:

Westborough Facility
EPA 624/624.1: m/p-xylene, o-xylene, Naphthalene
EPA 625/625.1: alpha-Terpineol
EPA 8260C/8260D: NPW: 1,2,4,5-Tetramethylbenzene; 4-Ethyltoluene, Azobenzene; SCM: Iodomethane (methyl iodide), 1,2,4,5-Tetramethylbenzene; 4-Ethyltoluene.
EPA 8270D/8270E: NPW: Dimethylnaphthalene,1,4-Diphenylhydrazine, alpha-Terpineol; SCM: Dimethylnaphthalene,1,4-Diphenylhydrazine.
SM4500: NPW: Amenable Cyanide; SCM: Total Phosphorus, TKN, NO2, NO3.

Mansfield Facility
SM 2540D: TSS
EPA 8082A: NPW: PCB: 1, 5, 31, 87,101, 110, 141, 151, 153, 180, 183, 187.
EPA TO-15: Halothane, 2,4,4-Trimethyl-2-pentene, 2,4,4-Trimethyl-1-pentene, Thiophene, 2-Methylthiophene, 3-Methylthiophene, 2-Ethylthiophene, 1,2,3-Trimethylbenzene, Indan, Indene, 1,2,4,5-Tetramethylbenzene, Benzothiophene, 1-Methylnaphthalene.
Biological Tissue Matrix: EPA 3050B

The following analytes are included in our Massachusetts DEP Scope of Accreditation

Westborough Facility:

Drinking Water
EPA 300.0: Chloride, Nitrate-N, Fluoride, Sulfate; **EPA 353.2**: Nitrate-N, Nitrite-N; **SM4500NO3-F**: Nitrate-N, Nitrite-N; **SM4500F-C, SM4500CN-CE, EPA 180.1, SM2130B, SM4500Cl-D, SM2320B, SM2540C, SM4500H-B, SM4500NO2-B**
EPA 332: Perchlorate; **EPA 524.2:** THMs and VOCs; **EPA 504.1:** EDB, DBCP.
Microbiology: **SM9215B; SM9223-P/A, SM9223B-Colilert-QT,SM9222D**.

Non-Potable Water
SM4500H,B, EPA 120.1, SM2510B, SM2540C, SM2320B, SM4500CL-E, SM4500F-BC, SM4500NH3-BH: Ammonia-N and Kjeldahl-N, **EPA 350.1**: Ammonia-N, **LACHAT 10-107-06-1-B**: Ammonia-N, **EPA 351.1, SM4500NO3-F, EPA 353.2**: Nitrate-N, **SM4500P-E, SM4500P-B, E, SM4500SO4-E, SM5220D, EPA 410.4, SM5210B, SM5310C, SM4500CL-D, EPA 1664, EPA 420.1, SM4500-CN-CE, SM2540D, EPA 300: Chloride, Sulfate, Nitrate.**
EPA 624.1: Volatile Halocarbons & Aromatics,
EPA 608.3: Chlordane, Toxaphene, Aldrin, alpha-BHC, beta-BHC, gamma-BHC, delta-BHC, Dieldrin, DDD, DDE, DDT, Endosulfan I, Endosulfan II, Endosulfan sulfate, Endrin, Endrin Aldehyde, Heptachlor, Heptachlor Epoxide, PCBs
EPA 625.1: SVOC (Acid/Base/Neutral Extractables), **EPA 600/4-81-045**: PCB-Oil.
Microbiology: **SM9223B-Colilert-QT; Enterolert-QT, SM9221E, EPA 1600, EPA 1603, SM9222D.**

Mansfield Facility:

Drinking Water
EPA 200.7: Al, Ba, Cd, Cr, Cu, Fe, Mn, Ni, Na, Ag, Ca, Zn. **EPA 200.8:** Al, Sb, As, Ba, Be, Cd, Cr, Cu, Pb, Mn, Ni, Se, Ag, TL, Zn. **EPA 245.1** Hg.
EPA 522, EPA 537.1.

Non-Potable Water
EPA 200.7: Al, Sb, As, Be, Cd, Ca, Cr, Co, Cu, Fe, Pb, Mg, Mn, Mo, Ni, K, Se, Ag, Na, Sr, TL, Ti, V, Zn.
EPA 200.8: Al, Sb, As, Be, Cd, Cr, Cu, Fe, Pb, Mn, Ni, K, Se, Ag, Na, TL, Zn.
EPA 245.1 Hg.
SM2340B

For a complete listing of analytes and methods, please contact your Alpha Project Manager.

NEW YORK CHAIN OF CUSTODY

ALPHA ANALYTICAL

Westborough, MA 01581
8 Walkup Dr.
TEL: 508-898-9220
FAX: 508-898-9193

Mansfield, MA 02048
320 Forbes Blvd
TEL: 508-822-9300
FAX: 508-822-3288

Service Centers
Mahwah, NJ 07430: 35 Whitney Rd, Suite 5
Albany, NY 12205: 14 Walker Way
Tonawanda, NY 14150: 275 Cooper Ave, Suite 105

Page 1 of 1

Date Rec'd in Lab: 6/6/23

ALPHA Job #: L2331480

Client Information

Client: SESI
Address: 959 US 46 Fl 3 S300
Parsippany NJ 07054
Phone: 973 808 9050
Fax:
Email: JCS@sesi.org

Project Information

Project Name: 100 Main St
Project Location: White Plains NY
Project #: 12461
(Use Project name as Project #) ☐
Project Manager: Jon Stuart
ALPHAQuote #:

Turn-Around Time

Standard ☐ Due Date:
Rush (only if pre approved) ☐ # of Days:

Deliverables

☐ ASP-A ☑ ASP-B
☐ EQuIS (1 File) ☐ EQuIS (4 File)
☐ Other

Billing Information

☐ Same as Client Info
PO # Renaissance Env. Mgmt.
Attn: Kevin McNamus

Regulatory Requirement

☐ NY TOGS ☐ NY Part 375
☑ AWQ Standards ☐ NY CP-51
☐ NY Restricted Use ☐ Other
☑ NY Unrestricted Use
☐ NYC Sewer Discharge

Disposal Site Information

Please identify below location of applicable disposal facilities.

Disposal Facility:
☐ NJ ☐ NY
☐ Other:

These samples have been previously analyzed by Alpha ☐

Other project specific requirements/comments:

Please specify Metals or TAL.

ANALYSIS

TCL+30TAL

Sample Filtration
☐ Done
☐ Lab to do
Preservation
☐ Lab to do
(Please Specify below)

Total Bottle

ALPHA Lab ID (Lab Use Only)	Sample ID	Collection Date	Collection Time	Sample Matrix	Sampler's Initials	Sample Specific Comments
31480-01	SB-285 (7-7.5)	6/6/23	930	S	CB	
02	SB-295 (1-1.5)		1015	S	CB	
03	SB-305 (7-7.5)		1030	S	CB	
04	SB-305 (1.5-2)		1040	S	CB	
05	SB-315 (0.5-1)		1055	S	CB	
06	GW-17		9:50	GW	CB	
07	GW-13		11:20	GW	CB	
08	SB-325 (3-3.5)		12:15	S	CB	

Container Type: CP
Preservative: some

Preservative Code:
A = None
B = HCl
C = HNO_3
D = H_2SO_4
E = NaOH
F = MeOH
G = $NaHSO_4$
H = $Na_2S_2O_3$
K/E = Zn Ac/NaOH
O = Other

Container Code
P = Plastic
A = Amber Glass
V = Vial
G = Glass
B = Bacteria Cup
C = Cube
O = Other
E = Encore
D = BOD Bottle

Westboro: Certification No: MA935
Mansfield: Certification No: MA015

Relinquished By:	Date/Time	Received By:	Date/Time
	6/6/23 13:50		6/6/23 13:52
	6/6/23 17:20		6/6/23 18:30
	6/6/23		6/6/23 21:30
	6/6/23 23:15		6/6/23 23:15

Please print clearly, legibly and completely. Samples can not be logged in and turnaround time clock will not start until any ambiguities are resolved. BY EXECUTING THIS COC, THE CLIENT HAS READ AND AGREES TO BE BOUND BY ALPHA'S TERMS & CONDITIONS. (See reverse side.)

Form No: 01-25 HC (rev. 30-Sept-2013)

ANALYTICAL REPORT

Lab Number:	L2331827
Client:	Soils Engineering Services, Inc. 959 Route 46E Parsippany, NJ 07054
ATTN:	Steven Gustems
Phone:	(973) 808-9050
Project Name:	100 MAIN ST.
Project Number:	12461
Report Date:	06/16/23

The original project report/data package is held by Alpha Analytical. This report/data package is paginated and should be reproduced only in its entirety. Alpha Analytical holds no responsibility for results and/or data that are not consistent with the original.

Certifications & Approvals: MA (M-MA086), NH NELAP (2064), CT (PH-0826), IL (200077), IN (C-MA-03), KY (KY98045), ME (MA00086), MD (348), NJ (MA935), NY (11148), NC (25700/666), OH (CL108), OR (MA-1316), PA (68-03671), RI (LAO00065), TX (T104704476), VT (VT-0935), VA (460195), USDA (Permit #525-23-122-91930).

Eight Walkup Drive, Westborough, MA 01581-1019
508-898-9220 (Fax) 508-898-9193 800-624-9220 - www.alphalab.com

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331827
Report Date: 06/16/23

Alpha Sample ID	Client ID	Matrix	Sample Location	Collection Date/Time	Receive Date
L2331827-01	SB-39 (0.5-1)	SOIL	WHITE PLAINS, NY	06/07/23 09:05	06/07/23
L2331827-02	SB-40 (1-1.5)	SOIL	WHITE PLAINS, NY	06/07/23 10:05	06/07/23
L2331827-03	SB-41 (2.5-3)	SOIL	WHITE PLAINS, NY	06/07/23 10:20	06/07/23
L2331827-04	SB-42 (2-2.5)	SOIL	WHITE PLAINS, NY	06/07/23 10:50	06/07/23
L2331827-05	SB-43 (5-5.5)	SOIL	WHITE PLAINS, NY	06/07/23 11:30	06/07/23
L2331827-06	GW-14	WATER	WHITE PLAINS, NY	06/07/23 09:20	06/07/23
L2331827-07	GW-15	WATER	WHITE PLAINS, NY	06/07/23 11:45	06/07/23
L2331827-08	SB-26G (1.5-2)	SOIL	WHITE PLAINS, NY	06/07/23 12:45	06/07/23

Project Name:	100 MAIN ST.	**Lab Number:**	L2331827
Project Number:	12461	**Report Date:**	06/16/23

Case Narrative

The samples were received in accordance with the Chain of Custody and no significant deviations were encountered during the preparation or analysis unless otherwise noted. Sample Receipt, Container Information, and the Chain of Custody are located at the back of the report.

Results contained within this report relate only to the samples submitted under this Alpha Lab Number and meet NELAP requirements for all NELAP accredited parameters unless otherwise noted in the following narrative. The data presented in this report is organized by parameter (i.e. VOC, SVOC, etc.). Sample specific Quality Control data (i.e. Surrogate Spike Recovery) is reported at the end of the target analyte list for each individual sample, followed by the Laboratory Batch Quality Control at the end of each parameter. Tentatively Identified Compounds (TICs), if requested, are reported for compounds identified to be present and are not part of the method/program Target Compound List, even if only a subset of the TCL are being reported. If a sample was re-analyzed or re-extracted due to a required quality control corrective action and if both sets of data are reported, the Laboratory ID of the re-analysis or re-extraction is designated with an "R" or "RE", respectively.

When multiple Batch Quality Control elements are reported (e.g. more than one LCS), the associated samples for each element are noted in the grey shaded header line of each data table. Any Laboratory Batch, Sample Specific % recovery or RPD value that is outside the listed Acceptance Criteria is bolded in the report. In reference to questions H (CAM) or 4 (RCP) when "NO" is checked, the performance criteria for CAM and RCP methods allow for some quality control failures to occur and still be within method compliance. In these instances, the specific failure is not narrated but noted in the associated QC Outlier Summary Report, located directly after the Case Narrative. QC information is also incorporated in the Data Usability Assessment table (Format 11) of our Data Merger tool, where it can be reviewed in conjunction with the sample result, associated regulatory criteria and any associated data usability implications.

Soil/sediments, solids and tissues are reported on a dry weight basis unless otherwise noted. Definitions of all data qualifiers and acronyms used in this report are provided in the Glossary located at the back of the report.

HOLD POLICY - For samples submitted on hold, Alpha's policy is to hold samples (with the exception of Air canisters) free of charge for 21 calendar days from the date the project is completed. After 21 calendar days, we will dispose of all samples submitted including those put on hold unless you have contacted your Alpha Project Manager and made arrangements for Alpha to continue to hold the samples. Air canisters will be disposed after 3 business days from the date the project is completed.

Please contact Project Management at 800-624-9220 with any questions.

Project Name: 100 MAIN ST. **Lab Number:** L2331827
Project Number: 12461 **Report Date:** 06/16/23

Case Narrative (continued)

Report Submission

All non-detect (ND) or estimated concentrations (J-qualified) have been quantitated to the limit noted in the MDL column.

Semivolatile Organics

L2331827-01: The surrogate recoveries were outside the acceptance criteria for 2-fluorophenol (14%) and 2,4,6-tribromophenol (3%); however, re-extraction achieved similar results: 2-fluorophenol (9%) and 2,4,6-tribromophenol (3%). The results of both extractions are reported; however, all associated compounds are considered to have a potential bias.

The WG1788928-2 LCS recoveries, associated with L2331827-02 through -05 and -08, are below the acceptance criteria for 2,4-dinitrophenol (0%) and 4,6-dinitro-o-cresol (3%); however, they have been identified as "difficult" analytes. The results of the associated samples are reported.

Total Metals

L2331827-01 through -05 and -08: The sample has elevated detection limits for all elements, with the exception of mercury, due to the dilution required by the sample matrix.

Cyanide, Total

L2331827-06: The pH was greater than two; however, the sample was analyzed within the method required holding time.

The WG1789595-3 LCSD recovery for cyanide, total (78%), associated with L2331827-01 through -05 and -08, is outside our in-house acceptance criteria, but within the vendor-certified acceptance limits. The results of the original analyses are reported.

I, the undersigned, attest under the pains and penalties of perjury that, to the best of my knowledge and belief and based upon my personal inquiry of those responsible for providing the information contained in this analytical report, such information is accurate and complete. This certificate of analysis is not complete unless this page accompanies any and all pages of this report.

Authorized Signature: Cristin Walker

Title: Technical Director/Representative Date: 06/16/23

ORGANICS

VOLATILES

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331827
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-01
Client ID: SB-39 (0.5-1)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/07/23 09:05
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8260D
Analytical Date: 06/09/23 14:28
Analyst: JIC
Percent Solids: 94%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Methylene chloride	ND		ug/kg	5.4	2.5	1
1,1-Dichloroethane	ND		ug/kg	1.1	0.16	1
Chloroform	0.33	J	ug/kg	1.6	0.15	1
Carbon tetrachloride	ND		ug/kg	1.1	0.25	1
1,2-Dichloropropane	ND		ug/kg	1.1	0.14	1
Dibromochloromethane	ND		ug/kg	1.1	0.15	1
1,1,2-Trichloroethane	ND		ug/kg	1.1	0.29	1
Tetrachloroethene	ND		ug/kg	0.54	0.21	1
Chlorobenzene	ND		ug/kg	0.54	0.14	1
Trichlorofluoromethane	ND		ug/kg	4.4	0.76	1
1,2-Dichloroethane	ND		ug/kg	1.1	0.28	1
1,1,1-Trichloroethane	ND		ug/kg	0.54	0.18	1
Bromodichloromethane	ND		ug/kg	0.54	0.12	1
trans-1,3-Dichloropropene	ND		ug/kg	1.1	0.30	1
cis-1,3-Dichloropropene	ND		ug/kg	0.54	0.17	1
1,3-Dichloropropene, Total	ND		ug/kg	0.54	0.17	1
1,1-Dichloropropene	ND		ug/kg	0.54	0.17	1
Bromoform	ND		ug/kg	4.4	0.27	1
1,1,2,2-Tetrachloroethane	ND		ug/kg	0.54	0.18	1
Benzene	ND		ug/kg	0.54	0.18	1
Toluene	ND		ug/kg	1.1	0.59	1
Ethylbenzene	ND		ug/kg	1.1	0.15	1
Chloromethane	ND		ug/kg	4.4	1.0	1
Bromomethane	ND		ug/kg	2.2	0.63	1
Vinyl chloride	ND		ug/kg	1.1	0.36	1
Chloroethane	ND		ug/kg	2.2	0.49	1
1,1-Dichloroethene	ND		ug/kg	1.1	0.26	1
trans-1,2-Dichloroethene	ND		ug/kg	1.6	0.15	1

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-01 Date Collected: 06/07/23 09:05

Client ID: SB-39 (0.5-1) Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Trichloroethene	ND		ug/kg	0.54	0.15	1
1,2-Dichlorobenzene	ND		ug/kg	2.2	0.16	1
1,3-Dichlorobenzene	ND		ug/kg	2.2	0.16	1
1,4-Dichlorobenzene	ND		ug/kg	2.2	0.19	1
Methyl tert butyl ether	ND		ug/kg	2.2	0.22	1
p/m-Xylene	ND		ug/kg	2.2	0.61	1
o-Xylene	ND		ug/kg	1.1	0.32	1
Xylenes, Total	ND		ug/kg	1.1	0.32	1
cis-1,2-Dichloroethene	ND		ug/kg	1.1	0.19	1
1,2-Dichloroethene, Total	ND		ug/kg	1.1	0.15	1
Dibromomethane	ND		ug/kg	2.2	0.26	1
Styrene	ND		ug/kg	1.1	0.21	1
Dichlorodifluoromethane	ND		ug/kg	11	1.0	1
Acetone	ND		ug/kg	11	5.2	1
Carbon disulfide	ND		ug/kg	11	5.0	1
2-Butanone	ND		ug/kg	11	2.4	1
Vinyl acetate	ND		ug/kg	11	2.3	1
4-Methyl-2-pentanone	ND		ug/kg	11	1.4	1
1,2,3-Trichloropropane	ND		ug/kg	2.2	0.14	1
2-Hexanone	ND		ug/kg	11	1.3	1
Bromochloromethane	ND		ug/kg	2.2	0.22	1
2,2-Dichloropropane	ND		ug/kg	2.2	0.22	1
1,2-Dibromoethane	ND		ug/kg	1.1	0.30	1
1,3-Dichloropropane	ND		ug/kg	2.2	0.18	1
1,1,1,2-Tetrachloroethane	ND		ug/kg	0.54	0.14	1
Bromobenzene	ND		ug/kg	2.2	0.16	1
n-Butylbenzene	ND		ug/kg	1.1	0.18	1
sec-Butylbenzene	ND		ug/kg	1.1	0.16	1
tert-Butylbenzene	ND		ug/kg	2.2	0.13	1
o-Chlorotoluene	ND		ug/kg	2.2	0.21	1
p-Chlorotoluene	ND		ug/kg	2.2	0.12	1
1,2-Dibromo-3-chloropropane	ND		ug/kg	3.3	1.1	1
Hexachlorobutadiene	ND		ug/kg	4.4	0.18	1
Isopropylbenzene	ND		ug/kg	1.1	0.12	1
p-Isopropyltoluene	ND		ug/kg	1.1	0.12	1
Naphthalene	ND		ug/kg	4.4	0.71	1
Acrylonitrile	ND		ug/kg	4.4	1.2	1

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-01 Date Collected: 06/07/23 09:05

Client ID: SB-39 (0.5-1) Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
n-Propylbenzene	ND		ug/kg	1.1	0.19	1
1,2,3-Trichlorobenzene	ND		ug/kg	2.2	0.35	1
1,2,4-Trichlorobenzene	ND		ug/kg	2.2	0.30	1
1,3,5-Trimethylbenzene	ND		ug/kg	2.2	0.21	1
1,2,4-Trimethylbenzene	ND		ug/kg	2.2	0.36	1
1,4-Dioxane	ND		ug/kg	87	38.	1
p-Diethylbenzene	ND		ug/kg	2.2	0.19	1
p-Ethyltoluene	ND		ug/kg	2.2	0.42	1
1,2,4,5-Tetramethylbenzene	ND		ug/kg	2.2	0.21	1
Ethyl ether	ND		ug/kg	2.2	0.37	1
trans-1,4-Dichloro-2-butene	ND		ug/kg	5.4	1.5	1
Tentatively Identified Compounds						
No Tentatively Identified Compounds	ND		ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	100		70-130
Toluene-d8	99		70-130
4-Bromofluorobenzene	101		70-130
Dibromofluoromethane	108		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-02
Client ID: SB-40 (1-1.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/07/23 10:05
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8260D
Analytical Date: 06/09/23 14:54
Analyst: JIC
Percent Solids: 93%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Methylene chloride	ND		ug/kg	5.9	2.7	1
1,1-Dichloroethane	ND		ug/kg	1.2	0.17	1
Chloroform	ND		ug/kg	1.8	0.16	1
Carbon tetrachloride	ND		ug/kg	1.2	0.27	1
1,2-Dichloropropane	ND		ug/kg	1.2	0.15	1
Dibromochloromethane	ND		ug/kg	1.2	0.16	1
1,1,2-Trichloroethane	ND		ug/kg	1.2	0.31	1
Tetrachloroethene	ND		ug/kg	0.59	0.23	1
Chlorobenzene	ND		ug/kg	0.59	0.15	1
Trichlorofluoromethane	ND		ug/kg	4.7	0.82	1
1,2-Dichloroethane	ND		ug/kg	1.2	0.30	1
1,1,1-Trichloroethane	ND		ug/kg	0.59	0.20	1
Bromodichloromethane	ND		ug/kg	0.59	0.13	1
trans-1,3-Dichloropropene	ND		ug/kg	1.2	0.32	1
cis-1,3-Dichloropropene	ND		ug/kg	0.59	0.18	1
1,3-Dichloropropene, Total	ND		ug/kg	0.59	0.18	1
1,1-Dichloropropene	ND		ug/kg	0.59	0.19	1
Bromoform	ND		ug/kg	4.7	0.29	1
1,1,2,2-Tetrachloroethane	ND		ug/kg	0.59	0.20	1
Benzene	ND		ug/kg	0.59	0.20	1
Toluene	ND		ug/kg	1.2	0.64	1
Ethylbenzene	ND		ug/kg	1.2	0.16	1
Chloromethane	ND		ug/kg	4.7	1.1	1
Bromomethane	ND		ug/kg	2.4	0.68	1
Vinyl chloride	ND		ug/kg	1.2	0.39	1
Chloroethane	ND		ug/kg	2.4	0.53	1
1,1-Dichloroethene	ND		ug/kg	1.2	0.28	1
trans-1,2-Dichloroethene	ND		ug/kg	1.8	0.16	1

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-02 Date Collected: 06/07/23 10:05

Client ID: SB-40 (1-1.5) Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Trichloroethene	ND		ug/kg	0.59	0.16	1
1,2-Dichlorobenzene	ND		ug/kg	2.4	0.17	1
1,3-Dichlorobenzene	ND		ug/kg	2.4	0.17	1
1,4-Dichlorobenzene	ND		ug/kg	2.4	0.20	1
Methyl tert butyl ether	ND		ug/kg	2.4	0.24	1
p/m-Xylene	ND		ug/kg	2.4	0.66	1
o-Xylene	ND		ug/kg	1.2	0.34	1
Xylenes, Total	ND		ug/kg	1.2	0.34	1
cis-1,2-Dichloroethene	ND		ug/kg	1.2	0.20	1
1,2-Dichloroethene, Total	ND		ug/kg	1.2	0.16	1
Dibromomethane	ND		ug/kg	2.4	0.28	1
Styrene	ND		ug/kg	1.2	0.23	1
Dichlorodifluoromethane	ND		ug/kg	12	1.1	1
Acetone	ND		ug/kg	12	5.6	1
Carbon disulfide	ND		ug/kg	12	5.4	1
2-Butanone	ND		ug/kg	12	2.6	1
Vinyl acetate	ND		ug/kg	12	2.5	1
4-Methyl-2-pentanone	ND		ug/kg	12	1.5	1
1,2,3-Trichloropropane	ND		ug/kg	2.4	0.15	1
2-Hexanone	ND		ug/kg	12	1.4	1
Bromochloromethane	ND		ug/kg	2.4	0.24	1
2,2-Dichloropropane	ND		ug/kg	2.4	0.24	1
1,2-Dibromoethane	ND		ug/kg	1.2	0.33	1
1,3-Dichloropropane	ND		ug/kg	2.4	0.20	1
1,1,1,2-Tetrachloroethane	ND		ug/kg	0.59	0.16	1
Bromobenzene	ND		ug/kg	2.4	0.17	1
n-Butylbenzene	ND		ug/kg	1.2	0.20	1
sec-Butylbenzene	ND		ug/kg	1.2	0.17	1
tert-Butylbenzene	ND		ug/kg	2.4	0.14	1
o-Chlorotoluene	ND		ug/kg	2.4	0.22	1
p-Chlorotoluene	ND		ug/kg	2.4	0.13	1
1,2-Dibromo-3-chloropropane	ND		ug/kg	3.5	1.2	1
Hexachlorobutadiene	ND		ug/kg	4.7	0.20	1
Isopropylbenzene	ND		ug/kg	1.2	0.13	1
p-Isopropyltoluene	ND		ug/kg	1.2	0.13	1
Naphthalene	ND		ug/kg	4.7	0.76	1
Acrylonitrile	ND		ug/kg	4.7	1.4	1

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-02 Date Collected: 06/07/23 10:05

Client ID: SB-40 (1-1.5) Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
n-Propylbenzene	ND		ug/kg	1.2	0.20	1
1,2,3-Trichlorobenzene	ND		ug/kg	2.4	0.38	1
1,2,4-Trichlorobenzene	ND		ug/kg	2.4	0.32	1
1,3,5-Trimethylbenzene	ND		ug/kg	2.4	0.23	1
1,2,4-Trimethylbenzene	ND		ug/kg	2.4	0.39	1
1,4-Dioxane	ND		ug/kg	94	41.	1
p-Diethylbenzene	ND		ug/kg	2.4	0.21	1
p-Ethyltoluene	ND		ug/kg	2.4	0.45	1
1,2,4,5-Tetramethylbenzene	ND		ug/kg	2.4	0.22	1
Ethyl ether	ND		ug/kg	2.4	0.40	1
trans-1,4-Dichloro-2-butene	ND		ug/kg	5.9	1.7	1
Tentatively Identified Compounds						
No Tentatively Identified Compounds	ND		ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	99		70-130
Toluene-d8	100		70-130
4-Bromofluorobenzene	103		70-130
Dibromofluoromethane	106		70-130

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331827
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-03
Client ID: SB-41 (2.5-3)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/07/23 10:20
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8260D
Analytical Date: 06/09/23 15:20
Analyst: JIC
Percent Solids: 94%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Methylene chloride	ND		ug/kg	5.6	2.5	1
1,1-Dichloroethane	ND		ug/kg	1.1	0.16	1
Chloroform	ND		ug/kg	1.7	0.16	1
Carbon tetrachloride	ND		ug/kg	1.1	0.26	1
1,2-Dichloropropane	ND		ug/kg	1.1	0.14	1
Dibromochloromethane	ND		ug/kg	1.1	0.16	1
1,1,2-Trichloroethane	ND		ug/kg	1.1	0.30	1
Tetrachloroethene	ND		ug/kg	0.56	0.22	1
Chlorobenzene	ND		ug/kg	0.56	0.14	1
Trichlorofluoromethane	ND		ug/kg	4.4	0.77	1
1,2-Dichloroethane	ND		ug/kg	1.1	0.28	1
1,1,1-Trichloroethane	ND		ug/kg	0.56	0.18	1
Bromodichloromethane	ND		ug/kg	0.56	0.12	1
trans-1,3-Dichloropropene	ND		ug/kg	1.1	0.30	1
cis-1,3-Dichloropropene	ND		ug/kg	0.56	0.18	1
1,3-Dichloropropene, Total	ND		ug/kg	0.56	0.18	1
1,1-Dichloropropene	ND		ug/kg	0.56	0.18	1
Bromoform	ND		ug/kg	4.4	0.27	1
1,1,2,2-Tetrachloroethane	ND		ug/kg	0.56	0.18	1
Benzene	ND		ug/kg	0.56	0.18	1
Toluene	ND		ug/kg	1.1	0.60	1
Ethylbenzene	ND		ug/kg	1.1	0.16	1
Chloromethane	ND		ug/kg	4.4	1.0	1
Bromomethane	ND		ug/kg	2.2	0.64	1
Vinyl chloride	ND		ug/kg	1.1	0.37	1
Chloroethane	ND		ug/kg	2.2	0.50	1
1,1-Dichloroethene	ND		ug/kg	1.1	0.26	1
trans-1,2-Dichloroethene	ND		ug/kg	1.7	0.15	1

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-03 Date Collected: 06/07/23 10:20

Client ID: SB-41 (2.5-3) Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Trichloroethene	ND		ug/kg	0.56	0.15	1
1,2-Dichlorobenzene	ND		ug/kg	2.2	0.16	1
1,3-Dichlorobenzene	ND		ug/kg	2.2	0.16	1
1,4-Dichlorobenzene	ND		ug/kg	2.2	0.19	1
Methyl tert butyl ether	ND		ug/kg	2.2	0.22	1
p/m-Xylene	ND		ug/kg	2.2	0.62	1
o-Xylene	ND		ug/kg	1.1	0.32	1
Xylenes, Total	ND		ug/kg	1.1	0.32	1
cis-1,2-Dichloroethene	ND		ug/kg	1.1	0.19	1
1,2-Dichloroethene, Total	ND		ug/kg	1.1	0.15	1
Dibromomethane	ND		ug/kg	2.2	0.26	1
Styrene	ND		ug/kg	1.1	0.22	1
Dichlorodifluoromethane	ND		ug/kg	11	1.0	1
Acetone	ND		ug/kg	11	5.3	1
Carbon disulfide	ND		ug/kg	11	5.0	1
2-Butanone	ND		ug/kg	11	2.5	1
Vinyl acetate	ND		ug/kg	11	2.4	1
4-Methyl-2-pentanone	ND		ug/kg	11	1.4	1
1,2,3-Trichloropropane	ND		ug/kg	2.2	0.14	1
2-Hexanone	ND		ug/kg	11	1.3	1
Bromochloromethane	ND		ug/kg	2.2	0.23	1
2,2-Dichloropropane	ND		ug/kg	2.2	0.22	1
1,2-Dibromoethane	ND		ug/kg	1.1	0.31	1
1,3-Dichloropropane	ND		ug/kg	2.2	0.18	1
1,1,1,2-Tetrachloroethane	ND		ug/kg	0.56	0.15	1
Bromobenzene	ND		ug/kg	2.2	0.16	1
n-Butylbenzene	ND		ug/kg	1.1	0.18	1
sec-Butylbenzene	ND		ug/kg	1.1	0.16	1
tert-Butylbenzene	ND		ug/kg	2.2	0.13	1
o-Chlorotoluene	ND		ug/kg	2.2	0.21	1
p-Chlorotoluene	ND		ug/kg	2.2	0.12	1
1,2-Dibromo-3-chloropropane	ND		ug/kg	3.3	1.1	1
Hexachlorobutadiene	ND		ug/kg	4.4	0.19	1
Isopropylbenzene	ND		ug/kg	1.1	0.12	1
p-Isopropyltoluene	ND		ug/kg	1.1	0.12	1
Naphthalene	ND		ug/kg	4.4	0.72	1
Acrylonitrile	ND		ug/kg	4.4	1.3	1

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-03 Date Collected: 06/07/23 10:20

Client ID: SB-41 (2.5-3) Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
n-Propylbenzene	ND		ug/kg	1.1	0.19	1
1,2,3-Trichlorobenzene	ND		ug/kg	2.2	0.36	1
1,2,4-Trichlorobenzene	ND		ug/kg	2.2	0.30	1
1,3,5-Trimethylbenzene	ND		ug/kg	2.2	0.21	1
1,2,4-Trimethylbenzene	ND		ug/kg	2.2	0.37	1
1,4-Dioxane	ND		ug/kg	89	39.	1
p-Diethylbenzene	ND		ug/kg	2.2	0.20	1
p-Ethyltoluene	ND		ug/kg	2.2	0.43	1
1,2,4,5-Tetramethylbenzene	ND		ug/kg	2.2	0.21	1
Ethyl ether	ND		ug/kg	2.2	0.38	1
trans-1,4-Dichloro-2-butene	ND		ug/kg	5.6	1.6	1
Tentatively Identified Compounds						
No Tentatively Identified Compounds	ND		ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	101		70-130
Toluene-d8	99		70-130
4-Bromofluorobenzene	104		70-130
Dibromofluoromethane	105		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-04
Client ID: SB-42 (2-2.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/07/23 10:50
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8260D
Analytical Date: 06/09/23 15:46
Analyst: JIC
Percent Solids: 93%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Methylene chloride	ND		ug/kg	5.1	2.3	1
1,1-Dichloroethane	ND		ug/kg	1.0	0.15	1
Chloroform	ND		ug/kg	1.5	0.14	1
Carbon tetrachloride	ND		ug/kg	1.0	0.23	1
1,2-Dichloropropane	ND		ug/kg	1.0	0.13	1
Dibromochloromethane	ND		ug/kg	1.0	0.14	1
1,1,2-Trichloroethane	ND		ug/kg	1.0	0.27	1
Tetrachloroethene	ND		ug/kg	0.51	0.20	1
Chlorobenzene	ND		ug/kg	0.51	0.13	1
Trichlorofluoromethane	ND		ug/kg	4.1	0.71	1
1,2-Dichloroethane	ND		ug/kg	1.0	0.26	1
1,1,1-Trichloroethane	ND		ug/kg	0.51	0.17	1
Bromodichloromethane	ND		ug/kg	0.51	0.11	1
trans-1,3-Dichloropropene	ND		ug/kg	1.0	0.28	1
cis-1,3-Dichloropropene	ND		ug/kg	0.51	0.16	1
1,3-Dichloropropene, Total	ND		ug/kg	0.51	0.16	1
1,1-Dichloropropene	ND		ug/kg	0.51	0.16	1
Bromoform	ND		ug/kg	4.1	0.25	1
1,1,2,2-Tetrachloroethane	ND		ug/kg	0.51	0.17	1
Benzene	ND		ug/kg	0.51	0.17	1
Toluene	ND		ug/kg	1.0	0.55	1
Ethylbenzene	ND		ug/kg	1.0	0.14	1
Chloromethane	ND		ug/kg	4.1	0.95	1
Bromomethane	ND		ug/kg	2.0	0.59	1
Vinyl chloride	ND		ug/kg	1.0	0.34	1
Chloroethane	ND		ug/kg	2.0	0.46	1
1,1-Dichloroethene	ND		ug/kg	1.0	0.24	1
trans-1,2-Dichloroethene	ND		ug/kg	1.5	0.14	1

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-04 Date Collected: 06/07/23 10:50

Client ID: SB-42 (2-2.5) Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Trichloroethene	ND		ug/kg	0.51	0.14	1
1,2-Dichlorobenzene	ND		ug/kg	2.0	0.15	1
1,3-Dichlorobenzene	ND		ug/kg	2.0	0.15	1
1,4-Dichlorobenzene	ND		ug/kg	2.0	0.17	1
Methyl tert butyl ether	ND		ug/kg	2.0	0.20	1
p/m-Xylene	ND		ug/kg	2.0	0.57	1
o-Xylene	ND		ug/kg	1.0	0.30	1
Xylenes, Total	ND		ug/kg	1.0	0.30	1
cis-1,2-Dichloroethene	ND		ug/kg	1.0	0.18	1
1,2-Dichloroethene, Total	ND		ug/kg	1.0	0.14	1
Dibromomethane	ND		ug/kg	2.0	0.24	1
Styrene	ND		ug/kg	1.0	0.20	1
Dichlorodifluoromethane	ND		ug/kg	10	0.93	1
Acetone	ND		ug/kg	10	4.9	1
Carbon disulfide	ND		ug/kg	10	4.6	1
2-Butanone	ND		ug/kg	10	2.2	1
Vinyl acetate	ND		ug/kg	10	2.2	1
4-Methyl-2-pentanone	ND		ug/kg	10	1.3	1
1,2,3-Trichloropropane	ND		ug/kg	2.0	0.13	1
2-Hexanone	ND		ug/kg	10	1.2	1
Bromochloromethane	ND		ug/kg	2.0	0.21	1
2,2-Dichloropropane	ND		ug/kg	2.0	0.20	1
1,2-Dibromoethane	ND		ug/kg	1.0	0.28	1
1,3-Dichloropropane	ND		ug/kg	2.0	0.17	1
1,1,1,2-Tetrachloroethane	ND		ug/kg	0.51	0.13	1
Bromobenzene	ND		ug/kg	2.0	0.15	1
n-Butylbenzene	ND		ug/kg	1.0	0.17	1
sec-Butylbenzene	ND		ug/kg	1.0	0.15	1
tert-Butylbenzene	ND		ug/kg	2.0	0.12	1
o-Chlorotoluene	ND		ug/kg	2.0	0.19	1
p-Chlorotoluene	ND		ug/kg	2.0	0.11	1
1,2-Dibromo-3-chloropropane	ND		ug/kg	3.0	1.0	1
Hexachlorobutadiene	ND		ug/kg	4.1	0.17	1
Isopropylbenzene	ND		ug/kg	1.0	0.11	1
p-Isopropyltoluene	ND		ug/kg	1.0	0.11	1
Naphthalene	ND		ug/kg	4.1	0.66	1
Acrylonitrile	ND		ug/kg	4.1	1.2	1

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-04 Date Collected: 06/07/23 10:50

Client ID: SB-42 (2-2.5) Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
n-Propylbenzene	ND		ug/kg	1.0	0.17	1
1,2,3-Trichlorobenzene	ND		ug/kg	2.0	0.33	1
1,2,4-Trichlorobenzene	ND		ug/kg	2.0	0.28	1
1,3,5-Trimethylbenzene	ND		ug/kg	2.0	0.20	1
1,2,4-Trimethylbenzene	ND		ug/kg	2.0	0.34	1
1,4-Dioxane	ND		ug/kg	81	36.	1
p-Diethylbenzene	ND		ug/kg	2.0	0.18	1
p-Ethyltoluene	ND		ug/kg	2.0	0.39	1
1,2,4,5-Tetramethylbenzene	ND		ug/kg	2.0	0.19	1
Ethyl ether	ND		ug/kg	2.0	0.35	1
trans-1,4-Dichloro-2-butene	ND		ug/kg	5.1	1.4	1
Tentatively Identified Compounds						
No Tentatively Identified Compounds	ND		ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	106		70-130
Toluene-d8	99		70-130
4-Bromofluorobenzene	105		70-130
Dibromofluoromethane	117		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-05
Client ID: SB-43 (5-5.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/07/23 11:30
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8260D
Analytical Date: 06/09/23 16:12
Analyst: JIC
Percent Solids: 95%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Methylene chloride	ND		ug/kg	6.6	3.0	1
1,1-Dichloroethane	ND		ug/kg	1.3	0.19	1
Chloroform	ND		ug/kg	2.0	0.18	1
Carbon tetrachloride	ND		ug/kg	1.3	0.30	1
1,2-Dichloropropane	ND		ug/kg	1.3	0.16	1
Dibromochloromethane	ND		ug/kg	1.3	0.18	1
1,1,2-Trichloroethane	ND		ug/kg	1.3	0.35	1
Tetrachloroethene	ND		ug/kg	0.66	0.26	1
Chlorobenzene	ND		ug/kg	0.66	0.17	1
Trichlorofluoromethane	ND		ug/kg	5.3	0.92	1
1,2-Dichloroethane	ND		ug/kg	1.3	0.34	1
1,1,1-Trichloroethane	ND		ug/kg	0.66	0.22	1
Bromodichloromethane	ND		ug/kg	0.66	0.14	1
trans-1,3-Dichloropropene	ND		ug/kg	1.3	0.36	1
cis-1,3-Dichloropropene	ND		ug/kg	0.66	0.21	1
1,3-Dichloropropene, Total	ND		ug/kg	0.66	0.21	1
1,1-Dichloropropene	ND		ug/kg	0.66	0.21	1
Bromoform	ND		ug/kg	5.3	0.32	1
1,1,2,2-Tetrachloroethane	ND		ug/kg	0.66	0.22	1
Benzene	ND		ug/kg	0.66	0.22	1
Toluene	ND		ug/kg	1.3	0.72	1
Ethylbenzene	ND		ug/kg	1.3	0.19	1
Chloromethane	ND		ug/kg	5.3	1.2	1
Bromomethane	ND		ug/kg	2.6	0.77	1
Vinyl chloride	ND		ug/kg	1.3	0.44	1
Chloroethane	ND		ug/kg	2.6	0.60	1
1,1-Dichloroethene	ND		ug/kg	1.3	0.31	1
trans-1,2-Dichloroethene	ND		ug/kg	2.0	0.18	1

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-05 Date Collected: 06/07/23 11:30

Client ID: SB-43 (5-5.5) Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Trichloroethene	ND		ug/kg	0.66	0.18	1
1,2-Dichlorobenzene	ND		ug/kg	2.6	0.19	1
1,3-Dichlorobenzene	ND		ug/kg	2.6	0.20	1
1,4-Dichlorobenzene	ND		ug/kg	2.6	0.22	1
Methyl tert butyl ether	ND		ug/kg	2.6	0.26	1
p/m-Xylene	ND		ug/kg	2.6	0.74	1
o-Xylene	ND		ug/kg	1.3	0.38	1
Xylenes, Total	ND		ug/kg	1.3	0.38	1
cis-1,2-Dichloroethene	ND		ug/kg	1.3	0.23	1
1,2-Dichloroethene, Total	ND		ug/kg	1.3	0.18	1
Dibromomethane	ND		ug/kg	2.6	0.31	1
Styrene	ND		ug/kg	1.3	0.26	1
Dichlorodifluoromethane	ND		ug/kg	13	1.2	1
Acetone	ND		ug/kg	13	6.3	1
Carbon disulfide	ND		ug/kg	13	6.0	1
2-Butanone	ND		ug/kg	13	2.9	1
Vinyl acetate	ND		ug/kg	13	2.8	1
4-Methyl-2-pentanone	ND		ug/kg	13	1.7	1
1,2,3-Trichloropropane	ND		ug/kg	2.6	0.17	1
2-Hexanone	ND		ug/kg	13	1.6	1
Bromochloromethane	ND		ug/kg	2.6	0.27	1
2,2-Dichloropropane	ND		ug/kg	2.6	0.27	1
1,2-Dibromoethane	ND		ug/kg	1.3	0.37	1
1,3-Dichloropropane	ND		ug/kg	2.6	0.22	1
1,1,1,2-Tetrachloroethane	ND		ug/kg	0.66	0.17	1
Bromobenzene	ND		ug/kg	2.6	0.19	1
n-Butylbenzene	ND		ug/kg	1.3	0.22	1
sec-Butylbenzene	ND		ug/kg	1.3	0.19	1
tert-Butylbenzene	ND		ug/kg	2.6	0.16	1
o-Chlorotoluene	ND		ug/kg	2.6	0.25	1
p-Chlorotoluene	ND		ug/kg	2.6	0.14	1
1,2-Dibromo-3-chloropropane	ND		ug/kg	4.0	1.3	1
Hexachlorobutadiene	ND		ug/kg	5.3	0.22	1
Isopropylbenzene	ND		ug/kg	1.3	0.14	1
p-Isopropyltoluene	ND		ug/kg	1.3	0.14	1
Naphthalene	ND		ug/kg	5.3	0.86	1
Acrylonitrile	ND		ug/kg	5.3	1.5	1

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-05 Date Collected: 06/07/23 11:30

Client ID: SB-43 (5-5.5) Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
n-Propylbenzene	ND		ug/kg	1.3	0.22	1
1,2,3-Trichlorobenzene	ND		ug/kg	2.6	0.42	1
1,2,4-Trichlorobenzene	ND		ug/kg	2.6	0.36	1
1,3,5-Trimethylbenzene	ND		ug/kg	2.6	0.25	1
1,2,4-Trimethylbenzene	ND		ug/kg	2.6	0.44	1
1,4-Dioxane	ND		ug/kg	100	46.	1
p-Diethylbenzene	ND		ug/kg	2.6	0.23	1
p-Ethyltoluene	ND		ug/kg	2.6	0.51	1
1,2,4,5-Tetramethylbenzene	ND		ug/kg	2.6	0.25	1
Ethyl ether	ND		ug/kg	2.6	0.45	1
trans-1,4-Dichloro-2-butene	ND		ug/kg	6.6	1.9	1
Tentatively Identified Compounds						
No Tentatively Identified Compounds	ND		ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	101		70-130
Toluene-d8	98		70-130
4-Bromofluorobenzene	102		70-130
Dibromofluoromethane	105		70-130

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331827
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-06
Client ID: GW-14
Sample Location: WHITE PLAINS, NY
Date Collected: 06/07/23 09:20
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8260D
Analytical Date: 06/11/23 10:30
Analyst: MJV

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Methylene chloride	ND		ug/l	2.5	0.70	1
1,1-Dichloroethane	ND		ug/l	2.5	0.70	1
Chloroform	17		ug/l	2.5	0.70	1
Carbon tetrachloride	ND		ug/l	0.50	0.13	1
1,2-Dichloropropane	ND		ug/l	1.0	0.14	1
Dibromochloromethane	ND		ug/l	0.50	0.15	1
1,1,2-Trichloroethane	ND		ug/l	1.5	0.50	1
Tetrachloroethene	1.1		ug/l	0.50	0.18	1
Chlorobenzene	ND		ug/l	2.5	0.70	1
Trichlorofluoromethane	ND		ug/l	2.5	0.70	1
1,2-Dichloroethane	ND		ug/l	0.50	0.13	1
1,1,1-Trichloroethane	ND		ug/l	2.5	0.70	1
Bromodichloromethane	0.24	J	ug/l	0.50	0.19	1
trans-1,3-Dichloropropene	ND		ug/l	0.50	0.16	1
cis-1,3-Dichloropropene	ND		ug/l	0.50	0.14	1
1,3-Dichloropropene, Total	ND		ug/l	0.50	0.14	1
1,1-Dichloropropene	ND		ug/l	2.5	0.70	1
Bromoform	ND		ug/l	2.0	0.65	1
1,1,2,2-Tetrachloroethane	ND		ug/l	0.50	0.17	1
Benzene	ND		ug/l	0.50	0.16	1
Toluene	ND		ug/l	2.5	0.70	1
Ethylbenzene	ND		ug/l	2.5	0.70	1
Chloromethane	ND		ug/l	2.5	0.70	1
Bromomethane	ND		ug/l	2.5	0.70	1
Vinyl chloride	ND		ug/l	1.0	0.07	1
Chloroethane	ND		ug/l	2.5	0.70	1
1,1-Dichloroethene	ND		ug/l	0.50	0.17	1
trans-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-06 Date Collected: 06/07/23 09:20

Client ID: GW-14 Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Trichloroethene	ND		ug/l	0.50	0.18	1
1,2-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,3-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,4-Dichlorobenzene	ND		ug/l	2.5	0.70	1
Methyl tert butyl ether	ND		ug/l	2.5	0.70	1
p/m-Xylene	ND		ug/l	2.5	0.70	1
o-Xylene	ND		ug/l	2.5	0.70	1
Xylenes, Total	ND		ug/l	2.5	0.70	1
cis-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1
1,2-Dichloroethene, Total	ND		ug/l	2.5	0.70	1
Dibromomethane	ND		ug/l	5.0	1.0	1
1,2,3-Trichloropropane	ND		ug/l	2.5	0.70	1
Acrylonitrile	ND		ug/l	5.0	1.5	1
Styrene	ND		ug/l	2.5	0.70	1
Dichlorodifluoromethane	3.0	J	ug/l	5.0	1.0	1
Acetone	ND		ug/l	5.0	1.5	1
Carbon disulfide	ND		ug/l	5.0	1.0	1
2-Butanone	ND		ug/l	5.0	1.9	1
Vinyl acetate	ND		ug/l	5.0	1.0	1
4-Methyl-2-pentanone	ND		ug/l	5.0	1.0	1
2-Hexanone	ND		ug/l	5.0	1.0	1
Bromochloromethane	ND		ug/l	2.5	0.70	1
2,2-Dichloropropane	ND		ug/l	2.5	0.70	1
1,2-Dibromoethane	ND		ug/l	2.0	0.65	1
1,3-Dichloropropane	ND		ug/l	2.5	0.70	1
1,1,1,2-Tetrachloroethane	ND		ug/l	2.5	0.70	1
Bromobenzene	ND		ug/l	2.5	0.70	1
n-Butylbenzene	ND		ug/l	2.5	0.70	1
sec-Butylbenzene	ND		ug/l	2.5	0.70	1
tert-Butylbenzene	ND		ug/l	2.5	0.70	1
o-Chlorotoluene	ND		ug/l	2.5	0.70	1
p-Chlorotoluene	ND		ug/l	2.5	0.70	1
1,2-Dibromo-3-chloropropane	ND		ug/l	2.5	0.70	1
Hexachlorobutadiene	ND		ug/l	2.5	0.70	1
Isopropylbenzene	ND		ug/l	2.5	0.70	1
p-Isopropyltoluene	ND		ug/l	2.5	0.70	1
Naphthalene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-06 Date Collected: 06/07/23 09:20

Client ID: GW-14 Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
n-Propylbenzene	ND		ug/l	2.5	0.70	1
1,2,3-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,3,5-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,4-Dioxane	ND		ug/l	250	61.	1
p-Diethylbenzene	ND		ug/l	2.0	0.70	1
p-Ethyltoluene	ND		ug/l	2.0	0.70	1
1,2,4,5-Tetramethylbenzene	ND		ug/l	2.0	0.54	1
Ethyl ether	ND		ug/l	2.5	0.70	1
trans-1,4-Dichloro-2-butene	ND		ug/l	2.5	0.70	1
Tentatively Identified Compounds						
No Tentatively Identified Compounds	ND		ug/l			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	98		70-130
Toluene-d8	96		70-130
4-Bromofluorobenzene	99		70-130
Dibromofluoromethane	100		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-07
Client ID: GW-15
Sample Location: WHITE PLAINS, NY

Date Collected: 06/07/23 11:45
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8260D
Analytical Date: 06/11/23 10:54
Analyst: MJV

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Methylene chloride	ND		ug/l	2.5	0.70	1
1,1-Dichloroethane	ND		ug/l	2.5	0.70	1
Chloroform	4.6		ug/l	2.5	0.70	1
Carbon tetrachloride	ND		ug/l	0.50	0.13	1
1,2-Dichloropropane	ND		ug/l	1.0	0.14	1
Dibromochloromethane	ND		ug/l	0.50	0.15	1
1,1,2-Trichloroethane	ND		ug/l	1.5	0.50	1
Tetrachloroethene	0.28	J	ug/l	0.50	0.18	1
Chlorobenzene	ND		ug/l	2.5	0.70	1
Trichlorofluoromethane	ND		ug/l	2.5	0.70	1
1,2-Dichloroethane	ND		ug/l	0.50	0.13	1
1,1,1-Trichloroethane	ND		ug/l	2.5	0.70	1
Bromodichloromethane	ND		ug/l	0.50	0.19	1
trans-1,3-Dichloropropene	ND		ug/l	0.50	0.16	1
cis-1,3-Dichloropropene	ND		ug/l	0.50	0.14	1
1,3-Dichloropropene, Total	ND		ug/l	0.50	0.14	1
1,1-Dichloropropene	ND		ug/l	2.5	0.70	1
Bromoform	ND		ug/l	2.0	0.65	1
1,1,2,2-Tetrachloroethane	ND		ug/l	0.50	0.17	1
Benzene	ND		ug/l	0.50	0.16	1
Toluene	ND		ug/l	2.5	0.70	1
Ethylbenzene	ND		ug/l	2.5	0.70	1
Chloromethane	ND		ug/l	2.5	0.70	1
Bromomethane	ND		ug/l	2.5	0.70	1
Vinyl chloride	ND		ug/l	1.0	0.07	1
Chloroethane	ND		ug/l	2.5	0.70	1
1,1-Dichloroethene	ND		ug/l	0.50	0.17	1
trans-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-07 Date Collected: 06/07/23 11:45

Client ID: GW-15 Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Trichloroethene	ND		ug/l	0.50	0.18	1
1,2-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,3-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,4-Dichlorobenzene	ND		ug/l	2.5	0.70	1
Methyl tert butyl ether	ND		ug/l	2.5	0.70	1
p/m-Xylene	ND		ug/l	2.5	0.70	1
o-Xylene	ND		ug/l	2.5	0.70	1
Xylenes, Total	ND		ug/l	2.5	0.70	1
cis-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1
1,2-Dichloroethene, Total	ND		ug/l	2.5	0.70	1
Dibromomethane	ND		ug/l	5.0	1.0	1
1,2,3-Trichloropropane	ND		ug/l	2.5	0.70	1
Acrylonitrile	ND		ug/l	5.0	1.5	1
Styrene	ND		ug/l	2.5	0.70	1
Dichlorodifluoromethane	ND		ug/l	5.0	1.0	1
Acetone	1.9	J	ug/l	5.0	1.5	1
Carbon disulfide	ND		ug/l	5.0	1.0	1
2-Butanone	ND		ug/l	5.0	1.9	1
Vinyl acetate	ND		ug/l	5.0	1.0	1
4-Methyl-2-pentanone	ND		ug/l	5.0	1.0	1
2-Hexanone	ND		ug/l	5.0	1.0	1
Bromochloromethane	ND		ug/l	2.5	0.70	1
2,2-Dichloropropane	ND		ug/l	2.5	0.70	1
1,2-Dibromoethane	ND		ug/l	2.0	0.65	1
1,3-Dichloropropane	ND		ug/l	2.5	0.70	1
1,1,1,2-Tetrachloroethane	ND		ug/l	2.5	0.70	1
Bromobenzene	ND		ug/l	2.5	0.70	1
n-Butylbenzene	ND		ug/l	2.5	0.70	1
sec-Butylbenzene	ND		ug/l	2.5	0.70	1
tert-Butylbenzene	ND		ug/l	2.5	0.70	1
o-Chlorotoluene	ND		ug/l	2.5	0.70	1
p-Chlorotoluene	ND		ug/l	2.5	0.70	1
1,2-Dibromo-3-chloropropane	ND		ug/l	2.5	0.70	1
Hexachlorobutadiene	ND		ug/l	2.5	0.70	1
Isopropylbenzene	ND		ug/l	2.5	0.70	1
p-Isopropyltoluene	ND		ug/l	2.5	0.70	1
Naphthalene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-07 Date Collected: 06/07/23 11:45

Client ID: GW-15 Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
n-Propylbenzene	ND		ug/l	2.5	0.70	1
1,2,3-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,3,5-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,4-Dioxane	ND		ug/l	250	61.	1
p-Diethylbenzene	ND		ug/l	2.0	0.70	1
p-Ethyltoluene	ND		ug/l	2.0	0.70	1
1,2,4,5-Tetramethylbenzene	ND		ug/l	2.0	0.54	1
Ethyl ether	ND		ug/l	2.5	0.70	1
trans-1,4-Dichloro-2-butene	ND		ug/l	2.5	0.70	1
Tentatively Identified Compounds						
No Tentatively Identified Compounds	ND		ug/l			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	97		70-130
Toluene-d8	97		70-130
4-Bromofluorobenzene	99		70-130
Dibromofluoromethane	99		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-08
Client ID: SB-26G (1.5-2)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/07/23 12:45
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8260D
Analytical Date: 06/09/23 16:38
Analyst: JIC
Percent Solids: 95%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Methylene chloride	ND		ug/kg	6.0	2.7	1
1,1-Dichloroethane	ND		ug/kg	1.2	0.17	1
Chloroform	ND		ug/kg	1.8	0.17	1
Carbon tetrachloride	ND		ug/kg	1.2	0.28	1
1,2-Dichloropropane	ND		ug/kg	1.2	0.15	1
Dibromochloromethane	ND		ug/kg	1.2	0.17	1
1,1,2-Trichloroethane	ND		ug/kg	1.2	0.32	1
Tetrachloroethene	ND		ug/kg	0.60	0.24	1
Chlorobenzene	ND		ug/kg	0.60	0.15	1
Trichlorofluoromethane	ND		ug/kg	4.8	0.83	1
1,2-Dichloroethane	ND		ug/kg	1.2	0.31	1
1,1,1-Trichloroethane	ND		ug/kg	0.60	0.20	1
Bromodichloromethane	ND		ug/kg	0.60	0.13	1
trans-1,3-Dichloropropene	ND		ug/kg	1.2	0.33	1
cis-1,3-Dichloropropene	ND		ug/kg	0.60	0.19	1
1,3-Dichloropropene, Total	ND		ug/kg	0.60	0.19	1
1,1-Dichloropropene	ND		ug/kg	0.60	0.19	1
Bromoform	ND		ug/kg	4.8	0.29	1
1,1,2,2-Tetrachloroethane	ND		ug/kg	0.60	0.20	1
Benzene	ND		ug/kg	0.60	0.20	1
Toluene	ND		ug/kg	1.2	0.65	1
Ethylbenzene	ND		ug/kg	1.2	0.17	1
Chloromethane	ND		ug/kg	4.8	1.1	1
Bromomethane	ND		ug/kg	2.4	0.70	1
Vinyl chloride	ND		ug/kg	1.2	0.40	1
Chloroethane	ND		ug/kg	2.4	0.54	1
1,1-Dichloroethene	ND		ug/kg	1.2	0.28	1
trans-1,2-Dichloroethene	ND		ug/kg	1.8	0.16	1

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-08 Date Collected: 06/07/23 12:45

Client ID: SB-26G (1.5-2) Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Trichloroethene	ND		ug/kg	0.60	0.16	1
1,2-Dichlorobenzene	ND		ug/kg	2.4	0.17	1
1,3-Dichlorobenzene	ND		ug/kg	2.4	0.18	1
1,4-Dichlorobenzene	ND		ug/kg	2.4	0.20	1
Methyl tert butyl ether	ND		ug/kg	2.4	0.24	1
p/m-Xylene	ND		ug/kg	2.4	0.67	1
o-Xylene	ND		ug/kg	1.2	0.35	1
Xylenes, Total	ND		ug/kg	1.2	0.35	1
cis-1,2-Dichloroethene	ND		ug/kg	1.2	0.21	1
1,2-Dichloroethene, Total	ND		ug/kg	1.2	0.16	1
Dibromomethane	ND		ug/kg	2.4	0.28	1
Styrene	ND		ug/kg	1.2	0.24	1
Dichlorodifluoromethane	ND		ug/kg	12	1.1	1
Acetone	ND		ug/kg	12	5.8	1
Carbon disulfide	ND		ug/kg	12	5.4	1
2-Butanone	ND		ug/kg	12	2.7	1
Vinyl acetate	ND		ug/kg	12	2.6	1
4-Methyl-2-pentanone	ND		ug/kg	12	1.5	1
1,2,3-Trichloropropane	ND		ug/kg	2.4	0.15	1
2-Hexanone	ND		ug/kg	12	1.4	1
Bromochloromethane	ND		ug/kg	2.4	0.24	1
2,2-Dichloropropane	ND		ug/kg	2.4	0.24	1
1,2-Dibromoethane	ND		ug/kg	1.2	0.33	1
1,3-Dichloropropane	ND		ug/kg	2.4	0.20	1
1,1,1,2-Tetrachloroethane	ND		ug/kg	0.60	0.16	1
Bromobenzene	ND		ug/kg	2.4	0.17	1
n-Butylbenzene	ND		ug/kg	1.2	0.20	1
sec-Butylbenzene	ND		ug/kg	1.2	0.18	1
tert-Butylbenzene	ND		ug/kg	2.4	0.14	1
o-Chlorotoluene	ND		ug/kg	2.4	0.23	1
p-Chlorotoluene	ND		ug/kg	2.4	0.13	1
1,2-Dibromo-3-chloropropane	ND		ug/kg	3.6	1.2	1
Hexachlorobutadiene	ND		ug/kg	4.8	0.20	1
Isopropylbenzene	ND		ug/kg	1.2	0.13	1
p-Isopropyltoluene	ND		ug/kg	1.2	0.13	1
Naphthalene	ND		ug/kg	4.8	0.78	1
Acrylonitrile	ND		ug/kg	4.8	1.4	1

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-08 Date Collected: 06/07/23 12:45

Client ID: SB-26G (1.5-2) Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
n-Propylbenzene	ND		ug/kg	1.2	0.20	1
1,2,3-Trichlorobenzene	ND		ug/kg	2.4	0.39	1
1,2,4-Trichlorobenzene	ND		ug/kg	2.4	0.33	1
1,3,5-Trimethylbenzene	ND		ug/kg	2.4	0.23	1
1,2,4-Trimethylbenzene	ND		ug/kg	2.4	0.40	1
1,4-Dioxane	ND		ug/kg	96	42.	1
p-Diethylbenzene	ND		ug/kg	2.4	0.21	1
p-Ethyltoluene	ND		ug/kg	2.4	0.46	1
1,2,4,5-Tetramethylbenzene	ND		ug/kg	2.4	0.23	1
Ethyl ether	ND		ug/kg	2.4	0.41	1
trans-1,4-Dichloro-2-butene	ND		ug/kg	6.0	1.7	1
Tentatively Identified Compounds						
No Tentatively Identified Compounds	ND		ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	99		70-130
Toluene-d8	99		70-130
4-Bromofluorobenzene	98		70-130
Dibromofluoromethane	104		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 06/09/23 08:51
Analyst: MKS

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by EPA 5035 Low - Westborough Lab for sample(s): 01-05,08 Batch: WG1790102-5					
Methylene chloride	ND		ug/kg	5.0	2.3
1,1-Dichloroethane	ND		ug/kg	1.0	0.14
Chloroform	ND		ug/kg	1.5	0.14
Carbon tetrachloride	ND		ug/kg	1.0	0.23
1,2-Dichloropropane	ND		ug/kg	1.0	0.12
Dibromochloromethane	ND		ug/kg	1.0	0.14
1,1,2-Trichloroethane	ND		ug/kg	1.0	0.27
Tetrachloroethene	ND		ug/kg	0.50	0.20
Chlorobenzene	ND		ug/kg	0.50	0.13
Trichlorofluoromethane	ND		ug/kg	4.0	0.70
1,2-Dichloroethane	ND		ug/kg	1.0	0.26
1,1,1-Trichloroethane	ND		ug/kg	0.50	0.17
Bromodichloromethane	ND		ug/kg	0.50	0.11
trans-1,3-Dichloropropene	ND		ug/kg	1.0	0.27
cis-1,3-Dichloropropene	ND		ug/kg	0.50	0.16
1,3-Dichloropropene, Total	ND		ug/kg	0.50	0.16
1,1-Dichloropropene	ND		ug/kg	0.50	0.16
Bromoform	ND		ug/kg	4.0	0.25
1,1,2,2-Tetrachloroethane	ND		ug/kg	0.50	0.17
Benzene	ND		ug/kg	0.50	0.17
Toluene	ND		ug/kg	1.0	0.54
Ethylbenzene	ND		ug/kg	1.0	0.14
Chloromethane	ND		ug/kg	4.0	0.93
Bromomethane	ND		ug/kg	2.0	0.58
Vinyl chloride	ND		ug/kg	1.0	0.34
Chloroethane	ND		ug/kg	2.0	0.45
1,1-Dichloroethene	ND		ug/kg	1.0	0.24
trans-1,2-Dichloroethene	ND		ug/kg	1.5	0.14
Trichloroethene	ND		ug/kg	0.50	0.14

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 06/09/23 08:51
Analyst: MKS

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by EPA 5035 Low - Westborough Lab for sample(s): 01-05,08 Batch: WG1790102-5					
1,2-Dichlorobenzene	ND		ug/kg	2.0	0.14
1,3-Dichlorobenzene	ND		ug/kg	2.0	0.15
1,4-Dichlorobenzene	ND		ug/kg	2.0	0.17
Methyl tert butyl ether	ND		ug/kg	2.0	0.20
p/m-Xylene	ND		ug/kg	2.0	0.56
o-Xylene	ND		ug/kg	1.0	0.29
Xylenes, Total	ND		ug/kg	1.0	0.29
cis-1,2-Dichloroethene	ND		ug/kg	1.0	0.18
1,2-Dichloroethene, Total	ND		ug/kg	1.0	0.14
Dibromomethane	ND		ug/kg	2.0	0.24
Styrene	ND		ug/kg	1.0	0.20
Dichlorodifluoromethane	ND		ug/kg	10	0.92
Acetone	ND		ug/kg	10	4.8
Carbon disulfide	ND		ug/kg	10	4.6
2-Butanone	ND		ug/kg	10	2.2
Vinyl acetate	ND		ug/kg	10	2.2
4-Methyl-2-pentanone	ND		ug/kg	10	1.3
1,2,3-Trichloropropane	ND		ug/kg	2.0	0.13
2-Hexanone	ND		ug/kg	10	1.2
Bromochloromethane	ND		ug/kg	2.0	0.20
2,2-Dichloropropane	ND		ug/kg	2.0	0.20
1,2-Dibromoethane	ND		ug/kg	1.0	0.28
1,3-Dichloropropane	ND		ug/kg	2.0	0.17
1,1,1,2-Tetrachloroethane	ND		ug/kg	0.50	0.13
Bromobenzene	ND		ug/kg	2.0	0.14
n-Butylbenzene	ND		ug/kg	1.0	0.17
sec-Butylbenzene	ND		ug/kg	1.0	0.15
tert-Butylbenzene	ND		ug/kg	2.0	0.12
o-Chlorotoluene	ND		ug/kg	2.0	0.19

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 06/09/23 08:51
Analyst: MKS

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by EPA 5035 Low - Westborough Lab for sample(s): 01-05,08 Batch: WG1790102-5					
p-Chlorotoluene	ND		ug/kg	2.0	0.11
1,2-Dibromo-3-chloropropane	ND		ug/kg	3.0	1.0
Hexachlorobutadiene	ND		ug/kg	4.0	0.17
Isopropylbenzene	ND		ug/kg	1.0	0.11
p-Isopropyltoluene	ND		ug/kg	1.0	0.11
Naphthalene	ND		ug/kg	4.0	0.65
Acrylonitrile	ND		ug/kg	4.0	1.2
n-Propylbenzene	ND		ug/kg	1.0	0.17
1,2,3-Trichlorobenzene	ND		ug/kg	2.0	0.32
1,2,4-Trichlorobenzene	ND		ug/kg	2.0	0.27
1,3,5-Trimethylbenzene	ND		ug/kg	2.0	0.19
1,2,4-Trimethylbenzene	ND		ug/kg	2.0	0.33
1,4-Dioxane	ND		ug/kg	80	35.
p-Diethylbenzene	ND		ug/kg	2.0	0.18
p-Ethyltoluene	ND		ug/kg	2.0	0.38
1,2,4,5-Tetramethylbenzene	ND		ug/kg	2.0	0.19
Ethyl ether	ND		ug/kg	2.0	0.34
trans-1,4-Dichloro-2-butene	ND		ug/kg	5.0	1.4

Tentatively Identified Compounds			
Total TIC Compounds	2.12	J	ug/kg
Unknown	2.12	J	ug/kg

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 06/09/23 08:51
Analyst: MKS

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by EPA 5035 Low - Westborough Lab for sample(s): 01-05,08 Batch: WG1790102-5					

Surrogate	%Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	101		70-130
Toluene-d8	97		70-130
4-Bromofluorobenzene	102		70-130
Dibromofluoromethane	104		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 06/11/23 10:06
Analyst: PID

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by GC/MS - Westborough Lab for sample(s): 06-07 Batch: WG1790237-5					
Methylene chloride	ND		ug/l	2.5	0.70
1,1-Dichloroethane	ND		ug/l	2.5	0.70
Chloroform	ND		ug/l	2.5	0.70
Carbon tetrachloride	ND		ug/l	0.50	0.13
1,2-Dichloropropane	ND		ug/l	1.0	0.14
Dibromochloromethane	ND		ug/l	0.50	0.15
1,1,2-Trichloroethane	ND		ug/l	1.5	0.50
Tetrachloroethene	ND		ug/l	0.50	0.18
Chlorobenzene	ND		ug/l	2.5	0.70
Trichlorofluoromethane	ND		ug/l	2.5	0.70
1,2-Dichloroethane	ND		ug/l	0.50	0.13
1,1,1-Trichloroethane	ND		ug/l	2.5	0.70
Bromodichloromethane	ND		ug/l	0.50	0.19
trans-1,3-Dichloropropene	ND		ug/l	0.50	0.16
cis-1,3-Dichloropropene	ND		ug/l	0.50	0.14
1,3-Dichloropropene, Total	ND		ug/l	0.50	0.14
1,1-Dichloropropene	ND		ug/l	2.5	0.70
Bromoform	ND		ug/l	2.0	0.65
1,1,2,2-Tetrachloroethane	ND		ug/l	0.50	0.17
Benzene	ND		ug/l	0.50	0.16
Toluene	ND		ug/l	2.5	0.70
Ethylbenzene	ND		ug/l	2.5	0.70
Chloromethane	ND		ug/l	2.5	0.70
Bromomethane	ND		ug/l	2.5	0.70
Vinyl chloride	ND		ug/l	1.0	0.07
Chloroethane	ND		ug/l	2.5	0.70
1,1-Dichloroethene	ND		ug/l	0.50	0.17
trans-1,2-Dichloroethene	ND		ug/l	2.5	0.70
Trichloroethene	ND		ug/l	0.50	0.18

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 06/11/23 10:06
Analyst: PID

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by GC/MS - Westborough Lab for sample(s): 06-07 Batch: WG1790237-5					
1,2-Dichlorobenzene	ND		ug/l	2.5	0.70
1,3-Dichlorobenzene	ND		ug/l	2.5	0.70
1,4-Dichlorobenzene	ND		ug/l	2.5	0.70
Methyl tert butyl ether	ND		ug/l	2.5	0.70
p/m-Xylene	ND		ug/l	2.5	0.70
o-Xylene	ND		ug/l	2.5	0.70
Xylenes, Total	ND		ug/l	2.5	0.70
cis-1,2-Dichloroethene	ND		ug/l	2.5	0.70
1,2-Dichloroethene, Total	ND		ug/l	2.5	0.70
Dibromomethane	ND		ug/l	5.0	1.0
1,2,3-Trichloropropane	ND		ug/l	2.5	0.70
Acrylonitrile	ND		ug/l	5.0	1.5
Styrene	ND		ug/l	2.5	0.70
Dichlorodifluoromethane	ND		ug/l	5.0	1.0
Acetone	ND		ug/l	5.0	1.5
Carbon disulfide	ND		ug/l	5.0	1.0
2-Butanone	ND		ug/l	5.0	1.9
Vinyl acetate	ND		ug/l	5.0	1.0
4-Methyl-2-pentanone	ND		ug/l	5.0	1.0
2-Hexanone	ND		ug/l	5.0	1.0
Bromochloromethane	ND		ug/l	2.5	0.70
2,2-Dichloropropane	ND		ug/l	2.5	0.70
1,2-Dibromoethane	ND		ug/l	2.0	0.65
1,3-Dichloropropane	ND		ug/l	2.5	0.70
1,1,1,2-Tetrachloroethane	ND		ug/l	2.5	0.70
Bromobenzene	ND		ug/l	2.5	0.70
n-Butylbenzene	ND		ug/l	2.5	0.70
sec-Butylbenzene	ND		ug/l	2.5	0.70
tert-Butylbenzene	ND		ug/l	2.5	0.70

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 06/11/23 10:06
Analyst: PID

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by GC/MS - Westborough Lab for sample(s): 06-07 Batch: WG1790237-5					
o-Chlorotoluene	ND		ug/l	2.5	0.70
p-Chlorotoluene	ND		ug/l	2.5	0.70
1,2-Dibromo-3-chloropropane	ND		ug/l	2.5	0.70
Hexachlorobutadiene	ND		ug/l	2.5	0.70
Isopropylbenzene	ND		ug/l	2.5	0.70
p-Isopropyltoluene	ND		ug/l	2.5	0.70
Naphthalene	ND		ug/l	2.5	0.70
n-Propylbenzene	ND		ug/l	2.5	0.70
1,2,3-Trichlorobenzene	ND		ug/l	2.5	0.70
1,2,4-Trichlorobenzene	ND		ug/l	2.5	0.70
1,3,5-Trimethylbenzene	ND		ug/l	2.5	0.70
1,2,4-Trimethylbenzene	ND		ug/l	2.5	0.70
1,4-Dioxane	ND		ug/l	250	61.
p-Diethylbenzene	ND		ug/l	2.0	0.70
p-Ethyltoluene	ND		ug/l	2.0	0.70
1,2,4,5-Tetramethylbenzene	ND		ug/l	2.0	0.54
Ethyl ether	ND		ug/l	2.5	0.70
trans-1,4-Dichloro-2-butene	ND		ug/l	2.5	0.70
Tentatively Identified Compounds					
No Tentatively Identified Compounds	ND		ug/l		

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 06/11/23 10:06
Analyst: PID

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by GC/MS - Westborough Lab for sample(s): 06-07 Batch: WG1790237-5					

Surrogate	%Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	99		70-130
Toluene-d8	97		70-130
4-Bromofluorobenzene	99		70-130
Dibromofluoromethane	99		70-130

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331827

Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by EPA 5035 Low - Westborough Lab Associated sample(s): 01-05,08 Batch: WG1790102-3 WG1790102-4								
Methylene chloride	98		98		70-130	0		30
1,1-Dichloroethane	104		103		70-130	1		30
Chloroform	105		104		70-130	1		30
Carbon tetrachloride	104		103		70-130	1		30
1,2-Dichloropropane	101		102		70-130	1		30
Dibromochloromethane	94		94		70-130	0		30
1,1,2-Trichloroethane	93		93		70-130	0		30
Tetrachloroethene	102		101		70-130	1		30
Chlorobenzene	100		99		70-130	1		30
Trichlorofluoromethane	108		106		70-139	2		30
1,2-Dichloroethane	97		96		70-130	1		30
1,1,1-Trichloroethane	109		107		70-130	2		30
Bromodichloromethane	101		102		70-130	1		30
trans-1,3-Dichloropropene	95		97		70-130	2		30
cis-1,3-Dichloropropene	104		103		70-130	1		30
1,1-Dichloropropene	109		106		70-130	3		30
Bromoform	91		91		70-130	0		30
1,1,2,2-Tetrachloroethane	89		88		70-130	1		30
Benzene	105		104		70-130	1		30
Toluene	99		99		70-130	0		30
Ethylbenzene	103		102		70-130	1		30
Chloromethane	104		101		52-130	3		30
Bromomethane	124		124		57-147	0		30

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331827

Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by EPA 5035 Low - Westborough Lab Associated sample(s): 01-05,08 Batch: WG1790102-3 WG1790102-4								
Vinyl chloride	101		100		67-130	1		30
Chloroethane	114		114		50-151	0		30
1,1-Dichloroethene	109		107		65-135	2		30
trans-1,2-Dichloroethene	107		107		70-130	0		30
Trichloroethene	108		107		70-130	1		30
1,2-Dichlorobenzene	99		99		70-130	0		30
1,3-Dichlorobenzene	101		100		70-130	1		30
1,4-Dichlorobenzene	98		98		70-130	0		30
Methyl tert butyl ether	95		96		66-130	1		30
p/m-Xylene	102		102		70-130	0		30
o-Xylene	101		102		70-130	1		30
cis-1,2-Dichloroethene	107		105		70-130	2		30
Dibromomethane	98		98		70-130	0		30
Styrene	104		104		70-130	0		30
Dichlorodifluoromethane	107		105		30-146	2		30
Acetone	65		65		54-140	0		30
Carbon disulfide	105		103		59-130	2		30
2-Butanone	**66**	Q	**59**	Q	70-130	11		30
Vinyl acetate	81		78		70-130	4		30
4-Methyl-2-pentanone	85		85		70-130	0		30
1,2,3-Trichloropropane	87		87		68-130	0		30
2-Hexanone	74		71		70-130	4		30
Bromochloromethane	101		102		70-130	1		30

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331827

Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by EPA 5035 Low - Westborough Lab Associated sample(s): 01-05,08 Batch: WG1790102-3 WG1790102-4								
2,2-Dichloropropane	110		105		70-130	5		30
1,2-Dibromoethane	96		97		70-130	1		30
1,3-Dichloropropane	94		93		69-130	1		30
1,1,1,2-Tetrachloroethane	99		98		70-130	1		30
Bromobenzene	98		98		70-130	0		30
n-Butylbenzene	103		102		70-130	1		30
sec-Butylbenzene	103		103		70-130	0		30
tert-Butylbenzene	102		102		70-130	0		30
o-Chlorotoluene	102		101		70-130	1		30
p-Chlorotoluene	100		101		70-130	1		30
1,2-Dibromo-3-chloropropane	84		86		68-130	2		30
Hexachlorobutadiene	104		104		67-130	0		30
Isopropylbenzene	103		102		70-130	1		30
p-Isopropyltoluene	103		103		70-130	0		30
Naphthalene	92		92		70-130	0		30
Acrylonitrile	77		78		70-130	1		30
n-Propylbenzene	105		105		70-130	0		30
1,2,3-Trichlorobenzene	98		100		70-130	2		30
1,2,4-Trichlorobenzene	102		103		70-130	1		30
1,3,5-Trimethylbenzene	99		98		70-130	1		30
1,2,4-Trimethylbenzene	101		100		70-130	1		30
1,4-Dioxane	84		84		65-136	0		30
p-Diethylbenzene	102		101		70-130	1		30

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331827

Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by EPA 5035 Low - Westborough Lab Associated sample(s): 01-05,08 Batch: WG1790102-3 WG1790102-4								
p-Ethyltoluene	104		102		70-130	2		30
1,2,4,5-Tetramethylbenzene	102		102		70-130	0		30
Ethyl ether	97		97		67-130	0		30
trans-1,4-Dichloro-2-butene	86		95		70-130	10		30

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
1,2-Dichloroethane-d4	90		91		70-130
Toluene-d8	99		99		70-130
4-Bromofluorobenzene	101		101		70-130
Dibromofluoromethane	99		98		70-130

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331827
Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by GC/MS - Westborough Lab Associated sample(s): 06-07 Batch: WG1790237-3 WG1790237-4								
Methylene chloride	96		100		70-130	4		20
1,1-Dichloroethane	96		100		70-130	4		20
Chloroform	93		99		70-130	6		20
Carbon tetrachloride	99		98		63-132	1		20
1,2-Dichloropropane	99		100		70-130	1		20
Dibromochloromethane	87		91		63-130	4		20
1,1,2-Trichloroethane	91		96		70-130	5		20
Tetrachloroethene	97		95		70-130	2		20
Chlorobenzene	93		95		75-130	2		20
Trichlorofluoromethane	100		100		62-150	0		20
1,2-Dichloroethane	90		98		70-130	9		20
1,1,1-Trichloroethane	99		99		67-130	0		20
Bromodichloromethane	93		96		67-130	3		20
trans-1,3-Dichloropropene	90		94		70-130	4		20
cis-1,3-Dichloropropene	96		98		70-130	2		20
1,1-Dichloropropene	100		100		70-130	0		20
Bromoform	84		91		54-136	8		20
1,1,2,2-Tetrachloroethane	88		100		67-130	13		20
Benzene	97		98		70-130	1		20
Toluene	93		94		70-130	1		20
Ethylbenzene	95		95		70-130	0		20
Chloromethane	95		97		64-130	2		20
Bromomethane	67		78		39-139	15		20

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331827
Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by GC/MS - Westborough Lab Associated sample(s): 06-07 Batch: WG1790237-3 WG1790237-4								
Vinyl chloride	98		99		55-140	1		20
Chloroethane	110		110		55-138	0		20
1,1-Dichloroethene	100		100		61-145	0		20
trans-1,2-Dichloroethene	99		100		70-130	1		20
Trichloroethene	90		91		70-130	1		20
1,2-Dichlorobenzene	90		94		70-130	4		20
1,3-Dichlorobenzene	92		93		70-130	1		20
1,4-Dichlorobenzene	91		92		70-130	1		20
Methyl tert butyl ether	91		99		63-130	8		20
p/m-Xylene	95		100		70-130	5		20
o-Xylene	95		95		70-130	0		20
cis-1,2-Dichloroethene	96		97		70-130	1		20
Dibromomethane	91		99		70-130	8		20
1,2,3-Trichloropropane	86		96		64-130	11		20
Acrylonitrile	89		100		70-130	12		20
Styrene	95		95		70-130	0		20
Dichlorodifluoromethane	99		95		36-147	4		20
Acetone	84		97		58-148	14		20
Carbon disulfide	100		100		51-130	0		20
2-Butanone	78		95		63-138	20		20
Vinyl acetate	110		120		70-130	9		20
4-Methyl-2-pentanone	88		100		59-130	13		20
2-Hexanone	81		98		57-130	19		20

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331827
Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by GC/MS - Westborough Lab Associated sample(s): 06-07 Batch: WG1790237-3 WG1790237-4								
Bromochloromethane	98		100		70-130	2		20
2,2-Dichloropropane	100		100		63-133	0		20
1,2-Dibromoethane	88		94		70-130	7		20
1,3-Dichloropropane	90		96		70-130	6		20
1,1,1,2-Tetrachloroethane	91		92		64-130	1		20
Bromobenzene	91		95		70-130	4		20
n-Butylbenzene	95		96		53-136	1		20
sec-Butylbenzene	95		96		70-130	1		20
tert-Butylbenzene	95		96		70-130	1		20
o-Chlorotoluene	94		95		70-130	1		20
p-Chlorotoluene	91		94		70-130	3		20
1,2-Dibromo-3-chloropropane	78		96		41-144	**21**	Q	20
Hexachlorobutadiene	91		93		63-130	2		20
Isopropylbenzene	96		95		70-130	1		20
p-Isopropyltoluene	95		96		70-130	1		20
Naphthalene	76		94		70-130	**21**	Q	20
n-Propylbenzene	96		96		69-130	0		20
1,2,3-Trichlorobenzene	83		94		70-130	12		20
1,2,4-Trichlorobenzene	86		94		70-130	9		20
1,3,5-Trimethylbenzene	94		95		64-130	1		20
1,2,4-Trimethylbenzene	94		95		70-130	1		20
1,4-Dioxane	80		98		56-162	20		20
p-Diethylbenzene	96		98		70-130	2		20

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331827

Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by GC/MS - Westborough Lab Associated sample(s): 06-07 Batch: WG1790237-3 WG1790237-4								
p-Ethyltoluene	95		94		70-130	1		20
1,2,4,5-Tetramethylbenzene	91		93		70-130	2		20
Ethyl ether	86		97		59-134	12		20
trans-1,4-Dichloro-2-butene	**69**	Q	78		70-130	12		20

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
1,2-Dichloroethane-d4	101		105		70-130
Toluene-d8	99		99		70-130
4-Bromofluorobenzene	101		101		70-130
Dibromofluoromethane	101		102		70-130

SEMIVOLATILES

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331827
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-01
Client ID: SB-39 (0.5-1)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/07/23 09:05
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8270E
Analytical Date: 06/09/23 20:21
Analyst: JG
Percent Solids: 94%

Extraction Method: EPA 3546
Extraction Date: 06/08/23 18:27

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Acenaphthene	23	J	ug/kg	140	18.	1
1,2,4-Trichlorobenzene	ND		ug/kg	170	20.	1
Hexachlorobenzene	ND		ug/kg	100	20.	1
Bis(2-chloroethyl)ether	ND		ug/kg	160	24.	1
2-Chloronaphthalene	ND		ug/kg	170	17.	1
1,2-Dichlorobenzene	ND		ug/kg	170	31.	1
1,3-Dichlorobenzene	ND		ug/kg	170	30.	1
1,4-Dichlorobenzene	ND		ug/kg	170	30.	1
3,3'-Dichlorobenzidine	ND		ug/kg	170	46.	1
2,4-Dinitrotoluene	ND		ug/kg	170	35.	1
2,6-Dinitrotoluene	ND		ug/kg	170	30.	1
Fluoranthene	1500		ug/kg	100	20.	1
4-Chlorophenyl phenyl ether	ND		ug/kg	170	19.	1
4-Bromophenyl phenyl ether	ND		ug/kg	170	27.	1
Bis(2-chloroisopropyl)ether	ND		ug/kg	210	30.	1
Bis(2-chloroethoxy)methane	ND		ug/kg	190	18.	1
Hexachlorobutadiene	ND		ug/kg	170	26.	1
Hexachlorocyclopentadiene	ND		ug/kg	500	160	1
Hexachloroethane	ND		ug/kg	140	28.	1
Isophorone	ND		ug/kg	160	23.	1
Naphthalene	ND		ug/kg	170	21.	1
Nitrobenzene	ND		ug/kg	160	26.	1
NDPA/DPA	ND		ug/kg	140	20.	1
n-Nitrosodi-n-propylamine	ND		ug/kg	170	27.	1
Bis(2-ethylhexyl)phthalate	ND		ug/kg	170	60.	1
Butyl benzyl phthalate	ND		ug/kg	170	44.	1
Di-n-butylphthalate	ND		ug/kg	170	33.	1
Di-n-octylphthalate	ND		ug/kg	170	59.	1

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-01 Date Collected: 06/07/23 09:05

Client ID: SB-39 (0.5-1) Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Diethyl phthalate	ND		ug/kg	170	16.	1
Dimethyl phthalate	ND		ug/kg	170	37.	1
Benzo(a)anthracene	680		ug/kg	100	20.	1
Benzo(a)pyrene	770		ug/kg	140	43.	1
Benzo(b)fluoranthene	930		ug/kg	100	29.	1
Benzo(k)fluoranthene	230		ug/kg	100	28.	1
Chrysene	670		ug/kg	100	18.	1
Acenaphthylene	58	J	ug/kg	140	27.	1
Anthracene	140		ug/kg	100	34.	1
Benzo(ghi)perylene	460		ug/kg	140	20.	1
Fluorene	33	J	ug/kg	170	17.	1
Phenanthrene	570		ug/kg	100	21.	1
Dibenzo(a,h)anthracene	110		ug/kg	100	20.	1
Indeno(1,2,3-cd)pyrene	410		ug/kg	140	24.	1
Pyrene	1300		ug/kg	100	17.	1
Biphenyl	ND		ug/kg	400	23.	1
4-Chloroaniline	ND		ug/kg	170	32.	1
2-Nitroaniline	ND		ug/kg	170	34.	1
3-Nitroaniline	ND		ug/kg	170	33.	1
4-Nitroaniline	ND		ug/kg	170	72.	1
Dibenzofuran	ND		ug/kg	170	16.	1
2-Methylnaphthalene	ND		ug/kg	210	21.	1
1,2,4,5-Tetrachlorobenzene	ND		ug/kg	170	18.	1
Acetophenone	ND		ug/kg	170	22.	1
2,4,6-Trichlorophenol	ND		ug/kg	100	33.	1
p-Chloro-m-cresol	ND		ug/kg	170	26.	1
2-Chlorophenol	ND		ug/kg	170	21.	1
2,4-Dichlorophenol	ND		ug/kg	160	28.	1
2,4-Dimethylphenol	ND		ug/kg	170	58.	1
2-Nitrophenol	ND		ug/kg	380	66.	1
4-Nitrophenol	ND		ug/kg	240	71.	1
2,4-Dinitrophenol	ND		ug/kg	840	82.	1
4,6-Dinitro-o-cresol	ND		ug/kg	450	84.	1
Pentachlorophenol	ND		ug/kg	140	38.	1
Phenol	ND		ug/kg	170	26.	1
2-Methylphenol	ND		ug/kg	170	27.	1
3-Methylphenol/4-Methylphenol	ND		ug/kg	250	27.	1

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-01 Date Collected: 06/07/23 09:05

Client ID: SB-39 (0.5-1) Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
2,4,5-Trichlorophenol	ND		ug/kg	170	34.	1
Benzoic Acid	ND		ug/kg	570	180	1
Benzyl Alcohol	ND		ug/kg	170	54.	1
Carbazole	36	J	ug/kg	170	17.	1
1,4-Dioxane	ND		ug/kg	26	8.0	1
Tentatively Identified Compounds						
Total TIC Compounds	836	J	ug/kg			1
Unknown	249	J	ug/kg			1
Unknown	180	J	ug/kg			1
Unknown	407	J	ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	**14**	Q	25-120
Phenol-d6	48		10-120
Nitrobenzene-d5	74		23-120
2-Fluorobiphenyl	69		30-120
2,4,6-Tribromophenol	**3**	Q	10-136
4-Terphenyl-d14	70		18-120

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-01 RE
Client ID: SB-39 (0.5-1)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/07/23 09:05
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8270E
Analytical Date: 06/14/23 08:48
Analyst: CMM
Percent Solids: 94%

Extraction Method: EPA 3546
Extraction Date: 06/13/23 18:29

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Acenaphthene	ND		ug/kg	140	18.	1
1,2,4-Trichlorobenzene	ND		ug/kg	170	20.	1
Hexachlorobenzene	ND		ug/kg	100	19.	1
Bis(2-chloroethyl)ether	ND		ug/kg	160	23.	1
2-Chloronaphthalene	ND		ug/kg	170	17.	1
1,2-Dichlorobenzene	ND		ug/kg	170	31.	1
1,3-Dichlorobenzene	ND		ug/kg	170	30.	1
1,4-Dichlorobenzene	ND		ug/kg	170	30.	1
3,3'-Dichlorobenzidine	ND		ug/kg	170	46.	1
2,4-Dinitrotoluene	ND		ug/kg	170	35.	1
2,6-Dinitrotoluene	ND		ug/kg	170	30.	1
Fluoranthene	340		ug/kg	100	20.	1
4-Chlorophenyl phenyl ether	ND		ug/kg	170	18.	1
4-Bromophenyl phenyl ether	ND		ug/kg	170	26.	1
Bis(2-chloroisopropyl)ether	ND		ug/kg	210	30.	1
Bis(2-chloroethoxy)methane	ND		ug/kg	190	17.	1
Hexachlorobutadiene	ND		ug/kg	170	25.	1
Hexachlorocyclopentadiene	ND		ug/kg	490	160	1
Hexachloroethane	ND		ug/kg	140	28.	1
Isophorone	ND		ug/kg	160	22.	1
Naphthalene	23	J	ug/kg	170	21.	1
Nitrobenzene	ND		ug/kg	160	26.	1
NDPA/DPA	ND		ug/kg	140	20.	1
n-Nitrosodi-n-propylamine	ND		ug/kg	170	27.	1
Bis(2-ethylhexyl)phthalate	ND		ug/kg	170	60.	1
Butyl benzyl phthalate	ND		ug/kg	170	44.	1
Di-n-butylphthalate	ND		ug/kg	170	33.	1
Di-n-octylphthalate	ND		ug/kg	170	59.	1

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-01 RE
Client ID: SB-39 (0.5-1)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/07/23 09:05
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Diethyl phthalate	ND		ug/kg	170	16.	1
Dimethyl phthalate	ND		ug/kg	170	36.	1
Benzo(a)anthracene	180		ug/kg	100	19.	1
Benzo(a)pyrene	180		ug/kg	140	42.	1
Benzo(b)fluoranthene	220		ug/kg	100	29.	1
Benzo(k)fluoranthene	71	J	ug/kg	100	28.	1
Chrysene	170		ug/kg	100	18.	1
Acenaphthylene	35	J	ug/kg	140	27.	1
Anthracene	40	J	ug/kg	100	34.	1
Benzo(ghi)perylene	120	J	ug/kg	140	20.	1
Fluorene	ND		ug/kg	170	17.	1
Phenanthrene	170		ug/kg	100	21.	1
Dibenzo(a,h)anthracene	23	J	ug/kg	100	20.	1
Indeno(1,2,3-cd)pyrene	130	J	ug/kg	140	24.	1
Pyrene	300		ug/kg	100	17.	1
Biphenyl	ND		ug/kg	390	22.	1
4-Chloroaniline	ND		ug/kg	170	31.	1
2-Nitroaniline	ND		ug/kg	170	33.	1
3-Nitroaniline	ND		ug/kg	170	33.	1
4-Nitroaniline	ND		ug/kg	170	72.	1
Dibenzofuran	ND		ug/kg	170	16.	1
2-Methylnaphthalene	ND		ug/kg	210	21.	1
1,2,4,5-Tetrachlorobenzene	ND		ug/kg	170	18.	1
Acetophenone	ND		ug/kg	170	21.	1
2,4,6-Trichlorophenol	ND		ug/kg	100	33.	1
p-Chloro-m-cresol	ND		ug/kg	170	26.	1
2-Chlorophenol	ND		ug/kg	170	20.	1
2,4-Dichlorophenol	ND		ug/kg	160	28.	1
2,4-Dimethylphenol	ND		ug/kg	170	57.	1
2-Nitrophenol	ND		ug/kg	370	65.	1
4-Nitrophenol	ND		ug/kg	240	71.	1
2,4-Dinitrophenol	ND		ug/kg	830	81.	1
4,6-Dinitro-o-cresol	ND		ug/kg	450	83.	1
Pentachlorophenol	ND		ug/kg	140	38.	1
Phenol	ND		ug/kg	170	26.	1
2-Methylphenol	ND		ug/kg	170	27.	1
3-Methylphenol/4-Methylphenol	ND		ug/kg	250	27.	1

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-01 RE
Client ID: SB-39 (0.5-1)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/07/23 09:05
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
2,4,5-Trichlorophenol	ND		ug/kg	170	33.	1
Benzoic Acid	ND		ug/kg	560	180	1
Benzyl Alcohol	ND		ug/kg	170	53.	1
Carbazole	18	J	ug/kg	170	17.	1
1,4-Dioxane	ND		ug/kg	26	8.0	1
Tentatively Identified Compounds						
Total TIC Compounds	289	J	ug/kg			1
Unknown	289	J	ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	**9**	Q	25-120
Phenol-d6	47		10-120
Nitrobenzene-d5	74		23-120
2-Fluorobiphenyl	76		30-120
2,4,6-Tribromophenol	**3**	Q	10-136
4-Terphenyl-d14	64		18-120

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331827
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-02
Client ID: SB-40 (1-1.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/07/23 10:05
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8270E
Analytical Date: 06/09/23 20:37
Analyst: JG
Percent Solids: 93%

Extraction Method: EPA 3546
Extraction Date: 06/08/23 18:27

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Acenaphthene	41	J	ug/kg	140	18.	1
1,2,4-Trichlorobenzene	ND		ug/kg	180	20.	1
Hexachlorobenzene	ND		ug/kg	110	20.	1
Bis(2-chloroethyl)ether	ND		ug/kg	160	24.	1
2-Chloronaphthalene	ND		ug/kg	180	18.	1
1,2-Dichlorobenzene	ND		ug/kg	180	32.	1
1,3-Dichlorobenzene	ND		ug/kg	180	30.	1
1,4-Dichlorobenzene	ND		ug/kg	180	31.	1
3,3'-Dichlorobenzidine	ND		ug/kg	180	47.	1
2,4-Dinitrotoluene	ND		ug/kg	180	35.	1
2,6-Dinitrotoluene	ND		ug/kg	180	30.	1
Fluoranthene	960		ug/kg	110	20.	1
4-Chlorophenyl phenyl ether	ND		ug/kg	180	19.	1
4-Bromophenyl phenyl ether	ND		ug/kg	180	27.	1
Bis(2-chloroisopropyl)ether	ND		ug/kg	210	30.	1
Bis(2-chloroethoxy)methane	ND		ug/kg	190	18.	1
Hexachlorobutadiene	ND		ug/kg	180	26.	1
Hexachlorocyclopentadiene	ND		ug/kg	510	160	1
Hexachloroethane	ND		ug/kg	140	29.	1
Isophorone	ND		ug/kg	160	23.	1
Naphthalene	ND		ug/kg	180	22.	1
Nitrobenzene	ND		ug/kg	160	26.	1
NDPA/DPA	ND		ug/kg	140	20.	1
n-Nitrosodi-n-propylamine	ND		ug/kg	180	27.	1
Bis(2-ethylhexyl)phthalate	ND		ug/kg	180	61.	1
Butyl benzyl phthalate	ND		ug/kg	180	45.	1
Di-n-butylphthalate	ND		ug/kg	180	34.	1
Di-n-octylphthalate	ND		ug/kg	180	60.	1

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-02 Date Collected: 06/07/23 10:05

Client ID: SB-40 (1-1.5) Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Diethyl phthalate	ND		ug/kg	180	16.	1
Dimethyl phthalate	ND		ug/kg	180	37.	1
Benzo(a)anthracene	500		ug/kg	110	20.	1
Benzo(a)pyrene	560		ug/kg	140	43.	1
Benzo(b)fluoranthene	610		ug/kg	110	30.	1
Benzo(k)fluoranthene	240		ug/kg	110	28.	1
Chrysene	490		ug/kg	110	18.	1
Acenaphthylene	52	J	ug/kg	140	27.	1
Anthracene	120		ug/kg	110	34.	1
Benzo(ghi)perylene	360		ug/kg	140	21.	1
Fluorene	34	J	ug/kg	180	17.	1
Phenanthrene	430		ug/kg	110	22.	1
Dibenzo(a,h)anthracene	83	J	ug/kg	110	20.	1
Indeno(1,2,3-cd)pyrene	310		ug/kg	140	25.	1
Pyrene	900		ug/kg	110	18.	1
Biphenyl	ND		ug/kg	400	23.	1
4-Chloroaniline	ND		ug/kg	180	32.	1
2-Nitroaniline	ND		ug/kg	180	34.	1
3-Nitroaniline	ND		ug/kg	180	33.	1
4-Nitroaniline	ND		ug/kg	180	73.	1
Dibenzofuran	ND		ug/kg	180	17.	1
2-Methylnaphthalene	ND		ug/kg	210	21.	1
1,2,4,5-Tetrachlorobenzene	ND		ug/kg	180	18.	1
Acetophenone	ND		ug/kg	180	22.	1
2,4,6-Trichlorophenol	ND		ug/kg	110	34.	1
p-Chloro-m-cresol	ND		ug/kg	180	26.	1
2-Chlorophenol	ND		ug/kg	180	21.	1
2,4-Dichlorophenol	ND		ug/kg	160	28.	1
2,4-Dimethylphenol	ND		ug/kg	180	58.	1
2-Nitrophenol	ND		ug/kg	380	67.	1
4-Nitrophenol	ND		ug/kg	250	72.	1
2,4-Dinitrophenol	ND		ug/kg	850	83.	1
4,6-Dinitro-o-cresol	ND		ug/kg	460	85.	1
Pentachlorophenol	ND		ug/kg	140	39.	1
Phenol	ND		ug/kg	180	27.	1
2-Methylphenol	ND		ug/kg	180	27.	1
3-Methylphenol/4-Methylphenol	ND		ug/kg	260	28.	1

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-02 Date Collected: 06/07/23 10:05

Client ID: SB-40 (1-1.5) Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
2,4,5-Trichlorophenol	ND		ug/kg	180	34.	1
Benzoic Acid	ND		ug/kg	570	180	1
Benzyl Alcohol	ND		ug/kg	180	54.	1
Carbazole	47	J	ug/kg	180	17.	1
1,4-Dioxane	ND		ug/kg	26	8.2	1
Tentatively Identified Compounds						
Total TIC Compounds	154	J	ug/kg			1
Unknown	154	J	ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	71		25-120
Phenol-d6	70		10-120
Nitrobenzene-d5	75		23-120
2-Fluorobiphenyl	68		30-120
2,4,6-Tribromophenol	75		10-136
4-Terphenyl-d14	67		18-120

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331827
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-03
Client ID: SB-41 (2.5-3)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/07/23 10:20
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8270E
Analytical Date: 06/09/23 20:54
Analyst: JG
Percent Solids: 94%

Extraction Method: EPA 3546
Extraction Date: 06/08/23 18:27

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Acenaphthene	73	J	ug/kg	140	18.	1
1,2,4-Trichlorobenzene	ND		ug/kg	170	20.	1
Hexachlorobenzene	ND		ug/kg	100	20.	1
Bis(2-chloroethyl)ether	ND		ug/kg	160	24.	1
2-Chloronaphthalene	ND		ug/kg	170	17.	1
1,2-Dichlorobenzene	ND		ug/kg	170	31.	1
1,3-Dichlorobenzene	ND		ug/kg	170	30.	1
1,4-Dichlorobenzene	ND		ug/kg	170	30.	1
3,3'-Dichlorobenzidine	ND		ug/kg	170	46.	1
2,4-Dinitrotoluene	ND		ug/kg	170	35.	1
2,6-Dinitrotoluene	ND		ug/kg	170	30.	1
Fluoranthene	1600		ug/kg	100	20.	1
4-Chlorophenyl phenyl ether	ND		ug/kg	170	19.	1
4-Bromophenyl phenyl ether	ND		ug/kg	170	27.	1
Bis(2-chloroisopropyl)ether	ND		ug/kg	210	30.	1
Bis(2-chloroethoxy)methane	ND		ug/kg	190	18.	1
Hexachlorobutadiene	ND		ug/kg	170	26.	1
Hexachlorocyclopentadiene	ND		ug/kg	500	160	1
Hexachloroethane	ND		ug/kg	140	28.	1
Isophorone	ND		ug/kg	160	23.	1
Naphthalene	47	J	ug/kg	170	21.	1
Nitrobenzene	ND		ug/kg	160	26.	1
NDPA/DPA	ND		ug/kg	140	20.	1
n-Nitrosodi-n-propylamine	ND		ug/kg	170	27.	1
Bis(2-ethylhexyl)phthalate	ND		ug/kg	170	60.	1
Butyl benzyl phthalate	ND		ug/kg	170	44.	1
Di-n-butylphthalate	ND		ug/kg	170	33.	1
Di-n-octylphthalate	ND		ug/kg	170	59.	1

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-03 Date Collected: 06/07/23 10:20

Client ID: SB-41 (2.5-3) Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Diethyl phthalate	ND		ug/kg	170	16.	1
Dimethyl phthalate	ND		ug/kg	170	37.	1
Benzo(a)anthracene	810		ug/kg	100	20.	1
Benzo(a)pyrene	910		ug/kg	140	43.	1
Benzo(b)fluoranthene	1000		ug/kg	100	29.	1
Benzo(k)fluoranthene	330		ug/kg	100	28.	1
Chrysene	780		ug/kg	100	18.	1
Acenaphthylene	110	J	ug/kg	140	27.	1
Anthracene	200		ug/kg	100	34.	1
Benzo(ghi)perylene	620		ug/kg	140	20.	1
Fluorene	56	J	ug/kg	170	17.	1
Phenanthrene	650		ug/kg	100	21.	1
Dibenzo(a,h)anthracene	150		ug/kg	100	20.	1
Indeno(1,2,3-cd)pyrene	540		ug/kg	140	24.	1
Pyrene	1400		ug/kg	100	17.	1
Biphenyl	ND		ug/kg	400	23.	1
4-Chloroaniline	ND		ug/kg	170	32.	1
2-Nitroaniline	ND		ug/kg	170	34.	1
3-Nitroaniline	ND		ug/kg	170	33.	1
4-Nitroaniline	ND		ug/kg	170	72.	1
Dibenzofuran	32	J	ug/kg	170	16.	1
2-Methylnaphthalene	26	J	ug/kg	210	21.	1
1,2,4,5-Tetrachlorobenzene	ND		ug/kg	170	18.	1
Acetophenone	ND		ug/kg	170	22.	1
2,4,6-Trichlorophenol	ND		ug/kg	100	33.	1
p-Chloro-m-cresol	ND		ug/kg	170	26.	1
2-Chlorophenol	ND		ug/kg	170	21.	1
2,4-Dichlorophenol	ND		ug/kg	160	28.	1
2,4-Dimethylphenol	ND		ug/kg	170	58.	1
2-Nitrophenol	ND		ug/kg	380	66.	1
4-Nitrophenol	ND		ug/kg	240	71.	1
2,4-Dinitrophenol	ND		ug/kg	840	81.	1
4,6-Dinitro-o-cresol	ND		ug/kg	450	84.	1
Pentachlorophenol	ND		ug/kg	140	38.	1
Phenol	ND		ug/kg	170	26.	1
2-Methylphenol	ND		ug/kg	170	27.	1
3-Methylphenol/4-Methylphenol	ND		ug/kg	250	27.	1

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-03 Date Collected: 06/07/23 10:20

Client ID: SB-41 (2.5-3) Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
2,4,5-Trichlorophenol	ND		ug/kg	170	33.	1
Benzoic Acid	ND		ug/kg	560	180	1
Benzyl Alcohol	ND		ug/kg	170	53.	1
Carbazole	67	J	ug/kg	170	17.	1
1,4-Dioxane	ND		ug/kg	26	8.0	1
Tentatively Identified Compounds						
Total TIC Compounds	214	J	ug/kg			1
Unknown	214	J	ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	67		25-120
Phenol-d6	68		10-120
Nitrobenzene-d5	73		23-120
2-Fluorobiphenyl	62		30-120
2,4,6-Tribromophenol	66		10-136
4-Terphenyl-d14	59		18-120

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331827
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-04
Client ID: SB-42 (2-2.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/07/23 10:50
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8270E
Analytical Date: 06/09/23 21:11
Analyst: JG
Percent Solids: 93%

Extraction Method: EPA 3546
Extraction Date: 06/08/23 18:27

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Acenaphthene	49	J	ug/kg	140	18.	1
1,2,4-Trichlorobenzene	ND		ug/kg	180	20.	1
Hexachlorobenzene	ND		ug/kg	100	20.	1
Bis(2-chloroethyl)ether	ND		ug/kg	160	24.	1
2-Chloronaphthalene	ND		ug/kg	180	17.	1
1,2-Dichlorobenzene	ND		ug/kg	180	32.	1
1,3-Dichlorobenzene	ND		ug/kg	180	30.	1
1,4-Dichlorobenzene	ND		ug/kg	180	31.	1
3,3'-Dichlorobenzidine	ND		ug/kg	180	47.	1
2,4-Dinitrotoluene	ND		ug/kg	180	35.	1
2,6-Dinitrotoluene	ND		ug/kg	180	30.	1
Fluoranthene	1100		ug/kg	100	20.	1
4-Chlorophenyl phenyl ether	ND		ug/kg	180	19.	1
4-Bromophenyl phenyl ether	ND		ug/kg	180	27.	1
Bis(2-chloroisopropyl)ether	ND		ug/kg	210	30.	1
Bis(2-chloroethoxy)methane	ND		ug/kg	190	18.	1
Hexachlorobutadiene	ND		ug/kg	180	26.	1
Hexachlorocyclopentadiene	ND		ug/kg	500	160	1
Hexachloroethane	ND		ug/kg	140	28.	1
Isophorone	ND		ug/kg	160	23.	1
Naphthalene	39	J	ug/kg	180	21.	1
Nitrobenzene	ND		ug/kg	160	26.	1
NDPA/DPA	ND		ug/kg	140	20.	1
n-Nitrosodi-n-propylamine	ND		ug/kg	180	27.	1
Bis(2-ethylhexyl)phthalate	ND		ug/kg	180	61.	1
Butyl benzyl phthalate	ND		ug/kg	180	44.	1
Di-n-butylphthalate	ND		ug/kg	180	33.	1
Di-n-octylphthalate	ND		ug/kg	180	60.	1

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-04 Date Collected: 06/07/23 10:50

Client ID: SB-42 (2-2.5) Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Diethyl phthalate	ND		ug/kg	180	16.	1
Dimethyl phthalate	ND		ug/kg	180	37.	1
Benzo(a)anthracene	600		ug/kg	100	20.	1
Benzo(a)pyrene	670		ug/kg	140	43.	1
Benzo(b)fluoranthene	780		ug/kg	100	30.	1
Benzo(k)fluoranthene	230		ug/kg	100	28.	1
Chrysene	560		ug/kg	100	18.	1
Acenaphthylene	63	J	ug/kg	140	27.	1
Anthracene	150		ug/kg	100	34.	1
Benzo(ghi)perylene	440		ug/kg	140	21.	1
Fluorene	40	J	ug/kg	180	17.	1
Phenanthrene	480		ug/kg	100	21.	1
Dibenzo(a,h)anthracene	130		ug/kg	100	20.	1
Indeno(1,2,3-cd)pyrene	400		ug/kg	140	24.	1
Pyrene	970		ug/kg	100	17.	1
Biphenyl	ND		ug/kg	400	23.	1
4-Chloroaniline	ND		ug/kg	180	32.	1
2-Nitroaniline	ND		ug/kg	180	34.	1
3-Nitroaniline	ND		ug/kg	180	33.	1
4-Nitroaniline	ND		ug/kg	180	73.	1
Dibenzofuran	21	J	ug/kg	180	16.	1
2-Methylnaphthalene	23	J	ug/kg	210	21.	1
1,2,4,5-Tetrachlorobenzene	ND		ug/kg	180	18.	1
Acetophenone	ND		ug/kg	180	22.	1
2,4,6-Trichlorophenol	ND		ug/kg	100	33.	1
p-Chloro-m-cresol	ND		ug/kg	180	26.	1
2-Chlorophenol	ND		ug/kg	180	21.	1
2,4-Dichlorophenol	ND		ug/kg	160	28.	1
2,4-Dimethylphenol	ND		ug/kg	180	58.	1
2-Nitrophenol	ND		ug/kg	380	66.	1
4-Nitrophenol	ND		ug/kg	240	72.	1
2,4-Dinitrophenol	ND		ug/kg	840	82.	1
4,6-Dinitro-o-cresol	ND		ug/kg	460	84.	1
Pentachlorophenol	ND		ug/kg	140	38.	1
Phenol	ND		ug/kg	180	26.	1
2-Methylphenol	ND		ug/kg	180	27.	1
3-Methylphenol/4-Methylphenol	ND		ug/kg	250	27.	1

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-04 Date Collected: 06/07/23 10:50

Client ID: SB-42 (2-2.5) Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
2,4,5-Trichlorophenol	ND		ug/kg	180	34.	1
Benzoic Acid	ND		ug/kg	570	180	1
Benzyl Alcohol	ND		ug/kg	180	54.	1
Carbazole	63	J	ug/kg	180	17.	1
1,4-Dioxane	ND		ug/kg	26	8.1	1
Tentatively Identified Compounds						
Total TIC Compounds	246	J	ug/kg			1
Unknown	246	J	ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	73		25-120
Phenol-d6	75		10-120
Nitrobenzene-d5	79		23-120
2-Fluorobiphenyl	72		30-120
2,4,6-Tribromophenol	78		10-136
4-Terphenyl-d14	68		18-120

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331827
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-05
Client ID: SB-43 (5-5.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/07/23 11:30
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8270E
Analytical Date: 06/09/23 21:27
Analyst: JG
Percent Solids: 95%

Extraction Method: EPA 3546
Extraction Date: 06/08/23 18:27

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Acenaphthene	18	J	ug/kg	140	18.	1
1,2,4-Trichlorobenzene	ND		ug/kg	180	20.	1
Hexachlorobenzene	ND		ug/kg	100	20.	1
Bis(2-chloroethyl)ether	ND		ug/kg	160	24.	1
2-Chloronaphthalene	ND		ug/kg	180	17.	1
1,2-Dichlorobenzene	ND		ug/kg	180	31.	1
1,3-Dichlorobenzene	ND		ug/kg	180	30.	1
1,4-Dichlorobenzene	ND		ug/kg	180	30.	1
3,3'-Dichlorobenzidine	ND		ug/kg	180	46.	1
2,4-Dinitrotoluene	ND		ug/kg	180	35.	1
2,6-Dinitrotoluene	ND		ug/kg	180	30.	1
Fluoranthene	320		ug/kg	100	20.	1
4-Chlorophenyl phenyl ether	ND		ug/kg	180	19.	1
4-Bromophenyl phenyl ether	ND		ug/kg	180	27.	1
Bis(2-chloroisopropyl)ether	ND		ug/kg	210	30.	1
Bis(2-chloroethoxy)methane	ND		ug/kg	190	18.	1
Hexachlorobutadiene	ND		ug/kg	180	26.	1
Hexachlorocyclopentadiene	ND		ug/kg	500	160	1
Hexachloroethane	ND		ug/kg	140	28.	1
Isophorone	ND		ug/kg	160	23.	1
Naphthalene	ND		ug/kg	180	21.	1
Nitrobenzene	ND		ug/kg	160	26.	1
NDPA/DPA	ND		ug/kg	140	20.	1
n-Nitrosodi-n-propylamine	ND		ug/kg	180	27.	1
Bis(2-ethylhexyl)phthalate	ND		ug/kg	180	60.	1
Butyl benzyl phthalate	ND		ug/kg	180	44.	1
Di-n-butylphthalate	ND		ug/kg	180	33.	1
Di-n-octylphthalate	ND		ug/kg	180	60.	1

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-05 Date Collected: 06/07/23 11:30

Client ID: SB-43 (5-5.5) Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Diethyl phthalate	ND		ug/kg	180	16.	1
Dimethyl phthalate	ND		ug/kg	180	37.	1
Benzo(a)anthracene	170		ug/kg	100	20.	1
Benzo(a)pyrene	190		ug/kg	140	43.	1
Benzo(b)fluoranthene	200		ug/kg	100	29.	1
Benzo(k)fluoranthene	99	J	ug/kg	100	28.	1
Chrysene	160		ug/kg	100	18.	1
Acenaphthylene	ND		ug/kg	140	27.	1
Anthracene	55	J	ug/kg	100	34.	1
Benzo(ghi)perylene	120	J	ug/kg	140	20.	1
Fluorene	ND		ug/kg	180	17.	1
Phenanthrene	180		ug/kg	100	21.	1
Dibenzo(a,h)anthracene	30	J	ug/kg	100	20.	1
Indeno(1,2,3-cd)pyrene	110	J	ug/kg	140	24.	1
Pyrene	280		ug/kg	100	17.	1
Biphenyl	ND		ug/kg	400	23.	1
4-Chloroaniline	ND		ug/kg	180	32.	1
2-Nitroaniline	ND		ug/kg	180	34.	1
3-Nitroaniline	ND		ug/kg	180	33.	1
4-Nitroaniline	ND		ug/kg	180	72.	1
Dibenzofuran	ND		ug/kg	180	16.	1
2-Methylnaphthalene	ND		ug/kg	210	21.	1
1,2,4,5-Tetrachlorobenzene	ND		ug/kg	180	18.	1
Acetophenone	ND		ug/kg	180	22.	1
2,4,6-Trichlorophenol	ND		ug/kg	100	33.	1
p-Chloro-m-cresol	ND		ug/kg	180	26.	1
2-Chlorophenol	ND		ug/kg	180	21.	1
2,4-Dichlorophenol	ND		ug/kg	160	28.	1
2,4-Dimethylphenol	ND		ug/kg	180	58.	1
2-Nitrophenol	ND		ug/kg	380	66.	1
4-Nitrophenol	ND		ug/kg	240	71.	1
2,4-Dinitrophenol	ND		ug/kg	840	82.	1
4,6-Dinitro-o-cresol	ND		ug/kg	460	84.	1
Pentachlorophenol	ND		ug/kg	140	38.	1
Phenol	ND		ug/kg	180	26.	1
2-Methylphenol	ND		ug/kg	180	27.	1
3-Methylphenol/4-Methylphenol	ND		ug/kg	250	27.	1

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-05 Date Collected: 06/07/23 11:30

Client ID: SB-43 (5-5.5) Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
2,4,5-Trichlorophenol	ND		ug/kg	180	34.	1
Benzoic Acid	ND		ug/kg	570	180	1
Benzyl Alcohol	ND		ug/kg	180	54.	1
Carbazole	25	J	ug/kg	180	17.	1
1,4-Dioxane	ND		ug/kg	26	8.0	1
Tentatively Identified Compounds						
No Tentatively Identified Compounds	ND		ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	66		25-120
Phenol-d6	66		10-120
Nitrobenzene-d5	69		23-120
2-Fluorobiphenyl	64		30-120
2,4,6-Tribromophenol	67		10-136
4-Terphenyl-d14	61		18-120

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331827
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-06
Client ID: GW-14
Sample Location: WHITE PLAINS, NY

Date Collected: 06/07/23 09:20
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E
Analytical Date: 06/14/23 14:53
Analyst: JG

Extraction Method: EPA 3510C
Extraction Date: 06/13/23 09:08

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
1,2,4-Trichlorobenzene	ND		ug/l	5.0	0.50	1
Bis(2-chloroethyl)ether	ND		ug/l	2.0	0.50	1
1,2-Dichlorobenzene	ND		ug/l	2.0	0.45	1
1,3-Dichlorobenzene	ND		ug/l	2.0	0.40	1
1,4-Dichlorobenzene	ND		ug/l	2.0	0.43	1
3,3'-Dichlorobenzidine	ND		ug/l	5.0	1.6	1
2,4-Dinitrotoluene	ND		ug/l	5.0	1.2	1
2,6-Dinitrotoluene	ND		ug/l	5.0	0.93	1
4-Chlorophenyl phenyl ether	ND		ug/l	2.0	0.49	1
4-Bromophenyl phenyl ether	ND		ug/l	2.0	0.38	1
Bis(2-chloroisopropyl)ether	ND		ug/l	2.0	0.53	1
Bis(2-chloroethoxy)methane	ND		ug/l	5.0	0.50	1
Hexachlorocyclopentadiene	ND		ug/l	20	0.69	1
Isophorone	ND		ug/l	5.0	1.2	1
Nitrobenzene	ND		ug/l	2.0	0.77	1
NDPA/DPA	ND		ug/l	2.0	0.42	1
n-Nitrosodi-n-propylamine	ND		ug/l	5.0	0.64	1
Bis(2-ethylhexyl)phthalate	2.0	J	ug/l	3.0	1.5	1
Butyl benzyl phthalate	ND		ug/l	5.0	1.2	1
Di-n-butylphthalate	ND		ug/l	5.0	0.39	1
Di-n-octylphthalate	ND		ug/l	5.0	1.3	1
Diethyl phthalate	ND		ug/l	5.0	0.38	1
Dimethyl phthalate	ND		ug/l	5.0	1.8	1
Biphenyl	ND		ug/l	2.0	0.46	1
4-Chloroaniline	ND		ug/l	5.0	1.1	1
2-Nitroaniline	ND		ug/l	5.0	0.50	1
3-Nitroaniline	ND		ug/l	5.0	0.81	1
4-Nitroaniline	ND		ug/l	5.0	0.80	1

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-06 Date Collected: 06/07/23 09:20

Client ID: GW-14 Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Dibenzofuran	ND		ug/l	2.0	0.50	1
1,2,4,5-Tetrachlorobenzene	ND		ug/l	10	0.44	1
Acetophenone	ND		ug/l	5.0	0.53	1
2,4,6-Trichlorophenol	ND		ug/l	5.0	0.61	1
p-Chloro-m-cresol	ND		ug/l	2.0	0.35	1
2-Chlorophenol	ND		ug/l	2.0	0.48	1
2,4-Dichlorophenol	ND		ug/l	5.0	0.41	1
2,4-Dimethylphenol	ND		ug/l	5.0	1.8	1
2-Nitrophenol	ND		ug/l	10	0.85	1
4-Nitrophenol	ND		ug/l	10	0.67	1
2,4-Dinitrophenol	ND		ug/l	20	6.6	1
4,6-Dinitro-o-cresol	ND		ug/l	10	1.8	1
Phenol	ND		ug/l	5.0	0.57	1
2-Methylphenol	ND		ug/l	5.0	0.49	1
3-Methylphenol/4-Methylphenol	ND		ug/l	5.0	0.48	1
2,4,5-Trichlorophenol	ND		ug/l	5.0	0.77	1
Benzoic Acid	8.6	J	ug/l	50	2.6	1
Benzyl Alcohol	ND		ug/l	2.0	0.59	1
Carbazole	ND		ug/l	2.0	0.49	1

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-06 Date Collected: 06/07/23 09:20

Client ID: GW-14 Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Tentatively Identified Compounds						
Total TIC Compounds	190	J	ug/l			1
Unknown Amine	11.2	J	ug/l			1
Unknown	6.73	J	ug/l			1
Unknown	5.96	J	ug/l			1
Unknown	15.0	J	ug/l			1
Unknown Alkene	19.3	J	ug/l			1
Unknown Amide	7.02	J	ug/l			1
Unknown	4.44	J	ug/l			1
Unknown	17.6	J	ug/l			1
Unknown	5.64	J	ug/l			1
Unknown	21.6	J	ug/l			1
Unknown Organic Acid	56.2	J	ug/l			1
Unknown Siloxane	4.22	J	ug/l			1
Unknown Alkane	4.80	J	ug/l			1
Unknown Siloxane	5.85	J	ug/l			1
Unknown	4.07	J	ug/l			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	36		21-120
Phenol-d6	27		10-120
Nitrobenzene-d5	59		23-120
2-Fluorobiphenyl	54		15-120
2,4,6-Tribromophenol	58		10-120
4-Terphenyl-d14	67		41-149

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331827
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-06
Client ID: GW-14
Sample Location: WHITE PLAINS, NY

Date Collected: 06/07/23 09:20
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E-SIM
Analytical Date: 06/14/23 13:08
Analyst: AH

Extraction Method: EPA 3510C
Extraction Date: 06/13/23 09:03

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS-SIM - Westborough Lab						
Acenaphthene	0.03	J	ug/l	0.10	0.01	1
2-Chloronaphthalene	ND		ug/l	0.20	0.02	1
Fluoranthene	0.20		ug/l	0.10	0.02	1
Hexachlorobutadiene	ND		ug/l	0.50	0.05	1
Naphthalene	0.10		ug/l	0.10	0.05	1
Benzo(a)anthracene	0.21		ug/l	0.10	0.02	1
Benzo(a)pyrene	0.10		ug/l	0.10	0.02	1
Benzo(b)fluoranthene	0.14		ug/l	0.10	0.01	1
Benzo(k)fluoranthene	0.05	J	ug/l	0.10	0.01	1
Chrysene	0.09	J	ug/l	0.10	0.01	1
Acenaphthylene	0.04	J	ug/l	0.10	0.01	1
Anthracene	0.04	J	ug/l	0.10	0.01	1
Benzo(ghi)perylene	0.10	J	ug/l	0.10	0.01	1
Fluorene	0.05	J	ug/l	0.10	0.01	1
Phenanthrene	0.11		ug/l	0.10	0.02	1
Dibenzo(a,h)anthracene	ND		ug/l	0.10	0.01	1
Indeno(1,2,3-cd)pyrene	0.08	J	ug/l	0.10	0.01	1
Pyrene	ND		ug/l	0.10	0.02	1
2-Methylnaphthalene	0.08	J	ug/l	0.10	0.02	1
Pentachlorophenol	ND		ug/l	0.80	0.01	1
Hexachlorobenzene	0.03	J	ug/l	0.80	0.01	1
Hexachloroethane	ND		ug/l	0.80	0.06	1

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-06 Date Collected: 06/07/23 09:20

Client ID: GW-14 Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS-SIM - Westborough Lab						

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	35		21-120
Phenol-d6	28		10-120
Nitrobenzene-d5	66		23-120
2-Fluorobiphenyl	77		15-120
2,4,6-Tribromophenol	110		10-120
4-Terphenyl-d14	75		41-149

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331827
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-07
Client ID: GW-15
Sample Location: WHITE PLAINS, NY

Date Collected: 06/07/23 11:45
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E
Analytical Date: 06/14/23 15:17
Analyst: JG

Extraction Method: EPA 3510C
Extraction Date: 06/13/23 09:08

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
1,2,4-Trichlorobenzene	ND		ug/l	5.0	0.50	1
Bis(2-chloroethyl)ether	ND		ug/l	2.0	0.50	1
1,2-Dichlorobenzene	ND		ug/l	2.0	0.45	1
1,3-Dichlorobenzene	ND		ug/l	2.0	0.40	1
1,4-Dichlorobenzene	ND		ug/l	2.0	0.43	1
3,3'-Dichlorobenzidine	ND		ug/l	5.0	1.6	1
2,4-Dinitrotoluene	ND		ug/l	5.0	1.2	1
2,6-Dinitrotoluene	ND		ug/l	5.0	0.93	1
4-Chlorophenyl phenyl ether	ND		ug/l	2.0	0.49	1
4-Bromophenyl phenyl ether	ND		ug/l	2.0	0.38	1
Bis(2-chloroisopropyl)ether	ND		ug/l	2.0	0.53	1
Bis(2-chloroethoxy)methane	ND		ug/l	5.0	0.50	1
Hexachlorocyclopentadiene	ND		ug/l	20	0.69	1
Isophorone	ND		ug/l	5.0	1.2	1
Nitrobenzene	ND		ug/l	2.0	0.77	1
NDPA/DPA	ND		ug/l	2.0	0.42	1
n-Nitrosodi-n-propylamine	ND		ug/l	5.0	0.64	1
Bis(2-ethylhexyl)phthalate	ND		ug/l	3.0	1.5	1
Butyl benzyl phthalate	ND		ug/l	5.0	1.2	1
Di-n-butylphthalate	0.58	J	ug/l	5.0	0.39	1
Di-n-octylphthalate	ND		ug/l	5.0	1.3	1
Diethyl phthalate	ND		ug/l	5.0	0.38	1
Dimethyl phthalate	ND		ug/l	5.0	1.8	1
Biphenyl	ND		ug/l	2.0	0.46	1
4-Chloroaniline	ND		ug/l	5.0	1.1	1
2-Nitroaniline	ND		ug/l	5.0	0.50	1
3-Nitroaniline	ND		ug/l	5.0	0.81	1
4-Nitroaniline	ND		ug/l	5.0	0.80	1

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-07 Date Collected: 06/07/23 11:45

Client ID: GW-15 Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Dibenzofuran	ND		ug/l	2.0	0.50	1
1,2,4,5-Tetrachlorobenzene	ND		ug/l	10	0.44	1
Acetophenone	ND		ug/l	5.0	0.53	1
2,4,6-Trichlorophenol	ND		ug/l	5.0	0.61	1
p-Chloro-m-cresol	ND		ug/l	2.0	0.35	1
2-Chlorophenol	ND		ug/l	2.0	0.48	1
2,4-Dichlorophenol	ND		ug/l	5.0	0.41	1
2,4-Dimethylphenol	ND		ug/l	5.0	1.8	1
2-Nitrophenol	ND		ug/l	10	0.85	1
4-Nitrophenol	ND		ug/l	10	0.67	1
2,4-Dinitrophenol	ND		ug/l	20	6.6	1
4,6-Dinitro-o-cresol	ND		ug/l	10	1.8	1
Phenol	ND		ug/l	5.0	0.57	1
2-Methylphenol	ND		ug/l	5.0	0.49	1
3-Methylphenol/4-Methylphenol	ND		ug/l	5.0	0.48	1
2,4,5-Trichlorophenol	ND		ug/l	5.0	0.77	1
Benzoic Acid	10.	J	ug/l	50	2.6	1
Benzyl Alcohol	ND		ug/l	2.0	0.59	1
Carbazole	ND		ug/l	2.0	0.49	1

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-07 Date Collected: 06/07/23 11:45

Client ID: GW-15 Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Tentatively Identified Compounds						
Total TIC Compounds	161	J	ug/l			1
Unknown	2.65	J	ug/l			1
Unknown	2.54	J	ug/l			1
Unknown	4.00	J	ug/l			1
Unknown Alkane	7.53	J	ug/l			1
Unknown Organic Acid	3.34	J	ug/l			1
Unknown	24.2	J	ug/l			1
Unknown	3.24	J	ug/l			1
Unknown Alkane	6.25	J	ug/l			1
Unknown	4.73	J	ug/l			1
Unknown	11.2	J	ug/l			1
Unknown Alkane	2.65	J	ug/l			1
Unknown Alkane	3.24	J	ug/l			1
Unknown Benzene	10.2	J	ug/l			1
Unknown Alkane	3.02	J	ug/l			1
Unknown Organic Acid	72.0	J	ug/l			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	46		21-120
Phenol-d6	36		10-120
Nitrobenzene-d5	56		23-120
2-Fluorobiphenyl	49		15-120
2,4,6-Tribromophenol	57		10-120
4-Terphenyl-d14	54		41-149

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331827
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-07
Client ID: GW-15
Sample Location: WHITE PLAINS, NY

Date Collected: 06/07/23 11:45
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E-SIM
Analytical Date: 06/14/23 13:25
Analyst: AH

Extraction Method: EPA 3510C
Extraction Date: 06/13/23 09:03

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS-SIM - Westborough Lab						
Acenaphthene	0.02	J	ug/l	0.10	0.01	1
2-Chloronaphthalene	ND		ug/l	0.20	0.02	1
Fluoranthene	0.18		ug/l	0.10	0.02	1
Hexachlorobutadiene	ND		ug/l	0.50	0.05	1
Naphthalene	ND		ug/l	0.10	0.05	1
Benzo(a)anthracene	0.11		ug/l	0.10	0.02	1
Benzo(a)pyrene	0.09	J	ug/l	0.10	0.02	1
Benzo(b)fluoranthene	0.11		ug/l	0.10	0.01	1
Benzo(k)fluoranthene	0.05	J	ug/l	0.10	0.01	1
Chrysene	0.10		ug/l	0.10	0.01	1
Acenaphthylene	0.03	J	ug/l	0.10	0.01	1
Anthracene	0.03	J	ug/l	0.10	0.01	1
Benzo(ghi)perylene	0.07	J	ug/l	0.10	0.01	1
Fluorene	0.04	J	ug/l	0.10	0.01	1
Phenanthrene	0.14		ug/l	0.10	0.02	1
Dibenzo(a,h)anthracene	ND		ug/l	0.10	0.01	1
Indeno(1,2,3-cd)pyrene	0.06	J	ug/l	0.10	0.01	1
Pyrene	ND		ug/l	0.10	0.02	1
2-Methylnaphthalene	0.04	J	ug/l	0.10	0.02	1
Pentachlorophenol	ND		ug/l	0.80	0.01	1
Hexachlorobenzene	0.04	J	ug/l	0.80	0.01	1
Hexachloroethane	ND		ug/l	0.80	0.06	1

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-07 Date Collected: 06/07/23 11:45

Client ID: GW-15 Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS-SIM - Westborough Lab						

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	49		21-120
Phenol-d6	44		10-120
Nitrobenzene-d5	64		23-120
2-Fluorobiphenyl	73		15-120
2,4,6-Tribromophenol	113		10-120
4-Terphenyl-d14	70		41-149

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331827
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-08
Client ID: SB-26G (1.5-2)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/07/23 12:45
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8270E
Analytical Date: 06/09/23 21:44
Analyst: JG
Percent Solids: 95%

Extraction Method: EPA 3546
Extraction Date: 06/08/23 18:27

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Acenaphthene	ND		ug/kg	140	18.	1
1,2,4-Trichlorobenzene	ND		ug/kg	170	19.	1
Hexachlorobenzene	ND		ug/kg	100	19.	1
Bis(2-chloroethyl)ether	ND		ug/kg	150	23.	1
2-Chloronaphthalene	ND		ug/kg	170	17.	1
1,2-Dichlorobenzene	ND		ug/kg	170	30.	1
1,3-Dichlorobenzene	ND		ug/kg	170	29.	1
1,4-Dichlorobenzene	ND		ug/kg	170	30.	1
3,3'-Dichlorobenzidine	ND		ug/kg	170	45.	1
2,4-Dinitrotoluene	ND		ug/kg	170	34.	1
2,6-Dinitrotoluene	ND		ug/kg	170	29.	1
Fluoranthene	74	J	ug/kg	100	20.	1
4-Chlorophenyl phenyl ether	ND		ug/kg	170	18.	1
4-Bromophenyl phenyl ether	ND		ug/kg	170	26.	1
Bis(2-chloroisopropyl)ether	ND		ug/kg	200	29.	1
Bis(2-chloroethoxy)methane	ND		ug/kg	180	17.	1
Hexachlorobutadiene	ND		ug/kg	170	25.	1
Hexachlorocyclopentadiene	ND		ug/kg	480	150	1
Hexachloroethane	ND		ug/kg	140	27.	1
Isophorone	ND		ug/kg	150	22.	1
Naphthalene	ND		ug/kg	170	21.	1
Nitrobenzene	ND		ug/kg	150	25.	1
NDPA/DPA	ND		ug/kg	140	19.	1
n-Nitrosodi-n-propylamine	ND		ug/kg	170	26.	1
Bis(2-ethylhexyl)phthalate	ND		ug/kg	170	59.	1
Butyl benzyl phthalate	ND		ug/kg	170	43.	1
Di-n-butylphthalate	ND		ug/kg	170	32.	1
Di-n-octylphthalate	ND		ug/kg	170	58.	1

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-08 Date Collected: 06/07/23 12:45

Client ID: SB-26G (1.5-2) Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Diethyl phthalate	ND		ug/kg	170	16.	1
Dimethyl phthalate	ND		ug/kg	170	36.	1
Benzo(a)anthracene	40	J	ug/kg	100	19.	1
Benzo(a)pyrene	43	J	ug/kg	140	41.	1
Benzo(b)fluoranthene	44	J	ug/kg	100	29.	1
Benzo(k)fluoranthene	ND		ug/kg	100	27.	1
Chrysene	36	J	ug/kg	100	18.	1
Acenaphthylene	ND		ug/kg	140	26.	1
Anthracene	ND		ug/kg	100	33.	1
Benzo(ghi)perylene	30	J	ug/kg	140	20.	1
Fluorene	ND		ug/kg	170	16.	1
Phenanthrene	46	J	ug/kg	100	21.	1
Dibenzo(a,h)anthracene	ND		ug/kg	100	20.	1
Indeno(1,2,3-cd)pyrene	25	J	ug/kg	140	24.	1
Pyrene	68	J	ug/kg	100	17.	1
Biphenyl	ND		ug/kg	390	22.	1
4-Chloroaniline	ND		ug/kg	170	31.	1
2-Nitroaniline	ND		ug/kg	170	33.	1
3-Nitroaniline	ND		ug/kg	170	32.	1
4-Nitroaniline	ND		ug/kg	170	70.	1
Dibenzofuran	ND		ug/kg	170	16.	1
2-Methylnaphthalene	ND		ug/kg	200	20.	1
1,2,4,5-Tetrachlorobenzene	ND		ug/kg	170	18.	1
Acetophenone	ND		ug/kg	170	21.	1
2,4,6-Trichlorophenol	ND		ug/kg	100	32.	1
p-Chloro-m-cresol	ND		ug/kg	170	25.	1
2-Chlorophenol	ND		ug/kg	170	20.	1
2,4-Dichlorophenol	ND		ug/kg	150	27.	1
2,4-Dimethylphenol	ND		ug/kg	170	56.	1
2-Nitrophenol	ND		ug/kg	370	64.	1
4-Nitrophenol	ND		ug/kg	240	69.	1
2,4-Dinitrophenol	ND		ug/kg	820	79.	1
4,6-Dinitro-o-cresol	ND		ug/kg	440	82.	1
Pentachlorophenol	ND		ug/kg	140	37.	1
Phenol	ND		ug/kg	170	26.	1
2-Methylphenol	ND		ug/kg	170	26.	1
3-Methylphenol/4-Methylphenol	ND		ug/kg	240	27.	1

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-08 Date Collected: 06/07/23 12:45

Client ID: SB-26G (1.5-2) Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
2,4,5-Trichlorophenol	ND		ug/kg	170	32.	1
Benzoic Acid	ND		ug/kg	550	170	1
Benzyl Alcohol	ND		ug/kg	170	52.	1
Carbazole	ND		ug/kg	170	16.	1
1,4-Dioxane	ND		ug/kg	25	7.8	1
Tentatively Identified Compounds						
No Tentatively Identified Compounds	ND		ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	72		25-120
Phenol-d6	70		10-120
Nitrobenzene-d5	72		23-120
2-Fluorobiphenyl	68		30-120
2,4,6-Tribromophenol	73		10-136
4-Terphenyl-d14	69		18-120

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331827
Report Date: 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 06/09/23 18:38
Analyst: JG

Extraction Method: EPA 3546
Extraction Date: 06/08/23 15:21

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 01-05,08 Batch: WG1788928-1					
Acenaphthene	ND		ug/kg	130	17.
1,2,4-Trichlorobenzene	ND		ug/kg	160	19.
Hexachlorobenzene	ND		ug/kg	98	18.
Bis(2-chloroethyl)ether	ND		ug/kg	150	22.
2-Chloronaphthalene	ND		ug/kg	160	16.
1,2-Dichlorobenzene	ND		ug/kg	160	29.
1,3-Dichlorobenzene	ND		ug/kg	160	28.
1,4-Dichlorobenzene	ND		ug/kg	160	29.
3,3'-Dichlorobenzidine	ND		ug/kg	160	44.
2,4-Dinitrotoluene	ND		ug/kg	160	33.
2,6-Dinitrotoluene	ND		ug/kg	160	28.
Fluoranthene	ND		ug/kg	98	19.
4-Chlorophenyl phenyl ether	ND		ug/kg	160	18.
4-Bromophenyl phenyl ether	ND		ug/kg	160	25.
Bis(2-chloroisopropyl)ether	ND		ug/kg	200	28.
Bis(2-chloroethoxy)methane	ND		ug/kg	180	16.
Hexachlorobutadiene	ND		ug/kg	160	24.
Hexachlorocyclopentadiene	ND		ug/kg	470	150
Hexachloroethane	ND		ug/kg	130	26.
Isophorone	ND		ug/kg	150	21.
Naphthalene	ND		ug/kg	160	20.
Nitrobenzene	ND		ug/kg	150	24.
NDPA/DPA	ND		ug/kg	130	19.
n-Nitrosodi-n-propylamine	ND		ug/kg	160	25.
Bis(2-ethylhexyl)phthalate	ND		ug/kg	160	57.
Butyl benzyl phthalate	ND		ug/kg	160	41.
Di-n-butylphthalate	ND		ug/kg	160	31.
Di-n-octylphthalate	ND		ug/kg	160	56.
Diethyl phthalate	ND		ug/kg	160	15.

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331827
Report Date: 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 06/09/23 18:38
Analyst: JG

Extraction Method: EPA 3546
Extraction Date: 06/08/23 15:21

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 01-05,08 Batch: WG1788928-1					
Dimethyl phthalate	ND		ug/kg	160	34.
Benzo(a)anthracene	ND		ug/kg	98	18.
Benzo(a)pyrene	ND		ug/kg	130	40.
Benzo(b)fluoranthene	ND		ug/kg	98	28.
Benzo(k)fluoranthene	ND		ug/kg	98	26.
Chrysene	ND		ug/kg	98	17.
Acenaphthylene	ND		ug/kg	130	25.
Anthracene	ND		ug/kg	98	32.
Benzo(ghi)perylene	ND		ug/kg	130	19.
Fluorene	ND		ug/kg	160	16.
Phenanthrene	ND		ug/kg	98	20.
Dibenzo(a,h)anthracene	ND		ug/kg	98	19.
Indeno(1,2,3-cd)pyrene	ND		ug/kg	130	23.
Pyrene	ND		ug/kg	98	16.
Biphenyl	ND		ug/kg	370	21.
4-Chloroaniline	ND		ug/kg	160	30.
2-Nitroaniline	ND		ug/kg	160	32.
3-Nitroaniline	ND		ug/kg	160	31.
4-Nitroaniline	ND		ug/kg	160	68.
Dibenzofuran	ND		ug/kg	160	16.
2-Methylnaphthalene	ND		ug/kg	200	20.
1,2,4,5-Tetrachlorobenzene	ND		ug/kg	160	17.
Acetophenone	ND		ug/kg	160	20.
2,4,6-Trichlorophenol	ND		ug/kg	98	31.
p-Chloro-m-cresol	ND		ug/kg	160	24.
2-Chlorophenol	ND		ug/kg	160	19.
2,4-Dichlorophenol	ND		ug/kg	150	26.
2,4-Dimethylphenol	ND		ug/kg	160	54.
2-Nitrophenol	ND		ug/kg	350	62.

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331827
Report Date: 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 06/09/23 18:38
Analyst: JG

Extraction Method: EPA 3546
Extraction Date: 06/08/23 15:21

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 01-05,08 Batch: WG1788928-1					
4-Nitrophenol	ND		ug/kg	230	67.
2,4-Dinitrophenol	ND		ug/kg	790	76.
4,6-Dinitro-o-cresol	ND		ug/kg	430	79.
Pentachlorophenol	ND		ug/kg	130	36.
Phenol	ND		ug/kg	160	25.
2-Methylphenol	ND		ug/kg	160	25.
3-Methylphenol/4-Methylphenol	ND		ug/kg	240	26.
2,4,5-Trichlorophenol	ND		ug/kg	160	31.
Benzoic Acid	ND		ug/kg	530	160
Benzyl Alcohol	ND		ug/kg	160	50.
Carbazole	ND		ug/kg	160	16.
1,4-Dioxane	ND		ug/kg	24	7.5
Tentatively Identified Compounds					
No Tentatively Identified Compounds	ND		ug/kg		

Surrogate	%Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	92		25-120
Phenol-d6	87		10-120
Nitrobenzene-d5	76		23-120
2-Fluorobiphenyl	75		30-120
2,4,6-Tribromophenol	73		10-136
4-Terphenyl-d14	77		18-120

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331827
Report Date: 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 06/13/23 21:45
Analyst: LJG

Extraction Method: EPA 3546
Extraction Date: 06/13/23 01:00

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 01 Batch: WG1790396-1					
Acenaphthene	ND		ug/kg	130	17.
1,2,4-Trichlorobenzene	ND		ug/kg	160	19.
Hexachlorobenzene	ND		ug/kg	98	18.
Bis(2-chloroethyl)ether	ND		ug/kg	150	22.
2-Chloronaphthalene	ND		ug/kg	160	16.
1,2-Dichlorobenzene	ND		ug/kg	160	29.
1,3-Dichlorobenzene	ND		ug/kg	160	28.
1,4-Dichlorobenzene	ND		ug/kg	160	29.
3,3'-Dichlorobenzidine	ND		ug/kg	160	44.
2,4-Dinitrotoluene	ND		ug/kg	160	33.
2,6-Dinitrotoluene	ND		ug/kg	160	28.
Fluoranthene	ND		ug/kg	98	19.
4-Chlorophenyl phenyl ether	ND		ug/kg	160	18.
4-Bromophenyl phenyl ether	ND		ug/kg	160	25.
Bis(2-chloroisopropyl)ether	ND		ug/kg	200	28.
Bis(2-chloroethoxy)methane	ND		ug/kg	180	16.
Hexachlorobutadiene	ND		ug/kg	160	24.
Hexachlorocyclopentadiene	ND		ug/kg	470	150
Hexachloroethane	ND		ug/kg	130	26.
Isophorone	ND		ug/kg	150	21.
Naphthalene	ND		ug/kg	160	20.
Nitrobenzene	ND		ug/kg	150	24.
NDPA/DPA	ND		ug/kg	130	19.
n-Nitrosodi-n-propylamine	ND		ug/kg	160	25.
Bis(2-ethylhexyl)phthalate	ND		ug/kg	160	57.
Butyl benzyl phthalate	ND		ug/kg	160	41.
Di-n-butylphthalate	ND		ug/kg	160	31.
Di-n-octylphthalate	ND		ug/kg	160	56.
Diethyl phthalate	ND		ug/kg	160	15.

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331827
Report Date: 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 06/13/23 21:45
Analyst: LJG

Extraction Method: EPA 3546
Extraction Date: 06/13/23 01:00

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 01 Batch: WG1790396-1					
Dimethyl phthalate	ND		ug/kg	160	34.
Benzo(a)anthracene	ND		ug/kg	98	18.
Benzo(a)pyrene	ND		ug/kg	130	40.
Benzo(b)fluoranthene	ND		ug/kg	98	28.
Benzo(k)fluoranthene	ND		ug/kg	98	26.
Chrysene	ND		ug/kg	98	17.
Acenaphthylene	ND		ug/kg	130	25.
Anthracene	ND		ug/kg	98	32.
Benzo(ghi)perylene	ND		ug/kg	130	19.
Fluorene	ND		ug/kg	160	16.
Phenanthrene	ND		ug/kg	98	20.
Dibenzo(a,h)anthracene	ND		ug/kg	98	19.
Indeno(1,2,3-cd)pyrene	ND		ug/kg	130	23.
Pyrene	ND		ug/kg	98	16.
Biphenyl	ND		ug/kg	370	21.
4-Chloroaniline	ND		ug/kg	160	30.
2-Nitroaniline	ND		ug/kg	160	32.
3-Nitroaniline	ND		ug/kg	160	31.
4-Nitroaniline	ND		ug/kg	160	68.
Dibenzofuran	ND		ug/kg	160	16.
2-Methylnaphthalene	ND		ug/kg	200	20.
1,2,4,5-Tetrachlorobenzene	ND		ug/kg	160	17.
Acetophenone	ND		ug/kg	160	20.
2,4,6-Trichlorophenol	ND		ug/kg	98	31.
p-Chloro-m-cresol	ND		ug/kg	160	24.
2-Chlorophenol	ND		ug/kg	160	19.
2,4-Dichlorophenol	ND		ug/kg	150	26.
2,4-Dimethylphenol	ND		ug/kg	160	54.
2-Nitrophenol	ND		ug/kg	350	62.

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331827
Report Date: 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 06/13/23 21:45
Analyst: LJG

Extraction Method: EPA 3546
Extraction Date: 06/13/23 01:00

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 01 Batch: WG1790396-1					
4-Nitrophenol	ND		ug/kg	230	67.
2,4-Dinitrophenol	ND		ug/kg	790	76.
4,6-Dinitro-o-cresol	ND		ug/kg	430	79.
Pentachlorophenol	ND		ug/kg	130	36.
Phenol	ND		ug/kg	160	25.
2-Methylphenol	ND		ug/kg	160	25.
3-Methylphenol/4-Methylphenol	ND		ug/kg	240	26.
2,4,5-Trichlorophenol	ND		ug/kg	160	31.
Benzoic Acid	ND		ug/kg	530	170
Benzyl Alcohol	ND		ug/kg	160	50.
Carbazole	ND		ug/kg	160	16.
1,4-Dioxane	ND		ug/kg	25	7.5
Tentatively Identified Compounds					
No Tentatively Identified Compounds	ND		ug/kg		

Surrogate	%Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	83		25-120
Phenol-d6	78		10-120
Nitrobenzene-d5	82		23-120
2-Fluorobiphenyl	77		30-120
2,4,6-Tribromophenol	80		10-136
4-Terphenyl-d14	86		18-120

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331827
Report Date: 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E-SIM
Analytical Date: 06/14/23 10:55
Analyst: AH

Extraction Method: EPA 3510C
Extraction Date: 06/13/23 09:03

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS-SIM - Westborough Lab for sample(s): 06-07 Batch: WG1790588-1					
Acenaphthene	0.05	J	ug/l	0.10	0.01
2-Chloronaphthalene	0.03	J	ug/l	0.20	0.02
Fluoranthene	0.03	J	ug/l	0.10	0.02
Hexachlorobutadiene	ND		ug/l	0.50	0.05
Naphthalene	0.09	J	ug/l	0.10	0.05
Benzo(a)anthracene	0.08	J	ug/l	0.10	0.02
Benzo(a)pyrene	ND		ug/l	0.10	0.02
Benzo(b)fluoranthene	ND		ug/l	0.10	0.01
Benzo(k)fluoranthene	ND		ug/l	0.10	0.01
Chrysene	ND		ug/l	0.10	0.01
Acenaphthylene	0.01	J	ug/l	0.10	0.01
Anthracene	0.03	J	ug/l	0.10	0.01
Benzo(ghi)perylene	ND		ug/l	0.10	0.01
Fluorene	0.04	J	ug/l	0.10	0.01
Phenanthrene	0.06	J	ug/l	0.10	0.02
Dibenzo(a,h)anthracene	ND		ug/l	0.10	0.01
Indeno(1,2,3-cd)pyrene	ND		ug/l	0.10	0.01
Pyrene	ND		ug/l	0.10	0.02
2-Methylnaphthalene	0.09	J	ug/l	0.10	0.02
Pentachlorophenol	ND		ug/l	0.80	0.01
Hexachlorobenzene	0.07	J	ug/l	0.80	0.01
Hexachloroethane	ND		ug/l	0.80	0.06

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331827
Report Date: 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E-SIM
Analytical Date: 06/14/23 10:55
Analyst: AH

Extraction Method: EPA 3510C
Extraction Date: 06/13/23 09:03

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS-SIM - Westborough Lab for sample(s): 06-07 Batch: WG1790588-1					

Surrogate	%Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	43		21-120
Phenol-d6	37		10-120
Nitrobenzene-d5	60		23-120
2-Fluorobiphenyl	67		15-120
2,4,6-Tribromophenol	115		10-120
4-Terphenyl-d14	82		41-149

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331827
Report Date: 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 06/14/23 12:28
Analyst: JG

Extraction Method: EPA 3510C
Extraction Date: 06/13/23 09:08

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 06-07 Batch: WG1790589-1					
Acenaphthene	ND		ug/l	2.0	0.44
1,2,4-Trichlorobenzene	ND		ug/l	5.0	0.50
Hexachlorobenzene	ND		ug/l	2.0	0.46
Bis(2-chloroethyl)ether	ND		ug/l	2.0	0.50
2-Chloronaphthalene	ND		ug/l	2.0	0.44
1,2-Dichlorobenzene	ND		ug/l	2.0	0.45
1,3-Dichlorobenzene	ND		ug/l	2.0	0.40
1,4-Dichlorobenzene	ND		ug/l	2.0	0.43
3,3'-Dichlorobenzidine	ND		ug/l	5.0	1.6
2,4-Dinitrotoluene	ND		ug/l	5.0	1.2
2,6-Dinitrotoluene	ND		ug/l	5.0	0.93
Fluoranthene	ND		ug/l	2.0	0.26
4-Chlorophenyl phenyl ether	ND		ug/l	2.0	0.49
4-Bromophenyl phenyl ether	ND		ug/l	2.0	0.38
Bis(2-chloroisopropyl)ether	ND		ug/l	2.0	0.53
Bis(2-chloroethoxy)methane	ND		ug/l	5.0	0.50
Hexachlorobutadiene	ND		ug/l	2.0	0.66
Hexachlorocyclopentadiene	ND		ug/l	20	0.69
Hexachloroethane	ND		ug/l	2.0	0.58
Isophorone	ND		ug/l	5.0	1.2
Naphthalene	ND		ug/l	2.0	0.46
Nitrobenzene	ND		ug/l	2.0	0.77
NDPA/DPA	ND		ug/l	2.0	0.42
n-Nitrosodi-n-propylamine	ND		ug/l	5.0	0.64
Bis(2-ethylhexyl)phthalate	ND		ug/l	3.0	1.5
Butyl benzyl phthalate	ND		ug/l	5.0	1.2
Di-n-butylphthalate	ND		ug/l	5.0	0.39
Di-n-octylphthalate	ND		ug/l	5.0	1.3
Diethyl phthalate	ND		ug/l	5.0	0.38

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331827
Report Date: 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 06/14/23 12:28
Analyst: JG

Extraction Method: EPA 3510C
Extraction Date: 06/13/23 09:08

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 06-07 Batch: WG1790589-1					
Dimethyl phthalate	ND		ug/l	5.0	1.8
Benzo(a)anthracene	ND		ug/l	2.0	0.32
Benzo(a)pyrene	ND		ug/l	2.0	0.41
Benzo(b)fluoranthene	ND		ug/l	2.0	0.35
Benzo(k)fluoranthene	ND		ug/l	2.0	0.37
Chrysene	ND		ug/l	2.0	0.34
Acenaphthylene	ND		ug/l	2.0	0.46
Anthracene	ND		ug/l	2.0	0.33
Benzo(ghi)perylene	ND		ug/l	2.0	0.30
Fluorene	ND		ug/l	2.0	0.41
Phenanthrene	ND		ug/l	2.0	0.33
Dibenzo(a,h)anthracene	ND		ug/l	2.0	0.32
Indeno(1,2,3-cd)pyrene	ND		ug/l	2.0	0.40
Pyrene	ND		ug/l	2.0	0.28
Biphenyl	ND		ug/l	2.0	0.46
4-Chloroaniline	ND		ug/l	5.0	1.1
2-Nitroaniline	ND		ug/l	5.0	0.50
3-Nitroaniline	ND		ug/l	5.0	0.81
4-Nitroaniline	ND		ug/l	5.0	0.80
Dibenzofuran	ND		ug/l	2.0	0.50
2-Methylnaphthalene	ND		ug/l	2.0	0.45
1,2,4,5-Tetrachlorobenzene	ND		ug/l	10	0.44
Acetophenone	ND		ug/l	5.0	0.53
2,4,6-Trichlorophenol	ND		ug/l	5.0	0.61
p-Chloro-m-cresol	ND		ug/l	2.0	0.35
2-Chlorophenol	ND		ug/l	2.0	0.48
2,4-Dichlorophenol	ND		ug/l	5.0	0.41
2,4-Dimethylphenol	ND		ug/l	5.0	1.8
2-Nitrophenol	ND		ug/l	10	0.85

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331827
Report Date: 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 06/14/23 12:28
Analyst: JG

Extraction Method: EPA 3510C
Extraction Date: 06/13/23 09:08

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 06-07 Batch: WG1790589-1					
4-Nitrophenol	ND		ug/l	10	0.67
2,4-Dinitrophenol	ND		ug/l	20	6.6
4,6-Dinitro-o-cresol	ND		ug/l	10	1.8
Pentachlorophenol	ND		ug/l	10	1.8
Phenol	ND		ug/l	5.0	0.57
2-Methylphenol	ND		ug/l	5.0	0.49
3-Methylphenol/4-Methylphenol	ND		ug/l	5.0	0.48
2,4,5-Trichlorophenol	ND		ug/l	5.0	0.77
Benzoic Acid	ND		ug/l	50	2.6
Benzyl Alcohol	ND		ug/l	2.0	0.59
Carbazole	ND		ug/l	2.0	0.49

Tentatively Identified Compounds			
Total TIC Compounds	78.4	J	ug/l
Unknown	2.69	J	ug/l
Unknown	4.94	J	ug/l
Unknown	5.24	J	ug/l
Unknown	5.64	J	ug/l
Unknown	2.58	J	ug/l
Unknown	2.73	J	ug/l
Unknown	4.44	J	ug/l
Unknown	4.73	J	ug/l
Unknown	5.96	J	ug/l
Unknown	14.8	J	ug/l

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331827
Report Date: 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 06/14/23 12:28
Analyst: JG

Extraction Method: EPA 3510C
Extraction Date: 06/13/23 09:08

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 06-07 Batch: WG1790589-1					
Tentatively Identified Compounds					
Unknown	3.53	J	ug/l		
Unknown Organic Acid	6.98	J	ug/l		
Unknown	2.76	J	ug/l		
Unknown Organic Acid	8.80	J	ug/l		

Surrogate	%Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	40		21-120
Phenol-d6	34		10-120
Nitrobenzene-d5	52		23-120
2-Fluorobiphenyl	48		15-120
2,4,6-Tribromophenol	52		10-120
4-Terphenyl-d14	65		41-149

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331827
Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 01-05,08 Batch: WG1788928-2 WG1788928-3								
Acenaphthene	44		74		31-137	**51**	Q	50
1,2,4-Trichlorobenzene	41		71		38-107	**54**	Q	50
Hexachlorobenzene	**39**	Q	64		40-140	49		50
Bis(2-chloroethyl)ether	47		82		40-140	**54**	Q	50
2-Chloronaphthalene	44		72		40-140	48		50
1,2-Dichlorobenzene	45		75		40-140	50		50
1,3-Dichlorobenzene	45		75		40-140	50		50
1,4-Dichlorobenzene	44		73		28-104	50		50
3,3'-Dichlorobenzidine	46		78		40-140	**52**	Q	50
2,4-Dinitrotoluene	**39**	Q	71		40-132	**58**	Q	50
2,6-Dinitrotoluene	**37**	Q	67		40-140	**58**	Q	50
Fluoranthene	49		78		40-140	46		50
4-Chlorophenyl phenyl ether	41		71		40-140	**54**	Q	50
4-Bromophenyl phenyl ether	40		68		40-140	**52**	Q	50
Bis(2-chloroisopropyl)ether	55		95		40-140	**53**	Q	50
Bis(2-chloroethoxy)methane	47		84		40-117	**56**	Q	50
Hexachlorobutadiene	40		69		40-140	**53**	Q	50
Hexachlorocyclopentadiene	**10**	Q	**20**	Q	40-140	**70**	Q	50
Hexachloroethane	42		71		40-140	**51**	Q	50
Isophorone	47		82		40-140	**54**	Q	50
Naphthalene	45		76		40-140	**51**	Q	50
Nitrobenzene	46		80		40-140	**54**	Q	50
NDPA/DPA	44		76		36-157	**53**	Q	50

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331827
Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 01-05,08 Batch: WG1788928-2 WG1788928-3								
n-Nitrosodi-n-propylamine	52		91		32-121	**55**	Q	50
Bis(2-ethylhexyl)phthalate	51		85		40-140	50		50
Butyl benzyl phthalate	66		102		40-140	43		50
Di-n-butylphthalate	58		101		40-140	**54**	Q	50
Di-n-octylphthalate	58		91		40-140	44		50
Diethyl phthalate	50		87		40-140	**54**	Q	50
Dimethyl phthalate	43		75		40-140	**54**	Q	50
Benzo(a)anthracene	50		83		40-140	50		50
Benzo(a)pyrene	58		95		40-140	48		50
Benzo(b)fluoranthene	51		89		40-140	**54**	Q	50
Benzo(k)fluoranthene	53		79		40-140	39		50
Chrysene	48		80		40-140	50		50
Acenaphthylene	46		75		40-140	48		50
Anthracene	51		87		40-140	**52**	Q	50
Benzo(ghi)perylene	51		85		40-140	50		50
Fluorene	42		71		40-140	**51**	Q	50
Phenanthrene	50		83		40-140	50		50
Dibenzo(a,h)anthracene	49		82		40-140	50		50
Indeno(1,2,3-cd)pyrene	50		84		40-140	**51**	Q	50
Pyrene	50		79		35-142	45		50
Biphenyl	44		74		37-127	**51**	Q	50
4-Chloroaniline	**39**	Q	58		40-140	39		50
2-Nitroaniline	**45**	Q	79		47-134	**55**	Q	50

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331827
Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 01-05,08 Batch: WG1788928-2 WG1788928-3								
3-Nitroaniline	51		82		26-129	47		50
4-Nitroaniline	50		79		41-125	45		50
Dibenzofuran	43		74		40-140	**53**	Q	50
2-Methylnaphthalene	45		74		40-140	49		50
1,2,4,5-Tetrachlorobenzene	**38**	Q	62		40-117	48		50
Acetophenone	52		85		14-144	48		50
2,4,6-Trichlorophenol	49		72		30-130	38		50
p-Chloro-m-cresol	51		84		26-103	49		50
2-Chlorophenol	48		80		25-102	50		50
2,4-Dichlorophenol	46		75		30-130	48		50
2,4-Dimethylphenol	48		81		30-130	**51**	Q	50
2-Nitrophenol	**29**	Q	60		30-130	**70**	Q	50
4-Nitrophenol	47		76		11-114	47		50
2,4-Dinitrophenol	**0**	Q	12		4-130	NC		50
4,6-Dinitro-o-cresol	**3**	Q	11		10-130	**121**	Q	50
Pentachlorophenol	32		48		17-109	40		50
Phenol	47		81		26-90	**53**	Q	50
2-Methylphenol	44		76		30-130.	**53**	Q	50
3-Methylphenol/4-Methylphenol	45		80		30-130	**56**	Q	50
2,4,5-Trichlorophenol	45		72		30-130	46		50
Benzoic Acid	18		19		10-110	5		50
Benzyl Alcohol	51		84		40-140	49		50
Carbazole	**53**	Q	88		54-128	50		50

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331827
Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 01-05,08 Batch: WG1788928-2 WG1788928-3								
1,4-Dioxane	45		67		40-140	39		50

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
2-Fluorophenol	49		84		25-120
Phenol-d6	46		79		10-120
Nitrobenzene-d5	45		80		23-120
2-Fluorobiphenyl	40		67		30-120
2,4,6-Tribromophenol	48		71		10-136
4-Terphenyl-d14	47		74		18-120

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331827
Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 01 Batch: WG1790396-2 WG1790396-3								
Acenaphthene	67		83		31-137	21		50
1,2,4-Trichlorobenzene	61		77		38-107	23		50
Hexachlorobenzene	62		74		40-140	18		50
Bis(2-chloroethyl)ether	60		78		40-140	26		50
2-Chloronaphthalene	67		80		40-140	18		50
1,2-Dichlorobenzene	59		76		40-140	25		50
1,3-Dichlorobenzene	60		77		40-140	25		50
1,4-Dichlorobenzene	59		77		28-104	26		50
3,3'-Dichlorobenzidine	57		70		40-140	20		50
2,4-Dinitrotoluene	95		113		40-132	17		50
2,6-Dinitrotoluene	82		101		40-140	21		50
Fluoranthene	67		82		40-140	20		50
4-Chlorophenyl phenyl ether	66		80		40-140	19		50
4-Bromophenyl phenyl ether	66		78		40-140	17		50
Bis(2-chloroisopropyl)ether	61		75		40-140	21		50
Bis(2-chloroethoxy)methane	62		77		40-117	22		50
Hexachlorobutadiene	64		78		40-140	20		50
Hexachlorocyclopentadiene	77		95		40-140	21		50
Hexachloroethane	64		80		40-140	22		50
Isophorone	58		71		40-140	20		50
Naphthalene	63		79		40-140	23		50
Nitrobenzene	66		82		40-140	22		50
NDPA/DPA	68		80		36-157	16		50

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331827
Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 01 Batch: WG1790396-2 WG1790396-3								
n-Nitrosodi-n-propylamine	62		78		32-121	23		50
Bis(2-ethylhexyl)phthalate	91		103		40-140	12		50
Butyl benzyl phthalate	79		87		40-140	10		50
Di-n-butylphthalate	80		93		40-140	15		50
Di-n-octylphthalate	95		111		40-140	16		50
Diethyl phthalate	69		82		40-140	17		50
Dimethyl phthalate	69		80		40-140	15		50
Benzo(a)anthracene	73		89		40-140	20		50
Benzo(a)pyrene	80		101		40-140	23		50
Benzo(b)fluoranthene	72		90		40-140	22		50
Benzo(k)fluoranthene	74		91		40-140	21		50
Chrysene	70		86		40-140	21		50
Acenaphthylene	70		83		40-140	17		50
Anthracene	69		84		40-140	20		50
Benzo(ghi)perylene	70		92		40-140	27		50
Fluorene	64		77		40-140	18		50
Phenanthrene	67		82		40-140	20		50
Dibenzo(a,h)anthracene	69		89		40-140	25		50
Indeno(1,2,3-cd)pyrene	70		91		40-140	26		50
Pyrene	66		80		35-142	19		50
Biphenyl	67		79		37-127	16		50
4-Chloroaniline	**38**	Q	50		40-140	27		50
2-Nitroaniline	84		103		47-134	20		50

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331827
Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 01 Batch: WG1790396-2 WG1790396-3								
3-Nitroaniline	64		77		26-129	18		50
4-Nitroaniline	75		89		41-125	17		50
Dibenzofuran	64		79		40-140	21		50
2-Methylnaphthalene	67		81		40-140	19		50
1,2,4,5-Tetrachlorobenzene	68		80		40-117	16		50
Acetophenone	65		81		14-144	22		50
2,4,6-Trichlorophenol	76		90		30-130	17		50
p-Chloro-m-cresol	73		86		26-103	16		50
2-Chlorophenol	66		85		25-102	25		50
2,4-Dichlorophenol	68		83		30-130	20		50
2,4-Dimethylphenol	62		76		30-130	20		50
2-Nitrophenol	83		104		30-130	22		50
4-Nitrophenol	67		83		11-114	21		50
2,4-Dinitrophenol	70		89		4-130	24		50
4,6-Dinitro-o-cresol	99		118		10-130	18		50
Pentachlorophenol	75		87		17-109	15		50
Phenol	63		81		26-90	25		50
2-Methylphenol	61		76		30-130.	22		50
3-Methylphenol/4-Methylphenol	64		78		30-130	20		50
2,4,5-Trichlorophenol	76		93		30-130	20		50
Benzoic Acid	17		16		10-110	6		50
Benzyl Alcohol	63		79		40-140	23		50
Carbazole	68		83		54-128	20		50

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331827
Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 01 Batch: WG1790396-2 WG1790396-3								
1,4-Dioxane	52		66		40-140	24		50

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
2-Fluorophenol	70		88		25-120
Phenol-d6	65		81		10-120
Nitrobenzene-d5	69		84		23-120
2-Fluorobiphenyl	66		76		30-120
2,4,6-Tribromophenol	68		79		10-136
4-Terphenyl-d14	63		71		18-120

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331827
Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS-SIM - Westborough Lab Associated sample(s): 06-07 Batch: WG1790588-2 WG1790588-3								
Acenaphthene	65		66		40-140	2		40
2-Chloronaphthalene	76		78		40-140	3		40
Fluoranthene	81		82		40-140	1		40
Hexachlorobutadiene	81		80		40-140	1		40
Naphthalene	64		64		40-140	0		40
Benzo(a)anthracene	79		80		40-140	1		40
Benzo(a)pyrene	80		79		40-140	1		40
Benzo(b)fluoranthene	80		80		40-140	0		40
Benzo(k)fluoranthene	80		80		40-140	0		40
Chrysene	72		73		40-140	1		40
Acenaphthylene	80		81		40-140	1		40
Anthracene	69		72		40-140	4		40
Benzo(ghi)perylene	74		76		40-140	3		40
Fluorene	74		75		40-140	1		40
Phenanthrene	67		68		40-140	1		40
Dibenzo(a,h)anthracene	77		77		40-140	0		40
Indeno(1,2,3-cd)pyrene	72		72		40-140	0		40
Pyrene	81		82		40-140	1		40
2-Methylnaphthalene	73		74		40-140	1		40
Pentachlorophenol	112		110		40-140	2		40
Hexachlorobenzene	76		77		40-140	1		40
Hexachloroethane	56		56		40-140	0		40

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331827
Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS-SIM - Westborough Lab Associated sample(s): 06-07 Batch: WG1790588-2 WG1790588-3								

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
2-Fluorophenol	57		52		21-120
Phenol-d6	47		46		10-120
Nitrobenzene-d5	68		68		23-120
2-Fluorobiphenyl	74		76		15-120
2,4,6-Tribromophenol	117		120		10-120
4-Terphenyl-d14	85		84		41-149

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331827

Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 06-07 Batch: WG1790589-2 WG1790589-3								
Acenaphthene	65		67		37-111	3		30
1,2,4-Trichlorobenzene	59		58		39-98	2		30
Hexachlorobenzene	56		60		40-140	7		30
Bis(2-chloroethyl)ether	59		58		40-140	2		30
2-Chloronaphthalene	58		58		40-140	0		30
1,2-Dichlorobenzene	62		59		40-140	5		30
1,3-Dichlorobenzene	60		58		40-140	3		30
1,4-Dichlorobenzene	62		57		36-97	8		30
3,3'-Dichlorobenzidine	46		61		40-140	28		30
2,4-Dinitrotoluene	82		86		48-143	5		30
2,6-Dinitrotoluene	68		72		40-140	6		30
Fluoranthene	71		74		40-140	4		30
4-Chlorophenyl phenyl ether	60		62		40-140	3		30
4-Bromophenyl phenyl ether	54		56		40-140	4		30
Bis(2-chloroisopropyl)ether	86		82		40-140	5		30
Bis(2-chloroethoxy)methane	63		64		40-140	2		30
Hexachlorobutadiene	42		42		40-140	0		30
Hexachlorocyclopentadiene	**39**	Q	**38**	Q	40-140	3		30
Hexachloroethane	60		60		40-140	0		30
Isophorone	55		56		40-140	2		30
Naphthalene	58		61		40-140	5		30
Nitrobenzene	59		62		40-140	5		30
NDPA/DPA	60		70		40-140	15		30

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331827

Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 06-07 Batch: WG1790589-2 WG1790589-3								
n-Nitrosodi-n-propylamine	57		57		29-132	0		30
Bis(2-ethylhexyl)phthalate	109		109		40-140	0		30
Butyl benzyl phthalate	100		101		40-140	1		30
Di-n-butylphthalate	91		92		40-140	1		30
Di-n-octylphthalate	104		105		40-140	1		30
Diethyl phthalate	80		81		40-140	1		30
Dimethyl phthalate	68		70		40-140	3		30
Benzo(a)anthracene	76		77		40-140	1		30
Benzo(a)pyrene	78		82		40-140	5		30
Benzo(b)fluoranthene	75		83		40-140	10		30
Benzo(k)fluoranthene	81		77		40-140	5		30
Chrysene	76		79		40-140	4		30
Acenaphthylene	62		66		45-123	6		30
Anthracene	72		75		40-140	4		30
Benzo(ghi)perylene	84		84		40-140	0		30
Fluorene	69		69		40-140	0		30
Phenanthrene	75		77		40-140	3		30
Dibenzo(a,h)anthracene	85		84		40-140	1		30
Indeno(1,2,3-cd)pyrene	81		86		40-140	6		30
Pyrene	72		75		26-127	4		30
Biphenyl	56		56		40-140	0		30
4-Chloroaniline	51		56		40-140	9		30
2-Nitroaniline	70		72		52-143	3		30

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331827
Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 06-07 Batch: WG1790589-2 WG1790589-3								
3-Nitroaniline	75		79		25-145	5		30
4-Nitroaniline	81		86		51-143	6		30
Dibenzofuran	68		69		40-140	1		30
2-Methylnaphthalene	63		64		40-140	2		30
1,2,4,5-Tetrachlorobenzene	42		44		2-134	5		30
Acetophenone	53		52		39-129	2		30
2,4,6-Trichlorophenol	57		59		30-130	3		30
p-Chloro-m-cresol	64		65		23-97	2		30
2-Chlorophenol	66		65		27-123	2		30
2,4-Dichlorophenol	66		66		30-130	0		30
2,4-Dimethylphenol	51		59		30-130	15		30
2-Nitrophenol	73		75		30-130	3		30
4-Nitrophenol	**85**	Q	**89**	Q	10-80	5		30
2,4-Dinitrophenol	75		74		20-130	1		30
4,6-Dinitro-o-cresol	82		83		20-164	1		30
Pentachlorophenol	70		69		9-103	1		30
Phenol	46		45		12-110	2		30
2-Methylphenol	58		61		30-130	5		30
3-Methylphenol/4-Methylphenol	60		62		30-130	3		30
2,4,5-Trichlorophenol	58		61		30-130	5		30
Benzoic Acid	74		67		10-164	10		30
Benzyl Alcohol	52		50		26-116	4		30
Carbazole	84		86		55-144	2		30

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331827
Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 06-07 Batch: WG1790589-2 WG1790589-3								

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
2-Fluorophenol	51		48		21-120
Phenol-d6	44		42		10-120
Nitrobenzene-d5	60		57		23-120
2-Fluorobiphenyl	53		53		15-120
2,4,6-Tribromophenol	63		64		10-120
4-Terphenyl-d14	66		67		41-149

PCBS

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331827
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-01
Client ID: SB-39 (0.5-1)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/07/23 09:05
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8082A
Analytical Date: 06/09/23 12:06
Analyst: JM
Percent Solids: 94%

Extraction Method: EPA 3546
Extraction Date: 06/09/23 00:23
Cleanup Method: EPA 3665A
Cleanup Date: 06/09/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/09/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/kg	50.6	4.49	1	A
Aroclor 1221	ND		ug/kg	50.6	5.07	1	A
Aroclor 1232	ND		ug/kg	50.6	10.7	1	A
Aroclor 1242	ND		ug/kg	50.6	6.82	1	A
Aroclor 1248	ND		ug/kg	50.6	7.59	1	A
Aroclor 1254	ND		ug/kg	50.6	5.53	1	A
Aroclor 1260	ND		ug/kg	50.6	9.35	1	A
Aroclor 1262	ND		ug/kg	50.6	6.42	1	A
Aroclor 1268	ND		ug/kg	50.6	5.24	1	A
PCBs, Total	ND		ug/kg	50.6	4.49	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	70		30-150	A
Decachlorobiphenyl	64		30-150	A
2,4,5,6-Tetrachloro-m-xylene	74		30-150	B
Decachlorobiphenyl	68		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331827
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-02
Client ID: SB-40 (1-1.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/07/23 10:05
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8082A
Analytical Date: 06/09/23 12:14
Analyst: JM
Percent Solids: 93%

Extraction Method: EPA 3546
Extraction Date: 06/09/23 00:23
Cleanup Method: EPA 3665A
Cleanup Date: 06/09/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/09/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/kg	52.8	4.69	1	A
Aroclor 1221	ND		ug/kg	52.8	5.29	1	A
Aroclor 1232	ND		ug/kg	52.8	11.2	1	A
Aroclor 1242	ND		ug/kg	52.8	7.12	1	A
Aroclor 1248	ND		ug/kg	52.8	7.92	1	A
Aroclor 1254	ND		ug/kg	52.8	5.78	1	A
Aroclor 1260	ND		ug/kg	52.8	9.76	1	B
Aroclor 1262	ND		ug/kg	52.8	6.71	1	A
Aroclor 1268	ND		ug/kg	52.8	5.47	1	A
PCBs, Total	ND		ug/kg	52.8	4.69	1	B

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	72		30-150	A
Decachlorobiphenyl	67		30-150	A
2,4,5,6-Tetrachloro-m-xylene	74		30-150	B
Decachlorobiphenyl	69		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331827
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-03
Client ID: SB-41 (2.5-3)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/07/23 10:20
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8082A
Analytical Date: 06/11/23 14:29
Analyst: JM
Percent Solids: 94%

Extraction Method: EPA 3546
Extraction Date: 06/09/23 08:53
Cleanup Method: EPA 3665A
Cleanup Date: 06/10/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/10/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/kg	50.5	4.48	1	A
Aroclor 1221	ND		ug/kg	50.5	5.06	1	A
Aroclor 1232	ND		ug/kg	50.5	10.7	1	A
Aroclor 1242	ND		ug/kg	50.5	6.81	1	A
Aroclor 1248	ND		ug/kg	50.5	7.58	1	A
Aroclor 1254	ND		ug/kg	50.5	5.53	1	A
Aroclor 1260	ND		ug/kg	50.5	9.34	1	A
Aroclor 1262	ND		ug/kg	50.5	6.42	1	A
Aroclor 1268	ND		ug/kg	50.5	5.23	1	A
PCBs, Total	ND		ug/kg	50.5	4.48	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	68		30-150	A
Decachlorobiphenyl	66		30-150	A
2,4,5,6-Tetrachloro-m-xylene	64		30-150	B
Decachlorobiphenyl	68		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331827
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-04
Client ID: SB-42 (2-2.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/07/23 10:50
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8082A
Analytical Date: 06/09/23 12:22
Analyst: JM
Percent Solids: 93%

Extraction Method: EPA 3546
Extraction Date: 06/09/23 00:23
Cleanup Method: EPA 3665A
Cleanup Date: 06/09/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/09/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/kg	50.4	4.48	1	A
Aroclor 1221	ND		ug/kg	50.4	5.05	1	A
Aroclor 1232	ND		ug/kg	50.4	10.7	1	A
Aroclor 1242	ND		ug/kg	50.4	6.80	1	A
Aroclor 1248	ND		ug/kg	50.4	7.56	1	A
Aroclor 1254	ND		ug/kg	50.4	5.52	1	A
Aroclor 1260	ND		ug/kg	50.4	9.32	1	B
Aroclor 1262	ND		ug/kg	50.4	6.40	1	A
Aroclor 1268	ND		ug/kg	50.4	5.22	1	B
PCBs, Total	ND		ug/kg	50.4	4.48	1	B

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	69		30-150	A
Decachlorobiphenyl	67		30-150	A
2,4,5,6-Tetrachloro-m-xylene	70		30-150	B
Decachlorobiphenyl	69		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331827
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-05
Client ID: SB-43 (5-5.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/07/23 11:30
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8082A
Analytical Date: 06/09/23 12:30
Analyst: JM
Percent Solids: 95%

Extraction Method: EPA 3546
Extraction Date: 06/09/23 00:23
Cleanup Method: EPA 3665A
Cleanup Date: 06/09/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/09/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/kg	49.6	4.40	1	A
Aroclor 1221	ND		ug/kg	49.6	4.97	1	A
Aroclor 1232	ND		ug/kg	49.6	10.5	1	A
Aroclor 1242	ND		ug/kg	49.6	6.68	1	A
Aroclor 1248	ND		ug/kg	49.6	7.44	1	A
Aroclor 1254	ND		ug/kg	49.6	5.42	1	A
Aroclor 1260	ND		ug/kg	49.6	9.16	1	B
Aroclor 1262	ND		ug/kg	49.6	6.30	1	A
Aroclor 1268	ND		ug/kg	49.6	5.14	1	A
PCBs, Total	ND		ug/kg	49.6	4.40	1	B

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	67		30-150	A
Decachlorobiphenyl	58		30-150	A
2,4,5,6-Tetrachloro-m-xylene	68		30-150	B
Decachlorobiphenyl	61		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331827
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-06
Client ID: GW-14
Sample Location: WHITE PLAINS, NY

Date Collected: 06/07/23 09:20
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8082A
Analytical Date: 06/13/23 09:15
Analyst: MEO

Extraction Method: EPA 3510C
Extraction Date: 06/12/23 03:10
Cleanup Method: EPA 3665A
Cleanup Date: 06/12/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/13/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/l	0.071	0.061	1	A
Aroclor 1221	ND		ug/l	0.071	0.061	1	A
Aroclor 1232	ND		ug/l	0.071	0.061	1	A
Aroclor 1242	ND		ug/l	0.071	0.061	1	A
Aroclor 1248	ND		ug/l	0.071	0.061	1	A
Aroclor 1254	ND		ug/l	0.071	0.061	1	A
Aroclor 1260	ND		ug/l	0.071	0.061	1	A
Aroclor 1262	ND		ug/l	0.071	0.061	1	A
Aroclor 1268	ND		ug/l	0.071	0.061	1	A
PCBs, Total	ND		ug/l	0.071	0.061	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	61		30-150	A
Decachlorobiphenyl	45		30-150	A
2,4,5,6-Tetrachloro-m-xylene	63		30-150	B
Decachlorobiphenyl	48		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331827
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-07
Client ID: GW-15
Sample Location: WHITE PLAINS, NY

Date Collected: 06/07/23 11:45
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8082A
Analytical Date: 06/13/23 09:24
Analyst: MEO

Extraction Method: EPA 3510C
Extraction Date: 06/12/23 03:10
Cleanup Method: EPA 3665A
Cleanup Date: 06/12/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/13/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/l	0.071	0.061	1	A
Aroclor 1221	ND		ug/l	0.071	0.061	1	A
Aroclor 1232	ND		ug/l	0.071	0.061	1	A
Aroclor 1242	ND		ug/l	0.071	0.061	1	A
Aroclor 1248	ND		ug/l	0.071	0.061	1	A
Aroclor 1254	ND		ug/l	0.071	0.061	1	A
Aroclor 1260	ND		ug/l	0.071	0.061	1	A
Aroclor 1262	ND		ug/l	0.071	0.061	1	A
Aroclor 1268	ND		ug/l	0.071	0.061	1	A
PCBs, Total	ND		ug/l	0.071	0.061	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	60		30-150	A
Decachlorobiphenyl	44		30-150	A
2,4,5,6-Tetrachloro-m-xylene	62		30-150	B
Decachlorobiphenyl	48		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331827
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-08
Client ID: SB-26G (1.5-2)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/07/23 12:45
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8082A
Analytical Date: 06/09/23 12:38
Analyst: JM
Percent Solids: 95%

Extraction Method: EPA 3546
Extraction Date: 06/09/23 00:23
Cleanup Method: EPA 3665A
Cleanup Date: 06/09/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/09/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/kg	48.8	4.34	1	A
Aroclor 1221	ND		ug/kg	48.8	4.90	1	A
Aroclor 1232	ND		ug/kg	48.8	10.4	1	A
Aroclor 1242	ND		ug/kg	48.8	6.58	1	A
Aroclor 1248	ND		ug/kg	48.8	7.33	1	A
Aroclor 1254	ND		ug/kg	48.8	5.34	1	A
Aroclor 1260	ND		ug/kg	48.8	9.03	1	A
Aroclor 1262	ND		ug/kg	48.8	6.20	1	A
Aroclor 1268	ND		ug/kg	48.8	5.06	1	A
PCBs, Total	ND		ug/kg	48.8	4.34	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	68		30-150	A
Decachlorobiphenyl	58		30-150	A
2,4,5,6-Tetrachloro-m-xylene	68		30-150	B
Decachlorobiphenyl	60		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331827
Report Date: 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8082A
Analytical Date: 06/09/23 11:42
Analyst: JM

Extraction Method: EPA 3546
Extraction Date: 06/08/23 19:15
Cleanup Method: EPA 3665A
Cleanup Date: 06/09/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/09/23

Parameter	Result	Qualifier	Units	RL	MDL	Column
Polychlorinated Biphenyls by GC - Westborough Lab for sample(s): 01-05,08 Batch: WG1789006-1						
Aroclor 1016	ND		ug/kg	48.4	4.30	A
Aroclor 1221	ND		ug/kg	48.4	4.85	A
Aroclor 1232	ND		ug/kg	48.4	10.3	A
Aroclor 1242	ND		ug/kg	48.4	6.53	A
Aroclor 1248	ND		ug/kg	48.4	7.27	A
Aroclor 1254	ND		ug/kg	48.4	5.30	A
Aroclor 1260	ND		ug/kg	48.4	8.95	A
Aroclor 1262	ND		ug/kg	48.4	6.15	A
Aroclor 1268	ND		ug/kg	48.4	5.02	A
PCBs, Total	ND		ug/kg	48.4	4.30	A

Surrogate	%Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	78		30-150	A
Decachlorobiphenyl	77		30-150	A
2,4,5,6-Tetrachloro-m-xylene	79		30-150	B
Decachlorobiphenyl	77		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331827
Report Date: 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8082A
Analytical Date: 06/13/23 08:37
Analyst: MEO

Extraction Method: EPA 3510C
Extraction Date: 06/12/23 03:06
Cleanup Method: EPA 3665A
Cleanup Date: 06/12/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/13/23

Parameter	Result	Qualifier	Units	RL	MDL	Column
Polychlorinated Biphenyls by GC - Westborough Lab for sample(s): 06-07 Batch: WG1789936-1						
Aroclor 1016	ND		ug/l	0.071	0.061	A
Aroclor 1221	ND		ug/l	0.071	0.061	A
Aroclor 1232	ND		ug/l	0.071	0.061	A
Aroclor 1242	ND		ug/l	0.071	0.061	A
Aroclor 1248	ND		ug/l	0.071	0.061	A
Aroclor 1254	ND		ug/l	0.071	0.061	A
Aroclor 1260	ND		ug/l	0.071	0.061	A
Aroclor 1262	ND		ug/l	0.071	0.061	A
Aroclor 1268	ND		ug/l	0.071	0.061	A
PCBs, Total	ND		ug/l	0.071	0.061	A

Surrogate	%Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	56		30-150	A
Decachlorobiphenyl	67		30-150	A
2,4,5,6-Tetrachloro-m-xylene	58		30-150	B
Decachlorobiphenyl	71		30-150	B

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331827
Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits	Column
Polychlorinated Biphenyls by GC - Westborough Lab Associated sample(s): 01-05,08 Batch: WG1789006-2 WG1789006-3									
Aroclor 1016	80		76		40-140	5		50	A
Aroclor 1260	72		71		40-140	1		50	A

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	78		78		30-150	A
Decachlorobiphenyl	75		74		30-150	A
2,4,5,6-Tetrachloro-m-xylene	79		78		30-150	B
Decachlorobiphenyl	76		74		30-150	B

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331827
Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits	Column
Polychlorinated Biphenyls by GC - Westborough Lab Associated sample(s): 06-07 Batch: WG1789936-2 WG1789936-3									
Aroclor 1016	60		63		40-140	5		50	A
Aroclor 1260	59		62		40-140	6		50	A

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	57		57		30-150	A
Decachlorobiphenyl	67		70		30-150	A
2,4,5,6-Tetrachloro-m-xylene	57		59		30-150	B
Decachlorobiphenyl	70		72		30-150	B

PESTICIDES

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331827
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-01
Client ID: SB-39 (0.5-1)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/07/23 09:05
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8081B
Analytical Date: 06/10/23 23:14
Analyst: MMG
Percent Solids: 94%

Extraction Method: EPA 3546
Extraction Date: 06/09/23 01:27
Cleanup Method: EPA 3620B
Cleanup Date: 06/10/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/10/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/kg	1.66	0.325	1	A
Lindane	ND		ug/kg	0.691	0.309	1	A
Alpha-BHC	ND		ug/kg	0.691	0.196	1	A
Beta-BHC	ND		ug/kg	1.66	0.629	1	A
Heptachlor	ND		ug/kg	0.829	0.372	1	A
Aldrin	ND		ug/kg	1.66	0.584	1	A
Heptachlor epoxide	ND		ug/kg	3.11	0.933	1	A
Endrin	ND		ug/kg	0.691	0.283	1	A
Endrin aldehyde	ND		ug/kg	2.07	0.725	1	A
Endrin ketone	ND		ug/kg	1.66	0.427	1	A
Dieldrin	ND		ug/kg	1.04	0.518	1	A
4,4'-DDE	ND		ug/kg	1.66	0.383	1	A
4,4'-DDD	ND		ug/kg	1.66	0.591	1	A
4,4'-DDT	ND		ug/kg	1.66	1.33	1	A
Endosulfan I	ND		ug/kg	1.66	0.392	1	A
Endosulfan II	ND		ug/kg	1.66	0.554	1	A
Endosulfan sulfate	ND		ug/kg	0.691	0.329	1	A
Methoxychlor	ND		ug/kg	3.11	0.967	1	A
Toxaphene	ND		ug/kg	31.1	8.70	1	A
cis-Chlordane	ND		ug/kg	2.07	0.578	1	A
trans-Chlordane	ND		ug/kg	2.07	0.547	1	A
Chlordane	ND		ug/kg	13.8	5.49	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-01 Date Collected: 06/07/23 09:05

Client ID: SB-39 (0.5-1) Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	66		30-150	A
Decachlorobiphenyl	87		30-150	A
2,4,5,6-Tetrachloro-m-xylene	62		30-150	B
Decachlorobiphenyl	74		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331827
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-02
Client ID: SB-40 (1-1.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/07/23 10:05
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8081B
Analytical Date: 06/10/23 23:25
Analyst: MMG
Percent Solids: 93%

Extraction Method: EPA 3546
Extraction Date: 06/09/23 01:27
Cleanup Method: EPA 3620B
Cleanup Date: 06/10/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/10/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/kg	1.66	0.326	1	A
Lindane	ND		ug/kg	0.693	0.310	1	A
Alpha-BHC	ND		ug/kg	0.693	0.197	1	A
Beta-BHC	ND		ug/kg	1.66	0.631	1	A
Heptachlor	ND		ug/kg	0.832	0.373	1	A
Aldrin	ND		ug/kg	1.66	0.586	1	A
Heptachlor epoxide	ND		ug/kg	3.12	0.936	1	A
Endrin	ND		ug/kg	0.693	0.284	1	A
Endrin aldehyde	ND		ug/kg	2.08	0.728	1	A
Endrin ketone	ND		ug/kg	1.66	0.428	1	A
Dieldrin	ND		ug/kg	1.04	0.520	1	A
4,4'-DDE	ND		ug/kg	1.66	0.385	1	A
4,4'-DDD	ND		ug/kg	1.66	0.593	1	A
4,4'-DDT	1.38	J	ug/kg	1.66	1.34	1	B
Endosulfan I	ND		ug/kg	1.66	0.393	1	A
Endosulfan II	ND		ug/kg	1.66	0.556	1	A
Endosulfan sulfate	ND		ug/kg	0.693	0.330	1	A
Methoxychlor	ND		ug/kg	3.12	0.970	1	A
Toxaphene	ND		ug/kg	31.2	8.74	1	A
cis-Chlordane	ND		ug/kg	2.08	0.580	1	A
trans-Chlordane	ND		ug/kg	2.08	0.549	1	A
Chlordane	ND		ug/kg	13.9	5.51	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-02 Date Collected: 06/07/23 10:05

Client ID: SB-40 (1-1.5) Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	39		30-150	A
Decachlorobiphenyl	51		30-150	A
2,4,5,6-Tetrachloro-m-xylene	37		30-150	B
Decachlorobiphenyl	44		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331827
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-03
Client ID: SB-41 (2.5-3)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/07/23 10:20
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8081B
Analytical Date: 06/10/23 23:36
Analyst: MMG
Percent Solids: 94%

Extraction Method: EPA 3546
Extraction Date: 06/09/23 01:27
Cleanup Method: EPA 3620B
Cleanup Date: 06/10/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/10/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/kg	1.63	0.319	1	A
Lindane	ND		ug/kg	0.679	0.303	1	A
Alpha-BHC	ND		ug/kg	0.679	0.193	1	A
Beta-BHC	ND		ug/kg	1.63	0.618	1	A
Heptachlor	ND		ug/kg	0.815	0.365	1	A
Aldrin	ND		ug/kg	1.63	0.574	1	A
Heptachlor epoxide	ND		ug/kg	3.06	0.916	1	A
Endrin	ND		ug/kg	0.679	0.278	1	A
Endrin aldehyde	ND		ug/kg	2.04	0.713	1	A
Endrin ketone	ND		ug/kg	1.63	0.420	1	A
Dieldrin	ND		ug/kg	1.02	0.509	1	A
4,4'-DDE	1.09	J	ug/kg	1.63	0.377	1	A
4,4'-DDD	ND		ug/kg	1.63	0.581	1	A
4,4'-DDT	5.27		ug/kg	1.63	1.31	1	A
Endosulfan I	ND		ug/kg	1.63	0.385	1	A
Endosulfan II	ND		ug/kg	1.63	0.544	1	A
Endosulfan sulfate	ND		ug/kg	0.679	0.323	1	A
Methoxychlor	ND		ug/kg	3.06	0.950	1	A
Toxaphene	ND		ug/kg	30.6	8.55	1	A
cis-Chlordane	1.06	J	ug/kg	2.04	0.568	1	A
trans-Chlordane	1.34	JIP	ug/kg	2.04	0.538	1	B
Chlordane	ND		ug/kg	13.6	5.40	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-03 Date Collected: 06/07/23 10:20

Client ID: SB-41 (2.5-3) Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	66		30-150	A
Decachlorobiphenyl	81		30-150	A
2,4,5,6-Tetrachloro-m-xylene	65		30-150	B
Decachlorobiphenyl	80		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331827
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-04
Client ID: SB-42 (2-2.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/07/23 10:50
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8081B
Analytical Date: 06/10/23 23:47
Analyst: MMG
Percent Solids: 93%

Extraction Method: EPA 3546
Extraction Date: 06/09/23 01:27
Cleanup Method: EPA 3620B
Cleanup Date: 06/10/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/10/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/kg	1.66	0.324	1	A
Lindane	ND		ug/kg	0.691	0.309	1	A
Alpha-BHC	ND		ug/kg	0.691	0.196	1	A
Beta-BHC	ND		ug/kg	1.66	0.628	1	A
Heptachlor	ND		ug/kg	0.829	0.372	1	A
Aldrin	ND		ug/kg	1.66	0.584	1	A
Heptachlor epoxide	ND		ug/kg	3.11	0.932	1	A
Endrin	ND		ug/kg	0.691	0.283	1	A
Endrin aldehyde	ND		ug/kg	2.07	0.725	1	A
Endrin ketone	ND		ug/kg	1.66	0.427	1	A
Dieldrin	ND		ug/kg	1.04	0.518	1	A
4,4'-DDE	2.84		ug/kg	1.66	0.383	1	B
4,4'-DDD	7.81		ug/kg	1.66	0.591	1	A
4,4'-DDT	11.4		ug/kg	1.66	1.33	1	B
Endosulfan I	ND		ug/kg	1.66	0.392	1	A
Endosulfan II	ND		ug/kg	1.66	0.554	1	A
Endosulfan sulfate	ND		ug/kg	0.691	0.329	1	A
Methoxychlor	ND		ug/kg	3.11	0.967	1	A
Toxaphene	ND		ug/kg	31.1	8.70	1	A
cis-Chlordane	1.18	J	ug/kg	2.07	0.577	1	A
trans-Chlordane	2.04	JIP	ug/kg	2.07	0.547	1	B
Chlordane	ND		ug/kg	13.8	5.49	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-04 Date Collected: 06/07/23 10:50

Client ID: SB-42 (2-2.5) Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	71		30-150	A
Decachlorobiphenyl	87		30-150	A
2,4,5,6-Tetrachloro-m-xylene	68		30-150	B
Decachlorobiphenyl	82		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331827
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-05
Client ID: SB-43 (5-5.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/07/23 11:30
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8081B
Analytical Date: 06/10/23 23:59
Analyst: MMG
Percent Solids: 95%

Extraction Method: EPA 3546
Extraction Date: 06/09/23 01:27
Cleanup Method: EPA 3620B
Cleanup Date: 06/10/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/10/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/kg	1.65	0.324	1	A
Lindane	ND		ug/kg	0.689	0.308	1	A
Alpha-BHC	ND		ug/kg	0.689	0.196	1	A
Beta-BHC	ND		ug/kg	1.65	0.627	1	A
Heptachlor	ND		ug/kg	0.827	0.371	1	A
Aldrin	ND		ug/kg	1.65	0.582	1	A
Heptachlor epoxide	ND		ug/kg	3.10	0.930	1	A
Endrin	ND		ug/kg	0.689	0.282	1	A
Endrin aldehyde	ND		ug/kg	2.07	0.723	1	A
Endrin ketone	ND		ug/kg	1.65	0.426	1	A
Dieldrin	ND		ug/kg	1.03	0.517	1	A
4,4'-DDE	ND		ug/kg	1.65	0.382	1	A
4,4'-DDD	ND		ug/kg	1.65	0.590	1	B
4,4'-DDT	2.46		ug/kg	1.65	1.33	1	B
Endosulfan I	ND		ug/kg	1.65	0.391	1	A
Endosulfan II	ND		ug/kg	1.65	0.552	1	A
Endosulfan sulfate	ND		ug/kg	0.689	0.328	1	A
Methoxychlor	ND		ug/kg	3.10	0.964	1	A
Toxaphene	ND		ug/kg	31.0	8.68	1	A
cis-Chlordane	0.846	J	ug/kg	2.07	0.576	1	A
trans-Chlordane	0.946	JIP	ug/kg	2.07	0.546	1	B
Chlordane	ND		ug/kg	13.8	5.48	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-05 Date Collected: 06/07/23 11:30

Client ID: SB-43 (5-5.5) Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	70		30-150	A
Decachlorobiphenyl	77		30-150	A
2,4,5,6-Tetrachloro-m-xylene	72		30-150	B
Decachlorobiphenyl	79		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331827
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-06
Client ID: GW-14
Sample Location: WHITE PLAINS, NY

Date Collected: 06/07/23 09:20
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8081B
Analytical Date: 06/13/23 11:05
Analyst: MMG

Extraction Method: EPA 3510C
Extraction Date: 06/12/23 09:06

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/l	0.014	0.003	1	A
Lindane	ND		ug/l	0.014	0.003	1	A
Alpha-BHC	ND		ug/l	0.014	0.003	1	A
Beta-BHC	ND		ug/l	0.014	0.004	1	A
Heptachlor	ND		ug/l	0.014	0.002	1	A
Aldrin	ND		ug/l	0.014	0.002	1	A
Heptachlor epoxide	ND		ug/l	0.014	0.003	1	A
Endrin	ND		ug/l	0.029	0.003	1	A
Endrin aldehyde	ND		ug/l	0.029	0.006	1	A
Endrin ketone	ND		ug/l	0.029	0.003	1	A
Dieldrin	ND		ug/l	0.029	0.003	1	A
4,4'-DDE	ND		ug/l	0.029	0.003	1	A
4,4'-DDD	ND		ug/l	0.029	0.003	1	A
4,4'-DDT	ND		ug/l	0.029	0.003	1	A
Endosulfan I	ND		ug/l	0.014	0.002	1	A
Endosulfan II	ND		ug/l	0.029	0.004	1	A
Endosulfan sulfate	ND		ug/l	0.029	0.003	1	A
Methoxychlor	ND		ug/l	0.143	0.005	1	A
Toxaphene	ND		ug/l	0.143	0.045	1	A
cis-Chlordane	ND		ug/l	0.014	0.005	1	A
trans-Chlordane	ND		ug/l	0.014	0.004	1	A
Chlordane	ND		ug/l	0.143	0.033	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-06 Date Collected: 06/07/23 09:20

Client ID: GW-14 Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	71		30-150	A
Decachlorobiphenyl	64		30-150	A
2,4,5,6-Tetrachloro-m-xylene	70		30-150	B
Decachlorobiphenyl	58		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331827
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-07
Client ID: GW-15
Sample Location: WHITE PLAINS, NY

Date Collected: 06/07/23 11:45
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8081B
Analytical Date: 06/13/23 11:16
Analyst: MMG

Extraction Method: EPA 3510C
Extraction Date: 06/12/23 09:06

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/l	0.017	0.004	1	A
Lindane	ND		ug/l	0.017	0.004	1	A
Alpha-BHC	ND		ug/l	0.017	0.004	1	A
Beta-BHC	ND		ug/l	0.017	0.005	1	A
Heptachlor	ND		ug/l	0.017	0.003	1	A
Aldrin	ND		ug/l	0.017	0.002	1	A
Heptachlor epoxide	ND		ug/l	0.017	0.003	1	A
Endrin	ND		ug/l	0.033	0.004	1	A
Endrin aldehyde	ND		ug/l	0.033	0.007	1	A
Endrin ketone	ND		ug/l	0.033	0.004	1	A
Dieldrin	ND		ug/l	0.033	0.004	1	A
4,4'-DDE	ND		ug/l	0.033	0.003	1	A
4,4'-DDD	ND		ug/l	0.033	0.004	1	A
4,4'-DDT	ND		ug/l	0.033	0.004	1	A
Endosulfan I	ND		ug/l	0.017	0.003	1	A
Endosulfan II	ND		ug/l	0.033	0.004	1	A
Endosulfan sulfate	ND		ug/l	0.033	0.004	1	A
Methoxychlor	ND		ug/l	0.167	0.006	1	A
Toxaphene	ND		ug/l	0.167	0.052	1	A
cis-Chlordane	ND		ug/l	0.017	0.006	1	A
trans-Chlordane	ND		ug/l	0.017	0.005	1	A
Chlordane	ND		ug/l	0.167	0.039	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-07 Date Collected: 06/07/23 11:45

Client ID: GW-15 Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	60		30-150	A
Decachlorobiphenyl	53		30-150	A
2,4,5,6-Tetrachloro-m-xylene	57		30-150	B
Decachlorobiphenyl	50		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331827
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-08
Client ID: SB-26G (1.5-2)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/07/23 12:45
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8081B
Analytical Date: 06/11/23 00:10
Analyst: MMG
Percent Solids: 95%

Extraction Method: EPA 3546
Extraction Date: 06/09/23 01:27
Cleanup Method: EPA 3620B
Cleanup Date: 06/10/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/10/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/kg	1.60	0.314	1	A
Lindane	ND		ug/kg	0.669	0.299	1	A
Alpha-BHC	ND		ug/kg	0.669	0.190	1	A
Beta-BHC	ND		ug/kg	1.60	0.609	1	A
Heptachlor	ND		ug/kg	0.803	0.360	1	A
Aldrin	ND		ug/kg	1.60	0.565	1	A
Heptachlor epoxide	ND		ug/kg	3.01	0.903	1	A
Endrin	ND		ug/kg	0.669	0.274	1	A
Endrin aldehyde	ND		ug/kg	2.01	0.702	1	A
Endrin ketone	ND		ug/kg	1.60	0.413	1	A
Dieldrin	ND		ug/kg	1.00	0.502	1	A
4,4'-DDE	ND		ug/kg	1.60	0.371	1	A
4,4'-DDD	ND		ug/kg	1.60	0.573	1	A
4,4'-DDT	ND		ug/kg	1.60	1.29	1	A
Endosulfan I	ND		ug/kg	1.60	0.379	1	A
Endosulfan II	ND		ug/kg	1.60	0.536	1	A
Endosulfan sulfate	ND		ug/kg	0.669	0.318	1	A
Methoxychlor	ND		ug/kg	3.01	0.937	1	A
Toxaphene	ND		ug/kg	30.1	8.43	1	A
cis-Chlordane	ND		ug/kg	2.01	0.559	1	A
trans-Chlordane	ND		ug/kg	2.01	0.530	1	A
Chlordane	ND		ug/kg	13.4	5.32	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-08 Date Collected: 06/07/23 12:45

Client ID: SB-26G (1.5-2) Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	63		30-150	A
Decachlorobiphenyl	81		30-150	A
2,4,5,6-Tetrachloro-m-xylene	61		30-150	B
Decachlorobiphenyl	71		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331827
Report Date: 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8081B
Analytical Date: 06/10/23 18:45
Analyst: AKM

Extraction Method: EPA 3546
Extraction Date: 06/09/23 01:24
Cleanup Method: EPA 3620B
Cleanup Date: 06/10/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/10/23

Parameter	Result	Qualifier	Units	RL	MDL	Column
Organochlorine Pesticides by GC - Westborough Lab for sample(s): 01-05,08 Batch: WG1789050-1						
Delta-BHC	ND		ug/kg	1.51	0.296	A
Lindane	ND		ug/kg	0.630	0.282	A
Alpha-BHC	ND		ug/kg	0.630	0.179	A
Beta-BHC	ND		ug/kg	1.51	0.573	A
Heptachlor	ND		ug/kg	0.756	0.339	A
Aldrin	ND		ug/kg	1.51	0.532	A
Heptachlor epoxide	ND		ug/kg	2.84	0.851	A
Endrin	ND		ug/kg	0.630	0.258	A
Endrin aldehyde	ND		ug/kg	1.89	0.662	A
Endrin ketone	ND		ug/kg	1.51	0.389	A
Dieldrin	ND		ug/kg	0.945	0.472	A
4,4'-DDE	ND		ug/kg	1.51	0.350	A
4,4'-DDD	ND		ug/kg	1.51	0.539	A
4,4'-DDT	ND		ug/kg	1.51	1.22	A
Endosulfan I	ND		ug/kg	1.51	0.357	A
Endosulfan II	ND		ug/kg	1.51	0.505	A
Endosulfan sulfate	ND		ug/kg	0.630	0.300	A
Methoxychlor	ND		ug/kg	2.84	0.882	A
Toxaphene	ND		ug/kg	28.4	7.94	A
cis-Chlordane	ND		ug/kg	1.89	0.527	A
trans-Chlordane	ND		ug/kg	1.89	0.499	A
Chlordane	ND		ug/kg	12.6	5.01	A

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331827
Report Date: 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8081B
Analytical Date: 06/10/23 18:45
Analyst: AKM

Extraction Method: EPA 3546
Extraction Date: 06/09/23 01:24
Cleanup Method: EPA 3620B
Cleanup Date: 06/10/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/10/23

Parameter	Result	Qualifier	Units	RL	MDL	Column
Organochlorine Pesticides by GC - Westborough Lab for sample(s): 01-05,08 Batch: WG1789050-1						

Surrogate	%Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	79		30-150	A
Decachlorobiphenyl	96		30-150	A
2,4,5,6-Tetrachloro-m-xylene	79		30-150	B
Decachlorobiphenyl	97		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331827
Report Date: 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8081B
Analytical Date: 06/13/23 11:50
Analyst: MMG

Extraction Method: EPA 3510C
Extraction Date: 06/12/23 09:06

Parameter	Result	Qualifier	Units	RL	MDL	Column
Organochlorine Pesticides by GC - Westborough Lab for sample(s): 06-07 Batch: WG1790042-1						
Delta-BHC	ND		ug/l	0.014	0.003	A
Lindane	ND		ug/l	0.014	0.003	A
Alpha-BHC	ND		ug/l	0.014	0.003	A
Beta-BHC	ND		ug/l	0.014	0.004	A
Heptachlor	ND		ug/l	0.014	0.002	A
Aldrin	ND		ug/l	0.014	0.002	A
Heptachlor epoxide	ND		ug/l	0.014	0.003	A
Endrin	ND		ug/l	0.029	0.003	A
Endrin aldehyde	ND		ug/l	0.029	0.006	A
Endrin ketone	ND		ug/l	0.029	0.003	A
Dieldrin	ND		ug/l	0.029	0.003	A
4,4'-DDE	ND		ug/l	0.029	0.003	A
4,4'-DDD	ND		ug/l	0.029	0.003	A
4,4'-DDT	ND		ug/l	0.029	0.003	A
Endosulfan I	ND		ug/l	0.014	0.002	A
Endosulfan II	ND		ug/l	0.029	0.004	A
Endosulfan sulfate	ND		ug/l	0.029	0.003	A
Methoxychlor	ND		ug/l	0.143	0.005	A
Toxaphene	ND		ug/l	0.143	0.045	A
cis-Chlordane	ND		ug/l	0.014	0.005	A
trans-Chlordane	ND		ug/l	0.014	0.004	A
Chlordane	ND		ug/l	0.143	0.033	A

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331827
Report Date: 06/16/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8081B
Analytical Date: 06/13/23 11:50
Analyst: MMG

Extraction Method: EPA 3510C
Extraction Date: 06/12/23 09:06

Parameter	Result	Qualifier	Units	RL	MDL	Column
Organochlorine Pesticides by GC - Westborough Lab for sample(s): 06-07 Batch: WG1790042-1						

Surrogate	%Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	48		30-150	A
Decachlorobiphenyl	59		30-150	A
2,4,5,6-Tetrachloro-m-xylene	47		30-150	B
Decachlorobiphenyl	56		30-150	B

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331827
Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits	Column
Organochlorine Pesticides by GC - Westborough Lab Associated sample(s): 01-05,08 Batch: WG1789050-2 WG1789050-3									
Delta-BHC	85		91		30-150	7		30	A
Lindane	79		83		30-150	5		30	A
Alpha-BHC	78		83		30-150	6		30	A
Beta-BHC	103		90		30-150	13		30	A
Heptachlor	76		80		30-150	5		30	A
Aldrin	76		81		30-150	6		30	A
Heptachlor epoxide	77		82		30-150	6		30	A
Endrin	79		84		30-150	6		30	A
Endrin aldehyde	74		78		30-150	5		30	A
Endrin ketone	84		87		30-150	4		30	A
Dieldrin	82		88		30-150	7		30	A
4,4'-DDE	80		86		30-150	7		30	A
4,4'-DDD	86		92		30-150	7		30	A
4,4'-DDT	82		86		30-150	5		30	A
Endosulfan I	75		79		30-150	5		30	A
Endosulfan II	77		82		30-150	6		30	A
Endosulfan sulfate	80		85		30-150	6		30	A
Methoxychlor	81		85		30-150	5		30	A
cis-Chlordane	72		76		30-150	5		30	A
trans-Chlordane	88		94		30-150	7		30	A

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331827
Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Organochlorine Pesticides by GC - Westborough Lab Associated sample(s): 01-05,08 Batch: WG1789050-2 WG1789050-3								

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	70		77		30-150	A
Decachlorobiphenyl	89		94		30-150	A
2,4,5,6-Tetrachloro-m-xylene	76		76		30-150	B
Decachlorobiphenyl	97		96		30-150	B

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331827

Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits	Column
Organochlorine Pesticides by GC - Westborough Lab Associated sample(s): 06-07 Batch: WG1790042-2 WG1790042-3									
Delta-BHC	56		66		30-150	16		20	A
Lindane	54		65		30-150	19		20	A
Alpha-BHC	54		65		30-150	18		20	A
Beta-BHC	58		70		30-150	18		20	A
Heptachlor	54		65		30-150	18		20	A
Aldrin	52		62		30-150	18		20	A
Heptachlor epoxide	52		63		30-150	20		20	A
Endrin	52		63		30-150	19		20	A
Endrin aldehyde	48		56		30-150	15		20	A
Endrin ketone	56		66		30-150	18		20	A
Dieldrin	55		67		30-150	19		20	A
4,4'-DDE	51		61		30-150	18		20	A
4,4'-DDD	56		68		30-150	20		20	A
4,4'-DDT	60		72		30-150	19		20	A
Endosulfan I	52		62		30-150	18		20	A
Endosulfan II	55		65		30-150	17		20	A
Endosulfan sulfate	52		61		30-150	16		20	A
Methoxychlor	65		76		30-150	16		20	A
cis-Chlordane	55		66		30-150	19		20	A
trans-Chlordane	65		79		30-150	19		20	A

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331827

Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Organochlorine Pesticides by GC - Westborough Lab Associated sample(s): 06-07 Batch: WG1790042-2 WG1790042-3								

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	50		58		30-150	A
Decachlorobiphenyl	56		73		30-150	A
2,4,5,6-Tetrachloro-m-xylene	49		57		30-150	B
Decachlorobiphenyl	53		68		30-150	B

METALS

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-01 Date Collected: 06/07/23 09:05

Client ID: SB-39 (0.5-1) Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Soil

Percent Solids: 94%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	5690		mg/kg	8.07	2.18	2	06/13/23 12:16	06/14/23 01:16	EPA 3050B	1,6010D	TAA
Antimony, Total	0.765	J	mg/kg	4.04	0.307	2	06/13/23 12:16	06/14/23 01:16	EPA 3050B	1,6010D	TAA
Arsenic, Total	1.18		mg/kg	0.807	0.168	2	06/13/23 12:16	06/14/23 13:52	EPA 3050B	1,6010D	JMF
Barium, Total	49.0		mg/kg	0.807	0.140	2	06/13/23 12:16	06/14/23 01:16	EPA 3050B	1,6010D	TAA
Beryllium, Total	0.276	J	mg/kg	0.404	0.027	2	06/13/23 12:16	06/14/23 01:16	EPA 3050B	1,6010D	TAA
Cadmium, Total	0.122	J	mg/kg	0.807	0.079	2	06/13/23 12:16	06/14/23 01:16	EPA 3050B	1,6010D	TAA
Calcium, Total	4980		mg/kg	8.07	2.82	2	06/13/23 12:16	06/14/23 01:16	EPA 3050B	1,6010D	TAA
Chromium, Total	13.1		mg/kg	0.807	0.078	2	06/13/23 12:16	06/14/23 01:16	EPA 3050B	1,6010D	TAA
Cobalt, Total	5.15		mg/kg	1.61	0.134	2	06/13/23 12:16	06/14/23 01:16	EPA 3050B	1,6010D	TAA
Copper, Total	18.0		mg/kg	0.807	0.208	2	06/13/23 12:16	06/14/23 01:16	EPA 3050B	1,6010D	TAA
Iron, Total	12400		mg/kg	4.04	0.729	2	06/13/23 12:16	06/14/23 01:16	EPA 3050B	1,6010D	TAA
Lead, Total	24.2		mg/kg	4.04	0.216	2	06/13/23 12:16	06/14/23 01:16	EPA 3050B	1,6010D	TAA
Magnesium, Total	3120		mg/kg	8.07	1.24	2	06/13/23 12:16	06/14/23 01:16	EPA 3050B	1,6010D	TAA
Manganese, Total	188		mg/kg	0.807	0.128	2	06/13/23 12:16	06/14/23 01:16	EPA 3050B	1,6010D	TAA
Mercury, Total	0.070	J	mg/kg	0.081	0.053	1	06/13/23 12:58	06/14/23 14:07	EPA 7471B	1,7471B	DMB
Nickel, Total	10.2		mg/kg	2.02	0.195	2	06/13/23 12:16	06/14/23 01:16	EPA 3050B	1,6010D	TAA
Potassium, Total	1410		mg/kg	202	11.6	2	06/13/23 12:16	06/14/23 01:16	EPA 3050B	1,6010D	TAA
Selenium, Total	0.208	J	mg/kg	1.61	0.208	2	06/13/23 12:16	06/14/23 13:52	EPA 3050B	1,6010D	JMF
Silver, Total	ND		mg/kg	0.404	0.228	2	06/13/23 12:16	06/14/23 01:16	EPA 3050B	1,6010D	TAA
Sodium, Total	264		mg/kg	161	2.54	2	06/13/23 12:16	06/14/23 01:16	EPA 3050B	1,6010D	TAA
Thallium, Total	0.353	J	mg/kg	1.61	0.254	2	06/13/23 12:16	06/14/23 01:16	EPA 3050B	1,6010D	TAA
Vanadium, Total	17.8		mg/kg	0.807	0.164	2	06/13/23 12:16	06/14/23 01:16	EPA 3050B	1,6010D	TAA
Zinc, Total	31.9		mg/kg	4.04	0.236	2	06/13/23 12:16	06/14/23 01:16	EPA 3050B	1,6010D	TAA

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-02 Date Collected: 06/07/23 10:05

Client ID: SB-40 (1-1.5) Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Soil

Percent Solids: 93%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	6800		mg/kg	8.36	2.26	2	06/13/23 12:16	06/14/23 01:19	EPA 3050B	1,6010D	TAA
Antimony, Total	0.829	J	mg/kg	4.18	0.318	2	06/13/23 12:16	06/14/23 01:19	EPA 3050B	1,6010D	TAA
Arsenic, Total	1.86		mg/kg	0.836	0.174	2	06/13/23 12:16	06/14/23 13:55	EPA 3050B	1,6010D	JMF
Barium, Total	64.1		mg/kg	0.836	0.145	2	06/13/23 12:16	06/14/23 01:19	EPA 3050B	1,6010D	TAA
Beryllium, Total	0.315	J	mg/kg	0.418	0.028	2	06/13/23 12:16	06/14/23 01:19	EPA 3050B	1,6010D	TAA
Cadmium, Total	0.193	J	mg/kg	0.836	0.082	2	06/13/23 12:16	06/14/23 01:19	EPA 3050B	1,6010D	TAA
Calcium, Total	5930		mg/kg	8.36	2.93	2	06/13/23 12:16	06/14/23 01:19	EPA 3050B	1,6010D	TAA
Chromium, Total	14.0		mg/kg	0.836	0.080	2	06/13/23 12:16	06/14/23 01:19	EPA 3050B	1,6010D	TAA
Cobalt, Total	5.30		mg/kg	1.67	0.139	2	06/13/23 12:16	06/14/23 01:19	EPA 3050B	1,6010D	TAA
Copper, Total	28.0		mg/kg	0.836	0.216	2	06/13/23 12:16	06/14/23 01:19	EPA 3050B	1,6010D	TAA
Iron, Total	12900		mg/kg	4.18	0.755	2	06/13/23 12:16	06/14/23 01:19	EPA 3050B	1,6010D	TAA
Lead, Total	76.1		mg/kg	4.18	0.224	2	06/13/23 12:16	06/14/23 01:19	EPA 3050B	1,6010D	TAA
Magnesium, Total	4550		mg/kg	8.36	1.29	2	06/13/23 12:16	06/14/23 01:19	EPA 3050B	1,6010D	TAA
Manganese, Total	182		mg/kg	0.836	0.133	2	06/13/23 12:16	06/14/23 01:19	EPA 3050B	1,6010D	TAA
Mercury, Total	0.216		mg/kg	0.083	0.054	1	06/13/23 12:58	06/14/23 14:11	EPA 7471B	1,7471B	DMB
Nickel, Total	10.9		mg/kg	2.09	0.202	2	06/13/23 12:16	06/14/23 01:19	EPA 3050B	1,6010D	TAA
Potassium, Total	1430		mg/kg	209	12.0	2	06/13/23 12:16	06/14/23 01:19	EPA 3050B	1,6010D	TAA
Selenium, Total	0.320	J	mg/kg	1.67	0.216	2	06/13/23 12:16	06/14/23 13:55	EPA 3050B	1,6010D	JMF
Silver, Total	ND		mg/kg	0.418	0.237	2	06/13/23 12:16	06/14/23 01:19	EPA 3050B	1,6010D	TAA
Sodium, Total	154	J	mg/kg	167	2.63	2	06/13/23 12:16	06/14/23 01:19	EPA 3050B	1,6010D	TAA
Thallium, Total	0.280	J	mg/kg	1.67	0.263	2	06/13/23 12:16	06/14/23 01:19	EPA 3050B	1,6010D	TAA
Vanadium, Total	21.8		mg/kg	0.836	0.170	2	06/13/23 12:16	06/14/23 01:19	EPA 3050B	1,6010D	TAA
Zinc, Total	62.1		mg/kg	4.18	0.245	2	06/13/23 12:16	06/14/23 01:19	EPA 3050B	1,6010D	TAA

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-03 Date Collected: 06/07/23 10:20

Client ID: SB-41 (2.5-3) Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Soil

Percent Solids: 94%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	7490		mg/kg	8.16	2.20	2	06/13/23 12:16	06/14/23 01:22	EPA 3050B	1,6010D	TAA
Antimony, Total	1.34	J	mg/kg	4.08	0.310	2	06/13/23 12:16	06/14/23 01:22	EPA 3050B	1,6010D	TAA
Arsenic, Total	3.81		mg/kg	0.816	0.170	2	06/13/23 12:16	06/14/23 13:58	EPA 3050B	1,6010D	JMF
Barium, Total	89.4		mg/kg	0.816	0.142	2	06/13/23 12:16	06/14/23 01:22	EPA 3050B	1,6010D	TAA
Beryllium, Total	0.379	J	mg/kg	0.408	0.027	2	06/13/23 12:16	06/14/23 01:22	EPA 3050B	1,6010D	TAA
Cadmium, Total	0.555	J	mg/kg	0.816	0.080	2	06/13/23 12:16	06/14/23 01:22	EPA 3050B	1,6010D	TAA
Calcium, Total	12100		mg/kg	8.16	2.86	2	06/13/23 12:16	06/14/23 01:22	EPA 3050B	1,6010D	TAA
Chromium, Total	15.3		mg/kg	0.816	0.078	2	06/13/23 12:16	06/14/23 01:22	EPA 3050B	1,6010D	TAA
Cobalt, Total	5.68		mg/kg	1.63	0.136	2	06/13/23 12:16	06/14/23 01:22	EPA 3050B	1,6010D	TAA
Copper, Total	33.3		mg/kg	0.816	0.211	2	06/13/23 12:16	06/14/23 01:22	EPA 3050B	1,6010D	TAA
Iron, Total	18400		mg/kg	4.08	0.737	2	06/13/23 12:16	06/14/23 01:22	EPA 3050B	1,6010D	TAA
Lead, Total	271		mg/kg	4.08	0.219	2	06/13/23 12:16	06/14/23 01:22	EPA 3050B	1,6010D	TAA
Magnesium, Total	7300		mg/kg	8.16	1.26	2	06/13/23 12:16	06/14/23 01:22	EPA 3050B	1,6010D	TAA
Manganese, Total	241		mg/kg	0.816	0.130	2	06/13/23 12:16	06/14/23 01:22	EPA 3050B	1,6010D	TAA
Mercury, Total	0.280		mg/kg	0.079	0.052	1	06/13/23 12:58	06/14/23 14:14	EPA 7471B	1,7471B	DMB
Nickel, Total	11.6		mg/kg	2.04	0.198	2	06/13/23 12:16	06/14/23 01:22	EPA 3050B	1,6010D	TAA
Potassium, Total	1440		mg/kg	204	11.8	2	06/13/23 12:16	06/14/23 01:22	EPA 3050B	1,6010D	TAA
Selenium, Total	0.728	J	mg/kg	1.63	0.211	2	06/13/23 12:16	06/14/23 13:58	EPA 3050B	1,6010D	JMF
Silver, Total	ND		mg/kg	0.408	0.231	2	06/13/23 12:16	06/14/23 01:22	EPA 3050B	1,6010D	TAA
Sodium, Total	188		mg/kg	163	2.57	2	06/13/23 12:16	06/14/23 01:22	EPA 3050B	1,6010D	TAA
Thallium, Total	0.473	J	mg/kg	1.63	0.257	2	06/13/23 12:16	06/14/23 01:22	EPA 3050B	1,6010D	TAA
Vanadium, Total	22.1		mg/kg	0.816	0.166	2	06/13/23 12:16	06/14/23 01:22	EPA 3050B	1,6010D	TAA
Zinc, Total	134		mg/kg	4.08	0.239	2	06/13/23 12:16	06/14/23 01:22	EPA 3050B	1,6010D	TAA

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-04 Date Collected: 06/07/23 10:50

Client ID: SB-42 (2-2.5) Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Soil

Percent Solids: 93%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	6980		mg/kg	8.36	2.26	2	06/13/23 12:16	06/14/23 01:25	EPA 3050B	1,6010D	TAA
Antimony, Total	0.919	J	mg/kg	4.18	0.318	2	06/13/23 12:16	06/14/23 01:25	EPA 3050B	1,6010D	TAA
Arsenic, Total	2.16		mg/kg	0.836	0.174	2	06/13/23 12:16	06/14/23 14:01	EPA 3050B	1,6010D	JMF
Barium, Total	98.3		mg/kg	0.836	0.145	2	06/13/23 12:16	06/14/23 01:25	EPA 3050B	1,6010D	TAA
Beryllium, Total	0.327	J	mg/kg	0.418	0.028	2	06/13/23 12:16	06/14/23 01:25	EPA 3050B	1,6010D	TAA
Cadmium, Total	0.329	J	mg/kg	0.836	0.082	2	06/13/23 12:16	06/14/23 01:25	EPA 3050B	1,6010D	TAA
Calcium, Total	11900		mg/kg	8.36	2.93	2	06/13/23 12:16	06/14/23 01:25	EPA 3050B	1,6010D	TAA
Chromium, Total	16.2		mg/kg	0.836	0.080	2	06/13/23 12:16	06/14/23 01:25	EPA 3050B	1,6010D	TAA
Cobalt, Total	5.17		mg/kg	1.67	0.139	2	06/13/23 12:16	06/14/23 01:25	EPA 3050B	1,6010D	TAA
Copper, Total	21.0		mg/kg	0.836	0.216	2	06/13/23 12:16	06/14/23 01:25	EPA 3050B	1,6010D	TAA
Iron, Total	13300		mg/kg	4.18	0.755	2	06/13/23 12:16	06/14/23 01:25	EPA 3050B	1,6010D	TAA
Lead, Total	96.1		mg/kg	4.18	0.224	2	06/13/23 12:16	06/14/23 01:25	EPA 3050B	1,6010D	TAA
Magnesium, Total	5720		mg/kg	8.36	1.29	2	06/13/23 12:16	06/14/23 01:25	EPA 3050B	1,6010D	TAA
Manganese, Total	213		mg/kg	0.836	0.133	2	06/13/23 12:16	06/14/23 01:25	EPA 3050B	1,6010D	TAA
Mercury, Total	0.186		mg/kg	0.077	0.050	1	06/13/23 12:58	06/14/23 14:17	EPA 7471B	1,7471B	DMB
Nickel, Total	11.9		mg/kg	2.09	0.202	2	06/13/23 12:16	06/14/23 01:25	EPA 3050B	1,6010D	TAA
Potassium, Total	1690		mg/kg	209	12.0	2	06/13/23 12:16	06/14/23 01:25	EPA 3050B	1,6010D	TAA
Selenium, Total	ND		mg/kg	1.67	0.216	2	06/13/23 12:16	06/14/23 14:01	EPA 3050B	1,6010D	JMF
Silver, Total	ND		mg/kg	0.418	0.237	2	06/13/23 12:16	06/14/23 01:25	EPA 3050B	1,6010D	TAA
Sodium, Total	215		mg/kg	167	2.63	2	06/13/23 12:16	06/14/23 01:25	EPA 3050B	1,6010D	TAA
Thallium, Total	0.299	J	mg/kg	1.67	0.263	2	06/13/23 12:16	06/14/23 01:25	EPA 3050B	1,6010D	TAA
Vanadium, Total	20.9		mg/kg	0.836	0.170	2	06/13/23 12:16	06/14/23 01:25	EPA 3050B	1,6010D	TAA
Zinc, Total	74.9		mg/kg	4.18	0.245	2	06/13/23 12:16	06/14/23 01:25	EPA 3050B	1,6010D	TAA

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-05 Date Collected: 06/07/23 11:30

Client ID: SB-43 (5-5.5) Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Soil

Percent Solids: 95%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	6090		mg/kg	8.11	2.19	2	06/13/23 12:16	06/14/23 01:29	EPA 3050B	1,6010D	TAA
Antimony, Total	0.768	J	mg/kg	4.05	0.308	2	06/13/23 12:16	06/14/23 01:29	EPA 3050B	1,6010D	TAA
Arsenic, Total	1.43		mg/kg	0.811	0.169	2	06/13/23 12:16	06/14/23 14:04	EPA 3050B	1,6010D	JMF
Barium, Total	59.9		mg/kg	0.811	0.141	2	06/13/23 12:16	06/14/23 01:29	EPA 3050B	1,6010D	TAA
Beryllium, Total	0.282	J	mg/kg	0.405	0.027	2	06/13/23 12:16	06/14/23 01:29	EPA 3050B	1,6010D	TAA
Cadmium, Total	0.162	J	mg/kg	0.811	0.080	2	06/13/23 12:16	06/14/23 01:29	EPA 3050B	1,6010D	TAA
Calcium, Total	6120		mg/kg	8.11	2.84	2	06/13/23 12:16	06/14/23 01:29	EPA 3050B	1,6010D	TAA
Chromium, Total	13.7		mg/kg	0.811	0.078	2	06/13/23 12:16	06/14/23 01:29	EPA 3050B	1,6010D	TAA
Cobalt, Total	4.74		mg/kg	1.62	0.135	2	06/13/23 12:16	06/14/23 01:29	EPA 3050B	1,6010D	TAA
Copper, Total	17.5		mg/kg	0.811	0.209	2	06/13/23 12:16	06/14/23 01:29	EPA 3050B	1,6010D	TAA
Iron, Total	11400		mg/kg	4.05	0.732	2	06/13/23 12:16	06/14/23 01:29	EPA 3050B	1,6010D	TAA
Lead, Total	45.5		mg/kg	4.05	0.217	2	06/13/23 12:16	06/14/23 01:29	EPA 3050B	1,6010D	TAA
Magnesium, Total	4480		mg/kg	8.11	1.25	2	06/13/23 12:16	06/14/23 01:29	EPA 3050B	1,6010D	TAA
Manganese, Total	170		mg/kg	0.811	0.129	2	06/13/23 12:16	06/14/23 01:29	EPA 3050B	1,6010D	TAA
Mercury, Total	0.100		mg/kg	0.077	0.050	1	06/13/23 12:58	06/14/23 14:21	EPA 7471B	1,7471B	DMB
Nickel, Total	10.7		mg/kg	2.03	0.196	2	06/13/23 12:16	06/14/23 01:29	EPA 3050B	1,6010D	TAA
Potassium, Total	1490		mg/kg	203	11.7	2	06/13/23 12:16	06/14/23 01:29	EPA 3050B	1,6010D	TAA
Selenium, Total	0.319	J	mg/kg	1.62	0.209	2	06/13/23 12:16	06/14/23 14:04	EPA 3050B	1,6010D	JMF
Silver, Total	ND		mg/kg	0.405	0.229	2	06/13/23 12:16	06/14/23 01:29	EPA 3050B	1,6010D	TAA
Sodium, Total	107	J	mg/kg	162	2.55	2	06/13/23 12:16	06/14/23 01:29	EPA 3050B	1,6010D	TAA
Thallium, Total	0.286	J	mg/kg	1.62	0.255	2	06/13/23 12:16	06/14/23 01:29	EPA 3050B	1,6010D	TAA
Vanadium, Total	19.7		mg/kg	0.811	0.165	2	06/13/23 12:16	06/14/23 01:29	EPA 3050B	1,6010D	TAA
Zinc, Total	51.7		mg/kg	4.05	0.238	2	06/13/23 12:16	06/14/23 01:29	EPA 3050B	1,6010D	TAA

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-06 Date Collected: 06/07/23 09:20

Client ID: GW-14 Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Water

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	33.6		mg/l	0.0100	0.00327	1	06/12/23 10:43	06/14/23 13:00	EPA 3005A	1,6020B	SMV
Antimony, Total	ND		mg/l	0.00400	0.00042	1	06/12/23 10:43	06/14/23 13:00	EPA 3005A	1,6020B	SMV
Arsenic, Total	0.00430		mg/l	0.00050	0.00016	1	06/12/23 10:43	06/14/23 13:00	EPA 3005A	1,6020B	SMV
Barium, Total	1.029		mg/l	0.00050	0.00017	1	06/12/23 10:43	06/14/23 13:00	EPA 3005A	1,6020B	SMV
Beryllium, Total	0.00129		mg/l	0.00050	0.00010	1	06/12/23 10:43	06/14/23 13:00	EPA 3005A	1,6020B	SMV
Cadmium, Total	0.00131		mg/l	0.00020	0.00005	1	06/12/23 10:43	06/14/23 13:00	EPA 3005A	1,6020B	SMV
Calcium, Total	312.		mg/l	0.100	0.0394	1	06/12/23 10:43	06/14/23 13:00	EPA 3005A	1,6020B	SMV
Chromium, Total	0.05673		mg/l	0.00100	0.00017	1	06/12/23 10:43	06/14/23 13:00	EPA 3005A	1,6020B	SMV
Cobalt, Total	0.07652		mg/l	0.00050	0.00016	1	06/12/23 10:43	06/14/23 13:00	EPA 3005A	1,6020B	SMV
Copper, Total	0.2218		mg/l	0.00100	0.00038	1	06/12/23 10:43	06/14/23 13:00	EPA 3005A	1,6020B	SMV
Iron, Total	60.2		mg/l	0.0500	0.0191	1	06/12/23 10:43	06/14/23 13:00	EPA 3005A	1,6020B	SMV
Lead, Total	0.05553		mg/l	0.00100	0.00034	1	06/12/23 10:43	06/14/23 13:00	EPA 3005A	1,6020B	SMV
Magnesium, Total	95.9		mg/l	0.0700	0.0242	1	06/12/23 10:43	06/14/23 13:00	EPA 3005A	1,6020B	SMV
Manganese, Total	6.747		mg/l	0.00100	0.00044	1	06/12/23 10:43	06/14/23 13:00	EPA 3005A	1,6020B	SMV
Mercury, Total	ND		mg/l	0.00020	0.00009	1	06/12/23 13:09	06/14/23 13:24	EPA 7470A	1,7470A	DMB
Nickel, Total	0.1204		mg/l	0.00200	0.00055	1	06/12/23 10:43	06/14/23 13:00	EPA 3005A	1,6020B	SMV
Potassium, Total	35.6		mg/l	0.100	0.0309	1	06/12/23 10:43	06/14/23 13:00	EPA 3005A	1,6020B	SMV
Selenium, Total	0.0367		mg/l	0.00500	0.00173	1	06/12/23 10:43	06/14/23 13:00	EPA 3005A	1,6020B	SMV
Silver, Total	0.00032	J	mg/l	0.00040	0.00016	1	06/12/23 10:43	06/14/23 13:00	EPA 3005A	1,6020B	SMV
Sodium, Total	389.		mg/l	1.00	0.293	10	06/12/23 10:43	06/14/23 14:26	EPA 3005A	1,6020B	SMV
Thallium, Total	0.00201		mg/l	0.00100	0.00014	1	06/12/23 10:43	06/14/23 13:00	EPA 3005A	1,6020B	SMV
Vanadium, Total	0.05310		mg/l	0.00500	0.00157	1	06/12/23 10:43	06/14/23 13:00	EPA 3005A	1,6020B	SMV
Zinc, Total	0.1912		mg/l	0.01000	0.00341	1	06/12/23 10:43	06/14/23 13:00	EPA 3005A	1,6020B	SMV

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-07 Date Collected: 06/07/23 11:45

Client ID: GW-15 Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Water

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	71.6		mg/l	0.0100	0.00327	1	06/12/23 10:43	06/14/23 13:05	EPA 3005A	1,6020B	SMV
Antimony, Total	ND		mg/l	0.00400	0.00042	1	06/12/23 10:43	06/14/23 13:05	EPA 3005A	1,6020B	SMV
Arsenic, Total	0.00480		mg/l	0.00050	0.00016	1	06/12/23 10:43	06/14/23 13:05	EPA 3005A	1,6020B	SMV
Barium, Total	2.540		mg/l	0.00050	0.00017	1	06/12/23 10:43	06/14/23 13:05	EPA 3005A	1,6020B	SMV
Beryllium, Total	0.00467		mg/l	0.00050	0.00010	1	06/12/23 10:43	06/14/23 13:05	EPA 3005A	1,6020B	SMV
Cadmium, Total	0.00447		mg/l	0.00020	0.00005	1	06/12/23 10:43	06/14/23 13:05	EPA 3005A	1,6020B	SMV
Calcium, Total	203.		mg/l	0.100	0.0394	1	06/12/23 10:43	06/14/23 13:05	EPA 3005A	1,6020B	SMV
Chromium, Total	0.1044		mg/l	0.00100	0.00017	1	06/12/23 10:43	06/14/23 13:05	EPA 3005A	1,6020B	SMV
Cobalt, Total	0.3625		mg/l	0.00500	0.00163	10	06/12/23 10:43	06/14/23 14:32	EPA 3005A	1,6020B	SMV
Copper, Total	0.2969		mg/l	0.00100	0.00038	1	06/12/23 10:43	06/14/23 13:05	EPA 3005A	1,6020B	SMV
Iron, Total	80.5		mg/l	0.0500	0.0191	1	06/12/23 10:43	06/14/23 13:05	EPA 3005A	1,6020B	SMV
Lead, Total	0.1149		mg/l	0.00100	0.00034	1	06/12/23 10:43	06/14/23 13:05	EPA 3005A	1,6020B	SMV
Magnesium, Total	77.4		mg/l	0.0700	0.0242	1	06/12/23 10:43	06/14/23 13:05	EPA 3005A	1,6020B	SMV
Manganese, Total	5.566		mg/l	0.00100	0.00044	1	06/12/23 10:43	06/14/23 13:05	EPA 3005A	1,6020B	SMV
Mercury, Total	0.00013	J	mg/l	0.00020	0.00009	1	06/12/23 13:09	06/14/23 13:28	EPA 7470A	1,7470A	DMB
Nickel, Total	0.1441		mg/l	0.00200	0.00055	1	06/12/23 10:43	06/14/23 13:05	EPA 3005A	1,6020B	SMV
Potassium, Total	31.6		mg/l	0.100	0.0309	1	06/12/23 10:43	06/14/23 13:05	EPA 3005A	1,6020B	SMV
Selenium, Total	0.0959		mg/l	0.00500	0.00173	1	06/12/23 10:43	06/14/23 13:05	EPA 3005A	1,6020B	SMV
Silver, Total	0.00031	J	mg/l	0.00040	0.00016	1	06/12/23 10:43	06/14/23 13:05	EPA 3005A	1,6020B	SMV
Sodium, Total	372.		mg/l	1.00	0.293	10	06/12/23 10:43	06/14/23 14:32	EPA 3005A	1,6020B	SMV
Thallium, Total	0.00118		mg/l	0.00100	0.00014	1	06/12/23 10:43	06/14/23 13:05	EPA 3005A	1,6020B	SMV
Vanadium, Total	0.07151		mg/l	0.00500	0.00157	1	06/12/23 10:43	06/14/23 13:05	EPA 3005A	1,6020B	SMV
Zinc, Total	0.5045		mg/l	0.01000	0.00341	1	06/12/23 10:43	06/14/23 13:05	EPA 3005A	1,6020B	SMV

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-08 Date Collected: 06/07/23 12:45

Client ID: SB-26G (1.5-2) Date Received: 06/07/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Soil

Percent Solids: 95%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	6480		mg/kg	8.02	2.17	2	06/13/23 12:16	06/14/23 01:32	EPA 3050B	1,6010D	TAA
Antimony, Total	0.673	J	mg/kg	4.01	0.305	2	06/13/23 12:16	06/14/23 01:32	EPA 3050B	1,6010D	TAA
Arsenic, Total	1.16		mg/kg	0.802	0.167	2	06/13/23 12:16	06/14/23 14:07	EPA 3050B	1,6010D	JMF
Barium, Total	55.3		mg/kg	0.802	0.140	2	06/13/23 12:16	06/14/23 01:32	EPA 3050B	1,6010D	TAA
Beryllium, Total	0.313	J	mg/kg	0.401	0.027	2	06/13/23 12:16	06/14/23 01:32	EPA 3050B	1,6010D	TAA
Cadmium, Total	0.348	J	mg/kg	0.802	0.079	2	06/13/23 12:16	06/14/23 01:32	EPA 3050B	1,6010D	TAA
Calcium, Total	11200		mg/kg	8.02	2.81	2	06/13/23 12:16	06/14/23 01:32	EPA 3050B	1,6010D	TAA
Chromium, Total	14.2		mg/kg	0.802	0.077	2	06/13/23 12:16	06/14/23 01:32	EPA 3050B	1,6010D	TAA
Cobalt, Total	5.09		mg/kg	1.60	0.133	2	06/13/23 12:16	06/14/23 01:32	EPA 3050B	1,6010D	TAA
Copper, Total	15.1		mg/kg	0.802	0.207	2	06/13/23 12:16	06/14/23 01:32	EPA 3050B	1,6010D	TAA
Iron, Total	12200		mg/kg	4.01	0.725	2	06/13/23 12:16	06/14/23 01:32	EPA 3050B	1,6010D	TAA
Lead, Total	27.9		mg/kg	4.01	0.215	2	06/13/23 12:16	06/14/23 01:32	EPA 3050B	1,6010D	TAA
Magnesium, Total	6590		mg/kg	8.02	1.24	2	06/13/23 12:16	06/14/23 01:32	EPA 3050B	1,6010D	TAA
Manganese, Total	177		mg/kg	0.802	0.128	2	06/13/23 12:16	06/14/23 01:32	EPA 3050B	1,6010D	TAA
Mercury, Total	0.076	J	mg/kg	0.079	0.051	1	06/13/23 12:58	06/14/23 14:24	EPA 7471B	1,7471B	DMB
Nickel, Total	10.7		mg/kg	2.01	0.194	2	06/13/23 12:16	06/14/23 01:32	EPA 3050B	1,6010D	TAA
Potassium, Total	2080		mg/kg	201	11.6	2	06/13/23 12:16	06/14/23 01:32	EPA 3050B	1,6010D	TAA
Selenium, Total	0.299	J	mg/kg	1.60	0.207	2	06/13/23 12:16	06/14/23 14:07	EPA 3050B	1,6010D	JMF
Silver, Total	ND		mg/kg	0.401	0.227	2	06/13/23 12:16	06/14/23 01:32	EPA 3050B	1,6010D	TAA
Sodium, Total	170		mg/kg	160	2.53	2	06/13/23 12:16	06/14/23 01:32	EPA 3050B	1,6010D	TAA
Thallium, Total	0.328	J	mg/kg	1.60	0.253	2	06/13/23 12:16	06/14/23 01:32	EPA 3050B	1,6010D	TAA
Vanadium, Total	18.2		mg/kg	0.802	0.163	2	06/13/23 12:16	06/14/23 01:32	EPA 3050B	1,6010D	TAA
Zinc, Total	66.2		mg/kg	4.01	0.235	2	06/13/23 12:16	06/14/23 01:32	EPA 3050B	1,6010D	TAA

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

Method Blank Analysis
Batch Quality Control

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
Total Metals - Mansfield Lab for sample(s): 06-07 Batch: WG1789335-1										
Aluminum, Total	ND		mg/l	0.0100	0.00327	1	06/12/23 10:43	06/14/23 08:34	1,6020B	SMV
Antimony, Total	ND		mg/l	0.00400	0.00042	1	06/12/23 10:43	06/14/23 08:34	1,6020B	SMV
Arsenic, Total	ND		mg/l	0.00050	0.00016	1	06/12/23 10:43	06/14/23 08:34	1,6020B	SMV
Barium, Total	ND		mg/l	0.00050	0.00017	1	06/12/23 10:43	06/14/23 08:34	1,6020B	SMV
Beryllium, Total	ND		mg/l	0.00050	0.00010	1	06/12/23 10:43	06/14/23 08:34	1,6020B	SMV
Cadmium, Total	ND		mg/l	0.00020	0.00005	1	06/12/23 10:43	06/14/23 08:34	1,6020B	SMV
Calcium, Total	ND		mg/l	0.100	0.0394	1	06/12/23 10:43	06/14/23 08:34	1,6020B	SMV
Chromium, Total	ND		mg/l	0.00100	0.00017	1	06/12/23 10:43	06/14/23 08:34	1,6020B	SMV
Cobalt, Total	ND		mg/l	0.00050	0.00016	1	06/12/23 10:43	06/14/23 08:34	1,6020B	SMV
Copper, Total	ND		mg/l	0.00100	0.00038	1	06/12/23 10:43	06/14/23 08:34	1,6020B	SMV
Iron, Total	ND		mg/l	0.0500	0.0191	1	06/12/23 10:43	06/14/23 08:34	1,6020B	SMV
Lead, Total	ND		mg/l	0.00100	0.00034	1	06/12/23 10:43	06/14/23 08:34	1,6020B	SMV
Magnesium, Total	ND		mg/l	0.0700	0.0242	1	06/12/23 10:43	06/14/23 08:34	1,6020B	SMV
Manganese, Total	ND		mg/l	0.00100	0.00044	1	06/12/23 10:43	06/14/23 08:34	1,6020B	SMV
Nickel, Total	0.00061	J	mg/l	0.00200	0.00055	1	06/12/23 10:43	06/14/23 08:34	1,6020B	SMV
Potassium, Total	ND		mg/l	0.100	0.0309	1	06/12/23 10:43	06/14/23 08:34	1,6020B	SMV
Selenium, Total	ND		mg/l	0.00500	0.00173	1	06/12/23 10:43	06/14/23 08:34	1,6020B	SMV
Silver, Total	ND		mg/l	0.00040	0.00016	1	06/12/23 10:43	06/14/23 10:21	1,6020B	SMV
Sodium, Total	ND		mg/l	0.100	0.0293	1	06/12/23 10:43	06/14/23 10:21	1,6020B	SMV
Thallium, Total	ND		mg/l	0.00100	0.00014	1	06/12/23 10:43	06/14/23 08:34	1,6020B	SMV
Vanadium, Total	ND		mg/l	0.00500	0.00157	1	06/12/23 10:43	06/14/23 08:34	1,6020B	SMV
Zinc, Total	ND		mg/l	0.01000	0.00341	1	06/12/23 10:43	06/14/23 08:34	1,6020B	SMV

Prep Information

Digestion Method: EPA 3005A

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
Total Metals - Mansfield Lab for sample(s): 06-07 Batch: WG1789345-1										
Mercury, Total	ND		mg/l	0.00020	0.00009	1	06/12/23 13:09	06/14/23 12:55	1,7470A	DMB

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

Method Blank Analysis
Batch Quality Control

Prep Information

Digestion Method: EPA 7470A

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
Total Metals - Mansfield Lab for sample(s): 01-05,08 Batch: WG1789367-1										
Aluminum, Total	ND		mg/kg	4.00	1.08	1	06/13/23 12:16	06/13/23 23:58	1,6010D	TAA
Antimony, Total	ND		mg/kg	2.00	0.152	1	06/13/23 12:16	06/13/23 23:58	1,6010D	TAA
Arsenic, Total	ND		mg/kg	0.400	0.083	1	06/13/23 12:16	06/14/23 13:04	1,6010D	JMF
Barium, Total	ND		mg/kg	0.400	0.070	1	06/13/23 12:16	06/13/23 23:58	1,6010D	TAA
Beryllium, Total	ND		mg/kg	0.200	0.013	1	06/13/23 12:16	06/13/23 23:58	1,6010D	TAA
Cadmium, Total	ND		mg/kg	0.400	0.039	1	06/13/23 12:16	06/13/23 23:58	1,6010D	TAA
Calcium, Total	ND		mg/kg	4.00	1.40	1	06/13/23 12:16	06/13/23 23:58	1,6010D	TAA
Chromium, Total	ND		mg/kg	0.400	0.038	1	06/13/23 12:16	06/13/23 23:58	1,6010D	TAA
Cobalt, Total	ND		mg/kg	0.800	0.066	1	06/13/23 12:16	06/13/23 23:58	1,6010D	TAA
Copper, Total	ND		mg/kg	0.400	0.103	1	06/13/23 12:16	06/13/23 23:58	1,6010D	TAA
Iron, Total	ND		mg/kg	2.00	0.361	1	06/13/23 12:16	06/13/23 23:58	1,6010D	TAA
Lead, Total	ND		mg/kg	2.00	0.107	1	06/13/23 12:16	06/13/23 23:58	1,6010D	TAA
Magnesium, Total	ND		mg/kg	4.00	0.616	1	06/13/23 12:16	06/13/23 23:58	1,6010D	TAA
Manganese, Total	ND		mg/kg	0.400	0.064	1	06/13/23 12:16	06/13/23 23:58	1,6010D	TAA
Nickel, Total	ND		mg/kg	1.00	0.097	1	06/13/23 12:16	06/13/23 23:58	1,6010D	TAA
Potassium, Total	6.82	J	mg/kg	100	5.76	1	06/13/23 12:16	06/13/23 23:58	1,6010D	TAA
Selenium, Total	ND		mg/kg	0.800	0.103	1	06/13/23 12:16	06/14/23 13:04	1,6010D	JMF
Silver, Total	ND		mg/kg	0.200	0.113	1	06/13/23 12:16	06/13/23 23:58	1,6010D	TAA
Sodium, Total	22.0	J	mg/kg	80.0	1.26	1	06/13/23 12:16	06/13/23 23:58	1,6010D	TAA
Thallium, Total	ND		mg/kg	0.800	0.126	1	06/13/23 12:16	06/13/23 23:58	1,6010D	TAA
Vanadium, Total	ND		mg/kg	0.400	0.081	1	06/13/23 12:16	06/13/23 23:58	1,6010D	TAA
Zinc, Total	ND		mg/kg	2.00	0.117	1	06/13/23 12:16	06/13/23 23:58	1,6010D	TAA

Prep Information

Digestion Method: EPA 3050B

Project Name: 100 MAIN ST. **Lab Number:** L2331827

Project Number: 12461 **Report Date:** 06/16/23

Method Blank Analysis
Batch Quality Control

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
Total Metals - Mansfield Lab for sample(s): 01-05,08 Batch: WG1789368-1										
Mercury, Total	ND		mg/kg	0.083	0.054	1	06/13/23 12:58	06/14/23 13:24	1,7471B	DMB

Prep Information

Digestion Method: EPA 7471B

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331827

Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 06-07 Batch: WG1789335-2								
Aluminum, Total	102		-		80-120	-		
Antimony, Total	85		-		80-120	-		
Arsenic, Total	98		-		80-120	-		
Barium, Total	98		-		80-120	-		
Beryllium, Total	104		-		80-120	-		
Cadmium, Total	98		-		80-120	-		
Calcium, Total	80		-		80-120	-		
Chromium, Total	96		-		80-120	-		
Cobalt, Total	120		-		80-120	-		
Copper, Total	99		-		80-120	-		
Iron, Total	98		-		80-120	-		
Lead, Total	103		-		80-120	-		
Magnesium, Total	86		-		80-120	-		
Manganese, Total	98		-		80-120	-		
Nickel, Total	96		-		80-120	-		
Potassium, Total	83		-		80-120	-		
Selenium, Total	92		-		80-120	-		
Silver, Total	102		-		80-120	-		
Sodium, Total	94		-		80-120	-		
Thallium, Total	91		-		80-120	-		
Vanadium, Total	96		-		80-120	-		

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331827

Report Date: 06/16/23

Parameter	LCS %Recovery	LCSD %Recovery	%Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 06-07 Batch: WG1789335-2					
Zinc, Total	101	-	80-120	-	
Total Metals - Mansfield Lab Associated sample(s): 06-07 Batch: WG1789345-2					
Mercury, Total	88	-	80-120	-	

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331827

Report Date: 06/16/23

Parameter	LCS %Recovery	LCSD %Recovery	%Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-05,08 Batch: WG1789367-2 SRM Lot Number: D119-540					
Aluminum, Total	74	-	48-152	-	
Antimony, Total	155	-	10-190	-	
Arsenic, Total	100	-	83-117	-	
Barium, Total	94	-	82-118	-	
Beryllium, Total	97	-	83-117	-	
Cadmium, Total	97	-	82-117	-	
Calcium, Total	96	-	81-118	-	
Chromium, Total	99	-	82-119	-	
Cobalt, Total	98	-	83-117	-	
Copper, Total	97	-	84-116	-	
Iron, Total	94	-	60-140	-	
Lead, Total	97	-	82-118	-	
Magnesium, Total	88	-	76-124	-	
Manganese, Total	98	-	82-118	-	
Nickel, Total	98	-	82-117	-	
Potassium, Total	86	-	70-130	-	
Selenium, Total	104	-	79-121	-	
Silver, Total	96	-	80-120	-	
Sodium, Total	103	-	74-126	-	
Thallium, Total	98	-	81-119	-	
Vanadium, Total	97	-	79-121	-	

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331827

Report Date: 06/16/23

Parameter	LCS %Recovery	LCSD %Recovery	%Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-05,08 Batch: WG1789367-2 SRM Lot Number: D119-540					
Zinc, Total	95	-	80-120	-	
Total Metals - Mansfield Lab Associated sample(s): 01-05,08 Batch: WG1789368-2 SRM Lot Number: D119-540					
Mercury, Total	103	-	73-127	-	

Matrix Spike Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331827
Report Date: 06/16/23

Parameter	Native Sample	MS Added	MS Found	MS %Recovery	Qual	MSD Found	MSD %Recovery	Qual	Recovery Limits	RPD	Qual	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 06-07 QC Batch ID: WG1789335-3 QC Sample: L2329270-01 Client ID: MS Sample												
Aluminum, Total	0.107	2	2.15	102		-	-		75-125	-		20
Antimony, Total	0.0018J	0.5	0.4888	98		-	-		75-125	-		20
Arsenic, Total	0.00292	0.12	0.1178	96		-	-		75-125	-		20
Barium, Total	0.0069	2	2.035	101		-	-		75-125	-		20
Beryllium, Total	ND	0.05	0.05376	108		-	-		75-125	-		20
Cadmium, Total	0.0001J	0.053	0.05433	102		-	-		75-125	-		20
Calcium, Total	11.5	10	19.1	76		-	-		75-125	-		20
Chromium, Total	0.0021	0.2	0.1980	98		-	-		75-125	-		20
Cobalt, Total	0.0004J	0.5	0.4974	99		-	-		75-125	-		20
Copper, Total	0.0060	0.25	0.2613	102		-	-		75-125	-		20
Iron, Total	0.596	1	1.59	99		-	-		75-125	-		20
Lead, Total	0.0015	0.53	0.4743	89		-	-		75-125	-		20
Magnesium, Total	0.951	10	9.22	83		-	-		75-125	-		20
Manganese, Total	0.0625	0.5	0.5532	98		-	-		75-125	-		20
Nickel, Total	ND	0.5	0.4998	100		-	-		75-125	-		20
Potassium, Total	2.78	10	10.8	80		-	-		75-125	-		20
Selenium, Total	ND	0.12	0.113	94		-	-		75-125	-		20
Silver, Total	ND	0.05	0.03609	**72**	Q	-	-		75-125	-		20
Sodium, Total	10.1	10	18.8	87		-	-		75-125	-		20
Thallium, Total	0.0002J	0.12	0.07830	**65**	Q	-	-		75-125	-		20
Vanadium, Total	ND	0.5	0.4839	97		-	-		75-125	-		20

Matrix Spike Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331827
Report Date: 06/16/23

Parameter	Native Sample	MS Added	MS Found	MS %Recovery	MSD Found	MSD %Recovery	Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 06-07 QC Batch ID: WG1789335-3 QC Sample: L2329270-01 Client ID: MS Sample									
Zinc, Total	0.05278	0.5	0.5747	104	-	-	75-125	-	20
Total Metals - Mansfield Lab Associated sample(s): 06-07 QC Batch ID: WG1789345-3 QC Sample: L2329934-04 Client ID: MS Sample									
Mercury, Total	ND	0.005	0.00496	99	-	-	75-125	-	20

Matrix Spike Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331827
Report Date: 06/16/23

Parameter	Native Sample	MS Added	MS Found	MS %Recovery		MSD Found	MSD %Recovery		Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-05,08 QC Batch ID: WG1789367-3 WG1789367-4 QC Sample: L2331800-02 Client ID: MS Sample											
Aluminum, Total	4490	210	4660	81		4450	**0**	Q	75-125	5	20
Antimony, Total	0.410J	52.4	45.6	87		42.9	84		75-125	6	20
Arsenic, Total	1.13	12.6	13.3	97		12.0	89		75-125	10	20
Barium, Total	30.6	210	224	92		210	88		75-125	6	20
Beryllium, Total	0.275J	5.24	5.14	98		4.79	94		75-125	7	20
Cadmium, Total	ND	5.55	5.01	90		4.68	87		75-125	7	20
Calcium, Total	2720	1050	4520	**172**	Q	3880	114		75-125	15	20
Chromium, Total	11.0	21	30.3	92		28.2	84		75-125	7	20
Cobalt, Total	3.92	52.4	50.8	89		47.0	85		75-125	8	20
Copper, Total	10.8	26.2	35.3	94		32.0	83		75-125	10	20
Iron, Total	8820	105	8810	**0**	Q	8490	**0**	Q	75-125	4	20
Lead, Total	12.5	55.5	62.3	90		64.6	97		75-125	4	20
Magnesium, Total	2250	1050	3400	110		3170	90		75-125	7	20
Manganese, Total	276	52.4	322	88		292	**31**	Q	75-125	10	20
Nickel, Total	9.70	52.4	56.0	88		51.8	83		75-125	8	20
Potassium, Total	946	1050	1990	100		2050	108		75-125	3	20
Selenium, Total	0.357J	12.6	12.6	100		11.9	97		75-125	6	20
Silver, Total	ND	5.24	4.75	91		4.46	88		75-125	6	20
Sodium, Total	148J	1050	1170	112		1080	106		75-125	8	20
Thallium, Total	ND	12.6	11.5	91		10.7	88		75-125	7	20
Vanadium, Total	13.2	52.4	62.2	94		57.4	87		75-125	8	20

Matrix Spike Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331827
Report Date: 06/16/23

Parameter	Native Sample	MS Added	MS Found	MS %Recovery	MSD Found	MSD %Recovery	Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-05,08 QC Batch ID: WG1789367-3 WG1789367-4 QC Sample: L2331800-02 Client ID: MS Sample									
Zinc, Total	28.8	52.4	74.9	88	70.3	82	75-125	6	20
Total Metals - Mansfield Lab Associated sample(s): 01-05,08 QC Batch ID: WG1789368-3 WG1789368-4 QC Sample: L2331800-02 Client ID: MS Sample									
Mercury, Total	0.069J	1.83	1.89	103	2.19	103	80-120	15	20

Lab Duplicate Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331827

Report Date: 06/16/23

Parameter	Native Sample	Duplicate Sample	Units	RPD	Qual	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 06-07 QC Batch ID: WG1789335-4 QC Sample: L2329270-01 Client ID: DUP Sample						
Arsenic, Total	0.00292	0.00288	mg/l	1		20
Zinc, Total	0.05278	0.05150	mg/l	2		20
Total Metals - Mansfield Lab Associated sample(s): 06-07 QC Batch ID: WG1789345-4 QC Sample: L2329934-04 Client ID: DUP Sample						
Mercury, Total	ND	ND	mg/l	NC		20

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Serial Dilution Analysis
Batch Quality Control

Lab Number: L2331827
Report Date: 06/16/23

Parameter	Native Sample	Serial Dilution	Units	% D	Qual	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-05,08 QC Batch ID: WG1789367-6 QC Sample: L2331800-02 Client ID: DUP Sample						
Aluminum, Total	4490	4810	mg/kg	7		20
Barium, Total	30.6	32.4	mg/kg	6		20
Calcium, Total	2720	2890	mg/kg	6		20
Iron, Total	8820	9620	mg/kg	9		20
Magnesium, Total	2250	2450	mg/kg	9		20
Manganese, Total	276	295	mg/kg	7		20

INORGANICS
&
MISCELLANEOUS

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331827
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-01
Client ID: SB-39 (0.5-1)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/07/23 09:05
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Solids, Total	94.3		%	0.100	NA	1	-	06/08/23 11:48	121,2540G	ROI
Cyanide, Total	ND		mg/kg	1.0	0.22	1	06/10/23 11:00	06/12/23 17:25	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331827
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-02
Client ID: SB-40 (1-1.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/07/23 10:05
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Solids, Total	93.0		%	0.100	NA	1	-	06/08/23 11:48	121,2540G	ROI
Cyanide, Total	ND		mg/kg	1.0	0.22	1	06/10/23 11:00	06/12/23 17:26	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331827
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-03
Client ID: SB-41 (2.5-3)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/07/23 10:20
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Solids, Total	94.0		%	0.100	NA	1	-	06/08/23 11:48	121,2540G	ROI
Cyanide, Total	ND		mg/kg	1.0	0.22	1	06/10/23 11:00	06/12/23 17:27	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331827
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-04
Client ID: SB-42 (2-2.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/07/23 10:50
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Solids, Total	93.0		%	0.100	NA	1	-	06/08/23 11:48	121,2540G	ROI
Cyanide, Total	ND		mg/kg	0.99	0.21	1	06/10/23 11:00	06/12/23 17:28	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331827
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-05
Client ID: SB-43 (5-5.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/07/23 11:30
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Solids, Total	94.5		%	0.100	NA	1	-	06/08/23 11:48	121,2540G	ROI
Cyanide, Total	ND		mg/kg	1.0	0.22	1	06/10/23 11:00	06/12/23 17:29	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331827
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-06
Client ID: GW-14
Sample Location: WHITE PLAINS, NY

Date Collected: 06/07/23 09:20
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Cyanide, Total	0.005		mg/l	0.005	0.001	1	06/08/23 16:00	06/09/23 12:33	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331827
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-07
Client ID: GW-15
Sample Location: WHITE PLAINS, NY

Date Collected: 06/07/23 11:45
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Cyanide, Total	0.001	J	mg/l	0.005	0.001	1	06/08/23 16:00	06/09/23 12:34	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331827
Report Date: 06/16/23

SAMPLE RESULTS

Lab ID: L2331827-08
Client ID: SB-26G (1.5-2)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/07/23 12:45
Date Received: 06/07/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Solids, Total	95.2		%	0.100	NA	1	-	06/08/23 11:48	121,2540G	ROI
Cyanide, Total	ND		mg/kg	0.90	0.19	1	06/10/23 11:00	06/12/23 17:30	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2331827
Report Date: 06/16/23

Method Blank Analysis
Batch Quality Control

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab for sample(s): 06-07 Batch: WG1788885-1										
Cyanide, Total	ND		mg/l	0.005	0.001	1	06/08/23 16:00	06/09/23 12:17	1,9010C/9012B	JER
General Chemistry - Westborough Lab for sample(s): 01-05,08 Batch: WG1789595-1										
Cyanide, Total	ND		mg/kg	0.95	0.20	1	06/10/23 11:00	06/12/23 17:31	1,9010C/9012B	JER

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331827

Report Date: 06/16/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
General Chemistry - Westborough Lab Associated sample(s): 06-07 Batch: WG1788885-2 WG1788885-3								
Cyanide, Total	104		107		85-115	3		20
General Chemistry - Westborough Lab Associated sample(s): 01-05,08 Batch: WG1789595-2 WG1789595-3								
Cyanide, Total	104		**78**	Q	80-120	32		35

Matrix Spike Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331827
Report Date: 06/16/23

Parameter	Native Sample	MS Added	MS Found	MS %Recovery	Qual	MSD Found	MSD %Recovery	Qual	Recovery Limits	RPD	Qual	RPD Limits
General Chemistry - Westborough Lab Associated sample(s): 06-07 QC Batch ID: WG1788885-4 WG1788885-5 QC Sample: L2331480-06 Client ID: MS Sample												
Cyanide, Total	0.001J	0.2	0.195	98		0.126	**63**	Q	80-120	**43**	Q	20
General Chemistry - Westborough Lab Associated sample(s): 01-05,08 QC Batch ID: WG1789595-4 WG1789595-5 QC Sample: L2331189-02 Client ID: MS Sample												
Cyanide, Total	ND	9.7	9.8	100		11	100		75-125	12		35

Lab Duplicate Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2331827

Report Date: 06/16/23

Parameter	Native Sample	Duplicate Sample	Units	RPD	Qual	RPD Limits
General Chemistry - Westborough Lab Associated sample(s): 01-05,08 QC Batch ID: WG1788766-1 QC Sample: L2331800-02 Client ID: DUP Sample						
Solids, Total	74.2	74.9	%	1		20

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331827
Report Date: 06/16/23

Sample Receipt and Container Information

Were project specific reporting limits specified? YES

Cooler Information

Cooler	Custody Seal
A	Absent

Container Information

Container ID	Container Type	Cooler	Initial pH	Final pH	Temp deg C	Pres	Seal	Frozen Date/Time	Analysis(*)
L2331827-01A	5 gram Encore Sampler	A	NA		3.4	Y	Absent		NYTCL-8260HLW(14)
L2331827-01B	5 gram Encore Sampler	A	NA		3.4	Y	Absent		NYTCL-8260HLW(14)
L2331827-01C	5 gram Encore Sampler	A	NA		3.4	Y	Absent		NYTCL-8260HLW(14)
L2331827-01D	Plastic 2oz unpreserved for TS	A	NA		3.4	Y	Absent		TS(7)
L2331827-01E	Metals Only-Glass 60mL/2oz unpreserved	A	NA		3.4	Y	Absent		BE-TI(180),BA-TI(180),AS-TI(180),AG-TI(180),CR-TI(180),AL-TI(180),TL-TI(180),NI-TI(180),PB-TI(180),SE-TI(180),CU-TI(180),SB-TI(180),ZN-TI(180),V-TI(180),CO-TI(180),FE-TI(180),HG-T(28),MN-TI(180),MG-TI(180),NA-TI(180),CD-TI(180),CA-TI(180),K-TI(180)
L2331827-01F	Glass 250ml/8oz unpreserved	A	NA		3.4	Y	Absent		NYTCL-8270(14),TCN-9010(14),NYTCL-8081(14),NYTCL-8082(365)
L2331827-01X	Vial MeOH preserved split	A	NA		3.4	Y	Absent		NYTCL-8260HLW(14)
L2331827-01Y	Vial Water preserved split	A	NA		3.4	Y	Absent	08-JUN-23 07:37	NYTCL-8260HLW(14)
L2331827-01Z	Vial Water preserved split	A	NA		3.4	Y	Absent	08-JUN-23 07:37	NYTCL-8260HLW(14)
L2331827-02A	5 gram Encore Sampler	A	NA		3.4	Y	Absent		NYTCL-8260HLW(14)
L2331827-02B	5 gram Encore Sampler	A	NA		3.4	Y	Absent		NYTCL-8260HLW(14)
L2331827-02C	5 gram Encore Sampler	A	NA		3.4	Y	Absent		NYTCL-8260HLW(14)
L2331827-02D	Plastic 2oz unpreserved for TS	A	NA		3.4	Y	Absent		TS(7)
L2331827-02E	Metals Only-Glass 60mL/2oz unpreserved	A	NA		3.4	Y	Absent		BE-TI(180),AS-TI(180),BA-TI(180),AG-TI(180),NI-TI(180),CR-TI(180),TL-TI(180),AL-TI(180),ZN-TI(180),PB-TI(180),SE-TI(180),CU-TI(180),SB-TI(180),V-TI(180),CO-TI(180),HG-T(28),FE-TI(180),MN-TI(180),MG-TI(180),CA-TI(180),K-TI(180),NA-TI(180),CD-TI(180)
L2331827-02F	Glass 250ml/8oz unpreserved	A	NA		3.4	Y	Absent		NYTCL-8270(14),TCN-9010(14),NYTCL-8081(14),NYTCL-8082(365)
L2331827-02X	Vial MeOH preserved split	A	NA		3.4	Y	Absent		NYTCL-8260HLW(14)
L2331827-02Y	Vial Water preserved split	A	NA		3.4	Y	Absent	08-JUN-23 07:37	NYTCL-8260HLW(14)

*Values in parentheses indicate holding time in days

Container Information

Container ID	Container Type	Cooler	Initial pH	Final pH	Temp deg C	Pres	Seal	Frozen Date/Time	Analysis(*)
L2331827-02Z	Vial Water preserved split	A	NA		3.4	Y	Absent	08-JUN-23 07:37	NYTCL-8260HLW(14)
L2331827-03A	5 gram Encore Sampler	A	NA		3.4	Y	Absent		NYTCL-8260HLW(14)
L2331827-03B	5 gram Encore Sampler	A	NA		3.4	Y	Absent		NYTCL-8260HLW(14)
L2331827-03C	5 gram Encore Sampler	A	NA		3.4	Y	Absent		NYTCL-8260HLW(14)
L2331827-03D	Plastic 2oz unpreserved for TS	A	NA		3.4	Y	Absent		TS(7)
L2331827-03E	Metals Only-Glass 60mL/2oz unpreserved	A	NA		3.4	Y	Absent		BE-TI(180),AS-TI(180),BA-TI(180),AG-TI(180),AL-TI(180),CR-TI(180),NI-TI(180),TL-TI(180),SB-TI(180),SE-TI(180),CU-TI(180),PB-TI(180),ZN-TI(180),CO-TI(180),V-TI(180),FE-TI(180),MG-TI(180),MN-TI(180),HG-T(28),K-TI(180),NA-TI(180),CD-TI(180),CA-TI(180)
L2331827-03F	Glass 250ml/8oz unpreserved	A	NA		3.4	Y	Absent		NYTCL-8270(14),TCN-9010(14),NYTCL-8081(14),NYTCL-8082(365)
L2331827-03X	Vial MeOH preserved split	A	NA		3.4	Y	Absent		NYTCL-8260HLW(14)
L2331827-03Y	Vial Water preserved split	A	NA		3.4	Y	Absent	08-JUN-23 07:37	NYTCL-8260HLW(14)
L2331827-03Z	Vial Water preserved split	A	NA		3.4	Y	Absent	08-JUN-23 07:37	NYTCL-8260HLW(14)
L2331827-04A	5 gram Encore Sampler	A	NA		3.4	Y	Absent		NYTCL-8260HLW(14)
L2331827-04B	5 gram Encore Sampler	A	NA		3.4	Y	Absent		NYTCL-8260HLW(14)
L2331827-04C	5 gram Encore Sampler	A	NA		3.4	Y	Absent		NYTCL-8260HLW(14)
L2331827-04D	Plastic 2oz unpreserved for TS	A	NA		3.4	Y	Absent		TS(7)
L2331827-04E	Metals Only-Glass 60mL/2oz unpreserved	A	NA		3.4	Y	Absent		BE-TI(180),BA-TI(180),AS-TI(180),AG-TI(180),CR-TI(180),NI-TI(180),AL-TI(180),TL-TI(180),CU-TI(180),PB-TI(180),SB-TI(180),SE-TI(180),ZN-TI(180),CO-TI(180),V-TI(180),MG-TI(180),HG-T(28),MN-TI(180),FE-TI(180),CA-TI(180),CD-TI(180),K-TI(180),NA-TI(180)
L2331827-04F	Glass 250ml/8oz unpreserved	A	NA		3.4	Y	Absent		TCN-9010(14),NYTCL-8270(14),NYTCL-8081(14),NYTCL-8082(365)
L2331827-04X	Vial MeOH preserved split	A	NA		3.4	Y	Absent		NYTCL-8260HLW(14)
L2331827-04Y	Vial Water preserved split	A	NA		3.4	Y	Absent	08-JUN-23 07:37	NYTCL-8260HLW(14)
L2331827-04Z	Vial Water preserved split	A	NA		3.4	Y	Absent	08-JUN-23 07:37	NYTCL-8260HLW(14)
L2331827-05A	5 gram Encore Sampler	A	NA		3.4	Y	Absent		NYTCL-8260HLW(14)
L2331827-05B	5 gram Encore Sampler	A	NA		3.4	Y	Absent		NYTCL-8260HLW(14)
L2331827-05C	5 gram Encore Sampler	A	NA		3.4	Y	Absent		NYTCL-8260HLW(14)
L2331827-05D	Plastic 2oz unpreserved for TS	A	NA		3.4	Y	Absent		TS(7)

*Values in parentheses indicate holding time in days

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2331827
Report Date: 06/16/23

Container Information

Container ID	Container Type	Cooler	Initial pH	Final pH	Temp deg C	Pres	Seal	Frozen Date/Time	Analysis(*)
L2331827-05E	Metals Only-Glass 60mL/2oz unpreserved	A	NA		3.4	Y	Absent		BE-TI(180),AS-TI(180),BA-TI(180),AG-TI(180),NI-TI(180),TL-TI(180),AL-TI(180),CR-TI(180),PB-TI(180),ZN-TI(180),CU-TI(180),SE-TI(180),SB-TI(180),CO-TI(180),V-TI(180),MG-TI(180),MN-TI(180),FE-TI(180),HG-T(28),CA-TI(180),K-TI(180),NA-TI(180),CD-TI(180)
L2331827-05F	Glass 250ml/8oz unpreserved	A	NA		3.4	Y	Absent		NYTCL-8270(14),TCN-9010(14),NYTCL-8081(14),NYTCL-8082(365)
L2331827-05X	Vial MeOH preserved split	A	NA		3.4	Y	Absent		NYTCL-8260HLW(14)
L2331827-05Y	Vial Water preserved split	A	NA		3.4	Y	Absent	08-JUN-23 07:37	NYTCL-8260HLW(14)
L2331827-05Z	Vial Water preserved split	A	NA		3.4	Y	Absent	08-JUN-23 07:37	NYTCL-8260HLW(14)
L2331827-06A	Vial HCl preserved	A	NA		3.4	Y	Absent		NYTCL-8260(14)
L2331827-06B	Vial HCl preserved	A	NA		3.4	Y	Absent		NYTCL-8260(14)
L2331827-06C	Vial HCl preserved	A	NA		3.4	Y	Absent		NYTCL-8260(14)
L2331827-06D	Amber 120ml unpreserved	A	7	7	3.4	Y	Absent		NYTCL-8081(7)
L2331827-06E	Amber 120ml unpreserved	A	7	7	3.4	Y	Absent		NYTCL-8081(7)
L2331827-06F	Amber 120ml unpreserved	A	7	7	3.4	Y	Absent		NYTCL-8082-LVI(365)
L2331827-06G	Amber 120ml unpreserved	A	7	7	3.4	Y	Absent		NYTCL-8082-LVI(365)
L2331827-06H	Amber 250ml unpreserved	A	7	7	3.4	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)
L2331827-06I	Amber 250ml unpreserved	A	7	7	3.4	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)
L2331827-06J	Plastic 250ml NaOH preserved	A	>12	>12	3.4	Y	Absent		TCN-9010(14)
L2331827-06K	Plastic 250ml HNO3 preserved	A	<2	<2	3.4	Y	Absent		SE-6020T(180),BA-6020T(180),FE-6020T(180),TL-6020T(180),CR-6020T(180),NI-6020T(180),CA-6020T(180),K-6020T(180),NA-6020T(180),ZN-6020T(180),CU-6020T(180),PB-6020T(180),MN-6020T(180),BE-6020T(180),SB-6020T(180),V-6020T(180),AS-6020T(180),AG-6020T(180),AL-6020T(180),HG-T(28),MG-6020T(180),CD-6020T(180),CO-6020T(180)
L2331827-07A	Vial HCl preserved	A	NA		3.4	Y	Absent		NYTCL-8260(14)
L2331827-07B	Vial HCl preserved	A	NA		3.4	Y	Absent		NYTCL-8260(14)
L2331827-07C	Vial HCl preserved	A	NA		3.4	Y	Absent		NYTCL-8260(14)
L2331827-07D	Amber 120ml unpreserved	A	7	7	3.4	Y	Absent		NYTCL-8081(7)
L2331827-07E	Amber 120ml unpreserved	A	7	7	3.4	Y	Absent		NYTCL-8081(7)

*Values in parentheses indicate holding time in days

Container Information

Container ID	Container Type	Cooler	Initial pH	Final pH	Temp deg C	Pres	Seal	Frozen Date/Time	Analysis(*)
L2331827-07F	Amber 120ml unpreserved	A	7	7	3.4	Y	Absent		NYTCL-8082-LVI(365)
L2331827-07G	Amber 120ml unpreserved	A	7	7	3.4	Y	Absent		NYTCL-8082-LVI(365)
L2331827-07H	Amber 250ml unpreserved	A	7	7	3.4	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)
L2331827-07I	Amber 250ml unpreserved	A	7	7	3.4	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)
L2331827-07J	Plastic 250ml NaOH preserved	A	>12	>12	3.4	Y	Absent		TCN-9010(14)
L2331827-07K	Plastic 250ml HNO3 preserved	A	<2	<2	3.4	Y	Absent		TL-6020T(180),SE-6020T(180),BA-6020T(180),FE-6020T(180),NI-6020T(180),CA-6020T(180),K-6020T(180),CR-6020T(180),CU-6020T(180),ZN-6020T(180),NA-6020T(180),PB-6020T(180),BE-6020T(180),MN-6020T(180),V-6020T(180),AS-6020T(180),SB-6020T(180),AL-6020T(180),MG-6020T(180),CD-6020T(180),HG-T(28),AG-6020T(180),CO-6020T(180)
L2331827-08A	5 gram Encore Sampler	A	NA		3.4	Y	Absent		NYTCL-8260HLW(14)
L2331827-08B	5 gram Encore Sampler	A	NA		3.4	Y	Absent		NYTCL-8260HLW(14)
L2331827-08C	5 gram Encore Sampler	A	NA		3.4	Y	Absent		NYTCL-8260HLW(14)
L2331827-08D	Plastic 2oz unpreserved for TS	A	NA		3.4	Y	Absent		TS(7)
L2331827-08E	Metals Only-Glass 60mL/2oz unpreserved	A	NA		3.4	Y	Absent		BE-TI(180),AS-TI(180),BA-TI(180),AG-TI(180),NI-TI(180),CR-TI(180),AL-TI(180),TL-TI(180),CU-TI(180),ZN-TI(180),SE-TI(180),SB-TI(180),PB-TI(180),V-TI(180),CO-TI(180),MG-TI(180),HG-T(28),MN-TI(180),FE-TI(180),CA-TI(180),NA-TI(180),CD-TI(180),K-TI(180)
L2331827-08F	Glass 250ml/8oz unpreserved	A	NA		3.4	Y	Absent		TCN-9010(14),NYTCL-8270(14),NYTCL-8081(14),NYTCL-8082(365)
L2331827-08X	Vial MeOH preserved split	A	NA		3.4	Y	Absent		NYTCL-8260HLW(14)
L2331827-08Y	Vial Water preserved split	A	NA		3.4	Y	Absent	08-JUN-23 07:37	NYTCL-8260HLW(14)
L2331827-08Z	Vial Water preserved split	A	NA		3.4	Y	Absent	08-JUN-23 07:37	NYTCL-8260HLW(14)

*Values in parentheses indicate holding time in days

Project Name:	100 MAIN ST.	**Lab Number:**	L2331827
Project Number:	12461	**Report Date:**	06/16/23

GLOSSARY

Acronyms

DL	- Detection Limit: This value represents the level to which target analyte concentrations are reported as estimated values, when those target analyte concentrations are quantified below the limit of quantitation (LOQ). The DL includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.)
EDL	- Estimated Detection Limit: This value represents the level to which target analyte concentrations are reported as estimated values, when those target analyte concentrations are quantified below the reporting limit (RL). The EDL includes any adjustments from dilutions, concentrations or moisture content, where applicable. The use of EDLs is specific to the analysis of PAHs using Solid-Phase Microextraction (SPME).
EMPC	- Estimated Maximum Possible Concentration: The concentration that results from the signal present at the retention time of an analyte when the ions meet all of the identification criteria except the ion abundance ratio criteria. An EMPC is a worst-case estimate of the concentration.
EPA	- Environmental Protection Agency.
LCS	- Laboratory Control Sample: A sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes or a material containing known and verified amounts of analytes.
LCSD	- Laboratory Control Sample Duplicate: Refer to LCS.
LFB	- Laboratory Fortified Blank: A sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes or a material containing known and verified amounts of analytes.
LOD	- Limit of Detection: This value represents the level to which a target analyte can reliably be detected for a specific analyte in a specific matrix by a specific method. The LOD includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.)
LOQ	- Limit of Quantitation: The value at which an instrument can accurately measure an analyte at a specific concentration. The LOQ includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.) Limit of Quantitation: The value at which an instrument can accurately measure an analyte at a specific concentration. The LOQ includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.)
MDL	- Method Detection Limit: This value represents the level to which target analyte concentrations are reported as estimated values, when those target analyte concentrations are quantified below the reporting limit (RL). The MDL includes any adjustments from dilutions, concentrations or moisture content, where applicable.
MS	- Matrix Spike Sample: A sample prepared by adding a known mass of target analyte to a specified amount of matrix sample for which an independent estimate of target analyte concentration is available. For Method 332.0, the spike recovery is calculated using the native concentration, including estimated values.
MSD	- Matrix Spike Sample Duplicate: Refer to MS.
NA	- Not Applicable.
NC	- Not Calculated: Term is utilized when one or more of the results utilized in the calculation are non-detect at the parameter's reporting unit.
NDPA/DPA	- N-Nitrosodiphenylamine/Diphenylamine.
NI	- Not Ignitable.
NP	- Non-Plastic: Term is utilized for the analysis of Atterberg Limits in soil.
NR	- No Results: Term is utilized when 'No Target Compounds Requested' is reported for the analysis of Volatile or Semivolatile Organic TIC only requests.
RL	- Reporting Limit: The value at which an instrument can accurately measure an analyte at a specific concentration. The RL includes any adjustments from dilutions, concentrations or moisture content, where applicable.
RPD	- Relative Percent Difference: The results from matrix and/or matrix spike duplicates are primarily designed to assess the precision of analytical results in a given matrix and are expressed as relative percent difference (RPD). Values which are less than five times the reporting limit for any individual parameter are evaluated by utilizing the absolute difference between the values; although the RPD value will be provided in the report.
SRM	- Standard Reference Material: A reference sample of a known or certified value that is of the same or similar matrix as the associated field samples.
STLP	- Semi-dynamic Tank Leaching Procedure per EPA Method 1315.
TEF	- Toxic Equivalency Factors: The values assigned to each dioxin and furan to evaluate their toxicity relative to 2,3,7,8-TCDD.
TEQ	- Toxic Equivalent: The measure of a sample's toxicity derived by multiplying each dioxin and furan by its corresponding TEF and then summing the resulting values.
TIC	- Tentatively Identified Compound: A compound that has been identified to be present and is not part of the target compound list (TCL) for the method and/or program. All TICs are qualitatively identified and reported as estimated concentrations.

Report Format: DU Report with 'J' Qualifiers

Project Name:	100 MAIN ST.	**Lab Number:**	L2331827
Project Number:	12461	**Report Date:**	06/16/23

Footnotes

1 - The reference for this analyte should be considered modified since this analyte is absent from the target analyte list of the original method.

Terms

Analytical Method: Both the document from which the method originates and the analytical reference method. (Example: EPA 8260B is shown as 1,8260B.) The codes for the reference method documents are provided in the References section of the Addendum.

Chlordane: The target compound Chlordane (CAS No. 57-74-9) is reported for GC ECD analyses. Per EPA,this compound "refers to a mixture of chlordane isomers, other chlorinated hydrocarbons and numerous other components." (Reference: USEPA Toxicological Review of Chlordane, In Support of Summary Information on the Integrated Risk Information System (IRIS), December 1997.)

Difference: With respect to Total Oxidizable Precursor (TOP) Assay analysis, the difference is defined as the Post-Treatment value minus the Pre-Treatment value.

Final pH: As it pertains to Sample Receipt & Container Information section of the report, Final pH reflects pH of container determined after adjustment at the laboratory, if applicable. If no adjustment required, value reflects Initial pH.

Frozen Date/Time: With respect to Volatile Organics in soil, Frozen Date/Time reflects the date/time at which associated Reagent Water-preserved vials were initially frozen. Note: If frozen date/time is beyond 48 hours from sample collection, value will be reflected in 'bold'.

Gasoline Range Organics (GRO): Gasoline Range Organics (GRO) results include all chromatographic peaks eluting from Methyl tert butyl ether through Naphthalene, with the exception of GRO analysis in support of State of Ohio programs, which includes all chromatographic peaks eluting from Hexane through Dodecane.

Initial pH: As it pertains to Sample Receipt & Container Information section of the report, Initial pH reflects pH of container determined upon receipt, if applicable.

PAH Total: With respect to Alkylated PAH analyses, the 'PAHs, Total' result is defined as the summation of results for all or a subset of the following compounds: Naphthalene, C1-C4 Naphthalenes, 2-Methylnaphthalene, 1-Methylnaphthalene, Biphenyl, Acenaphthylene, Acenaphthene, Fluorene, C1-C3 Fluorenes, Phenanthrene, C1-C4 Phenanthrenes/Anthracenes, Anthracene, Fluoranthene, Pyrene, C1-C4 Fluoranthenes/Pyrenes, Benz(a)anthracene, Chrysene, C1-C4 Chrysenes, Benzo(b)fluoranthene, Benzo(j)+(k)fluoranthene, Benzo(e)pyrene, Benzo(a)pyrene, Perylene, Indeno(1,2,3-cd)pyrene, Dibenz(ah)+(ac)anthracene, Benzo(g,h,i)perylene. If a 'Total' result is requested, the results of its individual components will also be reported.

PFAS Total: With respect to PFAS analyses, the 'PFAS, Total (5)' result is defined as the summation of results for: PFHpA, PFHxS, PFOA, PFNA and PFOS. In addition, the 'PFAS, Total (6)' result is defined as the summation of results for: PFHpA, PFHxS, PFOA, PFNA, PFDA and PFOS. For MassDEP DW compliance analysis only, the 'PFAS, Total (6)' result is defined as the summation of results at or above the RL. Note: If a 'Total' result is requested, the results of its individual components will also be reported.

Total: With respect to Organic analyses, a 'Total' result is defined as the summation of results for individual isomers or Aroclors. If a 'Total' result is requested, the results of its individual components will also be reported. This is applicable to 'Total' results for methods 8260, 8081 and 8082.

Data Qualifiers

A - Spectra identified as "Aldol Condensates" are byproducts of the extraction/concentration procedures when acetone is introduced in the process.

B - The analyte was detected above the reporting limit in the associated method blank. Flag only applies to associated field samples that have detectable concentrations of the analyte at less than ten times (10x) the concentration found in the blank. For MCP-related projects, flag only applies to associated field samples that have detectable concentrations of the analyte at less than ten times (10x) the concentration found in the blank. For DOD-related projects, flag only applies to associated field samples that have detectable concentrations of the analyte at less than ten times (10x) the concentration found in the blank AND the analyte was detected above one-half the reporting limit (or above the reporting limit for common lab contaminants) in the associated method blank. For NJ-Air-related projects, flag only applies to associated field samples that have detectable concentrations of the analyte above the reporting limit. For NJ-related projects (excluding Air), flag only applies to associated field samples that have detectable concentrations of the analyte, which was detected above the reporting limit in the associated method blank or above five times the reporting limit for common lab contaminants (Phthalates, Acetone, Methylene Chloride, 2-Butanone).

C - Co-elution: The target analyte co-elutes with a known lab standard (i.e. surrogate, internal standards, etc.) for co-extracted analyses.

D - Concentration of analyte was quantified from diluted analysis. Flag only applies to field samples that have detectable concentrations of the analyte.

E - Concentration of analyte exceeds the range of the calibration curve and/or linear range of the instrument.

F - The ratio of quantifier ion response to qualifier ion response falls outside of the laboratory criteria. Results are considered to be an estimated maximum concentration.

G - The concentration may be biased high due to matrix interferences (i.e, co-elution) with non-target compound(s). The result should be considered estimated.

H - The analysis of pH was performed beyond the regulatory-required holding time of 15 minutes from the time of sample collection.

I - The lower value for the two columns has been reported due to obvious interference.

J - Estimated value. The Target analyte concentration is below the quantitation limit (RL), but above the Method Detection Limit (MDL) or Estimated Detection Limit (EDL) for SPME-related analyses. This represents an estimated concentration for Tentatively

Report Format: DU Report with 'J' Qualifiers

Project Name:	100 MAIN ST.	**Lab Number:**	L2331827
Project Number:	12461	**Report Date:**	06/16/23

Data Qualifiers

Identified Compounds (TICs).

M - Reporting Limit (RL) exceeds the MCP CAM Reporting Limit for this analyte.

ND - Not detected at the method detection limit (MDL) for the sample, or estimated detection limit (EDL) for SPME-related analyses.

NJ - Presumptive evidence of compound. This represents an estimated concentration for Tentatively Identified Compounds (TICs), where the identification is based on a mass spectral library search.

P - The RPD between the results for the two columns exceeds the method-specified criteria.

Q - The quality control sample exceeds the associated acceptance criteria. For DOD-related projects, LCS and/or Continuing Calibration Standard exceedences are also qualified on all associated sample results. Note: This flag is not applicable for matrix spike recoveries when the sample concentration is greater than 4x the spike added or for batch duplicate RPD when the sample concentrations are less than 5x the RL. (Metals only.)

R - Analytical results are from sample re-analysis.

RE - Analytical results are from sample re-extraction.

S - Analytical results are from modified screening analysis.

V - The surrogate associated with this target analyte has a recovery outside the QC acceptance limits. (Applicable to MassDEP DW Compliance samples only.)

Z - The batch matrix spike and/or duplicate associated with this target analyte has a recovery/RPD outside the QC acceptance limits. (Applicable to MassDEP DW Compliance samples only.)

Report Format: DU Report with 'J' Qualifiers

Project Name:	100 MAIN ST.	**Lab Number:**	L2331827
Project Number:	12461	**Report Date:**	06/16/23

REFERENCES

1 Test Methods for Evaluating Solid Waste: Physical/Chemical Methods. EPA SW-846. Third Edition. Updates I - VI, 2018.

121 Standard Methods for the Examination of Water and Wastewater. APHA-AWWA-WEF. Standard Methods Online.

LIMITATION OF LIABILITIES

Alpha Analytical performs services with reasonable care and diligence normal to the analytical testing laboratory industry. In the event of an error, the sole and exclusive responsibility of Alpha Analytical shall be to re-perform the work at it's own expense. In no event shall Alpha Analytical be held liable for any incidental, consequential or special damages, including but not limited to, damages in any way connected with the use of, interpretation of, information or analysis provided by Alpha Analytical.

We strongly urge our clients to comply with EPA protocol regarding sample volume, preservation, cooling, containers, sampling procedures, holding time and splitting of samples in the field.

Certification Information

The following analytes are not included in our Primary NELAP Scope of Accreditation:

Westborough Facility
EPA 624/624.1: m/p-xylene, o-xylene, Naphthalene
EPA 625/625.1: alpha-Terpineol
EPA 8260C/8260D: NPW: 1,2,4,5-Tetramethylbenzene; 4-Ethyltoluene, Azobenzene; SCM: Iodomethane (methyl iodide), 1,2,4,5-Tetramethylbenzene; 4-Ethyltoluene.
EPA 8270D/8270E: NPW: Dimethylnaphthalene,1,4-Diphenylhydrazine, alpha-Terpineol; SCM: Dimethylnaphthalene,1,4-Diphenylhydrazine.
SM4500: NPW: Amenable Cyanide; SCM: Total Phosphorus, TKN, NO2, NO3.

Mansfield Facility
SM 2540D: TSS
EPA 8082A: NPW: PCB: 1, 5, 31, 87,101, 110, 141, 151, 153, 180, 183, 187.
EPA TO-15: Halothane, 2,4,4-Trimethyl-2-pentene, 2,4,4-Trimethyl-1-pentene, Thiophene, 2-Methylthiophene, 3-Methylthiophene, 2-Ethylthiophene, 1,2,3-Trimethylbenzene, Indan, Indene, 1,2,4,5-Tetramethylbenzene, Benzothiophene, 1-Methylnaphthalene.
Biological Tissue Matrix: EPA 3050B

The following analytes are included in our Massachusetts DEP Scope of Accreditation

Westborough Facility:

Drinking Water
EPA 300.0: Chloride, Nitrate-N, Fluoride, Sulfate; **EPA 353.2**: Nitrate-N, Nitrite-N; **SM4500NO3-F**: Nitrate-N, Nitrite-N; **SM4500F-C, SM4500CN-CE, EPA 180.1, SM2130B, SM4500Cl-D, SM2320B, SM2540C, SM4500H-B, SM4500NO2-B**
EPA 332: Perchlorate; **EPA 524.2:** THMs and VOCs; **EPA 504.1:** EDB, DBCP.
Microbiology: **SM9215B; SM9223-P/A, SM9223B-Colilert-QT,SM9222D**.

Non-Potable Water
SM4500H,B, EPA 120.1, SM2510B, SM2540C, SM2320B, SM4500CL-E, SM4500F-BC, SM4500NH3-BH: Ammonia-N and Kjeldahl-N, **EPA 350.1**: Ammonia-N, **LACHAT 10-107-06-1-B**: Ammonia-N, **EPA 351.1, SM4500NO3-F, EPA 353.2**: Nitrate-N, **SM4500P-E, SM4500P-B, E, SM4500SO4-E, SM5220D, EPA 410.4, SM5210B, SM5310C, SM4500CL-D, EPA 1664, EPA 420.1, SM4500-CN-CE, SM2540D, EPA 300: Chloride, Sulfate, Nitrate.**
EPA 624.1: Volatile Halocarbons & Aromatics,
EPA 608.3: Chlordane, Toxaphene, Aldrin, alpha-BHC, beta-BHC, gamma-BHC, delta-BHC, Dieldrin, DDD, DDE, DDT, Endosulfan I, Endosulfan II, Endosulfan sulfate, Endrin, Endrin Aldehyde, Heptachlor, Heptachlor Epoxide, PCBs
EPA 625.1: SVOC (Acid/Base/Neutral Extractables), **EPA 600/4-81-045**: PCB-Oil.
Microbiology: **SM9223B-Colilert-QT; Enterolert-QT, SM9221E, EPA 1600, EPA 1603, SM9222D.**

Mansfield Facility:

Drinking Water
EPA 200.7: Al, Ba, Cd, Cr, Cu, Fe, Mn, Ni, Na, Ag, Ca, Zn. **EPA 200.8:** Al, Sb, As, Ba, Be, Cd, Cr, Cu, Pb, Mn, Ni, Se, Ag, TL, Zn. **EPA 245.1** Hg.
EPA 522, EPA 537.1.

Non-Potable Water
EPA 200.7: Al, Sb, As, Be, Cd, Ca, Cr, Co, Cu, Fe, Pb, Mg, Mn, Mo, Ni, K, Se, Ag, Na, Sr, TL, Ti, V, Zn.
EPA 200.8: Al, Sb, As, Be, Cd, Cr, Cu, Fe, Pb, Mn, Ni, K, Se, Ag, Na, TL, Zn.
EPA 245.1 Hg.
SM2340B

For a complete listing of analytes and methods, please contact your Alpha Project Manager.

NEW YORK CHAIN OF CUSTODY

ALPHA ANALYTICAL

Westborough, MA 01581 — 8 Walkup Dr. — TEL: 508-898-9220 — FAX: 508-898-9193

Mansfield, MA 02048 — 320 Forbes Blvd — TEL: 508-822-9300 — FAX: 508-822-3288

Service Centers
Mahwah, NJ 07430: 35 Whitney Rd, Suite 5
Albany, NY 12205: 14 Walker Way
Tonawanda, NY 14150: 275 Cooper Ave, Suite 105

Page 1 of 1

Date Rec'd in Lab: 06/07/23

ALPHA Job #: L2331827

Client Information
Client: SESI
Address: 959 US 46 Fl 3 5300 Parsippany, NJ 07054
Phone: 973 808 9050
Fax:
Email: JCS@sesi.org

Project Information
Project Name: 100 Main St
Project Location: White Plains NY
Project #: 12461
(Use Project name as Project #)
Project Manager: Jon Stuart
ALPHAQuote #:

Turn-Around Time
Standard ☑ Due Date:
Rush (only if pre approved) ☐ # of Days:

Deliverables
☐ ASP-A ☑ ASP-B
☐ EQuIS (1 File) ☐ EQuIS (4 File)
☐ Other

Billing Information
☐ Same as Client Info
PO # Renaissance Equity Mgmt.
Attn: Kevin McNamus

Regulatory Requirement
☐ NY TOGS ☐ NY Part 375
☑ AWQ Standards ☐ NY CP-51
☐ NY Restricted Use ☐ Other
☑ NY Unrestricted Use
☐ NYC Sewer Discharge

Disposal Site Information
Please identify below location of applicable disposal facilities.
Disposal Facility:
☐ NJ ☐ NY
☐ Other:

These samples have been previously analyzed by Alpha ☐

Other project specific requirements/comments:

Please specify Metals or TAL.

ANALYSIS
TCL+30/TAL

Sample Filtration
☐ Done
☐ Lab to do
Preservation
☐ Lab to do
(Please Specify below)

ALPHA Lab ID (Lab Use Only)	Sample ID	Collection Date	Collection Time	Sample Matrix	Sampler's Initials	TCL+30/TAL	Sample Specific Comments	Total Bottle
31827-01	SB-39(0.5-1)	6/7/23	905	S	CB	✓		
-02	SB-40(1-1.5)		1005	S	CB	✓		
-03	SB-41(2.5-3)		1070	S	CB	✓		
-04	SB-42(7-7.5)		1050	S	CB	✓		
-05	SB-43(5-5.5)		1130	S	CB	✓		
-06	GW-14		920	GW	CB	✓		
-07	GW-15		1145	GW	CB	✓		
-08	SB-26C(1.5-2)		1245	S	CB	✓		

Preservative Code:
A = None
B = HCl
C = HNO_3
D = H_2SO_4
E = NaOH
F = MeOH
G = $NaHSO_4$
H = $Na_2S_2O_3$
K/E = Zn Ac/NaOH
O = Other

Container Code
P = Plastic
A = Amber Glass
V = Vial
G = Glass
B = Bacteria Cup
C = Cube
O = Other
E = Encore
D = BOD Bottle

Westboro: Certification No: MA935
Mansfield: Certification No: MA015

Container Type	P/G	
Preservative	some	

Relinquished By:	Date/Time	Received By:	Date/Time
	06/07/23 1305	FIPEX ALPHA	6/7/23 13:05
MPS via ALPHA	6/7/23 18:45		6/7/23 18:50
	6/7/23		6/7/23 21:30
	6/7/23 23:30		6/7/23 23:30

Please print clearly, legibly and completely. Samples can not be logged in and turnaround time clock will not start until any ambiguities are resolved. BY EXECUTING THIS COC, THE CLIENT HAS READ AND AGREES TO BE BOUND BY ALPHA'S TERMS & CONDITIONS. (See reverse side.)

Form No: 01-25 HC (rev. 30-Sept-2013)

ANALYTICAL REPORT

Lab Number:	L2332665
Client:	Soils Engineering Services, Inc. 959 Route 46E Parsippany, NJ 07054
ATTN:	Jonathan Stuart
Phone:	(973) 808-9050
Project Name:	100 MAIN ST.
Project Number:	12461
Report Date:	06/19/23

The original project report/data package is held by Alpha Analytical. This report/data package is paginated and should be reproduced only in its entirety. Alpha Analytical holds no responsibility for results and/or data that are not consistent with the original.

Certifications & Approvals: MA (M-MA086), NH NELAP (2064), CT (PH-0826), IL (200077), IN (C-MA-03), KY (KY98045), ME (MA00086), MD (348), NJ (MA935), NY (11148), NC (25700/666), OH (CL108), OR (MA-1316), PA (68-03671), RI (LAO00065), TX (T104704476), VT (VT-0935), VA (460195), USDA (Permit #525-23-122-91930).

Eight Walkup Drive, Westborough, MA 01581-1019
508-898-9220 (Fax) 508-898-9193 800-624-9220 - www.alphalab.com

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2332665
Report Date: 06/19/23

Alpha Sample ID	Client ID	Matrix	Sample Location	Collection Date/Time	Receive Date
L2332665-01	SB-44P (2-2.5)	SOIL	WHITE PLAINS, NY	06/09/23 07:35	06/09/23
L2332665-02	SB-45P (4-4.5)	SOIL	WHITE PLAINS, NY	06/09/23 07:50	06/09/23
L2332665-03	SB-46P (4.5-5)	SOIL	WHITE PLAINS, NY	06/09/23 11:30	06/09/23
L2332665-04	SB-47P (3-3.5)	SOIL	WHITE PLAINS, NY	06/09/23 12:40	06/09/23
L2332665-05	SB-48P (3.5-4)	SOIL	WHITE PLAINS, NY	06/09/23 12:55	06/09/23
L2332665-06	GW-16	WATER	WHITE PLAINS, NY	06/09/23 13:10	06/09/23
L2332665-07	GW-17	WATER	WHITE PLAINS, NY	06/09/23 12:10	06/09/23

Project Name:	100 MAIN ST.	**Lab Number:**	L2332665
Project Number:	12461	**Report Date:**	06/19/23

Case Narrative

The samples were received in accordance with the Chain of Custody and no significant deviations were encountered during the preparation or analysis unless otherwise noted. Sample Receipt, Container Information, and the Chain of Custody are located at the back of the report.

Results contained within this report relate only to the samples submitted under this Alpha Lab Number and meet NELAP requirements for all NELAP accredited parameters unless otherwise noted in the following narrative. The data presented in this report is organized by parameter (i.e. VOC, SVOC, etc.). Sample specific Quality Control data (i.e. Surrogate Spike Recovery) is reported at the end of the target analyte list for each individual sample, followed by the Laboratory Batch Quality Control at the end of each parameter. Tentatively Identified Compounds (TICs), if requested, are reported for compounds identified to be present and are not part of the method/program Target Compound List, even if only a subset of the TCL are being reported. If a sample was re-analyzed or re-extracted due to a required quality control corrective action and if both sets of data are reported, the Laboratory ID of the re-analysis or re-extraction is designated with an "R" or "RE", respectively.

When multiple Batch Quality Control elements are reported (e.g. more than one LCS), the associated samples for each element are noted in the grey shaded header line of each data table. Any Laboratory Batch, Sample Specific % recovery or RPD value that is outside the listed Acceptance Criteria is bolded in the report. In reference to questions H (CAM) or 4 (RCP) when "NO" is checked, the performance criteria for CAM and RCP methods allow for some quality control failures to occur and still be within method compliance. In these instances, the specific failure is not narrated but noted in the associated QC Outlier Summary Report, located directly after the Case Narrative. QC information is also incorporated in the Data Usability Assessment table (Format 11) of our Data Merger tool, where it can be reviewed in conjunction with the sample result, associated regulatory criteria and any associated data usability implications.

Soil/sediments, solids and tissues are reported on a dry weight basis unless otherwise noted. Definitions of all data qualifiers and acronyms used in this report are provided in the Glossary located at the back of the report.

HOLD POLICY - For samples submitted on hold, Alpha's policy is to hold samples (with the exception of Air canisters) free of charge for 21 calendar days from the date the project is completed. After 21 calendar days, we will dispose of all samples submitted including those put on hold unless you have contacted your Alpha Project Manager and made arrangements for Alpha to continue to hold the samples. Air canisters will be disposed after 3 business days from the date the project is completed.

Please contact Project Management at 800-624-9220 with any questions.

Project Name:	100 MAIN ST.	**Lab Number:**	L2332665
Project Number:	12461	**Report Date:**	06/19/23

Case Narrative (continued)

Report Submission

All non-detect (ND) or estimated concentrations (J-qualified) have been quantitated to the limit noted in the MDL column.

Sample Receipt

L2332665-06: The collection date and time on the chain of custody was 09-JUN-23 13:10; however, the collection date/time on the container label was 09-JUN-23 13:50. At the client's request, the collection date/time is reported as 09-JUN-23 13:10.

Volatile Organics

L2332665-06 and -07: The pH was greater than two; however, the sample was analyzed within the method required holding time.

Semivolatile Organics

The WG1789783-2/-3 LCS/LCSD recoveries, associated with L2332665-01 through -05, are below the acceptance criteria for benzoic acid (0%/0%); however, it has been identified as a "difficult" analyte. The results of the associated samples are reported.

Pesticides

L2332665-05: The internal standard (IS) response for 1-bromo-2-nitrobenzene (1503%) was above the acceptance criteria on column A; however, the sample was not re-analyzed due to obvious interferences. The surrogate recoveries are outside the method acceptance criteria for 2,4,5,6-tetrachloro-m-xylene (7%) and decachlorobiphenyl (6%) due to interference with the Internal Standard.

Total Metals

L2332665-01 through -05: The sample has elevated detection limits for all elements, with the exception of mercury, due to the dilution required by the sample matrix.

Project Name:	100 MAIN ST.	**Lab Number:**	L2332665
Project Number:	12461	**Report Date:**	06/19/23

Case Narrative (continued)

The WG1789741-1 Method Blank, associated with L2332665-01 through -05, has concentrations above the reporting limits for calcium and iron. Since the associated sample concentrations are either greater than 10x the blank concentrations or non-detect to the RL for these target analytes, no corrective action is required. Any results detected below the reporting limit are qualified with a "B".

Cyanide, Total

The WG1791402-2 LCS recovery for cyanide, total (76%), associated with L2332665-01, is outside our in-house acceptance criteria, but within the vendor-certified acceptance limits. The results of the original analyses are reported.

The WG1791403-2 LCS recovery for cyanide, total (76%), associated with L2332665-02 through -04, is outside our in-house acceptance criteria, but within the vendor-certified acceptance limits. The results of the original analyses are reported.

I, the undersigned, attest under the pains and penalties of perjury that, to the best of my knowledge and belief and based upon my personal inquiry of those responsible for providing the information contained in this analytical report, such information is accurate and complete. This certificate of analysis is not complete unless this page accompanies any and all pages of this report.

Authorized Signature: Kelly Stenstrom

Title: Technical Director/Representative Date: 06/19/23

ORGANICS

VOLATILES

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-01
Client ID: SB-44P (2-2.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/09/23 07:35
Date Received: 06/09/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8260D
Analytical Date: 06/13/23 16:04
Analyst: JIC
Percent Solids: 93%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Methylene chloride	ND		ug/kg	5.1	2.3	1
1,1-Dichloroethane	ND		ug/kg	1.0	0.15	1
Chloroform	ND		ug/kg	1.5	0.14	1
Carbon tetrachloride	ND		ug/kg	1.0	0.23	1
1,2-Dichloropropane	ND		ug/kg	1.0	0.13	1
Dibromochloromethane	ND		ug/kg	1.0	0.14	1
1,1,2-Trichloroethane	ND		ug/kg	1.0	0.27	1
Tetrachloroethene	ND		ug/kg	0.51	0.20	1
Chlorobenzene	ND		ug/kg	0.51	0.13	1
Trichlorofluoromethane	ND		ug/kg	4.1	0.71	1
1,2-Dichloroethane	ND		ug/kg	1.0	0.26	1
1,1,1-Trichloroethane	ND		ug/kg	0.51	0.17	1
Bromodichloromethane	ND		ug/kg	0.51	0.11	1
trans-1,3-Dichloropropene	ND		ug/kg	1.0	0.28	1
cis-1,3-Dichloropropene	ND		ug/kg	0.51	0.16	1
1,3-Dichloropropene, Total	ND		ug/kg	0.51	0.16	1
1,1-Dichloropropene	ND		ug/kg	0.51	0.16	1
Bromoform	ND		ug/kg	4.1	0.25	1
1,1,2,2-Tetrachloroethane	ND		ug/kg	0.51	0.17	1
Benzene	ND		ug/kg	0.51	0.17	1
Toluene	ND		ug/kg	1.0	0.55	1
Ethylbenzene	ND		ug/kg	1.0	0.14	1
Chloromethane	ND		ug/kg	4.1	0.95	1
Bromomethane	ND		ug/kg	2.0	0.59	1
Vinyl chloride	ND		ug/kg	1.0	0.34	1
Chloroethane	ND		ug/kg	2.0	0.46	1
1,1-Dichloroethene	ND		ug/kg	1.0	0.24	1
trans-1,2-Dichloroethene	ND		ug/kg	1.5	0.14	1

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-01 Date Collected: 06/09/23 07:35

Client ID: SB-44P (2-2.5) Date Received: 06/09/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Trichloroethene	ND		ug/kg	0.51	0.14	1
1,2-Dichlorobenzene	ND		ug/kg	2.0	0.15	1
1,3-Dichlorobenzene	ND		ug/kg	2.0	0.15	1
1,4-Dichlorobenzene	ND		ug/kg	2.0	0.17	1
Methyl tert butyl ether	ND		ug/kg	2.0	0.20	1
p/m-Xylene	ND		ug/kg	2.0	0.57	1
o-Xylene	ND		ug/kg	1.0	0.30	1
Xylenes, Total	ND		ug/kg	1.0	0.30	1
cis-1,2-Dichloroethene	ND		ug/kg	1.0	0.18	1
1,2-Dichloroethene, Total	ND		ug/kg	1.0	0.14	1
Dibromomethane	ND		ug/kg	2.0	0.24	1
Styrene	ND		ug/kg	1.0	0.20	1
Dichlorodifluoromethane	ND		ug/kg	10	0.93	1
Acetone	ND		ug/kg	10	4.9	1
Carbon disulfide	ND		ug/kg	10	4.6	1
2-Butanone	ND		ug/kg	10	2.2	1
Vinyl acetate	ND		ug/kg	10	2.2	1
4-Methyl-2-pentanone	ND		ug/kg	10	1.3	1
1,2,3-Trichloropropane	ND		ug/kg	2.0	0.13	1
2-Hexanone	ND		ug/kg	10	1.2	1
Bromochloromethane	ND		ug/kg	2.0	0.21	1
2,2-Dichloropropane	ND		ug/kg	2.0	0.20	1
1,2-Dibromoethane	ND		ug/kg	1.0	0.28	1
1,3-Dichloropropane	ND		ug/kg	2.0	0.17	1
1,1,1,2-Tetrachloroethane	ND		ug/kg	0.51	0.13	1
Bromobenzene	ND		ug/kg	2.0	0.15	1
n-Butylbenzene	ND		ug/kg	1.0	0.17	1
sec-Butylbenzene	ND		ug/kg	1.0	0.15	1
tert-Butylbenzene	ND		ug/kg	2.0	0.12	1
o-Chlorotoluene	ND		ug/kg	2.0	0.19	1
p-Chlorotoluene	ND		ug/kg	2.0	0.11	1
1,2-Dibromo-3-chloropropane	ND		ug/kg	3.0	1.0	1
Hexachlorobutadiene	ND		ug/kg	4.1	0.17	1
Isopropylbenzene	ND		ug/kg	1.0	0.11	1
p-Isopropyltoluene	ND		ug/kg	1.0	0.11	1
Naphthalene	ND		ug/kg	4.1	0.66	1
Acrylonitrile	ND		ug/kg	4.1	1.2	1

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-01 Date Collected: 06/09/23 07:35

Client ID: SB-44P (2-2.5) Date Received: 06/09/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
n-Propylbenzene	ND		ug/kg	1.0	0.17	1
1,2,3-Trichlorobenzene	ND		ug/kg	2.0	0.33	1
1,2,4-Trichlorobenzene	ND		ug/kg	2.0	0.28	1
1,3,5-Trimethylbenzene	ND		ug/kg	2.0	0.20	1
1,2,4-Trimethylbenzene	ND		ug/kg	2.0	0.34	1
1,4-Dioxane	ND		ug/kg	81	36.	1
p-Diethylbenzene	ND		ug/kg	2.0	0.18	1
p-Ethyltoluene	ND		ug/kg	2.0	0.39	1
1,2,4,5-Tetramethylbenzene	ND		ug/kg	2.0	0.19	1
Ethyl ether	ND		ug/kg	2.0	0.35	1
trans-1,4-Dichloro-2-butene	ND		ug/kg	5.1	1.4	1
Tentatively Identified Compounds						
Total TIC Compounds	18.0	J	ug/kg			1
Unknown	3.51	J	ug/kg			1
Unknown	2.12	J	ug/kg			1
Unknown	2.85	J	ug/kg			1
Unknown Naphthalene	3.21	J	ug/kg			1
Unknown	6.32	J	ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	103		70-130
Toluene-d8	101		70-130
4-Bromofluorobenzene	101		70-130
Dibromofluoromethane	97		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-02
Client ID: SB-45P (4-4.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/09/23 07:50
Date Received: 06/09/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8260D
Analytical Date: 06/13/23 16:30
Analyst: JIC
Percent Solids: 93%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Methylene chloride	ND		ug/kg	5.0	2.3	1
1,1-Dichloroethane	ND		ug/kg	1.0	0.14	1
Chloroform	ND		ug/kg	1.5	0.14	1
Carbon tetrachloride	ND		ug/kg	1.0	0.23	1
1,2-Dichloropropane	ND		ug/kg	1.0	0.12	1
Dibromochloromethane	ND		ug/kg	1.0	0.14	1
1,1,2-Trichloroethane	ND		ug/kg	1.0	0.27	1
Tetrachloroethene	ND		ug/kg	0.50	0.20	1
Chlorobenzene	ND		ug/kg	0.50	0.13	1
Trichlorofluoromethane	ND		ug/kg	4.0	0.70	1
1,2-Dichloroethane	ND		ug/kg	1.0	0.26	1
1,1,1-Trichloroethane	ND		ug/kg	0.50	0.17	1
Bromodichloromethane	ND		ug/kg	0.50	0.11	1
trans-1,3-Dichloropropene	ND		ug/kg	1.0	0.27	1
cis-1,3-Dichloropropene	ND		ug/kg	0.50	0.16	1
1,3-Dichloropropene, Total	ND		ug/kg	0.50	0.16	1
1,1-Dichloropropene	ND		ug/kg	0.50	0.16	1
Bromoform	ND		ug/kg	4.0	0.25	1
1,1,2,2-Tetrachloroethane	ND		ug/kg	0.50	0.17	1
Benzene	ND		ug/kg	0.50	0.17	1
Toluene	ND		ug/kg	1.0	0.54	1
Ethylbenzene	ND		ug/kg	1.0	0.14	1
Chloromethane	ND		ug/kg	4.0	0.94	1
Bromomethane	ND		ug/kg	2.0	0.58	1
Vinyl chloride	ND		ug/kg	1.0	0.34	1
Chloroethane	ND		ug/kg	2.0	0.45	1
1,1-Dichloroethene	ND		ug/kg	1.0	0.24	1
trans-1,2-Dichloroethene	ND		ug/kg	1.5	0.14	1

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-02 Date Collected: 06/09/23 07:50

Client ID: SB-45P (4-4.5) Date Received: 06/09/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Trichloroethene	ND		ug/kg	0.50	0.14	1
1,2-Dichlorobenzene	ND		ug/kg	2.0	0.14	1
1,3-Dichlorobenzene	ND		ug/kg	2.0	0.15	1
1,4-Dichlorobenzene	ND		ug/kg	2.0	0.17	1
Methyl tert butyl ether	ND		ug/kg	2.0	0.20	1
p/m-Xylene	ND		ug/kg	2.0	0.56	1
o-Xylene	ND		ug/kg	1.0	0.29	1
Xylenes, Total	ND		ug/kg	1.0	0.29	1
cis-1,2-Dichloroethene	ND		ug/kg	1.0	0.18	1
1,2-Dichloroethene, Total	ND		ug/kg	1.0	0.14	1
Dibromomethane	ND		ug/kg	2.0	0.24	1
Styrene	ND		ug/kg	1.0	0.20	1
Dichlorodifluoromethane	ND		ug/kg	10	0.92	1
Acetone	ND		ug/kg	10	4.8	1
Carbon disulfide	ND		ug/kg	10	4.6	1
2-Butanone	2.5	J	ug/kg	10	2.2	1
Vinyl acetate	ND		ug/kg	10	2.2	1
4-Methyl-2-pentanone	ND		ug/kg	10	1.3	1
1,2,3-Trichloropropane	ND		ug/kg	2.0	0.13	1
2-Hexanone	ND		ug/kg	10	1.2	1
Bromochloromethane	ND		ug/kg	2.0	0.20	1
2,2-Dichloropropane	ND		ug/kg	2.0	0.20	1
1,2-Dibromoethane	ND		ug/kg	1.0	0.28	1
1,3-Dichloropropane	ND		ug/kg	2.0	0.17	1
1,1,1,2-Tetrachloroethane	ND		ug/kg	0.50	0.13	1
Bromobenzene	ND		ug/kg	2.0	0.14	1
n-Butylbenzene	ND		ug/kg	1.0	0.17	1
sec-Butylbenzene	ND		ug/kg	1.0	0.15	1
tert-Butylbenzene	ND		ug/kg	2.0	0.12	1
o-Chlorotoluene	ND		ug/kg	2.0	0.19	1
p-Chlorotoluene	ND		ug/kg	2.0	0.11	1
1,2-Dibromo-3-chloropropane	ND		ug/kg	3.0	1.0	1
Hexachlorobutadiene	ND		ug/kg	4.0	0.17	1
Isopropylbenzene	ND		ug/kg	1.0	0.11	1
p-Isopropyltoluene	ND		ug/kg	1.0	0.11	1
Naphthalene	ND		ug/kg	4.0	0.65	1
Acrylonitrile	ND		ug/kg	4.0	1.2	1

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-02 Date Collected: 06/09/23 07:50

Client ID: SB-45P (4-4.5) Date Received: 06/09/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
n-Propylbenzene	ND		ug/kg	1.0	0.17	1
1,2,3-Trichlorobenzene	ND		ug/kg	2.0	0.32	1
1,2,4-Trichlorobenzene	ND		ug/kg	2.0	0.27	1
1,3,5-Trimethylbenzene	ND		ug/kg	2.0	0.19	1
1,2,4-Trimethylbenzene	ND		ug/kg	2.0	0.34	1
1,4-Dioxane	ND		ug/kg	80	35.	1
p-Diethylbenzene	ND		ug/kg	2.0	0.18	1
p-Ethyltoluene	ND		ug/kg	2.0	0.38	1
1,2,4,5-Tetramethylbenzene	ND		ug/kg	2.0	0.19	1
Ethyl ether	ND		ug/kg	2.0	0.34	1
trans-1,4-Dichloro-2-butene	ND		ug/kg	5.0	1.4	1
Tentatively Identified Compounds						
Total TIC Compounds	2.12	J	ug/kg			1
Unknown	2.12	J	ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	101		70-130
Toluene-d8	102		70-130
4-Bromofluorobenzene	98		70-130
Dibromofluoromethane	97		70-130

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-03
Client ID: SB-46P (4.5-5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/09/23 11:30
Date Received: 06/09/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8260D
Analytical Date: 06/13/23 16:56
Analyst: JIC
Percent Solids: 92%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Methylene chloride	ND		ug/kg	4.8	2.2	1
1,1-Dichloroethane	ND		ug/kg	0.96	0.14	1
Chloroform	ND		ug/kg	1.4	0.14	1
Carbon tetrachloride	ND		ug/kg	0.96	0.22	1
1,2-Dichloropropane	ND		ug/kg	0.96	0.12	1
Dibromochloromethane	ND		ug/kg	0.96	0.14	1
1,1,2-Trichloroethane	ND		ug/kg	0.96	0.26	1
Tetrachloroethene	ND		ug/kg	0.48	0.19	1
Chlorobenzene	ND		ug/kg	0.48	0.12	1
Trichlorofluoromethane	ND		ug/kg	3.9	0.67	1
1,2-Dichloroethane	ND		ug/kg	0.96	0.25	1
1,1,1-Trichloroethane	ND		ug/kg	0.48	0.16	1
Bromodichloromethane	ND		ug/kg	0.48	0.10	1
trans-1,3-Dichloropropene	ND		ug/kg	0.96	0.26	1
cis-1,3-Dichloropropene	ND		ug/kg	0.48	0.15	1
1,3-Dichloropropene, Total	ND		ug/kg	0.48	0.15	1
1,1-Dichloropropene	ND		ug/kg	0.48	0.15	1
Bromoform	ND		ug/kg	3.9	0.24	1
1,1,2,2-Tetrachloroethane	ND		ug/kg	0.48	0.16	1
Benzene	ND		ug/kg	0.48	0.16	1
Toluene	ND		ug/kg	0.96	0.52	1
Ethylbenzene	ND		ug/kg	0.96	0.14	1
Chloromethane	ND		ug/kg	3.9	0.90	1
Bromomethane	ND		ug/kg	1.9	0.56	1
Vinyl chloride	ND		ug/kg	0.96	0.32	1
Chloroethane	ND		ug/kg	1.9	0.44	1
1,1-Dichloroethene	ND		ug/kg	0.96	0.23	1
trans-1,2-Dichloroethene	ND		ug/kg	1.4	0.13	1

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-03 Date Collected: 06/09/23 11:30

Client ID: SB-46P (4.5-5) Date Received: 06/09/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Trichloroethene	ND		ug/kg	0.48	0.13	1
1,2-Dichlorobenzene	ND		ug/kg	1.9	0.14	1
1,3-Dichlorobenzene	ND		ug/kg	1.9	0.14	1
1,4-Dichlorobenzene	ND		ug/kg	1.9	0.16	1
Methyl tert butyl ether	ND		ug/kg	1.9	0.19	1
p/m-Xylene	ND		ug/kg	1.9	0.54	1
o-Xylene	ND		ug/kg	0.96	0.28	1
Xylenes, Total	ND		ug/kg	0.96	0.28	1
cis-1,2-Dichloroethene	ND		ug/kg	0.96	0.17	1
1,2-Dichloroethene, Total	ND		ug/kg	0.96	0.13	1
Dibromomethane	ND		ug/kg	1.9	0.23	1
Styrene	ND		ug/kg	0.96	0.19	1
Dichlorodifluoromethane	ND		ug/kg	9.6	0.88	1
Acetone	35		ug/kg	9.6	4.6	1
Carbon disulfide	ND		ug/kg	9.6	4.4	1
2-Butanone	4.6	J	ug/kg	9.6	2.1	1
Vinyl acetate	ND		ug/kg	9.6	2.1	1
4-Methyl-2-pentanone	ND		ug/kg	9.6	1.2	1
1,2,3-Trichloropropane	ND		ug/kg	1.9	0.12	1
2-Hexanone	ND		ug/kg	9.6	1.1	1
Bromochloromethane	ND		ug/kg	1.9	0.20	1
2,2-Dichloropropane	ND		ug/kg	1.9	0.19	1
1,2-Dibromoethane	ND		ug/kg	0.96	0.27	1
1,3-Dichloropropane	ND		ug/kg	1.9	0.16	1
1,1,1,2-Tetrachloroethane	ND		ug/kg	0.48	0.13	1
Bromobenzene	ND		ug/kg	1.9	0.14	1
n-Butylbenzene	ND		ug/kg	0.96	0.16	1
sec-Butylbenzene	ND		ug/kg	0.96	0.14	1
tert-Butylbenzene	ND		ug/kg	1.9	0.11	1
o-Chlorotoluene	ND		ug/kg	1.9	0.18	1
p-Chlorotoluene	ND		ug/kg	1.9	0.10	1
1,2-Dibromo-3-chloropropane	ND		ug/kg	2.9	0.96	1
Hexachlorobutadiene	ND		ug/kg	3.9	0.16	1
Isopropylbenzene	ND		ug/kg	0.96	0.10	1
p-Isopropyltoluene	ND		ug/kg	0.96	0.10	1
Naphthalene	ND		ug/kg	3.9	0.63	1
Acrylonitrile	ND		ug/kg	3.9	1.1	1

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-03 Date Collected: 06/09/23 11:30

Client ID: SB-46P (4.5-5) Date Received: 06/09/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
n-Propylbenzene	ND		ug/kg	0.96	0.16	1
1,2,3-Trichlorobenzene	ND		ug/kg	1.9	0.31	1
1,2,4-Trichlorobenzene	ND		ug/kg	1.9	0.26	1
1,3,5-Trimethylbenzene	ND		ug/kg	1.9	0.19	1
1,2,4-Trimethylbenzene	ND		ug/kg	1.9	0.32	1
1,4-Dioxane	ND		ug/kg	77	34.	1
p-Diethylbenzene	ND		ug/kg	1.9	0.17	1
p-Ethyltoluene	ND		ug/kg	1.9	0.37	1
1,2,4,5-Tetramethylbenzene	ND		ug/kg	1.9	0.18	1
Ethyl ether	ND		ug/kg	1.9	0.33	1
trans-1,4-Dichloro-2-butene	ND		ug/kg	4.8	1.4	1
Tentatively Identified Compounds						
Total TIC Compounds	2.19	J	ug/kg			1
Unknown	2.19	J	ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	103		70-130
Toluene-d8	101		70-130
4-Bromofluorobenzene	102		70-130
Dibromofluoromethane	97		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-04
Client ID: SB-47P (3-3.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/09/23 12:40
Date Received: 06/09/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8260D
Analytical Date: 06/13/23 17:22
Analyst: JIC
Percent Solids: 86%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Methylene chloride	ND		ug/kg	4.8	2.2	1
1,1-Dichloroethane	ND		ug/kg	0.95	0.14	1
Chloroform	ND		ug/kg	1.4	0.13	1
Carbon tetrachloride	ND		ug/kg	0.95	0.22	1
1,2-Dichloropropane	ND		ug/kg	0.95	0.12	1
Dibromochloromethane	ND		ug/kg	0.95	0.13	1
1,1,2-Trichloroethane	ND		ug/kg	0.95	0.25	1
Tetrachloroethene	ND		ug/kg	0.48	0.19	1
Chlorobenzene	ND		ug/kg	0.48	0.12	1
Trichlorofluoromethane	ND		ug/kg	3.8	0.66	1
1,2-Dichloroethane	ND		ug/kg	0.95	0.24	1
1,1,1-Trichloroethane	ND		ug/kg	0.48	0.16	1
Bromodichloromethane	ND		ug/kg	0.48	0.10	1
trans-1,3-Dichloropropene	ND		ug/kg	0.95	0.26	1
cis-1,3-Dichloropropene	ND		ug/kg	0.48	0.15	1
1,3-Dichloropropene, Total	ND		ug/kg	0.48	0.15	1
1,1-Dichloropropene	ND		ug/kg	0.48	0.15	1
Bromoform	ND		ug/kg	3.8	0.23	1
1,1,2,2-Tetrachloroethane	ND		ug/kg	0.48	0.16	1
Benzene	ND		ug/kg	0.48	0.16	1
Toluene	ND		ug/kg	0.95	0.52	1
Ethylbenzene	ND		ug/kg	0.95	0.13	1
Chloromethane	ND		ug/kg	3.8	0.89	1
Bromomethane	ND		ug/kg	1.9	0.55	1
Vinyl chloride	ND		ug/kg	0.95	0.32	1
Chloroethane	ND		ug/kg	1.9	0.43	1
1,1-Dichloroethene	ND		ug/kg	0.95	0.23	1
trans-1,2-Dichloroethene	ND		ug/kg	1.4	0.13	1

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-04 Date Collected: 06/09/23 12:40

Client ID: SB-47P (3-3.5) Date Received: 06/09/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Trichloroethene	ND		ug/kg	0.48	0.13	1
1,2-Dichlorobenzene	ND		ug/kg	1.9	0.14	1
1,3-Dichlorobenzene	ND		ug/kg	1.9	0.14	1
1,4-Dichlorobenzene	ND		ug/kg	1.9	0.16	1
Methyl tert butyl ether	ND		ug/kg	1.9	0.19	1
p/m-Xylene	ND		ug/kg	1.9	0.53	1
o-Xylene	ND		ug/kg	0.95	0.28	1
Xylenes, Total	ND		ug/kg	0.95	0.28	1
cis-1,2-Dichloroethene	ND		ug/kg	0.95	0.17	1
1,2-Dichloroethene, Total	ND		ug/kg	0.95	0.13	1
Dibromomethane	ND		ug/kg	1.9	0.23	1
Styrene	ND		ug/kg	0.95	0.19	1
Dichlorodifluoromethane	ND		ug/kg	9.5	0.87	1
Acetone	36		ug/kg	9.5	4.6	1
Carbon disulfide	ND		ug/kg	9.5	4.3	1
2-Butanone	6.9	J	ug/kg	9.5	2.1	1
Vinyl acetate	ND		ug/kg	9.5	2.0	1
4-Methyl-2-pentanone	ND		ug/kg	9.5	1.2	1
1,2,3-Trichloropropane	ND		ug/kg	1.9	0.12	1
2-Hexanone	ND		ug/kg	9.5	1.1	1
Bromochloromethane	ND		ug/kg	1.9	0.20	1
2,2-Dichloropropane	ND		ug/kg	1.9	0.19	1
1,2-Dibromoethane	ND		ug/kg	0.95	0.26	1
1,3-Dichloropropane	ND		ug/kg	1.9	0.16	1
1,1,1,2-Tetrachloroethane	ND		ug/kg	0.48	0.12	1
Bromobenzene	ND		ug/kg	1.9	0.14	1
n-Butylbenzene	ND		ug/kg	0.95	0.16	1
sec-Butylbenzene	ND		ug/kg	0.95	0.14	1
tert-Butylbenzene	ND		ug/kg	1.9	0.11	1
o-Chlorotoluene	ND		ug/kg	1.9	0.18	1
p-Chlorotoluene	ND		ug/kg	1.9	0.10	1
1,2-Dibromo-3-chloropropane	ND		ug/kg	2.8	0.95	1
Hexachlorobutadiene	ND		ug/kg	3.8	0.16	1
Isopropylbenzene	ND		ug/kg	0.95	0.10	1
p-Isopropyltoluene	ND		ug/kg	0.95	0.10	1
Naphthalene	ND		ug/kg	3.8	0.62	1
Acrylonitrile	ND		ug/kg	3.8	1.1	1

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-04 Date Collected: 06/09/23 12:40

Client ID: SB-47P (3-3.5) Date Received: 06/09/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
n-Propylbenzene	ND		ug/kg	0.95	0.16	1
1,2,3-Trichlorobenzene	ND		ug/kg	1.9	0.31	1
1,2,4-Trichlorobenzene	ND		ug/kg	1.9	0.26	1
1,3,5-Trimethylbenzene	ND		ug/kg	1.9	0.18	1
1,2,4-Trimethylbenzene	ND		ug/kg	1.9	0.32	1
1,4-Dioxane	ND		ug/kg	76	33.	1
p-Diethylbenzene	ND		ug/kg	1.9	0.17	1
p-Ethyltoluene	ND		ug/kg	1.9	0.36	1
1,2,4,5-Tetramethylbenzene	ND		ug/kg	1.9	0.18	1
Ethyl ether	ND		ug/kg	1.9	0.32	1
trans-1,4-Dichloro-2-butene	ND		ug/kg	4.8	1.4	1
Tentatively Identified Compounds						
Total TIC Compounds	1.98	J	ug/kg			1
Unknown	1.98	J	ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	101		70-130
Toluene-d8	102		70-130
4-Bromofluorobenzene	100		70-130
Dibromofluoromethane	97		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-05
Client ID: SB-48P (3.5-4)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/09/23 12:55
Date Received: 06/09/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8260D
Analytical Date: 06/13/23 17:48
Analyst: JIC
Percent Solids: 84%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Methylene chloride	ND		ug/kg	8.6	4.0	1
1,1-Dichloroethane	ND		ug/kg	1.7	0.25	1
Chloroform	ND		ug/kg	2.6	0.24	1
Carbon tetrachloride	ND		ug/kg	1.7	0.40	1
1,2-Dichloropropane	ND		ug/kg	1.7	0.22	1
Dibromochloromethane	ND		ug/kg	1.7	0.24	1
1,1,2-Trichloroethane	ND		ug/kg	1.7	0.46	1
Tetrachloroethene	ND		ug/kg	0.86	0.34	1
Chlorobenzene	ND		ug/kg	0.86	0.22	1
Trichlorofluoromethane	ND		ug/kg	6.9	1.2	1
1,2-Dichloroethane	ND		ug/kg	1.7	0.44	1
1,1,1-Trichloroethane	ND		ug/kg	0.86	0.29	1
Bromodichloromethane	ND		ug/kg	0.86	0.19	1
trans-1,3-Dichloropropene	ND		ug/kg	1.7	0.47	1
cis-1,3-Dichloropropene	ND		ug/kg	0.86	0.27	1
1,3-Dichloropropene, Total	ND		ug/kg	0.86	0.27	1
1,1-Dichloropropene	ND		ug/kg	0.86	0.27	1
Bromoform	ND		ug/kg	6.9	0.42	1
1,1,2,2-Tetrachloroethane	ND		ug/kg	0.86	0.29	1
Benzene	ND		ug/kg	0.86	0.29	1
Toluene	ND		ug/kg	1.7	0.94	1
Ethylbenzene	ND		ug/kg	1.7	0.24	1
Chloromethane	ND		ug/kg	6.9	1.6	1
Bromomethane	ND		ug/kg	3.4	1.0	1
Vinyl chloride	ND		ug/kg	1.7	0.58	1
Chloroethane	ND		ug/kg	3.4	0.78	1
1,1-Dichloroethene	ND		ug/kg	1.7	0.41	1
trans-1,2-Dichloroethene	ND		ug/kg	2.6	0.24	1

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-05 Date Collected: 06/09/23 12:55

Client ID: SB-48P (3.5-4) Date Received: 06/09/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Trichloroethene	ND		ug/kg	0.86	0.24	1
1,2-Dichlorobenzene	ND		ug/kg	3.4	0.25	1
1,3-Dichlorobenzene	ND		ug/kg	3.4	0.26	1
1,4-Dichlorobenzene	ND		ug/kg	3.4	0.30	1
Methyl tert butyl ether	ND		ug/kg	3.4	0.35	1
p/m-Xylene	ND		ug/kg	3.4	0.97	1
o-Xylene	ND		ug/kg	1.7	0.50	1
Xylenes, Total	ND		ug/kg	1.7	0.50	1
cis-1,2-Dichloroethene	ND		ug/kg	1.7	0.30	1
1,2-Dichloroethene, Total	ND		ug/kg	1.7	0.24	1
Dibromomethane	ND		ug/kg	3.4	0.41	1
Styrene	ND		ug/kg	1.7	0.34	1
Dichlorodifluoromethane	ND		ug/kg	17	1.6	1
Acetone	53		ug/kg	17	8.3	1
Carbon disulfide	ND		ug/kg	17	7.8	1
2-Butanone	7.0	J	ug/kg	17	3.8	1
Vinyl acetate	ND		ug/kg	17	3.7	1
4-Methyl-2-pentanone	ND		ug/kg	17	2.2	1
1,2,3-Trichloropropane	ND		ug/kg	3.4	0.22	1
2-Hexanone	ND		ug/kg	17	2.0	1
Bromochloromethane	ND		ug/kg	3.4	0.35	1
2,2-Dichloropropane	ND		ug/kg	3.4	0.35	1
1,2-Dibromoethane	ND		ug/kg	1.7	0.48	1
1,3-Dichloropropane	ND		ug/kg	3.4	0.29	1
1,1,1,2-Tetrachloroethane	ND		ug/kg	0.86	0.23	1
Bromobenzene	ND		ug/kg	3.4	0.25	1
n-Butylbenzene	ND		ug/kg	1.7	0.29	1
sec-Butylbenzene	ND		ug/kg	1.7	0.25	1
tert-Butylbenzene	ND		ug/kg	3.4	0.20	1
o-Chlorotoluene	ND		ug/kg	3.4	0.33	1
p-Chlorotoluene	ND		ug/kg	3.4	0.19	1
1,2-Dibromo-3-chloropropane	ND		ug/kg	5.2	1.7	1
Hexachlorobutadiene	ND		ug/kg	6.9	0.29	1
Isopropylbenzene	ND		ug/kg	1.7	0.19	1
p-Isopropyltoluene	ND		ug/kg	1.7	0.19	1
Naphthalene	ND		ug/kg	6.9	1.1	1
Acrylonitrile	ND		ug/kg	6.9	2.0	1

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-05 Date Collected: 06/09/23 12:55

Client ID: SB-48P (3.5-4) Date Received: 06/09/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
n-Propylbenzene	ND		ug/kg	1.7	0.30	1
1,2,3-Trichlorobenzene	ND		ug/kg	3.4	0.56	1
1,2,4-Trichlorobenzene	ND		ug/kg	3.4	0.47	1
1,3,5-Trimethylbenzene	ND		ug/kg	3.4	0.33	1
1,2,4-Trimethylbenzene	ND		ug/kg	3.4	0.58	1
1,4-Dioxane	ND		ug/kg	140	61.	1
p-Diethylbenzene	ND		ug/kg	3.4	0.30	1
p-Ethyltoluene	ND		ug/kg	3.4	0.66	1
1,2,4,5-Tetramethylbenzene	ND		ug/kg	3.4	0.33	1
Ethyl ether	ND		ug/kg	3.4	0.59	1
trans-1,4-Dichloro-2-butene	ND		ug/kg	8.6	2.4	1
Tentatively Identified Compounds						
Total TIC Compounds	4.08	J	ug/kg			1
Unknown	4.08	J	ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	101		70-130
Toluene-d8	103		70-130
4-Bromofluorobenzene	99		70-130
Dibromofluoromethane	98		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-06
Client ID: GW-16
Sample Location: WHITE PLAINS, NY

Date Collected: 06/09/23 13:10
Date Received: 06/09/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8260D
Analytical Date: 06/13/23 11:22
Analyst: PID

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Methylene chloride	ND		ug/l	2.5	0.70	1
1,1-Dichloroethane	ND		ug/l	2.5	0.70	1
Chloroform	ND		ug/l	2.5	0.70	1
Carbon tetrachloride	ND		ug/l	0.50	0.13	1
1,2-Dichloropropane	ND		ug/l	1.0	0.14	1
Dibromochloromethane	ND		ug/l	0.50	0.15	1
1,1,2-Trichloroethane	ND		ug/l	1.5	0.50	1
Tetrachloroethene	ND		ug/l	0.50	0.18	1
Chlorobenzene	ND		ug/l	2.5	0.70	1
Trichlorofluoromethane	ND		ug/l	2.5	0.70	1
1,2-Dichloroethane	ND		ug/l	0.50	0.13	1
1,1,1-Trichloroethane	ND		ug/l	2.5	0.70	1
Bromodichloromethane	ND		ug/l	0.50	0.19	1
trans-1,3-Dichloropropene	ND		ug/l	0.50	0.16	1
cis-1,3-Dichloropropene	ND		ug/l	0.50	0.14	1
1,3-Dichloropropene, Total	ND		ug/l	0.50	0.14	1
1,1-Dichloropropene	ND		ug/l	2.5	0.70	1
Bromoform	ND		ug/l	2.0	0.65	1
1,1,2,2-Tetrachloroethane	ND		ug/l	0.50	0.17	1
Benzene	ND		ug/l	0.50	0.16	1
Toluene	ND		ug/l	2.5	0.70	1
Ethylbenzene	ND		ug/l	2.5	0.70	1
Chloromethane	ND		ug/l	2.5	0.70	1
Bromomethane	ND		ug/l	2.5	0.70	1
Vinyl chloride	ND		ug/l	1.0	0.07	1
Chloroethane	ND		ug/l	2.5	0.70	1
1,1-Dichloroethene	ND		ug/l	0.50	0.17	1
trans-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-06 Date Collected: 06/09/23 13:10

Client ID: GW-16 Date Received: 06/09/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Trichloroethene	ND		ug/l	0.50	0.18	1
1,2-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,3-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,4-Dichlorobenzene	ND		ug/l	2.5	0.70	1
Methyl tert butyl ether	1.2	J	ug/l	2.5	0.70	1
p/m-Xylene	ND		ug/l	2.5	0.70	1
o-Xylene	ND		ug/l	2.5	0.70	1
Xylenes, Total	ND		ug/l	2.5	0.70	1
cis-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1
1,2-Dichloroethene, Total	ND		ug/l	2.5	0.70	1
Dibromomethane	ND		ug/l	5.0	1.0	1
1,2,3-Trichloropropane	ND		ug/l	2.5	0.70	1
Acrylonitrile	ND		ug/l	5.0	1.5	1
Styrene	ND		ug/l	2.5	0.70	1
Dichlorodifluoromethane	ND		ug/l	5.0	1.0	1
Acetone	2.3	J	ug/l	5.0	1.5	1
Carbon disulfide	ND		ug/l	5.0	1.0	1
2-Butanone	ND		ug/l	5.0	1.9	1
Vinyl acetate	ND		ug/l	5.0	1.0	1
4-Methyl-2-pentanone	ND		ug/l	5.0	1.0	1
2-Hexanone	ND		ug/l	5.0	1.0	1
Bromochloromethane	ND		ug/l	2.5	0.70	1
2,2-Dichloropropane	ND		ug/l	2.5	0.70	1
1,2-Dibromoethane	ND		ug/l	2.0	0.65	1
1,3-Dichloropropane	ND		ug/l	2.5	0.70	1
1,1,1,2-Tetrachloroethane	ND		ug/l	2.5	0.70	1
Bromobenzene	ND		ug/l	2.5	0.70	1
n-Butylbenzene	ND		ug/l	2.5	0.70	1
sec-Butylbenzene	ND		ug/l	2.5	0.70	1
tert-Butylbenzene	ND		ug/l	2.5	0.70	1
o-Chlorotoluene	ND		ug/l	2.5	0.70	1
p-Chlorotoluene	ND		ug/l	2.5	0.70	1
1,2-Dibromo-3-chloropropane	ND		ug/l	2.5	0.70	1
Hexachlorobutadiene	ND		ug/l	2.5	0.70	1
Isopropylbenzene	ND		ug/l	2.5	0.70	1
p-Isopropyltoluene	ND		ug/l	2.5	0.70	1
Naphthalene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-06 Date Collected: 06/09/23 13:10

Client ID: GW-16 Date Received: 06/09/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
n-Propylbenzene	ND		ug/l	2.5	0.70	1
1,2,3-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,3,5-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,4-Dioxane	ND		ug/l	250	61.	1
p-Diethylbenzene	ND		ug/l	2.0	0.70	1
p-Ethyltoluene	ND		ug/l	2.0	0.70	1
1,2,4,5-Tetramethylbenzene	ND		ug/l	2.0	0.54	1
Ethyl ether	ND		ug/l	2.5	0.70	1
trans-1,4-Dichloro-2-butene	ND		ug/l	2.5	0.70	1
Tentatively Identified Compounds						
No Tentatively Identified Compounds	ND		ug/l			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	97		70-130
Toluene-d8	98		70-130
4-Bromofluorobenzene	98		70-130
Dibromofluoromethane	108		70-130

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-07
Client ID: GW-17
Sample Location: WHITE PLAINS, NY

Date Collected: 06/09/23 12:10
Date Received: 06/09/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8260D
Analytical Date: 06/13/23 11:46
Analyst: PID

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Methylene chloride	ND		ug/l	2.5	0.70	1
1,1-Dichloroethane	ND		ug/l	2.5	0.70	1
Chloroform	ND		ug/l	2.5	0.70	1
Carbon tetrachloride	ND		ug/l	0.50	0.13	1
1,2-Dichloropropane	ND		ug/l	1.0	0.14	1
Dibromochloromethane	ND		ug/l	0.50	0.15	1
1,1,2-Trichloroethane	ND		ug/l	1.5	0.50	1
Tetrachloroethene	ND		ug/l	0.50	0.18	1
Chlorobenzene	ND		ug/l	2.5	0.70	1
Trichlorofluoromethane	ND		ug/l	2.5	0.70	1
1,2-Dichloroethane	ND		ug/l	0.50	0.13	1
1,1,1-Trichloroethane	ND		ug/l	2.5	0.70	1
Bromodichloromethane	ND		ug/l	0.50	0.19	1
trans-1,3-Dichloropropene	ND		ug/l	0.50	0.16	1
cis-1,3-Dichloropropene	ND		ug/l	0.50	0.14	1
1,3-Dichloropropene, Total	ND		ug/l	0.50	0.14	1
1,1-Dichloropropene	ND		ug/l	2.5	0.70	1
Bromoform	ND		ug/l	2.0	0.65	1
1,1,2,2-Tetrachloroethane	ND		ug/l	0.50	0.17	1
Benzene	ND		ug/l	0.50	0.16	1
Toluene	ND		ug/l	2.5	0.70	1
Ethylbenzene	ND		ug/l	2.5	0.70	1
Chloromethane	ND		ug/l	2.5	0.70	1
Bromomethane	ND		ug/l	2.5	0.70	1
Vinyl chloride	ND		ug/l	1.0	0.07	1
Chloroethane	ND		ug/l	2.5	0.70	1
1,1-Dichloroethene	ND		ug/l	0.50	0.17	1
trans-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-07 Date Collected: 06/09/23 12:10

Client ID: GW-17 Date Received: 06/09/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Trichloroethene	ND		ug/l	0.50	0.18	1
1,2-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,3-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,4-Dichlorobenzene	ND		ug/l	2.5	0.70	1
Methyl tert butyl ether	ND		ug/l	2.5	0.70	1
p/m-Xylene	ND		ug/l	2.5	0.70	1
o-Xylene	ND		ug/l	2.5	0.70	1
Xylenes, Total	ND		ug/l	2.5	0.70	1
cis-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1
1,2-Dichloroethene, Total	ND		ug/l	2.5	0.70	1
Dibromomethane	ND		ug/l	5.0	1.0	1
1,2,3-Trichloropropane	ND		ug/l	2.5	0.70	1
Acrylonitrile	ND		ug/l	5.0	1.5	1
Styrene	ND		ug/l	2.5	0.70	1
Dichlorodifluoromethane	ND		ug/l	5.0	1.0	1
Acetone	1.8	J	ug/l	5.0	1.5	1
Carbon disulfide	ND		ug/l	5.0	1.0	1
2-Butanone	ND		ug/l	5.0	1.9	1
Vinyl acetate	ND		ug/l	5.0	1.0	1
4-Methyl-2-pentanone	ND		ug/l	5.0	1.0	1
2-Hexanone	ND		ug/l	5.0	1.0	1
Bromochloromethane	ND		ug/l	2.5	0.70	1
2,2-Dichloropropane	ND		ug/l	2.5	0.70	1
1,2-Dibromoethane	ND		ug/l	2.0	0.65	1
1,3-Dichloropropane	ND		ug/l	2.5	0.70	1
1,1,1,2-Tetrachloroethane	ND		ug/l	2.5	0.70	1
Bromobenzene	ND		ug/l	2.5	0.70	1
n-Butylbenzene	ND		ug/l	2.5	0.70	1
sec-Butylbenzene	ND		ug/l	2.5	0.70	1
tert-Butylbenzene	ND		ug/l	2.5	0.70	1
o-Chlorotoluene	ND		ug/l	2.5	0.70	1
p-Chlorotoluene	ND		ug/l	2.5	0.70	1
1,2-Dibromo-3-chloropropane	ND		ug/l	2.5	0.70	1
Hexachlorobutadiene	ND		ug/l	2.5	0.70	1
Isopropylbenzene	ND		ug/l	2.5	0.70	1
p-Isopropyltoluene	ND		ug/l	2.5	0.70	1
Naphthalene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-07 Date Collected: 06/09/23 12:10

Client ID: GW-17 Date Received: 06/09/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
n-Propylbenzene	ND		ug/l	2.5	0.70	1
1,2,3-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,3,5-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,4-Dioxane	ND		ug/l	250	61.	1
p-Diethylbenzene	ND		ug/l	2.0	0.70	1
p-Ethyltoluene	ND		ug/l	2.0	0.70	1
1,2,4,5-Tetramethylbenzene	ND		ug/l	2.0	0.54	1
Ethyl ether	ND		ug/l	2.5	0.70	1
trans-1,4-Dichloro-2-butene	ND		ug/l	2.5	0.70	1
Tentatively Identified Compounds						
No Tentatively Identified Compounds	ND		ug/l			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	100		70-130
Toluene-d8	99		70-130
4-Bromofluorobenzene	98		70-130
Dibromofluoromethane	108		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 06/13/23 08:17
Analyst: PID

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by GC/MS - Westborough Lab for sample(s): 06-07 Batch: WG1791001-5					
Methylene chloride	ND		ug/l	2.5	0.70
1,1-Dichloroethane	ND		ug/l	2.5	0.70
Chloroform	ND		ug/l	2.5	0.70
Carbon tetrachloride	ND		ug/l	0.50	0.13
1,2-Dichloropropane	ND		ug/l	1.0	0.14
Dibromochloromethane	ND		ug/l	0.50	0.15
1,1,2-Trichloroethane	ND		ug/l	1.5	0.50
Tetrachloroethene	ND		ug/l	0.50	0.18
Chlorobenzene	ND		ug/l	2.5	0.70
Trichlorofluoromethane	ND		ug/l	2.5	0.70
1,2-Dichloroethane	ND		ug/l	0.50	0.13
1,1,1-Trichloroethane	ND		ug/l	2.5	0.70
Bromodichloromethane	ND		ug/l	0.50	0.19
trans-1,3-Dichloropropene	ND		ug/l	0.50	0.16
cis-1,3-Dichloropropene	ND		ug/l	0.50	0.14
1,3-Dichloropropene, Total	ND		ug/l	0.50	0.14
1,1-Dichloropropene	ND		ug/l	2.5	0.70
Bromoform	ND		ug/l	2.0	0.65
1,1,2,2-Tetrachloroethane	ND		ug/l	0.50	0.17
Benzene	ND		ug/l	0.50	0.16
Toluene	ND		ug/l	2.5	0.70
Ethylbenzene	ND		ug/l	2.5	0.70
Chloromethane	ND		ug/l	2.5	0.70
Bromomethane	ND		ug/l	2.5	0.70
Vinyl chloride	ND		ug/l	1.0	0.07
Chloroethane	ND		ug/l	2.5	0.70
1,1-Dichloroethene	ND		ug/l	0.50	0.17
trans-1,2-Dichloroethene	ND		ug/l	2.5	0.70
Trichloroethene	ND		ug/l	0.50	0.18

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 06/13/23 08:17
Analyst: PID

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by GC/MS - Westborough Lab for sample(s): 06-07 Batch: WG1791001-5					
1,2-Dichlorobenzene	ND		ug/l	2.5	0.70
1,3-Dichlorobenzene	ND		ug/l	2.5	0.70
1,4-Dichlorobenzene	ND		ug/l	2.5	0.70
Methyl tert butyl ether	ND		ug/l	2.5	0.70
p/m-Xylene	ND		ug/l	2.5	0.70
o-Xylene	ND		ug/l	2.5	0.70
Xylenes, Total	ND		ug/l	2.5	0.70
cis-1,2-Dichloroethene	ND		ug/l	2.5	0.70
1,2-Dichloroethene, Total	ND		ug/l	2.5	0.70
Dibromomethane	ND		ug/l	5.0	1.0
1,2,3-Trichloropropane	ND		ug/l	2.5	0.70
Acrylonitrile	ND		ug/l	5.0	1.5
Styrene	ND		ug/l	2.5	0.70
Dichlorodifluoromethane	ND		ug/l	5.0	1.0
Acetone	ND		ug/l	5.0	1.5
Carbon disulfide	ND		ug/l	5.0	1.0
2-Butanone	ND		ug/l	5.0	1.9
Vinyl acetate	ND		ug/l	5.0	1.0
4-Methyl-2-pentanone	ND		ug/l	5.0	1.0
2-Hexanone	ND		ug/l	5.0	1.0
Bromochloromethane	ND		ug/l	2.5	0.70
2,2-Dichloropropane	ND		ug/l	2.5	0.70
1,2-Dibromoethane	ND		ug/l	2.0	0.65
1,3-Dichloropropane	ND		ug/l	2.5	0.70
1,1,1,2-Tetrachloroethane	ND		ug/l	2.5	0.70
Bromobenzene	ND		ug/l	2.5	0.70
n-Butylbenzene	ND		ug/l	2.5	0.70
sec-Butylbenzene	ND		ug/l	2.5	0.70
tert-Butylbenzene	ND		ug/l	2.5	0.70

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 06/13/23 08:17
Analyst: PID

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by GC/MS - Westborough Lab for sample(s): 06-07 Batch: WG1791001-5					
o-Chlorotoluene	ND		ug/l	2.5	0.70
p-Chlorotoluene	ND		ug/l	2.5	0.70
1,2-Dibromo-3-chloropropane	ND		ug/l	2.5	0.70
Hexachlorobutadiene	ND		ug/l	2.5	0.70
Isopropylbenzene	ND		ug/l	2.5	0.70
p-Isopropyltoluene	ND		ug/l	2.5	0.70
Naphthalene	ND		ug/l	2.5	0.70
n-Propylbenzene	ND		ug/l	2.5	0.70
1,2,3-Trichlorobenzene	ND		ug/l	2.5	0.70
1,2,4-Trichlorobenzene	ND		ug/l	2.5	0.70
1,3,5-Trimethylbenzene	ND		ug/l	2.5	0.70
1,2,4-Trimethylbenzene	ND		ug/l	2.5	0.70
1,4-Dioxane	ND		ug/l	250	61.
p-Diethylbenzene	ND		ug/l	2.0	0.70
p-Ethyltoluene	ND		ug/l	2.0	0.70
1,2,4,5-Tetramethylbenzene	ND		ug/l	2.0	0.54
Ethyl ether	ND		ug/l	2.5	0.70
trans-1,4-Dichloro-2-butene	ND		ug/l	2.5	0.70
Tentatively Identified Compounds					
No Tentatively Identified Compounds	ND		ug/l		

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 06/13/23 08:17
Analyst: PID

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by GC/MS - Westborough Lab for sample(s): 06-07 Batch: WG1791001-5					

Surrogate	%Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	91		70-130
Toluene-d8	95		70-130
4-Bromofluorobenzene	95		70-130
Dibromofluoromethane	103		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 06/13/23 09:07
Analyst: AJK

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by EPA 5035 Low - Westborough Lab for sample(s): 01-05 Batch: WG1791311-5					
Methylene chloride	ND		ug/kg	5.0	2.3
1,1-Dichloroethane	ND		ug/kg	1.0	0.14
Chloroform	ND		ug/kg	1.5	0.14
Carbon tetrachloride	ND		ug/kg	1.0	0.23
1,2-Dichloropropane	ND		ug/kg	1.0	0.12
Dibromochloromethane	ND		ug/kg	1.0	0.14
1,1,2-Trichloroethane	ND		ug/kg	1.0	0.27
Tetrachloroethene	ND		ug/kg	0.50	0.20
Chlorobenzene	ND		ug/kg	0.50	0.13
Trichlorofluoromethane	ND		ug/kg	4.0	0.70
1,2-Dichloroethane	ND		ug/kg	1.0	0.26
1,1,1-Trichloroethane	ND		ug/kg	0.50	0.17
Bromodichloromethane	ND		ug/kg	0.50	0.11
trans-1,3-Dichloropropene	ND		ug/kg	1.0	0.27
cis-1,3-Dichloropropene	ND		ug/kg	0.50	0.16
1,3-Dichloropropene, Total	ND		ug/kg	0.50	0.16
1,1-Dichloropropene	ND		ug/kg	0.50	0.16
Bromoform	ND		ug/kg	4.0	0.25
1,1,2,2-Tetrachloroethane	ND		ug/kg	0.50	0.17
Benzene	ND		ug/kg	0.50	0.17
Toluene	ND		ug/kg	1.0	0.54
Ethylbenzene	ND		ug/kg	1.0	0.14
Chloromethane	ND		ug/kg	4.0	0.93
Bromomethane	ND		ug/kg	2.0	0.58
Vinyl chloride	ND		ug/kg	1.0	0.34
Chloroethane	ND		ug/kg	2.0	0.45
1,1-Dichloroethene	ND		ug/kg	1.0	0.24
trans-1,2-Dichloroethene	ND		ug/kg	1.5	0.14
Trichloroethene	ND		ug/kg	0.50	0.14

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 06/13/23 09:07
Analyst: AJK

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by EPA 5035 Low - Westborough Lab for sample(s): 01-05 Batch: WG1791311-5					
1,2-Dichlorobenzene	ND		ug/kg	2.0	0.14
1,3-Dichlorobenzene	ND		ug/kg	2.0	0.15
1,4-Dichlorobenzene	ND		ug/kg	2.0	0.17
Methyl tert butyl ether	ND		ug/kg	2.0	0.20
p/m-Xylene	ND		ug/kg	2.0	0.56
o-Xylene	ND		ug/kg	1.0	0.29
Xylenes, Total	ND		ug/kg	1.0	0.29
cis-1,2-Dichloroethene	ND		ug/kg	1.0	0.18
1,2-Dichloroethene, Total	ND		ug/kg	1.0	0.14
Dibromomethane	ND		ug/kg	2.0	0.24
Styrene	ND		ug/kg	1.0	0.20
Dichlorodifluoromethane	ND		ug/kg	10	0.92
Acetone	ND		ug/kg	10	4.8
Carbon disulfide	ND		ug/kg	10	4.6
2-Butanone	ND		ug/kg	10	2.2
Vinyl acetate	ND		ug/kg	10	2.2
4-Methyl-2-pentanone	ND		ug/kg	10	1.3
1,2,3-Trichloropropane	ND		ug/kg	2.0	0.13
2-Hexanone	ND		ug/kg	10	1.2
Bromochloromethane	ND		ug/kg	2.0	0.20
2,2-Dichloropropane	ND		ug/kg	2.0	0.20
1,2-Dibromoethane	ND		ug/kg	1.0	0.28
1,3-Dichloropropane	ND		ug/kg	2.0	0.17
1,1,1,2-Tetrachloroethane	ND		ug/kg	0.50	0.13
Bromobenzene	ND		ug/kg	2.0	0.14
n-Butylbenzene	ND		ug/kg	1.0	0.17
sec-Butylbenzene	ND		ug/kg	1.0	0.15
tert-Butylbenzene	ND		ug/kg	2.0	0.12
o-Chlorotoluene	ND		ug/kg	2.0	0.19

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 06/13/23 09:07
Analyst: AJK

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by EPA 5035 Low - Westborough Lab for sample(s): 01-05 Batch: WG1791311-5					
p-Chlorotoluene	ND		ug/kg	2.0	0.11
1,2-Dibromo-3-chloropropane	ND		ug/kg	3.0	1.0
Hexachlorobutadiene	ND		ug/kg	4.0	0.17
Isopropylbenzene	ND		ug/kg	1.0	0.11
p-Isopropyltoluene	ND		ug/kg	1.0	0.11
Naphthalene	ND		ug/kg	4.0	0.65
Acrylonitrile	ND		ug/kg	4.0	1.2
n-Propylbenzene	ND		ug/kg	1.0	0.17
1,2,3-Trichlorobenzene	ND		ug/kg	2.0	0.32
1,2,4-Trichlorobenzene	ND		ug/kg	2.0	0.27
1,3,5-Trimethylbenzene	ND		ug/kg	2.0	0.19
1,2,4-Trimethylbenzene	ND		ug/kg	2.0	0.33
1,4-Dioxane	ND		ug/kg	80	35.
p-Diethylbenzene	ND		ug/kg	2.0	0.18
p-Ethyltoluene	ND		ug/kg	2.0	0.38
1,2,4,5-Tetramethylbenzene	ND		ug/kg	2.0	0.19
Ethyl ether	ND		ug/kg	2.0	0.34
trans-1,4-Dichloro-2-butene	ND		ug/kg	5.0	1.4

Tentatively Identified Compounds			
Total TIC Compounds	4.07	J	ug/kg
Unknown	4.07	J	ug/kg

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 06/13/23 09:07
Analyst: AJK

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by EPA 5035 Low - Westborough Lab for sample(s): 01-05 Batch: WG1791311-5					

Surrogate	%Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	100		70-130
Toluene-d8	100		70-130
4-Bromofluorobenzene	97		70-130
Dibromofluoromethane	96		70-130

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2332665
Report Date: 06/19/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by GC/MS - Westborough Lab Associated sample(s): 06-07 Batch: WG1791001-3 WG1791001-4								
Methylene chloride	97		95		70-130	2		20
1,1-Dichloroethane	99		96		70-130	3		20
Chloroform	100		99		70-130	1		20
Carbon tetrachloride	100		100		63-132	0		20
1,2-Dichloropropane	94		91		70-130	3		20
Dibromochloromethane	88		85		63-130	3		20
1,1,2-Trichloroethane	88		85		70-130	3		20
Tetrachloroethene	110		100		70-130	10		20
Chlorobenzene	99		98		75-130	1		20
Trichlorofluoromethane	120		110		62-150	9		20
1,2-Dichloroethane	91		87		70-130	4		20
1,1,1-Trichloroethane	100		100		67-130	0		20
Bromodichloromethane	90		89		67-130	1		20
trans-1,3-Dichloropropene	86		83		70-130	4		20
cis-1,3-Dichloropropene	92		89		70-130	3		20
1,1-Dichloropropene	100		100		70-130	0		20
Bromoform	80		79		54-136	1		20
1,1,2,2-Tetrachloroethane	79		77		67-130	3		20
Benzene	97		95		70-130	2		20
Toluene	99		98		70-130	1		20
Ethylbenzene	100		99		70-130	1		20
Chloromethane	81		78		64-130	4		20
Bromomethane	91		90		39-139	1		20

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2332665
Report Date: 06/19/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by GC/MS - Westborough Lab Associated sample(s): 06-07 Batch: WG1791001-3 WG1791001-4								
Vinyl chloride	98		95		55-140	3		20
Chloroethane	110		110		55-138	0		20
1,1-Dichloroethene	110		110		61-145	0		20
trans-1,2-Dichloroethene	110		100		70-130	10		20
Trichloroethene	100		96		70-130	4		20
1,2-Dichlorobenzene	94		92		70-130	2		20
1,3-Dichlorobenzene	98		97		70-130	1		20
1,4-Dichlorobenzene	97		94		70-130	3		20
Methyl tert butyl ether	83		81		63-130	2		20
p/m-Xylene	105		100		70-130	5		20
o-Xylene	100		100		70-130	0		20
cis-1,2-Dichloroethene	100		99		70-130	1		20
Dibromomethane	90		88		70-130	2		20
1,2,3-Trichloropropane	77		76		64-130	1		20
Acrylonitrile	74		71		70-130	4		20
Styrene	100		100		70-130	0		20
Dichlorodifluoromethane	99		97		36-147	2		20
Acetone	**57**	Q	**54**	Q	58-148	5		20
Carbon disulfide	110		100		51-130	10		20
2-Butanone	67		**59**	Q	63-138	13		20
Vinyl acetate	93		91		70-130	2		20
4-Methyl-2-pentanone	63		63		59-130	0		20
2-Hexanone	66		62		57-130	6		20

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2332665
Report Date: 06/19/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by GC/MS - Westborough Lab Associated sample(s): 06-07 Batch: WG1791001-3 WG1791001-4								
Bromochloromethane	100		99		70-130	1		20
2,2-Dichloropropane	110		110		63-133	0		20
1,2-Dibromoethane	86		85		70-130	1		20
1,3-Dichloropropane	87		86		70-130	1		20
1,1,1,2-Tetrachloroethane	95		93		64-130	2		20
Bromobenzene	97		95		70-130	2		20
n-Butylbenzene	97		96		53-136	1		20
sec-Butylbenzene	100		99		70-130	1		20
tert-Butylbenzene	100		99		70-130	1		20
o-Chlorotoluene	97		96		70-130	1		20
p-Chlorotoluene	96		95		70-130	1		20
1,2-Dibromo-3-chloropropane	71		69		41-144	3		20
Hexachlorobutadiene	100		100		63-130	0		20
Isopropylbenzene	100		98		70-130	2		20
p-Isopropyltoluene	100		100		70-130	0		20
Naphthalene	73		71		70-130	3		20
n-Propylbenzene	100		98		69-130	2		20
1,2,3-Trichlorobenzene	83		82		70-130	1		20
1,2,4-Trichlorobenzene	87		86		70-130	1		20
1,3,5-Trimethylbenzene	98		97		64-130	1		20
1,2,4-Trimethylbenzene	96		95		70-130	1		20
1,4-Dioxane	74		74		56-162	0		20
p-Diethylbenzene	95		95		70-130	0		20

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2332665

Report Date: 06/19/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by GC/MS - Westborough Lab Associated sample(s): 06-07 Batch: WG1791001-3 WG1791001-4								
p-Ethyltoluene	100		99		70-130	1		20
1,2,4,5-Tetramethylbenzene	92		90		70-130	2		20
Ethyl ether	90		87		59-134	3		20
trans-1,4-Dichloro-2-butene	**49**	Q	**48**	Q	70-130	2		20

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
1,2-Dichloroethane-d4	98		94		70-130
Toluene-d8	98		98		70-130
4-Bromofluorobenzene	97		97		70-130
Dibromofluoromethane	102		101		70-130

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2332665

Report Date: 06/19/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by EPA 5035 Low - Westborough Lab Associated sample(s): 01-05 Batch: WG1791311-3 WG1791311-4								
Methylene chloride	74		74		70-130	0		30
1,1-Dichloroethane	82		82		70-130	0		30
Chloroform	80		80		70-130	0		30
Carbon tetrachloride	72		73		70-130	1		30
1,2-Dichloropropane	82		82		70-130	0		30
Dibromochloromethane	77		76		70-130	1		30
1,1,2-Trichloroethane	87		85		70-130	2		30
Tetrachloroethene	80		80		70-130	0		30
Chlorobenzene	84		83		70-130	1		30
Trichlorofluoromethane	77		78		70-139	1		30
1,2-Dichloroethane	80		80		70-130	0		30
1,1,1-Trichloroethane	74		75		70-130	1		30
Bromodichloromethane	82		82		70-130	0		30
trans-1,3-Dichloropropene	84		84		70-130	0		30
cis-1,3-Dichloropropene	84		83		70-130	1		30
1,1-Dichloropropene	76		76		70-130	0		30
Bromoform	84		84		70-130	0		30
1,1,2,2-Tetrachloroethane	84		82		70-130	2		30
Benzene	83		82		70-130	1		30
Toluene	80		80		70-130	0		30
Ethylbenzene	83		82		70-130	1		30
Chloromethane	78		76		52-130	3		30
Bromomethane	91		89		57-147	2		30

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2332665
Report Date: 06/19/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by EPA 5035 Low - Westborough Lab Associated sample(s): 01-05 Batch: WG1791311-3 WG1791311-4								
Vinyl chloride	68		67		67-130	1		30
Chloroethane	81		79		50-151	3		30
1,1-Dichloroethene	73		72		65-135	1		30
trans-1,2-Dichloroethene	82		81		70-130	1		30
Trichloroethene	78		77		70-130	1		30
1,2-Dichlorobenzene	83		83		70-130	0		30
1,3-Dichlorobenzene	83		83		70-130	0		30
1,4-Dichlorobenzene	84		83		70-130	1		30
Methyl tert butyl ether	82		81		66-130	1		30
p/m-Xylene	86		84		70-130	2		30
o-Xylene	85		85		70-130	0		30
cis-1,2-Dichloroethene	81		80		70-130	1		30
Dibromomethane	82		81		70-130	1		30
Styrene	84		83		70-130	1		30
Dichlorodifluoromethane	64		65		30-146	2		30
Acetone	74		74		54-140	0		30
Carbon disulfide	71		70		59-130	1		30
2-Butanone	80		77		70-130	4		30
Vinyl acetate	85		83		70-130	2		30
4-Methyl-2-pentanone	80		78		70-130	3		30
1,2,3-Trichloropropane	82		81		68-130	1		30
2-Hexanone	80		78		70-130	3		30
Bromochloromethane	85		85		70-130	0		30

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2332665
Report Date: 06/19/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by EPA 5035 Low - Westborough Lab Associated sample(s): 01-05 Batch: WG1791311-3 WG1791311-4								
2,2-Dichloropropane	80		79		70-130	1		30
1,2-Dibromoethane	79		77		70-130	3		30
1,3-Dichloropropane	85		83		69-130	2		30
1,1,1,2-Tetrachloroethane	84		84		70-130	0		30
Bromobenzene	82		81		70-130	1		30
n-Butylbenzene	85		85		70-130	0		30
sec-Butylbenzene	84		84		70-130	0		30
tert-Butylbenzene	82		82		70-130	0		30
o-Chlorotoluene	92		92		70-130	0		30
p-Chlorotoluene	81		81		70-130	0		30
1,2-Dibromo-3-chloropropane	79		78		68-130	1		30
Hexachlorobutadiene	83		83		67-130	0		30
Isopropylbenzene	82		83		70-130	1		30
p-Isopropyltoluene	83		84		70-130	1		30
Naphthalene	78		77		70-130	1		30
Acrylonitrile	84		82		70-130	2		30
n-Propylbenzene	84		84		70-130	0		30
1,2,3-Trichlorobenzene	82		81		70-130	1		30
1,2,4-Trichlorobenzene	86		85		70-130	1		30
1,3,5-Trimethylbenzene	82		82		70-130	0		30
1,2,4-Trimethylbenzene	81		81		70-130	0		30
1,4-Dioxane	89		83		65-136	7		30
p-Diethylbenzene	83		84		70-130	1		30

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by EPA 5035 Low - Westborough Lab Associated sample(s): 01-05 Batch: WG1791311-3 WG1791311-4								
p-Ethyltoluene	83		83		70-130	0		30
1,2,4,5-Tetramethylbenzene	80		80		70-130	0		30
Ethyl ether	84		83		67-130	1		30
trans-1,4-Dichloro-2-butene	86		83		70-130	4		30

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
1,2-Dichloroethane-d4	100		99		70-130
Toluene-d8	102		102		70-130
4-Bromofluorobenzene	98		99		70-130
Dibromofluoromethane	96		96		70-130

SEMIVOLATILES

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-01
Client ID: SB-44P (2-2.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/09/23 07:35
Date Received: 06/09/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8270E
Analytical Date: 06/13/23 21:06
Analyst: IM
Percent Solids: 93%

Extraction Method: EPA 3546
Extraction Date: 06/11/23 00:29

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Acenaphthene	ND		ug/kg	140	18.	1
1,2,4-Trichlorobenzene	ND		ug/kg	180	20.	1
Hexachlorobenzene	ND		ug/kg	110	20.	1
Bis(2-chloroethyl)ether	ND		ug/kg	160	24.	1
2-Chloronaphthalene	ND		ug/kg	180	18.	1
1,2-Dichlorobenzene	ND		ug/kg	180	32.	1
1,3-Dichlorobenzene	ND		ug/kg	180	30.	1
1,4-Dichlorobenzene	ND		ug/kg	180	31.	1
3,3'-Dichlorobenzidine	ND		ug/kg	180	47.	1
2,4-Dinitrotoluene	ND		ug/kg	180	36.	1
2,6-Dinitrotoluene	ND		ug/kg	180	30.	1
Fluoranthene	84	J	ug/kg	110	20.	1
4-Chlorophenyl phenyl ether	ND		ug/kg	180	19.	1
4-Bromophenyl phenyl ether	ND		ug/kg	180	27.	1
Bis(2-chloroisopropyl)ether	ND		ug/kg	210	30.	1
Bis(2-chloroethoxy)methane	ND		ug/kg	190	18.	1
Hexachlorobutadiene	ND		ug/kg	180	26.	1
Hexachlorocyclopentadiene	ND		ug/kg	510	160	1
Hexachloroethane	ND		ug/kg	140	29.	1
Isophorone	ND		ug/kg	160	23.	1
Naphthalene	ND		ug/kg	180	22.	1
Nitrobenzene	ND		ug/kg	160	26.	1
NDPA/DPA	ND		ug/kg	140	20.	1
n-Nitrosodi-n-propylamine	ND		ug/kg	180	27.	1
Bis(2-ethylhexyl)phthalate	ND		ug/kg	180	61.	1
Butyl benzyl phthalate	ND		ug/kg	180	45.	1
Di-n-butylphthalate	ND		ug/kg	180	34.	1
Di-n-octylphthalate	ND		ug/kg	180	60.	1

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-01 Date Collected: 06/09/23 07:35

Client ID: SB-44P (2-2.5) Date Received: 06/09/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Diethyl phthalate	ND		ug/kg	180	16.	1
Dimethyl phthalate	ND		ug/kg	180	37.	1
Benzo(a)anthracene	52	J	ug/kg	110	20.	1
Benzo(a)pyrene	60	J	ug/kg	140	43.	1
Benzo(b)fluoranthene	75	J	ug/kg	110	30.	1
Benzo(k)fluoranthene	ND		ug/kg	110	28.	1
Chrysene	47	J	ug/kg	110	18.	1
Acenaphthylene	ND		ug/kg	140	27.	1
Anthracene	ND		ug/kg	110	35.	1
Benzo(ghi)perylene	44	J	ug/kg	140	21.	1
Fluorene	ND		ug/kg	180	17.	1
Phenanthrene	51	J	ug/kg	110	22.	1
Dibenzo(a,h)anthracene	ND		ug/kg	110	20.	1
Indeno(1,2,3-cd)pyrene	36	J	ug/kg	140	25.	1
Pyrene	72	J	ug/kg	110	18.	1
Biphenyl	ND		ug/kg	400	23.	1
4-Chloroaniline	ND		ug/kg	180	32.	1
2-Nitroaniline	ND		ug/kg	180	34.	1
3-Nitroaniline	ND		ug/kg	180	33.	1
4-Nitroaniline	ND		ug/kg	180	73.	1
Dibenzofuran	ND		ug/kg	180	17.	1
2-Methylnaphthalene	ND		ug/kg	210	21.	1
1,2,4,5-Tetrachlorobenzene	ND		ug/kg	180	18.	1
Acetophenone	ND		ug/kg	180	22.	1
2,4,6-Trichlorophenol	ND		ug/kg	110	34.	1
p-Chloro-m-cresol	ND		ug/kg	180	26.	1
2-Chlorophenol	ND		ug/kg	180	21.	1
2,4-Dichlorophenol	ND		ug/kg	160	28.	1
2,4-Dimethylphenol	ND		ug/kg	180	58.	1
2-Nitrophenol	ND		ug/kg	380	67.	1
4-Nitrophenol	ND		ug/kg	250	72.	1
2,4-Dinitrophenol	ND		ug/kg	850	83.	1
4,6-Dinitro-o-cresol	ND		ug/kg	460	85.	1
Pentachlorophenol	ND		ug/kg	140	39.	1
Phenol	ND		ug/kg	180	27.	1
2-Methylphenol	ND		ug/kg	180	28.	1
3-Methylphenol/4-Methylphenol	ND		ug/kg	260	28.	1

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-01 Date Collected: 06/09/23 07:35

Client ID: SB-44P (2-2.5) Date Received: 06/09/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
2,4,5-Trichlorophenol	ND		ug/kg	180	34.	1
Benzoic Acid	ND		ug/kg	580	180	1
Benzyl Alcohol	ND		ug/kg	180	54.	1
Carbazole	ND		ug/kg	180	17.	1
1,4-Dioxane	ND		ug/kg	27	8.2	1
Tentatively Identified Compounds						
Total TIC Compounds	196	J	ug/kg			1
Unknown	196	J	ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	86		25-120
Phenol-d6	83		10-120
Nitrobenzene-d5	82		23-120
2-Fluorobiphenyl	83		30-120
2,4,6-Tribromophenol	70		10-136
4-Terphenyl-d14	71		18-120

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-02
Client ID: SB-45P (4-4.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/09/23 07:50
Date Received: 06/09/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8270E
Analytical Date: 06/13/23 21:23
Analyst: IM
Percent Solids: 93%

Extraction Method: EPA 3546
Extraction Date: 06/11/23 00:29

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Acenaphthene	ND		ug/kg	140	18.	1
1,2,4-Trichlorobenzene	ND		ug/kg	180	20.	1
Hexachlorobenzene	ND		ug/kg	110	20.	1
Bis(2-chloroethyl)ether	ND		ug/kg	160	24.	1
2-Chloronaphthalene	ND		ug/kg	180	18.	1
1,2-Dichlorobenzene	ND		ug/kg	180	32.	1
1,3-Dichlorobenzene	ND		ug/kg	180	30.	1
1,4-Dichlorobenzene	ND		ug/kg	180	31.	1
3,3'-Dichlorobenzidine	ND		ug/kg	180	47.	1
2,4-Dinitrotoluene	ND		ug/kg	180	35.	1
2,6-Dinitrotoluene	ND		ug/kg	180	30.	1
Fluoranthene	ND		ug/kg	110	20.	1
4-Chlorophenyl phenyl ether	ND		ug/kg	180	19.	1
4-Bromophenyl phenyl ether	ND		ug/kg	180	27.	1
Bis(2-chloroisopropyl)ether	ND		ug/kg	210	30.	1
Bis(2-chloroethoxy)methane	ND		ug/kg	190	18.	1
Hexachlorobutadiene	ND		ug/kg	180	26.	1
Hexachlorocyclopentadiene	ND		ug/kg	510	160	1
Hexachloroethane	ND		ug/kg	140	29.	1
Isophorone	ND		ug/kg	160	23.	1
Naphthalene	ND		ug/kg	180	22.	1
Nitrobenzene	ND		ug/kg	160	26.	1
NDPA/DPA	ND		ug/kg	140	20.	1
n-Nitrosodi-n-propylamine	ND		ug/kg	180	27.	1
Bis(2-ethylhexyl)phthalate	ND		ug/kg	180	61.	1
Butyl benzyl phthalate	ND		ug/kg	180	45.	1
Di-n-butylphthalate	ND		ug/kg	180	34.	1
Di-n-octylphthalate	ND		ug/kg	180	60.	1

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-02 Date Collected: 06/09/23 07:50

Client ID: SB-45P (4-4.5) Date Received: 06/09/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Diethyl phthalate	ND		ug/kg	180	16.	1
Dimethyl phthalate	ND		ug/kg	180	37.	1
Benzo(a)anthracene	ND		ug/kg	110	20.	1
Benzo(a)pyrene	ND		ug/kg	140	43.	1
Benzo(b)fluoranthene	ND		ug/kg	110	30.	1
Benzo(k)fluoranthene	ND		ug/kg	110	28.	1
Chrysene	ND		ug/kg	110	18.	1
Acenaphthylene	ND		ug/kg	140	27.	1
Anthracene	ND		ug/kg	110	35.	1
Benzo(ghi)perylene	ND		ug/kg	140	21.	1
Fluorene	ND		ug/kg	180	17.	1
Phenanthrene	ND		ug/kg	110	22.	1
Dibenzo(a,h)anthracene	ND		ug/kg	110	20.	1
Indeno(1,2,3-cd)pyrene	ND		ug/kg	140	25.	1
Pyrene	ND		ug/kg	110	18.	1
Biphenyl	ND		ug/kg	400	23.	1
4-Chloroaniline	ND		ug/kg	180	32.	1
2-Nitroaniline	ND		ug/kg	180	34.	1
3-Nitroaniline	ND		ug/kg	180	33.	1
4-Nitroaniline	ND		ug/kg	180	73.	1
Dibenzofuran	ND		ug/kg	180	17.	1
2-Methylnaphthalene	ND		ug/kg	210	21.	1
1,2,4,5-Tetrachlorobenzene	ND		ug/kg	180	18.	1
Acetophenone	ND		ug/kg	180	22.	1
2,4,6-Trichlorophenol	ND		ug/kg	110	34.	1
p-Chloro-m-cresol	ND		ug/kg	180	26.	1
2-Chlorophenol	ND		ug/kg	180	21.	1
2,4-Dichlorophenol	ND		ug/kg	160	28.	1
2,4-Dimethylphenol	ND		ug/kg	180	58.	1
2-Nitrophenol	ND		ug/kg	380	67.	1
4-Nitrophenol	ND		ug/kg	250	72.	1
2,4-Dinitrophenol	ND		ug/kg	850	83.	1
4,6-Dinitro-o-cresol	ND		ug/kg	460	85.	1
Pentachlorophenol	ND		ug/kg	140	39.	1
Phenol	ND		ug/kg	180	27.	1
2-Methylphenol	ND		ug/kg	180	28.	1
3-Methylphenol/4-Methylphenol	ND		ug/kg	260	28.	1

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-02 Date Collected: 06/09/23 07:50

Client ID: SB-45P (4-4.5) Date Received: 06/09/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
2,4,5-Trichlorophenol	ND		ug/kg	180	34.	1
Benzoic Acid	ND		ug/kg	580	180	1
Benzyl Alcohol	ND		ug/kg	180	54.	1
Carbazole	ND		ug/kg	180	17.	1
1,4-Dioxane	ND		ug/kg	27	8.2	1
Tentatively Identified Compounds						
Total TIC Compounds	169	J	ug/kg			1
Unknown	169	J	ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	81		25-120
Phenol-d6	77		10-120
Nitrobenzene-d5	75		23-120
2-Fluorobiphenyl	74		30-120
2,4,6-Tribromophenol	65		10-136
4-Terphenyl-d14	61		18-120

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-03
Client ID: SB-46P (4.5-5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/09/23 11:30
Date Received: 06/09/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8270E
Analytical Date: 06/13/23 21:40
Analyst: IM
Percent Solids: 92%

Extraction Method: EPA 3546
Extraction Date: 06/11/23 00:29

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Acenaphthene	ND		ug/kg	140	18.	1
1,2,4-Trichlorobenzene	ND		ug/kg	180	20.	1
Hexachlorobenzene	ND		ug/kg	110	20.	1
Bis(2-chloroethyl)ether	ND		ug/kg	160	24.	1
2-Chloronaphthalene	ND		ug/kg	180	18.	1
1,2-Dichlorobenzene	ND		ug/kg	180	32.	1
1,3-Dichlorobenzene	ND		ug/kg	180	31.	1
1,4-Dichlorobenzene	ND		ug/kg	180	31.	1
3,3'-Dichlorobenzidine	ND		ug/kg	180	48.	1
2,4-Dinitrotoluene	ND		ug/kg	180	36.	1
2,6-Dinitrotoluene	ND		ug/kg	180	31.	1
Fluoranthene	500		ug/kg	110	20.	1
4-Chlorophenyl phenyl ether	ND		ug/kg	180	19.	1
4-Bromophenyl phenyl ether	ND		ug/kg	180	27.	1
Bis(2-chloroisopropyl)ether	ND		ug/kg	220	31.	1
Bis(2-chloroethoxy)methane	ND		ug/kg	190	18.	1
Hexachlorobutadiene	ND		ug/kg	180	26.	1
Hexachlorocyclopentadiene	ND		ug/kg	510	160	1
Hexachloroethane	ND		ug/kg	140	29.	1
Isophorone	ND		ug/kg	160	23.	1
Naphthalene	ND		ug/kg	180	22.	1
Nitrobenzene	ND		ug/kg	160	26.	1
NDPA/DPA	ND		ug/kg	140	20.	1
n-Nitrosodi-n-propylamine	ND		ug/kg	180	28.	1
Bis(2-ethylhexyl)phthalate	63	J	ug/kg	180	62.	1
Butyl benzyl phthalate	ND		ug/kg	180	45.	1
Di-n-butylphthalate	ND		ug/kg	180	34.	1
Di-n-octylphthalate	ND		ug/kg	180	61.	1

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-03 Date Collected: 06/09/23 11:30

Client ID: SB-46P (4.5-5) Date Received: 06/09/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Diethyl phthalate	ND		ug/kg	180	17.	1
Dimethyl phthalate	ND		ug/kg	180	38.	1
Benzo(a)anthracene	220		ug/kg	110	20.	1
Benzo(a)pyrene	260		ug/kg	140	44.	1
Benzo(b)fluoranthene	290		ug/kg	110	30.	1
Benzo(k)fluoranthene	88	J	ug/kg	110	29.	1
Chrysene	210		ug/kg	110	19.	1
Acenaphthylene	35	J	ug/kg	140	28.	1
Anthracene	81	J	ug/kg	110	35.	1
Benzo(ghi)perylene	160		ug/kg	140	21.	1
Fluorene	17	J	ug/kg	180	17.	1
Phenanthrene	180		ug/kg	110	22.	1
Dibenzo(a,h)anthracene	35	J	ug/kg	110	21.	1
Indeno(1,2,3-cd)pyrene	130	J	ug/kg	140	25.	1
Pyrene	460		ug/kg	110	18.	1
Biphenyl	ND		ug/kg	410	23.	1
4-Chloroaniline	ND		ug/kg	180	33.	1
2-Nitroaniline	ND		ug/kg	180	34.	1
3-Nitroaniline	ND		ug/kg	180	34.	1
4-Nitroaniline	ND		ug/kg	180	74.	1
Dibenzofuran	26	J	ug/kg	180	17.	1
2-Methylnaphthalene	ND		ug/kg	220	22.	1
1,2,4,5-Tetrachlorobenzene	ND		ug/kg	180	19.	1
Acetophenone	ND		ug/kg	180	22.	1
2,4,6-Trichlorophenol	ND		ug/kg	110	34.	1
p-Chloro-m-cresol	ND		ug/kg	180	27.	1
2-Chlorophenol	ND		ug/kg	180	21.	1
2,4-Dichlorophenol	ND		ug/kg	160	29.	1
2,4-Dimethylphenol	ND		ug/kg	180	59.	1
2-Nitrophenol	ND		ug/kg	390	67.	1
4-Nitrophenol	ND		ug/kg	250	73.	1
2,4-Dinitrophenol	ND		ug/kg	860	84.	1
4,6-Dinitro-o-cresol	ND		ug/kg	470	86.	1
Pentachlorophenol	ND		ug/kg	140	39.	1
Phenol	ND		ug/kg	180	27.	1
2-Methylphenol	ND		ug/kg	180	28.	1
3-Methylphenol/4-Methylphenol	ND		ug/kg	260	28.	1

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-03 Date Collected: 06/09/23 11:30

Client ID: SB-46P (4.5-5) Date Received: 06/09/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
2,4,5-Trichlorophenol	ND		ug/kg	180	34.	1
Benzoic Acid	ND		ug/kg	580	180	1
Benzyl Alcohol	ND		ug/kg	180	55.	1
Carbazole	22	J	ug/kg	180	17.	1
1,4-Dioxane	ND		ug/kg	27	8.2	1
Tentatively Identified Compounds						
Total TIC Compounds	1000	J	ug/kg			1
Unknown	158	J	ug/kg			1
Unknown	158	J	ug/kg			1
Unknown Alkane	162	J	ug/kg			1
Unknown Alkane	174	J	ug/kg			1
Unknown PAH	156	J	ug/kg			1
Unknown Alkane	196	J	ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	83		25-120
Phenol-d6	82		10-120
Nitrobenzene-d5	78		23-120
2-Fluorobiphenyl	78		30-120
2,4,6-Tribromophenol	76		10-136
4-Terphenyl-d14	71		18-120

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-04
Client ID: SB-47P (3-3.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/09/23 12:40
Date Received: 06/09/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8270E
Analytical Date: 06/13/23 21:57
Analyst: IM
Percent Solids: 86%

Extraction Method: EPA 3546
Extraction Date: 06/11/23 00:29

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Acenaphthene	ND		ug/kg	150	20.	1
1,2,4-Trichlorobenzene	ND		ug/kg	190	22.	1
Hexachlorobenzene	ND		ug/kg	110	21.	1
Bis(2-chloroethyl)ether	ND		ug/kg	170	26.	1
2-Chloronaphthalene	ND		ug/kg	190	19.	1
1,2-Dichlorobenzene	ND		ug/kg	190	34.	1
1,3-Dichlorobenzene	ND		ug/kg	190	33.	1
1,4-Dichlorobenzene	ND		ug/kg	190	33.	1
3,3'-Dichlorobenzidine	ND		ug/kg	190	50.	1
2,4-Dinitrotoluene	ND		ug/kg	190	38.	1
2,6-Dinitrotoluene	ND		ug/kg	190	32.	1
Fluoranthene	120		ug/kg	110	22.	1
4-Chlorophenyl phenyl ether	ND		ug/kg	190	20.	1
4-Bromophenyl phenyl ether	ND		ug/kg	190	29.	1
Bis(2-chloroisopropyl)ether	ND		ug/kg	230	32.	1
Bis(2-chloroethoxy)methane	ND		ug/kg	200	19.	1
Hexachlorobutadiene	ND		ug/kg	190	28.	1
Hexachlorocyclopentadiene	ND		ug/kg	540	170	1
Hexachloroethane	ND		ug/kg	150	31.	1
Isophorone	ND		ug/kg	170	25.	1
Naphthalene	ND		ug/kg	190	23.	1
Nitrobenzene	ND		ug/kg	170	28.	1
NDPA/DPA	ND		ug/kg	150	22.	1
n-Nitrosodi-n-propylamine	ND		ug/kg	190	29.	1
Bis(2-ethylhexyl)phthalate	ND		ug/kg	190	66.	1
Butyl benzyl phthalate	ND		ug/kg	190	48.	1
Di-n-butylphthalate	ND		ug/kg	190	36.	1
Di-n-octylphthalate	ND		ug/kg	190	64.	1

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-04 Date Collected: 06/09/23 12:40

Client ID: SB-47P (3-3.5) Date Received: 06/09/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Diethyl phthalate	ND		ug/kg	190	18.	1
Dimethyl phthalate	ND		ug/kg	190	40.	1
Benzo(a)anthracene	75	J	ug/kg	110	21.	1
Benzo(a)pyrene	82	J	ug/kg	150	46.	1
Benzo(b)fluoranthene	97	J	ug/kg	110	32.	1
Benzo(k)fluoranthene	ND		ug/kg	110	30.	1
Chrysene	69	J	ug/kg	110	20.	1
Acenaphthylene	ND		ug/kg	150	29.	1
Anthracene	ND		ug/kg	110	37.	1
Benzo(ghi)perylene	50	J	ug/kg	150	22.	1
Fluorene	ND		ug/kg	190	18.	1
Phenanthrene	69	J	ug/kg	110	23.	1
Dibenzo(a,h)anthracene	ND		ug/kg	110	22.	1
Indeno(1,2,3-cd)pyrene	45	J	ug/kg	150	26.	1
Pyrene	120		ug/kg	110	19.	1
Biphenyl	ND		ug/kg	430	25.	1
4-Chloroaniline	ND		ug/kg	190	34.	1
2-Nitroaniline	ND		ug/kg	190	36.	1
3-Nitroaniline	ND		ug/kg	190	36.	1
4-Nitroaniline	ND		ug/kg	190	78.	1
Dibenzofuran	ND		ug/kg	190	18.	1
2-Methylnaphthalene	ND		ug/kg	230	23.	1
1,2,4,5-Tetrachlorobenzene	ND		ug/kg	190	20.	1
Acetophenone	ND		ug/kg	190	23.	1
2,4,6-Trichlorophenol	ND		ug/kg	110	36.	1
p-Chloro-m-cresol	ND		ug/kg	190	28.	1
2-Chlorophenol	ND		ug/kg	190	22.	1
2,4-Dichlorophenol	ND		ug/kg	170	30.	1
2,4-Dimethylphenol	ND		ug/kg	190	62.	1
2-Nitrophenol	ND		ug/kg	410	71.	1
4-Nitrophenol	ND		ug/kg	260	77.	1
2,4-Dinitrophenol	ND		ug/kg	910	88.	1
4,6-Dinitro-o-cresol	ND		ug/kg	490	91.	1
Pentachlorophenol	ND		ug/kg	150	42.	1
Phenol	ND		ug/kg	190	29.	1
2-Methylphenol	ND		ug/kg	190	29.	1
3-Methylphenol/4-Methylphenol	ND		ug/kg	270	30.	1

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-04 Date Collected: 06/09/23 12:40

Client ID: SB-47P (3-3.5) Date Received: 06/09/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
2,4,5-Trichlorophenol	ND		ug/kg	190	36.	1
Benzoic Acid	ND		ug/kg	610	190	1
Benzyl Alcohol	ND		ug/kg	190	58.	1
Carbazole	ND		ug/kg	190	18.	1
1,4-Dioxane	ND		ug/kg	28	8.7	1
Tentatively Identified Compounds						
Total TIC Compounds	978	J	ug/kg			1
Unknown	778	J	ug/kg			1
Unknown	200	J	ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	76		25-120
Phenol-d6	75		10-120
Nitrobenzene-d5	74		23-120
2-Fluorobiphenyl	68		30-120
2,4,6-Tribromophenol	61		10-136
4-Terphenyl-d14	51		18-120

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-05
Client ID: SB-48P (3.5-4)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/09/23 12:55
Date Received: 06/09/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8270E
Analytical Date: 06/13/23 22:14
Analyst: IM
Percent Solids: 84%

Extraction Method: EPA 3546
Extraction Date: 06/11/23 00:29

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Acenaphthene	570		ug/kg	150	20.	1
1,2,4-Trichlorobenzene	ND		ug/kg	190	22.	1
Hexachlorobenzene	ND		ug/kg	120	22.	1
Bis(2-chloroethyl)ether	ND		ug/kg	170	26.	1
2-Chloronaphthalene	ND		ug/kg	190	19.	1
1,2-Dichlorobenzene	ND		ug/kg	190	34.	1
1,3-Dichlorobenzene	ND		ug/kg	190	33.	1
1,4-Dichlorobenzene	ND		ug/kg	190	34.	1
3,3'-Dichlorobenzidine	ND		ug/kg	190	51.	1
2,4-Dinitrotoluene	ND		ug/kg	190	38.	1
2,6-Dinitrotoluene	ND		ug/kg	190	33.	1
Fluoranthene	2400		ug/kg	120	22.	1
4-Chlorophenyl phenyl ether	ND		ug/kg	190	21.	1
4-Bromophenyl phenyl ether	ND		ug/kg	190	29.	1
Bis(2-chloroisopropyl)ether	ND		ug/kg	230	33.	1
Bis(2-chloroethoxy)methane	ND		ug/kg	210	19.	1
Hexachlorobutadiene	ND		ug/kg	190	28.	1
Hexachlorocyclopentadiene	ND		ug/kg	550	170	1
Hexachloroethane	ND		ug/kg	150	31.	1
Isophorone	ND		ug/kg	170	25.	1
Naphthalene	920		ug/kg	190	23.	1
Nitrobenzene	ND		ug/kg	170	28.	1
NDPA/DPA	ND		ug/kg	150	22.	1
n-Nitrosodi-n-propylamine	ND		ug/kg	190	30.	1
Bis(2-ethylhexyl)phthalate	120	J	ug/kg	190	67.	1
Butyl benzyl phthalate	ND		ug/kg	190	48.	1
Di-n-butylphthalate	ND		ug/kg	190	36.	1
Di-n-octylphthalate	ND		ug/kg	190	65.	1

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-05 Date Collected: 06/09/23 12:55

Client ID: SB-48P (3.5-4) Date Received: 06/09/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Diethyl phthalate	ND		ug/kg	190	18.	1
Dimethyl phthalate	ND		ug/kg	190	40.	1
Benzo(a)anthracene	1000		ug/kg	120	22.	1
Benzo(a)pyrene	1100		ug/kg	150	47.	1
Benzo(b)fluoranthene	1100		ug/kg	120	32.	1
Benzo(k)fluoranthene	410		ug/kg	120	31.	1
Chrysene	1000		ug/kg	120	20.	1
Acenaphthylene	160		ug/kg	150	30.	1
Anthracene	610		ug/kg	120	38.	1
Benzo(ghi)perylene	590		ug/kg	150	23.	1
Fluorene	450		ug/kg	190	19.	1
Phenanthrene	2600		ug/kg	120	23.	1
Dibenzo(a,h)anthracene	140		ug/kg	120	22.	1
Indeno(1,2,3-cd)pyrene	520		ug/kg	150	27.	1
Pyrene	2200		ug/kg	120	19.	1
Biphenyl	78	J	ug/kg	440	25.	1
4-Chloroaniline	ND		ug/kg	190	35.	1
2-Nitroaniline	ND		ug/kg	190	37.	1
3-Nitroaniline	ND		ug/kg	190	36.	1
4-Nitroaniline	ND		ug/kg	190	80.	1
Dibenzofuran	250		ug/kg	190	18.	1
2-Methylnaphthalene	390		ug/kg	230	23.	1
1,2,4,5-Tetrachlorobenzene	ND		ug/kg	190	20.	1
Acetophenone	ND		ug/kg	190	24.	1
2,4,6-Trichlorophenol	ND		ug/kg	120	36.	1
p-Chloro-m-cresol	ND		ug/kg	190	29.	1
2-Chlorophenol	ND		ug/kg	190	23.	1
2,4-Dichlorophenol	ND		ug/kg	170	31.	1
2,4-Dimethylphenol	ND		ug/kg	190	64.	1
2-Nitrophenol	ND		ug/kg	420	72.	1
4-Nitrophenol	ND		ug/kg	270	78.	1
2,4-Dinitrophenol	ND		ug/kg	920	90.	1
4,6-Dinitro-o-cresol	ND		ug/kg	500	92.	1
Pentachlorophenol	ND		ug/kg	150	42.	1
Phenol	31	J	ug/kg	190	29.	1
2-Methylphenol	ND		ug/kg	190	30.	1
3-Methylphenol/4-Methylphenol	48	J	ug/kg	280	30.	1

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-05 Date Collected: 06/09/23 12:55

Client ID: SB-48P (3.5-4) Date Received: 06/09/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
2,4,5-Trichlorophenol	ND		ug/kg	190	37.	1
Benzoic Acid	ND		ug/kg	620	190	1
Benzyl Alcohol	ND		ug/kg	190	59.	1
Carbazole	250		ug/kg	190	19.	1
1,4-Dioxane	ND		ug/kg	29	8.8	1
Tentatively Identified Compounds						
Total TIC Compounds	3780	J	ug/kg			1
Unknown Naphthalene	168	J	ug/kg			1
Unknown	286	J	ug/kg			1
Unknown PAH	361	J	ug/kg			1
Unknown Thiophene	166	J	ug/kg			1
Unknown Thiophene	231	J	ug/kg			1
Unknown	197	J	ug/kg			1
Unknown Thiophene	198	J	ug/kg			1
Unknown	210	J	ug/kg			1
Unknown	673	J	ug/kg			1
Unknown PAH	238	J	ug/kg			1
Unknown PAH	346	J	ug/kg			1
Unknown Ketone	304	J	ug/kg			1
Unknown PAH	402	J	ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	80		25-120
Phenol-d6	78		10-120
Nitrobenzene-d5	80		23-120
2-Fluorobiphenyl	67		30-120
2,4,6-Tribromophenol	74		10-136
4-Terphenyl-d14	53		18-120

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-06
Client ID: GW-16
Sample Location: WHITE PLAINS, NY

Date Collected: 06/09/23 13:10
Date Received: 06/09/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E
Analytical Date: 06/15/23 23:32
Analyst: ALS

Extraction Method: EPA 3510C
Extraction Date: 06/15/23 04:02

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
1,2,4-Trichlorobenzene	ND		ug/l	5.0	0.50	1
Bis(2-chloroethyl)ether	ND		ug/l	2.0	0.50	1
1,2-Dichlorobenzene	ND		ug/l	2.0	0.45	1
1,3-Dichlorobenzene	ND		ug/l	2.0	0.40	1
1,4-Dichlorobenzene	ND		ug/l	2.0	0.43	1
3,3'-Dichlorobenzidine	ND		ug/l	5.0	1.6	1
2,4-Dinitrotoluene	ND		ug/l	5.0	1.2	1
2,6-Dinitrotoluene	ND		ug/l	5.0	0.93	1
4-Chlorophenyl phenyl ether	ND		ug/l	2.0	0.49	1
4-Bromophenyl phenyl ether	ND		ug/l	2.0	0.38	1
Bis(2-chloroisopropyl)ether	ND		ug/l	2.0	0.53	1
Bis(2-chloroethoxy)methane	ND		ug/l	5.0	0.50	1
Hexachlorocyclopentadiene	ND		ug/l	20	0.69	1
Isophorone	ND		ug/l	5.0	1.2	1
Nitrobenzene	ND		ug/l	2.0	0.77	1
NDPA/DPA	ND		ug/l	2.0	0.42	1
n-Nitrosodi-n-propylamine	ND		ug/l	5.0	0.64	1
Bis(2-ethylhexyl)phthalate	ND		ug/l	3.0	1.5	1
Butyl benzyl phthalate	ND		ug/l	5.0	1.2	1
Di-n-butylphthalate	ND		ug/l	5.0	0.39	1
Di-n-octylphthalate	ND		ug/l	5.0	1.3	1
Diethyl phthalate	ND		ug/l	5.0	0.38	1
Dimethyl phthalate	ND		ug/l	5.0	1.8	1
Biphenyl	ND		ug/l	2.0	0.46	1
4-Chloroaniline	ND		ug/l	5.0	1.1	1
2-Nitroaniline	ND		ug/l	5.0	0.50	1
3-Nitroaniline	ND		ug/l	5.0	0.81	1
4-Nitroaniline	ND		ug/l	5.0	0.80	1

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-06 Date Collected: 06/09/23 13:10

Client ID: GW-16 Date Received: 06/09/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Dibenzofuran	ND		ug/l	2.0	0.50	1
1,2,4,5-Tetrachlorobenzene	ND		ug/l	10	0.44	1
Acetophenone	ND		ug/l	5.0	0.53	1
2,4,6-Trichlorophenol	ND		ug/l	5.0	0.61	1
p-Chloro-m-cresol	ND		ug/l	2.0	0.35	1
2-Chlorophenol	ND		ug/l	2.0	0.48	1
2,4-Dichlorophenol	ND		ug/l	5.0	0.41	1
2,4-Dimethylphenol	ND		ug/l	5.0	1.8	1
2-Nitrophenol	ND		ug/l	10	0.85	1
4-Nitrophenol	ND		ug/l	10	0.67	1
2,4-Dinitrophenol	ND		ug/l	20	6.6	1
4,6-Dinitro-o-cresol	ND		ug/l	10	1.8	1
Phenol	ND		ug/l	5.0	0.57	1
2-Methylphenol	ND		ug/l	5.0	0.49	1
3-Methylphenol/4-Methylphenol	ND		ug/l	5.0	0.48	1
2,4,5-Trichlorophenol	ND		ug/l	5.0	0.77	1
Benzoic Acid	8.1	J	ug/l	50	2.6	1
Benzyl Alcohol	ND		ug/l	2.0	0.59	1
Carbazole	ND		ug/l	2.0	0.49	1

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-06 Date Collected: 06/09/23 13:10

Client ID: GW-16 Date Received: 06/09/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Tentatively Identified Compounds						
Total TIC Compounds	94.9	J	ug/l			1
Unknown	1.89	J	ug/l			1
Unknown	1.89	J	ug/l			1
Unknown	1.60	J	ug/l			1
Unknown	15.2	J	ug/l			1
Unknown Organic Acid	2.22	J	ug/l			1
Unknown	3.42	J	ug/l			1
Unknown	4.58	J	ug/l			1
Unknown Organic Acid	5.71	J	ug/l			1
Unknown	1.74	J	ug/l			1
Unknown Organic Acid	33.6	J	ug/l			1
Unknown	1.56	J	ug/l			1
Unknown Organic Acid	8.62	J	ug/l			1
Unknown	6.33	J	ug/l			1
Unknown Organic Acid	6.54	J	ug/l			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	55		21-120
Phenol-d6	42		10-120
Nitrobenzene-d5	73		23-120
2-Fluorobiphenyl	65		15-120
2,4,6-Tribromophenol	72		10-120
4-Terphenyl-d14	65		41-149

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-06
Client ID: GW-16
Sample Location: WHITE PLAINS, NY

Date Collected: 06/09/23 13:10
Date Received: 06/09/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E-SIM
Analytical Date: 06/16/23 13:26
Analyst: DV

Extraction Method: EPA 3510C
Extraction Date: 06/15/23 04:05

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS-SIM - Westborough Lab						
Acenaphthene	0.04	J	ug/l	0.10	0.01	1
2-Chloronaphthalene	ND		ug/l	0.20	0.02	1
Fluoranthene	0.02	J	ug/l	0.10	0.02	1
Hexachlorobutadiene	ND		ug/l	0.50	0.05	1
Naphthalene	ND		ug/l	0.10	0.05	1
Benzo(a)anthracene	ND		ug/l	0.10	0.02	1
Benzo(a)pyrene	ND		ug/l	0.10	0.02	1
Benzo(b)fluoranthene	ND		ug/l	0.10	0.01	1
Benzo(k)fluoranthene	ND		ug/l	0.10	0.01	1
Chrysene	ND		ug/l	0.10	0.01	1
Acenaphthylene	ND		ug/l	0.10	0.01	1
Anthracene	0.02	J	ug/l	0.10	0.01	1
Benzo(ghi)perylene	ND		ug/l	0.10	0.01	1
Fluorene	0.03	J	ug/l	0.10	0.01	1
Phenanthrene	0.04	J	ug/l	0.10	0.02	1
Dibenzo(a,h)anthracene	ND		ug/l	0.10	0.01	1
Indeno(1,2,3-cd)pyrene	ND		ug/l	0.10	0.01	1
Pyrene	0.02	J	ug/l	0.10	0.02	1
2-Methylnaphthalene	ND		ug/l	0.10	0.02	1
Pentachlorophenol	ND		ug/l	0.80	0.01	1
Hexachlorobenzene	ND		ug/l	0.80	0.01	1
Hexachloroethane	ND		ug/l	0.80	0.06	1

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-06 Date Collected: 06/09/23 13:10

Client ID: GW-16 Date Received: 06/09/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS-SIM - Westborough Lab						

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	61		21-120
Phenol-d6	51		10-120
Nitrobenzene-d5	96		23-120
2-Fluorobiphenyl	86		15-120
2,4,6-Tribromophenol	**128**	Q	10-120
4-Terphenyl-d14	88		41-149

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-07
Client ID: GW-17
Sample Location: WHITE PLAINS, NY

Date Collected: 06/09/23 12:10
Date Received: 06/09/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E
Analytical Date: 06/15/23 23:56
Analyst: ALS

Extraction Method: EPA 3510C
Extraction Date: 06/15/23 04:02

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
1,2,4-Trichlorobenzene	ND		ug/l	5.0	0.50	1
Bis(2-chloroethyl)ether	ND		ug/l	2.0	0.50	1
1,2-Dichlorobenzene	ND		ug/l	2.0	0.45	1
1,3-Dichlorobenzene	ND		ug/l	2.0	0.40	1
1,4-Dichlorobenzene	ND		ug/l	2.0	0.43	1
3,3'-Dichlorobenzidine	ND		ug/l	5.0	1.6	1
2,4-Dinitrotoluene	ND		ug/l	5.0	1.2	1
2,6-Dinitrotoluene	ND		ug/l	5.0	0.93	1
4-Chlorophenyl phenyl ether	ND		ug/l	2.0	0.49	1
4-Bromophenyl phenyl ether	ND		ug/l	2.0	0.38	1
Bis(2-chloroisopropyl)ether	ND		ug/l	2.0	0.53	1
Bis(2-chloroethoxy)methane	ND		ug/l	5.0	0.50	1
Hexachlorocyclopentadiene	ND		ug/l	20	0.69	1
Isophorone	ND		ug/l	5.0	1.2	1
Nitrobenzene	ND		ug/l	2.0	0.77	1
NDPA/DPA	ND		ug/l	2.0	0.42	1
n-Nitrosodi-n-propylamine	ND		ug/l	5.0	0.64	1
Bis(2-ethylhexyl)phthalate	ND		ug/l	3.0	1.5	1
Butyl benzyl phthalate	ND		ug/l	5.0	1.2	1
Di-n-butylphthalate	ND		ug/l	5.0	0.39	1
Di-n-octylphthalate	ND		ug/l	5.0	1.3	1
Diethyl phthalate	ND		ug/l	5.0	0.38	1
Dimethyl phthalate	ND		ug/l	5.0	1.8	1
Biphenyl	ND		ug/l	2.0	0.46	1
4-Chloroaniline	ND		ug/l	5.0	1.1	1
2-Nitroaniline	ND		ug/l	5.0	0.50	1
3-Nitroaniline	ND		ug/l	5.0	0.81	1
4-Nitroaniline	ND		ug/l	5.0	0.80	1

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-07 Date Collected: 06/09/23 12:10

Client ID: GW-17 Date Received: 06/09/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Dibenzofuran	ND		ug/l	2.0	0.50	1
1,2,4,5-Tetrachlorobenzene	ND		ug/l	10	0.44	1
Acetophenone	ND		ug/l	5.0	0.53	1
2,4,6-Trichlorophenol	ND		ug/l	5.0	0.61	1
p-Chloro-m-cresol	ND		ug/l	2.0	0.35	1
2-Chlorophenol	ND		ug/l	2.0	0.48	1
2,4-Dichlorophenol	ND		ug/l	5.0	0.41	1
2,4-Dimethylphenol	ND		ug/l	5.0	1.8	1
2-Nitrophenol	ND		ug/l	10	0.85	1
4-Nitrophenol	ND		ug/l	10	0.67	1
2,4-Dinitrophenol	ND		ug/l	20	6.6	1
4,6-Dinitro-o-cresol	ND		ug/l	10	1.8	1
Phenol	1.3	J	ug/l	5.0	0.57	1
2-Methylphenol	ND		ug/l	5.0	0.49	1
3-Methylphenol/4-Methylphenol	ND		ug/l	5.0	0.48	1
2,4,5-Trichlorophenol	ND		ug/l	5.0	0.77	1
Benzoic Acid	11.	J	ug/l	50	2.6	1
Benzyl Alcohol	ND		ug/l	2.0	0.59	1
Carbazole	ND		ug/l	2.0	0.49	1

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-07 Date Collected: 06/09/23 12:10

Client ID: GW-17 Date Received: 06/09/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Tentatively Identified Compounds						
Total TIC Compounds	107	J	ug/l			1
Unknown	2.29	J	ug/l			1
Unknown Organic Acid	5.16	J	ug/l			1
Unknown Organic Acid	34.7	J	ug/l			1
Unknown	3.89	J	ug/l			1
Unknown Organic Acid	5.89	J	ug/l			1
Unknown Organic Acid	5.64	J	ug/l			1
Unknown	1.78	J	ug/l			1
Unknown	5.20	J	ug/l			1
Unknown Organic Acid	22.2	J	ug/l			1
Unknown	1.93	J	ug/l			1
Unknown	3.49	J	ug/l			1
Unknown Organic Acid	2.44	J	ug/l			1
Unknown Organic Acid	2.87	J	ug/l			1
Unknown Amide	5.49	J	ug/l			1
Unknown Benzene	3.67	J	ug/l			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	51		21-120
Phenol-d6	42		10-120
Nitrobenzene-d5	70		23-120
2-Fluorobiphenyl	59		15-120
2,4,6-Tribromophenol	67		10-120
4-Terphenyl-d14	62		41-149

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-07
Client ID: GW-17
Sample Location: WHITE PLAINS, NY

Date Collected: 06/09/23 12:10
Date Received: 06/09/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E-SIM
Analytical Date: 06/16/23 13:42
Analyst: DV

Extraction Method: EPA 3510C
Extraction Date: 06/15/23 04:05

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS-SIM - Westborough Lab						
Acenaphthene	0.11		ug/l	0.10	0.01	1
2-Chloronaphthalene	ND		ug/l	0.20	0.02	1
Fluoranthene	0.08	J	ug/l	0.10	0.02	1
Hexachlorobutadiene	ND		ug/l	0.50	0.05	1
Naphthalene	1.3		ug/l	0.10	0.05	1
Benzo(a)anthracene	ND		ug/l	0.10	0.02	1
Benzo(a)pyrene	0.02	J	ug/l	0.10	0.02	1
Benzo(b)fluoranthene	0.02	J	ug/l	0.10	0.01	1
Benzo(k)fluoranthene	ND		ug/l	0.10	0.01	1
Chrysene	0.02	J	ug/l	0.10	0.01	1
Acenaphthylene	ND		ug/l	0.10	0.01	1
Anthracene	0.04	J	ug/l	0.10	0.01	1
Benzo(ghi)perylene	ND		ug/l	0.10	0.01	1
Fluorene	0.08	J	ug/l	0.10	0.01	1
Phenanthrene	0.15		ug/l	0.10	0.02	1
Dibenzo(a,h)anthracene	ND		ug/l	0.10	0.01	1
Indeno(1,2,3-cd)pyrene	ND		ug/l	0.10	0.01	1
Pyrene	0.08	J	ug/l	0.10	0.02	1
2-Methylnaphthalene	0.66		ug/l	0.10	0.02	1
Pentachlorophenol	ND		ug/l	0.80	0.01	1
Hexachlorobenzene	ND		ug/l	0.80	0.01	1
Hexachloroethane	ND		ug/l	0.80	0.06	1

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-07 Date Collected: 06/09/23 12:10

Client ID: GW-17 Date Received: 06/09/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor

Semivolatile Organics by GC/MS-SIM - Westborough Lab

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	57		21-120
Phenol-d6	49		10-120
Nitrobenzene-d5	87		23-120
2-Fluorobiphenyl	79		15-120
2,4,6-Tribromophenol	**121**	Q	10-120
4-Terphenyl-d14	83		41-149

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 06/13/23 13:33
Analyst: IM

Extraction Method: EPA 3546
Extraction Date: 06/11/23 00:29

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 01-05 Batch: WG1789783-1					
Acenaphthene	ND		ug/kg	130	17.
1,2,4-Trichlorobenzene	ND		ug/kg	160	19.
Hexachlorobenzene	ND		ug/kg	98	18.
Bis(2-chloroethyl)ether	ND		ug/kg	150	22.
2-Chloronaphthalene	ND		ug/kg	160	16.
1,2-Dichlorobenzene	ND		ug/kg	160	30.
1,3-Dichlorobenzene	ND		ug/kg	160	28.
1,4-Dichlorobenzene	ND		ug/kg	160	29.
3,3'-Dichlorobenzidine	ND		ug/kg	160	44.
2,4-Dinitrotoluene	ND		ug/kg	160	33.
2,6-Dinitrotoluene	ND		ug/kg	160	28.
Fluoranthene	ND		ug/kg	98	19.
4-Chlorophenyl phenyl ether	ND		ug/kg	160	18.
4-Bromophenyl phenyl ether	ND		ug/kg	160	25.
Bis(2-chloroisopropyl)ether	ND		ug/kg	200	28.
Bis(2-chloroethoxy)methane	ND		ug/kg	180	16.
Hexachlorobutadiene	ND		ug/kg	160	24.
Hexachlorocyclopentadiene	ND		ug/kg	470	150
Hexachloroethane	ND		ug/kg	130	26.
Isophorone	ND		ug/kg	150	21.
Naphthalene	ND		ug/kg	160	20.
Nitrobenzene	ND		ug/kg	150	24.
NDPA/DPA	ND		ug/kg	130	19.
n-Nitrosodi-n-propylamine	ND		ug/kg	160	25.
Bis(2-ethylhexyl)phthalate	ND		ug/kg	160	57.
Butyl benzyl phthalate	ND		ug/kg	160	41.
Di-n-butylphthalate	ND		ug/kg	160	31.
Di-n-octylphthalate	ND		ug/kg	160	56.
Diethyl phthalate	ND		ug/kg	160	15.

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2332665
Report Date: 06/19/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 06/13/23 13:33
Analyst: IM

Extraction Method: EPA 3546
Extraction Date: 06/11/23 00:29

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 01-05 Batch: WG1789783-1					
Dimethyl phthalate	ND		ug/kg	160	34.
Benzo(a)anthracene	ND		ug/kg	98	18.
Benzo(a)pyrene	ND		ug/kg	130	40.
Benzo(b)fluoranthene	ND		ug/kg	98	28.
Benzo(k)fluoranthene	ND		ug/kg	98	26.
Chrysene	ND		ug/kg	98	17.
Acenaphthylene	ND		ug/kg	130	25.
Anthracene	ND		ug/kg	98	32.
Benzo(ghi)perylene	ND		ug/kg	130	19.
Fluorene	ND		ug/kg	160	16.
Phenanthrene	ND		ug/kg	98	20.
Dibenzo(a,h)anthracene	ND		ug/kg	98	19.
Indeno(1,2,3-cd)pyrene	ND		ug/kg	130	23.
Pyrene	ND		ug/kg	98	16.
Biphenyl	ND		ug/kg	370	21.
4-Chloroaniline	ND		ug/kg	160	30.
2-Nitroaniline	ND		ug/kg	160	32.
3-Nitroaniline	ND		ug/kg	160	31.
4-Nitroaniline	ND		ug/kg	160	68.
Dibenzofuran	ND		ug/kg	160	16.
2-Methylnaphthalene	ND		ug/kg	200	20.
1,2,4,5-Tetrachlorobenzene	ND		ug/kg	160	17.
Acetophenone	ND		ug/kg	160	20.
2,4,6-Trichlorophenol	ND		ug/kg	98	31.
p-Chloro-m-cresol	ND		ug/kg	160	24.
2-Chlorophenol	ND		ug/kg	160	19.
2,4-Dichlorophenol	ND		ug/kg	150	26.
2,4-Dimethylphenol	ND		ug/kg	160	54.
2-Nitrophenol	ND		ug/kg	350	62.

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 06/13/23 13:33
Analyst: IM

Extraction Method: EPA 3546
Extraction Date: 06/11/23 00:29

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 01-05 Batch: WG1789783-1					
4-Nitrophenol	ND		ug/kg	230	67.
2,4-Dinitrophenol	ND		ug/kg	790	76.
4,6-Dinitro-o-cresol	ND		ug/kg	430	79.
Pentachlorophenol	ND		ug/kg	130	36.
Phenol	ND		ug/kg	160	25.
2-Methylphenol	ND		ug/kg	160	25.
3-Methylphenol/4-Methylphenol	ND		ug/kg	240	26.
2,4,5-Trichlorophenol	ND		ug/kg	160	31.
Benzoic Acid	ND		ug/kg	530	170
Benzyl Alcohol	ND		ug/kg	160	50.
Carbazole	ND		ug/kg	160	16.
1,4-Dioxane	ND		ug/kg	25	7.6
Tentatively Identified Compounds					
Total TIC Compounds	140	J	ug/kg		
Unknown	140	J	ug/kg		

Surrogate	%Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	76		25-120
Phenol-d6	72		10-120
Nitrobenzene-d5	68		23-120
2-Fluorobiphenyl	69		30-120
2,4,6-Tribromophenol	54		10-136
4-Terphenyl-d14	59		18-120

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 06/15/23 22:21
Analyst: ALS

Extraction Method: EPA 3510C
Extraction Date: 06/15/23 04:02

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 06-07 Batch: WG1791499-1					
Acenaphthene	ND		ug/l	2.0	0.44
1,2,4-Trichlorobenzene	ND		ug/l	5.0	0.50
Hexachlorobenzene	ND		ug/l	2.0	0.46
Bis(2-chloroethyl)ether	ND		ug/l	2.0	0.50
2-Chloronaphthalene	ND		ug/l	2.0	0.44
1,2-Dichlorobenzene	ND		ug/l	2.0	0.45
1,3-Dichlorobenzene	ND		ug/l	2.0	0.40
1,4-Dichlorobenzene	ND		ug/l	2.0	0.43
3,3'-Dichlorobenzidine	ND		ug/l	5.0	1.6
2,4-Dinitrotoluene	ND		ug/l	5.0	1.2
2,6-Dinitrotoluene	ND		ug/l	5.0	0.93
Fluoranthene	ND		ug/l	2.0	0.26
4-Chlorophenyl phenyl ether	ND		ug/l	2.0	0.49
4-Bromophenyl phenyl ether	ND		ug/l	2.0	0.38
Bis(2-chloroisopropyl)ether	ND		ug/l	2.0	0.53
Bis(2-chloroethoxy)methane	ND		ug/l	5.0	0.50
Hexachlorobutadiene	ND		ug/l	2.0	0.66
Hexachlorocyclopentadiene	ND		ug/l	20	0.69
Hexachloroethane	ND		ug/l	2.0	0.58
Isophorone	ND		ug/l	5.0	1.2
Naphthalene	ND		ug/l	2.0	0.46
Nitrobenzene	ND		ug/l	2.0	0.77
NDPA/DPA	ND		ug/l	2.0	0.42
n-Nitrosodi-n-propylamine	ND		ug/l	5.0	0.64
Bis(2-ethylhexyl)phthalate	ND		ug/l	3.0	1.5
Butyl benzyl phthalate	ND		ug/l	5.0	1.2
Di-n-butylphthalate	ND		ug/l	5.0	0.39
Di-n-octylphthalate	ND		ug/l	5.0	1.3
Diethyl phthalate	ND		ug/l	5.0	0.38

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 06/15/23 22:21
Analyst: ALS

Extraction Method: EPA 3510C
Extraction Date: 06/15/23 04:02

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 06-07 Batch: WG1791499-1					
Dimethyl phthalate	ND		ug/l	5.0	1.8
Benzo(a)anthracene	ND		ug/l	2.0	0.32
Benzo(a)pyrene	ND		ug/l	2.0	0.41
Benzo(b)fluoranthene	ND		ug/l	2.0	0.35
Benzo(k)fluoranthene	ND		ug/l	2.0	0.37
Chrysene	ND		ug/l	2.0	0.34
Acenaphthylene	ND		ug/l	2.0	0.46
Anthracene	ND		ug/l	2.0	0.33
Benzo(ghi)perylene	ND		ug/l	2.0	0.30
Fluorene	ND		ug/l	2.0	0.41
Phenanthrene	ND		ug/l	2.0	0.33
Dibenzo(a,h)anthracene	ND		ug/l	2.0	0.32
Indeno(1,2,3-cd)pyrene	ND		ug/l	2.0	0.40
Pyrene	ND		ug/l	2.0	0.28
Biphenyl	ND		ug/l	2.0	0.46
4-Chloroaniline	ND		ug/l	5.0	1.1
2-Nitroaniline	ND		ug/l	5.0	0.50
3-Nitroaniline	ND		ug/l	5.0	0.81
4-Nitroaniline	ND		ug/l	5.0	0.80
Dibenzofuran	ND		ug/l	2.0	0.50
2-Methylnaphthalene	ND		ug/l	2.0	0.45
1,2,4,5-Tetrachlorobenzene	ND		ug/l	10	0.44
Acetophenone	ND		ug/l	5.0	0.53
2,4,6-Trichlorophenol	ND		ug/l	5.0	0.61
p-Chloro-m-cresol	ND		ug/l	2.0	0.35
2-Chlorophenol	ND		ug/l	2.0	0.48
2,4-Dichlorophenol	ND		ug/l	5.0	0.41
2,4-Dimethylphenol	ND		ug/l	5.0	1.8
2-Nitrophenol	ND		ug/l	10	0.85

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2332665
Report Date: 06/19/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 06/15/23 22:21
Analyst: ALS

Extraction Method: EPA 3510C
Extraction Date: 06/15/23 04:02

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 06-07 Batch: WG1791499-1					
4-Nitrophenol	ND		ug/l	10	0.67
2,4-Dinitrophenol	ND		ug/l	20	6.6
4,6-Dinitro-o-cresol	ND		ug/l	10	1.8
Pentachlorophenol	ND		ug/l	10	1.8
Phenol	ND		ug/l	5.0	0.57
2-Methylphenol	ND		ug/l	5.0	0.49
3-Methylphenol/4-Methylphenol	ND		ug/l	5.0	0.48
2,4,5-Trichlorophenol	ND		ug/l	5.0	0.77
Benzoic Acid	ND		ug/l	50	2.6
Benzyl Alcohol	ND		ug/l	2.0	0.59
Carbazole	ND		ug/l	2.0	0.49

Tentatively Identified Compounds			
Total TIC Compounds	22.5	J	ug/l
Unknown Organic Acid	4.04	J	ug/l
Unknown	4.40	J	ug/l
Unknown	3.49	J	ug/l
Unknown Organic Acid	3.45	J	ug/l
Unknown	1.49	J	ug/l
Unknown	1.74	J	ug/l
Unknown Organic Acid	1.67	J	ug/l
Unknown	2.22	J	ug/l

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 06/15/23 22:21
Analyst: ALS

Extraction Method: EPA 3510C
Extraction Date: 06/15/23 04:02

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 06-07 Batch: WG1791499-1					

Surrogate	%Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	54		21-120
Phenol-d6	42		10-120
Nitrobenzene-d5	75		23-120
2-Fluorobiphenyl	65		15-120
2,4,6-Tribromophenol	62		10-120
4-Terphenyl-d14	70		41-149

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E-SIM
Analytical Date: 06/16/23 09:50
Analyst: DV

Extraction Method: EPA 3510C
Extraction Date: 06/15/23 04:05

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS-SIM - Westborough Lab for sample(s): 06-07 Batch: WG1791500-1					
Acenaphthene	ND		ug/l	0.10	0.01
2-Chloronaphthalene	ND		ug/l	0.20	0.02
Fluoranthene	ND		ug/l	0.10	0.02
Hexachlorobutadiene	ND		ug/l	0.50	0.05
Naphthalene	ND		ug/l	0.10	0.05
Benzo(a)anthracene	ND		ug/l	0.10	0.02
Benzo(a)pyrene	ND		ug/l	0.10	0.02
Benzo(b)fluoranthene	ND		ug/l	0.10	0.01
Benzo(k)fluoranthene	ND		ug/l	0.10	0.01
Chrysene	ND		ug/l	0.10	0.01
Acenaphthylene	ND		ug/l	0.10	0.01
Anthracene	ND		ug/l	0.10	0.01
Benzo(ghi)perylene	ND		ug/l	0.10	0.01
Fluorene	ND		ug/l	0.10	0.01
Phenanthrene	ND		ug/l	0.10	0.02
Dibenzo(a,h)anthracene	ND		ug/l	0.10	0.01
Indeno(1,2,3-cd)pyrene	ND		ug/l	0.10	0.01
Pyrene	ND		ug/l	0.10	0.02
2-Methylnaphthalene	ND		ug/l	0.10	0.02
Pentachlorophenol	ND		ug/l	0.80	0.01
Hexachlorobenzene	ND		ug/l	0.80	0.01
Hexachloroethane	ND		ug/l	0.80	0.06

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E-SIM
Analytical Date: 06/16/23 09:50
Analyst: DV

Extraction Method: EPA 3510C
Extraction Date: 06/15/23 04:05

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS-SIM - Westborough Lab for sample(s): 06-07 Batch: WG1791500-1					

Surrogate	%Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	61		21-120
Phenol-d6	46		10-120
Nitrobenzene-d5	94		23-120
2-Fluorobiphenyl	87		15-120
2,4,6-Tribromophenol	118		10-120
4-Terphenyl-d14	98		41-149

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2332665

Report Date: 06/19/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 01-05 Batch: WG1789783-2 WG1789783-3								
Acenaphthene	63		62		31-137	2		50
1,2,4-Trichlorobenzene	75		69		38-107	8		50
Hexachlorobenzene	64		62		40-140	3		50
Bis(2-chloroethyl)ether	74		69		40-140	7		50
2-Chloronaphthalene	72		68		40-140	6		50
1,2-Dichlorobenzene	71		67		40-140	6		50
1,3-Dichlorobenzene	71		68		40-140	4		50
1,4-Dichlorobenzene	71		65		28-104	9		50
3,3'-Dichlorobenzidine	60		62		40-140	3		50
2,4-Dinitrotoluene	73		71		40-132	3		50
2,6-Dinitrotoluene	82		78		40-140	5		50
Fluoranthene	67		63		40-140	6		50
4-Chlorophenyl phenyl ether	66		64		40-140	3		50
4-Bromophenyl phenyl ether	67		65		40-140	3		50
Bis(2-chloroisopropyl)ether	86		78		40-140	10		50
Bis(2-chloroethoxy)methane	78		73		40-117	7		50
Hexachlorobutadiene	72		68		40-140	6		50
Hexachlorocyclopentadiene	58		52		40-140	11		50
Hexachloroethane	75		68		40-140	10		50
Isophorone	83		77		40-140	8		50
Naphthalene	73		68		40-140	7		50
Nitrobenzene	79		72		40-140	9		50
NDPA/DPA	68		66		36-157	3		50

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2332665
Report Date: 06/19/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 01-05 Batch: WG1789783-2 WG1789783-3								
n-Nitrosodi-n-propylamine	83		77		32-121	8		50
Bis(2-ethylhexyl)phthalate	69		65		40-140	6		50
Butyl benzyl phthalate	81		75		40-140	8		50
Di-n-butylphthalate	78		72		40-140	8		50
Di-n-octylphthalate	70		66		40-140	6		50
Diethyl phthalate	72		70		40-140	3		50
Dimethyl phthalate	79		73		40-140	8		50
Benzo(a)anthracene	71		68		40-140	4		50
Benzo(a)pyrene	72		72		40-140	0		50
Benzo(b)fluoranthene	66		68		40-140	3		50
Benzo(k)fluoranthene	67		64		40-140	5		50
Chrysene	68		66		40-140	3		50
Acenaphthylene	80		76		40-140	5		50
Anthracene	69		66		40-140	4		50
Benzo(ghi)perylene	66		68		40-140	3		50
Fluorene	66		64		40-140	3		50
Phenanthrene	66		63		40-140	5		50
Dibenzo(a,h)anthracene	67		66		40-140	2		50
Indeno(1,2,3-cd)pyrene	69		68		40-140	1		50
Pyrene	67		64		35-142	5		50
Biphenyl	73		70		37-127	4		50
4-Chloroaniline	56		63		40-140	12		50
2-Nitroaniline	79		76		47-134	4		50

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2332665
Report Date: 06/19/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 01-05 Batch: WG1789783-2 WG1789783-3								
3-Nitroaniline	54		57		26-129	5		50
4-Nitroaniline	63		64		41-125	2		50
Dibenzofuran	67		65		40-140	3		50
2-Methylnaphthalene	76		70		40-140	8		50
1,2,4,5-Tetrachlorobenzene	72		66		40-117	9		50
Acetophenone	81		77		14-144	5		50
2,4,6-Trichlorophenol	77		70		30-130	10		50
p-Chloro-m-cresol	82		80		26-103	2		50
2-Chlorophenol	78		72		25-102	8		50
2,4-Dichlorophenol	79		72		30-130	9		50
2,4-Dimethylphenol	77		69		30-130	11		50
2-Nitrophenol	85		79		30-130	7		50
4-Nitrophenol	72		72		11-114	0		50
2,4-Dinitrophenol	25		22		4-130	13		50
4,6-Dinitro-o-cresol	63		63		10-130	0		50
Pentachlorophenol	36		35		17-109	3		50
Phenol	87		76		26-90	13		50
2-Methylphenol	77		70		30-130.	10		50
3-Methylphenol/4-Methylphenol	80		75		30-130	6		50
2,4,5-Trichlorophenol	78		73		30-130	7		50
Benzoic Acid	**0**	Q	**0**	Q	10-110	NC		50
Benzyl Alcohol	80		78		40-140	3		50
Carbazole	71		69		54-128	3		50

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2332665

Report Date: 06/19/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 01-05 Batch: WG1789783-2 WG1789783-3								
1,4-Dioxane	61		57		40-140	7		50

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
2-Fluorophenol	83		79		25-120
Phenol-d6	80		77		10-120
Nitrobenzene-d5	79		75		23-120
2-Fluorobiphenyl	76		71		30-120
2,4,6-Tribromophenol	65		62		10-136
4-Terphenyl-d14	66		61		18-120

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2332665
Report Date: 06/19/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 06-07 Batch: WG1791499-2 WG1791499-3								
Acenaphthene	67		66		37-111	2		30
1,2,4-Trichlorobenzene	64		66		39-98	3		30
Hexachlorobenzene	60		54		40-140	11		30
Bis(2-chloroethyl)ether	66		68		40-140	3		30
2-Chloronaphthalene	61		60		40-140	2		30
1,2-Dichlorobenzene	65		69		40-140	6		30
1,3-Dichlorobenzene	68		69		40-140	1		30
1,4-Dichlorobenzene	66		70		36-97	6		30
3,3'-Dichlorobenzidine	54		51		40-140	6		30
2,4-Dinitrotoluene	80		73		48-143	9		30
2,6-Dinitrotoluene	70		60		40-140	15		30
Fluoranthene	67		60		40-140	11		30
4-Chlorophenyl phenyl ether	63		61		40-140	3		30
4-Bromophenyl phenyl ether	57		53		40-140	7		30
Bis(2-chloroisopropyl)ether	94		94		40-140	0		30
Bis(2-chloroethoxy)methane	68		68		40-140	0		30
Hexachlorobutadiene	46		46		40-140	0		30
Hexachlorocyclopentadiene	48		48		40-140	0		30
Hexachloroethane	69		70		40-140	1		30
Isophorone	58		58		40-140	0		30
Naphthalene	64		63		40-140	2		30
Nitrobenzene	65		66		40-140	2		30
NDPA/DPA	71		63		40-140	12		30

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2332665
Report Date: 06/19/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 06-07 Batch: WG1791499-2 WG1791499-3								
n-Nitrosodi-n-propylamine	59		60		29-132	2		30
Bis(2-ethylhexyl)phthalate	104		95		40-140	9		30
Butyl benzyl phthalate	94		77		40-140	20		30
Di-n-butylphthalate	85		76		40-140	11		30
Di-n-octylphthalate	97		92		40-140	5		30
Diethyl phthalate	79		72		40-140	9		30
Dimethyl phthalate	71		63		40-140	12		30
Benzo(a)anthracene	72		68		40-140	6		30
Benzo(a)pyrene	76		79		40-140	4		30
Benzo(b)fluoranthene	72		72		40-140	0		30
Benzo(k)fluoranthene	73		74		40-140	1		30
Chrysene	72		71		40-140	1		30
Acenaphthylene	68		64		45-123	6		30
Anthracene	71		68		40-140	4		30
Benzo(ghi)perylene	76		83		40-140	9		30
Fluorene	70		66		40-140	6		30
Phenanthrene	72		69		40-140	4		30
Dibenzo(a,h)anthracene	75		81		40-140	8		30
Indeno(1,2,3-cd)pyrene	74		80		40-140	8		30
Pyrene	68		60		26-127	13		30
Biphenyl	59		56		40-140	5		30
4-Chloroaniline	52		48		40-140	8		30
2-Nitroaniline	69		63		52-143	9		30

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2332665
Report Date: 06/19/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 06-07 Batch: WG1791499-2 WG1791499-3								
3-Nitroaniline	72		67		25-145	7		30
4-Nitroaniline	80		71		51-143	12		30
Dibenzofuran	70		67		40-140	4		30
2-Methylnaphthalene	69		66		40-140	4		30
1,2,4,5-Tetrachlorobenzene	47		44		2-134	7		30
Acetophenone	56		58		39-129	4		30
2,4,6-Trichlorophenol	59		54		30-130	9		30
p-Chloro-m-cresol	63		56		23-97	12		30
2-Chlorophenol	68		67		27-123	1		30
2,4-Dichlorophenol	68		66		30-130	3		30
2,4-Dimethylphenol	65		63		30-130	3		30
2-Nitrophenol	79		80		30-130	1		30
4-Nitrophenol	66		58		10-80	13		30
2,4-Dinitrophenol	48		57		20-130	17		30
4,6-Dinitro-o-cresol	74		69		20-164	7		30
Pentachlorophenol	60		60		9-103	0		30
Phenol	41		42		12-110	2		30
2-Methylphenol	60		61		30-130	2		30
3-Methylphenol/4-Methylphenol	58		58		30-130	0		30
2,4,5-Trichlorophenol	61		54		30-130	12		30
Benzoic Acid	50		58		10-164	15		30
Benzyl Alcohol	52		51		26-116	2		30
Carbazole	78		71		55-144	9		30

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2332665
Report Date: 06/19/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 06-07 Batch: WG1791499-2 WG1791499-3								

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
2-Fluorophenol	53		54		21-120
Phenol-d6	41		42		10-120
Nitrobenzene-d5	66		67		23-120
2-Fluorobiphenyl	58		56		15-120
2,4,6-Tribromophenol	67		60		10-120
4-Terphenyl-d14	65		55		41-149

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2332665
Report Date: 06/19/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS-SIM - Westborough Lab Associated sample(s): 06-07 Batch: WG1791500-2 WG1791500-3								
Acenaphthene	76		70		40-140	8		40
2-Chloronaphthalene	77		72		40-140	7		40
Fluoranthene	83		75		40-140	10		40
Hexachlorobutadiene	68		65		40-140	5		40
Naphthalene	72		68		40-140	6		40
Benzo(a)anthracene	89		80		40-140	11		40
Benzo(a)pyrene	88		82		40-140	7		40
Benzo(b)fluoranthene	80		74		40-140	8		40
Benzo(k)fluoranthene	81		76		40-140	6		40
Chrysene	78		72		40-140	8		40
Acenaphthylene	86		80		40-140	7		40
Anthracene	83		76		40-140	9		40
Benzo(ghi)perylene	92		84		40-140	9		40
Fluorene	80		74		40-140	8		40
Phenanthrene	74		68		40-140	8		40
Dibenzo(a,h)anthracene	89		81		40-140	9		40
Indeno(1,2,3-cd)pyrene	89		80		40-140	11		40
Pyrene	80		73		40-140	9		40
2-Methylnaphthalene	76		72		40-140	5		40
Pentachlorophenol	87		86		40-140	1		40
Hexachlorobenzene	71		65		40-140	9		40
Hexachloroethane	69		66		40-140	4		40

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2332665

Report Date: 06/19/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits

Semivolatile Organics by GC/MS-SIM - Westborough Lab Associated sample(s): 06-07 Batch: WG1791500-2 WG1791500-3

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
2-Fluorophenol	61		59		21-120
Phenol-d6	52		50		10-120
Nitrobenzene-d5	86		83		23-120
2-Fluorobiphenyl	77		72		15-120
2,4,6-Tribromophenol	117		108		10-120
4-Terphenyl-d14	82		75		41-149

PCBS

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-01
Client ID: SB-44P (2-2.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/09/23 07:35
Date Received: 06/09/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8082A
Analytical Date: 06/11/23 18:53
Analyst: ER
Percent Solids: 93%

Extraction Method: EPA 3546
Extraction Date: 06/11/23 00:00
Cleanup Method: EPA 3665A
Cleanup Date: 06/11/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/11/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/kg	49.8	4.42	1	A
Aroclor 1221	ND		ug/kg	49.8	4.99	1	A
Aroclor 1232	ND		ug/kg	49.8	10.6	1	A
Aroclor 1242	ND		ug/kg	49.8	6.71	1	A
Aroclor 1248	ND		ug/kg	49.8	7.46	1	A
Aroclor 1254	5.92	J	ug/kg	49.8	5.44	1	B
Aroclor 1260	ND		ug/kg	49.8	9.20	1	A
Aroclor 1262	ND		ug/kg	49.8	6.32	1	A
Aroclor 1268	ND		ug/kg	49.8	5.16	1	A
PCBs, Total	5.92	J	ug/kg	49.8	4.42	1	B

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	60		30-150	A
Decachlorobiphenyl	65		30-150	A
2,4,5,6-Tetrachloro-m-xylene	62		30-150	B
Decachlorobiphenyl	67		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-02
Client ID: SB-45P (4-4.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/09/23 07:50
Date Received: 06/09/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8082A
Analytical Date: 06/11/23 19:01
Analyst: ER
Percent Solids: 93%

Extraction Method: EPA 3546
Extraction Date: 06/11/23 00:00
Cleanup Method: EPA 3665A
Cleanup Date: 06/11/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/11/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/kg	51.1	4.54	1	A
Aroclor 1221	ND		ug/kg	51.1	5.12	1	A
Aroclor 1232	ND		ug/kg	51.1	10.8	1	A
Aroclor 1242	ND		ug/kg	51.1	6.89	1	A
Aroclor 1248	ND		ug/kg	51.1	7.67	1	A
Aroclor 1254	ND		ug/kg	51.1	5.60	1	A
Aroclor 1260	ND		ug/kg	51.1	9.45	1	A
Aroclor 1262	ND		ug/kg	51.1	6.50	1	A
Aroclor 1268	ND		ug/kg	51.1	5.30	1	A
PCBs, Total	ND		ug/kg	51.1	4.54	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	61		30-150	A
Decachlorobiphenyl	64		30-150	A
2,4,5,6-Tetrachloro-m-xylene	64		30-150	B
Decachlorobiphenyl	66		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-03
Client ID: SB-46P (4.5-5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/09/23 11:30
Date Received: 06/09/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8082A
Analytical Date: 06/11/23 19:09
Analyst: ER
Percent Solids: 92%

Extraction Method: EPA 3546
Extraction Date: 06/11/23 00:00
Cleanup Method: EPA 3665A
Cleanup Date: 06/11/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/11/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/kg	51.3	4.55	1	A
Aroclor 1221	ND		ug/kg	51.3	5.14	1	A
Aroclor 1232	ND		ug/kg	51.3	10.9	1	A
Aroclor 1242	ND		ug/kg	51.3	6.91	1	A
Aroclor 1248	ND		ug/kg	51.3	7.69	1	A
Aroclor 1254	ND		ug/kg	51.3	5.61	1	A
Aroclor 1260	ND		ug/kg	51.3	9.48	1	A
Aroclor 1262	ND		ug/kg	51.3	6.51	1	A
Aroclor 1268	ND		ug/kg	51.3	5.31	1	A
PCBs, Total	ND		ug/kg	51.3	4.55	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	59		30-150	A
Decachlorobiphenyl	62		30-150	A
2,4,5,6-Tetrachloro-m-xylene	61		30-150	B
Decachlorobiphenyl	64		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-04
Client ID: SB-47P (3-3.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/09/23 12:40
Date Received: 06/09/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8082A
Analytical Date: 06/11/23 19:17
Analyst: ER
Percent Solids: 86%

Extraction Method: EPA 3546
Extraction Date: 06/11/23 00:00
Cleanup Method: EPA 3665A
Cleanup Date: 06/11/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/11/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/kg	56.6	5.03	1	A
Aroclor 1221	ND		ug/kg	56.6	5.67	1	A
Aroclor 1232	ND		ug/kg	56.6	12.0	1	A
Aroclor 1242	ND		ug/kg	56.6	7.63	1	A
Aroclor 1248	ND		ug/kg	56.6	8.50	1	A
Aroclor 1254	ND		ug/kg	56.6	6.20	1	A
Aroclor 1260	ND		ug/kg	56.6	10.5	1	A
Aroclor 1262	ND		ug/kg	56.6	7.19	1	A
Aroclor 1268	ND		ug/kg	56.6	5.87	1	A
PCBs, Total	ND		ug/kg	56.6	5.03	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	59		30-150	A
Decachlorobiphenyl	60		30-150	A
2,4,5,6-Tetrachloro-m-xylene	60		30-150	B
Decachlorobiphenyl	62		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-05
Client ID: SB-48P (3.5-4)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/09/23 12:55
Date Received: 06/09/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8082A
Analytical Date: 06/11/23 19:25
Analyst: ER
Percent Solids: 84%

Extraction Method: EPA 3546
Extraction Date: 06/11/23 00:00
Cleanup Method: EPA 3665A
Cleanup Date: 06/11/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/11/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/kg	55.4	4.92	1	A
Aroclor 1221	ND		ug/kg	55.4	5.55	1	A
Aroclor 1232	ND		ug/kg	55.4	11.7	1	A
Aroclor 1242	ND		ug/kg	55.4	7.46	1	A
Aroclor 1248	ND		ug/kg	55.4	8.30	1	A
Aroclor 1254	9.40	J	ug/kg	55.4	6.06	1	B
Aroclor 1260	ND		ug/kg	55.4	10.2	1	A
Aroclor 1262	ND		ug/kg	55.4	7.03	1	A
Aroclor 1268	ND		ug/kg	55.4	5.74	1	A
PCBs, Total	9.40	J	ug/kg	55.4	4.92	1	B

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	60		30-150	A
Decachlorobiphenyl	60		30-150	A
2,4,5,6-Tetrachloro-m-xylene	63		30-150	B
Decachlorobiphenyl	63		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-06
Client ID: GW-16
Sample Location: WHITE PLAINS, NY

Date Collected: 06/09/23 13:10
Date Received: 06/09/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8082A
Analytical Date: 06/16/23 16:12
Analyst: MEO

Extraction Method: EPA 3510C
Extraction Date: 06/16/23 00:29
Cleanup Method: EPA 3665A
Cleanup Date: 06/16/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/16/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/l	0.089	0.076	1	A
Aroclor 1221	ND		ug/l	0.089	0.076	1	A
Aroclor 1232	ND		ug/l	0.089	0.076	1	A
Aroclor 1242	ND		ug/l	0.089	0.076	1	A
Aroclor 1248	ND		ug/l	0.089	0.076	1	A
Aroclor 1254	ND		ug/l	0.089	0.076	1	A
Aroclor 1260	ND		ug/l	0.089	0.076	1	A
Aroclor 1262	ND		ug/l	0.089	0.076	1	A
Aroclor 1268	ND		ug/l	0.089	0.076	1	A
PCBs, Total	ND		ug/l	0.089	0.076	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	74		30-150	A
Decachlorobiphenyl	61		30-150	A
2,4,5,6-Tetrachloro-m-xylene	57		30-150	B
Decachlorobiphenyl	51		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-07
Client ID: GW-17
Sample Location: WHITE PLAINS, NY

Date Collected: 06/09/23 12:10
Date Received: 06/09/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8082A
Analytical Date: 06/17/23 11:32
Analyst: MEO

Extraction Method: EPA 3510C
Extraction Date: 06/16/23 19:03
Cleanup Method: EPA 3660B
Cleanup Date: 06/17/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/l	0.071	0.061	1	A
Aroclor 1221	ND		ug/l	0.071	0.061	1	A
Aroclor 1232	ND		ug/l	0.071	0.061	1	A
Aroclor 1242	ND		ug/l	0.071	0.061	1	A
Aroclor 1248	ND		ug/l	0.071	0.061	1	A
Aroclor 1254	ND		ug/l	0.071	0.061	1	A
Aroclor 1260	ND		ug/l	0.071	0.061	1	A
Aroclor 1262	ND		ug/l	0.071	0.061	1	A
Aroclor 1268	ND		ug/l	0.071	0.061	1	A
PCBs, Total	ND		ug/l	0.071	0.061	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	64		30-150	A
Decachlorobiphenyl	58		30-150	A
2,4,5,6-Tetrachloro-m-xylene	60		30-150	B
Decachlorobiphenyl	55		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8082A
Analytical Date: 06/11/23 10:33
Analyst: ER

Extraction Method: EPA 3546
Extraction Date: 06/10/23 09:01
Cleanup Method: EPA 3665A
Cleanup Date: 06/10/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/10/23

Parameter	Result	Qualifier	Units	RL	MDL	Column
Polychlorinated Biphenyls by GC - Westborough Lab for sample(s): 01-05 Batch: WG1789644-1						
Aroclor 1016	ND		ug/kg	48.8	4.33	A
Aroclor 1221	ND		ug/kg	48.8	4.89	A
Aroclor 1232	ND		ug/kg	48.8	10.3	A
Aroclor 1242	ND		ug/kg	48.8	6.58	A
Aroclor 1248	ND		ug/kg	48.8	7.32	A
Aroclor 1254	ND		ug/kg	48.8	5.34	A
Aroclor 1260	ND		ug/kg	48.8	9.01	A
Aroclor 1262	ND		ug/kg	48.8	6.20	A
Aroclor 1268	ND		ug/kg	48.8	5.05	A
PCBs, Total	ND		ug/kg	48.8	4.33	A

Surrogate	%Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	70		30-150	A
Decachlorobiphenyl	79		30-150	A
2,4,5,6-Tetrachloro-m-xylene	73		30-150	B
Decachlorobiphenyl	76		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8082A
Analytical Date: 06/16/23 02:51
Analyst: JM

Extraction Method: EPA 3510C
Extraction Date: 06/15/23 05:01
Cleanup Method: EPA 3665A
Cleanup Date: 06/16/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/16/23

Parameter	Result	Qualifier	Units	RL	MDL	Column
Polychlorinated Biphenyls by GC - Westborough Lab for sample(s): 06 Batch: WG1791511-1						
Aroclor 1016	ND		ug/l	0.071	0.061	A
Aroclor 1221	ND		ug/l	0.071	0.061	A
Aroclor 1232	ND		ug/l	0.071	0.061	A
Aroclor 1242	ND		ug/l	0.071	0.061	A
Aroclor 1248	ND		ug/l	0.071	0.061	A
Aroclor 1254	ND		ug/l	0.071	0.061	A
Aroclor 1260	ND		ug/l	0.071	0.061	A
Aroclor 1262	ND		ug/l	0.071	0.061	A
Aroclor 1268	ND		ug/l	0.071	0.061	A
PCBs, Total	ND		ug/l	0.071	0.061	A

Surrogate	%Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	58		30-150	A
Decachlorobiphenyl	87		30-150	A
2,4,5,6-Tetrachloro-m-xylene	60		30-150	B
Decachlorobiphenyl	90		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2332665
Report Date: 06/19/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8082A
Analytical Date: 06/17/23 11:03
Analyst: MEO

Extraction Method: EPA 3510C
Extraction Date: 06/16/23 15:59

Cleanup Method: EPA 3660B
Cleanup Date: 06/17/23

Parameter	Result	Qualifier	Units	RL	MDL	Column
Polychlorinated Biphenyls by GC - Westborough Lab for sample(s): 07 Batch: WG1792423-1						
Aroclor 1016	ND		ug/l	0.071	0.061	A
Aroclor 1221	ND		ug/l	0.071	0.061	A
Aroclor 1232	ND		ug/l	0.071	0.061	A
Aroclor 1242	ND		ug/l	0.071	0.061	A
Aroclor 1248	ND		ug/l	0.071	0.061	A
Aroclor 1254	ND		ug/l	0.071	0.061	A
Aroclor 1260	ND		ug/l	0.071	0.061	A
Aroclor 1262	ND		ug/l	0.071	0.061	A
Aroclor 1268	ND		ug/l	0.071	0.061	A
PCBs, Total	ND		ug/l	0.071	0.061	A

Surrogate	%Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	63		30-150	A
Decachlorobiphenyl	79		30-150	A
2,4,5,6-Tetrachloro-m-xylene	56		30-150	B
Decachlorobiphenyl	75		30-150	B

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2332665
Report Date: 06/19/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits	Column
Polychlorinated Biphenyls by GC - Westborough Lab Associated sample(s): 01-05 Batch: WG1789644-2 WG1789644-3									
Aroclor 1016	80		84		40-140	5		50	A
Aroclor 1260	80		82		40-140	2		50	A

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	73		79		30-150	A
Decachlorobiphenyl	77		80		30-150	A
2,4,5,6-Tetrachloro-m-xylene	76		83		30-150	B
Decachlorobiphenyl	79		83		30-150	B

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2332665

Report Date: 06/19/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits	Column
Polychlorinated Biphenyls by GC - Westborough Lab Associated sample(s): 06 Batch: WG1791511-2 WG1791511-3									
Aroclor 1016	68		75		40-140	9		50	A
Aroclor 1260	66		72		40-140	10		50	A

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	65		67		30-150	A
Decachlorobiphenyl	76		80		30-150	A
2,4,5,6-Tetrachloro-m-xylene	64		67		30-150	B
Decachlorobiphenyl	79		82		30-150	B

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2332665
Report Date: 06/19/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits	Column
Polychlorinated Biphenyls by GC - Westborough Lab Associated sample(s): 07 Batch: WG1792423-2 WG1792423-3									
Aroclor 1016	67		58		40-140	15		50	A
Aroclor 1260	66		56		40-140	16		50	A

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	65		53		30-150	A
Decachlorobiphenyl	80		70		30-150	A
2,4,5,6-Tetrachloro-m-xylene	60		51		30-150	B
Decachlorobiphenyl	74		68		30-150	B

PESTICIDES

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-01
Client ID: SB-44P (2-2.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/09/23 07:35
Date Received: 06/09/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8081B
Analytical Date: 06/12/23 11:35
Analyst: AR
Percent Solids: 93%

Extraction Method: EPA 3546
Extraction Date: 06/10/23 23:55
Cleanup Method: EPA 3620B
Cleanup Date: 06/12/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/12/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/kg	1.64	0.322	1	A
Lindane	ND		ug/kg	0.684	0.306	1	A
Alpha-BHC	ND		ug/kg	0.684	0.194	1	A
Beta-BHC	ND		ug/kg	1.64	0.623	1	A
Heptachlor	ND		ug/kg	0.821	0.368	1	A
Aldrin	ND		ug/kg	1.64	0.578	1	A
Heptachlor epoxide	ND		ug/kg	3.08	0.924	1	A
Endrin	ND		ug/kg	0.684	0.280	1	A
Endrin aldehyde	ND		ug/kg	2.05	0.718	1	A
Endrin ketone	ND		ug/kg	1.64	0.423	1	A
Dieldrin	ND		ug/kg	1.03	0.513	1	A
4,4'-DDE	ND		ug/kg	1.64	0.380	1	A
4,4'-DDD	ND		ug/kg	1.64	0.586	1	A
4,4'-DDT	ND		ug/kg	1.64	1.32	1	A
Endosulfan I	ND		ug/kg	1.64	0.388	1	A
Endosulfan II	ND		ug/kg	1.64	0.549	1	A
Endosulfan sulfate	ND		ug/kg	0.684	0.326	1	A
Methoxychlor	ND		ug/kg	3.08	0.958	1	A
Toxaphene	ND		ug/kg	30.8	8.62	1	A
cis-Chlordane	1.08	J	ug/kg	2.05	0.572	1	A
trans-Chlordane	1.23	J	ug/kg	2.05	0.542	1	B
Chlordane	ND		ug/kg	13.7	5.44	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-01 Date Collected: 06/09/23 07:35

Client ID: SB-44P (2-2.5) Date Received: 06/09/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	83		30-150	A
Decachlorobiphenyl	97		30-150	A
2,4,5,6-Tetrachloro-m-xylene	84		30-150	B
Decachlorobiphenyl	103		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-02
Client ID: SB-45P (4-4.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/09/23 07:50
Date Received: 06/09/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8081B
Analytical Date: 06/12/23 11:48
Analyst: AR
Percent Solids: 93%

Extraction Method: EPA 3546
Extraction Date: 06/10/23 23:55
Cleanup Method: EPA 3620B
Cleanup Date: 06/12/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/12/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/kg	1.68	0.330	1	A
Lindane	ND		ug/kg	0.702	0.314	1	A
Alpha-BHC	ND		ug/kg	0.702	0.200	1	A
Beta-BHC	ND		ug/kg	1.68	0.639	1	A
Heptachlor	ND		ug/kg	0.843	0.378	1	A
Aldrin	ND		ug/kg	1.68	0.594	1	A
Heptachlor epoxide	ND		ug/kg	3.16	0.948	1	A
Endrin	ND		ug/kg	0.702	0.288	1	A
Endrin aldehyde	ND		ug/kg	2.11	0.738	1	A
Endrin ketone	ND		ug/kg	1.68	0.434	1	A
Dieldrin	ND		ug/kg	1.05	0.527	1	A
4,4'-DDE	ND		ug/kg	1.68	0.390	1	A
4,4'-DDD	ND		ug/kg	1.68	0.601	1	A
4,4'-DDT	ND		ug/kg	1.68	1.36	1	A
Endosulfan I	ND		ug/kg	1.68	0.398	1	A
Endosulfan II	ND		ug/kg	1.68	0.563	1	A
Endosulfan sulfate	ND		ug/kg	0.702	0.334	1	A
Methoxychlor	ND		ug/kg	3.16	0.983	1	A
Toxaphene	ND		ug/kg	31.6	8.85	1	A
cis-Chlordane	ND		ug/kg	2.11	0.587	1	A
trans-Chlordane	ND		ug/kg	2.11	0.556	1	A
Chlordane	ND		ug/kg	14.0	5.58	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-02 Date Collected: 06/09/23 07:50

Client ID: SB-45P (4-4.5) Date Received: 06/09/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	75		30-150	A
Decachlorobiphenyl	92		30-150	A
2,4,5,6-Tetrachloro-m-xylene	77		30-150	B
Decachlorobiphenyl	98		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-03
Client ID: SB-46P (4.5-5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/09/23 11:30
Date Received: 06/09/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8081B
Analytical Date: 06/12/23 12:00
Analyst: AR
Percent Solids: 92%

Extraction Method: EPA 3546
Extraction Date: 06/10/23 23:55
Cleanup Method: EPA 3620B
Cleanup Date: 06/12/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/12/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/kg	1.69	0.330	1	A
Lindane	ND		ug/kg	0.703	0.314	1	A
Alpha-BHC	ND		ug/kg	0.703	0.200	1	A
Beta-BHC	ND		ug/kg	1.69	0.640	1	A
Heptachlor	ND		ug/kg	0.844	0.378	1	A
Aldrin	ND		ug/kg	1.69	0.594	1	A
Heptachlor epoxide	ND		ug/kg	3.16	0.949	1	A
Endrin	ND		ug/kg	0.703	0.288	1	A
Endrin aldehyde	ND		ug/kg	2.11	0.738	1	A
Endrin ketone	ND		ug/kg	1.69	0.434	1	A
Dieldrin	ND		ug/kg	1.05	0.527	1	A
4,4'-DDE	ND		ug/kg	1.69	0.390	1	A
4,4'-DDD	1.17	JIP	ug/kg	1.69	0.602	1	B
4,4'-DDT	ND		ug/kg	1.69	1.36	1	A
Endosulfan I	ND		ug/kg	1.69	0.399	1	A
Endosulfan II	ND		ug/kg	1.69	0.564	1	A
Endosulfan sulfate	ND		ug/kg	0.703	0.335	1	A
Methoxychlor	ND		ug/kg	3.16	0.984	1	A
Toxaphene	ND		ug/kg	31.6	8.86	1	A
cis-Chlordane	ND		ug/kg	2.11	0.588	1	A
trans-Chlordane	ND		ug/kg	2.11	0.557	1	A
Chlordane	ND		ug/kg	14.1	5.59	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-03 Date Collected: 06/09/23 11:30

Client ID: SB-46P (4.5-5) Date Received: 06/09/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	57		30-150	A
Decachlorobiphenyl	66		30-150	A
2,4,5,6-Tetrachloro-m-xylene	94		30-150	B
Decachlorobiphenyl	113		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-04
Client ID: SB-47P (3-3.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/09/23 12:40
Date Received: 06/09/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8081B
Analytical Date: 06/12/23 12:12
Analyst: AR
Percent Solids: 86%

Extraction Method: EPA 3546
Extraction Date: 06/10/23 23:55
Cleanup Method: EPA 3620B
Cleanup Date: 06/12/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/12/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/kg	1.79	0.350	1	A
Lindane	ND		ug/kg	0.745	0.333	1	A
Alpha-BHC	ND		ug/kg	0.745	0.212	1	A
Beta-BHC	ND		ug/kg	1.79	0.678	1	A
Heptachlor	ND		ug/kg	0.894	0.401	1	A
Aldrin	ND		ug/kg	1.79	0.630	1	A
Heptachlor epoxide	ND		ug/kg	3.35	1.00	1	A
Endrin	ND		ug/kg	0.745	0.306	1	A
Endrin aldehyde	ND		ug/kg	2.24	0.782	1	A
Endrin ketone	ND		ug/kg	1.79	0.460	1	A
Dieldrin	ND		ug/kg	1.12	0.559	1	A
4,4'-DDE	ND		ug/kg	1.79	0.414	1	A
4,4'-DDD	ND		ug/kg	1.79	0.638	1	B
4,4'-DDT	ND		ug/kg	1.79	1.44	1	A
Endosulfan I	ND		ug/kg	1.79	0.422	1	A
Endosulfan II	ND		ug/kg	1.79	0.598	1	A
Endosulfan sulfate	ND		ug/kg	0.745	0.355	1	A
Methoxychlor	ND		ug/kg	3.35	1.04	1	A
Toxaphene	ND		ug/kg	33.5	9.39	1	A
cis-Chlordane	ND		ug/kg	2.24	0.623	1	A
trans-Chlordane	ND		ug/kg	2.24	0.590	1	A
Chlordane	ND		ug/kg	14.9	5.92	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-04 Date Collected: 06/09/23 12:40

Client ID: SB-47P (3-3.5) Date Received: 06/09/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	63		30-150	A
Decachlorobiphenyl	67		30-150	A
2,4,5,6-Tetrachloro-m-xylene	83		30-150	B
Decachlorobiphenyl	103		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-05
Client ID: SB-48P (3.5-4)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/09/23 12:55
Date Received: 06/09/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8081B
Analytical Date: 06/12/23 12:24
Analyst: AR
Percent Solids: 84%

Extraction Method: EPA 3546
Extraction Date: 06/10/23 23:55
Cleanup Method: EPA 3620B
Cleanup Date: 06/12/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/12/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/kg	1.85	0.362	1	B
Lindane	ND		ug/kg	0.769	0.344	1	B
Alpha-BHC	ND		ug/kg	0.769	0.218	1	B
Beta-BHC	ND		ug/kg	1.85	0.700	1	B
Heptachlor	ND		ug/kg	0.923	0.414	1	B
Aldrin	ND		ug/kg	1.85	0.650	1	B
Heptachlor epoxide	ND		ug/kg	3.46	1.04	1	B
Endrin	ND		ug/kg	0.769	0.315	1	B
Endrin aldehyde	ND		ug/kg	2.31	0.808	1	B
Endrin ketone	ND		ug/kg	1.85	0.475	1	B
Dieldrin	ND		ug/kg	1.15	0.577	1	B
4,4'-DDE	ND		ug/kg	1.85	0.427	1	B
4,4'-DDD	4.83	P	ug/kg	1.85	0.658	1	B
4,4'-DDT	ND		ug/kg	1.85	1.48	1	B
Endosulfan I	ND		ug/kg	1.85	0.436	1	B
Endosulfan II	ND		ug/kg	1.85	0.617	1	B
Endosulfan sulfate	ND		ug/kg	0.769	0.366	1	B
Methoxychlor	ND		ug/kg	3.46	1.08	1	B
Toxaphene	ND		ug/kg	34.6	9.69	1	B
cis-Chlordane	ND		ug/kg	2.31	0.643	1	B
trans-Chlordane	ND		ug/kg	2.31	0.609	1	B
Chlordane	ND		ug/kg	15.4	6.12	1	B

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-05 Date Collected: 06/09/23 12:55

Client ID: SB-48P (3.5-4) Date Received: 06/09/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	**7**	Q	30-150	A
Decachlorobiphenyl	**6**	Q	30-150	A
2,4,5,6-Tetrachloro-m-xylene	102		30-150	B
Decachlorobiphenyl	114		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-06
Client ID: GW-16
Sample Location: WHITE PLAINS, NY

Date Collected: 06/09/23 13:10
Date Received: 06/09/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8081B
Analytical Date: 06/15/23 16:13
Analyst: AAR

Extraction Method: EPA 3510C
Extraction Date: 06/14/23 09:23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/l	0.014	0.003	1	A
Lindane	ND		ug/l	0.014	0.003	1	A
Alpha-BHC	ND		ug/l	0.014	0.003	1	A
Beta-BHC	ND		ug/l	0.014	0.004	1	A
Heptachlor	ND		ug/l	0.014	0.002	1	A
Aldrin	ND		ug/l	0.014	0.002	1	A
Heptachlor epoxide	ND		ug/l	0.014	0.003	1	A
Endrin	ND		ug/l	0.029	0.003	1	A
Endrin aldehyde	ND		ug/l	0.029	0.006	1	A
Endrin ketone	ND		ug/l	0.029	0.003	1	A
Dieldrin	ND		ug/l	0.029	0.003	1	A
4,4'-DDE	ND		ug/l	0.029	0.003	1	A
4,4'-DDD	ND		ug/l	0.029	0.003	1	A
4,4'-DDT	ND		ug/l	0.029	0.003	1	A
Endosulfan I	ND		ug/l	0.014	0.002	1	A
Endosulfan II	ND		ug/l	0.029	0.004	1	A
Endosulfan sulfate	ND		ug/l	0.029	0.003	1	A
Methoxychlor	ND		ug/l	0.143	0.005	1	A
Toxaphene	ND		ug/l	0.143	0.045	1	A
cis-Chlordane	ND		ug/l	0.014	0.005	1	A
trans-Chlordane	ND		ug/l	0.014	0.004	1	A
Chlordane	ND		ug/l	0.143	0.033	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-06 Date Collected: 06/09/23 13:10

Client ID: GW-16 Date Received: 06/09/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	47		30-150	A
Decachlorobiphenyl	46		30-150	A
2,4,5,6-Tetrachloro-m-xylene	45		30-150	B
Decachlorobiphenyl	40		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-07
Client ID: GW-17
Sample Location: WHITE PLAINS, NY

Date Collected: 06/09/23 12:10
Date Received: 06/09/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8081B
Analytical Date: 06/15/23 16:24
Analyst: AAR

Extraction Method: EPA 3510C
Extraction Date: 06/14/23 09:23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/l	0.014	0.003	1	A
Lindane	ND		ug/l	0.014	0.003	1	A
Alpha-BHC	ND		ug/l	0.014	0.003	1	A
Beta-BHC	ND		ug/l	0.014	0.004	1	A
Heptachlor	ND		ug/l	0.014	0.002	1	A
Aldrin	ND		ug/l	0.014	0.002	1	A
Heptachlor epoxide	ND		ug/l	0.014	0.003	1	A
Endrin	ND		ug/l	0.029	0.003	1	A
Endrin aldehyde	ND		ug/l	0.029	0.006	1	A
Endrin ketone	ND		ug/l	0.029	0.003	1	A
Dieldrin	ND		ug/l	0.029	0.003	1	A
4,4'-DDE	ND		ug/l	0.029	0.003	1	A
4,4'-DDD	ND		ug/l	0.029	0.003	1	A
4,4'-DDT	ND		ug/l	0.029	0.003	1	A
Endosulfan I	ND		ug/l	0.014	0.002	1	A
Endosulfan II	ND		ug/l	0.029	0.004	1	A
Endosulfan sulfate	ND		ug/l	0.029	0.003	1	A
Methoxychlor	ND		ug/l	0.143	0.005	1	A
Toxaphene	ND		ug/l	0.143	0.045	1	A
cis-Chlordane	ND		ug/l	0.014	0.005	1	A
trans-Chlordane	ND		ug/l	0.014	0.004	1	A
Chlordane	ND		ug/l	0.143	0.033	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-07 Date Collected: 06/09/23 12:10

Client ID: GW-17 Date Received: 06/09/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	50		30-150	A
Decachlorobiphenyl	48		30-150	A
2,4,5,6-Tetrachloro-m-xylene	47		30-150	B
Decachlorobiphenyl	40		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8081B
Analytical Date: 06/12/23 09:21
Analyst: EJL

Extraction Method: EPA 3546
Extraction Date: 06/10/23 10:26
Cleanup Method: EPA 3620B
Cleanup Date: 06/12/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/12/23

Parameter	Result	Qualifier	Units	RL	MDL	Column
Organochlorine Pesticides by GC - Westborough Lab for sample(s): 01-05 Batch: WG1789658-1						
Delta-BHC	ND		ug/kg	1.55	0.303	A
Lindane	ND		ug/kg	0.644	0.288	A
Alpha-BHC	ND		ug/kg	0.644	0.183	A
Beta-BHC	ND		ug/kg	1.55	0.586	A
Heptachlor	ND		ug/kg	0.773	0.347	A
Aldrin	ND		ug/kg	1.55	0.544	A
Heptachlor epoxide	ND		ug/kg	2.90	0.870	A
Endrin	ND		ug/kg	0.644	0.264	A
Endrin aldehyde	ND		ug/kg	1.93	0.676	A
Endrin ketone	ND		ug/kg	1.55	0.398	A
Dieldrin	ND		ug/kg	0.966	0.483	A
4,4'-DDE	ND		ug/kg	1.55	0.358	A
4,4'-DDD	ND		ug/kg	1.55	0.552	A
4,4'-DDT	ND		ug/kg	1.55	1.24	A
Endosulfan I	ND		ug/kg	1.55	0.365	A
Endosulfan II	ND		ug/kg	1.55	0.517	A
Endosulfan sulfate	ND		ug/kg	0.644	0.307	A
Methoxychlor	ND		ug/kg	2.90	0.902	A
Toxaphene	ND		ug/kg	29.0	8.12	A
cis-Chlordane	ND		ug/kg	1.93	0.539	A
trans-Chlordane	ND		ug/kg	1.93	0.510	A
Chlordane	ND		ug/kg	12.9	5.12	A

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8081B
Analytical Date: 06/12/23 09:21
Analyst: EJL

Extraction Method: EPA 3546
Extraction Date: 06/10/23 10:26
Cleanup Method: EPA 3620B
Cleanup Date: 06/12/23
Cleanup Method: EPA 3660B
Cleanup Date: 06/12/23

Parameter	Result	Qualifier	Units	RL	MDL	Column
Organochlorine Pesticides by GC - Westborough Lab for sample(s): 01-05 Batch: WG1789658-1						

Surrogate	%Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	64		30-150	A
Decachlorobiphenyl	79		30-150	A
2,4,5,6-Tetrachloro-m-xylene	69		30-150	B
Decachlorobiphenyl	91		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8081B
Analytical Date: 06/14/23 15:51
Analyst: AKM

Extraction Method: EPA 3510C
Extraction Date: 06/14/23 03:15

Parameter	Result	Qualifier	Units	RL	MDL	Column
Organochlorine Pesticides by GC - Westborough Lab for sample(s): 06-07 Batch: WG1790949-1						
Delta-BHC	ND		ug/l	0.014	0.003	A
Lindane	ND		ug/l	0.014	0.003	A
Alpha-BHC	ND		ug/l	0.014	0.003	A
Beta-BHC	ND		ug/l	0.014	0.004	A
Heptachlor	ND		ug/l	0.014	0.002	A
Aldrin	ND		ug/l	0.014	0.002	A
Heptachlor epoxide	ND		ug/l	0.014	0.003	A
Endrin	ND		ug/l	0.029	0.003	A
Endrin aldehyde	ND		ug/l	0.029	0.006	A
Endrin ketone	ND		ug/l	0.029	0.003	A
Dieldrin	ND		ug/l	0.029	0.003	A
4,4'-DDE	ND		ug/l	0.029	0.003	A
4,4'-DDD	ND		ug/l	0.029	0.003	A
4,4'-DDT	ND		ug/l	0.029	0.003	A
Endosulfan I	ND		ug/l	0.014	0.002	A
Endosulfan II	ND		ug/l	0.029	0.004	A
Endosulfan sulfate	ND		ug/l	0.029	0.003	A
Methoxychlor	ND		ug/l	0.143	0.005	A
Toxaphene	ND		ug/l	0.143	0.045	A
cis-Chlordane	ND		ug/l	0.014	0.005	A
trans-Chlordane	ND		ug/l	0.014	0.004	A
Chlordane	ND		ug/l	0.143	0.033	A

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8081B
Analytical Date: 06/14/23 15:51
Analyst: AKM

Extraction Method: EPA 3510C
Extraction Date: 06/14/23 03:15

Parameter	Result	Qualifier	Units	RL	MDL	Column
Organochlorine Pesticides by GC - Westborough Lab for sample(s): 06-07 Batch: WG1790949-1						

Surrogate	%Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	65		30-150	A
Decachlorobiphenyl	77		30-150	A
2,4,5,6-Tetrachloro-m-xylene	63		30-150	B
Decachlorobiphenyl	71		30-150	B

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2332665
Report Date: 06/19/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits	Column
Organochlorine Pesticides by GC - Westborough Lab Associated sample(s): 01-05 Batch: WG1789658-2 WG1789658-3									
Delta-BHC	78		66		30-150	17		30	A
Lindane	72		61		30-150	17		30	A
Alpha-BHC	74		62		30-150	18		30	A
Beta-BHC	80		63		30-150	24		30	A
Heptachlor	67		57		30-150	16		30	A
Aldrin	71		60		30-150	17		30	A
Heptachlor epoxide	68		57		30-150	18		30	A
Endrin	73		61		30-150	18		30	A
Endrin aldehyde	64		54		30-150	17		30	A
Endrin ketone	78		67		30-150	15		30	A
Dieldrin	76		64		30-150	17		30	A
4,4'-DDE	75		62		30-150	19		30	A
4,4'-DDD	80		67		30-150	18		30	A
4,4'-DDT	74		63		30-150	16		30	A
Endosulfan I	71		61		30-150	15		30	A
Endosulfan II	73		61		30-150	18		30	A
Endosulfan sulfate	71		60		30-150	17		30	A
Methoxychlor	73		63		30-150	15		30	A
cis-Chlordane	66		55		30-150	18		30	A
trans-Chlordane	81		68		30-150	17		30	A

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits

Organochlorine Pesticides by GC - Westborough Lab Associated sample(s): 01-05 Batch: WG1789658-2 WG1789658-3

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	63		53		30-150	A
Decachlorobiphenyl	79		69		30-150	A
2,4,5,6-Tetrachloro-m-xylene	67		57		30-150	B
Decachlorobiphenyl	89		75		30-150	B

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2332665
Report Date: 06/19/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits	Column
Organochlorine Pesticides by GC - Westborough Lab Associated sample(s): 06-07 Batch: WG1790949-2 WG1790949-3									
Delta-BHC	57		62		30-150	9		20	A
Lindane	55		60		30-150	8		20	A
Alpha-BHC	63		63		30-150	0		20	A
Beta-BHC	64		66		30-150	4		20	A
Heptachlor	59		63		30-150	5		20	A
Aldrin	57		61		30-150	7		20	A
Heptachlor epoxide	55		60		30-150	9		20	A
Endrin	55		62		30-150	12		20	A
Endrin aldehyde	54		61		30-150	12		20	A
Endrin ketone	60		68		30-150	13		20	A
Dieldrin	59		66		30-150	10		20	A
4,4'-DDE	54		60		30-150	9		20	A
4,4'-DDD	61		68		30-150	11		20	A
4,4'-DDT	66		73		30-150	10		20	A
Endosulfan I	56		62		30-150	11		20	A
Endosulfan II	57		65		30-150	13		20	A
Endosulfan sulfate	54		61		30-150	12		20	A
Methoxychlor	73		81		30-150	10		20	A
cis-Chlordane	59		65		30-150	10		20	A
trans-Chlordane	70		76		30-150	9		20	A

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2332665

Report Date: 06/19/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Organochlorine Pesticides by GC - Westborough Lab Associated sample(s): 06-07 Batch: WG1790949-2 WG1790949-3								

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	51		53		30-150	A
Decachlorobiphenyl	60		64		30-150	A
2,4,5,6-Tetrachloro-m-xylene	49		51		30-150	B
Decachlorobiphenyl	55		59		30-150	B

METALS

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-01 Date Collected: 06/09/23 07:35

Client ID: SB-44P (2-2.5) Date Received: 06/09/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Soil

Percent Solids: 93%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	5560		mg/kg	8.29	2.24	2	06/14/23 06:15	06/17/23 11:23	EPA 3050B	1,6010D	EJF
Antimony, Total	0.571	J	mg/kg	4.15	0.315	2	06/14/23 06:15	06/17/23 11:23	EPA 3050B	1,6010D	EJF
Arsenic, Total	0.784	J	mg/kg	0.829	0.172	2	06/14/23 06:15	06/17/23 11:23	EPA 3050B	1,6010D	EJF
Barium, Total	58.7		mg/kg	0.829	0.144	2	06/14/23 06:15	06/17/23 11:23	EPA 3050B	1,6010D	EJF
Beryllium, Total	0.298	J	mg/kg	0.415	0.027	2	06/14/23 06:15	06/17/23 11:23	EPA 3050B	1,6010D	EJF
Cadmium, Total	0.147	J	mg/kg	0.829	0.081	2	06/14/23 06:15	06/17/23 11:23	EPA 3050B	1,6010D	EJF
Calcium, Total	11300		mg/kg	8.29	2.90	2	06/14/23 06:15	06/17/23 11:23	EPA 3050B	1,6010D	EJF
Chromium, Total	14.7		mg/kg	0.829	0.080	2	06/14/23 06:15	06/17/23 11:23	EPA 3050B	1,6010D	EJF
Cobalt, Total	6.36		mg/kg	1.66	0.138	2	06/14/23 06:15	06/17/23 11:23	EPA 3050B	1,6010D	EJF
Copper, Total	18.6		mg/kg	0.829	0.214	2	06/14/23 06:15	06/17/23 11:23	EPA 3050B	1,6010D	EJF
Iron, Total	13200		mg/kg	4.15	0.749	2	06/14/23 06:15	06/17/23 11:23	EPA 3050B	1,6010D	EJF
Lead, Total	2.58	J	mg/kg	4.15	0.222	2	06/14/23 06:15	06/17/23 11:23	EPA 3050B	1,6010D	EJF
Magnesium, Total	8080		mg/kg	8.29	1.28	2	06/14/23 06:15	06/17/23 11:23	EPA 3050B	1,6010D	EJF
Manganese, Total	207		mg/kg	0.829	0.132	2	06/14/23 06:15	06/17/23 11:23	EPA 3050B	1,6010D	EJF
Mercury, Total	ND		mg/kg	0.068	0.044	1	06/14/23 07:15	06/15/23 20:35	EPA 7471B	1,7471B	GMG
Nickel, Total	11.0		mg/kg	2.07	0.201	2	06/14/23 06:15	06/17/23 11:23	EPA 3050B	1,6010D	EJF
Potassium, Total	1960		mg/kg	207	11.9	2	06/14/23 06:15	06/17/23 11:23	EPA 3050B	1,6010D	EJF
Selenium, Total	ND		mg/kg	1.66	0.214	2	06/14/23 06:15	06/17/23 11:23	EPA 3050B	1,6010D	EJF
Silver, Total	ND		mg/kg	0.415	0.235	2	06/14/23 06:15	06/17/23 11:23	EPA 3050B	1,6010D	EJF
Sodium, Total	494		mg/kg	166	2.61	2	06/14/23 06:15	06/17/23 11:23	EPA 3050B	1,6010D	EJF
Thallium, Total	ND		mg/kg	1.66	0.261	2	06/14/23 06:15	06/17/23 11:23	EPA 3050B	1,6010D	EJF
Vanadium, Total	22.1		mg/kg	0.829	0.168	2	06/14/23 06:15	06/17/23 11:23	EPA 3050B	1,6010D	EJF
Zinc, Total	22.9		mg/kg	4.15	0.243	2	06/14/23 06:15	06/17/23 11:23	EPA 3050B	1,6010D	EJF

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-02 Date Collected: 06/09/23 07:50

Client ID: SB-45P (4-4.5) Date Received: 06/09/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Soil

Percent Solids: 93%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	5440		mg/kg	8.37	2.26	2	06/14/23 06:15	06/17/23 11:26	EPA 3050B	1,6010D	EJF
Antimony, Total	0.818	J	mg/kg	4.18	0.318	2	06/14/23 06:15	06/17/23 11:26	EPA 3050B	1,6010D	EJF
Arsenic, Total	1.04		mg/kg	0.837	0.174	2	06/14/23 06:15	06/17/23 11:26	EPA 3050B	1,6010D	EJF
Barium, Total	49.6		mg/kg	0.837	0.146	2	06/14/23 06:15	06/17/23 11:26	EPA 3050B	1,6010D	EJF
Beryllium, Total	0.285	J	mg/kg	0.418	0.028	2	06/14/23 06:15	06/17/23 11:26	EPA 3050B	1,6010D	EJF
Cadmium, Total	0.148	J	mg/kg	0.837	0.082	2	06/14/23 06:15	06/17/23 11:26	EPA 3050B	1,6010D	EJF
Calcium, Total	4990		mg/kg	8.37	2.93	2	06/14/23 06:15	06/17/23 11:26	EPA 3050B	1,6010D	EJF
Chromium, Total	15.6		mg/kg	0.837	0.080	2	06/14/23 06:15	06/17/23 11:26	EPA 3050B	1,6010D	EJF
Cobalt, Total	4.98		mg/kg	1.67	0.139	2	06/14/23 06:15	06/17/23 11:26	EPA 3050B	1,6010D	EJF
Copper, Total	16.2		mg/kg	0.837	0.216	2	06/14/23 06:15	06/17/23 11:26	EPA 3050B	1,6010D	EJF
Iron, Total	12300		mg/kg	4.18	0.756	2	06/14/23 06:15	06/17/23 11:26	EPA 3050B	1,6010D	EJF
Lead, Total	10.2		mg/kg	4.18	0.224	2	06/14/23 06:15	06/17/23 11:26	EPA 3050B	1,6010D	EJF
Magnesium, Total	4340		mg/kg	8.37	1.29	2	06/14/23 06:15	06/17/23 11:26	EPA 3050B	1,6010D	EJF
Manganese, Total	182		mg/kg	0.837	0.133	2	06/14/23 06:15	06/17/23 11:26	EPA 3050B	1,6010D	EJF
Mercury, Total	ND		mg/kg	0.068	0.044	1	06/14/23 07:15	06/15/23 20:38	EPA 7471B	1,7471B	GMG
Nickel, Total	9.79		mg/kg	2.09	0.202	2	06/14/23 06:15	06/17/23 11:26	EPA 3050B	1,6010D	EJF
Potassium, Total	1590		mg/kg	209	12.0	2	06/14/23 06:15	06/17/23 11:26	EPA 3050B	1,6010D	EJF
Selenium, Total	ND		mg/kg	1.67	0.216	2	06/14/23 06:15	06/17/23 11:26	EPA 3050B	1,6010D	EJF
Silver, Total	0.257	J	mg/kg	0.418	0.237	2	06/14/23 06:15	06/17/23 11:26	EPA 3050B	1,6010D	EJF
Sodium, Total	242		mg/kg	167	2.64	2	06/14/23 06:15	06/17/23 11:26	EPA 3050B	1,6010D	EJF
Thallium, Total	ND		mg/kg	1.67	0.264	2	06/14/23 06:15	06/17/23 11:26	EPA 3050B	1,6010D	EJF
Vanadium, Total	19.8		mg/kg	0.837	0.170	2	06/14/23 06:15	06/17/23 11:26	EPA 3050B	1,6010D	EJF
Zinc, Total	26.3		mg/kg	4.18	0.245	2	06/14/23 06:15	06/17/23 11:26	EPA 3050B	1,6010D	EJF

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-03 Date Collected: 06/09/23 11:30

Client ID: SB-46P (4.5-5) Date Received: 06/09/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Soil

Percent Solids: 92%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	5330		mg/kg	8.45	2.28	2	06/14/23 06:15	06/17/23 11:28	EPA 3050B	1,6010D	EJF
Antimony, Total	ND		mg/kg	4.23	0.321	2	06/14/23 06:15	06/17/23 11:28	EPA 3050B	1,6010D	EJF
Arsenic, Total	1.11		mg/kg	0.845	0.176	2	06/14/23 06:15	06/17/23 11:28	EPA 3050B	1,6010D	EJF
Barium, Total	55.7		mg/kg	0.845	0.147	2	06/14/23 06:15	06/17/23 11:28	EPA 3050B	1,6010D	EJF
Beryllium, Total	0.265	J	mg/kg	0.423	0.028	2	06/14/23 06:15	06/17/23 11:28	EPA 3050B	1,6010D	EJF
Cadmium, Total	0.132	J	mg/kg	0.845	0.083	2	06/14/23 06:15	06/17/23 11:28	EPA 3050B	1,6010D	EJF
Calcium, Total	11600		mg/kg	8.45	2.96	2	06/14/23 06:15	06/17/23 11:28	EPA 3050B	1,6010D	EJF
Chromium, Total	13.3		mg/kg	0.845	0.081	2	06/14/23 06:15	06/17/23 11:28	EPA 3050B	1,6010D	EJF
Cobalt, Total	4.80		mg/kg	1.69	0.140	2	06/14/23 06:15	06/17/23 11:28	EPA 3050B	1,6010D	EJF
Copper, Total	16.2		mg/kg	0.845	0.218	2	06/14/23 06:15	06/17/23 11:28	EPA 3050B	1,6010D	EJF
Iron, Total	11700		mg/kg	4.23	0.763	2	06/14/23 06:15	06/17/23 11:28	EPA 3050B	1,6010D	EJF
Lead, Total	15.4		mg/kg	4.23	0.226	2	06/14/23 06:15	06/17/23 11:28	EPA 3050B	1,6010D	EJF
Magnesium, Total	6580		mg/kg	8.45	1.30	2	06/14/23 06:15	06/17/23 11:28	EPA 3050B	1,6010D	EJF
Manganese, Total	129		mg/kg	0.845	0.134	2	06/14/23 06:15	06/17/23 11:28	EPA 3050B	1,6010D	EJF
Mercury, Total	0.081		mg/kg	0.069	0.045	1	06/14/23 07:15	06/15/23 20:42	EPA 7471B	1,7471B	GMG
Nickel, Total	9.20		mg/kg	2.11	0.204	2	06/14/23 06:15	06/17/23 11:28	EPA 3050B	1,6010D	EJF
Potassium, Total	1740		mg/kg	211	12.2	2	06/14/23 06:15	06/17/23 11:28	EPA 3050B	1,6010D	EJF
Selenium, Total	ND		mg/kg	1.69	0.218	2	06/14/23 06:15	06/17/23 11:28	EPA 3050B	1,6010D	EJF
Silver, Total	ND		mg/kg	0.423	0.239	2	06/14/23 06:15	06/17/23 11:28	EPA 3050B	1,6010D	EJF
Sodium, Total	195		mg/kg	169	2.66	2	06/14/23 06:15	06/17/23 11:28	EPA 3050B	1,6010D	EJF
Thallium, Total	ND		mg/kg	1.69	0.266	2	06/14/23 06:15	06/17/23 11:28	EPA 3050B	1,6010D	EJF
Vanadium, Total	20.0		mg/kg	0.845	0.172	2	06/14/23 06:15	06/17/23 11:28	EPA 3050B	1,6010D	EJF
Zinc, Total	26.9		mg/kg	4.23	0.248	2	06/14/23 06:15	06/17/23 11:28	EPA 3050B	1,6010D	EJF

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-04 Date Collected: 06/09/23 12:40

Client ID: SB-47P (3-3.5) Date Received: 06/09/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Soil

Percent Solids: 86%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	12700		mg/kg	8.91	2.41	2	06/14/23 06:15	06/17/23 11:31	EPA 3050B	1,6010D	EJF
Antimony, Total	0.557	J	mg/kg	4.46	0.339	2	06/14/23 06:15	06/17/23 11:31	EPA 3050B	1,6010D	EJF
Arsenic, Total	2.21		mg/kg	0.891	0.185	2	06/14/23 06:15	06/17/23 11:31	EPA 3050B	1,6010D	EJF
Barium, Total	75.5		mg/kg	0.891	0.155	2	06/14/23 06:15	06/17/23 11:31	EPA 3050B	1,6010D	EJF
Beryllium, Total	0.466		mg/kg	0.446	0.029	2	06/14/23 06:15	06/17/23 11:31	EPA 3050B	1,6010D	EJF
Cadmium, Total	0.155	J	mg/kg	0.891	0.087	2	06/14/23 06:15	06/17/23 11:31	EPA 3050B	1,6010D	EJF
Calcium, Total	3150		mg/kg	8.91	3.12	2	06/14/23 06:15	06/17/23 11:31	EPA 3050B	1,6010D	EJF
Chromium, Total	19.3		mg/kg	0.891	0.086	2	06/14/23 06:15	06/17/23 11:31	EPA 3050B	1,6010D	EJF
Cobalt, Total	6.35		mg/kg	1.78	0.148	2	06/14/23 06:15	06/17/23 11:31	EPA 3050B	1,6010D	EJF
Copper, Total	19.1		mg/kg	0.891	0.230	2	06/14/23 06:15	06/17/23 11:31	EPA 3050B	1,6010D	EJF
Iron, Total	16000		mg/kg	4.46	0.805	2	06/14/23 06:15	06/17/23 11:31	EPA 3050B	1,6010D	EJF
Lead, Total	32.3		mg/kg	4.46	0.239	2	06/14/23 06:15	06/17/23 11:31	EPA 3050B	1,6010D	EJF
Magnesium, Total	3970		mg/kg	8.91	1.37	2	06/14/23 06:15	06/17/23 11:31	EPA 3050B	1,6010D	EJF
Manganese, Total	215		mg/kg	0.891	0.142	2	06/14/23 06:15	06/17/23 11:31	EPA 3050B	1,6010D	EJF
Mercury, Total	0.120		mg/kg	0.074	0.048	1	06/14/23 07:15	06/15/23 20:52	EPA 7471B	1,7471B	GMG
Nickel, Total	14.4		mg/kg	2.23	0.216	2	06/14/23 06:15	06/17/23 11:31	EPA 3050B	1,6010D	EJF
Potassium, Total	2410		mg/kg	223	12.8	2	06/14/23 06:15	06/17/23 11:31	EPA 3050B	1,6010D	EJF
Selenium, Total	ND		mg/kg	1.78	0.230	2	06/14/23 06:15	06/17/23 11:31	EPA 3050B	1,6010D	EJF
Silver, Total	ND		mg/kg	0.446	0.252	2	06/14/23 06:15	06/17/23 11:31	EPA 3050B	1,6010D	EJF
Sodium, Total	340		mg/kg	178	2.81	2	06/14/23 06:15	06/17/23 11:31	EPA 3050B	1,6010D	EJF
Thallium, Total	ND		mg/kg	1.78	0.281	2	06/14/23 06:15	06/17/23 11:31	EPA 3050B	1,6010D	EJF
Vanadium, Total	28.5		mg/kg	0.891	0.181	2	06/14/23 06:15	06/17/23 11:31	EPA 3050B	1,6010D	EJF
Zinc, Total	39.3		mg/kg	4.46	0.261	2	06/14/23 06:15	06/17/23 11:31	EPA 3050B	1,6010D	EJF

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-05 Date Collected: 06/09/23 12:55

Client ID: SB-48P (3.5-4) Date Received: 06/09/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Soil

Percent Solids: 84%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	6810		mg/kg	9.00	2.43	2	06/14/23 06:15	06/17/23 11:34	EPA 3050B	1,6010D	EJF
Antimony, Total	3.27	J	mg/kg	4.50	0.342	2	06/14/23 06:15	06/17/23 11:34	EPA 3050B	1,6010D	EJF
Arsenic, Total	5.88		mg/kg	0.900	0.187	2	06/14/23 06:15	06/17/23 11:34	EPA 3050B	1,6010D	EJF
Barium, Total	134		mg/kg	0.900	0.156	2	06/14/23 06:15	06/17/23 11:34	EPA 3050B	1,6010D	EJF
Beryllium, Total	0.346	J	mg/kg	0.450	0.030	2	06/14/23 06:15	06/17/23 11:34	EPA 3050B	1,6010D	EJF
Cadmium, Total	1.51		mg/kg	0.900	0.088	2	06/14/23 06:15	06/17/23 11:34	EPA 3050B	1,6010D	EJF
Calcium, Total	15300		mg/kg	9.00	3.15	2	06/14/23 06:15	06/17/23 11:34	EPA 3050B	1,6010D	EJF
Chromium, Total	14.2		mg/kg	0.900	0.086	2	06/14/23 06:15	06/17/23 11:34	EPA 3050B	1,6010D	EJF
Cobalt, Total	5.25		mg/kg	1.80	0.149	2	06/14/23 06:15	06/17/23 11:34	EPA 3050B	1,6010D	EJF
Copper, Total	90.7		mg/kg	0.900	0.232	2	06/14/23 06:15	06/17/23 11:34	EPA 3050B	1,6010D	EJF
Iron, Total	14000		mg/kg	4.50	0.812	2	06/14/23 06:15	06/17/23 11:34	EPA 3050B	1,6010D	EJF
Lead, Total	317		mg/kg	4.50	0.241	2	06/14/23 06:15	06/17/23 11:34	EPA 3050B	1,6010D	EJF
Magnesium, Total	4030		mg/kg	9.00	1.38	2	06/14/23 06:15	06/17/23 11:34	EPA 3050B	1,6010D	EJF
Manganese, Total	167		mg/kg	0.900	0.143	2	06/14/23 06:15	06/17/23 11:34	EPA 3050B	1,6010D	EJF
Mercury, Total	0.408		mg/kg	0.075	0.049	1	06/14/23 07:15	06/15/23 20:55	EPA 7471B	1,7471B	GMG
Nickel, Total	15.4		mg/kg	2.25	0.218	2	06/14/23 06:15	06/17/23 11:34	EPA 3050B	1,6010D	EJF
Potassium, Total	1280		mg/kg	225	13.0	2	06/14/23 06:15	06/17/23 11:34	EPA 3050B	1,6010D	EJF
Selenium, Total	0.478	J	mg/kg	1.80	0.232	2	06/14/23 06:15	06/17/23 11:34	EPA 3050B	1,6010D	EJF
Silver, Total	ND		mg/kg	0.450	0.254	2	06/14/23 06:15	06/17/23 11:34	EPA 3050B	1,6010D	EJF
Sodium, Total	195		mg/kg	180	2.83	2	06/14/23 06:15	06/17/23 11:34	EPA 3050B	1,6010D	EJF
Thallium, Total	ND		mg/kg	1.80	0.283	2	06/14/23 06:15	06/17/23 11:34	EPA 3050B	1,6010D	EJF
Vanadium, Total	26.0		mg/kg	0.900	0.183	2	06/14/23 06:15	06/17/23 11:34	EPA 3050B	1,6010D	EJF
Zinc, Total	567		mg/kg	4.50	0.264	2	06/14/23 06:15	06/17/23 11:34	EPA 3050B	1,6010D	EJF

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-06 Date Collected: 06/09/23 13:10

Client ID: GW-16 Date Received: 06/09/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Water

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	27.7		mg/l	0.0100	0.00327	1	06/14/23 03:00	06/18/23 16:41	EPA 3005A	1,6020B	WKP
Antimony, Total	ND		mg/l	0.00400	0.00042	1	06/14/23 03:00	06/18/23 16:41	EPA 3005A	1,6020B	WKP
Arsenic, Total	0.00223		mg/l	0.00050	0.00016	1	06/14/23 03:00	06/18/23 16:41	EPA 3005A	1,6020B	WKP
Barium, Total	0.6646		mg/l	0.00050	0.00017	1	06/14/23 03:00	06/18/23 16:41	EPA 3005A	1,6020B	WKP
Beryllium, Total	0.00067		mg/l	0.00050	0.00010	1	06/14/23 03:00	06/18/23 16:41	EPA 3005A	1,6020B	WKP
Cadmium, Total	0.00056		mg/l	0.00020	0.00005	1	06/14/23 03:00	06/18/23 16:41	EPA 3005A	1,6020B	WKP
Calcium, Total	207.		mg/l	0.100	0.0394	1	06/14/23 03:00	06/18/23 16:41	EPA 3005A	1,6020B	WKP
Chromium, Total	0.05769		mg/l	0.00100	0.00017	1	06/14/23 03:00	06/18/23 16:41	EPA 3005A	1,6020B	WKP
Cobalt, Total	0.04913		mg/l	0.00050	0.00016	1	06/14/23 03:00	06/18/23 16:41	EPA 3005A	1,6020B	WKP
Copper, Total	0.1515		mg/l	0.00100	0.00038	1	06/14/23 03:00	06/18/23 16:41	EPA 3005A	1,6020B	WKP
Iron, Total	46.5		mg/l	0.0500	0.0191	1	06/14/23 03:00	06/18/23 16:41	EPA 3005A	1,6020B	WKP
Lead, Total	0.05190		mg/l	0.00100	0.00034	1	06/14/23 03:00	06/18/23 16:41	EPA 3005A	1,6020B	WKP
Magnesium, Total	127.		mg/l	0.0700	0.0242	1	06/14/23 03:00	06/18/23 16:41	EPA 3005A	1,6020B	WKP
Manganese, Total	1.926		mg/l	0.00100	0.00044	1	06/14/23 03:00	06/18/23 16:41	EPA 3005A	1,6020B	WKP
Mercury, Total	ND		mg/l	0.00020	0.00009	1	06/14/23 03:45	06/15/23 12:39	EPA 7470A	1,7470A	DMB
Nickel, Total	0.07378		mg/l	0.00200	0.00055	1	06/14/23 03:00	06/18/23 16:41	EPA 3005A	1,6020B	WKP
Potassium, Total	20.2		mg/l	0.100	0.0309	1	06/14/23 03:00	06/18/23 16:41	EPA 3005A	1,6020B	WKP
Selenium, Total	0.0340		mg/l	0.00500	0.00173	1	06/14/23 03:00	06/18/23 16:41	EPA 3005A	1,6020B	WKP
Silver, Total	0.00032	J	mg/l	0.00040	0.00016	1	06/14/23 03:00	06/18/23 16:41	EPA 3005A	1,6020B	WKP
Sodium, Total	610.		mg/l	1.00	0.293	10	06/14/23 03:00	06/18/23 18:54	EPA 3005A	1,6020B	WKP
Thallium, Total	0.00059	J	mg/l	0.00100	0.00014	1	06/14/23 03:00	06/18/23 16:41	EPA 3005A	1,6020B	WKP
Vanadium, Total	0.05386		mg/l	0.00500	0.00157	1	06/14/23 03:00	06/18/23 16:41	EPA 3005A	1,6020B	WKP
Zinc, Total	0.1998		mg/l	0.01000	0.00341	1	06/14/23 03:00	06/18/23 16:41	EPA 3005A	1,6020B	WKP

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-07 Date Collected: 06/09/23 12:10

Client ID: GW-17 Date Received: 06/09/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Water

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	48.0		mg/l	0.0100	0.00327	1	06/14/23 03:00	06/18/23 16:46	EPA 3005A	1,6020B	WKP
Antimony, Total	ND		mg/l	0.00400	0.00042	1	06/14/23 03:00	06/18/23 16:46	EPA 3005A	1,6020B	WKP
Arsenic, Total	0.00322		mg/l	0.00050	0.00016	1	06/14/23 03:00	06/18/23 16:46	EPA 3005A	1,6020B	WKP
Barium, Total	2.032		mg/l	0.00050	0.00017	1	06/14/23 03:00	06/18/23 16:46	EPA 3005A	1,6020B	WKP
Beryllium, Total	0.00151		mg/l	0.00050	0.00010	1	06/14/23 03:00	06/18/23 16:46	EPA 3005A	1,6020B	WKP
Cadmium, Total	0.00139		mg/l	0.00020	0.00005	1	06/14/23 03:00	06/18/23 16:46	EPA 3005A	1,6020B	WKP
Calcium, Total	400.		mg/l	0.100	0.0394	1	06/14/23 03:00	06/18/23 16:46	EPA 3005A	1,6020B	WKP
Chromium, Total	0.1168		mg/l	0.00100	0.00017	1	06/14/23 03:00	06/18/23 16:46	EPA 3005A	1,6020B	WKP
Cobalt, Total	0.1324		mg/l	0.00500	0.00163	10	06/14/23 03:00	06/18/23 18:59	EPA 3005A	1,6020B	WKP
Copper, Total	0.2002		mg/l	0.00100	0.00038	1	06/14/23 03:00	06/18/23 16:46	EPA 3005A	1,6020B	WKP
Iron, Total	78.4		mg/l	0.0500	0.0191	1	06/14/23 03:00	06/18/23 16:46	EPA 3005A	1,6020B	WKP
Lead, Total	0.08037		mg/l	0.00100	0.00034	1	06/14/23 03:00	06/18/23 16:46	EPA 3005A	1,6020B	WKP
Magnesium, Total	265.		mg/l	0.0700	0.0242	1	06/14/23 03:00	06/18/23 16:46	EPA 3005A	1,6020B	WKP
Manganese, Total	4.566		mg/l	0.00100	0.00044	1	06/14/23 03:00	06/18/23 16:46	EPA 3005A	1,6020B	WKP
Mercury, Total	ND		mg/l	0.00020	0.00009	1	06/14/23 03:45	06/15/23 12:50	EPA 7470A	1,7470A	DMB
Nickel, Total	0.1302		mg/l	0.00200	0.00055	1	06/14/23 03:00	06/18/23 16:46	EPA 3005A	1,6020B	WKP
Potassium, Total	26.7		mg/l	0.100	0.0309	1	06/14/23 03:00	06/18/23 16:46	EPA 3005A	1,6020B	WKP
Selenium, Total	0.104		mg/l	0.0500	0.0173	10	06/14/23 03:00	06/18/23 18:59	EPA 3005A	1,6020B	WKP
Silver, Total	0.00135		mg/l	0.00040	0.00016	1	06/14/23 03:00	06/18/23 16:46	EPA 3005A	1,6020B	WKP
Sodium, Total	1770		mg/l	1.00	0.293	10	06/14/23 03:00	06/18/23 18:59	EPA 3005A	1,6020B	WKP
Thallium, Total	0.00142		mg/l	0.00100	0.00014	1	06/14/23 03:00	06/18/23 16:46	EPA 3005A	1,6020B	WKP
Vanadium, Total	0.04351		mg/l	0.00500	0.00157	1	06/14/23 03:00	06/18/23 16:46	EPA 3005A	1,6020B	WKP
Zinc, Total	0.2749		mg/l	0.01000	0.00341	1	06/14/23 03:00	06/18/23 16:46	EPA 3005A	1,6020B	WKP

Project Name: 100 MAIN ST. **Lab Number:** L2332665

Project Number: 12461 **Report Date:** 06/19/23

Method Blank Analysis
Batch Quality Control

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
Total Metals - Mansfield Lab for sample(s): 01-05 Batch: WG1789741-1										
Aluminum, Total	ND		mg/kg	4.00	1.08	1	06/14/23 06:15	06/16/23 09:30	1,6010D	JMF
Antimony, Total	ND		mg/kg	2.00	0.152	1	06/14/23 06:15	06/16/23 09:30	1,6010D	JMF
Arsenic, Total	ND		mg/kg	0.400	0.083	1	06/14/23 06:15	06/16/23 09:30	1,6010D	JMF
Barium, Total	ND		mg/kg	0.400	0.070	1	06/14/23 06:15	06/16/23 09:30	1,6010D	JMF
Beryllium, Total	ND		mg/kg	0.200	0.013	1	06/14/23 06:15	06/16/23 09:30	1,6010D	JMF
Cadmium, Total	ND		mg/kg	0.400	0.039	1	06/14/23 06:15	06/16/23 09:30	1,6010D	JMF
Calcium, Total	4.40		mg/kg	4.00	1.40	1	06/14/23 06:15	06/16/23 09:30	1,6010D	JMF
Chromium, Total	ND		mg/kg	0.400	0.038	1	06/14/23 06:15	06/16/23 09:30	1,6010D	JMF
Cobalt, Total	ND		mg/kg	0.800	0.066	1	06/14/23 06:15	06/16/23 09:30	1,6010D	JMF
Copper, Total	ND		mg/kg	0.400	0.103	1	06/14/23 06:15	06/16/23 09:30	1,6010D	JMF
Iron, Total	3.82		mg/kg	2.00	0.361	1	06/14/23 06:15	06/16/23 09:30	1,6010D	JMF
Lead, Total	ND		mg/kg	2.00	0.107	1	06/14/23 06:15	06/16/23 09:30	1,6010D	JMF
Magnesium, Total	2.39	J	mg/kg	4.00	0.616	1	06/14/23 06:15	06/16/23 09:30	1,6010D	JMF
Manganese, Total	ND		mg/kg	0.400	0.064	1	06/14/23 06:15	06/16/23 09:30	1,6010D	JMF
Nickel, Total	ND		mg/kg	1.00	0.097	1	06/14/23 06:15	06/16/23 09:30	1,6010D	JMF
Potassium, Total	ND		mg/kg	100	5.76	1	06/14/23 06:15	06/16/23 09:30	1,6010D	JMF
Selenium, Total	ND		mg/kg	0.800	0.103	1	06/14/23 06:15	06/16/23 09:30	1,6010D	JMF
Silver, Total	ND		mg/kg	0.200	0.113	1	06/14/23 06:15	06/16/23 09:30	1,6010D	JMF
Sodium, Total	ND		mg/kg	80.0	1.26	1	06/14/23 06:15	06/16/23 09:30	1,6010D	JMF
Thallium, Total	ND		mg/kg	0.800	0.126	1	06/14/23 06:15	06/16/23 09:30	1,6010D	JMF
Vanadium, Total	ND		mg/kg	0.400	0.081	1	06/14/23 06:15	06/16/23 09:30	1,6010D	JMF
Zinc, Total	ND		mg/kg	2.00	0.117	1	06/14/23 06:15	06/16/23 09:30	1,6010D	JMF

Prep Information

Digestion Method: EPA 3050B

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
Total Metals - Mansfield Lab for sample(s): 01-05 Batch: WG1789742-1										
Mercury, Total	ND		mg/kg	0.083	0.054	1	06/14/23 07:15	06/15/23 14:51	1,7471B	GMG

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

Method Blank Analysis
Batch Quality Control

Prep Information

Digestion Method: EPA 7471B

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
Total Metals - Mansfield Lab for sample(s): 06-07 Batch: WG1790325-1										
Aluminum, Total	0.00434	J	mg/l	0.0100	0.00327	1	06/14/23 03:00	06/18/23 15:23	1,6020B	WKP
Antimony, Total	ND		mg/l	0.00400	0.00042	1	06/14/23 03:00	06/18/23 15:23	1,6020B	WKP
Arsenic, Total	ND		mg/l	0.00050	0.00016	1	06/14/23 03:00	06/18/23 15:23	1,6020B	WKP
Barium, Total	ND		mg/l	0.00050	0.00017	1	06/14/23 03:00	06/18/23 15:23	1,6020B	WKP
Beryllium, Total	ND		mg/l	0.00050	0.00010	1	06/14/23 03:00	06/18/23 15:23	1,6020B	WKP
Cadmium, Total	ND		mg/l	0.00020	0.00005	1	06/14/23 03:00	06/18/23 15:23	1,6020B	WKP
Calcium, Total	ND		mg/l	0.100	0.0394	1	06/14/23 03:00	06/18/23 15:23	1,6020B	WKP
Chromium, Total	ND		mg/l	0.00100	0.00017	1	06/14/23 03:00	06/18/23 15:23	1,6020B	WKP
Cobalt, Total	ND		mg/l	0.00050	0.00016	1	06/14/23 03:00	06/18/23 15:23	1,6020B	WKP
Copper, Total	ND		mg/l	0.00100	0.00038	1	06/14/23 03:00	06/18/23 15:23	1,6020B	WKP
Iron, Total	ND		mg/l	0.0500	0.0191	1	06/14/23 03:00	06/18/23 15:23	1,6020B	WKP
Lead, Total	ND		mg/l	0.00100	0.00034	1	06/14/23 03:00	06/18/23 15:23	1,6020B	WKP
Magnesium, Total	ND		mg/l	0.0700	0.0242	1	06/14/23 03:00	06/18/23 15:23	1,6020B	WKP
Manganese, Total	ND		mg/l	0.00100	0.00044	1	06/14/23 03:00	06/18/23 15:23	1,6020B	WKP
Nickel, Total	ND		mg/l	0.00200	0.00055	1	06/14/23 03:00	06/18/23 15:23	1,6020B	WKP
Potassium, Total	ND		mg/l	0.100	0.0309	1	06/14/23 03:00	06/18/23 15:23	1,6020B	WKP
Selenium, Total	ND		mg/l	0.00500	0.00173	1	06/14/23 03:00	06/18/23 15:23	1,6020B	WKP
Silver, Total	ND		mg/l	0.00040	0.00016	1	06/14/23 03:00	06/18/23 15:23	1,6020B	WKP
Sodium, Total	ND		mg/l	0.100	0.0293	1	06/14/23 03:00	06/18/23 15:23	1,6020B	WKP
Thallium, Total	ND		mg/l	0.00100	0.00014	1	06/14/23 03:00	06/18/23 15:23	1,6020B	WKP
Vanadium, Total	ND		mg/l	0.00500	0.00157	1	06/14/23 03:00	06/18/23 15:23	1,6020B	WKP
Zinc, Total	ND		mg/l	0.01000	0.00341	1	06/14/23 03:00	06/18/23 15:23	1,6020B	WKP

Prep Information

Digestion Method: EPA 3005A

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

Method Blank Analysis
Batch Quality Control

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
Total Metals - Mansfield Lab for sample(s): 06-07 Batch: WG1790326-1										
Mercury, Total	ND		mg/l	0.00020	0.00009	1	06/14/23 03:45	06/15/23 12:09	1,7470A	DMB

Prep Information

Digestion Method: EPA 7470A

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2332665

Report Date: 06/19/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-05 Batch: WG1789741-2 SRM Lot Number: D119-540								
Aluminum, Total	74		-		48-152	-		
Antimony, Total	122		-		10-190	-		
Arsenic, Total	95		-		83-117	-		
Barium, Total	96		-		82-118	-		
Beryllium, Total	95		-		83-117	-		
Cadmium, Total	96		-		82-117	-		
Calcium, Total	93		-		81-118	-		
Chromium, Total	97		-		82-119	-		
Cobalt, Total	95		-		83-117	-		
Copper, Total	93		-		84-116	-		
Iron, Total	91		-		60-140	-		
Lead, Total	94		-		82-118	-		
Magnesium, Total	84		-		76-124	-		
Manganese, Total	96		-		82-118	-		
Nickel, Total	95		-		82-117	-		
Potassium, Total	87		-		70-130	-		
Selenium, Total	98		-		79-121	-		
Silver, Total	93		-		80-120	-		
Sodium, Total	97		-		74-126	-		
Thallium, Total	100		-		81-119	-		
Vanadium, Total	95		-		79-121	-		

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2332665

Report Date: 06/19/23

Parameter	LCS %Recovery	LCSD %Recovery	%Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-05 Batch: WG1789741-2 SRM Lot Number: D119-540					
Zinc, Total	91	-	80-120	-	
Total Metals - Mansfield Lab Associated sample(s): 01-05 Batch: WG1789742-2 SRM Lot Number: D119-540					
Mercury, Total	98	-	73-127	-	

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2332665

Report Date: 06/19/23

Parameter	LCS %Recovery	LCSD %Recovery	%Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 06-07 Batch: WG1790325-2					
Aluminum, Total	114	-	80-120	-	
Antimony, Total	96	-	80-120	-	
Arsenic, Total	103	-	80-120	-	
Barium, Total	96	-	80-120	-	
Beryllium, Total	103	-	80-120	-	
Cadmium, Total	93	-	80-120	-	
Calcium, Total	90	-	80-120	-	
Chromium, Total	106	-	80-120	-	
Cobalt, Total	110	-	80-120	-	
Copper, Total	104	-	80-120	-	
Iron, Total	119	-	80-120	-	
Lead, Total	104	-	80-120	-	
Magnesium, Total	94	-	80-120	-	
Manganese, Total	115	-	80-120	-	
Nickel, Total	108	-	80-120	-	
Potassium, Total	114	-	80-120	-	
Selenium, Total	102	-	80-120	-	
Silver, Total	90	-	80-120	-	
Sodium, Total	98	-	80-120	-	
Thallium, Total	100	-	80-120	-	
Vanadium, Total	116	-	80-120	-	

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2332665

Report Date: 06/19/23

Parameter	LCS %Recovery	LCSD %Recovery	%Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 06-07 Batch: WG1790325-2					
Zinc, Total	103	-	80-120	-	
Total Metals - Mansfield Lab Associated sample(s): 06-07 Batch: WG1790326-2					
Mercury, Total	94	-	80-120	-	

Matrix Spike Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2332665
Report Date: 06/19/23

Parameter	Native Sample	MS Added	MS Found	MS %Recovery	Qual	MSD Found	MSD %Recovery	Qual	Recovery Limits	RPD	Qual	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-05 QC Batch ID: WG1789741-3 WG1789741-4 QC Sample: L2332644-06 Client ID: MS Sample												
Aluminum, Total	4120	175	4230	**63**	Q	4370	**143**	Q	75-125	3		20
Antimony, Total	9.88	43.9	52.1	96		52.4	97		75-125	1		20
Arsenic, Total	102	10.5	132	**285**	Q	136	**324**	Q	75-125	3		20
Barium, Total	1140	175	1030	**0**	Q	359	**0**	Q	75-125	**97**	Q	20
Beryllium, Total	0.456	4.39	5.15	107		5.08	106		75-125	1		20
Cadmium, Total	2.34	4.65	6.83	96		6.61	92		75-125	3		20
Calcium, Total	20200	877	32600	**1410**	Q	21200	114		75-125	**42**	Q	20
Chromium, Total	18.2	17.5	36.6	105		36.5	105		75-125	0		20
Cobalt, Total	8.81	43.9	52.3	99		52.4	100		75-125	0		20
Copper, Total	308	21.9	183	**0**	Q	221	**0**	Q	75-125	19		20
Iron, Total	141000	87.7	152000	**12500**	Q	170000	**33200**	Q	75-125	11		20
Lead, Total	299	46.5	344	97		341	91		75-125	1		20
Magnesium, Total	2480	877	3450	110		3190	81		75-125	8		20
Manganese, Total	646	43.9	679	75		776	**298**	Q	75-125	13		20
Nickel, Total	30.2	43.9	77.2	107		73.2	98		75-125	5		20
Potassium, Total	405	877	1470	121		1450	120		75-125	1		20
Selenium, Total	5.02	10.5	19.2	**135**	Q	18.4	**128**	Q	75-125	4		20
Silver, Total	ND	4.39	3.77J	**0**	Q	3.27J	**0**	Q	75-125	NC		20
Sodium, Total	119J	877	1200	**137**	Q	1200	**137**	Q	75-125	0		20
Thallium, Total	2.08	10.5	13.2	106		13.6	110		75-125	3		20
Vanadium, Total	40.1	43.9	90.4	115		87.2	108		75-125	4		20

Matrix Spike Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2332665
Report Date: 06/19/23

Parameter	Native Sample	MS Added	MS Found	MS %Recovery		MSD Found	MSD %Recovery		Recovery Limits	RPD		RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-05 QC Batch ID: WG1789741-3 WG1789741-4 QC Sample: L2332644-06 Client ID: MS Sample												
Zinc, Total	1480	43.9	1500	**46**	Q	483	**0**	Q	75-125	**103**	Q	20
Total Metals - Mansfield Lab Associated sample(s): 01-05 QC Batch ID: WG1789742-3 WG1789742-4 QC Sample: L2332644-06 Client ID: MS Sample												
Mercury, Total	0.190	1.45	1.67	102		1.74	107		80-120	4		20

Matrix Spike Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2332665
Report Date: 06/19/23

Parameter	Native Sample	MS Added	MS Found	MS %Recovery		MSD Found	MSD %Recovery	Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 06-07 QC Batch ID: WG1790325-3 QC Sample: L2330783-01 Client ID: MS Sample										
Aluminum, Total	0.00514J	2	2.19	110		-	-	75-125	-	20
Antimony, Total	ND	0.5	0.4573	91		-	-	75-125	-	20
Arsenic, Total	0.00454	0.12	0.1290	104		-	-	75-125	-	20
Barium, Total	0.08585	2	1.958	94		-	-	75-125	-	20
Beryllium, Total	ND	0.05	0.04704	94		-	-	75-125	-	20
Cadmium, Total	ND	0.053	0.04949	93		-	-	75-125	-	20
Calcium, Total	620.	10	615	**0**	Q	-	-	75-125	-	20
Chromium, Total	ND	0.2	0.1956	98		-	-	75-125	-	20
Cobalt, Total	0.00341	0.5	0.4994	99		-	-	75-125	-	20
Copper, Total	ND	0.25	0.2435	97		-	-	75-125	-	20
Iron, Total	108.	1	105	**0**	Q	-	-	75-125	-	20
Lead, Total	ND	0.53	0.5625	106		-	-	75-125	-	20
Magnesium, Total	36.6	10	59.5	**229**	Q	-	-	75-125	-	20
Manganese, Total	3.420	0.5	3.993	115		-	-	75-125	-	20
Nickel, Total	0.02589	0.5	0.5248	100		-	-	75-125	-	20
Potassium, Total	16.6	10	27.4	108		-	-	75-125	-	20
Selenium, Total	ND	0.12	0.130	108		-	-	75-125	-	20
Silver, Total	ND	0.05	0.04396	88		-	-	75-125	-	20
Sodium, Total	14.9	10	29.9	**150**	Q	-	-	75-125	-	20
Thallium, Total	ND	0.12	0.1199	100		-	-	75-125	-	20
Vanadium, Total	ND	0.5	0.5052	101		-	-	75-125	-	20

Matrix Spike Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2332665
Report Date: 06/19/23

Parameter	Native Sample	MS Added	MS Found	MS %Recovery	MSD Found	MSD %Recovery	Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 06-07 QC Batch ID: WG1790325-3 QC Sample: L2330783-01 Client ID: MS Sample									
Zinc, Total	0.02168	0.5	0.5117	98	-	-	75-125	-	20
Total Metals - Mansfield Lab Associated sample(s): 06-07 QC Batch ID: WG1790326-3 QC Sample: L2330783-02 Client ID: MS Sample									
Mercury, Total	ND	0.005	0.00409	82	-	-	75-125	-	20

Lab Duplicate Analysis

Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2332665
Report Date: 06/19/23

Parameter	Native Sample	Duplicate Sample	Units	RPD	Qual	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 06-07 QC Batch ID: WG1790325-4 QC Sample: L2330783-01 Client ID: DUP Sample						
Aluminum, Total	0.00514J	0.00375J	mg/l	NC		20
Antimony, Total	ND	ND	mg/l	NC		20
Arsenic, Total	0.00454	0.00432	mg/l	5		20
Barium, Total	0.08585	0.08143	mg/l	5		20
Beryllium, Total	ND	ND	mg/l	NC		20
Cadmium, Total	ND	ND	mg/l	NC		20
Chromium, Total	ND	ND	mg/l	NC		20
Cobalt, Total	0.00341	0.00318	mg/l	7		20
Copper, Total	ND	ND	mg/l	NC		20
Iron, Total	108.	94.7	mg/l	13		20
Lead, Total	ND	ND	mg/l	NC		20
Magnesium, Total	36.6	34.5	mg/l	6		20
Manganese, Total	3.420	3.053	mg/l	11		20
Nickel, Total	0.02589	0.02522	mg/l	3		20
Potassium, Total	16.6	14.8	mg/l	11		20
Selenium, Total	ND	ND	mg/l	NC		20
Silver, Total	ND	ND	mg/l	NC		20
Sodium, Total	14.9	14.3	mg/l	4		20
Thallium, Total	ND	0.00018J	mg/l	NC		20

Lab Duplicate Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2332665

Report Date: 06/19/23

Parameter	Native Sample	Duplicate Sample	Units	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 06-07 QC Batch ID: WG1790325-4 QC Sample: L2330783-01 Client ID: DUP Sample					
Vanadium, Total	ND	ND	mg/l	NC	20
Zinc, Total	0.02168	0.01995	mg/l	8	20
Total Metals - Mansfield Lab Associated sample(s): 06-07 QC Batch ID: WG1790325-4 QC Sample: L2330783-01 Client ID: DUP Sample					
Calcium, Total	620.	641	mg/l	3	20
Total Metals - Mansfield Lab Associated sample(s): 06-07 QC Batch ID: WG1790326-4 QC Sample: L2330783-02 Client ID: DUP Sample					
Mercury, Total	ND	ND	mg/l	NC	20

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Serial Dilution Analysis
Batch Quality Control

Lab Number: L2332665
Report Date: 06/19/23

Parameter	Native Sample	Serial Dilution	Units	% D	Qual	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-05 QC Batch ID: WG1789741-6 QC Sample: L2332644-06 Client ID: DUP Sample						
Aluminum, Total	4120	4030	mg/kg	2		20
Arsenic, Total	102	82.6	mg/kg	19		20
Barium, Total	1140	1110	mg/kg	3		20
Calcium, Total	20200	20300	mg/kg	0		20
Copper, Total	308	308	mg/kg	0		20
Lead, Total	299	264	mg/kg	12		20
Magnesium, Total	2480	2720	mg/kg	10		20
Manganese, Total	646	655	mg/kg	1		20
Vanadium, Total	40.1	40.1	mg/kg	0		20
Zinc, Total	1480	1640	mg/kg	11		20
Total Metals - Mansfield Lab Associated sample(s): 01-05 QC Batch ID: WG1789741-6 QC Sample: L2332644-06 Client ID: DUP Sample						
Iron, Total	141000	141000	mg/kg	0		20
Total Metals - Mansfield Lab Associated sample(s): 06-07 QC Batch ID: WG1790325-6 QC Sample: L2330783-01 Client ID: DUP Sample						
Magnesium, Total	36.6	50.4	mg/l	**38**	Q	20
Total Metals - Mansfield Lab Associated sample(s): 06-07 QC Batch ID: WG1790325-6 QC Sample: L2330783-01 Client ID: DUP Sample						
Calcium, Total	620.	632.	mg/l	2		20

INORGANICS
&
MISCELLANEOUS

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2332665
Report Date: 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-01
Client ID: SB-44P (2-2.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/09/23 07:35
Date Received: 06/09/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Solids, Total	92.6		%	0.100	NA	1	-	06/13/23 13:08	121,2540G	ROI
Cyanide, Total	ND		mg/kg	1.0	0.22	1	06/14/23 21:10	06/15/23 11:21	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2332665
Report Date: 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-02
Client ID: SB-45P (4-4.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/09/23 07:50
Date Received: 06/09/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Solids, Total	93.1		%	0.100	NA	1	-	06/13/23 13:08	121,2540G	ROI
Cyanide, Total	ND		mg/kg	1.0	0.22	1	06/14/23 21:10	06/15/23 11:32	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2332665
Report Date: 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-03
Client ID: SB-46P (4.5-5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/09/23 11:30
Date Received: 06/09/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Solids, Total	91.7		%	0.100	NA	1	-	06/13/23 13:08	121,2540G	ROI
Cyanide, Total	ND		mg/kg	1.0	0.21	1	06/14/23 21:10	06/15/23 11:34	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2332665
Report Date: 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-04
Client ID: SB-47P (3-3.5)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/09/23 12:40
Date Received: 06/09/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Solids, Total	86.3		%	0.100	NA	1	-	06/13/23 13:08	121,2540G	ROI
Cyanide, Total	ND		mg/kg	1.1	0.23	1	06/14/23 21:10	06/15/23 11:35	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2332665
Report Date: 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-05
Client ID: SB-48P (3.5-4)
Sample Location: WHITE PLAINS, NY

Date Collected: 06/09/23 12:55
Date Received: 06/09/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Solids, Total	84.4		%	0.100	NA	1	-	06/13/23 13:08	121,2540G	ROI
Cyanide, Total	0.25	J	mg/kg	1.1	0.23	1	06/16/23 09:45	06/16/23 14:12	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2332665
Report Date: 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-06
Client ID: GW-16
Sample Location: WHITE PLAINS, NY

Date Collected: 06/09/23 13:10
Date Received: 06/09/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Cyanide, Total	ND		mg/l	0.005	0.001	1	06/14/23 14:50	06/14/23 18:37	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2332665
Report Date: 06/19/23

SAMPLE RESULTS

Lab ID: L2332665-07
Client ID: GW-17
Sample Location: WHITE PLAINS, NY

Sample Depth:
Matrix: Water

Date Collected: 06/09/23 12:10
Date Received: 06/09/23
Field Prep: Not Specified

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Cyanide, Total	0.003	J	mg/l	0.005	0.001	1	06/14/23 14:50	06/14/23 18:38	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

Method Blank Analysis
Batch Quality Control

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab for sample(s): 06-07 Batch: WG1791227-1										
Cyanide, Total	ND		mg/l	0.005	0.001	1	06/14/23 14:50	06/14/23 18:17	1,9010C/9012B	JER
General Chemistry - Westborough Lab for sample(s): 01 Batch: WG1791402-1										
Cyanide, Total	ND		mg/kg	0.89	0.19	1	06/14/23 21:10	06/15/23 10:57	1,9010C/9012B	JER
General Chemistry - Westborough Lab for sample(s): 02-04 Batch: WG1791403-1										
Cyanide, Total	ND		mg/kg	0.89	0.19	1	06/14/23 21:10	06/15/23 10:57	1,9010C/9012B	JER
General Chemistry - Westborough Lab for sample(s): 05 Batch: WG1792107-1										
Cyanide, Total	ND		mg/kg	0.92	0.20	1	06/16/23 09:45	06/16/23 13:53	1,9010C/9012B	JER

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2332665

Report Date: 06/19/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
General Chemistry - Westborough Lab Associated sample(s): 06-07 Batch: WG1791227-2 WG1791227-3								
Cyanide, Total	99		98		85-115	1		20
General Chemistry - Westborough Lab Associated sample(s): 01 Batch: WG1791402-2 WG1791402-3								
Cyanide, Total	**76**	Q	83		80-120	9		35
General Chemistry - Westborough Lab Associated sample(s): 02-04 Batch: WG1791403-2 WG1791403-3								
Cyanide, Total	**76**	Q	83		80-120	9		35
General Chemistry - Westborough Lab Associated sample(s): 05 Batch: WG1792107-2 WG1792107-3								
Cyanide, Total	105		96		80-120	6		35

Matrix Spike Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2332665
Report Date: 06/19/23

Parameter	Native Sample	MS Added	MS Found	MS %Recovery	Qual	MSD Found	MSD %Recovery	Qual	Recovery Limits	RPD	Qual	RPD Limits
General Chemistry - Westborough Lab Associated sample(s): 06-07 QC Batch ID: WG1791227-4 WG1791227-5 QC Sample: L2332644-03 Client ID: MS Sample												
Cyanide, Total	ND	0.2	0.201	100		0.209	104		80-120	4		20
General Chemistry - Westborough Lab Associated sample(s): 01 QC Batch ID: WG1791402-4 WG1791402-5 QC Sample: L2330640-18 Client ID: MS Sample												
Cyanide, Total	0.71J	11	9.2	77		10	86		75-125	8		35
General Chemistry - Westborough Lab Associated sample(s): 02-04 QC Batch ID: WG1791403-4 WG1791403-5 QC Sample: L2332796-02 Client ID: MS Sample												
Cyanide, Total	ND	11	11	97		12	110		75-125	9		35
General Chemistry - Westborough Lab Associated sample(s): 05 QC Batch ID: WG1792107-4 WG1792107-5 QC Sample: L2332665-05 Client ID: SB-48P (3.5-4)												
Cyanide, Total	0.25J	12	12	99		11	99		75-125	9		35

Lab Duplicate Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2332665

Report Date: 06/19/23

Parameter	Native Sample	Duplicate Sample	Units	RPD	Qual	RPD Limits
General Chemistry - Westborough Lab Associated sample(s): 01-05 QC Batch ID: WG1790691-1 QC Sample: L2332103-01 Client ID: DUP Sample						
Solids, Total	94.6	95.5	%	1		20

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2332665
Report Date: 06/19/23

Sample Receipt and Container Information

Were project specific reporting limits specified? YES

Cooler Information

Cooler	Custody Seal
A	Absent

Container Information

Container ID	Container Type	Cooler	Initial pH	Final pH	Temp deg C	Pres	Seal	Frozen Date/Time	Analysis(*)
L2332665-01A	5 gram Encore Sampler	A	NA		4.8	Y	Absent		NYTCL-8260HLW(14)
L2332665-01B	5 gram Encore Sampler	A	NA		4.8	Y	Absent		NYTCL-8260HLW(14)
L2332665-01C	5 gram Encore Sampler	A	NA		4.8	Y	Absent		NYTCL-8260HLW(14)
L2332665-01D	Metals Only-Glass 60mL/2oz unpreserved	A	NA		4.8	Y	Absent		BE-TI(180),AS-TI(180),BA-TI(180),AG-TI(180),NI-TI(180),AL-TI(180),CR-TI(180),TL-TI(180),SB-TI(180),CU-TI(180),SE-TI(180),PB-TI(180),ZN-TI(180),V-TI(180),CO-TI(180),FE-TI(180),HG-T(28),MG-TI(180),MN-TI(180),CD-TI(180),CA-TI(180),K-TI(180),NA-TI(180)
L2332665-01E	Plastic 2oz unpreserved for TS	A	NA		4.8	Y	Absent		TS(7)
L2332665-01F	Glass 250ml/8oz unpreserved	A	NA		4.8	Y	Absent		TCN-9010(14),NYTCL-8270(14),NYTCL-8081(14),NYTCL-8082(365)
L2332665-01X	Vial MeOH preserved split	A	NA		4.8	Y	Absent		NYTCL-8260HLW(14)
L2332665-01Y	Vial Water preserved split	A	NA		4.8	Y	Absent	10-JUN-23 10:36	NYTCL-8260HLW(14)
L2332665-01Z	Vial Water preserved split	A	NA		4.8	Y	Absent	10-JUN-23 10:36	NYTCL-8260HLW(14)
L2332665-02A	5 gram Encore Sampler	A	NA		4.8	Y	Absent		NYTCL-8260HLW(14)
L2332665-02B	5 gram Encore Sampler	A	NA		4.8	Y	Absent		NYTCL-8260HLW(14)
L2332665-02C	5 gram Encore Sampler	A	NA		4.8	Y	Absent		NYTCL-8260HLW(14)
L2332665-02D	Metals Only-Glass 60mL/2oz unpreserved	A	NA		4.8	Y	Absent		BE-TI(180),AS-TI(180),BA-TI(180),AG-TI(180),TL-TI(180),AL-TI(180),NI-TI(180),CR-TI(180),SE-TI(180),PB-TI(180),CU-TI(180),SB-TI(180),ZN-TI(180),V-TI(180),CO-TI(180),MG-TI(180),MN-TI(180),FE-TI(180),HG-T(28),CD-TI(180),K-TI(180),NA-TI(180),CA-TI(180)
L2332665-02E	Plastic 2oz unpreserved for TS	A	NA		4.8	Y	Absent		TS(7)
L2332665-02F	Glass 250ml/8oz unpreserved	A	NA		4.8	Y	Absent		NYTCL-8270(14),TCN-9010(14),NYTCL-8081(14),NYTCL-8082(365)
L2332665-02X	Vial MeOH preserved split	A	NA		4.8	Y	Absent		NYTCL-8260HLW(14)
L2332665-02Y	Vial Water preserved split	A	NA		4.8	Y	Absent	10-JUN-23 10:36	NYTCL-8260HLW(14)

*Values in parentheses indicate holding time in days

Container Information

Container ID	Container Type	Cooler	Initial pH	Final pH	Temp deg C	Pres	Seal	Frozen Date/Time	Analysis(*)
L2332665-02Z	Vial Water preserved split	A	NA		4.8	Y	Absent	10-JUN-23 10:36	NYTCL-8260HLW(14)
L2332665-03A	5 gram Encore Sampler	A	NA		4.8	Y	Absent		NYTCL-8260HLW(14)
L2332665-03B	5 gram Encore Sampler	A	NA		4.8	Y	Absent		NYTCL-8260HLW(14)
L2332665-03C	5 gram Encore Sampler	A	NA		4.8	Y	Absent		NYTCL-8260HLW(14)
L2332665-03D	Metals Only-Glass 60mL/2oz unpreserved	A	NA		4.8	Y	Absent		BE-TI(180),AS-TI(180),BA-TI(180),AG-TI(180),NI-TI(180),AL-TI(180),CR-TI(180),TL-TI(180),CU-TI(180),ZN-TI(180),SE-TI(180),PB-TI(180),SB-TI(180),CO-TI(180),V-TI(180),MN-TI(180),HG-T(28),MG-TI(180),FE-TI(180),NA-TI(180),K-TI(180),CD-TI(180),CA-TI(180)
L2332665-03E	Plastic 2oz unpreserved for TS	A	NA		4.8	Y	Absent		TS(7)
L2332665-03F	Glass 250ml/8oz unpreserved	A	NA		4.8	Y	Absent		TCN-9010(14),NYTCL-8270(14),NYTCL-8081(14),NYTCL-8082(365)
L2332665-03X	Vial MeOH preserved split	A	NA		4.8	Y	Absent		NYTCL-8260HLW(14)
L2332665-03Y	Vial Water preserved split	A	NA		4.8	Y	Absent	10-JUN-23 10:36	NYTCL-8260HLW(14)
L2332665-03Z	Vial Water preserved split	A	NA		4.8	Y	Absent	10-JUN-23 10:36	NYTCL-8260HLW(14)
L2332665-04A	5 gram Encore Sampler	A	NA		4.8	Y	Absent		NYTCL-8260HLW(14)
L2332665-04B	5 gram Encore Sampler	A	NA		4.8	Y	Absent		NYTCL-8260HLW(14)
L2332665-04C	5 gram Encore Sampler	A	NA		4.8	Y	Absent		NYTCL-8260HLW(14)
L2332665-04D	Metals Only-Glass 60mL/2oz unpreserved	A	NA		4.8	Y	Absent		BE-TI(180),BA-TI(180),AS-TI(180),AG-TI(180),CR-TI(180),NI-TI(180),AL-TI(180),TL-TI(180),PB-TI(180),ZN-TI(180),SB-TI(180),SE-TI(180),CU-TI(180),CO-TI(180),V-TI(180),FE-TI(180),MN-TI(180),HG-T(28),MG-TI(180),NA-TI(180),CD-TI(180),K-TI(180),CA-TI(180)
L2332665-04E	Plastic 2oz unpreserved for TS	A	NA		4.8	Y	Absent		TS(7)
L2332665-04F	Glass 250ml/8oz unpreserved	A	NA		4.8	Y	Absent		NYTCL-8270(14),TCN-9010(14),NYTCL-8081(14),NYTCL-8082(365)
L2332665-04X	Vial MeOH preserved split	A	NA		4.8	Y	Absent		NYTCL-8260HLW(14)
L2332665-04Y	Vial Water preserved split	A	NA		4.8	Y	Absent	10-JUN-23 10:36	NYTCL-8260HLW(14)
L2332665-04Z	Vial Water preserved split	A	NA		4.8	Y	Absent	10-JUN-23 10:36	NYTCL-8260HLW(14)
L2332665-05A	5 gram Encore Sampler	A	NA		4.8	Y	Absent		NYTCL-8260HLW(14)
L2332665-05B	5 gram Encore Sampler	A	NA		4.8	Y	Absent		NYTCL-8260HLW(14)
L2332665-05C	5 gram Encore Sampler	A	NA		4.8	Y	Absent		NYTCL-8260HLW(14)

*Values in parentheses indicate holding time in days

Container Information

Container ID	Container Type	Cooler	Initial pH	Final pH	Temp deg C	Pres	Seal	Frozen Date/Time	Analysis(*)
L2332665-05D	Metals Only-Glass 60mL/2oz unpreserved	A	NA		4.8	Y	Absent		BE-TI(180),BA-TI(180),AS-TI(180),AG-TI(180),TL-TI(180),AL-TI(180),CR-TI(180),NI-TI(180),CU-TI(180),SE-TI(180),ZN-TI(180),PB-TI(180),SB-TI(180),CO-TI(180),V-TI(180),FE-TI(180),MN-TI(180),HG-T(28),MG-TI(180),CA-TI(180),K-TI(180),NA-TI(180),CD-TI(180)
L2332665-05E	Plastic 2oz unpreserved for TS	A	NA		4.8	Y	Absent		TS(7)
L2332665-05F	Glass 250ml/8oz unpreserved	A	NA		4.8	Y	Absent		TCN-9010(14),NYTCL-8270(14),NYTCL-8081(14),NYTCL-8082(365)
L2332665-05X	Vial MeOH preserved split	A	NA		4.8	Y	Absent		NYTCL-8260HLW(14)
L2332665-05Y	Vial Water preserved split	A	NA		4.8	Y	Absent	10-JUN-23 10:36	NYTCL-8260HLW(14)
L2332665-05Z	Vial Water preserved split	A	NA		4.8	Y	Absent	10-JUN-23 10:36	NYTCL-8260HLW(14)
L2332665-06A	Vial HCl preserved	A	NA		4.8	Y	Absent		NYTCL-8260(14)
L2332665-06B	Vial HCl preserved	A	NA		4.8	Y	Absent		NYTCL-8260(14)
L2332665-06C	Vial HCl preserved	A	NA		4.8	Y	Absent		NYTCL-8260(14)
L2332665-06D	Amber 120ml unpreserved	A	7	7	4.8	Y	Absent		NYTCL-8081(7)
L2332665-06E	Amber 120ml unpreserved	A	7	7	4.8	Y	Absent		NYTCL-8081(7)
L2332665-06F	Amber 120ml unpreserved	A	7	7	4.8	Y	Absent		NYTCL-8082-LVI(365)
L2332665-06G	Amber 120ml unpreserved	A	7	7	4.8	Y	Absent		NYTCL-8082-LVI(365)
L2332665-06H	Plastic 250ml NaOH preserved	A	>12	>12	4.8	Y	Absent		TCN-9010(14)
L2332665-06J	Amber 250ml unpreserved	A	7	7	4.8	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)
L2332665-06K	Amber 250ml unpreserved	A	7	7	4.8	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)
L2332665-06L	Plastic 250ml HNO3 preserved	A	<2	<2	4.8	Y	Absent		BA-6020T(180),TL-6020T(180),FE-6020T(180),SE-6020T(180),K-6020T(180),CA-6020T(180),NI-6020T(180),CR-6020T(180),ZN-6020T(180),CU-6020T(180),NA-6020T(180),PB-6020T(180),BE-6020T(180),MN-6020T(180),V-6020T(180),AS-6020T(180),SB-6020T(180),AL-6020T(180),MG-6020T(180),AG-6020T(180),HG-T(28),CD-6020T(180),CO-6020T(180)
L2332665-07A	Vial HCl preserved	A	NA		4.8	Y	Absent		NYTCL-8260(14)
L2332665-07B	Vial HCl preserved	A	NA		4.8	Y	Absent		NYTCL-8260(14)
L2332665-07C	Vial HCl preserved	A	NA		4.8	Y	Absent		NYTCL-8260(14)
L2332665-07D	Amber 120ml unpreserved	A	7	7	4.8	Y	Absent		NYTCL-8081(7)

*Values in parentheses indicate holding time in days

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2332665
Report Date: 06/19/23

Container Information

Container ID	Container Type	Cooler	Initial pH	Final pH	Temp deg C	Pres	Seal	Frozen Date/Time	Analysis(*)
L2332665-07E	Amber 120ml unpreserved	A	7	7	4.8	Y	Absent		NYTCL-8081(7)
L2332665-07F	Amber 120ml unpreserved	A	7	7	4.8	Y	Absent		NYTCL-8082-LVI(365)
L2332665-07G	Amber 120ml unpreserved	A	7	7	4.8	Y	Absent		NYTCL-8082-LVI(365)
L2332665-07H	Plastic 250ml NaOH preserved	A	>12	>12	4.8	Y	Absent		TCN-9010(14)
L2332665-07J	Amber 250ml unpreserved	A	7	7	4.8	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)
L2332665-07K	Amber 250ml unpreserved	A	7	7	4.8	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)
L2332665-07L	Plastic 250ml HNO3 preserved	A	<2	<2	4.8	Y	Absent		TL-6020T(180),FE-6020T(180),BA-6020T(180),SE-6020T(180),NI-6020T(180),K-6020T(180),CA-6020T(180),CR-6020T(180),NA-6020T(180),CU-6020T(180),ZN-6020T(180),PB-6020T(180),MN-6020T(180),BE-6020T(180),AS-6020T(180),V-6020T(180),SB-6020T(180),AG-6020T(180),AL-6020T(180),CD-6020T(180),HG-T(28),MG-6020T(180),CO-6020T(180)

*Values in parentheses indicate holding time in days

Project Name:	100 MAIN ST.	**Lab Number:**	L2332665
Project Number:	12461	**Report Date:**	06/19/23

GLOSSARY

Acronyms

DL	- Detection Limit: This value represents the level to which target analyte concentrations are reported as estimated values, when those target analyte concentrations are quantified below the limit of quantitation (LOQ). The DL includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.)
EDL	- Estimated Detection Limit: This value represents the level to which target analyte concentrations are reported as estimated values, when those target analyte concentrations are quantified below the reporting limit (RL). The EDL includes any adjustments from dilutions, concentrations or moisture content, where applicable. The use of EDLs is specific to the analysis of PAHs using Solid-Phase Microextraction (SPME).
EMPC	- Estimated Maximum Possible Concentration: The concentration that results from the signal present at the retention time of an analyte when the ions meet all of the identification criteria except the ion abundance ratio criteria. An EMPC is a worst-case estimate of the concentration.
EPA	- Environmental Protection Agency.
LCS	- Laboratory Control Sample: A sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes or a material containing known and verified amounts of analytes.
LCSD	- Laboratory Control Sample Duplicate: Refer to LCS.
LFB	- Laboratory Fortified Blank: A sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes or a material containing known and verified amounts of analytes.
LOD	- Limit of Detection: This value represents the level to which a target analyte can reliably be detected for a specific analyte in a specific matrix by a specific method. The LOD includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.)
LOQ	- Limit of Quantitation: The value at which an instrument can accurately measure an analyte at a specific concentration. The LOQ includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.) Limit of Quantitation: The value at which an instrument can accurately measure an analyte at a specific concentration. The LOQ includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.)
MDL	- Method Detection Limit: This value represents the level to which target analyte concentrations are reported as estimated values, when those target analyte concentrations are quantified below the reporting limit (RL). The MDL includes any adjustments from dilutions, concentrations or moisture content, where applicable.
MS	- Matrix Spike Sample: A sample prepared by adding a known mass of target analyte to a specified amount of matrix sample for which an independent estimate of target analyte concentration is available. For Method 332.0, the spike recovery is calculated using the native concentration, including estimated values.
MSD	- Matrix Spike Sample Duplicate: Refer to MS.
NA	- Not Applicable.
NC	- Not Calculated: Term is utilized when one or more of the results utilized in the calculation are non-detect at the parameter's reporting unit.
NDPA/DPA	- N-Nitrosodiphenylamine/Diphenylamine.
NI	- Not Ignitable.
NP	- Non-Plastic: Term is utilized for the analysis of Atterberg Limits in soil.
NR	- No Results: Term is utilized when 'No Target Compounds Requested' is reported for the analysis of Volatile or Semivolatile Organic TIC only requests.
RL	- Reporting Limit: The value at which an instrument can accurately measure an analyte at a specific concentration. The RL includes any adjustments from dilutions, concentrations or moisture content, where applicable.
RPD	- Relative Percent Difference: The results from matrix and/or matrix spike duplicates are primarily designed to assess the precision of analytical results in a given matrix and are expressed as relative percent difference (RPD). Values which are less than five times the reporting limit for any individual parameter are evaluated by utilizing the absolute difference between the values; although the RPD value will be provided in the report.
SRM	- Standard Reference Material: A reference sample of a known or certified value that is of the same or similar matrix as the associated field samples.
STLP	- Semi-dynamic Tank Leaching Procedure per EPA Method 1315.
TEF	- Toxic Equivalency Factors: The values assigned to each dioxin and furan to evaluate their toxicity relative to 2,3,7,8-TCDD.
TEQ	- Toxic Equivalent: The measure of a sample's toxicity derived by multiplying each dioxin and furan by its corresponding TEF and then summing the resulting values.
TIC	- Tentatively Identified Compound: A compound that has been identified to be present and is not part of the target compound list (TCL) for the method and/or program. All TICs are qualitatively identified and reported as estimated concentrations.

Report Format: DU Report with 'J' Qualifiers

Project Name:	100 MAIN ST.	**Lab Number:**	L2332665
Project Number:	12461	**Report Date:**	06/19/23

Footnotes

1 - The reference for this analyte should be considered modified since this analyte is absent from the target analyte list of the original method.

Terms

Analytical Method: Both the document from which the method originates and the analytical reference method. (Example: EPA 8260B is shown as 1,8260B.) The codes for the reference method documents are provided in the References section of the Addendum.

Chlordane: The target compound Chlordane (CAS No. 57-74-9) is reported for GC ECD analyses. Per EPA,this compound "refers to a mixture of chlordane isomers, other chlorinated hydrocarbons and numerous other components." (Reference: USEPA Toxicological Review of Chlordane, In Support of Summary Information on the Integrated Risk Information System (IRIS), December 1997.)

Difference: With respect to Total Oxidizable Precursor (TOP) Assay analysis, the difference is defined as the Post-Treatment value minus the Pre-Treatment value.

Final pH: As it pertains to Sample Receipt & Container Information section of the report, Final pH reflects pH of container determined after adjustment at the laboratory, if applicable. If no adjustment required, value reflects Initial pH.

Frozen Date/Time: With respect to Volatile Organics in soil, Frozen Date/Time reflects the date/time at which associated Reagent Water-preserved vials were initially frozen. Note: If frozen date/time is beyond 48 hours from sample collection, value will be reflected in 'bold'.

Gasoline Range Organics (GRO): Gasoline Range Organics (GRO) results include all chromatographic peaks eluting from Methyl tert butyl ether through Naphthalene, with the exception of GRO analysis in support of State of Ohio programs, which includes all chromatographic peaks eluting from Hexane through Dodecane.

Initial pH: As it pertains to Sample Receipt & Container Information section of the report, Initial pH reflects pH of container determined upon receipt, if applicable.

PAH Total: With respect to Alkylated PAH analyses, the 'PAHs, Total' result is defined as the summation of results for all or a subset of the following compounds: Naphthalene, C1-C4 Naphthalenes, 2-Methylnaphthalene, 1-Methylnaphthalene, Biphenyl, Acenaphthylene, Acenaphthene, Fluorene, C1-C3 Fluorenes, Phenanthrene, C1-C4 Phenanthrenes/Anthracenes, Anthracene, Fluoranthene, Pyrene, C1-C4 Fluoranthenes/Pyrenes, Benz(a)anthracene, Chrysene, C1-C4 Chrysenes, Benzo(b)fluoranthene, Benzo(j)+(k)fluoranthene, Benzo(e)pyrene, Benzo(a)pyrene, Perylene, Indeno(1,2,3-cd)pyrene, Dibenz(ah)+(ac)anthracene, Benzo(g,h,i)perylene. If a 'Total' result is requested, the results of its individual components will also be reported.

PFAS Total: With respect to PFAS analyses, the 'PFAS, Total (5)' result is defined as the summation of results for: PFHpA, PFHxS, PFOA, PFNA and PFOS. In addition, the 'PFAS, Total (6)' result is defined as the summation of results for: PFHpA, PFHxS, PFOA, PFNA, PFDA and PFOS. For MassDEP DW compliance analysis only, the 'PFAS, Total (6)' result is defined as the summation of results at or above the RL. Note: If a 'Total' result is requested, the results of its individual components will also be reported.

Total: With respect to Organic analyses, a 'Total' result is defined as the summation of results for individual isomers or Aroclors. If a 'Total' result is requested, the results of its individual components will also be reported. This is applicable to 'Total' results for methods 8260, 8081 and 8082.

Data Qualifiers

A - Spectra identified as "Aldol Condensates" are byproducts of the extraction/concentration procedures when acetone is introduced in the process.

B - The analyte was detected above the reporting limit in the associated method blank. Flag only applies to associated field samples that have detectable concentrations of the analyte at less than ten times (10x) the concentration found in the blank. For MCP-related projects, flag only applies to associated field samples that have detectable concentrations of the analyte at less than ten times (10x) the concentration found in the blank. For DOD-related projects, flag only applies to associated field samples that have detectable concentrations of the analyte at less than ten times (10x) the concentration found in the blank AND the analyte was detected above one-half the reporting limit (or above the reporting limit for common lab contaminants) in the associated method blank. For NJ-Air-related projects, flag only applies to associated field samples that have detectable concentrations of the analyte above the reporting limit. For NJ-related projects (excluding Air), flag only applies to associated field samples that have detectable concentrations of the analyte, which was detected above the reporting limit in the associated method blank or above five times the reporting limit for common lab contaminants (Phthalates, Acetone, Methylene Chloride, 2-Butanone).

C - Co-elution: The target analyte co-elutes with a known lab standard (i.e. surrogate, internal standards, etc.) for co-extracted analyses.

D - Concentration of analyte was quantified from diluted analysis. Flag only applies to field samples that have detectable concentrations of the analyte.

E - Concentration of analyte exceeds the range of the calibration curve and/or linear range of the instrument.

F - The ratio of quantifier ion response to qualifier ion response falls outside of the laboratory criteria. Results are considered to be an estimated maximum concentration.

G - The concentration may be biased high due to matrix interferences (i.e, co-elution) with non-target compound(s). The result should be considered estimated.

H - The analysis of pH was performed beyond the regulatory-required holding time of 15 minutes from the time of sample collection.

I - The lower value for the two columns has been reported due to obvious interference.

J - Estimated value. The Target analyte concentration is below the quantitation limit (RL), but above the Method Detection Limit (MDL) or Estimated Detection Limit (EDL) for SPME-related analyses. This represents an estimated concentration for Tentatively

Report Format: DU Report with 'J' Qualifiers

Project Name:	100 MAIN ST.	**Lab Number:**	L2332665
Project Number:	12461	**Report Date:**	06/19/23

Data Qualifiers

Identified Compounds (TICs).

M - Reporting Limit (RL) exceeds the MCP CAM Reporting Limit for this analyte.

ND - Not detected at the method detection limit (MDL) for the sample, or estimated detection limit (EDL) for SPME-related analyses.

NJ - Presumptive evidence of compound. This represents an estimated concentration for Tentatively Identified Compounds (TICs), where the identification is based on a mass spectral library search.

P - The RPD between the results for the two columns exceeds the method-specified criteria.

Q - The quality control sample exceeds the associated acceptance criteria. For DOD-related projects, LCS and/or Continuing Calibration Standard exceedences are also qualified on all associated sample results. Note: This flag is not applicable for matrix spike recoveries when the sample concentration is greater than 4x the spike added or for batch duplicate RPD when the sample concentrations are less than 5x the RL. (Metals only.)

R - Analytical results are from sample re-analysis.

RE - Analytical results are from sample re-extraction.

S - Analytical results are from modified screening analysis.

V - The surrogate associated with this target analyte has a recovery outside the QC acceptance limits. (Applicable to MassDEP DW Compliance samples only.)

Z - The batch matrix spike and/or duplicate associated with this target analyte has a recovery/RPD outside the QC acceptance limits. (Applicable to MassDEP DW Compliance samples only.)

Project Name:	100 MAIN ST.	**Lab Number:**	L2332665
Project Number:	12461	**Report Date:**	06/19/23

REFERENCES

1 Test Methods for Evaluating Solid Waste: Physical/Chemical Methods. EPA SW-846. Third Edition. Updates I - VI, 2018.

121 Standard Methods for the Examination of Water and Wastewater. APHA-AWWA-WEF. Standard Methods Online.

LIMITATION OF LIABILITIES

Alpha Analytical performs services with reasonable care and diligence normal to the analytical testing laboratory industry. In the event of an error, the sole and exclusive responsibility of Alpha Analytical shall be to re-perform the work at it's own expense. In no event shall Alpha Analytical be held liable for any incidental, consequential or special damages, including but not limited to, damages in any way connected with the use of, interpretation of, information or analysis provided by Alpha Analytical.

We strongly urge our clients to comply with EPA protocol regarding sample volume, preservation, cooling, containers, sampling procedures, holding time and splitting of samples in the field.

Certification Information

The following analytes are not included in our Primary NELAP Scope of Accreditation:

Westborough Facility
EPA 624.1: m/p-xylene, o-xylene, Naphthalene
EPA 625.1: alpha-Terpineol
EPA 8260D: NPW: 1,2,4,5-Tetramethylbenzene; 4-Ethyltoluene, Azobenzene; SCM: Iodomethane (methyl iodide), 1,2,4,5-Tetramethylbenzene; 4-Ethyltoluene.
EPA 8270E: NPW: Dimethylnaphthalene,1,4-Diphenylhydrazine, alpha-Terpineol; SCM: Dimethylnaphthalene,1,4-Diphenylhydrazine.
SM4500: NPW: Amenable Cyanide; SCM: Total Phosphorus, TKN, NO2, NO3.

Mansfield Facility
SM 2540D: TSS.
EPA TO-15: Halothane, 2,4,4-Trimethyl-2-pentene, 2,4,4-Trimethyl-1-pentene, Thiophene, 2-Methylthiophene, 3-Methylthiophene, 2-Ethylthiophene, 1,2,3-Trimethylbenzene, Indan, Indene, 1,2,4,5-Tetramethylbenzene, Benzothiophene, 1-Methylnaphthalene.
Biological Tissue Matrix: EPA 3050B

The following analytes are included in our Massachusetts DEP Scope of Accreditation

Westborough Facility:

Drinking Water
EPA 300.0: Chloride, Nitrate-N, Fluoride, Sulfate; **EPA 353.2**: Nitrate-N, Nitrite-N; **SM4500NO3-F**: Nitrate-N, Nitrite-N; **SM4500F-C, SM4500CN-CE, EPA 180.1, SM2130B, SM4500Cl-D, SM2320B, SM2540C, SM4500H-B, SM4500NO2-B**
EPA 524.2: THMs and VOCs; **EPA 504.1:** EDB, DBCP.
Microbiology: **SM9215B; SM9223-P/A, SM9223B-Colilert-QT,SM9222D**.

Non-Potable Water
SM4500H,B, EPA 120.1, SM2510B, SM2540C, SM2320B, SM4500CL-E, SM4500F-BC, SM4500NH3-BH: Ammonia-N and Kjeldahl-N, **EPA 350.1**: Ammonia-N, **LACHAT 10-107-06-1-B**: Ammonia-N, **EPA 351.1, SM4500NO3-F, EPA 353.2**: Nitrate-N**, SM4500P-E, SM4500P-B, E, SM4500SO4-E, SM5220D, EPA 410.4, SM5210B, SM5310C, SM4500CL-D, EPA 1664, EPA 420.1, SM4500-CN-CE, SM2540D, EPA 300: Chloride, Sulfate, Nitrate.**
EPA 624.1: Volatile Halocarbons & Aromatics,
EPA 608.3: Chlordane, Toxaphene, Aldrin, alpha-BHC, beta-BHC, gamma-BHC, delta-BHC, Dieldrin, DDD, DDE, DDT, Endosulfan I, Endosulfan II, Endosulfan sulfate, Endrin, Endrin Aldehyde, Heptachlor, Heptachlor Epoxide, PCBs
EPA 625.1: SVOC (Acid/Base/Neutral Extractables).
Microbiology: **SM9223B-Colilert-QT; Enterolert-QT, SM9221E, EPA 1600, EPA 1603, SM9222D.**

Mansfield Facility:

Drinking Water
EPA 200.7: Al, Ba, Cd, Cr, Cu, Fe, Mn, Ni, Na, Ag, Ca, Zn. **EPA 200.8:** Al, Sb, As, Ba, Be, Cd, Cr, Cu, Pb, Mn, Ni, Se, Ag, TL, Zn. **EPA 245.1** Hg.
EPA 522, EPA 537.1.

Non-Potable Water
EPA 200.7: Al, Sb, As, Be, Cd, Ca, Cr, Co, Cu, Fe, Pb, Mg, Mn, Mo, Ni, K, Se, Ag, Na, Sr, TL, Ti, V, Zn.
EPA 200.8: Al, Sb**,** As, Be, Cd, Cr, Cu, Fe, Pb, Mn, Ni, K, Se, Ag, Na, TL, Zn.
EPA 245.1 Hg.
SM2340B

For a complete listing of analytes and methods, please contact your Alpha Project Manager.

NEW YORK CHAIN OF CUSTODY

ALPHA ANALYTICAL

Westborough, MA 01581
8 Walkup Dr.
TEL: 508-898-9220
FAX: 508-898-9193

Mansfield, MA 02048
320 Forbes Blvd
TEL: 508-822-9300
FAX: 508-822-3288

Service Centers
Mahwah, NJ 07430: 35 Whitney Rd, Suite 5
Albany, NY 12205: 14 Walker Way
Tonawanda, NY 14150: 275 Cooper Ave, Suite 105

Page 1 of 1

Date Rec'd in Lab: 6/9/23

ALPHA Job #: L2332665

Client Information

Client: SESI
Address: 954 US 46 Fl 3 S300
Parsippany NJ 07054
Phone: 973 8089050
Fax:
Email: JCS@sesi.org

Project Information

Project Name: 100 Main St
Project Location: White Plains NY
Project #: 12461a
(Use Project name as Project #) ☐
Project Manager: Jon Stuart
ALPHAQuote #:

Turn-Around Time

Standard ☑ Due Date:
Rush (only if pre approved) ☐ # of Days:

Deliverables

☐ ASP-A ☑ ASP-B
☐ EQuIS (1 File) ☐ EQuIS (4 File)
☐ Other

Regulatory Requirement

☐ NY TOGS ☐ NY Part 375
☑ AWQ Standards ☐ NY CP-51
☐ NY Restricted Use ☐ Other
☑ NY Unrestricted Use
☐ NYC Sewer Discharge

Billing Information

☐ Same as Client Info
PO # Renaissance Env. Mgmt.
Attn: Kevin McNamara

Disposal Site Information

Please identify below location of applicable disposal facilities.

Disposal Facility:
☐ NJ ☐ NY
☐ Other:

These samples have been previously analyzed by Alpha ☐

Other project specific requirements/comments:

Please specify Metals or TAL.

ANALYSIS

TCL+30 TAL

Sample Filtration
☐ Done
☐ Lab to do
Preservation
☐ Lab to do
(Please Specify below)

Total Bottle

ALPHA Lab ID (Lab Use Only)	Sample ID	Collection Date	Collection Time	Sample Matrix	Sampler's Initials	Sample Specific Comments
32665-01	SB-44P (2-2.5)	6/9/23	735	S	CB	
02	SB-45P (4-4.5)		750	S	CB	
03	SB-46P (4.5-5)		1130	S	CB	
04	SB-47P (3-3.5)		1740	S	CB	
05	SB-48P (3.5-4)		1755	S	CB	
06	GW-16		1310	GW	CB	
07	GW-17	↓	1710	GW	CB	

Preservative Code:
A = None
B = HCl
C = HNO_3
D = H_2SO_4
E = NaOH
F = MeOH
G = $NaHSO_4$
H = $Na_2S_2O_3$
K/E = Zn Ac/NaOH
O = Other

Container Code
P = Plastic
A = Amber Glass
V = Vial
G = Glass
B = Bacteria Cup
C = Cube
O = Other
E = Encore
D = BOD Bottle

Westboro: Certification No: MA935
Mansfield: Certification No: MA015

Container Type	P/G										
Preservative	Soil										

Relinquished By:	Date/Time	Received By:	Date/Time
	06/09/23 14:28	AAL	6/9/23 14:28
AAL	6/9/23 18:20		6/9/23 18:55
	6/9/23	AAL	6/9/23 21:30
AAL	6/9/23 23:20		6/9/23 23:20

Please print clearly, legibly and completely. Samples can not be logged in and turnaround time clock will not start until any ambiguities are resolved. BY EXECUTING THIS COC, THE CLIENT HAS READ AND AGREES TO BE BOUND BY ALPHA'S TERMS & CONDITIONS. (See reverse side.)

Form No: 01-25 HC (rev. 30-Sept-2013)

ANALYTICAL REPORT

Lab Number:	L2341423
Client:	Soils Engineering Services, Inc. 959 Route 46E Parsippany, NJ 07054
ATTN:	Jonathan Stuart
Phone:	(973) 808-9050
Project Name:	100 MAIN ST.
Project Number:	12461
Report Date:	07/24/23

The original project report/data package is held by Alpha Analytical. This report/data package is paginated and should be reproduced only in its entirety. Alpha Analytical holds no responsibility for results and/or data that are not consistent with the original.

Certifications & Approvals: MA (M-MA086), NH NELAP (2064), CT (PH-0826), IL (200077), IN (C-MA-03), KY (KY98045), ME (MA00086), MD (348), NJ (MA935), NY (11148), NC (25700/666), OH (CL108), OR (MA-1316), PA (68-03671), RI (LAO00065), TX (T104704476), VT (VT-0935), VA (460195), USDA (Permit #525-23-122-91930).

Eight Walkup Drive, Westborough, MA 01581-1019
508-898-9220 (Fax) 508-898-9193 800-624-9220 - www.alphalab.com

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341423
Report Date: 07/24/23

Alpha Sample ID	Client ID	Matrix	Sample Location	Collection Date/Time	Receive Date
L2341423-01	GW-18	WATER	WHITE PLAINS, NY	07/19/23 09:45	07/19/23
L2341423-02	GW-19	WATER	WHITE PLAINS, NY	07/19/23 08:30	07/19/23
L2341423-03	GW-20	WATER	WHITE PLAINS, NY	07/19/23 14:20	07/19/23
L2341423-04	GW-21	WATER	WHITE PLAINS, NY	07/19/23 11:20	07/19/23
L2341423-05	GW-22	WATER	WHITE PLAINS, NY	07/19/23 11:45	07/19/23
L2341423-06	GW-23	WATER	WHITE PLAINS, NY	07/19/23 13:50	07/19/23
L2341423-07	SB-51P (3.5-4)	SOIL	WHITE PLAINS, NY	07/19/23 15:00	07/19/23

Project Name:	100 MAIN ST.	**Lab Number:**	L2341423
Project Number:	12461	**Report Date:**	07/24/23

Case Narrative

The samples were received in accordance with the Chain of Custody and no significant deviations were encountered during the preparation or analysis unless otherwise noted. Sample Receipt, Container Information, and the Chain of Custody are located at the back of the report.

Results contained within this report relate only to the samples submitted under this Alpha Lab Number and meet NELAP requirements for all NELAP accredited parameters unless otherwise noted in the following narrative. The data presented in this report is organized by parameter (i.e. VOC, SVOC, etc.). Sample specific Quality Control data (i.e. Surrogate Spike Recovery) is reported at the end of the target analyte list for each individual sample, followed by the Laboratory Batch Quality Control at the end of each parameter. Tentatively Identified Compounds (TICs), if requested, are reported for compounds identified to be present and are not part of the method/program Target Compound List, even if only a subset of the TCL are being reported. If a sample was re-analyzed or re-extracted due to a required quality control corrective action and if both sets of data are reported, the Laboratory ID of the re-analysis or re-extraction is designated with an "R" or "RE", respectively.

When multiple Batch Quality Control elements are reported (e.g. more than one LCS), the associated samples for each element are noted in the grey shaded header line of each data table. Any Laboratory Batch, Sample Specific % recovery or RPD value that is outside the listed Acceptance Criteria is bolded in the report. In reference to questions H (CAM) or 4 (RCP) when "NO" is checked, the performance criteria for CAM and RCP methods allow for some quality control failures to occur and still be within method compliance. In these instances, the specific failure is not narrated but noted in the associated QC Outlier Summary Report, located directly after the Case Narrative. QC information is also incorporated in the Data Usability Assessment table (Format 11) of our Data Merger tool, where it can be reviewed in conjunction with the sample result, associated regulatory criteria and any associated data usability implications.

Soil/sediments, solids and tissues are reported on a dry weight basis unless otherwise noted. Definitions of all data qualifiers and acronyms used in this report are provided in the Glossary located at the back of the report.

HOLD POLICY - For samples submitted on hold, Alpha's policy is to hold samples (with the exception of Air canisters) free of charge for 21 calendar days from the date the project is completed. After 21 calendar days, we will dispose of all samples submitted including those put on hold unless you have contacted your Alpha Project Manager and made arrangements for Alpha to continue to hold the samples. Air canisters will be disposed after 3 business days from the date the project is completed.

Please contact Project Management at 800-624-9220 with any questions.

Project Name: 100 MAIN ST. **Lab Number:** L2341423
Project Number: 12461 **Report Date:** 07/24/23

Case Narrative (continued)

Report Submission
All non-detect (ND) or estimated concentrations (J-qualified) have been quantitated to the limit noted in the MDL column.

Volatile Organics
L2341423-02 and -04: The pH was greater than two; however, the sample was analyzed within the method required holding time.

Semivolatile Organics
The WG1805644-3 LCS recovery, associated with L2341423-01 through -05, is below the acceptance criteria for benzoic acid (0%); however, it has been identified as a "difficult" analyte. The results of the associated samples are reported.

Semivolatile Organics by SIM
The WG1805593-1 Method Blank, associated with L2341423-01 through -05, has a concentration above the reporting limit for Naphthalene. Since the associated sample concentrations are either greater than 10x the blank concentration or non-detect to the RL for this target analyte, no corrective action is required. Any results detected below the reporting limit are qualified with a "B".
The WG1805593-1 Method Blank, associated with L2341423-06, has a concentration above the reporting limit for Naphthalene; however, re-extraction achieved similar results. The results of both extractions are reported and are qualified with a "B".
The WG1806557-1 Method Blank, associated with L2341423-06RE, has a concentration above the reporting limit for Naphthalene; however, re-extraction could not be performed due to lack of additional sample volume.

Total Metals
L2341423-07: The sample has elevated detection limits for all elements, with the exception of mercury, due to the dilution required by the sample matrix.

Project Name: 100 MAIN ST. **Lab Number:** L2341423
Project Number: 12461 **Report Date:** 07/24/23

Case Narrative (continued)

The WG1805519-3 MS recovery for aluminum (266%), performed on L2341423-07, does not apply because the sample concentration is greater than four times the spike amount added.
The WG1805519-3 MS recovery, performed on L2341423-07, is outside the acceptance criteria for manganese (126%). A post digestion spike was performed and yielded an unacceptable recovery for manganese(74%). The serial dilution recovery was acceptable; therefore, the matrix test passed for the sample matrix.
The WG1805519-4 Laboratory Duplicate RPD for barium (28%), performed on L2341423-07, is outside the acceptance criteria. The elevated RPD has been attributed to the non-homogeneous nature of the native sample.
The WG1805552-3 MS recoveries for calcium (190%), iron (20%), magnesium (50%), manganese (28%), potassium (51%), and sodium (60%), performed on L2341423-01, do not apply because the sample concentrations are greater than four times the spike amounts added.

I, the undersigned, attest under the pains and penalties of perjury that, to the best of my knowledge and belief and based upon my personal inquiry of those responsible for providing the information contained in this analytical report, such information is accurate and complete. This certificate of analysis is not complete unless this page accompanies any and all pages of this report.

Authorized Signature: Kelly O'Neill

Title: Technical Director/Representative Date: 07/24/23

ORGANICS

VOLATILES

Project Name: 100 MAIN ST.
Lab Number: L2341423
Project Number: 12461
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-01
Client ID: GW-18
Sample Location: WHITE PLAINS, NY

Date Collected: 07/19/23 09:45
Date Received: 07/19/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8260D
Analytical Date: 07/20/23 17:38
Analyst: PID

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Methylene chloride	ND		ug/l	2.5	0.70	1
1,1-Dichloroethane	ND		ug/l	2.5	0.70	1
Chloroform	ND		ug/l	2.5	0.70	1
Carbon tetrachloride	ND		ug/l	0.50	0.13	1
1,2-Dichloropropane	ND		ug/l	1.0	0.14	1
Dibromochloromethane	ND		ug/l	0.50	0.15	1
1,1,2-Trichloroethane	ND		ug/l	1.5	0.50	1
Tetrachloroethene	ND		ug/l	0.50	0.18	1
Chlorobenzene	ND		ug/l	2.5	0.70	1
Trichlorofluoromethane	ND		ug/l	2.5	0.70	1
1,2-Dichloroethane	ND		ug/l	0.50	0.13	1
1,1,1-Trichloroethane	ND		ug/l	2.5	0.70	1
Bromodichloromethane	ND		ug/l	0.50	0.19	1
trans-1,3-Dichloropropene	ND		ug/l	0.50	0.16	1
cis-1,3-Dichloropropene	ND		ug/l	0.50	0.14	1
1,3-Dichloropropene, Total	ND		ug/l	0.50	0.14	1
1,1-Dichloropropene	ND		ug/l	2.5	0.70	1
Bromoform	ND		ug/l	2.0	0.65	1
1,1,2,2-Tetrachloroethane	ND		ug/l	0.50	0.17	1
Benzene	ND		ug/l	0.50	0.16	1
Toluene	ND		ug/l	2.5	0.70	1
Ethylbenzene	ND		ug/l	2.5	0.70	1
Chloromethane	ND		ug/l	2.5	0.70	1
Bromomethane	ND		ug/l	2.5	0.70	1
Vinyl chloride	ND		ug/l	1.0	0.07	1
Chloroethane	ND		ug/l	2.5	0.70	1
1,1-Dichloroethene	ND		ug/l	0.50	0.17	1
trans-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-01 Date Collected: 07/19/23 09:45

Client ID: GW-18 Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Trichloroethene	ND		ug/l	0.50	0.18	1
1,2-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,3-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,4-Dichlorobenzene	ND		ug/l	2.5	0.70	1
Methyl tert butyl ether	ND		ug/l	2.5	0.70	1
p/m-Xylene	ND		ug/l	2.5	0.70	1
o-Xylene	ND		ug/l	2.5	0.70	1
Xylenes, Total	ND		ug/l	2.5	0.70	1
cis-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1
1,2-Dichloroethene, Total	ND		ug/l	2.5	0.70	1
Dibromomethane	ND		ug/l	5.0	1.0	1
1,2,3-Trichloropropane	ND		ug/l	2.5	0.70	1
Acrylonitrile	ND		ug/l	5.0	1.5	1
Styrene	ND		ug/l	2.5	0.70	1
Dichlorodifluoromethane	ND		ug/l	5.0	1.0	1
Acetone	ND		ug/l	5.0	1.5	1
Carbon disulfide	ND		ug/l	5.0	1.0	1
2-Butanone	ND		ug/l	5.0	1.9	1
Vinyl acetate	ND		ug/l	5.0	1.0	1
4-Methyl-2-pentanone	ND		ug/l	5.0	1.0	1
2-Hexanone	ND		ug/l	5.0	1.0	1
Bromochloromethane	ND		ug/l	2.5	0.70	1
2,2-Dichloropropane	ND		ug/l	2.5	0.70	1
1,2-Dibromoethane	ND		ug/l	2.0	0.65	1
1,3-Dichloropropane	ND		ug/l	2.5	0.70	1
1,1,1,2-Tetrachloroethane	ND		ug/l	2.5	0.70	1
Bromobenzene	ND		ug/l	2.5	0.70	1
n-Butylbenzene	ND		ug/l	2.5	0.70	1
sec-Butylbenzene	ND		ug/l	2.5	0.70	1
tert-Butylbenzene	ND		ug/l	2.5	0.70	1
o-Chlorotoluene	ND		ug/l	2.5	0.70	1
p-Chlorotoluene	ND		ug/l	2.5	0.70	1
1,2-Dibromo-3-chloropropane	ND		ug/l	2.5	0.70	1
Hexachlorobutadiene	ND		ug/l	2.5	0.70	1
Isopropylbenzene	ND		ug/l	2.5	0.70	1
p-Isopropyltoluene	ND		ug/l	2.5	0.70	1
Naphthalene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-01 Date Collected: 07/19/23 09:45

Client ID: GW-18 Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
n-Propylbenzene	ND		ug/l	2.5	0.70	1
1,2,3-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,3,5-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,4-Dioxane	ND		ug/l	250	61.	1
p-Diethylbenzene	ND		ug/l	2.0	0.70	1
p-Ethyltoluene	ND		ug/l	2.0	0.70	1
1,2,4,5-Tetramethylbenzene	ND		ug/l	2.0	0.54	1
Ethyl ether	ND		ug/l	2.5	0.70	1
trans-1,4-Dichloro-2-butene	ND		ug/l	2.5	0.70	1
Tentatively Identified Compounds						
No Tentatively Identified Compounds	ND		ug/l			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	103		70-130
Toluene-d8	99		70-130
4-Bromofluorobenzene	99		70-130
Dibromofluoromethane	99		70-130

Project Name: 100 MAIN ST.
Lab Number: L2341423
Project Number: 12461
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-02
Client ID: GW-19
Sample Location: WHITE PLAINS, NY
Date Collected: 07/19/23 08:30
Date Received: 07/19/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8260D
Analytical Date: 07/20/23 18:04
Analyst: PID

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Methylene chloride	ND		ug/l	2.5	0.70	1
1,1-Dichloroethane	ND		ug/l	2.5	0.70	1
Chloroform	ND		ug/l	2.5	0.70	1
Carbon tetrachloride	ND		ug/l	0.50	0.13	1
1,2-Dichloropropane	ND		ug/l	1.0	0.14	1
Dibromochloromethane	ND		ug/l	0.50	0.15	1
1,1,2-Trichloroethane	ND		ug/l	1.5	0.50	1
Tetrachloroethene	ND		ug/l	0.50	0.18	1
Chlorobenzene	ND		ug/l	2.5	0.70	1
Trichlorofluoromethane	ND		ug/l	2.5	0.70	1
1,2-Dichloroethane	ND		ug/l	0.50	0.13	1
1,1,1-Trichloroethane	ND		ug/l	2.5	0.70	1
Bromodichloromethane	ND		ug/l	0.50	0.19	1
trans-1,3-Dichloropropene	ND		ug/l	0.50	0.16	1
cis-1,3-Dichloropropene	ND		ug/l	0.50	0.14	1
1,3-Dichloropropene, Total	ND		ug/l	0.50	0.14	1
1,1-Dichloropropene	ND		ug/l	2.5	0.70	1
Bromoform	ND		ug/l	2.0	0.65	1
1,1,2,2-Tetrachloroethane	ND		ug/l	0.50	0.17	1
Benzene	ND		ug/l	0.50	0.16	1
Toluene	ND		ug/l	2.5	0.70	1
Ethylbenzene	ND		ug/l	2.5	0.70	1
Chloromethane	ND		ug/l	2.5	0.70	1
Bromomethane	ND		ug/l	2.5	0.70	1
Vinyl chloride	ND		ug/l	1.0	0.07	1
Chloroethane	ND		ug/l	2.5	0.70	1
1,1-Dichloroethene	ND		ug/l	0.50	0.17	1
trans-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-02 Date Collected: 07/19/23 08:30

Client ID: GW-19 Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Trichloroethene	ND		ug/l	0.50	0.18	1
1,2-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,3-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,4-Dichlorobenzene	ND		ug/l	2.5	0.70	1
Methyl tert butyl ether	ND		ug/l	2.5	0.70	1
p/m-Xylene	ND		ug/l	2.5	0.70	1
o-Xylene	ND		ug/l	2.5	0.70	1
Xylenes, Total	ND		ug/l	2.5	0.70	1
cis-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1
1,2-Dichloroethene, Total	ND		ug/l	2.5	0.70	1
Dibromomethane	ND		ug/l	5.0	1.0	1
1,2,3-Trichloropropane	ND		ug/l	2.5	0.70	1
Acrylonitrile	ND		ug/l	5.0	1.5	1
Styrene	ND		ug/l	2.5	0.70	1
Dichlorodifluoromethane	ND		ug/l	5.0	1.0	1
Acetone	1.7	J	ug/l	5.0	1.5	1
Carbon disulfide	ND		ug/l	5.0	1.0	1
2-Butanone	ND		ug/l	5.0	1.9	1
Vinyl acetate	ND		ug/l	5.0	1.0	1
4-Methyl-2-pentanone	ND		ug/l	5.0	1.0	1
2-Hexanone	ND		ug/l	5.0	1.0	1
Bromochloromethane	ND		ug/l	2.5	0.70	1
2,2-Dichloropropane	ND		ug/l	2.5	0.70	1
1,2-Dibromoethane	ND		ug/l	2.0	0.65	1
1,3-Dichloropropane	ND		ug/l	2.5	0.70	1
1,1,1,2-Tetrachloroethane	ND		ug/l	2.5	0.70	1
Bromobenzene	ND		ug/l	2.5	0.70	1
n-Butylbenzene	ND		ug/l	2.5	0.70	1
sec-Butylbenzene	ND		ug/l	2.5	0.70	1
tert-Butylbenzene	ND		ug/l	2.5	0.70	1
o-Chlorotoluene	ND		ug/l	2.5	0.70	1
p-Chlorotoluene	ND		ug/l	2.5	0.70	1
1,2-Dibromo-3-chloropropane	ND		ug/l	2.5	0.70	1
Hexachlorobutadiene	ND		ug/l	2.5	0.70	1
Isopropylbenzene	ND		ug/l	2.5	0.70	1
p-Isopropyltoluene	ND		ug/l	2.5	0.70	1
Naphthalene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-02 Date Collected: 07/19/23 08:30

Client ID: GW-19 Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
n-Propylbenzene	ND		ug/l	2.5	0.70	1
1,2,3-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,3,5-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,4-Dioxane	ND		ug/l	250	61.	1
p-Diethylbenzene	ND		ug/l	2.0	0.70	1
p-Ethyltoluene	ND		ug/l	2.0	0.70	1
1,2,4,5-Tetramethylbenzene	ND		ug/l	2.0	0.54	1
Ethyl ether	ND		ug/l	2.5	0.70	1
trans-1,4-Dichloro-2-butene	ND		ug/l	2.5	0.70	1
Tentatively Identified Compounds						
No Tentatively Identified Compounds	ND		ug/l			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	104		70-130
Toluene-d8	99		70-130
4-Bromofluorobenzene	100		70-130
Dibromofluoromethane	102		70-130

Project Name: 100 MAIN ST.
Lab Number: L2341423
Project Number: 12461
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-03
Client ID: GW-20
Sample Location: WHITE PLAINS, NY

Date Collected: 07/19/23 14:20
Date Received: 07/19/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8260D
Analytical Date: 07/20/23 18:31
Analyst: PID

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Methylene chloride	ND		ug/l	2.5	0.70	1
1,1-Dichloroethane	ND		ug/l	2.5	0.70	1
Chloroform	ND		ug/l	2.5	0.70	1
Carbon tetrachloride	ND		ug/l	0.50	0.13	1
1,2-Dichloropropane	ND		ug/l	1.0	0.14	1
Dibromochloromethane	ND		ug/l	0.50	0.15	1
1,1,2-Trichloroethane	ND		ug/l	1.5	0.50	1
Tetrachloroethene	ND		ug/l	0.50	0.18	1
Chlorobenzene	ND		ug/l	2.5	0.70	1
Trichlorofluoromethane	ND		ug/l	2.5	0.70	1
1,2-Dichloroethane	ND		ug/l	0.50	0.13	1
1,1,1-Trichloroethane	ND		ug/l	2.5	0.70	1
Bromodichloromethane	ND		ug/l	0.50	0.19	1
trans-1,3-Dichloropropene	ND		ug/l	0.50	0.16	1
cis-1,3-Dichloropropene	ND		ug/l	0.50	0.14	1
1,3-Dichloropropene, Total	ND		ug/l	0.50	0.14	1
1,1-Dichloropropene	ND		ug/l	2.5	0.70	1
Bromoform	ND		ug/l	2.0	0.65	1
1,1,2,2-Tetrachloroethane	ND		ug/l	0.50	0.17	1
Benzene	ND		ug/l	0.50	0.16	1
Toluene	ND		ug/l	2.5	0.70	1
Ethylbenzene	ND		ug/l	2.5	0.70	1
Chloromethane	ND		ug/l	2.5	0.70	1
Bromomethane	ND		ug/l	2.5	0.70	1
Vinyl chloride	ND		ug/l	1.0	0.07	1
Chloroethane	ND		ug/l	2.5	0.70	1
1,1-Dichloroethene	ND		ug/l	0.50	0.17	1
trans-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-03 Date Collected: 07/19/23 14:20

Client ID: GW-20 Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Trichloroethene	ND		ug/l	0.50	0.18	1
1,2-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,3-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,4-Dichlorobenzene	ND		ug/l	2.5	0.70	1
Methyl tert butyl ether	ND		ug/l	2.5	0.70	1
p/m-Xylene	ND		ug/l	2.5	0.70	1
o-Xylene	ND		ug/l	2.5	0.70	1
Xylenes, Total	ND		ug/l	2.5	0.70	1
cis-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1
1,2-Dichloroethene, Total	ND		ug/l	2.5	0.70	1
Dibromomethane	ND		ug/l	5.0	1.0	1
1,2,3-Trichloropropane	ND		ug/l	2.5	0.70	1
Acrylonitrile	ND		ug/l	5.0	1.5	1
Styrene	ND		ug/l	2.5	0.70	1
Dichlorodifluoromethane	ND		ug/l	5.0	1.0	1
Acetone	ND		ug/l	5.0	1.5	1
Carbon disulfide	ND		ug/l	5.0	1.0	1
2-Butanone	ND		ug/l	5.0	1.9	1
Vinyl acetate	ND		ug/l	5.0	1.0	1
4-Methyl-2-pentanone	ND		ug/l	5.0	1.0	1
2-Hexanone	ND		ug/l	5.0	1.0	1
Bromochloromethane	ND		ug/l	2.5	0.70	1
2,2-Dichloropropane	ND		ug/l	2.5	0.70	1
1,2-Dibromoethane	ND		ug/l	2.0	0.65	1
1,3-Dichloropropane	ND		ug/l	2.5	0.70	1
1,1,1,2-Tetrachloroethane	ND		ug/l	2.5	0.70	1
Bromobenzene	ND		ug/l	2.5	0.70	1
n-Butylbenzene	ND		ug/l	2.5	0.70	1
sec-Butylbenzene	ND		ug/l	2.5	0.70	1
tert-Butylbenzene	ND		ug/l	2.5	0.70	1
o-Chlorotoluene	ND		ug/l	2.5	0.70	1
p-Chlorotoluene	ND		ug/l	2.5	0.70	1
1,2-Dibromo-3-chloropropane	ND		ug/l	2.5	0.70	1
Hexachlorobutadiene	ND		ug/l	2.5	0.70	1
Isopropylbenzene	ND		ug/l	2.5	0.70	1
p-Isopropyltoluene	ND		ug/l	2.5	0.70	1
Naphthalene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-03 Date Collected: 07/19/23 14:20

Client ID: GW-20 Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
n-Propylbenzene	ND		ug/l	2.5	0.70	1
1,2,3-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,3,5-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,4-Dioxane	ND		ug/l	250	61.	1
p-Diethylbenzene	ND		ug/l	2.0	0.70	1
p-Ethyltoluene	ND		ug/l	2.0	0.70	1
1,2,4,5-Tetramethylbenzene	ND		ug/l	2.0	0.54	1
Ethyl ether	ND		ug/l	2.5	0.70	1
trans-1,4-Dichloro-2-butene	ND		ug/l	2.5	0.70	1
Tentatively Identified Compounds						
No Tentatively Identified Compounds	ND		ug/l			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	104		70-130
Toluene-d8	97		70-130
4-Bromofluorobenzene	97		70-130
Dibromofluoromethane	100		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-04
Client ID: GW-21
Sample Location: WHITE PLAINS, NY

Date Collected: 07/19/23 11:20
Date Received: 07/19/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8260D
Analytical Date: 07/20/23 18:57
Analyst: PID

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Methylene chloride	ND		ug/l	2.5	0.70	1
1,1-Dichloroethane	ND		ug/l	2.5	0.70	1
Chloroform	ND		ug/l	2.5	0.70	1
Carbon tetrachloride	ND		ug/l	0.50	0.13	1
1,2-Dichloropropane	ND		ug/l	1.0	0.14	1
Dibromochloromethane	ND		ug/l	0.50	0.15	1
1,1,2-Trichloroethane	ND		ug/l	1.5	0.50	1
Tetrachloroethene	ND		ug/l	0.50	0.18	1
Chlorobenzene	ND		ug/l	2.5	0.70	1
Trichlorofluoromethane	ND		ug/l	2.5	0.70	1
1,2-Dichloroethane	ND		ug/l	0.50	0.13	1
1,1,1-Trichloroethane	ND		ug/l	2.5	0.70	1
Bromodichloromethane	ND		ug/l	0.50	0.19	1
trans-1,3-Dichloropropene	ND		ug/l	0.50	0.16	1
cis-1,3-Dichloropropene	ND		ug/l	0.50	0.14	1
1,3-Dichloropropene, Total	ND		ug/l	0.50	0.14	1
1,1-Dichloropropene	ND		ug/l	2.5	0.70	1
Bromoform	ND		ug/l	2.0	0.65	1
1,1,2,2-Tetrachloroethane	ND		ug/l	0.50	0.17	1
Benzene	ND		ug/l	0.50	0.16	1
Toluene	ND		ug/l	2.5	0.70	1
Ethylbenzene	ND		ug/l	2.5	0.70	1
Chloromethane	ND		ug/l	2.5	0.70	1
Bromomethane	ND		ug/l	2.5	0.70	1
Vinyl chloride	ND		ug/l	1.0	0.07	1
Chloroethane	ND		ug/l	2.5	0.70	1
1,1-Dichloroethene	ND		ug/l	0.50	0.17	1
trans-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-04 Date Collected: 07/19/23 11:20

Client ID: GW-21 Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Trichloroethene	ND		ug/l	0.50	0.18	1
1,2-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,3-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,4-Dichlorobenzene	ND		ug/l	2.5	0.70	1
Methyl tert butyl ether	ND		ug/l	2.5	0.70	1
p/m-Xylene	ND		ug/l	2.5	0.70	1
o-Xylene	ND		ug/l	2.5	0.70	1
Xylenes, Total	ND		ug/l	2.5	0.70	1
cis-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1
1,2-Dichloroethene, Total	ND		ug/l	2.5	0.70	1
Dibromomethane	ND		ug/l	5.0	1.0	1
1,2,3-Trichloropropane	ND		ug/l	2.5	0.70	1
Acrylonitrile	ND		ug/l	5.0	1.5	1
Styrene	ND		ug/l	2.5	0.70	1
Dichlorodifluoromethane	ND		ug/l	5.0	1.0	1
Acetone	1.8	J	ug/l	5.0	1.5	1
Carbon disulfide	ND		ug/l	5.0	1.0	1
2-Butanone	ND		ug/l	5.0	1.9	1
Vinyl acetate	ND		ug/l	5.0	1.0	1
4-Methyl-2-pentanone	ND		ug/l	5.0	1.0	1
2-Hexanone	ND		ug/l	5.0	1.0	1
Bromochloromethane	ND		ug/l	2.5	0.70	1
2,2-Dichloropropane	ND		ug/l	2.5	0.70	1
1,2-Dibromoethane	ND		ug/l	2.0	0.65	1
1,3-Dichloropropane	ND		ug/l	2.5	0.70	1
1,1,1,2-Tetrachloroethane	ND		ug/l	2.5	0.70	1
Bromobenzene	ND		ug/l	2.5	0.70	1
n-Butylbenzene	ND		ug/l	2.5	0.70	1
sec-Butylbenzene	ND		ug/l	2.5	0.70	1
tert-Butylbenzene	ND		ug/l	2.5	0.70	1
o-Chlorotoluene	ND		ug/l	2.5	0.70	1
p-Chlorotoluene	ND		ug/l	2.5	0.70	1
1,2-Dibromo-3-chloropropane	ND		ug/l	2.5	0.70	1
Hexachlorobutadiene	ND		ug/l	2.5	0.70	1
Isopropylbenzene	ND		ug/l	2.5	0.70	1
p-Isopropyltoluene	ND		ug/l	2.5	0.70	1
Naphthalene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-04 Date Collected: 07/19/23 11:20

Client ID: GW-21 Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
n-Propylbenzene	ND		ug/l	2.5	0.70	1
1,2,3-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,3,5-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,4-Dioxane	ND		ug/l	250	61.	1
p-Diethylbenzene	ND		ug/l	2.0	0.70	1
p-Ethyltoluene	ND		ug/l	2.0	0.70	1
1,2,4,5-Tetramethylbenzene	ND		ug/l	2.0	0.54	1
Ethyl ether	ND		ug/l	2.5	0.70	1
trans-1,4-Dichloro-2-butene	ND		ug/l	2.5	0.70	1
Tentatively Identified Compounds						
No Tentatively Identified Compounds	ND		ug/l			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	103		70-130
Toluene-d8	99		70-130
4-Bromofluorobenzene	98		70-130
Dibromofluoromethane	100		70-130

Project Name: 100 MAIN ST.
Lab Number: L2341423
Project Number: 12461
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-05
Client ID: GW-22
Sample Location: WHITE PLAINS, NY

Date Collected: 07/19/23 11:45
Date Received: 07/19/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8260D
Analytical Date: 07/20/23 19:23
Analyst: PID

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Methylene chloride	ND		ug/l	2.5	0.70	1
1,1-Dichloroethane	ND		ug/l	2.5	0.70	1
Chloroform	ND		ug/l	2.5	0.70	1
Carbon tetrachloride	ND		ug/l	0.50	0.13	1
1,2-Dichloropropane	ND		ug/l	1.0	0.14	1
Dibromochloromethane	ND		ug/l	0.50	0.15	1
1,1,2-Trichloroethane	ND		ug/l	1.5	0.50	1
Tetrachloroethene	ND		ug/l	0.50	0.18	1
Chlorobenzene	ND		ug/l	2.5	0.70	1
Trichlorofluoromethane	ND		ug/l	2.5	0.70	1
1,2-Dichloroethane	ND		ug/l	0.50	0.13	1
1,1,1-Trichloroethane	ND		ug/l	2.5	0.70	1
Bromodichloromethane	ND		ug/l	0.50	0.19	1
trans-1,3-Dichloropropene	ND		ug/l	0.50	0.16	1
cis-1,3-Dichloropropene	ND		ug/l	0.50	0.14	1
1,3-Dichloropropene, Total	ND		ug/l	0.50	0.14	1
1,1-Dichloropropene	ND		ug/l	2.5	0.70	1
Bromoform	ND		ug/l	2.0	0.65	1
1,1,2,2-Tetrachloroethane	ND		ug/l	0.50	0.17	1
Benzene	ND		ug/l	0.50	0.16	1
Toluene	ND		ug/l	2.5	0.70	1
Ethylbenzene	ND		ug/l	2.5	0.70	1
Chloromethane	ND		ug/l	2.5	0.70	1
Bromomethane	ND		ug/l	2.5	0.70	1
Vinyl chloride	ND		ug/l	1.0	0.07	1
Chloroethane	ND		ug/l	2.5	0.70	1
1,1-Dichloroethene	ND		ug/l	0.50	0.17	1
trans-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-05 Date Collected: 07/19/23 11:45

Client ID: GW-22 Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Trichloroethene	ND		ug/l	0.50	0.18	1
1,2-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,3-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,4-Dichlorobenzene	ND		ug/l	2.5	0.70	1
Methyl tert butyl ether	ND		ug/l	2.5	0.70	1
p/m-Xylene	ND		ug/l	2.5	0.70	1
o-Xylene	ND		ug/l	2.5	0.70	1
Xylenes, Total	ND		ug/l	2.5	0.70	1
cis-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1
1,2-Dichloroethene, Total	ND		ug/l	2.5	0.70	1
Dibromomethane	ND		ug/l	5.0	1.0	1
1,2,3-Trichloropropane	ND		ug/l	2.5	0.70	1
Acrylonitrile	ND		ug/l	5.0	1.5	1
Styrene	ND		ug/l	2.5	0.70	1
Dichlorodifluoromethane	ND		ug/l	5.0	1.0	1
Acetone	1.8	J	ug/l	5.0	1.5	1
Carbon disulfide	ND		ug/l	5.0	1.0	1
2-Butanone	ND		ug/l	5.0	1.9	1
Vinyl acetate	ND		ug/l	5.0	1.0	1
4-Methyl-2-pentanone	ND		ug/l	5.0	1.0	1
2-Hexanone	ND		ug/l	5.0	1.0	1
Bromochloromethane	ND		ug/l	2.5	0.70	1
2,2-Dichloropropane	ND		ug/l	2.5	0.70	1
1,2-Dibromoethane	ND		ug/l	2.0	0.65	1
1,3-Dichloropropane	ND		ug/l	2.5	0.70	1
1,1,1,2-Tetrachloroethane	ND		ug/l	2.5	0.70	1
Bromobenzene	ND		ug/l	2.5	0.70	1
n-Butylbenzene	ND		ug/l	2.5	0.70	1
sec-Butylbenzene	ND		ug/l	2.5	0.70	1
tert-Butylbenzene	ND		ug/l	2.5	0.70	1
o-Chlorotoluene	ND		ug/l	2.5	0.70	1
p-Chlorotoluene	ND		ug/l	2.5	0.70	1
1,2-Dibromo-3-chloropropane	ND		ug/l	2.5	0.70	1
Hexachlorobutadiene	ND		ug/l	2.5	0.70	1
Isopropylbenzene	ND		ug/l	2.5	0.70	1
p-Isopropyltoluene	ND		ug/l	2.5	0.70	1
Naphthalene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-05 Date Collected: 07/19/23 11:45

Client ID: GW-22 Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
n-Propylbenzene	ND		ug/l	2.5	0.70	1
1,2,3-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,3,5-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,4-Dioxane	ND		ug/l	250	61.	1
p-Diethylbenzene	ND		ug/l	2.0	0.70	1
p-Ethyltoluene	ND		ug/l	2.0	0.70	1
1,2,4,5-Tetramethylbenzene	ND		ug/l	2.0	0.54	1
Ethyl ether	ND		ug/l	2.5	0.70	1
trans-1,4-Dichloro-2-butene	ND		ug/l	2.5	0.70	1
Tentatively Identified Compounds						
No Tentatively Identified Compounds	ND		ug/l			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	104		70-130
Toluene-d8	99		70-130
4-Bromofluorobenzene	98		70-130
Dibromofluoromethane	100		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-06 Date Collected: 07/19/23 13:50
Client ID: GW-23 Date Received: 07/19/23
Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8260D
Analytical Date: 07/20/23 19:50
Analyst: PID

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Methylene chloride	ND		ug/l	2.5	0.70	1
1,1-Dichloroethane	ND		ug/l	2.5	0.70	1
Chloroform	ND		ug/l	2.5	0.70	1
Carbon tetrachloride	ND		ug/l	0.50	0.13	1
1,2-Dichloropropane	ND		ug/l	1.0	0.14	1
Dibromochloromethane	ND		ug/l	0.50	0.15	1
1,1,2-Trichloroethane	ND		ug/l	1.5	0.50	1
Tetrachloroethene	ND		ug/l	0.50	0.18	1
Chlorobenzene	ND		ug/l	2.5	0.70	1
Trichlorofluoromethane	ND		ug/l	2.5	0.70	1
1,2-Dichloroethane	ND		ug/l	0.50	0.13	1
1,1,1-Trichloroethane	ND		ug/l	2.5	0.70	1
Bromodichloromethane	ND		ug/l	0.50	0.19	1
trans-1,3-Dichloropropene	ND		ug/l	0.50	0.16	1
cis-1,3-Dichloropropene	ND		ug/l	0.50	0.14	1
1,3-Dichloropropene, Total	ND		ug/l	0.50	0.14	1
1,1-Dichloropropene	ND		ug/l	2.5	0.70	1
Bromoform	ND		ug/l	2.0	0.65	1
1,1,2,2-Tetrachloroethane	ND		ug/l	0.50	0.17	1
Benzene	ND		ug/l	0.50	0.16	1
Toluene	ND		ug/l	2.5	0.70	1
Ethylbenzene	ND		ug/l	2.5	0.70	1
Chloromethane	ND		ug/l	2.5	0.70	1
Bromomethane	0.84	J	ug/l	2.5	0.70	1
Vinyl chloride	ND		ug/l	1.0	0.07	1
Chloroethane	ND		ug/l	2.5	0.70	1
1,1-Dichloroethene	ND		ug/l	0.50	0.17	1
trans-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-06 Date Collected: 07/19/23 13:50

Client ID: GW-23 Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Trichloroethene	ND		ug/l	0.50	0.18	1
1,2-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,3-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,4-Dichlorobenzene	ND		ug/l	2.5	0.70	1
Methyl tert butyl ether	ND		ug/l	2.5	0.70	1
p/m-Xylene	ND		ug/l	2.5	0.70	1
o-Xylene	ND		ug/l	2.5	0.70	1
Xylenes, Total	ND		ug/l	2.5	0.70	1
cis-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1
1,2-Dichloroethene, Total	ND		ug/l	2.5	0.70	1
Dibromomethane	ND		ug/l	5.0	1.0	1
1,2,3-Trichloropropane	ND		ug/l	2.5	0.70	1
Acrylonitrile	ND		ug/l	5.0	1.5	1
Styrene	ND		ug/l	2.5	0.70	1
Dichlorodifluoromethane	ND		ug/l	5.0	1.0	1
Acetone	1.6	J	ug/l	5.0	1.5	1
Carbon disulfide	ND		ug/l	5.0	1.0	1
2-Butanone	ND		ug/l	5.0	1.9	1
Vinyl acetate	ND		ug/l	5.0	1.0	1
4-Methyl-2-pentanone	ND		ug/l	5.0	1.0	1
2-Hexanone	ND		ug/l	5.0	1.0	1
Bromochloromethane	ND		ug/l	2.5	0.70	1
2,2-Dichloropropane	ND		ug/l	2.5	0.70	1
1,2-Dibromoethane	ND		ug/l	2.0	0.65	1
1,3-Dichloropropane	ND		ug/l	2.5	0.70	1
1,1,1,2-Tetrachloroethane	ND		ug/l	2.5	0.70	1
Bromobenzene	ND		ug/l	2.5	0.70	1
n-Butylbenzene	ND		ug/l	2.5	0.70	1
sec-Butylbenzene	ND		ug/l	2.5	0.70	1
tert-Butylbenzene	ND		ug/l	2.5	0.70	1
o-Chlorotoluene	ND		ug/l	2.5	0.70	1
p-Chlorotoluene	ND		ug/l	2.5	0.70	1
1,2-Dibromo-3-chloropropane	ND		ug/l	2.5	0.70	1
Hexachlorobutadiene	ND		ug/l	2.5	0.70	1
Isopropylbenzene	ND		ug/l	2.5	0.70	1
p-Isopropyltoluene	ND		ug/l	2.5	0.70	1
Naphthalene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-06 Date Collected: 07/19/23 13:50

Client ID: GW-23 Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
n-Propylbenzene	ND		ug/l	2.5	0.70	1
1,2,3-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,3,5-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,4-Dioxane	ND		ug/l	250	61.	1
p-Diethylbenzene	ND		ug/l	2.0	0.70	1
p-Ethyltoluene	ND		ug/l	2.0	0.70	1
1,2,4,5-Tetramethylbenzene	ND		ug/l	2.0	0.54	1
Ethyl ether	ND		ug/l	2.5	0.70	1
trans-1,4-Dichloro-2-butene	ND		ug/l	2.5	0.70	1
Tentatively Identified Compounds						
Total TIC Compounds	1.10	J	ug/l			1
Unknown	1.10	J	ug/l			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	105		70-130
Toluene-d8	97		70-130
4-Bromofluorobenzene	98		70-130
Dibromofluoromethane	100		70-130

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-07
Client ID: SB-51P (3.5-4)
Sample Location: WHITE PLAINS, NY

Date Collected: 07/19/23 15:00
Date Received: 07/19/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8260D
Analytical Date: 07/21/23 12:31
Analyst: JIC
Percent Solids: 93%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Methylene chloride	ND		ug/kg	4.6	2.1	1
1,1-Dichloroethane	ND		ug/kg	0.92	0.13	1
Chloroform	ND		ug/kg	1.4	0.13	1
Carbon tetrachloride	ND		ug/kg	0.92	0.21	1
1,2-Dichloropropane	ND		ug/kg	0.92	0.12	1
Dibromochloromethane	ND		ug/kg	0.92	0.13	1
1,1,2-Trichloroethane	ND		ug/kg	0.92	0.25	1
Tetrachloroethene	ND		ug/kg	0.46	0.18	1
Chlorobenzene	ND		ug/kg	0.46	0.12	1
Trichlorofluoromethane	ND		ug/kg	3.7	0.64	1
1,2-Dichloroethane	ND		ug/kg	0.92	0.24	1
1,1,1-Trichloroethane	ND		ug/kg	0.46	0.15	1
Bromodichloromethane	ND		ug/kg	0.46	0.10	1
trans-1,3-Dichloropropene	ND		ug/kg	0.92	0.25	1
cis-1,3-Dichloropropene	ND		ug/kg	0.46	0.14	1
1,3-Dichloropropene, Total	ND		ug/kg	0.46	0.14	1
1,1-Dichloropropene	ND		ug/kg	0.46	0.15	1
Bromoform	ND		ug/kg	3.7	0.23	1
1,1,2,2-Tetrachloroethane	ND		ug/kg	0.46	0.15	1
Benzene	ND		ug/kg	0.46	0.15	1
Toluene	ND		ug/kg	0.92	0.50	1
Ethylbenzene	ND		ug/kg	0.92	0.13	1
Chloromethane	ND		ug/kg	3.7	0.86	1
Bromomethane	ND		ug/kg	1.8	0.54	1
Vinyl chloride	ND		ug/kg	0.92	0.31	1
Chloroethane	ND		ug/kg	1.8	0.42	1
1,1-Dichloroethene	ND		ug/kg	0.92	0.22	1
trans-1,2-Dichloroethene	ND		ug/kg	1.4	0.13	1

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-07 Date Collected: 07/19/23 15:00

Client ID: SB-51P (3.5-4) Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
Trichloroethene	ND		ug/kg	0.46	0.13	1
1,2-Dichlorobenzene	ND		ug/kg	1.8	0.13	1
1,3-Dichlorobenzene	ND		ug/kg	1.8	0.14	1
1,4-Dichlorobenzene	ND		ug/kg	1.8	0.16	1
Methyl tert butyl ether	ND		ug/kg	1.8	0.18	1
p/m-Xylene	ND		ug/kg	1.8	0.52	1
o-Xylene	ND		ug/kg	0.92	0.27	1
Xylenes, Total	ND		ug/kg	0.92	0.27	1
cis-1,2-Dichloroethene	ND		ug/kg	0.92	0.16	1
1,2-Dichloroethene, Total	ND		ug/kg	0.92	0.13	1
Dibromomethane	ND		ug/kg	1.8	0.22	1
Styrene	ND		ug/kg	0.92	0.18	1
Dichlorodifluoromethane	ND		ug/kg	9.2	0.84	1
Acetone	ND		ug/kg	9.2	4.4	1
Carbon disulfide	ND		ug/kg	9.2	4.2	1
2-Butanone	ND		ug/kg	9.2	2.0	1
Vinyl acetate	ND		ug/kg	9.2	2.0	1
4-Methyl-2-pentanone	ND		ug/kg	9.2	1.2	1
1,2,3-Trichloropropane	ND		ug/kg	1.8	0.12	1
2-Hexanone	ND		ug/kg	9.2	1.1	1
Bromochloromethane	ND		ug/kg	1.8	0.19	1
2,2-Dichloropropane	ND		ug/kg	1.8	0.19	1
1,2-Dibromoethane	ND		ug/kg	0.92	0.26	1
1,3-Dichloropropane	ND		ug/kg	1.8	0.15	1
1,1,1,2-Tetrachloroethane	ND		ug/kg	0.46	0.12	1
Bromobenzene	ND		ug/kg	1.8	0.13	1
n-Butylbenzene	ND		ug/kg	0.92	0.15	1
sec-Butylbenzene	ND		ug/kg	0.92	0.13	1
tert-Butylbenzene	ND		ug/kg	1.8	0.11	1
o-Chlorotoluene	ND		ug/kg	1.8	0.18	1
p-Chlorotoluene	ND		ug/kg	1.8	0.10	1
1,2-Dibromo-3-chloropropane	ND		ug/kg	2.8	0.92	1
Hexachlorobutadiene	ND		ug/kg	3.7	0.16	1
Isopropylbenzene	ND		ug/kg	0.92	0.10	1
p-Isopropyltoluene	ND		ug/kg	0.92	0.10	1
Naphthalene	ND		ug/kg	3.7	0.60	1
Acrylonitrile	ND		ug/kg	3.7	1.0	1

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-07 Date Collected: 07/19/23 15:00

Client ID: SB-51P (3.5-4) Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by EPA 5035 Low - Westborough Lab						
n-Propylbenzene	ND		ug/kg	0.92	0.16	1
1,2,3-Trichlorobenzene	ND		ug/kg	1.8	0.30	1
1,2,4-Trichlorobenzene	ND		ug/kg	1.8	0.25	1
1,3,5-Trimethylbenzene	ND		ug/kg	1.8	0.18	1
1,2,4-Trimethylbenzene	ND		ug/kg	1.8	0.31	1
1,4-Dioxane	ND		ug/kg	74	32.	1
p-Diethylbenzene	ND		ug/kg	1.8	0.16	1
p-Ethyltoluene	ND		ug/kg	1.8	0.35	1
1,2,4,5-Tetramethylbenzene	ND		ug/kg	1.8	0.18	1
Ethyl ether	ND		ug/kg	1.8	0.31	1
trans-1,4-Dichloro-2-butene	ND		ug/kg	4.6	1.3	1
Tentatively Identified Compounds						
Total TIC Compounds	2.46	J	ug/kg			1
Unknown	2.46	J	ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	105		70-130
Toluene-d8	92		70-130
4-Bromofluorobenzene	93		70-130
Dibromofluoromethane	110		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 07/20/23 17:11
Analyst: TMS

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by GC/MS - Westborough Lab for sample(s): 01-06 Batch: WG1806034-5					
Methylene chloride	ND		ug/l	2.5	0.70
1,1-Dichloroethane	ND		ug/l	2.5	0.70
Chloroform	ND		ug/l	2.5	0.70
Carbon tetrachloride	ND		ug/l	0.50	0.13
1,2-Dichloropropane	ND		ug/l	1.0	0.14
Dibromochloromethane	ND		ug/l	0.50	0.15
1,1,2-Trichloroethane	ND		ug/l	1.5	0.50
Tetrachloroethene	ND		ug/l	0.50	0.18
Chlorobenzene	ND		ug/l	2.5	0.70
Trichlorofluoromethane	ND		ug/l	2.5	0.70
1,2-Dichloroethane	ND		ug/l	0.50	0.13
1,1,1-Trichloroethane	ND		ug/l	2.5	0.70
Bromodichloromethane	ND		ug/l	0.50	0.19
trans-1,3-Dichloropropene	ND		ug/l	0.50	0.16
cis-1,3-Dichloropropene	ND		ug/l	0.50	0.14
1,3-Dichloropropene, Total	ND		ug/l	0.50	0.14
1,1-Dichloropropene	ND		ug/l	2.5	0.70
Bromoform	ND		ug/l	2.0	0.65
1,1,2,2-Tetrachloroethane	ND		ug/l	0.50	0.17
Benzene	ND		ug/l	0.50	0.16
Toluene	ND		ug/l	2.5	0.70
Ethylbenzene	ND		ug/l	2.5	0.70
Chloromethane	ND		ug/l	2.5	0.70
Bromomethane	ND		ug/l	2.5	0.70
Vinyl chloride	ND		ug/l	1.0	0.07
Chloroethane	ND		ug/l	2.5	0.70
1,1-Dichloroethene	ND		ug/l	0.50	0.17
trans-1,2-Dichloroethene	ND		ug/l	2.5	0.70
Trichloroethene	ND		ug/l	0.50	0.18

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 07/20/23 17:11
Analyst: TMS

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by GC/MS - Westborough Lab for sample(s): 01-06 Batch: WG1806034-5					
1,2-Dichlorobenzene	ND		ug/l	2.5	0.70
1,3-Dichlorobenzene	ND		ug/l	2.5	0.70
1,4-Dichlorobenzene	ND		ug/l	2.5	0.70
Methyl tert butyl ether	ND		ug/l	2.5	0.70
p/m-Xylene	ND		ug/l	2.5	0.70
o-Xylene	ND		ug/l	2.5	0.70
Xylenes, Total	ND		ug/l	2.5	0.70
cis-1,2-Dichloroethene	ND		ug/l	2.5	0.70
1,2-Dichloroethene, Total	ND		ug/l	2.5	0.70
Dibromomethane	ND		ug/l	5.0	1.0
1,2,3-Trichloropropane	ND		ug/l	2.5	0.70
Acrylonitrile	ND		ug/l	5.0	1.5
Styrene	ND		ug/l	2.5	0.70
Dichlorodifluoromethane	ND		ug/l	5.0	1.0
Acetone	ND		ug/l	5.0	1.5
Carbon disulfide	ND		ug/l	5.0	1.0
2-Butanone	ND		ug/l	5.0	1.9
Vinyl acetate	ND		ug/l	5.0	1.0
4-Methyl-2-pentanone	ND		ug/l	5.0	1.0
2-Hexanone	ND		ug/l	5.0	1.0
Bromochloromethane	ND		ug/l	2.5	0.70
2,2-Dichloropropane	ND		ug/l	2.5	0.70
1,2-Dibromoethane	ND		ug/l	2.0	0.65
1,3-Dichloropropane	ND		ug/l	2.5	0.70
1,1,1,2-Tetrachloroethane	ND		ug/l	2.5	0.70
Bromobenzene	ND		ug/l	2.5	0.70
n-Butylbenzene	ND		ug/l	2.5	0.70
sec-Butylbenzene	ND		ug/l	2.5	0.70
tert-Butylbenzene	ND		ug/l	2.5	0.70

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 07/20/23 17:11
Analyst: TMS

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by GC/MS - Westborough Lab for sample(s): 01-06 Batch: WG1806034-5					
o-Chlorotoluene	ND		ug/l	2.5	0.70
p-Chlorotoluene	ND		ug/l	2.5	0.70
1,2-Dibromo-3-chloropropane	ND		ug/l	2.5	0.70
Hexachlorobutadiene	ND		ug/l	2.5	0.70
Isopropylbenzene	ND		ug/l	2.5	0.70
p-Isopropyltoluene	ND		ug/l	2.5	0.70
Naphthalene	ND		ug/l	2.5	0.70
n-Propylbenzene	ND		ug/l	2.5	0.70
1,2,3-Trichlorobenzene	ND		ug/l	2.5	0.70
1,2,4-Trichlorobenzene	ND		ug/l	2.5	0.70
1,3,5-Trimethylbenzene	ND		ug/l	2.5	0.70
1,2,4-Trimethylbenzene	ND		ug/l	2.5	0.70
1,4-Dioxane	ND		ug/l	250	61.
p-Diethylbenzene	ND		ug/l	2.0	0.70
p-Ethyltoluene	ND		ug/l	2.0	0.70
1,2,4,5-Tetramethylbenzene	ND		ug/l	2.0	0.54
Ethyl ether	ND		ug/l	2.5	0.70
trans-1,4-Dichloro-2-butene	ND		ug/l	2.5	0.70
Tentatively Identified Compounds					
No Tentatively Identified Compounds	ND		ug/l		

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 07/20/23 17:11
Analyst: TMS

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by GC/MS - Westborough Lab for sample(s): 01-06 Batch: WG1806034-5					

Surrogate	%Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	102		70-130
Toluene-d8	99		70-130
4-Bromofluorobenzene	98		70-130
Dibromofluoromethane	100		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 07/21/23 08:56
Analyst: MKS

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by EPA 5035 Low - Westborough Lab for sample(s): 07 Batch: WG1806128-5					
Methylene chloride	ND		ug/kg	5.0	2.3
1,1-Dichloroethane	ND		ug/kg	1.0	0.14
Chloroform	ND		ug/kg	1.5	0.14
Carbon tetrachloride	ND		ug/kg	1.0	0.23
1,2-Dichloropropane	ND		ug/kg	1.0	0.12
Dibromochloromethane	ND		ug/kg	1.0	0.14
1,1,2-Trichloroethane	ND		ug/kg	1.0	0.27
Tetrachloroethene	ND		ug/kg	0.50	0.20
Chlorobenzene	ND		ug/kg	0.50	0.13
Trichlorofluoromethane	ND		ug/kg	4.0	0.70
1,2-Dichloroethane	ND		ug/kg	1.0	0.26
1,1,1-Trichloroethane	ND		ug/kg	0.50	0.17
Bromodichloromethane	ND		ug/kg	0.50	0.11
trans-1,3-Dichloropropene	ND		ug/kg	1.0	0.27
cis-1,3-Dichloropropene	ND		ug/kg	0.50	0.16
1,3-Dichloropropene, Total	ND		ug/kg	0.50	0.16
1,1-Dichloropropene	ND		ug/kg	0.50	0.16
Bromoform	ND		ug/kg	4.0	0.25
1,1,2,2-Tetrachloroethane	ND		ug/kg	0.50	0.17
Benzene	ND		ug/kg	0.50	0.17
Toluene	ND		ug/kg	1.0	0.54
Ethylbenzene	ND		ug/kg	1.0	0.14
Chloromethane	ND		ug/kg	4.0	0.93
Bromomethane	ND		ug/kg	2.0	0.58
Vinyl chloride	ND		ug/kg	1.0	0.34
Chloroethane	ND		ug/kg	2.0	0.45
1,1-Dichloroethene	ND		ug/kg	1.0	0.24
trans-1,2-Dichloroethene	ND		ug/kg	1.5	0.14
Trichloroethene	ND		ug/kg	0.50	0.14

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 07/21/23 08:56
Analyst: MKS

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by EPA 5035 Low - Westborough Lab for sample(s): 07 Batch: WG1806128-5					
1,2-Dichlorobenzene	ND		ug/kg	2.0	0.14
1,3-Dichlorobenzene	ND		ug/kg	2.0	0.15
1,4-Dichlorobenzene	ND		ug/kg	2.0	0.17
Methyl tert butyl ether	ND		ug/kg	2.0	0.20
p/m-Xylene	ND		ug/kg	2.0	0.56
o-Xylene	ND		ug/kg	1.0	0.29
Xylenes, Total	ND		ug/kg	1.0	0.29
cis-1,2-Dichloroethene	ND		ug/kg	1.0	0.18
1,2-Dichloroethene, Total	ND		ug/kg	1.0	0.14
Dibromomethane	ND		ug/kg	2.0	0.24
Styrene	ND		ug/kg	1.0	0.20
Dichlorodifluoromethane	ND		ug/kg	10	0.92
Acetone	ND		ug/kg	10	4.8
Carbon disulfide	ND		ug/kg	10	4.6
2-Butanone	ND		ug/kg	10	2.2
Vinyl acetate	ND		ug/kg	10	2.2
4-Methyl-2-pentanone	ND		ug/kg	10	1.3
1,2,3-Trichloropropane	ND		ug/kg	2.0	0.13
2-Hexanone	ND		ug/kg	10	1.2
Bromochloromethane	ND		ug/kg	2.0	0.20
2,2-Dichloropropane	ND		ug/kg	2.0	0.20
1,2-Dibromoethane	ND		ug/kg	1.0	0.28
1,3-Dichloropropane	ND		ug/kg	2.0	0.17
1,1,1,2-Tetrachloroethane	ND		ug/kg	0.50	0.13
Bromobenzene	ND		ug/kg	2.0	0.14
n-Butylbenzene	ND		ug/kg	1.0	0.17
sec-Butylbenzene	ND		ug/kg	1.0	0.15
tert-Butylbenzene	ND		ug/kg	2.0	0.12
o-Chlorotoluene	ND		ug/kg	2.0	0.19

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 07/21/23 08:56
Analyst: MKS

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by EPA 5035 Low - Westborough Lab for sample(s): 07 Batch: WG1806128-5					
p-Chlorotoluene	ND		ug/kg	2.0	0.11
1,2-Dibromo-3-chloropropane	ND		ug/kg	3.0	1.0
Hexachlorobutadiene	ND		ug/kg	4.0	0.17
Isopropylbenzene	ND		ug/kg	1.0	0.11
p-Isopropyltoluene	ND		ug/kg	1.0	0.11
Naphthalene	ND		ug/kg	4.0	0.65
Acrylonitrile	ND		ug/kg	4.0	1.2
n-Propylbenzene	ND		ug/kg	1.0	0.17
1,2,3-Trichlorobenzene	ND		ug/kg	2.0	0.32
1,2,4-Trichlorobenzene	ND		ug/kg	2.0	0.27
1,3,5-Trimethylbenzene	ND		ug/kg	2.0	0.19
1,2,4-Trimethylbenzene	ND		ug/kg	2.0	0.33
1,4-Dioxane	ND		ug/kg	80	35.
p-Diethylbenzene	ND		ug/kg	2.0	0.18
p-Ethyltoluene	ND		ug/kg	2.0	0.38
1,2,4,5-Tetramethylbenzene	ND		ug/kg	2.0	0.19
Ethyl ether	ND		ug/kg	2.0	0.34
trans-1,4-Dichloro-2-butene	ND		ug/kg	5.0	1.4

Tentatively Identified Compounds

Total TIC Compounds	3.32	J	ug/kg
Unknown	3.32	J	ug/kg

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 07/21/23 08:56
Analyst: MKS

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by EPA 5035 Low - Westborough Lab for sample(s): 07 Batch: WG1806128-5					

Surrogate	%Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	118		70-130
Toluene-d8	93		70-130
4-Bromofluorobenzene	94		70-130
Dibromofluoromethane	117		70-130

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341423
Report Date: 07/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by GC/MS - Westborough Lab Associated sample(s): 01-06 Batch: WG1806034-3 WG1806034-4								
Methylene chloride	100		100		70-130	0		20
1,1-Dichloroethane	110		110		70-130	0		20
Chloroform	110		110		70-130	0		20
Carbon tetrachloride	110		110		63-132	0		20
1,2-Dichloropropane	110		110		70-130	0		20
Dibromochloromethane	110		110		63-130	0		20
1,1,2-Trichloroethane	120		110		70-130	9		20
Tetrachloroethene	110		110		70-130	0		20
Chlorobenzene	110		110		75-130	0		20
Trichlorofluoromethane	110		110		62-150	0		20
1,2-Dichloroethane	110		110		70-130	0		20
1,1,1-Trichloroethane	110		110		67-130	0		20
Bromodichloromethane	110		110		67-130	0		20
trans-1,3-Dichloropropene	110		110		70-130	0		20
cis-1,3-Dichloropropene	110		110		70-130	0		20
1,1-Dichloropropene	110		110		70-130	0		20
Bromoform	110		110		54-136	0		20
1,1,2,2-Tetrachloroethane	120		120		67-130	0		20
Benzene	110		110		70-130	0		20
Toluene	110		110		70-130	0		20
Ethylbenzene	110		110		70-130	0		20
Chloromethane	120		120		64-130	0		20
Bromomethane	100		130		39-139	**26**	Q	20

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341423
Report Date: 07/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by GC/MS - Westborough Lab Associated sample(s): 01-06 Batch: WG1806034-3 WG1806034-4								
Vinyl chloride	110		110		55-140	0		20
Chloroethane	100		100		55-138	0		20
1,1-Dichloroethene	110		110		61-145	0		20
trans-1,2-Dichloroethene	110		110		70-130	0		20
Trichloroethene	110		110		70-130	0		20
1,2-Dichlorobenzene	110		110		70-130	0		20
1,3-Dichlorobenzene	110		110		70-130	0		20
1,4-Dichlorobenzene	100		100		70-130	0		20
Methyl tert butyl ether	120		110		63-130	9		20
p/m-Xylene	110		110		70-130	0		20
o-Xylene	110		110		70-130	0		20
cis-1,2-Dichloroethene	110		110		70-130	0		20
Dibromomethane	110		110		70-130	0		20
1,2,3-Trichloropropane	110		100		64-130	10		20
Acrylonitrile	130		120		70-130	8		20
Styrene	110		110		70-130	0		20
Dichlorodifluoromethane	110		110		36-147	0		20
Acetone	130		110		58-148	17		20
Carbon disulfide	110		110		51-130	0		20
2-Butanone	130		130		63-138	0		20
Vinyl acetate	**160**	Q	**150**	Q	70-130	6		20
4-Methyl-2-pentanone	120		120		59-130	0		20
2-Hexanone	120		120		57-130	0		20

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341423
Report Date: 07/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by GC/MS - Westborough Lab Associated sample(s): 01-06 Batch: WG1806034-3 WG1806034-4								
Bromochloromethane	110		110		70-130	0		20
2,2-Dichloropropane	120		110		63-133	9		20
1,2-Dibromoethane	120		110		70-130	9		20
1,3-Dichloropropane	110		110		70-130	0		20
1,1,1,2-Tetrachloroethane	110		110		64-130	0		20
Bromobenzene	100		100		70-130	0		20
n-Butylbenzene	110		110		53-136	0		20
sec-Butylbenzene	110		110		70-130	0		20
tert-Butylbenzene	110		110		70-130	0		20
o-Chlorotoluene	100		100		70-130	0		20
p-Chlorotoluene	110		100		70-130	10		20
1,2-Dibromo-3-chloropropane	110		110		41-144	0		20
Hexachlorobutadiene	100		100		63-130	0		20
Isopropylbenzene	110		110		70-130	0		20
p-Isopropyltoluene	110		110		70-130	0		20
Naphthalene	120		120		70-130	0		20
n-Propylbenzene	110		110		69-130	0		20
1,2,3-Trichlorobenzene	110		110		70-130	0		20
1,2,4-Trichlorobenzene	110		110		70-130	0		20
1,3,5-Trimethylbenzene	110		100		64-130	10		20
1,2,4-Trimethylbenzene	110		110		70-130	0		20
1,4-Dioxane	136		140		56-162	3		20
p-Diethylbenzene	110		110		70-130	0		20

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2341423

Report Date: 07/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by GC/MS - Westborough Lab Associated sample(s): 01-06 Batch: WG1806034-3 WG1806034-4								
p-Ethyltoluene	110		110		70-130	0		20
1,2,4,5-Tetramethylbenzene	110		110		70-130	0		20
Ethyl ether	110		110		59-134	0		20
trans-1,4-Dichloro-2-butene	120		110		70-130	9		20

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
1,2-Dichloroethane-d4	103		101		70-130
Toluene-d8	99		99		70-130
4-Bromofluorobenzene	98		98		70-130
Dibromofluoromethane	101		100		70-130

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2341423

Report Date: 07/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by EPA 5035 Low - Westborough Lab Associated sample(s): 07 Batch: WG1806128-3 WG1806128-4								
Methylene chloride	102		97		70-130	5		30
1,1-Dichloroethane	105		103		70-130	2		30
Chloroform	93		94		70-130	1		30
Carbon tetrachloride	115		112		70-130	3		30
1,2-Dichloropropane	96		96		70-130	0		30
Dibromochloromethane	91		90		70-130	1		30
1,1,2-Trichloroethane	88		90		70-130	2		30
Tetrachloroethene	91		88		70-130	3		30
Chlorobenzene	95		94		70-130	1		30
Trichlorofluoromethane	103		101		70-139	2		30
1,2-Dichloroethane	99		100		70-130	1		30
1,1,1-Trichloroethane	116		115		70-130	1		30
Bromodichloromethane	106		106		70-130	0		30
trans-1,3-Dichloropropene	89		89		70-130	0		30
cis-1,3-Dichloropropene	101		100		70-130	1		30
1,1-Dichloropropene	90		88		70-130	2		30
Bromoform	87		86		70-130	1		30
1,1,2,2-Tetrachloroethane	**63**	Q	**61**	Q	70-130	3		30
Benzene	104		102		70-130	2		30
Toluene	91		90		70-130	1		30
Ethylbenzene	96		95		70-130	1		30
Chloromethane	**141**	Q	**148**	Q	52-130	5		30
Bromomethane	118		117		57-147	1		30

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2341423

Report Date: 07/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by EPA 5035 Low - Westborough Lab Associated sample(s): 07 Batch: WG1806128-3 WG1806128-4								
Vinyl chloride	124		130		67-130	5		30
Chloroethane	118		118		50-151	0		30
1,1-Dichloroethene	109		110		65-135	1		30
trans-1,2-Dichloroethene	93		90		70-130	3		30
Trichloroethene	98		96		70-130	2		30
1,2-Dichlorobenzene	90		89		70-130	1		30
1,3-Dichlorobenzene	91		89		70-130	2		30
1,4-Dichlorobenzene	91		90		70-130	1		30
Methyl tert butyl ether	105		108		66-130	3		30
p/m-Xylene	104		103		70-130	1		30
o-Xylene	102		102		70-130	0		30
cis-1,2-Dichloroethene	94		92		70-130	2		30
Dibromomethane	97		98		70-130	1		30
Styrene	100		99		70-130	1		30
Dichlorodifluoromethane	144		143		30-146	1		30
Acetone	118		123		54-140	4		30
Carbon disulfide	124		121		59-130	2		30
2-Butanone	99		104		70-130	5		30
Vinyl acetate	83		83		70-130	0		30
4-Methyl-2-pentanone	82		84		70-130	2		30
1,2,3-Trichloropropane	75		76		68-130	1		30
2-Hexanone	84		88		70-130	5		30
Bromochloromethane	106		104		70-130	2		30

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341423
Report Date: 07/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by EPA 5035 Low - Westborough Lab Associated sample(s): 07 Batch: WG1806128-3 WG1806128-4								
2,2-Dichloropropane	108		106		70-130	2		30
1,2-Dibromoethane	80		80		70-130	0		30
1,3-Dichloropropane	84		85		69-130	1		30
1,1,1,2-Tetrachloroethane	93		92		70-130	1		30
Bromobenzene	85		84		70-130	1		30
n-Butylbenzene	96		94		70-130	2		30
sec-Butylbenzene	91		89		70-130	2		30
tert-Butylbenzene	90		88		70-130	2		30
o-Chlorotoluene	87		86		70-130	1		30
p-Chlorotoluene	88		87		70-130	1		30
1,2-Dibromo-3-chloropropane	83		83		68-130	0		30
Hexachlorobutadiene	104		99		67-130	5		30
Isopropylbenzene	86		84		70-130	2		30
p-Isopropyltoluene	95		92		70-130	3		30
Naphthalene	81		81		70-130	0		30
Acrylonitrile	104		110		70-130	6		30
n-Propylbenzene	90		88		70-130	2		30
1,2,3-Trichlorobenzene	89		87		70-130	2		30
1,2,4-Trichlorobenzene	94		90		70-130	4		30
1,3,5-Trimethylbenzene	98		96		70-130	2		30
1,2,4-Trimethylbenzene	96		93		70-130	3		30
1,4-Dioxane	105		111		65-136	6		30
p-Diethylbenzene	98		96		70-130	2		30

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by EPA 5035 Low - Westborough Lab Associated sample(s): 07 Batch: WG1806128-3 WG1806128-4								
p-Ethyltoluene	94		92		70-130	2		30
1,2,4,5-Tetramethylbenzene	81		77		70-130	5		30
Ethyl ether	94		103		67-130	9		30
trans-1,4-Dichloro-2-butene	82		84		70-130	2		30

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
1,2-Dichloroethane-d4	97		99		70-130
Toluene-d8	93		94		70-130
4-Bromofluorobenzene	90		89		70-130
Dibromofluoromethane	97		98		70-130

SEMIVOLATILES

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-01
Client ID: GW-18
Sample Location: WHITE PLAINS, NY

Date Collected: 07/19/23 09:45
Date Received: 07/19/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E
Analytical Date: 07/22/23 09:57
Analyst: JG

Extraction Method: EPA 3510C
Extraction Date: 07/21/23 02:47

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
1,2,4-Trichlorobenzene	ND		ug/l	5.0	0.50	1
Bis(2-chloroethyl)ether	ND		ug/l	2.0	0.50	1
1,2-Dichlorobenzene	ND		ug/l	2.0	0.45	1
1,3-Dichlorobenzene	ND		ug/l	2.0	0.40	1
1,4-Dichlorobenzene	ND		ug/l	2.0	0.43	1
3,3'-Dichlorobenzidine	ND		ug/l	5.0	1.6	1
2,4-Dinitrotoluene	ND		ug/l	5.0	1.2	1
2,6-Dinitrotoluene	ND		ug/l	5.0	0.93	1
4-Chlorophenyl phenyl ether	ND		ug/l	2.0	0.49	1
4-Bromophenyl phenyl ether	ND		ug/l	2.0	0.38	1
Bis(2-chloroisopropyl)ether	ND		ug/l	2.0	0.53	1
Bis(2-chloroethoxy)methane	ND		ug/l	5.0	0.50	1
Hexachlorocyclopentadiene	ND		ug/l	20	0.69	1
Isophorone	ND		ug/l	5.0	1.2	1
Nitrobenzene	ND		ug/l	2.0	0.77	1
NDPA/DPA	ND		ug/l	2.0	0.42	1
n-Nitrosodi-n-propylamine	ND		ug/l	5.0	0.64	1
Bis(2-ethylhexyl)phthalate	ND		ug/l	3.0	1.5	1
Butyl benzyl phthalate	ND		ug/l	5.0	1.2	1
Di-n-butylphthalate	ND		ug/l	5.0	0.39	1
Di-n-octylphthalate	ND		ug/l	5.0	1.3	1
Diethyl phthalate	ND		ug/l	5.0	0.38	1
Dimethyl phthalate	ND		ug/l	5.0	1.8	1
Biphenyl	ND		ug/l	2.0	0.46	1
4-Chloroaniline	ND		ug/l	5.0	1.1	1
2-Nitroaniline	ND		ug/l	5.0	0.50	1
3-Nitroaniline	ND		ug/l	5.0	0.81	1
4-Nitroaniline	ND		ug/l	5.0	0.80	1

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-01 Date Collected: 07/19/23 09:45

Client ID: GW-18 Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Dibenzofuran	ND		ug/l	2.0	0.50	1
1,2,4,5-Tetrachlorobenzene	ND		ug/l	10	0.44	1
Acetophenone	ND		ug/l	5.0	0.53	1
2,4,6-Trichlorophenol	ND		ug/l	5.0	0.61	1
p-Chloro-m-cresol	ND		ug/l	2.0	0.35	1
2-Chlorophenol	ND		ug/l	2.0	0.48	1
2,4-Dichlorophenol	ND		ug/l	5.0	0.41	1
2,4-Dimethylphenol	ND		ug/l	5.0	1.8	1
2-Nitrophenol	ND		ug/l	10	0.85	1
4-Nitrophenol	ND		ug/l	10	0.67	1
2,4-Dinitrophenol	ND		ug/l	20	6.6	1
4,6-Dinitro-o-cresol	ND		ug/l	10	1.8	1
Phenol	ND		ug/l	5.0	0.57	1
2-Methylphenol	ND		ug/l	5.0	0.49	1
3-Methylphenol/4-Methylphenol	ND		ug/l	5.0	0.48	1
2,4,5-Trichlorophenol	ND		ug/l	5.0	0.77	1
Benzoic Acid	ND		ug/l	50	2.6	1
Benzyl Alcohol	ND		ug/l	2.0	0.59	1
Carbazole	ND		ug/l	2.0	0.49	1

Tentatively Identified Compounds				
Total TIC Compounds	22.9	J	ug/l	1
Unknown	1.82	J	ug/l	1
Unknown Organic Acid	6.11	J	ug/l	1
Unknown Organic Acid	7.31	J	ug/l	1
Unknown	3.78	J	ug/l	1
Unknown	1.85	J	ug/l	1
Unknown Organic Acid	2.00	J	ug/l	1

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-01 Date Collected: 07/19/23 09:45

Client ID: GW-18 Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	51		21-120
Phenol-d6	42		10-120
Nitrobenzene-d5	61		23-120
2-Fluorobiphenyl	58		15-120
2,4,6-Tribromophenol	63		10-120
4-Terphenyl-d14	64		41-149

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-01
Client ID: GW-18
Sample Location: WHITE PLAINS, NY

Date Collected: 07/19/23 09:45
Date Received: 07/19/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E-SIM
Analytical Date: 07/21/23 13:00
Analyst: RP

Extraction Method: EPA 3510C
Extraction Date: 07/21/23 02:50

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS-SIM - Westborough Lab						
Acenaphthene	ND		ug/l	0.10	0.01	1
2-Chloronaphthalene	ND		ug/l	0.20	0.02	1
Fluoranthene	0.02	J	ug/l	0.10	0.02	1
Hexachlorobutadiene	ND		ug/l	0.50	0.05	1
Naphthalene	ND		ug/l	0.10	0.05	1
Benzo(a)anthracene	ND		ug/l	0.10	0.02	1
Benzo(a)pyrene	ND		ug/l	0.10	0.02	1
Benzo(b)fluoranthene	ND		ug/l	0.10	0.01	1
Benzo(k)fluoranthene	ND		ug/l	0.10	0.01	1
Chrysene	ND		ug/l	0.10	0.01	1
Acenaphthylene	ND		ug/l	0.10	0.01	1
Anthracene	0.01	J	ug/l	0.10	0.01	1
Benzo(ghi)perylene	ND		ug/l	0.10	0.01	1
Fluorene	ND		ug/l	0.10	0.01	1
Phenanthrene	ND		ug/l	0.10	0.02	1
Dibenzo(a,h)anthracene	ND		ug/l	0.10	0.01	1
Indeno(1,2,3-cd)pyrene	ND		ug/l	0.10	0.01	1
Pyrene	0.02	J	ug/l	0.10	0.02	1
2-Methylnaphthalene	ND		ug/l	0.10	0.02	1
Pentachlorophenol	ND		ug/l	0.80	0.01	1
Hexachlorobenzene	ND		ug/l	0.80	0.01	1
Hexachloroethane	ND		ug/l	0.80	0.06	1

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-01 Date Collected: 07/19/23 09:45

Client ID: GW-18 Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS-SIM - Westborough Lab						

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	52		21-120
Phenol-d6	46		10-120
Nitrobenzene-d5	84		23-120
2-Fluorobiphenyl	70		15-120
2,4,6-Tribromophenol	**135**	Q	10-120
4-Terphenyl-d14	70		41-149

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-02
Client ID: GW-19
Sample Location: WHITE PLAINS, NY

Date Collected: 07/19/23 08:30
Date Received: 07/19/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E
Analytical Date: 07/22/23 10:21
Analyst: JG

Extraction Method: EPA 3510C
Extraction Date: 07/21/23 02:47

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
1,2,4-Trichlorobenzene	ND		ug/l	5.0	0.50	1
Bis(2-chloroethyl)ether	ND		ug/l	2.0	0.50	1
1,2-Dichlorobenzene	ND		ug/l	2.0	0.45	1
1,3-Dichlorobenzene	ND		ug/l	2.0	0.40	1
1,4-Dichlorobenzene	ND		ug/l	2.0	0.43	1
3,3'-Dichlorobenzidine	ND		ug/l	5.0	1.6	1
2,4-Dinitrotoluene	ND		ug/l	5.0	1.2	1
2,6-Dinitrotoluene	ND		ug/l	5.0	0.93	1
4-Chlorophenyl phenyl ether	ND		ug/l	2.0	0.49	1
4-Bromophenyl phenyl ether	ND		ug/l	2.0	0.38	1
Bis(2-chloroisopropyl)ether	ND		ug/l	2.0	0.53	1
Bis(2-chloroethoxy)methane	ND		ug/l	5.0	0.50	1
Hexachlorocyclopentadiene	ND		ug/l	20	0.69	1
Isophorone	ND		ug/l	5.0	1.2	1
Nitrobenzene	ND		ug/l	2.0	0.77	1
NDPA/DPA	ND		ug/l	2.0	0.42	1
n-Nitrosodi-n-propylamine	ND		ug/l	5.0	0.64	1
Bis(2-ethylhexyl)phthalate	ND		ug/l	3.0	1.5	1
Butyl benzyl phthalate	ND		ug/l	5.0	1.2	1
Di-n-butylphthalate	ND		ug/l	5.0	0.39	1
Di-n-octylphthalate	ND		ug/l	5.0	1.3	1
Diethyl phthalate	ND		ug/l	5.0	0.38	1
Dimethyl phthalate	ND		ug/l	5.0	1.8	1
Biphenyl	ND		ug/l	2.0	0.46	1
4-Chloroaniline	ND		ug/l	5.0	1.1	1
2-Nitroaniline	ND		ug/l	5.0	0.50	1
3-Nitroaniline	ND		ug/l	5.0	0.81	1
4-Nitroaniline	ND		ug/l	5.0	0.80	1

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-02 Date Collected: 07/19/23 08:30

Client ID: GW-19 Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Dibenzofuran	ND		ug/l	2.0	0.50	1
1,2,4,5-Tetrachlorobenzene	ND		ug/l	10	0.44	1
Acetophenone	ND		ug/l	5.0	0.53	1
2,4,6-Trichlorophenol	ND		ug/l	5.0	0.61	1
p-Chloro-m-cresol	ND		ug/l	2.0	0.35	1
2-Chlorophenol	ND		ug/l	2.0	0.48	1
2,4-Dichlorophenol	ND		ug/l	5.0	0.41	1
2,4-Dimethylphenol	ND		ug/l	5.0	1.8	1
2-Nitrophenol	ND		ug/l	10	0.85	1
4-Nitrophenol	ND		ug/l	10	0.67	1
2,4-Dinitrophenol	ND		ug/l	20	6.6	1
4,6-Dinitro-o-cresol	ND		ug/l	10	1.8	1
Phenol	ND		ug/l	5.0	0.57	1
2-Methylphenol	ND		ug/l	5.0	0.49	1
3-Methylphenol/4-Methylphenol	ND		ug/l	5.0	0.48	1
2,4,5-Trichlorophenol	ND		ug/l	5.0	0.77	1
Benzoic Acid	ND		ug/l	50	2.6	1
Benzyl Alcohol	ND		ug/l	2.0	0.59	1
Carbazole	ND		ug/l	2.0	0.49	1

Tentatively Identified Compounds				
Total TIC Compounds	21.4	J	ug/l	1
Unknown	1.67	J	ug/l	1
Unknown Organic Acid	2.22	J	ug/l	1
Unknown	2.11	J	ug/l	1
Unknown	4.29	J	ug/l	1
Unknown	2.22	J	ug/l	1
Unknown	2.04	J	ug/l	1
Unknown	2.04	J	ug/l	1
Unknown Organic Acid	4.84	J	ug/l	1

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-02 Date Collected: 07/19/23 08:30

Client ID: GW-19 Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	62		21-120
Phenol-d6	52		10-120
Nitrobenzene-d5	76		23-120
2-Fluorobiphenyl	72		15-120
2,4,6-Tribromophenol	75		10-120
4-Terphenyl-d14	79		41-149

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-02
Client ID: GW-19
Sample Location: WHITE PLAINS, NY

Date Collected: 07/19/23 08:30
Date Received: 07/19/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E-SIM
Analytical Date: 07/21/23 13:17
Analyst: RP

Extraction Method: EPA 3510C
Extraction Date: 07/21/23 02:50

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS-SIM - Westborough Lab						
Acenaphthene	ND		ug/l	0.10	0.01	1
2-Chloronaphthalene	ND		ug/l	0.20	0.02	1
Fluoranthene	0.04	J	ug/l	0.10	0.02	1
Hexachlorobutadiene	ND		ug/l	0.50	0.05	1
Naphthalene	ND		ug/l	0.10	0.05	1
Benzo(a)anthracene	ND		ug/l	0.10	0.02	1
Benzo(a)pyrene	ND		ug/l	0.10	0.02	1
Benzo(b)fluoranthene	ND		ug/l	0.10	0.01	1
Benzo(k)fluoranthene	0.01	J	ug/l	0.10	0.01	1
Chrysene	ND		ug/l	0.10	0.01	1
Acenaphthylene	ND		ug/l	0.10	0.01	1
Anthracene	0.03	J	ug/l	0.10	0.01	1
Benzo(ghi)perylene	ND		ug/l	0.10	0.01	1
Fluorene	0.02	J	ug/l	0.10	0.01	1
Phenanthrene	0.05	J	ug/l	0.10	0.02	1
Dibenzo(a,h)anthracene	ND		ug/l	0.10	0.01	1
Indeno(1,2,3-cd)pyrene	ND		ug/l	0.10	0.01	1
Pyrene	0.04	J	ug/l	0.10	0.02	1
2-Methylnaphthalene	ND		ug/l	0.10	0.02	1
Pentachlorophenol	ND		ug/l	0.80	0.01	1
Hexachlorobenzene	0.02	J	ug/l	0.80	0.01	1
Hexachloroethane	ND		ug/l	0.80	0.06	1

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-02 Date Collected: 07/19/23 08:30

Client ID: GW-19 Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS-SIM - Westborough Lab						

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	59		21-120
Phenol-d6	53		10-120
Nitrobenzene-d5	101		23-120
2-Fluorobiphenyl	82		15-120
2,4,6-Tribromophenol	**151**	Q	10-120
4-Terphenyl-d14	77		41-149

Project Name: 100 MAIN ST.
Lab Number: L2341423
Project Number: 12461
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-03
Client ID: GW-20
Sample Location: WHITE PLAINS, NY

Date Collected: 07/19/23 14:20
Date Received: 07/19/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E
Analytical Date: 07/22/23 10:44
Analyst: JG

Extraction Method: EPA 3510C
Extraction Date: 07/21/23 02:47

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
1,2,4-Trichlorobenzene	ND		ug/l	5.0	0.50	1
Bis(2-chloroethyl)ether	ND		ug/l	2.0	0.50	1
1,2-Dichlorobenzene	ND		ug/l	2.0	0.45	1
1,3-Dichlorobenzene	ND		ug/l	2.0	0.40	1
1,4-Dichlorobenzene	ND		ug/l	2.0	0.43	1
3,3'-Dichlorobenzidine	ND		ug/l	5.0	1.6	1
2,4-Dinitrotoluene	ND		ug/l	5.0	1.2	1
2,6-Dinitrotoluene	ND		ug/l	5.0	0.93	1
4-Chlorophenyl phenyl ether	ND		ug/l	2.0	0.49	1
4-Bromophenyl phenyl ether	ND		ug/l	2.0	0.38	1
Bis(2-chloroisopropyl)ether	ND		ug/l	2.0	0.53	1
Bis(2-chloroethoxy)methane	ND		ug/l	5.0	0.50	1
Hexachlorocyclopentadiene	ND		ug/l	20	0.69	1
Isophorone	ND		ug/l	5.0	1.2	1
Nitrobenzene	ND		ug/l	2.0	0.77	1
NDPA/DPA	ND		ug/l	2.0	0.42	1
n-Nitrosodi-n-propylamine	ND		ug/l	5.0	0.64	1
Bis(2-ethylhexyl)phthalate	ND		ug/l	3.0	1.5	1
Butyl benzyl phthalate	ND		ug/l	5.0	1.2	1
Di-n-butylphthalate	0.90	J	ug/l	5.0	0.39	1
Di-n-octylphthalate	ND		ug/l	5.0	1.3	1
Diethyl phthalate	ND		ug/l	5.0	0.38	1
Dimethyl phthalate	ND		ug/l	5.0	1.8	1
Biphenyl	ND		ug/l	2.0	0.46	1
4-Chloroaniline	ND		ug/l	5.0	1.1	1
2-Nitroaniline	ND		ug/l	5.0	0.50	1
3-Nitroaniline	ND		ug/l	5.0	0.81	1
4-Nitroaniline	ND		ug/l	5.0	0.80	1

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-03 Date Collected: 07/19/23 14:20

Client ID: GW-20 Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Dibenzofuran	ND		ug/l	2.0	0.50	1
1,2,4,5-Tetrachlorobenzene	ND		ug/l	10	0.44	1
Acetophenone	ND		ug/l	5.0	0.53	1
2,4,6-Trichlorophenol	ND		ug/l	5.0	0.61	1
p-Chloro-m-cresol	ND		ug/l	2.0	0.35	1
2-Chlorophenol	ND		ug/l	2.0	0.48	1
2,4-Dichlorophenol	ND		ug/l	5.0	0.41	1
2,4-Dimethylphenol	ND		ug/l	5.0	1.8	1
2-Nitrophenol	ND		ug/l	10	0.85	1
4-Nitrophenol	ND		ug/l	10	0.67	1
2,4-Dinitrophenol	ND		ug/l	20	6.6	1
4,6-Dinitro-o-cresol	ND		ug/l	10	1.8	1
Phenol	ND		ug/l	5.0	0.57	1
2-Methylphenol	ND		ug/l	5.0	0.49	1
3-Methylphenol/4-Methylphenol	ND		ug/l	5.0	0.48	1
2,4,5-Trichlorophenol	ND		ug/l	5.0	0.77	1
Benzoic Acid	25.	J	ug/l	50	2.6	1
Benzyl Alcohol	ND		ug/l	2.0	0.59	1
Carbazole	ND		ug/l	2.0	0.49	1

Tentatively Identified Compounds				
Total TIC Compounds	39.3	J	ug/l	1
Unknown	5.78	J	ug/l	1
Unknown Organic Acid	4.91	J	ug/l	1
Unknown	2.47	J	ug/l	1
Unknown Alcohol	2.36	J	ug/l	1
Unknown Organic Acid	2.04	J	ug/l	1
Unknown	2.11	J	ug/l	1
Unknown Organic Acid	1.60	J	ug/l	1
Unknown Organic Acid	2.80	J	ug/l	1
Unknown	3.85	J	ug/l	1
Unknown Organic Acid	11.4	J	ug/l	1

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-03 Date Collected: 07/19/23 14:20

Client ID: GW-20 Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	62		21-120
Phenol-d6	50		10-120
Nitrobenzene-d5	77		23-120
2-Fluorobiphenyl	73		15-120
2,4,6-Tribromophenol	75		10-120
4-Terphenyl-d14	82		41-149

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-03
Client ID: GW-20
Sample Location: WHITE PLAINS, NY

Date Collected: 07/19/23 14:20
Date Received: 07/19/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E-SIM
Analytical Date: 07/21/23 13:34
Analyst: RP

Extraction Method: EPA 3510C
Extraction Date: 07/21/23 02:50

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS-SIM - Westborough Lab						
Acenaphthene	ND		ug/l	0.10	0.01	1
2-Chloronaphthalene	ND		ug/l	0.20	0.02	1
Fluoranthene	0.03	J	ug/l	0.10	0.02	1
Hexachlorobutadiene	ND		ug/l	0.50	0.05	1
Naphthalene	ND		ug/l	0.10	0.05	1
Benzo(a)anthracene	ND		ug/l	0.10	0.02	1
Benzo(a)pyrene	ND		ug/l	0.10	0.02	1
Benzo(b)fluoranthene	0.03	J	ug/l	0.10	0.01	1
Benzo(k)fluoranthene	0.02	J	ug/l	0.10	0.01	1
Chrysene	0.02	J	ug/l	0.10	0.01	1
Acenaphthylene	ND		ug/l	0.10	0.01	1
Anthracene	0.02	J	ug/l	0.10	0.01	1
Benzo(ghi)perylene	0.02	J	ug/l	0.10	0.01	1
Fluorene	0.02	J	ug/l	0.10	0.01	1
Phenanthrene	0.04	J	ug/l	0.10	0.02	1
Dibenzo(a,h)anthracene	ND		ug/l	0.10	0.01	1
Indeno(1,2,3-cd)pyrene	0.02	J	ug/l	0.10	0.01	1
Pyrene	ND		ug/l	0.10	0.02	1
2-Methylnaphthalene	0.02	J	ug/l	0.10	0.02	1
Pentachlorophenol	ND		ug/l	0.80	0.01	1
Hexachlorobenzene	ND		ug/l	0.80	0.01	1
Hexachloroethane	ND		ug/l	0.80	0.06	1

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-03 Date Collected: 07/19/23 14:20

Client ID: GW-20 Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor

Semivolatile Organics by GC/MS-SIM - Westborough Lab

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	57		21-120
Phenol-d6	52		10-120
Nitrobenzene-d5	99		23-120
2-Fluorobiphenyl	81		15-120
2,4,6-Tribromophenol	**153**	Q	10-120
4-Terphenyl-d14	75		41-149

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-04
Client ID: GW-21
Sample Location: WHITE PLAINS, NY

Date Collected: 07/19/23 11:20
Date Received: 07/19/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E
Analytical Date: 07/22/23 11:08
Analyst: JG

Extraction Method: EPA 3510C
Extraction Date: 07/21/23 02:47

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
1,2,4-Trichlorobenzene	ND		ug/l	5.0	0.50	1
Bis(2-chloroethyl)ether	ND		ug/l	2.0	0.50	1
1,2-Dichlorobenzene	ND		ug/l	2.0	0.45	1
1,3-Dichlorobenzene	ND		ug/l	2.0	0.40	1
1,4-Dichlorobenzene	ND		ug/l	2.0	0.43	1
3,3'-Dichlorobenzidine	ND		ug/l	5.0	1.6	1
2,4-Dinitrotoluene	ND		ug/l	5.0	1.2	1
2,6-Dinitrotoluene	ND		ug/l	5.0	0.93	1
4-Chlorophenyl phenyl ether	ND		ug/l	2.0	0.49	1
4-Bromophenyl phenyl ether	ND		ug/l	2.0	0.38	1
Bis(2-chloroisopropyl)ether	ND		ug/l	2.0	0.53	1
Bis(2-chloroethoxy)methane	ND		ug/l	5.0	0.50	1
Hexachlorocyclopentadiene	ND		ug/l	20	0.69	1
Isophorone	ND		ug/l	5.0	1.2	1
Nitrobenzene	ND		ug/l	2.0	0.77	1
NDPA/DPA	ND		ug/l	2.0	0.42	1
n-Nitrosodi-n-propylamine	ND		ug/l	5.0	0.64	1
Bis(2-ethylhexyl)phthalate	ND		ug/l	3.0	1.5	1
Butyl benzyl phthalate	ND		ug/l	5.0	1.2	1
Di-n-butylphthalate	0.57	J	ug/l	5.0	0.39	1
Di-n-octylphthalate	ND		ug/l	5.0	1.3	1
Diethyl phthalate	ND		ug/l	5.0	0.38	1
Dimethyl phthalate	ND		ug/l	5.0	1.8	1
Biphenyl	ND		ug/l	2.0	0.46	1
4-Chloroaniline	ND		ug/l	5.0	1.1	1
2-Nitroaniline	ND		ug/l	5.0	0.50	1
3-Nitroaniline	ND		ug/l	5.0	0.81	1
4-Nitroaniline	ND		ug/l	5.0	0.80	1

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-04 Date Collected: 07/19/23 11:20

Client ID: GW-21 Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Dibenzofuran	ND		ug/l	2.0	0.50	1
1,2,4,5-Tetrachlorobenzene	ND		ug/l	10	0.44	1
Acetophenone	ND		ug/l	5.0	0.53	1
2,4,6-Trichlorophenol	ND		ug/l	5.0	0.61	1
p-Chloro-m-cresol	ND		ug/l	2.0	0.35	1
2-Chlorophenol	ND		ug/l	2.0	0.48	1
2,4-Dichlorophenol	ND		ug/l	5.0	0.41	1
2,4-Dimethylphenol	ND		ug/l	5.0	1.8	1
2-Nitrophenol	ND		ug/l	10	0.85	1
4-Nitrophenol	ND		ug/l	10	0.67	1
2,4-Dinitrophenol	ND		ug/l	20	6.6	1
4,6-Dinitro-o-cresol	ND		ug/l	10	1.8	1
Phenol	ND		ug/l	5.0	0.57	1
2-Methylphenol	ND		ug/l	5.0	0.49	1
3-Methylphenol/4-Methylphenol	ND		ug/l	5.0	0.48	1
2,4,5-Trichlorophenol	ND		ug/l	5.0	0.77	1
Benzoic Acid	6.8	J	ug/l	50	2.6	1
Benzyl Alcohol	ND		ug/l	2.0	0.59	1
Carbazole	ND		ug/l	2.0	0.49	1

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-04 Date Collected: 07/19/23 11:20

Client ID: GW-21 Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Tentatively Identified Compounds						
Total TIC Compounds	38.9	J	ug/l			1
Unknown Organic Acid	2.00	J	ug/l			1
Unknown Organic Acid	4.69	J	ug/l			1
Unknown	1.93	J	ug/l			1
Unknown	4.80	J	ug/l			1
Unknown Organic Acid	11.3	J	ug/l			1
Unknown Organic Acid	1.74	J	ug/l			1
Unknown	1.74	J	ug/l			1
Unknown	3.78	J	ug/l			1
Unknown	2.00	J	ug/l			1
Unknown	2.87	J	ug/l			1
Unknown Organic Acid	2.07	J	ug/l			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	64		21-120
Phenol-d6	53		10-120
Nitrobenzene-d5	80		23-120
2-Fluorobiphenyl	75		15-120
2,4,6-Tribromophenol	78		10-120
4-Terphenyl-d14	82		41-149

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-04
Client ID: GW-21
Sample Location: WHITE PLAINS, NY

Date Collected: 07/19/23 11:20
Date Received: 07/19/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E-SIM
Analytical Date: 07/21/23 13:50
Analyst: RP

Extraction Method: EPA 3510C
Extraction Date: 07/21/23 02:50

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS-SIM - Westborough Lab						
Acenaphthene	ND		ug/l	0.10	0.01	1
2-Chloronaphthalene	ND		ug/l	0.20	0.02	1
Fluoranthene	0.04	J	ug/l	0.10	0.02	1
Hexachlorobutadiene	ND		ug/l	0.50	0.05	1
Naphthalene	ND		ug/l	0.10	0.05	1
Benzo(a)anthracene	ND		ug/l	0.10	0.02	1
Benzo(a)pyrene	ND		ug/l	0.10	0.02	1
Benzo(b)fluoranthene	0.02	J	ug/l	0.10	0.01	1
Benzo(k)fluoranthene	0.02	J	ug/l	0.10	0.01	1
Chrysene	0.02	J	ug/l	0.10	0.01	1
Acenaphthylene	ND		ug/l	0.10	0.01	1
Anthracene	0.03	J	ug/l	0.10	0.01	1
Benzo(ghi)perylene	0.02	J	ug/l	0.10	0.01	1
Fluorene	0.02	J	ug/l	0.10	0.01	1
Phenanthrene	0.04	J	ug/l	0.10	0.02	1
Dibenzo(a,h)anthracene	0.01	J	ug/l	0.10	0.01	1
Indeno(1,2,3-cd)pyrene	0.02	J	ug/l	0.10	0.01	1
Pyrene	0.06	J	ug/l	0.10	0.02	1
2-Methylnaphthalene	ND		ug/l	0.10	0.02	1
Pentachlorophenol	ND		ug/l	0.80	0.01	1
Hexachlorobenzene	0.02	J	ug/l	0.80	0.01	1
Hexachloroethane	ND		ug/l	0.80	0.06	1

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-04 Date Collected: 07/19/23 11:20

Client ID: GW-21 Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor

Semivolatile Organics by GC/MS-SIM - Westborough Lab

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	64		21-120
Phenol-d6	57		10-120
Nitrobenzene-d5	113		23-120
2-Fluorobiphenyl	91		15-120
2,4,6-Tribromophenol	**179**	Q	10-120
4-Terphenyl-d14	85		41-149

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-05
Client ID: GW-22
Sample Location: WHITE PLAINS, NY

Date Collected: 07/19/23 11:45
Date Received: 07/19/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E
Analytical Date: 07/22/23 11:31
Analyst: JG

Extraction Method: EPA 3510C
Extraction Date: 07/21/23 02:47

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
1,2,4-Trichlorobenzene	ND		ug/l	5.0	0.50	1
Bis(2-chloroethyl)ether	ND		ug/l	2.0	0.50	1
1,2-Dichlorobenzene	ND		ug/l	2.0	0.45	1
1,3-Dichlorobenzene	ND		ug/l	2.0	0.40	1
1,4-Dichlorobenzene	ND		ug/l	2.0	0.43	1
3,3'-Dichlorobenzidine	ND		ug/l	5.0	1.6	1
2,4-Dinitrotoluene	ND		ug/l	5.0	1.2	1
2,6-Dinitrotoluene	ND		ug/l	5.0	0.93	1
4-Chlorophenyl phenyl ether	ND		ug/l	2.0	0.49	1
4-Bromophenyl phenyl ether	ND		ug/l	2.0	0.38	1
Bis(2-chloroisopropyl)ether	ND		ug/l	2.0	0.53	1
Bis(2-chloroethoxy)methane	ND		ug/l	5.0	0.50	1
Hexachlorocyclopentadiene	ND		ug/l	20	0.69	1
Isophorone	ND		ug/l	5.0	1.2	1
Nitrobenzene	ND		ug/l	2.0	0.77	1
NDPA/DPA	ND		ug/l	2.0	0.42	1
n-Nitrosodi-n-propylamine	ND		ug/l	5.0	0.64	1
Bis(2-ethylhexyl)phthalate	ND		ug/l	3.0	1.5	1
Butyl benzyl phthalate	ND		ug/l	5.0	1.2	1
Di-n-butylphthalate	ND		ug/l	5.0	0.39	1
Di-n-octylphthalate	ND		ug/l	5.0	1.3	1
Diethyl phthalate	ND		ug/l	5.0	0.38	1
Dimethyl phthalate	ND		ug/l	5.0	1.8	1
Biphenyl	ND		ug/l	2.0	0.46	1
4-Chloroaniline	ND		ug/l	5.0	1.1	1
2-Nitroaniline	ND		ug/l	5.0	0.50	1
3-Nitroaniline	ND		ug/l	5.0	0.81	1
4-Nitroaniline	ND		ug/l	5.0	0.80	1

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-05 Date Collected: 07/19/23 11:45

Client ID: GW-22 Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Dibenzofuran	ND		ug/l	2.0	0.50	1
1,2,4,5-Tetrachlorobenzene	ND		ug/l	10	0.44	1
Acetophenone	ND		ug/l	5.0	0.53	1
2,4,6-Trichlorophenol	ND		ug/l	5.0	0.61	1
p-Chloro-m-cresol	ND		ug/l	2.0	0.35	1
2-Chlorophenol	ND		ug/l	2.0	0.48	1
2,4-Dichlorophenol	ND		ug/l	5.0	0.41	1
2,4-Dimethylphenol	ND		ug/l	5.0	1.8	1
2-Nitrophenol	ND		ug/l	10	0.85	1
4-Nitrophenol	ND		ug/l	10	0.67	1
2,4-Dinitrophenol	ND		ug/l	20	6.6	1
4,6-Dinitro-o-cresol	ND		ug/l	10	1.8	1
Phenol	ND		ug/l	5.0	0.57	1
2-Methylphenol	ND		ug/l	5.0	0.49	1
3-Methylphenol/4-Methylphenol	ND		ug/l	5.0	0.48	1
2,4,5-Trichlorophenol	ND		ug/l	5.0	0.77	1
Benzoic Acid	ND		ug/l	50	2.6	1
Benzyl Alcohol	ND		ug/l	2.0	0.59	1
Carbazole	ND		ug/l	2.0	0.49	1

Tentatively Identified Compounds						
Total TIC Compounds	16.4	J	ug/l			1
Unknown	3.85	J	ug/l			1
Unknown	2.11	J	ug/l			1
Unknown Organic Acid	2.40	J	ug/l			1
Unknown	2.00	J	ug/l			1
Unknown Organic Acid	1.49	J	ug/l			1
Unknown Organic Acid	4.54	J	ug/l			1

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-05 Date Collected: 07/19/23 11:45

Client ID: GW-22 Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	52		21-120
Phenol-d6	42		10-120
Nitrobenzene-d5	65		23-120
2-Fluorobiphenyl	60		15-120
2,4,6-Tribromophenol	64		10-120
4-Terphenyl-d14	70		41-149

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-05
Client ID: GW-22
Sample Location: WHITE PLAINS, NY

Date Collected: 07/19/23 11:45
Date Received: 07/19/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E-SIM
Analytical Date: 07/21/23 14:07
Analyst: RP

Extraction Method: EPA 3510C
Extraction Date: 07/21/23 02:50

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS-SIM - Westborough Lab						
Acenaphthene	ND		ug/l	0.10	0.01	1
2-Chloronaphthalene	ND		ug/l	0.20	0.02	1
Fluoranthene	ND		ug/l	0.10	0.02	1
Hexachlorobutadiene	ND		ug/l	0.50	0.05	1
Naphthalene	ND		ug/l	0.10	0.05	1
Benzo(a)anthracene	ND		ug/l	0.10	0.02	1
Benzo(a)pyrene	ND		ug/l	0.10	0.02	1
Benzo(b)fluoranthene	ND		ug/l	0.10	0.01	1
Benzo(k)fluoranthene	ND		ug/l	0.10	0.01	1
Chrysene	ND		ug/l	0.10	0.01	1
Acenaphthylene	ND		ug/l	0.10	0.01	1
Anthracene	ND		ug/l	0.10	0.01	1
Benzo(ghi)perylene	ND		ug/l	0.10	0.01	1
Fluorene	ND		ug/l	0.10	0.01	1
Phenanthrene	ND		ug/l	0.10	0.02	1
Dibenzo(a,h)anthracene	ND		ug/l	0.10	0.01	1
Indeno(1,2,3-cd)pyrene	ND		ug/l	0.10	0.01	1
Pyrene	ND		ug/l	0.10	0.02	1
2-Methylnaphthalene	ND		ug/l	0.10	0.02	1
Pentachlorophenol	ND		ug/l	0.80	0.01	1
Hexachlorobenzene	ND		ug/l	0.80	0.01	1
Hexachloroethane	ND		ug/l	0.80	0.06	1

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-05 Date Collected: 07/19/23 11:45

Client ID: GW-22 Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor

Semivolatile Organics by GC/MS-SIM - Westborough Lab

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	53		21-120
Phenol-d6	47		10-120
Nitrobenzene-d5	91		23-120
2-Fluorobiphenyl	77		15-120
2,4,6-Tribromophenol	**146**	Q	10-120
4-Terphenyl-d14	76		41-149

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-06
Client ID: GW-23
Sample Location: WHITE PLAINS, NY

Date Collected: 07/19/23 13:50
Date Received: 07/19/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E
Analytical Date: 07/22/23 11:55
Analyst: JG

Extraction Method: EPA 3510C
Extraction Date: 07/21/23 02:47

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
1,2,4-Trichlorobenzene	ND		ug/l	5.0	0.50	1
Bis(2-chloroethyl)ether	ND		ug/l	2.0	0.50	1
1,2-Dichlorobenzene	ND		ug/l	2.0	0.45	1
1,3-Dichlorobenzene	ND		ug/l	2.0	0.40	1
1,4-Dichlorobenzene	ND		ug/l	2.0	0.43	1
3,3'-Dichlorobenzidine	ND		ug/l	5.0	1.6	1
2,4-Dinitrotoluene	ND		ug/l	5.0	1.2	1
2,6-Dinitrotoluene	ND		ug/l	5.0	0.93	1
4-Chlorophenyl phenyl ether	ND		ug/l	2.0	0.49	1
4-Bromophenyl phenyl ether	ND		ug/l	2.0	0.38	1
Bis(2-chloroisopropyl)ether	ND		ug/l	2.0	0.53	1
Bis(2-chloroethoxy)methane	ND		ug/l	5.0	0.50	1
Hexachlorocyclopentadiene	ND		ug/l	20	0.69	1
Isophorone	ND		ug/l	5.0	1.2	1
Nitrobenzene	ND		ug/l	2.0	0.77	1
NDPA/DPA	ND		ug/l	2.0	0.42	1
n-Nitrosodi-n-propylamine	ND		ug/l	5.0	0.64	1
Bis(2-ethylhexyl)phthalate	ND		ug/l	3.0	1.5	1
Butyl benzyl phthalate	ND		ug/l	5.0	1.2	1
Di-n-butylphthalate	0.81	J	ug/l	5.0	0.39	1
Di-n-octylphthalate	ND		ug/l	5.0	1.3	1
Diethyl phthalate	ND		ug/l	5.0	0.38	1
Dimethyl phthalate	ND		ug/l	5.0	1.8	1
Biphenyl	ND		ug/l	2.0	0.46	1
4-Chloroaniline	ND		ug/l	5.0	1.1	1
2-Nitroaniline	ND		ug/l	5.0	0.50	1
3-Nitroaniline	ND		ug/l	5.0	0.81	1
4-Nitroaniline	ND		ug/l	5.0	0.80	1

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-06 Date Collected: 07/19/23 13:50

Client ID: GW-23 Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Dibenzofuran	ND		ug/l	2.0	0.50	1
1,2,4,5-Tetrachlorobenzene	ND		ug/l	10	0.44	1
Acetophenone	ND		ug/l	5.0	0.53	1
2,4,6-Trichlorophenol	ND		ug/l	5.0	0.61	1
p-Chloro-m-cresol	ND		ug/l	2.0	0.35	1
2-Chlorophenol	ND		ug/l	2.0	0.48	1
2,4-Dichlorophenol	ND		ug/l	5.0	0.41	1
2,4-Dimethylphenol	ND		ug/l	5.0	1.8	1
2-Nitrophenol	ND		ug/l	10	0.85	1
4-Nitrophenol	3.0	J	ug/l	10	0.67	1
2,4-Dinitrophenol	ND		ug/l	20	6.6	1
4,6-Dinitro-o-cresol	ND		ug/l	10	1.8	1
Phenol	ND		ug/l	5.0	0.57	1
2-Methylphenol	ND		ug/l	5.0	0.49	1
3-Methylphenol/4-Methylphenol	ND		ug/l	5.0	0.48	1
2,4,5-Trichlorophenol	ND		ug/l	5.0	0.77	1
Benzoic Acid	57.		ug/l	50	2.6	1
Benzyl Alcohol	ND		ug/l	2.0	0.59	1
Carbazole	ND		ug/l	2.0	0.49	1

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-06 Date Collected: 07/19/23 13:50

Client ID: GW-23 Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Tentatively Identified Compounds						
Total TIC Compounds	95.9	J	ug/l			1
Unknown	1.89	J	ug/l			1
Unknown Organic Acid	5.38	J	ug/l			1
Unknown	2.11	J	ug/l			1
Unknown	3.16	J	ug/l			1
Unknown	5.20	J	ug/l			1
Unknown Organic Acid	7.09	J	ug/l			1
Unknown Organic Acid	18.8	J	ug/l			1
Unknown	2.29	J	ug/l			1
Unknown Organic Acid	4.65	J	ug/l			1
Unknown Organic Acid	12.4	J	ug/l			1
Unknown Alcohol	9.24	J	ug/l			1
Unknown Organic Acid	5.24	J	ug/l			1
Unknown	4.54	J	ug/l			1
Unknown	12.1	J	ug/l			1
Unknown Alcohol	1.78	J	ug/l			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	64		21-120
Phenol-d6	52		10-120
Nitrobenzene-d5	82		23-120
2-Fluorobiphenyl	78		15-120
2,4,6-Tribromophenol	81		10-120
4-Terphenyl-d14	84		41-149

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-06
Client ID: GW-23
Sample Location: WHITE PLAINS, NY

Date Collected: 07/19/23 13:50
Date Received: 07/19/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E-SIM
Analytical Date: 07/21/23 14:24
Analyst: RP

Extraction Method: EPA 3510C
Extraction Date: 07/21/23 02:50

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS-SIM - Westborough Lab						
Acenaphthene	0.07	J	ug/l	0.10	0.01	1
2-Chloronaphthalene	ND		ug/l	0.20	0.02	1
Fluoranthene	ND		ug/l	0.10	0.02	1
Hexachlorobutadiene	ND		ug/l	0.50	0.05	1
Naphthalene	0.14	B	ug/l	0.10	0.05	1
Benzo(a)anthracene	0.02	J	ug/l	0.10	0.02	1
Benzo(a)pyrene	ND		ug/l	0.10	0.02	1
Benzo(b)fluoranthene	0.05	J	ug/l	0.10	0.01	1
Benzo(k)fluoranthene	0.03	J	ug/l	0.10	0.01	1
Chrysene	0.03	J	ug/l	0.10	0.01	1
Acenaphthylene	0.02	J	ug/l	0.10	0.01	1
Anthracene	0.02	J	ug/l	0.10	0.01	1
Benzo(ghi)perylene	0.02	J	ug/l	0.10	0.01	1
Fluorene	0.12		ug/l	0.10	0.01	1
Phenanthrene	0.16		ug/l	0.10	0.02	1
Dibenzo(a,h)anthracene	ND		ug/l	0.10	0.01	1
Indeno(1,2,3-cd)pyrene	0.02	J	ug/l	0.10	0.01	1
Pyrene	ND		ug/l	0.10	0.02	1
2-Methylnaphthalene	0.32		ug/l	0.10	0.02	1
Pentachlorophenol	ND		ug/l	0.80	0.01	1
Hexachlorobenzene	ND		ug/l	0.80	0.01	1
Hexachloroethane	ND		ug/l	0.80	0.06	1

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-06 Date Collected: 07/19/23 13:50

Client ID: GW-23 Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS-SIM - Westborough Lab						

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	67		21-120
Phenol-d6	61		10-120
Nitrobenzene-d5	116		23-120
2-Fluorobiphenyl	93		15-120
2,4,6-Tribromophenol	**186**	Q	10-120
4-Terphenyl-d14	89		41-149

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-06 RE
Client ID: GW-23
Sample Location: WHITE PLAINS, NY

Date Collected: 07/19/23 13:50
Date Received: 07/19/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E-SIM
Analytical Date: 07/23/23 12:37
Analyst: JJW

Extraction Method: EPA 3510C
Extraction Date: 07/22/23 23:06

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS-SIM - Westborough Lab						
Acenaphthene	0.08	J	ug/l	0.10	0.01	1
2-Chloronaphthalene	ND		ug/l	0.20	0.02	1
Fluoranthene	0.02	J	ug/l	0.10	0.02	1
Hexachlorobutadiene	ND		ug/l	0.50	0.05	1
Naphthalene	1.1	B	ug/l	0.10	0.05	1
Benzo(a)anthracene	0.02	J	ug/l	0.10	0.02	1
Benzo(a)pyrene	ND		ug/l	0.10	0.02	1
Benzo(b)fluoranthene	ND		ug/l	0.10	0.01	1
Benzo(k)fluoranthene	ND		ug/l	0.10	0.01	1
Chrysene	ND		ug/l	0.10	0.01	1
Acenaphthylene	0.08	J	ug/l	0.10	0.01	1
Anthracene	0.03	J	ug/l	0.10	0.01	1
Benzo(ghi)perylene	ND		ug/l	0.10	0.01	1
Fluorene	0.14		ug/l	0.10	0.01	1
Phenanthrene	0.20		ug/l	0.10	0.02	1
Dibenzo(a,h)anthracene	ND		ug/l	0.10	0.01	1
Indeno(1,2,3-cd)pyrene	ND		ug/l	0.10	0.01	1
Pyrene	ND		ug/l	0.10	0.02	1
2-Methylnaphthalene	0.41		ug/l	0.10	0.02	1
Pentachlorophenol	ND		ug/l	0.80	0.01	1
Hexachlorobenzene	ND		ug/l	0.80	0.01	1
Hexachloroethane	ND		ug/l	0.80	0.06	1

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-06 RE
Client ID: GW-23
Sample Location: WHITE PLAINS, NY

Date Collected: 07/19/23 13:50
Date Received: 07/19/23
Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor

Semivolatile Organics by GC/MS-SIM - Westborough Lab

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	78		21-120
Phenol-d6	76		10-120
Nitrobenzene-d5	**126**	Q	23-120
2-Fluorobiphenyl	98		15-120
2,4,6-Tribromophenol	**184**	Q	10-120
4-Terphenyl-d14	82		41-149

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-07
Client ID: SB-51P (3.5-4)
Sample Location: WHITE PLAINS, NY

Date Collected: 07/19/23 15:00
Date Received: 07/19/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8270E
Analytical Date: 07/21/23 11:21
Analyst: JG
Percent Solids: 93%

Extraction Method: EPA 3546
Extraction Date: 07/20/23 11:27

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Acenaphthene	ND		ug/kg	140	18.	1
1,2,4-Trichlorobenzene	ND		ug/kg	170	20.	1
Hexachlorobenzene	ND		ug/kg	100	19.	1
Bis(2-chloroethyl)ether	ND		ug/kg	160	23.	1
2-Chloronaphthalene	ND		ug/kg	170	17.	1
1,2-Dichlorobenzene	ND		ug/kg	170	31.	1
1,3-Dichlorobenzene	ND		ug/kg	170	30.	1
1,4-Dichlorobenzene	ND		ug/kg	170	30.	1
3,3'-Dichlorobenzidine	ND		ug/kg	170	46.	1
2,4-Dinitrotoluene	ND		ug/kg	170	35.	1
2,6-Dinitrotoluene	ND		ug/kg	170	30.	1
Fluoranthene	ND		ug/kg	100	20.	1
4-Chlorophenyl phenyl ether	ND		ug/kg	170	18.	1
4-Bromophenyl phenyl ether	ND		ug/kg	170	26.	1
Bis(2-chloroisopropyl)ether	ND		ug/kg	210	30.	1
Bis(2-chloroethoxy)methane	ND		ug/kg	190	17.	1
Hexachlorobutadiene	ND		ug/kg	170	25.	1
Hexachlorocyclopentadiene	ND		ug/kg	500	160	1
Hexachloroethane	ND		ug/kg	140	28.	1
Isophorone	ND		ug/kg	160	22.	1
Naphthalene	ND		ug/kg	170	21.	1
Nitrobenzene	ND		ug/kg	160	26.	1
NDPA/DPA	ND		ug/kg	140	20.	1
n-Nitrosodi-n-propylamine	ND		ug/kg	170	27.	1
Bis(2-ethylhexyl)phthalate	ND		ug/kg	170	60.	1
Butyl benzyl phthalate	ND		ug/kg	170	44.	1
Di-n-butylphthalate	ND		ug/kg	170	33.	1
Di-n-octylphthalate	ND		ug/kg	170	59.	1

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-07 Date Collected: 07/19/23 15:00

Client ID: SB-51P (3.5-4) Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Diethyl phthalate	ND		ug/kg	170	16.	1
Dimethyl phthalate	ND		ug/kg	170	36.	1
Benzo(a)anthracene	ND		ug/kg	100	20.	1
Benzo(a)pyrene	ND		ug/kg	140	42.	1
Benzo(b)fluoranthene	ND		ug/kg	100	29.	1
Benzo(k)fluoranthene	ND		ug/kg	100	28.	1
Chrysene	ND		ug/kg	100	18.	1
Acenaphthylene	ND		ug/kg	140	27.	1
Anthracene	ND		ug/kg	100	34.	1
Benzo(ghi)perylene	ND		ug/kg	140	20.	1
Fluorene	ND		ug/kg	170	17.	1
Phenanthrene	ND		ug/kg	100	21.	1
Dibenzo(a,h)anthracene	ND		ug/kg	100	20.	1
Indeno(1,2,3-cd)pyrene	ND		ug/kg	140	24.	1
Pyrene	ND		ug/kg	100	17.	1
Biphenyl	ND		ug/kg	390	22.	1
4-Chloroaniline	ND		ug/kg	170	32.	1
2-Nitroaniline	ND		ug/kg	170	33.	1
3-Nitroaniline	ND		ug/kg	170	33.	1
4-Nitroaniline	ND		ug/kg	170	72.	1
Dibenzofuran	ND		ug/kg	170	16.	1
2-Methylnaphthalene	ND		ug/kg	210	21.	1
1,2,4,5-Tetrachlorobenzene	ND		ug/kg	170	18.	1
Acetophenone	ND		ug/kg	170	21.	1
2,4,6-Trichlorophenol	ND		ug/kg	100	33.	1
p-Chloro-m-cresol	ND		ug/kg	170	26.	1
2-Chlorophenol	ND		ug/kg	170	20.	1
2,4-Dichlorophenol	ND		ug/kg	160	28.	1
2,4-Dimethylphenol	ND		ug/kg	170	57.	1
2-Nitrophenol	ND		ug/kg	370	65.	1
4-Nitrophenol	ND		ug/kg	240	71.	1
2,4-Dinitrophenol	ND		ug/kg	830	81.	1
4,6-Dinitro-o-cresol	ND		ug/kg	450	83.	1
Pentachlorophenol	ND		ug/kg	140	38.	1
Phenol	ND		ug/kg	170	26.	1
2-Methylphenol	ND		ug/kg	170	27.	1
3-Methylphenol/4-Methylphenol	ND		ug/kg	250	27.	1

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-07 Date Collected: 07/19/23 15:00

Client ID: SB-51P (3.5-4) Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
2,4,5-Trichlorophenol	ND		ug/kg	170	33.	1
Benzoic Acid	ND		ug/kg	560	180	1
Benzyl Alcohol	ND		ug/kg	170	53.	1
Carbazole	ND		ug/kg	170	17.	1
1,4-Dioxane	ND		ug/kg	26	8.0	1
Tentatively Identified Compounds						
No Tentatively Identified Compounds	ND		ug/kg			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	74		25-120
Phenol-d6	72		10-120
Nitrobenzene-d5	68		23-120
2-Fluorobiphenyl	73		30-120
2,4,6-Tribromophenol	75		10-136
4-Terphenyl-d14	64		18-120

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 07/20/23 19:05
Analyst: JG

Extraction Method: EPA 3546
Extraction Date: 07/20/23 11:27

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 07 Batch: WG1805578-1					
Acenaphthene	ND		ug/kg	130	17.
1,2,4-Trichlorobenzene	ND		ug/kg	160	19.
Hexachlorobenzene	ND		ug/kg	99	18.
Bis(2-chloroethyl)ether	ND		ug/kg	150	22.
2-Chloronaphthalene	ND		ug/kg	160	16.
1,2-Dichlorobenzene	ND		ug/kg	160	30.
1,3-Dichlorobenzene	ND		ug/kg	160	28.
1,4-Dichlorobenzene	ND		ug/kg	160	29.
3,3'-Dichlorobenzidine	ND		ug/kg	160	44.
2,4-Dinitrotoluene	ND		ug/kg	160	33.
2,6-Dinitrotoluene	ND		ug/kg	160	28.
Fluoranthene	ND		ug/kg	99	19.
4-Chlorophenyl phenyl ether	ND		ug/kg	160	18.
4-Bromophenyl phenyl ether	ND		ug/kg	160	25.
Bis(2-chloroisopropyl)ether	ND		ug/kg	200	28.
Bis(2-chloroethoxy)methane	ND		ug/kg	180	16.
Hexachlorobutadiene	ND		ug/kg	160	24.
Hexachlorocyclopentadiene	ND		ug/kg	470	150
Hexachloroethane	ND		ug/kg	130	27.
Isophorone	ND		ug/kg	150	21.
Naphthalene	ND		ug/kg	160	20.
Nitrobenzene	ND		ug/kg	150	24.
NDPA/DPA	ND		ug/kg	130	19.
n-Nitrosodi-n-propylamine	ND		ug/kg	160	25.
Bis(2-ethylhexyl)phthalate	ND		ug/kg	160	57.
Butyl benzyl phthalate	ND		ug/kg	160	41.
Di-n-butylphthalate	ND		ug/kg	160	31.
Di-n-octylphthalate	ND		ug/kg	160	56.
Diethyl phthalate	ND		ug/kg	160	15.

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 07/20/23 19:05
Analyst: JG

Extraction Method: EPA 3546
Extraction Date: 07/20/23 11:27

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 07 Batch: WG1805578-1					
Dimethyl phthalate	ND		ug/kg	160	34.
Benzo(a)anthracene	ND		ug/kg	99	18.
Benzo(a)pyrene	ND		ug/kg	130	40.
Benzo(b)fluoranthene	ND		ug/kg	99	28.
Benzo(k)fluoranthene	ND		ug/kg	99	26.
Chrysene	ND		ug/kg	99	17.
Acenaphthylene	ND		ug/kg	130	25.
Anthracene	ND		ug/kg	99	32.
Benzo(ghi)perylene	ND		ug/kg	130	19.
Fluorene	ND		ug/kg	160	16.
Phenanthrene	ND		ug/kg	99	20.
Dibenzo(a,h)anthracene	ND		ug/kg	99	19.
Indeno(1,2,3-cd)pyrene	ND		ug/kg	130	23.
Pyrene	ND		ug/kg	99	16.
Biphenyl	ND		ug/kg	380	21.
4-Chloroaniline	ND		ug/kg	160	30.
2-Nitroaniline	ND		ug/kg	160	32.
3-Nitroaniline	ND		ug/kg	160	31.
4-Nitroaniline	ND		ug/kg	160	68.
Dibenzofuran	ND		ug/kg	160	16.
2-Methylnaphthalene	ND		ug/kg	200	20.
1,2,4,5-Tetrachlorobenzene	ND		ug/kg	160	17.
Acetophenone	ND		ug/kg	160	20.
2,4,6-Trichlorophenol	ND		ug/kg	99	31.
p-Chloro-m-cresol	ND		ug/kg	160	24.
2-Chlorophenol	ND		ug/kg	160	19.
2,4-Dichlorophenol	ND		ug/kg	150	26.
2,4-Dimethylphenol	ND		ug/kg	160	54.
2-Nitrophenol	ND		ug/kg	360	62.

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 07/20/23 19:05
Analyst: JG

Extraction Method: EPA 3546
Extraction Date: 07/20/23 11:27

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 07 Batch: WG1805578-1					
4-Nitrophenol	ND		ug/kg	230	67.
2,4-Dinitrophenol	ND		ug/kg	790	77.
4,6-Dinitro-o-cresol	ND		ug/kg	430	79.
Pentachlorophenol	ND		ug/kg	130	36.
Phenol	ND		ug/kg	160	25.
2-Methylphenol	ND		ug/kg	160	26.
3-Methylphenol/4-Methylphenol	ND		ug/kg	240	26.
2,4,5-Trichlorophenol	ND		ug/kg	160	32.
Benzoic Acid	ND		ug/kg	530	170
Benzyl Alcohol	ND		ug/kg	160	50.
Carbazole	ND		ug/kg	160	16.
1,4-Dioxane	ND		ug/kg	25	7.6
Tentatively Identified Compounds					
No Tentatively Identified Compounds	ND		ug/kg		

Surrogate	%Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	67		25-120
Phenol-d6	64		10-120
Nitrobenzene-d5	57		23-120
2-Fluorobiphenyl	65		30-120
2,4,6-Tribromophenol	78		10-136
4-Terphenyl-d14	64		18-120

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E-SIM
Analytical Date: 07/21/23 12:10
Analyst: RP

Extraction Method: EPA 3510C
Extraction Date: 07/20/23 11:58

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS-SIM - Westborough Lab for sample(s): 01-06 Batch: WG1805593-1					
Acenaphthene	0.02	J	ug/l	0.10	0.01
2-Chloronaphthalene	ND		ug/l	0.20	0.02
Fluoranthene	ND		ug/l	0.10	0.02
Hexachlorobutadiene	ND		ug/l	0.50	0.05
Naphthalene	0.89		ug/l	0.10	0.05
Benzo(a)anthracene	ND		ug/l	0.10	0.02
Benzo(a)pyrene	ND		ug/l	0.10	0.02
Benzo(b)fluoranthene	ND		ug/l	0.10	0.01
Benzo(k)fluoranthene	ND		ug/l	0.10	0.01
Chrysene	ND		ug/l	0.10	0.01
Acenaphthylene	ND		ug/l	0.10	0.01
Anthracene	ND		ug/l	0.10	0.01
Benzo(ghi)perylene	ND		ug/l	0.10	0.01
Fluorene	ND		ug/l	0.10	0.01
Phenanthrene	ND		ug/l	0.10	0.02
Dibenzo(a,h)anthracene	ND		ug/l	0.10	0.01
Indeno(1,2,3-cd)pyrene	ND		ug/l	0.10	0.01
Pyrene	ND		ug/l	0.10	0.02
2-Methylnaphthalene	0.06	J	ug/l	0.10	0.02
Pentachlorophenol	ND		ug/l	0.80	0.01
Hexachlorobenzene	ND		ug/l	0.80	0.01
Hexachloroethane	ND		ug/l	0.80	0.06

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E-SIM
Analytical Date: 07/21/23 12:10
Analyst: RP

Extraction Method: EPA 3510C
Extraction Date: 07/20/23 11:58

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS-SIM - Westborough Lab for sample(s): 01-06 Batch: WG1805593-1					

Surrogate	%Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	42		21-120
Phenol-d6	35		10-120
Nitrobenzene-d5	64		23-120
2-Fluorobiphenyl	55		15-120
2,4,6-Tribromophenol	99		10-120
4-Terphenyl-d14	58		41-149

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341423
Report Date: 07/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 07/20/23 22:00
Analyst: JG

Extraction Method: EPA 3510C
Extraction Date: 07/20/23 14:22

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 01-06 Batch: WG1805644-1					
Acenaphthene	ND		ug/l	2.0	0.44
1,2,4-Trichlorobenzene	ND		ug/l	5.0	0.50
Hexachlorobenzene	ND		ug/l	2.0	0.46
Bis(2-chloroethyl)ether	ND		ug/l	2.0	0.50
2-Chloronaphthalene	ND		ug/l	2.0	0.44
1,2-Dichlorobenzene	ND		ug/l	2.0	0.45
1,3-Dichlorobenzene	ND		ug/l	2.0	0.40
1,4-Dichlorobenzene	ND		ug/l	2.0	0.43
3,3'-Dichlorobenzidine	ND		ug/l	5.0	1.6
2,4-Dinitrotoluene	ND		ug/l	5.0	1.2
2,6-Dinitrotoluene	ND		ug/l	5.0	0.93
Fluoranthene	ND		ug/l	2.0	0.26
4-Chlorophenyl phenyl ether	ND		ug/l	2.0	0.49
4-Bromophenyl phenyl ether	ND		ug/l	2.0	0.38
Bis(2-chloroisopropyl)ether	ND		ug/l	2.0	0.53
Bis(2-chloroethoxy)methane	ND		ug/l	5.0	0.50
Hexachlorobutadiene	ND		ug/l	2.0	0.66
Hexachlorocyclopentadiene	ND		ug/l	20	0.69
Hexachloroethane	ND		ug/l	2.0	0.58
Isophorone	ND		ug/l	5.0	1.2
Naphthalene	1.2	J	ug/l	2.0	0.46
Nitrobenzene	ND		ug/l	2.0	0.77
NDPA/DPA	ND		ug/l	2.0	0.42
n-Nitrosodi-n-propylamine	ND		ug/l	5.0	0.64
Bis(2-ethylhexyl)phthalate	ND		ug/l	3.0	1.5
Butyl benzyl phthalate	ND		ug/l	5.0	1.2
Di-n-butylphthalate	ND		ug/l	5.0	0.39
Di-n-octylphthalate	ND		ug/l	5.0	1.3
Diethyl phthalate	ND		ug/l	5.0	0.38

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 07/20/23 22:00
Analyst: JG

Extraction Method: EPA 3510C
Extraction Date: 07/20/23 14:22

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 01-06 Batch: WG1805644-1					
Dimethyl phthalate	ND		ug/l	5.0	1.8
Benzo(a)anthracene	ND		ug/l	2.0	0.32
Benzo(a)pyrene	ND		ug/l	2.0	0.41
Benzo(b)fluoranthene	ND		ug/l	2.0	0.35
Benzo(k)fluoranthene	ND		ug/l	2.0	0.37
Chrysene	ND		ug/l	2.0	0.34
Acenaphthylene	ND		ug/l	2.0	0.46
Anthracene	ND		ug/l	2.0	0.33
Benzo(ghi)perylene	ND		ug/l	2.0	0.30
Fluorene	ND		ug/l	2.0	0.41
Phenanthrene	ND		ug/l	2.0	0.33
Dibenzo(a,h)anthracene	ND		ug/l	2.0	0.32
Indeno(1,2,3-cd)pyrene	ND		ug/l	2.0	0.40
Pyrene	ND		ug/l	2.0	0.28
Biphenyl	ND		ug/l	2.0	0.46
4-Chloroaniline	ND		ug/l	5.0	1.1
2-Nitroaniline	ND		ug/l	5.0	0.50
3-Nitroaniline	ND		ug/l	5.0	0.81
4-Nitroaniline	ND		ug/l	5.0	0.80
Dibenzofuran	ND		ug/l	2.0	0.50
2-Methylnaphthalene	ND		ug/l	2.0	0.45
1,2,4,5-Tetrachlorobenzene	ND		ug/l	10	0.44
Acetophenone	ND		ug/l	5.0	0.53
2,4,6-Trichlorophenol	ND		ug/l	5.0	0.61
p-Chloro-m-cresol	ND		ug/l	2.0	0.35
2-Chlorophenol	ND		ug/l	2.0	0.48
2,4-Dichlorophenol	ND		ug/l	5.0	0.41
2,4-Dimethylphenol	ND		ug/l	5.0	1.8
2-Nitrophenol	ND		ug/l	10	0.85

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341423
Report Date: 07/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 07/20/23 22:00
Analyst: JG

Extraction Method: EPA 3510C
Extraction Date: 07/20/23 14:22

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 01-06 Batch: WG1805644-1					
4-Nitrophenol	ND		ug/l	10	0.67
2,4-Dinitrophenol	ND		ug/l	20	6.6
4,6-Dinitro-o-cresol	ND		ug/l	10	1.8
Pentachlorophenol	ND		ug/l	10	1.8
Phenol	ND		ug/l	5.0	0.57
2-Methylphenol	ND		ug/l	5.0	0.49
3-Methylphenol/4-Methylphenol	ND		ug/l	5.0	0.48
2,4,5-Trichlorophenol	ND		ug/l	5.0	0.77
Benzoic Acid	ND		ug/l	50	2.6
Benzyl Alcohol	ND		ug/l	2.0	0.59
Carbazole	ND		ug/l	2.0	0.49

Tentatively Identified Compounds			
Total TIC Compounds	16.8	J	ug/l
Unknown	4.65	J	ug/l
Unknown	6.22	J	ug/l
Unknown Organic Acid	4.04	J	ug/l
Unknown	1.93	J	ug/l

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 07/20/23 22:00
Analyst: JG

Extraction Method: EPA 3510C
Extraction Date: 07/20/23 14:22

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 01-06 Batch: WG1805644-1					

Surrogate	%Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	50		21-120
Phenol-d6	40		10-120
Nitrobenzene-d5	54		23-120
2-Fluorobiphenyl	61		15-120
2,4,6-Tribromophenol	77		10-120
4-Terphenyl-d14	64		41-149

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341423
Report Date: 07/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E-SIM
Analytical Date: 07/23/23 11:14
Analyst: RP

Extraction Method: EPA 3510C
Extraction Date: 07/22/23 23:06

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS-SIM - Westborough Lab for sample(s): 06 Batch: WG1806557-1					
Acenaphthene	ND		ug/l	0.10	0.01
2-Chloronaphthalene	0.02	J	ug/l	0.20	0.02
Fluoranthene	0.03	J	ug/l	0.10	0.02
Hexachlorobutadiene	ND		ug/l	0.50	0.05
Naphthalene	1.1		ug/l	0.10	0.05
Benzo(a)anthracene	ND		ug/l	0.10	0.02
Benzo(a)pyrene	ND		ug/l	0.10	0.02
Benzo(b)fluoranthene	ND		ug/l	0.10	0.01
Benzo(k)fluoranthene	ND		ug/l	0.10	0.01
Chrysene	0.01	J	ug/l	0.10	0.01
Acenaphthylene	0.05	J	ug/l	0.10	0.01
Anthracene	0.02	J	ug/l	0.10	0.01
Benzo(ghi)perylene	ND		ug/l	0.10	0.01
Fluorene	0.04	J	ug/l	0.10	0.01
Phenanthrene	0.07	J	ug/l	0.10	0.02
Dibenzo(a,h)anthracene	ND		ug/l	0.10	0.01
Indeno(1,2,3-cd)pyrene	ND		ug/l	0.10	0.01
Pyrene	0.04	J	ug/l	0.10	0.02
2-Methylnaphthalene	0.10	J	ug/l	0.10	0.02
Pentachlorophenol	0.17	J	ug/l	0.80	0.01
Hexachlorobenzene	0.02	J	ug/l	0.80	0.01
Hexachloroethane	ND		ug/l	0.80	0.06

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E-SIM
Analytical Date: 07/23/23 11:14
Analyst: RP

Extraction Method: EPA 3510C
Extraction Date: 07/22/23 23:06

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS-SIM - Westborough Lab for sample(s): 06 Batch: WG1806557-1					

Surrogate	%Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	78		21-120
Phenol-d6	71		10-120
Nitrobenzene-d5	**121**	Q	23-120
2-Fluorobiphenyl	99		15-120
2,4,6-Tribromophenol	**171**	Q	10-120
4-Terphenyl-d14	90		41-149

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2341423

Report Date: 07/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 07 Batch: WG1805578-2 WG1805578-3								
Acenaphthene	63		55		31-137	14		50
1,2,4-Trichlorobenzene	66		56		38-107	16		50
Hexachlorobenzene	70		60		40-140	15		50
Bis(2-chloroethyl)ether	62		53		40-140	16		50
2-Chloronaphthalene	68		58		40-140	16		50
1,2-Dichlorobenzene	63		54		40-140	15		50
1,3-Dichlorobenzene	62		53		40-140	16		50
1,4-Dichlorobenzene	63		54		28-104	15		50
3,3'-Dichlorobenzidine	54		51		40-140	6		50
2,4-Dinitrotoluene	72		62		40-132	15		50
2,6-Dinitrotoluene	71		60		40-140	17		50
Fluoranthene	65		56		40-140	15		50
4-Chlorophenyl phenyl ether	67		58		40-140	14		50
4-Bromophenyl phenyl ether	68		58		40-140	16		50
Bis(2-chloroisopropyl)ether	63		54		40-140	15		50
Bis(2-chloroethoxy)methane	65		55		40-117	17		50
Hexachlorobutadiene	61		52		40-140	16		50
Hexachlorocyclopentadiene	60		52		40-140	14		50
Hexachloroethane	58		49		40-140	17		50
Isophorone	63		53		40-140	17		50
Naphthalene	66		57		40-140	15		50
Nitrobenzene	63		55		40-140	14		50
NDPA/DPA	67		58		36-157	14		50

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341423
Report Date: 07/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 07 Batch: WG1805578-2 WG1805578-3								
n-Nitrosodi-n-propylamine	62		53		32-121	16		50
Bis(2-ethylhexyl)phthalate	60		52		40-140	14		50
Butyl benzyl phthalate	62		55		40-140	12		50
Di-n-butylphthalate	63		54		40-140	15		50
Di-n-octylphthalate	58		52		40-140	11		50
Diethyl phthalate	63		54		40-140	15		50
Dimethyl phthalate	70		60		40-140	15		50
Benzo(a)anthracene	63		54		40-140	15		50
Benzo(a)pyrene	72		64		40-140	12		50
Benzo(b)fluoranthene	67		59		40-140	13		50
Benzo(k)fluoranthene	69		61		40-140	12		50
Chrysene	63		55		40-140	14		50
Acenaphthylene	75		64		40-140	16		50
Anthracene	67		57		40-140	16		50
Benzo(ghi)perylene	63		55		40-140	14		50
Fluorene	66		57		40-140	15		50
Phenanthrene	64		55		40-140	15		50
Dibenzo(a,h)anthracene	62		55		40-140	12		50
Indeno(1,2,3-cd)pyrene	63		56		40-140	12		50
Pyrene	65		58		35-142	11		50
Biphenyl	74		64		37-127	14		50
4-Chloroaniline	46		55		40-140	18		50
2-Nitroaniline	76		65		47-134	16		50

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341423
Report Date: 07/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 07 Batch: WG1805578-2 WG1805578-3								
3-Nitroaniline	56		52		26-129	7		50
4-Nitroaniline	68		59		41-125	14		50
Dibenzofuran	66		58		40-140	13		50
2-Methylnaphthalene	69		59		40-140	16		50
1,2,4,5-Tetrachlorobenzene	70		60		40-117	15		50
Acetophenone	71		61		14-144	15		50
2,4,6-Trichlorophenol	78		66		30-130	17		50
p-Chloro-m-cresol	72		62		26-103	15		50
2-Chlorophenol	68		58		25-102	16		50
2,4-Dichlorophenol	77		64		30-130	18		50
2,4-Dimethylphenol	74		63		30-130	16		50
2-Nitrophenol	72		60		30-130	18		50
4-Nitrophenol	72		63		11-114	13		50
2,4-Dinitrophenol	48		44		4-130	9		50
4,6-Dinitro-o-cresol	74		66		10-130	11		50
Pentachlorophenol	77		67		17-109	14		50
Phenol	69		58		26-90	17		50
2-Methylphenol	73		61		30-130.	18		50
3-Methylphenol/4-Methylphenol	74		64		30-130	14		50
2,4,5-Trichlorophenol	76		65		30-130	16		50
Benzoic Acid	28		22		10-110	24		50
Benzyl Alcohol	68		58		40-140	16		50
Carbazole	66		57		54-128	15		50

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2341423

Report Date: 07/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 07 Batch: WG1805578-2 WG1805578-3								
1,4-Dioxane	53		46		40-140	14		50

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
2-Fluorophenol	72		61		25-120
Phenol-d6	69		58		10-120
Nitrobenzene-d5	63		54		23-120
2-Fluorobiphenyl	69		59		30-120
2,4,6-Tribromophenol	80		71		10-136
4-Terphenyl-d14	63		55		18-120

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2341423

Report Date: 07/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS-SIM - Westborough Lab Associated sample(s): 01-06 Batch: WG1805593-2 WG1805593-3								
Acenaphthene	71		67		40-140	6		40
2-Chloronaphthalene	77		73		40-140	5		40
Fluoranthene	88		85		40-140	3		40
Hexachlorobutadiene	84		79		40-140	6		40
Naphthalene	75		71		40-140	5		40
Benzo(a)anthracene	88		84		40-140	5		40
Benzo(a)pyrene	91		89		40-140	2		40
Benzo(b)fluoranthene	86		81		40-140	6		40
Benzo(k)fluoranthene	88		88		40-140	0		40
Chrysene	80		76		40-140	5		40
Acenaphthylene	86		82		40-140	5		40
Anthracene	82		78		40-140	5		40
Benzo(ghi)perylene	83		80		40-140	4		40
Fluorene	79		75		40-140	5		40
Phenanthrene	72		68		40-140	6		40
Dibenzo(a,h)anthracene	82		79		40-140	4		40
Indeno(1,2,3-cd)pyrene	84		80		40-140	5		40
Pyrene	86		82		40-140	5		40
2-Methylnaphthalene	75		71		40-140	5		40
Pentachlorophenol	116		103		40-140	12		40
Hexachlorobenzene	88		83		40-140	6		40
Hexachloroethane	67		64		40-140	5		40

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits

Semivolatile Organics by GC/MS-SIM - Westborough Lab Associated sample(s): 01-06 Batch: WG1805593-2 WG1805593-3

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
2-Fluorophenol	59		59		21-120
Phenol-d6	53		53		10-120
Nitrobenzene-d5	83		81		23-120
2-Fluorobiphenyl	74		71		15-120
2,4,6-Tribromophenol	**143**	Q	**140**	Q	10-120
4-Terphenyl-d14	74		72		41-149

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2341423

Report Date: 07/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 01-06 Batch: WG1805644-2 WG1805644-3								
Acenaphthene	76		67		37-111	13		30
1,2,4-Trichlorobenzene	74		65		39-98	13		30
Hexachlorobenzene	80		74		40-140	8		30
Bis(2-chloroethyl)ether	80		66		40-140	19		30
2-Chloronaphthalene	75		68		40-140	10		30
1,2-Dichlorobenzene	75		62		40-140	19		30
1,3-Dichlorobenzene	74		57		40-140	26		30
1,4-Dichlorobenzene	79		63		36-97	23		30
3,3'-Dichlorobenzidine	69		69		40-140	0		30
2,4-Dinitrotoluene	86		75		48-143	14		30
2,6-Dinitrotoluene	83		78		40-140	6		30
Fluoranthene	84		72		40-140	15		30
4-Chlorophenyl phenyl ether	78		68		40-140	14		30
4-Bromophenyl phenyl ether	85		74		40-140	14		30
Bis(2-chloroisopropyl)ether	70		59		40-140	17		30
Bis(2-chloroethoxy)methane	88		71		40-140	21		30
Hexachlorobutadiene	70		64		40-140	9		30
Hexachlorocyclopentadiene	60		51		40-140	16		30
Hexachloroethane	82		73		40-140	12		30
Isophorone	80		69		40-140	15		30
Naphthalene	85		77		40-140	10		30
Nitrobenzene	89		72		40-140	21		30
NDPA/DPA	80		68		40-140	16		30

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2341423

Report Date: 07/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 01-06 Batch: WG1805644-2 WG1805644-3								
n-Nitrosodi-n-propylamine	97		78		29-132	22		30
Bis(2-ethylhexyl)phthalate	109		98		40-140	11		30
Butyl benzyl phthalate	103		86		40-140	18		30
Di-n-butylphthalate	92		83		40-140	10		30
Di-n-octylphthalate	97		91		40-140	6		30
Diethyl phthalate	94		82		40-140	14		30
Dimethyl phthalate	90		79		40-140	13		30
Benzo(a)anthracene	82		76		40-140	8		30
Benzo(a)pyrene	90		80		40-140	12		30
Benzo(b)fluoranthene	86		79		40-140	8		30
Benzo(k)fluoranthene	84		78		40-140	7		30
Chrysene	84		78		40-140	7		30
Acenaphthylene	83		77		45-123	8		30
Anthracene	83		73		40-140	13		30
Benzo(ghi)perylene	84		79		40-140	6		30
Fluorene	80		70		40-140	13		30
Phenanthrene	82		69		40-140	17		30
Dibenzo(a,h)anthracene	79		76		40-140	4		30
Indeno(1,2,3-cd)pyrene	78		73		40-140	7		30
Pyrene	82		73		26-127	12		30
Biphenyl	69		65		40-140	6		30
4-Chloroaniline	75		89		40-140	17		30
2-Nitroaniline	89		83		52-143	7		30

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2341423

Report Date: 07/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 01-06 Batch: WG1805644-2 WG1805644-3								
3-Nitroaniline	77		72		25-145	7		30
4-Nitroaniline	84		77		51-143	9		30
Dibenzofuran	79		71		40-140	11		30
2-Methylnaphthalene	75		71		40-140	5		30
1,2,4,5-Tetrachlorobenzene	68		60		2-134	13		30
Acetophenone	76		64		39-129	17		30
2,4,6-Trichlorophenol	83		76		30-130	9		30
p-Chloro-m-cresol	90		90		23-97	0		30
2-Chlorophenol	80		68		27-123	16		30
2,4-Dichlorophenol	89		76		30-130	16		30
2,4-Dimethylphenol	85		76		30-130	11		30
2-Nitrophenol	88		73		30-130	19		30
4-Nitrophenol	**93**	Q	**90**	Q	10-80	3		30
2,4-Dinitrophenol	88		87		20-130	1		30
4,6-Dinitro-o-cresol	100		86		20-164	15		30
Pentachlorophenol	96		87		9-103	10		30
Phenol	59		50		12-110	17		30
2-Methylphenol	84		70		30-130	18		30
3-Methylphenol/4-Methylphenol	94		82		30-130	14		30
2,4,5-Trichlorophenol	94		85		30-130	10		30
Benzoic Acid	66		**0**	Q	10-164	NC		30
Benzyl Alcohol	82		71		26-116	14		30
Carbazole	88		78		55-144	12		30

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2341423

Report Date: 07/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits

Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 01-06 Batch: WG1805644-2 WG1805644-3

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
2-Fluorophenol	68		59		21-120
Phenol-d6	60		50		10-120
Nitrobenzene-d5	80		68		23-120
2-Fluorobiphenyl	74		66		15-120
2,4,6-Tribromophenol	101		89		10-120
4-Terphenyl-d14	75		67		41-149

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341423
Report Date: 07/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS-SIM - Westborough Lab Associated sample(s): 06 Batch: WG1806557-2 WG1806557-3								
Acenaphthene	69		66		40-140	4		40
2-Chloronaphthalene	77		72		40-140	7		40
Fluoranthene	75		67		40-140	11		40
Hexachlorobutadiene	76		76		40-140	0		40
Naphthalene	68		67		40-140	1		40
Benzo(a)anthracene	76		70		40-140	8		40
Benzo(a)pyrene	81		73		40-140	10		40
Benzo(b)fluoranthene	80		72		40-140	11		40
Benzo(k)fluoranthene	87		79		40-140	10		40
Chrysene	75		66		40-140	13		40
Acenaphthylene	76		71		40-140	7		40
Anthracene	77		70		40-140	10		40
Benzo(ghi)perylene	75		67		40-140	11		40
Fluorene	74		69		40-140	7		40
Phenanthrene	70		64		40-140	9		40
Dibenzo(a,h)anthracene	78		69		40-140	12		40
Indeno(1,2,3-cd)pyrene	71		64		40-140	10		40
Pyrene	75		64		40-140	16		40
2-Methylnaphthalene	73		71		40-140	3		40
Pentachlorophenol	81		67		40-140	19		40
Hexachlorobenzene	88		83		40-140	6		40
Hexachloroethane	70		64		40-140	9		40

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits

Semivolatile Organics by GC/MS-SIM - Westborough Lab Associated sample(s): 06 Batch: WG1806557-2 WG1806557-3

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
2-Fluorophenol	58		57		21-120
Phenol-d6	54		51		10-120
Nitrobenzene-d5	73		72		23-120
2-Fluorobiphenyl	76		73		15-120
2,4,6-Tribromophenol	109		86		10-120
4-Terphenyl-d14	71		65		41-149

PCBS

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-01
Client ID: GW-18
Sample Location: WHITE PLAINS, NY

Date Collected: 07/19/23 09:45
Date Received: 07/19/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8082A
Analytical Date: 07/21/23 09:40
Analyst: MEO

Extraction Method: EPA 3510C
Extraction Date: 07/21/23 01:51
Cleanup Method: EPA 3665A
Cleanup Date: 07/21/23
Cleanup Method: EPA 3660B
Cleanup Date: 07/21/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/l	0.071	0.061	1	A
Aroclor 1221	ND		ug/l	0.071	0.061	1	A
Aroclor 1232	ND		ug/l	0.071	0.061	1	A
Aroclor 1242	ND		ug/l	0.071	0.061	1	A
Aroclor 1248	ND		ug/l	0.071	0.061	1	A
Aroclor 1254	ND		ug/l	0.071	0.061	1	A
Aroclor 1260	ND		ug/l	0.071	0.061	1	A
Aroclor 1262	ND		ug/l	0.071	0.061	1	A
Aroclor 1268	ND		ug/l	0.071	0.061	1	A
PCBs, Total	ND		ug/l	0.071	0.061	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	62		30-150	A
Decachlorobiphenyl	70		30-150	A
2,4,5,6-Tetrachloro-m-xylene	57		30-150	B
Decachlorobiphenyl	65		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-02
Client ID: GW-19
Sample Location: WHITE PLAINS, NY

Date Collected: 07/19/23 08:30
Date Received: 07/19/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8082A
Analytical Date: 07/21/23 09:49
Analyst: MEO

Extraction Method: EPA 3510C
Extraction Date: 07/21/23 01:51
Cleanup Method: EPA 3665A
Cleanup Date: 07/21/23
Cleanup Method: EPA 3660B
Cleanup Date: 07/21/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/l	0.071	0.061	1	A
Aroclor 1221	ND		ug/l	0.071	0.061	1	A
Aroclor 1232	ND		ug/l	0.071	0.061	1	A
Aroclor 1242	ND		ug/l	0.071	0.061	1	A
Aroclor 1248	ND		ug/l	0.071	0.061	1	A
Aroclor 1254	ND		ug/l	0.071	0.061	1	A
Aroclor 1260	ND		ug/l	0.071	0.061	1	A
Aroclor 1262	ND		ug/l	0.071	0.061	1	A
Aroclor 1268	ND		ug/l	0.071	0.061	1	A
PCBs, Total	ND		ug/l	0.071	0.061	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	60		30-150	A
Decachlorobiphenyl	55		30-150	A
2,4,5,6-Tetrachloro-m-xylene	56		30-150	B
Decachlorobiphenyl	53		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-03
Client ID: GW-20
Sample Location: WHITE PLAINS, NY

Date Collected: 07/19/23 14:20
Date Received: 07/19/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8082A
Analytical Date: 07/21/23 09:59
Analyst: MEO

Extraction Method: EPA 3510C
Extraction Date: 07/21/23 01:51
Cleanup Method: EPA 3665A
Cleanup Date: 07/21/23
Cleanup Method: EPA 3660B
Cleanup Date: 07/21/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/l	0.071	0.061	1	A
Aroclor 1221	ND		ug/l	0.071	0.061	1	A
Aroclor 1232	ND		ug/l	0.071	0.061	1	A
Aroclor 1242	ND		ug/l	0.071	0.061	1	A
Aroclor 1248	ND		ug/l	0.071	0.061	1	A
Aroclor 1254	ND		ug/l	0.071	0.061	1	A
Aroclor 1260	ND		ug/l	0.071	0.061	1	A
Aroclor 1262	ND		ug/l	0.071	0.061	1	A
Aroclor 1268	ND		ug/l	0.071	0.061	1	A
PCBs, Total	ND		ug/l	0.071	0.061	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	55		30-150	A
Decachlorobiphenyl	68		30-150	A
2,4,5,6-Tetrachloro-m-xylene	56		30-150	B
Decachlorobiphenyl	64		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-04
Client ID: GW-21
Sample Location: WHITE PLAINS, NY

Date Collected: 07/19/23 11:20
Date Received: 07/19/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8082A
Analytical Date: 07/21/23 10:08
Analyst: MEO

Extraction Method: EPA 3510C
Extraction Date: 07/21/23 01:51
Cleanup Method: EPA 3665A
Cleanup Date: 07/21/23
Cleanup Method: EPA 3660B
Cleanup Date: 07/21/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/l	0.071	0.061	1	A
Aroclor 1221	ND		ug/l	0.071	0.061	1	A
Aroclor 1232	ND		ug/l	0.071	0.061	1	A
Aroclor 1242	ND		ug/l	0.071	0.061	1	A
Aroclor 1248	ND		ug/l	0.071	0.061	1	A
Aroclor 1254	ND		ug/l	0.071	0.061	1	A
Aroclor 1260	ND		ug/l	0.071	0.061	1	A
Aroclor 1262	ND		ug/l	0.071	0.061	1	A
Aroclor 1268	ND		ug/l	0.071	0.061	1	A
PCBs, Total	ND		ug/l	0.071	0.061	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	59		30-150	A
Decachlorobiphenyl	64		30-150	A
2,4,5,6-Tetrachloro-m-xylene	55		30-150	B
Decachlorobiphenyl	61		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-05
Client ID: GW-22
Sample Location: WHITE PLAINS, NY

Date Collected: 07/19/23 11:45
Date Received: 07/19/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8082A
Analytical Date: 07/21/23 10:18
Analyst: MEO

Extraction Method: EPA 3510C
Extraction Date: 07/21/23 01:51
Cleanup Method: EPA 3665A
Cleanup Date: 07/21/23
Cleanup Method: EPA 3660B
Cleanup Date: 07/21/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/l	0.071	0.061	1	A
Aroclor 1221	ND		ug/l	0.071	0.061	1	A
Aroclor 1232	ND		ug/l	0.071	0.061	1	A
Aroclor 1242	ND		ug/l	0.071	0.061	1	A
Aroclor 1248	ND		ug/l	0.071	0.061	1	A
Aroclor 1254	ND		ug/l	0.071	0.061	1	A
Aroclor 1260	ND		ug/l	0.071	0.061	1	A
Aroclor 1262	ND		ug/l	0.071	0.061	1	A
Aroclor 1268	ND		ug/l	0.071	0.061	1	A
PCBs, Total	ND		ug/l	0.071	0.061	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	59		30-150	A
Decachlorobiphenyl	60		30-150	A
2,4,5,6-Tetrachloro-m-xylene	57		30-150	B
Decachlorobiphenyl	58		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-06
Client ID: GW-23
Sample Location: WHITE PLAINS, NY

Date Collected: 07/19/23 13:50
Date Received: 07/19/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8082A
Analytical Date: 07/21/23 10:27
Analyst: MEO

Extraction Method: EPA 3510C
Extraction Date: 07/21/23 01:51
Cleanup Method: EPA 3665A
Cleanup Date: 07/21/23
Cleanup Method: EPA 3660B
Cleanup Date: 07/21/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/l	0.071	0.061	1	A
Aroclor 1221	ND		ug/l	0.071	0.061	1	A
Aroclor 1232	ND		ug/l	0.071	0.061	1	A
Aroclor 1242	ND		ug/l	0.071	0.061	1	A
Aroclor 1248	ND		ug/l	0.071	0.061	1	A
Aroclor 1254	ND		ug/l	0.071	0.061	1	A
Aroclor 1260	ND		ug/l	0.071	0.061	1	A
Aroclor 1262	ND		ug/l	0.071	0.061	1	A
Aroclor 1268	ND		ug/l	0.071	0.061	1	A
PCBs, Total	ND		ug/l	0.071	0.061	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	64		30-150	A
Decachlorobiphenyl	70		30-150	A
2,4,5,6-Tetrachloro-m-xylene	58		30-150	B
Decachlorobiphenyl	64		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-07
Client ID: SB-51P (3.5-4)
Sample Location: WHITE PLAINS, NY

Date Collected: 07/19/23 15:00
Date Received: 07/19/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8082A
Analytical Date: 07/21/23 01:23
Analyst: JM
Percent Solids: 93%

Extraction Method: EPA 3546
Extraction Date: 07/20/23 07:50
Cleanup Method: EPA 3665A
Cleanup Date: 07/20/23
Cleanup Method: EPA 3660B
Cleanup Date: 07/20/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/kg	52.0	4.62	1	A
Aroclor 1221	ND		ug/kg	52.0	5.21	1	A
Aroclor 1232	ND		ug/kg	52.0	11.0	1	A
Aroclor 1242	ND		ug/kg	52.0	7.01	1	A
Aroclor 1248	ND		ug/kg	52.0	7.80	1	A
Aroclor 1254	ND		ug/kg	52.0	5.68	1	A
Aroclor 1260	ND		ug/kg	52.0	9.60	1	A
Aroclor 1262	ND		ug/kg	52.0	6.60	1	A
Aroclor 1268	ND		ug/kg	52.0	5.38	1	A
PCBs, Total	ND		ug/kg	52.0	4.62	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	57		30-150	A
Decachlorobiphenyl	58		30-150	A
2,4,5,6-Tetrachloro-m-xylene	59		30-150	B
Decachlorobiphenyl	60		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8082A
Analytical Date: 07/20/23 00:38
Analyst: JM

Extraction Method: EPA 3546
Extraction Date: 07/19/23 09:41
Cleanup Method: EPA 3665A
Cleanup Date: 07/19/23
Cleanup Method: EPA 3660B
Cleanup Date: 07/20/23

Parameter	Result	Qualifier	Units	RL	MDL	Column
Polychlorinated Biphenyls by GC - Westborough Lab for sample(s): 07 Batch: WG1804997-1						
Aroclor 1016	ND		ug/kg	47.1	4.18	A
Aroclor 1221	ND		ug/kg	47.1	4.72	A
Aroclor 1232	ND		ug/kg	47.1	9.98	A
Aroclor 1242	ND		ug/kg	47.1	6.35	A
Aroclor 1248	ND		ug/kg	47.1	7.06	A
Aroclor 1254	ND		ug/kg	47.1	5.15	A
Aroclor 1260	ND		ug/kg	47.1	8.70	A
Aroclor 1262	ND		ug/kg	47.1	5.98	A
Aroclor 1268	ND		ug/kg	47.1	4.88	A
PCBs, Total	ND		ug/kg	47.1	4.18	A

Surrogate	%Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	67		30-150	A
Decachlorobiphenyl	71		30-150	A
2,4,5,6-Tetrachloro-m-xylene	70		30-150	B
Decachlorobiphenyl	74		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8082A
Analytical Date: 07/21/23 08:06
Analyst: MEO

Extraction Method: EPA 3510C
Extraction Date: 07/20/23 23:00
Cleanup Method: EPA 3665A
Cleanup Date: 07/21/23
Cleanup Method: EPA 3660B
Cleanup Date: 07/21/23

Parameter	Result	Qualifier	Units	RL	MDL	Column
Polychlorinated Biphenyls by GC - Westborough Lab for sample(s): 01-06 Batch: WG1805781-1						
Aroclor 1016	ND		ug/l	0.071	0.061	A
Aroclor 1221	ND		ug/l	0.071	0.061	A
Aroclor 1232	ND		ug/l	0.071	0.061	A
Aroclor 1242	ND		ug/l	0.071	0.061	A
Aroclor 1248	ND		ug/l	0.071	0.061	A
Aroclor 1254	ND		ug/l	0.071	0.061	A
Aroclor 1260	ND		ug/l	0.071	0.061	A
Aroclor 1262	ND		ug/l	0.071	0.061	A
Aroclor 1268	ND		ug/l	0.071	0.061	A
PCBs, Total	ND		ug/l	0.071	0.061	A

Surrogate	%Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	65		30-150	A
Decachlorobiphenyl	84		30-150	A
2,4,5,6-Tetrachloro-m-xylene	55		30-150	B
Decachlorobiphenyl	72		30-150	B

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341423
Report Date: 07/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits	Column
Polychlorinated Biphenyls by GC - Westborough Lab Associated sample(s): 07 Batch: WG1804997-2 WG1804997-3									
Aroclor 1016	71		72		40-140	1		50	A
Aroclor 1260	70		72		40-140	3		50	A

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	73		71		30-150	A
Decachlorobiphenyl	77		79		30-150	A
2,4,5,6-Tetrachloro-m-xylene	76		73		30-150	B
Decachlorobiphenyl	83		84		30-150	B

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2341423

Report Date: 07/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits	Column
Polychlorinated Biphenyls by GC - Westborough Lab Associated sample(s): 01-06 Batch: WG1805781-2 WG1805781-3									
Aroclor 1016	73		73		40-140	0		50	A
Aroclor 1260	76		77		40-140	2		50	A

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	64		63		30-150	A
Decachlorobiphenyl	80		77		30-150	A
2,4,5,6-Tetrachloro-m-xylene	58		58		30-150	B
Decachlorobiphenyl	74		73		30-150	B

PESTICIDES

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-01
Client ID: GW-18
Sample Location: WHITE PLAINS, NY

Date Collected: 07/19/23 09:45
Date Received: 07/19/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8081B
Analytical Date: 07/22/23 10:16
Analyst: AR

Extraction Method: EPA 3510C
Extraction Date: 07/21/23 01:48

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/l	0.014	0.003	1	A
Lindane	ND		ug/l	0.014	0.003	1	A
Alpha-BHC	ND		ug/l	0.014	0.003	1	A
Beta-BHC	ND		ug/l	0.014	0.004	1	A
Heptachlor	ND		ug/l	0.014	0.002	1	A
Aldrin	ND		ug/l	0.014	0.002	1	A
Heptachlor epoxide	ND		ug/l	0.014	0.003	1	A
Endrin	ND		ug/l	0.029	0.003	1	A
Endrin aldehyde	ND		ug/l	0.029	0.006	1	A
Endrin ketone	ND		ug/l	0.029	0.003	1	A
Dieldrin	ND		ug/l	0.029	0.003	1	A
4,4'-DDE	ND		ug/l	0.029	0.003	1	A
4,4'-DDD	ND		ug/l	0.029	0.003	1	A
4,4'-DDT	ND		ug/l	0.029	0.003	1	A
Endosulfan I	ND		ug/l	0.014	0.002	1	A
Endosulfan II	ND		ug/l	0.029	0.004	1	A
Endosulfan sulfate	ND		ug/l	0.029	0.003	1	A
Methoxychlor	ND		ug/l	0.143	0.005	1	A
Toxaphene	ND		ug/l	0.143	0.045	1	A
cis-Chlordane	ND		ug/l	0.014	0.005	1	A
trans-Chlordane	ND		ug/l	0.014	0.004	1	A
Chlordane	ND		ug/l	0.143	0.033	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-01 Date Collected: 07/19/23 09:45

Client ID: GW-18 Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	68		30-150	A
Decachlorobiphenyl	67		30-150	A
2,4,5,6-Tetrachloro-m-xylene	64		30-150	B
Decachlorobiphenyl	55		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-02
Client ID: GW-19
Sample Location: WHITE PLAINS, NY

Date Collected: 07/19/23 08:30
Date Received: 07/19/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8081B
Analytical Date: 07/22/23 10:27
Analyst: AR

Extraction Method: EPA 3510C
Extraction Date: 07/21/23 01:48

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/l	0.014	0.003	1	A
Lindane	ND		ug/l	0.014	0.003	1	A
Alpha-BHC	ND		ug/l	0.014	0.003	1	A
Beta-BHC	ND		ug/l	0.014	0.004	1	A
Heptachlor	ND		ug/l	0.014	0.002	1	A
Aldrin	ND		ug/l	0.014	0.002	1	A
Heptachlor epoxide	ND		ug/l	0.014	0.003	1	A
Endrin	ND		ug/l	0.029	0.003	1	A
Endrin aldehyde	ND		ug/l	0.029	0.006	1	A
Endrin ketone	ND		ug/l	0.029	0.003	1	A
Dieldrin	ND		ug/l	0.029	0.003	1	A
4,4'-DDE	ND		ug/l	0.029	0.003	1	A
4,4'-DDD	ND		ug/l	0.029	0.003	1	A
4,4'-DDT	ND		ug/l	0.029	0.003	1	A
Endosulfan I	ND		ug/l	0.014	0.002	1	A
Endosulfan II	ND		ug/l	0.029	0.004	1	A
Endosulfan sulfate	ND		ug/l	0.029	0.003	1	A
Methoxychlor	ND		ug/l	0.143	0.005	1	A
Toxaphene	ND		ug/l	0.143	0.045	1	A
cis-Chlordane	ND		ug/l	0.014	0.005	1	A
trans-Chlordane	ND		ug/l	0.014	0.004	1	A
Chlordane	ND		ug/l	0.143	0.033	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-02 Date Collected: 07/19/23 08:30

Client ID: GW-19 Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	60		30-150	A
Decachlorobiphenyl	54		30-150	A
2,4,5,6-Tetrachloro-m-xylene	54		30-150	B
Decachlorobiphenyl	43		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-03
Client ID: GW-20
Sample Location: WHITE PLAINS, NY

Date Collected: 07/19/23 14:20
Date Received: 07/19/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8081B
Analytical Date: 07/22/23 10:38
Analyst: AR

Extraction Method: EPA 3510C
Extraction Date: 07/21/23 01:48

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/l	0.014	0.003	1	A
Lindane	ND		ug/l	0.014	0.003	1	A
Alpha-BHC	ND		ug/l	0.014	0.003	1	A
Beta-BHC	ND		ug/l	0.014	0.004	1	A
Heptachlor	ND		ug/l	0.014	0.002	1	A
Aldrin	ND		ug/l	0.014	0.002	1	A
Heptachlor epoxide	ND		ug/l	0.014	0.003	1	A
Endrin	ND		ug/l	0.029	0.003	1	A
Endrin aldehyde	ND		ug/l	0.029	0.006	1	A
Endrin ketone	ND		ug/l	0.029	0.003	1	A
Dieldrin	0.013	J	ug/l	0.029	0.003	1	A
4,4'-DDE	ND		ug/l	0.029	0.003	1	A
4,4'-DDD	ND		ug/l	0.029	0.003	1	A
4,4'-DDT	ND		ug/l	0.029	0.003	1	A
Endosulfan I	ND		ug/l	0.014	0.002	1	A
Endosulfan II	ND		ug/l	0.029	0.004	1	A
Endosulfan sulfate	ND		ug/l	0.029	0.003	1	A
Methoxychlor	ND		ug/l	0.143	0.005	1	A
Toxaphene	ND		ug/l	0.143	0.045	1	A
cis-Chlordane	ND		ug/l	0.014	0.005	1	A
trans-Chlordane	ND		ug/l	0.014	0.004	1	A
Chlordane	ND		ug/l	0.143	0.033	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-03 Date Collected: 07/19/23 14:20

Client ID: GW-20 Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	63		30-150	A
Decachlorobiphenyl	74		30-150	A
2,4,5,6-Tetrachloro-m-xylene	59		30-150	B
Decachlorobiphenyl	64		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-04
Client ID: GW-21
Sample Location: WHITE PLAINS, NY

Date Collected: 07/19/23 11:20
Date Received: 07/19/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8081B
Analytical Date: 07/22/23 10:50
Analyst: AR

Extraction Method: EPA 3510C
Extraction Date: 07/21/23 01:48

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/l	0.014	0.003	1	A
Lindane	ND		ug/l	0.014	0.003	1	A
Alpha-BHC	ND		ug/l	0.014	0.003	1	A
Beta-BHC	ND		ug/l	0.014	0.004	1	A
Heptachlor	ND		ug/l	0.014	0.002	1	A
Aldrin	ND		ug/l	0.014	0.002	1	A
Heptachlor epoxide	ND		ug/l	0.014	0.003	1	A
Endrin	ND		ug/l	0.029	0.003	1	A
Endrin aldehyde	ND		ug/l	0.029	0.006	1	A
Endrin ketone	ND		ug/l	0.029	0.003	1	A
Dieldrin	ND		ug/l	0.029	0.003	1	A
4,4'-DDE	ND		ug/l	0.029	0.003	1	A
4,4'-DDD	ND		ug/l	0.029	0.003	1	A
4,4'-DDT	ND		ug/l	0.029	0.003	1	A
Endosulfan I	ND		ug/l	0.014	0.002	1	A
Endosulfan II	ND		ug/l	0.029	0.004	1	A
Endosulfan sulfate	ND		ug/l	0.029	0.003	1	A
Methoxychlor	ND		ug/l	0.143	0.005	1	A
Toxaphene	ND		ug/l	0.143	0.045	1	A
cis-Chlordane	ND		ug/l	0.014	0.005	1	A
trans-Chlordane	ND		ug/l	0.014	0.004	1	A
Chlordane	ND		ug/l	0.143	0.033	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-04 Date Collected: 07/19/23 11:20

Client ID: GW-21 Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	66		30-150	A
Decachlorobiphenyl	66		30-150	A
2,4,5,6-Tetrachloro-m-xylene	65		30-150	B
Decachlorobiphenyl	58		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-05
Client ID: GW-22
Sample Location: WHITE PLAINS, NY

Date Collected: 07/19/23 11:45
Date Received: 07/19/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8081B
Analytical Date: 07/22/23 11:01
Analyst: AR

Extraction Method: EPA 3510C
Extraction Date: 07/21/23 01:48

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/l	0.014	0.003	1	A
Lindane	ND		ug/l	0.014	0.003	1	A
Alpha-BHC	ND		ug/l	0.014	0.003	1	A
Beta-BHC	ND		ug/l	0.014	0.004	1	A
Heptachlor	ND		ug/l	0.014	0.002	1	A
Aldrin	ND		ug/l	0.014	0.002	1	A
Heptachlor epoxide	ND		ug/l	0.014	0.003	1	A
Endrin	ND		ug/l	0.029	0.003	1	A
Endrin aldehyde	ND		ug/l	0.029	0.006	1	A
Endrin ketone	ND		ug/l	0.029	0.003	1	A
Dieldrin	ND		ug/l	0.029	0.003	1	A
4,4'-DDE	ND		ug/l	0.029	0.003	1	A
4,4'-DDD	ND		ug/l	0.029	0.003	1	A
4,4'-DDT	ND		ug/l	0.029	0.003	1	A
Endosulfan I	ND		ug/l	0.014	0.002	1	A
Endosulfan II	ND		ug/l	0.029	0.004	1	A
Endosulfan sulfate	ND		ug/l	0.029	0.003	1	A
Methoxychlor	ND		ug/l	0.143	0.005	1	A
Toxaphene	ND		ug/l	0.143	0.045	1	A
cis-Chlordane	ND		ug/l	0.014	0.005	1	A
trans-Chlordane	ND		ug/l	0.014	0.004	1	A
Chlordane	ND		ug/l	0.143	0.033	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-05 Date Collected: 07/19/23 11:45

Client ID: GW-22 Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	65		30-150	A
Decachlorobiphenyl	73		30-150	A
2,4,5,6-Tetrachloro-m-xylene	62		30-150	B
Decachlorobiphenyl	63		30-150	B

Project Name: 100 MAIN ST.
Lab Number: L2341423
Project Number: 12461
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-06
Client ID: GW-23
Sample Location: WHITE PLAINS, NY

Date Collected: 07/19/23 13:50
Date Received: 07/19/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8081B
Analytical Date: 07/22/23 11:12
Analyst: AR

Extraction Method: EPA 3510C
Extraction Date: 07/21/23 01:48

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/l	0.014	0.003	1	A
Lindane	ND		ug/l	0.014	0.003	1	A
Alpha-BHC	ND		ug/l	0.014	0.003	1	A
Beta-BHC	ND		ug/l	0.014	0.004	1	A
Heptachlor	ND		ug/l	0.014	0.002	1	A
Aldrin	ND		ug/l	0.014	0.002	1	A
Heptachlor epoxide	ND		ug/l	0.014	0.003	1	A
Endrin	ND		ug/l	0.029	0.003	1	A
Endrin aldehyde	ND		ug/l	0.029	0.006	1	A
Endrin ketone	ND		ug/l	0.029	0.003	1	A
Dieldrin	ND		ug/l	0.029	0.003	1	A
4,4'-DDE	ND		ug/l	0.029	0.003	1	A
4,4'-DDD	ND		ug/l	0.029	0.003	1	A
4,4'-DDT	ND		ug/l	0.029	0.003	1	A
Endosulfan I	ND		ug/l	0.014	0.002	1	A
Endosulfan II	ND		ug/l	0.029	0.004	1	A
Endosulfan sulfate	ND		ug/l	0.029	0.003	1	A
Methoxychlor	ND		ug/l	0.143	0.005	1	A
Toxaphene	ND		ug/l	0.143	0.045	1	A
cis-Chlordane	ND		ug/l	0.014	0.005	1	A
trans-Chlordane	ND		ug/l	0.014	0.004	1	A
Chlordane	ND		ug/l	0.143	0.033	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-06 Date Collected: 07/19/23 13:50

Client ID: GW-23 Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	68		30-150	A
Decachlorobiphenyl	61		30-150	A
2,4,5,6-Tetrachloro-m-xylene	62		30-150	B
Decachlorobiphenyl	52		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-07
Client ID: SB-51P (3.5-4)
Sample Location: WHITE PLAINS, NY

Date Collected: 07/19/23 15:00
Date Received: 07/19/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil
Analytical Method: 1,8081B
Analytical Date: 07/21/23 12:12
Analyst: AR
Percent Solids: 93%

Extraction Method: EPA 3546
Extraction Date: 07/20/23 07:56
Cleanup Method: EPA 3620B
Cleanup Date: 07/21/23
Cleanup Method: EPA 3660B
Cleanup Date: 07/21/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/kg	1.64	0.321	1	A
Lindane	ND		ug/kg	0.683	0.305	1	A
Alpha-BHC	ND		ug/kg	0.683	0.194	1	A
Beta-BHC	ND		ug/kg	1.64	0.622	1	A
Heptachlor	ND		ug/kg	0.820	0.368	1	A
Aldrin	ND		ug/kg	1.64	0.577	1	A
Heptachlor epoxide	ND		ug/kg	3.07	0.922	1	A
Endrin	ND		ug/kg	0.683	0.280	1	A
Endrin aldehyde	ND		ug/kg	2.05	0.717	1	A
Endrin ketone	ND		ug/kg	1.64	0.422	1	A
Dieldrin	ND		ug/kg	1.02	0.512	1	A
4,4'-DDE	ND		ug/kg	1.64	0.379	1	A
4,4'-DDD	ND		ug/kg	1.64	0.585	1	A
4,4'-DDT	ND		ug/kg	1.64	1.32	1	A
Endosulfan I	ND		ug/kg	1.64	0.387	1	A
Endosulfan II	ND		ug/kg	1.64	0.548	1	A
Endosulfan sulfate	ND		ug/kg	0.683	0.325	1	A
Methoxychlor	ND		ug/kg	3.07	0.956	1	A
Toxaphene	ND		ug/kg	30.7	8.61	1	A
cis-Chlordane	ND		ug/kg	2.05	0.571	1	A
trans-Chlordane	ND		ug/kg	2.05	0.541	1	A
Chlordane	ND		ug/kg	13.7	5.43	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-07 Date Collected: 07/19/23 15:00

Client ID: SB-51P (3.5-4) Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	69		30-150	A
Decachlorobiphenyl	80		30-150	A
2,4,5,6-Tetrachloro-m-xylene	73		30-150	B
Decachlorobiphenyl	80		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8081B
Analytical Date: 07/20/23 07:22
Analyst: AR

Extraction Method: EPA 3546
Extraction Date: 07/19/23 08:12
Cleanup Method: EPA 3620B
Cleanup Date: 07/19/23
Cleanup Method: EPA 3660B
Cleanup Date: 07/19/23

Parameter	Result	Qualifier	Units	RL	MDL	Column
Organochlorine Pesticides by GC - Westborough Lab for sample(s): 07 Batch: WG1804931-1						
Delta-BHC	ND		ug/kg	1.58	0.310	A
Lindane	ND		ug/kg	0.660	0.295	A
Alpha-BHC	ND		ug/kg	0.660	0.188	A
Beta-BHC	ND		ug/kg	1.58	0.601	A
Heptachlor	ND		ug/kg	0.793	0.355	A
Aldrin	ND		ug/kg	1.58	0.558	A
Heptachlor epoxide	ND		ug/kg	2.97	0.892	A
Endrin	ND		ug/kg	0.660	0.271	A
Endrin aldehyde	ND		ug/kg	1.98	0.694	A
Endrin ketone	ND		ug/kg	1.58	0.408	A
Dieldrin	ND		ug/kg	0.991	0.495	A
4,4'-DDE	ND		ug/kg	1.58	0.366	A
4,4'-DDD	ND		ug/kg	1.58	0.565	A
4,4'-DDT	ND		ug/kg	1.58	1.27	A
Endosulfan I	ND		ug/kg	1.58	0.374	A
Endosulfan II	ND		ug/kg	1.58	0.530	A
Endosulfan sulfate	ND		ug/kg	0.660	0.314	A
Methoxychlor	ND		ug/kg	2.97	0.925	A
Toxaphene	ND		ug/kg	29.7	8.32	A
cis-Chlordane	ND		ug/kg	1.98	0.552	A
trans-Chlordane	ND		ug/kg	1.98	0.523	A
Chlordane	ND		ug/kg	13.2	5.25	A

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8081B
Analytical Date: 07/20/23 07:22
Analyst: AR

Extraction Method: EPA 3546
Extraction Date: 07/19/23 08:12
Cleanup Method: EPA 3620B
Cleanup Date: 07/19/23
Cleanup Method: EPA 3660B
Cleanup Date: 07/19/23

Parameter	Result	Qualifier	Units	RL	MDL	Column
Organochlorine Pesticides by GC - Westborough Lab for sample(s): 07 Batch: WG1804931-1						

Surrogate	%Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	75		30-150	A
Decachlorobiphenyl	107		30-150	A
2,4,5,6-Tetrachloro-m-xylene	82		30-150	B
Decachlorobiphenyl	112		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8081B
Analytical Date: 07/20/23 14:34
Analyst: MMG

Extraction Method: EPA 3510C
Extraction Date: 07/20/23 05:40

Parameter	Result	Qualifier	Units	RL	MDL	Column
Organochlorine Pesticides by GC - Westborough Lab for sample(s): 01-06 Batch: WG1805342-1						
Delta-BHC	ND		ug/l	0.014	0.003	A
Lindane	ND		ug/l	0.014	0.003	A
Alpha-BHC	ND		ug/l	0.014	0.003	A
Beta-BHC	ND		ug/l	0.014	0.004	A
Heptachlor	ND		ug/l	0.014	0.002	A
Aldrin	ND		ug/l	0.014	0.002	A
Heptachlor epoxide	ND		ug/l	0.014	0.003	A
Endrin	ND		ug/l	0.029	0.003	A
Endrin aldehyde	ND		ug/l	0.029	0.006	A
Endrin ketone	ND		ug/l	0.029	0.003	A
Dieldrin	ND		ug/l	0.029	0.003	A
4,4'-DDE	ND		ug/l	0.029	0.003	A
4,4'-DDD	ND		ug/l	0.029	0.003	A
4,4'-DDT	ND		ug/l	0.029	0.003	A
Endosulfan I	ND		ug/l	0.014	0.002	A
Endosulfan II	ND		ug/l	0.029	0.004	A
Endosulfan sulfate	ND		ug/l	0.029	0.003	A
Methoxychlor	ND		ug/l	0.143	0.005	A
Toxaphene	ND		ug/l	0.143	0.045	A
cis-Chlordane	ND		ug/l	0.014	0.005	A
trans-Chlordane	ND		ug/l	0.014	0.004	A
Chlordane	ND		ug/l	0.143	0.033	A

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8081B
Analytical Date: 07/20/23 14:34
Analyst: MMG

Extraction Method: EPA 3510C
Extraction Date: 07/20/23 05:40

Parameter	Result	Qualifier	Units	RL	MDL	Column
Organochlorine Pesticides by GC - Westborough Lab for sample(s): 01-06 Batch: WG1805342-1						

Surrogate	%Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	74		30-150	A
Decachlorobiphenyl	92		30-150	A
2,4,5,6-Tetrachloro-m-xylene	75		30-150	B
Decachlorobiphenyl	87		30-150	B

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2341423

Report Date: 07/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits	Column
Organochlorine Pesticides by GC - Westborough Lab Associated sample(s): 07 Batch: WG1804931-2 WG1804931-3									
Delta-BHC	90		89		30-150	1		30	A
Lindane	90		89		30-150	1		30	A
Alpha-BHC	86		87		30-150	1		30	A
Beta-BHC	91		94		30-150	3		30	A
Heptachlor	93		91		30-150	2		30	A
Aldrin	89		87		30-150	2		30	A
Heptachlor epoxide	89		86		30-150	3		30	A
Endrin	94		92		30-150	2		30	A
Endrin aldehyde	83		82		30-150	1		30	A
Endrin ketone	102		101		30-150	1		30	A
Dieldrin	99		95		30-150	4		30	A
4,4'-DDE	97		94		30-150	3		30	A
4,4'-DDD	104		102		30-150	2		30	A
4,4'-DDT	102		98		30-150	4		30	A
Endosulfan I	89		85		30-150	5		30	A
Endosulfan II	95		92		30-150	3		30	A
Endosulfan sulfate	94		91		30-150	3		30	A
Methoxychlor	103		104		30-150	1		30	A
cis-Chlordane	88		85		30-150	3		30	A
trans-Chlordane	102		97		30-150	5		30	A

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2341423

Report Date: 07/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits

Organochlorine Pesticides by GC - Westborough Lab Associated sample(s): 07 Batch: WG1804931-2 WG1804931-3

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	79		69		30-150	A
Decachlorobiphenyl	107		96		30-150	A
2,4,5,6-Tetrachloro-m-xylene	80		70		30-150	B
Decachlorobiphenyl	105		95		30-150	B

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2341423

Report Date: 07/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits	Column
Organochlorine Pesticides by GC - Westborough Lab Associated sample(s): 01-06 Batch: WG1805342-2 WG1805342-3									
Delta-BHC	80		84		30-150	5		20	A
Lindane	79		83		30-150	5		20	A
Alpha-BHC	88		83		30-150	6		20	A
Beta-BHC	83		87		30-150	5		20	A
Heptachlor	81		85		30-150	5		20	A
Aldrin	76		80		30-150	6		20	A
Heptachlor epoxide	78		82		30-150	5		20	A
Endrin	78		85		30-150	9		20	A
Endrin aldehyde	76		82		30-150	8		20	A
Endrin ketone	89		96		30-150	7		20	A
Dieldrin	82		88		30-150	7		20	A
4,4'-DDE	77		85		30-150	9		20	A
4,4'-DDD	88		95		30-150	7		20	A
4,4'-DDT	89		99		30-150	10		20	A
Endosulfan I	101		83		30-150	19		20	A
Endosulfan II	80		87		30-150	8		20	A
Endosulfan sulfate	78		85		30-150	8		20	A
Methoxychlor	96		100		30-150	4		20	A
cis-Chlordane	68		74		30-150	8		20	A
trans-Chlordane	91		89		30-150	2		20	A

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2341423

Report Date: 07/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits

Organochlorine Pesticides by GC - Westborough Lab Associated sample(s): 01-06 Batch: WG1805342-2 WG1805342-3

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	73		77		30-150	A
Decachlorobiphenyl	91		96		30-150	A
2,4,5,6-Tetrachloro-m-xylene	75		75		30-150	B
Decachlorobiphenyl	102		92		30-150	B

METALS

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-01 Date Collected: 07/19/23 09:45

Client ID: GW-18 Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Water

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	16.3		mg/l	0.0100	0.00327	1	07/21/23 00:53	07/24/23 00:05	EPA 3005A	1,6020B	WKP
Antimony, Total	ND		mg/l	0.00400	0.00042	1	07/21/23 00:53	07/24/23 00:05	EPA 3005A	1,6020B	WKP
Arsenic, Total	0.00436		mg/l	0.00050	0.00016	1	07/21/23 00:53	07/24/23 00:05	EPA 3005A	1,6020B	WKP
Barium, Total	0.8590		mg/l	0.00050	0.00017	1	07/21/23 00:53	07/24/23 00:05	EPA 3005A	1,6020B	WKP
Beryllium, Total	0.00099		mg/l	0.00050	0.00010	1	07/21/23 00:53	07/24/23 00:05	EPA 3005A	1,6020B	WKP
Cadmium, Total	0.00205		mg/l	0.00020	0.00005	1	07/21/23 00:53	07/24/23 00:05	EPA 3005A	1,6020B	WKP
Calcium, Total	357.		mg/l	0.100	0.0394	1	07/21/23 00:53	07/24/23 00:05	EPA 3005A	1,6020B	WKP
Chromium, Total	0.04010		mg/l	0.00100	0.00017	1	07/21/23 00:53	07/24/23 00:05	EPA 3005A	1,6020B	WKP
Cobalt, Total	0.05261		mg/l	0.00050	0.00016	1	07/21/23 00:53	07/24/23 00:05	EPA 3005A	1,6020B	WKP
Copper, Total	0.07645		mg/l	0.00100	0.00038	1	07/21/23 00:53	07/24/23 00:05	EPA 3005A	1,6020B	WKP
Iron, Total	25.2		mg/l	0.0500	0.0191	1	07/21/23 00:53	07/24/23 00:05	EPA 3005A	1,6020B	WKP
Lead, Total	0.03032		mg/l	0.00100	0.00034	1	07/21/23 00:53	07/24/23 00:05	EPA 3005A	1,6020B	WKP
Magnesium, Total	108.		mg/l	0.0700	0.0242	1	07/21/23 00:53	07/24/23 00:05	EPA 3005A	1,6020B	WKP
Manganese, Total	3.830		mg/l	0.00100	0.00044	1	07/21/23 00:53	07/24/23 00:05	EPA 3005A	1,6020B	WKP
Mercury, Total	0.00023		mg/l	0.00020	0.00009	1	07/21/23 02:41	07/24/23 10:33	EPA 7470A	1,7470A	MJR
Nickel, Total	0.04247		mg/l	0.00200	0.00055	1	07/21/23 00:53	07/24/23 00:05	EPA 3005A	1,6020B	WKP
Potassium, Total	73.4		mg/l	0.100	0.0309	1	07/21/23 00:53	07/24/23 00:05	EPA 3005A	1,6020B	WKP
Selenium, Total	0.0255		mg/l	0.00500	0.00173	1	07/21/23 00:53	07/24/23 00:05	EPA 3005A	1,6020B	WKP
Silver, Total	0.00026	J	mg/l	0.00040	0.00016	1	07/21/23 00:53	07/24/23 00:05	EPA 3005A	1,6020B	WKP
Sodium, Total	862.		mg/l	1.00	0.293	10	07/21/23 00:53	07/24/23 07:13	EPA 3005A	1,6020B	EJF
Thallium, Total	0.00051	J	mg/l	0.00100	0.00014	1	07/21/23 00:53	07/24/23 00:05	EPA 3005A	1,6020B	WKP
Vanadium, Total	0.03229		mg/l	0.00500	0.00157	1	07/21/23 00:53	07/24/23 00:05	EPA 3005A	1,6020B	WKP
Zinc, Total	0.1089		mg/l	0.01000	0.00341	1	07/21/23 00:53	07/24/23 00:05	EPA 3005A	1,6020B	WKP

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-02 Date Collected: 07/19/23 08:30

Client ID: GW-19 Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Water

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	9.99		mg/l	0.0100	0.00327	1	07/21/23 00:53	07/24/23 00:09	EPA 3005A	1,6020B	WKP
Antimony, Total	ND		mg/l	0.00400	0.00042	1	07/21/23 00:53	07/24/23 00:09	EPA 3005A	1,6020B	WKP
Arsenic, Total	0.01620		mg/l	0.00050	0.00016	1	07/21/23 00:53	07/24/23 00:09	EPA 3005A	1,6020B	WKP
Barium, Total	2.396		mg/l	0.00050	0.00017	1	07/21/23 00:53	07/24/23 00:09	EPA 3005A	1,6020B	WKP
Beryllium, Total	0.00117		mg/l	0.00050	0.00010	1	07/21/23 00:53	07/24/23 00:09	EPA 3005A	1,6020B	WKP
Cadmium, Total	0.00165		mg/l	0.00020	0.00005	1	07/21/23 00:53	07/24/23 00:09	EPA 3005A	1,6020B	WKP
Calcium, Total	701.		mg/l	1.00	0.394	10	07/21/23 00:53	07/24/23 07:18	EPA 3005A	1,6020B	EJF
Chromium, Total	0.09515		mg/l	0.00100	0.00017	1	07/21/23 00:53	07/24/23 00:09	EPA 3005A	1,6020B	WKP
Cobalt, Total	0.04075		mg/l	0.00050	0.00016	1	07/21/23 00:53	07/24/23 00:09	EPA 3005A	1,6020B	WKP
Copper, Total	0.1336		mg/l	0.00100	0.00038	1	07/21/23 00:53	07/24/23 00:09	EPA 3005A	1,6020B	WKP
Iron, Total	71.0		mg/l	0.0500	0.0191	1	07/21/23 00:53	07/24/23 00:09	EPA 3005A	1,6020B	WKP
Lead, Total	0.07155		mg/l	0.00100	0.00034	1	07/21/23 00:53	07/24/23 00:09	EPA 3005A	1,6020B	WKP
Magnesium, Total	222.		mg/l	0.0700	0.0242	1	07/21/23 00:53	07/24/23 00:09	EPA 3005A	1,6020B	WKP
Manganese, Total	6.587		mg/l	0.00100	0.00044	1	07/21/23 00:53	07/24/23 00:09	EPA 3005A	1,6020B	WKP
Mercury, Total	0.00029		mg/l	0.00020	0.00009	1	07/21/23 02:41	07/24/23 10:36	EPA 7470A	1,7470A	MJR
Nickel, Total	0.05117		mg/l	0.00200	0.00055	1	07/21/23 00:53	07/24/23 00:09	EPA 3005A	1,6020B	WKP
Potassium, Total	45.1		mg/l	0.100	0.0309	1	07/21/23 00:53	07/24/23 00:09	EPA 3005A	1,6020B	WKP
Selenium, Total	0.00626		mg/l	0.00500	0.00173	1	07/21/23 00:53	07/24/23 00:09	EPA 3005A	1,6020B	WKP
Silver, Total	ND		mg/l	0.00040	0.00016	1	07/21/23 00:53	07/24/23 00:09	EPA 3005A	1,6020B	WKP
Sodium, Total	836.		mg/l	1.00	0.293	10	07/21/23 00:53	07/24/23 07:18	EPA 3005A	1,6020B	EJF
Thallium, Total	0.00023	J	mg/l	0.00100	0.00014	1	07/21/23 00:53	07/24/23 00:09	EPA 3005A	1,6020B	WKP
Vanadium, Total	0.04187		mg/l	0.00500	0.00157	1	07/21/23 00:53	07/24/23 00:09	EPA 3005A	1,6020B	WKP
Zinc, Total	0.07328		mg/l	0.01000	0.00341	1	07/21/23 00:53	07/24/23 00:09	EPA 3005A	1,6020B	WKP

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-03 Date Collected: 07/19/23 14:20

Client ID: GW-20 Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Water

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	15.9		mg/l	0.0100	0.00327	1	07/21/23 00:53	07/24/23 00:14	EPA 3005A	1,6020B	WKP
Antimony, Total	ND		mg/l	0.00400	0.00042	1	07/21/23 00:53	07/24/23 00:14	EPA 3005A	1,6020B	WKP
Arsenic, Total	0.00255		mg/l	0.00050	0.00016	1	07/21/23 00:53	07/24/23 00:14	EPA 3005A	1,6020B	WKP
Barium, Total	0.5748		mg/l	0.00050	0.00017	1	07/21/23 00:53	07/24/23 00:14	EPA 3005A	1,6020B	WKP
Beryllium, Total	0.00028	J	mg/l	0.00050	0.00010	1	07/21/23 00:53	07/24/23 00:14	EPA 3005A	1,6020B	WKP
Cadmium, Total	0.00022		mg/l	0.00020	0.00005	1	07/21/23 00:53	07/24/23 00:14	EPA 3005A	1,6020B	WKP
Calcium, Total	503.		mg/l	1.00	0.394	10	07/21/23 00:53	07/24/23 07:22	EPA 3005A	1,6020B	EJF
Chromium, Total	0.08921		mg/l	0.00100	0.00017	1	07/21/23 00:53	07/24/23 00:14	EPA 3005A	1,6020B	WKP
Cobalt, Total	0.06944		mg/l	0.00050	0.00016	1	07/21/23 00:53	07/24/23 00:14	EPA 3005A	1,6020B	WKP
Copper, Total	0.09520		mg/l	0.00100	0.00038	1	07/21/23 00:53	07/24/23 00:14	EPA 3005A	1,6020B	WKP
Iron, Total	31.5		mg/l	0.0500	0.0191	1	07/21/23 00:53	07/24/23 00:14	EPA 3005A	1,6020B	WKP
Lead, Total	0.00944		mg/l	0.00100	0.00034	1	07/21/23 00:53	07/24/23 00:14	EPA 3005A	1,6020B	WKP
Magnesium, Total	168.		mg/l	0.0700	0.0242	1	07/21/23 00:53	07/24/23 00:14	EPA 3005A	1,6020B	WKP
Manganese, Total	1.373		mg/l	0.00100	0.00044	1	07/21/23 00:53	07/24/23 00:14	EPA 3005A	1,6020B	WKP
Mercury, Total	ND		mg/l	0.00020	0.00009	1	07/21/23 02:41	07/24/23 11:02	EPA 7470A	1,7470A	MJR
Nickel, Total	0.04944		mg/l	0.00200	0.00055	1	07/21/23 00:53	07/24/23 00:14	EPA 3005A	1,6020B	WKP
Potassium, Total	27.5		mg/l	0.100	0.0309	1	07/21/23 00:53	07/24/23 00:14	EPA 3005A	1,6020B	WKP
Selenium, Total	0.00381	J	mg/l	0.00500	0.00173	1	07/21/23 00:53	07/24/23 00:14	EPA 3005A	1,6020B	WKP
Silver, Total	ND		mg/l	0.00040	0.00016	1	07/21/23 00:53	07/24/23 00:14	EPA 3005A	1,6020B	WKP
Sodium, Total	1020		mg/l	1.00	0.293	10	07/21/23 00:53	07/24/23 07:22	EPA 3005A	1,6020B	EJF
Thallium, Total	0.00026	J	mg/l	0.00100	0.00014	1	07/21/23 00:53	07/24/23 00:14	EPA 3005A	1,6020B	WKP
Vanadium, Total	0.05377		mg/l	0.00500	0.00157	1	07/21/23 00:53	07/24/23 00:14	EPA 3005A	1,6020B	WKP
Zinc, Total	0.07309		mg/l	0.01000	0.00341	1	07/21/23 00:53	07/24/23 00:14	EPA 3005A	1,6020B	WKP

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-04 Date Collected: 07/19/23 11:20

Client ID: GW-21 Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Water

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	21.6		mg/l	0.0100	0.00327	1	07/21/23 00:53	07/24/23 00:18	EPA 3005A	1,6020B	WKP
Antimony, Total	ND		mg/l	0.00400	0.00042	1	07/21/23 00:53	07/24/23 00:18	EPA 3005A	1,6020B	WKP
Arsenic, Total	0.00329		mg/l	0.00050	0.00016	1	07/21/23 00:53	07/24/23 00:18	EPA 3005A	1,6020B	WKP
Barium, Total	0.6216		mg/l	0.00050	0.00017	1	07/21/23 00:53	07/24/23 00:18	EPA 3005A	1,6020B	WKP
Beryllium, Total	0.00074		mg/l	0.00050	0.00010	1	07/21/23 00:53	07/24/23 00:18	EPA 3005A	1,6020B	WKP
Cadmium, Total	0.00046		mg/l	0.00020	0.00005	1	07/21/23 00:53	07/24/23 00:18	EPA 3005A	1,6020B	WKP
Calcium, Total	624.		mg/l	1.00	0.394	10	07/21/23 00:53	07/24/23 07:27	EPA 3005A	1,6020B	EJF
Chromium, Total	0.08388		mg/l	0.00100	0.00017	1	07/21/23 00:53	07/24/23 00:18	EPA 3005A	1,6020B	WKP
Cobalt, Total	0.09047		mg/l	0.00050	0.00016	1	07/21/23 00:53	07/24/23 00:18	EPA 3005A	1,6020B	WKP
Copper, Total	0.09822		mg/l	0.00100	0.00038	1	07/21/23 00:53	07/24/23 00:18	EPA 3005A	1,6020B	WKP
Iron, Total	36.6		mg/l	0.0500	0.0191	1	07/21/23 00:53	07/24/23 00:18	EPA 3005A	1,6020B	WKP
Lead, Total	0.02742		mg/l	0.00100	0.00034	1	07/21/23 00:53	07/24/23 00:18	EPA 3005A	1,6020B	WKP
Magnesium, Total	210.		mg/l	0.0700	0.0242	1	07/21/23 00:53	07/24/23 00:18	EPA 3005A	1,6020B	WKP
Manganese, Total	3.057		mg/l	0.00100	0.00044	1	07/21/23 00:53	07/24/23 00:18	EPA 3005A	1,6020B	WKP
Mercury, Total	0.00009	J	mg/l	0.00020	0.00009	1	07/21/23 02:41	07/24/23 11:06	EPA 7470A	1,7470A	MJR
Nickel, Total	0.07163		mg/l	0.00200	0.00055	1	07/21/23 00:53	07/24/23 00:18	EPA 3005A	1,6020B	WKP
Potassium, Total	34.1		mg/l	0.100	0.0309	1	07/21/23 00:53	07/24/23 00:18	EPA 3005A	1,6020B	WKP
Selenium, Total	0.00577		mg/l	0.00500	0.00173	1	07/21/23 00:53	07/24/23 00:18	EPA 3005A	1,6020B	WKP
Silver, Total	0.00018	J	mg/l	0.00040	0.00016	1	07/21/23 00:53	07/24/23 00:18	EPA 3005A	1,6020B	WKP
Sodium, Total	1940		mg/l	1.00	0.293	10	07/21/23 00:53	07/24/23 07:27	EPA 3005A	1,6020B	EJF
Thallium, Total	0.00045	J	mg/l	0.00100	0.00014	1	07/21/23 00:53	07/24/23 00:18	EPA 3005A	1,6020B	WKP
Vanadium, Total	0.06111		mg/l	0.00500	0.00157	1	07/21/23 00:53	07/24/23 00:18	EPA 3005A	1,6020B	WKP
Zinc, Total	0.1406		mg/l	0.01000	0.00341	1	07/21/23 00:53	07/24/23 00:18	EPA 3005A	1,6020B	WKP

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-05 Date Collected: 07/19/23 11:45

Client ID: GW-22 Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Water

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	8.88		mg/l	0.0100	0.00327	1	07/21/23 00:53	07/24/23 00:23	EPA 3005A	1,6020B	WKP
Antimony, Total	ND		mg/l	0.00400	0.00042	1	07/21/23 00:53	07/24/23 00:23	EPA 3005A	1,6020B	WKP
Arsenic, Total	0.00151		mg/l	0.00050	0.00016	1	07/21/23 00:53	07/24/23 00:23	EPA 3005A	1,6020B	WKP
Barium, Total	0.3338		mg/l	0.00050	0.00017	1	07/21/23 00:53	07/24/23 00:23	EPA 3005A	1,6020B	WKP
Beryllium, Total	0.00022	J	mg/l	0.00050	0.00010	1	07/21/23 00:53	07/24/23 00:23	EPA 3005A	1,6020B	WKP
Cadmium, Total	0.00016	J	mg/l	0.00020	0.00005	1	07/21/23 00:53	07/24/23 00:23	EPA 3005A	1,6020B	WKP
Calcium, Total	193.		mg/l	0.100	0.0394	1	07/21/23 00:53	07/24/23 00:23	EPA 3005A	1,6020B	WKP
Chromium, Total	0.05283		mg/l	0.00100	0.00017	1	07/21/23 00:53	07/24/23 00:23	EPA 3005A	1,6020B	WKP
Cobalt, Total	0.04890		mg/l	0.00050	0.00016	1	07/21/23 00:53	07/24/23 00:23	EPA 3005A	1,6020B	WKP
Copper, Total	0.05240		mg/l	0.00100	0.00038	1	07/21/23 00:53	07/24/23 00:23	EPA 3005A	1,6020B	WKP
Iron, Total	18.9		mg/l	0.0500	0.0191	1	07/21/23 00:53	07/24/23 00:23	EPA 3005A	1,6020B	WKP
Lead, Total	0.00901		mg/l	0.00100	0.00034	1	07/21/23 00:53	07/24/23 00:23	EPA 3005A	1,6020B	WKP
Magnesium, Total	67.2		mg/l	0.0700	0.0242	1	07/21/23 00:53	07/24/23 00:23	EPA 3005A	1,6020B	WKP
Manganese, Total	1.226		mg/l	0.00100	0.00044	1	07/21/23 00:53	07/24/23 00:23	EPA 3005A	1,6020B	WKP
Mercury, Total	ND		mg/l	0.00020	0.00009	1	07/21/23 02:41	07/24/23 11:09	EPA 7470A	1,7470A	MJR
Nickel, Total	0.03772		mg/l	0.00200	0.00055	1	07/21/23 00:53	07/24/23 00:23	EPA 3005A	1,6020B	WKP
Potassium, Total	21.8		mg/l	0.100	0.0309	1	07/21/23 00:53	07/24/23 00:23	EPA 3005A	1,6020B	WKP
Selenium, Total	0.00254	J	mg/l	0.00500	0.00173	1	07/21/23 00:53	07/24/23 00:23	EPA 3005A	1,6020B	WKP
Silver, Total	ND		mg/l	0.00040	0.00016	1	07/21/23 00:53	07/24/23 00:23	EPA 3005A	1,6020B	WKP
Sodium, Total	2060		mg/l	1.00	0.293	10	07/21/23 00:53	07/24/23 07:31	EPA 3005A	1,6020B	EJF
Thallium, Total	0.00022	J	mg/l	0.00100	0.00014	1	07/21/23 00:53	07/24/23 00:23	EPA 3005A	1,6020B	WKP
Vanadium, Total	0.02222		mg/l	0.00500	0.00157	1	07/21/23 00:53	07/24/23 00:23	EPA 3005A	1,6020B	WKP
Zinc, Total	0.03732		mg/l	0.01000	0.00341	1	07/21/23 00:53	07/24/23 00:23	EPA 3005A	1,6020B	WKP

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-06 Date Collected: 07/19/23 13:50

Client ID: GW-23 Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Water

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	10.8		mg/l	0.0100	0.00327	1	07/21/23 00:53	07/24/23 00:27	EPA 3005A	1,6020B	WKP
Antimony, Total	ND		mg/l	0.00400	0.00042	1	07/21/23 00:53	07/24/23 00:27	EPA 3005A	1,6020B	WKP
Arsenic, Total	0.00344		mg/l	0.00050	0.00016	1	07/21/23 00:53	07/24/23 00:27	EPA 3005A	1,6020B	WKP
Barium, Total	0.3714		mg/l	0.00050	0.00017	1	07/21/23 00:53	07/24/23 00:27	EPA 3005A	1,6020B	WKP
Beryllium, Total	0.00027	J	mg/l	0.00050	0.00010	1	07/21/23 00:53	07/24/23 00:27	EPA 3005A	1,6020B	WKP
Cadmium, Total	0.00021		mg/l	0.00020	0.00005	1	07/21/23 00:53	07/24/23 00:27	EPA 3005A	1,6020B	WKP
Calcium, Total	655.		mg/l	1.00	0.394	10	07/21/23 00:53	07/24/23 07:36	EPA 3005A	1,6020B	EJF
Chromium, Total	0.07286		mg/l	0.00100	0.00017	1	07/21/23 00:53	07/24/23 00:27	EPA 3005A	1,6020B	WKP
Cobalt, Total	0.02742		mg/l	0.00050	0.00016	1	07/21/23 00:53	07/24/23 00:27	EPA 3005A	1,6020B	WKP
Copper, Total	0.02566		mg/l	0.00100	0.00038	1	07/21/23 00:53	07/24/23 00:27	EPA 3005A	1,6020B	WKP
Iron, Total	16.7		mg/l	0.0500	0.0191	1	07/21/23 00:53	07/24/23 00:27	EPA 3005A	1,6020B	WKP
Lead, Total	0.00833		mg/l	0.00100	0.00034	1	07/21/23 00:53	07/24/23 00:27	EPA 3005A	1,6020B	WKP
Magnesium, Total	91.9		mg/l	0.0700	0.0242	1	07/21/23 00:53	07/24/23 00:27	EPA 3005A	1,6020B	WKP
Manganese, Total	0.6761		mg/l	0.00100	0.00044	1	07/21/23 00:53	07/24/23 00:27	EPA 3005A	1,6020B	WKP
Mercury, Total	ND		mg/l	0.00020	0.00009	1	07/21/23 02:41	07/24/23 11:12	EPA 7470A	1,7470A	MJR
Nickel, Total	0.02757		mg/l	0.00200	0.00055	1	07/21/23 00:53	07/24/23 00:27	EPA 3005A	1,6020B	WKP
Potassium, Total	50.3		mg/l	0.100	0.0309	1	07/21/23 00:53	07/24/23 00:27	EPA 3005A	1,6020B	WKP
Selenium, Total	0.00336	J	mg/l	0.00500	0.00173	1	07/21/23 00:53	07/24/23 00:27	EPA 3005A	1,6020B	WKP
Silver, Total	ND		mg/l	0.00040	0.00016	1	07/21/23 00:53	07/24/23 00:27	EPA 3005A	1,6020B	WKP
Sodium, Total	2320		mg/l	1.00	0.293	10	07/21/23 00:53	07/24/23 07:36	EPA 3005A	1,6020B	EJF
Thallium, Total	ND		mg/l	0.00100	0.00014	1	07/21/23 00:53	07/24/23 00:27	EPA 3005A	1,6020B	WKP
Vanadium, Total	0.03086		mg/l	0.00500	0.00157	1	07/21/23 00:53	07/24/23 00:27	EPA 3005A	1,6020B	WKP
Zinc, Total	0.07890		mg/l	0.01000	0.00341	1	07/21/23 00:53	07/24/23 00:27	EPA 3005A	1,6020B	WKP

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-07 Date Collected: 07/19/23 15:00

Client ID: SB-51P (3.5-4) Date Received: 07/19/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Soil

Percent Solids: 93%

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	5530		mg/kg	8.34	2.25	2	07/21/23 06:20	07/21/23 15:35	EPA 3050B	1,6010D	DMB
Antimony, Total	0.689	J	mg/kg	4.17	0.317	2	07/21/23 06:20	07/21/23 15:35	EPA 3050B	1,6010D	DMB
Arsenic, Total	0.685	J	mg/kg	0.834	0.174	2	07/21/23 06:20	07/21/23 15:35	EPA 3050B	1,6010D	DMB
Barium, Total	70.3		mg/kg	0.834	0.145	2	07/21/23 06:20	07/21/23 15:35	EPA 3050B	1,6010D	DMB
Beryllium, Total	1.23		mg/kg	0.417	0.028	2	07/21/23 06:20	07/21/23 15:35	EPA 3050B	1,6010D	DMB
Cadmium, Total	0.214	J	mg/kg	0.834	0.082	2	07/21/23 06:20	07/21/23 15:35	EPA 3050B	1,6010D	DMB
Calcium, Total	2090		mg/kg	8.34	2.92	2	07/21/23 06:20	07/21/23 15:35	EPA 3050B	1,6010D	DMB
Chromium, Total	15.6		mg/kg	0.834	0.080	2	07/21/23 06:20	07/21/23 15:35	EPA 3050B	1,6010D	DMB
Cobalt, Total	5.40		mg/kg	1.67	0.138	2	07/21/23 06:20	07/21/23 15:35	EPA 3050B	1,6010D	DMB
Copper, Total	19.7		mg/kg	0.834	0.215	2	07/21/23 06:20	07/21/23 15:35	EPA 3050B	1,6010D	DMB
Iron, Total	12200		mg/kg	4.17	0.754	2	07/21/23 06:20	07/21/23 15:35	EPA 3050B	1,6010D	DMB
Lead, Total	2.75	J	mg/kg	4.17	0.224	2	07/21/23 06:20	07/21/23 15:35	EPA 3050B	1,6010D	DMB
Magnesium, Total	3370		mg/kg	8.34	1.28	2	07/21/23 06:20	07/21/23 15:35	EPA 3050B	1,6010D	DMB
Manganese, Total	125		mg/kg	0.834	0.133	2	07/21/23 06:20	07/21/23 15:35	EPA 3050B	1,6010D	DMB
Mercury, Total	ND		mg/kg	0.070	0.045	1	07/21/23 11:10	07/21/23 13:52	EPA 7471B	1,7471B	GMG
Nickel, Total	11.0		mg/kg	2.09	0.202	2	07/21/23 06:20	07/21/23 15:35	EPA 3050B	1,6010D	DMB
Potassium, Total	2140		mg/kg	209	12.0	2	07/21/23 06:20	07/21/23 15:35	EPA 3050B	1,6010D	DMB
Selenium, Total	ND		mg/kg	1.67	0.215	2	07/21/23 06:20	07/21/23 15:35	EPA 3050B	1,6010D	DMB
Silver, Total	ND		mg/kg	0.417	0.236	2	07/21/23 06:20	07/21/23 15:35	EPA 3050B	1,6010D	DMB
Sodium, Total	189		mg/kg	167	2.63	2	07/21/23 06:20	07/21/23 15:35	EPA 3050B	1,6010D	DMB
Thallium, Total	ND		mg/kg	1.67	0.263	2	07/21/23 06:20	07/21/23 15:35	EPA 3050B	1,6010D	DMB
Vanadium, Total	19.3		mg/kg	0.834	0.169	2	07/21/23 06:20	07/21/23 15:35	EPA 3050B	1,6010D	DMB
Zinc, Total	23.4		mg/kg	4.17	0.244	2	07/21/23 06:20	07/21/23 15:35	EPA 3050B	1,6010D	DMB

Project Name: 100 MAIN ST. **Lab Number:** L2341423

Project Number: 12461 **Report Date:** 07/24/23

Method Blank Analysis
Batch Quality Control

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
Total Metals - Mansfield Lab for sample(s): 07 Batch: WG1805519-1										
Aluminum, Total	ND		mg/kg	4.00	1.08	1	07/21/23 06:20	07/21/23 15:13	1,6010D	DMB
Antimony, Total	ND		mg/kg	2.00	0.152	1	07/21/23 06:20	07/21/23 15:13	1,6010D	DMB
Arsenic, Total	ND		mg/kg	0.400	0.083	1	07/21/23 06:20	07/21/23 15:13	1,6010D	DMB
Barium, Total	ND		mg/kg	0.400	0.070	1	07/21/23 06:20	07/21/23 15:13	1,6010D	DMB
Beryllium, Total	ND		mg/kg	0.200	0.013	1	07/21/23 06:20	07/21/23 15:13	1,6010D	DMB
Cadmium, Total	ND		mg/kg	0.400	0.039	1	07/21/23 06:20	07/21/23 15:13	1,6010D	DMB
Calcium, Total	ND		mg/kg	4.00	1.40	1	07/21/23 06:20	07/21/23 15:13	1,6010D	DMB
Chromium, Total	ND		mg/kg	0.400	0.038	1	07/21/23 06:20	07/21/23 15:13	1,6010D	DMB
Cobalt, Total	ND		mg/kg	0.800	0.066	1	07/21/23 06:20	07/21/23 15:13	1,6010D	DMB
Copper, Total	ND		mg/kg	0.400	0.103	1	07/21/23 06:20	07/21/23 15:13	1,6010D	DMB
Iron, Total	ND		mg/kg	2.00	0.361	1	07/21/23 06:20	07/21/23 15:13	1,6010D	DMB
Lead, Total	ND		mg/kg	2.00	0.107	1	07/21/23 06:20	07/21/23 15:13	1,6010D	DMB
Magnesium, Total	ND		mg/kg	4.00	0.616	1	07/21/23 06:20	07/21/23 15:13	1,6010D	DMB
Manganese, Total	ND		mg/kg	0.400	0.064	1	07/21/23 06:20	07/21/23 15:13	1,6010D	DMB
Nickel, Total	ND		mg/kg	1.00	0.097	1	07/21/23 06:20	07/21/23 15:13	1,6010D	DMB
Potassium, Total	ND		mg/kg	100	5.76	1	07/21/23 06:20	07/21/23 15:13	1,6010D	DMB
Selenium, Total	ND		mg/kg	0.800	0.103	1	07/21/23 06:20	07/21/23 15:13	1,6010D	DMB
Silver, Total	ND		mg/kg	0.200	0.113	1	07/21/23 06:20	07/21/23 15:13	1,6010D	DMB
Sodium, Total	3.85	J	mg/kg	80.0	1.26	1	07/21/23 06:20	07/21/23 15:13	1,6010D	DMB
Thallium, Total	ND		mg/kg	0.800	0.126	1	07/21/23 06:20	07/21/23 15:13	1,6010D	DMB
Vanadium, Total	ND		mg/kg	0.400	0.081	1	07/21/23 06:20	07/21/23 15:13	1,6010D	DMB
Zinc, Total	ND		mg/kg	2.00	0.117	1	07/21/23 06:20	07/21/23 15:13	1,6010D	DMB

Prep Information

Digestion Method: EPA 3050B

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
Total Metals - Mansfield Lab for sample(s): 07 Batch: WG1805520-1										
Mercury, Total	ND		mg/kg	0.083	0.054	1	07/21/23 11:10	07/21/23 13:45	1,7471B	GMG

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

Method Blank Analysis
Batch Quality Control

Prep Information

Digestion Method: EPA 7471B

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
Total Metals - Mansfield Lab for sample(s): 01-06 Batch: WG1805552-1										
Aluminum, Total	ND		mg/l	0.0100	0.00327	1	07/21/23 00:53	07/23/23 22:57	1,6020B	WKP
Antimony, Total	ND		mg/l	0.00400	0.00042	1	07/21/23 00:53	07/23/23 22:57	1,6020B	WKP
Arsenic, Total	ND		mg/l	0.00050	0.00016	1	07/21/23 00:53	07/23/23 22:57	1,6020B	WKP
Barium, Total	ND		mg/l	0.00050	0.00017	1	07/21/23 00:53	07/23/23 22:57	1,6020B	WKP
Beryllium, Total	ND		mg/l	0.00050	0.00010	1	07/21/23 00:53	07/23/23 22:57	1,6020B	WKP
Cadmium, Total	ND		mg/l	0.00020	0.00005	1	07/21/23 00:53	07/23/23 22:57	1,6020B	WKP
Calcium, Total	ND		mg/l	0.100	0.0394	1	07/21/23 00:53	07/23/23 22:57	1,6020B	WKP
Chromium, Total	ND		mg/l	0.00100	0.00017	1	07/21/23 00:53	07/23/23 22:57	1,6020B	WKP
Cobalt, Total	ND		mg/l	0.00050	0.00016	1	07/21/23 00:53	07/23/23 22:57	1,6020B	WKP
Copper, Total	ND		mg/l	0.00100	0.00038	1	07/21/23 00:53	07/23/23 22:57	1,6020B	WKP
Iron, Total	ND		mg/l	0.0500	0.0191	1	07/21/23 00:53	07/23/23 22:57	1,6020B	WKP
Lead, Total	ND		mg/l	0.00100	0.00034	1	07/21/23 00:53	07/23/23 22:57	1,6020B	WKP
Magnesium, Total	ND		mg/l	0.0700	0.0242	1	07/21/23 00:53	07/23/23 22:57	1,6020B	WKP
Manganese, Total	ND		mg/l	0.00100	0.00044	1	07/21/23 00:53	07/23/23 22:57	1,6020B	WKP
Nickel, Total	ND		mg/l	0.00200	0.00055	1	07/21/23 00:53	07/23/23 22:57	1,6020B	WKP
Potassium, Total	ND		mg/l	0.100	0.0309	1	07/21/23 00:53	07/23/23 22:57	1,6020B	WKP
Selenium, Total	ND		mg/l	0.00500	0.00173	1	07/21/23 00:53	07/23/23 22:57	1,6020B	WKP
Silver, Total	ND		mg/l	0.00040	0.00016	1	07/21/23 00:53	07/23/23 22:57	1,6020B	WKP
Sodium, Total	ND		mg/l	0.100	0.0293	1	07/21/23 00:53	07/23/23 22:57	1,6020B	WKP
Thallium, Total	ND		mg/l	0.00100	0.00014	1	07/21/23 00:53	07/23/23 22:57	1,6020B	WKP
Vanadium, Total	ND		mg/l	0.00500	0.00157	1	07/21/23 00:53	07/23/23 22:57	1,6020B	WKP
Zinc, Total	ND		mg/l	0.01000	0.00341	1	07/21/23 00:53	07/23/23 22:57	1,6020B	WKP

Prep Information

Digestion Method: EPA 3005A

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

Method Blank Analysis
Batch Quality Control

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
Total Metals - Mansfield Lab for sample(s): 01-06 Batch: WG1805553-1										
Mercury, Total	0.00012	J	mg/l	0.00020	0.00009	1	07/21/23 02:41	07/24/23 10:16	1,7470A	MJR

Prep Information

Digestion Method: EPA 7470A

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2341423

Report Date: 07/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 07 Batch: WG1805519-2 SRM Lot Number: D119-540								
Aluminum, Total	69		-		48-152	-		
Antimony, Total	146		-		10-190	-		
Arsenic, Total	98		-		83-117	-		
Barium, Total	95		-		82-118	-		
Beryllium, Total	97		-		83-117	-		
Cadmium, Total	95		-		82-117	-		
Calcium, Total	92		-		81-118	-		
Chromium, Total	98		-		82-119	-		
Cobalt, Total	99		-		83-117	-		
Copper, Total	97		-		84-116	-		
Iron, Total	88		-		60-140	-		
Lead, Total	99		-		82-118	-		
Magnesium, Total	86		-		76-124	-		
Manganese, Total	94		-		82-118	-		
Nickel, Total	99		-		82-117	-		
Potassium, Total	84		-		70-130	-		
Selenium, Total	101		-		79-121	-		
Silver, Total	100		-		80-120	-		
Sodium, Total	99		-		74-126	-		
Thallium, Total	100		-		81-119	-		
Vanadium, Total	96		-		79-121	-		

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2341423

Report Date: 07/24/23

Parameter	LCS %Recovery	LCSD %Recovery	%Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 07 Batch: WG1805519-2 SRM Lot Number: D119-540					
Zinc, Total	95	-	80-120	-	
Total Metals - Mansfield Lab Associated sample(s): 07 Batch: WG1805520-2 SRM Lot Number: D119-540					
Mercury, Total	89	-	73-127	-	

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2341423

Report Date: 07/24/23

Parameter	LCS %Recovery	LCSD %Recovery	%Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-06 Batch: WG1805552-2					
Aluminum, Total	104	-	80-120	-	
Antimony, Total	101	-	80-120	-	
Arsenic, Total	104	-	80-120	-	
Barium, Total	103	-	80-120	-	
Beryllium, Total	105	-	80-120	-	
Cadmium, Total	107	-	80-120	-	
Calcium, Total	87	-	80-120	-	
Chromium, Total	101	-	80-120	-	
Cobalt, Total	100	-	80-120	-	
Copper, Total	103	-	80-120	-	
Iron, Total	106	-	80-120	-	
Lead, Total	105	-	80-120	-	
Magnesium, Total	103	-	80-120	-	
Manganese, Total	104	-	80-120	-	
Nickel, Total	102	-	80-120	-	
Potassium, Total	104	-	80-120	-	
Selenium, Total	98	-	80-120	-	
Silver, Total	108	-	80-120	-	
Sodium, Total	103	-	80-120	-	
Thallium, Total	102	-	80-120	-	
Vanadium, Total	98	-	80-120	-	

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2341423

Report Date: 07/24/23

Parameter	LCS %Recovery	LCSD %Recovery	%Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-06 Batch: WG1805552-2					
Zinc, Total	101	-	80-120	-	
Total Metals - Mansfield Lab Associated sample(s): 01-06 Batch: WG1805553-2					
Mercury, Total	111	-	80-120	-	

Matrix Spike Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341423
Report Date: 07/24/23

Parameter	Native Sample	MS Added	MS Found	MS %Recovery	Qual	MSD Found	MSD %Recovery	Qual	Recovery Limits	RPD	Qual	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 07 QC Batch ID: WG1805519-3 QC Sample: L2341423-07 Client ID: SB-51P (3.5-4)												
Aluminum, Total	5530	165	5970	**266**	Q	-	-		75-125	-		20
Antimony, Total	0.689J	41.3	34.2	83		-	-		75-125	-		20
Arsenic, Total	0.685J	9.9	10.4	105		-	-		75-125	-		20
Barium, Total	70.3	165	232	98		-	-		75-125	-		20
Beryllium, Total	1.23	4.13	5.26	98		-	-		75-125	-		20
Cadmium, Total	0.214J	4.38	4.26	97		-	-		75-125	-		20
Calcium, Total	2090	825	2800	86		-	-		75-125	-		20
Chromium, Total	15.6	16.5	30.7	91		-	-		75-125	-		20
Cobalt, Total	5.40	41.3	43.1	91		-	-		75-125	-		20
Copper, Total	19.7	20.6	38.4	91		-	-		75-125	-		20
Iron, Total	12200	82.5	12300	121		-	-		75-125	-		20
Lead, Total	2.75J	43.8	42.5	97		-	-		75-125	-		20
Magnesium, Total	3370	825	4210	102		-	-		75-125	-		20
Manganese, Total	125	41.3	177	**126**	Q	-	-		75-125	-		20
Nickel, Total	11.0	41.3	47.5	88		-	-		75-125	-		20
Potassium, Total	2140	825	3090	115		-	-		75-125	-		20
Selenium, Total	ND	9.9	8.98	91		-	-		75-125	-		20
Silver, Total	ND	4.13	3.82	92		-	-		75-125	-		20
Sodium, Total	189	825	978	96		-	-		75-125	-		20
Thallium, Total	ND	9.9	9.12	92		-	-		75-125	-		20
Vanadium, Total	19.3	41.3	57.4	92		-	-		75-125	-		20

Matrix Spike Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341423
Report Date: 07/24/23

Parameter	Native Sample	MS Added	MS Found	MS %Recovery	MSD Found	MSD %Recovery	Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 07 QC Batch ID: WG1805519-3 QC Sample: L2341423-07 Client ID: SB-51P (3.5-4)									
Zinc, Total	23.4	41.3	59.6	88	-	-	75-125	-	20
Total Metals - Mansfield Lab Associated sample(s): 07 QC Batch ID: WG1805520-3 QC Sample: L2341423-07 Client ID: SB-51P (3.5-4)									
Mercury, Total	ND	1.37	1.41	103	-	-	80-120	-	20

Matrix Spike Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341423
Report Date: 07/24/23

Parameter	Native Sample	MS Added	MS Found	MS %Recovery		MSD Found	MSD %Recovery	Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-06 QC Batch ID: WG1805552-3 QC Sample: L2341423-01 Client ID: GW-18										
Aluminum, Total	16.3	2	18.6	115		-	-	75-125	-	20
Antimony, Total	ND	0.5	0.4947	99		-	-	75-125	-	20
Arsenic, Total	0.00436	0.12	0.1313	106		-	-	75-125	-	20
Barium, Total	0.8590	2	2.980	106		-	-	75-125	-	20
Beryllium, Total	0.00099	0.05	0.05091	100		-	-	75-125	-	20
Cadmium, Total	0.00205	0.053	0.05600	102		-	-	75-125	-	20
Calcium, Total	357.	10	376	**190**	Q	-	-	75-125	-	20
Chromium, Total	0.04010	0.2	0.2417	101		-	-	75-125	-	20
Cobalt, Total	0.05261	0.5	0.5582	101		-	-	75-125	-	20
Copper, Total	0.07645	0.25	0.3337	103		-	-	75-125	-	20
Iron, Total	25.2	1	25.4	**20**	Q	-	-	75-125	-	20
Lead, Total	0.03032	0.53	0.6045	108		-	-	75-125	-	20
Magnesium, Total	108.	10	113	**50**	Q	-	-	75-125	-	20
Manganese, Total	3.830	0.5	3.970	**28**	Q	-	-	75-125	-	20
Nickel, Total	0.04247	0.5	0.5444	100		-	-	75-125	-	20
Potassium, Total	73.4	10	78.5	**51**	Q	-	-	75-125	-	20
Selenium, Total	0.0255	0.12	0.141	96		-	-	75-125	-	20
Silver, Total	0.00026J	0.05	0.05263	105		-	-	75-125	-	20
Sodium, Total	862.	10	868	**60**	Q	-	-	75-125	-	20
Thallium, Total	0.00051J	0.12	0.1240	103		-	-	75-125	-	20
Vanadium, Total	0.03229	0.5	0.5469	103		-	-	75-125	-	20

Matrix Spike Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341423
Report Date: 07/24/23

Parameter	Native Sample	MS Added	MS Found	MS %Recovery	MSD Found	MSD %Recovery	Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-06 QC Batch ID: WG1805552-3 QC Sample: L2341423-01 Client ID: GW-18									
Zinc, Total	0.1089	0.5	0.6017	98	-	-	75-125	-	20
Total Metals - Mansfield Lab Associated sample(s): 01-06 QC Batch ID: WG1805553-3 WG1805553-4 QC Sample: L2341367-03 Client ID: MS Sample									
Mercury, Total	0.00013J	0.005	0.00493	99	0.00490	98	75-125	1	20

Lab Duplicate Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341423
Report Date: 07/24/23

Parameter	Native Sample	Duplicate Sample	Units	RPD	Qual	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 07 QC Batch ID: WG1805519-4 QC Sample: L2341423-07 Client ID: SB-51P (3.5-4)						
Aluminum, Total	5530	5570	mg/kg	1		20
Antimony, Total	0.689J	0.773J	mg/kg	NC		20
Arsenic, Total	0.685J	2.91	mg/kg	NC		20
Barium, Total	70.3	93.6	mg/kg	**28**	Q	20
Beryllium, Total	1.23	1.24	mg/kg	1		20
Cadmium, Total	0.214J	0.230J	mg/kg	NC		20
Calcium, Total	2090	2450	mg/kg	16		20
Chromium, Total	15.6	16.4	mg/kg	5		20
Cobalt, Total	5.40	5.34	mg/kg	1		20
Copper, Total	19.7	20.2	mg/kg	3		20
Iron, Total	12200	12800	mg/kg	5		20
Lead, Total	2.75J	3.44J	mg/kg	NC		20
Magnesium, Total	3370	3430	mg/kg	2		20
Manganese, Total	125	129	mg/kg	3		20
Nickel, Total	11.0	11.1	mg/kg	1		20
Potassium, Total	2140	2230	mg/kg	4		20
Selenium, Total	ND	ND	mg/kg	NC		20
Silver, Total	ND	ND	mg/kg	NC		20
Sodium, Total	189	197	mg/kg	4		20

Lab Duplicate Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2341423

Report Date: 07/24/23

Parameter	Native Sample	Duplicate Sample	Units	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 07 QC Batch ID: WG1805519-4 QC Sample: L2341423-07 Client ID: SB-51P (3.5-4)					
Thallium, Total	ND	ND	mg/kg	NC	20
Vanadium, Total	19.3	20.6	mg/kg	7	20
Zinc, Total	23.4	24.1	mg/kg	3	20
Total Metals - Mansfield Lab Associated sample(s): 07 QC Batch ID: WG1805520-4 QC Sample: L2341423-07 Client ID: SB-51P (3.5-4)					
Mercury, Total	ND	ND	mg/kg	NC	20

Lab Duplicate Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2341423

Report Date: 07/24/23

Parameter	Native Sample	Duplicate Sample	Units	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-06 QC Batch ID: WG1805552-4 QC Sample: L2341423-01 Client ID: GW-18					
Aluminum, Total	16.3	16.6	mg/l	2	20
Antimony, Total	ND	ND	mg/l	NC	20
Arsenic, Total	0.00436	0.00446	mg/l	2	20
Barium, Total	0.8590	0.8994	mg/l	5	20
Beryllium, Total	0.00099	0.00105	mg/l	5	20
Cadmium, Total	0.00205	0.00206	mg/l	1	20
Calcium, Total	357.	337	mg/l	6	20
Chromium, Total	0.04010	0.03982	mg/l	1	20
Cobalt, Total	0.05261	0.05158	mg/l	2	20
Copper, Total	0.07645	0.07934	mg/l	4	20
Iron, Total	25.2	27.1	mg/l	7	20
Lead, Total	0.03032	0.03244	mg/l	7	20
Magnesium, Total	108.	105	mg/l	3	20
Manganese, Total	3.830	3.677	mg/l	4	20
Nickel, Total	0.04247	0.04358	mg/l	3	20
Potassium, Total	73.4	72.3	mg/l	2	20
Selenium, Total	0.0255	0.0251	mg/l	2	20
Silver, Total	0.00026J	0.00028J	mg/l	NC	20
Thallium, Total	0.00051J	0.00079J	mg/l	NC	20

Lab Duplicate Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2341423

Report Date: 07/24/23

Parameter	Native Sample	Duplicate Sample	Units	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01-06 QC Batch ID: WG1805552-4 QC Sample: L2341423-01 Client ID: GW-18					
Vanadium, Total	0.03229	0.03286	mg/l	2	20
Zinc, Total	0.1089	0.1112	mg/l	2	20
Total Metals - Mansfield Lab Associated sample(s): 01-06 QC Batch ID: WG1805552-4 QC Sample: L2341423-01 Client ID: GW-18					
Sodium, Total	862.	862	mg/l	0	20

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Serial Dilution Analysis
Batch Quality Control

Lab Number: L2341423
Report Date: 07/24/23

Parameter	Native Sample	Serial Dilution	Units	% D	Qual	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 07 QC Batch ID: WG1805519-6 QC Sample: L2341423-07 Client ID: SB-51P (3.5-4)						
Manganese, Total	125	117	mg/kg	6		20

INORGANICS
&
MISCELLANEOUS

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341423
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-01
Client ID: GW-18
Sample Location: WHITE PLAINS, NY

Date Collected: 07/19/23 09:45
Date Received: 07/19/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Cyanide, Total	0.002	J	mg/l	0.005	0.001	1	07/20/23 14:55	07/20/23 18:14	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341423
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-02
Client ID: GW-19
Sample Location: WHITE PLAINS, NY

Date Collected: 07/19/23 08:30
Date Received: 07/19/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Cyanide, Total	ND		mg/l	0.005	0.001	1	07/20/23 14:55	07/20/23 18:15	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341423
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-03
Client ID: GW-20
Sample Location: WHITE PLAINS, NY

Date Collected: 07/19/23 14:20
Date Received: 07/19/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Cyanide, Total	0.003	J	mg/l	0.005	0.001	1	07/20/23 14:55	07/20/23 18:16	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341423
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-04
Client ID: GW-21
Sample Location: WHITE PLAINS, NY

Sample Depth:
Matrix: Water

Date Collected: 07/19/23 11:20
Date Received: 07/19/23
Field Prep: Not Specified

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Cyanide, Total	0.004	J	mg/l	0.005	0.001	1	07/20/23 14:55	07/20/23 18:17	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341423
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-05
Client ID: GW-22
Sample Location: WHITE PLAINS, NY

Date Collected: 07/19/23 11:45
Date Received: 07/19/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Cyanide, Total	0.019		mg/l	0.005	0.001	1	07/20/23 14:55	07/20/23 18:18	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341423
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-06
Client ID: GW-23
Sample Location: WHITE PLAINS, NY

Date Collected: 07/19/23 13:50
Date Received: 07/19/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Cyanide, Total	0.003	J	mg/l	0.005	0.001	1	07/20/23 14:55	07/20/23 18:19	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341423
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341423-07
Client ID: SB-51P (3.5-4)
Sample Location: WHITE PLAINS, NY

Date Collected: 07/19/23 15:00
Date Received: 07/19/23
Field Prep: Not Specified

Sample Depth:
Matrix: Soil

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Solids, Total	93.4		%	0.100	NA	1	-	07/20/23 07:39	121,2540G	ROI
Cyanide, Total	ND		mg/kg	1.0	0.21	1	07/20/23 11:10	07/20/23 14:38	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341423
Report Date: 07/24/23

Method Blank Analysis
Batch Quality Control

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab for sample(s): 07 Batch: WG1805428-1										
Cyanide, Total	ND		mg/kg	0.87	0.18	1	07/20/23 11:10	07/20/23 13:58	1,9010C/9012B	JER
General Chemistry - Westborough Lab for sample(s): 01-06 Batch: WG1805444-1										
Cyanide, Total	ND		mg/l	0.005	0.001	1	07/20/23 14:55	07/20/23 18:02	1,9010C/9012B	JER

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2341423

Report Date: 07/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
General Chemistry - Westborough Lab Associated sample(s): 07 Batch: WG1805428-2 WG1805428-3								
Cyanide, Total	108		97		80-120	8		35
General Chemistry - Westborough Lab Associated sample(s): 01-06 Batch: WG1805444-2 WG1805444-3								
Cyanide, Total	106		103		85-115	3		20

Matrix Spike Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341423
Report Date: 07/24/23

Parameter	Native Sample	MS Added	MS Found	MS %Recovery	Qual	MSD Found	MSD %Recovery	Qual	Recovery Limits	RPD	Qual	RPD Limits
General Chemistry - Westborough Lab Associated sample(s): 07 QC Batch ID: WG1805428-4 WG1805428-5 QC Sample: L2340796-11 Client ID: MS Sample												
Cyanide, Total	ND	11	12	110		12	120		75-125	0		35
General Chemistry - Westborough Lab Associated sample(s): 01-06 QC Batch ID: WG1805444-4 WG1805444-5 QC Sample: L2339211-11 Client ID: MS Sample												
Cyanide, Total	ND	0.2	0.238	119		0.231	116		80-120	3		20

Lab Duplicate Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2341423

Report Date: 07/24/23

Parameter	Native Sample	Duplicate Sample	Units	RPD	Qual	RPD Limits
General Chemistry - Westborough Lab Associated sample(s): 07 QC Batch ID: WG1805395-1 QC Sample: L2341280-01 Client ID: DUP Sample						
Solids, Total	83.2	82.6	%	1		20

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341423
Report Date: 07/24/23

Sample Receipt and Container Information

Were project specific reporting limits specified? YES

Cooler Information

Cooler	Custody Seal
A	Absent

Container Information

Container ID	Container Type	Cooler	Initial pH	Final pH	Temp deg C	Pres	Seal	Frozen Date/Time	Analysis(*)
L2341423-01A	Vial HCl preserved	A	NA		3.3	Y	Absent		NYTCL-8260(14)
L2341423-01B	Vial HCl preserved	A	NA		3.3	Y	Absent		NYTCL-8260(14)
L2341423-01C	Vial HCl preserved	A	NA		3.3	Y	Absent		NYTCL-8260(14)
L2341423-01D	Amber 120ml unpreserved	A	7	7	3.3	Y	Absent		NYTCL-8082-LVI(365)
L2341423-01E	Amber 120ml unpreserved	A	7	7	3.3	Y	Absent		NYTCL-8082-LVI(365)
L2341423-01F	Amber 120ml unpreserved	A	7	7	3.3	Y	Absent		NYTCL-8081(7)
L2341423-01G	Amber 120ml unpreserved	A	7	7	3.3	Y	Absent		NYTCL-8081(7)
L2341423-01H	Plastic 250ml HNO3 preserved	A	<2	<2	3.3	Y	Absent		FE-6020T(180),TL-6020T(180),BA-6020T(180),SE-6020T(180),CR-6020T(180),K-6020T(180),CA-6020T(180),NI-6020T(180),CU-6020T(180),NA-6020T(180),ZN-6020T(180),PB-6020T(180),BE-6020T(180),MN-6020T(180),V-6020T(180),SB-6020T(180),AS-6020T(180),AG-6020T(180),MG-6020T(180),HG-T(28),CD-6020T(180),AL-6020T(180),CO-6020T(180)
L2341423-01I	Plastic 250ml NaOH preserved	A	>12	>12	3.3	Y	Absent		TCN-9010(14)
L2341423-01J	Amber 250ml unpreserved	A	7	7	3.3	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)
L2341423-01K	Amber 250ml unpreserved	A	7	7	3.3	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)
L2341423-02A	Vial HCl preserved	A	NA		3.3	Y	Absent		NYTCL-8260(14)
L2341423-02B	Vial HCl preserved	A	NA		3.3	Y	Absent		NYTCL-8260(14)
L2341423-02C	Vial HCl preserved	A	NA		3.3	Y	Absent		NYTCL-8260(14)
L2341423-02D	Amber 120ml unpreserved	A	7	7	3.3	Y	Absent		NYTCL-8082-LVI(365)
L2341423-02E	Amber 120ml unpreserved	A	7	7	3.3	Y	Absent		NYTCL-8082-LVI(365)
L2341423-02F	Amber 120ml unpreserved	A	7	7	3.3	Y	Absent		NYTCL-8081(7)
L2341423-02G	Amber 120ml unpreserved	A	7	7	3.3	Y	Absent		NYTCL-8081(7)

*Values in parentheses indicate holding time in days

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341423
Report Date: 07/24/23

Container Information

Container ID	Container Type	Cooler	Initial pH	Final pH	Temp deg C	Pres	Seal	Frozen Date/Time	Analysis(*)
L2341423-02H	Plastic 250ml HNO3 preserved	A	<2	<2	3.3	Y	Absent		FE-6020T(180),BA-6020T(180),SE-6020T(180),TL-6020T(180),NI-6020T(180),CR-6020T(180),K-6020T(180),CA-6020T(180),NA-6020T(180),ZN-6020T(180),CU-6020T(180),PB-6020T(180),MN-6020T(180),BE-6020T(180),V-6020T(180),SB-6020T(180),AS-6020T(180),AL-6020T(180),AG-6020T(180),CD-6020T(180),HG-T(28),MG-6020T(180),CO-6020T(180)
L2341423-02I	Plastic 250ml NaOH preserved	A	>12	>12	3.3	Y	Absent		TCN-9010(14)
L2341423-02J	Amber 250ml unpreserved	A	7	7	3.3	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)
L2341423-02K	Amber 250ml unpreserved	A	7	7	3.3	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)
L2341423-03A	Vial HCl preserved	A	NA		3.3	Y	Absent		NYTCL-8260(14)
L2341423-03B	Vial HCl preserved	A	NA		3.3	Y	Absent		NYTCL-8260(14)
L2341423-03C	Vial HCl preserved	A	NA		3.3	Y	Absent		NYTCL-8260(14)
L2341423-03D	Amber 120ml unpreserved	A	7	7	3.3	Y	Absent		NYTCL-8082-LVI(365)
L2341423-03E	Amber 120ml unpreserved	A	7	7	3.3	Y	Absent		NYTCL-8082-LVI(365)
L2341423-03F	Amber 120ml unpreserved	A	7	7	3.3	Y	Absent		NYTCL-8081(7)
L2341423-03G	Amber 120ml unpreserved	A	7	7	3.3	Y	Absent		NYTCL-8081(7)
L2341423-03H	Plastic 250ml HNO3 preserved	A	<2	<2	3.3	Y	Absent		BA-6020T(180),FE-6020T(180),SE-6020T(180),TL-6020T(180),K-6020T(180),CA-6020T(180),CR-6020T(180),NI-6020T(180),CU-6020T(180),ZN-6020T(180),NA-6020T(180),PB-6020T(180),BE-6020T(180),MN-6020T(180),SB-6020T(180),AS-6020T(180),V-6020T(180),AG-6020T(180),AL-6020T(180),CD-6020T(180),HG-T(28),MG-6020T(180),CO-6020T(180)
L2341423-03I	Plastic 250ml NaOH preserved	A	>12	>12	3.3	Y	Absent		TCN-9010(14)
L2341423-03J	Amber 250ml unpreserved	A	7	7	3.3	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)
L2341423-03K	Amber 250ml unpreserved	A	7	7	3.3	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)
L2341423-04A	Vial HCl preserved	A	NA		3.3	Y	Absent		NYTCL-8260(14)
L2341423-04B	Vial HCl preserved	A	NA		3.3	Y	Absent		NYTCL-8260(14)
L2341423-04C	Vial HCl preserved	A	NA		3.3	Y	Absent		NYTCL-8260(14)
L2341423-04D	Amber 120ml unpreserved	A	7	7	3.3	Y	Absent		NYTCL-8082-LVI(365)
L2341423-04E	Amber 120ml unpreserved	A	7	7	3.3	Y	Absent		NYTCL-8082-LVI(365)

*Values in parentheses indicate holding time in days

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341423
Report Date: 07/24/23

Container Information

Container ID	Container Type	Cooler	Initial pH	Final pH	Temp deg C	Pres	Seal	Frozen Date/Time	Analysis(*)
L2341423-04F	Amber 120ml unpreserved	A	7	7	3.3	Y	Absent		NYTCL-8081(7)
L2341423-04G	Amber 120ml unpreserved	A	7	7	3.3	Y	Absent		NYTCL-8081(7)
L2341423-04H	Plastic 250ml HNO3 preserved	A	<2	<2	3.3	Y	Absent		SE-6020T(180),TL-6020T(180),FE-6020T(180),BA-6020T(180),CA-6020T(180),CR-6020T(180),NI-6020T(180),K-6020T(180),CU-6020T(180),NA-6020T(180),ZN-6020T(180),PB-6020T(180),MN-6020T(180),BE-6020T(180),SB-6020T(180),AS-6020T(180),V-6020T(180),AL-6020T(180),MG-6020T(180),CD-6020T(180),AG-6020T(180),HG-T(28),CO-6020T(180)
L2341423-04I	Plastic 250ml NaOH preserved	A	>12	>12	3.3	Y	Absent		TCN-9010(14)
L2341423-04J	Amber 250ml unpreserved	A	7	7	3.3	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)
L2341423-04K	Amber 250ml unpreserved	A	7	7	3.3	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)
L2341423-05A	Vial HCl preserved	A	NA		3.3	Y	Absent		NYTCL-8260(14)
L2341423-05B	Vial HCl preserved	A	NA		3.3	Y	Absent		NYTCL-8260(14)
L2341423-05C	Vial HCl preserved	A	NA		3.3	Y	Absent		NYTCL-8260(14)
L2341423-05D	Amber 120ml unpreserved	A	7	7	3.3	Y	Absent		NYTCL-8082-LVI(365)
L2341423-05E	Amber 120ml unpreserved	A	7	7	3.3	Y	Absent		NYTCL-8082-LVI(365)
L2341423-05F	Amber 120ml unpreserved	A	7	7	3.3	Y	Absent		NYTCL-8081(7)
L2341423-05G	Amber 120ml unpreserved	A	7	7	3.3	Y	Absent		NYTCL-8081(7)
L2341423-05H	Plastic 250ml HNO3 preserved	A	<2	<2	3.3	Y	Absent		TL-6020T(180),BA-6020T(180),FE-6020T(180),SE-6020T(180),NI-6020T(180),CA-6020T(180),CR-6020T(180),K-6020T(180),ZN-6020T(180),NA-6020T(180),CU-6020T(180),PB-6020T(180),BE-6020T(180),MN-6020T(180),SB-6020T(180),V-6020T(180),AS-6020T(180),CD-6020T(180),HG-T(28),AG-6020T(180),MG-6020T(180),AL-6020T(180),CO-6020T(180)
L2341423-05I	Plastic 250ml NaOH preserved	A	>12	>12	3.3	Y	Absent		TCN-9010(14)
L2341423-05J	Amber 250ml unpreserved	A	7	7	3.3	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)
L2341423-05K	Amber 250ml unpreserved	A	7	7	3.3	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)
L2341423-06A	Vial HCl preserved	A	NA		3.3	Y	Absent		NYTCL-8260(14)
L2341423-06B	Vial HCl preserved	A	NA		3.3	Y	Absent		NYTCL-8260(14)
L2341423-06C	Vial HCl preserved	A	NA		3.3	Y	Absent		NYTCL-8260(14)

*Values in parentheses indicate holding time in days

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341423
Report Date: 07/24/23

Container Information

Container ID	Container Type	Cooler	Initial pH	Final pH	Temp deg C	Pres	Seal	Frozen Date/Time	Analysis(*)
L2341423-06D	Amber 120ml unpreserved	A	10	10	3.3	Y	Absent		NYTCL-8082-LVI(365)
L2341423-06E	Amber 120ml unpreserved	A	10	10	3.3	Y	Absent		NYTCL-8082-LVI(365)
L2341423-06F	Amber 120ml unpreserved	A	10	10	3.3	Y	Absent		NYTCL-8081(7)
L2341423-06G	Amber 120ml unpreserved	A	10	10	3.3	Y	Absent		NYTCL-8081(7)
L2341423-06H	Plastic 250ml HNO3 preserved	A	<2	<2	3.3	Y	Absent		FE-6020T(180),TL-6020T(180),SE-6020T(180),BA-6020T(180),K-6020T(180),NI-6020T(180),CA-6020T(180),CR-6020T(180),ZN-6020T(180),CU-6020T(180),NA-6020T(180),PB-6020T(180),BE-6020T(180),MN-6020T(180),AS-6020T(180),V-6020T(180),SB-6020T(180),HG-T(28),MG-6020T(180),AG-6020T(180),CD-6020T(180),AL-6020T(180),CO-6020T(180)
L2341423-06I	Plastic 250ml NaOH preserved	A	>12	>12	3.3	Y	Absent		TCN-9010(14)
L2341423-06J	Amber 250ml unpreserved	A	10	10	3.3	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)
L2341423-06K	Amber 250ml unpreserved	A	10	10	3.3	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)
L2341423-07A	5 gram Encore Sampler	A	NA		3.3	Y	Absent		NYTCL-8260HLW(14)
L2341423-07B	5 gram Encore Sampler	A	NA		3.3	Y	Absent		NYTCL-8260HLW(14)
L2341423-07C	5 gram Encore Sampler	A	NA		3.3	Y	Absent		NYTCL-8260HLW(14)
L2341423-07D	Plastic 2oz unpreserved for TS	A	NA		3.3	Y	Absent		TS(7)
L2341423-07E	Metals Only-Glass 60mL/2oz unpreserved	A	NA		3.3	Y	Absent		BE-TI(180),BA-TI(180),AS-TI(180),AG-TI(180),NI-TI(180),TL-TI(180),CR-TI(180),AL-TI(180),ZN-TI(180),CU-TI(180),PB-TI(180),SB-TI(180),SE-TI(180),V-TI(180),CO-TI(180),FE-TI(180),HG-T(28),MG-TI(180),MN-TI(180),CA-TI(180),CD-TI(180),NA-TI(180),K-TI(180)
L2341423-07F	Glass 250ml/8oz unpreserved	A	NA		3.3	Y	Absent		NYTCL-8270(14),TCN-9010(14),NYTCL-8081(14),NYTCL-8082(365)
L2341423-07X	Vial MeOH preserved split	A	NA		3.3	Y	Absent		NYTCL-8260HLW(14)
L2341423-07Y	Vial Water preserved split	A	NA		3.3	Y	Absent	20-JUL-23 06:44	NYTCL-8260HLW(14)
L2341423-07Z	Vial Water preserved split	A	NA		3.3	Y	Absent	20-JUL-23 06:44	NYTCL-8260HLW(14)

*Values in parentheses indicate holding time in days

Project Name:	100 MAIN ST.	**Lab Number:**	L2341423
Project Number:	12461	**Report Date:**	07/24/23

GLOSSARY

Acronyms

DL - Detection Limit: This value represents the level to which target analyte concentrations are reported as estimated values, when those target analyte concentrations are quantified below the limit of quantitation (LOQ). The DL includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.)

EDL - Estimated Detection Limit: This value represents the level to which target analyte concentrations are reported as estimated values, when those target analyte concentrations are quantified below the reporting limit (RL). The EDL includes any adjustments from dilutions, concentrations or moisture content, where applicable. The use of EDLs is specific to the analysis of PAHs using Solid-Phase Microextraction (SPME).

EMPC - Estimated Maximum Possible Concentration: The concentration that results from the signal present at the retention time of an analyte when the ions meet all of the identification criteria except the ion abundance ratio criteria. An EMPC is a worst-case estimate of the concentration.

EPA - Environmental Protection Agency.

LCS - Laboratory Control Sample: A sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes or a material containing known and verified amounts of analytes.

LCSD - Laboratory Control Sample Duplicate: Refer to LCS.

LFB - Laboratory Fortified Blank: A sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes or a material containing known and verified amounts of analytes.

LOD - Limit of Detection: This value represents the level to which a target analyte can reliably be detected for a specific analyte in a specific matrix by a specific method. The LOD includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.)

LOQ - Limit of Quantitation: The value at which an instrument can accurately measure an analyte at a specific concentration. The LOQ includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.)

Limit of Quantitation: The value at which an instrument can accurately measure an analyte at a specific concentration. The LOQ includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.)

MDL - Method Detection Limit: This value represents the level to which target analyte concentrations are reported as estimated values, when those target analyte concentrations are quantified below the reporting limit (RL). The MDL includes any adjustments from dilutions, concentrations or moisture content, where applicable.

MS - Matrix Spike Sample: A sample prepared by adding a known mass of target analyte to a specified amount of matrix sample for which an independent estimate of target analyte concentration is available. For Method 332.0, the spike recovery is calculated using the native concentration, including estimated values.

MSD - Matrix Spike Sample Duplicate: Refer to MS.

NA - Not Applicable.

NC - Not Calculated: Term is utilized when one or more of the results utilized in the calculation are non-detect at the parameter's reporting unit.

NDPA/DPA - N-Nitrosodiphenylamine/Diphenylamine.

NI - Not Ignitable.

NP - Non-Plastic: Term is utilized for the analysis of Atterberg Limits in soil.

NR - No Results: Term is utilized when 'No Target Compounds Requested' is reported for the analysis of Volatile or Semivolatile Organic TIC only requests.

RL - Reporting Limit: The value at which an instrument can accurately measure an analyte at a specific concentration. The RL includes any adjustments from dilutions, concentrations or moisture content, where applicable.

RPD - Relative Percent Difference: The results from matrix and/or matrix spike duplicates are primarily designed to assess the precision of analytical results in a given matrix and are expressed as relative percent difference (RPD). Values which are less than five times the reporting limit for any individual parameter are evaluated by utilizing the absolute difference between the values; although the RPD value will be provided in the report.

SRM - Standard Reference Material: A reference sample of a known or certified value that is of the same or similar matrix as the associated field samples.

STLP - Semi-dynamic Tank Leaching Procedure per EPA Method 1315.

TEF - Toxic Equivalency Factors: The values assigned to each dioxin and furan to evaluate their toxicity relative to 2,3,7,8-TCDD.

TEQ - Toxic Equivalent: The measure of a sample's toxicity derived by multiplying each dioxin and furan by its corresponding TEF and then summing the resulting values.

TIC - Tentatively Identified Compound: A compound that has been identified to be present and is not part of the target compound list (TCL) for the method and/or program. All TICs are qualitatively identified and reported as estimated concentrations.

Report Format: DU Report with 'J' Qualifiers

Project Name:	100 MAIN ST.	**Lab Number:**	L2341423
Project Number:	12461	**Report Date:**	07/24/23

Footnotes

1 - The reference for this analyte should be considered modified since this analyte is absent from the target analyte list of the original method.

Terms

Analytical Method: Both the document from which the method originates and the analytical reference method. (Example: EPA 8260B is shown as 1,8260B.) The codes for the reference method documents are provided in the References section of the Addendum.

Chlordane: The target compound Chlordane (CAS No. 57-74-9) is reported for GC ECD analyses. Per EPA,this compound "refers to a mixture of chlordane isomers, other chlorinated hydrocarbons and numerous other components." (Reference: USEPA Toxicological Review of Chlordane, In Support of Summary Information on the Integrated Risk Information System (IRIS), December 1997.)

Difference: With respect to Total Oxidizable Precursor (TOP) Assay analysis, the difference is defined as the Post-Treatment value minus the Pre-Treatment value.

Final pH: As it pertains to Sample Receipt & Container Information section of the report, Final pH reflects pH of container determined after adjustment at the laboratory, if applicable. If no adjustment required, value reflects Initial pH.

Frozen Date/Time: With respect to Volatile Organics in soil, Frozen Date/Time reflects the date/time at which associated Reagent Water-preserved vials were initially frozen. Note: If frozen date/time is beyond 48 hours from sample collection, value will be reflected in 'bold'.

Gasoline Range Organics (GRO): Gasoline Range Organics (GRO) results include all chromatographic peaks eluting from Methyl tert butyl ether through Naphthalene, with the exception of GRO analysis in support of State of Ohio programs, which includes all chromatographic peaks eluting from Hexane through Dodecane.

Initial pH: As it pertains to Sample Receipt & Container Information section of the report, Initial pH reflects pH of container determined upon receipt, if applicable.

PAH Total: With respect to Alkylated PAH analyses, the 'PAHs, Total' result is defined as the summation of results for all or a subset of the following compounds: Naphthalene, C1-C4 Naphthalenes, 2-Methylnaphthalene, 1-Methylnaphthalene, Biphenyl, Acenaphthylene, Acenaphthene, Fluorene, C1-C3 Fluorenes, Phenanthrene, C1-C4 Phenanthrenes/Anthracenes, Anthracene, Fluoranthene, Pyrene, C1-C4 Fluoranthenes/Pyrenes, Benz(a)anthracene, Chrysene, C1-C4 Chrysenes, Benzo(b)fluoranthene, Benzo(j)+(k)fluoranthene, Benzo(e)pyrene, Benzo(a)pyrene, Perylene, Indeno(1,2,3-cd)pyrene, Dibenz(ah)+(ac)anthracene, Benzo(g,h,i)perylene. If a 'Total' result is requested, the results of its individual components will also be reported.

PFAS Total: With respect to PFAS analyses, the 'PFAS, Total (5)' result is defined as the summation of results for: PFHpA, PFHxS, PFOA, PFNA and PFOS. In addition, the 'PFAS, Total (6)' result is defined as the summation of results for: PFHpA, PFHxS, PFOA, PFNA, PFDA and PFOS. For MassDEP DW compliance analysis only, the 'PFAS, Total (6)' result is defined as the summation of results at or above the RL. Note: If a 'Total' result is requested, the results of its individual components will also be reported.

Total: With respect to Organic analyses, a 'Total' result is defined as the summation of results for individual isomers or Aroclors. If a 'Total' result is requested, the results of its individual components will also be reported. This is applicable to 'Total' results for methods 8260, 8081 and 8082.

Data Qualifiers

A - Spectra identified as "Aldol Condensates" are byproducts of the extraction/concentration procedures when acetone is introduced in the process.

B - The analyte was detected above the reporting limit in the associated method blank. Flag only applies to associated field samples that have detectable concentrations of the analyte at less than ten times (10x) the concentration found in the blank. For MCP-related projects, flag only applies to associated field samples that have detectable concentrations of the analyte at less than ten times (10x) the concentration found in the blank. For DOD-related projects, flag only applies to associated field samples that have detectable concentrations of the analyte at less than ten times (10x) the concentration found in the blank AND the analyte was detected above one-half the reporting limit (or above the reporting limit for common lab contaminants) in the associated method blank. For NJ-Air-related projects, flag only applies to associated field samples that have detectable concentrations of the analyte above the reporting limit. For NJ-related projects (excluding Air), flag only applies to associated field samples that have detectable concentrations of the analyte, which was detected above the reporting limit in the associated method blank or above five times the reporting limit for common lab contaminants (Phthalates, Acetone, Methylene Chloride, 2-Butanone).

C - Co-elution: The target analyte co-elutes with a known lab standard (i.e. surrogate, internal standards, etc.) for co-extracted analyses.

D - Concentration of analyte was quantified from diluted analysis. Flag only applies to field samples that have detectable concentrations of the analyte.

E - Concentration of analyte exceeds the range of the calibration curve and/or linear range of the instrument.

F - The ratio of quantifier ion response to qualifier ion response falls outside of the laboratory criteria. Results are considered to be an estimated maximum concentration.

G - The concentration may be biased high due to matrix interferences (i.e, co-elution) with non-target compound(s). The result should be considered estimated.

H - The analysis of pH was performed beyond the regulatory-required holding time of 15 minutes from the time of sample collection.

I - The lower value for the two columns has been reported due to obvious interference.

J - Estimated value. The Target analyte concentration is below the quantitation limit (RL), but above the Method Detection Limit (MDL) or Estimated Detection Limit (EDL) for SPME-related analyses. This represents an estimated concentration for Tentatively

Report Format: DU Report with 'J' Qualifiers

Project Name:	100 MAIN ST.	**Lab Number:**	L2341423
Project Number:	12461	**Report Date:**	07/24/23

Data Qualifiers

Identified Compounds (TICs). For calculated parameters, this represents that one or more values used in the calculation were estimated.

M - Reporting Limit (RL) exceeds the MCP CAM Reporting Limit for this analyte.

ND - Not detected at the method detection limit (MDL) for the sample, or estimated detection limit (EDL) for SPME-related analyses.

NJ - Presumptive evidence of compound. This represents an estimated concentration for Tentatively Identified Compounds (TICs), where the identification is based on a mass spectral library search.

P - The RPD between the results for the two columns exceeds the method-specified criteria.

Q - The quality control sample exceeds the associated acceptance criteria. For DOD-related projects, LCS and/or Continuing Calibration Standard exceedences are also qualified on all associated sample results. Note: This flag is not applicable for matrix spike recoveries when the sample concentration is greater than 4x the spike added or for batch duplicate RPD when the sample concentrations are less than 5x the RL. (Metals only.)

R - Analytical results are from sample re-analysis.

RE - Analytical results are from sample re-extraction.

S - Analytical results are from modified screening analysis.

V - The surrogate associated with this target analyte has a recovery outside the QC acceptance limits. (Applicable to MassDEP DW Compliance samples only.)

Z - The batch matrix spike and/or duplicate associated with this target analyte has a recovery/RPD outside the QC acceptance limits. (Applicable to MassDEP DW Compliance samples only.)

Project Name:	100 MAIN ST.	**Lab Number:**	L2341423
Project Number:	12461	**Report Date:**	07/24/23

REFERENCES

1 Test Methods for Evaluating Solid Waste: Physical/Chemical Methods. EPA SW-846. Third Edition. Updates I - VI, 2018.

121 Standard Methods for the Examination of Water and Wastewater. APHA-AWWA-WEF. Standard Methods Online.

LIMITATION OF LIABILITIES

Alpha Analytical performs services with reasonable care and diligence normal to the analytical testing laboratory industry. In the event of an error, the sole and exclusive responsibility of Alpha Analytical shall be to re-perform the work at it's own expense. In no event shall Alpha Analytical be held liable for any incidental, consequential or special damages, including but not limited to, damages in any way connected with the use of, interpretation of, information or analysis provided by Alpha Analytical.

We strongly urge our clients to comply with EPA protocol regarding sample volume, preservation, cooling, containers, sampling procedures, holding time and splitting of samples in the field.

Certification Information

The following analytes are not included in our Primary NELAP Scope of Accreditation:

Westborough Facility
EPA 624.1: m/p-xylene, o-xylene, Naphthalene
EPA 625.1: alpha-Terpineol
EPA 8260D: NPW: 1,2,4,5-Tetramethylbenzene; 4-Ethyltoluene, Azobenzene; SCM: Iodomethane (methyl iodide), 1,2,4,5-Tetramethylbenzene; 4-Ethyltoluene.
EPA 8270E: NPW: Dimethylnaphthalene,1,4-Diphenylhydrazine, alpha-Terpineol; SCM: Dimethylnaphthalene,1,4-Diphenylhydrazine.
SM4500: NPW: Amenable Cyanide; SCM: Total Phosphorus, TKN, NO2, NO3.

Mansfield Facility
SM 2540D: TSS.
EPA TO-15: Halothane, 2,4,4-Trimethyl-2-pentene, 2,4,4-Trimethyl-1-pentene, Thiophene, 2-Methylthiophene, 3-Methylthiophene, 2-Ethylthiophene, 1,2,3-Trimethylbenzene, Indan, Indene, 1,2,4,5-Tetramethylbenzene, Benzothiophene, 1-Methylnaphthalene.
Biological Tissue Matrix: EPA 3050B

The following analytes are included in our Massachusetts DEP Scope of Accreditation

Westborough Facility:

Drinking Water
EPA 300.0: Chloride, Nitrate-N, Fluoride, Sulfate; **EPA 353.2**: Nitrate-N, Nitrite-N; **SM4500NO3-F**: Nitrate-N, Nitrite-N; **SM4500F-C, SM4500CN-CE, EPA 180.1, SM2130B, SM4500Cl-D, SM2320B, SM2540C, SM4500H-B, SM4500NO2-B**
EPA 524.2: THMs and VOCs; **EPA 504.1:** EDB, DBCP.
Microbiology: **SM9215B; SM9223-P/A, SM9223B-Colilert-QT,SM9222D**.

Non-Potable Water
SM4500H,B, EPA 120.1, SM2510B, SM2540C, SM2320B, SM4500CL-E, SM4500F-BC, SM4500NH3-BH: Ammonia-N and Kjeldahl-N, **EPA 350.1**: Ammonia-N, **LACHAT 10-107-06-1-B**: Ammonia-N, **EPA 351.1, SM4500NO3-F, EPA 353.2**: Nitrate-N**, SM4500P-E, SM4500P-B, E, SM4500SO4-E, SM5220D, EPA 410.4, SM5210B, SM5310C, SM4500CL-D, EPA 1664, EPA 420.1, SM4500-CN-CE, SM2540D, EPA 300: Chloride, Sulfate, Nitrate.**
EPA 624.1: Volatile Halocarbons & Aromatics,
EPA 608.3: Chlordane, Toxaphene, Aldrin, alpha-BHC, beta-BHC, gamma-BHC, delta-BHC, Dieldrin, DDD, DDE, DDT, Endosulfan I, Endosulfan II, Endosulfan sulfate, Endrin, Endrin Aldehyde, Heptachlor, Heptachlor Epoxide, PCBs
EPA 625.1: SVOC (Acid/Base/Neutral Extractables).
Microbiology: **SM9223B-Colilert-QT; Enterolert-QT, SM9221E, EPA 1600, EPA 1603, SM9222D.**

Mansfield Facility:

Drinking Water
EPA 200.7: Al, Ba, Cd, Cr, Cu, Fe, Mn, Ni, Na, Ag, Ca, Zn. **EPA 200.8:** Al, Sb, As, Ba, Be, Cd, Cr, Cu, Pb, Mn, Ni, Se, Ag, TL, Zn. **EPA 245.1** Hg.
EPA 522, EPA 537.1.

Non-Potable Water
EPA 200.7: Al, Sb, As, Be, Cd, Ca, Cr, Co, Cu, Fe, Pb, Mg, Mn, Mo, Ni, K, Se, Ag, Na, Sr, TL, Ti, V, Zn.
EPA 200.8: Al, Sb**,** As, Be, Cd, Cr, Cu, Fe, Pb, Mn, Ni, K, Se, Ag, Na, TL, Zn.
EPA 245.1 Hg.
SM2340B

For a complete listing of analytes and methods, please contact your Alpha Project Manager.

NEW YORK CHAIN OF CUSTODY

ALPHA ANALYTICAL

Westborough, MA 01581 — 8 Walkup Dr. — TEL: 508-898-9220 — FAX: 508-898-9193

Mansfield, MA 02048 — 320 Forbes Blvd — TEL: 508-822-9300 — FAX: 508-822-3288

Service Centers
Mahwah, NJ 07430: 35 Whitney Rd, Suite 5
Albany, NY 12205: 14 Walker Way
Tonawanda, NY 14150: 275 Cooper Ave, Suite 105

Page of

Date Rec'd in Lab: 7/20/23

ALPHA Job #: L2341423

Client Information
Client: SESI
Address: 959 US 46 E/3 S300
Parsippany NJ 07054
Phone: 973 808 9050
Fax:
Email: JCS@sesi.org

Project Information
Project Name: 100 main St
Project Location: White Plains NY
Project #: 17461
(Use Project name as Project #): ☐
Project Manager: Jon Stuart
ALPHAQuote #:

Turn-Around Time
Standard ☐ Due Date:
Rush (only if pre approved) ☑ # of Days: 3

Deliverables
☐ ASP-A ☑ ASP-B
☐ EQuIS (1 File) ☐ EQuIS (4 File)
☐ Other

Regulatory Requirement
☐ NY TOGS ☐ NY Part 375
☑ AWQ Standards ☐ NY CP-51
☐ NY Restricted Use ☐ Other
☑ NY Unrestricted Use
☐ NYC Sewer Discharge

Billing Information
☐ Same as Client Info
PO # Renaissance Env Mgmt
Attn: Kevin McNamus

Disposal Site Information
Please identify below location of applicable disposal facilities.
Disposal Facility:
☐ NJ ☐ NY
☐ Other:

These samples have been previously analyzed by Alpha ☐

Other project specific requirements/comments:

Please specify Metals or TAL.

ANALYSIS

Sample Filtration
☐ Done
☐ Lab to do
Preservation
☐ Lab to do
(Please Specify below)

ALPHA Lab ID (Lab Use Only)	Sample ID	Collection Date	Collection Time	Sample Matrix	Sampler's Initials	TCL+30 / TAL	Total Bottle	Sample Specific Comments
L2341423-01	GW-18	7/19/23	945	GW	CB	✓		
02	GW-19		830	GW	CB	✓		
03	GW-20		1420	GW	CB	✓		
04	GW-21		1170	GW	CB	✓		
05	GW-22		1145	GW	CB	✓		
06	GW-23	↓	1350	GW	CB	✓		
07	SB-51P(3.5-4)	↓	1500	S	CB	✓		

Container Type: P/G
Preservative: some

Preservative Code:
A = None
B = HCl
C = HNO_3
D = H_2SO_4
E = NaOH
F = MeOH
G = $NaHSO_4$
H = $Na_2S_2O_3$
K/E = Zn Ac/NaOH
O = Other

Container Code
P = Plastic
A = Amber Glass
V = Vial
G = Glass
B = Bacteria Cup
C = Cube
O = Other
E = Encore
D = BOD Bottle

Westboro: Certification No: MA935
Mansfield: Certification No: MA015

Relinquished By:	Date/Time	Received By:	Date/Time
	7/19/23 1503	AAL	7/19/23 15:04
	7/19/23 18:30		7/19 2100
	7/20 0030		7/20 0020
	7/20/23 0220		7/20/23 0220

Please print clearly, legibly and completely. Samples can not be logged in and turnaround time clock will not start until any ambiguities are resolved. BY EXECUTING THIS COC, THE CLIENT HAS READ AND AGREES TO BE BOUND BY ALPHA'S TERMS & CONDITIONS. (See reverse side.)

Form No: 01-25 HC (rev. 30-Sept-2013)

ANALYTICAL REPORT

Lab Number:	L2341778
Client:	Soils Engineering Services, Inc. 959 Route 46E Parsippany, NJ 07054
ATTN:	Jonathan Stuart
Phone:	(973) 808-9050
Project Name:	100 MAIN ST.
Project Number:	12461
Report Date:	07/24/23

The original project report/data package is held by Alpha Analytical. This report/data package is paginated and should be reproduced only in its entirety. Alpha Analytical holds no responsibility for results and/or data that are not consistent with the original.

Certifications & Approvals: MA (M-MA086), NH NELAP (2064), CT (PH-0826), IL (200077), IN (C-MA-03), KY (KY98045), ME (MA00086), MD (348), NJ (MA935), NY (11148), NC (25700/666), OH (CL108), OR (MA-1316), PA (68-03671), RI (LAO00065), TX (T104704476), VT (VT-0935), VA (460195), USDA (Permit #525-23-122-91930).

Eight Walkup Drive, Westborough, MA 01581-1019
508-898-9220 (Fax) 508-898-9193 800-624-9220 - www.alphalab.com

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341778
Report Date: 07/24/23

Alpha Sample ID	Client ID	Matrix	Sample Location	Collection Date/Time	Receive Date
L2341778-01	GW-27	WATER	WHITE PLAINS, NY	07/20/23 10:45	07/20/23

Project Name:	100 MAIN ST.	**Lab Number:**	L2341778
Project Number:	12461	**Report Date:**	07/24/23

Case Narrative

The samples were received in accordance with the Chain of Custody and no significant deviations were encountered during the preparation or analysis unless otherwise noted. Sample Receipt, Container Information, and the Chain of Custody are located at the back of the report.

Results contained within this report relate only to the samples submitted under this Alpha Lab Number and meet NELAP requirements for all NELAP accredited parameters unless otherwise noted in the following narrative. The data presented in this report is organized by parameter (i.e. VOC, SVOC, etc.). Sample specific Quality Control data (i.e. Surrogate Spike Recovery) is reported at the end of the target analyte list for each individual sample, followed by the Laboratory Batch Quality Control at the end of each parameter. Tentatively Identified Compounds (TICs), if requested, are reported for compounds identified to be present and are not part of the method/program Target Compound List, even if only a subset of the TCL are being reported. If a sample was re-analyzed or re-extracted due to a required quality control corrective action and if both sets of data are reported, the Laboratory ID of the re-analysis or re-extraction is designated with an "R" or "RE", respectively.

When multiple Batch Quality Control elements are reported (e.g. more than one LCS), the associated samples for each element are noted in the grey shaded header line of each data table. Any Laboratory Batch, Sample Specific % recovery or RPD value that is outside the listed Acceptance Criteria is bolded in the report. In reference to questions H (CAM) or 4 (RCP) when "NO" is checked, the performance criteria for CAM and RCP methods allow for some quality control failures to occur and still be within method compliance. In these instances, the specific failure is not narrated but noted in the associated QC Outlier Summary Report, located directly after the Case Narrative. QC information is also incorporated in the Data Usability Assessment table (Format 11) of our Data Merger tool, where it can be reviewed in conjunction with the sample result, associated regulatory criteria and any associated data usability implications.

Soil/sediments, solids and tissues are reported on a dry weight basis unless otherwise noted. Definitions of all data qualifiers and acronyms used in this report are provided in the Glossary located at the back of the report.

HOLD POLICY - For samples submitted on hold, Alpha's policy is to hold samples (with the exception of Air canisters) free of charge for 21 calendar days from the date the project is completed. After 21 calendar days, we will dispose of all samples submitted including those put on hold unless you have contacted your Alpha Project Manager and made arrangements for Alpha to continue to hold the samples. Air canisters will be disposed after 3 business days from the date the project is completed.

Please contact Project Management at 800-624-9220 with any questions.

Project Name:	100 MAIN ST.	**Lab Number:**	L2341778
Project Number:	12461	**Report Date:**	07/24/23

Case Narrative (continued)

Report Submission

July 24, 2023: This final report includes the results of all requested analyses.

July 21, 2023: This is a preliminary report.

All non-detect (ND) or estimated concentrations (J-qualified) have been quantitated to the limit noted in the MDL column.

Semivolatile Organics

The WG1805644-3 LCSD recovery, associated with L2341778-01, is below the acceptance criteria for benzoic acid (0%); however, it has been identified as a "difficult" analyte. The results of the associated sample are reported.

Semivolatile Organics by SIM

The WG1805593-1 Method Blank, associated with L2341778-01, has a concentration above the reporting limit for naphthalene. Since the associated sample concentration is non-detect to the RL for this target analyte, no corrective action is required.

Total Metals

The WG1805857-1 Method Blank, associated with L2341778-01, has a concentration above the reporting limit for mercury. Since the associated sample concentration is non-detect to the RL for this target analyte, no corrective action is required.

Cyanide, Total

The WG1805945-5 MSD recovery, performed on L2341778-01, is outside the acceptance criteria for cyanide, total (22%); however, the associated LCS recovery is within criteria. No further action was taken. The MS/MSD RPD for cyanide, total (131%) is above the acceptance criteria.

I, the undersigned, attest under the pains and penalties of perjury that, to the best of my knowledge and belief and based upon my personal inquiry of those responsible for providing the information contained in this analytical report, such information is accurate and complete. This certificate of analysis is not complete unless this page accompanies any and all pages of this report.

Authorized Signature: Kelly Stenstrom

Title: Technical Director/Representative Date: 07/24/23

ORGANICS

VOLATILES

Project Name: 100 MAIN ST.
Lab Number: L2341778
Project Number: 12461
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341778-01
Client ID: GW-27
Sample Location: WHITE PLAINS, NY

Date Collected: 07/20/23 10:45
Date Received: 07/20/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8260D
Analytical Date: 07/21/23 08:36
Analyst: MJV

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Methylene chloride	ND		ug/l	2.5	0.70	1
1,1-Dichloroethane	ND		ug/l	2.5	0.70	1
Chloroform	12		ug/l	2.5	0.70	1
Carbon tetrachloride	ND		ug/l	0.50	0.13	1
1,2-Dichloropropane	ND		ug/l	1.0	0.14	1
Dibromochloromethane	ND		ug/l	0.50	0.15	1
1,1,2-Trichloroethane	ND		ug/l	1.5	0.50	1
Tetrachloroethene	ND		ug/l	0.50	0.18	1
Chlorobenzene	ND		ug/l	2.5	0.70	1
Trichlorofluoromethane	ND		ug/l	2.5	0.70	1
1,2-Dichloroethane	ND		ug/l	0.50	0.13	1
1,1,1-Trichloroethane	ND		ug/l	2.5	0.70	1
Bromodichloromethane	0.95		ug/l	0.50	0.19	1
trans-1,3-Dichloropropene	ND		ug/l	0.50	0.16	1
cis-1,3-Dichloropropene	ND		ug/l	0.50	0.14	1
1,3-Dichloropropene, Total	ND		ug/l	0.50	0.14	1
1,1-Dichloropropene	ND		ug/l	2.5	0.70	1
Bromoform	ND		ug/l	2.0	0.65	1
1,1,2,2-Tetrachloroethane	ND		ug/l	0.50	0.17	1
Benzene	ND		ug/l	0.50	0.16	1
Toluene	ND		ug/l	2.5	0.70	1
Ethylbenzene	ND		ug/l	2.5	0.70	1
Chloromethane	ND		ug/l	2.5	0.70	1
Bromomethane	ND		ug/l	2.5	0.70	1
Vinyl chloride	ND		ug/l	1.0	0.07	1
Chloroethane	ND		ug/l	2.5	0.70	1
1,1-Dichloroethene	ND		ug/l	0.50	0.17	1
trans-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST. **Lab Number:** L2341778

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341778-01 Date Collected: 07/20/23 10:45

Client ID: GW-27 Date Received: 07/20/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
Trichloroethene	1.0		ug/l	0.50	0.18	1
1,2-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,3-Dichlorobenzene	ND		ug/l	2.5	0.70	1
1,4-Dichlorobenzene	ND		ug/l	2.5	0.70	1
Methyl tert butyl ether	ND		ug/l	2.5	0.70	1
p/m-Xylene	ND		ug/l	2.5	0.70	1
o-Xylene	ND		ug/l	2.5	0.70	1
Xylenes, Total	ND		ug/l	2.5	0.70	1
cis-1,2-Dichloroethene	ND		ug/l	2.5	0.70	1
1,2-Dichloroethene, Total	ND		ug/l	2.5	0.70	1
Dibromomethane	ND		ug/l	5.0	1.0	1
1,2,3-Trichloropropane	ND		ug/l	2.5	0.70	1
Acrylonitrile	ND		ug/l	5.0	1.5	1
Styrene	ND		ug/l	2.5	0.70	1
Dichlorodifluoromethane	ND		ug/l	5.0	1.0	1
Acetone	4.5	J	ug/l	5.0	1.5	1
Carbon disulfide	ND		ug/l	5.0	1.0	1
2-Butanone	ND		ug/l	5.0	1.9	1
Vinyl acetate	ND		ug/l	5.0	1.0	1
4-Methyl-2-pentanone	ND		ug/l	5.0	1.0	1
2-Hexanone	ND		ug/l	5.0	1.0	1
Bromochloromethane	ND		ug/l	2.5	0.70	1
2,2-Dichloropropane	ND		ug/l	2.5	0.70	1
1,2-Dibromoethane	ND		ug/l	2.0	0.65	1
1,3-Dichloropropane	ND		ug/l	2.5	0.70	1
1,1,1,2-Tetrachloroethane	ND		ug/l	2.5	0.70	1
Bromobenzene	ND		ug/l	2.5	0.70	1
n-Butylbenzene	ND		ug/l	2.5	0.70	1
sec-Butylbenzene	ND		ug/l	2.5	0.70	1
tert-Butylbenzene	ND		ug/l	2.5	0.70	1
o-Chlorotoluene	ND		ug/l	2.5	0.70	1
p-Chlorotoluene	ND		ug/l	2.5	0.70	1
1,2-Dibromo-3-chloropropane	ND		ug/l	2.5	0.70	1
Hexachlorobutadiene	ND		ug/l	2.5	0.70	1
Isopropylbenzene	ND		ug/l	2.5	0.70	1
p-Isopropyltoluene	ND		ug/l	2.5	0.70	1
Naphthalene	ND		ug/l	2.5	0.70	1

Project Name: 100 MAIN ST. **Lab Number:** L2341778

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341778-01 Date Collected: 07/20/23 10:45

Client ID: GW-27 Date Received: 07/20/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Volatile Organics by GC/MS - Westborough Lab						
n-Propylbenzene	ND		ug/l	2.5	0.70	1
1,2,3-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trichlorobenzene	ND		ug/l	2.5	0.70	1
1,3,5-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,2,4-Trimethylbenzene	ND		ug/l	2.5	0.70	1
1,4-Dioxane	ND		ug/l	250	61.	1
p-Diethylbenzene	ND		ug/l	2.0	0.70	1
p-Ethyltoluene	ND		ug/l	2.0	0.70	1
1,2,4,5-Tetramethylbenzene	ND		ug/l	2.0	0.54	1
Ethyl ether	ND		ug/l	2.5	0.70	1
trans-1,4-Dichloro-2-butene	ND		ug/l	2.5	0.70	1
Tentatively Identified Compounds						
No Tentatively Identified Compounds	ND		ug/l			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	118		70-130
Toluene-d8	97		70-130
4-Bromofluorobenzene	98		70-130
Dibromofluoromethane	103		70-130

Project Name: 100 MAIN ST. **Lab Number:** L2341778

Project Number: 12461 **Report Date:** 07/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 07/21/23 07:50
Analyst: MJV

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by GC/MS - Westborough Lab for sample(s): 01 Batch: WG1806095-5					
Methylene chloride	ND		ug/l	2.5	0.70
1,1-Dichloroethane	ND		ug/l	2.5	0.70
Chloroform	ND		ug/l	2.5	0.70
Carbon tetrachloride	ND		ug/l	0.50	0.13
1,2-Dichloropropane	ND		ug/l	1.0	0.14
Dibromochloromethane	ND		ug/l	0.50	0.15
1,1,2-Trichloroethane	ND		ug/l	1.5	0.50
Tetrachloroethene	ND		ug/l	0.50	0.18
Chlorobenzene	ND		ug/l	2.5	0.70
Trichlorofluoromethane	ND		ug/l	2.5	0.70
1,2-Dichloroethane	ND		ug/l	0.50	0.13
1,1,1-Trichloroethane	ND		ug/l	2.5	0.70
Bromodichloromethane	ND		ug/l	0.50	0.19
trans-1,3-Dichloropropene	ND		ug/l	0.50	0.16
cis-1,3-Dichloropropene	ND		ug/l	0.50	0.14
1,3-Dichloropropene, Total	ND		ug/l	0.50	0.14
1,1-Dichloropropene	ND		ug/l	2.5	0.70
Bromoform	ND		ug/l	2.0	0.65
1,1,2,2-Tetrachloroethane	ND		ug/l	0.50	0.17
Benzene	ND		ug/l	0.50	0.16
Toluene	ND		ug/l	2.5	0.70
Ethylbenzene	ND		ug/l	2.5	0.70
Chloromethane	ND		ug/l	2.5	0.70
Bromomethane	ND		ug/l	2.5	0.70
Vinyl chloride	ND		ug/l	1.0	0.07
Chloroethane	ND		ug/l	2.5	0.70
1,1-Dichloroethene	ND		ug/l	0.50	0.17
trans-1,2-Dichloroethene	ND		ug/l	2.5	0.70
Trichloroethene	ND		ug/l	0.50	0.18

Project Name: 100 MAIN ST. **Lab Number:** L2341778

Project Number: 12461 **Report Date:** 07/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 07/21/23 07:50
Analyst: MJV

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by GC/MS - Westborough Lab for sample(s): 01 Batch: WG1806095-5					
1,2-Dichlorobenzene	ND		ug/l	2.5	0.70
1,3-Dichlorobenzene	ND		ug/l	2.5	0.70
1,4-Dichlorobenzene	ND		ug/l	2.5	0.70
Methyl tert butyl ether	ND		ug/l	2.5	0.70
p/m-Xylene	ND		ug/l	2.5	0.70
o-Xylene	ND		ug/l	2.5	0.70
Xylenes, Total	ND		ug/l	2.5	0.70
cis-1,2-Dichloroethene	ND		ug/l	2.5	0.70
1,2-Dichloroethene, Total	ND		ug/l	2.5	0.70
Dibromomethane	ND		ug/l	5.0	1.0
1,2,3-Trichloropropane	ND		ug/l	2.5	0.70
Acrylonitrile	ND		ug/l	5.0	1.5
Styrene	ND		ug/l	2.5	0.70
Dichlorodifluoromethane	ND		ug/l	5.0	1.0
Acetone	ND		ug/l	5.0	1.5
Carbon disulfide	ND		ug/l	5.0	1.0
2-Butanone	ND		ug/l	5.0	1.9
Vinyl acetate	ND		ug/l	5.0	1.0
4-Methyl-2-pentanone	ND		ug/l	5.0	1.0
2-Hexanone	ND		ug/l	5.0	1.0
Bromochloromethane	ND		ug/l	2.5	0.70
2,2-Dichloropropane	ND		ug/l	2.5	0.70
1,2-Dibromoethane	ND		ug/l	2.0	0.65
1,3-Dichloropropane	ND		ug/l	2.5	0.70
1,1,1,2-Tetrachloroethane	ND		ug/l	2.5	0.70
Bromobenzene	ND		ug/l	2.5	0.70
n-Butylbenzene	ND		ug/l	2.5	0.70
sec-Butylbenzene	ND		ug/l	2.5	0.70
tert-Butylbenzene	ND		ug/l	2.5	0.70

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341778
Report Date: 07/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 07/21/23 07:50
Analyst: MJV

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by GC/MS - Westborough Lab for sample(s): 01 Batch: WG1806095-5					
o-Chlorotoluene	ND		ug/l	2.5	0.70
p-Chlorotoluene	ND		ug/l	2.5	0.70
1,2-Dibromo-3-chloropropane	ND		ug/l	2.5	0.70
Hexachlorobutadiene	ND		ug/l	2.5	0.70
Isopropylbenzene	ND		ug/l	2.5	0.70
p-Isopropyltoluene	ND		ug/l	2.5	0.70
Naphthalene	ND		ug/l	2.5	0.70
n-Propylbenzene	ND		ug/l	2.5	0.70
1,2,3-Trichlorobenzene	ND		ug/l	2.5	0.70
1,2,4-Trichlorobenzene	ND		ug/l	2.5	0.70
1,3,5-Trimethylbenzene	ND		ug/l	2.5	0.70
1,2,4-Trimethylbenzene	ND		ug/l	2.5	0.70
1,4-Dioxane	ND		ug/l	250	61.
p-Diethylbenzene	ND		ug/l	2.0	0.70
p-Ethyltoluene	ND		ug/l	2.0	0.70
1,2,4,5-Tetramethylbenzene	ND		ug/l	2.0	0.54
Ethyl ether	ND		ug/l	2.5	0.70
trans-1,4-Dichloro-2-butene	ND		ug/l	2.5	0.70
Tentatively Identified Compounds					
No Tentatively Identified Compounds	ND		ug/l		

Project Name: 100 MAIN ST. **Lab Number:** L2341778

Project Number: 12461 **Report Date:** 07/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8260D
Analytical Date: 07/21/23 07:50
Analyst: MJV

Parameter	Result	Qualifier	Units	RL	MDL
Volatile Organics by GC/MS - Westborough Lab for sample(s): 01 Batch: WG1806095-5					

Surrogate	%Recovery	Qualifier	Acceptance Criteria
1,2-Dichloroethane-d4	117		70-130
Toluene-d8	98		70-130
4-Bromofluorobenzene	98		70-130
Dibromofluoromethane	104		70-130

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341778
Report Date: 07/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by GC/MS - Westborough Lab Associated sample(s): 01 Batch: WG1806095-3 WG1806095-4								
Methylene chloride	100		98		70-130	2		20
1,1-Dichloroethane	110		110		70-130	0		20
Chloroform	110		110		70-130	0		20
Carbon tetrachloride	120		120		63-132	0		20
1,2-Dichloropropane	100		100		70-130	0		20
Dibromochloromethane	100		100		63-130	0		20
1,1,2-Trichloroethane	100		100		70-130	0		20
Tetrachloroethene	110		110		70-130	0		20
Chlorobenzene	100		100		75-130	0		20
Trichlorofluoromethane	120		120		62-150	0		20
1,2-Dichloroethane	110		110		70-130	0		20
1,1,1-Trichloroethane	120		120		67-130	0		20
Bromodichloromethane	110		110		67-130	0		20
trans-1,3-Dichloropropene	110		100		70-130	10		20
cis-1,3-Dichloropropene	100		100		70-130	0		20
1,1-Dichloropropene	110		110		70-130	0		20
Bromoform	100		94		54-136	6		20
1,1,2,2-Tetrachloroethane	100		100		67-130	0		20
Benzene	110		100		70-130	10		20
Toluene	100		100		70-130	0		20
Ethylbenzene	110		100		70-130	10		20
Chloromethane	100		95		64-130	5		20
Bromomethane	97		100		39-139	3		20

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341778
Report Date: 07/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by GC/MS - Westborough Lab Associated sample(s): 01 Batch: WG1806095-3 WG1806095-4								
Vinyl chloride	110		100		55-140	10		20
Chloroethane	100		100		55-138	0		20
1,1-Dichloroethene	110		110		61-145	0		20
trans-1,2-Dichloroethene	110		100		70-130	10		20
Trichloroethene	95		91		70-130	4		20
1,2-Dichlorobenzene	100		100		70-130	0		20
1,3-Dichlorobenzene	100		100		70-130	0		20
1,4-Dichlorobenzene	100		97		70-130	3		20
Methyl tert butyl ether	100		100		63-130	0		20
p/m-Xylene	110		105		70-130	5		20
o-Xylene	110		105		70-130	5		20
cis-1,2-Dichloroethene	100		100		70-130	0		20
Dibromomethane	100		100		70-130	0		20
1,2,3-Trichloropropane	98		95		64-130	3		20
Acrylonitrile	88		88		70-130	0		20
Styrene	110		105		70-130	5		20
Dichlorodifluoromethane	120		120		36-147	0		20
Acetone	77		78		58-148	1		20
Carbon disulfide	110		100		51-130	10		20
2-Butanone	76		**62**	Q	63-138	20		20
Vinyl acetate	**160**	Q	**150**	Q	70-130	6		20
4-Methyl-2-pentanone	94		94		59-130	0		20
2-Hexanone	84		86		57-130	2		20

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341778
Report Date: 07/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by GC/MS - Westborough Lab Associated sample(s): 01 Batch: WG1806095-3 WG1806095-4								
Bromochloromethane	110		110		70-130	0		20
2,2-Dichloropropane	130		130		63-133	0		20
1,2-Dibromoethane	100		100		70-130	0		20
1,3-Dichloropropane	100		100		70-130	0		20
1,1,1,2-Tetrachloroethane	110		100		64-130	10		20
Bromobenzene	100		99		70-130	1		20
n-Butylbenzene	110		100		53-136	10		20
sec-Butylbenzene	110		100		70-130	10		20
tert-Butylbenzene	100		100		70-130	0		20
o-Chlorotoluene	120		110		70-130	9		20
p-Chlorotoluene	100		100		70-130	0		20
1,2-Dibromo-3-chloropropane	95		92		41-144	3		20
Hexachlorobutadiene	120		120		63-130	0		20
Isopropylbenzene	100		100		70-130	0		20
p-Isopropyltoluene	100		100		70-130	0		20
Naphthalene	92		96		70-130	4		20
n-Propylbenzene	100		100		69-130	0		20
1,2,3-Trichlorobenzene	100		110		70-130	10		20
1,2,4-Trichlorobenzene	100		100		70-130	0		20
1,3,5-Trimethylbenzene	110		100		64-130	10		20
1,2,4-Trimethylbenzene	100		100		70-130	0		20
1,4-Dioxane	90		88		56-162	2		20
p-Diethylbenzene	100		98		70-130	2		20

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2341778

Report Date: 07/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Volatile Organics by GC/MS - Westborough Lab Associated sample(s): 01 Batch: WG1806095-3 WG1806095-4								
p-Ethyltoluene	110		100		70-130	10		20
1,2,4,5-Tetramethylbenzene	100		98		70-130	2		20
Ethyl ether	100		98		59-134	2		20
trans-1,4-Dichloro-2-butene	77		78		70-130	1		20

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
1,2-Dichloroethane-d4	114		115		70-130
Toluene-d8	101		101		70-130
4-Bromofluorobenzene	100		98		70-130
Dibromofluoromethane	100		100		70-130

SEMIVOLATILES

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341778
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341778-01
Client ID: GW-27
Sample Location: WHITE PLAINS, NY

Date Collected: 07/20/23 10:45
Date Received: 07/20/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E
Analytical Date: 07/21/23 09:55
Analyst: JG

Extraction Method: EPA 3510C
Extraction Date: 07/21/23 02:47

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
1,2,4-Trichlorobenzene	ND		ug/l	5.0	0.50	1
Bis(2-chloroethyl)ether	ND		ug/l	2.0	0.50	1
1,2-Dichlorobenzene	ND		ug/l	2.0	0.45	1
1,3-Dichlorobenzene	ND		ug/l	2.0	0.40	1
1,4-Dichlorobenzene	ND		ug/l	2.0	0.43	1
3,3'-Dichlorobenzidine	ND		ug/l	5.0	1.6	1
2,4-Dinitrotoluene	ND		ug/l	5.0	1.2	1
2,6-Dinitrotoluene	ND		ug/l	5.0	0.93	1
4-Chlorophenyl phenyl ether	ND		ug/l	2.0	0.49	1
4-Bromophenyl phenyl ether	ND		ug/l	2.0	0.38	1
Bis(2-chloroisopropyl)ether	ND		ug/l	2.0	0.53	1
Bis(2-chloroethoxy)methane	ND		ug/l	5.0	0.50	1
Hexachlorocyclopentadiene	ND		ug/l	20	0.69	1
Isophorone	ND		ug/l	5.0	1.2	1
Nitrobenzene	ND		ug/l	2.0	0.77	1
NDPA/DPA	ND		ug/l	2.0	0.42	1
n-Nitrosodi-n-propylamine	ND		ug/l	5.0	0.64	1
Bis(2-ethylhexyl)phthalate	ND		ug/l	3.0	1.5	1
Butyl benzyl phthalate	ND		ug/l	5.0	1.2	1
Di-n-butylphthalate	0.48	J	ug/l	5.0	0.39	1
Di-n-octylphthalate	ND		ug/l	5.0	1.3	1
Diethyl phthalate	ND		ug/l	5.0	0.38	1
Dimethyl phthalate	ND		ug/l	5.0	1.8	1
Biphenyl	ND		ug/l	2.0	0.46	1
4-Chloroaniline	ND		ug/l	5.0	1.1	1
2-Nitroaniline	ND		ug/l	5.0	0.50	1
3-Nitroaniline	ND		ug/l	5.0	0.81	1
4-Nitroaniline	ND		ug/l	5.0	0.80	1

Project Name: 100 MAIN ST. **Lab Number:** L2341778

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341778-01 Date Collected: 07/20/23 10:45

Client ID: GW-27 Date Received: 07/20/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Dibenzofuran	ND		ug/l	2.0	0.50	1
1,2,4,5-Tetrachlorobenzene	ND		ug/l	10	0.44	1
Acetophenone	ND		ug/l	5.0	0.53	1
2,4,6-Trichlorophenol	ND		ug/l	5.0	0.61	1
p-Chloro-m-cresol	ND		ug/l	2.0	0.35	1
2-Chlorophenol	ND		ug/l	2.0	0.48	1
2,4-Dichlorophenol	ND		ug/l	5.0	0.41	1
2,4-Dimethylphenol	ND		ug/l	5.0	1.8	1
2-Nitrophenol	ND		ug/l	10	0.85	1
4-Nitrophenol	ND		ug/l	10	0.67	1
2,4-Dinitrophenol	ND		ug/l	20	6.6	1
4,6-Dinitro-o-cresol	ND		ug/l	10	1.8	1
Phenol	ND		ug/l	5.0	0.57	1
2-Methylphenol	ND		ug/l	5.0	0.49	1
3-Methylphenol/4-Methylphenol	ND		ug/l	5.0	0.48	1
2,4,5-Trichlorophenol	ND		ug/l	5.0	0.77	1
Benzoic Acid	6.7	J	ug/l	50	2.6	1
Benzyl Alcohol	ND		ug/l	2.0	0.59	1
Carbazole	ND		ug/l	2.0	0.49	1

Project Name: 100 MAIN ST. **Lab Number:** L2341778

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341778-01 Date Collected: 07/20/23 10:45

Client ID: GW-27 Date Received: 07/20/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS - Westborough Lab						
Tentatively Identified Compounds						
Total TIC Compounds	36.8	J	ug/l			1
Unknown Organic Acid	1.67	J	ug/l			1
Unknown Organic Acid	2.98	J	ug/l			1
Unknown	3.16	J	ug/l			1
Unknown Organic Acid	2.62	J	ug/l			1
Unknown	5.38	J	ug/l			1
Unknown Organic Acid	4.80	J	ug/l			1
Unknown Organic Acid	4.98	J	ug/l			1
Unknown Organic Acid	3.82	J	ug/l			1
Unknown	1.60	J	ug/l			1
Unknown	4.29	J	ug/l			1
Unknown	1.49	J	ug/l			1

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	45		21-120
Phenol-d6	39		10-120
Nitrobenzene-d5	55		23-120
2-Fluorobiphenyl	52		15-120
2,4,6-Tribromophenol	45		10-120
4-Terphenyl-d14	44		41-149

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341778
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341778-01
Client ID: GW-27
Sample Location: WHITE PLAINS, NY

Date Collected: 07/20/23 10:45
Date Received: 07/20/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8270E-SIM
Analytical Date: 07/21/23 10:30
Analyst: RP

Extraction Method: EPA 3510C
Extraction Date: 07/21/23 02:50

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS-SIM - Westborough Lab						
Acenaphthene	0.02	J	ug/l	0.10	0.01	1
2-Chloronaphthalene	ND		ug/l	0.20	0.02	1
Fluoranthene	0.07	J	ug/l	0.10	0.02	1
Hexachlorobutadiene	ND		ug/l	0.50	0.05	1
Naphthalene	ND		ug/l	0.10	0.05	1
Benzo(a)anthracene	0.04	J	ug/l	0.10	0.02	1
Benzo(a)pyrene	0.04	J	ug/l	0.10	0.02	1
Benzo(b)fluoranthene	0.04	J	ug/l	0.10	0.01	1
Benzo(k)fluoranthene	0.04	J	ug/l	0.10	0.01	1
Chrysene	0.03	J	ug/l	0.10	0.01	1
Acenaphthylene	0.03	J	ug/l	0.10	0.01	1
Anthracene	0.05	J	ug/l	0.10	0.01	1
Benzo(ghi)perylene	0.03	J	ug/l	0.10	0.01	1
Fluorene	0.04	J	ug/l	0.10	0.01	1
Phenanthrene	0.08	J	ug/l	0.10	0.02	1
Dibenzo(a,h)anthracene	0.03	J	ug/l	0.10	0.01	1
Indeno(1,2,3-cd)pyrene	0.03	J	ug/l	0.10	0.01	1
Pyrene	0.07	J	ug/l	0.10	0.02	1
2-Methylnaphthalene	ND		ug/l	0.10	0.02	1
Pentachlorophenol	0.26	J	ug/l	0.80	0.01	1
Hexachlorobenzene	0.04	J	ug/l	0.80	0.01	1
Hexachloroethane	ND		ug/l	0.80	0.06	1

Project Name: 100 MAIN ST. **Lab Number:** L2341778

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341778-01 Date Collected: 07/20/23 10:45

Client ID: GW-27 Date Received: 07/20/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor
Semivolatile Organics by GC/MS-SIM - Westborough Lab						

Surrogate	% Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	59		21-120
Phenol-d6	57		10-120
Nitrobenzene-d5	99		23-120
2-Fluorobiphenyl	81		15-120
2,4,6-Tribromophenol	**154**	Q	10-120
4-Terphenyl-d14	73		41-149

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341778
Report Date: 07/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E-SIM
Analytical Date: 07/21/23 12:10
Analyst: RP

Extraction Method: EPA 3510C
Extraction Date: 07/20/23 11:58

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS-SIM - Westborough Lab for sample(s): 01 Batch: WG1805593-1					
Acenaphthene	0.02	J	ug/l	0.10	0.01
2-Chloronaphthalene	ND		ug/l	0.20	0.02
Fluoranthene	ND		ug/l	0.10	0.02
Hexachlorobutadiene	ND		ug/l	0.50	0.05
Naphthalene	0.89		ug/l	0.10	0.05
Benzo(a)anthracene	ND		ug/l	0.10	0.02
Benzo(a)pyrene	ND		ug/l	0.10	0.02
Benzo(b)fluoranthene	ND		ug/l	0.10	0.01
Benzo(k)fluoranthene	ND		ug/l	0.10	0.01
Chrysene	ND		ug/l	0.10	0.01
Acenaphthylene	ND		ug/l	0.10	0.01
Anthracene	ND		ug/l	0.10	0.01
Benzo(ghi)perylene	ND		ug/l	0.10	0.01
Fluorene	ND		ug/l	0.10	0.01
Phenanthrene	ND		ug/l	0.10	0.02
Dibenzo(a,h)anthracene	ND		ug/l	0.10	0.01
Indeno(1,2,3-cd)pyrene	ND		ug/l	0.10	0.01
Pyrene	ND		ug/l	0.10	0.02
2-Methylnaphthalene	0.06	J	ug/l	0.10	0.02
Pentachlorophenol	ND		ug/l	0.80	0.01
Hexachlorobenzene	ND		ug/l	0.80	0.01
Hexachloroethane	ND		ug/l	0.80	0.06

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341778
Report Date: 07/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E-SIM
Analytical Date: 07/21/23 12:10
Analyst: RP

Extraction Method: EPA 3510C
Extraction Date: 07/20/23 11:58

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS-SIM - Westborough Lab for sample(s): 01 Batch: WG1805593-1					

Surrogate	%Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	42		21-120
Phenol-d6	35		10-120
Nitrobenzene-d5	64		23-120
2-Fluorobiphenyl	55		15-120
2,4,6-Tribromophenol	99		10-120
4-Terphenyl-d14	58		41-149

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341778
Report Date: 07/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 07/20/23 22:00
Analyst: JG

Extraction Method: EPA 3510C
Extraction Date: 07/20/23 14:22

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 01 Batch: WG1805644-1					
Acenaphthene	ND		ug/l	2.0	0.44
1,2,4-Trichlorobenzene	ND		ug/l	5.0	0.50
Hexachlorobenzene	ND		ug/l	2.0	0.46
Bis(2-chloroethyl)ether	ND		ug/l	2.0	0.50
2-Chloronaphthalene	ND		ug/l	2.0	0.44
1,2-Dichlorobenzene	ND		ug/l	2.0	0.45
1,3-Dichlorobenzene	ND		ug/l	2.0	0.40
1,4-Dichlorobenzene	ND		ug/l	2.0	0.43
3,3'-Dichlorobenzidine	ND		ug/l	5.0	1.6
2,4-Dinitrotoluene	ND		ug/l	5.0	1.2
2,6-Dinitrotoluene	ND		ug/l	5.0	0.93
Fluoranthene	ND		ug/l	2.0	0.26
4-Chlorophenyl phenyl ether	ND		ug/l	2.0	0.49
4-Bromophenyl phenyl ether	ND		ug/l	2.0	0.38
Bis(2-chloroisopropyl)ether	ND		ug/l	2.0	0.53
Bis(2-chloroethoxy)methane	ND		ug/l	5.0	0.50
Hexachlorobutadiene	ND		ug/l	2.0	0.66
Hexachlorocyclopentadiene	ND		ug/l	20	0.69
Hexachloroethane	ND		ug/l	2.0	0.58
Isophorone	ND		ug/l	5.0	1.2
Naphthalene	1.2	J	ug/l	2.0	0.46
Nitrobenzene	ND		ug/l	2.0	0.77
NDPA/DPA	ND		ug/l	2.0	0.42
n-Nitrosodi-n-propylamine	ND		ug/l	5.0	0.64
Bis(2-ethylhexyl)phthalate	ND		ug/l	3.0	1.5
Butyl benzyl phthalate	ND		ug/l	5.0	1.2
Di-n-butylphthalate	ND		ug/l	5.0	0.39
Di-n-octylphthalate	ND		ug/l	5.0	1.3
Diethyl phthalate	ND		ug/l	5.0	0.38

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341778
Report Date: 07/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 07/20/23 22:00
Analyst: JG

Extraction Method: EPA 3510C
Extraction Date: 07/20/23 14:22

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 01 Batch: WG1805644-1					
Dimethyl phthalate	ND		ug/l	5.0	1.8
Benzo(a)anthracene	ND		ug/l	2.0	0.32
Benzo(a)pyrene	ND		ug/l	2.0	0.41
Benzo(b)fluoranthene	ND		ug/l	2.0	0.35
Benzo(k)fluoranthene	ND		ug/l	2.0	0.37
Chrysene	ND		ug/l	2.0	0.34
Acenaphthylene	ND		ug/l	2.0	0.46
Anthracene	ND		ug/l	2.0	0.33
Benzo(ghi)perylene	ND		ug/l	2.0	0.30
Fluorene	ND		ug/l	2.0	0.41
Phenanthrene	ND		ug/l	2.0	0.33
Dibenzo(a,h)anthracene	ND		ug/l	2.0	0.32
Indeno(1,2,3-cd)pyrene	ND		ug/l	2.0	0.40
Pyrene	ND		ug/l	2.0	0.28
Biphenyl	ND		ug/l	2.0	0.46
4-Chloroaniline	ND		ug/l	5.0	1.1
2-Nitroaniline	ND		ug/l	5.0	0.50
3-Nitroaniline	ND		ug/l	5.0	0.81
4-Nitroaniline	ND		ug/l	5.0	0.80
Dibenzofuran	ND		ug/l	2.0	0.50
2-Methylnaphthalene	ND		ug/l	2.0	0.45
1,2,4,5-Tetrachlorobenzene	ND		ug/l	10	0.44
Acetophenone	ND		ug/l	5.0	0.53
2,4,6-Trichlorophenol	ND		ug/l	5.0	0.61
p-Chloro-m-cresol	ND		ug/l	2.0	0.35
2-Chlorophenol	ND		ug/l	2.0	0.48
2,4-Dichlorophenol	ND		ug/l	5.0	0.41
2,4-Dimethylphenol	ND		ug/l	5.0	1.8
2-Nitrophenol	ND		ug/l	10	0.85

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341778
Report Date: 07/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 07/20/23 22:00
Analyst: JG

Extraction Method: EPA 3510C
Extraction Date: 07/20/23 14:22

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 01 Batch: WG1805644-1					
4-Nitrophenol	ND		ug/l	10	0.67
2,4-Dinitrophenol	ND		ug/l	20	6.6
4,6-Dinitro-o-cresol	ND		ug/l	10	1.8
Pentachlorophenol	ND		ug/l	10	1.8
Phenol	ND		ug/l	5.0	0.57
2-Methylphenol	ND		ug/l	5.0	0.49
3-Methylphenol/4-Methylphenol	ND		ug/l	5.0	0.48
2,4,5-Trichlorophenol	ND		ug/l	5.0	0.77
Benzoic Acid	ND		ug/l	50	2.6
Benzyl Alcohol	ND		ug/l	2.0	0.59
Carbazole	ND		ug/l	2.0	0.49

Tentatively Identified Compounds			
Total TIC Compounds	16.8	J	ug/l
Unknown	4.65	J	ug/l
Unknown	6.22	J	ug/l
Unknown Organic Acid	4.04	J	ug/l
Unknown	1.93	J	ug/l

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341778
Report Date: 07/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8270E
Analytical Date: 07/20/23 22:00
Analyst: JG

Extraction Method: EPA 3510C
Extraction Date: 07/20/23 14:22

Parameter	Result	Qualifier	Units	RL	MDL
Semivolatile Organics by GC/MS - Westborough Lab for sample(s): 01 Batch: WG1805644-1					

Surrogate	%Recovery	Qualifier	Acceptance Criteria
2-Fluorophenol	50		21-120
Phenol-d6	40		10-120
Nitrobenzene-d5	54		23-120
2-Fluorobiphenyl	61		15-120
2,4,6-Tribromophenol	77		10-120
4-Terphenyl-d14	64		41-149

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341778
Report Date: 07/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS-SIM - Westborough Lab Associated sample(s): 01 Batch: WG1805593-2 WG1805593-3								
Acenaphthene	71		67		40-140	6		40
2-Chloronaphthalene	77		73		40-140	5		40
Fluoranthene	88		85		40-140	3		40
Hexachlorobutadiene	84		79		40-140	6		40
Naphthalene	75		71		40-140	5		40
Benzo(a)anthracene	88		84		40-140	5		40
Benzo(a)pyrene	91		89		40-140	2		40
Benzo(b)fluoranthene	86		81		40-140	6		40
Benzo(k)fluoranthene	88		88		40-140	0		40
Chrysene	80		76		40-140	5		40
Acenaphthylene	86		82		40-140	5		40
Anthracene	82		78		40-140	5		40
Benzo(ghi)perylene	83		80		40-140	4		40
Fluorene	79		75		40-140	5		40
Phenanthrene	72		68		40-140	6		40
Dibenzo(a,h)anthracene	82		79		40-140	4		40
Indeno(1,2,3-cd)pyrene	84		80		40-140	5		40
Pyrene	86		82		40-140	5		40
2-Methylnaphthalene	75		71		40-140	5		40
Pentachlorophenol	116		103		40-140	12		40
Hexachlorobenzene	88		83		40-140	6		40
Hexachloroethane	67		64		40-140	5		40

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341778
Report Date: 07/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS-SIM - Westborough Lab Associated sample(s): 01 Batch: WG1805593-2 WG1805593-3								

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
2-Fluorophenol	59		59		21-120
Phenol-d6	53		53		10-120
Nitrobenzene-d5	83		81		23-120
2-Fluorobiphenyl	74		71		15-120
2,4,6-Tribromophenol	**143**	Q	**140**	Q	10-120
4-Terphenyl-d14	74		72		41-149

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341778
Report Date: 07/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 01 Batch: WG1805644-2 WG1805644-3								
Acenaphthene	76		67		37-111	13		30
1,2,4-Trichlorobenzene	74		65		39-98	13		30
Hexachlorobenzene	80		74		40-140	8		30
Bis(2-chloroethyl)ether	80		66		40-140	19		30
2-Chloronaphthalene	75		68		40-140	10		30
1,2-Dichlorobenzene	75		62		40-140	19		30
1,3-Dichlorobenzene	74		57		40-140	26		30
1,4-Dichlorobenzene	79		63		36-97	23		30
3,3'-Dichlorobenzidine	69		69		40-140	0		30
2,4-Dinitrotoluene	86		75		48-143	14		30
2,6-Dinitrotoluene	83		78		40-140	6		30
Fluoranthene	84		72		40-140	15		30
4-Chlorophenyl phenyl ether	78		68		40-140	14		30
4-Bromophenyl phenyl ether	85		74		40-140	14		30
Bis(2-chloroisopropyl)ether	70		59		40-140	17		30
Bis(2-chloroethoxy)methane	88		71		40-140	21		30
Hexachlorobutadiene	70		64		40-140	9		30
Hexachlorocyclopentadiene	60		51		40-140	16		30
Hexachloroethane	82		73		40-140	12		30
Isophorone	80		69		40-140	15		30
Naphthalene	85		77		40-140	10		30
Nitrobenzene	89		72		40-140	21		30
NDPA/DPA	80		68		40-140	16		30

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341778
Report Date: 07/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 01 Batch: WG1805644-2 WG1805644-3								
n-Nitrosodi-n-propylamine	97		78		29-132	22		30
Bis(2-ethylhexyl)phthalate	109		98		40-140	11		30
Butyl benzyl phthalate	103		86		40-140	18		30
Di-n-butylphthalate	92		83		40-140	10		30
Di-n-octylphthalate	97		91		40-140	6		30
Diethyl phthalate	94		82		40-140	14		30
Dimethyl phthalate	90		79		40-140	13		30
Benzo(a)anthracene	82		76		40-140	8		30
Benzo(a)pyrene	90		80		40-140	12		30
Benzo(b)fluoranthene	86		79		40-140	8		30
Benzo(k)fluoranthene	84		78		40-140	7		30
Chrysene	84		78		40-140	7		30
Acenaphthylene	83		77		45-123	8		30
Anthracene	83		73		40-140	13		30
Benzo(ghi)perylene	84		79		40-140	6		30
Fluorene	80		70		40-140	13		30
Phenanthrene	82		69		40-140	17		30
Dibenzo(a,h)anthracene	79		76		40-140	4		30
Indeno(1,2,3-cd)pyrene	78		73		40-140	7		30
Pyrene	82		73		26-127	12		30
Biphenyl	69		65		40-140	6		30
4-Chloroaniline	75		89		40-140	17		30
2-Nitroaniline	89		83		52-143	7		30

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341778
Report Date: 07/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 01 Batch: WG1805644-2 WG1805644-3								
3-Nitroaniline	77		72		25-145	7		30
4-Nitroaniline	84		77		51-143	9		30
Dibenzofuran	79		71		40-140	11		30
2-Methylnaphthalene	75		71		40-140	5		30
1,2,4,5-Tetrachlorobenzene	68		60		2-134	13		30
Acetophenone	76		64		39-129	17		30
2,4,6-Trichlorophenol	83		76		30-130	9		30
p-Chloro-m-cresol	90		90		23-97	0		30
2-Chlorophenol	80		68		27-123	16		30
2,4-Dichlorophenol	89		76		30-130	16		30
2,4-Dimethylphenol	85		76		30-130	11		30
2-Nitrophenol	88		73		30-130	19		30
4-Nitrophenol	**93**	Q	**90**	Q	10-80	3		30
2,4-Dinitrophenol	88		87		20-130	1		30
4,6-Dinitro-o-cresol	100		86		20-164	15		30
Pentachlorophenol	96		87		9-103	10		30
Phenol	59		50		12-110	17		30
2-Methylphenol	84		70		30-130	18		30
3-Methylphenol/4-Methylphenol	94		82		30-130	14		30
2,4,5-Trichlorophenol	94		85		30-130	10		30
Benzoic Acid	66		**0**	Q	10-164	NC		30
Benzyl Alcohol	82		71		26-116	14		30
Carbazole	88		78		55-144	12		30

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2341778

Report Date: 07/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits

Semivolatile Organics by GC/MS - Westborough Lab Associated sample(s): 01 Batch: WG1805644-2 WG1805644-3

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria
2-Fluorophenol	68		59		21-120
Phenol-d6	60		50		10-120
Nitrobenzene-d5	80		68		23-120
2-Fluorobiphenyl	74		66		15-120
2,4,6-Tribromophenol	101		89		10-120
4-Terphenyl-d14	75		67		41-149

PCBS

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341778
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341778-01
Client ID: GW-27
Sample Location: WHITE PLAINS, NY

Date Collected: 07/20/23 10:45
Date Received: 07/20/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8082A
Analytical Date: 07/21/23 10:36
Analyst: MEO

Extraction Method: EPA 3510C
Extraction Date: 07/21/23 01:51
Cleanup Method: EPA 3665A
Cleanup Date: 07/21/23
Cleanup Method: EPA 3660B
Cleanup Date: 07/21/23

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Polychlorinated Biphenyls by GC - Westborough Lab							
Aroclor 1016	ND		ug/l	0.071	0.061	1	A
Aroclor 1221	ND		ug/l	0.071	0.061	1	A
Aroclor 1232	ND		ug/l	0.071	0.061	1	A
Aroclor 1242	ND		ug/l	0.071	0.061	1	A
Aroclor 1248	ND		ug/l	0.071	0.061	1	A
Aroclor 1254	ND		ug/l	0.071	0.061	1	A
Aroclor 1260	ND		ug/l	0.071	0.061	1	A
Aroclor 1262	ND		ug/l	0.071	0.061	1	A
Aroclor 1268	ND		ug/l	0.071	0.061	1	A
PCBs, Total	ND		ug/l	0.071	0.061	1	A

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	64		30-150	A
Decachlorobiphenyl	58		30-150	A
2,4,5,6-Tetrachloro-m-xylene	59		30-150	B
Decachlorobiphenyl	52		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341778
Report Date: 07/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8082A
Analytical Date: 07/21/23 08:06
Analyst: MEO

Extraction Method: EPA 3510C
Extraction Date: 07/20/23 23:00
Cleanup Method: EPA 3665A
Cleanup Date: 07/21/23
Cleanup Method: EPA 3660B
Cleanup Date: 07/21/23

Parameter	Result	Qualifier	Units	RL	MDL	Column
Polychlorinated Biphenyls by GC - Westborough Lab for sample(s): 01 Batch: WG1805781-1						
Aroclor 1016	ND		ug/l	0.071	0.061	A
Aroclor 1221	ND		ug/l	0.071	0.061	A
Aroclor 1232	ND		ug/l	0.071	0.061	A
Aroclor 1242	ND		ug/l	0.071	0.061	A
Aroclor 1248	ND		ug/l	0.071	0.061	A
Aroclor 1254	ND		ug/l	0.071	0.061	A
Aroclor 1260	ND		ug/l	0.071	0.061	A
Aroclor 1262	ND		ug/l	0.071	0.061	A
Aroclor 1268	ND		ug/l	0.071	0.061	A
PCBs, Total	ND		ug/l	0.071	0.061	A

Surrogate	%Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	65		30-150	A
Decachlorobiphenyl	84		30-150	A
2,4,5,6-Tetrachloro-m-xylene	55		30-150	B
Decachlorobiphenyl	72		30-150	B

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341778
Report Date: 07/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits	Column
Polychlorinated Biphenyls by GC - Westborough Lab Associated sample(s): 01 Batch: WG1805781-2 WG1805781-3									
Aroclor 1016	73		73		40-140	0		50	A
Aroclor 1260	76		77		40-140	2		50	A

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	64		63		30-150	A
Decachlorobiphenyl	80		77		30-150	A
2,4,5,6-Tetrachloro-m-xylene	58		58		30-150	B
Decachlorobiphenyl	74		73		30-150	B

PESTICIDES

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341778
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341778-01
Client ID: GW-27
Sample Location: WHITE PLAINS, NY

Date Collected: 07/20/23 10:45
Date Received: 07/20/23
Field Prep: Not Specified

Sample Depth:
Matrix: Water
Analytical Method: 1,8081B
Analytical Date: 07/21/23 10:35
Analyst: AKM

Extraction Method: EPA 3510C
Extraction Date: 07/21/23 01:48

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							
Delta-BHC	ND		ug/l	0.014	0.003	1	A
Lindane	ND		ug/l	0.014	0.003	1	A
Alpha-BHC	ND		ug/l	0.014	0.003	1	A
Beta-BHC	ND		ug/l	0.014	0.004	1	A
Heptachlor	ND		ug/l	0.014	0.002	1	A
Aldrin	ND		ug/l	0.014	0.002	1	A
Heptachlor epoxide	ND		ug/l	0.014	0.003	1	A
Endrin	ND		ug/l	0.029	0.003	1	A
Endrin aldehyde	ND		ug/l	0.029	0.006	1	A
Endrin ketone	ND		ug/l	0.029	0.003	1	A
Dieldrin	ND		ug/l	0.029	0.003	1	A
4,4'-DDE	ND		ug/l	0.029	0.003	1	A
4,4'-DDD	ND		ug/l	0.029	0.003	1	A
4,4'-DDT	ND		ug/l	0.029	0.003	1	A
Endosulfan I	ND		ug/l	0.014	0.002	1	A
Endosulfan II	ND		ug/l	0.029	0.004	1	A
Endosulfan sulfate	ND		ug/l	0.029	0.003	1	A
Methoxychlor	ND		ug/l	0.143	0.005	1	A
Toxaphene	ND		ug/l	0.143	0.045	1	A
cis-Chlordane	ND		ug/l	0.014	0.005	1	A
trans-Chlordane	ND		ug/l	0.014	0.004	1	A
Chlordane	ND		ug/l	0.143	0.033	1	A

Project Name: 100 MAIN ST. **Lab Number:** L2341778

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341778-01 Date Collected: 07/20/23 10:45

Client ID: GW-27 Date Received: 07/20/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Column
Organochlorine Pesticides by GC - Westborough Lab							

Surrogate	% Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	68		30-150	A
Decachlorobiphenyl	61		30-150	A
2,4,5,6-Tetrachloro-m-xylene	66		30-150	B
Decachlorobiphenyl	59		30-150	B

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341778
Report Date: 07/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8081B
Analytical Date: 07/20/23 14:34
Analyst: MMG

Extraction Method: EPA 3510C
Extraction Date: 07/20/23 05:40

Parameter	Result	Qualifier	Units	RL	MDL	Column
Organochlorine Pesticides by GC - Westborough Lab for sample(s): 01 Batch: WG1805342-1						
Delta-BHC	ND		ug/l	0.014	0.003	A
Lindane	ND		ug/l	0.014	0.003	A
Alpha-BHC	ND		ug/l	0.014	0.003	A
Beta-BHC	ND		ug/l	0.014	0.004	A
Heptachlor	ND		ug/l	0.014	0.002	A
Aldrin	ND		ug/l	0.014	0.002	A
Heptachlor epoxide	ND		ug/l	0.014	0.003	A
Endrin	ND		ug/l	0.029	0.003	A
Endrin aldehyde	ND		ug/l	0.029	0.006	A
Endrin ketone	ND		ug/l	0.029	0.003	A
Dieldrin	ND		ug/l	0.029	0.003	A
4,4'-DDE	ND		ug/l	0.029	0.003	A
4,4'-DDD	ND		ug/l	0.029	0.003	A
4,4'-DDT	ND		ug/l	0.029	0.003	A
Endosulfan I	ND		ug/l	0.014	0.002	A
Endosulfan II	ND		ug/l	0.029	0.004	A
Endosulfan sulfate	ND		ug/l	0.029	0.003	A
Methoxychlor	ND		ug/l	0.143	0.005	A
Toxaphene	ND		ug/l	0.143	0.045	A
cis-Chlordane	ND		ug/l	0.014	0.005	A
trans-Chlordane	ND		ug/l	0.014	0.004	A
Chlordane	ND		ug/l	0.143	0.033	A

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341778
Report Date: 07/24/23

Method Blank Analysis
Batch Quality Control

Analytical Method: 1,8081B
Analytical Date: 07/20/23 14:34
Analyst: MMG

Extraction Method: EPA 3510C
Extraction Date: 07/20/23 05:40

Parameter	Result	Qualifier	Units	RL	MDL	Column
Organochlorine Pesticides by GC - Westborough Lab for sample(s): 01 Batch: WG1805342-1						

Surrogate	%Recovery	Qualifier	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	74		30-150	A
Decachlorobiphenyl	92		30-150	A
2,4,5,6-Tetrachloro-m-xylene	75		30-150	B
Decachlorobiphenyl	87		30-150	B

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341778
Report Date: 07/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits	Column
Organochlorine Pesticides by GC - Westborough Lab Associated sample(s): 01 Batch: WG1805342-2 WG1805342-3									
Delta-BHC	80		84		30-150	5		20	A
Lindane	79		83		30-150	5		20	A
Alpha-BHC	88		83		30-150	6		20	A
Beta-BHC	83		87		30-150	5		20	A
Heptachlor	81		85		30-150	5		20	A
Aldrin	76		80		30-150	6		20	A
Heptachlor epoxide	78		82		30-150	5		20	A
Endrin	78		85		30-150	9		20	A
Endrin aldehyde	76		82		30-150	8		20	A
Endrin ketone	89		96		30-150	7		20	A
Dieldrin	82		88		30-150	7		20	A
4,4'-DDE	77		85		30-150	9		20	A
4,4'-DDD	88		95		30-150	7		20	A
4,4'-DDT	89		99		30-150	10		20	A
Endosulfan I	101		83		30-150	19		20	A
Endosulfan II	80		87		30-150	8		20	A
Endosulfan sulfate	78		85		30-150	8		20	A
Methoxychlor	96		100		30-150	4		20	A
cis-Chlordane	68		74		30-150	8		20	A
trans-Chlordane	91		89		30-150	2		20	A

Lab Control Sample Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341778
Report Date: 07/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Organochlorine Pesticides by GC - Westborough Lab Associated sample(s): 01 Batch: WG1805342-2 WG1805342-3								

Surrogate	LCS %Recovery	Qual	LCSD %Recovery	Qual	Acceptance Criteria	Column
2,4,5,6-Tetrachloro-m-xylene	73		77		30-150	A
Decachlorobiphenyl	91		96		30-150	A
2,4,5,6-Tetrachloro-m-xylene	75		75		30-150	B
Decachlorobiphenyl	102		92		30-150	B

METALS

Project Name: 100 MAIN ST. **Lab Number:** L2341778

Project Number: 12461 **Report Date:** 07/24/23

SAMPLE RESULTS

Lab ID: L2341778-01 Date Collected: 07/20/23 10:45

Client ID: GW-27 Date Received: 07/20/23

Sample Location: WHITE PLAINS, NY Field Prep: Not Specified

Sample Depth:

Matrix: Water

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Aluminum, Total	92.3		mg/l	0.0100	0.00327	1	07/21/23 09:47	07/21/23 14:41	EPA 3005A	1,6020B	EJF
Antimony, Total	ND		mg/l	0.00400	0.00042	1	07/21/23 09:47	07/21/23 14:41	EPA 3005A	1,6020B	EJF
Arsenic, Total	0.00874		mg/l	0.00050	0.00016	1	07/21/23 09:47	07/21/23 14:41	EPA 3005A	1,6020B	EJF
Barium, Total	1.833		mg/l	0.00050	0.00017	1	07/21/23 09:47	07/21/23 14:41	EPA 3005A	1,6020B	EJF
Beryllium, Total	0.00346		mg/l	0.00050	0.00010	1	07/21/23 09:47	07/21/23 14:41	EPA 3005A	1,6020B	EJF
Cadmium, Total	0.00139		mg/l	0.00020	0.00005	1	07/21/23 09:47	07/21/23 14:41	EPA 3005A	1,6020B	EJF
Calcium, Total	354.		mg/l	0.100	0.0394	1	07/21/23 09:47	07/21/23 13:49	EPA 3005A	1,6020B	EJF
Chromium, Total	0.2250		mg/l	0.00100	0.00017	1	07/21/23 09:47	07/21/23 14:41	EPA 3005A	1,6020B	EJF
Cobalt, Total	0.1397		mg/l	0.00050	0.00016	1	07/21/23 09:47	07/21/23 14:41	EPA 3005A	1,6020B	EJF
Copper, Total	0.5798		mg/l	0.00100	0.00038	1	07/21/23 09:47	07/21/23 14:41	EPA 3005A	1,6020B	EJF
Iron, Total	154.		mg/l	0.0500	0.0191	1	07/21/23 09:47	07/21/23 14:41	EPA 3005A	1,6020B	EJF
Lead, Total	0.09506		mg/l	0.00100	0.00034	1	07/21/23 09:47	07/21/23 14:41	EPA 3005A	1,6020B	EJF
Magnesium, Total	201.		mg/l	0.0700	0.0242	1	07/21/23 09:47	07/21/23 14:41	EPA 3005A	1,6020B	EJF
Manganese, Total	3.440		mg/l	0.00100	0.00044	1	07/21/23 09:47	07/21/23 14:41	EPA 3005A	1,6020B	EJF
Mercury, Total	ND		mg/l	0.00020	0.00009	1	07/21/23 09:19	07/21/23 13:17	EPA 7470A	1,7470A	GMG
Nickel, Total	0.2469		mg/l	0.00200	0.00055	1	07/21/23 09:47	07/21/23 14:41	EPA 3005A	1,6020B	EJF
Potassium, Total	48.3		mg/l	0.100	0.0309	1	07/21/23 09:47	07/21/23 14:41	EPA 3005A	1,6020B	EJF
Selenium, Total	0.0201		mg/l	0.00500	0.00173	1	07/21/23 09:47	07/21/23 14:41	EPA 3005A	1,6020B	EJF
Silver, Total	0.00093		mg/l	0.00040	0.00016	1	07/21/23 09:47	07/21/23 14:41	EPA 3005A	1,6020B	EJF
Sodium, Total	206.		mg/l	0.100	0.0293	1	07/21/23 09:47	07/21/23 14:41	EPA 3005A	1,6020B	EJF
Thallium, Total	0.00152		mg/l	0.00100	0.00014	1	07/21/23 09:47	07/21/23 14:41	EPA 3005A	1,6020B	EJF
Vanadium, Total	0.1714		mg/l	0.02500	0.00785	5	07/21/23 09:47	07/21/23 15:53	EPA 3005A	1,6020B	EJF
Zinc, Total	0.6041		mg/l	0.01000	0.00341	1	07/21/23 09:47	07/21/23 14:41	EPA 3005A	1,6020B	EJF

Project Name: 100 MAIN ST. **Lab Number:** L2341778

Project Number: 12461 **Report Date:** 07/24/23

Method Blank Analysis
Batch Quality Control

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
Total Metals - Mansfield Lab for sample(s): 01 Batch: WG1805856-1										
Aluminum, Total	ND		mg/l	0.0100	0.00327	1	07/21/23 09:47	07/21/23 15:17	1,6020B	EJF
Antimony, Total	ND		mg/l	0.00400	0.00042	1	07/21/23 09:47	07/21/23 15:17	1,6020B	EJF
Arsenic, Total	ND		mg/l	0.00050	0.00016	1	07/21/23 09:47	07/21/23 15:17	1,6020B	EJF
Barium, Total	ND		mg/l	0.00050	0.00017	1	07/21/23 09:47	07/21/23 15:17	1,6020B	EJF
Beryllium, Total	ND		mg/l	0.00050	0.00010	1	07/21/23 09:47	07/21/23 15:17	1,6020B	EJF
Cadmium, Total	ND		mg/l	0.00020	0.00005	1	07/21/23 09:47	07/21/23 15:17	1,6020B	EJF
Calcium, Total	ND		mg/l	0.100	0.0394	1	07/21/23 09:47	07/21/23 13:31	1,6020B	EJF
Chromium, Total	ND		mg/l	0.00100	0.00017	1	07/21/23 09:47	07/21/23 15:17	1,6020B	EJF
Cobalt, Total	ND		mg/l	0.00050	0.00016	1	07/21/23 09:47	07/21/23 15:17	1,6020B	EJF
Copper, Total	ND		mg/l	0.00100	0.00038	1	07/21/23 09:47	07/21/23 15:17	1,6020B	EJF
Iron, Total	ND		mg/l	0.0500	0.0191	1	07/21/23 09:47	07/21/23 15:17	1,6020B	EJF
Lead, Total	ND		mg/l	0.00100	0.00034	1	07/21/23 09:47	07/21/23 15:17	1,6020B	EJF
Magnesium, Total	ND		mg/l	0.0700	0.0242	1	07/21/23 09:47	07/21/23 15:17	1,6020B	EJF
Manganese, Total	ND		mg/l	0.00100	0.00044	1	07/21/23 09:47	07/21/23 15:17	1,6020B	EJF
Nickel, Total	ND		mg/l	0.00200	0.00055	1	07/21/23 09:47	07/21/23 15:17	1,6020B	EJF
Potassium, Total	ND		mg/l	0.100	0.0309	1	07/21/23 09:47	07/21/23 15:17	1,6020B	EJF
Selenium, Total	ND		mg/l	0.00500	0.00173	1	07/21/23 09:47	07/21/23 15:17	1,6020B	EJF
Silver, Total	ND		mg/l	0.00040	0.00016	1	07/21/23 09:47	07/21/23 15:17	1,6020B	EJF
Sodium, Total	ND		mg/l	0.100	0.0293	1	07/21/23 09:47	07/21/23 15:17	1,6020B	EJF
Thallium, Total	ND		mg/l	0.00100	0.00014	1	07/21/23 09:47	07/21/23 15:17	1,6020B	EJF
Vanadium, Total	ND		mg/l	0.00500	0.00157	1	07/21/23 09:47	07/21/23 13:31	1,6020B	EJF
Zinc, Total	ND		mg/l	0.01000	0.00341	1	07/21/23 09:47	07/21/23 15:17	1,6020B	EJF

Prep Information

Digestion Method: EPA 3005A

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
Total Metals - Mansfield Lab for sample(s): 01 Batch: WG1805857-1										
Mercury, Total	0.00021		mg/l	0.00020	0.00009	1	07/21/23 09:19	07/21/23 14:55	1,7470A	GMG

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341778
Report Date: 07/24/23

Method Blank Analysis
Batch Quality Control

Prep Information

Digestion Method: EPA 7470A

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2341778

Report Date: 07/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01 Batch: WG1805856-2								
Aluminum, Total	97		-		80-120	-		
Antimony, Total	88		-		80-120	-		
Arsenic, Total	97		-		80-120	-		
Barium, Total	93		-		80-120	-		
Beryllium, Total	97		-		80-120	-		
Cadmium, Total	97		-		80-120	-		
Calcium, Total	87		-		80-120	-		
Chromium, Total	94		-		80-120	-		
Cobalt, Total	94		-		80-120	-		
Copper, Total	97		-		80-120	-		
Iron, Total	100		-		80-120	-		
Lead, Total	95		-		80-120	-		
Magnesium, Total	96		-		80-120	-		
Manganese, Total	95		-		80-120	-		
Nickel, Total	94		-		80-120	-		
Potassium, Total	94		-		80-120	-		
Selenium, Total	92		-		80-120	-		
Silver, Total	94		-		80-120	-		
Sodium, Total	95		-		80-120	-		
Thallium, Total	95		-		80-120	-		
Vanadium, Total	96		-		80-120	-		

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2341778

Report Date: 07/24/23

Parameter	LCS %Recovery	LCSD %Recovery	%Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01 Batch: WG1805856-2					
Zinc, Total	92	-	80-120	-	
Total Metals - Mansfield Lab Associated sample(s): 01 Batch: WG1805857-2					
Mercury, Total	119	-	80-120	-	

Matrix Spike Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341778
Report Date: 07/24/23

Parameter	Native Sample	MS Added	MS Found	MS %Recovery	Qual	MSD Found	MSD %Recovery	Qual	Recovery Limits	RPD	Qual	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01 QC Batch ID: WG1805856-3 QC Sample: L2341875-01 Client ID: MS Sample												
Aluminum, Total	0.084	2	2.01	96		-	-		75-125	-		20
Antimony, Total	0.0065	0.5	0.4870	96		-	-		75-125	-		20
Arsenic, Total	0.0219	0.12	0.1407	99		-	-		75-125	-		20
Barium, Total	0.0100	2	1.942	97		-	-		75-125	-		20
Beryllium, Total	ND	0.05	0.05059	101		-	-		75-125	-		20
Cadmium, Total	ND	0.053	0.05321	100		-	-		75-125	-		20
Calcium, Total	25.8	10	33.9	81		-	-		75-125	-		20
Chromium, Total	0.0006J	0.2	0.2023	101		-	-		75-125	-		20
Cobalt, Total	0.0004J	0.5	0.4864	97		-	-		75-125	-		20
Copper, Total	0.0070	0.25	0.2573	100		-	-		75-125	-		20
Iron, Total	0.219	1	1.23	101		-	-		75-125	-		20
Lead, Total	0.0105	0.53	0.5336	99		-	-		75-125	-		20
Magnesium, Total	5.25	10	14.8	96		-	-		75-125	-		20
Manganese, Total	0.09565	0.5	0.6129	103		-	-		75-125	-		20
Nickel, Total	0.0043	0.5	0.4906	97		-	-		75-125	-		20
Potassium, Total	8.64	10	18.6	100		-	-		75-125	-		20
Selenium, Total	0.002J	0.12	0.130	108		-	-		75-125	-		20
Silver, Total	ND	0.05	0.04706	94		-	-		75-125	-		20
Sodium, Total	143	10	146	**30**	Q	-	-		75-125	-		20
Thallium, Total	0.0002J	0.12	0.1250	104		-	-		75-125	-		20
Vanadium, Total	0.0040J	0.5	0.4998	100		-	-		75-125	-		20

Matrix Spike Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341778
Report Date: 07/24/23

Parameter	Native Sample	MS Added	MS Found	MS %Recovery	MSD Found	MSD %Recovery	Recovery Limits	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01 QC Batch ID: WG1805856-3 QC Sample: L2341875-01 Client ID: MS Sample									
Zinc, Total	0.0901	0.5	0.5716	96	-	-	75-125	-	20
Total Metals - Mansfield Lab Associated sample(s): 01 QC Batch ID: WG1805857-3 QC Sample: L2341778-01 Client ID: GW-27									
Mercury, Total	ND	0.005	0.00498	100	-	-	75-125	-	20

Lab Duplicate Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341778
Report Date: 07/24/23

Parameter	Native Sample	Duplicate Sample	Units	RPD	Qual	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 01 QC Batch ID: WG1805856-4 QC Sample: L2341875-01 Client ID: DUP Sample						
Iron, Total	0.219	0.208	mg/l	5		20
Manganese, Total	0.09565	0.09139	mg/l	5		20
Total Metals - Mansfield Lab Associated sample(s): 01 QC Batch ID: WG1805857-4 QC Sample: L2341778-01 Client ID: GW-27						
Mercury, Total	ND	ND	mg/l	NC		20

INORGANICS
&
MISCELLANEOUS

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341778
Report Date: 07/24/23

SAMPLE RESULTS

Lab ID: L2341778-01
Client ID: GW-27
Sample Location: WHITE PLAINS, NY

Sample Depth:
Matrix: Water

Date Collected: 07/20/23 10:45
Date Received: 07/20/23
Field Prep: Not Specified

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab										
Cyanide, Total	0.002	J	mg/l	0.005	0.001	1	07/21/23 11:55	07/21/23 14:52	1,9010C/9012B	JER

Project Name: 100 MAIN ST.
Project Number: 12461
Lab Number: L2341778
Report Date: 07/24/23

Method Blank Analysis
Batch Quality Control

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
General Chemistry - Westborough Lab for sample(s): 01 Batch: WG1805945-1										
Cyanide, Total	ND		mg/l	0.005	0.001	1	07/21/23 11:55	07/21/23 14:36	1,9010C/9012B	JER

Lab Control Sample Analysis

Batch Quality Control

Project Name: 100 MAIN ST.

Project Number: 12461

Lab Number: L2341778

Report Date: 07/24/23

Parameter	LCS %Recovery	Qual	LCSD %Recovery	Qual	%Recovery Limits	RPD	Qual	RPD Limits
General Chemistry - Westborough Lab Associated sample(s): 01 Batch: WG1805945-2 WG1805945-3								
Cyanide, Total	93		96		85-115	3		20

Matrix Spike Analysis
Batch Quality Control

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341778
Report Date: 07/24/23

Parameter	Native Sample	MS Added	MS Found	MS %Recovery	Qual	MSD Found	MSD %Recovery	Qual	Recovery Limits	RPD	Qual	RPD Limits
General Chemistry - Westborough Lab Associated sample(s): 01 QC Batch ID: WG1805945-4 WG1805945-5 QC Sample: L2341778-01 Client ID: GW-27												
Cyanide, Total	0.002J	0.2	0.207	104		0.043	**22**	Q	80-120	**131**	Q	20

Project Name: 100 MAIN ST.
Project Number: 12461

Lab Number: L2341778
Report Date: 07/24/23

Sample Receipt and Container Information

Were project specific reporting limits specified? YES

Cooler Information

Cooler	Custody Seal
A	Absent

Container Information

Container ID	Container Type	Cooler	Initial pH	Final pH	Temp deg C	Pres	Seal	Frozen Date/Time	Analysis(*)
L2341778-01A	Vial HCl preserved	A	NA		3.3	Y	Absent		NYTCL-8260(14)
L2341778-01B	Vial HCl preserved	A	NA		3.3	Y	Absent		NYTCL-8260(14)
L2341778-01C	Vial HCl preserved	A	NA		3.3	Y	Absent		NYTCL-8260(14)
L2341778-01D	Plastic 250ml HNO3 preserved	A	<2	<2	3.3	Y	Absent		BA-6020T(180),FE-6020T(180),TL-6020T(180),SE-6020T(180),CR-6020T(180),K-6020T(180),NI-6020T(180),CA-6020T(180),CU-6020T(180),ZN-6020T(180),NA-6020T(180),PB-6020T(180),BE-6020T(180),MN-6020T(180),SB-6020T(180),V-6020T(180),AS-6020T(180),AL-6020T(180),HG-T(28),CD-6020T(180),MG-6020T(180),AG-6020T(180),CO-6020T(180)
L2341778-01E	Plastic 250ml NaOH preserved	A	>12	>12	3.3	Y	Absent		TCN-9010(14)
L2341778-01F	Amber 120ml unpreserved	A	7	7	3.3	Y	Absent		NYTCL-8081(7)
L2341778-01G	Amber 120ml unpreserved	A	7	7	3.3	Y	Absent		NYTCL-8081(7)
L2341778-01H	Amber 120ml unpreserved	A	7	7	3.3	Y	Absent		NYTCL-8082-LVI(365)
L2341778-01I	Amber 120ml unpreserved	A	7	7	3.3	Y	Absent		NYTCL-8082-LVI(365)
L2341778-01J	Amber 250ml unpreserved	A	7	7	3.3	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)
L2341778-01K	Amber 250ml unpreserved	A	7	7	3.3	Y	Absent		NYTCL-8270-SIM-LVI(7),NYTCL-8270-LVI(7)

*Values in parentheses indicate holding time in days

Project Name:	100 MAIN ST.	**Lab Number:**	L2341778
Project Number:	12461	**Report Date:**	07/24/23

GLOSSARY

Acronyms

DL	- Detection Limit: This value represents the level to which target analyte concentrations are reported as estimated values, when those target analyte concentrations are quantified below the limit of quantitation (LOQ). The DL includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.)
EDL	- Estimated Detection Limit: This value represents the level to which target analyte concentrations are reported as estimated values, when those target analyte concentrations are quantified below the reporting limit (RL). The EDL includes any adjustments from dilutions, concentrations or moisture content, where applicable. The use of EDLs is specific to the analysis of PAHs using Solid-Phase Microextraction (SPME).
EMPC	- Estimated Maximum Possible Concentration: The concentration that results from the signal present at the retention time of an analyte when the ions meet all of the identification criteria except the ion abundance ratio criteria. An EMPC is a worst-case estimate of the concentration.
EPA	- Environmental Protection Agency.
LCS	- Laboratory Control Sample: A sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes or a material containing known and verified amounts of analytes.
LCSD	- Laboratory Control Sample Duplicate: Refer to LCS.
LFB	- Laboratory Fortified Blank: A sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes or a material containing known and verified amounts of analytes.
LOD	- Limit of Detection: This value represents the level to which a target analyte can reliably be detected for a specific analyte in a specific matrix by a specific method. The LOD includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.)
LOQ	- Limit of Quantitation: The value at which an instrument can accurately measure an analyte at a specific concentration. The LOQ includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.) Limit of Quantitation: The value at which an instrument can accurately measure an analyte at a specific concentration. The LOQ includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.)
MDL	- Method Detection Limit: This value represents the level to which target analyte concentrations are reported as estimated values, when those target analyte concentrations are quantified below the reporting limit (RL). The MDL includes any adjustments from dilutions, concentrations or moisture content, where applicable.
MS	- Matrix Spike Sample: A sample prepared by adding a known mass of target analyte to a specified amount of matrix sample for which an independent estimate of target analyte concentration is available. For Method 332.0, the spike recovery is calculated using the native concentration, including estimated values.
MSD	- Matrix Spike Sample Duplicate: Refer to MS.
NA	- Not Applicable.
NC	- Not Calculated: Term is utilized when one or more of the results utilized in the calculation are non-detect at the parameter's reporting unit.
NDPA/DPA	- N-Nitrosodiphenylamine/Diphenylamine.
NI	- Not Ignitable.
NP	- Non-Plastic: Term is utilized for the analysis of Atterberg Limits in soil.
NR	- No Results: Term is utilized when 'No Target Compounds Requested' is reported for the analysis of Volatile or Semivolatile Organic TIC only requests.
RL	- Reporting Limit: The value at which an instrument can accurately measure an analyte at a specific concentration. The RL includes any adjustments from dilutions, concentrations or moisture content, where applicable.
RPD	- Relative Percent Difference: The results from matrix and/or matrix spike duplicates are primarily designed to assess the precision of analytical results in a given matrix and are expressed as relative percent difference (RPD). Values which are less than five times the reporting limit for any individual parameter are evaluated by utilizing the absolute difference between the values; although the RPD value will be provided in the report.
SRM	- Standard Reference Material: A reference sample of a known or certified value that is of the same or similar matrix as the associated field samples.
STLP	- Semi-dynamic Tank Leaching Procedure per EPA Method 1315.
TEF	- Toxic Equivalency Factors: The values assigned to each dioxin and furan to evaluate their toxicity relative to 2,3,7,8-TCDD.
TEQ	- Toxic Equivalent: The measure of a sample's toxicity derived by multiplying each dioxin and furan by its corresponding TEF and then summing the resulting values.
TIC	- Tentatively Identified Compound: A compound that has been identified to be present and is not part of the target compound list (TCL) for the method and/or program. All TICs are qualitatively identified and reported as estimated concentrations.

Report Format: DU Report with 'J' Qualifiers

Project Name:	100 MAIN ST.	**Lab Number:**	L2341778
Project Number:	12461	**Report Date:**	07/24/23

Footnotes

1 - The reference for this analyte should be considered modified since this analyte is absent from the target analyte list of the original method.

Terms

Analytical Method: Both the document from which the method originates and the analytical reference method. (Example: EPA 8260B is shown as 1,8260B.) The codes for the reference method documents are provided in the References section of the Addendum.

Chlordane: The target compound Chlordane (CAS No. 57-74-9) is reported for GC ECD analyses. Per EPA,this compound "refers to a mixture of chlordane isomers, other chlorinated hydrocarbons and numerous other components." (Reference: USEPA Toxicological Review of Chlordane, In Support of Summary Information on the Integrated Risk Information System (IRIS), December 1997.)

Difference: With respect to Total Oxidizable Precursor (TOP) Assay analysis, the difference is defined as the Post-Treatment value minus the Pre-Treatment value.

Final pH: As it pertains to Sample Receipt & Container Information section of the report, Final pH reflects pH of container determined after adjustment at the laboratory, if applicable. If no adjustment required, value reflects Initial pH.

Frozen Date/Time: With respect to Volatile Organics in soil, Frozen Date/Time reflects the date/time at which associated Reagent Water-preserved vials were initially frozen. Note: If frozen date/time is beyond 48 hours from sample collection, value will be reflected in 'bold'.

Gasoline Range Organics (GRO): Gasoline Range Organics (GRO) results include all chromatographic peaks eluting from Methyl tert butyl ether through Naphthalene, with the exception of GRO analysis in support of State of Ohio programs, which includes all chromatographic peaks eluting from Hexane through Dodecane.

Initial pH: As it pertains to Sample Receipt & Container Information section of the report, Initial pH reflects pH of container determined upon receipt, if applicable.

PAH Total: With respect to Alkylated PAH analyses, the 'PAHs, Total' result is defined as the summation of results for all or a subset of the following compounds: Naphthalene, C1-C4 Naphthalenes, 2-Methylnaphthalene, 1-Methylnaphthalene, Biphenyl, Acenaphthylene, Acenaphthene, Fluorene, C1-C3 Fluorenes, Phenanthrene, C1-C4 Phenanthrenes/Anthracenes, Anthracene, Fluoranthene, Pyrene, C1-C4 Fluoranthenes/Pyrenes, Benz(a)anthracene, Chrysene, C1-C4 Chrysenes, Benzo(b)fluoranthene, Benzo(j)+(k)fluoranthene, Benzo(e)pyrene, Benzo(a)pyrene, Perylene, Indeno(1,2,3-cd)pyrene, Dibenz(ah)+(ac)anthracene, Benzo(g,h,i)perylene. If a 'Total' result is requested, the results of its individual components will also be reported.

PFAS Total: With respect to PFAS analyses, the 'PFAS, Total (5)' result is defined as the summation of results for: PFHpA, PFHxS, PFOA, PFNA and PFOS. In addition, the 'PFAS, Total (6)' result is defined as the summation of results for: PFHpA, PFHxS, PFOA, PFNA, PFDA and PFOS. For MassDEP DW compliance analysis only, the 'PFAS, Total (6)' result is defined as the summation of results at or above the RL. Note: If a 'Total' result is requested, the results of its individual components will also be reported.

Total: With respect to Organic analyses, a 'Total' result is defined as the summation of results for individual isomers or Aroclors. If a 'Total' result is requested, the results of its individual components will also be reported. This is applicable to 'Total' results for methods 8260, 8081 and 8082.

Data Qualifiers

A - Spectra identified as "Aldol Condensates" are byproducts of the extraction/concentration procedures when acetone is introduced in the process.

B - The analyte was detected above the reporting limit in the associated method blank. Flag only applies to associated field samples that have detectable concentrations of the analyte at less than ten times (10x) the concentration found in the blank. For MCP-related projects, flag only applies to associated field samples that have detectable concentrations of the analyte at less than ten times (10x) the concentration found in the blank. For DOD-related projects, flag only applies to associated field samples that have detectable concentrations of the analyte at less than ten times (10x) the concentration found in the blank AND the analyte was detected above one-half the reporting limit (or above the reporting limit for common lab contaminants) in the associated method blank. For NJ-Air-related projects, flag only applies to associated field samples that have detectable concentrations of the analyte above the reporting limit. For NJ-related projects (excluding Air), flag only applies to associated field samples that have detectable concentrations of the analyte, which was detected above the reporting limit in the associated method blank or above five times the reporting limit for common lab contaminants (Phthalates, Acetone, Methylene Chloride, 2-Butanone).

C - Co-elution: The target analyte co-elutes with a known lab standard (i.e. surrogate, internal standards, etc.) for co-extracted analyses.

D - Concentration of analyte was quantified from diluted analysis. Flag only applies to field samples that have detectable concentrations of the analyte.

E - Concentration of analyte exceeds the range of the calibration curve and/or linear range of the instrument.

F - The ratio of quantifier ion response to qualifier ion response falls outside of the laboratory criteria. Results are considered to be an estimated maximum concentration.

G - The concentration may be biased high due to matrix interferences (i.e, co-elution) with non-target compound(s). The result should be considered estimated.

H - The analysis of pH was performed beyond the regulatory-required holding time of 15 minutes from the time of sample collection.

I - The lower value for the two columns has been reported due to obvious interference.

J - Estimated value. The Target analyte concentration is below the quantitation limit (RL), but above the Method Detection Limit (MDL) or Estimated Detection Limit (EDL) for SPME-related analyses. This represents an estimated concentration for Tentatively

Report Format: DU Report with 'J' Qualifiers

Project Name:	100 MAIN ST.	**Lab Number:**	L2341778
Project Number:	12461	**Report Date:**	07/24/23

Data Qualifiers

Identified Compounds (TICs). For calculated parameters, this represents that one or more values used in the calculation were estimated.

M - Reporting Limit (RL) exceeds the MCP CAM Reporting Limit for this analyte.

ND - Not detected at the method detection limit (MDL) for the sample, or estimated detection limit (EDL) for SPME-related analyses.

NJ - Presumptive evidence of compound. This represents an estimated concentration for Tentatively Identified Compounds (TICs), where the identification is based on a mass spectral library search.

P - The RPD between the results for the two columns exceeds the method-specified criteria.

Q - The quality control sample exceeds the associated acceptance criteria. For DOD-related projects, LCS and/or Continuing Calibration Standard exceedences are also qualified on all associated sample results. Note: This flag is not applicable for matrix spike recoveries when the sample concentration is greater than 4x the spike added or for batch duplicate RPD when the sample concentrations are less than 5x the RL. (Metals only.)

R - Analytical results are from sample re-analysis.

RE - Analytical results are from sample re-extraction.

S - Analytical results are from modified screening analysis.

V - The surrogate associated with this target analyte has a recovery outside the QC acceptance limits. (Applicable to MassDEP DW Compliance samples only.)

Z - The batch matrix spike and/or duplicate associated with this target analyte has a recovery/RPD outside the QC acceptance limits. (Applicable to MassDEP DW Compliance samples only.)

Project Name:	100 MAIN ST.	**Lab Number:**	L2341778
Project Number:	12461	**Report Date:**	07/24/23

REFERENCES

1 Test Methods for Evaluating Solid Waste: Physical/Chemical Methods. EPA SW-846. Third Edition. Updates I - VI, 2018.

LIMITATION OF LIABILITIES

Alpha Analytical performs services with reasonable care and diligence normal to the analytical testing laboratory industry. In the event of an error, the sole and exclusive responsibility of Alpha Analytical shall be to re-perform the work at it's own expense. In no event shall Alpha Analytical be held liable for any incidental, consequential or special damages, including but not limited to, damages in any way connected with the use of, interpretation of, information or analysis provided by Alpha Analytical.

We strongly urge our clients to comply with EPA protocol regarding sample volume, preservation, cooling, containers, sampling procedures, holding time and splitting of samples in the field.

Certification Information

The following analytes are not included in our Primary NELAP Scope of Accreditation:

Westborough Facility
EPA 624.1: m/p-xylene, o-xylene, Naphthalene
EPA 625.1: alpha-Terpineol
EPA 8260D: NPW: 1,2,4,5-Tetramethylbenzene; 4-Ethyltoluene, Azobenzene; SCM: Iodomethane (methyl iodide), 1,2,4,5-Tetramethylbenzene; 4-Ethyltoluene.
EPA 8270E: NPW: Dimethylnaphthalene,1,4-Diphenylhydrazine, alpha-Terpineol; SCM: Dimethylnaphthalene,1,4-Diphenylhydrazine.
SM4500: NPW: Amenable Cyanide; SCM: Total Phosphorus, TKN, NO2, NO3.

Mansfield Facility
SM 2540D: TSS.
EPA TO-15: Halothane, 2,4,4-Trimethyl-2-pentene, 2,4,4-Trimethyl-1-pentene, Thiophene, 2-Methylthiophene, 3-Methylthiophene, 2-Ethylthiophene, 1,2,3-Trimethylbenzene, Indan, Indene, 1,2,4,5-Tetramethylbenzene, Benzothiophene, 1-Methylnaphthalene.
Biological Tissue Matrix: EPA 3050B

The following analytes are included in our Massachusetts DEP Scope of Accreditation

Westborough Facility:

Drinking Water
EPA 300.0: Chloride, Nitrate-N, Fluoride, Sulfate; **EPA 353.2**: Nitrate-N, Nitrite-N; **SM4500NO3-F**: Nitrate-N, Nitrite-N; **SM4500F-C, SM4500CN-CE, EPA 180.1, SM2130B, SM4500Cl-D, SM2320B, SM2540C, SM4500H-B, SM4500NO2-B**
EPA 524.2: THMs and VOCs; **EPA 504.1:** EDB, DBCP.
Microbiology: **SM9215B; SM9223-P/A, SM9223B-Colilert-QT,SM9222D**.

Non-Potable Water
SM4500H,B, EPA 120.1, SM2510B, SM2540C, SM2320B, SM4500CL-E, SM4500F-BC, SM4500NH3-BH: Ammonia-N and Kjeldahl-N, **EPA 350.1**: Ammonia-N, **LACHAT 10-107-06-1-B**: Ammonia-N, **EPA 351.1, SM4500NO3-F, EPA 353.2**: Nitrate-N**, SM4500P-E, SM4500P-B, E, SM4500SO4-E, SM5220D, EPA 410.4, SM5210B, SM5310C, SM4500CL-D, EPA 1664, EPA 420.1, SM4500-CN-CE, SM2540D, EPA 300: Chloride, Sulfate, Nitrate.**
EPA 624.1: Volatile Halocarbons & Aromatics,
EPA 608.3: Chlordane, Toxaphene, Aldrin, alpha-BHC, beta-BHC, gamma-BHC, delta-BHC, Dieldrin, DDD, DDE, DDT, Endosulfan I, Endosulfan II, Endosulfan sulfate, Endrin, Endrin Aldehyde, Heptachlor, Heptachlor Epoxide, PCBs
EPA 625.1: SVOC (Acid/Base/Neutral Extractables).
Microbiology: **SM9223B-Colilert-QT; Enterolert-QT, SM9221E, EPA 1600, EPA 1603, SM9222D.**

Mansfield Facility:

Drinking Water
EPA 200.7: Al, Ba, Cd, Cr, Cu, Fe, Mn, Ni, Na, Ag, Ca, Zn. **EPA 200.8:** Al, Sb, As, Ba, Be, Cd, Cr, Cu, Pb, Mn, Ni, Se, Ag, TL, Zn. **EPA 245.1** Hg.
EPA 522, EPA 537.1.

Non-Potable Water
EPA 200.7: Al, Sb, As, Be, Cd, Ca, Cr, Co, Cu, Fe, Pb, Mg, Mn, Mo, Ni, K, Se, Ag, Na, Sr, TL, Ti, V, Zn.
EPA 200.8: Al, Sb**,** As, Be, Cd, Cr, Cu, Fe, Pb, Mn, Ni, K, Se, Ag, Na, TL, Zn.
EPA 245.1 Hg.
SM2340B

For a complete listing of analytes and methods, please contact your Alpha Project Manager.

NEW YORK CHAIN OF CUSTODY

ALPHA ANALYTICAL

Westborough, MA 01581
8 Walkup Dr.
TEL: 508-898-9220
FAX: 508-898-9193

Mansfield, MA 02048
320 Forbes Blvd
TEL: 508-822-9300
FAX: 508-822-3288

Service Centers
Mahwah, NJ 07430: 35 Whitney Rd, Suite 5
Albany, NY 12205: 14 Walker Way
Tonawanda, NY 14150: 275 Cooper Ave, Suite 105

Page 1 of 1

Date Rec'd in Lab: 7/20/23

ALPHA Job #: L2341778

Client Information

Client: SESI
Address: 959 US 46
Parsippany NJ 07054
Phone: 973 808 9050
Fax:
Email: JCS@sesi.org

Project Information

Project Name: 100 Main St
Project Location: White Plains NY
Project #: 12461
(Use Project name as Project #) ☐
Project Manager: Jon Stuart
ALPHAQuote #:

Turn-Around Time

Standard ☐ Due Date:
Rush (only if pre approved) ☑ # of Days: 1

Deliverables

☐ ASP-A ☑ ASP-B
☐ EQuIS (1 File) ☐ EQuIS (4 File)
☐ Other

Regulatory Requirement

☐ NY TOGS ☐ NY Part 375
☑ AWQ Standards ☐ NY CP-51
☐ NY Restricted Use ☐ Other
☐ NY Unrestricted Use
☐ NYC Sewer Discharge

Billing Information

☐ Same as Client Info
PO # Renaissance Env Mgmt
Attn: Kevin McNamus

Disposal Site Information

Please identify below location of applicable disposal facilities.
Disposal Facility:
☐ NJ ☐ NY
☐ Other:

These samples have been previously analyzed by Alpha ☐

Other project specific requirements/comments:

Please specify Metals or TAL.

ANALYSIS

TCL+30/TAL

Sample Filtration
☐ Done
☐ Lab to do
Preservation
☐ Lab to do
(Please Specify below)

Total Bottle

ALPHA Lab ID (Lab Use Only)	Sample ID	Collection Date	Collection Time	Sample Matrix	Sampler's Initials	TCL+30/TAL	Sample Specific Comments
41778-01	GW-27	7/20/23	1045	GW	CB	✓	

Container Type: P/C
Preservative: some

Preservative Code:
A = None
B = HCl
C = HNO_3
D = H_2SO_4
E = NaOH
F = MeOH
G = $NaHSO_4$
H = $Na_2S_2O_3$
K/E = Zn Ac/NaOH
O = Other

Container Code
P = Plastic
A = Amber Glass
V = Vial
G = Glass
B = Bacteria Cup
C = Cube
O = Other
E = Encore
D = BOD Bottle

Westboro: Certification No: MA935
Mansfield: Certification No: MA015

Relinquished By:	Date/Time	Received By:	Date/Time
	07/20/23	Anna (ALC)	7.20.23 1500
Anna (ALC)	7.20.23 1601	Paul Mazzella	7/20/23 1601
Paul Mazzella	7/20/23		
	7/20/23 2235		7/20/23 2235

Please print clearly, legibly and completely. Samples can not be logged in and turnaround time clock will not start until any ambiguities are resolved. BY EXECUTING THIS COC, THE CLIENT HAS READ AND AGREES TO BE BOUND BY ALPHA'S TERMS & CONDITIONS. (See reverse side.)

Form No: 01-25HC (rev. 30-Sept-2013)

The results set forth herein are provided by SGS North America Inc.

e-Hardcopy 2.0
Automated Report

Technical Report for

SESI Consulting Engineers

100 Main Street, White Plains, NY

12461

SGS Job Number: JD83927

Sampling Date: 03/07/24

Report to:

SESI Consulting Engineers

ssg@sesi.org
jcs@sesi.org
ATTN: Steven Gustems

Total number of pages in report: 568

Test results contained within this data package meet the requirements of the National Environmental Laboratory Accreditation Program and/or state specific certification programs as applicable unless noted in the narrative, comments or footnotes.

David Chastain
General Manager

Client Service contact: Kelly Ramos 732-329-0200
Certifications: NJ(12129),NY(10983),CA,CO,CT,FL,HI,IL,IN,KY,LA (120428),MA,MD,ME,MN,NC,NH,NV, AK (UST-103),AZ (AZ0786),PA(68-00408),RI,SC,TX (T104704234),UT,VA,WA,WV

This report shall not be reproduced, except in its entirety, without the written approval of SGS.
Test results relate only to samples analyzed.

SGS is the sole authority for authorizing edits or modifications to this document.
Unauthorized modification of this report is strictly prohibited.
Review standard terms at: http://www.sgs.com/en/terms-and-conditions

Please share your ideas about
how we can serve you better at:
EHS.US.CustomerCare@sgs.com

Table of Contents

Section 1: Sample Summary **4**
Section 2: Summary of Hits **6**
Section 3: Sample Results **18**
3.1: JD83927-1: SB-7(4-4.5)030724 19
3.2: JD83927-2: SB-7(7-7.5)030724 28
3.3: JD83927-3: SB-8(4-4.5)030724 37
3.4: JD83927-4: SB-8(7.5-8)030724 46
3.5: JD83927-5: SB-9(3.5-4)030724 55
3.6: JD83927-6: SB-10(3.5-4)030724 64
3.7: JD83927-7: SB-10(7-5.5)030724 73
3.8: JD83927-8: SB-11(3.5-4)030724 82
3.9: JD83927-9: SB-11(8-8.5)030724 91
3.10: JD83927-10: SB-16(3-3.5)030724 100
3.11: JD83927-11: SB-16(7.5-8)030724 109
3.12: JD83927-12: SB-19(4-4.5)030724 118
3.13: JD83927-13: SB-19(7-7.5)030724 127
3.14: JD83927-14: SB-22(3.5-4)030724 136
3.15: JD83927-15: SB-22(8-8.5)030724 146
3.16: JD83927-16: SB-25(1.5-2)030724 155
3.17: JD83927-17: SB-25(3-3.5)030724 166
3.18: JD83927-18: SB-25(7.5-8)030724 175
Section 4: GC/LC Semi-volatiles - QC Data Summaries **184**
4.1: Chain of Custody 185
4.2: Sample Tracking Chronicle 189
4.3: Internal Chain of Custody 196
Section 5: MS Volatiles - QC Data Summaries **216**
5.1: Method Blank Summary 217
5.2: Blank Spike Summary 221
5.3: Matrix Spike/Matrix Spike Duplicate Summary 225
5.4: Instrument Performance Checks (BFB) 229
5.5: Internal Standard Area Summaries 231
5.6: Surrogate Recovery Summaries 233
5.7: Initial and Continuing Calibration Summaries 234
5.8: Run Sequence Reports 268
Section 6: MS Semi-volatiles - QC Data Summaries **272**
6.1: Method Blank Summary 273
6.2: Blank Spike Summary 276
6.3: Matrix Spike/Matrix Spike Duplicate Summary 279
6.4: Instrument Performance Checks (DFTPP) 282
6.5: Internal Standard Area Summaries 288
6.6: Surrogate Recovery Summaries 291
6.7: Initial and Continuing Calibration Summaries 292

Table of Contents

6.8: Run Sequence Reports 322
Section 7: GC/LC Semi-volatiles - QC Data Summaries 328
7.1: Method Blank Summary 329
7.2: Blank Spike Summary 331
7.3: Matrix Spike/Matrix Spike Duplicate Summary 333
7.4: Internal Standard Area Summaries 335
7.5: DDT/Endrin Breakdown Checks 337
7.6: GC Identification Summaries (Hits) 342
7.7: Surrogate Recovery Summaries 358
7.8: GC Surrogate Retention Time Summaries 360
7.9: Initial and Continuing Calibration Summaries 366
7.10: Run Sequence Reports 422
Section 8: Metals Analysis - QC Data Summaries 430
8.1: Inst QC MA55686: Al,Sb,As,Ba,Be,Cd,Ca,Cr,Co,Cu,Fe,Pb,Mg,Mn,Ni,K,Se,Ag,Na, Tl,V,Zn 431
8.2: Inst QC MA55688: Hg 456
8.3: Inst QC MA55691: Al,Sb,As,Ba,Be,Cd,Ca,Cr,Co,Cu,Fe,Pb,Mg,Mn,Ni,K,Se,Ag,Na, Tl,V,Zn 473
8.4: Inst QC MA55725: Hg 507
8.5: Prep QC MP45216: Al,Sb,As,Ba,Be,Cd,Ca,Cr,Co,Cu,Fe,Pb,Mg,Mn,Ni,K,Se,Ag,Na, Tl,V,Zn 525
8.6: Prep QC MP45278: Hg 537
8.7: Prep QC MP45342: Hg 541
8.8: IDL and Linear Range Summaries 545
Section 9: General Chemistry - QC Data Summaries 553
9.1: Method Blank and Spike Results Summary 554
9.2: Duplicate Results Summary 555
9.3: Matrix Spike Results Summary 556
9.4: Inst QC GN52269: Cyanide 557
9.5: Percent Solids Raw Data Summary 566

SGS North America Inc.

Sample Summary

SESI Consulting Engineers

Job No: JD83927

100 Main Street, White Plains, NY
Project No: 12461

Sample Number	Collected Date	Time	By	Received	Matrix Code	Type	Client Sample ID
JD83927-1	03/07/24	10:05	CB	03/07/24	SO	Soil	SB-7(4-4.5)030724
JD83927-2	03/07/24	10:10	CB	03/07/24	SO	Soil	SB-7(7-7.5)030724
JD83927-3	03/07/24	08:50	CB	03/07/24	SO	Soil	SB-8(4-4.5)030724
JD83927-4	03/07/24	08:55	CB	03/07/24	SO	Soil	SB-8(7.5-8)030724
JD83927-5	03/07/24	09:00	CB	03/07/24	SO	Soil	SB-9(3.5-4)030724
JD83927-6	03/07/24	09:20	CB	03/07/24	SO	Soil	SB-10(3.5-4)030724
JD83927-7	03/07/24	09:25	CB	03/07/24	SO	Soil	SB-10(7-5.5)030724
JD83927-8	03/07/24	09:40	CB	03/07/24	SO	Soil	SB-11(3.5-4)030724
JD83927-9	03/07/24	09:45	CB	03/07/24	SO	Soil	SB-11(8-8.5)030724
JD83927-10	03/07/24	10:25	CB	03/07/24	SO	Soil	SB-16(3-3.5)030724
JD83927-11	03/07/24	10:30	CB	03/07/24	SO	Soil	SB-16(7.5-8)030724
JD83927-12	03/07/24	10:35	CB	03/07/24	SO	Soil	SB-19(4-4.5)030724

This report contains results reported as ND = Not detected. The following applies:
Organics ND = Not detected above the MDL

Soil samples reported on a dry weight basis unless otherwise indicated on result page.

SGS North America Inc.

Sample Summary
(continued)

SESI Consulting Engineers

Job No: JD83927

100 Main Street, White Plains, NY
Project No: 12461

Sample Number	Collected Date	Time	By	Received	Matrix Code	Type	Client Sample ID
JD83927-13	03/07/24	10:40	CB	03/07/24	SO	Soil	SB-19(7-7.5)030724
JD83927-14	03/07/24	11:25	CB	03/07/24	SO	Soil	SB-22(3.5-4)030724
JD83927-15	03/07/24	11:30	CB	03/07/24	SO	Soil	SB-22(8-8.5)030724
JD83927-16	03/07/24	12:00	CB	03/07/24	SO	Soil	SB-25(1.5-2)030724
JD83927-17	03/07/24	12:05	CB	03/07/24	SO	Soil	SB-25(3-3.5)030724
JD83927-18	03/07/24	12:10	CB	03/07/24	SO	Soil	SB-25(7.5-8)030724

Soil samples reported on a dry weight basis unless otherwise indicated on result page.

Summary of Hits

Job Number: JD83927
Account: SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY
Collected: 03/07/24

Lab Sample ID / Analyte	Client Sample ID	Result/ Qual	RL	MDL	Units	Method
JD83927-1	**SB-7(4-4.5)030724**					
Total TIC, Semi-Volatile		260 J			ug/kg	
Aluminum		5060	53		mg/kg	SW846 6010D
Barium		34.0	21		mg/kg	SW846 6010D
Beryllium		0.24	0.21		mg/kg	SW846 6010D
Calcium		18500	530		mg/kg	SW846 6010D
Chromium		10.7	1.1		mg/kg	SW846 6010D
Copper		11.6	2.6		mg/kg	SW846 6010D
Iron		10600	53		mg/kg	SW846 6010D
Lead		3.3	2.1		mg/kg	SW846 6010D
Magnesium		11700	530		mg/kg	SW846 6010D
Manganese		173	1.6		mg/kg	SW846 6010D
Nickel		9.3	4.2		mg/kg	SW846 6010D
Potassium		1550	1100		mg/kg	SW846 6010D
Vanadium		15.4	5.3		mg/kg	SW846 6010D
Zinc		26.2	5.3		mg/kg	SW846 6010D
JD83927-2	**SB-7(7-7.5)030724**					
Total TIC, Semi-Volatile		370 J			ug/kg	
Aluminum		6430	56		mg/kg	SW846 6010D
Barium		41.8	22		mg/kg	SW846 6010D
Beryllium		0.28	0.22		mg/kg	SW846 6010D
Calcium		7850	560		mg/kg	SW846 6010D
Chromium		13.0	1.1		mg/kg	SW846 6010D
Cobalt		6.4	5.6		mg/kg	SW846 6010D
Copper		13.7	2.8		mg/kg	SW846 6010D
Iron		13900	56		mg/kg	SW846 6010D
Lead		2.9	2.2		mg/kg	SW846 6010D
Magnesium		6830	560		mg/kg	SW846 6010D
Manganese		161	1.7		mg/kg	SW846 6010D
Nickel		12.3	4.4		mg/kg	SW846 6010D
Potassium		1960	1100		mg/kg	SW846 6010D
Vanadium		18.7	5.6		mg/kg	SW846 6010D
Zinc		30.9	5.6		mg/kg	SW846 6010D
JD83927-3	**SB-8(4-4.5)030724**					
Acenaphthene [a]		19.9 J	35	12	ug/kg	SW846 8270E
Anthracene		47.0	35	21	ug/kg	SW846 8270E
Benzo(a)anthracene		166	35	9.9	ug/kg	SW846 8270E
Benzo(a)pyrene		166	35	16	ug/kg	SW846 8270E
Benzo(b)fluoranthene		187	35	15	ug/kg	SW846 8270E
Benzo(g,h,i)perylene		84.0	35	17	ug/kg	SW846 8270E

Summary of Hits

Job Number: JD83927
Account: SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY
Collected: 03/07/24

Lab Sample ID / Analyte	Client Sample ID	Result/ Qual	RL	MDL	Units	Method
Benzo(k)fluoranthene		56.7	35	16	ug/kg	SW846 8270E
Carbazole		25.2 J	70	5.1	ug/kg	SW846 8270E
Chrysene		131	35	11	ug/kg	SW846 8270E
Dibenzo(a,h)anthracene		23.7 J	35	15	ug/kg	SW846 8270E
Dibenzofuran [a]		14.7 J	70	14	ug/kg	SW846 8270E
Fluoranthene		286	35	16	ug/kg	SW846 8270E
Fluorene [a]		24.3 J	35	16	ug/kg	SW846 8270E
Indeno(1,2,3-cd)pyrene		69.8	35	16	ug/kg	SW846 8270E
Naphthalene [a]		12.7 J	35	9.9	ug/kg	SW846 8270E
Phenanthrene [a]		185	35	12	ug/kg	SW846 8270E
Pyrene		273	35	11	ug/kg	SW846 8270E
Total TIC, Semi-Volatile		160 J			ug/kg	
alpha-Chlordane [b]		0.28 J	0.40	0.055	ug/kg	SW846 8081B
gamma-Chlordane		0.30 J	0.40	0.061	ug/kg	SW846 8081B
Dieldrin		0.33 J	0.40	0.065	ug/kg	SW846 8081B
4,4'-DDD		0.075 J	0.40	0.043	ug/kg	SW846 8081B
4,4'-DDE		0.092 J	0.40	0.049	ug/kg	SW846 8081B
4,4'-DDT		0.33 J	0.40	0.071	ug/kg	SW846 8081B
Aluminum		7080	55		mg/kg	SW846 6010D
Barium		79.8	22		mg/kg	SW846 6010D
Beryllium		0.34	0.22		mg/kg	SW846 6010D
Calcium		11600	550		mg/kg	SW846 6010D
Chromium		16.0	1.1		mg/kg	SW846 6010D
Cobalt		8.7	5.5		mg/kg	SW846 6010D
Copper		15.6	2.8		mg/kg	SW846 6010D
Iron		13600	55		mg/kg	SW846 6010D
Lead		23.1	2.2		mg/kg	SW846 6010D
Magnesium		7500	550		mg/kg	SW846 6010D
Manganese		299	1.7		mg/kg	SW846 6010D
Mercury		0.054	0.033		mg/kg	SW846 7471B
Nickel		12.3	4.4		mg/kg	SW846 6010D
Potassium		1950	1100		mg/kg	SW846 6010D
Vanadium		21.2	5.5		mg/kg	SW846 6010D
Zinc		40.1	5.5		mg/kg	SW846 6010D
JD83927-4	**SB-8(7.5-8)030724**					
Benzo(a)anthracene		67.4	37	11	ug/kg	SW846 8270E
Benzo(a)pyrene		62.7	37	17	ug/kg	SW846 8270E
Benzo(b)fluoranthene		76.6	37	16	ug/kg	SW846 8270E
Benzo(g,h,i)perylene		41.3	37	19	ug/kg	SW846 8270E
Benzo(k)fluoranthene		20.5 J	37	17	ug/kg	SW846 8270E
Chrysene		45.3	37	12	ug/kg	SW846 8270E
Fluoranthene		87.9	37	17	ug/kg	SW846 8270E
Indeno(1,2,3-cd)pyrene		33.1 J	37	17	ug/kg	SW846 8270E

Summary of Hits

Job Number: JD83927
Account: SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY
Collected: 03/07/24

Lab Sample ID / Client Sample ID / Analyte	Result/ Qual	RL	MDL	Units	Method
Phenanthrene [a]	48.0	37	12	ug/kg	SW846 8270E
Pyrene	94.7	37	12	ug/kg	SW846 8270E
Total TIC, Semi-Volatile	240 J			ug/kg	
alpha-Chlordane [b]	0.52	0.43	0.058	ug/kg	SW846 8081B
gamma-Chlordane	0.52	0.43	0.065	ug/kg	SW846 8081B
Dieldrin	0.66	0.43	0.069	ug/kg	SW846 8081B
4,4'-DDD	0.12 J	0.43	0.045	ug/kg	SW846 8081B
4,4'-DDE	0.15 J	0.43	0.052	ug/kg	SW846 8081B
4,4'-DDT	0.59	0.43	0.075	ug/kg	SW846 8081B
Aluminum	6660	57		mg/kg	SW846 6010D
Barium	53.1	23		mg/kg	SW846 6010D
Beryllium	0.32	0.23		mg/kg	SW846 6010D
Calcium	11500	570		mg/kg	SW846 6010D
Chromium	13.7	1.1		mg/kg	SW846 6010D
Copper	14.8	2.9		mg/kg	SW846 6010D
Iron	12700	57		mg/kg	SW846 6010D
Lead	28.6	2.3		mg/kg	SW846 6010D
Magnesium	7330	570		mg/kg	SW846 6010D
Manganese	212	1.7		mg/kg	SW846 6010D
Mercury	0.10	0.035		mg/kg	SW846 7471B
Nickel	11.1	4.6		mg/kg	SW846 6010D
Potassium	1760	1100		mg/kg	SW846 6010D
Vanadium	19.5	5.7		mg/kg	SW846 6010D
Zinc	59.3	5.7		mg/kg	SW846 6010D
JD83927-5 SB-9(3.5-4)030724					
Benzo(a)anthracene	30.6 J	34	9.6	ug/kg	SW846 8270E
Benzo(a)pyrene	34.4	34	15	ug/kg	SW846 8270E
Benzo(b)fluoranthene	33.7 J	34	15	ug/kg	SW846 8270E
Benzo(g,h,i)perylene	18.3 J	34	17	ug/kg	SW846 8270E
Chrysene	22.4 J	34	11	ug/kg	SW846 8270E
Fluoranthene	45.1	34	15	ug/kg	SW846 8270E
Indeno(1,2,3-cd)pyrene	16.2 J	34	16	ug/kg	SW846 8270E
Phenanthrene [a]	30.1 J	34	11	ug/kg	SW846 8270E
Pyrene	48.2	34	11	ug/kg	SW846 8270E
Total TIC, Semi-Volatile	890 J			ug/kg	
alpha-Chlordane [b]	0.11 J	0.39	0.052	ug/kg	SW846 8081B
gamma-Chlordane	0.13 J	0.39	0.058	ug/kg	SW846 8081B
Dieldrin	0.083 J	0.39	0.062	ug/kg	SW846 8081B
4,4'-DDT	0.095 J	0.39	0.068	ug/kg	SW846 8081B
Aluminum	5920	52		mg/kg	SW846 6010D
Barium	39.3	21		mg/kg	SW846 6010D
Beryllium	0.29	0.21		mg/kg	SW846 6010D
Calcium	5180	520		mg/kg	SW846 6010D

Summary of Hits

Job Number: JD83927
Account: SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY
Collected: 03/07/24

Lab Sample ID / Analyte	Client Sample ID	Result/ Qual	RL	MDL	Units	Method
Chromium		12.6	1.0		mg/kg	SW846 6010D
Cobalt		5.6	5.2		mg/kg	SW846 6010D
Copper		12.4	2.6		mg/kg	SW846 6010D
Iron		12800	52		mg/kg	SW846 6010D
Lead		11.7	2.1		mg/kg	SW846 6010D
Magnesium		5030	520		mg/kg	SW846 6010D
Manganese		201	1.6		mg/kg	SW846 6010D
Nickel		10.0	4.2		mg/kg	SW846 6010D
Potassium		1360	1000		mg/kg	SW846 6010D
Vanadium		17.4	5.2		mg/kg	SW846 6010D
Zinc		33.8	5.2		mg/kg	SW846 6010D
JD83927-6	**SB-10(3.5-4)030724**					
Benzo(a)anthracene		14.7 J	35	10	ug/kg	SW846 8270E
Benzo(a)pyrene		19.1 J	35	16	ug/kg	SW846 8270E
Benzo(b)fluoranthene		18.2 J	35	16	ug/kg	SW846 8270E
Fluoranthene		18.8 J	35	16	ug/kg	SW846 8270E
Pyrene		19.4 J	35	11	ug/kg	SW846 8270E
alpha-Chlordane [b]		0.22 J	0.40	0.054	ug/kg	SW846 8081B
gamma-Chlordane		0.24 J	0.40	0.060	ug/kg	SW846 8081B
4,4'-DDT		0.084 J	0.40	0.070	ug/kg	SW846 8081B
Aluminum		6350	54		mg/kg	SW846 6010D
Barium		46.5	22		mg/kg	SW846 6010D
Beryllium		0.29	0.22		mg/kg	SW846 6010D
Cadmium		0.77	0.54		mg/kg	SW846 6010D
Calcium		11300	540		mg/kg	SW846 6010D
Chromium		13.1	1.1		mg/kg	SW846 6010D
Cobalt		5.5	5.4		mg/kg	SW846 6010D
Copper		13.9	2.7		mg/kg	SW846 6010D
Iron		12800	54		mg/kg	SW846 6010D
Lead		7.4	2.2		mg/kg	SW846 6010D
Magnesium		8210	540		mg/kg	SW846 6010D
Manganese		209	1.6		mg/kg	SW846 6010D
Nickel		11.8	4.3		mg/kg	SW846 6010D
Potassium		1850	1100		mg/kg	SW846 6010D
Vanadium		19.0	5.4		mg/kg	SW846 6010D
Zinc		33.9	5.4		mg/kg	SW846 6010D
JD83927-7	**SB-10(7-5.5)030724**					
Benzo(a)anthracene		17.8 J	38	11	ug/kg	SW846 8270E
Benzo(a)pyrene		18.1 J	38	17	ug/kg	SW846 8270E
Chrysene		12.8 J	38	12	ug/kg	SW846 8270E
Fluoranthene		18.2 J	38	17	ug/kg	SW846 8270E

Summary of Hits

Job Number: JD83927
Account: SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY
Collected: 03/07/24

Lab Sample ID / Analyte	Client Sample ID	Result/ Qual	RL	MDL	Units	Method
Pyrene		29.5 J	38	12	ug/kg	SW846 8270E
alpha-Chlordane [b]		0.13 J	0.45	0.061	ug/kg	SW846 8081B
gamma-Chlordane		0.13 J	0.45	0.068	ug/kg	SW846 8081B
Dieldrin		0.085 J	0.45	0.072	ug/kg	SW846 8081B
4,4'-DDD		0.20 J	0.45	0.048	ug/kg	SW846 8081B
4,4'-DDE		0.12 J	0.45	0.054	ug/kg	SW846 8081B
4,4'-DDT [b]		0.16 J	0.45	0.079	ug/kg	SW846 8081B
Aluminum		5840	56		mg/kg	SW846 6010D
Barium		43.0	22		mg/kg	SW846 6010D
Beryllium		0.26	0.22		mg/kg	SW846 6010D
Cadmium		2.0	0.56		mg/kg	SW846 6010D
Calcium		14100	560		mg/kg	SW846 6010D
Chromium		12.1	1.1		mg/kg	SW846 6010D
Copper		13.3	2.8		mg/kg	SW846 6010D
Iron		12100	56		mg/kg	SW846 6010D
Lead		9.4	2.2		mg/kg	SW846 6010D
Magnesium		9560	560		mg/kg	SW846 6010D
Manganese		190	1.7		mg/kg	SW846 6010D
Mercury		0.031	0.030		mg/kg	SW846 7471B
Nickel		12.7	4.5		mg/kg	SW846 6010D
Potassium		1890	1100		mg/kg	SW846 6010D
Vanadium		17.0	5.6		mg/kg	SW846 6010D
Zinc		32.4	5.6		mg/kg	SW846 6010D
JD83927-8	**SB-11(3.5-4)030724**					
Benzo(a)anthracene		21.7 J	36	10	ug/kg	SW846 8270E
Benzo(a)pyrene		21.9 J	36	17	ug/kg	SW846 8270E
Benzo(b)fluoranthene		22.5 J	36	16	ug/kg	SW846 8270E
Chrysene		14.9 J	36	11	ug/kg	SW846 8270E
Fluoranthene		25.4 J	36	16	ug/kg	SW846 8270E
Phenanthrene [a]		15.7 J	36	12	ug/kg	SW846 8270E
Pyrene		28.9 J	36	12	ug/kg	SW846 8270E
Total TIC, Semi-Volatile		460 J			ug/kg	
alpha-Chlordane [b]		0.23 J	0.42	0.057	ug/kg	SW846 8081B
gamma-Chlordane		0.22 J	0.42	0.063	ug/kg	SW846 8081B
Dieldrin		0.22 J	0.42	0.067	ug/kg	SW846 8081B
4,4'-DDE		0.10 J	0.42	0.050	ug/kg	SW846 8081B
4,4'-DDT		0.35 J	0.42	0.074	ug/kg	SW846 8081B
Aluminum		8230	58		mg/kg	SW846 6010D
Barium		59.4	23		mg/kg	SW846 6010D
Beryllium		0.39	0.23		mg/kg	SW846 6010D
Calcium		13100	580		mg/kg	SW846 6010D
Chromium		17.0	1.2		mg/kg	SW846 6010D
Cobalt		8.1	5.8		mg/kg	SW846 6010D

Summary of Hits

Job Number: JD83927
Account: SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY
Collected: 03/07/24

Lab Sample ID / Analyte	Client Sample ID	Result/ Qual	RL	MDL	Units	Method
Copper		19.9	2.9		mg/kg	SW846 6010D
Iron		16400	58		mg/kg	SW846 6010D
Lead		15.0	2.3		mg/kg	SW846 6010D
Magnesium		9250	580		mg/kg	SW846 6010D
Manganese		288	1.7		mg/kg	SW846 6010D
Mercury		0.076	0.030		mg/kg	SW846 7471B
Nickel		15.4	4.6		mg/kg	SW846 6010D
Potassium		2630	1200		mg/kg	SW846 6010D
Vanadium		24.7	5.8		mg/kg	SW846 6010D
Zinc		63.7	5.8		mg/kg	SW846 6010D
JD83927-9	**SB-11(8-8.5)030724**					
Chloroform		0.90 J	2.2	0.57	ug/kg	SW846 8260D
Aluminum		4300	58		mg/kg	SW846 6010D
Barium		35.7	23		mg/kg	SW846 6010D
Calcium		1510	580		mg/kg	SW846 6010D
Chromium		9.5	1.2		mg/kg	SW846 6010D
Cobalt		8.2	5.8		mg/kg	SW846 6010D
Copper		10.8	2.9		mg/kg	SW846 6010D
Iron		10400	58		mg/kg	SW846 6010D
Magnesium		2840	580		mg/kg	SW846 6010D
Manganese		282	1.7		mg/kg	SW846 6010D
Nickel		8.3	4.6		mg/kg	SW846 6010D
Potassium		1410	1200		mg/kg	SW846 6010D
Vanadium		13.3	5.8		mg/kg	SW846 6010D
Zinc		57.2	5.8		mg/kg	SW846 6010D
JD83927-10	**SB-16(3-3.5)030724**					
Total TIC, Semi-Volatile		150 J			ug/kg	
Aluminum		8000	53		mg/kg	SW846 6010D
Barium		45.7	21		mg/kg	SW846 6010D
Beryllium		0.32	0.21		mg/kg	SW846 6010D
Calcium		2000	530		mg/kg	SW846 6010D
Chromium		14.8	1.1		mg/kg	SW846 6010D
Cobalt		5.7	5.3		mg/kg	SW846 6010D
Copper		14.8	2.7		mg/kg	SW846 6010D
Iron		13800	53		mg/kg	SW846 6010D
Lead		2.7	2.1		mg/kg	SW846 6010D
Magnesium		4420	530		mg/kg	SW846 6010D
Manganese		182	1.6		mg/kg	SW846 6010D
Nickel		12.6	4.3		mg/kg	SW846 6010D
Potassium		2030	1100		mg/kg	SW846 6010D
Vanadium		21.0	5.3		mg/kg	SW846 6010D

Summary of Hits

Job Number: JD83927
Account: SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY
Collected: 03/07/24

Lab Sample ID / Analyte	Client Sample ID	Result/ Qual	RL	MDL	Units	Method
Zinc		32.5	5.3		mg/kg	SW846 6010D
JD83927-11	**SB-16(7.5-8)030724**					
Total TIC, Semi-Volatile		480 J			ug/kg	
Aluminum		6660	58		mg/kg	SW846 6010D
Barium		35.7	23		mg/kg	SW846 6010D
Beryllium		0.30	0.23		mg/kg	SW846 6010D
Calcium		2040	580		mg/kg	SW846 6010D
Chromium		13.6	1.2		mg/kg	SW846 6010D
Copper		13.5	2.9		mg/kg	SW846 6010D
Iron		12800	58		mg/kg	SW846 6010D
Lead		3.9	2.3		mg/kg	SW846 6010D
Magnesium		3270	580		mg/kg	SW846 6010D
Manganese		162	1.7		mg/kg	SW846 6010D
Nickel		10.9	4.6		mg/kg	SW846 6010D
Potassium		1430	1200		mg/kg	SW846 6010D
Vanadium		18.8	5.8		mg/kg	SW846 6010D
Zinc		28.4	5.8		mg/kg	SW846 6010D
JD83927-12	**SB-19(4-4.5)030724**					
Total TIC, Semi-Volatile		760 J			ug/kg	
Aluminum		8740	58		mg/kg	SW846 6010D
Barium		63.6	23		mg/kg	SW846 6010D
Beryllium		0.37	0.23		mg/kg	SW846 6010D
Calcium		2700	580		mg/kg	SW846 6010D
Chromium		17.5	1.2		mg/kg	SW846 6010D
Cobalt		6.9	5.8		mg/kg	SW846 6010D
Copper		16.4	2.9		mg/kg	SW846 6010D
Iron		16300	58		mg/kg	SW846 6010D
Lead		5.5	2.3		mg/kg	SW846 6010D
Magnesium		5090	580		mg/kg	SW846 6010D
Manganese		236	1.7		mg/kg	SW846 6010D
Nickel		14.4	4.6		mg/kg	SW846 6010D
Potassium		2760	1200		mg/kg	SW846 6010D
Vanadium		24.9	5.8		mg/kg	SW846 6010D
Zinc		40.4	5.8		mg/kg	SW846 6010D
JD83927-13	**SB-19(7-7.5)030724**					
Total TIC, Semi-Volatile		190 J			ug/kg	
Aluminum		6390	60		mg/kg	SW846 6010D
Barium		33.4	24		mg/kg	SW846 6010D
Beryllium		0.25	0.24		mg/kg	SW846 6010D

Summary of Hits

Job Number: JD83927
Account: SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY
Collected: 03/07/24

Lab Sample ID / Analyte	Client Sample ID	Result/ Qual	RL	MDL	Units	Method
Calcium		1640	600		mg/kg	SW846 6010D
Chromium		12.5	1.2		mg/kg	SW846 6010D
Copper		12.9	3.0		mg/kg	SW846 6010D
Iron		11700	60		mg/kg	SW846 6010D
Magnesium		3550	600		mg/kg	SW846 6010D
Manganese		163	1.8		mg/kg	SW846 6010D
Nickel		10	4.8		mg/kg	SW846 6010D
Potassium		1680	1200		mg/kg	SW846 6010D
Vanadium		17.0	6.0		mg/kg	SW846 6010D
Zinc		25.6	6.0		mg/kg	SW846 6010D
JD83927-14	**SB-22(3.5-4)030724**					
Benzo(g,h,i)perylene		23.6 J	34	17	ug/kg	SW846 8270E
1,1'-Biphenyl		7.2 J	68	4.6	ug/kg	SW846 8270E
2-Methylnaphthalene		26.8 J	34	7.6	ug/kg	SW846 8270E
Naphthalene [a]		14.7 J	34	9.5	ug/kg	SW846 8270E
Total TIC, Semi-Volatile		8260 J			ug/kg	
beta-BHC [b]		8.9	0.41	0.060	ug/kg	SW846 8081B
gamma-BHC (Lindane)		9.0	0.41	0.072	ug/kg	SW846 8081B
Dieldrin		9.4	0.41	0.066	ug/kg	SW846 8081B
4,4'-DDT		5.4	0.41	0.072	ug/kg	SW846 8081B
Heptachlor [b]		2.8	0.41	0.053	ug/kg	SW846 8081B
Aluminum		5500	52		mg/kg	SW846 6010D
Barium		44.1	21		mg/kg	SW846 6010D
Beryllium		0.24	0.21		mg/kg	SW846 6010D
Calcium		14800	520		mg/kg	SW846 6010D
Chromium		11.0	1.0		mg/kg	SW846 6010D
Copper		12.5	2.6		mg/kg	SW846 6010D
Iron		10800	52		mg/kg	SW846 6010D
Lead		8.1	2.1		mg/kg	SW846 6010D
Magnesium		9810	520		mg/kg	SW846 6010D
Manganese		189	1.6		mg/kg	SW846 6010D
Nickel		9.6	4.2		mg/kg	SW846 6010D
Potassium		1850	1000		mg/kg	SW846 6010D
Vanadium		16.5	5.2		mg/kg	SW846 6010D
Zinc		28.7	5.2		mg/kg	SW846 6010D
JD83927-15	**SB-22(8-8.5)030724**					
Anthracene		23.4 J	34	21	ug/kg	SW846 8270E
Benzo(a)anthracene		107	34	9.6	ug/kg	SW846 8270E
Benzo(a)pyrene		119	34	16	ug/kg	SW846 8270E
Benzo(b)fluoranthene		127	34	15	ug/kg	SW846 8270E
Benzo(g,h,i)perylene		87.9	34	17	ug/kg	SW846 8270E

Summary of Hits

Job Number: JD83927
Account: SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY
Collected: 03/07/24

Lab Sample ID Client Sample ID Analyte	Result/ Qual	RL	MDL	Units	Method
Benzo(k)fluoranthene	41.1	34	16	ug/kg	SW846 8270E
Carbazole	16.0 J	68	4.9	ug/kg	SW846 8270E
Chrysene	105	34	11	ug/kg	SW846 8270E
Dibenzo(a,h)anthracene	23.0 J	34	15	ug/kg	SW846 8270E
Fluoranthene	197	34	15	ug/kg	SW846 8270E
Indeno(1,2,3-cd)pyrene	60.2	34	16	ug/kg	SW846 8270E
Phenanthrene [a]	102	34	11	ug/kg	SW846 8270E
Pyrene	169	34	11	ug/kg	SW846 8270E
Total TIC, Semi-Volatile	670 J			ug/kg	
gamma-BHC (Lindane)	0.47	0.38	0.067	ug/kg	SW846 8081B
gamma-Chlordane [b]	0.27 J	0.38	0.057	ug/kg	SW846 8081B
Dieldrin	0.29 J	0.38	0.061	ug/kg	SW846 8081B
4,4'-DDT	0.45	0.38	0.067	ug/kg	SW846 8081B
Aluminum	6100	53		mg/kg	SW846 6010D
Barium	36.5	21		mg/kg	SW846 6010D
Beryllium	0.25	0.21		mg/kg	SW846 6010D
Calcium	5950	530		mg/kg	SW846 6010D
Chromium	10.6	1.1		mg/kg	SW846 6010D
Copper	11.5	2.6		mg/kg	SW846 6010D
Iron	11700	53		mg/kg	SW846 6010D
Lead	10.3	2.1		mg/kg	SW846 6010D
Magnesium	4610	530		mg/kg	SW846 6010D
Manganese	197	1.6		mg/kg	SW846 6010D
Mercury	0.066	0.033		mg/kg	SW846 7471B
Nickel	11.1	4.2		mg/kg	SW846 6010D
Potassium	1340	1100		mg/kg	SW846 6010D
Vanadium	15.2	5.3		mg/kg	SW846 6010D
Zinc	30.8	5.3		mg/kg	SW846 6010D
JD83927-16 SB-25(1.5-2)030724					
Acenaphthene [a]	75.0	34	12	ug/kg	SW846 8270E
Anthracene	416	34	21	ug/kg	SW846 8270E
Benzo(a)anthracene	4370	340	97	ug/kg	SW846 8270E
Benzo(a)pyrene	4720	340	160	ug/kg	SW846 8270E
Benzo(b)fluoranthene	5920	340	150	ug/kg	SW846 8270E
Benzo(g,h,i)perylene	3350	34	17	ug/kg	SW846 8270E
Benzo(k)fluoranthene	2140	34	16	ug/kg	SW846 8270E
Carbazole	196	69	5.0	ug/kg	SW846 8270E
Chrysene	4890	340	110	ug/kg	SW846 8270E
Dibenzo(a,h)anthracene	925	34	15	ug/kg	SW846 8270E
Dibenzofuran [a]	21.7 J	69	14	ug/kg	SW846 8270E
bis(2-Ethylhexyl)phthalate	34.9 J	69	8.0	ug/kg	SW846 8270E
Fluoranthene	7040	340	150	ug/kg	SW846 8270E
Fluorene [a]	56.6	34	16	ug/kg	SW846 8270E

Summary of Hits

Job Number: JD83927
Account: SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY
Collected: 03/07/24

Lab Sample ID / Analyte	Client Sample ID	Result/ Qual	RL	MDL	Units	Method
Indeno(1,2,3-cd)pyrene		2770	34	16	ug/kg	SW846 8270E
Phenanthrene [a]		1510	34	12	ug/kg	SW846 8270E
Pyrene		6570	340	110	ug/kg	SW846 8270E
Total TIC, Semi-Volatile		28060 J			ug/kg	
Aldrin		0.20 J	0.39	0.076	ug/kg	SW846 8081B
alpha-BHC [b]		0.078 J	0.39	0.045	ug/kg	SW846 8081B
delta-BHC [c]		0.22 J	0.39	0.059	ug/kg	SW846 8081B
Dieldrin		2.1	0.39	0.063	ug/kg	SW846 8081B
4,4'-DDD [b]		0.15 J	0.39	0.041	ug/kg	SW846 8081B
4,4'-DDE [b]		0.20 J	0.39	0.047	ug/kg	SW846 8081B
4,4'-DDT [b]		0.84	0.39	0.069	ug/kg	SW846 8081B
Heptachlor epoxide [b]		0.11 J	0.39	0.071	ug/kg	SW846 8081B
Aluminum		6280	55		mg/kg	SW846 6010D
Barium		56.9	22		mg/kg	SW846 6010D
Beryllium		0.29	0.22		mg/kg	SW846 6010D
Calcium		13300	550		mg/kg	SW846 6010D
Chromium		12.8	1.1		mg/kg	SW846 6010D
Copper		14.8	2.7		mg/kg	SW846 6010D
Iron		12000	55		mg/kg	SW846 6010D
Lead		27.1	2.2		mg/kg	SW846 6010D
Magnesium		8240	550		mg/kg	SW846 6010D
Manganese		181	1.6		mg/kg	SW846 6010D
Mercury		0.061	0.034		mg/kg	SW846 7471B
Nickel		10.3	4.4		mg/kg	SW846 6010D
Potassium		1740	1100		mg/kg	SW846 6010D
Vanadium		18.2	5.5		mg/kg	SW846 6010D
Zinc		44.4	5.5		mg/kg	SW846 6010D
JD83927-17	**SB-25(3-3.5)030724**					
Acenaphthene [a]		23.5 J	35	12	ug/kg	SW846 8270E
Acenaphthylene		39.8	35	18	ug/kg	SW846 8270E
Anthracene		98.8	35	22	ug/kg	SW846 8270E
Benzo(a)anthracene		504	35	10	ug/kg	SW846 8270E
Benzo(a)pyrene		507	35	16	ug/kg	SW846 8270E
Benzo(b)fluoranthene		504	35	16	ug/kg	SW846 8270E
Benzo(g,h,i)perylene		269	35	18	ug/kg	SW846 8270E
Benzo(k)fluoranthene		198	35	17	ug/kg	SW846 8270E
Carbazole		37.6 J	71	5.1	ug/kg	SW846 8270E
Chrysene		444	35	11	ug/kg	SW846 8270E
Dibenzo(a,h)anthracene		71.7	35	16	ug/kg	SW846 8270E
Dibenzofuran [a]		14.2 J	71	14	ug/kg	SW846 8270E
Fluoranthene		711	35	16	ug/kg	SW846 8270E
Fluorene [a]		24.6 J	35	16	ug/kg	SW846 8270E
Indeno(1,2,3-cd)pyrene		229	35	17	ug/kg	SW846 8270E

Summary of Hits

Job Number: JD83927
Account: SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY
Collected: 03/07/24

Lab Sample ID / Analyte	Client Sample ID	Result/ Qual	RL	MDL	Units	Method
Naphthalene [a]		13.5 J	35	10	ug/kg	SW846 8270E
Phenanthrene [a]		293	35	12	ug/kg	SW846 8270E
Pyrene		599	35	11	ug/kg	SW846 8270E
Total TIC, Semi-Volatile		2380 J			ug/kg	
4,4'-DDT [b]		0.80	0.40	0.070	ug/kg	SW846 8081B
Aluminum		6230	55		mg/kg	SW846 6010D
Barium		52.4	22		mg/kg	SW846 6010D
Beryllium		0.34	0.22		mg/kg	SW846 6010D
Calcium		12700	550		mg/kg	SW846 6010D
Chromium		13.6	1.1		mg/kg	SW846 6010D
Copper		15.7	2.7		mg/kg	SW846 6010D
Iron		11200	55		mg/kg	SW846 6010D
Lead		24.8	2.2		mg/kg	SW846 6010D
Magnesium		7830	550		mg/kg	SW846 6010D
Manganese		147	1.6		mg/kg	SW846 6010D
Mercury		0.10	0.032		mg/kg	SW846 7471B
Nickel		10.8	4.4		mg/kg	SW846 6010D
Potassium		1600	1100		mg/kg	SW846 6010D
Vanadium		17.0	5.5		mg/kg	SW846 6010D
Zinc		55.9	5.5		mg/kg	SW846 6010D
JD83927-18	**SB-25(7.5-8)030724**					
Benzo(a)anthracene		47.8	34	9.6	ug/kg	SW846 8270E
Benzo(a)pyrene		47.6	34	15	ug/kg	SW846 8270E
Benzo(b)fluoranthene		42.9	34	15	ug/kg	SW846 8270E
Benzo(g,h,i)perylene		35.4	34	17	ug/kg	SW846 8270E
Benzo(k)fluoranthene		23.0 J	34	16	ug/kg	SW846 8270E
Chrysene		33.6 J	34	11	ug/kg	SW846 8270E
Fluoranthene		72.1	34	15	ug/kg	SW846 8270E
Indeno(1,2,3-cd)pyrene		22.9 J	34	16	ug/kg	SW846 8270E
Phenanthrene [a]		30.9 J	34	11	ug/kg	SW846 8270E
Pyrene		65.0	34	11	ug/kg	SW846 8270E
Total TIC, Semi-Volatile		190 J			ug/kg	
Aluminum		6410	54		mg/kg	SW846 6010D
Barium		51.4	21		mg/kg	SW846 6010D
Beryllium		0.32	0.21		mg/kg	SW846 6010D
Calcium		11200	540		mg/kg	SW846 6010D
Chromium		12.8	1.1		mg/kg	SW846 6010D
Copper		14.6	2.7		mg/kg	SW846 6010D
Iron		12300	54		mg/kg	SW846 6010D
Lead		11.1	2.1		mg/kg	SW846 6010D
Magnesium		7480	540		mg/kg	SW846 6010D
Manganese		193	1.6		mg/kg	SW846 6010D
Mercury		0.035	0.030		mg/kg	SW846 7471B

Summary of Hits

Job Number: JD83927
Account: SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY
Collected: 03/07/24

Lab Sample ID / Analyte	Client Sample ID	Result/ Qual	RL	MDL	Units	Method
Nickel		10.6	4.3		mg/kg	SW846 6010D
Potassium		1970	1100		mg/kg	SW846 6010D
Vanadium		18.4	5.4		mg/kg	SW846 6010D
Zinc		33.6	5.4		mg/kg	SW846 6010D

(a) Associated CCV outside of control limits low. Low-level verification was analyzed to demonstrate system suitability to detect affected analytes. Estimated value, due to corresponding failure in the batch associated CCV.
(b) More than 40 % RPD for detected concentrations between the two GC columns.
(c) Reported from the 2nd signal. The %D of the CCV on the 1st signal exceeds the method criteria of 20%, so it being used for confirmation only. More than 40 % RPD for detected concentrations between the two GC columns.

Sample Results

Report of Analysis

Report of Analysis

Client Sample ID:	SB-7(4-4.5)030724		
Lab Sample ID:	JD83927-1	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8260D SW846 5035	**Percent Solids:**	93.9
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	1C199825.D	1	03/09/24 00:48	PS	03/08/24 09:00	n/a	V1C8643
Run #2							

	Initial Weight
Run #1	5.7 g
Run #2	

VOA TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
67-64-1	Acetone	ND	9.3	3.9	ug/kg	
71-43-2	Benzene	ND	0.47	0.43	ug/kg	
74-97-5	Bromochloromethane	ND	4.7	0.52	ug/kg	
75-27-4	Bromodichloromethane	ND	1.9	0.40	ug/kg	
75-25-2	Bromoform	ND	4.7	1.3	ug/kg	
74-83-9	Bromomethane	ND	4.7	0.71	ug/kg	
78-93-3	2-Butanone (MEK)	ND	9.3	2.3	ug/kg	
75-15-0	Carbon disulfide	ND	1.9	0.50	ug/kg	
56-23-5	Carbon tetrachloride	ND	1.9	0.58	ug/kg	
108-90-7	Chlorobenzene	ND	1.9	0.43	ug/kg	
75-00-3	Chloroethane	ND	4.7	0.55	ug/kg	
67-66-3	Chloroform	ND	1.9	0.48	ug/kg	
74-87-3	Chloromethane	ND	4.7	1.8	ug/kg	
110-82-7	Cyclohexane	ND	1.9	0.61	ug/kg	
96-12-8	1,2-Dibromo-3-chloropropane	ND	1.9	0.65	ug/kg	
124-48-1	Dibromochloromethane	ND	1.9	0.52	ug/kg	
106-93-4	1,2-Dibromoethane	ND	0.93	0.39	ug/kg	
95-50-1	1,2-Dichlorobenzene	ND	0.93	0.51	ug/kg	
541-73-1	1,3-Dichlorobenzene	ND	0.93	0.46	ug/kg	
106-46-7	1,4-Dichlorobenzene	ND	0.93	0.46	ug/kg	
75-71-8	Dichlorodifluoromethane [a]	ND	4.7	0.68	ug/kg	
75-34-3	1,1-Dichloroethane	ND	0.93	0.46	ug/kg	
107-06-2	1,2-Dichloroethane	ND	0.93	0.44	ug/kg	
75-35-4	1,1-Dichloroethene	ND	0.93	0.61	ug/kg	
156-59-2	cis-1,2-Dichloroethene	ND	0.93	0.78	ug/kg	
156-60-5	trans-1,2-Dichloroethene	ND	0.93	0.57	ug/kg	
78-87-5	1,2-Dichloropropane	ND	1.9	0.44	ug/kg	
10061-01-5	cis-1,3-Dichloropropene	ND	1.9	0.44	ug/kg	
10061-02-6	trans-1,3-Dichloropropene	ND	1.9	0.43	ug/kg	
100-41-4	Ethylbenzene	ND	0.93	0.42	ug/kg	
76-13-1	Freon 113	ND	4.7	2.5	ug/kg	
591-78-6	2-Hexanone	ND	4.7	2.0	ug/kg	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-7(4-4.5)030724		
Lab Sample ID:	JD83927-1	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8260D SW846 5035	**Percent Solids:**	93.9
Project:	100 Main Street, White Plains, NY		

VOA TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
98-82-8	Isopropylbenzene	ND	1.9	1.3	ug/kg	
79-20-9	Methyl Acetate	ND	4.7	1.3	ug/kg	
108-87-2	Methylcyclohexane	ND	1.9	0.82	ug/kg	
1634-04-4	Methyl Tert Butyl Ether	ND	0.93	0.44	ug/kg	
108-10-1	4-Methyl-2-pentanone(MIBK)	ND	4.7	2.1	ug/kg	
75-09-2	Methylene chloride	ND	4.7	2.4	ug/kg	
100-42-5	Styrene	ND	1.9	0.38	ug/kg	
79-34-5	1,1,2,2-Tetrachloroethane	ND	1.9	0.56	ug/kg	
127-18-4	Tetrachloroethene	ND	1.9	0.54	ug/kg	
108-88-3	Toluene	ND	0.93	0.49	ug/kg	
87-61-6	1,2,3-Trichlorobenzene	ND	4.7	2.3	ug/kg	
120-82-1	1,2,4-Trichlorobenzene	ND	4.7	2.3	ug/kg	
71-55-6	1,1,1-Trichloroethane	ND	1.9	0.45	ug/kg	
79-00-5	1,1,2-Trichloroethane	ND	1.9	0.52	ug/kg	
79-01-6	Trichloroethene	ND	0.93	0.71	ug/kg	
75-69-4	Trichlorofluoromethane	ND	4.7	0.64	ug/kg	
75-01-4	Vinyl chloride	ND	1.9	0.45	ug/kg	
	m,p-Xylene	ND	0.93	0.84	ug/kg	
95-47-6	o-Xylene	ND	0.93	0.43	ug/kg	
1330-20-7	Xylene (total)	ND	0.93	0.43	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
1868-53-7	Dibromofluoromethane	105%		80-124%
17060-07-0	1,2-Dichloroethane-D4	112%		75-133%
2037-26-5	Toluene-D8	99%		79-125%
460-00-4	4-Bromofluorobenzene	99%		58-148%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Total TIC, Volatile		0	ug/kg	

(a) Associated CCV outside of control limits high, sample was ND.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-7(4-4.5)030724		
Lab Sample ID:	JD83927-1	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	93.9
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	Z166829.D	1	03/11/24 13:34	JY	03/09/24 18:30	OP53010	EZ8267
Run #2							

	Initial Weight	Final Volume
Run #1	30.5 g	1.0 ml
Run #2		

ABN TCL List (SOM0 2.0)

CAS No.	Compound	Result	RL	MDL	Units	Q
95-57-8	2-Chlorophenol	ND	70	17	ug/kg	
59-50-7	4-Chloro-3-methyl phenol	ND	170	21	ug/kg	
120-83-2	2,4-Dichlorophenol	ND	170	30	ug/kg	
105-67-9	2,4-Dimethylphenol	ND	170	62	ug/kg	
51-28-5	2,4-Dinitrophenol	ND	170	130	ug/kg	
534-52-1	4,6-Dinitro-o-cresol	ND	170	37	ug/kg	
95-48-7	2-Methylphenol	ND	70	22	ug/kg	
	3&4-Methylphenol	ND	70	29	ug/kg	
88-75-5	2-Nitrophenol	ND	170	23	ug/kg	
100-02-7	4-Nitrophenol	ND	350	93	ug/kg	
87-86-5	Pentachlorophenol	ND	140	33	ug/kg	
108-95-2	Phenol	ND	70	18	ug/kg	
58-90-2	2,3,4,6-Tetrachlorophenol	ND	170	23	ug/kg	
95-95-4	2,4,5-Trichlorophenol	ND	170	26	ug/kg	
88-06-2	2,4,6-Trichlorophenol	ND	170	21	ug/kg	
83-32-9	Acenaphthene [a]	ND	35	12	ug/kg	
208-96-8	Acenaphthylene	ND	35	18	ug/kg	
98-86-2	Acetophenone	ND	170	7.5	ug/kg	
120-12-7	Anthracene	ND	35	21	ug/kg	
1912-24-9	Atrazine	ND	70	15	ug/kg	
56-55-3	Benzo(a)anthracene	ND	35	9.9	ug/kg	
50-32-8	Benzo(a)pyrene	ND	35	16	ug/kg	
205-99-2	Benzo(b)fluoranthene	ND	35	15	ug/kg	
191-24-2	Benzo(g,h,i)perylene	ND	35	17	ug/kg	
207-08-9	Benzo(k)fluoranthene	ND	35	16	ug/kg	
101-55-3	4-Bromophenyl phenyl ether	ND	70	13	ug/kg	
85-68-7	Butyl benzyl phthalate	ND	70	8.5	ug/kg	
92-52-4	1,1'-Biphenyl	ND	70	4.8	ug/kg	
100-52-7	Benzaldehyde [b]	ND	170	8.7	ug/kg	
91-58-7	2-Chloronaphthalene	ND	70	8.3	ug/kg	
106-47-8	4-Chloroaniline	ND	170	13	ug/kg	
86-74-8	Carbazole	ND	70	5.1	ug/kg	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-7(4-4.5)030724		
Lab Sample ID:	JD83927-1	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	93.9
Project:	100 Main Street, White Plains, NY		

ABN TCL List (SOM0 2.0)

CAS No.	Compound	Result	RL	MDL	Units	Q
105-60-2	Caprolactam	ND	70	14	ug/kg	
218-01-9	Chrysene	ND	35	11	ug/kg	
111-91-1	bis(2-Chloroethoxy)methane	ND	70	7.5	ug/kg	
111-44-4	bis(2-Chloroethyl)ether	ND	70	15	ug/kg	
108-60-1	2,2'-Oxybis(1-chloropropane)	ND	70	13	ug/kg	
7005-72-3	4-Chlorophenyl phenyl ether	ND	70	11	ug/kg	
121-14-2	2,4-Dinitrotoluene	ND	35	11	ug/kg	
606-20-2	2,6-Dinitrotoluene	ND	35	18	ug/kg	
91-94-1	3,3'-Dichlorobenzidine	ND	70	29	ug/kg	
123-91-1	1,4-Dioxane	ND	35	23	ug/kg	
53-70-3	Dibenzo(a,h)anthracene	ND	35	15	ug/kg	
132-64-9	Dibenzofuran [a]	ND	70	14	ug/kg	
84-74-2	Di-n-butyl phthalate	ND	70	5.7	ug/kg	
117-84-0	Di-n-octyl phthalate	ND	70	8.7	ug/kg	
84-66-2	Diethyl phthalate	ND	70	7.4	ug/kg	
131-11-3	Dimethyl phthalate	ND	70	6.2	ug/kg	
117-81-7	bis(2-Ethylhexyl)phthalate	ND	70	8.2	ug/kg	
206-44-0	Fluoranthene	ND	35	16	ug/kg	
86-73-7	Fluorene [a]	ND	35	16	ug/kg	
118-74-1	Hexachlorobenzene [a]	ND	70	8.8	ug/kg	
87-68-3	Hexachlorobutadiene [a]	ND	35	14	ug/kg	
77-47-4	Hexachlorocyclopentadiene	ND	350	14	ug/kg	
67-72-1	Hexachloroethane	ND	170	17	ug/kg	
193-39-5	Indeno(1,2,3-cd)pyrene	ND	35	16	ug/kg	
78-59-1	Isophorone	ND	70	7.5	ug/kg	
91-57-6	2-Methylnaphthalene	ND	35	7.9	ug/kg	
88-74-4	2-Nitroaniline	ND	170	8.2	ug/kg	
99-09-2	3-Nitroaniline	ND	170	8.7	ug/kg	
100-01-6	4-Nitroaniline	ND	170	9.0	ug/kg	
91-20-3	Naphthalene [a]	ND	35	9.8	ug/kg	
98-95-3	Nitrobenzene	ND	70	13	ug/kg	
621-64-7	N-Nitroso-di-n-propylamine	ND	70	10	ug/kg	
86-30-6	N-Nitrosodiphenylamine	ND	170	13	ug/kg	
85-01-8	Phenanthrene [a]	ND	35	12	ug/kg	
129-00-0	Pyrene	ND	35	11	ug/kg	
95-94-3	1,2,4,5-Tetrachlorobenzene	ND	170	8.9	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
367-12-4	2-Fluorophenol	33%		10-99%

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-7(4-4.5)030724		
Lab Sample ID:	JD83927-1	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	93.9
Project:	100 Main Street, White Plains, NY		

ABN TCL List (SOM0 2.0)

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
4165-62-2	Phenol-d5	32%		10-96%
118-79-6	2,4,6-Tribromophenol	33%		10-123%
4165-60-0	Nitrobenzene-d5	35%		10-109%
321-60-8	2-Fluorobiphenyl	33%		11-109%
1718-51-0	Terphenyl-d14	42%		10-120%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Unknown	7.66	260	ug/kg	J
	Total TIC, Semi-Volatile		260	ug/kg	J

(a) Associated CCV outside of control limits low. Low-level verification was analyzed to demonstrate system suitability to detect affected analytes. Sample was ND.
(b) Associated CCV outside of control limits high, sample was ND.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-7(4-4.5)030724		
Lab Sample ID:	JD83927-1	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8081B SW846 3570	**Percent Solids:**	93.9
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	4G9737022.D	1	03/11/24 02:56	CP	03/09/24 08:40	OP53021	G4G4306
Run #2							

	Initial Weight	Final Volume
Run #1	5.0 g	10.0 ml
Run #2		

Pesticide TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
309-00-2	Aldrin	ND	0.43	0.083	ug/kg	
319-84-6	alpha-BHC	ND	0.43	0.049	ug/kg	
319-85-7	beta-BHC	ND	0.43	0.062	ug/kg	
319-86-8	delta-BHC	ND	0.43	0.064	ug/kg	
58-89-9	gamma-BHC (Lindane)	ND	0.43	0.075	ug/kg	
5103-71-9	alpha-Chlordane	ND	0.43	0.058	ug/kg	
5103-74-2	gamma-Chlordane	ND	0.43	0.064	ug/kg	
60-57-1	Dieldrin	ND	0.43	0.068	ug/kg	
72-54-8	4,4'-DDD	ND	0.43	0.045	ug/kg	
72-55-9	4,4'-DDE	ND	0.43	0.051	ug/kg	
50-29-3	4,4'-DDT	ND	0.43	0.075	ug/kg	
72-20-8	Endrin	ND	0.43	0.062	ug/kg	
1031-07-8	Endosulfan sulfate	ND	0.43	0.051	ug/kg	
7421-93-4	Endrin aldehyde	ND	0.43	0.12	ug/kg	
959-98-8	Endosulfan-I	ND	0.43	0.058	ug/kg	
33213-65-9	Endosulfan-II	ND	0.43	0.060	ug/kg	
76-44-8	Heptachlor	ND	0.43	0.055	ug/kg	
1024-57-3	Heptachlor epoxide	ND	0.43	0.077	ug/kg	
72-43-5	Methoxychlor	ND	0.43	0.17	ug/kg	
53494-70-5	Endrin ketone	ND	0.43	0.068	ug/kg	
8001-35-2	Toxaphene	ND	5.3	3.5	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
877-09-8	Tetrachloro-m-xylene	87%		66-150%
877-09-8	Tetrachloro-m-xylene	93%		66-150%
2051-24-3	Decachlorobiphenyl	79%		40-150%
2051-24-3	Decachlorobiphenyl	77%		40-150%

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-7(4-4.5)030724		
Lab Sample ID:	JD83927-1	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8082A SW846 3570	**Percent Solids:**	93.9
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	2G231129.D	1	03/10/24 22:44	TP	03/09/24 08:40	OP53022	G2G6058
Run #2							

	Initial Weight	Final Volume
Run #1	5.0 g	10.0 ml
Run #2		

PCB List

CAS No.	Compound	Result	RL	MDL	Units	Q
12674-11-2	Aroclor 1016	ND	21	9.1	ug/kg	
11104-28-2	Aroclor 1221	ND	21	7.2	ug/kg	
11141-16-5	Aroclor 1232	ND	21	18	ug/kg	
53469-21-9	Aroclor 1242	ND	21	13	ug/kg	
12672-29-6	Aroclor 1248	ND	21	4.6	ug/kg	
11097-69-1	Aroclor 1254	ND	21	2.3	ug/kg	
11096-82-5	Aroclor 1260	ND	21	7.3	ug/kg	
11100-14-4	Aroclor 1268	ND	21	2.2	ug/kg	
37324-23-5	Aroclor 1262	ND	21	1.8	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
877-09-8	Tetrachloro-m-xylene	92%		42-159%
877-09-8	Tetrachloro-m-xylene	95%		42-159%
2051-24-3	Decachlorobiphenyl	96%		18-154%
2051-24-3	Decachlorobiphenyl	106%		18-154%

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-7(4-4.5)030724		
Lab Sample ID:	JD83927-1	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
		Percent Solids:	93.9
Project:	100 Main Street, White Plains, NY		

Metals Analysis

Analyte	Result	RL	Units	DF	Prep	Analyzed	By	Method	Prep Method
Aluminum	5060	53	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Antimony	< 2.1	2.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Arsenic	< 2.1	2.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Barium	34.0	21	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Beryllium	0.24	0.21	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Cadmium	< 0.53	0.53	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Calcium	18500	530	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Chromium	10.7	1.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Cobalt	< 5.3	5.3	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Copper	11.6	2.6	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Iron	10600	53	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Lead	3.3	2.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Magnesium	11700	530	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Manganese	173	1.6	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Mercury	< 0.034	0.034	mg/kg	1	03/13/24	03/14/24	LM	SW846 7471B [1]	SW846 7471B [4]
Nickel	9.3	4.2	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Potassium	1550	1100	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Selenium	< 2.1	2.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Silver	< 0.53	0.53	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Sodium	< 1100	1100	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Thallium	< 1.1	1.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Vanadium	15.4	5.3	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Zinc	26.2	5.3	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]

(1) Instrument QC Batch: MA55688
(2) Instrument QC Batch: MA55691
(3) Prep QC Batch: MP45216
(4) Prep QC Batch: MP45278

RL = Reporting Limit

Report of Analysis

Client Sample ID:	SB-7(4-4.5)030724		
Lab Sample ID:	JD83927-1	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
		Percent Solids:	93.9
Project:	100 Main Street, White Plains, NY		

General Chemistry

Analyte	Result	RL	Units	DF	Analyzed	By	Method
Cyanide	< 0.22	0.22	mg/kg	1	03/12/24 20:24	JD	SW846 9012B/LACHAT
Solids, Percent	93.9		%	1	03/08/24 06:00	SC	SM2540 G 18TH ED MOD

RL = Reporting Limit

Report of Analysis

Client Sample ID:	SB-7(7-7.5)030724		
Lab Sample ID:	JD83927-2	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8260D SW846 5035	**Percent Solids:**	88.2
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	1C199829.D	1	03/09/24 02:32	PS	03/08/24 09:00	n/a	V1C8643
Run #2							

	Initial Weight
Run #1	5.9 g
Run #2	

VOA TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
67-64-1	Acetone	ND	9.6	4.0	ug/kg	
71-43-2	Benzene	ND	0.48	0.44	ug/kg	
74-97-5	Bromochloromethane	ND	4.8	0.54	ug/kg	
75-27-4	Bromodichloromethane	ND	1.9	0.41	ug/kg	
75-25-2	Bromoform	ND	4.8	1.3	ug/kg	
74-83-9	Bromomethane	ND	4.8	0.73	ug/kg	
78-93-3	2-Butanone (MEK)	ND	9.6	2.3	ug/kg	
75-15-0	Carbon disulfide	ND	1.9	0.51	ug/kg	
56-23-5	Carbon tetrachloride	ND	1.9	0.59	ug/kg	
108-90-7	Chlorobenzene	ND	1.9	0.44	ug/kg	
75-00-3	Chloroethane	ND	4.8	0.57	ug/kg	
67-66-3	Chloroform	ND	1.9	0.50	ug/kg	
74-87-3	Chloromethane	ND	4.8	1.9	ug/kg	
110-82-7	Cyclohexane	ND	1.9	0.63	ug/kg	
96-12-8	1,2-Dibromo-3-chloropropane	ND	1.9	0.67	ug/kg	
124-48-1	Dibromochloromethane	ND	1.9	0.54	ug/kg	
106-93-4	1,2-Dibromoethane	ND	0.96	0.40	ug/kg	
95-50-1	1,2-Dichlorobenzene	ND	0.96	0.52	ug/kg	
541-73-1	1,3-Dichlorobenzene	ND	0.96	0.48	ug/kg	
106-46-7	1,4-Dichlorobenzene	ND	0.96	0.47	ug/kg	
75-71-8	Dichlorodifluoromethane [a]	ND	4.8	0.70	ug/kg	
75-34-3	1,1-Dichloroethane	ND	0.96	0.48	ug/kg	
107-06-2	1,2-Dichloroethane	ND	0.96	0.45	ug/kg	
75-35-4	1,1-Dichloroethene	ND	0.96	0.63	ug/kg	
156-59-2	cis-1,2-Dichloroethene	ND	0.96	0.81	ug/kg	
156-60-5	trans-1,2-Dichloroethene	ND	0.96	0.59	ug/kg	
78-87-5	1,2-Dichloropropane	ND	1.9	0.45	ug/kg	
10061-01-5	cis-1,3-Dichloropropene	ND	1.9	0.46	ug/kg	
10061-02-6	trans-1,3-Dichloropropene	ND	1.9	0.44	ug/kg	
100-41-4	Ethylbenzene	ND	0.96	0.44	ug/kg	
76-13-1	Freon 113	ND	4.8	2.6	ug/kg	
591-78-6	2-Hexanone	ND	4.8	2.0	ug/kg	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-7(7-7.5)030724		
Lab Sample ID:	JD83927-2	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8260D SW846 5035	**Percent Solids:**	88.2
Project:	100 Main Street, White Plains, NY		

VOA TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
98-82-8	Isopropylbenzene	ND	1.9	1.4	ug/kg	
79-20-9	Methyl Acetate	ND	4.8	1.3	ug/kg	
108-87-2	Methylcyclohexane	ND	1.9	0.84	ug/kg	
1634-04-4	Methyl Tert Butyl Ether	ND	0.96	0.45	ug/kg	
108-10-1	4-Methyl-2-pentanone(MIBK)	ND	4.8	2.2	ug/kg	
75-09-2	Methylene chloride	ND	4.8	2.5	ug/kg	
100-42-5	Styrene	ND	1.9	0.39	ug/kg	
79-34-5	1,1,2,2-Tetrachloroethane	ND	1.9	0.58	ug/kg	
127-18-4	Tetrachloroethene	ND	1.9	0.56	ug/kg	
108-88-3	Toluene	ND	0.96	0.50	ug/kg	
87-61-6	1,2,3-Trichlorobenzene	ND	4.8	2.4	ug/kg	
120-82-1	1,2,4-Trichlorobenzene	ND	4.8	2.4	ug/kg	
71-55-6	1,1,1-Trichloroethane	ND	1.9	0.46	ug/kg	
79-00-5	1,1,2-Trichloroethane	ND	1.9	0.53	ug/kg	
79-01-6	Trichloroethene	ND	0.96	0.73	ug/kg	
75-69-4	Trichlorofluoromethane	ND	4.8	0.66	ug/kg	
75-01-4	Vinyl chloride	ND	1.9	0.46	ug/kg	
	m,p-Xylene	ND	0.96	0.86	ug/kg	
95-47-6	o-Xylene	ND	0.96	0.44	ug/kg	
1330-20-7	Xylene (total)	ND	0.96	0.44	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
1868-53-7	Dibromofluoromethane	104%		80-124%
17060-07-0	1,2-Dichloroethane-D4	105%		75-133%
2037-26-5	Toluene-D8	101%		79-125%
460-00-4	4-Bromofluorobenzene	97%		58-148%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Total TIC, Volatile		0	ug/kg	

(a) Associated CCV outside of control limits high, sample was ND.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-7(7-7.5)030724		
Lab Sample ID:	JD83927-2	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	88.2
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	Z166830.D	1	03/11/24 13:57	JY	03/09/24 18:30	OP53010	EZ8267
Run #2							

	Initial Weight	Final Volume
Run #1	30.8 g	1.0 ml
Run #2		

ABN TCL List (SOM0 2.0)

CAS No.	Compound	Result	RL	MDL	Units	Q
95-57-8	2-Chlorophenol	ND	74	18	ug/kg	
59-50-7	4-Chloro-3-methyl phenol	ND	180	23	ug/kg	
120-83-2	2,4-Dichlorophenol	ND	180	31	ug/kg	
105-67-9	2,4-Dimethylphenol	ND	180	66	ug/kg	
51-28-5	2,4-Dinitrophenol	ND	180	140	ug/kg	
534-52-1	4,6-Dinitro-o-cresol	ND	180	39	ug/kg	
95-48-7	2-Methylphenol	ND	74	24	ug/kg	
	3&4-Methylphenol	ND	74	30	ug/kg	
88-75-5	2-Nitrophenol	ND	180	24	ug/kg	
100-02-7	4-Nitrophenol	ND	370	98	ug/kg	
87-86-5	Pentachlorophenol	ND	150	35	ug/kg	
108-95-2	Phenol	ND	74	19	ug/kg	
58-90-2	2,3,4,6-Tetrachlorophenol	ND	180	24	ug/kg	
95-95-4	2,4,5-Trichlorophenol	ND	180	28	ug/kg	
88-06-2	2,4,6-Trichlorophenol	ND	180	22	ug/kg	
83-32-9	Acenaphthene [a]	ND	37	13	ug/kg	
208-96-8	Acenaphthylene	ND	37	19	ug/kg	
98-86-2	Acetophenone	ND	180	7.9	ug/kg	
120-12-7	Anthracene	ND	37	23	ug/kg	
1912-24-9	Atrazine	ND	74	16	ug/kg	
56-55-3	Benzo(a)anthracene	ND	37	10	ug/kg	
50-32-8	Benzo(a)pyrene	ND	37	17	ug/kg	
205-99-2	Benzo(b)fluoranthene	ND	37	16	ug/kg	
191-24-2	Benzo(g,h,i)perylene	ND	37	18	ug/kg	
207-08-9	Benzo(k)fluoranthene	ND	37	17	ug/kg	
101-55-3	4-Bromophenyl phenyl ether	ND	74	14	ug/kg	
85-68-7	Butyl benzyl phthalate	ND	74	9.0	ug/kg	
92-52-4	1,1'-Biphenyl	ND	74	5.0	ug/kg	
100-52-7	Benzaldehyde [b]	ND	180	9.1	ug/kg	
91-58-7	2-Chloronaphthalene	ND	74	8.8	ug/kg	
106-47-8	4-Chloroaniline	ND	180	13	ug/kg	
86-74-8	Carbazole	ND	74	5.3	ug/kg	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-7(7-7.5)030724		
Lab Sample ID:	JD83927-2	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	88.2
Project:	100 Main Street, White Plains, NY		

ABN TCL List (SOM0 2.0)

CAS No.	Compound	Result	RL	MDL	Units	Q
105-60-2	Caprolactam	ND	74	15	ug/kg	
218-01-9	Chrysene	ND	37	12	ug/kg	
111-91-1	bis(2-Chloroethoxy)methane	ND	74	7.9	ug/kg	
111-44-4	bis(2-Chloroethyl)ether	ND	74	16	ug/kg	
108-60-1	2,2'-Oxybis(1-chloropropane)	ND	74	13	ug/kg	
7005-72-3	4-Chlorophenyl phenyl ether	ND	74	12	ug/kg	
121-14-2	2,4-Dinitrotoluene	ND	37	11	ug/kg	
606-20-2	2,6-Dinitrotoluene	ND	37	18	ug/kg	
91-94-1	3,3'-Dichlorobenzidine	ND	74	31	ug/kg	
123-91-1	1,4-Dioxane	ND	37	24	ug/kg	
53-70-3	Dibenzo(a,h)anthracene	ND	37	16	ug/kg	
132-64-9	Dibenzofuran [a]	ND	74	15	ug/kg	
84-74-2	Di-n-butyl phthalate	ND	74	6.0	ug/kg	
117-84-0	Di-n-octyl phthalate	ND	74	9.2	ug/kg	
84-66-2	Diethyl phthalate	ND	74	7.8	ug/kg	
131-11-3	Dimethyl phthalate	ND	74	6.6	ug/kg	
117-81-7	bis(2-Ethylhexyl)phthalate	ND	74	8.6	ug/kg	
206-44-0	Fluoranthene	ND	37	16	ug/kg	
86-73-7	Fluorene [a]	ND	37	17	ug/kg	
118-74-1	Hexachlorobenzene [a]	ND	74	9.3	ug/kg	
87-68-3	Hexachlorobutadiene [a]	ND	37	15	ug/kg	
77-47-4	Hexachlorocyclopentadiene	ND	370	15	ug/kg	
67-72-1	Hexachloroethane	ND	180	18	ug/kg	
193-39-5	Indeno(1,2,3-cd)pyrene	ND	37	17	ug/kg	
78-59-1	Isophorone	ND	74	7.9	ug/kg	
91-57-6	2-Methylnaphthalene	ND	37	8.3	ug/kg	
88-74-4	2-Nitroaniline	ND	180	8.7	ug/kg	
99-09-2	3-Nitroaniline	ND	180	9.2	ug/kg	
100-01-6	4-Nitroaniline	ND	180	9.5	ug/kg	
91-20-3	Naphthalene [a]	ND	37	10	ug/kg	
98-95-3	Nitrobenzene	ND	74	14	ug/kg	
621-64-7	N-Nitroso-di-n-propylamine	ND	74	11	ug/kg	
86-30-6	N-Nitrosodiphenylamine	ND	180	13	ug/kg	
85-01-8	Phenanthrene [a]	ND	37	12	ug/kg	
129-00-0	Pyrene	ND	37	12	ug/kg	
95-94-3	1,2,4,5-Tetrachlorobenzene	ND	180	9.4	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
367-12-4	2-Fluorophenol	35%		10-99%

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-7(7-7.5)030724		
Lab Sample ID:	JD83927-2	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	88.2
Project:	100 Main Street, White Plains, NY		

ABN TCL List (SOM0 2.0)

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
4165-62-2	Phenol-d5	35%		10-96%
118-79-6	2,4,6-Tribromophenol	36%		10-123%
4165-60-0	Nitrobenzene-d5	38%		10-109%
321-60-8	2-Fluorobiphenyl	34%		11-109%
1718-51-0	Terphenyl-d14	45%		10-120%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Unknown	7.66	370	ug/kg	J
	Total TIC, Semi-Volatile		370	ug/kg	J

(a) Associated CCV outside of control limits low. Low-level verification was analyzed to demonstrate system suitability to detect affected analytes. Sample was ND.
(b) Associated CCV outside of control limits high, sample was ND.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-7(7-7.5)030724		
Lab Sample ID:	JD83927-2	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8081B SW846 3570	**Percent Solids:**	88.2
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	4G9737023.D	1	03/11/24 03:19	CP	03/09/24 08:40	OP53021	G4G4306
Run #2							

	Initial Weight	Final Volume
Run #1	5.5 g	10.0 ml
Run #2		

Pesticide TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
309-00-2	Aldrin	ND	0.41	0.080	ug/kg	
319-84-6	alpha-BHC	ND	0.41	0.047	ug/kg	
319-85-7	beta-BHC	ND	0.41	0.060	ug/kg	
319-86-8	delta-BHC	ND	0.41	0.062	ug/kg	
58-89-9	gamma-BHC (Lindane)	ND	0.41	0.072	ug/kg	
5103-71-9	alpha-Chlordane	ND	0.41	0.056	ug/kg	
5103-74-2	gamma-Chlordane	ND	0.41	0.062	ug/kg	
60-57-1	Dieldrin	ND	0.41	0.066	ug/kg	
72-54-8	4,4'-DDD	ND	0.41	0.043	ug/kg	
72-55-9	4,4'-DDE	ND	0.41	0.049	ug/kg	
50-29-3	4,4'-DDT	ND	0.41	0.072	ug/kg	
72-20-8	Endrin	ND	0.41	0.060	ug/kg	
1031-07-8	Endosulfan sulfate	ND	0.41	0.049	ug/kg	
7421-93-4	Endrin aldehyde	ND	0.41	0.12	ug/kg	
959-98-8	Endosulfan-I	ND	0.41	0.056	ug/kg	
33213-65-9	Endosulfan-II	ND	0.41	0.058	ug/kg	
76-44-8	Heptachlor	ND	0.41	0.054	ug/kg	
1024-57-3	Heptachlor epoxide	ND	0.41	0.074	ug/kg	
72-43-5	Methoxychlor	ND	0.41	0.16	ug/kg	
53494-70-5	Endrin ketone	ND	0.41	0.066	ug/kg	
8001-35-2	Toxaphene	ND	5.2	3.4	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
877-09-8	Tetrachloro-m-xylene	81%		66-150%
877-09-8	Tetrachloro-m-xylene	86%		66-150%
2051-24-3	Decachlorobiphenyl	73%		40-150%
2051-24-3	Decachlorobiphenyl	64%		40-150%

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-7(7-7.5)030724		
Lab Sample ID:	JD83927-2	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8082A SW846 3570	**Percent Solids:**	88.2
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	2G231134.D	1	03/11/24 00:45	TP	03/09/24 08:40	OP53022	G2G6058
Run #2							

	Initial Weight	Final Volume
Run #1	5.5 g	10.0 ml
Run #2		

PCB List

CAS No.	Compound	Result	RL	MDL	Units	Q
12674-11-2	Aroclor 1016	ND	21	8.8	ug/kg	
11104-28-2	Aroclor 1221	ND	21	6.9	ug/kg	
11141-16-5	Aroclor 1232	ND	21	17	ug/kg	
53469-21-9	Aroclor 1242	ND	21	12	ug/kg	
12672-29-6	Aroclor 1248	ND	21	4.5	ug/kg	
11097-69-1	Aroclor 1254	ND	21	2.2	ug/kg	
11096-82-5	Aroclor 1260	ND	21	7.1	ug/kg	
11100-14-4	Aroclor 1268	ND	21	2.1	ug/kg	
37324-23-5	Aroclor 1262	ND	21	1.7	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
877-09-8	Tetrachloro-m-xylene	87%		42-159%
877-09-8	Tetrachloro-m-xylene	89%		42-159%
2051-24-3	Decachlorobiphenyl	99%		18-154%
2051-24-3	Decachlorobiphenyl	108%		18-154%

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-7(7-7.5)030724		
Lab Sample ID:	JD83927-2	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
		Percent Solids:	88.2
Project:	100 Main Street, White Plains, NY		

Metals Analysis

Analyte	Result	RL	Units	DF	Prep	Analyzed	By	Method	Prep Method
Aluminum	6430	56	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Antimony	< 2.2	2.2	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Arsenic	< 2.2	2.2	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Barium	41.8	22	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Beryllium	0.28	0.22	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Cadmium	< 0.56	0.56	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Calcium	7850	560	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Chromium	13.0	1.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Cobalt	6.4	5.6	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Copper	13.7	2.8	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Iron	13900	56	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Lead	2.9	2.2	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Magnesium	6830	560	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Manganese	161	1.7	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Mercury	< 0.035	0.035	mg/kg	1	03/13/24	03/14/24	LM	SW846 7471B [1]	SW846 7471B [4]
Nickel	12.3	4.4	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Potassium	1960	1100	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Selenium	< 2.2	2.2	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Silver	< 0.56	0.56	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Sodium	< 1100	1100	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Thallium	< 1.1	1.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Vanadium	18.7	5.6	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Zinc	30.9	5.6	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]

(1) Instrument QC Batch: MA55688
(2) Instrument QC Batch: MA55691
(3) Prep QC Batch: MP45216
(4) Prep QC Batch: MP45278

RL = Reporting Limit

Report of Analysis

Client Sample ID:	SB-7(7-7.5)030724		
Lab Sample ID:	JD83927-2	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
		Percent Solids:	88.2
Project:	100 Main Street, White Plains, NY		

General Chemistry

Analyte	Result	RL	Units	DF	Analyzed	By	Method
Cyanide	< 0.26	0.26	mg/kg	1	03/12/24 20:25	JD	SW846 9012B/LACHAT
Solids, Percent	88.2		%	1	03/08/24 06:00	SC	SM2540 G 18TH ED MOD

RL = Reporting Limit

Report of Analysis

Client Sample ID:	SB-8(4-4.5)030724		
Lab Sample ID:	JD83927-3	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8260D SW846 5035	**Percent Solids:**	93.2
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	1C199830.D	1	03/09/24 02:59	PS	03/08/24 09:00	n/a	V1C8643
Run #2							

	Initial Weight
Run #1	5.6 g
Run #2	

VOA TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
67-64-1	Acetone	ND	9.6	4.0	ug/kg	
71-43-2	Benzene	ND	0.48	0.44	ug/kg	
74-97-5	Bromochloromethane	ND	4.8	0.54	ug/kg	
75-27-4	Bromodichloromethane	ND	1.9	0.41	ug/kg	
75-25-2	Bromoform	ND	4.8	1.3	ug/kg	
74-83-9	Bromomethane	ND	4.8	0.73	ug/kg	
78-93-3	2-Butanone (MEK)	ND	9.6	2.3	ug/kg	
75-15-0	Carbon disulfide	ND	1.9	0.51	ug/kg	
56-23-5	Carbon tetrachloride	ND	1.9	0.59	ug/kg	
108-90-7	Chlorobenzene	ND	1.9	0.44	ug/kg	
75-00-3	Chloroethane	ND	4.8	0.57	ug/kg	
67-66-3	Chloroform	ND	1.9	0.50	ug/kg	
74-87-3	Chloromethane	ND	4.8	1.9	ug/kg	
110-82-7	Cyclohexane	ND	1.9	0.63	ug/kg	
96-12-8	1,2-Dibromo-3-chloropropane	ND	1.9	0.66	ug/kg	
124-48-1	Dibromochloromethane	ND	1.9	0.54	ug/kg	
106-93-4	1,2-Dibromoethane	ND	0.96	0.40	ug/kg	
95-50-1	1,2-Dichlorobenzene	ND	0.96	0.52	ug/kg	
541-73-1	1,3-Dichlorobenzene	ND	0.96	0.48	ug/kg	
106-46-7	1,4-Dichlorobenzene	ND	0.96	0.47	ug/kg	
75-71-8	Dichlorodifluoromethane [a]	ND	4.8	0.70	ug/kg	
75-34-3	1,1-Dichloroethane	ND	0.96	0.47	ug/kg	
107-06-2	1,2-Dichloroethane	ND	0.96	0.45	ug/kg	
75-35-4	1,1-Dichloroethene	ND	0.96	0.63	ug/kg	
156-59-2	cis-1,2-Dichloroethene	ND	0.96	0.80	ug/kg	
156-60-5	trans-1,2-Dichloroethene	ND	0.96	0.59	ug/kg	
78-87-5	1,2-Dichloropropane	ND	1.9	0.45	ug/kg	
10061-01-5	cis-1,3-Dichloropropene	ND	1.9	0.46	ug/kg	
10061-02-6	trans-1,3-Dichloropropene	ND	1.9	0.44	ug/kg	
100-41-4	Ethylbenzene	ND	0.96	0.43	ug/kg	
76-13-1	Freon 113	ND	4.8	2.6	ug/kg	
591-78-6	2-Hexanone	ND	4.8	2.0	ug/kg	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-8(4-4.5)030724		
Lab Sample ID:	JD83927-3	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8260D SW846 5035	**Percent Solids:**	93.2
Project:	100 Main Street, White Plains, NY		

VOA TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
98-82-8	Isopropylbenzene	ND	1.9	1.4	ug/kg	
79-20-9	Methyl Acetate	ND	4.8	1.3	ug/kg	
108-87-2	Methylcyclohexane	ND	1.9	0.84	ug/kg	
1634-04-4	Methyl Tert Butyl Ether	ND	0.96	0.45	ug/kg	
108-10-1	4-Methyl-2-pentanone(MIBK)	ND	4.8	2.2	ug/kg	
75-09-2	Methylene chloride	ND	4.8	2.5	ug/kg	
100-42-5	Styrene	ND	1.9	0.39	ug/kg	
79-34-5	1,1,2,2-Tetrachloroethane	ND	1.9	0.57	ug/kg	
127-18-4	Tetrachloroethene	ND	1.9	0.56	ug/kg	
108-88-3	Toluene	ND	0.96	0.50	ug/kg	
87-61-6	1,2,3-Trichlorobenzene	ND	4.8	2.4	ug/kg	
120-82-1	1,2,4-Trichlorobenzene	ND	4.8	2.4	ug/kg	
71-55-6	1,1,1-Trichloroethane	ND	1.9	0.46	ug/kg	
79-00-5	1,1,2-Trichloroethane	ND	1.9	0.53	ug/kg	
79-01-6	Trichloroethene	ND	0.96	0.73	ug/kg	
75-69-4	Trichlorofluoromethane	ND	4.8	0.66	ug/kg	
75-01-4	Vinyl chloride	ND	1.9	0.46	ug/kg	
	m,p-Xylene	ND	0.96	0.86	ug/kg	
95-47-6	o-Xylene	ND	0.96	0.44	ug/kg	
1330-20-7	Xylene (total)	ND	0.96	0.44	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
1868-53-7	Dibromofluoromethane	107%		80-124%
17060-07-0	1,2-Dichloroethane-D4	110%		75-133%
2037-26-5	Toluene-D8	103%		79-125%
460-00-4	4-Bromofluorobenzene	101%		58-148%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Total TIC, Volatile		0	ug/kg	

(a) Associated CCV outside of control limits high, sample was ND.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-8(4-4.5)030724		
Lab Sample ID:	JD83927-3	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	93.2
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	Z166831.D	1	03/11/24 14:20	JY	03/09/24 18:30	OP53010	EZ8267
Run #2							

	Initial Weight	Final Volume
Run #1	30.7 g	1.0 ml
Run #2		

ABN TCL List (SOM0 2.0)

CAS No.	Compound	Result	RL	MDL	Units	Q
95-57-8	2-Chlorophenol	ND	70	17	ug/kg	
59-50-7	4-Chloro-3-methyl phenol	ND	170	21	ug/kg	
120-83-2	2,4-Dichlorophenol	ND	170	30	ug/kg	
105-67-9	2,4-Dimethylphenol	ND	170	62	ug/kg	
51-28-5	2,4-Dinitrophenol	ND	170	130	ug/kg	
534-52-1	4,6-Dinitro-o-cresol	ND	170	37	ug/kg	
95-48-7	2-Methylphenol	ND	70	22	ug/kg	
	3&4-Methylphenol	ND	70	29	ug/kg	
88-75-5	2-Nitrophenol	ND	170	23	ug/kg	
100-02-7	4-Nitrophenol	ND	350	93	ug/kg	
87-86-5	Pentachlorophenol	ND	140	33	ug/kg	
108-95-2	Phenol	ND	70	18	ug/kg	
58-90-2	2,3,4,6-Tetrachlorophenol	ND	170	23	ug/kg	
95-95-4	2,4,5-Trichlorophenol	ND	170	26	ug/kg	
88-06-2	2,4,6-Trichlorophenol	ND	170	21	ug/kg	
83-32-9	Acenaphthene [a]	19.9	35	12	ug/kg	J
208-96-8	Acenaphthylene	ND	35	18	ug/kg	
98-86-2	Acetophenone	ND	170	7.5	ug/kg	
120-12-7	Anthracene	47.0	35	21	ug/kg	
1912-24-9	Atrazine	ND	70	15	ug/kg	
56-55-3	Benzo(a)anthracene	166	35	9.9	ug/kg	
50-32-8	Benzo(a)pyrene	166	35	16	ug/kg	
205-99-2	Benzo(b)fluoranthene	187	35	15	ug/kg	
191-24-2	Benzo(g,h,i)perylene	84.0	35	17	ug/kg	
207-08-9	Benzo(k)fluoranthene	56.7	35	16	ug/kg	
101-55-3	4-Bromophenyl phenyl ether	ND	70	13	ug/kg	
85-68-7	Butyl benzyl phthalate	ND	70	8.5	ug/kg	
92-52-4	1,1'-Biphenyl	ND	70	4.8	ug/kg	
100-52-7	Benzaldehyde [b]	ND	170	8.7	ug/kg	
91-58-7	2-Chloronaphthalene	ND	70	8.3	ug/kg	
106-47-8	4-Chloroaniline	ND	170	13	ug/kg	
86-74-8	Carbazole	25.2	70	5.1	ug/kg	J

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-8(4-4.5)030724		
Lab Sample ID:	JD83927-3	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	93.2
Project:	100 Main Street, White Plains, NY		

ABN TCL List (SOM0 2.0)

CAS No.	Compound	Result	RL	MDL	Units	Q
105-60-2	Caprolactam	ND	70	14	ug/kg	
218-01-9	Chrysene	131	35	11	ug/kg	
111-91-1	bis(2-Chloroethoxy)methane	ND	70	7.5	ug/kg	
111-44-4	bis(2-Chloroethyl)ether	ND	70	15	ug/kg	
108-60-1	2,2'-Oxybis(1-chloropropane)	ND	70	13	ug/kg	
7005-72-3	4-Chlorophenyl phenyl ether	ND	70	11	ug/kg	
121-14-2	2,4-Dinitrotoluene	ND	35	11	ug/kg	
606-20-2	2,6-Dinitrotoluene	ND	35	18	ug/kg	
91-94-1	3,3'-Dichlorobenzidine	ND	70	29	ug/kg	
123-91-1	1,4-Dioxane	ND	35	23	ug/kg	
53-70-3	Dibenzo(a,h)anthracene	23.7	35	15	ug/kg	J
132-64-9	Dibenzofuran [a]	14.7	70	14	ug/kg	J
84-74-2	Di-n-butyl phthalate	ND	70	5.7	ug/kg	
117-84-0	Di-n-octyl phthalate	ND	70	8.7	ug/kg	
84-66-2	Diethyl phthalate	ND	70	7.4	ug/kg	
131-11-3	Dimethyl phthalate	ND	70	6.2	ug/kg	
117-81-7	bis(2-Ethylhexyl)phthalate	ND	70	8.2	ug/kg	
206-44-0	Fluoranthene	286	35	16	ug/kg	
86-73-7	Fluorene [a]	24.3	35	16	ug/kg	J
118-74-1	Hexachlorobenzene [c]	ND	70	8.8	ug/kg	
87-68-3	Hexachlorobutadiene [c]	ND	35	14	ug/kg	
77-47-4	Hexachlorocyclopentadiene	ND	350	14	ug/kg	
67-72-1	Hexachloroethane	ND	170	17	ug/kg	
193-39-5	Indeno(1,2,3-cd)pyrene	69.8	35	16	ug/kg	
78-59-1	Isophorone	ND	70	7.5	ug/kg	
91-57-6	2-Methylnaphthalene	ND	35	7.9	ug/kg	
88-74-4	2-Nitroaniline	ND	170	8.2	ug/kg	
99-09-2	3-Nitroaniline	ND	170	8.7	ug/kg	
100-01-6	4-Nitroaniline	ND	170	9.1	ug/kg	
91-20-3	Naphthalene [a]	12.7	35	9.9	ug/kg	J
98-95-3	Nitrobenzene	ND	70	13	ug/kg	
621-64-7	N-Nitroso-di-n-propylamine	ND	70	10	ug/kg	
86-30-6	N-Nitrosodiphenylamine	ND	170	13	ug/kg	
85-01-8	Phenanthrene [a]	185	35	12	ug/kg	
129-00-0	Pyrene	273	35	11	ug/kg	
95-94-3	1,2,4,5-Tetrachlorobenzene	ND	170	8.9	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
367-12-4	2-Fluorophenol	34%		10-99%

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-8(4-4.5)030724		
Lab Sample ID:	JD83927-3	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	93.2
Project:	100 Main Street, White Plains, NY		

ABN TCL List (SOM0 2.0)

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
4165-62-2	Phenol-d5	33%		10-96%
118-79-6	2,4,6-Tribromophenol	36%		10-123%
4165-60-0	Nitrobenzene-d5	37%		10-109%
321-60-8	2-Fluorobiphenyl	34%		11-109%
1718-51-0	Terphenyl-d14	41%		10-120%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Unknown	7.66	160	ug/kg	J
	Total TIC, Semi-Volatile		160	ug/kg	J

(a) Associated CCV outside of control limits low. Low-level verification was analyzed to demonstrate system suitability to detect affected analytes. Estimated value, due to corresponding failure in the batch associated CCV.
(b) Associated CCV outside of control limits high, sample was ND.
(c) Associated CCV outside of control limits low. Low-level verification was analyzed to demonstrate system suitability to detect affected analytes. Sample was ND.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-8(4-4.5)030724		
Lab Sample ID:	JD83927-3	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8081B SW846 3570	**Percent Solids:**	93.2
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	4G9737024.D	1	03/11/24 03:39	CP	03/09/24 08:40	OP53021	G4G4306
Run #2							

	Initial Weight	Final Volume
Run #1	5.3 g	10.0 ml
Run #2		

Pesticide TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
309-00-2	Aldrin	ND	0.40	0.079	ug/kg	
319-84-6	alpha-BHC	ND	0.40	0.047	ug/kg	
319-85-7	beta-BHC	ND	0.40	0.059	ug/kg	
319-86-8	delta-BHC	ND	0.40	0.061	ug/kg	
58-89-9	gamma-BHC (Lindane)	ND	0.40	0.071	ug/kg	
5103-71-9	alpha-Chlordane [a]	0.28	0.40	0.055	ug/kg	J
5103-74-2	gamma-Chlordane	0.30	0.40	0.061	ug/kg	J
60-57-1	Dieldrin	0.33	0.40	0.065	ug/kg	J
72-54-8	4,4'-DDD	0.075	0.40	0.043	ug/kg	J
72-55-9	4,4'-DDE	0.092	0.40	0.049	ug/kg	J
50-29-3	4,4'-DDT	0.33	0.40	0.071	ug/kg	J
72-20-8	Endrin	ND	0.40	0.059	ug/kg	
1031-07-8	Endosulfan sulfate	ND	0.40	0.049	ug/kg	
7421-93-4	Endrin aldehyde	ND	0.40	0.12	ug/kg	
959-98-8	Endosulfan-I	ND	0.40	0.055	ug/kg	
33213-65-9	Endosulfan-II	ND	0.40	0.057	ug/kg	
76-44-8	Heptachlor	ND	0.40	0.053	ug/kg	
1024-57-3	Heptachlor epoxide	ND	0.40	0.073	ug/kg	
72-43-5	Methoxychlor	ND	0.40	0.16	ug/kg	
53494-70-5	Endrin ketone	ND	0.40	0.065	ug/kg	
8001-35-2	Toxaphene	ND	5.1	3.3	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
877-09-8	Tetrachloro-m-xylene	86%		66-150%
877-09-8	Tetrachloro-m-xylene	94%		66-150%
2051-24-3	Decachlorobiphenyl	80%		40-150%
2051-24-3	Decachlorobiphenyl	86%		40-150%

(a) More than 40 % RPD for detected concentrations between the two GC columns.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-8(4-4.5)030724		
Lab Sample ID:	JD83927-3	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8082A SW846 3570	**Percent Solids:**	93.2
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	2G231135.D	1	03/11/24 01:09	TP	03/09/24 08:40	OP53022	G2G6058
Run #2							

	Initial Weight	Final Volume
Run #1	5.3 g	10.0 ml
Run #2		

PCB List

CAS No.	Compound	Result	RL	MDL	Units	Q
12674-11-2	Aroclor 1016	ND	20	8.6	ug/kg	
11104-28-2	Aroclor 1221	ND	20	6.8	ug/kg	
11141-16-5	Aroclor 1232	ND	20	17	ug/kg	
53469-21-9	Aroclor 1242	ND	20	12	ug/kg	
12672-29-6	Aroclor 1248	ND	20	4.4	ug/kg	
11097-69-1	Aroclor 1254	ND	20	2.2	ug/kg	
11096-82-5	Aroclor 1260	ND	20	7.0	ug/kg	
11100-14-4	Aroclor 1268	ND	20	2.0	ug/kg	
37324-23-5	Aroclor 1262	ND	20	1.7	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
877-09-8	Tetrachloro-m-xylene	92%		42-159%
877-09-8	Tetrachloro-m-xylene	90%		42-159%
2051-24-3	Decachlorobiphenyl	105%		18-154%
2051-24-3	Decachlorobiphenyl	113%		18-154%

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-8(4-4.5)030724		
Lab Sample ID:	JD83927-3	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
		Percent Solids:	93.2
Project:	100 Main Street, White Plains, NY		

Metals Analysis

Analyte	Result	RL	Units	DF	Prep	Analyzed	By	Method	Prep Method
Aluminum	7080	55	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Antimony	< 2.2	2.2	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Arsenic	< 2.2	2.2	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Barium	79.8	22	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Beryllium	0.34	0.22	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Cadmium	< 0.55	0.55	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Calcium	11600	550	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Chromium	16.0	1.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Cobalt	8.7	5.5	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Copper	15.6	2.8	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Iron	13600	55	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Lead	23.1	2.2	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Magnesium	7500	550	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Manganese	299	1.7	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Mercury	0.054	0.033	mg/kg	1	03/13/24	03/14/24	LM	SW846 7471B [1]	SW846 7471B [4]
Nickel	12.3	4.4	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Potassium	1950	1100	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Selenium	< 2.2	2.2	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Silver	< 0.55	0.55	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Sodium	< 1100	1100	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Thallium	< 1.1	1.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Vanadium	21.2	5.5	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Zinc	40.1	5.5	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]

(1) Instrument QC Batch: MA55688
(2) Instrument QC Batch: MA55691
(3) Prep QC Batch: MP45216
(4) Prep QC Batch: MP45278

RL = Reporting Limit

Report of Analysis

Client Sample ID:	SB-8(4-4.5)030724		
Lab Sample ID:	JD83927-3	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
		Percent Solids:	93.2
Project:	100 Main Street, White Plains, NY		

General Chemistry

Analyte	Result	RL	Units	DF	Analyzed	By	Method
Cyanide	< 0.26	0.26	mg/kg	1	03/12/24 20:27	JD	SW846 9012B/LACHAT
Solids, Percent	93.2		%	1	03/08/24 06:00	SC	SM2540 G 18TH ED MOD

RL = Reporting Limit

Report of Analysis

Client Sample ID:	SB-8(7.5-8)030724		
Lab Sample ID:	JD83927-4	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8260D SW846 5035	**Percent Solids:**	89.2
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	1C199831.D	1	03/09/24 03:25	PS	03/08/24 09:00	n/a	V1C8643
Run #2							

	Initial Weight
Run #1	5.9 g
Run #2	

VOA TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
67-64-1	Acetone	ND	9.5	3.9	ug/kg	
71-43-2	Benzene	ND	0.48	0.43	ug/kg	
74-97-5	Bromochloromethane	ND	4.8	0.53	ug/kg	
75-27-4	Bromodichloromethane	ND	1.9	0.41	ug/kg	
75-25-2	Bromoform	ND	4.8	1.3	ug/kg	
74-83-9	Bromomethane	ND	4.8	0.73	ug/kg	
78-93-3	2-Butanone (MEK)	ND	9.5	2.3	ug/kg	
75-15-0	Carbon disulfide	ND	1.9	0.51	ug/kg	
56-23-5	Carbon tetrachloride	ND	1.9	0.59	ug/kg	
108-90-7	Chlorobenzene	ND	1.9	0.44	ug/kg	
75-00-3	Chloroethane	ND	4.8	0.56	ug/kg	
67-66-3	Chloroform	ND	1.9	0.49	ug/kg	
74-87-3	Chloromethane	ND	4.8	1.9	ug/kg	
110-82-7	Cyclohexane	ND	1.9	0.62	ug/kg	
96-12-8	1,2-Dibromo-3-chloropropane	ND	1.9	0.66	ug/kg	
124-48-1	Dibromochloromethane	ND	1.9	0.53	ug/kg	
106-93-4	1,2-Dibromoethane	ND	0.95	0.40	ug/kg	
95-50-1	1,2-Dichlorobenzene	ND	0.95	0.52	ug/kg	
541-73-1	1,3-Dichlorobenzene	ND	0.95	0.47	ug/kg	
106-46-7	1,4-Dichlorobenzene	ND	0.95	0.47	ug/kg	
75-71-8	Dichlorodifluoromethane [a]	ND	4.8	0.69	ug/kg	
75-34-3	1,1-Dichloroethane	ND	0.95	0.47	ug/kg	
107-06-2	1,2-Dichloroethane	ND	0.95	0.45	ug/kg	
75-35-4	1,1-Dichloroethene	ND	0.95	0.62	ug/kg	
156-59-2	cis-1,2-Dichloroethene	ND	0.95	0.80	ug/kg	
156-60-5	trans-1,2-Dichloroethene	ND	0.95	0.58	ug/kg	
78-87-5	1,2-Dichloropropane	ND	1.9	0.45	ug/kg	
10061-01-5	cis-1,3-Dichloropropene	ND	1.9	0.45	ug/kg	
10061-02-6	trans-1,3-Dichloropropene	ND	1.9	0.43	ug/kg	
100-41-4	Ethylbenzene	ND	0.95	0.43	ug/kg	
76-13-1	Freon 113	ND	4.8	2.5	ug/kg	
591-78-6	2-Hexanone	ND	4.8	2.0	ug/kg	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-8(7.5-8)030724		
Lab Sample ID:	JD83927-4	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8260D SW846 5035	**Percent Solids:**	89.2
Project:	100 Main Street, White Plains, NY		

VOA TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
98-82-8	Isopropylbenzene	ND	1.9	1.3	ug/kg	
79-20-9	Methyl Acetate	ND	4.8	1.3	ug/kg	
108-87-2	Methylcyclohexane	ND	1.9	0.83	ug/kg	
1634-04-4	Methyl Tert Butyl Ether	ND	0.95	0.45	ug/kg	
108-10-1	4-Methyl-2-pentanone(MIBK)	ND	4.8	2.2	ug/kg	
75-09-2	Methylene chloride	ND	4.8	2.5	ug/kg	
100-42-5	Styrene	ND	1.9	0.38	ug/kg	
79-34-5	1,1,2,2-Tetrachloroethane	ND	1.9	0.57	ug/kg	
127-18-4	Tetrachloroethene	ND	1.9	0.55	ug/kg	
108-88-3	Toluene	ND	0.95	0.50	ug/kg	
87-61-6	1,2,3-Trichlorobenzene	ND	4.8	2.4	ug/kg	
120-82-1	1,2,4-Trichlorobenzene	ND	4.8	2.4	ug/kg	
71-55-6	1,1,1-Trichloroethane	ND	1.9	0.46	ug/kg	
79-00-5	1,1,2-Trichloroethane	ND	1.9	0.53	ug/kg	
79-01-6	Trichloroethene	ND	0.95	0.72	ug/kg	
75-69-4	Trichlorofluoromethane	ND	4.8	0.65	ug/kg	
75-01-4	Vinyl chloride	ND	1.9	0.46	ug/kg	
	m,p-Xylene	ND	0.95	0.85	ug/kg	
95-47-6	o-Xylene	ND	0.95	0.44	ug/kg	
1330-20-7	Xylene (total)	ND	0.95	0.44	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
1868-53-7	Dibromofluoromethane	107%		80-124%
17060-07-0	1,2-Dichloroethane-D4	111%		75-133%
2037-26-5	Toluene-D8	96%		79-125%
460-00-4	4-Bromofluorobenzene	98%		58-148%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Total TIC, Volatile		0	ug/kg	

(a) Associated CCV outside of control limits high, sample was ND.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-8(7.5-8)030724		
Lab Sample ID:	JD83927-4	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	89.2
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	Z166832.D	1	03/11/24 14:43	JY	03/09/24 18:30	OP53010	EZ8267
Run #2							

	Initial Weight	Final Volume
Run #1	30.2 g	1.0 ml
Run #2		

ABN TCL List (SOM0 2.0)

CAS No.	Compound	Result	RL	MDL	Units	Q
95-57-8	2-Chlorophenol	ND	74	18	ug/kg	
59-50-7	4-Chloro-3-methyl phenol	ND	190	23	ug/kg	
120-83-2	2,4-Dichlorophenol	ND	190	32	ug/kg	
105-67-9	2,4-Dimethylphenol	ND	190	66	ug/kg	
51-28-5	2,4-Dinitrophenol	ND	190	140	ug/kg	
534-52-1	4,6-Dinitro-o-cresol	ND	190	40	ug/kg	
95-48-7	2-Methylphenol	ND	74	24	ug/kg	
	3&4-Methylphenol	ND	74	31	ug/kg	
88-75-5	2-Nitrophenol	ND	190	25	ug/kg	
100-02-7	4-Nitrophenol	ND	370	99	ug/kg	
87-86-5	Pentachlorophenol	ND	150	35	ug/kg	
108-95-2	Phenol	ND	74	19	ug/kg	
58-90-2	2,3,4,6-Tetrachlorophenol	ND	190	25	ug/kg	
95-95-4	2,4,5-Trichlorophenol	ND	190	28	ug/kg	
88-06-2	2,4,6-Trichlorophenol	ND	190	22	ug/kg	
83-32-9	Acenaphthene [a]	ND	37	13	ug/kg	
208-96-8	Acenaphthylene	ND	37	19	ug/kg	
98-86-2	Acetophenone	ND	190	8.0	ug/kg	
120-12-7	Anthracene	ND	37	23	ug/kg	
1912-24-9	Atrazine	ND	74	16	ug/kg	
56-55-3	Benzo(a)anthracene	67.4	37	11	ug/kg	
50-32-8	Benzo(a)pyrene	62.7	37	17	ug/kg	
205-99-2	Benzo(b)fluoranthene	76.6	37	16	ug/kg	
191-24-2	Benzo(g,h,i)perylene	41.3	37	19	ug/kg	
207-08-9	Benzo(k)fluoranthene	20.5	37	17	ug/kg	J
101-55-3	4-Bromophenyl phenyl ether	ND	74	14	ug/kg	
85-68-7	Butyl benzyl phthalate	ND	74	9.1	ug/kg	
92-52-4	1,1'-Biphenyl	ND	74	5.1	ug/kg	
100-52-7	Benzaldehyde [b]	ND	190	9.2	ug/kg	
91-58-7	2-Chloronaphthalene	ND	74	8.8	ug/kg	
106-47-8	4-Chloroaniline	ND	190	13	ug/kg	
86-74-8	Carbazole	ND	74	5.4	ug/kg	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-8(7.5-8)030724		
Lab Sample ID:	JD83927-4	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	89.2
Project:	100 Main Street, White Plains, NY		

ABN TCL List (SOM0 2.0)

CAS No.	Compound	Result	RL	MDL	Units	Q
105-60-2	Caprolactam	ND	74	15	ug/kg	
218-01-9	Chrysene	45.3	37	12	ug/kg	
111-91-1	bis(2-Chloroethoxy)methane	ND	74	7.9	ug/kg	
111-44-4	bis(2-Chloroethyl)ether	ND	74	16	ug/kg	
108-60-1	2,2'-Oxybis(1-chloropropane)	ND	74	13	ug/kg	
7005-72-3	4-Chlorophenyl phenyl ether	ND	74	12	ug/kg	
121-14-2	2,4-Dinitrotoluene	ND	37	12	ug/kg	
606-20-2	2,6-Dinitrotoluene	ND	37	19	ug/kg	
91-94-1	3,3'-Dichlorobenzidine	ND	74	31	ug/kg	
123-91-1	1,4-Dioxane	ND	37	25	ug/kg	
53-70-3	Dibenzo(a,h)anthracene	ND	37	16	ug/kg	
132-64-9	Dibenzofuran [a]	ND	74	15	ug/kg	
84-74-2	Di-n-butyl phthalate	ND	74	6.1	ug/kg	
117-84-0	Di-n-octyl phthalate	ND	74	9.2	ug/kg	
84-66-2	Diethyl phthalate	ND	74	7.9	ug/kg	
131-11-3	Dimethyl phthalate	ND	74	6.6	ug/kg	
117-81-7	bis(2-Ethylhexyl)phthalate	ND	74	8.7	ug/kg	
206-44-0	Fluoranthene	87.9	37	17	ug/kg	
86-73-7	Fluorene [a]	ND	37	17	ug/kg	
118-74-1	Hexachlorobenzene [a]	ND	74	9.4	ug/kg	
87-68-3	Hexachlorobutadiene [a]	ND	37	15	ug/kg	
77-47-4	Hexachlorocyclopentadiene	ND	370	15	ug/kg	
67-72-1	Hexachloroethane	ND	190	18	ug/kg	
193-39-5	Indeno(1,2,3-cd)pyrene	33.1	37	17	ug/kg	J
78-59-1	Isophorone	ND	74	7.9	ug/kg	
91-57-6	2-Methylnaphthalene	ND	37	8.4	ug/kg	
88-74-4	2-Nitroaniline	ND	190	8.8	ug/kg	
99-09-2	3-Nitroaniline	ND	190	9.3	ug/kg	
100-01-6	4-Nitroaniline	ND	190	9.6	ug/kg	
91-20-3	Naphthalene [a]	ND	37	10	ug/kg	
98-95-3	Nitrobenzene	ND	74	14	ug/kg	
621-64-7	N-Nitroso-di-n-propylamine	ND	74	11	ug/kg	
86-30-6	N-Nitrosodiphenylamine	ND	190	14	ug/kg	
85-01-8	Phenanthrene [c]	48.0	37	12	ug/kg	
129-00-0	Pyrene	94.7	37	12	ug/kg	
95-94-3	1,2,4,5-Tetrachlorobenzene	ND	190	9.4	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
367-12-4	2-Fluorophenol	44%		10-99%

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-8(7.5-8)030724		
Lab Sample ID:	JD83927-4	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	89.2
Project:	100 Main Street, White Plains, NY		

ABN TCL List (SOM0 2.0)

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
4165-62-2	Phenol-d5	45%		10-96%
118-79-6	2,4,6-Tribromophenol	45%		10-123%
4165-60-0	Nitrobenzene-d5	46%		10-109%
321-60-8	2-Fluorobiphenyl	42%		11-109%
1718-51-0	Terphenyl-d14	55%		10-120%

CAS No.	Tentatively Identified Compounds [d]	R.T.	Est. Conc.	Units	Q
	Unknown	7.66	240	ug/kg	J
	Total TIC, Semi-Volatile		240	ug/kg	J

(a) Associated CCV outside of control limits low. Low-level verification was analyzed to demonstrate system suitability to detect affected analytes. Sample was ND.
(b) Associated CCV outside of control limits high, sample was ND.
(c) Associated CCV outside of control limits low. Low-level verification was analyzed to demonstrate system suitability to detect affected analytes. Estimated value, due to corresponding failure in the batch associated CCV.
(d) reprint tic

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-8(7.5-8)030724		
Lab Sample ID:	JD83927-4	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8081B SW846 3570	**Percent Solids:**	89.2
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	4G9737025.D	1	03/11/24 03:58	CP	03/09/24 08:40	OP53021	G4G4306
Run #2							

	Initial Weight	Final Volume
Run #1	5.2 g	10.0 ml
Run #2		

Pesticide TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
309-00-2	Aldrin	ND	0.43	0.084	ug/kg	
319-84-6	alpha-BHC	ND	0.43	0.050	ug/kg	
319-85-7	beta-BHC	ND	0.43	0.063	ug/kg	
319-86-8	delta-BHC	ND	0.43	0.065	ug/kg	
58-89-9	gamma-BHC (Lindane)	ND	0.43	0.075	ug/kg	
5103-71-9	alpha-Chlordane [a]	0.52	0.43	0.058	ug/kg	
5103-74-2	gamma-Chlordane	0.52	0.43	0.065	ug/kg	
60-57-1	Dieldrin	0.66	0.43	0.069	ug/kg	
72-54-8	4,4'-DDD	0.12	0.43	0.045	ug/kg	J
72-55-9	4,4'-DDE	0.15	0.43	0.052	ug/kg	J
50-29-3	4,4'-DDT	0.59	0.43	0.075	ug/kg	
72-20-8	Endrin	ND	0.43	0.063	ug/kg	
1031-07-8	Endosulfan sulfate	ND	0.43	0.052	ug/kg	
7421-93-4	Endrin aldehyde	ND	0.43	0.13	ug/kg	
959-98-8	Endosulfan-I	ND	0.43	0.058	ug/kg	
33213-65-9	Endosulfan-II	ND	0.43	0.060	ug/kg	
76-44-8	Heptachlor	ND	0.43	0.056	ug/kg	
1024-57-3	Heptachlor epoxide	ND	0.43	0.078	ug/kg	
72-43-5	Methoxychlor	ND	0.43	0.17	ug/kg	
53494-70-5	Endrin ketone	ND	0.43	0.069	ug/kg	
8001-35-2	Toxaphene	ND	5.4	3.6	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
877-09-8	Tetrachloro-m-xylene	83%		66-150%
877-09-8	Tetrachloro-m-xylene	93%		66-150%
2051-24-3	Decachlorobiphenyl	75%		40-150%
2051-24-3	Decachlorobiphenyl	100%		40-150%

(a) More than 40 % RPD for detected concentrations between the two GC columns.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-8(7.5-8)030724		
Lab Sample ID:	JD83927-4	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8082A SW846 3570	**Percent Solids:**	89.2
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	2G231136.D	1	03/11/24 01:34	TP	03/09/24 08:40	OP53022	G2G6058
Run #2							

	Initial Weight	Final Volume
Run #1	5.2 g	10.0 ml
Run #2		

PCB List

CAS No.	Compound	Result	RL	MDL	Units	Q
12674-11-2	Aroclor 1016	ND	22	9.2	ug/kg	
11104-28-2	Aroclor 1221	ND	22	7.2	ug/kg	
11141-16-5	Aroclor 1232	ND	22	18	ug/kg	
53469-21-9	Aroclor 1242	ND	22	13	ug/kg	
12672-29-6	Aroclor 1248	ND	22	4.7	ug/kg	
11097-69-1	Aroclor 1254	ND	22	2.3	ug/kg	
11096-82-5	Aroclor 1260	ND	22	7.4	ug/kg	
11100-14-4	Aroclor 1268	ND	22	2.2	ug/kg	
37324-23-5	Aroclor 1262	ND	22	1.8	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
877-09-8	Tetrachloro-m-xylene	91%		42-159%
877-09-8	Tetrachloro-m-xylene	92%		42-159%
2051-24-3	Decachlorobiphenyl	107%		18-154%
2051-24-3	Decachlorobiphenyl	117%		18-154%

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-8(7.5-8)030724		
Lab Sample ID:	JD83927-4	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
		Percent Solids:	89.2
Project:	100 Main Street, White Plains, NY		

Metals Analysis

Analyte	Result	RL	Units	DF	Prep	Analyzed	By	Method	Prep Method
Aluminum	6660	57	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Antimony	< 2.3	2.3	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Arsenic	< 2.3	2.3	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Barium	53.1	23	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Beryllium	0.32	0.23	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Cadmium	< 0.57	0.57	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Calcium	11500	570	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Chromium	13.7	1.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Cobalt	< 5.7	5.7	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Copper	14.8	2.9	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Iron	12700	57	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Lead	28.6	2.3	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Magnesium	7330	570	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Manganese	212	1.7	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Mercury	0.10	0.035	mg/kg	1	03/13/24	03/14/24	LM	SW846 7471B [1]	SW846 7471B [4]
Nickel	11.1	4.6	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Potassium	1760	1100	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Selenium	< 2.3	2.3	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Silver	< 0.57	0.57	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Sodium	< 1100	1100	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Thallium	< 1.1	1.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Vanadium	19.5	5.7	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Zinc	59.3	5.7	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]

(1) Instrument QC Batch: MA55688
(2) Instrument QC Batch: MA55691
(3) Prep QC Batch: MP45216
(4) Prep QC Batch: MP45278

RL = Reporting Limit

Report of Analysis

Client Sample ID:	SB-8(7.5-8)030724		
Lab Sample ID:	JD83927-4	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
		Percent Solids:	89.2
Project:	100 Main Street, White Plains, NY		

General Chemistry

Analyte	Result	RL	Units	DF	Analyzed	By	Method
Cyanide	< 0.24	0.24	mg/kg	1	03/12/24 20:28	JD	SW846 9012B/LACHAT
Solids, Percent	89.2		%	1	03/08/24 06:00	SC	SM2540 G 18TH ED MOD

RL = Reporting Limit

Report of Analysis

Client Sample ID:	SB-9(3.5-4)030724		
Lab Sample ID:	JD83927-5	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8260D SW846 5035	**Percent Solids:**	95.4
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	1C199832.D	1	03/09/24 03:51	PS	03/08/24 09:00	n/a	V1C8643
Run #2							

	Initial Weight
Run #1	4.8 g
Run #2	

VOA TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
67-64-1	Acetone	ND	11	4.5	ug/kg	
71-43-2	Benzene	ND	0.55	0.50	ug/kg	
74-97-5	Bromochloromethane	ND	5.5	0.61	ug/kg	
75-27-4	Bromodichloromethane	ND	2.2	0.47	ug/kg	
75-25-2	Bromoform	ND	5.5	1.5	ug/kg	
74-83-9	Bromomethane	ND	5.5	0.83	ug/kg	
78-93-3	2-Butanone (MEK)	ND	11	2.7	ug/kg	
75-15-0	Carbon disulfide	ND	2.2	0.58	ug/kg	
56-23-5	Carbon tetrachloride	ND	2.2	0.67	ug/kg	
108-90-7	Chlorobenzene	ND	2.2	0.50	ug/kg	
75-00-3	Chloroethane	ND	5.5	0.65	ug/kg	
67-66-3	Chloroform	ND	2.2	0.57	ug/kg	
74-87-3	Chloromethane	ND	5.5	2.1	ug/kg	
110-82-7	Cyclohexane	ND	2.2	0.72	ug/kg	
96-12-8	1,2-Dibromo-3-chloropropane	ND	2.2	0.76	ug/kg	
124-48-1	Dibromochloromethane	ND	2.2	0.61	ug/kg	
106-93-4	1,2-Dibromoethane	ND	1.1	0.46	ug/kg	
95-50-1	1,2-Dichlorobenzene	ND	1.1	0.60	ug/kg	
541-73-1	1,3-Dichlorobenzene	ND	1.1	0.54	ug/kg	
106-46-7	1,4-Dichlorobenzene	ND	1.1	0.54	ug/kg	
75-71-8	Dichlorodifluoromethane [a]	ND	5.5	0.79	ug/kg	
75-34-3	1,1-Dichloroethane	ND	1.1	0.54	ug/kg	
107-06-2	1,2-Dichloroethane	ND	1.1	0.51	ug/kg	
75-35-4	1,1-Dichloroethene	ND	1.1	0.72	ug/kg	
156-59-2	cis-1,2-Dichloroethene	ND	1.1	0.92	ug/kg	
156-60-5	trans-1,2-Dichloroethene	ND	1.1	0.67	ug/kg	
78-87-5	1,2-Dichloropropane	ND	2.2	0.52	ug/kg	
10061-01-5	cis-1,3-Dichloropropene	ND	2.2	0.52	ug/kg	
10061-02-6	trans-1,3-Dichloropropene	ND	2.2	0.50	ug/kg	
100-41-4	Ethylbenzene	ND	1.1	0.49	ug/kg	
76-13-1	Freon 113	ND	5.5	2.9	ug/kg	
591-78-6	2-Hexanone	ND	5.5	2.3	ug/kg	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-9(3.5-4)030724		
Lab Sample ID:	JD83927-5	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8260D SW846 5035	**Percent Solids:**	95.4
Project:	100 Main Street, White Plains, NY		

VOA TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
98-82-8	Isopropylbenzene	ND	2.2	1.6	ug/kg	
79-20-9	Methyl Acetate	ND	5.5	1.5	ug/kg	
108-87-2	Methylcyclohexane	ND	2.2	0.96	ug/kg	
1634-04-4	Methyl Tert Butyl Ether	ND	1.1	0.51	ug/kg	
108-10-1	4-Methyl-2-pentanone(MIBK)	ND	5.5	2.5	ug/kg	
75-09-2	Methylene chloride	ND	5.5	2.8	ug/kg	
100-42-5	Styrene	ND	2.2	0.44	ug/kg	
79-34-5	1,1,2,2-Tetrachloroethane	ND	2.2	0.65	ug/kg	
127-18-4	Tetrachloroethene	ND	2.2	0.63	ug/kg	
108-88-3	Toluene	ND	1.1	0.57	ug/kg	
87-61-6	1,2,3-Trichlorobenzene	ND	5.5	2.7	ug/kg	
120-82-1	1,2,4-Trichlorobenzene	ND	5.5	2.7	ug/kg	
71-55-6	1,1,1-Trichloroethane	ND	2.2	0.53	ug/kg	
79-00-5	1,1,2-Trichloroethane	ND	2.2	0.60	ug/kg	
79-01-6	Trichloroethene	ND	1.1	0.83	ug/kg	
75-69-4	Trichlorofluoromethane	ND	5.5	0.75	ug/kg	
75-01-4	Vinyl chloride	ND	2.2	0.53	ug/kg	
	m,p-Xylene	ND	1.1	0.98	ug/kg	
95-47-6	o-Xylene	ND	1.1	0.50	ug/kg	
1330-20-7	Xylene (total)	ND	1.1	0.50	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
1868-53-7	Dibromofluoromethane	103%		80-124%
17060-07-0	1,2-Dichloroethane-D4	110%		75-133%
2037-26-5	Toluene-D8	97%		79-125%
460-00-4	4-Bromofluorobenzene	98%		58-148%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Total TIC, Volatile		0	ug/kg	

(a) Associated CCV outside of control limits high, sample was ND.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-9(3.5-4)030724		
Lab Sample ID:	JD83927-5	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	95.4
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	Z166833.D	1	03/11/24 15:06	JY	03/09/24 18:30	OP53010	EZ8267
Run #2							

	Initial Weight	Final Volume
Run #1	30.8 g	1.0 ml
Run #2		

ABN TCL List (SOM0 2.0)

CAS No.	Compound	Result	RL	MDL	Units	Q
95-57-8	2-Chlorophenol	ND	68	17	ug/kg	
59-50-7	4-Chloro-3-methyl phenol	ND	170	21	ug/kg	
120-83-2	2,4-Dichlorophenol	ND	170	29	ug/kg	
105-67-9	2,4-Dimethylphenol	ND	170	61	ug/kg	
51-28-5	2,4-Dinitrophenol	ND	170	130	ug/kg	
534-52-1	4,6-Dinitro-o-cresol	ND	170	36	ug/kg	
95-48-7	2-Methylphenol	ND	68	22	ug/kg	
	3&4-Methylphenol	ND	68	28	ug/kg	
88-75-5	2-Nitrophenol	ND	170	22	ug/kg	
100-02-7	4-Nitrophenol	ND	340	91	ug/kg	
87-86-5	Pentachlorophenol	ND	140	32	ug/kg	
108-95-2	Phenol	ND	68	18	ug/kg	
58-90-2	2,3,4,6-Tetrachlorophenol	ND	170	23	ug/kg	
95-95-4	2,4,5-Trichlorophenol	ND	170	25	ug/kg	
88-06-2	2,4,6-Trichlorophenol	ND	170	20	ug/kg	
83-32-9	Acenaphthene [a]	ND	34	12	ug/kg	
208-96-8	Acenaphthylene	ND	34	17	ug/kg	
98-86-2	Acetophenone	ND	170	7.3	ug/kg	
120-12-7	Anthracene	ND	34	21	ug/kg	
1912-24-9	Atrazine	ND	68	15	ug/kg	
56-55-3	Benzo(a)anthracene	30.6	34	9.6	ug/kg	J
50-32-8	Benzo(a)pyrene	34.4	34	15	ug/kg	
205-99-2	Benzo(b)fluoranthene	33.7	34	15	ug/kg	J
191-24-2	Benzo(g,h,i)perylene	18.3	34	17	ug/kg	J
207-08-9	Benzo(k)fluoranthene	ND	34	16	ug/kg	
101-55-3	4-Bromophenyl phenyl ether	ND	68	13	ug/kg	
85-68-7	Butyl benzyl phthalate	ND	68	8.3	ug/kg	
92-52-4	1,1'-Biphenyl	ND	68	4.7	ug/kg	
100-52-7	Benzaldehyde [b]	ND	170	8.4	ug/kg	
91-58-7	2-Chloronaphthalene	ND	68	8.1	ug/kg	
106-47-8	4-Chloroaniline	ND	170	12	ug/kg	
86-74-8	Carbazole	ND	68	4.9	ug/kg	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-9(3.5-4)030724		
Lab Sample ID:	JD83927-5	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	95.4
Project:	100 Main Street, White Plains, NY		

ABN TCL List (SOM0 2.0)

CAS No.	Compound	Result	RL	MDL	Units	Q
105-60-2	Caprolactam	ND	68	13	ug/kg	
218-01-9	Chrysene	22.4	34	11	ug/kg	J
111-91-1	bis(2-Chloroethoxy)methane	ND	68	7.3	ug/kg	
111-44-4	bis(2-Chloroethyl)ether	ND	68	15	ug/kg	
108-60-1	2,2'-Oxybis(1-chloropropane)	ND	68	12	ug/kg	
7005-72-3	4-Chlorophenyl phenyl ether	ND	68	11	ug/kg	
121-14-2	2,4-Dinitrotoluene	ND	34	11	ug/kg	
606-20-2	2,6-Dinitrotoluene	ND	34	17	ug/kg	
91-94-1	3,3'-Dichlorobenzidine	ND	68	28	ug/kg	
123-91-1	1,4-Dioxane	ND	34	22	ug/kg	
53-70-3	Dibenzo(a,h)anthracene	ND	34	15	ug/kg	
132-64-9	Dibenzofuran [a]	ND	68	14	ug/kg	
84-74-2	Di-n-butyl phthalate	ND	68	5.5	ug/kg	
117-84-0	Di-n-octyl phthalate	ND	68	8.5	ug/kg	
84-66-2	Diethyl phthalate	ND	68	7.2	ug/kg	
131-11-3	Dimethyl phthalate	ND	68	6.1	ug/kg	
117-81-7	bis(2-Ethylhexyl)phthalate	ND	68	8.0	ug/kg	
206-44-0	Fluoranthene	45.1	34	15	ug/kg	
86-73-7	Fluorene [a]	ND	34	16	ug/kg	
118-74-1	Hexachlorobenzene [a]	ND	68	8.6	ug/kg	
87-68-3	Hexachlorobutadiene [a]	ND	34	14	ug/kg	
77-47-4	Hexachlorocyclopentadiene	ND	340	14	ug/kg	
67-72-1	Hexachloroethane	ND	170	17	ug/kg	
193-39-5	Indeno(1,2,3-cd)pyrene	16.2	34	16	ug/kg	J
78-59-1	Isophorone	ND	68	7.3	ug/kg	
91-57-6	2-Methylnaphthalene	ND	34	7.7	ug/kg	
88-74-4	2-Nitroaniline	ND	170	8.0	ug/kg	
99-09-2	3-Nitroaniline	ND	170	8.5	ug/kg	
100-01-6	4-Nitroaniline	ND	170	8.8	ug/kg	
91-20-3	Naphthalene [a]	ND	34	9.6	ug/kg	
98-95-3	Nitrobenzene	ND	68	13	ug/kg	
621-64-7	N-Nitroso-di-n-propylamine	ND	68	9.8	ug/kg	
86-30-6	N-Nitrosodiphenylamine	ND	170	12	ug/kg	
85-01-8	Phenanthrene [c]	30.1	34	11	ug/kg	J
129-00-0	Pyrene	48.2	34	11	ug/kg	
95-94-3	1,2,4,5-Tetrachlorobenzene	ND	170	8.6	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
367-12-4	2-Fluorophenol	41%		10-99%

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-9(3.5-4)030724		
Lab Sample ID:	JD83927-5	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	95.4
Project:	100 Main Street, White Plains, NY		

ABN TCL List (SOM0 2.0)

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
4165-62-2	Phenol-d5	43%		10-96%
118-79-6	2,4,6-Tribromophenol	43%		10-123%
4165-60-0	Nitrobenzene-d5	44%		10-109%
321-60-8	2-Fluorobiphenyl	42%		11-109%
1718-51-0	Terphenyl-d14	54%		10-120%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	n-Hexadecanoic acid	7.19	230	ug/kg	J
	Unknown	7.66	350	ug/kg	J
	Unknown acid	7.92	160	ug/kg	J
	System artifact	9.30	140	ug/kg	J
	Unknown	12.37	150	ug/kg	J
	Total TIC, Semi-Volatile		890	ug/kg	J

(a) Associated CCV outside of control limits low. Low-level verification was analyzed to demonstrate system suitability to detect affected analytes. Sample was ND.
(b) Associated CCV outside of control limits high, sample was ND.
(c) Associated CCV outside of control limits low. Low-level verification was analyzed to demonstrate system suitability to detect affected analytes. Estimated value, due to corresponding failure in the batch associated CCV.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-9(3.5-4)030724		
Lab Sample ID:	JD83927-5	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8081B SW846 3570	**Percent Solids:**	95.4
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	4G9737026.D	1	03/11/24 04:18	CP	03/09/24 08:40	OP53021	G4G4306
Run #2							

	Initial Weight	Final Volume
Run #1	5.4 g	10.0 ml
Run #2		

Pesticide TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
309-00-2	Aldrin	ND	0.39	0.076	ug/kg	
319-84-6	alpha-BHC	ND	0.39	0.045	ug/kg	
319-85-7	beta-BHC	ND	0.39	0.056	ug/kg	
319-86-8	delta-BHC	ND	0.39	0.058	ug/kg	
58-89-9	gamma-BHC (Lindane)	ND	0.39	0.068	ug/kg	
5103-71-9	alpha-Chlordane [a]	0.11	0.39	0.052	ug/kg	J
5103-74-2	gamma-Chlordane	0.13	0.39	0.058	ug/kg	J
60-57-1	Dieldrin	0.083	0.39	0.062	ug/kg	J
72-54-8	4,4'-DDD	ND	0.39	0.041	ug/kg	
72-55-9	4,4'-DDE	ND	0.39	0.047	ug/kg	
50-29-3	4,4'-DDT	0.095	0.39	0.068	ug/kg	J
72-20-8	Endrin	ND	0.39	0.056	ug/kg	
1031-07-8	Endosulfan sulfate	ND	0.39	0.047	ug/kg	
7421-93-4	Endrin aldehyde	ND	0.39	0.11	ug/kg	
959-98-8	Endosulfan-I	ND	0.39	0.052	ug/kg	
33213-65-9	Endosulfan-II	ND	0.39	0.054	ug/kg	
76-44-8	Heptachlor	ND	0.39	0.050	ug/kg	
1024-57-3	Heptachlor epoxide	ND	0.39	0.070	ug/kg	
72-43-5	Methoxychlor	ND	0.39	0.15	ug/kg	
53494-70-5	Endrin ketone	ND	0.39	0.062	ug/kg	
8001-35-2	Toxaphene	ND	4.9	3.2	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
877-09-8	Tetrachloro-m-xylene	84%		66-150%
877-09-8	Tetrachloro-m-xylene	94%		66-150%
2051-24-3	Decachlorobiphenyl	71%		40-150%
2051-24-3	Decachlorobiphenyl	87%		40-150%

(a) More than 40 % RPD for detected concentrations between the two GC columns.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-9(3.5-4)030724		
Lab Sample ID:	JD83927-5	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8082A SW846 3570	**Percent Solids:**	95.4
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	2G231128.D	1	03/10/24 22:19	TP	03/09/24 08:40	OP53022	G2G6058
Run #2							

	Initial Weight	Final Volume
Run #1	5.4 g	10.0 ml
Run #2		

PCB List

CAS No.	Compound	Result	RL	MDL	Units	Q
12674-11-2	Aroclor 1016	ND	19	8.2	ug/kg	
11104-28-2	Aroclor 1221	ND	19	6.5	ug/kg	
11141-16-5	Aroclor 1232	ND	19	16	ug/kg	
53469-21-9	Aroclor 1242	ND	19	12	ug/kg	
12672-29-6	Aroclor 1248	ND	19	4.2	ug/kg	
11097-69-1	Aroclor 1254	ND	19	2.1	ug/kg	
11096-82-5	Aroclor 1260	ND	19	6.7	ug/kg	
11100-14-4	Aroclor 1268	ND	19	2.0	ug/kg	
37324-23-5	Aroclor 1262	ND	19	1.6	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
877-09-8	Tetrachloro-m-xylene	92%		42-159%
877-09-8	Tetrachloro-m-xylene	93%		42-159%
2051-24-3	Decachlorobiphenyl	100%		18-154%
2051-24-3	Decachlorobiphenyl	110%		18-154%

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID: SB-9(3.5-4)030724
Lab Sample ID: JD83927-5
Matrix: SO - Soil
Project: 100 Main Street, White Plains, NY

Date Sampled: 03/07/24
Date Received: 03/07/24
Percent Solids: 95.4

Metals Analysis

Analyte	Result	RL	Units	DF	Prep	Analyzed	By	Method	Prep Method
Aluminum	5920	52	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Antimony	< 2.1	2.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Arsenic	< 2.1	2.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Barium	39.3	21	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Beryllium	0.29	0.21	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Cadmium	< 0.52	0.52	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Calcium	5180	520	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Chromium	12.6	1.0	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Cobalt	5.6	5.2	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Copper	12.4	2.6	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Iron	12800	52	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Lead	11.7	2.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Magnesium	5030	520	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Manganese	201	1.6	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Mercury	< 0.029	0.029	mg/kg	1	03/13/24	03/14/24	LM	SW846 7471B [1]	SW846 7471B [4]
Nickel	10.0	4.2	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Potassium	1360	1000	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Selenium	< 2.1	2.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Silver	< 0.52	0.52	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Sodium	< 1000	1000	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Thallium	< 1.0	1.0	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Vanadium	17.4	5.2	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Zinc	33.8	5.2	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]

(1) Instrument QC Batch: MA55688
(2) Instrument QC Batch: MA55691
(3) Prep QC Batch: MP45216
(4) Prep QC Batch: MP45278

RL = Reporting Limit

Report of Analysis

Client Sample ID:	SB-9(3.5-4)030724		
Lab Sample ID:	JD83927-5	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
		Percent Solids:	95.4
Project:	100 Main Street, White Plains, NY		

General Chemistry

Analyte	Result	RL	Units	DF	Analyzed	By	Method
Cyanide	< 0.23	0.23	mg/kg	1	03/12/24 20:29	JD	SW846 9012B/LACHAT
Solids, Percent	95.4		%	1	03/08/24 06:00	SC	SM2540 G 18TH ED MOD

RL = Reporting Limit

Report of Analysis

Client Sample ID:	SB-10(3.5-4)030724		
Lab Sample ID:	JD83927-6	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8260D SW846 5035	**Percent Solids:**	92.8
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	1C199833.D	1	03/09/24 04:17	PS	03/08/24 09:00	n/a	V1C8643
Run #2							

	Initial Weight
Run #1	5.4 g
Run #2	

VOA TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
67-64-1	Acetone	ND	10	4.1	ug/kg	
71-43-2	Benzene	ND	0.50	0.45	ug/kg	
74-97-5	Bromochloromethane	ND	5.0	0.56	ug/kg	
75-27-4	Bromodichloromethane	ND	2.0	0.43	ug/kg	
75-25-2	Bromoform	ND	5.0	1.4	ug/kg	
74-83-9	Bromomethane	ND	5.0	0.76	ug/kg	
78-93-3	2-Butanone (MEK)	ND	10	2.4	ug/kg	
75-15-0	Carbon disulfide	ND	2.0	0.53	ug/kg	
56-23-5	Carbon tetrachloride	ND	2.0	0.62	ug/kg	
108-90-7	Chlorobenzene	ND	2.0	0.46	ug/kg	
75-00-3	Chloroethane	ND	5.0	0.59	ug/kg	
67-66-3	Chloroform	ND	2.0	0.52	ug/kg	
74-87-3	Chloromethane	ND	5.0	2.0	ug/kg	
110-82-7	Cyclohexane	ND	2.0	0.66	ug/kg	
96-12-8	1,2-Dibromo-3-chloropropane	ND	2.0	0.69	ug/kg	
124-48-1	Dibromochloromethane	ND	2.0	0.56	ug/kg	
106-93-4	1,2-Dibromoethane	ND	1.0	0.42	ug/kg	
95-50-1	1,2-Dichlorobenzene	ND	1.0	0.54	ug/kg	
541-73-1	1,3-Dichlorobenzene	ND	1.0	0.49	ug/kg	
106-46-7	1,4-Dichlorobenzene	ND	1.0	0.49	ug/kg	
75-71-8	Dichlorodifluoromethane [a]	ND	5.0	0.73	ug/kg	
75-34-3	1,1-Dichloroethane	ND	1.0	0.49	ug/kg	
107-06-2	1,2-Dichloroethane	ND	1.0	0.47	ug/kg	
75-35-4	1,1-Dichloroethene	ND	1.0	0.65	ug/kg	
156-59-2	cis-1,2-Dichloroethene	ND	1.0	0.84	ug/kg	
156-60-5	trans-1,2-Dichloroethene	ND	1.0	0.61	ug/kg	
78-87-5	1,2-Dichloropropane	ND	2.0	0.47	ug/kg	
10061-01-5	cis-1,3-Dichloropropene	ND	2.0	0.47	ug/kg	
10061-02-6	trans-1,3-Dichloropropene	ND	2.0	0.46	ug/kg	
100-41-4	Ethylbenzene	ND	1.0	0.45	ug/kg	
76-13-1	Freon 113	ND	5.0	2.7	ug/kg	
591-78-6	2-Hexanone	ND	5.0	2.1	ug/kg	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-10(3.5-4)030724		
Lab Sample ID:	JD83927-6	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8260D SW846 5035	**Percent Solids:**	92.8
Project:	100 Main Street, White Plains, NY		

VOA TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
98-82-8	Isopropylbenzene	ND	2.0	1.4	ug/kg	
79-20-9	Methyl Acetate	ND	5.0	1.4	ug/kg	
108-87-2	Methylcyclohexane	ND	2.0	0.87	ug/kg	
1634-04-4	Methyl Tert Butyl Ether	ND	1.0	0.47	ug/kg	
108-10-1	4-Methyl-2-pentanone(MIBK)	ND	5.0	2.3	ug/kg	
75-09-2	Methylene chloride	ND	5.0	2.6	ug/kg	
100-42-5	Styrene	ND	2.0	0.40	ug/kg	
79-34-5	1,1,2,2-Tetrachloroethane	ND	2.0	0.60	ug/kg	
127-18-4	Tetrachloroethene	ND	2.0	0.58	ug/kg	
108-88-3	Toluene	ND	1.0	0.52	ug/kg	
87-61-6	1,2,3-Trichlorobenzene	ND	5.0	2.5	ug/kg	
120-82-1	1,2,4-Trichlorobenzene	ND	5.0	2.5	ug/kg	
71-55-6	1,1,1-Trichloroethane	ND	2.0	0.48	ug/kg	
79-00-5	1,1,2-Trichloroethane	ND	2.0	0.55	ug/kg	
79-01-6	Trichloroethene	ND	1.0	0.76	ug/kg	
75-69-4	Trichlorofluoromethane	ND	5.0	0.68	ug/kg	
75-01-4	Vinyl chloride	ND	2.0	0.48	ug/kg	
	m,p-Xylene	ND	1.0	0.89	ug/kg	
95-47-6	o-Xylene	ND	1.0	0.46	ug/kg	
1330-20-7	Xylene (total)	ND	1.0	0.46	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
1868-53-7	Dibromofluoromethane	106%		80-124%
17060-07-0	1,2-Dichloroethane-D4	116%		75-133%
2037-26-5	Toluene-D8	99%		79-125%
460-00-4	4-Bromofluorobenzene	93%		58-148%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Total TIC, Volatile		0	ug/kg	

(a) Associated CCV outside of control limits high, sample was ND.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-10(3.5-4)030724		
Lab Sample ID:	JD83927-6	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	92.8
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	Z166834.D	1	03/11/24 15:29	JY	03/09/24 18:30	OP53010	EZ8267
Run #2							

	Initial Weight	Final Volume
Run #1	30.4 g	1.0 ml
Run #2		

ABN TCL List (SOM0 2.0)

CAS No.	Compound	Result	RL	MDL	Units	Q
95-57-8	2-Chlorophenol	ND	71	18	ug/kg	
59-50-7	4-Chloro-3-methyl phenol	ND	180	22	ug/kg	
120-83-2	2,4-Dichlorophenol	ND	180	30	ug/kg	
105-67-9	2,4-Dimethylphenol	ND	180	63	ug/kg	
51-28-5	2,4-Dinitrophenol	ND	180	130	ug/kg	
534-52-1	4,6-Dinitro-o-cresol	ND	180	38	ug/kg	
95-48-7	2-Methylphenol	ND	71	23	ug/kg	
	3&4-Methylphenol	ND	71	29	ug/kg	
88-75-5	2-Nitrophenol	ND	180	23	ug/kg	
100-02-7	4-Nitrophenol	ND	350	95	ug/kg	
87-86-5	Pentachlorophenol	ND	140	33	ug/kg	
108-95-2	Phenol	ND	71	19	ug/kg	
58-90-2	2,3,4,6-Tetrachlorophenol	ND	180	23	ug/kg	
95-95-4	2,4,5-Trichlorophenol	ND	180	27	ug/kg	
88-06-2	2,4,6-Trichlorophenol	ND	180	21	ug/kg	
83-32-9	Acenaphthene [a]	ND	35	12	ug/kg	
208-96-8	Acenaphthylene	ND	35	18	ug/kg	
98-86-2	Acetophenone	ND	180	7.6	ug/kg	
120-12-7	Anthracene	ND	35	22	ug/kg	
1912-24-9	Atrazine	ND	71	15	ug/kg	
56-55-3	Benzo(a)anthracene	14.7	35	10	ug/kg	J
50-32-8	Benzo(a)pyrene	19.1	35	16	ug/kg	J
205-99-2	Benzo(b)fluoranthene	18.2	35	16	ug/kg	J
191-24-2	Benzo(g,h,i)perylene	ND	35	18	ug/kg	
207-08-9	Benzo(k)fluoranthene	ND	35	17	ug/kg	
101-55-3	4-Bromophenyl phenyl ether	ND	71	14	ug/kg	
85-68-7	Butyl benzyl phthalate	ND	71	8.6	ug/kg	
92-52-4	1,1'-Biphenyl	ND	71	4.9	ug/kg	
100-52-7	Benzaldehyde [b]	ND	180	8.8	ug/kg	
91-58-7	2-Chloronaphthalene	ND	71	8.4	ug/kg	
106-47-8	4-Chloroaniline	ND	180	13	ug/kg	
86-74-8	Carbazole	ND	71	5.1	ug/kg	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-10(3.5-4)030724		
Lab Sample ID:	JD83927-6	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	92.8
Project:	100 Main Street, White Plains, NY		

ABN TCL List (SOM0 2.0)

CAS No.	Compound	Result	RL	MDL	Units	Q
105-60-2	Caprolactam	ND	71	14	ug/kg	
218-01-9	Chrysene	ND	35	11	ug/kg	
111-91-1	bis(2-Chloroethoxy)methane	ND	71	7.6	ug/kg	
111-44-4	bis(2-Chloroethyl)ether	ND	71	15	ug/kg	
108-60-1	2,2'-Oxybis(1-chloropropane)	ND	71	13	ug/kg	
7005-72-3	4-Chlorophenyl phenyl ether	ND	71	11	ug/kg	
121-14-2	2,4-Dinitrotoluene	ND	35	11	ug/kg	
606-20-2	2,6-Dinitrotoluene	ND	35	18	ug/kg	
91-94-1	3,3'-Dichlorobenzidine	ND	71	30	ug/kg	
123-91-1	1,4-Dioxane	ND	35	23	ug/kg	
53-70-3	Dibenzo(a,h)anthracene	ND	35	16	ug/kg	
132-64-9	Dibenzofuran [a]	ND	71	14	ug/kg	
84-74-2	Di-n-butyl phthalate	ND	71	5.8	ug/kg	
117-84-0	Di-n-octyl phthalate	ND	71	8.8	ug/kg	
84-66-2	Diethyl phthalate	ND	71	7.6	ug/kg	
131-11-3	Dimethyl phthalate	ND	71	6.3	ug/kg	
117-81-7	bis(2-Ethylhexyl)phthalate	ND	71	8.3	ug/kg	
206-44-0	Fluoranthene	18.8	35	16	ug/kg	J
86-73-7	Fluorene [a]	ND	35	16	ug/kg	
118-74-1	Hexachlorobenzene [a]	ND	71	9.0	ug/kg	
87-68-3	Hexachlorobutadiene [a]	ND	35	14	ug/kg	
77-47-4	Hexachlorocyclopentadiene	ND	350	14	ug/kg	
67-72-1	Hexachloroethane	ND	180	18	ug/kg	
193-39-5	Indeno(1,2,3-cd)pyrene	ND	35	17	ug/kg	
78-59-1	Isophorone	ND	71	7.6	ug/kg	
91-57-6	2-Methylnaphthalene	ND	35	8.0	ug/kg	
88-74-4	2-Nitroaniline	ND	180	8.4	ug/kg	
99-09-2	3-Nitroaniline	ND	180	8.9	ug/kg	
100-01-6	4-Nitroaniline	ND	180	9.2	ug/kg	
91-20-3	Naphthalene [a]	ND	35	10	ug/kg	
98-95-3	Nitrobenzene	ND	71	14	ug/kg	
621-64-7	N-Nitroso-di-n-propylamine	ND	71	10	ug/kg	
86-30-6	N-Nitrosodiphenylamine	ND	180	13	ug/kg	
85-01-8	Phenanthrene [a]	ND	35	12	ug/kg	
129-00-0	Pyrene	19.4	35	11	ug/kg	J
95-94-3	1,2,4,5-Tetrachlorobenzene	ND	180	9.0	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
367-12-4	2-Fluorophenol	24%		10-99%

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-10(3.5-4)030724		
Lab Sample ID:	JD83927-6	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	92.8
Project:	100 Main Street, White Plains, NY		

ABN TCL List (SOM0 2.0)

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
4165-62-2	Phenol-d5	26%		10-96%
118-79-6	2,4,6-Tribromophenol	29%		10-123%
4165-60-0	Nitrobenzene-d5	26%		10-109%
321-60-8	2-Fluorobiphenyl	26%		11-109%
1718-51-0	Terphenyl-d14	34%		10-120%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Total TIC, Semi-Volatile		0	ug/kg	

(a) Associated CCV outside of control limits low. Low-level verification was analyzed to demonstrate system suitability to detect affected analytes. Sample was ND.
(b) Associated CCV outside of control limits high, sample was ND.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-10(3.5-4)030724		
Lab Sample ID:	JD83927-6	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8081B SW846 3570	**Percent Solids:**	92.8
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	4G9737027.D	1	03/11/24 04:37	CP	03/09/24 08:40	OP53021	G4G4306
Run #2							

	Initial Weight	Final Volume
Run #1	5.4 g	10.0 ml
Run #2		

Pesticide TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
309-00-2	Aldrin	ND	0.40	0.078	ug/kg	
319-84-6	alpha-BHC	ND	0.40	0.046	ug/kg	
319-85-7	beta-BHC	ND	0.40	0.058	ug/kg	
319-86-8	delta-BHC	ND	0.40	0.060	ug/kg	
58-89-9	gamma-BHC (Lindane)	ND	0.40	0.070	ug/kg	
5103-71-9	alpha-Chlordane [a]	0.22	0.40	0.054	ug/kg	J
5103-74-2	gamma-Chlordane	0.24	0.40	0.060	ug/kg	J
60-57-1	Dieldrin	ND	0.40	0.064	ug/kg	
72-54-8	4,4'-DDD	ND	0.40	0.042	ug/kg	
72-55-9	4,4'-DDE	ND	0.40	0.048	ug/kg	
50-29-3	4,4'-DDT	0.084	0.40	0.070	ug/kg	J
72-20-8	Endrin	ND	0.40	0.058	ug/kg	
1031-07-8	Endosulfan sulfate	ND	0.40	0.048	ug/kg	
7421-93-4	Endrin aldehyde	ND	0.40	0.12	ug/kg	
959-98-8	Endosulfan-I	ND	0.40	0.054	ug/kg	
33213-65-9	Endosulfan-II	ND	0.40	0.056	ug/kg	
76-44-8	Heptachlor	ND	0.40	0.052	ug/kg	
1024-57-3	Heptachlor epoxide	ND	0.40	0.072	ug/kg	
72-43-5	Methoxychlor	ND	0.40	0.16	ug/kg	
53494-70-5	Endrin ketone	ND	0.40	0.064	ug/kg	
8001-35-2	Toxaphene	ND	5.0	3.3	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
877-09-8	Tetrachloro-m-xylene	102%		66-150%
877-09-8	Tetrachloro-m-xylene	110%		66-150%
2051-24-3	Decachlorobiphenyl	89%		40-150%
2051-24-3	Decachlorobiphenyl	89%		40-150%

(a) More than 40 % RPD for detected concentrations between the two GC columns.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-10(3.5-4)030724		
Lab Sample ID:	JD83927-6	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8082A SW846 3570	**Percent Solids:**	92.8
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	2G231137.D	1	03/11/24 01:58	TP	03/09/24 08:40	OP53022	G2G6058
Run #2							

	Initial Weight	Final Volume
Run #1	5.4 g	10.0 ml
Run #2		

PCB List

CAS No.	Compound	Result	RL	MDL	Units	Q
12674-11-2	Aroclor 1016	ND	20	8.5	ug/kg	
11104-28-2	Aroclor 1221	ND	20	6.7	ug/kg	
11141-16-5	Aroclor 1232	ND	20	17	ug/kg	
53469-21-9	Aroclor 1242	ND	20	12	ug/kg	
12672-29-6	Aroclor 1248	ND	20	4.3	ug/kg	
11097-69-1	Aroclor 1254	ND	20	2.2	ug/kg	
11096-82-5	Aroclor 1260	ND	20	6.9	ug/kg	
11100-14-4	Aroclor 1268	ND	20	2.0	ug/kg	
37324-23-5	Aroclor 1262	ND	20	1.7	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
877-09-8	Tetrachloro-m-xylene	95%		42-159%
877-09-8	Tetrachloro-m-xylene	98%		42-159%
2051-24-3	Decachlorobiphenyl	105%		18-154%
2051-24-3	Decachlorobiphenyl	109%		18-154%

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-10(3.5-4)030724		
Lab Sample ID:	JD83927-6	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
		Percent Solids:	92.8
Project:	100 Main Street, White Plains, NY		

Metals Analysis

Analyte	Result	RL	Units	DF	Prep	Analyzed	By	Method	Prep Method
Aluminum	6350	54	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Antimony	< 2.2	2.2	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Arsenic	< 2.2	2.2	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Barium	46.5	22	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Beryllium	0.29	0.22	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Cadmium	0.77	0.54	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Calcium	11300	540	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Chromium	13.1	1.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Cobalt	5.5	5.4	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Copper	13.9	2.7	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Iron	12800	54	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Lead	7.4	2.2	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Magnesium	8210	540	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Manganese	209	1.6	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Mercury	< 0.031	0.031	mg/kg	1	03/13/24	03/14/24	LM	SW846 7471B [1]	SW846 7471B [4]
Nickel	11.8	4.3	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Potassium	1850	1100	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Selenium	< 2.2	2.2	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Silver	< 0.54	0.54	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Sodium	< 1100	1100	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Thallium	< 1.1	1.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Vanadium	19.0	5.4	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Zinc	33.9	5.4	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]

(1) Instrument QC Batch: MA55688
(2) Instrument QC Batch: MA55691
(3) Prep QC Batch: MP45216
(4) Prep QC Batch: MP45278

RL = Reporting Limit

Report of Analysis

Client Sample ID:	SB-10(3.5-4)030724		
Lab Sample ID:	JD83927-6	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
		Percent Solids:	92.8
Project:	100 Main Street, White Plains, NY		

General Chemistry

Analyte	Result	RL	Units	DF	Analyzed	By	Method
Cyanide	< 0.24	0.24	mg/kg	1	03/12/24 20:30	JD	SW846 9012B/LACHAT
Solids, Percent	92.8		%	1	03/08/24 06:00	SC	SM2540 G 18TH ED MOD

RL = Reporting Limit

Report of Analysis

Client Sample ID:	SB-10(7-5.5)030724		
Lab Sample ID:	JD83927-7	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8260D SW846 5035	**Percent Solids:**	86.6
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	1C199834.D	1	03/09/24 04:43	PS	03/08/24 09:00	n/a	V1C8643
Run #2							

	Initial Weight
Run #1	6.1 g
Run #2	

VOA TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
67-64-1	Acetone	ND	9.5	3.9	ug/kg	
71-43-2	Benzene	ND	0.47	0.43	ug/kg	
74-97-5	Bromochloromethane	ND	4.7	0.53	ug/kg	
75-27-4	Bromodichloromethane	ND	1.9	0.41	ug/kg	
75-25-2	Bromoform	ND	4.7	1.3	ug/kg	
74-83-9	Bromomethane	ND	4.7	0.72	ug/kg	
78-93-3	2-Butanone (MEK)	ND	9.5	2.3	ug/kg	
75-15-0	Carbon disulfide	ND	1.9	0.51	ug/kg	
56-23-5	Carbon tetrachloride	ND	1.9	0.58	ug/kg	
108-90-7	Chlorobenzene	ND	1.9	0.43	ug/kg	
75-00-3	Chloroethane	ND	4.7	0.56	ug/kg	
67-66-3	Chloroform	ND	1.9	0.49	ug/kg	
74-87-3	Chloromethane	ND	4.7	1.9	ug/kg	
110-82-7	Cyclohexane	ND	1.9	0.62	ug/kg	
96-12-8	1,2-Dibromo-3-chloropropane	ND	1.9	0.66	ug/kg	
124-48-1	Dibromochloromethane	ND	1.9	0.53	ug/kg	
106-93-4	1,2-Dibromoethane	ND	0.95	0.40	ug/kg	
95-50-1	1,2-Dichlorobenzene	ND	0.95	0.52	ug/kg	
541-73-1	1,3-Dichlorobenzene	ND	0.95	0.47	ug/kg	
106-46-7	1,4-Dichlorobenzene	ND	0.95	0.47	ug/kg	
75-71-8	Dichlorodifluoromethane [a]	ND	4.7	0.69	ug/kg	
75-34-3	1,1-Dichloroethane	ND	0.95	0.47	ug/kg	
107-06-2	1,2-Dichloroethane	ND	0.95	0.44	ug/kg	
75-35-4	1,1-Dichloroethene	ND	0.95	0.62	ug/kg	
156-59-2	cis-1,2-Dichloroethene	ND	0.95	0.80	ug/kg	
156-60-5	trans-1,2-Dichloroethene	ND	0.95	0.58	ug/kg	
78-87-5	1,2-Dichloropropane	ND	1.9	0.45	ug/kg	
10061-01-5	cis-1,3-Dichloropropene	ND	1.9	0.45	ug/kg	
10061-02-6	trans-1,3-Dichloropropene	ND	1.9	0.43	ug/kg	
100-41-4	Ethylbenzene	ND	0.95	0.43	ug/kg	
76-13-1	Freon 113	ND	4.7	2.5	ug/kg	
591-78-6	2-Hexanone	ND	4.7	2.0	ug/kg	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-10(7-5.5)030724		
Lab Sample ID:	JD83927-7	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8260D SW846 5035	**Percent Solids:**	86.6
Project:	100 Main Street, White Plains, NY		

VOA TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
98-82-8	Isopropylbenzene	ND	1.9	1.3	ug/kg	
79-20-9	Methyl Acetate	ND	4.7	1.3	ug/kg	
108-87-2	Methylcyclohexane	ND	1.9	0.83	ug/kg	
1634-04-4	Methyl Tert Butyl Ether	ND	0.95	0.44	ug/kg	
108-10-1	4-Methyl-2-pentanone(MIBK)	ND	4.7	2.1	ug/kg	
75-09-2	Methylene chloride	ND	4.7	2.5	ug/kg	
100-42-5	Styrene	ND	1.9	0.38	ug/kg	
79-34-5	1,1,2,2-Tetrachloroethane	ND	1.9	0.57	ug/kg	
127-18-4	Tetrachloroethene	ND	1.9	0.55	ug/kg	
108-88-3	Toluene	ND	0.95	0.50	ug/kg	
87-61-6	1,2,3-Trichlorobenzene	ND	4.7	2.4	ug/kg	
120-82-1	1,2,4-Trichlorobenzene	ND	4.7	2.4	ug/kg	
71-55-6	1,1,1-Trichloroethane	ND	1.9	0.46	ug/kg	
79-00-5	1,1,2-Trichloroethane	ND	1.9	0.52	ug/kg	
79-01-6	Trichloroethene	ND	0.95	0.72	ug/kg	
75-69-4	Trichlorofluoromethane	ND	4.7	0.65	ug/kg	
75-01-4	Vinyl chloride	ND	1.9	0.46	ug/kg	
	m,p-Xylene	ND	0.95	0.85	ug/kg	
95-47-6	o-Xylene	ND	0.95	0.43	ug/kg	
1330-20-7	Xylene (total)	ND	0.95	0.43	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
1868-53-7	Dibromofluoromethane	104%		80-124%
17060-07-0	1,2-Dichloroethane-D4	110%		75-133%
2037-26-5	Toluene-D8	97%		79-125%
460-00-4	4-Bromofluorobenzene	97%		58-148%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Total TIC, Volatile		0	ug/kg	

(a) Associated CCV outside of control limits high, sample was ND.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-10(7-5.5)030724		
Lab Sample ID:	JD83927-7	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	86.6
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	Z166835.D	1	03/11/24 15:52	JY	03/09/24 18:30	OP53010	EZ8267
Run #2							

	Initial Weight	Final Volume
Run #1	30.6 g	1.0 ml
Run #2		

ABN TCL List (SOM0 2.0)

CAS No.	Compound	Result	RL	MDL	Units	Q
95-57-8	2-Chlorophenol	ND	75	19	ug/kg	
59-50-7	4-Chloro-3-methyl phenol	ND	190	23	ug/kg	
120-83-2	2,4-Dichlorophenol	ND	190	32	ug/kg	
105-67-9	2,4-Dimethylphenol	ND	190	67	ug/kg	
51-28-5	2,4-Dinitrophenol	ND	190	140	ug/kg	
534-52-1	4,6-Dinitro-o-cresol	ND	190	40	ug/kg	
95-48-7	2-Methylphenol	ND	75	24	ug/kg	
	3&4-Methylphenol	ND	75	31	ug/kg	
88-75-5	2-Nitrophenol	ND	190	25	ug/kg	
100-02-7	4-Nitrophenol	ND	380	100	ug/kg	
87-86-5	Pentachlorophenol	ND	150	35	ug/kg	
108-95-2	Phenol	ND	75	20	ug/kg	
58-90-2	2,3,4,6-Tetrachlorophenol	ND	190	25	ug/kg	
95-95-4	2,4,5-Trichlorophenol	ND	190	28	ug/kg	
88-06-2	2,4,6-Trichlorophenol	ND	190	22	ug/kg	
83-32-9	Acenaphthene [a]	ND	38	13	ug/kg	
208-96-8	Acenaphthylene	ND	38	19	ug/kg	
98-86-2	Acetophenone	ND	190	8.1	ug/kg	
120-12-7	Anthracene	ND	38	23	ug/kg	
1912-24-9	Atrazine	ND	75	16	ug/kg	
56-55-3	Benzo(a)anthracene	17.8	38	11	ug/kg	J
50-32-8	Benzo(a)pyrene	18.1	38	17	ug/kg	J
205-99-2	Benzo(b)fluoranthene	ND	38	17	ug/kg	
191-24-2	Benzo(g,h,i)perylene	ND	38	19	ug/kg	
207-08-9	Benzo(k)fluoranthene	ND	38	18	ug/kg	
101-55-3	4-Bromophenyl phenyl ether	ND	75	15	ug/kg	
85-68-7	Butyl benzyl phthalate	ND	75	9.2	ug/kg	
92-52-4	1,1'-Biphenyl	ND	75	5.2	ug/kg	
100-52-7	Benzaldehyde [b]	ND	190	9.4	ug/kg	
91-58-7	2-Chloronaphthalene	ND	75	9.0	ug/kg	
106-47-8	4-Chloroaniline	ND	190	14	ug/kg	
86-74-8	Carbazole	ND	75	5.5	ug/kg	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-10(7-5.5)030724		
Lab Sample ID:	JD83927-7	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	86.6
Project:	100 Main Street, White Plains, NY		

ABN TCL List (SOM0 2.0)

CAS No.	Compound	Result	RL	MDL	Units	Q
105-60-2	Caprolactam	ND	75	15	ug/kg	
218-01-9	Chrysene	12.8	38	12	ug/kg	J
111-91-1	bis(2-Chloroethoxy)methane	ND	75	8.1	ug/kg	
111-44-4	bis(2-Chloroethyl)ether	ND	75	16	ug/kg	
108-60-1	2,2'-Oxybis(1-chloropropane)	ND	75	14	ug/kg	
7005-72-3	4-Chlorophenyl phenyl ether	ND	75	12	ug/kg	
121-14-2	2,4-Dinitrotoluene	ND	38	12	ug/kg	
606-20-2	2,6-Dinitrotoluene	ND	38	19	ug/kg	
91-94-1	3,3'-Dichlorobenzidine	ND	75	31	ug/kg	
123-91-1	1,4-Dioxane	ND	38	25	ug/kg	
53-70-3	Dibenzo(a,h)anthracene	ND	38	17	ug/kg	
132-64-9	Dibenzofuran [a]	ND	75	15	ug/kg	
84-74-2	Di-n-butyl phthalate	ND	75	6.2	ug/kg	
117-84-0	Di-n-octyl phthalate	ND	75	9.4	ug/kg	
84-66-2	Diethyl phthalate	ND	75	8.0	ug/kg	
131-11-3	Dimethyl phthalate	ND	75	6.7	ug/kg	
117-81-7	bis(2-Ethylhexyl)phthalate	ND	75	8.8	ug/kg	
206-44-0	Fluoranthene	18.2	38	17	ug/kg	J
86-73-7	Fluorene [a]	ND	38	17	ug/kg	
118-74-1	Hexachlorobenzene [a]	ND	75	9.5	ug/kg	
87-68-3	Hexachlorobutadiene [a]	ND	38	15	ug/kg	
77-47-4	Hexachlorocyclopentadiene	ND	380	15	ug/kg	
67-72-1	Hexachloroethane	ND	190	19	ug/kg	
193-39-5	Indeno(1,2,3-cd)pyrene	ND	38	18	ug/kg	
78-59-1	Isophorone	ND	75	8.1	ug/kg	
91-57-6	2-Methylnaphthalene	ND	38	8.5	ug/kg	
88-74-4	2-Nitroaniline	ND	190	8.9	ug/kg	
99-09-2	3-Nitroaniline	ND	190	9.4	ug/kg	
100-01-6	4-Nitroaniline	ND	190	9.8	ug/kg	
91-20-3	Naphthalene [a]	ND	38	11	ug/kg	
98-95-3	Nitrobenzene	ND	75	15	ug/kg	
621-64-7	N-Nitroso-di-n-propylamine	ND	75	11	ug/kg	
86-30-6	N-Nitrosodiphenylamine	ND	190	14	ug/kg	
85-01-8	Phenanthrene [a]	ND	38	13	ug/kg	
129-00-0	Pyrene	29.5	38	12	ug/kg	J
95-94-3	1,2,4,5-Tetrachlorobenzene	ND	190	9.6	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
367-12-4	2-Fluorophenol	34%		10-99%

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-10(7-5.5)030724		
Lab Sample ID:	JD83927-7	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	86.6
Project:	100 Main Street, White Plains, NY		

ABN TCL List (SOM0 2.0)

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
4165-62-2	Phenol-d5	33%		10-96%
118-79-6	2,4,6-Tribromophenol	37%		10-123%
4165-60-0	Nitrobenzene-d5	34%		10-109%
321-60-8	2-Fluorobiphenyl	32%		11-109%
1718-51-0	Terphenyl-d14	44%		10-120%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Total TIC, Semi-Volatile		0	ug/kg	

(a) Associated CCV outside of control limits low. Low-level verification was analyzed to demonstrate system suitability to detect affected analytes. Sample was ND.
(b) Associated CCV outside of control limits high, sample was ND.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-10(7-5.5)030724		
Lab Sample ID:	JD83927-7	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8081B SW846 3570	**Percent Solids:**	86.6
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	4G9737028.D	1	03/11/24 04:56	CP	03/09/24 08:40	OP53021	G4G4306
Run #2							

	Initial Weight	Final Volume
Run #1	5.1 g	10.0 ml
Run #2		

Pesticide TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
309-00-2	Aldrin	ND	0.45	0.088	ug/kg	
319-84-6	alpha-BHC	ND	0.45	0.052	ug/kg	
319-85-7	beta-BHC	ND	0.45	0.066	ug/kg	
319-86-8	delta-BHC	ND	0.45	0.068	ug/kg	
58-89-9	gamma-BHC (Lindane)	ND	0.45	0.079	ug/kg	
5103-71-9	alpha-Chlordane [a]	0.13	0.45	0.061	ug/kg	J
5103-74-2	gamma-Chlordane	0.13	0.45	0.068	ug/kg	J
60-57-1	Dieldrin	0.085	0.45	0.072	ug/kg	J
72-54-8	4,4'-DDD	0.20	0.45	0.048	ug/kg	J
72-55-9	4,4'-DDE	0.12	0.45	0.054	ug/kg	J
50-29-3	4,4'-DDT [a]	0.16	0.45	0.079	ug/kg	J
72-20-8	Endrin	ND	0.45	0.066	ug/kg	
1031-07-8	Endosulfan sulfate	ND	0.45	0.054	ug/kg	
7421-93-4	Endrin aldehyde	ND	0.45	0.13	ug/kg	
959-98-8	Endosulfan-I	ND	0.45	0.061	ug/kg	
33213-65-9	Endosulfan-II	ND	0.45	0.063	ug/kg	
76-44-8	Heptachlor	ND	0.45	0.059	ug/kg	
1024-57-3	Heptachlor epoxide	ND	0.45	0.082	ug/kg	
72-43-5	Methoxychlor	ND	0.45	0.18	ug/kg	
53494-70-5	Endrin ketone	ND	0.45	0.072	ug/kg	
8001-35-2	Toxaphene	ND	5.7	3.7	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
877-09-8	Tetrachloro-m-xylene	89%		66-150%
877-09-8	Tetrachloro-m-xylene	101%		66-150%
2051-24-3	Decachlorobiphenyl	83%		40-150%
2051-24-3	Decachlorobiphenyl	79%		40-150%

(a) More than 40 % RPD for detected concentrations between the two GC columns.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-10(7-5.5)030724		
Lab Sample ID:	JD83927-7	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8082A SW846 3570	**Percent Solids:**	86.6
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	2G231138.D	1	03/11/24 02:22	TP	03/09/24 08:40	OP53022	G2G6058
Run #2							

	Initial Weight	Final Volume
Run #1	5.1 g	10.0 ml
Run #2		

PCB List

CAS No.	Compound	Result	RL	MDL	Units	Q
12674-11-2	Aroclor 1016	ND	23	9.6	ug/kg	
11104-28-2	Aroclor 1221	ND	23	7.6	ug/kg	
11141-16-5	Aroclor 1232	ND	23	19	ug/kg	
53469-21-9	Aroclor 1242	ND	23	14	ug/kg	
12672-29-6	Aroclor 1248	ND	23	4.9	ug/kg	
11097-69-1	Aroclor 1254	ND	23	2.4	ug/kg	
11096-82-5	Aroclor 1260	ND	23	7.8	ug/kg	
11100-14-4	Aroclor 1268	ND	23	2.3	ug/kg	
37324-23-5	Aroclor 1262	ND	23	1.9	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
877-09-8	Tetrachloro-m-xylene	92%		42-159%
877-09-8	Tetrachloro-m-xylene	91%		42-159%
2051-24-3	Decachlorobiphenyl	108%		18-154%
2051-24-3	Decachlorobiphenyl	112%		18-154%

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID: SB-10(7-5.5)030724
Lab Sample ID: JD83927-7
Matrix: SO - Soil
Project: 100 Main Street, White Plains, NY

Date Sampled: 03/07/24
Date Received: 03/07/24
Percent Solids: 86.6

Metals Analysis

Analyte	Result	RL	Units	DF	Prep	Analyzed	By	Method	Prep Method
Aluminum	5840	56	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Antimony	< 2.2	2.2	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Arsenic	< 2.2	2.2	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Barium	43.0	22	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Beryllium	0.26	0.22	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Cadmium	2.0	0.56	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Calcium	14100	560	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Chromium	12.1	1.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Cobalt	< 5.6	5.6	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Copper	13.3	2.8	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Iron	12100	56	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Lead	9.4	2.2	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Magnesium	9560	560	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Manganese	190	1.7	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Mercury	0.031	0.030	mg/kg	1	03/13/24	03/14/24	LM	SW846 7471B [1]	SW846 7471B [4]
Nickel	12.7	4.5	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Potassium	1890	1100	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Selenium	< 2.2	2.2	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Silver	< 0.56	0.56	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Sodium	< 1100	1100	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Thallium	< 1.1	1.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Vanadium	17.0	5.6	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Zinc	32.4	5.6	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]

(1) Instrument QC Batch: MA55688
(2) Instrument QC Batch: MA55691
(3) Prep QC Batch: MP45216
(4) Prep QC Batch: MP45278

RL = Reporting Limit

Report of Analysis

Client Sample ID:	SB-10(7-5.5)030724		
Lab Sample ID:	JD83927-7	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
		Percent Solids:	86.6
Project:	100 Main Street, White Plains, NY		

General Chemistry

Analyte	Result	RL	Units	DF	Analyzed	By	Method
Cyanide	< 0.28	0.28	mg/kg	1	03/12/24 20:31	JD	SW846 9012B/LACHAT
Solids, Percent	86.6		%	1	03/08/24 06:00	SC	SM2540 G 18TH ED MOD

RL = Reporting Limit

Report of Analysis

Client Sample ID:	SB-11(3.5-4)030724		
Lab Sample ID:	JD83927-8	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8260D SW846 5035	**Percent Solids:**	89.8
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	1C199835.D	1	03/09/24 05:09	PS	03/08/24 09:00	n/a	V1C8643
Run #2							

	Initial Weight
Run #1	5.2 g
Run #2	

VOA TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
67-64-1	Acetone	ND	11	4.4	ug/kg	
71-43-2	Benzene	ND	0.54	0.49	ug/kg	
74-97-5	Bromochloromethane	ND	5.4	0.60	ug/kg	
75-27-4	Bromodichloromethane	ND	2.1	0.46	ug/kg	
75-25-2	Bromoform	ND	5.4	1.5	ug/kg	
74-83-9	Bromomethane	ND	5.4	0.82	ug/kg	
78-93-3	2-Butanone (MEK)	ND	11	2.6	ug/kg	
75-15-0	Carbon disulfide	ND	2.1	0.57	ug/kg	
56-23-5	Carbon tetrachloride	ND	2.1	0.66	ug/kg	
108-90-7	Chlorobenzene	ND	2.1	0.49	ug/kg	
75-00-3	Chloroethane	ND	5.4	0.63	ug/kg	
67-66-3	Chloroform	ND	2.1	0.56	ug/kg	
74-87-3	Chloromethane	ND	5.4	2.1	ug/kg	
110-82-7	Cyclohexane	ND	2.1	0.70	ug/kg	
96-12-8	1,2-Dibromo-3-chloropropane	ND	2.1	0.74	ug/kg	
124-48-1	Dibromochloromethane	ND	2.1	0.60	ug/kg	
106-93-4	1,2-Dibromoethane	ND	1.1	0.45	ug/kg	
95-50-1	1,2-Dichlorobenzene	ND	1.1	0.58	ug/kg	
541-73-1	1,3-Dichlorobenzene	ND	1.1	0.53	ug/kg	
106-46-7	1,4-Dichlorobenzene	ND	1.1	0.53	ug/kg	
75-71-8	Dichlorodifluoromethane [a]	ND	5.4	0.78	ug/kg	
75-34-3	1,1-Dichloroethane	ND	1.1	0.53	ug/kg	
107-06-2	1,2-Dichloroethane	ND	1.1	0.50	ug/kg	
75-35-4	1,1-Dichloroethene	ND	1.1	0.70	ug/kg	
156-59-2	cis-1,2-Dichloroethene	ND	1.1	0.90	ug/kg	
156-60-5	trans-1,2-Dichloroethene	ND	1.1	0.65	ug/kg	
78-87-5	1,2-Dichloropropane	ND	2.1	0.51	ug/kg	
10061-01-5	cis-1,3-Dichloropropene	ND	2.1	0.51	ug/kg	
10061-02-6	trans-1,3-Dichloropropene	ND	2.1	0.49	ug/kg	
100-41-4	Ethylbenzene	ND	1.1	0.49	ug/kg	
76-13-1	Freon 113	ND	5.4	2.9	ug/kg	
591-78-6	2-Hexanone	ND	5.4	2.3	ug/kg	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-11(3.5-4)030724		
Lab Sample ID:	JD83927-8	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8260D SW846 5035	**Percent Solids:**	89.8
Project:	100 Main Street, White Plains, NY		

VOA TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
98-82-8	Isopropylbenzene	ND	2.1	1.5	ug/kg	
79-20-9	Methyl Acetate	ND	5.4	1.5	ug/kg	
108-87-2	Methylcyclohexane	ND	2.1	0.94	ug/kg	
1634-04-4	Methyl Tert Butyl Ether	ND	1.1	0.50	ug/kg	
108-10-1	4-Methyl-2-pentanone(MIBK)	ND	5.4	2.4	ug/kg	
75-09-2	Methylene chloride	ND	5.4	2.8	ug/kg	
100-42-5	Styrene	ND	2.1	0.43	ug/kg	
79-34-5	1,1,2,2-Tetrachloroethane	ND	2.1	0.64	ug/kg	
127-18-4	Tetrachloroethene	ND	2.1	0.62	ug/kg	
108-88-3	Toluene	ND	1.1	0.56	ug/kg	
87-61-6	1,2,3-Trichlorobenzene	ND	5.4	2.7	ug/kg	
120-82-1	1,2,4-Trichlorobenzene	ND	5.4	2.7	ug/kg	
71-55-6	1,1,1-Trichloroethane	ND	2.1	0.52	ug/kg	
79-00-5	1,1,2-Trichloroethane	ND	2.1	0.59	ug/kg	
79-01-6	Trichloroethene	ND	1.1	0.82	ug/kg	
75-69-4	Trichlorofluoromethane	ND	5.4	0.73	ug/kg	
75-01-4	Vinyl chloride	ND	2.1	0.52	ug/kg	
	m,p-Xylene	ND	1.1	0.96	ug/kg	
95-47-6	o-Xylene	ND	1.1	0.49	ug/kg	
1330-20-7	Xylene (total)	ND	1.1	0.49	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
1868-53-7	Dibromofluoromethane	105%		80-124%
17060-07-0	1,2-Dichloroethane-D4	108%		75-133%
2037-26-5	Toluene-D8	96%		79-125%
460-00-4	4-Bromofluorobenzene	96%		58-148%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Total TIC, Volatile		0	ug/kg	

(a) Associated CCV outside of control limits high, sample was ND.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-11(3.5-4)030724		
Lab Sample ID:	JD83927-8	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	89.8
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	Z166836.D	1	03/11/24 16:15	JY	03/09/24 18:30	OP53010	EZ8267
Run #2							

	Initial Weight	Final Volume
Run #1	30.7 g	1.0 ml
Run #2		

ABN TCL List (SOM0 2.0)

CAS No.	Compound	Result	RL	MDL	Units	Q
95-57-8	2-Chlorophenol	ND	73	18	ug/kg	
59-50-7	4-Chloro-3-methyl phenol	ND	180	22	ug/kg	
120-83-2	2,4-Dichlorophenol	ND	180	31	ug/kg	
105-67-9	2,4-Dimethylphenol	ND	180	65	ug/kg	
51-28-5	2,4-Dinitrophenol	ND	180	140	ug/kg	
534-52-1	4,6-Dinitro-o-cresol	ND	180	39	ug/kg	
95-48-7	2-Methylphenol	ND	73	23	ug/kg	
	3&4-Methylphenol	ND	73	30	ug/kg	
88-75-5	2-Nitrophenol	ND	180	24	ug/kg	
100-02-7	4-Nitrophenol	ND	360	97	ug/kg	
87-86-5	Pentachlorophenol	ND	150	34	ug/kg	
108-95-2	Phenol	ND	73	19	ug/kg	
58-90-2	2,3,4,6-Tetrachlorophenol	ND	180	24	ug/kg	
95-95-4	2,4,5-Trichlorophenol	ND	180	27	ug/kg	
88-06-2	2,4,6-Trichlorophenol	ND	180	22	ug/kg	
83-32-9	Acenaphthene [a]	ND	36	13	ug/kg	
208-96-8	Acenaphthylene	ND	36	18	ug/kg	
98-86-2	Acetophenone	ND	180	7.8	ug/kg	
120-12-7	Anthracene	ND	36	22	ug/kg	
1912-24-9	Atrazine	ND	73	16	ug/kg	
56-55-3	Benzo(a)anthracene	21.7	36	10	ug/kg	J
50-32-8	Benzo(a)pyrene	21.9	36	17	ug/kg	J
205-99-2	Benzo(b)fluoranthene	22.5	36	16	ug/kg	J
191-24-2	Benzo(g,h,i)perylene	ND	36	18	ug/kg	
207-08-9	Benzo(k)fluoranthene	ND	36	17	ug/kg	
101-55-3	4-Bromophenyl phenyl ether	ND	73	14	ug/kg	
85-68-7	Butyl benzyl phthalate	ND	73	8.9	ug/kg	
92-52-4	1,1'-Biphenyl	ND	73	5.0	ug/kg	
100-52-7	Benzaldehyde [b]	ND	180	9.0	ug/kg	
91-58-7	2-Chloronaphthalene	ND	73	8.6	ug/kg	
106-47-8	4-Chloroaniline	ND	180	13	ug/kg	
86-74-8	Carbazole	ND	73	5.3	ug/kg	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-11(3.5-4)030724		
Lab Sample ID:	JD83927-8	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	89.8
Project:	100 Main Street, White Plains, NY		

ABN TCL List (SOM0 2.0)

CAS No.	Compound	Result	RL	MDL	Units	Q
105-60-2	Caprolactam	ND	73	14	ug/kg	
218-01-9	Chrysene	14.9	36	11	ug/kg	J
111-91-1	bis(2-Chloroethoxy)methane	ND	73	7.8	ug/kg	
111-44-4	bis(2-Chloroethyl)ether	ND	73	16	ug/kg	
108-60-1	2,2'-Oxybis(1-chloropropane)	ND	73	13	ug/kg	
7005-72-3	4-Chlorophenyl phenyl ether	ND	73	12	ug/kg	
121-14-2	2,4-Dinitrotoluene	ND	36	11	ug/kg	
606-20-2	2,6-Dinitrotoluene	ND	36	18	ug/kg	
91-94-1	3,3'-Dichlorobenzidine	ND	73	30	ug/kg	
123-91-1	1,4-Dioxane	ND	36	24	ug/kg	
53-70-3	Dibenzo(a,h)anthracene	ND	36	16	ug/kg	
132-64-9	Dibenzofuran [a]	ND	73	15	ug/kg	
84-74-2	Di-n-butyl phthalate	ND	73	5.9	ug/kg	
117-84-0	Di-n-octyl phthalate	ND	73	9.0	ug/kg	
84-66-2	Diethyl phthalate	ND	73	7.7	ug/kg	
131-11-3	Dimethyl phthalate	ND	73	6.5	ug/kg	
117-81-7	bis(2-Ethylhexyl)phthalate	ND	73	8.5	ug/kg	
206-44-0	Fluoranthene	25.4	36	16	ug/kg	J
86-73-7	Fluorene [a]	ND	36	17	ug/kg	
118-74-1	Hexachlorobenzene [a]	ND	73	9.2	ug/kg	
87-68-3	Hexachlorobutadiene [a]	ND	36	15	ug/kg	
77-47-4	Hexachlorocyclopentadiene	ND	360	14	ug/kg	
67-72-1	Hexachloroethane	ND	180	18	ug/kg	
193-39-5	Indeno(1,2,3-cd)pyrene	ND	36	17	ug/kg	
78-59-1	Isophorone	ND	73	7.8	ug/kg	
91-57-6	2-Methylnaphthalene	ND	36	8.2	ug/kg	
88-74-4	2-Nitroaniline	ND	180	8.6	ug/kg	
99-09-2	3-Nitroaniline	ND	180	9.1	ug/kg	
100-01-6	4-Nitroaniline	ND	180	9.4	ug/kg	
91-20-3	Naphthalene [a]	ND	36	10	ug/kg	
98-95-3	Nitrobenzene	ND	73	14	ug/kg	
621-64-7	N-Nitroso-di-n-propylamine	ND	73	10	ug/kg	
86-30-6	N-Nitrosodiphenylamine	ND	180	13	ug/kg	
85-01-8	Phenanthrene [c]	15.7	36	12	ug/kg	J
129-00-0	Pyrene	28.9	36	12	ug/kg	J
95-94-3	1,2,4,5-Tetrachlorobenzene	ND	180	9.2	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
367-12-4	2-Fluorophenol	32%		10-99%

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-11(3.5-4)030724		
Lab Sample ID:	JD83927-8	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	89.8
Project:	100 Main Street, White Plains, NY		

ABN TCL List (SOM0 2.0)

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
4165-62-2	Phenol-d5	33%		10-96%
118-79-6	2,4,6-Tribromophenol	31%		10-123%
4165-60-0	Nitrobenzene-d5	37%		10-109%
321-60-8	2-Fluorobiphenyl	33%		11-109%
1718-51-0	Terphenyl-d14	37%		10-120%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Unknown	7.66	460	ug/kg	J
	Total TIC, Semi-Volatile		460	ug/kg	J

(a) Associated CCV outside of control limits low. Low-level verification was analyzed to demonstrate system suitability to detect affected analytes. Sample was ND.
(b) Associated CCV outside of control limits high, sample was ND.
(c) Associated CCV outside of control limits low. Low-level verification was analyzed to demonstrate system suitability to detect affected analytes. Estimated value, due to corresponding failure in the batch associated CCV.

Report of Analysis

Client Sample ID:	SB-11(3.5-4)030724		
Lab Sample ID:	JD83927-8	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8081B SW846 3570	**Percent Solids:**	89.8
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	4G9737029.D	1	03/11/24 05:16	CP	03/09/24 08:40	OP53021	G4G4306
Run #2							

	Initial Weight	Final Volume
Run #1	5.3 g	10.0 ml
Run #2		

Pesticide TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
309-00-2	Aldrin	ND	0.42	0.082	ug/kg	
319-84-6	alpha-BHC	ND	0.42	0.048	ug/kg	
319-85-7	beta-BHC	ND	0.42	0.061	ug/kg	
319-86-8	delta-BHC	ND	0.42	0.063	ug/kg	
58-89-9	gamma-BHC (Lindane)	ND	0.42	0.074	ug/kg	
5103-71-9	alpha-Chlordane [a]	0.23	0.42	0.057	ug/kg	J
5103-74-2	gamma-Chlordane	0.22	0.42	0.063	ug/kg	J
60-57-1	Dieldrin	0.22	0.42	0.067	ug/kg	J
72-54-8	4,4'-DDD	ND	0.42	0.044	ug/kg	
72-55-9	4,4'-DDE	0.10	0.42	0.050	ug/kg	J
50-29-3	4,4'-DDT	0.35	0.42	0.074	ug/kg	J
72-20-8	Endrin	ND	0.42	0.061	ug/kg	
1031-07-8	Endosulfan sulfate	ND	0.42	0.050	ug/kg	
7421-93-4	Endrin aldehyde	ND	0.42	0.12	ug/kg	
959-98-8	Endosulfan-I	ND	0.42	0.057	ug/kg	
33213-65-9	Endosulfan-II	ND	0.42	0.059	ug/kg	
76-44-8	Heptachlor	ND	0.42	0.055	ug/kg	
1024-57-3	Heptachlor epoxide	ND	0.42	0.076	ug/kg	
72-43-5	Methoxychlor	ND	0.42	0.17	ug/kg	
53494-70-5	Endrin ketone	ND	0.42	0.067	ug/kg	
8001-35-2	Toxaphene	ND	5.3	3.5	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
877-09-8	Tetrachloro-m-xylene	95%		66-150%
877-09-8	Tetrachloro-m-xylene	103%		66-150%
2051-24-3	Decachlorobiphenyl	83%		40-150%
2051-24-3	Decachlorobiphenyl	81%		40-150%

(a) More than 40 % RPD for detected concentrations between the two GC columns.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-11(3.5-4)030724		
Lab Sample ID:	JD83927-8	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8082A SW846 3570	**Percent Solids:**	89.8
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	2G231139.D	1	03/11/24 02:46	TP	03/09/24 08:40	OP53022	G2G6058
Run #2							

	Initial Weight	Final Volume
Run #1	5.3 g	10.0 ml
Run #2		

PCB List

CAS No.	Compound	Result	RL	MDL	Units	Q
12674-11-2	Aroclor 1016	ND	21	8.9	ug/kg	
11104-28-2	Aroclor 1221	ND	21	7.1	ug/kg	
11141-16-5	Aroclor 1232	ND	21	17	ug/kg	
53469-21-9	Aroclor 1242	ND	21	13	ug/kg	
12672-29-6	Aroclor 1248	ND	21	4.5	ug/kg	
11097-69-1	Aroclor 1254	ND	21	2.3	ug/kg	
11096-82-5	Aroclor 1260	ND	21	7.2	ug/kg	
11100-14-4	Aroclor 1268	ND	21	2.1	ug/kg	
37324-23-5	Aroclor 1262	ND	21	1.8	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
877-09-8	Tetrachloro-m-xylene	94%		42-159%
877-09-8	Tetrachloro-m-xylene	94%		42-159%
2051-24-3	Decachlorobiphenyl	109%		18-154%
2051-24-3	Decachlorobiphenyl	113%		18-154%

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID: SB-11(3.5-4)030724
Lab Sample ID: JD83927-8
Matrix: SO - Soil
Project: 100 Main Street, White Plains, NY

Date Sampled: 03/07/24
Date Received: 03/07/24
Percent Solids: 89.8

Metals Analysis

Analyte	Result	RL	Units	DF	Prep	Analyzed	By	Method	Prep Method
Aluminum	8230	58	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [1]	SW846 3050B [3]
Antimony	< 2.3	2.3	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [1]	SW846 3050B [3]
Arsenic	< 2.3	2.3	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [1]	SW846 3050B [3]
Barium	59.4	23	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [1]	SW846 3050B [3]
Beryllium	0.39	0.23	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [1]	SW846 3050B [3]
Cadmium	< 0.58	0.58	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [1]	SW846 3050B [3]
Calcium	13100	580	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [1]	SW846 3050B [3]
Chromium	17.0	1.2	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [1]	SW846 3050B [3]
Cobalt	8.1	5.8	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [1]	SW846 3050B [3]
Copper	19.9	2.9	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [1]	SW846 3050B [3]
Iron	16400	58	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [1]	SW846 3050B [3]
Lead	15.0	2.3	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [1]	SW846 3050B [3]
Magnesium	9250	580	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [1]	SW846 3050B [3]
Manganese	288	1.7	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [1]	SW846 3050B [3]
Mercury	0.076	0.030	mg/kg	1	03/14/24	03/15/24	LM	SW846 7471B [2]	SW846 7471B [4]
Nickel	15.4	4.6	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [1]	SW846 3050B [3]
Potassium	2630	1200	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [1]	SW846 3050B [3]
Selenium	< 2.3	2.3	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [1]	SW846 3050B [3]
Silver	< 0.58	0.58	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [1]	SW846 3050B [3]
Sodium	< 1200	1200	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [1]	SW846 3050B [3]
Thallium	< 1.2	1.2	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [1]	SW846 3050B [3]
Vanadium	24.7	5.8	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [1]	SW846 3050B [3]
Zinc	63.7	5.8	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [1]	SW846 3050B [3]

(1) Instrument QC Batch: MA55691
(2) Instrument QC Batch: MA55725
(3) Prep QC Batch: MP45216
(4) Prep QC Batch: MP45342

RL = Reporting Limit

Report of Analysis

Client Sample ID:	SB-11(3.5-4)030724		
Lab Sample ID:	JD83927-8	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
		Percent Solids:	89.8
Project:	100 Main Street, White Plains, NY		

General Chemistry

Analyte	Result	RL	Units	DF	Analyzed	By	Method
Cyanide	< 0.24	0.24	mg/kg	1	03/12/24 20:32	JD	SW846 9012B/LACHAT
Solids, Percent	89.8		%	1	03/08/24 06:00	SC	SM2540 G 18TH ED MOD

RL = Reporting Limit

Report of Analysis

Client Sample ID:	SB-11(8-8.5)030724		
Lab Sample ID:	JD83927-9	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8260D SW846 5035	**Percent Solids:**	86.2
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	1C199836.D	1	03/09/24 05:35	PS	03/08/24 09:00	n/a	V1C8643
Run #2							

	Initial Weight
Run #1	5.3 g
Run #2	

VOA TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
67-64-1	Acetone	ND	11	4.5	ug/kg	
71-43-2	Benzene	ND	0.55	0.50	ug/kg	
74-97-5	Bromochloromethane	ND	5.5	0.61	ug/kg	
75-27-4	Bromodichloromethane	ND	2.2	0.47	ug/kg	
75-25-2	Bromoform	ND	5.5	1.5	ug/kg	
74-83-9	Bromomethane	ND	5.5	0.84	ug/kg	
78-93-3	2-Butanone (MEK)	ND	11	2.7	ug/kg	
75-15-0	Carbon disulfide	ND	2.2	0.59	ug/kg	
56-23-5	Carbon tetrachloride	ND	2.2	0.68	ug/kg	
108-90-7	Chlorobenzene	ND	2.2	0.50	ug/kg	
75-00-3	Chloroethane	ND	5.5	0.65	ug/kg	
67-66-3	Chloroform	0.90	2.2	0.57	ug/kg	J
74-87-3	Chloromethane	ND	5.5	2.1	ug/kg	
110-82-7	Cyclohexane	ND	2.2	0.72	ug/kg	
96-12-8	1,2-Dibromo-3-chloropropane	ND	2.2	0.76	ug/kg	
124-48-1	Dibromochloromethane	ND	2.2	0.61	ug/kg	
106-93-4	1,2-Dibromoethane	ND	1.1	0.46	ug/kg	
95-50-1	1,2-Dichlorobenzene	ND	1.1	0.60	ug/kg	
541-73-1	1,3-Dichlorobenzene	ND	1.1	0.54	ug/kg	
106-46-7	1,4-Dichlorobenzene	ND	1.1	0.54	ug/kg	
75-71-8	Dichlorodifluoromethane [a]	ND	5.5	0.80	ug/kg	
75-34-3	1,1-Dichloroethane	ND	1.1	0.54	ug/kg	
107-06-2	1,2-Dichloroethane	ND	1.1	0.51	ug/kg	
75-35-4	1,1-Dichloroethene	ND	1.1	0.72	ug/kg	
156-59-2	cis-1,2-Dichloroethene	ND	1.1	0.92	ug/kg	
156-60-5	trans-1,2-Dichloroethene	ND	1.1	0.67	ug/kg	
78-87-5	1,2-Dichloropropane	ND	2.2	0.52	ug/kg	
10061-01-5	cis-1,3-Dichloropropene	ND	2.2	0.52	ug/kg	
10061-02-6	trans-1,3-Dichloropropene	ND	2.2	0.50	ug/kg	
100-41-4	Ethylbenzene	ND	1.1	0.50	ug/kg	
76-13-1	Freon 113	ND	5.5	2.9	ug/kg	
591-78-6	2-Hexanone	ND	5.5	2.3	ug/kg	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-11(8-8.5)030724		
Lab Sample ID:	JD83927-9	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8260D SW846 5035	**Percent Solids:**	86.2
Project:	100 Main Street, White Plains, NY		

VOA TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
98-82-8	Isopropylbenzene	ND	2.2	1.6	ug/kg	
79-20-9	Methyl Acetate	ND	5.5	1.5	ug/kg	
108-87-2	Methylcyclohexane	ND	2.2	0.96	ug/kg	
1634-04-4	Methyl Tert Butyl Ether	ND	1.1	0.51	ug/kg	
108-10-1	4-Methyl-2-pentanone(MIBK)	ND	5.5	2.5	ug/kg	
75-09-2	Methylene chloride	ND	5.5	2.9	ug/kg	
100-42-5	Styrene	ND	2.2	0.44	ug/kg	
79-34-5	1,1,2,2-Tetrachloroethane	ND	2.2	0.66	ug/kg	
127-18-4	Tetrachloroethene	ND	2.2	0.63	ug/kg	
108-88-3	Toluene	ND	1.1	0.57	ug/kg	
87-61-6	1,2,3-Trichlorobenzene	ND	5.5	2.7	ug/kg	
120-82-1	1,2,4-Trichlorobenzene	ND	5.5	2.7	ug/kg	
71-55-6	1,1,1-Trichloroethane	ND	2.2	0.53	ug/kg	
79-00-5	1,1,2-Trichloroethane	ND	2.2	0.61	ug/kg	
79-01-6	Trichloroethene	ND	1.1	0.83	ug/kg	
75-69-4	Trichlorofluoromethane	ND	5.5	0.75	ug/kg	
75-01-4	Vinyl chloride	ND	2.2	0.53	ug/kg	
	m,p-Xylene	ND	1.1	0.98	ug/kg	
95-47-6	o-Xylene	ND	1.1	0.50	ug/kg	
1330-20-7	Xylene (total)	ND	1.1	0.50	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
1868-53-7	Dibromofluoromethane	103%		80-124%
17060-07-0	1,2-Dichloroethane-D4	110%		75-133%
2037-26-5	Toluene-D8	102%		79-125%
460-00-4	4-Bromofluorobenzene	94%		58-148%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Total TIC, Volatile		0	ug/kg	

(a) Associated CCV outside of control limits high, sample was ND.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-11(8-8.5)030724		
Lab Sample ID:	JD83927-9	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	86.2
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	Z166837.D	1	03/11/24 16:38	JY	03/09/24 18:30	OP53010	EZ8267
Run #2							

	Initial Weight	Final Volume
Run #1	31.8 g	1.0 ml
Run #2		

ABN TCL List (SOM0 2.0)

CAS No.	Compound	Result	RL	MDL	Units	Q
95-57-8	2-Chlorophenol	ND	73	18	ug/kg	
59-50-7	4-Chloro-3-methyl phenol	ND	180	22	ug/kg	
120-83-2	2,4-Dichlorophenol	ND	180	31	ug/kg	
105-67-9	2,4-Dimethylphenol	ND	180	65	ug/kg	
51-28-5	2,4-Dinitrophenol	ND	180	140	ug/kg	
534-52-1	4,6-Dinitro-o-cresol	ND	180	39	ug/kg	
95-48-7	2-Methylphenol	ND	73	23	ug/kg	
	3&4-Methylphenol	ND	73	30	ug/kg	
88-75-5	2-Nitrophenol	ND	180	24	ug/kg	
100-02-7	4-Nitrophenol	ND	360	97	ug/kg	
87-86-5	Pentachlorophenol	ND	150	34	ug/kg	
108-95-2	Phenol	ND	73	19	ug/kg	
58-90-2	2,3,4,6-Tetrachlorophenol	ND	180	24	ug/kg	
95-95-4	2,4,5-Trichlorophenol	ND	180	27	ug/kg	
88-06-2	2,4,6-Trichlorophenol	ND	180	22	ug/kg	
83-32-9	Acenaphthene [a]	ND	36	13	ug/kg	
208-96-8	Acenaphthylene	ND	36	19	ug/kg	
98-86-2	Acetophenone	ND	180	7.8	ug/kg	
120-12-7	Anthracene	ND	36	22	ug/kg	
1912-24-9	Atrazine	ND	73	16	ug/kg	
56-55-3	Benzo(a)anthracene	ND	36	10	ug/kg	
50-32-8	Benzo(a)pyrene	ND	36	17	ug/kg	
205-99-2	Benzo(b)fluoranthene	ND	36	16	ug/kg	
191-24-2	Benzo(g,h,i)perylene	ND	36	18	ug/kg	
207-08-9	Benzo(k)fluoranthene	ND	36	17	ug/kg	
101-55-3	4-Bromophenyl phenyl ether	ND	73	14	ug/kg	
85-68-7	Butyl benzyl phthalate	ND	73	8.9	ug/kg	
92-52-4	1,1'-Biphenyl	ND	73	5.0	ug/kg	
100-52-7	Benzaldehyde [b]	ND	180	9.0	ug/kg	
91-58-7	2-Chloronaphthalene	ND	73	8.7	ug/kg	
106-47-8	4-Chloroaniline	ND	180	13	ug/kg	
86-74-8	Carbazole	ND	73	5.3	ug/kg	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-11(8-8.5)030724		
Lab Sample ID:	JD83927-9	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	86.2
Project:	100 Main Street, White Plains, NY		

ABN TCL List (SOM0 2.0)

CAS No.	Compound	Result	RL	MDL	Units	Q
105-60-2	Caprolactam	ND	73	14	ug/kg	
218-01-9	Chrysene	ND	36	11	ug/kg	
111-91-1	bis(2-Chloroethoxy)methane	ND	73	7.8	ug/kg	
111-44-4	bis(2-Chloroethyl)ether	ND	73	16	ug/kg	
108-60-1	2,2'-Oxybis(1-chloropropane)	ND	73	13	ug/kg	
7005-72-3	4-Chlorophenyl phenyl ether	ND	73	12	ug/kg	
121-14-2	2,4-Dinitrotoluene	ND	36	11	ug/kg	
606-20-2	2,6-Dinitrotoluene	ND	36	18	ug/kg	
91-94-1	3,3'-Dichlorobenzidine	ND	73	30	ug/kg	
123-91-1	1,4-Dioxane	ND	36	24	ug/kg	
53-70-3	Dibenzo(a,h)anthracene	ND	36	16	ug/kg	
132-64-9	Dibenzofuran [a]	ND	73	15	ug/kg	
84-74-2	Di-n-butyl phthalate	ND	73	5.9	ug/kg	
117-84-0	Di-n-octyl phthalate	ND	73	9.1	ug/kg	
84-66-2	Diethyl phthalate	ND	73	7.8	ug/kg	
131-11-3	Dimethyl phthalate	ND	73	6.5	ug/kg	
117-81-7	bis(2-Ethylhexyl)phthalate	ND	73	8.5	ug/kg	
206-44-0	Fluoranthene	ND	36	16	ug/kg	
86-73-7	Fluorene [a]	ND	36	17	ug/kg	
118-74-1	Hexachlorobenzene [a]	ND	73	9.2	ug/kg	
87-68-3	Hexachlorobutadiene [a]	ND	36	15	ug/kg	
77-47-4	Hexachlorocyclopentadiene	ND	360	15	ug/kg	
67-72-1	Hexachloroethane	ND	180	18	ug/kg	
193-39-5	Indeno(1,2,3-cd)pyrene	ND	36	17	ug/kg	
78-59-1	Isophorone	ND	73	7.8	ug/kg	
91-57-6	2-Methylnaphthalene	ND	36	8.2	ug/kg	
88-74-4	2-Nitroaniline	ND	180	8.6	ug/kg	
99-09-2	3-Nitroaniline	ND	180	9.1	ug/kg	
100-01-6	4-Nitroaniline	ND	180	9.4	ug/kg	
91-20-3	Naphthalene [a]	ND	36	10	ug/kg	
98-95-3	Nitrobenzene	ND	73	14	ug/kg	
621-64-7	N-Nitroso-di-n-propylamine	ND	73	11	ug/kg	
86-30-6	N-Nitrosodiphenylamine	ND	180	13	ug/kg	
85-01-8	Phenanthrene [a]	ND	36	12	ug/kg	
129-00-0	Pyrene	ND	36	12	ug/kg	
95-94-3	1,2,4,5-Tetrachlorobenzene	ND	180	9.3	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
367-12-4	2-Fluorophenol	37%		10-99%

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-11(8-8.5)030724		
Lab Sample ID:	JD83927-9	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	86.2
Project:	100 Main Street, White Plains, NY		

ABN TCL List (SOM0 2.0)

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
4165-62-2	Phenol-d5	40%		10-96%
118-79-6	2,4,6-Tribromophenol	38%		10-123%
4165-60-0	Nitrobenzene-d5	39%		10-109%
321-60-8	2-Fluorobiphenyl	38%		11-109%
1718-51-0	Terphenyl-d14	45%		10-120%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Total TIC, Semi-Volatile		0	ug/kg	

(a) Associated CCV outside of control limits low. Low-level verification was analyzed to demonstrate system suitability to detect affected analytes. Sample was ND.
(b) Associated CCV outside of control limits high, sample was ND.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-11(8-8.5)030724		
Lab Sample ID:	JD83927-9	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8081B SW846 3570	**Percent Solids:**	86.2
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	4G9737030.D	1	03/11/24 05:35	CP	03/09/24 08:40	OP53021	G4G4306
Run #2							

	Initial Weight	Final Volume
Run #1	5.4 g	10.0 ml
Run #2		

Pesticide TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
309-00-2	Aldrin	ND	0.43	0.084	ug/kg	
319-84-6	alpha-BHC	ND	0.43	0.049	ug/kg	
319-85-7	beta-BHC	ND	0.43	0.062	ug/kg	
319-86-8	delta-BHC	ND	0.43	0.064	ug/kg	
58-89-9	gamma-BHC (Lindane)	ND	0.43	0.075	ug/kg	
5103-71-9	alpha-Chlordane	ND	0.43	0.058	ug/kg	
5103-74-2	gamma-Chlordane	ND	0.43	0.064	ug/kg	
60-57-1	Dieldrin	ND	0.43	0.069	ug/kg	
72-54-8	4,4'-DDD	ND	0.43	0.045	ug/kg	
72-55-9	4,4'-DDE	ND	0.43	0.052	ug/kg	
50-29-3	4,4'-DDT	ND	0.43	0.075	ug/kg	
72-20-8	Endrin	ND	0.43	0.062	ug/kg	
1031-07-8	Endosulfan sulfate	ND	0.43	0.052	ug/kg	
7421-93-4	Endrin aldehyde	ND	0.43	0.12	ug/kg	
959-98-8	Endosulfan-I	ND	0.43	0.058	ug/kg	
33213-65-9	Endosulfan-II	ND	0.43	0.060	ug/kg	
76-44-8	Heptachlor	ND	0.43	0.056	ug/kg	
1024-57-3	Heptachlor epoxide	ND	0.43	0.077	ug/kg	
72-43-5	Methoxychlor	ND	0.43	0.17	ug/kg	
53494-70-5	Endrin ketone	ND	0.43	0.069	ug/kg	
8001-35-2	Toxaphene	ND	5.4	3.5	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
877-09-8	Tetrachloro-m-xylene	95%		66-150%
877-09-8	Tetrachloro-m-xylene	112%		66-150%
2051-24-3	Decachlorobiphenyl	88%		40-150%
2051-24-3	Decachlorobiphenyl	81%		40-150%

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-11(8-8.5)030724		
Lab Sample ID:	JD83927-9	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8082A SW846 3570	**Percent Solids:**	86.2
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	2G231140.D	1	03/11/24 03:11	TP	03/09/24 08:40	OP53022	G2G6058
Run #2							

	Initial Weight	Final Volume
Run #1	5.4 g	10.0 ml
Run #2		

PCB List

CAS No.	Compound	Result	RL	MDL	Units	Q
12674-11-2	Aroclor 1016	ND	21	9.1	ug/kg	
11104-28-2	Aroclor 1221	ND	21	7.2	ug/kg	
11141-16-5	Aroclor 1232	ND	21	18	ug/kg	
53469-21-9	Aroclor 1242	ND	21	13	ug/kg	
12672-29-6	Aroclor 1248	ND	21	4.6	ug/kg	
11097-69-1	Aroclor 1254	ND	21	2.3	ug/kg	
11096-82-5	Aroclor 1260	ND	21	7.4	ug/kg	
11100-14-4	Aroclor 1268	ND	21	2.2	ug/kg	
37324-23-5	Aroclor 1262	ND	21	1.8	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
877-09-8	Tetrachloro-m-xylene	96%		42-159%
877-09-8	Tetrachloro-m-xylene	97%		42-159%
2051-24-3	Decachlorobiphenyl	116%		18-154%
2051-24-3	Decachlorobiphenyl	112%		18-154%

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-11(8-8.5)030724		
Lab Sample ID:	JD83927-9	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
		Percent Solids:	86.2
Project:	100 Main Street, White Plains, NY		

Metals Analysis

Analyte	Result	RL	Units	DF	Prep	Analyzed	By	Method	Prep Method
Aluminum	4300	58	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Antimony	< 2.3	2.3	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Arsenic	< 2.3	2.3	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Barium	35.7	23	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Beryllium	< 0.23	0.23	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Cadmium	< 0.58	0.58	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Calcium	1510	580	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Chromium	9.5	1.2	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Cobalt	8.2	5.8	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Copper	10.8	2.9	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Iron	10400	58	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Lead	< 2.3	2.3	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Magnesium	2840	580	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Manganese	282	1.7	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Mercury	< 0.035	0.035	mg/kg	1	03/13/24	03/14/24	LM	SW846 7471B [1]	SW846 7471B [4]
Nickel	8.3	4.6	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Potassium	1410	1200	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Selenium	< 2.3	2.3	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Silver	< 0.58	0.58	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Sodium	< 1200	1200	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Thallium	< 1.2	1.2	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Vanadium	13.3	5.8	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Zinc	57.2	5.8	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]

(1) Instrument QC Batch: MA55688
(2) Instrument QC Batch: MA55691
(3) Prep QC Batch: MP45216
(4) Prep QC Batch: MP45278

RL = Reporting Limit

Report of Analysis

Client Sample ID:	SB-11(8-8.5)030724		
Lab Sample ID:	JD83927-9	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
		Percent Solids:	86.2
Project:	100 Main Street, White Plains, NY		

General Chemistry

Analyte	Result	RL	Units	DF	Analyzed	By	Method
Cyanide	< 0.27	0.27	mg/kg	1	03/12/24 19:46	JD	SW846 9012B/LACHAT
Solids, Percent	86.2		%	1	03/08/24 06:00	SC	SM2540 G 18TH ED MOD

RL = Reporting Limit

Report of Analysis

Client Sample ID:	SB-16(3-3.5)030724		
Lab Sample ID:	JD83927-10	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8260D SW846 5035	**Percent Solids:**	90.2
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	1C199837.D	1	03/09/24 06:01	PS	03/08/24 10:00	n/a	V1C8643
Run #2							

	Initial Weight
Run #1	5.0 g
Run #2	

VOA TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
67-64-1	Acetone	ND	11	4.6	ug/kg	
71-43-2	Benzene	ND	0.55	0.50	ug/kg	
74-97-5	Bromochloromethane	ND	5.5	0.62	ug/kg	
75-27-4	Bromodichloromethane	ND	2.2	0.48	ug/kg	
75-25-2	Bromoform	ND	5.5	1.5	ug/kg	
74-83-9	Bromomethane	ND	5.5	0.85	ug/kg	
78-93-3	2-Butanone (MEK)	ND	11	2.7	ug/kg	
75-15-0	Carbon disulfide	ND	2.2	0.59	ug/kg	
56-23-5	Carbon tetrachloride	ND	2.2	0.69	ug/kg	
108-90-7	Chlorobenzene	ND	2.2	0.51	ug/kg	
75-00-3	Chloroethane	ND	5.5	0.66	ug/kg	
67-66-3	Chloroform	ND	2.2	0.58	ug/kg	
74-87-3	Chloromethane	ND	5.5	2.2	ug/kg	
110-82-7	Cyclohexane	ND	2.2	0.73	ug/kg	
96-12-8	1,2-Dibromo-3-chloropropane	ND	2.2	0.77	ug/kg	
124-48-1	Dibromochloromethane	ND	2.2	0.62	ug/kg	
106-93-4	1,2-Dibromoethane	ND	1.1	0.47	ug/kg	
95-50-1	1,2-Dichlorobenzene	ND	1.1	0.61	ug/kg	
541-73-1	1,3-Dichlorobenzene	ND	1.1	0.55	ug/kg	
106-46-7	1,4-Dichlorobenzene	ND	1.1	0.55	ug/kg	
75-71-8	Dichlorodifluoromethane [a]	ND	5.5	0.81	ug/kg	
75-34-3	1,1-Dichloroethane	ND	1.1	0.55	ug/kg	
107-06-2	1,2-Dichloroethane	ND	1.1	0.52	ug/kg	
75-35-4	1,1-Dichloroethene	ND	1.1	0.73	ug/kg	
156-59-2	cis-1,2-Dichloroethene	ND	1.1	0.93	ug/kg	
156-60-5	trans-1,2-Dichloroethene	ND	1.1	0.68	ug/kg	
78-87-5	1,2-Dichloropropane	ND	2.2	0.52	ug/kg	
10061-01-5	cis-1,3-Dichloropropene	ND	2.2	0.53	ug/kg	
10061-02-6	trans-1,3-Dichloropropene	ND	2.2	0.51	ug/kg	
100-41-4	Ethylbenzene	ND	1.1	0.50	ug/kg	
76-13-1	Freon 113	ND	5.5	3.0	ug/kg	
591-78-6	2-Hexanone	ND	5.5	2.4	ug/kg	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-16(3-3.5)030724		
Lab Sample ID:	JD83927-10	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8260D SW846 5035	**Percent Solids:**	90.2
Project:	100 Main Street, White Plains, NY		

VOA TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
98-82-8	Isopropylbenzene	ND	2.2	1.6	ug/kg	
79-20-9	Methyl Acetate	ND	5.5	1.5	ug/kg	
108-87-2	Methylcyclohexane	ND	2.2	0.97	ug/kg	
1634-04-4	Methyl Tert Butyl Ether	ND	1.1	0.52	ug/kg	
108-10-1	4-Methyl-2-pentanone(MIBK)	ND	5.5	2.5	ug/kg	
75-09-2	Methylene chloride	ND	5.5	2.9	ug/kg	
100-42-5	Styrene	ND	2.2	0.45	ug/kg	
79-34-5	1,1,2,2-Tetrachloroethane	ND	2.2	0.66	ug/kg	
127-18-4	Tetrachloroethene	ND	2.2	0.64	ug/kg	
108-88-3	Toluene	ND	1.1	0.58	ug/kg	
87-61-6	1,2,3-Trichlorobenzene	ND	5.5	2.8	ug/kg	
120-82-1	1,2,4-Trichlorobenzene	ND	5.5	2.8	ug/kg	
71-55-6	1,1,1-Trichloroethane	ND	2.2	0.54	ug/kg	
79-00-5	1,1,2-Trichloroethane	ND	2.2	0.61	ug/kg	
79-01-6	Trichloroethene	ND	1.1	0.84	ug/kg	
75-69-4	Trichlorofluoromethane	ND	5.5	0.76	ug/kg	
75-01-4	Vinyl chloride	ND	2.2	0.53	ug/kg	
	m,p-Xylene	ND	1.1	0.99	ug/kg	
95-47-6	o-Xylene	ND	1.1	0.51	ug/kg	
1330-20-7	Xylene (total)	ND	1.1	0.51	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
1868-53-7	Dibromofluoromethane	103%		80-124%
17060-07-0	1,2-Dichloroethane-D4	109%		75-133%
2037-26-5	Toluene-D8	97%		79-125%
460-00-4	4-Bromofluorobenzene	97%		58-148%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Total TIC, Volatile		0	ug/kg	

(a) Associated CCV outside of control limits high, sample was ND.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-16(3-3.5)030724		
Lab Sample ID:	JD83927-10	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	90.2
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	Z166838.D	1	03/11/24 17:01	JY	03/09/24 18:30	OP53010	EZ8267
Run #2							

	Initial Weight	Final Volume
Run #1	30.2 g	1.0 ml
Run #2		

ABN TCL List (SOM0 2.0)

CAS No.	Compound	Result	RL	MDL	Units	Q
95-57-8	2-Chlorophenol	ND	73	18	ug/kg	
59-50-7	4-Chloro-3-methyl phenol	ND	180	23	ug/kg	
120-83-2	2,4-Dichlorophenol	ND	180	31	ug/kg	
105-67-9	2,4-Dimethylphenol	ND	180	65	ug/kg	
51-28-5	2,4-Dinitrophenol	ND	180	140	ug/kg	
534-52-1	4,6-Dinitro-o-cresol	ND	180	39	ug/kg	
95-48-7	2-Methylphenol	ND	73	23	ug/kg	
	3&4-Methylphenol	ND	73	30	ug/kg	
88-75-5	2-Nitrophenol	ND	180	24	ug/kg	
100-02-7	4-Nitrophenol	ND	370	98	ug/kg	
87-86-5	Pentachlorophenol	ND	150	34	ug/kg	
108-95-2	Phenol	ND	73	19	ug/kg	
58-90-2	2,3,4,6-Tetrachlorophenol	ND	180	24	ug/kg	
95-95-4	2,4,5-Trichlorophenol	ND	180	27	ug/kg	
88-06-2	2,4,6-Trichlorophenol	ND	180	22	ug/kg	
83-32-9	Acenaphthene [a]	ND	37	13	ug/kg	
208-96-8	Acenaphthylene	ND	37	19	ug/kg	
98-86-2	Acetophenone	ND	180	7.9	ug/kg	
120-12-7	Anthracene	ND	37	23	ug/kg	
1912-24-9	Atrazine	ND	73	16	ug/kg	
56-55-3	Benzo(a)anthracene	ND	37	10	ug/kg	
50-32-8	Benzo(a)pyrene	ND	37	17	ug/kg	
205-99-2	Benzo(b)fluoranthene	ND	37	16	ug/kg	
191-24-2	Benzo(g,h,i)perylene	ND	37	18	ug/kg	
207-08-9	Benzo(k)fluoranthene	ND	37	17	ug/kg	
101-55-3	4-Bromophenyl phenyl ether	ND	73	14	ug/kg	
85-68-7	Butyl benzyl phthalate	ND	73	9.0	ug/kg	
92-52-4	1,1'-Biphenyl	ND	73	5.0	ug/kg	
100-52-7	Benzaldehyde [b]	ND	180	9.1	ug/kg	
91-58-7	2-Chloronaphthalene	ND	73	8.7	ug/kg	
106-47-8	4-Chloroaniline	ND	180	13	ug/kg	
86-74-8	Carbazole	ND	73	5.3	ug/kg	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-16(3-3.5)030724		
Lab Sample ID:	JD83927-10	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	90.2
Project:	100 Main Street, White Plains, NY		

ABN TCL List (SOM0 2.0)

CAS No.	Compound	Result	RL	MDL	Units	Q
105-60-2	Caprolactam	ND	73	15	ug/kg	
218-01-9	Chrysene	ND	37	12	ug/kg	
111-91-1	bis(2-Chloroethoxy)methane	ND	73	7.9	ug/kg	
111-44-4	bis(2-Chloroethyl)ether	ND	73	16	ug/kg	
108-60-1	2,2'-Oxybis(1-chloropropane)	ND	73	13	ug/kg	
7005-72-3	4-Chlorophenyl phenyl ether	ND	73	12	ug/kg	
121-14-2	2,4-Dinitrotoluene	ND	37	11	ug/kg	
606-20-2	2,6-Dinitrotoluene	ND	37	18	ug/kg	
91-94-1	3,3'-Dichlorobenzidine	ND	73	31	ug/kg	
123-91-1	1,4-Dioxane	ND	37	24	ug/kg	
53-70-3	Dibenzo(a,h)anthracene	ND	37	16	ug/kg	
132-64-9	Dibenzofuran [a]	ND	73	15	ug/kg	
84-74-2	Di-n-butyl phthalate	ND	73	6.0	ug/kg	
117-84-0	Di-n-octyl phthalate	ND	73	9.1	ug/kg	
84-66-2	Diethyl phthalate	ND	73	7.8	ug/kg	
131-11-3	Dimethyl phthalate	ND	73	6.5	ug/kg	
117-81-7	bis(2-Ethylhexyl)phthalate	ND	73	8.6	ug/kg	
206-44-0	Fluoranthene	ND	37	16	ug/kg	
86-73-7	Fluorene [a]	ND	37	17	ug/kg	
118-74-1	Hexachlorobenzene [a]	ND	73	9.3	ug/kg	
87-68-3	Hexachlorobutadiene [a]	ND	37	15	ug/kg	
77-47-4	Hexachlorocyclopentadiene	ND	370	15	ug/kg	
67-72-1	Hexachloroethane	ND	180	18	ug/kg	
193-39-5	Indeno(1,2,3-cd)pyrene	ND	37	17	ug/kg	
78-59-1	Isophorone	ND	73	7.9	ug/kg	
91-57-6	2-Methylnaphthalene	ND	37	8.3	ug/kg	
88-74-4	2-Nitroaniline	ND	180	8.7	ug/kg	
99-09-2	3-Nitroaniline	ND	180	9.2	ug/kg	
100-01-6	4-Nitroaniline	ND	180	9.5	ug/kg	
91-20-3	Naphthalene [a]	ND	37	10	ug/kg	
98-95-3	Nitrobenzene	ND	73	14	ug/kg	
621-64-7	N-Nitroso-di-n-propylamine	ND	73	11	ug/kg	
86-30-6	N-Nitrosodiphenylamine	ND	180	13	ug/kg	
85-01-8	Phenanthrene [a]	ND	37	12	ug/kg	
129-00-0	Pyrene	ND	37	12	ug/kg	
95-94-3	1,2,4,5-Tetrachlorobenzene	ND	180	9.3	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
367-12-4	2-Fluorophenol	34%		10-99%

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-16(3-3.5)030724		
Lab Sample ID:	JD83927-10	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	90.2
Project:	100 Main Street, White Plains, NY		

ABN TCL List (SOM0 2.0)

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
4165-62-2	Phenol-d5	35%		10-96%
118-79-6	2,4,6-Tribromophenol	35%		10-123%
4165-60-0	Nitrobenzene-d5	36%		10-109%
321-60-8	2-Fluorobiphenyl	33%		11-109%
1718-51-0	Terphenyl-d14	41%		10-120%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Unknown	7.66	150	ug/kg	J
	Total TIC, Semi-Volatile		150	ug/kg	J

(a) Associated CCV outside of control limits low. Low-level verification was analyzed to demonstrate system suitability to detect affected analytes. Sample was ND.
(b) Associated CCV outside of control limits high, sample was ND.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-16(3-3.5)030724		
Lab Sample ID:	JD83927-10	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8081B SW846 3570	**Percent Solids:**	90.2
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	4G9737031.D	1	03/11/24 05:54	CP	03/09/24 08:40	OP53021	G4G4306
Run #2							

	Initial Weight	Final Volume
Run #1	5.4 g	10.0 ml
Run #2		

Pesticide TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
309-00-2	Aldrin	ND	0.41	0.080	ug/kg	
319-84-6	alpha-BHC	ND	0.41	0.047	ug/kg	
319-85-7	beta-BHC	ND	0.41	0.060	ug/kg	
319-86-8	delta-BHC	ND	0.41	0.062	ug/kg	
58-89-9	gamma-BHC (Lindane)	ND	0.41	0.072	ug/kg	
5103-71-9	alpha-Chlordane	ND	0.41	0.055	ug/kg	
5103-74-2	gamma-Chlordane	ND	0.41	0.062	ug/kg	
60-57-1	Dieldrin	ND	0.41	0.066	ug/kg	
72-54-8	4,4'-DDD	ND	0.41	0.043	ug/kg	
72-55-9	4,4'-DDE	ND	0.41	0.049	ug/kg	
50-29-3	4,4'-DDT	ND	0.41	0.072	ug/kg	
72-20-8	Endrin	ND	0.41	0.060	ug/kg	
1031-07-8	Endosulfan sulfate	ND	0.41	0.049	ug/kg	
7421-93-4	Endrin aldehyde	ND	0.41	0.12	ug/kg	
959-98-8	Endosulfan-I	ND	0.41	0.055	ug/kg	
33213-65-9	Endosulfan-II	ND	0.41	0.057	ug/kg	
76-44-8	Heptachlor	ND	0.41	0.053	ug/kg	
1024-57-3	Heptachlor epoxide	ND	0.41	0.074	ug/kg	
72-43-5	Methoxychlor	ND	0.41	0.16	ug/kg	
53494-70-5	Endrin ketone	ND	0.41	0.066	ug/kg	
8001-35-2	Toxaphene	ND	5.1	3.4	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
877-09-8	Tetrachloro-m-xylene	99%		66-150%
877-09-8	Tetrachloro-m-xylene	115%		66-150%
2051-24-3	Decachlorobiphenyl	92%		40-150%
2051-24-3	Decachlorobiphenyl	73%		40-150%

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-16(3-3.5)030724		
Lab Sample ID:	JD83927-10	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8082A SW846 3570	**Percent Solids:**	90.2
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	2G231145.D	1	03/11/24 05:12	TP	03/09/24 08:40	OP53022	G2G6058
Run #2							

	Initial Weight	Final Volume
Run #1	5.4 g	10.0 ml
Run #2		

PCB List

CAS No.	Compound	Result	RL	MDL	Units	Q
12674-11-2	Aroclor 1016	ND	21	8.7	ug/kg	
11104-28-2	Aroclor 1221	ND	21	6.9	ug/kg	
11141-16-5	Aroclor 1232	ND	21	17	ug/kg	
53469-21-9	Aroclor 1242	ND	21	12	ug/kg	
12672-29-6	Aroclor 1248	ND	21	4.4	ug/kg	
11097-69-1	Aroclor 1254	ND	21	2.2	ug/kg	
11096-82-5	Aroclor 1260	ND	21	7.1	ug/kg	
11100-14-4	Aroclor 1268	ND	21	2.1	ug/kg	
37324-23-5	Aroclor 1262	ND	21	1.7	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
877-09-8	Tetrachloro-m-xylene	97%		42-159%
877-09-8	Tetrachloro-m-xylene	102%		42-159%
2051-24-3	Decachlorobiphenyl	111%		18-154%
2051-24-3	Decachlorobiphenyl	119%		18-154%

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID: SB-16(3-3.5)030724
Lab Sample ID: JD83927-10
Matrix: SO - Soil
Project: 100 Main Street, White Plains, NY

Date Sampled: 03/07/24
Date Received: 03/07/24
Percent Solids: 90.2

Metals Analysis

Analyte	Result	RL	Units	DF	Prep	Analyzed	By	Method	Prep Method
Aluminum	8000	53	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Antimony	< 2.1	2.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Arsenic	< 2.1	2.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Barium	45.7	21	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Beryllium	0.32	0.21	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Cadmium	< 0.53	0.53	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Calcium	2000	530	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Chromium	14.8	1.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Cobalt	5.7	5.3	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Copper	14.8	2.7	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Iron	13800	53	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Lead	2.7	2.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Magnesium	4420	530	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Manganese	182	1.6	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Mercury	< 0.033	0.033	mg/kg	1	03/13/24	03/14/24	LM	SW846 7471B [1]	SW846 7471B [4]
Nickel	12.6	4.3	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Potassium	2030	1100	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Selenium	< 2.1	2.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Silver	< 0.53	0.53	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Sodium	< 1100	1100	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Thallium	< 1.1	1.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Vanadium	21.0	5.3	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Zinc	32.5	5.3	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]

(1) Instrument QC Batch: MA55688
(2) Instrument QC Batch: MA55691
(3) Prep QC Batch: MP45216
(4) Prep QC Batch: MP45278

RL = Reporting Limit

Report of Analysis

Client Sample ID:	SB-16(3-3.5)030724		
Lab Sample ID:	JD83927-10	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
		Percent Solids:	90.2
Project:	100 Main Street, White Plains, NY		

General Chemistry

Analyte	Result	RL	Units	DF	Analyzed	By	Method
Cyanide	< 0.26	0.26	mg/kg	1	03/12/24 19:47	JD	SW846 9012B/LACHAT
Solids, Percent	90.2		%	1	03/08/24 06:00	SC	SM2540 G 18TH ED MOD

RL = Reporting Limit

Report of Analysis

Client Sample ID:	SB-16(7.5-8)030724		
Lab Sample ID:	JD83927-11	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8260D SW846 5035	**Percent Solids:**	86.2
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	1C199838.D	1	03/09/24 06:28	PS	03/08/24 10:00	n/a	V1C8643
Run #2							

	Initial Weight
Run #1	5.6 g
Run #2	

VOA TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
67-64-1	Acetone	ND	10	4.3	ug/kg	
71-43-2	Benzene	ND	0.52	0.47	ug/kg	
74-97-5	Bromochloromethane	ND	5.2	0.58	ug/kg	
75-27-4	Bromodichloromethane	ND	2.1	0.44	ug/kg	
75-25-2	Bromoform	ND	5.2	1.4	ug/kg	
74-83-9	Bromomethane	ND	5.2	0.79	ug/kg	
78-93-3	2-Butanone (MEK)	ND	10	2.5	ug/kg	
75-15-0	Carbon disulfide	ND	2.1	0.55	ug/kg	
56-23-5	Carbon tetrachloride	ND	2.1	0.64	ug/kg	
108-90-7	Chlorobenzene	ND	2.1	0.48	ug/kg	
75-00-3	Chloroethane	ND	5.2	0.61	ug/kg	
67-66-3	Chloroform	ND	2.1	0.54	ug/kg	
74-87-3	Chloromethane	ND	5.2	2.0	ug/kg	
110-82-7	Cyclohexane	ND	2.1	0.68	ug/kg	
96-12-8	1,2-Dibromo-3-chloropropane	ND	2.1	0.72	ug/kg	
124-48-1	Dibromochloromethane	ND	2.1	0.58	ug/kg	
106-93-4	1,2-Dibromoethane	ND	1.0	0.44	ug/kg	
95-50-1	1,2-Dichlorobenzene	ND	1.0	0.57	ug/kg	
541-73-1	1,3-Dichlorobenzene	ND	1.0	0.51	ug/kg	
106-46-7	1,4-Dichlorobenzene	ND	1.0	0.51	ug/kg	
75-71-8	Dichlorodifluoromethane [a]	ND	5.2	0.75	ug/kg	
75-34-3	1,1-Dichloroethane	ND	1.0	0.51	ug/kg	
107-06-2	1,2-Dichloroethane	ND	1.0	0.49	ug/kg	
75-35-4	1,1-Dichloroethene	ND	1.0	0.68	ug/kg	
156-59-2	cis-1,2-Dichloroethene	ND	1.0	0.87	ug/kg	
156-60-5	trans-1,2-Dichloroethene	ND	1.0	0.63	ug/kg	
78-87-5	1,2-Dichloropropane	ND	2.1	0.49	ug/kg	
10061-01-5	cis-1,3-Dichloropropene	ND	2.1	0.49	ug/kg	
10061-02-6	trans-1,3-Dichloropropene	ND	2.1	0.47	ug/kg	
100-41-4	Ethylbenzene	ND	1.0	0.47	ug/kg	
76-13-1	Freon 113	ND	5.2	2.8	ug/kg	
591-78-6	2-Hexanone	ND	5.2	2.2	ug/kg	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-16(7.5-8)030724		
Lab Sample ID:	JD83927-11	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8260D SW846 5035	**Percent Solids:**	86.2
Project:	100 Main Street, White Plains, NY		

VOA TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
98-82-8	Isopropylbenzene	ND	2.1	1.5	ug/kg	
79-20-9	Methyl Acetate	ND	5.2	1.4	ug/kg	
108-87-2	Methylcyclohexane	ND	2.1	0.91	ug/kg	
1634-04-4	Methyl Tert Butyl Ether	ND	1.0	0.49	ug/kg	
108-10-1	4-Methyl-2-pentanone(MIBK)	ND	5.2	2.4	ug/kg	
75-09-2	Methylene chloride	ND	5.2	2.7	ug/kg	
100-42-5	Styrene	ND	2.1	0.42	ug/kg	
79-34-5	1,1,2,2-Tetrachloroethane	ND	2.1	0.62	ug/kg	
127-18-4	Tetrachloroethene	ND	2.1	0.60	ug/kg	
108-88-3	Toluene	ND	1.0	0.54	ug/kg	
87-61-6	1,2,3-Trichlorobenzene	ND	5.2	2.6	ug/kg	
120-82-1	1,2,4-Trichlorobenzene	ND	5.2	2.6	ug/kg	
71-55-6	1,1,1-Trichloroethane	ND	2.1	0.50	ug/kg	
79-00-5	1,1,2-Trichloroethane	ND	2.1	0.57	ug/kg	
79-01-6	Trichloroethene	ND	1.0	0.79	ug/kg	
75-69-4	Trichlorofluoromethane	ND	5.2	0.71	ug/kg	
75-01-4	Vinyl chloride	ND	2.1	0.50	ug/kg	
	m,p-Xylene	ND	1.0	0.93	ug/kg	
95-47-6	o-Xylene	ND	1.0	0.47	ug/kg	
1330-20-7	Xylene (total)	ND	1.0	0.47	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
1868-53-7	Dibromofluoromethane	107%		80-124%
17060-07-0	1,2-Dichloroethane-D4	110%		75-133%
2037-26-5	Toluene-D8	102%		79-125%
460-00-4	4-Bromofluorobenzene	95%		58-148%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Total TIC, Volatile		0	ug/kg	

(a) Associated CCV outside of control limits high, sample was ND.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-16(7.5-8)030724		
Lab Sample ID:	JD83927-11	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	86.2
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	Z166839.D	1	03/11/24 17:24	JY	03/09/24 18:30	OP53010	EZ8267
Run #2							

	Initial Weight	Final Volume
Run #1	30.1 g	1.0 ml
Run #2		

ABN TCL List (SOM0 2.0)

CAS No.	Compound	Result	RL	MDL	Units	Q
95-57-8	2-Chlorophenol	ND	77	19	ug/kg	
59-50-7	4-Chloro-3-methyl phenol	ND	190	24	ug/kg	
120-83-2	2,4-Dichlorophenol	ND	190	33	ug/kg	
105-67-9	2,4-Dimethylphenol	ND	190	69	ug/kg	
51-28-5	2,4-Dinitrophenol	ND	190	140	ug/kg	
534-52-1	4,6-Dinitro-o-cresol	ND	190	41	ug/kg	
95-48-7	2-Methylphenol	ND	77	25	ug/kg	
	3&4-Methylphenol	ND	77	32	ug/kg	
88-75-5	2-Nitrophenol	ND	190	25	ug/kg	
100-02-7	4-Nitrophenol	ND	390	100	ug/kg	
87-86-5	Pentachlorophenol	ND	150	36	ug/kg	
108-95-2	Phenol	ND	77	20	ug/kg	
58-90-2	2,3,4,6-Tetrachlorophenol	ND	190	26	ug/kg	
95-95-4	2,4,5-Trichlorophenol	ND	190	29	ug/kg	
88-06-2	2,4,6-Trichlorophenol	ND	190	23	ug/kg	
83-32-9	Acenaphthene [a]	ND	39	13	ug/kg	
208-96-8	Acenaphthylene	ND	39	20	ug/kg	
98-86-2	Acetophenone	ND	190	8.3	ug/kg	
120-12-7	Anthracene	ND	39	24	ug/kg	
1912-24-9	Atrazine	ND	77	16	ug/kg	
56-55-3	Benzo(a)anthracene	ND	39	11	ug/kg	
50-32-8	Benzo(a)pyrene	ND	39	18	ug/kg	
205-99-2	Benzo(b)fluoranthene	ND	39	17	ug/kg	
191-24-2	Benzo(g,h,i)perylene	ND	39	19	ug/kg	
207-08-9	Benzo(k)fluoranthene	ND	39	18	ug/kg	
101-55-3	4-Bromophenyl phenyl ether	ND	77	15	ug/kg	
85-68-7	Butyl benzyl phthalate	ND	77	9.4	ug/kg	
92-52-4	1,1'-Biphenyl	ND	77	5.3	ug/kg	
100-52-7	Benzaldehyde [b]	ND	190	9.6	ug/kg	
91-58-7	2-Chloronaphthalene	ND	77	9.2	ug/kg	
106-47-8	4-Chloroaniline	ND	190	14	ug/kg	
86-74-8	Carbazole	ND	77	5.6	ug/kg	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-16(7.5-8)030724		
Lab Sample ID:	JD83927-11	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	86.2
Project:	100 Main Street, White Plains, NY		

ABN TCL List (SOM0 2.0)

CAS No.	Compound	Result	RL	MDL	Units	Q
105-60-2	Caprolactam	ND	77	15	ug/kg	
218-01-9	Chrysene	ND	39	12	ug/kg	
111-91-1	bis(2-Chloroethoxy)methane	ND	77	8.2	ug/kg	
111-44-4	bis(2-Chloroethyl)ether	ND	77	17	ug/kg	
108-60-1	2,2'-Oxybis(1-chloropropane)	ND	77	14	ug/kg	
7005-72-3	4-Chlorophenyl phenyl ether	ND	77	12	ug/kg	
121-14-2	2,4-Dinitrotoluene	ND	39	12	ug/kg	
606-20-2	2,6-Dinitrotoluene	ND	39	19	ug/kg	
91-94-1	3,3'-Dichlorobenzidine	ND	77	32	ug/kg	
123-91-1	1,4-Dioxane	ND	39	25	ug/kg	
53-70-3	Dibenzo(a,h)anthracene	ND	39	17	ug/kg	
132-64-9	Dibenzofuran [a]	ND	77	16	ug/kg	
84-74-2	Di-n-butyl phthalate	ND	77	6.3	ug/kg	
117-84-0	Di-n-octyl phthalate	ND	77	9.6	ug/kg	
84-66-2	Diethyl phthalate	ND	77	8.2	ug/kg	
131-11-3	Dimethyl phthalate	ND	77	6.9	ug/kg	
117-81-7	bis(2-Ethylhexyl)phthalate	ND	77	9.0	ug/kg	
206-44-0	Fluoranthene	ND	39	17	ug/kg	
86-73-7	Fluorene [a]	ND	39	18	ug/kg	
118-74-1	Hexachlorobenzene [a]	ND	77	9.8	ug/kg	
87-68-3	Hexachlorobutadiene [a]	ND	39	15	ug/kg	
77-47-4	Hexachlorocyclopentadiene	ND	390	15	ug/kg	
67-72-1	Hexachloroethane	ND	190	19	ug/kg	
193-39-5	Indeno(1,2,3-cd)pyrene	ND	39	18	ug/kg	
78-59-1	Isophorone	ND	77	8.2	ug/kg	
91-57-6	2-Methylnaphthalene	ND	39	8.7	ug/kg	
88-74-4	2-Nitroaniline	ND	190	9.1	ug/kg	
99-09-2	3-Nitroaniline	ND	190	9.6	ug/kg	
100-01-6	4-Nitroaniline	ND	190	10	ug/kg	
91-20-3	Naphthalene [a]	ND	39	11	ug/kg	
98-95-3	Nitrobenzene	ND	77	15	ug/kg	
621-64-7	N-Nitroso-di-n-propylamine	ND	77	11	ug/kg	
86-30-6	N-Nitrosodiphenylamine	ND	190	14	ug/kg	
85-01-8	Phenanthrene [a]	ND	39	13	ug/kg	
129-00-0	Pyrene	ND	39	12	ug/kg	
95-94-3	1,2,4,5-Tetrachlorobenzene	ND	190	9.8	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
367-12-4	2-Fluorophenol	41%		10-99%

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-16(7.5-8)030724		
Lab Sample ID:	JD83927-11	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	86.2
Project:	100 Main Street, White Plains, NY		

ABN TCL List (SOM0 2.0)

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
4165-62-2	Phenol-d5	44%		10-96%
118-79-6	2,4,6-Tribromophenol	45%		10-123%
4165-60-0	Nitrobenzene-d5	44%		10-109%
321-60-8	2-Fluorobiphenyl	42%		11-109%
1718-51-0	Terphenyl-d14	51%		10-120%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	n-Hexadecanoic acid	7.19	210	ug/kg	J
	Unknown	7.66	270	ug/kg	J
	Total TIC, Semi-Volatile		480	ug/kg	J

(a) Associated CCV outside of control limits low. Low-level verification was analyzed to demonstrate system suitability to detect affected analytes. Sample was ND.
(b) Associated CCV outside of control limits high, sample was ND.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-16(7.5-8)030724		
Lab Sample ID:	JD83927-11	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8081B SW846 3570	**Percent Solids:**	86.2
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	4G9737032.D	1	03/11/24 06:14	CP	03/09/24 08:40	OP53021	G4G4306
Run #2							

	Initial Weight	Final Volume
Run #1	5.3 g	10.0 ml
Run #2		

Pesticide TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
309-00-2	Aldrin	ND	0.44	0.085	ug/kg	
319-84-6	alpha-BHC	ND	0.44	0.050	ug/kg	
319-85-7	beta-BHC	ND	0.44	0.063	ug/kg	
319-86-8	delta-BHC	ND	0.44	0.066	ug/kg	
58-89-9	gamma-BHC (Lindane)	ND	0.44	0.077	ug/kg	
5103-71-9	alpha-Chlordane	ND	0.44	0.059	ug/kg	
5103-74-2	gamma-Chlordane	ND	0.44	0.066	ug/kg	
60-57-1	Dieldrin	ND	0.44	0.070	ug/kg	
72-54-8	4,4'-DDD	ND	0.44	0.046	ug/kg	
72-55-9	4,4'-DDE	ND	0.44	0.053	ug/kg	
50-29-3	4,4'-DDT	ND	0.44	0.077	ug/kg	
72-20-8	Endrin	ND	0.44	0.063	ug/kg	
1031-07-8	Endosulfan sulfate	ND	0.44	0.053	ug/kg	
7421-93-4	Endrin aldehyde	ND	0.44	0.13	ug/kg	
959-98-8	Endosulfan-I	ND	0.44	0.059	ug/kg	
33213-65-9	Endosulfan-II	ND	0.44	0.061	ug/kg	
76-44-8	Heptachlor	ND	0.44	0.057	ug/kg	
1024-57-3	Heptachlor epoxide	ND	0.44	0.079	ug/kg	
72-43-5	Methoxychlor	ND	0.44	0.17	ug/kg	
53494-70-5	Endrin ketone	ND	0.44	0.070	ug/kg	
8001-35-2	Toxaphene	ND	5.5	3.6	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
877-09-8	Tetrachloro-m-xylene	94%		66-150%
877-09-8	Tetrachloro-m-xylene	102%		66-150%
2051-24-3	Decachlorobiphenyl	85%		40-150%
2051-24-3	Decachlorobiphenyl	69%		40-150%

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-16(7.5-8)030724		
Lab Sample ID:	JD83927-11	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8082A SW846 3570	**Percent Solids:**	86.2
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	2G231146.D	1	03/11/24 05:36	TP	03/09/24 08:40	OP53022	G2G6058
Run #2							

	Initial Weight	Final Volume
Run #1	5.3 g	10.0 ml
Run #2		

PCB List

CAS No.	Compound	Result	RL	MDL	Units	Q
12674-11-2	Aroclor 1016	ND	22	9.3	ug/kg	
11104-28-2	Aroclor 1221	ND	22	7.4	ug/kg	
11141-16-5	Aroclor 1232	ND	22	18	ug/kg	
53469-21-9	Aroclor 1242	ND	22	13	ug/kg	
12672-29-6	Aroclor 1248	ND	22	4.7	ug/kg	
11097-69-1	Aroclor 1254	ND	22	2.4	ug/kg	
11096-82-5	Aroclor 1260	ND	22	7.6	ug/kg	
11100-14-4	Aroclor 1268	ND	22	2.2	ug/kg	
37324-23-5	Aroclor 1262	ND	22	1.8	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
877-09-8	Tetrachloro-m-xylene	96%		42-159%
877-09-8	Tetrachloro-m-xylene	99%		42-159%
2051-24-3	Decachlorobiphenyl	117%		18-154%
2051-24-3	Decachlorobiphenyl	119%		18-154%

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID: SB-16(7.5-8)030724
Lab Sample ID: JD83927-11
Matrix: SO - Soil
Project: 100 Main Street, White Plains, NY

Date Sampled: 03/07/24
Date Received: 03/07/24
Percent Solids: 86.2

Metals Analysis

Analyte	Result	RL	Units	DF	Prep	Analyzed	By	Method	Prep Method
Aluminum	6660	58	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Antimony	< 2.3	2.3	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Arsenic	< 2.3	2.3	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Barium	35.7	23	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Beryllium	0.30	0.23	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Cadmium	< 0.58	0.58	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Calcium	2040	580	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Chromium	13.6	1.2	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Cobalt	< 5.8	5.8	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Copper	13.5	2.9	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Iron	12800	58	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Lead	3.9	2.3	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Magnesium	3270	580	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Manganese	162	1.7	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Mercury	< 0.036	0.036	mg/kg	1	03/13/24	03/14/24	LM	SW846 7471B [1]	SW846 7471B [4]
Nickel	10.9	4.6	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Potassium	1430	1200	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Selenium	< 2.3	2.3	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Silver	< 0.58	0.58	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Sodium	< 1200	1200	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Thallium	< 1.2	1.2	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Vanadium	18.8	5.8	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Zinc	28.4	5.8	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]

(1) Instrument QC Batch: MA55688
(2) Instrument QC Batch: MA55691
(3) Prep QC Batch: MP45216
(4) Prep QC Batch: MP45278

RL = Reporting Limit

Report of Analysis

Client Sample ID:	SB-16(7.5-8)030724		
Lab Sample ID:	JD83927-11	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
		Percent Solids:	86.2
Project:	100 Main Street, White Plains, NY		

General Chemistry

Analyte	Result	RL	Units	DF	Analyzed	By	Method
Cyanide	< 0.26	0.26	mg/kg	1	03/12/24 19:48	JD	SW846 9012B/LACHAT
Solids, Percent	86.2		%	1	03/08/24 06:00	SC	SM2540 G 18TH ED MOD

RL = Reporting Limit

Report of Analysis

Client Sample ID:	SB-19(4-4.5)030724		
Lab Sample ID:	JD83927-12	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8260D SW846 5035	**Percent Solids:**	88.0
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	1C199839.D	1	03/09/24 06:54	PS	03/08/24 10:00	n/a	V1C8643
Run #2							

	Initial Weight
Run #1	5.7 g
Run #2	

VOA TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
67-64-1	Acetone	ND	10	4.1	ug/kg	
71-43-2	Benzene	ND	0.50	0.45	ug/kg	
74-97-5	Bromochloromethane	ND	5.0	0.56	ug/kg	
75-27-4	Bromodichloromethane	ND	2.0	0.43	ug/kg	
75-25-2	Bromoform	ND	5.0	1.4	ug/kg	
74-83-9	Bromomethane	ND	5.0	0.76	ug/kg	
78-93-3	2-Butanone (MEK)	ND	10	2.4	ug/kg	
75-15-0	Carbon disulfide	ND	2.0	0.53	ug/kg	
56-23-5	Carbon tetrachloride	ND	2.0	0.62	ug/kg	
108-90-7	Chlorobenzene	ND	2.0	0.46	ug/kg	
75-00-3	Chloroethane	ND	5.0	0.59	ug/kg	
67-66-3	Chloroform	ND	2.0	0.52	ug/kg	
74-87-3	Chloromethane	ND	5.0	2.0	ug/kg	
110-82-7	Cyclohexane	ND	2.0	0.65	ug/kg	
96-12-8	1,2-Dibromo-3-chloropropane	ND	2.0	0.69	ug/kg	
124-48-1	Dibromochloromethane	ND	2.0	0.56	ug/kg	
106-93-4	1,2-Dibromoethane	ND	1.0	0.42	ug/kg	
95-50-1	1,2-Dichlorobenzene	ND	1.0	0.54	ug/kg	
541-73-1	1,3-Dichlorobenzene	ND	1.0	0.49	ug/kg	
106-46-7	1,4-Dichlorobenzene	ND	1.0	0.49	ug/kg	
75-71-8	Dichlorodifluoromethane [a]	ND	5.0	0.72	ug/kg	
75-34-3	1,1-Dichloroethane	ND	1.0	0.49	ug/kg	
107-06-2	1,2-Dichloroethane	ND	1.0	0.47	ug/kg	
75-35-4	1,1-Dichloroethene	ND	1.0	0.65	ug/kg	
156-59-2	cis-1,2-Dichloroethene	ND	1.0	0.84	ug/kg	
156-60-5	trans-1,2-Dichloroethene	ND	1.0	0.61	ug/kg	
78-87-5	1,2-Dichloropropane	ND	2.0	0.47	ug/kg	
10061-01-5	cis-1,3-Dichloropropene	ND	2.0	0.47	ug/kg	
10061-02-6	trans-1,3-Dichloropropene	ND	2.0	0.46	ug/kg	
100-41-4	Ethylbenzene	ND	1.0	0.45	ug/kg	
76-13-1	Freon 113	ND	5.0	2.7	ug/kg	
591-78-6	2-Hexanone	ND	5.0	2.1	ug/kg	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-19(4-4.5)030724		
Lab Sample ID:	JD83927-12	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8260D SW846 5035	**Percent Solids:**	88.0
Project:	100 Main Street, White Plains, NY		

VOA TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
98-82-8	Isopropylbenzene	ND	2.0	1.4	ug/kg	
79-20-9	Methyl Acetate	ND	5.0	1.4	ug/kg	
108-87-2	Methylcyclohexane	ND	2.0	0.87	ug/kg	
1634-04-4	Methyl Tert Butyl Ether	ND	1.0	0.47	ug/kg	
108-10-1	4-Methyl-2-pentanone(MIBK)	ND	5.0	2.3	ug/kg	
75-09-2	Methylene chloride	ND	5.0	2.6	ug/kg	
100-42-5	Styrene	ND	2.0	0.40	ug/kg	
79-34-5	1,1,2,2-Tetrachloroethane	ND	2.0	0.60	ug/kg	
127-18-4	Tetrachloroethene	ND	2.0	0.58	ug/kg	
108-88-3	Toluene	ND	1.0	0.52	ug/kg	
87-61-6	1,2,3-Trichlorobenzene	ND	5.0	2.5	ug/kg	
120-82-1	1,2,4-Trichlorobenzene	ND	5.0	2.5	ug/kg	
71-55-6	1,1,1-Trichloroethane	ND	2.0	0.48	ug/kg	
79-00-5	1,1,2-Trichloroethane	ND	2.0	0.55	ug/kg	
79-01-6	Trichloroethene	ND	1.0	0.76	ug/kg	
75-69-4	Trichlorofluoromethane	ND	5.0	0.68	ug/kg	
75-01-4	Vinyl chloride	ND	2.0	0.48	ug/kg	
	m,p-Xylene	ND	1.0	0.89	ug/kg	
95-47-6	o-Xylene	ND	1.0	0.46	ug/kg	
1330-20-7	Xylene (total)	ND	1.0	0.46	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
1868-53-7	Dibromofluoromethane	102%		80-124%
17060-07-0	1,2-Dichloroethane-D4	111%		75-133%
2037-26-5	Toluene-D8	99%		79-125%
460-00-4	4-Bromofluorobenzene	97%		58-148%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Total TIC, Volatile		0	ug/kg	

(a) Associated CCV outside of control limits high, sample was ND.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-19(4-4.5)030724		
Lab Sample ID:	JD83927-12	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	88.0
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	Z166840.D	1	03/11/24 17:47	JY	03/09/24 18:30	OP53010	EZ8267
Run #2							

	Initial Weight	Final Volume
Run #1	30.3 g	1.0 ml
Run #2		

ABN TCL List (SOM0 2.0)

CAS No.	Compound	Result	RL	MDL	Units	Q
95-57-8	2-Chlorophenol	ND	75	19	ug/kg	
59-50-7	4-Chloro-3-methyl phenol	ND	190	23	ug/kg	
120-83-2	2,4-Dichlorophenol	ND	190	32	ug/kg	
105-67-9	2,4-Dimethylphenol	ND	190	67	ug/kg	
51-28-5	2,4-Dinitrophenol	ND	190	140	ug/kg	
534-52-1	4,6-Dinitro-o-cresol	ND	190	40	ug/kg	
95-48-7	2-Methylphenol	ND	75	24	ug/kg	
	3&4-Methylphenol	ND	75	31	ug/kg	
88-75-5	2-Nitrophenol	ND	190	25	ug/kg	
100-02-7	4-Nitrophenol	ND	380	100	ug/kg	
87-86-5	Pentachlorophenol	ND	150	35	ug/kg	
108-95-2	Phenol	ND	75	20	ug/kg	
58-90-2	2,3,4,6-Tetrachlorophenol	ND	190	25	ug/kg	
95-95-4	2,4,5-Trichlorophenol	ND	190	28	ug/kg	
88-06-2	2,4,6-Trichlorophenol	ND	190	22	ug/kg	
83-32-9	Acenaphthene [a]	ND	38	13	ug/kg	
208-96-8	Acenaphthylene	ND	38	19	ug/kg	
98-86-2	Acetophenone	ND	190	8.1	ug/kg	
120-12-7	Anthracene	ND	38	23	ug/kg	
1912-24-9	Atrazine	ND	75	16	ug/kg	
56-55-3	Benzo(a)anthracene	ND	38	11	ug/kg	
50-32-8	Benzo(a)pyrene	ND	38	17	ug/kg	
205-99-2	Benzo(b)fluoranthene	ND	38	17	ug/kg	
191-24-2	Benzo(g,h,i)perylene	ND	38	19	ug/kg	
207-08-9	Benzo(k)fluoranthene	ND	38	18	ug/kg	
101-55-3	4-Bromophenyl phenyl ether	ND	75	14	ug/kg	
85-68-7	Butyl benzyl phthalate	ND	75	9.2	ug/kg	
92-52-4	1,1'-Biphenyl	ND	75	5.1	ug/kg	
100-52-7	Benzaldehyde [b]	ND	190	9.3	ug/kg	
91-58-7	2-Chloronaphthalene	ND	75	8.9	ug/kg	
106-47-8	4-Chloroaniline	ND	190	14	ug/kg	
86-74-8	Carbazole	ND	75	5.4	ug/kg	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID: SB-19(4-4.5)030724
Lab Sample ID: JD83927-12
Matrix: SO - Soil
Method: SW846 8270E SW846 3546
Project: 100 Main Street, White Plains, NY

Date Sampled: 03/07/24
Date Received: 03/07/24
Percent Solids: 88.0

ABN TCL List (SOM0 2.0)

CAS No.	Compound	Result	RL	MDL	Units	Q
105-60-2	Caprolactam	ND	75	15	ug/kg	
218-01-9	Chrysene	ND	38	12	ug/kg	
111-91-1	bis(2-Chloroethoxy)methane	ND	75	8.0	ug/kg	
111-44-4	bis(2-Chloroethyl)ether	ND	75	16	ug/kg	
108-60-1	2,2'-Oxybis(1-chloropropane)	ND	75	13	ug/kg	
7005-72-3	4-Chlorophenyl phenyl ether	ND	75	12	ug/kg	
121-14-2	2,4-Dinitrotoluene	ND	38	12	ug/kg	
606-20-2	2,6-Dinitrotoluene	ND	38	19	ug/kg	
91-94-1	3,3'-Dichlorobenzidine	ND	75	31	ug/kg	
123-91-1	1,4-Dioxane	ND	38	25	ug/kg	
53-70-3	Dibenzo(a,h)anthracene	ND	38	17	ug/kg	
132-64-9	Dibenzofuran [a]	ND	75	15	ug/kg	
84-74-2	Di-n-butyl phthalate	ND	75	6.1	ug/kg	
117-84-0	Di-n-octyl phthalate	ND	75	9.3	ug/kg	
84-66-2	Diethyl phthalate	ND	75	8.0	ug/kg	
131-11-3	Dimethyl phthalate	ND	75	6.7	ug/kg	
117-81-7	bis(2-Ethylhexyl)phthalate	ND	75	8.8	ug/kg	
206-44-0	Fluoranthene	ND	38	17	ug/kg	
86-73-7	Fluorene [a]	ND	38	17	ug/kg	
118-74-1	Hexachlorobenzene [a]	ND	75	9.5	ug/kg	
87-68-3	Hexachlorobutadiene [a]	ND	38	15	ug/kg	
77-47-4	Hexachlorocyclopentadiene	ND	380	15	ug/kg	
67-72-1	Hexachloroethane	ND	190	19	ug/kg	
193-39-5	Indeno(1,2,3-cd)pyrene	ND	38	18	ug/kg	
78-59-1	Isophorone	ND	75	8.0	ug/kg	
91-57-6	2-Methylnaphthalene	ND	38	8.5	ug/kg	
88-74-4	2-Nitroaniline	ND	190	8.9	ug/kg	
99-09-2	3-Nitroaniline	ND	190	9.4	ug/kg	
100-01-6	4-Nitroaniline	ND	190	9.7	ug/kg	
91-20-3	Naphthalene [a]	ND	38	11	ug/kg	
98-95-3	Nitrobenzene	ND	75	14	ug/kg	
621-64-7	N-Nitroso-di-n-propylamine	ND	75	11	ug/kg	
86-30-6	N-Nitrosodiphenylamine	ND	190	14	ug/kg	
85-01-8	Phenanthrene [a]	ND	38	13	ug/kg	
129-00-0	Pyrene	ND	38	12	ug/kg	
95-94-3	1,2,4,5-Tetrachlorobenzene	ND	190	9.5	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
367-12-4	2-Fluorophenol	44%		10-99%

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-19(4-4.5)030724		
Lab Sample ID:	JD83927-12	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	88.0
Project:	100 Main Street, White Plains, NY		

ABN TCL List (SOM0 2.0)

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
4165-62-2	Phenol-d5	45%		10-96%
118-79-6	2,4,6-Tribromophenol	48%		10-123%
4165-60-0	Nitrobenzene-d5	46%		10-109%
321-60-8	2-Fluorobiphenyl	44%		11-109%
1718-51-0	Terphenyl-d14	53%		10-120%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	n-Hexadecanoic acid	7.19	210	ug/kg	J
	Unknown	7.66	400	ug/kg	J
	Octadecanoic acid	7.92	150	ug/kg	J
	Total TIC, Semi-Volatile		760	ug/kg	J

(a) Associated CCV outside of control limits low. Low-level verification was analyzed to demonstrate system suitability to detect affected analytes. Sample was ND.
(b) Associated CCV outside of control limits high, sample was ND.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-19(4-4.5)030724		
Lab Sample ID:	JD83927-12	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8081B SW846 3570	**Percent Solids:**	88.0
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	4G9737033.D	1	03/11/24 06:33	CP	03/09/24 08:40	OP53021	G4G4306
Run #2							

	Initial Weight	Final Volume
Run #1	5.2 g	10.0 ml
Run #2		

Pesticide TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
309-00-2	Aldrin	ND	0.44	0.085	ug/kg	
319-84-6	alpha-BHC	ND	0.44	0.050	ug/kg	
319-85-7	beta-BHC	ND	0.44	0.063	ug/kg	
319-86-8	delta-BHC	ND	0.44	0.066	ug/kg	
58-89-9	gamma-BHC (Lindane)	ND	0.44	0.076	ug/kg	
5103-71-9	alpha-Chlordane	ND	0.44	0.059	ug/kg	
5103-74-2	gamma-Chlordane	ND	0.44	0.066	ug/kg	
60-57-1	Dieldrin	ND	0.44	0.070	ug/kg	
72-54-8	4,4'-DDD	ND	0.44	0.046	ug/kg	
72-55-9	4,4'-DDE	ND	0.44	0.052	ug/kg	
50-29-3	4,4'-DDT	ND	0.44	0.076	ug/kg	
72-20-8	Endrin	ND	0.44	0.063	ug/kg	
1031-07-8	Endosulfan sulfate	ND	0.44	0.052	ug/kg	
7421-93-4	Endrin aldehyde	ND	0.44	0.13	ug/kg	
959-98-8	Endosulfan-I	ND	0.44	0.059	ug/kg	
33213-65-9	Endosulfan-II	ND	0.44	0.061	ug/kg	
76-44-8	Heptachlor	ND	0.44	0.057	ug/kg	
1024-57-3	Heptachlor epoxide	ND	0.44	0.079	ug/kg	
72-43-5	Methoxychlor	ND	0.44	0.17	ug/kg	
53494-70-5	Endrin ketone	ND	0.44	0.070	ug/kg	
8001-35-2	Toxaphene	ND	5.5	3.6	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
877-09-8	Tetrachloro-m-xylene	93%		66-150%
877-09-8	Tetrachloro-m-xylene	99%		66-150%
2051-24-3	Decachlorobiphenyl	84%		40-150%
2051-24-3	Decachlorobiphenyl	68%		40-150%

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-19(4-4.5)030724		
Lab Sample ID:	JD83927-12	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8082A SW846 3570	**Percent Solids:**	88.0
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	2G231147.D	1	03/11/24 06:01	TP	03/09/24 08:40	OP53022	G2G6058
Run #2							

	Initial Weight	Final Volume
Run #1	5.2 g	10.0 ml
Run #2		

PCB List

CAS No.	Compound	Result	RL	MDL	Units	Q
12674-11-2	Aroclor 1016	ND	22	9.3	ug/kg	
11104-28-2	Aroclor 1221	ND	22	7.3	ug/kg	
11141-16-5	Aroclor 1232	ND	22	18	ug/kg	
53469-21-9	Aroclor 1242	ND	22	13	ug/kg	
12672-29-6	Aroclor 1248	ND	22	4.7	ug/kg	
11097-69-1	Aroclor 1254	ND	22	2.4	ug/kg	
11096-82-5	Aroclor 1260	ND	22	7.5	ug/kg	
11100-14-4	Aroclor 1268	ND	22	2.2	ug/kg	
37324-23-5	Aroclor 1262	ND	22	1.8	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
877-09-8	Tetrachloro-m-xylene	94%		42-159%
877-09-8	Tetrachloro-m-xylene	98%		42-159%
2051-24-3	Decachlorobiphenyl	111%		18-154%
2051-24-3	Decachlorobiphenyl	118%		18-154%

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-19(4-4.5)030724		
Lab Sample ID:	JD83927-12	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
		Percent Solids:	88.0
Project:	100 Main Street, White Plains, NY		

Metals Analysis

Analyte	Result	RL	Units	DF	Prep	Analyzed	By	Method	Prep Method
Aluminum	8740	58	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Antimony	< 2.3	2.3	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Arsenic	< 2.3	2.3	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Barium	63.6	23	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Beryllium	0.37	0.23	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Cadmium	< 0.58	0.58	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Calcium	2700	580	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Chromium	17.5	1.2	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Cobalt	6.9	5.8	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Copper	16.4	2.9	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Iron	16300	58	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Lead	5.5	2.3	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Magnesium	5090	580	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Manganese	236	1.7	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Mercury	< 0.037	0.037	mg/kg	1	03/13/24	03/14/24	LM	SW846 7471B [1]	SW846 7471B [4]
Nickel	14.4	4.6	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Potassium	2760	1200	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Selenium	< 2.3	2.3	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Silver	< 0.58	0.58	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Sodium	< 1200	1200	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Thallium	< 1.2	1.2	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Vanadium	24.9	5.8	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Zinc	40.4	5.8	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]

(1) Instrument QC Batch: MA55688
(2) Instrument QC Batch: MA55691
(3) Prep QC Batch: MP45216
(4) Prep QC Batch: MP45278

RL = Reporting Limit

Report of Analysis

Client Sample ID:	SB-19(4-4.5)030724		
Lab Sample ID:	JD83927-12	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
		Percent Solids:	88.0
Project:	100 Main Street, White Plains, NY		

General Chemistry

Analyte	Result	RL	Units	DF	Analyzed	By	Method
Cyanide	< 0.27	0.27	mg/kg	1	03/12/24 19:49	JD	SW846 9012B/LACHAT
Solids, Percent	88		%	1	03/08/24 06:00	SC	SM2540 G 18TH ED MOD

RL = Reporting Limit

Report of Analysis

Client Sample ID:	SB-19(7-7.5)030724		
Lab Sample ID:	JD83927-13	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8260D SW846 5035	**Percent Solids:**	82.1
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	1C199840.D	1	03/09/24 07:19	PS	03/08/24 10:00	n/a	V1C8643
Run #2							

	Initial Weight
Run #1	6.2 g
Run #2	

VOA TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
67-64-1	Acetone	ND	9.8	4.1	ug/kg	
71-43-2	Benzene	ND	0.49	0.45	ug/kg	
74-97-5	Bromochloromethane	ND	4.9	0.55	ug/kg	
75-27-4	Bromodichloromethane	ND	2.0	0.42	ug/kg	
75-25-2	Bromoform	ND	4.9	1.3	ug/kg	
74-83-9	Bromomethane	ND	4.9	0.75	ug/kg	
78-93-3	2-Butanone (MEK)	ND	9.8	2.4	ug/kg	
75-15-0	Carbon disulfide	ND	2.0	0.53	ug/kg	
56-23-5	Carbon tetrachloride	ND	2.0	0.61	ug/kg	
108-90-7	Chlorobenzene	ND	2.0	0.45	ug/kg	
75-00-3	Chloroethane	ND	4.9	0.58	ug/kg	
67-66-3	Chloroform	ND	2.0	0.51	ug/kg	
74-87-3	Chloromethane	ND	4.9	1.9	ug/kg	
110-82-7	Cyclohexane	ND	2.0	0.65	ug/kg	
96-12-8	1,2-Dibromo-3-chloropropane	ND	2.0	0.68	ug/kg	
124-48-1	Dibromochloromethane	ND	2.0	0.55	ug/kg	
106-93-4	1,2-Dibromoethane	ND	0.98	0.41	ug/kg	
95-50-1	1,2-Dichlorobenzene	ND	0.98	0.54	ug/kg	
541-73-1	1,3-Dichlorobenzene	ND	0.98	0.49	ug/kg	
106-46-7	1,4-Dichlorobenzene	ND	0.98	0.49	ug/kg	
75-71-8	Dichlorodifluoromethane [a]	ND	4.9	0.71	ug/kg	
75-34-3	1,1-Dichloroethane	ND	0.98	0.49	ug/kg	
107-06-2	1,2-Dichloroethane	ND	0.98	0.46	ug/kg	
75-35-4	1,1-Dichloroethene	ND	0.98	0.64	ug/kg	
156-59-2	cis-1,2-Dichloroethene	ND	0.98	0.83	ug/kg	
156-60-5	trans-1,2-Dichloroethene	ND	0.98	0.60	ug/kg	
78-87-5	1,2-Dichloropropane	ND	2.0	0.46	ug/kg	
10061-01-5	cis-1,3-Dichloropropene	ND	2.0	0.47	ug/kg	
10061-02-6	trans-1,3-Dichloropropene	ND	2.0	0.45	ug/kg	
100-41-4	Ethylbenzene	ND	0.98	0.44	ug/kg	
76-13-1	Freon 113	ND	4.9	2.6	ug/kg	
591-78-6	2-Hexanone	ND	4.9	2.1	ug/kg	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-19(7-7.5)030724		
Lab Sample ID:	JD83927-13	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8260D SW846 5035	**Percent Solids:**	82.1
Project:	100 Main Street, White Plains, NY		

VOA TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
98-82-8	Isopropylbenzene	ND	2.0	1.4	ug/kg	
79-20-9	Methyl Acetate	ND	4.9	1.4	ug/kg	
108-87-2	Methylcyclohexane	ND	2.0	0.86	ug/kg	
1634-04-4	Methyl Tert Butyl Ether	ND	0.98	0.46	ug/kg	
108-10-1	4-Methyl-2-pentanone(MIBK)	ND	4.9	2.2	ug/kg	
75-09-2	Methylene chloride	ND	4.9	2.6	ug/kg	
100-42-5	Styrene	ND	2.0	0.39	ug/kg	
79-34-5	1,1,2,2-Tetrachloroethane	ND	2.0	0.59	ug/kg	
127-18-4	Tetrachloroethene	ND	2.0	0.57	ug/kg	
108-88-3	Toluene	ND	0.98	0.52	ug/kg	
87-61-6	1,2,3-Trichlorobenzene	ND	4.9	2.5	ug/kg	
120-82-1	1,2,4-Trichlorobenzene	ND	4.9	2.5	ug/kg	
71-55-6	1,1,1-Trichloroethane	ND	2.0	0.47	ug/kg	
79-00-5	1,1,2-Trichloroethane	ND	2.0	0.54	ug/kg	
79-01-6	Trichloroethene	ND	0.98	0.75	ug/kg	
75-69-4	Trichlorofluoromethane	ND	4.9	0.67	ug/kg	
75-01-4	Vinyl chloride	ND	2.0	0.47	ug/kg	
	m,p-Xylene	ND	0.98	0.88	ug/kg	
95-47-6	o-Xylene	ND	0.98	0.45	ug/kg	
1330-20-7	Xylene (total)	ND	0.98	0.45	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
1868-53-7	Dibromofluoromethane	104%		80-124%
17060-07-0	1,2-Dichloroethane-D4	110%		75-133%
2037-26-5	Toluene-D8	105%		79-125%
460-00-4	4-Bromofluorobenzene	96%		58-148%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Total TIC, Volatile		0	ug/kg	

(a) Associated CCV outside of control limits high, sample was ND.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-19(7-7.5)030724		
Lab Sample ID:	JD83927-13	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	82.1
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	Z166841.D	1	03/11/24 18:11	JY	03/09/24 18:30	OP53010	EZ8267
Run #2							

	Initial Weight	Final Volume
Run #1	31.9 g	1.0 ml
Run #2		

ABN TCL List (SOM0 2.0)

CAS No.	Compound	Result	RL	MDL	Units	Q
95-57-8	2-Chlorophenol	ND	76	19	ug/kg	
59-50-7	4-Chloro-3-methyl phenol	ND	190	23	ug/kg	
120-83-2	2,4-Dichlorophenol	ND	190	33	ug/kg	
105-67-9	2,4-Dimethylphenol	ND	190	68	ug/kg	
51-28-5	2,4-Dinitrophenol	ND	190	140	ug/kg	
534-52-1	4,6-Dinitro-o-cresol	ND	190	41	ug/kg	
95-48-7	2-Methylphenol	ND	76	24	ug/kg	
	3&4-Methylphenol	ND	76	31	ug/kg	
88-75-5	2-Nitrophenol	ND	190	25	ug/kg	
100-02-7	4-Nitrophenol	ND	380	100	ug/kg	
87-86-5	Pentachlorophenol	ND	150	36	ug/kg	
108-95-2	Phenol	ND	76	20	ug/kg	
58-90-2	2,3,4,6-Tetrachlorophenol	ND	190	25	ug/kg	
95-95-4	2,4,5-Trichlorophenol	ND	190	29	ug/kg	
88-06-2	2,4,6-Trichlorophenol	ND	190	23	ug/kg	
83-32-9	Acenaphthene [a]	ND	38	13	ug/kg	
208-96-8	Acenaphthylene	ND	38	19	ug/kg	
98-86-2	Acetophenone	ND	190	8.2	ug/kg	
120-12-7	Anthracene	ND	38	23	ug/kg	
1912-24-9	Atrazine	ND	76	16	ug/kg	
56-55-3	Benzo(a)anthracene	ND	38	11	ug/kg	
50-32-8	Benzo(a)pyrene	ND	38	17	ug/kg	
205-99-2	Benzo(b)fluoranthene	ND	38	17	ug/kg	
191-24-2	Benzo(g,h,i)perylene	ND	38	19	ug/kg	
207-08-9	Benzo(k)fluoranthene	ND	38	18	ug/kg	
101-55-3	4-Bromophenyl phenyl ether	ND	76	15	ug/kg	
85-68-7	Butyl benzyl phthalate	ND	76	9.3	ug/kg	
92-52-4	1,1'-Biphenyl	ND	76	5.2	ug/kg	
100-52-7	Benzaldehyde [b]	ND	190	9.5	ug/kg	
91-58-7	2-Chloronaphthalene	ND	76	9.1	ug/kg	
106-47-8	4-Chloroaniline	ND	190	14	ug/kg	
86-74-8	Carbazole	ND	76	5.5	ug/kg	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID: SB-19(7-7.5)030724
Lab Sample ID: JD83927-13
Matrix: SO - Soil
Method: SW846 8270E SW846 3546
Project: 100 Main Street, White Plains, NY

Date Sampled: 03/07/24
Date Received: 03/07/24
Percent Solids: 82.1

ABN TCL List (SOM0 2.0)

CAS No.	Compound	Result	RL	MDL	Units	Q
105-60-2	Caprolactam	ND	76	15	ug/kg	
218-01-9	Chrysene	ND	38	12	ug/kg	
111-91-1	bis(2-Chloroethoxy)methane	ND	76	8.2	ug/kg	
111-44-4	bis(2-Chloroethyl)ether	ND	76	16	ug/kg	
108-60-1	2,2'-Oxybis(1-chloropropane)	ND	76	14	ug/kg	
7005-72-3	4-Chlorophenyl phenyl ether	ND	76	12	ug/kg	
121-14-2	2,4-Dinitrotoluene	ND	38	12	ug/kg	
606-20-2	2,6-Dinitrotoluene	ND	38	19	ug/kg	
91-94-1	3,3'-Dichlorobenzidine	ND	76	32	ug/kg	
123-91-1	1,4-Dioxane	ND	38	25	ug/kg	
53-70-3	Dibenzo(a,h)anthracene	ND	38	17	ug/kg	
132-64-9	Dibenzofuran [a]	ND	76	16	ug/kg	
84-74-2	Di-n-butyl phthalate	ND	76	6.2	ug/kg	
117-84-0	Di-n-octyl phthalate	ND	76	9.5	ug/kg	
84-66-2	Diethyl phthalate	ND	76	8.1	ug/kg	
131-11-3	Dimethyl phthalate	ND	76	6.8	ug/kg	
117-81-7	bis(2-Ethylhexyl)phthalate	ND	76	8.9	ug/kg	
206-44-0	Fluoranthene	ND	38	17	ug/kg	
86-73-7	Fluorene [a]	ND	38	18	ug/kg	
118-74-1	Hexachlorobenzene [a]	ND	76	9.7	ug/kg	
87-68-3	Hexachlorobutadiene [a]	ND	38	15	ug/kg	
77-47-4	Hexachlorocyclopentadiene	ND	380	15	ug/kg	
67-72-1	Hexachloroethane	ND	190	19	ug/kg	
193-39-5	Indeno(1,2,3-cd)pyrene	ND	38	18	ug/kg	
78-59-1	Isophorone	ND	76	8.2	ug/kg	
91-57-6	2-Methylnaphthalene	ND	38	8.6	ug/kg	
88-74-4	2-Nitroaniline	ND	190	9.0	ug/kg	
99-09-2	3-Nitroaniline	ND	190	9.5	ug/kg	
100-01-6	4-Nitroaniline	ND	190	9.9	ug/kg	
91-20-3	Naphthalene [a]	ND	38	11	ug/kg	
98-95-3	Nitrobenzene	ND	76	15	ug/kg	
621-64-7	N-Nitroso-di-n-propylamine	ND	76	11	ug/kg	
86-30-6	N-Nitrosodiphenylamine	ND	190	14	ug/kg	
85-01-8	Phenanthrene [a]	ND	38	13	ug/kg	
129-00-0	Pyrene	ND	38	12	ug/kg	
95-94-3	1,2,4,5-Tetrachlorobenzene	ND	190	9.7	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
367-12-4	2-Fluorophenol	46%		10-99%

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-19(7-7.5)030724		
Lab Sample ID:	JD83927-13	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	82.1
Project:	100 Main Street, White Plains, NY		

ABN TCL List (SOM0 2.0)

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
4165-62-2	Phenol-d5	46%		10-96%
118-79-6	2,4,6-Tribromophenol	45%		10-123%
4165-60-0	Nitrobenzene-d5	47%		10-109%
321-60-8	2-Fluorobiphenyl	41%		11-109%
1718-51-0	Terphenyl-d14	50%		10-120%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Unknown	7.66	190	ug/kg	J
	Total TIC, Semi-Volatile		190	ug/kg	J

(a) Associated CCV outside of control limits low. Low-level verification was analyzed to demonstrate system suitability to detect affected analytes. Sample was ND.
(b) Associated CCV outside of control limits high, sample was ND.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-19(7-7.5)030724		
Lab Sample ID:	JD83927-13	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8081B SW846 3570	**Percent Solids:**	82.1
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	4G9737034.D	1	03/11/24 06:52	CP	03/09/24 08:40	OP53021	G4G4306
Run #2							

	Initial Weight	Final Volume
Run #1	5.2 g	10.0 ml
Run #2		

Pesticide TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
309-00-2	Aldrin	ND	0.47	0.091	ug/kg	
319-84-6	alpha-BHC	ND	0.47	0.054	ug/kg	
319-85-7	beta-BHC	ND	0.47	0.068	ug/kg	
319-86-8	delta-BHC	ND	0.47	0.070	ug/kg	
58-89-9	gamma-BHC (Lindane)	ND	0.47	0.082	ug/kg	
5103-71-9	alpha-Chlordane	ND	0.47	0.063	ug/kg	
5103-74-2	gamma-Chlordane	ND	0.47	0.070	ug/kg	
60-57-1	Dieldrin	ND	0.47	0.075	ug/kg	
72-54-8	4,4'-DDD	ND	0.47	0.049	ug/kg	
72-55-9	4,4'-DDE	ND	0.47	0.056	ug/kg	
50-29-3	4,4'-DDT	ND	0.47	0.082	ug/kg	
72-20-8	Endrin	ND	0.47	0.068	ug/kg	
1031-07-8	Endosulfan sulfate	ND	0.47	0.056	ug/kg	
7421-93-4	Endrin aldehyde	ND	0.47	0.14	ug/kg	
959-98-8	Endosulfan-I	ND	0.47	0.063	ug/kg	
33213-65-9	Endosulfan-II	ND	0.47	0.066	ug/kg	
76-44-8	Heptachlor	ND	0.47	0.061	ug/kg	
1024-57-3	Heptachlor epoxide	ND	0.47	0.084	ug/kg	
72-43-5	Methoxychlor	ND	0.47	0.19	ug/kg	
53494-70-5	Endrin ketone	ND	0.47	0.075	ug/kg	
8001-35-2	Toxaphene	ND	5.9	3.9	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
877-09-8	Tetrachloro-m-xylene	86%		66-150%
877-09-8	Tetrachloro-m-xylene	97%		66-150%
2051-24-3	Decachlorobiphenyl	80%		40-150%
2051-24-3	Decachlorobiphenyl	68%		40-150%

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-19(7-7.5)030724		
Lab Sample ID:	JD83927-13	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8082A SW846 3570	**Percent Solids:**	82.1
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	2G231148.D	1	03/11/24 06:25	TP	03/09/24 08:40	OP53022	G2G6058
Run #2							

	Initial Weight	Final Volume
Run #1	5.2 g	10.0 ml
Run #2		

PCB List

CAS No.	Compound	Result	RL	MDL	Units	Q
12674-11-2	Aroclor 1016	ND	23	10	ug/kg	
11104-28-2	Aroclor 1221	ND	23	7.9	ug/kg	
11141-16-5	Aroclor 1232	ND	23	19	ug/kg	
53469-21-9	Aroclor 1242	ND	23	14	ug/kg	
12672-29-6	Aroclor 1248	ND	23	5.1	ug/kg	
11097-69-1	Aroclor 1254	ND	23	2.5	ug/kg	
11096-82-5	Aroclor 1260	ND	23	8.1	ug/kg	
11100-14-4	Aroclor 1268	ND	23	2.4	ug/kg	
37324-23-5	Aroclor 1262	ND	23	2.0	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
877-09-8	Tetrachloro-m-xylene	86%		42-159%
877-09-8	Tetrachloro-m-xylene	89%		42-159%
2051-24-3	Decachlorobiphenyl	98%		18-154%
2051-24-3	Decachlorobiphenyl	106%		18-154%

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

SGS North America Inc.

Report of Analysis

Client Sample ID:	SB-19(7-7.5)030724		
Lab Sample ID:	JD83927-13	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
		Percent Solids:	82.1
Project:	100 Main Street, White Plains, NY		

Metals Analysis

Analyte	Result	RL	Units	DF	Prep	Analyzed	By	Method	Prep Method
Aluminum	6390	60	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Antimony	< 2.4	2.4	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Arsenic	< 2.4	2.4	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Barium	33.4	24	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Beryllium	0.25	0.24	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Cadmium	< 0.60	0.60	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Calcium	1640	600	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Chromium	12.5	1.2	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Cobalt	< 6.0	6.0	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Copper	12.9	3.0	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Iron	11700	60	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Lead	< 2.4	2.4	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Magnesium	3550	600	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Manganese	163	1.8	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Mercury	< 0.036	0.036	mg/kg	1	03/13/24	03/14/24	LM	SW846 7471B [1]	SW846 7471B [4]
Nickel	10	4.8	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Potassium	1680	1200	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Selenium	< 2.4	2.4	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Silver	< 0.60	0.60	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Sodium	< 1200	1200	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Thallium	< 1.2	1.2	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Vanadium	17.0	6.0	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Zinc	25.6	6.0	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]

(1) Instrument QC Batch: MA55688
(2) Instrument QC Batch: MA55691
(3) Prep QC Batch: MP45216
(4) Prep QC Batch: MP45278

RL = Reporting Limit

Report of Analysis

Client Sample ID:	SB-19(7-7.5)030724		
Lab Sample ID:	JD83927-13	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
		Percent Solids:	82.1
Project:	100 Main Street, White Plains, NY		

General Chemistry

Analyte	Result	RL	Units	DF	Analyzed	By	Method
Cyanide	< 0.25	0.25	mg/kg	1	03/12/24 19:50	JD	SW846 9012B/LACHAT
Solids, Percent	82.1		%	1	03/08/24 06:00	SC	SM2540 G 18TH ED MOD

RL = Reporting Limit

Report of Analysis

Client Sample ID:	SB-22(3.5-4)030724		
Lab Sample ID:	JD83927-14	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8260D SW846 5035	**Percent Solids:**	95.4
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	Y206973.D	1	03/08/24 20:40	PS	03/08/24 10:00	n/a	VY8980
Run #2							

	Initial Weight
Run #1	5.4 g
Run #2	

VOA TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
67-64-1	Acetone	ND	9.7	4.0	ug/kg	
71-43-2	Benzene	ND	0.49	0.44	ug/kg	
74-97-5	Bromochloromethane	ND	4.9	0.54	ug/kg	
75-27-4	Bromodichloromethane	ND	1.9	0.42	ug/kg	
75-25-2	Bromoform	ND	4.9	1.3	ug/kg	
74-83-9	Bromomethane [a]	ND	4.9	0.74	ug/kg	
78-93-3	2-Butanone (MEK)	ND	9.7	2.4	ug/kg	
75-15-0	Carbon disulfide	ND	1.9	0.52	ug/kg	
56-23-5	Carbon tetrachloride	ND	1.9	0.60	ug/kg	
108-90-7	Chlorobenzene	ND	1.9	0.45	ug/kg	
75-00-3	Chloroethane	ND	4.9	0.57	ug/kg	
67-66-3	Chloroform	ND	1.9	0.50	ug/kg	
74-87-3	Chloromethane	ND	4.9	1.9	ug/kg	
110-82-7	Cyclohexane	ND	1.9	0.64	ug/kg	
96-12-8	1,2-Dibromo-3-chloropropane	ND	1.9	0.67	ug/kg	
124-48-1	Dibromochloromethane	ND	1.9	0.54	ug/kg	
106-93-4	1,2-Dibromoethane	ND	0.97	0.41	ug/kg	
95-50-1	1,2-Dichlorobenzene	ND	0.97	0.53	ug/kg	
541-73-1	1,3-Dichlorobenzene	ND	0.97	0.48	ug/kg	
106-46-7	1,4-Dichlorobenzene	ND	0.97	0.48	ug/kg	
75-71-8	Dichlorodifluoromethane [a]	ND	4.9	0.71	ug/kg	
75-34-3	1,1-Dichloroethane	ND	0.97	0.48	ug/kg	
107-06-2	1,2-Dichloroethane	ND	0.97	0.46	ug/kg	
75-35-4	1,1-Dichloroethene	ND	0.97	0.64	ug/kg	
156-59-2	cis-1,2-Dichloroethene	ND	0.97	0.82	ug/kg	
156-60-5	trans-1,2-Dichloroethene	ND	0.97	0.59	ug/kg	
78-87-5	1,2-Dichloropropane	ND	1.9	0.46	ug/kg	
10061-01-5	cis-1,3-Dichloropropene	ND	1.9	0.46	ug/kg	
10061-02-6	trans-1,3-Dichloropropene	ND	1.9	0.44	ug/kg	
100-41-4	Ethylbenzene	ND	0.97	0.44	ug/kg	
76-13-1	Freon 113	ND	4.9	2.6	ug/kg	
591-78-6	2-Hexanone	ND	4.9	2.1	ug/kg	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-22(3.5-4)030724		
Lab Sample ID:	JD83927-14	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8260D SW846 5035	**Percent Solids:**	95.4
Project:	100 Main Street, White Plains, NY		

VOA TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
98-82-8	Isopropylbenzene	ND	1.9	1.4	ug/kg	
79-20-9	Methyl Acetate	ND	4.9	1.3	ug/kg	
108-87-2	Methylcyclohexane	ND	1.9	0.85	ug/kg	
1634-04-4	Methyl Tert Butyl Ether	ND	0.97	0.46	ug/kg	
108-10-1	4-Methyl-2-pentanone(MIBK)	ND	4.9	2.2	ug/kg	
75-09-2	Methylene chloride	ND	4.9	2.5	ug/kg	
100-42-5	Styrene	ND	1.9	0.39	ug/kg	
79-34-5	1,1,2,2-Tetrachloroethane	ND	1.9	0.58	ug/kg	
127-18-4	Tetrachloroethene	ND	1.9	0.56	ug/kg	
108-88-3	Toluene	ND	0.97	0.51	ug/kg	
87-61-6	1,2,3-Trichlorobenzene	ND	4.9	2.4	ug/kg	
120-82-1	1,2,4-Trichlorobenzene	ND	4.9	2.4	ug/kg	
71-55-6	1,1,1-Trichloroethane	ND	1.9	0.47	ug/kg	
79-00-5	1,1,2-Trichloroethane	ND	1.9	0.54	ug/kg	
79-01-6	Trichloroethene	ND	0.97	0.74	ug/kg	
75-69-4	Trichlorofluoromethane	ND	4.9	0.66	ug/kg	
75-01-4	Vinyl chloride	ND	1.9	0.47	ug/kg	
	m,p-Xylene	ND	0.97	0.87	ug/kg	
95-47-6	o-Xylene	ND	0.97	0.44	ug/kg	
1330-20-7	Xylene (total)	ND	0.97	0.44	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
1868-53-7	Dibromofluoromethane	93%		80-124%
17060-07-0	1,2-Dichloroethane-D4	102%		75-133%
2037-26-5	Toluene-D8	102%		79-125%
460-00-4	4-Bromofluorobenzene	107%		58-148%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	system artifact	.86	13	ug/kg	J
	Total TIC, Volatile		0	ug/kg	

(a) Associated CCV outside of control limits high, sample was ND.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-22(3.5-4)030724		
Lab Sample ID:	JD83927-14	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	95.4
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	Z166848.D	1	03/11/24 20:31	JY	03/09/24 18:30	OP53010	EZ8267
Run #2							

	Initial Weight	Final Volume
Run #1	31.0 g	1.0 ml
Run #2		

ABN TCL List (SOM0 2.0)

CAS No.	Compound	Result	RL	MDL	Units	Q
95-57-8	2-Chlorophenol	ND	68	17	ug/kg	
59-50-7	4-Chloro-3-methyl phenol	ND	170	21	ug/kg	
120-83-2	2,4-Dichlorophenol	ND	170	29	ug/kg	
105-67-9	2,4-Dimethylphenol	ND	170	60	ug/kg	
51-28-5	2,4-Dinitrophenol	ND	170	130	ug/kg	
534-52-1	4,6-Dinitro-o-cresol	ND	170	36	ug/kg	
95-48-7	2-Methylphenol	ND	68	22	ug/kg	
	3&4-Methylphenol	ND	68	28	ug/kg	
88-75-5	2-Nitrophenol	ND	170	22	ug/kg	
100-02-7	4-Nitrophenol	ND	340	90	ug/kg	
87-86-5	Pentachlorophenol	ND	140	32	ug/kg	
108-95-2	Phenol	ND	68	18	ug/kg	
58-90-2	2,3,4,6-Tetrachlorophenol	ND	170	22	ug/kg	
95-95-4	2,4,5-Trichlorophenol	ND	170	25	ug/kg	
88-06-2	2,4,6-Trichlorophenol	ND	170	20	ug/kg	
83-32-9	Acenaphthene [a]	ND	34	12	ug/kg	
208-96-8	Acenaphthylene	ND	34	17	ug/kg	
98-86-2	Acetophenone	ND	170	7.3	ug/kg	
120-12-7	Anthracene	ND	34	21	ug/kg	
1912-24-9	Atrazine	ND	68	14	ug/kg	
56-55-3	Benzo(a)anthracene	ND	34	9.6	ug/kg	
50-32-8	Benzo(a)pyrene	ND	34	15	ug/kg	
205-99-2	Benzo(b)fluoranthene	ND	34	15	ug/kg	
191-24-2	Benzo(g,h,i)perylene	23.6	34	17	ug/kg	J
207-08-9	Benzo(k)fluoranthene	ND	34	16	ug/kg	
101-55-3	4-Bromophenyl phenyl ether	ND	68	13	ug/kg	
85-68-7	Butyl benzyl phthalate	ND	68	8.3	ug/kg	
92-52-4	1,1'-Biphenyl	7.2	68	4.6	ug/kg	J
100-52-7	Benzaldehyde [b]	ND	170	8.4	ug/kg	
91-58-7	2-Chloronaphthalene	ND	68	8.0	ug/kg	
106-47-8	4-Chloroaniline	ND	170	12	ug/kg	
86-74-8	Carbazole	ND	68	4.9	ug/kg	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID: SB-22(3.5-4)030724
Lab Sample ID: JD83927-14
Matrix: SO - Soil
Method: SW846 8270E SW846 3546
Project: 100 Main Street, White Plains, NY

Date Sampled: 03/07/24
Date Received: 03/07/24
Percent Solids: 95.4

ABN TCL List (SOM0 2.0)

CAS No.	Compound	Result	RL	MDL	Units	Q
105-60-2	Caprolactam	ND	68	13	ug/kg	
218-01-9	Chrysene	ND	34	11	ug/kg	
111-91-1	bis(2-Chloroethoxy)methane	ND	68	7.2	ug/kg	
111-44-4	bis(2-Chloroethyl)ether	ND	68	15	ug/kg	
108-60-1	2,2'-Oxybis(1-chloropropane)	ND	68	12	ug/kg	
7005-72-3	4-Chlorophenyl phenyl ether	ND	68	11	ug/kg	
121-14-2	2,4-Dinitrotoluene	ND	34	10	ug/kg	
606-20-2	2,6-Dinitrotoluene	ND	34	17	ug/kg	
91-94-1	3,3'-Dichlorobenzidine	ND	68	28	ug/kg	
123-91-1	1,4-Dioxane	ND	34	22	ug/kg	
53-70-3	Dibenzo(a,h)anthracene	ND	34	15	ug/kg	
132-64-9	Dibenzofuran [a]	ND	68	14	ug/kg	
84-74-2	Di-n-butyl phthalate	ND	68	5.5	ug/kg	
117-84-0	Di-n-octyl phthalate	ND	68	8.4	ug/kg	
84-66-2	Diethyl phthalate	ND	68	7.2	ug/kg	
131-11-3	Dimethyl phthalate	ND	68	6.0	ug/kg	
117-81-7	bis(2-Ethylhexyl)phthalate	ND	68	7.9	ug/kg	
206-44-0	Fluoranthene	ND	34	15	ug/kg	
86-73-7	Fluorene [a]	ND	34	16	ug/kg	
118-74-1	Hexachlorobenzene [a]	ND	68	8.6	ug/kg	
87-68-3	Hexachlorobutadiene [a]	ND	34	14	ug/kg	
77-47-4	Hexachlorocyclopentadiene	ND	340	13	ug/kg	
67-72-1	Hexachloroethane	ND	170	17	ug/kg	
193-39-5	Indeno(1,2,3-cd)pyrene	ND	34	16	ug/kg	
78-59-1	Isophorone	ND	68	7.2	ug/kg	
91-57-6	2-Methylnaphthalene	26.8	34	7.6	ug/kg	J
88-74-4	2-Nitroaniline	ND	170	8.0	ug/kg	
99-09-2	3-Nitroaniline	ND	170	8.5	ug/kg	
100-01-6	4-Nitroaniline	ND	170	8.8	ug/kg	
91-20-3	Naphthalene [c]	14.7	34	9.5	ug/kg	J
98-95-3	Nitrobenzene	ND	68	13	ug/kg	
621-64-7	N-Nitroso-di-n-propylamine	ND	68	9.8	ug/kg	
86-30-6	N-Nitrosodiphenylamine	ND	170	12	ug/kg	
85-01-8	Phenanthrene [a]	ND	34	11	ug/kg	
129-00-0	Pyrene	ND	34	11	ug/kg	
95-94-3	1,2,4,5-Tetrachlorobenzene	ND	170	8.6	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
367-12-4	2-Fluorophenol	49%		10-99%

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-22(3.5-4)030724		
Lab Sample ID:	JD83927-14	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	95.4
Project:	100 Main Street, White Plains, NY		

ABN TCL List (SOM0 2.0)

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
4165-62-2	Phenol-d5	54%		10-96%
118-79-6	2,4,6-Tribromophenol	63%		10-123%
4165-60-0	Nitrobenzene-d5	55%		10-109%
321-60-8	2-Fluorobiphenyl	55%		11-109%
1718-51-0	Terphenyl-d14	63%		10-120%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Unknown	5.22	260	ug/kg	J
	Unknown	5.45	250	ug/kg	J
	Unknown	5.64	330	ug/kg	J
	Unknown	5.68	360	ug/kg	J
	Unknown	5.83	440	ug/kg	J
	Unknown	5.98	380	ug/kg	J
	Alkane	6.22	310	ug/kg	J
	Unknown	6.33	250	ug/kg	J
	Unknown	6.40	410	ug/kg	J
	Unknown	6.58	430	ug/kg	J
	Unknown	6.81	300	ug/kg	J
	Unknown	6.93	260	ug/kg	J
	Unknown	6.97	440	ug/kg	J
	Unknown	7.04	490	ug/kg	J
	Unknown	7.10	400	ug/kg	J
	Unknown	7.21	480	ug/kg	J
	Unknown	7.23	550	ug/kg	J
	Unknown	7.46	460	ug/kg	J
	Unknown	8.07	200	ug/kg	J
	Unknown	8.61	190	ug/kg	J
	Unknown	9.06	200	ug/kg	J
	Unknown	9.37	220	ug/kg	J
	Unknown	9.47	240	ug/kg	J
	Unknown	9.69	200	ug/kg	J
	Unknown	10.87	210	ug/kg	J
	Total TIC, Semi-Volatile		8260	ug/kg	J

(a) Associated CCV outside of control limits low. Low-level verification was analyzed to demonstrate system suitability to detect affected analytes. Sample was ND.
(b) Associated CCV outside of control limits high, sample was ND.
(c) Associated CCV outside of control limits low. Low-level verification was analyzed to demonstrate system suitability to detect affected analytes. Estimated value, due to corresponding failure in the batch

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-22(3.5-4)030724		
Lab Sample ID:	JD83927-14	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	95.4
Project:	100 Main Street, White Plains, NY		

ABN TCL List (SOM0 2.0)

CAS No.	Compound	Result	RL	MDL	Units	Q

associated CCV.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-22(3.5-4)030724		
Lab Sample ID:	JD83927-14	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8081B SW846 3570	**Percent Solids:**	95.4
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	4G9737035.D	1	03/11/24 07:12	CP	03/09/24 08:40	OP53021	G4G4306
Run #2							

	Initial Weight	Final Volume
Run #1	5.1 g	10.0 ml
Run #2		

Pesticide TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
309-00-2	Aldrin	ND	0.41	0.080	ug/kg	
319-84-6	alpha-BHC	ND	0.41	0.047	ug/kg	
319-85-7	beta-BHC [a]	8.9	0.41	0.060	ug/kg	
319-86-8	delta-BHC	ND	0.41	0.062	ug/kg	
58-89-9	gamma-BHC (Lindane)	9.0	0.41	0.072	ug/kg	
5103-71-9	alpha-Chlordane	ND	0.41	0.055	ug/kg	
5103-74-2	gamma-Chlordane	ND	0.41	0.062	ug/kg	
60-57-1	Dieldrin	9.4	0.41	0.066	ug/kg	
72-54-8	4,4'-DDD	ND	0.41	0.043	ug/kg	
72-55-9	4,4'-DDE	ND	0.41	0.049	ug/kg	
50-29-3	4,4'-DDT	5.4	0.41	0.072	ug/kg	
72-20-8	Endrin	ND	0.41	0.060	ug/kg	
1031-07-8	Endosulfan sulfate	ND	0.41	0.049	ug/kg	
7421-93-4	Endrin aldehyde	ND	0.41	0.12	ug/kg	
959-98-8	Endosulfan-I	ND	0.41	0.055	ug/kg	
33213-65-9	Endosulfan-II	ND	0.41	0.058	ug/kg	
76-44-8	Heptachlor [a]	2.8	0.41	0.053	ug/kg	
1024-57-3	Heptachlor epoxide	ND	0.41	0.074	ug/kg	
72-43-5	Methoxychlor	ND	0.41	0.16	ug/kg	
53494-70-5	Endrin ketone	ND	0.41	0.066	ug/kg	
8001-35-2	Toxaphene	ND	5.1	3.4	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
877-09-8	Tetrachloro-m-xylene	439% [b]		66-150%
877-09-8	Tetrachloro-m-xylene	248% [b]		66-150%
2051-24-3	Decachlorobiphenyl	80%		40-150%
2051-24-3	Decachlorobiphenyl	83%		40-150%

(a) More than 40 % RPD for detected concentrations between the two GC columns.
(b) Outside control limits due to matrix interference.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-22(3.5-4)030724		
Lab Sample ID:	JD83927-14	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8082A SW846 3570	**Percent Solids:**	95.4
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	2G231149.D	1	03/11/24 06:49	TP	03/09/24 08:40	OP53022	G2G6058
Run #2							

	Initial Weight	Final Volume
Run #1	5.1 g	10.0 ml
Run #2		

PCB List

CAS No.	Compound	Result	RL	MDL	Units	Q
12674-11-2	Aroclor 1016	ND	21	8.7	ug/kg	
11104-28-2	Aroclor 1221	ND	21	6.9	ug/kg	
11141-16-5	Aroclor 1232	ND	21	17	ug/kg	
53469-21-9	Aroclor 1242	ND	21	12	ug/kg	
12672-29-6	Aroclor 1248	ND	21	4.4	ug/kg	
11097-69-1	Aroclor 1254	ND	21	2.2	ug/kg	
11096-82-5	Aroclor 1260	ND	21	7.1	ug/kg	
11100-14-4	Aroclor 1268	ND	21	2.1	ug/kg	
37324-23-5	Aroclor 1262	ND	21	1.7	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
877-09-8	Tetrachloro-m-xylene	61%		42-159%
877-09-8	Tetrachloro-m-xylene	58%		42-159%
2051-24-3	Decachlorobiphenyl	98%		18-154%
2051-24-3	Decachlorobiphenyl	120%		18-154%

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-22(3.5-4)030724		
Lab Sample ID:	JD83927-14	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
		Percent Solids:	95.4
Project:	100 Main Street, White Plains, NY		

Metals Analysis

Analyte	Result	RL	Units	DF	Prep	Analyzed	By	Method	Prep Method
Aluminum	5500	52	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Antimony	< 2.1	2.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Arsenic	< 2.1	2.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Barium	44.1	21	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Beryllium	0.24	0.21	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Cadmium	< 0.52	0.52	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Calcium	14800	520	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Chromium	11.0	1.0	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Cobalt	< 5.2	5.2	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Copper	12.5	2.6	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Iron	10800	52	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Lead	8.1	2.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Magnesium	9810	520	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Manganese	189	1.6	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Mercury	< 0.032	0.032	mg/kg	1	03/13/24	03/14/24	LM	SW846 7471B [1]	SW846 7471B [4]
Nickel	9.6	4.2	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Potassium	1850	1000	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Selenium	< 2.1	2.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Silver	< 0.52	0.52	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Sodium	< 1000	1000	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Thallium	< 1.0	1.0	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Vanadium	16.5	5.2	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Zinc	28.7	5.2	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]

(1) Instrument QC Batch: MA55688
(2) Instrument QC Batch: MA55691
(3) Prep QC Batch: MP45216
(4) Prep QC Batch: MP45278

RL = Reporting Limit

Report of Analysis

Client Sample ID:	SB-22(3.5-4)030724		
Lab Sample ID:	JD83927-14	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
		Percent Solids:	95.4
Project:	100 Main Street, White Plains, NY		

General Chemistry

Analyte	Result	RL	Units	DF	Analyzed	By	Method
Cyanide	< 0.23	0.23	mg/kg	1	03/12/24 19:51	JD	SW846 9012B/LACHAT
Solids, Percent	95.4		%	1	03/08/24 06:00	SC	SM2540 G 18TH ED MOD

RL = Reporting Limit

Report of Analysis

Client Sample ID:	SB-22(8-8.5)030724		
Lab Sample ID:	JD83927-15	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8260D SW846 5035	**Percent Solids:**	95.3
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	Y206974.D	1	03/08/24 21:01	PS	03/08/24 10:00	n/a	VY8980
Run #2							

	Initial Weight
Run #1	1.0 g
Run #2	

VOA TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
67-64-1	Acetone	ND	52	22	ug/kg	
71-43-2	Benzene	ND	2.6	2.4	ug/kg	
74-97-5	Bromochloromethane	ND	26	2.9	ug/kg	
75-27-4	Bromodichloromethane	ND	10	2.3	ug/kg	
75-25-2	Bromoform	ND	26	7.1	ug/kg	
74-83-9	Bromomethane [a]	ND	26	4.0	ug/kg	
78-93-3	2-Butanone (MEK)	ND	52	13	ug/kg	
75-15-0	Carbon disulfide	ND	10	2.8	ug/kg	
56-23-5	Carbon tetrachloride	ND	10	3.2	ug/kg	
108-90-7	Chlorobenzene	ND	10	2.4	ug/kg	
75-00-3	Chloroethane	ND	26	3.1	ug/kg	
67-66-3	Chloroform	ND	10	2.7	ug/kg	
74-87-3	Chloromethane	ND	26	10	ug/kg	
110-82-7	Cyclohexane	ND	10	3.4	ug/kg	
96-12-8	1,2-Dibromo-3-chloropropane	ND	10	3.6	ug/kg	
124-48-1	Dibromochloromethane	ND	10	2.9	ug/kg	
106-93-4	1,2-Dibromoethane	ND	5.2	2.2	ug/kg	
95-50-1	1,2-Dichlorobenzene	ND	5.2	2.9	ug/kg	
541-73-1	1,3-Dichlorobenzene	ND	5.2	2.6	ug/kg	
106-46-7	1,4-Dichlorobenzene	ND	5.2	2.6	ug/kg	
75-71-8	Dichlorodifluoromethane [a]	ND	26	3.8	ug/kg	
75-34-3	1,1-Dichloroethane	ND	5.2	2.6	ug/kg	
107-06-2	1,2-Dichloroethane	ND	5.2	2.5	ug/kg	
75-35-4	1,1-Dichloroethene	ND	5.2	3.4	ug/kg	
156-59-2	cis-1,2-Dichloroethene	ND	5.2	4.4	ug/kg	
156-60-5	trans-1,2-Dichloroethene	ND	5.2	3.2	ug/kg	
78-87-5	1,2-Dichloropropane	ND	10	2.5	ug/kg	
10061-01-5	cis-1,3-Dichloropropene	ND	10	2.5	ug/kg	
10061-02-6	trans-1,3-Dichloropropene	ND	10	2.4	ug/kg	
100-41-4	Ethylbenzene	ND	5.2	2.4	ug/kg	
76-13-1	Freon 113	ND	26	14	ug/kg	
591-78-6	2-Hexanone	ND	26	11	ug/kg	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-22(8-8.5)030724		
Lab Sample ID:	JD83927-15	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8260D SW846 5035	**Percent Solids:**	95.3
Project:	100 Main Street, White Plains, NY		

VOA TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
98-82-8	Isopropylbenzene	ND	10	7.5	ug/kg	
79-20-9	Methyl Acetate	ND	26	7.3	ug/kg	
108-87-2	Methylcyclohexane	ND	10	4.6	ug/kg	
1634-04-4	Methyl Tert Butyl Ether	ND	5.2	2.5	ug/kg	
108-10-1	4-Methyl-2-pentanone(MIBK)	ND	26	12	ug/kg	
75-09-2	Methylene chloride	ND	26	14	ug/kg	
100-42-5	Styrene	ND	10	2.1	ug/kg	
79-34-5	1,1,2,2-Tetrachloroethane	ND	10	3.1	ug/kg	
127-18-4	Tetrachloroethene	ND	10	3.0	ug/kg	
108-88-3	Toluene	ND	5.2	2.8	ug/kg	
87-61-6	1,2,3-Trichlorobenzene	ND	26	13	ug/kg	
120-82-1	1,2,4-Trichlorobenzene	ND	26	13	ug/kg	
71-55-6	1,1,1-Trichloroethane	ND	10	2.5	ug/kg	
79-00-5	1,1,2-Trichloroethane	ND	10	2.9	ug/kg	
79-01-6	Trichloroethene	ND	5.2	4.0	ug/kg	
75-69-4	Trichlorofluoromethane	ND	26	3.6	ug/kg	
75-01-4	Vinyl chloride	ND	10	2.5	ug/kg	
	m,p-Xylene	ND	5.2	4.7	ug/kg	
95-47-6	o-Xylene	ND	5.2	2.4	ug/kg	
1330-20-7	Xylene (total)	ND	5.2	2.4	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
1868-53-7	Dibromofluoromethane	94%		80-124%
17060-07-0	1,2-Dichloroethane-D4	103%		75-133%
2037-26-5	Toluene-D8	102%		79-125%
460-00-4	4-Bromofluorobenzene	104%		58-148%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	system artifact	.86	60	ug/kg	J
	Total TIC, Volatile		0	ug/kg	

(a) Associated CCV outside of control limits high, sample was ND.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID: SB-22(8-8.5)030724
Lab Sample ID: JD83927-15
Matrix: SO - Soil
Method: SW846 8270E SW846 3546
Project: 100 Main Street, White Plains, NY

Date Sampled: 03/07/24
Date Received: 03/07/24
Percent Solids: 95.3

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	Z166842.D	1	03/11/24 18:34	JY	03/09/24 18:30	OP53010	EZ8267
Run #2							

	Initial Weight	Final Volume
Run #1	30.8 g	1.0 ml
Run #2		

ABN TCL List (SOM0 2.0)

CAS No.	Compound	Result	RL	MDL	Units	Q
95-57-8	2-Chlorophenol	ND	68	17	ug/kg	
59-50-7	4-Chloro-3-methyl phenol	ND	170	21	ug/kg	
120-83-2	2,4-Dichlorophenol	ND	170	29	ug/kg	
105-67-9	2,4-Dimethylphenol	ND	170	61	ug/kg	
51-28-5	2,4-Dinitrophenol	ND	170	130	ug/kg	
534-52-1	4,6-Dinitro-o-cresol	ND	170	36	ug/kg	
95-48-7	2-Methylphenol	ND	68	22	ug/kg	
	3&4-Methylphenol	ND	68	28	ug/kg	
88-75-5	2-Nitrophenol	ND	170	23	ug/kg	
100-02-7	4-Nitrophenol	ND	340	91	ug/kg	
87-86-5	Pentachlorophenol	ND	140	32	ug/kg	
108-95-2	Phenol	ND	68	18	ug/kg	
58-90-2	2,3,4,6-Tetrachlorophenol	ND	170	23	ug/kg	
95-95-4	2,4,5-Trichlorophenol	ND	170	26	ug/kg	
88-06-2	2,4,6-Trichlorophenol	ND	170	20	ug/kg	
83-32-9	Acenaphthene [a]	ND	34	12	ug/kg	
208-96-8	Acenaphthylene	ND	34	17	ug/kg	
98-86-2	Acetophenone	ND	170	7.3	ug/kg	
120-12-7	Anthracene	23.4	34	21	ug/kg	J
1912-24-9	Atrazine	ND	68	15	ug/kg	
56-55-3	Benzo(a)anthracene	107	34	9.6	ug/kg	
50-32-8	Benzo(a)pyrene	119	34	16	ug/kg	
205-99-2	Benzo(b)fluoranthene	127	34	15	ug/kg	
191-24-2	Benzo(g,h,i)perylene	87.9	34	17	ug/kg	
207-08-9	Benzo(k)fluoranthene	41.1	34	16	ug/kg	
101-55-3	4-Bromophenyl phenyl ether	ND	68	13	ug/kg	
85-68-7	Butyl benzyl phthalate	ND	68	8.3	ug/kg	
92-52-4	1,1'-Biphenyl	ND	68	4.7	ug/kg	
100-52-7	Benzaldehyde [b]	ND	170	8.4	ug/kg	
91-58-7	2-Chloronaphthalene	ND	68	8.1	ug/kg	
106-47-8	4-Chloroaniline	ND	170	12	ug/kg	
86-74-8	Carbazole	16.0	68	4.9	ug/kg	J

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-22(8-8.5)030724		
Lab Sample ID:	JD83927-15	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	95.3
Project:	100 Main Street, White Plains, NY		

ABN TCL List (SOM0 2.0)

CAS No.	Compound	Result	RL	MDL	Units	Q
105-60-2	Caprolactam	ND	68	13	ug/kg	
218-01-9	Chrysene	105	34	11	ug/kg	
111-91-1	bis(2-Chloroethoxy)methane	ND	68	7.3	ug/kg	
111-44-4	bis(2-Chloroethyl)ether	ND	68	15	ug/kg	
108-60-1	2,2'-Oxybis(1-chloropropane)	ND	68	12	ug/kg	
7005-72-3	4-Chlorophenyl phenyl ether	ND	68	11	ug/kg	
121-14-2	2,4-Dinitrotoluene	ND	34	11	ug/kg	
606-20-2	2,6-Dinitrotoluene	ND	34	17	ug/kg	
91-94-1	3,3'-Dichlorobenzidine	ND	68	28	ug/kg	
123-91-1	1,4-Dioxane	ND	34	23	ug/kg	
53-70-3	Dibenzo(a,h)anthracene	23.0	34	15	ug/kg	J
132-64-9	Dibenzofuran [a]	ND	68	14	ug/kg	
84-74-2	Di-n-butyl phthalate	ND	68	5.6	ug/kg	
117-84-0	Di-n-octyl phthalate	ND	68	8.5	ug/kg	
84-66-2	Diethyl phthalate	ND	68	7.3	ug/kg	
131-11-3	Dimethyl phthalate	ND	68	6.1	ug/kg	
117-81-7	bis(2-Ethylhexyl)phthalate	ND	68	8.0	ug/kg	
206-44-0	Fluoranthene	197	34	15	ug/kg	
86-73-7	Fluorene [a]	ND	34	16	ug/kg	
118-74-1	Hexachlorobenzene [a]	ND	68	8.6	ug/kg	
87-68-3	Hexachlorobutadiene [a]	ND	34	14	ug/kg	
77-47-4	Hexachlorocyclopentadiene	ND	340	14	ug/kg	
67-72-1	Hexachloroethane	ND	170	17	ug/kg	
193-39-5	Indeno(1,2,3-cd)pyrene	60.2	34	16	ug/kg	
78-59-1	Isophorone	ND	68	7.3	ug/kg	
91-57-6	2-Methylnaphthalene	ND	34	7.7	ug/kg	
88-74-4	2-Nitroaniline	ND	170	8.0	ug/kg	
99-09-2	3-Nitroaniline	ND	170	8.5	ug/kg	
100-01-6	4-Nitroaniline	ND	170	8.8	ug/kg	
91-20-3	Naphthalene [a]	ND	34	9.6	ug/kg	
98-95-3	Nitrobenzene	ND	68	13	ug/kg	
621-64-7	N-Nitroso-di-n-propylamine	ND	68	9.8	ug/kg	
86-30-6	N-Nitrosodiphenylamine	ND	170	12	ug/kg	
85-01-8	Phenanthrene [c]	102	34	11	ug/kg	
129-00-0	Pyrene	169	34	11	ug/kg	
95-94-3	1,2,4,5-Tetrachlorobenzene	ND	170	8.7	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
367-12-4	2-Fluorophenol	42%		10-99%

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-22(8-8.5)030724		
Lab Sample ID:	JD83927-15	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	95.3
Project:	100 Main Street, White Plains, NY		

ABN TCL List (SOM0 2.0)

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
4165-62-2	Phenol-d5	46%		10-96%
118-79-6	2,4,6-Tribromophenol	51%		10-123%
4165-60-0	Nitrobenzene-d5	43%		10-109%
321-60-8	2-Fluorobiphenyl	46%		11-109%
1718-51-0	Terphenyl-d14	54%		10-120%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	n-Hexadecanoic acid	7.18	170	ug/kg	J
	Unknown	7.66	500	ug/kg	J
	System artifact	9.30	160	ug/kg	J
	Total TIC, Semi-Volatile		670	ug/kg	J

(a) Associated CCV outside of control limits low. Low-level verification was analyzed to demonstrate system suitability to detect affected analytes. Sample was ND.
(b) Associated CCV outside of control limits high, sample was ND.
(c) Associated CCV outside of control limits low. Low-level verification was analyzed to demonstrate system suitability to detect affected analytes. Estimated value, due to corresponding failure in the batch associated CCV.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-22(8-8.5)030724		
Lab Sample ID:	JD83927-15	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8081B SW846 3570	**Percent Solids:**	95.3
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	4G9737036.D	1	03/11/24 07:31	CP	03/09/24 08:40	OP53021	G4G4306
Run #2							

	Initial Weight	Final Volume
Run #1	5.5 g	10.0 ml
Run #2		

Pesticide TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
309-00-2	Aldrin	ND	0.38	0.074	ug/kg	
319-84-6	alpha-BHC	ND	0.38	0.044	ug/kg	
319-85-7	beta-BHC	ND	0.38	0.055	ug/kg	
319-86-8	delta-BHC	ND	0.38	0.057	ug/kg	
58-89-9	gamma-BHC (Lindane)	0.47	0.38	0.067	ug/kg	
5103-71-9	alpha-Chlordane	ND	0.38	0.052	ug/kg	
5103-74-2	gamma-Chlordane [a]	0.27	0.38	0.057	ug/kg	J
60-57-1	Dieldrin	0.29	0.38	0.061	ug/kg	J
72-54-8	4,4'-DDD	ND	0.38	0.040	ug/kg	
72-55-9	4,4'-DDE	ND	0.38	0.046	ug/kg	
50-29-3	4,4'-DDT	0.45	0.38	0.067	ug/kg	
72-20-8	Endrin	ND	0.38	0.055	ug/kg	
1031-07-8	Endosulfan sulfate	ND	0.38	0.046	ug/kg	
7421-93-4	Endrin aldehyde	ND	0.38	0.11	ug/kg	
959-98-8	Endosulfan-I	ND	0.38	0.052	ug/kg	
33213-65-9	Endosulfan-II	ND	0.38	0.053	ug/kg	
76-44-8	Heptachlor	ND	0.38	0.050	ug/kg	
1024-57-3	Heptachlor epoxide	ND	0.38	0.069	ug/kg	
72-43-5	Methoxychlor	ND	0.38	0.15	ug/kg	
53494-70-5	Endrin ketone	ND	0.38	0.061	ug/kg	
8001-35-2	Toxaphene	ND	4.8	3.1	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
877-09-8	Tetrachloro-m-xylene	93%		66-150%
877-09-8	Tetrachloro-m-xylene	89%		66-150%
2051-24-3	Decachlorobiphenyl	93%		40-150%
2051-24-3	Decachlorobiphenyl	92%		40-150%

(a) More than 40 % RPD for detected concentrations between the two GC columns.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-22(8-8.5)030724		
Lab Sample ID:	JD83927-15	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8082A SW846 3570	**Percent Solids:**	95.3
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	2G231150.D	1	03/11/24 07:13	TP	03/09/24 08:40	OP53022	G2G6058
Run #2							

	Initial Weight	Final Volume
Run #1	5.5 g	10.0 ml
Run #2		

PCB List

CAS No.	Compound	Result	RL	MDL	Units	Q
12674-11-2	Aroclor 1016	ND	19	8.1	ug/kg	
11104-28-2	Aroclor 1221	ND	19	6.4	ug/kg	
11141-16-5	Aroclor 1232	ND	19	16	ug/kg	
53469-21-9	Aroclor 1242	ND	19	11	ug/kg	
12672-29-6	Aroclor 1248	ND	19	4.1	ug/kg	
11097-69-1	Aroclor 1254	ND	19	2.1	ug/kg	
11096-82-5	Aroclor 1260	ND	19	6.6	ug/kg	
11100-14-4	Aroclor 1268	ND	19	1.9	ug/kg	
37324-23-5	Aroclor 1262	ND	19	1.6	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
877-09-8	Tetrachloro-m-xylene	86%		42-159%
877-09-8	Tetrachloro-m-xylene	85%		42-159%
2051-24-3	Decachlorobiphenyl	99%		18-154%
2051-24-3	Decachlorobiphenyl	126%		18-154%

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID: SB-22(8-8.5)030724
Lab Sample ID: JD83927-15
Matrix: SO - Soil
Project: 100 Main Street, White Plains, NY

Date Sampled: 03/07/24
Date Received: 03/07/24
Percent Solids: 95.3

Metals Analysis

Analyte	Result	RL	Units	DF	Prep	Analyzed	By	Method	Prep Method
Aluminum	6100	53	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Antimony	< 2.1	2.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Arsenic	< 2.1	2.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Barium	36.5	21	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Beryllium	0.25	0.21	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Cadmium	< 0.53	0.53	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Calcium	5950	530	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Chromium	10.6	1.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Cobalt	< 5.3	5.3	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Copper	11.5	2.6	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Iron	11700	53	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Lead	10.3	2.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Magnesium	4610	530	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Manganese	197	1.6	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Mercury	0.066	0.033	mg/kg	1	03/13/24	03/14/24	LM	SW846 7471B [1]	SW846 7471B [4]
Nickel	11.1	4.2	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Potassium	1340	1100	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Selenium	< 2.1	2.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Silver	< 0.53	0.53	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Sodium	< 1100	1100	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Thallium	< 1.1	1.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Vanadium	15.2	5.3	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Zinc	30.8	5.3	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]

(1) Instrument QC Batch: MA55688
(2) Instrument QC Batch: MA55691
(3) Prep QC Batch: MP45216
(4) Prep QC Batch: MP45278

RL = Reporting Limit

Report of Analysis

Client Sample ID:	SB-22(8-8.5)030724		
Lab Sample ID:	JD83927-15	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
		Percent Solids:	95.3
Project:	100 Main Street, White Plains, NY		

General Chemistry

Analyte	Result	RL	Units	DF	Analyzed	By	Method
Cyanide	< 0.25	0.25	mg/kg	1	03/12/24 19:52	JD	SW846 9012B/LACHAT
Solids, Percent	95.3		%	1	03/08/24 06:00	SC	SM2540 G 18TH ED MOD

RL = Reporting Limit

Report of Analysis

Client Sample ID:	SB-25(1.5-2)030724		
Lab Sample ID:	JD83927-16	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8260D SW846 5035	**Percent Solids:**	94.5
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	Y206975.D	1	03/08/24 21:23	PS	03/08/24 10:00	n/a	VY8980
Run #2							

	Initial Weight
Run #1	5.3 g
Run #2	

VOA TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
67-64-1	Acetone	ND	10	4.1	ug/kg	
71-43-2	Benzene	ND	0.50	0.45	ug/kg	
74-97-5	Bromochloromethane	ND	5.0	0.56	ug/kg	
75-27-4	Bromodichloromethane	ND	2.0	0.43	ug/kg	
75-25-2	Bromoform	ND	5.0	1.4	ug/kg	
74-83-9	Bromomethane [a]	ND	5.0	0.76	ug/kg	
78-93-3	2-Butanone (MEK)	ND	10	2.4	ug/kg	
75-15-0	Carbon disulfide	ND	2.0	0.53	ug/kg	
56-23-5	Carbon tetrachloride	ND	2.0	0.62	ug/kg	
108-90-7	Chlorobenzene	ND	2.0	0.46	ug/kg	
75-00-3	Chloroethane	ND	5.0	0.59	ug/kg	
67-66-3	Chloroform	ND	2.0	0.52	ug/kg	
74-87-3	Chloromethane	ND	5.0	2.0	ug/kg	
110-82-7	Cyclohexane	ND	2.0	0.66	ug/kg	
96-12-8	1,2-Dibromo-3-chloropropane	ND	2.0	0.69	ug/kg	
124-48-1	Dibromochloromethane	ND	2.0	0.56	ug/kg	
106-93-4	1,2-Dibromoethane	ND	1.0	0.42	ug/kg	
95-50-1	1,2-Dichlorobenzene	ND	1.0	0.55	ug/kg	
541-73-1	1,3-Dichlorobenzene	ND	1.0	0.50	ug/kg	
106-46-7	1,4-Dichlorobenzene	ND	1.0	0.49	ug/kg	
75-71-8	Dichlorodifluoromethane [a]	ND	5.0	0.73	ug/kg	
75-34-3	1,1-Dichloroethane	ND	1.0	0.49	ug/kg	
107-06-2	1,2-Dichloroethane	ND	1.0	0.47	ug/kg	
75-35-4	1,1-Dichloroethene	ND	1.0	0.65	ug/kg	
156-59-2	cis-1,2-Dichloroethene	ND	1.0	0.84	ug/kg	
156-60-5	trans-1,2-Dichloroethene	ND	1.0	0.61	ug/kg	
78-87-5	1,2-Dichloropropane	ND	2.0	0.47	ug/kg	
10061-01-5	cis-1,3-Dichloropropene	ND	2.0	0.47	ug/kg	
10061-02-6	trans-1,3-Dichloropropene	ND	2.0	0.46	ug/kg	
100-41-4	Ethylbenzene	ND	1.0	0.45	ug/kg	
76-13-1	Freon 113	ND	5.0	2.7	ug/kg	
591-78-6	2-Hexanone	ND	5.0	2.1	ug/kg	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-25(1.5-2)030724		
Lab Sample ID:	JD83927-16	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8260D SW846 5035	**Percent Solids:**	94.5
Project:	100 Main Street, White Plains, NY		

VOA TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
98-82-8	Isopropylbenzene	ND	2.0	1.4	ug/kg	
79-20-9	Methyl Acetate	ND	5.0	1.4	ug/kg	
108-87-2	Methylcyclohexane	ND	2.0	0.87	ug/kg	
1634-04-4	Methyl Tert Butyl Ether	ND	1.0	0.47	ug/kg	
108-10-1	4-Methyl-2-pentanone(MIBK)	ND	5.0	2.3	ug/kg	
75-09-2	Methylene chloride	ND	5.0	2.6	ug/kg	
100-42-5	Styrene	ND	2.0	0.40	ug/kg	
79-34-5	1,1,2,2-Tetrachloroethane	ND	2.0	0.60	ug/kg	
127-18-4	Tetrachloroethene	ND	2.0	0.58	ug/kg	
108-88-3	Toluene	ND	1.0	0.52	ug/kg	
87-61-6	1,2,3-Trichlorobenzene	ND	5.0	2.5	ug/kg	
120-82-1	1,2,4-Trichlorobenzene	ND	5.0	2.5	ug/kg	
71-55-6	1,1,1-Trichloroethane	ND	2.0	0.48	ug/kg	
79-00-5	1,1,2-Trichloroethane	ND	2.0	0.55	ug/kg	
79-01-6	Trichloroethene	ND	1.0	0.76	ug/kg	
75-69-4	Trichlorofluoromethane	ND	5.0	0.68	ug/kg	
75-01-4	Vinyl chloride	ND	2.0	0.48	ug/kg	
	m,p-Xylene	ND	1.0	0.89	ug/kg	
95-47-6	o-Xylene	ND	1.0	0.46	ug/kg	
1330-20-7	Xylene (total)	ND	1.0	0.46	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
1868-53-7	Dibromofluoromethane	96%		80-124%
17060-07-0	1,2-Dichloroethane-D4	102%		75-133%
2037-26-5	Toluene-D8	100%		79-125%
460-00-4	4-Bromofluorobenzene	103%		58-148%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	system artifact	.87	12	ug/kg	J
	Total TIC, Volatile		0	ug/kg	

(a) Associated CCV outside of control limits high, sample was ND.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-25(1.5-2)030724		
Lab Sample ID:	JD83927-16	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	94.5
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	Z166849.D	1	03/11/24 20:54	JY	03/09/24 18:30	OP53010	EZ8267
Run #2	2P118382.D	10	03/12/24 09:49	KM	03/09/24 18:30	OP53010	E2P5334

	Initial Weight	Final Volume
Run #1	30.8 g	1.0 ml
Run #2	30.8 g	1.0 ml

ABN TCL List (SOM0 2.0)

CAS No.	Compound	Result	RL	MDL	Units	Q
95-57-8	2-Chlorophenol	ND	69	17	ug/kg	
59-50-7	4-Chloro-3-methyl phenol	ND	170	21	ug/kg	
120-83-2	2,4-Dichlorophenol	ND	170	29	ug/kg	
105-67-9	2,4-Dimethylphenol	ND	170	61	ug/kg	
51-28-5	2,4-Dinitrophenol	ND	170	130	ug/kg	
534-52-1	4,6-Dinitro-o-cresol	ND	170	37	ug/kg	
95-48-7	2-Methylphenol	ND	69	22	ug/kg	
	3&4-Methylphenol	ND	69	28	ug/kg	
88-75-5	2-Nitrophenol	ND	170	23	ug/kg	
100-02-7	4-Nitrophenol	ND	340	92	ug/kg	
87-86-5	Pentachlorophenol	ND	140	32	ug/kg	
108-95-2	Phenol	ND	69	18	ug/kg	
58-90-2	2,3,4,6-Tetrachlorophenol	ND	170	23	ug/kg	
95-95-4	2,4,5-Trichlorophenol	ND	170	26	ug/kg	
88-06-2	2,4,6-Trichlorophenol	ND	170	20	ug/kg	
83-32-9	Acenaphthene [a]	75.0	34	12	ug/kg	
208-96-8	Acenaphthylene	ND	34	17	ug/kg	
98-86-2	Acetophenone	ND	170	7.4	ug/kg	
120-12-7	Anthracene	416	34	21	ug/kg	
1912-24-9	Atrazine	ND	69	15	ug/kg	
56-55-3	Benzo(a)anthracene	4370 [b]	340	97	ug/kg	
50-32-8	Benzo(a)pyrene	4720 [b]	340	160	ug/kg	
205-99-2	Benzo(b)fluoranthene	5920 [b]	340	150	ug/kg	
191-24-2	Benzo(g,h,i)perylene	3350	34	17	ug/kg	
207-08-9	Benzo(k)fluoranthene	2140	34	16	ug/kg	
101-55-3	4-Bromophenyl phenyl ether	ND	69	13	ug/kg	
85-68-7	Butyl benzyl phthalate	ND	69	8.4	ug/kg	
92-52-4	1,1'-Biphenyl	ND	69	4.7	ug/kg	
100-52-7	Benzaldehyde [c]	ND	170	8.5	ug/kg	
91-58-7	2-Chloronaphthalene	ND	69	8.2	ug/kg	
106-47-8	4-Chloroaniline	ND	170	12	ug/kg	
86-74-8	Carbazole	196	69	5.0	ug/kg	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-25(1.5-2)030724		
Lab Sample ID:	JD83927-16	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	94.5
Project:	100 Main Street, White Plains, NY		

ABN TCL List (SOM0 2.0)

CAS No.	Compound	Result	RL	MDL	Units	Q
105-60-2	Caprolactam	ND	69	14	ug/kg	
218-01-9	Chrysene	4890 [b]	340	110	ug/kg	
111-91-1	bis(2-Chloroethoxy)methane	ND	69	7.4	ug/kg	
111-44-4	bis(2-Chloroethyl)ether	ND	69	15	ug/kg	
108-60-1	2,2'-Oxybis(1-chloropropane)	ND	69	12	ug/kg	
7005-72-3	4-Chlorophenyl phenyl ether	ND	69	11	ug/kg	
121-14-2	2,4-Dinitrotoluene	ND	34	11	ug/kg	
606-20-2	2,6-Dinitrotoluene	ND	34	17	ug/kg	
91-94-1	3,3'-Dichlorobenzidine	ND	69	29	ug/kg	
123-91-1	1,4-Dioxane	ND	34	23	ug/kg	
53-70-3	Dibenzo(a,h)anthracene	925	34	15	ug/kg	
132-64-9	Dibenzofuran [a]	21.7	69	14	ug/kg	J
84-74-2	Di-n-butyl phthalate	ND	69	5.6	ug/kg	
117-84-0	Di-n-octyl phthalate	ND	69	8.6	ug/kg	
84-66-2	Diethyl phthalate	ND	69	7.3	ug/kg	
131-11-3	Dimethyl phthalate	ND	69	6.1	ug/kg	
117-81-7	bis(2-Ethylhexyl)phthalate	34.9	69	8.0	ug/kg	J
206-44-0	Fluoranthene	7040 [b]	340	150	ug/kg	
86-73-7	Fluorene [a]	56.6	34	16	ug/kg	
118-74-1	Hexachlorobenzene [d]	ND	69	8.7	ug/kg	
87-68-3	Hexachlorobutadiene [d]	ND	34	14	ug/kg	
77-47-4	Hexachlorocyclopentadiene	ND	340	14	ug/kg	
67-72-1	Hexachloroethane	ND	170	17	ug/kg	
193-39-5	Indeno(1,2,3-cd)pyrene	2770	34	16	ug/kg	
78-59-1	Isophorone	ND	69	7.4	ug/kg	
91-57-6	2-Methylnaphthalene	ND	34	7.8	ug/kg	
88-74-4	2-Nitroaniline	ND	170	8.1	ug/kg	
99-09-2	3-Nitroaniline	ND	170	8.6	ug/kg	
100-01-6	4-Nitroaniline	ND	170	8.9	ug/kg	
91-20-3	Naphthalene [d]	ND	34	9.7	ug/kg	
98-95-3	Nitrobenzene	ND	69	13	ug/kg	
621-64-7	N-Nitroso-di-n-propylamine	ND	69	9.9	ug/kg	
86-30-6	N-Nitrosodiphenylamine	ND	170	13	ug/kg	
85-01-8	Phenanthrene [a]	1510	34	12	ug/kg	
129-00-0	Pyrene	6570 [b]	340	110	ug/kg	
95-94-3	1,2,4,5-Tetrachlorobenzene	ND	170	8.7	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
367-12-4	2-Fluorophenol	44%	46%	10-99%

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-25(1.5-2)030724		
Lab Sample ID:	JD83927-16	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	94.5
Project:	100 Main Street, White Plains, NY		

ABN TCL List (SOM0 2.0)

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
4165-62-2	Phenol-d5	48%	45%	10-96%
118-79-6	2,4,6-Tribromophenol	62%	42%	10-123%
4165-60-0	Nitrobenzene-d5	47%	47%	10-109%
321-60-8	2-Fluorobiphenyl	53%	53%	11-109%
1718-51-0	Terphenyl-d14	56%	53%	10-120%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	4H-Cyclopenta[def]phenanthrene	7.27	810	ug/kg	J
	Benz(a)anthracene, dimethyl-	9.95	810	ug/kg	J
	Benz(a)anthracene, dimethyl-	9.99	1300	ug/kg	J
	Unknown	10.06	1100	ug/kg	J
	Unknown PAH substance	10.31	1200	ug/kg	J
	Benz(a)anthracene, trimethyl-	10.35	760	ug/kg	J
	Unknown	10.41	1500	ug/kg	J
	Unknown	10.45	900	ug/kg	J
	Unknown PAH substance	10.50	3600	ug/kg	J
	Unknown	10.77	1200	ug/kg	J
	Unknown	10.81	1400	ug/kg	J
	Unknown	10.89	1300	ug/kg	J
	Unknown	10.93	870	ug/kg	J
	Unknown	11.00	890	ug/kg	J
	Unknown	11.04	870	ug/kg	J
	Unknown	11.11	830	ug/kg	J
	Unknown	11.37	1300	ug/kg	J
	Unknown	11.49	750	ug/kg	J
	Unknown	11.59	750	ug/kg	J
	Unknown	11.65	1200	ug/kg	J
	Unknown PAH substance	11.76	1200	ug/kg	J
	Unknown PAH substance	12.07	870	ug/kg	J
	Unknown	12.13	890	ug/kg	J
	Unknown	12.19	770	ug/kg	J
	Unknown PAH substance	12.52	990	ug/kg	J
	Total TIC, Semi-Volatile		28060	ug/kg	J

(a) Associated CCV outside of control limits low. Low-level verification was analyzed to demonstrate system suitability to detect affected analytes. Estimated value, due to corresponding failure in the batch associated CCV.
(b) Result is from Run# 2
(c) Associated CCV outside of control limits high, sample was ND.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-25(1.5-2)030724		
Lab Sample ID:	JD83927-16	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	94.5
Project:	100 Main Street, White Plains, NY		

ABN TCL List (SOM0 2.0)

CAS No.	Compound	Result	RL	MDL	Units	Q

(d) Associated CCV outside of control limits low. Low-level verification was analyzed to demonstrate system suitability to detect affected analytes. Sample was ND.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-25(1.5-2)030724		
Lab Sample ID:	JD83927-16	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8081B SW846 3570	**Percent Solids:**	94.5
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	5G136417.D	1	03/11/24 03:33	CP	03/09/24 08:40	OP53021	G5G3550
Run #2							

	Initial Weight	Final Volume
Run #1	5.4 g	10.0 ml
Run #2		

Pesticide TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
309-00-2	Aldrin	0.20	0.39	0.076	ug/kg	J
319-84-6	alpha-BHC [a]	0.078	0.39	0.045	ug/kg	J
319-85-7	beta-BHC	ND	0.39	0.057	ug/kg	
319-86-8	delta-BHC [b]	0.22	0.39	0.059	ug/kg	J
58-89-9	gamma-BHC (Lindane)	ND	0.39	0.069	ug/kg	
5103-71-9	alpha-Chlordane	ND	0.39	0.053	ug/kg	
5103-74-2	gamma-Chlordane	ND	0.39	0.059	ug/kg	
60-57-1	Dieldrin	2.1	0.39	0.063	ug/kg	
72-54-8	4,4'-DDD [a]	0.15	0.39	0.041	ug/kg	J
72-55-9	4,4'-DDE [a]	0.20	0.39	0.047	ug/kg	J
50-29-3	4,4'-DDT [a]	0.84	0.39	0.069	ug/kg	
72-20-8	Endrin	ND	0.39	0.057	ug/kg	
1031-07-8	Endosulfan sulfate	ND	0.39	0.047	ug/kg	
7421-93-4	Endrin aldehyde	ND	0.39	0.11	ug/kg	
959-98-8	Endosulfan-I	ND	0.39	0.053	ug/kg	
33213-65-9	Endosulfan-II	ND	0.39	0.055	ug/kg	
76-44-8	Heptachlor	ND	0.39	0.051	ug/kg	
1024-57-3	Heptachlor epoxide [a]	0.11	0.39	0.071	ug/kg	J
72-43-5	Methoxychlor	ND	0.39	0.15	ug/kg	
53494-70-5	Endrin ketone	ND	0.39	0.063	ug/kg	
8001-35-2	Toxaphene	ND	4.9	3.2	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
877-09-8	Tetrachloro-m-xylene	73%		66-150%
877-09-8	Tetrachloro-m-xylene	80%		66-150%
2051-24-3	Decachlorobiphenyl	2050% [c]		40-150%
2051-24-3	Decachlorobiphenyl	496% [c]		40-150%

(a) More than 40 % RPD for detected concentrations between the two GC columns.
(b) Reported from the 2nd signal. The %D of the CCV on the 1st signal exceeds the method criteria of 20%, so it being used for confirmation only. More than 40 % RPD for detected concentrations between the two GC columns.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-25(1.5-2)030724		
Lab Sample ID:	JD83927-16	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8081B SW846 3570	**Percent Solids:**	94.5
Project:	100 Main Street, White Plains, NY		

Pesticide TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q

(c) Outside control limits due to matrix interference.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-25(1.5-2)030724		
Lab Sample ID:	JD83927-16	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8082A SW846 3570	**Percent Solids:**	94.5
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	2G231151.D	1	03/11/24 07:38	TP	03/09/24 08:40	OP53022	G2G6058
Run #2							

	Initial Weight	Final Volume
Run #1	5.4 g	10.0 ml
Run #2		

PCB List

CAS No.	Compound	Result	RL	MDL	Units	Q
12674-11-2	Aroclor 1016	ND	20	8.3	ug/kg	
11104-28-2	Aroclor 1221	ND	20	6.6	ug/kg	
11141-16-5	Aroclor 1232	ND	20	16	ug/kg	
53469-21-9	Aroclor 1242	ND	20	12	ug/kg	
12672-29-6	Aroclor 1248	ND	20	4.2	ug/kg	
11097-69-1	Aroclor 1254	ND	20	2.1	ug/kg	
11096-82-5	Aroclor 1260	ND	20	6.8	ug/kg	
11100-14-4	Aroclor 1268	ND	20	2.0	ug/kg	
37324-23-5	Aroclor 1262	ND	20	1.6	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
877-09-8	Tetrachloro-m-xylene	84%		42-159%
877-09-8	Tetrachloro-m-xylene	79%		42-159%
2051-24-3	Decachlorobiphenyl	94%		18-154%
2051-24-3	Decachlorobiphenyl	138%		18-154%

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID: SB-25(1.5-2)030724
Lab Sample ID: JD83927-16
Matrix: SO - Soil
Project: 100 Main Street, White Plains, NY

Date Sampled: 03/07/24
Date Received: 03/07/24
Percent Solids: 94.5

Metals Analysis

Analyte	Result	RL	Units	DF	Prep	Analyzed	By	Method	Prep Method
Aluminum	6280	55	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Antimony	< 2.2	2.2	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Arsenic	< 2.2	2.2	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Barium	56.9	22	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Beryllium	0.29	0.22	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Cadmium	< 0.55	0.55	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Calcium	13300	550	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Chromium	12.8	1.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Cobalt	< 5.5	5.5	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Copper	14.8	2.7	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Iron	12000	55	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Lead	27.1	2.2	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Magnesium	8240	550	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Manganese	181	1.6	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Mercury	0.061	0.034	mg/kg	1	03/13/24	03/14/24	LM	SW846 7471B [1]	SW846 7471B [4]
Nickel	10.3	4.4	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Potassium	1740	1100	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Selenium	< 2.2	2.2	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Silver	< 0.55	0.55	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Sodium	< 1100	1100	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Thallium	< 1.1	1.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Vanadium	18.2	5.5	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Zinc	44.4	5.5	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]

(1) Instrument QC Batch: MA55688
(2) Instrument QC Batch: MA55691
(3) Prep QC Batch: MP45216
(4) Prep QC Batch: MP45278

RL = Reporting Limit

Report of Analysis

Client Sample ID:	SB-25(1.5-2)030724		
Lab Sample ID:	JD83927-16	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
		Percent Solids:	94.5
Project:	100 Main Street, White Plains, NY		

General Chemistry

Analyte	Result	RL	Units	DF	Analyzed	By	Method
Cyanide	< 0.24	0.24	mg/kg	1	03/12/24 19:54	JD	SW846 9012B/LACHAT
Solids, Percent	94.5		%	1	03/08/24 06:00	SC	SM2540 G 18TH ED MOD

RL = Reporting Limit

Report of Analysis

Client Sample ID:	SB-25(3-3.5)030724		
Lab Sample ID:	JD83927-17	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8260D SW846 5035	**Percent Solids:**	94.2
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	Y206976.D	1	03/08/24 21:45	PS	03/08/24 10:00	n/a	VY8980
Run #2							

	Initial Weight
Run #1	5.2 g
Run #2	

VOA TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
67-64-1	Acetone	ND	10	4.2	ug/kg	
71-43-2	Benzene	ND	0.51	0.46	ug/kg	
74-97-5	Bromochloromethane	ND	5.1	0.57	ug/kg	
75-27-4	Bromodichloromethane	ND	2.0	0.44	ug/kg	
75-25-2	Bromoform	ND	5.1	1.4	ug/kg	
74-83-9	Bromomethane [a]	ND	5.1	0.78	ug/kg	
78-93-3	2-Butanone (MEK)	ND	10	2.5	ug/kg	
75-15-0	Carbon disulfide	ND	2.0	0.55	ug/kg	
56-23-5	Carbon tetrachloride	ND	2.0	0.63	ug/kg	
108-90-7	Chlorobenzene	ND	2.0	0.47	ug/kg	
75-00-3	Chloroethane	ND	5.1	0.60	ug/kg	
67-66-3	Chloroform	ND	2.0	0.53	ug/kg	
74-87-3	Chloromethane	ND	5.1	2.0	ug/kg	
110-82-7	Cyclohexane	ND	2.0	0.67	ug/kg	
96-12-8	1,2-Dibromo-3-chloropropane	ND	2.0	0.71	ug/kg	
124-48-1	Dibromochloromethane	ND	2.0	0.57	ug/kg	
106-93-4	1,2-Dibromoethane	ND	1.0	0.43	ug/kg	
95-50-1	1,2-Dichlorobenzene	ND	1.0	0.56	ug/kg	
541-73-1	1,3-Dichlorobenzene	ND	1.0	0.51	ug/kg	
106-46-7	1,4-Dichlorobenzene	ND	1.0	0.50	ug/kg	
75-71-8	Dichlorodifluoromethane [a]	ND	5.1	0.74	ug/kg	
75-34-3	1,1-Dichloroethane	ND	1.0	0.51	ug/kg	
107-06-2	1,2-Dichloroethane	ND	1.0	0.48	ug/kg	
75-35-4	1,1-Dichloroethene	ND	1.0	0.67	ug/kg	
156-59-2	cis-1,2-Dichloroethene	ND	1.0	0.86	ug/kg	
156-60-5	trans-1,2-Dichloroethene	ND	1.0	0.62	ug/kg	
78-87-5	1,2-Dichloropropane	ND	2.0	0.48	ug/kg	
10061-01-5	cis-1,3-Dichloropropene	ND	2.0	0.48	ug/kg	
10061-02-6	trans-1,3-Dichloropropene	ND	2.0	0.47	ug/kg	
100-41-4	Ethylbenzene	ND	1.0	0.46	ug/kg	
76-13-1	Freon 113	ND	5.1	2.7	ug/kg	
591-78-6	2-Hexanone	ND	5.1	2.2	ug/kg	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-25(3-3.5)030724		
Lab Sample ID:	JD83927-17	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8260D SW846 5035	**Percent Solids:**	94.2
Project:	100 Main Street, White Plains, NY		

VOA TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
98-82-8	Isopropylbenzene	ND	2.0	1.4	ug/kg	
79-20-9	Methyl Acetate	ND	5.1	1.4	ug/kg	
108-87-2	Methylcyclohexane	ND	2.0	0.89	ug/kg	
1634-04-4	Methyl Tert Butyl Ether	ND	1.0	0.48	ug/kg	
108-10-1	4-Methyl-2-pentanone(MIBK)	ND	5.1	2.3	ug/kg	
75-09-2	Methylene chloride	ND	5.1	2.7	ug/kg	
100-42-5	Styrene	ND	2.0	0.41	ug/kg	
79-34-5	1,1,2,2-Tetrachloroethane	ND	2.0	0.61	ug/kg	
127-18-4	Tetrachloroethene	ND	2.0	0.59	ug/kg	
108-88-3	Toluene	ND	1.0	0.54	ug/kg	
87-61-6	1,2,3-Trichlorobenzene	ND	5.1	2.6	ug/kg	
120-82-1	1,2,4-Trichlorobenzene	ND	5.1	2.6	ug/kg	
71-55-6	1,1,1-Trichloroethane	ND	2.0	0.49	ug/kg	
79-00-5	1,1,2-Trichloroethane	ND	2.0	0.57	ug/kg	
79-01-6	Trichloroethene	ND	1.0	0.78	ug/kg	
75-69-4	Trichlorofluoromethane	ND	5.1	0.70	ug/kg	
75-01-4	Vinyl chloride	ND	2.0	0.49	ug/kg	
	m,p-Xylene	ND	1.0	0.91	ug/kg	
95-47-6	o-Xylene	ND	1.0	0.47	ug/kg	
1330-20-7	Xylene (total)	ND	1.0	0.47	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
1868-53-7	Dibromofluoromethane	94%		80-124%
17060-07-0	1,2-Dichloroethane-D4	103%		75-133%
2037-26-5	Toluene-D8	101%		79-125%
460-00-4	4-Bromofluorobenzene	104%		58-148%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	system artifact	.87	13	ug/kg	J
	Total TIC, Volatile		0	ug/kg	

(a) Associated CCV outside of control limits high, sample was ND.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID: SB-25(3-3.5)030724
Lab Sample ID: JD83927-17
Matrix: SO - Soil
Method: SW846 8270E SW846 3546
Project: 100 Main Street, White Plains, NY

Date Sampled: 03/07/24
Date Received: 03/07/24
Percent Solids: 94.2

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	Z166843.D	1	03/11/24 18:58	JY	03/09/24 18:30	OP53010	EZ8267
Run #2							

	Initial Weight	Final Volume
Run #1	30.0 g	1.0 ml
Run #2		

ABN TCL List (SOM0 2.0)

CAS No.	Compound	Result	RL	MDL	Units	Q
95-57-8	2-Chlorophenol	ND	71	17	ug/kg	
59-50-7	4-Chloro-3-methyl phenol	ND	180	22	ug/kg	
120-83-2	2,4-Dichlorophenol	ND	180	30	ug/kg	
105-67-9	2,4-Dimethylphenol	ND	180	63	ug/kg	
51-28-5	2,4-Dinitrophenol	ND	180	130	ug/kg	
534-52-1	4,6-Dinitro-o-cresol	ND	180	38	ug/kg	
95-48-7	2-Methylphenol	ND	71	23	ug/kg	
	3&4-Methylphenol	ND	71	29	ug/kg	
88-75-5	2-Nitrophenol	ND	180	23	ug/kg	
100-02-7	4-Nitrophenol	ND	350	94	ug/kg	
87-86-5	Pentachlorophenol	ND	140	33	ug/kg	
108-95-2	Phenol	ND	71	18	ug/kg	
58-90-2	2,3,4,6-Tetrachlorophenol	ND	180	23	ug/kg	
95-95-4	2,4,5-Trichlorophenol	ND	180	27	ug/kg	
88-06-2	2,4,6-Trichlorophenol	ND	180	21	ug/kg	
83-32-9	Acenaphthene [a]	23.5	35	12	ug/kg	J
208-96-8	Acenaphthylene	39.8	35	18	ug/kg	
98-86-2	Acetophenone	ND	180	7.6	ug/kg	
120-12-7	Anthracene	98.8	35	22	ug/kg	
1912-24-9	Atrazine	ND	71	15	ug/kg	
56-55-3	Benzo(a)anthracene	504	35	10	ug/kg	
50-32-8	Benzo(a)pyrene	507	35	16	ug/kg	
205-99-2	Benzo(b)fluoranthene	504	35	16	ug/kg	
191-24-2	Benzo(g,h,i)perylene	269	35	18	ug/kg	
207-08-9	Benzo(k)fluoranthene	198	35	17	ug/kg	
101-55-3	4-Bromophenyl phenyl ether	ND	71	14	ug/kg	
85-68-7	Butyl benzyl phthalate	ND	71	8.6	ug/kg	
92-52-4	1,1'-Biphenyl	ND	71	4.8	ug/kg	
100-52-7	Benzaldehyde [b]	ND	180	8.8	ug/kg	
91-58-7	2-Chloronaphthalene	ND	71	8.4	ug/kg	
106-47-8	4-Chloroaniline	ND	180	13	ug/kg	
86-74-8	Carbazole	37.6	71	5.1	ug/kg	J

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-25(3-3.5)030724		
Lab Sample ID:	JD83927-17	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	94.2
Project:	100 Main Street, White Plains, NY		

ABN TCL List (SOM0 2.0)

CAS No.	Compound	Result	RL	MDL	Units	Q
105-60-2	Caprolactam	ND	71	14	ug/kg	
218-01-9	Chrysene	444	35	11	ug/kg	
111-91-1	bis(2-Chloroethoxy)methane	ND	71	7.6	ug/kg	
111-44-4	bis(2-Chloroethyl)ether	ND	71	15	ug/kg	
108-60-1	2,2'-Oxybis(1-chloropropane)	ND	71	13	ug/kg	
7005-72-3	4-Chlorophenyl phenyl ether	ND	71	11	ug/kg	
121-14-2	2,4-Dinitrotoluene	ND	35	11	ug/kg	
606-20-2	2,6-Dinitrotoluene	ND	35	18	ug/kg	
91-94-1	3,3'-Dichlorobenzidine	ND	71	30	ug/kg	
123-91-1	1,4-Dioxane	ND	35	23	ug/kg	
53-70-3	Dibenzo(a,h)anthracene	71.7	35	16	ug/kg	
132-64-9	Dibenzofuran [a]	14.2	71	14	ug/kg	J
84-74-2	Di-n-butyl phthalate	ND	71	5.8	ug/kg	
117-84-0	Di-n-octyl phthalate	ND	71	8.8	ug/kg	
84-66-2	Diethyl phthalate	ND	71	7.5	ug/kg	
131-11-3	Dimethyl phthalate	ND	71	6.3	ug/kg	
117-81-7	bis(2-Ethylhexyl)phthalate	ND	71	8.3	ug/kg	
206-44-0	Fluoranthene	711	35	16	ug/kg	
86-73-7	Fluorene [a]	24.6	35	16	ug/kg	J
118-74-1	Hexachlorobenzene [c]	ND	71	9.0	ug/kg	
87-68-3	Hexachlorobutadiene [c]	ND	35	14	ug/kg	
77-47-4	Hexachlorocyclopentadiene	ND	350	14	ug/kg	
67-72-1	Hexachloroethane	ND	180	18	ug/kg	
193-39-5	Indeno(1,2,3-cd)pyrene	229	35	17	ug/kg	
78-59-1	Isophorone	ND	71	7.6	ug/kg	
91-57-6	2-Methylnaphthalene	ND	35	8.0	ug/kg	
88-74-4	2-Nitroaniline	ND	180	8.4	ug/kg	
99-09-2	3-Nitroaniline	ND	180	8.8	ug/kg	
100-01-6	4-Nitroaniline	ND	180	9.2	ug/kg	
91-20-3	Naphthalene [a]	13.5	35	10	ug/kg	J
98-95-3	Nitrobenzene	ND	71	14	ug/kg	
621-64-7	N-Nitroso-di-n-propylamine	ND	71	10	ug/kg	
86-30-6	N-Nitrosodiphenylamine	ND	180	13	ug/kg	
85-01-8	Phenanthrene [a]	293	35	12	ug/kg	
129-00-0	Pyrene	599	35	11	ug/kg	
95-94-3	1,2,4,5-Tetrachlorobenzene	ND	180	9.0	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
367-12-4	2-Fluorophenol	43%		10-99%

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-25(3-3.5)030724		
Lab Sample ID:	JD83927-17	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	94.2
Project:	100 Main Street, White Plains, NY		

ABN TCL List (SOM0 2.0)

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
4165-62-2	Phenol-d5	46%		10-96%
118-79-6	2,4,6-Tribromophenol	49%		10-123%
4165-60-0	Nitrobenzene-d5	45%		10-109%
321-60-8	2-Fluorobiphenyl	50%		11-109%
1718-51-0	Terphenyl-d14	53%		10-120%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Phenanthrene, methyl-	7.19	190	ug/kg	J
	Naphthalene, dihydro- phenyl-	7.67	170	ug/kg	J
	Pyrene, methyl-	8.35	150	ug/kg	J
	Unknown	9.04	150	ug/kg	J
	System artifact	9.30	230	ug/kg	J
	Chrysene, methyl-	9.56	200	ug/kg	J
	Unknown	9.65	160	ug/kg	J
	Unknown	9.68	200	ug/kg	J
	Unknown PAH substance	10.29	180	ug/kg	J
	Unknown	10.39	160	ug/kg	J
	Unknown PAH substance	10.47	370	ug/kg	J
	Unknown	10.79	150	ug/kg	J
	Unknown	10.86	150	ug/kg	J
	Unknown	11.09	150	ug/kg	J
	Total TIC, Semi-Volatile		2380	ug/kg	J

(a) Associated CCV outside of control limits low. Low-level verification was analyzed to demonstrate system suitability to detect affected analytes. Estimated value, due to corresponding failure in the batch associated CCV.
(b) Associated CCV outside of control limits high, sample was ND.
(c) Associated CCV outside of control limits low. Low-level verification was analyzed to demonstrate system suitability to detect affected analytes. Sample was ND.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-25(3-3.5)030724		
Lab Sample ID:	JD83927-17	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8081B SW846 3570	**Percent Solids:**	94.2
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	5G136418.D	1	03/11/24 03:55	CP	03/09/24 08:40	OP53021	G5G3550
Run #2							

	Initial Weight	Final Volume
Run #1	5.3 g	10.0 ml
Run #2		

Pesticide TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
309-00-2	Aldrin	ND	0.40	0.078	ug/kg	
319-84-6	alpha-BHC	ND	0.40	0.046	ug/kg	
319-85-7	beta-BHC	ND	0.40	0.058	ug/kg	
319-86-8	delta-BHC	ND	0.40	0.060	ug/kg	
58-89-9	gamma-BHC (Lindane)	ND	0.40	0.070	ug/kg	
5103-71-9	alpha-Chlordane	ND	0.40	0.054	ug/kg	
5103-74-2	gamma-Chlordane	ND	0.40	0.060	ug/kg	
60-57-1	Dieldrin	ND	0.40	0.064	ug/kg	
72-54-8	4,4'-DDD	ND	0.40	0.042	ug/kg	
72-55-9	4,4'-DDE	ND	0.40	0.048	ug/kg	
50-29-3	4,4'-DDT [a]	0.80	0.40	0.070	ug/kg	
72-20-8	Endrin	ND	0.40	0.058	ug/kg	
1031-07-8	Endosulfan sulfate	ND	0.40	0.048	ug/kg	
7421-93-4	Endrin aldehyde	ND	0.40	0.12	ug/kg	
959-98-8	Endosulfan-I	ND	0.40	0.054	ug/kg	
33213-65-9	Endosulfan-II	ND	0.40	0.056	ug/kg	
76-44-8	Heptachlor	ND	0.40	0.052	ug/kg	
1024-57-3	Heptachlor epoxide	ND	0.40	0.072	ug/kg	
72-43-5	Methoxychlor	ND	0.40	0.16	ug/kg	
53494-70-5	Endrin ketone	ND	0.40	0.064	ug/kg	
8001-35-2	Toxaphene	ND	5.0	3.3	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
877-09-8	Tetrachloro-m-xylene	102%		66-150%
877-09-8	Tetrachloro-m-xylene	96%		66-150%
2051-24-3	Decachlorobiphenyl	552% [b]		40-150%
2051-24-3	Decachlorobiphenyl	204% [b]		40-150%

(a) More than 40 % RPD for detected concentrations between the two GC columns.
(b) Outside control limits due to matrix interference.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-25(3-3.5)030724		
Lab Sample ID:	JD83927-17	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8082A SW846 3570	**Percent Solids:**	94.2
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	2G231156.D	1	03/11/24 09:40	TP	03/09/24 08:40	OP53022	G2G6058
Run #2							

	Initial Weight	Final Volume
Run #1	5.3 g	10.0 ml
Run #2		

PCB List

CAS No.	Compound	Result	RL	MDL	Units	Q
12674-11-2	Aroclor 1016	ND	20	8.5	ug/kg	
11104-28-2	Aroclor 1221	ND	20	6.7	ug/kg	
11141-16-5	Aroclor 1232	ND	20	17	ug/kg	
53469-21-9	Aroclor 1242	ND	20	12	ug/kg	
12672-29-6	Aroclor 1248	ND	20	4.3	ug/kg	
11097-69-1	Aroclor 1254	ND	20	2.2	ug/kg	
11096-82-5	Aroclor 1260	ND	20	6.9	ug/kg	
11100-14-4	Aroclor 1268	ND	20	2.0	ug/kg	
37324-23-5	Aroclor 1262	ND	20	1.7	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
877-09-8	Tetrachloro-m-xylene	79%		42-159%
877-09-8	Tetrachloro-m-xylene	78%		42-159%
2051-24-3	Decachlorobiphenyl	96%		18-154%
2051-24-3	Decachlorobiphenyl	137%		18-154%

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID: SB-25(3-3.5)030724
Lab Sample ID: JD83927-17
Matrix: SO - Soil
Project: 100 Main Street, White Plains, NY

Date Sampled: 03/07/24
Date Received: 03/07/24
Percent Solids: 94.2

Metals Analysis

Analyte	Result	RL	Units	DF	Prep	Analyzed	By	Method	Prep Method
Aluminum	6230	55	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Antimony	< 2.2	2.2	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Arsenic	< 2.2	2.2	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Barium	52.4	22	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Beryllium	0.34	0.22	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Cadmium	< 0.55	0.55	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Calcium	12700	550	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Chromium	13.6	1.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Cobalt	< 5.5	5.5	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Copper	15.7	2.7	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Iron	11200	55	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Lead	24.8	2.2	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Magnesium	7830	550	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Manganese	147	1.6	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Mercury	0.10	0.032	mg/kg	1	03/13/24	03/14/24	LM	SW846 7471B [1]	SW846 7471B [4]
Nickel	10.8	4.4	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Potassium	1600	1100	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Selenium	< 2.2	2.2	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Silver	< 0.55	0.55	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Sodium	< 1100	1100	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Thallium	< 1.1	1.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Vanadium	17.0	5.5	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Zinc	55.9	5.5	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]

(1) Instrument QC Batch: MA55688
(2) Instrument QC Batch: MA55691
(3) Prep QC Batch: MP45216
(4) Prep QC Batch: MP45278

RL = Reporting Limit

Report of Analysis

Client Sample ID:	SB-25(3-3.5)030724		
Lab Sample ID:	JD83927-17	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
		Percent Solids:	94.2
Project:	100 Main Street, White Plains, NY		

General Chemistry

Analyte	Result	RL	Units	DF	Analyzed	By	Method
Cyanide	< 0.25	0.25	mg/kg	1	03/12/24 19:55	JD	SW846 9012B/LACHAT
Solids, Percent	94.2		%	1	03/08/24 06:00	SC	SM2540 G 18TH ED MOD

RL = Reporting Limit

Report of Analysis

Client Sample ID:	SB-25(7.5-8)030724		
Lab Sample ID:	JD83927-18	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8260D SW846 5035	**Percent Solids:**	93.4
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	Y206977.D	1	03/08/24 22:07	PS	03/08/24 10:00	n/a	VY8980
Run #2							

	Initial Weight
Run #1	5.0 g
Run #2	

VOA TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
67-64-1	Acetone	ND	11	4.4	ug/kg	
71-43-2	Benzene	ND	0.54	0.49	ug/kg	
74-97-5	Bromochloromethane	ND	5.4	0.60	ug/kg	
75-27-4	Bromodichloromethane	ND	2.1	0.46	ug/kg	
75-25-2	Bromoform	ND	5.4	1.5	ug/kg	
74-83-9	Bromomethane [a]	ND	5.4	0.82	ug/kg	
78-93-3	2-Butanone (MEK)	ND	11	2.6	ug/kg	
75-15-0	Carbon disulfide	ND	2.1	0.57	ug/kg	
56-23-5	Carbon tetrachloride	ND	2.1	0.66	ug/kg	
108-90-7	Chlorobenzene	ND	2.1	0.49	ug/kg	
75-00-3	Chloroethane	ND	5.4	0.63	ug/kg	
67-66-3	Chloroform	ND	2.1	0.56	ug/kg	
74-87-3	Chloromethane	ND	5.4	2.1	ug/kg	
110-82-7	Cyclohexane	ND	2.1	0.70	ug/kg	
96-12-8	1,2-Dibromo-3-chloropropane	ND	2.1	0.74	ug/kg	
124-48-1	Dibromochloromethane	ND	2.1	0.60	ug/kg	
106-93-4	1,2-Dibromoethane	ND	1.1	0.45	ug/kg	
95-50-1	1,2-Dichlorobenzene	ND	1.1	0.58	ug/kg	
541-73-1	1,3-Dichlorobenzene	ND	1.1	0.53	ug/kg	
106-46-7	1,4-Dichlorobenzene	ND	1.1	0.53	ug/kg	
75-71-8	Dichlorodifluoromethane [a]	ND	5.4	0.78	ug/kg	
75-34-3	1,1-Dichloroethane	ND	1.1	0.53	ug/kg	
107-06-2	1,2-Dichloroethane	ND	1.1	0.50	ug/kg	
75-35-4	1,1-Dichloroethene	ND	1.1	0.70	ug/kg	
156-59-2	cis-1,2-Dichloroethene	ND	1.1	0.90	ug/kg	
156-60-5	trans-1,2-Dichloroethene	ND	1.1	0.65	ug/kg	
78-87-5	1,2-Dichloropropane	ND	2.1	0.51	ug/kg	
10061-01-5	cis-1,3-Dichloropropene	ND	2.1	0.51	ug/kg	
10061-02-6	trans-1,3-Dichloropropene	ND	2.1	0.49	ug/kg	
100-41-4	Ethylbenzene	ND	1.1	0.49	ug/kg	
76-13-1	Freon 113	ND	5.4	2.9	ug/kg	
591-78-6	2-Hexanone	ND	5.4	2.3	ug/kg	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-25(7.5-8)030724		
Lab Sample ID:	JD83927-18	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8260D SW846 5035	**Percent Solids:**	93.4
Project:	100 Main Street, White Plains, NY		

VOA TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
98-82-8	Isopropylbenzene	ND	2.1	1.5	ug/kg	
79-20-9	Methyl Acetate	ND	5.4	1.5	ug/kg	
108-87-2	Methylcyclohexane	ND	2.1	0.94	ug/kg	
1634-04-4	Methyl Tert Butyl Ether	ND	1.1	0.50	ug/kg	
108-10-1	4-Methyl-2-pentanone(MIBK)	ND	5.4	2.4	ug/kg	
75-09-2	Methylene chloride	ND	5.4	2.8	ug/kg	
100-42-5	Styrene	ND	2.1	0.43	ug/kg	
79-34-5	1,1,2,2-Tetrachloroethane	ND	2.1	0.64	ug/kg	
127-18-4	Tetrachloroethene	ND	2.1	0.62	ug/kg	
108-88-3	Toluene	ND	1.1	0.56	ug/kg	
87-61-6	1,2,3-Trichlorobenzene	ND	5.4	2.7	ug/kg	
120-82-1	1,2,4-Trichlorobenzene	ND	5.4	2.7	ug/kg	
71-55-6	1,1,1-Trichloroethane	ND	2.1	0.52	ug/kg	
79-00-5	1,1,2-Trichloroethane	ND	2.1	0.59	ug/kg	
79-01-6	Trichloroethene	ND	1.1	0.82	ug/kg	
75-69-4	Trichlorofluoromethane	ND	5.4	0.73	ug/kg	
75-01-4	Vinyl chloride	ND	2.1	0.51	ug/kg	
	m,p-Xylene	ND	1.1	0.96	ug/kg	
95-47-6	o-Xylene	ND	1.1	0.49	ug/kg	
1330-20-7	Xylene (total)	ND	1.1	0.49	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
1868-53-7	Dibromofluoromethane	94%		80-124%
17060-07-0	1,2-Dichloroethane-D4	101%		75-133%
2037-26-5	Toluene-D8	99%		79-125%
460-00-4	4-Bromofluorobenzene	104%		58-148%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	system artifact	.86	12	ug/kg	J
	Total TIC, Volatile		0	ug/kg	

(a) Associated CCV outside of control limits high, sample was ND.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-25(7.5-8)030724		
Lab Sample ID:	JD83927-18	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	93.4
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	Z166844.D	1	03/11/24 19:21	JY	03/09/24 18:30	OP53010	EZ8267
Run #2							

	Initial Weight	Final Volume
Run #1	31.5 g	1.0 ml
Run #2		

ABN TCL List (SOM0 2.0)

CAS No.	Compound	Result	RL	MDL	Units	Q
95-57-8	2-Chlorophenol	ND	68	17	ug/kg	
59-50-7	4-Chloro-3-methyl phenol	ND	170	21	ug/kg	
120-83-2	2,4-Dichlorophenol	ND	170	29	ug/kg	
105-67-9	2,4-Dimethylphenol	ND	170	61	ug/kg	
51-28-5	2,4-Dinitrophenol	ND	170	130	ug/kg	
534-52-1	4,6-Dinitro-o-cresol	ND	170	36	ug/kg	
95-48-7	2-Methylphenol	ND	68	22	ug/kg	
	3&4-Methylphenol	ND	68	28	ug/kg	
88-75-5	2-Nitrophenol	ND	170	22	ug/kg	
100-02-7	4-Nitrophenol	ND	340	91	ug/kg	
87-86-5	Pentachlorophenol	ND	140	32	ug/kg	
108-95-2	Phenol	ND	68	18	ug/kg	
58-90-2	2,3,4,6-Tetrachlorophenol	ND	170	23	ug/kg	
95-95-4	2,4,5-Trichlorophenol	ND	170	25	ug/kg	
88-06-2	2,4,6-Trichlorophenol	ND	170	20	ug/kg	
83-32-9	Acenaphthene [a]	ND	34	12	ug/kg	
208-96-8	Acenaphthylene	ND	34	17	ug/kg	
98-86-2	Acetophenone	ND	170	7.3	ug/kg	
120-12-7	Anthracene	ND	34	21	ug/kg	
1912-24-9	Atrazine	ND	68	15	ug/kg	
56-55-3	Benzo(a)anthracene	47.8	34	9.6	ug/kg	
50-32-8	Benzo(a)pyrene	47.6	34	15	ug/kg	
205-99-2	Benzo(b)fluoranthene	42.9	34	15	ug/kg	
191-24-2	Benzo(g,h,i)perylene	35.4	34	17	ug/kg	
207-08-9	Benzo(k)fluoranthene	23.0	34	16	ug/kg	J
101-55-3	4-Bromophenyl phenyl ether	ND	68	13	ug/kg	
85-68-7	Butyl benzyl phthalate	ND	68	8.3	ug/kg	
92-52-4	1,1'-Biphenyl	ND	68	4.7	ug/kg	
100-52-7	Benzaldehyde [b]	ND	170	8.4	ug/kg	
91-58-7	2-Chloronaphthalene	ND	68	8.1	ug/kg	
106-47-8	4-Chloroaniline	ND	170	12	ug/kg	
86-74-8	Carbazole	ND	68	4.9	ug/kg	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-25(7.5-8)030724		
Lab Sample ID:	JD83927-18	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	93.4
Project:	100 Main Street, White Plains, NY		

ABN TCL List (SOM0 2.0)

CAS No.	Compound	Result	RL	MDL	Units	Q
105-60-2	Caprolactam	ND	68	13	ug/kg	
218-01-9	Chrysene	33.6	34	11	ug/kg	J
111-91-1	bis(2-Chloroethoxy)methane	ND	68	7.3	ug/kg	
111-44-4	bis(2-Chloroethyl)ether	ND	68	15	ug/kg	
108-60-1	2,2'-Oxybis(1-chloropropane)	ND	68	12	ug/kg	
7005-72-3	4-Chlorophenyl phenyl ether	ND	68	11	ug/kg	
121-14-2	2,4-Dinitrotoluene	ND	34	11	ug/kg	
606-20-2	2,6-Dinitrotoluene	ND	34	17	ug/kg	
91-94-1	3,3'-Dichlorobenzidine	ND	68	28	ug/kg	
123-91-1	1,4-Dioxane	ND	34	22	ug/kg	
53-70-3	Dibenzo(a,h)anthracene	ND	34	15	ug/kg	
132-64-9	Dibenzofuran [a]	ND	68	14	ug/kg	
84-74-2	Di-n-butyl phthalate	ND	68	5.5	ug/kg	
117-84-0	Di-n-octyl phthalate	ND	68	8.5	ug/kg	
84-66-2	Diethyl phthalate	ND	68	7.2	ug/kg	
131-11-3	Dimethyl phthalate	ND	68	6.1	ug/kg	
117-81-7	bis(2-Ethylhexyl)phthalate	ND	68	8.0	ug/kg	
206-44-0	Fluoranthene	72.1	34	15	ug/kg	
86-73-7	Fluorene [a]	ND	34	16	ug/kg	
118-74-1	Hexachlorobenzene [a]	ND	68	8.6	ug/kg	
87-68-3	Hexachlorobutadiene [a]	ND	34	14	ug/kg	
77-47-4	Hexachlorocyclopentadiene	ND	340	14	ug/kg	
67-72-1	Hexachloroethane	ND	170	17	ug/kg	
193-39-5	Indeno(1,2,3-cd)pyrene	22.9	34	16	ug/kg	J
78-59-1	Isophorone	ND	68	7.3	ug/kg	
91-57-6	2-Methylnaphthalene	ND	34	7.7	ug/kg	
88-74-4	2-Nitroaniline	ND	170	8.0	ug/kg	
99-09-2	3-Nitroaniline	ND	170	8.5	ug/kg	
100-01-6	4-Nitroaniline	ND	170	8.8	ug/kg	
91-20-3	Naphthalene [a]	ND	34	9.6	ug/kg	
98-95-3	Nitrobenzene	ND	68	13	ug/kg	
621-64-7	N-Nitroso-di-n-propylamine	ND	68	9.8	ug/kg	
86-30-6	N-Nitrosodiphenylamine	ND	170	12	ug/kg	
85-01-8	Phenanthrene [c]	30.9	34	11	ug/kg	J
129-00-0	Pyrene	65.0	34	11	ug/kg	
95-94-3	1,2,4,5-Tetrachlorobenzene	ND	170	8.6	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
367-12-4	2-Fluorophenol	33%		10-99%

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-25(7.5-8)030724		
Lab Sample ID:	JD83927-18	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8270E SW846 3546	**Percent Solids:**	93.4
Project:	100 Main Street, White Plains, NY		

ABN TCL List (SOM0 2.0)

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
4165-62-2	Phenol-d5	35%		10-96%
118-79-6	2,4,6-Tribromophenol	44%		10-123%
4165-60-0	Nitrobenzene-d5	39%		10-109%
321-60-8	2-Fluorobiphenyl	37%		11-109%
1718-51-0	Terphenyl-d14	44%		10-120%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	System artifact	9.30	170	ug/kg	J
	Unknown	9.67	190	ug/kg	J
	Total TIC, Semi-Volatile		190	ug/kg	J

(a) Associated CCV outside of control limits low. Low-level verification was analyzed to demonstrate system suitability to detect affected analytes. Sample was ND.
(b) Associated CCV outside of control limits high, sample was ND.
(c) Associated CCV outside of control limits low. Low-level verification was analyzed to demonstrate system suitability to detect affected analytes. Estimated value, due to corresponding failure in the batch associated CCV.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID: SB-25(7.5-8)030724
Lab Sample ID: JD83927-18
Matrix: SO - Soil
Method: SW846 8081B SW846 3570
Project: 100 Main Street, White Plains, NY

Date Sampled: 03/07/24
Date Received: 03/07/24
Percent Solids: 93.4

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	5G136419.D	1	03/11/24 04:16	CP	03/09/24 08:40	OP53021	G5G3550
Run #2							

	Initial Weight	Final Volume
Run #1	5.2 g	10.0 ml
Run #2		

Pesticide TCL List

CAS No.	Compound	Result	RL	MDL	Units	Q
309-00-2	Aldrin	ND	0.41	0.080	ug/kg	
319-84-6	alpha-BHC	ND	0.41	0.047	ug/kg	
319-85-7	beta-BHC	ND	0.41	0.060	ug/kg	
319-86-8	delta-BHC	ND	0.41	0.062	ug/kg	
58-89-9	gamma-BHC (Lindane)	ND	0.41	0.072	ug/kg	
5103-71-9	alpha-Chlordane	ND	0.41	0.056	ug/kg	
5103-74-2	gamma-Chlordane	ND	0.41	0.062	ug/kg	
60-57-1	Dieldrin	ND	0.41	0.066	ug/kg	
72-54-8	4,4'-DDD	ND	0.41	0.043	ug/kg	
72-55-9	4,4'-DDE	ND	0.41	0.049	ug/kg	
50-29-3	4,4'-DDT	ND	0.41	0.072	ug/kg	
72-20-8	Endrin	ND	0.41	0.060	ug/kg	
1031-07-8	Endosulfan sulfate	ND	0.41	0.049	ug/kg	
7421-93-4	Endrin aldehyde	ND	0.41	0.12	ug/kg	
959-98-8	Endosulfan-I	ND	0.41	0.056	ug/kg	
33213-65-9	Endosulfan-II	ND	0.41	0.058	ug/kg	
76-44-8	Heptachlor	ND	0.41	0.054	ug/kg	
1024-57-3	Heptachlor epoxide	ND	0.41	0.074	ug/kg	
72-43-5	Methoxychlor	ND	0.41	0.16	ug/kg	
53494-70-5	Endrin ketone	ND	0.41	0.066	ug/kg	
8001-35-2	Toxaphene	ND	5.1	3.4	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
877-09-8	Tetrachloro-m-xylene	107%		66-150%
877-09-8	Tetrachloro-m-xylene	92%		66-150%
2051-24-3	Decachlorobiphenyl	123%		40-150%
2051-24-3	Decachlorobiphenyl	95%		40-150%

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	SB-25(7.5-8)030724		
Lab Sample ID:	JD83927-18	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
Method:	SW846 8082A SW846 3570	**Percent Solids:**	93.4
Project:	100 Main Street, White Plains, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	2G231157.D	1	03/11/24 10:04	TP	03/09/24 08:40	OP53022	G2G6058
Run #2							

	Initial Weight	Final Volume
Run #1	5.2 g	10.0 ml
Run #2		

PCB List

CAS No.	Compound	Result	RL	MDL	Units	Q
12674-11-2	Aroclor 1016	ND	21	8.8	ug/kg	
11104-28-2	Aroclor 1221	ND	21	6.9	ug/kg	
11141-16-5	Aroclor 1232	ND	21	17	ug/kg	
53469-21-9	Aroclor 1242	ND	21	12	ug/kg	
12672-29-6	Aroclor 1248	ND	21	4.4	ug/kg	
11097-69-1	Aroclor 1254	ND	21	2.2	ug/kg	
11096-82-5	Aroclor 1260	ND	21	7.1	ug/kg	
11100-14-4	Aroclor 1268	ND	21	2.1	ug/kg	
37324-23-5	Aroclor 1262	ND	21	1.7	ug/kg	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
877-09-8	Tetrachloro-m-xylene	87%		42-159%
877-09-8	Tetrachloro-m-xylene	86%		42-159%
2051-24-3	Decachlorobiphenyl	96%		18-154%
2051-24-3	Decachlorobiphenyl	110%		18-154%

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID: SB-25(7.5-8)030724
Lab Sample ID: JD83927-18
Matrix: SO - Soil
Project: 100 Main Street, White Plains, NY

Date Sampled: 03/07/24
Date Received: 03/07/24
Percent Solids: 93.4

Metals Analysis

Analyte	Result	RL	Units	DF	Prep	Analyzed	By	Method	Prep Method
Aluminum	6410	54	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Antimony	< 2.1	2.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Arsenic	< 2.1	2.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Barium	51.4	21	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Beryllium	0.32	0.21	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Cadmium	< 0.54	0.54	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Calcium	11200	540	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Chromium	12.8	1.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Cobalt	< 5.4	5.4	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Copper	14.6	2.7	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Iron	12300	54	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Lead	11.1	2.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Magnesium	7480	540	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Manganese	193	1.6	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Mercury	0.035	0.030	mg/kg	1	03/13/24	03/14/24	LM	SW846 7471B [1]	SW846 7471B [4]
Nickel	10.6	4.3	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Potassium	1970	1100	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Selenium	< 2.1	2.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Silver	< 0.54	0.54	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Sodium	< 1100	1100	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Thallium	< 1.1	1.1	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Vanadium	18.4	5.4	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]
Zinc	33.6	5.4	mg/kg	1	03/08/24	03/11/24	MM	SW846 6010D [2]	SW846 3050B [3]

(1) Instrument QC Batch: MA55688
(2) Instrument QC Batch: MA55691
(3) Prep QC Batch: MP45216
(4) Prep QC Batch: MP45278

RL = Reporting Limit

Report of Analysis

Client Sample ID:	SB-25(7.5-8)030724		
Lab Sample ID:	JD83927-18	**Date Sampled:**	03/07/24
Matrix:	SO - Soil	**Date Received:**	03/07/24
		Percent Solids:	93.4
Project:	100 Main Street, White Plains, NY		

General Chemistry

Analyte	Result	RL	Units	DF	Analyzed	By	Method
Cyanide	< 0.23	0.23	mg/kg	1	03/12/24 19:56	JD	SW846 9012B/LACHAT
Solids, Percent	93.4		%	1	03/08/24 06:00	SC	SM2540 G 18TH ED MOD

RL = Reporting Limit

GC/LC Semi-volatiles

QC Data Summaries

Includes the following where applicable:

- Method Blank Summaries
- Blank Spike Summaries
- Matrix Spike and Duplicate Summaries
- Internal Standard Area Summaries
- DDT/Endrin Breakdown Checks
- GC Identification Summaries (Hits)
- Surrogate Recovery Summaries
- GC Surrogate Retention Time Summaries
- Initial and Continuing Calibration Summaries
- Run Sequence Reports



CHAIN OF CUSTODY
SGS North America Inc. - Dayton
2235 Route 139, Dayton, NJ 08810
TEL. 732-329-0200
www.sgs.com/ehsusa

Page 1 of 2

Client / Reporting Information: Company Name: SESI; Street Address: 959 US46 F135300; City: Parsippany; State: NJ; Zip: 07054; Project Contact: JonStuart; E-mail: JOS@SESI.org; Phone #: 973 8089050; Sampler(s) Name(s): Christian B; Phone #:

Project Information: Project Name: Galleria Mall; Street: 100 main street; City: White Plains; State: NY; Project #: 12461; Client Purchase Order #:; Project Manager: Jon Stuart

Billing Information (If different from Report to): Company Name: Renaissance Galleria Environmental Mgmt; Street Address:; City:; State:; Zip:; Attention: Kevin McNamus

FED-EX Tracking #:; Bottle Order Control #: Rem-KR-03524-26; SGS Quote #:; SGS Job #: JD83927

TCL +30 / TAL

Matrix Codes: DW - Drinking Water; GW - Ground Water; WW - Water; SW - Surface Water; SO - Soil; SL - Sludge; SED-Sediment; OI - Oil; LIQ - Other Liquid; AIR - Air; SOL - Other Solid; WP - Wipe; FB - Field Blank; EB-Equipment Blank; RB - Rinse Blank; TB - Trip Blank

SGS Sample #	Field ID / Point of Collection	MEOH/DI Vial #	Collection Date	Collection Time	Sampled by	Grab (G) Comp (C)	Source Chlorinated (Y/N)	Matrix	# of bottles	Number of Bottles: HCl	NaOH	HNO_3	H_2SO_4	NONE	DI Water	MEOH	ENCORE	pH Check (Lab Use Only)	LAB USE ONLY
1	SB-7 (4-4.5) 030724	•	3/7/24	1055	CB	G		SO	1								3	✓	
2	SB-7 (7-7.5) 030724			1010														✓	
3	SB-8 (4-4.5) 030724			850														✓	
4	SB-8 (7.5-8) 030724			855														✓	
5	SB-9 (3.5-4) 030724			900														✓	
6	SB-10 (3.5-4) 030724			920														✓	
7	SB-10 (7-7.5) 030724			925														✓	
8	SB-11 (3.5-4) 030724			940														✓	
9	SB-11 (8-8.5) 030724			945														✓	
10	SB-16 (3-3.5) 030724			1025														✓	
11	SB-16 (7.5-8) 030724			1030														✓	
12	SB-19 (4-4.5) 030724	•		1035														✓	

Turn Around Time (Business Days)
- [ ] 10 Business Days
- [x] 5 Business Days
- [ ] 3 Business Days*
- [ ] 2 Business Days*
- [ ] 1 Business Day*
- [ ] Other

Approved By (SGS PM) / Date:
All data available via SGS Engage
* Approval needed for 1-3 BD TAT

Deliverable
- [ ] Commercial "A" (Level 1)
- [ ] Commercial "B" (Level 2)
- [ ] NJ Reduced (Level 3)
- [ ] Full Tier I (Level 4)
- [ ] Commercial "C"
- [ ] NJ DKQP
- [ ] NYASP Category A
- [x] NYASP Category B
- [ ] MA MCP Criteria ____
- [ ] CT RCP Criteria ____
- [ ] State Forms
- [ ] EDD Format ____

Commercial "A" = Results only; Commercial "B" = Results + QC Summary; Commercial "C" = Results + QC Summary + Partial Raw data

Comments / Special Instructions: 3x 5g encore; IBEA; Initial Assessment IBEA; Label Verification ____

http://www.sgs.com/en/terms-and-conditions

Sample Custody must be documented below each time samples change possession, including courier delivery.

	Relinquished by:	Date / Time:	Received By:
1		3/7/24	Michael Gibbons
2	Michael Gibbons	3/7 1402	
3	Relinquished by:	Date / Time:	Received By: 3
4	Relinquished by:	Date / Time:	Received By: 4
5	Relinquished by:	Date / Time:	Received By: 5

Custody Seal # ____ Intact / Not Intact / Absent

Therm ID: ____ See Sample Receipt Summary

Cooler Temp: 14.1 / 14.0 / 14.0

EHSA-QAC-0023-05 Rev.Date:8/5/22

JD83927: Chain of Custody
Page 1 of 4

SGS

CHAIN OF CUSTODY

SGS North America Inc. - Dayton
2235 Route 130, Dayton, NJ 08810
TEL. 732-329-0200
www.sgs.com/ehsusa

Page 2 of 2

FED-EX Tracking #: | Bottle Order Control #:
SGS Quote #: | SGS Job #: JD83927

Client / Reporting Information

Company Name: SESI
Street Address: 959 US 46
City: Parsippany State: NJ Zip: 07054
Project Contact: E-mail:
Phone #: 9738689050
Sampler(s) Name(s): CB Phone #:

Project Information

Project Name: Galleria Mall
Street: 100 Main St
City: White Plains State: NY
Project #: 17461
Client Purchase Order #:
Project Manager: JonStuart

Billing Information (If different from Report to)

Company Name: Brandywine Env Mgmt Page 1
Street Address:
City: Page 1 State: Zip:
Attention:

TCL+TAL

Matrix Codes: DW - Drinking Water; GW - Ground Water; WW - Water; SW - Surface Water; SO - Soil; SL - Sludge; SED-Sediment; OI - Oil; LIQ - Other Liquid; AIR - Air; SOL - Other Solid; WP - Wipe; FB - Field Blank; EB-Equipment Blank; RB - Rinse Blank; TB - Trip Blank

SGS Sample #	Field ID / Point of Collection	MEOH/DI Vial #	Collection Date	Collection Time	Sampled by	Grab (G) Comp (C)	Source Chlorinated (Y/N)	Matrix	Number of Bottles # of bottles	HCl	NaOH	HNO_3	H_2SO_4	NONE	DI Water	MEOH	ENCORE	pH Check (Lab Use Only)	LAB USE ONLY
13	SB-19 (7-7.5) 030724		3/7/24	1040	CB	G		SO	1								3	✓	
14	SB-22 (3.5-4) 030724			1125														✓	
15	SB-22 (8-8.5) 030724			1130														✓	
16	SB-25 (1.5-2) 030724			1200														✓	
17	SB-25 (3-3.5) 030724			1205														✓	
18	SB-25 (7.5-8) 030724			1210														✓	

Turn Around Time (Business Days)

Approved By (SGS PM) / Date:

- [ ] 10 Business Days
- [x] 5 Business Days
- [ ] 3 Business Days*
- [ ] 2 Business Days*
- [ ] 1 Business Day*
- [ ] Other

All data available via SGS Engage

* Approval needed for 1-3 BD TAT

Deliverable

- [ ] Commercial "A" (Level 1)
- [ ] Commercial "B" (Level 2)
- [ ] NJ Reduced (Level 3)
- [ ] Full Tier I (Level 4)
- [ ] Commercial "C"
- [ ] NJ DKQP
- [ ] NYASP Category A
- [x] NYASP Category B
- [ ] MA MCP Criteria
- [ ] CT RCP Criteria
- [ ] State Forms
- [ ] EDD Format

Commercial "A" = Results only; Commercial "B" = Results + QC Summary
Commercial "C" = Results + QC Summary + Partial Raw data

Comments / Special Instructions

http://www.sgs.com/en/terms-and-conditions

Sample Custody must be documented below each time samples change possession, including courier delivery.

	Relinquished by:	Date / Time:	Received By:
1		3/7/24	1 Michael Gibbons
2			2 Michael Gibbons
3			3
4			4
5			5

Custody Seal # | Intact | Not intact | Absent

Therm ID: | On Ice | See Sample Receipt Summary

Cooler Temp. °C: 14.1 at PM

EHSA-QAC-0023-05 Rev.Date:8/5/22

JD83927: Chain of Custody
Page 2 of 4

SGS Sample Receipt Summary

Job Number: jd83927 **Client:** SESI CONSULTING ENGINEERS **Project:** 100 MAIN STREET, WHITE PLAINS, NY

Date / Time Received: 3/7/2024 2:02:00 PM **Delivery Method:** IMPLUSE **Airbill #'s:**

Cooler Temps (Raw Measured) °C: Cooler 1: (14.1);

Cooler Temps (Corrected) °C: Cooler 1: (14.4);

Cooler Security	Y	or	N		Y	or	N
1. Custody Seals Present:	☑		☐	3. COC Present:	☑		☐
2. Custody Seals Intact:	☑		☐	4. Smpl Dates/Time OK	☑		☐

Cooler Temperature	Y	or	N
1. Temp criteria achieved:	☑		☐
2. Cooler temp verification:	IR-40		
3. Cooler media:	Ice (Bag)		
4. No. Coolers:	1		

Quality Control Preservation	Y	or	N	N/A
1. Trip Blank present / cooler:	☐		☐	☑
2. Trip Blank listed on COC:	☐		☐	☑
3. Samples preserved properly:	☑		☐	
4. VOCs headspace free:	☐		☐	☐

Sample Integrity - Documentation	Y	or	N
1. Sample labels present on bottles:	☑		☐
2. Container labeling complete:	☑		☐
3. Sample container label / COC agree:	☑		☐

Sample Integrity - Condition	Y	or	N
1. Sample recvd within HT:	☑		☐
2. All containers accounted for:	☑		☐
3. Condition of sample:	Intact		

Sample Integrity - Instructions	Y	or	N	N/A
1. Analysis requested is clear:	☑		☐	
2. Bottles received for unspecified tests	☐		☑	
3. Sufficient volume recvd for analysis:	☑		☐	
4. Compositing instructions clear:	☐		☐	☑
5. Filtering instructions clear:	☐		☐	☑

Test Strip Lot #s: pH 1-12: 231619 pH 12+: 203117A Other: (Specify)

Comments: Samples were received without ice at an evelated temp of 14.1 degrees

Responded to by: Kelly Ramos

Response Date: 3/8/2024

Please proceed as noted

JD83927: Chain of Custody
Page 4 of 4

Internal Sample Tracking Chronicle

SESI Consulting Engineers

Job No: JD83927

100 Main Street, White Plains, NY
Project No: 12461

Sample Number	Method	Analyzed	By	Prepped	By	Test Codes
JD83927-1	Collected: 07-MAR-24 10:05 By: CB			Received: 07-MAR-24 By: EN		
SB-7(4-4.5)030724						
JD83927-1	SM2540 G 18TH ED MOD	08-MAR-24 06:00	SC			SOL104
JD83927-1	SW846 8260D	09-MAR-24 00:48	PS			V8260TCL20+
JD83927-1	SW846 8082A	10-MAR-24 22:44	TP	09-MAR-24	ED	P8082PCB11AO
JD83927-1	SW846 8081B	11-MAR-24 02:56	CP	09-MAR-24	ED	P8081PESTTCL
JD83927-1	SW846 8270E	11-MAR-24 13:34	JY	09-MAR-24	AC	AB8270TCL20+
JD83927-1	SW846 6010D	11-MAR-24 14:25	MM	08-MAR-24	SS	AG,AL,AS,BA,BE,CA,CD,CO,CR,CU,FE,K,MG,MN,NA,NI,PB,SB,SE,TL,V,ZN
JD83927-1	SW846 9012B/LACHAT	12-MAR-24 20:24	JD	12-MAR-24	MS	CN
JD83927-1	SW846 7471B	14-MAR-24 17:08	LM	13-MAR-24	LM	HG
JD83927-2	Collected: 07-MAR-24 10:10 By: CB			Received: 07-MAR-24 By: EN		
SB-7(7-7.5)030724						
JD83927-2	SM2540 G 18TH ED MOD	08-MAR-24 06:00	SC			SOL104
JD83927-2	SW846 8260D	09-MAR-24 02:32	PS			V8260TCL20+
JD83927-2	SW846 8082A	11-MAR-24 00:45	TP	09-MAR-24	ED	P8082PCB11AO
JD83927-2	SW846 8081B	11-MAR-24 03:19	CP	09-MAR-24	ED	P8081PESTTCL
JD83927-2	SW846 8270E	11-MAR-24 13:57	JY	09-MAR-24	AC	AB8270TCL20+
JD83927-2	SW846 6010D	11-MAR-24 14:30	MM	08-MAR-24	SS	AG,AL,AS,BA,BE,CA,CD,CO,CR,CU,FE,K,MG,MN,NA,NI,PB,SB,SE,TL,V,ZN
JD83927-2	SW846 9012B/LACHAT	12-MAR-24 20:25	JD	12-MAR-24	MS	CN
JD83927-2	SW846 7471B	14-MAR-24 17:09	LM	13-MAR-24	LM	HG
JD83927-3	Collected: 07-MAR-24 08:50 By: CB			Received: 07-MAR-24 By: EN		
SB-8(4-4.5)030724						
JD83927-3	SM2540 G 18TH ED MOD	08-MAR-24 06:00	SC			SOL104
JD83927-3	SW846 8260D	09-MAR-24 02:59	PS			V8260TCL20+
JD83927-3	SW846 8082A	11-MAR-24 01:09	TP	09-MAR-24	ED	P8082PCB11AO
JD83927-3	SW846 8081B	11-MAR-24 03:39	CP	09-MAR-24	ED	P8081PESTTCL
JD83927-3	SW846 8270E	11-MAR-24 14:20	JY	09-MAR-24	AC	AB8270TCL20+
JD83927-3	SW846 6010D	11-MAR-24 14:34	MM	08-MAR-24	SS	AG,AL,AS,BA,BE,CA,CD,CO,CR,CU,FE,K,MG,MN,NA,NI,PB,SB,SE,TL,V,ZN
JD83927-3	SW846 9012B/LACHAT	12-MAR-24 20:27	JD	12-MAR-24	MS	CN

Internal Sample Tracking Chronicle

SESI Consulting Engineers

Job No: JD83927

100 Main Street, White Plains, NY
Project No: 12461

Sample Number	Method	Analyzed	By	Prepped	By	Test Codes
JD83927-3	SW846 7471B	14-MAR-24 17:11	LM	13-MAR-24	LM	HG
JD83927-4	Collected: 07-MAR-24 08:55 By: CB		Received: 07-MAR-24 By: EN			
SB-8(7.5-8)030724						
JD83927-4	SM2540 G 18TH ED MOD	08-MAR-24 06:00	SC			SOL104
JD83927-4	SW846 8260D	09-MAR-24 03:25	PS			V8260TCL20+
JD83927-4	SW846 8082A	11-MAR-24 01:34	TP	09-MAR-24	ED	P8082PCB11AO
JD83927-4	SW846 8081B	11-MAR-24 03:58	CP	09-MAR-24	ED	P8081PESTTCL
JD83927-4	SW846 6010D	11-MAR-24 14:39	MM	08-MAR-24	SS	AG,AL,AS,BA,BE,CA,CD,CO,CR,CU,FE,K,MG,MN,NA,NI,PB,SB,SE,TL,V,ZN
JD83927-4	SW846 8270E	11-MAR-24 14:43	JY	09-MAR-24	AC	AB8270TCL20+
JD83927-4	SW846 9012B/LACHAT	12-MAR-24 20:28	JD	12-MAR-24	MS	CN
JD83927-4	SW846 7471B	14-MAR-24 17:16	LM	13-MAR-24	LM	HG
JD83927-5	Collected: 07-MAR-24 09:00 By: CB		Received: 07-MAR-24 By: EN			
SB-9(3.5-4)030724						
JD83927-5	SM2540 G 18TH ED MOD	08-MAR-24 06:00	SC			SOL104
JD83927-5	SW846 8260D	09-MAR-24 03:51	PS			V8260TCL20+
JD83927-5	SW846 8082A	10-MAR-24 22:19	TP	09-MAR-24	ED	P8082PCB11AO
JD83927-5	SW846 8081B	11-MAR-24 04:18	CP	09-MAR-24	ED	P8081PESTTCL
JD83927-5	SW846 6010D	11-MAR-24 14:44	MM	08-MAR-24	SS	AG,AL,AS,BA,BE,CA,CD,CO,CR,CU,FE,K,MG,MN,NA,NI,PB,SB,SE,TL,V,ZN
JD83927-5	SW846 8270E	11-MAR-24 15:06	JY	09-MAR-24	AC	AB8270TCL20+
JD83927-5	SW846 9012B/LACHAT	12-MAR-24 20:29	JD	12-MAR-24	MS	CN
JD83927-5	SW846 7471B	14-MAR-24 17:17	LM	13-MAR-24	LM	HG
JD83927-6	Collected: 07-MAR-24 09:20 By: CB		Received: 07-MAR-24 By: EN			
SB-10(3.5-4)030724						
JD83927-6	SM2540 G 18TH ED MOD	08-MAR-24 06:00	SC			SOL104
JD83927-6	SW846 8260D	09-MAR-24 04:17	PS			V8260TCL20+
JD83927-6	SW846 8082A	11-MAR-24 01:58	TP	09-MAR-24	ED	P8082PCB11AO
JD83927-6	SW846 8081B	11-MAR-24 04:37	CP	09-MAR-24	ED	P8081PESTTCL
JD83927-6	SW846 6010D	11-MAR-24 14:49	MM	08-MAR-24	SS	AG,AL,AS,BA,BE,CA,CD,CO,CR,CU,FE,K,MG,MN,NA,NI,PB,SB,SE,TL,V,ZN

Internal Sample Tracking Chronicle

SESI Consulting Engineers

Job No: JD83927

100 Main Street, White Plains, NY
Project No: 12461

Sample Number	Method	Analyzed	By	Prepped	By	Test Codes
JD83927-6	SW846 8270E	11-MAR-24 15:29	JY	09-MAR-24	AC	AB8270TCL20+
JD83927-6	SW846 9012B/LACHAT	12-MAR-24 20:30	JD	12-MAR-24	MS	CN
JD83927-6	SW846 7471B	14-MAR-24 17:19	LM	13-MAR-24	LM	HG
JD83927-7	Collected: 07-MAR-24 09:25 By: CB			Received: 07-MAR-24 By: EN		
SB-10(7-5.5)030724						
JD83927-7	SM2540 G 18TH ED MOD	08-MAR-24 06:00	SC			SOL104
JD83927-7	SW846 8260D	09-MAR-24 04:43	PS			V8260TCL20+
JD83927-7	SW846 8082A	11-MAR-24 02:22	TP	09-MAR-24	ED	P8082PCB11AO
JD83927-7	SW846 8081B	11-MAR-24 04:56	CP	09-MAR-24	ED	P8081PESTTCL
JD83927-7	SW846 6010D	11-MAR-24 14:54	MM	08-MAR-24	SS	AG,AL,AS,BA,BE,CA,CD,CO,CR,CU,FE,K,MG,MN,NA,NI,PB,SB,SE,TL,V,ZN
JD83927-7	SW846 8270E	11-MAR-24 15:52	JY	09-MAR-24	AC	AB8270TCL20+
JD83927-7	SW846 9012B/LACHAT	12-MAR-24 20:31	JD	12-MAR-24	MS	CN
JD83927-7	SW846 7471B	14-MAR-24 17:21	LM	13-MAR-24	LM	HG
JD83927-8	Collected: 07-MAR-24 09:40 By: CB			Received: 07-MAR-24 By: EN		
SB-11(3.5-4)030724						
JD83927-8	SM2540 G 18TH ED MOD	08-MAR-24 06:00	SC			SOL104
JD83927-8	SW846 8260D	09-MAR-24 05:09	PS			V8260TCL20+
JD83927-8	SW846 8082A	11-MAR-24 02:46	TP	09-MAR-24	ED	P8082PCB11AO
JD83927-8	SW846 8081B	11-MAR-24 05:16	CP	09-MAR-24	ED	P8081PESTTCL
JD83927-8	SW846 6010D	11-MAR-24 14:59	MM	08-MAR-24	SS	AG,AL,AS,BA,BE,CA,CD,CO,CR,CU,FE,K,MG,MN,NA,NI,PB,SB,SE,TL,V,ZN
JD83927-8	SW846 8270E	11-MAR-24 16:15	JY	09-MAR-24	AC	AB8270TCL20+
JD83927-8	SW846 9012B/LACHAT	12-MAR-24 20:32	JD	12-MAR-24	MS	CN
JD83927-8	SW846 7471B	15-MAR-24 21:47	LM	14-MAR-24	LM	HG
JD83927-9	Collected: 07-MAR-24 09:45 By: CB			Received: 07-MAR-24 By: EN		
SB-11(8-8.5)030724						
JD83927-9	SM2540 G 18TH ED MOD	08-MAR-24 06:00	SC			SOL104
JD83927-9	SW846 8260D	09-MAR-24 05:35	PS			V8260TCL20+
JD83927-9	SW846 8082A	11-MAR-24 03:11	TP	09-MAR-24	ED	P8082PCB11AO
JD83927-9	SW846 8081B	11-MAR-24 05:35	CP	09-MAR-24	ED	P8081PESTTCL
JD83927-9	SW846 8270E	11-MAR-24 16:38	JY	09-MAR-24	AC	AB8270TCL20+

Internal Sample Tracking Chronicle

SESI Consulting Engineers

Job No: JD83927

100 Main Street, White Plains, NY
Project No: 12461

Sample Number	Method	Analyzed	By	Prepped	By	Test Codes
JD83927-9	SW846 6010D	11-MAR-24 16:43	MM	08-MAR-24	SS	AG,AL,AS,BA,BE,CA,CD,CO,CR,CU,FE,K,MG,MN,NA,NI,PB,SB,SE,TL,V,ZN
JD83927-9	SW846 9012B/LACHAT	12-MAR-24 19:46	JD	12-MAR-24	MS	CN
JD83927-9	SW846 7471B	14-MAR-24 17:22	LM	13-MAR-24	LM	HG
JD83927-10	Collected: 07-MAR-24 10:25 By: CB			Received: 07-MAR-24 By: EN		
SB-16(3-3.5)030724						
JD83927-10	SM2540 G 18TH ED MOD	08-MAR-24 06:00	SC			SOL104
JD83927-10	SW846 8260D	09-MAR-24 06:01	PS			V8260TCL20+
JD83927-10	SW846 8082A	11-MAR-24 05:12	TP	09-MAR-24	ED	P8082PCB11AO
JD83927-10	SW846 8081B	11-MAR-24 05:54	CP	09-MAR-24	ED	P8081PESTTCL
JD83927-10	SW846 6010D	11-MAR-24 16:48	MM	08-MAR-24	SS	AG,AL,AS,BA,BE,CA,CD,CO,CR,CU,FE,K,MG,MN,NA,NI,PB,SB,SE,TL,V,ZN
JD83927-10	SW846 8270E	11-MAR-24 17:01	JY	09-MAR-24	AC	AB8270TCL20+
JD83927-10	SW846 9012B/LACHAT	12-MAR-24 19:47	JD	12-MAR-24	MS	CN
JD83927-10	SW846 7471B	14-MAR-24 17:24	LM	13-MAR-24	LM	HG
JD83927-11	Collected: 07-MAR-24 10:30 By: CB			Received: 07-MAR-24 By: EN		
SB-16(7.5-8)030724						
JD83927-11	SM2540 G 18TH ED MOD	08-MAR-24 06:00	SC			SOL104
JD83927-11	SW846 8260D	09-MAR-24 06:28	PS			V8260TCL20+
JD83927-11	SW846 8082A	11-MAR-24 05:36	TP	09-MAR-24	ED	P8082PCB11AO
JD83927-11	SW846 8081B	11-MAR-24 06:14	CP	09-MAR-24	ED	P8081PESTTCL
JD83927-11	SW846 6010D	11-MAR-24 16:53	MM	08-MAR-24	SS	AG,AL,AS,BA,BE,CA,CD,CO,CR,CU,FE,K,MG,MN,NA,NI,PB,SB,SE,TL,V,ZN
JD83927-11	SW846 8270E	11-MAR-24 17:24	JY	09-MAR-24	AC	AB8270TCL20+
JD83927-11	SW846 9012B/LACHAT	12-MAR-24 19:48	JD	12-MAR-24	MS	CN
JD83927-11	SW846 7471B	14-MAR-24 17:25	LM	13-MAR-24	LM	HG
JD83927-12	Collected: 07-MAR-24 10:35 By: CB			Received: 07-MAR-24 By: EN		
SB-19(4-4.5)030724						
JD83927-12	SM2540 G 18TH ED MOD	08-MAR-24 06:00	SC			SOL104
JD83927-12	SW846 8260D	09-MAR-24 06:54	PS			V8260TCL20+
JD83927-12	SW846 8082A	11-MAR-24 06:01	TP	09-MAR-24	ED	P8082PCB11AO

Internal Sample Tracking Chronicle

SESI Consulting Engineers

Job No: JD83927

100 Main Street, White Plains, NY
Project No: 12461

Sample Number	Method	Analyzed	By	Prepped	By	Test Codes
JD83927-12	SW846 8081B	11-MAR-24 06:33	CP	09-MAR-24	ED	P8081PESTTCL
JD83927-12	SW846 6010D	11-MAR-24 16:58	MM	08-MAR-24	SS	AG,AL,AS,BA,BE,CA,CD,CO,CR,CU,FE,K,MG,MN,NA,NI,PB,SB,SE,TL,V,ZN
JD83927-12	SW846 8270E	11-MAR-24 17:47	JY	09-MAR-24	AC	AB8270TCL20+
JD83927-12	SW846 9012B/LACHAT	12-MAR-24 19:49	JD	12-MAR-24	MS	CN
JD83927-12	SW846 7471B	14-MAR-24 17:27	LM	13-MAR-24	LM	HG
JD83927-13	Collected: 07-MAR-24 10:40 By: CB			Received: 07-MAR-24 By: EN		
SB-19(7-7.5)030724						
JD83927-13	SM2540 G 18TH ED MOD	08-MAR-24 06:00	SC			SOL104
JD83927-13	SW846 8260D	09-MAR-24 07:19	PS			V8260TCL20+
JD83927-13	SW846 8082A	11-MAR-24 06:25	TP	09-MAR-24	ED	P8082PCB11AO
JD83927-13	SW846 8081B	11-MAR-24 06:52	CP	09-MAR-24	ED	P8081PESTTCL
JD83927-13	SW846 6010D	11-MAR-24 17:03	MM	08-MAR-24	SS	AG,AL,AS,BA,BE,CA,CD,CO,CR,CU,FE,K,MG,MN,NA,NI,PB,SB,SE,TL,V,ZN
JD83927-13	SW846 8270E	11-MAR-24 18:11	JY	09-MAR-24	AC	AB8270TCL20+
JD83927-13	SW846 9012B/LACHAT	12-MAR-24 19:50	JD	12-MAR-24	MS	CN
JD83927-13	SW846 7471B	14-MAR-24 17:31	LM	13-MAR-24	LM	HG
JD83927-14	Collected: 07-MAR-24 11:25 By: CB			Received: 07-MAR-24 By: EN		
SB-22(3.5-4)030724						
JD83927-14	SM2540 G 18TH ED MOD	08-MAR-24 06:00	SC			SOL104
JD83927-14	SW846 8260D	08-MAR-24 20:40	PS			V8260TCL20+
JD83927-14	SW846 8082A	11-MAR-24 06:49	TP	09-MAR-24	ED	P8082PCB11AO
JD83927-14	SW846 8081B	11-MAR-24 07:12	CP	09-MAR-24	ED	P8081PESTTCL
JD83927-14	SW846 6010D	11-MAR-24 17:08	MM	08-MAR-24	SS	AG,AL,AS,BA,BE,CA,CD,CO,CR,CU,FE,K,MG,MN,NA,NI,PB,SB,SE,TL,V,ZN
JD83927-14	SW846 8270E	11-MAR-24 20:31	JY	09-MAR-24	AC	AB8270TCL20+
JD83927-14	SW846 9012B/LACHAT	12-MAR-24 19:51	JD	12-MAR-24	MS	CN
JD83927-14	SW846 7471B	14-MAR-24 17:33	LM	13-MAR-24	LM	HG
JD83927-15	Collected: 07-MAR-24 11:30 By: CB			Received: 07-MAR-24 By: EN		
SB-22(8-8.5)030724						
JD83927-15	SM2540 G 18TH ED MOD	08-MAR-24 06:00	SC			SOL104

Internal Sample Tracking Chronicle

SESI Consulting Engineers

Job No: JD83927

100 Main Street, White Plains, NY
Project No: 12461

Sample Number	Method	Analyzed	By	Prepped	By	Test Codes
JD83927-15	SW846 8260D	08-MAR-24 21:01	PS			V8260TCL20+
JD83927-15	SW846 8082A	11-MAR-24 07:13	TP	09-MAR-24	ED	P8082PCB11AO
JD83927-15	SW846 8081B	11-MAR-24 07:31	CP	09-MAR-24	ED	P8081PESTTCL
JD83927-15	SW846 6010D	11-MAR-24 17:12	MM	08-MAR-24	SS	AG,AL,AS,BA,BE,CA,CD,CO,CR,CU,FE,K,MG,MN,NA,NI,PB,SB,SE,TL,V,ZN
JD83927-15	SW846 8270E	11-MAR-24 18:34	JY	09-MAR-24	AC	AB8270TCL20+
JD83927-15	SW846 9012B/LACHAT	12-MAR-24 19:52	JD	12-MAR-24	MS	CN
JD83927-15	SW846 7471B	14-MAR-24 17:34	LM	13-MAR-24	LM	HG
JD83927-16	Collected: 07-MAR-24 12:00 By: CB			Received: 07-MAR-24 By: EN		
SB-25(1.5-2)030724						
JD83927-16	SM2540 G 18TH ED MOD	08-MAR-24 06:00	SC			SOL104
JD83927-16	SW846 8260D	08-MAR-24 21:23	PS			V8260TCL20+
JD83927-16	SW846 8081B	11-MAR-24 03:33	CP	09-MAR-24	ED	P8081PESTTCL
JD83927-16	SW846 8082A	11-MAR-24 07:38	TP	09-MAR-24	ED	P8082PCB11AO
JD83927-16	SW846 6010D	11-MAR-24 17:17	MM	08-MAR-24	SS	AG,AL,AS,BA,BE,CA,CD,CO,CR,CU,FE,K,MG,MN,NA,NI,PB,SB,SE,TL,V,ZN
JD83927-16	SW846 8270E	11-MAR-24 20:54	JY	09-MAR-24	AC	AB8270TCL20+
JD83927-16	SW846 8270E	12-MAR-24 09:49	KM	09-MAR-24	AC	AB8270TCL20+
JD83927-16	SW846 9012B/LACHAT	12-MAR-24 19:54	JD	12-MAR-24	MS	CN
JD83927-16	SW846 7471B	14-MAR-24 17:36	LM	13-MAR-24	LM	HG
JD83927-17	Collected: 07-MAR-24 12:05 By: CB			Received: 07-MAR-24 By: EN		
SB-25(3-3.5)030724						
JD83927-17	SM2540 G 18TH ED MOD	08-MAR-24 06:00	SC			SOL104
JD83927-17	SW846 8260D	08-MAR-24 21:45	PS			V8260TCL20+
JD83927-17	SW846 8081B	11-MAR-24 03:55	CP	09-MAR-24	ED	P8081PESTTCL
JD83927-17	SW846 8082A	11-MAR-24 09:40	TP	09-MAR-24	ED	P8082PCB11AO
JD83927-17	SW846 6010D	11-MAR-24 17:22	MM	08-MAR-24	SS	AG,AL,AS,BA,BE,CA,CD,CO,CR,CU,FE,K,MG,MN,NA,NI,PB,SB,SE,TL,V,ZN
JD83927-17	SW846 8270E	11-MAR-24 18:58	JY	09-MAR-24	AC	AB8270TCL20+
JD83927-17	SW846 9012B/LACHAT	12-MAR-24 19:55	JD	12-MAR-24	MS	CN
JD83927-17	SW846 7471B	14-MAR-24 17:37	LM	13-MAR-24	LM	HG

Internal Sample Tracking Chronicle

SESI Consulting Engineers

Job No: JD83927

100 Main Street, White Plains, NY
Project No: 12461

Sample Number	Method	Analyzed	By	Prepped	By	Test Codes
JD83927-18	Collected: 07-MAR-24 12:10 By: CB SB-25(7.5-8)030724		Received: 07-MAR-24 By: EN			
JD83927-18	SM2540 G 18TH ED MOD	08-MAR-24 06:00	SC			SOL104
JD83927-18	SW846 8260D	08-MAR-24 22:07	PS			V8260TCL20+
JD83927-18	SW846 8081B	11-MAR-24 04:16	CP	09-MAR-24	ED	P8081PESTTCL
JD83927-18	SW846 8082A	11-MAR-24 10:04	TP	09-MAR-24	ED	P8082PCB11AO
JD83927-18	SW846 6010D	11-MAR-24 17:27	MM	08-MAR-24	SS	AG,AL,AS,BA,BE,CA,CD,CO,CR,CU,FE,K,MG,MN,NA,NI,PB,SB,SE,TL,V,ZN
JD83927-18	SW846 8270E	11-MAR-24 19:21	JY	09-MAR-24	AC	AB8270TCL20+
JD83927-18	SW846 9012B/LACHAT	12-MAR-24 19:56	JD	12-MAR-24	MS	CN
JD83927-18	SW846 7471B	14-MAR-24 17:39	LM	13-MAR-24	LM	HG

SGS Internal Chain of Custody

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY
Received: 03/07/24

Sample.Bottle Number	Transfer FROM	Transfer TO	Date/Time	Reason
JD83927-1.1	Joshua Reitan	Secured Storage	03/07/24 22:03	Return to Storage
JD83927-1.1	Secured Storage	Todd Shoemaker	03/08/24 10:35	Retrieve from Storage
JD83927-1.1	Todd Shoemaker	Secured Staging Area	03/08/24 10:36	Return to Storage
JD83927-1.1	Secured Staging Area	Jayna Patel	03/08/24 15:43	Retrieve from Storage
JD83927-1.1	Jayna Patel	Secured Storage	03/08/24 15:43	Return to Storage
JD83927-1.1	Secured Storage	Taylor Gorman	03/08/24 21:54	Retrieve from Storage
JD83927-1.1	Taylor Gorman	Secured Storage	03/10/24 07:16	Return to Storage
JD83927-1.1	Secured Storage	Todd Shoemaker	03/12/24 11:10	Retrieve from Storage
JD83927-1.1	Todd Shoemaker	Secured Staging Area	03/12/24 11:10	Return to Storage
JD83927-1.1	Secured Staging Area	Melissa Saenz	03/12/24 17:08	Retrieve from Storage
JD83927-1.1	Melissa Saenz	Secured Storage	03/12/24 18:32	Return to Storage
JD83927-1.1	Secured Storage	Dave Hunkele	03/13/24 06:51	Retrieve from Storage
JD83927-1.1	Dave Hunkele	Secured Storage	03/13/24 06:52	Return to Storage
JD83927-1.1	Secured Storage	Dave Hunkele	03/13/24 09:26	Retrieve from Storage
JD83927-1.1	Dave Hunkele	Secured Staging Area	03/13/24 09:26	Return to Storage
JD83927-1.1	Secured Staging Area	Christopher Bruning	03/13/24 11:18	Retrieve from Storage
JD83927-1.1	Christopher Bruning	Secured Storage	03/13/24 19:02	Return to Storage
JD83927-1.1.1	Taylor Gorman	Organics Prep	03/08/24 22:22	Extract from JD83927-1.1
JD83927-1.1.1	Organics Prep	Alejandra Cruz	03/10/24 14:37	Extract from JD83927-1.1
JD83927-1.1.1	Alejandra Cruz	Extract Storage	03/10/24 14:37	Return to Storage
JD83927-1.1.2	Taylor Gorman	Organics Prep	03/08/24 22:57	Extract from JD83927-1.1
JD83927-1.1.2	Organics Prep	Ellen Dondeo	03/09/24 17:56	Extract from JD83927-1.1
JD83927-1.1.2	Ellen Dondeo	Extract Storage	03/09/24 17:56	Return to Storage
JD83927-1.1.2	Extract Storage	Christine Phillips	03/11/24 03:44	Retrieve from Storage
JD83927-1.1.2	Christine Phillips	GC4G	03/11/24 03:44	Load on Instrument
JD83927-1.1.3	Taylor Gorman	Organics Prep	03/08/24 22:57	Extract from JD83927-1.1
JD83927-1.1.3	Organics Prep	Ellen Dondeo	03/09/24 17:56	Extract from JD83927-1.1
JD83927-1.1.3	Ellen Dondeo	Extract Storage	03/09/24 17:56	Return to Storage
JD83927-1.2	Secured Storage	Jayna Patel	03/08/24 08:24	Retrieve from Storage
JD83927-1.2	Jayna Patel		03/08/24 08:25	Depleted
JD83927-1.3	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-1.3	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-1.4	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-1.4	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-1.4	Secured Storage	Prashant Shukla	03/08/24 17:09	Retrieve from Storage
JD83927-1.4	Prashant Shukla	GCMS1C	03/08/24 17:10	Load on Instrument
JD83927-1.4	GCMS1C	Prashant Shukla	03/09/24 11:21	Unload from Instrument
JD83927-1.4	Prashant Shukla		03/09/24 11:22	Depleted

SGS Internal Chain of Custody

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY
Received: 03/07/24

Sample.Bottle Number	Transfer FROM	Transfer TO	Date/Time	Reason
JD83927-1.5	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-1.5	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-2.1	Joshua Reitan	Secured Storage	03/07/24 22:03	Return to Storage
JD83927-2.1	Secured Storage	Todd Shoemaker	03/08/24 10:35	Retrieve from Storage
JD83927-2.1	Todd Shoemaker	Secured Staging Area	03/08/24 10:36	Return to Storage
JD83927-2.1	Secured Staging Area	Melissa Saenz	03/08/24 17:28	Retrieve from Storage
JD83927-2.1	Melissa Saenz	Secured Storage	03/08/24 17:38	Return to Storage
JD83927-2.1	Secured Storage	Taylor Gorman	03/08/24 21:54	Retrieve from Storage
JD83927-2.1	Taylor Gorman	Secured Storage	03/10/24 07:16	Return to Storage
JD83927-2.1	Secured Storage	Todd Shoemaker	03/12/24 11:10	Retrieve from Storage
JD83927-2.1	Todd Shoemaker	Secured Staging Area	03/12/24 11:10	Return to Storage
JD83927-2.1	Secured Staging Area	Melissa Saenz	03/12/24 17:08	Retrieve from Storage
JD83927-2.1	Melissa Saenz	Secured Storage	03/12/24 18:32	Return to Storage
JD83927-2.1	Secured Storage	Dave Hunkele	03/13/24 06:51	Retrieve from Storage
JD83927-2.1	Dave Hunkele	Secured Storage	03/13/24 06:52	Return to Storage
JD83927-2.1	Secured Storage	Dave Hunkele	03/13/24 09:26	Retrieve from Storage
JD83927-2.1	Dave Hunkele	Secured Staging Area	03/13/24 09:26	Return to Storage
JD83927-2.1	Secured Staging Area	Christopher Bruning	03/13/24 11:18	Retrieve from Storage
JD83927-2.1	Christopher Bruning	Secured Storage	03/13/24 19:02	Return to Storage
JD83927-2.1.1	Taylor Gorman	Organics Prep	03/08/24 22:22	Extract from JD83927-2.1
JD83927-2.1.1	Organics Prep	Alejandra Cruz	03/10/24 14:37	Extract from JD83927-2.1
JD83927-2.1.1	Alejandra Cruz	Extract Storage	03/10/24 14:37	Return to Storage
JD83927-2.1.2	Taylor Gorman	Organics Prep	03/08/24 22:57	Extract from JD83927-2.1
JD83927-2.1.2	Ellen Dondeo	Extract Storage	03/09/24 17:56	Return to Storage
JD83927-2.1.2	Organics Prep	Ellen Dondeo	03/09/24 17:56	Extract from JD83927-2.1
JD83927-2.1.2	Extract Storage	Christine Phillips	03/11/24 03:44	Retrieve from Storage
JD83927-2.1.2	Christine Phillips	GC4G	03/11/24 03:44	Load on Instrument
JD83927-2.1.3	Taylor Gorman	Organics Prep	03/08/24 22:57	Extract from JD83927-2.1
JD83927-2.1.3	Organics Prep	Ellen Dondeo	03/09/24 17:56	Extract from JD83927-2.1
JD83927-2.1.3	Ellen Dondeo	Extract Storage	03/09/24 17:56	Return to Storage
JD83927-2.2	Secured Storage	Jayna Patel	03/08/24 08:24	Retrieve from Storage
JD83927-2.2	Jayna Patel		03/08/24 08:25	Depleted
JD83927-2.3	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-2.3	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-2.4	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-2.4	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage

SGS Internal Chain of Custody

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY
Received: 03/07/24

Sample.Bottle Number	Transfer FROM	Transfer TO	Date/Time	Reason
JD83927-2.4	Secured Storage	Prashant Shukla	03/08/24 17:09	Retrieve from Storage
JD83927-2.4	Prashant Shukla	GCMS1C	03/08/24 17:10	Load on Instrument
JD83927-2.4	GCMS1C	Prashant Shukla	03/09/24 11:21	Unload from Instrument
JD83927-2.4	Prashant Shukla		03/09/24 11:22	Depleted
JD83927-2.5	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-2.5	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-3.1	Joshua Reitan	Secured Storage	03/07/24 22:03	Return to Storage
JD83927-3.1	Secured Storage	Todd Shoemaker	03/08/24 10:35	Retrieve from Storage
JD83927-3.1	Todd Shoemaker	Secured Staging Area	03/08/24 10:36	Return to Storage
JD83927-3.1	Secured Staging Area	Melissa Saenz	03/08/24 17:28	Retrieve from Storage
JD83927-3.1	Melissa Saenz	Secured Storage	03/08/24 17:38	Return to Storage
JD83927-3.1	Secured Storage	Taylor Gorman	03/08/24 21:54	Retrieve from Storage
JD83927-3.1	Taylor Gorman	Secured Storage	03/10/24 07:16	Return to Storage
JD83927-3.1	Secured Storage	Todd Shoemaker	03/12/24 11:10	Retrieve from Storage
JD83927-3.1	Todd Shoemaker	Secured Staging Area	03/12/24 11:10	Return to Storage
JD83927-3.1	Secured Staging Area	Melissa Saenz	03/12/24 17:08	Retrieve from Storage
JD83927-3.1	Melissa Saenz	Secured Storage	03/12/24 18:32	Return to Storage
JD83927-3.1	Secured Storage	Dave Hunkele	03/13/24 06:51	Retrieve from Storage
JD83927-3.1	Dave Hunkele	Secured Storage	03/13/24 06:52	Return to Storage
JD83927-3.1	Secured Storage	Dave Hunkele	03/13/24 09:26	Retrieve from Storage
JD83927-3.1	Dave Hunkele	Secured Staging Area	03/13/24 09:26	Return to Storage
JD83927-3.1	Secured Staging Area	Christopher Bruning	03/13/24 11:18	Retrieve from Storage
JD83927-3.1	Christopher Bruning	Secured Storage	03/13/24 19:02	Return to Storage
JD83927-3.1.1	Taylor Gorman	Organics Prep	03/08/24 22:22	Extract from JD83927-3.1
JD83927-3.1.1	Organics Prep	Alejandra Cruz	03/10/24 14:37	Extract from JD83927-3.1
JD83927-3.1.1	Alejandra Cruz	Extract Storage	03/10/24 14:37	Return to Storage
JD83927-3.1.2	Taylor Gorman	Organics Prep	03/08/24 22:57	Extract from JD83927-3.1
JD83927-3.1.2	Ellen Dondeo	Extract Storage	03/09/24 17:56	Return to Storage
JD83927-3.1.2	Organics Prep	Ellen Dondeo	03/09/24 17:56	Extract from JD83927-3.1
JD83927-3.1.2	Extract Storage	Christine Phillips	03/11/24 03:44	Retrieve from Storage
JD83927-3.1.2	Christine Phillips	GC4G	03/11/24 03:44	Load on Instrument
JD83927-3.1.3	Taylor Gorman	Organics Prep	03/08/24 22:57	Extract from JD83927-3.1
JD83927-3.1.3	Organics Prep	Ellen Dondeo	03/09/24 17:56	Extract from JD83927-3.1
JD83927-3.1.3	Ellen Dondeo	Extract Storage	03/09/24 17:56	Return to Storage
JD83927-3.2	Secured Storage	Jayna Patel	03/08/24 08:24	Retrieve from Storage
JD83927-3.2	Jayna Patel		03/08/24 08:25	Depleted
JD83927-3.3	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage

SGS Internal Chain of Custody

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY
Received: 03/07/24

Sample.Bottle Number	Transfer FROM	Transfer TO	Date/Time	Reason
JD83927-3.3	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-3.4	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-3.4	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-3.4	Secured Storage	Prashant Shukla	03/08/24 17:09	Retrieve from Storage
JD83927-3.4	Prashant Shukla	GCMS1C	03/08/24 17:10	Load on Instrument
JD83927-3.4	GCMS1C	Prashant Shukla	03/09/24 11:21	Unload from Instrument
JD83927-3.4	Prashant Shukla		03/09/24 11:22	Depleted
JD83927-3.5	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-3.5	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-4.1	Joshua Reitan	Secured Storage	03/07/24 22:03	Return to Storage
JD83927-4.1	Secured Storage	Todd Shoemaker	03/08/24 10:35	Retrieve from Storage
JD83927-4.1	Todd Shoemaker	Secured Staging Area	03/08/24 10:36	Return to Storage
JD83927-4.1	Secured Staging Area	Melissa Saenz	03/08/24 17:28	Retrieve from Storage
JD83927-4.1	Melissa Saenz	Secured Storage	03/08/24 17:38	Return to Storage
JD83927-4.1	Secured Storage	Taylor Gorman	03/08/24 21:54	Retrieve from Storage
JD83927-4.1	Taylor Gorman	Secured Storage	03/10/24 07:16	Return to Storage
JD83927-4.1	Secured Storage	Todd Shoemaker	03/12/24 11:10	Retrieve from Storage
JD83927-4.1	Todd Shoemaker	Secured Staging Area	03/12/24 11:10	Return to Storage
JD83927-4.1	Secured Staging Area	Melissa Saenz	03/12/24 17:08	Retrieve from Storage
JD83927-4.1	Melissa Saenz	Secured Storage	03/12/24 18:32	Return to Storage
JD83927-4.1	Secured Storage	Dave Hunkele	03/13/24 06:51	Retrieve from Storage
JD83927-4.1	Dave Hunkele	Secured Storage	03/13/24 06:52	Return to Storage
JD83927-4.1	Secured Storage	Dave Hunkele	03/13/24 09:26	Retrieve from Storage
JD83927-4.1	Dave Hunkele	Secured Staging Area	03/13/24 09:26	Return to Storage
JD83927-4.1	Secured Staging Area	Christopher Bruning	03/13/24 11:18	Retrieve from Storage
JD83927-4.1	Christopher Bruning	Secured Storage	03/13/24 19:02	Return to Storage
JD83927-4.1.1	Taylor Gorman	Organics Prep	03/08/24 22:22	Extract from JD83927-4.1
JD83927-4.1.1	Organics Prep	Alejandra Cruz	03/10/24 14:37	Extract from JD83927-4.1
JD83927-4.1.1	Alejandra Cruz	Extract Storage	03/10/24 14:37	Return to Storage
JD83927-4.1.2	Taylor Gorman	Organics Prep	03/08/24 22:57	Extract from JD83927-4.1
JD83927-4.1.2	Ellen Dondeo	Extract Storage	03/09/24 17:56	Return to Storage
JD83927-4.1.2	Organics Prep	Ellen Dondeo	03/09/24 17:56	Extract from JD83927-4.1
JD83927-4.1.2	Extract Storage	Christine Phillips	03/11/24 03:44	Retrieve from Storage
JD83927-4.1.2	Christine Phillips	GC4G	03/11/24 03:44	Load on Instrument
JD83927-4.1.3	Taylor Gorman	Organics Prep	03/08/24 22:57	Extract from JD83927-4.1
JD83927-4.1.3	Organics Prep	Ellen Dondeo	03/09/24 17:56	Extract from JD83927-4.1
JD83927-4.1.3	Ellen Dondeo	Extract Storage	03/09/24 17:56	Return to Storage

SGS Internal Chain of Custody

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY
Received: 03/07/24

Sample.Bottle Number	Transfer FROM	Transfer TO	Date/Time	Reason
JD83927-4.2	Secured Storage	Jayna Patel	03/08/24 08:24	Retrieve from Storage
JD83927-4.2	Jayna Patel		03/08/24 08:25	Depleted
JD83927-4.3	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-4.3	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-4.4	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-4.4	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-4.4	Secured Storage	Prashant Shukla	03/08/24 17:09	Retrieve from Storage
JD83927-4.4	Prashant Shukla	GCMS1C	03/08/24 17:10	Load on Instrument
JD83927-4.4	GCMS1C	Prashant Shukla	03/09/24 11:21	Unload from Instrument
JD83927-4.4	Prashant Shukla		03/09/24 11:22	Depleted
JD83927-4.5	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-4.5	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-5.1	Joshua Reitan	Secured Storage	03/07/24 22:03	Return to Storage
JD83927-5.1	Secured Storage	Todd Shoemaker	03/08/24 10:35	Retrieve from Storage
JD83927-5.1	Todd Shoemaker	Secured Staging Area	03/08/24 10:36	Return to Storage
JD83927-5.1	Secured Staging Area	Melissa Saenz	03/08/24 17:28	Retrieve from Storage
JD83927-5.1	Melissa Saenz	Secured Storage	03/08/24 17:38	Return to Storage
JD83927-5.1	Secured Storage	Taylor Gorman	03/08/24 21:54	Retrieve from Storage
JD83927-5.1	Taylor Gorman	Secured Storage	03/10/24 07:16	Return to Storage
JD83927-5.1	Secured Storage	Todd Shoemaker	03/12/24 11:10	Retrieve from Storage
JD83927-5.1	Todd Shoemaker	Secured Staging Area	03/12/24 11:10	Return to Storage
JD83927-5.1	Secured Staging Area	Melissa Saenz	03/12/24 17:08	Retrieve from Storage
JD83927-5.1	Melissa Saenz	Secured Storage	03/12/24 18:32	Return to Storage
JD83927-5.1	Secured Storage	Dave Hunkele	03/13/24 06:51	Retrieve from Storage
JD83927-5.1	Dave Hunkele	Secured Storage	03/13/24 06:52	Return to Storage
JD83927-5.1	Secured Storage	Dave Hunkele	03/13/24 09:26	Retrieve from Storage
JD83927-5.1	Dave Hunkele	Secured Staging Area	03/13/24 09:26	Return to Storage
JD83927-5.1	Secured Staging Area	Christopher Bruning	03/13/24 11:18	Retrieve from Storage
JD83927-5.1	Christopher Bruning	Secured Storage	03/13/24 19:02	Return to Storage
JD83927-5.1.1	Taylor Gorman	Organics Prep	03/08/24 22:22	Extract from JD83927-5.1
JD83927-5.1.1	Organics Prep	Alejandra Cruz	03/10/24 14:37	Extract from JD83927-5.1
JD83927-5.1.1	Alejandra Cruz	Extract Storage	03/10/24 14:37	Return to Storage
JD83927-5.1.2	Taylor Gorman	Organics Prep	03/08/24 22:57	Extract from JD83927-5.1
JD83927-5.1.2	Ellen Dondeo	Extract Storage	03/09/24 17:56	Return to Storage
JD83927-5.1.2	Organics Prep	Ellen Dondeo	03/09/24 17:56	Extract from JD83927-5.1
JD83927-5.1.2	Extract Storage	Christine Phillips	03/11/24 03:44	Retrieve from Storage
JD83927-5.1.2	Christine Phillips	GC4G	03/11/24 03:44	Load on Instrument

SGS Internal Chain of Custody

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY
Received: 03/07/24

Sample.Bottle Number	Transfer FROM	Transfer TO	Date/Time	Reason
JD83927-5.1.3	Taylor Gorman	Organics Prep	03/08/24 22:57	Extract from JD83927-5.1
JD83927-5.1.3	Organics Prep	Ellen Dondeo	03/09/24 17:56	Extract from JD83927-5.1
JD83927-5.1.3	Ellen Dondeo	Extract Storage	03/09/24 17:56	Return to Storage
JD83927-5.2	Secured Storage	Jayna Patel	03/08/24 08:24	Retrieve from Storage
JD83927-5.2	Jayna Patel		03/08/24 08:25	Depleted
JD83927-5.3	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-5.3	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-5.4	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-5.4	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-5.4	Secured Storage	Prashant Shukla	03/08/24 17:09	Retrieve from Storage
JD83927-5.4	Prashant Shukla	GCMS1C	03/08/24 17:10	Load on Instrument
JD83927-5.4	GCMS1C	Prashant Shukla	03/09/24 11:21	Unload from Instrument
JD83927-5.4	Prashant Shukla		03/09/24 11:22	Depleted
JD83927-5.5	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-5.5	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-6.1	Joshua Reitan	Secured Storage	03/07/24 22:03	Return to Storage
JD83927-6.1	Secured Storage	Todd Shoemaker	03/08/24 10:35	Retrieve from Storage
JD83927-6.1	Todd Shoemaker	Secured Staging Area	03/08/24 10:36	Return to Storage
JD83927-6.1	Secured Staging Area	Melissa Saenz	03/08/24 17:28	Retrieve from Storage
JD83927-6.1	Melissa Saenz	Secured Storage	03/08/24 17:38	Return to Storage
JD83927-6.1	Secured Storage	Taylor Gorman	03/08/24 21:54	Retrieve from Storage
JD83927-6.1	Taylor Gorman	Secured Storage	03/10/24 07:16	Return to Storage
JD83927-6.1	Secured Storage	Todd Shoemaker	03/12/24 11:10	Retrieve from Storage
JD83927-6.1	Todd Shoemaker	Secured Staging Area	03/12/24 11:10	Return to Storage
JD83927-6.1	Secured Staging Area	Melissa Saenz	03/12/24 17:08	Retrieve from Storage
JD83927-6.1	Melissa Saenz	Secured Storage	03/12/24 18:32	Return to Storage
JD83927-6.1	Secured Storage	Dave Hunkele	03/13/24 06:51	Retrieve from Storage
JD83927-6.1	Dave Hunkele	Secured Storage	03/13/24 06:52	Return to Storage
JD83927-6.1	Secured Storage	Dave Hunkele	03/13/24 09:26	Retrieve from Storage
JD83927-6.1	Dave Hunkele	Secured Staging Area	03/13/24 09:26	Return to Storage
JD83927-6.1	Secured Staging Area	Christopher Bruning	03/13/24 11:18	Retrieve from Storage
JD83927-6.1	Christopher Bruning	Secured Storage	03/13/24 19:02	Return to Storage
JD83927-6.1.1	Taylor Gorman	Organics Prep	03/08/24 22:22	Extract from JD83927-6.1
JD83927-6.1.1	Organics Prep	Alejandra Cruz	03/10/24 14:37	Extract from JD83927-6.1
JD83927-6.1.1	Alejandra Cruz	Extract Storage	03/10/24 14:37	Return to Storage
JD83927-6.1.2	Taylor Gorman	Organics Prep	03/08/24 22:57	Extract from JD83927-6.1
JD83927-6.1.2	Ellen Dondeo	Extract Storage	03/09/24 17:56	Return to Storage

SGS Internal Chain of Custody

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY
Received: 03/07/24

Sample.Bottle Number	Transfer FROM	Transfer TO	Date/Time	Reason
JD83927-6.1.2	Organics Prep	Ellen Dondeo	03/09/24 17:56	Extract from JD83927-6.1
JD83927-6.1.2	Extract Storage	Christine Phillips	03/11/24 03:44	Retrieve from Storage
JD83927-6.1.2	Christine Phillips	GC4G	03/11/24 03:44	Load on Instrument
JD83927-6.1.3	Taylor Gorman	Organics Prep	03/08/24 22:57	Extract from JD83927-6.1
JD83927-6.1.3	Organics Prep	Ellen Dondeo	03/09/24 17:56	Extract from JD83927-6.1
JD83927-6.1.3	Ellen Dondeo	Extract Storage	03/09/24 17:56	Return to Storage
JD83927-6.2	Secured Storage	Jayna Patel	03/08/24 08:24	Retrieve from Storage
JD83927-6.2	Jayna Patel		03/08/24 08:25	Depleted
JD83927-6.3	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-6.3	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-6.4	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-6.4	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-6.4	Secured Storage	Prashant Shukla	03/08/24 17:09	Retrieve from Storage
JD83927-6.4	Prashant Shukla	GCMS1C	03/08/24 17:10	Load on Instrument
JD83927-6.4	GCMS1C	Prashant Shukla	03/09/24 11:21	Unload from Instrument
JD83927-6.4	Prashant Shukla		03/09/24 11:22	Depleted
JD83927-6.5	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-6.5	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-7.1	Joshua Reitan	Secured Storage	03/07/24 22:03	Return to Storage
JD83927-7.1	Secured Storage	Todd Shoemaker	03/08/24 10:35	Retrieve from Storage
JD83927-7.1	Todd Shoemaker	Secured Staging Area	03/08/24 10:36	Return to Storage
JD83927-7.1	Secured Staging Area	Melissa Saenz	03/08/24 17:28	Retrieve from Storage
JD83927-7.1	Melissa Saenz	Secured Storage	03/08/24 17:38	Return to Storage
JD83927-7.1	Secured Storage	Taylor Gorman	03/08/24 21:54	Retrieve from Storage
JD83927-7.1	Taylor Gorman	Secured Storage	03/10/24 07:16	Return to Storage
JD83927-7.1	Secured Storage	Todd Shoemaker	03/12/24 11:10	Retrieve from Storage
JD83927-7.1	Todd Shoemaker	Secured Staging Area	03/12/24 11:10	Return to Storage
JD83927-7.1	Secured Staging Area	Melissa Saenz	03/12/24 17:08	Retrieve from Storage
JD83927-7.1	Melissa Saenz	Secured Storage	03/12/24 18:32	Return to Storage
JD83927-7.1	Secured Storage	Dave Hunkele	03/13/24 06:51	Retrieve from Storage
JD83927-7.1	Dave Hunkele	Secured Storage	03/13/24 06:52	Return to Storage
JD83927-7.1	Secured Storage	Dave Hunkele	03/13/24 09:26	Retrieve from Storage
JD83927-7.1	Dave Hunkele	Secured Staging Area	03/13/24 09:26	Return to Storage
JD83927-7.1	Secured Staging Area	Christopher Bruning	03/13/24 11:18	Retrieve from Storage
JD83927-7.1	Christopher Bruning	Secured Storage	03/13/24 19:02	Return to Storage
JD83927-7.1.1	Taylor Gorman	Organics Prep	03/08/24 22:22	Extract from JD83927-7.1
JD83927-7.1.1	Organics Prep	Alejandra Cruz	03/10/24 14:37	Extract from JD83927-7.1

SGS Internal Chain of Custody

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY
Received: 03/07/24

Sample.Bottle Number	Transfer FROM	Transfer TO	Date/Time	Reason
JD83927-7.1.1	Alejandra Cruz	Extract Storage	03/10/24 14:37	Return to Storage
JD83927-7.1.2	Taylor Gorman	Organics Prep	03/08/24 22:57	Extract from JD83927-7.1
JD83927-7.1.2	Ellen Dondeo	Extract Storage	03/09/24 17:56	Return to Storage
JD83927-7.1.2	Organics Prep	Ellen Dondeo	03/09/24 17:56	Extract from JD83927-7.1
JD83927-7.1.2	Extract Storage	Christine Phillips	03/11/24 03:44	Retrieve from Storage
JD83927-7.1.2	Christine Phillips	GC4G	03/11/24 03:44	Load on Instrument
JD83927-7.1.3	Taylor Gorman	Organics Prep	03/08/24 22:57	Extract from JD83927-7.1
JD83927-7.1.3	Organics Prep	Ellen Dondeo	03/09/24 17:56	Extract from JD83927-7.1
JD83927-7.1.3	Ellen Dondeo	Extract Storage	03/09/24 17:56	Return to Storage
JD83927-7.2	Secured Storage	Jayna Patel	03/08/24 08:24	Retrieve from Storage
JD83927-7.2	Jayna Patel		03/08/24 08:25	Depleted
JD83927-7.3	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-7.3	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-7.4	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-7.4	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-7.4	Secured Storage	Prashant Shukla	03/08/24 17:09	Retrieve from Storage
JD83927-7.4	Prashant Shukla	GCMS1C	03/08/24 17:10	Load on Instrument
JD83927-7.4	GCMS1C	Prashant Shukla	03/09/24 11:21	Unload from Instrument
JD83927-7.4	Prashant Shukla		03/09/24 11:22	Depleted
JD83927-7.5	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-7.5	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-8.1	Joshua Reitan	Secured Storage	03/07/24 22:03	Return to Storage
JD83927-8.1	Secured Storage	Todd Shoemaker	03/08/24 10:35	Retrieve from Storage
JD83927-8.1	Todd Shoemaker	Secured Staging Area	03/08/24 10:36	Return to Storage
JD83927-8.1	Secured Staging Area	Melissa Saenz	03/08/24 17:28	Retrieve from Storage
JD83927-8.1	Melissa Saenz	Secured Storage	03/08/24 17:38	Return to Storage
JD83927-8.1	Secured Storage	Taylor Gorman	03/08/24 21:54	Retrieve from Storage
JD83927-8.1	Taylor Gorman	Secured Storage	03/10/24 07:16	Return to Storage
JD83927-8.1	Secured Storage	Todd Shoemaker	03/12/24 11:10	Retrieve from Storage
JD83927-8.1	Todd Shoemaker	Secured Staging Area	03/12/24 11:10	Return to Storage
JD83927-8.1	Secured Staging Area	Melissa Saenz	03/12/24 17:08	Retrieve from Storage
JD83927-8.1	Melissa Saenz	Secured Storage	03/12/24 18:32	Return to Storage
JD83927-8.1	Secured Storage	Dave Hunkele	03/13/24 06:51	Retrieve from Storage
JD83927-8.1	Dave Hunkele	Secured Storage	03/13/24 06:52	Return to Storage
JD83927-8.1	Secured Storage	Dave Hunkele	03/13/24 09:26	Retrieve from Storage
JD83927-8.1	Dave Hunkele	Secured Staging Area	03/13/24 09:26	Return to Storage
JD83927-8.1	Secured Staging Area	Christopher Bruning	03/13/24 11:18	Retrieve from Storage

SGS Internal Chain of Custody

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY
Received: 03/07/24

Sample.Bottle Number	Transfer FROM	Transfer TO	Date/Time	Reason
JD83927-8.1	Christopher Bruning	Secured Storage	03/13/24 19:02	Return to Storage
JD83927-8.1	Secured Storage	Lauren Matthews	03/14/24 16:03	Retrieve from Storage
JD83927-8.1	Lauren Matthews	Secured Storage	03/14/24 19:06	Return to Storage
JD83927-8.1.1	Taylor Gorman	Organics Prep	03/08/24 22:22	Extract from JD83927-8.1
JD83927-8.1.1	Organics Prep	Alejandra Cruz	03/10/24 14:37	Extract from JD83927-8.1
JD83927-8.1.1	Alejandra Cruz	Extract Storage	03/10/24 14:37	Return to Storage
JD83927-8.1.2	Taylor Gorman	Organics Prep	03/08/24 22:57	Extract from JD83927-8.1
JD83927-8.1.2	Ellen Dondeo	Extract Storage	03/09/24 17:56	Return to Storage
JD83927-8.1.2	Organics Prep	Ellen Dondeo	03/09/24 17:56	Extract from JD83927-8.1
JD83927-8.1.2	Extract Storage	Christine Phillips	03/11/24 03:44	Retrieve from Storage
JD83927-8.1.2	Christine Phillips	GC4G	03/11/24 03:44	Load on Instrument
JD83927-8.1.3	Taylor Gorman	Organics Prep	03/08/24 22:57	Extract from JD83927-8.1
JD83927-8.1.3	Organics Prep	Ellen Dondeo	03/09/24 17:56	Extract from JD83927-8.1
JD83927-8.1.3	Ellen Dondeo	Extract Storage	03/09/24 17:56	Return to Storage
JD83927-8.2	Secured Storage	Jayna Patel	03/08/24 08:24	Retrieve from Storage
JD83927-8.2	Jayna Patel		03/08/24 08:25	Depleted
JD83927-8.3	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-8.3	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-8.4	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-8.4	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-8.4	Secured Storage	Prashant Shukla	03/08/24 17:09	Retrieve from Storage
JD83927-8.4	Prashant Shukla	GCMS1C	03/08/24 17:10	Load on Instrument
JD83927-8.4	GCMS1C	Prashant Shukla	03/09/24 11:21	Unload from Instrument
JD83927-8.4	Prashant Shukla		03/09/24 11:22	Depleted
JD83927-8.5	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-8.5	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-9.1	Joshua Reitan	Secured Storage	03/07/24 22:03	Return to Storage
JD83927-9.1	Secured Storage	Todd Shoemaker	03/08/24 10:35	Retrieve from Storage
JD83927-9.1	Todd Shoemaker	Secured Staging Area	03/08/24 10:36	Return to Storage
JD83927-9.1	Secured Staging Area	Melissa Saenz	03/08/24 17:28	Retrieve from Storage
JD83927-9.1	Melissa Saenz	Secured Storage	03/08/24 17:38	Return to Storage
JD83927-9.1	Secured Storage	Taylor Gorman	03/08/24 21:54	Retrieve from Storage
JD83927-9.1	Taylor Gorman	Secured Storage	03/10/24 07:16	Return to Storage
JD83927-9.1	Secured Storage	Todd Shoemaker	03/12/24 11:10	Retrieve from Storage
JD83927-9.1	Todd Shoemaker	Secured Staging Area	03/12/24 11:10	Return to Storage
JD83927-9.1	Secured Staging Area	Melissa Saenz	03/12/24 17:08	Retrieve from Storage

SGS Internal Chain of Custody

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY
Received: 03/07/24

Sample.Bottle Number	Transfer FROM	Transfer TO	Date/Time	Reason
JD83927-9.1	Melissa Saenz	Secured Storage	03/12/24 18:32	Return to Storage
JD83927-9.1	Secured Storage	Dave Hunkele	03/13/24 06:51	Retrieve from Storage
JD83927-9.1	Dave Hunkele	Secured Storage	03/13/24 06:52	Return to Storage
JD83927-9.1	Secured Storage	Dave Hunkele	03/13/24 09:26	Retrieve from Storage
JD83927-9.1	Dave Hunkele	Secured Staging Area	03/13/24 09:26	Return to Storage
JD83927-9.1	Secured Staging Area	Christopher Bruning	03/13/24 11:18	Retrieve from Storage
JD83927-9.1	Christopher Bruning	Secured Storage	03/13/24 19:02	Return to Storage
JD83927-9.1.1	Taylor Gorman	Organics Prep	03/08/24 22:22	Extract from JD83927-9.1
JD83927-9.1.1	Organics Prep	Alejandra Cruz	03/10/24 14:37	Extract from JD83927-9.1
JD83927-9.1.1	Alejandra Cruz	Extract Storage	03/10/24 14:37	Return to Storage
JD83927-9.1.2	Taylor Gorman	Organics Prep	03/08/24 22:57	Extract from JD83927-9.1
JD83927-9.1.2	Ellen Dondeo	Extract Storage	03/09/24 17:56	Return to Storage
JD83927-9.1.2	Organics Prep	Ellen Dondeo	03/09/24 17:56	Extract from JD83927-9.1
JD83927-9.1.2	Extract Storage	Christine Phillips	03/11/24 03:44	Retrieve from Storage
JD83927-9.1.2	Christine Phillips	GC4G	03/11/24 03:44	Load on Instrument
JD83927-9.1.3	Taylor Gorman	Organics Prep	03/08/24 22:57	Extract from JD83927-9.1
JD83927-9.1.3	Organics Prep	Ellen Dondeo	03/09/24 17:56	Extract from JD83927-9.1
JD83927-9.1.3	Ellen Dondeo	Extract Storage	03/09/24 17:56	Return to Storage
JD83927-9.2	Secured Storage	Jayna Patel	03/08/24 08:24	Retrieve from Storage
JD83927-9.2	Jayna Patel		03/08/24 08:25	Depleted
JD83927-9.3	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-9.3	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-9.4	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-9.4	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-9.5	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-9.5	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-9.5	Secured Storage	Prashant Shukla	03/08/24 17:09	Retrieve from Storage
JD83927-9.5	Prashant Shukla	GCMS1C	03/08/24 17:10	Load on Instrument
JD83927-9.5	GCMS1C	Prashant Shukla	03/09/24 11:21	Unload from Instrument
JD83927-9.5	Prashant Shukla		03/09/24 11:22	Depleted
JD83927-10.1	Joshua Reitan	Secured Storage	03/07/24 22:03	Return to Storage
JD83927-10.1	Secured Storage	Todd Shoemaker	03/08/24 10:35	Retrieve from Storage
JD83927-10.1	Todd Shoemaker	Secured Staging Area	03/08/24 10:36	Return to Storage
JD83927-10.1	Secured Staging Area	Melissa Saenz	03/08/24 17:28	Retrieve from Storage
JD83927-10.1	Melissa Saenz	Secured Storage	03/08/24 17:38	Return to Storage
JD83927-10.1	Secured Storage	Taylor Gorman	03/08/24 21:54	Retrieve from Storage

SGS Internal Chain of Custody

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY
Received: 03/07/24

Sample.Bottle Number	Transfer FROM	Transfer TO	Date/Time	Reason
JD83927-10.1	Taylor Gorman	Secured Storage	03/10/24 07:16	Return to Storage
JD83927-10.1	Secured Storage	Todd Shoemaker	03/12/24 11:10	Retrieve from Storage
JD83927-10.1	Todd Shoemaker	Secured Staging Area	03/12/24 11:10	Return to Storage
JD83927-10.1	Secured Staging Area	Melissa Saenz	03/12/24 17:08	Retrieve from Storage
JD83927-10.1	Melissa Saenz	Secured Storage	03/12/24 18:32	Return to Storage
JD83927-10.1	Secured Storage	Dave Hunkele	03/13/24 06:51	Retrieve from Storage
JD83927-10.1	Dave Hunkele	Secured Storage	03/13/24 06:52	Return to Storage
JD83927-10.1	Secured Storage	Dave Hunkele	03/13/24 09:26	Retrieve from Storage
JD83927-10.1	Dave Hunkele	Secured Staging Area	03/13/24 09:26	Return to Storage
JD83927-10.1	Secured Staging Area	Christopher Bruning	03/13/24 11:18	Retrieve from Storage
JD83927-10.1	Christopher Bruning	Secured Storage	03/13/24 19:02	Return to Storage
JD83927-10.1.1	Taylor Gorman	Organics Prep	03/08/24 22:22	Extract from JD83927-10.1
JD83927-10.1.1	Organics Prep	Alejandra Cruz	03/10/24 14:37	Extract from JD83927-10.1
JD83927-10.1.1	Alejandra Cruz	Extract Storage	03/10/24 14:37	Return to Storage
JD83927-10.1.2	Taylor Gorman	Organics Prep	03/08/24 22:57	Extract from JD83927-10.1
JD83927-10.1.2	Ellen Dondeo	Extract Storage	03/09/24 17:56	Return to Storage
JD83927-10.1.2	Organics Prep	Ellen Dondeo	03/09/24 17:56	Extract from JD83927-10.1
JD83927-10.1.2	Extract Storage	Christine Phillips	03/11/24 03:44	Retrieve from Storage
JD83927-10.1.2	Christine Phillips	GC4G	03/11/24 03:44	Load on Instrument
JD83927-10.1.3	Taylor Gorman	Organics Prep	03/08/24 22:57	Extract from JD83927-10.1
JD83927-10.1.3	Organics Prep	Ellen Dondeo	03/09/24 17:56	Extract from JD83927-10.1
JD83927-10.1.3	Ellen Dondeo	Extract Storage	03/09/24 17:56	Return to Storage
JD83927-10.2	Secured Storage	Jayna Patel	03/08/24 08:24	Retrieve from Storage
JD83927-10.2	Jayna Patel		03/08/24 08:25	Depleted
JD83927-10.3	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-10.3	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-10.4	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-10.4	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-10.4	Secured Storage	Prashant Shukla	03/08/24 17:09	Retrieve from Storage
JD83927-10.4	Prashant Shukla	GCMS1C	03/08/24 17:10	Load on Instrument
JD83927-10.4	GCMS1C	Prashant Shukla	03/09/24 11:21	Unload from Instrument
JD83927-10.4	Prashant Shukla		03/09/24 11:22	Depleted
JD83927-10.5	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-10.5	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-11.1	Joshua Reitan	Secured Storage	03/07/24 22:03	Return to Storage
JD83927-11.1	Secured Storage	Todd Shoemaker	03/08/24 10:35	Retrieve from Storage

SGS Internal Chain of Custody

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY
Received: 03/07/24

Sample.Bottle Number	Transfer FROM	Transfer TO	Date/Time	Reason
JD83927-11.1	Todd Shoemaker	Secured Staging Area	03/08/24 10:36	Return to Storage
JD83927-11.1	Secured Staging Area	Melissa Saenz	03/08/24 17:28	Retrieve from Storage
JD83927-11.1	Melissa Saenz	Secured Storage	03/08/24 17:38	Return to Storage
JD83927-11.1	Secured Storage	Taylor Gorman	03/08/24 21:54	Retrieve from Storage
JD83927-11.1	Taylor Gorman	Secured Storage	03/10/24 07:16	Return to Storage
JD83927-11.1	Secured Storage	Todd Shoemaker	03/12/24 11:10	Retrieve from Storage
JD83927-11.1	Todd Shoemaker	Secured Staging Area	03/12/24 11:10	Return to Storage
JD83927-11.1	Secured Staging Area	Melissa Saenz	03/12/24 17:08	Retrieve from Storage
JD83927-11.1	Melissa Saenz	Secured Storage	03/12/24 18:32	Return to Storage
JD83927-11.1	Secured Storage	Dave Hunkele	03/13/24 06:51	Retrieve from Storage
JD83927-11.1	Dave Hunkele	Secured Storage	03/13/24 06:52	Return to Storage
JD83927-11.1	Secured Storage	Dave Hunkele	03/13/24 09:26	Retrieve from Storage
JD83927-11.1	Dave Hunkele	Secured Staging Area	03/13/24 09:26	Return to Storage
JD83927-11.1	Secured Staging Area	Christopher Bruning	03/13/24 11:18	Retrieve from Storage
JD83927-11.1	Christopher Bruning	Secured Storage	03/13/24 19:02	Return to Storage
JD83927-11.1.1	Taylor Gorman	Organics Prep	03/08/24 22:22	Extract from JD83927-11.1
JD83927-11.1.1	Organics Prep	Alejandra Cruz	03/10/24 14:37	Extract from JD83927-11.1
JD83927-11.1.1	Alejandra Cruz	Extract Storage	03/10/24 14:37	Return to Storage
JD83927-11.1.2	Taylor Gorman	Organics Prep	03/08/24 22:57	Extract from JD83927-11.1
JD83927-11.1.2	Organics Prep	Ellen Dondeo	03/09/24 17:56	Extract from JD83927-11.1
JD83927-11.1.2	Ellen Dondeo	Extract Storage	03/09/24 17:56	Return to Storage
JD83927-11.1.2	Extract Storage	Christine Phillips	03/11/24 03:44	Retrieve from Storage
JD83927-11.1.2	Christine Phillips	GC4G	03/11/24 03:44	Load on Instrument
JD83927-11.1.3	Taylor Gorman	Organics Prep	03/08/24 22:57	Extract from JD83927-11.1
JD83927-11.1.3	Organics Prep	Ellen Dondeo	03/09/24 17:56	Extract from JD83927-11.1
JD83927-11.1.3	Ellen Dondeo	Extract Storage	03/09/24 17:56	Return to Storage
JD83927-11.2	Secured Storage	Jayna Patel	03/08/24 08:24	Retrieve from Storage
JD83927-11.2	Jayna Patel		03/08/24 08:25	Depleted
JD83927-11.3	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-11.3	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-11.4	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-11.4	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-11.4	Secured Storage	Prashant Shukla	03/08/24 17:09	Retrieve from Storage
JD83927-11.4	Prashant Shukla	GCMS1C	03/08/24 17:10	Load on Instrument
JD83927-11.4	GCMS1C	Prashant Shukla	03/09/24 11:21	Unload from Instrument
JD83927-11.4	Prashant Shukla		03/09/24 11:22	Depleted
JD83927-11.5	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage

SGS Internal Chain of Custody

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY
Received: 03/07/24

Sample.Bottle Number	Transfer FROM	Transfer TO	Date/Time	Reason
JD83927-11.5	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-12.1	Joshua Reitan	Secured Storage	03/07/24 22:03	Return to Storage
JD83927-12.1	Secured Storage	Todd Shoemaker	03/08/24 10:35	Retrieve from Storage
JD83927-12.1	Todd Shoemaker	Secured Staging Area	03/08/24 10:36	Return to Storage
JD83927-12.1	Secured Staging Area	Melissa Saenz	03/08/24 17:28	Retrieve from Storage
JD83927-12.1	Melissa Saenz	Secured Storage	03/08/24 17:38	Return to Storage
JD83927-12.1	Secured Storage	Taylor Gorman	03/08/24 21:54	Retrieve from Storage
JD83927-12.1	Taylor Gorman	Secured Storage	03/10/24 07:16	Return to Storage
JD83927-12.1	Secured Storage	Todd Shoemaker	03/12/24 11:10	Retrieve from Storage
JD83927-12.1	Todd Shoemaker	Secured Staging Area	03/12/24 11:10	Return to Storage
JD83927-12.1	Secured Staging Area	Melissa Saenz	03/12/24 17:08	Retrieve from Storage
JD83927-12.1	Melissa Saenz	Secured Storage	03/12/24 18:32	Return to Storage
JD83927-12.1	Secured Storage	Dave Hunkele	03/13/24 06:51	Retrieve from Storage
JD83927-12.1	Dave Hunkele	Secured Storage	03/13/24 06:52	Return to Storage
JD83927-12.1	Secured Storage	Dave Hunkele	03/13/24 09:26	Retrieve from Storage
JD83927-12.1	Dave Hunkele	Secured Staging Area	03/13/24 09:26	Return to Storage
JD83927-12.1	Secured Staging Area	Christopher Bruning	03/13/24 11:18	Retrieve from Storage
JD83927-12.1	Christopher Bruning	Secured Storage	03/13/24 19:02	Return to Storage
JD83927-12.1.1	Taylor Gorman	Organics Prep	03/08/24 22:22	Extract from JD83927-12.1
JD83927-12.1.1	Organics Prep	Alejandra Cruz	03/10/24 14:37	Extract from JD83927-12.1
JD83927-12.1.1	Alejandra Cruz	Extract Storage	03/10/24 14:37	Return to Storage
JD83927-12.1.2	Taylor Gorman	Organics Prep	03/08/24 22:57	Extract from JD83927-12.1
JD83927-12.1.2	Ellen Dondeo	Extract Storage	03/09/24 17:56	Return to Storage
JD83927-12.1.2	Organics Prep	Ellen Dondeo	03/09/24 17:56	Extract from JD83927-12.1
JD83927-12.1.2	Extract Storage	Christine Phillips	03/11/24 03:44	Retrieve from Storage
JD83927-12.1.2	Christine Phillips	GC4G	03/11/24 03:44	Load on Instrument
JD83927-12.1.3	Taylor Gorman	Organics Prep	03/08/24 22:57	Extract from JD83927-12.1
JD83927-12.1.3	Organics Prep	Ellen Dondeo	03/09/24 17:56	Extract from JD83927-12.1
JD83927-12.1.3	Ellen Dondeo	Extract Storage	03/09/24 17:56	Return to Storage
JD83927-12.2	Secured Storage	Jayna Patel	03/08/24 08:24	Retrieve from Storage
JD83927-12.2	Jayna Patel		03/08/24 08:25	Depleted
JD83927-12.3	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-12.3	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-12.4	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-12.4	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-12.4	Secured Storage	Prashant Shukla	03/08/24 17:09	Retrieve from Storage
JD83927-12.4	Prashant Shukla	GCMS1C	03/08/24 17:10	Load on Instrument

SGS Internal Chain of Custody

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY
Received: 03/07/24

Sample.Bottle Number	Transfer FROM	Transfer TO	Date/Time	Reason
JD83927-12.4	GCMS1C	Prashant Shukla	03/09/24 11:21	Unload from Instrument
JD83927-12.4	Prashant Shukla		03/09/24 11:22	Depleted
JD83927-12.5	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-12.5	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-13.1	Joshua Reitan	Secured Storage	03/07/24 22:03	Return to Storage
JD83927-13.1	Secured Storage	Todd Shoemaker	03/08/24 10:35	Retrieve from Storage
JD83927-13.1	Todd Shoemaker	Secured Staging Area	03/08/24 10:36	Return to Storage
JD83927-13.1	Secured Staging Area	Melissa Saenz	03/08/24 17:28	Retrieve from Storage
JD83927-13.1	Melissa Saenz	Secured Storage	03/08/24 17:38	Return to Storage
JD83927-13.1	Secured Storage	Taylor Gorman	03/08/24 21:54	Retrieve from Storage
JD83927-13.1	Taylor Gorman	Secured Storage	03/10/24 07:16	Return to Storage
JD83927-13.1	Secured Storage	Todd Shoemaker	03/12/24 11:10	Retrieve from Storage
JD83927-13.1	Todd Shoemaker	Secured Staging Area	03/12/24 11:10	Return to Storage
JD83927-13.1	Secured Staging Area	Melissa Saenz	03/12/24 17:08	Retrieve from Storage
JD83927-13.1	Melissa Saenz	Secured Storage	03/12/24 18:32	Return to Storage
JD83927-13.1	Secured Storage	Dave Hunkele	03/13/24 06:51	Retrieve from Storage
JD83927-13.1	Dave Hunkele	Secured Storage	03/13/24 06:52	Return to Storage
JD83927-13.1	Secured Storage	Dave Hunkele	03/13/24 09:26	Retrieve from Storage
JD83927-13.1	Dave Hunkele	Secured Staging Area	03/13/24 09:26	Return to Storage
JD83927-13.1	Secured Staging Area	Christopher Bruning	03/13/24 11:18	Retrieve from Storage
JD83927-13.1	Christopher Bruning	Secured Storage	03/13/24 19:02	Return to Storage
JD83927-13.1.1	Taylor Gorman	Organics Prep	03/08/24 22:22	Extract from JD83927-13.1
JD83927-13.1.1	Organics Prep	Alejandra Cruz	03/10/24 14:37	Extract from JD83927-13.1
JD83927-13.1.1	Alejandra Cruz	Extract Storage	03/10/24 14:37	Return to Storage
JD83927-13.1.2	Taylor Gorman	Organics Prep	03/08/24 22:57	Extract from JD83927-13.1
JD83927-13.1.2	Ellen Dondeo	Extract Storage	03/09/24 17:56	Return to Storage
JD83927-13.1.2	Organics Prep	Ellen Dondeo	03/09/24 17:56	Extract from JD83927-13.1
JD83927-13.1.2	Extract Storage	Christine Phillips	03/11/24 03:44	Retrieve from Storage
JD83927-13.1.2	Christine Phillips	GC4G	03/11/24 03:44	Load on Instrument
JD83927-13.1.3	Taylor Gorman	Organics Prep	03/08/24 22:57	Extract from JD83927-13.1
JD83927-13.1.3	Organics Prep	Ellen Dondeo	03/09/24 17:56	Extract from JD83927-13.1
JD83927-13.1.3	Ellen Dondeo	Extract Storage	03/09/24 17:56	Return to Storage
JD83927-13.2	Secured Storage	Jayna Patel	03/08/24 08:24	Retrieve from Storage
JD83927-13.2	Jayna Patel		03/08/24 08:25	Depleted
JD83927-13.3	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-13.3	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage

SGS Internal Chain of Custody

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY
Received: 03/07/24

Sample.Bottle Number	Transfer FROM	Transfer TO	Date/Time	Reason
JD83927-13.4	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-13.4	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-13.4	Secured Storage	Prashant Shukla	03/08/24 17:09	Retrieve from Storage
JD83927-13.4	Prashant Shukla	GCMS1C	03/08/24 17:10	Load on Instrument
JD83927-13.4	GCMS1C	Prashant Shukla	03/09/24 11:21	Unload from Instrument
JD83927-13.4	Prashant Shukla		03/09/24 11:22	Depleted
JD83927-13.5	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-13.5	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-14.1	Joshua Reitan	Secured Storage	03/07/24 22:03	Return to Storage
JD83927-14.1	Secured Storage	Todd Shoemaker	03/08/24 10:35	Retrieve from Storage
JD83927-14.1	Todd Shoemaker	Secured Staging Area	03/08/24 10:36	Return to Storage
JD83927-14.1	Secured Staging Area	Melissa Saenz	03/08/24 17:28	Retrieve from Storage
JD83927-14.1	Melissa Saenz	Secured Storage	03/08/24 17:38	Return to Storage
JD83927-14.1	Secured Storage	Taylor Gorman	03/08/24 21:54	Retrieve from Storage
JD83927-14.1	Taylor Gorman	Secured Storage	03/10/24 07:16	Return to Storage
JD83927-14.1	Secured Storage	Todd Shoemaker	03/12/24 11:10	Retrieve from Storage
JD83927-14.1	Todd Shoemaker	Secured Staging Area	03/12/24 11:10	Return to Storage
JD83927-14.1	Secured Staging Area	Melissa Saenz	03/12/24 17:08	Retrieve from Storage
JD83927-14.1	Melissa Saenz	Secured Storage	03/12/24 18:32	Return to Storage
JD83927-14.1	Secured Storage	Dave Hunkele	03/13/24 06:51	Retrieve from Storage
JD83927-14.1	Dave Hunkele	Secured Storage	03/13/24 06:52	Return to Storage
JD83927-14.1	Secured Storage	Dave Hunkele	03/13/24 09:26	Retrieve from Storage
JD83927-14.1	Dave Hunkele	Secured Staging Area	03/13/24 09:26	Return to Storage
JD83927-14.1	Secured Staging Area	Christopher Bruning	03/13/24 11:18	Retrieve from Storage
JD83927-14.1	Christopher Bruning	Secured Storage	03/13/24 19:02	Return to Storage
JD83927-14.1.1	Taylor Gorman	Organics Prep	03/08/24 22:22	Extract from JD83927-14.1
JD83927-14.1.1	Organics Prep	Alejandra Cruz	03/10/24 14:37	Extract from JD83927-14.1
JD83927-14.1.1	Alejandra Cruz	Extract Storage	03/10/24 14:37	Return to Storage
JD83927-14.1.2	Taylor Gorman	Organics Prep	03/08/24 22:57	Extract from JD83927-14.1
JD83927-14.1.2	Organics Prep	Ellen Dondeo	03/09/24 17:56	Extract from JD83927-14.1
JD83927-14.1.2	Ellen Dondeo	Extract Storage	03/09/24 17:56	Return to Storage
JD83927-14.1.2	Extract Storage	Christine Phillips	03/11/24 03:44	Retrieve from Storage
JD83927-14.1.2	Christine Phillips	GC4G	03/11/24 03:44	Load on Instrument
JD83927-14.1.3	Taylor Gorman	Organics Prep	03/08/24 22:57	Extract from JD83927-14.1
JD83927-14.1.3	Organics Prep	Ellen Dondeo	03/09/24 17:56	Extract from JD83927-14.1
JD83927-14.1.3	Ellen Dondeo	Extract Storage	03/09/24 17:56	Return to Storage
JD83927-14.2	Secured Storage	Jayna Patel	03/08/24 08:24	Retrieve from Storage
JD83927-14.2	Jayna Patel		03/08/24 08:25	Depleted

SGS Internal Chain of Custody

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY
Received: 03/07/24

Sample.Bottle Number	Transfer FROM	Transfer TO	Date/Time	Reason
JD83927-14.3	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-14.3	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-14.4	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-14.4	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-14.4	Secured Storage	Prashant Shukla	03/08/24 15:46	Retrieve from Storage
JD83927-14.4	Prashant Shukla	GCMSY	03/08/24 15:46	Load on Instrument
JD83927-14.4	GCMSY	Prashant Shukla	03/09/24 11:21	Unload from Instrument
JD83927-14.4	Prashant Shukla		03/09/24 11:22	Depleted
JD83927-14.5	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-14.5	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-15.1	Joshua Reitan	Secured Storage	03/07/24 22:03	Return to Storage
JD83927-15.1	Secured Storage	Todd Shoemaker	03/08/24 10:35	Retrieve from Storage
JD83927-15.1	Todd Shoemaker	Secured Staging Area	03/08/24 10:36	Return to Storage
JD83927-15.1	Secured Staging Area	Melissa Saenz	03/08/24 17:28	Retrieve from Storage
JD83927-15.1	Melissa Saenz	Secured Storage	03/08/24 17:38	Return to Storage
JD83927-15.1	Secured Storage	Taylor Gorman	03/08/24 21:54	Retrieve from Storage
JD83927-15.1	Taylor Gorman	Secured Storage	03/10/24 07:16	Return to Storage
JD83927-15.1	Secured Storage	Todd Shoemaker	03/12/24 11:10	Retrieve from Storage
JD83927-15.1	Todd Shoemaker	Secured Staging Area	03/12/24 11:10	Return to Storage
JD83927-15.1	Secured Staging Area	Melissa Saenz	03/12/24 17:08	Retrieve from Storage
JD83927-15.1	Melissa Saenz	Secured Storage	03/12/24 18:32	Return to Storage
JD83927-15.1	Secured Storage	Dave Hunkele	03/13/24 06:51	Retrieve from Storage
JD83927-15.1	Dave Hunkele	Secured Storage	03/13/24 06:52	Return to Storage
JD83927-15.1	Secured Storage	Dave Hunkele	03/13/24 09:26	Retrieve from Storage
JD83927-15.1	Dave Hunkele	Secured Staging Area	03/13/24 09:26	Return to Storage
JD83927-15.1	Secured Staging Area	Christopher Bruning	03/13/24 11:18	Retrieve from Storage
JD83927-15.1	Christopher Bruning	Secured Storage	03/13/24 19:02	Return to Storage
JD83927-15.1.1	Taylor Gorman	Organics Prep	03/08/24 22:22	Extract from JD83927-15.1
JD83927-15.1.1	Organics Prep	Alejandra Cruz	03/10/24 14:37	Extract from JD83927-15.1
JD83927-15.1.1	Alejandra Cruz	Extract Storage	03/10/24 14:37	Return to Storage
JD83927-15.1.2	Taylor Gorman	Organics Prep	03/08/24 22:57	Extract from JD83927-15.1
JD83927-15.1.2	Ellen Dondeo	Extract Storage	03/09/24 17:56	Return to Storage
JD83927-15.1.2	Organics Prep	Ellen Dondeo	03/09/24 17:56	Extract from JD83927-15.1
JD83927-15.1.2	Extract Storage	Christine Phillips	03/11/24 03:44	Retrieve from Storage
JD83927-15.1.2	Christine Phillips	GC4G	03/11/24 03:44	Load on Instrument
JD83927-15.1.3	Taylor Gorman	Organics Prep	03/08/24 22:57	Extract from JD83927-15.1
JD83927-15.1.3	Organics Prep	Ellen Dondeo	03/09/24 17:56	Extract from JD83927-15.1

SGS Internal Chain of Custody

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY
Received: 03/07/24

Sample.Bottle Number	Transfer FROM	Transfer TO	Date/Time	Reason
JD83927-15.1.3	Ellen Dondeo	Extract Storage	03/09/24 17:56	Return to Storage
JD83927-15.2	Secured Storage	Jayna Patel	03/08/24 08:24	Retrieve from Storage
JD83927-15.2	Jayna Patel		03/08/24 08:25	Depleted
JD83927-15.3	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-15.3	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-15.4	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-15.4	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-15.4	Secured Storage	Prashant Shukla	03/08/24 15:46	Retrieve from Storage
JD83927-15.4	Prashant Shukla	GCMSY	03/08/24 15:46	Load on Instrument
JD83927-15.4	GCMSY	Prashant Shukla	03/09/24 11:21	Unload from Instrument
JD83927-15.4	Prashant Shukla		03/09/24 11:22	Depleted
JD83927-15.5	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-15.5	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-16.1	Joshua Reitan	Secured Storage	03/07/24 22:03	Return to Storage
JD83927-16.1	Secured Storage	Todd Shoemaker	03/08/24 10:35	Retrieve from Storage
JD83927-16.1	Todd Shoemaker	Secured Staging Area	03/08/24 10:36	Return to Storage
JD83927-16.1	Secured Staging Area	Melissa Saenz	03/08/24 17:28	Retrieve from Storage
JD83927-16.1	Melissa Saenz	Secured Storage	03/08/24 17:38	Return to Storage
JD83927-16.1	Secured Storage	Taylor Gorman	03/08/24 21:54	Retrieve from Storage
JD83927-16.1	Taylor Gorman	Secured Storage	03/10/24 07:16	Return to Storage
JD83927-16.1	Secured Storage	Todd Shoemaker	03/12/24 11:10	Retrieve from Storage
JD83927-16.1	Todd Shoemaker	Secured Staging Area	03/12/24 11:10	Return to Storage
JD83927-16.1	Secured Staging Area	Melissa Saenz	03/12/24 17:08	Retrieve from Storage
JD83927-16.1	Melissa Saenz	Secured Storage	03/12/24 18:32	Return to Storage
JD83927-16.1	Secured Storage	Dave Hunkele	03/13/24 06:51	Retrieve from Storage
JD83927-16.1	Dave Hunkele	Secured Storage	03/13/24 06:52	Return to Storage
JD83927-16.1	Secured Storage	Dave Hunkele	03/13/24 09:26	Retrieve from Storage
JD83927-16.1	Dave Hunkele	Secured Staging Area	03/13/24 09:26	Return to Storage
JD83927-16.1	Secured Staging Area	Christopher Bruning	03/13/24 11:18	Retrieve from Storage
JD83927-16.1	Christopher Bruning	Secured Storage	03/13/24 19:02	Return to Storage
JD83927-16.1.1	Taylor Gorman	Organics Prep	03/08/24 22:22	Extract from JD83927-16.1
JD83927-16.1.1	Organics Prep	Alejandra Cruz	03/10/24 14:37	Extract from JD83927-16.1
JD83927-16.1.1	Alejandra Cruz	Extract Storage	03/10/24 14:37	Return to Storage
JD83927-16.1.2	Taylor Gorman	Organics Prep	03/08/24 22:57	Extract from JD83927-16.1
JD83927-16.1.2	Ellen Dondeo	Extract Storage	03/09/24 17:56	Return to Storage
JD83927-16.1.2	Organics Prep	Ellen Dondeo	03/09/24 17:56	Extract from JD83927-16.1
JD83927-16.1.2	Extract Storage	Christine Phillips	03/11/24 03:44	Retrieve from Storage

SGS Internal Chain of Custody

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY
Received: 03/07/24

Sample.Bottle Number	Transfer FROM	Transfer TO	Date/Time	Reason
JD83927-16.1.2	Christine Phillips	GC5G	03/11/24 03:44	Load on Instrument
JD83927-16.1.3	Taylor Gorman	Organics Prep	03/08/24 22:57	Extract from JD83927-16.1
JD83927-16.1.3	Organics Prep	Ellen Dondeo	03/09/24 17:56	Extract from JD83927-16.1
JD83927-16.1.3	Ellen Dondeo	Extract Storage	03/09/24 17:56	Return to Storage
JD83927-16.2	Secured Storage	Jayna Patel	03/08/24 08:24	Retrieve from Storage
JD83927-16.2	Jayna Patel		03/08/24 08:25	Depleted
JD83927-16.3	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-16.3	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-16.4	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-16.4	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-16.4	Secured Storage	Prashant Shukla	03/08/24 15:46	Retrieve from Storage
JD83927-16.4	Prashant Shukla	GCMSY	03/08/24 15:46	Load on Instrument
JD83927-16.4	GCMSY	Prashant Shukla	03/09/24 11:21	Unload from Instrument
JD83927-16.4	Prashant Shukla		03/09/24 11:22	Depleted
JD83927-16.5	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-16.5	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-17.1	Joshua Reitan	Secured Storage	03/07/24 22:03	Return to Storage
JD83927-17.1	Secured Storage	Todd Shoemaker	03/08/24 10:35	Retrieve from Storage
JD83927-17.1	Todd Shoemaker	Secured Staging Area	03/08/24 10:36	Return to Storage
JD83927-17.1	Secured Staging Area	Melissa Saenz	03/08/24 17:28	Retrieve from Storage
JD83927-17.1	Melissa Saenz	Secured Storage	03/08/24 17:38	Return to Storage
JD83927-17.1	Secured Storage	Taylor Gorman	03/08/24 21:54	Retrieve from Storage
JD83927-17.1	Taylor Gorman	Secured Storage	03/10/24 07:16	Return to Storage
JD83927-17.1	Secured Storage	Todd Shoemaker	03/12/24 11:10	Retrieve from Storage
JD83927-17.1	Todd Shoemaker	Secured Staging Area	03/12/24 11:10	Return to Storage
JD83927-17.1	Secured Staging Area	Melissa Saenz	03/12/24 17:08	Retrieve from Storage
JD83927-17.1	Melissa Saenz	Secured Storage	03/12/24 18:32	Return to Storage
JD83927-17.1	Secured Storage	Dave Hunkele	03/13/24 06:51	Retrieve from Storage
JD83927-17.1	Dave Hunkele	Secured Storage	03/13/24 06:52	Return to Storage
JD83927-17.1	Secured Storage	Dave Hunkele	03/13/24 09:26	Retrieve from Storage
JD83927-17.1	Dave Hunkele	Secured Staging Area	03/13/24 09:26	Return to Storage
JD83927-17.1	Secured Staging Area	Christopher Bruning	03/13/24 11:18	Retrieve from Storage
JD83927-17.1	Christopher Bruning	Secured Storage	03/13/24 19:02	Return to Storage
JD83927-17.1.1	Taylor Gorman	Organics Prep	03/08/24 22:22	Extract from JD83927-17.1
JD83927-17.1.1	Organics Prep	Alejandra Cruz	03/10/24 14:37	Extract from JD83927-17.1
JD83927-17.1.1	Alejandra Cruz	Extract Storage	03/10/24 14:37	Return to Storage

SGS Internal Chain of Custody

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY
Received: 03/07/24

Sample.Bottle Number	Transfer FROM	Transfer TO	Date/Time	Reason
JD83927-17.1.2	Taylor Gorman	Organics Prep	03/08/24 22:57	Extract from JD83927-17.1
JD83927-17.1.2	Ellen Dondeo	Extract Storage	03/09/24 17:56	Return to Storage
JD83927-17.1.2	Organics Prep	Ellen Dondeo	03/09/24 17:56	Extract from JD83927-17.1
JD83927-17.1.2	Extract Storage	Christine Phillips	03/11/24 03:44	Retrieve from Storage
JD83927-17.1.2	Christine Phillips	GC5G	03/11/24 03:44	Load on Instrument
JD83927-17.1.3	Taylor Gorman	Organics Prep	03/08/24 22:57	Extract from JD83927-17.1
JD83927-17.1.3	Organics Prep	Ellen Dondeo	03/09/24 17:56	Extract from JD83927-17.1
JD83927-17.1.3	Ellen Dondeo	Extract Storage	03/09/24 17:56	Return to Storage
JD83927-17.3	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-17.3	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-17.4	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-17.4	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-17.5	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-17.5	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-17.5	Secured Storage	Prashant Shukla	03/08/24 15:46	Retrieve from Storage
JD83927-17.5	Prashant Shukla	GCMSY	03/08/24 15:46	Load on Instrument
JD83927-17.5	GCMSY	Prashant Shukla	03/09/24 11:21	Unload from Instrument
JD83927-17.5	Prashant Shukla		03/09/24 11:22	Depleted
JD83927-18.1	Joshua Reitan	Secured Storage	03/07/24 22:03	Return to Storage
JD83927-18.1	Secured Storage	Todd Shoemaker	03/08/24 10:35	Retrieve from Storage
JD83927-18.1	Todd Shoemaker	Secured Staging Area	03/08/24 10:36	Return to Storage
JD83927-18.1	Secured Staging Area	Melissa Saenz	03/08/24 17:28	Retrieve from Storage
JD83927-18.1	Melissa Saenz	Secured Storage	03/08/24 17:38	Return to Storage
JD83927-18.1	Secured Storage	Taylor Gorman	03/08/24 21:54	Retrieve from Storage
JD83927-18.1	Taylor Gorman	Secured Storage	03/10/24 07:16	Return to Storage
JD83927-18.1	Secured Storage	Todd Shoemaker	03/12/24 11:10	Retrieve from Storage
JD83927-18.1	Todd Shoemaker	Secured Staging Area	03/12/24 11:10	Return to Storage
JD83927-18.1	Secured Staging Area	Melissa Saenz	03/12/24 17:08	Retrieve from Storage
JD83927-18.1	Melissa Saenz	Secured Storage	03/12/24 18:32	Return to Storage
JD83927-18.1	Secured Storage	Dave Hunkele	03/13/24 06:51	Retrieve from Storage
JD83927-18.1	Dave Hunkele	Secured Storage	03/13/24 06:52	Return to Storage
JD83927-18.1	Secured Storage	Dave Hunkele	03/13/24 09:26	Retrieve from Storage
JD83927-18.1	Dave Hunkele	Secured Staging Area	03/13/24 09:26	Return to Storage
JD83927-18.1	Secured Staging Area	Christopher Bruning	03/13/24 11:18	Retrieve from Storage
JD83927-18.1	Christopher Bruning	Secured Storage	03/13/24 19:02	Return to Storage
JD83927-18.1.1	Taylor Gorman	Organics Prep	03/08/24 22:22	Extract from JD83927-18.1
JD83927-18.1.1	Organics Prep	Alejandra Cruz	03/10/24 14:37	Extract from JD83927-18.1
JD83927-18.1.1	Alejandra Cruz	Extract Storage	03/10/24 14:37	Return to Storage

SGS Internal Chain of Custody

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY
Received: 03/07/24

Sample.Bottle Number	Transfer FROM	Transfer TO	Date/Time	Reason
JD83927-18.1.2	Taylor Gorman	Organics Prep	03/08/24 22:57	Extract from JD83927-18.1
JD83927-18.1.2	Ellen Dondeo	Extract Storage	03/09/24 17:56	Return to Storage
JD83927-18.1.2	Organics Prep	Ellen Dondeo	03/09/24 17:56	Extract from JD83927-18.1
JD83927-18.1.2	Extract Storage	Christine Phillips	03/11/24 03:44	Retrieve from Storage
JD83927-18.1.2	Christine Phillips	GC5G	03/11/24 03:44	Load on Instrument
JD83927-18.1.3	Taylor Gorman	Organics Prep	03/08/24 22:57	Extract from JD83927-18.1
JD83927-18.1.3	Organics Prep	Ellen Dondeo	03/09/24 17:56	Extract from JD83927-18.1
JD83927-18.1.3	Ellen Dondeo	Extract Storage	03/09/24 17:56	Return to Storage
JD83927-18.2	Secured Storage	Jayna Patel	03/08/24 08:24	Retrieve from Storage
JD83927-18.2	Jayna Patel		03/08/24 08:25	Depleted
JD83927-18.3	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-18.3	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-18.4	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-18.4	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage
JD83927-18.4	Secured Storage	Prashant Shukla	03/08/24 15:46	Retrieve from Storage
JD83927-18.4	Prashant Shukla	GCMSY	03/08/24 15:46	Load on Instrument
JD83927-18.4	GCMSY	Prashant Shukla	03/09/24 11:21	Unload from Instrument
JD83927-18.4	Prashant Shukla		03/09/24 11:22	Depleted
JD83927-18.5	Secured Storage	Jayna Patel	03/08/24 09:07	Retrieve from Storage
JD83927-18.5	Jayna Patel	Secured Storage	03/08/24 09:07	Return to Storage

MS Volatiles

QC Data Summaries

Includes the following where applicable:

- Method Blank Summaries
- Blank Spike Summaries
- Matrix Spike and Duplicate Summaries
- Instrument Performance Checks (BFB)
- Internal Standard Area Summaries
- Surrogate Recovery Summaries
- Initial and Continuing Calibration Summaries
- Run Sequence Reports

Method Blank Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
VY8980-MB	Y206952.D	1	03/08/24	PS	n/a	n/a	VY8980

The QC reported here applies to the following samples: **Method:** SW846 8260D

JD83927-14, JD83927-15, JD83927-16, JD83927-17, JD83927-18

CAS No.	Compound	Result	RL	MDL	Units	Q
67-64-1	Acetone	ND	10	4.1	ug/kg	
71-43-2	Benzene	ND	0.50	0.46	ug/kg	
74-97-5	Bromochloromethane	ND	5.0	0.56	ug/kg	
75-27-4	Bromodichloromethane	ND	2.0	0.43	ug/kg	
75-25-2	Bromoform	ND	5.0	1.4	ug/kg	
74-83-9	Bromomethane	ND	5.0	0.76	ug/kg	
78-93-3	2-Butanone (MEK)	ND	10	2.4	ug/kg	
75-15-0	Carbon disulfide	ND	2.0	0.54	ug/kg	
56-23-5	Carbon tetrachloride	ND	2.0	0.62	ug/kg	
108-90-7	Chlorobenzene	ND	2.0	0.46	ug/kg	
75-00-3	Chloroethane	ND	5.0	0.59	ug/kg	
67-66-3	Chloroform	ND	2.0	0.52	ug/kg	
74-87-3	Chloromethane	ND	5.0	2.0	ug/kg	
110-82-7	Cyclohexane	ND	2.0	0.66	ug/kg	
96-12-8	1,2-Dibromo-3-chloropropane	ND	2.0	0.69	ug/kg	
124-48-1	Dibromochloromethane	ND	2.0	0.56	ug/kg	
106-93-4	1,2-Dibromoethane	ND	1.0	0.42	ug/kg	
95-50-1	1,2-Dichlorobenzene	ND	1.0	0.55	ug/kg	
541-73-1	1,3-Dichlorobenzene	ND	1.0	0.50	ug/kg	
106-46-7	1,4-Dichlorobenzene	ND	1.0	0.49	ug/kg	
75-71-8	Dichlorodifluoromethane	ND	5.0	0.73	ug/kg	
75-34-3	1,1-Dichloroethane	ND	1.0	0.50	ug/kg	
107-06-2	1,2-Dichloroethane	ND	1.0	0.47	ug/kg	
75-35-4	1,1-Dichloroethene	ND	1.0	0.66	ug/kg	
156-59-2	cis-1,2-Dichloroethene	ND	1.0	0.84	ug/kg	
156-60-5	trans-1,2-Dichloroethene	ND	1.0	0.61	ug/kg	
78-87-5	1,2-Dichloropropane	ND	2.0	0.47	ug/kg	
10061-01-5	cis-1,3-Dichloropropene	ND	2.0	0.48	ug/kg	
10061-02-6	trans-1,3-Dichloropropene	ND	2.0	0.46	ug/kg	
100-41-4	Ethylbenzene	ND	1.0	0.45	ug/kg	
76-13-1	Freon 113	ND	5.0	2.7	ug/kg	
591-78-6	2-Hexanone	ND	5.0	2.1	ug/kg	
98-82-8	Isopropylbenzene	ND	2.0	1.4	ug/kg	
79-20-9	Methyl Acetate	ND	5.0	1.4	ug/kg	
108-87-2	Methylcyclohexane	ND	2.0	0.88	ug/kg	
1634-04-4	Methyl Tert Butyl Ether	ND	1.0	0.47	ug/kg	

Method Blank Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
VY8980-MB	Y206952.D	1	03/08/24	PS	n/a	n/a	VY8980

The QC reported here applies to the following samples: **Method:** SW846 8260D

JD83927-14, JD83927-15, JD83927-16, JD83927-17, JD83927-18

CAS No.	Compound	Result	RL	MDL	Units	Q
108-10-1	4-Methyl-2-pentanone(MIBK)	ND	5.0	2.3	ug/kg	
75-09-2	Methylene chloride	ND	5.0	2.6	ug/kg	
100-42-5	Styrene	ND	2.0	0.40	ug/kg	
79-34-5	1,1,2,2-Tetrachloroethane	ND	2.0	0.60	ug/kg	
127-18-4	Tetrachloroethene	ND	2.0	0.58	ug/kg	
108-88-3	Toluene	ND	1.0	0.53	ug/kg	
87-61-6	1,2,3-Trichlorobenzene	ND	5.0	2.5	ug/kg	
120-82-1	1,2,4-Trichlorobenzene	ND	5.0	2.5	ug/kg	
71-55-6	1,1,1-Trichloroethane	ND	2.0	0.48	ug/kg	
79-00-5	1,1,2-Trichloroethane	ND	2.0	0.55	ug/kg	
79-01-6	Trichloroethene	ND	1.0	0.76	ug/kg	
75-69-4	Trichlorofluoromethane	ND	5.0	0.68	ug/kg	
75-01-4	Vinyl chloride	ND	2.0	0.48	ug/kg	
	m,p-Xylene	ND	1.0	0.90	ug/kg	
95-47-6	o-Xylene	ND	1.0	0.46	ug/kg	
1330-20-7	Xylene (total)	ND	1.0	0.46	ug/kg	

CAS No.	Surrogate Recoveries		Limits
1868-53-7	Dibromofluoromethane	93%	80-124%
17060-07-0	1,2-Dichloroethane-D4	100%	75-133%
2037-26-5	Toluene-D8	101%	79-125%
460-00-4	4-Bromofluorobenzene	101%	58-148%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	system artifact	.86	11	ug/kg	J
	Total TIC, Volatile		0	ug/kg	

Method Blank Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
V1C8643-MB	1C199824.D	1	03/09/24	PS	n/a	n/a	V1C8643

The QC reported here applies to the following samples: **Method:** SW846 8260D

JD83927-1, JD83927-2, JD83927-3, JD83927-4, JD83927-5, JD83927-6, JD83927-7, JD83927-8, JD83927-9, JD83927-10, JD83927-11, JD83927-12, JD83927-13

CAS No.	Compound	Result	RL	MDL	Units	Q
67-64-1	Acetone	ND	10	4.1	ug/kg	
71-43-2	Benzene	ND	0.50	0.46	ug/kg	
74-97-5	Bromochloromethane	ND	5.0	0.56	ug/kg	
75-27-4	Bromodichloromethane	ND	2.0	0.43	ug/kg	
75-25-2	Bromoform	ND	5.0	1.4	ug/kg	
74-83-9	Bromomethane	ND	5.0	0.76	ug/kg	
78-93-3	2-Butanone (MEK)	ND	10	2.4	ug/kg	
75-15-0	Carbon disulfide	ND	2.0	0.54	ug/kg	
56-23-5	Carbon tetrachloride	ND	2.0	0.62	ug/kg	
108-90-7	Chlorobenzene	ND	2.0	0.46	ug/kg	
75-00-3	Chloroethane	ND	5.0	0.59	ug/kg	
67-66-3	Chloroform	ND	2.0	0.52	ug/kg	
74-87-3	Chloromethane	ND	5.0	2.0	ug/kg	
110-82-7	Cyclohexane	ND	2.0	0.66	ug/kg	
96-12-8	1,2-Dibromo-3-chloropropane	ND	2.0	0.69	ug/kg	
124-48-1	Dibromochloromethane	ND	2.0	0.56	ug/kg	
106-93-4	1,2-Dibromoethane	ND	1.0	0.42	ug/kg	
95-50-1	1,2-Dichlorobenzene	ND	1.0	0.55	ug/kg	
541-73-1	1,3-Dichlorobenzene	ND	1.0	0.50	ug/kg	
106-46-7	1,4-Dichlorobenzene	ND	1.0	0.49	ug/kg	
75-71-8	Dichlorodifluoromethane	ND	5.0	0.73	ug/kg	
75-34-3	1,1-Dichloroethane	ND	1.0	0.50	ug/kg	
107-06-2	1,2-Dichloroethane	ND	1.0	0.47	ug/kg	
75-35-4	1,1-Dichloroethene	ND	1.0	0.66	ug/kg	
156-59-2	cis-1,2-Dichloroethene	ND	1.0	0.84	ug/kg	
156-60-5	trans-1,2-Dichloroethene	ND	1.0	0.61	ug/kg	
78-87-5	1,2-Dichloropropane	ND	2.0	0.47	ug/kg	
10061-01-5	cis-1,3-Dichloropropene	ND	2.0	0.48	ug/kg	
10061-02-6	trans-1,3-Dichloropropene	ND	2.0	0.46	ug/kg	
100-41-4	Ethylbenzene	ND	1.0	0.45	ug/kg	
76-13-1	Freon 113	ND	5.0	2.7	ug/kg	
591-78-6	2-Hexanone	ND	5.0	2.1	ug/kg	
98-82-8	Isopropylbenzene	ND	2.0	1.4	ug/kg	
79-20-9	Methyl Acetate	ND	5.0	1.4	ug/kg	
108-87-2	Methylcyclohexane	ND	2.0	0.88	ug/kg	
1634-04-4	Methyl Tert Butyl Ether	ND	1.0	0.47	ug/kg	

Method Blank Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
V1C8643-MB	1C199824.D	1	03/09/24	PS	n/a	n/a	V1C8643

The QC reported here applies to the following samples: **Method:** SW846 8260D

JD83927-1, JD83927-2, JD83927-3, JD83927-4, JD83927-5, JD83927-6, JD83927-7, JD83927-8, JD83927-9, JD83927-10, JD83927-11, JD83927-12, JD83927-13

CAS No.	Compound	Result	RL	MDL	Units	Q
108-10-1	4-Methyl-2-pentanone(MIBK)	ND	5.0	2.3	ug/kg	
75-09-2	Methylene chloride	ND	5.0	2.6	ug/kg	
100-42-5	Styrene	ND	2.0	0.40	ug/kg	
79-34-5	1,1,2,2-Tetrachloroethane	ND	2.0	0.60	ug/kg	
127-18-4	Tetrachloroethene	ND	2.0	0.58	ug/kg	
108-88-3	Toluene	ND	1.0	0.53	ug/kg	
87-61-6	1,2,3-Trichlorobenzene	ND	5.0	2.5	ug/kg	
120-82-1	1,2,4-Trichlorobenzene	ND	5.0	2.5	ug/kg	
71-55-6	1,1,1-Trichloroethane	ND	2.0	0.48	ug/kg	
79-00-5	1,1,2-Trichloroethane	ND	2.0	0.55	ug/kg	
79-01-6	Trichloroethene	ND	1.0	0.76	ug/kg	
75-69-4	Trichlorofluoromethane	ND	5.0	0.68	ug/kg	
75-01-4	Vinyl chloride	ND	2.0	0.48	ug/kg	
	m,p-Xylene	ND	1.0	0.90	ug/kg	
95-47-6	o-Xylene	ND	1.0	0.46	ug/kg	
1330-20-7	Xylene (total)	ND	1.0	0.46	ug/kg	

CAS No.	Surrogate Recoveries		Limits
1868-53-7	Dibromofluoromethane	102%	80-124%
17060-07-0	1,2-Dichloroethane-D4	108%	75-133%
2037-26-5	Toluene-D8	100%	79-125%
460-00-4	4-Bromofluorobenzene	91%	58-148%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Total TIC, Volatile		0	ug/kg	

Blank Spike Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
VY8980-BS	Y206950.D	1	03/08/24	PS	n/a	n/a	VY8980

The QC reported here applies to the following samples: **Method:** SW846 8260D

JD83927-14, JD83927-15, JD83927-16, JD83927-17, JD83927-18

CAS No.	Compound	Spike ug/kg	BSP ug/kg	BSP %	Limits
67-64-1	Acetone	200	225	113	52-156
71-43-2	Benzene	50	46.4	93	82-119
74-97-5	Bromochloromethane	50	46.5	93	82-123
75-27-4	Bromodichloromethane	50	51.5	103	83-121
75-25-2	Bromoform	50	45.4	91	74-138
74-83-9	Bromomethane	50	54.2	108	56-150
78-93-3	2-Butanone (MEK)	200	214	107	72-138
75-15-0	Carbon disulfide	50	39.7	79	67-131
56-23-5	Carbon tetrachloride	50	43.6	87	72-130
108-90-7	Chlorobenzene	50	46.9	94	83-114
75-00-3	Chloroethane	50	52.6	105	67-141
67-66-3	Chloroform	50	41.5	83	76-115
74-87-3	Chloromethane	50	49.4	99	57-141
110-82-7	Cyclohexane	50	49.4	99	69-130
96-12-8	1,2-Dibromo-3-chloropropane	50	57.7	115	72-131
124-48-1	Dibromochloromethane	50	48.5	97	80-128
106-93-4	1,2-Dibromoethane	50	47.7	95	58-145
95-50-1	1,2-Dichlorobenzene	50	50.0	100	83-117
541-73-1	1,3-Dichlorobenzene	50	49.5	99	82-114
106-46-7	1,4-Dichlorobenzene	50	50.1	100	79-114
75-71-8	Dichlorodifluoromethane	50	58.5	117	49-146
75-34-3	1,1-Dichloroethane	50	43.4	87	76-126
107-06-2	1,2-Dichloroethane	50	47.0	94	76-118
75-35-4	1,1-Dichloroethene	50	41.7	83	72-125
156-59-2	cis-1,2-Dichloroethene	50	45.0	90	80-118
156-60-5	trans-1,2-Dichloroethene	50	43.6	87	76-122
78-87-5	1,2-Dichloropropane	50	51.4	103	82-123
10061-01-5	cis-1,3-Dichloropropene	50	51.5	103	83-123
10061-02-6	trans-1,3-Dichloropropene	50	47.9	96	83-123
100-41-4	Ethylbenzene	50	45.1	90	83-115
76-13-1	Freon 113	50	40.7	81	65-132
591-78-6	2-Hexanone	200	240	120	73-138
98-82-8	Isopropylbenzene	50	44.6	89	81-122
79-20-9	Methyl Acetate	50	50.8	102	63-142
108-87-2	Methylcyclohexane	50	46.0	92	73-126
1634-04-4	Methyl Tert Butyl Ether	50	48.4	97	75-126

* = Outside of Control Limits.

Blank Spike Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
VY8980-BS	Y206950.D	1	03/08/24	PS	n/a	n/a	VY8980

The QC reported here applies to the following samples: **Method:** SW846 8260D

JD83927-14, JD83927-15, JD83927-16, JD83927-17, JD83927-18

CAS No.	Compound	Spike ug/kg	BSP ug/kg	BSP %	Limits
108-10-1	4-Methyl-2-pentanone(MIBK)	200	236	118	71-138
75-09-2	Methylene chloride	50	41.0	82	73-122
100-42-5	Styrene	50	46.6	93	84-122
79-34-5	1,1,2,2-Tetrachloroethane	50	54.7	109	75-127
127-18-4	Tetrachloroethene	50	46.3	93	73-125
108-88-3	Toluene	50	46.0	92	82-118
87-61-6	1,2,3-Trichlorobenzene	50	51.1	102	68-132
120-82-1	1,2,4-Trichlorobenzene	50	53.0	106	72-133
71-55-6	1,1,1-Trichloroethane	50	44.4	89	77-124
79-00-5	1,1,2-Trichloroethane	50	48.7	97	83-122
79-01-6	Trichloroethene	50	50.3	101	80-122
75-69-4	Trichlorofluoromethane	50	49.0	98	69-132
75-01-4	Vinyl chloride	50	52.4	105	60-144
	m,p-Xylene	100	90.2	90	82-119
95-47-6	o-Xylene	50	44.9	90	84-120
1330-20-7	Xylene (total)	150	135	90	83-119

CAS No.	Surrogate Recoveries	BSP	Limits
1868-53-7	Dibromofluoromethane	92%	80-124%
17060-07-0	1,2-Dichloroethane-D4	94%	75-133%
2037-26-5	Toluene-D8	97%	79-125%
460-00-4	4-Bromofluorobenzene	104%	58-148%

* = Outside of Control Limits.

Blank Spike Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
V1C8643-BS	1C199822.D	1	03/08/24	PS	n/a	n/a	V1C8643

The QC reported here applies to the following samples: **Method:** SW846 8260D

JD83927-1, JD83927-2, JD83927-3, JD83927-4, JD83927-5, JD83927-6, JD83927-7, JD83927-8, JD83927-9, JD83927-10, JD83927-11, JD83927-12, JD83927-13

CAS No.	Compound	Spike ug/kg	BSP ug/kg	BSP %	Limits
67-64-1	Acetone	200	234	117	52-156
71-43-2	Benzene	50	44.3	89	82-119
74-97-5	Bromochloromethane	50	51.8	104	82-123
75-27-4	Bromodichloromethane	50	47.5	95	83-121
75-25-2	Bromoform	50	50.9	102	74-138
74-83-9	Bromomethane	50	47.4	95	56-150
78-93-3	2-Butanone (MEK)	200	209	105	72-138
75-15-0	Carbon disulfide	50	42.0	84	67-131
56-23-5	Carbon tetrachloride	50	51.4	103	72-130
108-90-7	Chlorobenzene	50	46.7	93	83-114
75-00-3	Chloroethane	50	54.5	109	67-141
67-66-3	Chloroform	50	47.1	94	76-115
74-87-3	Chloromethane	50	52.9	106	57-141
110-82-7	Cyclohexane	50	50.6	101	69-130
96-12-8	1,2-Dibromo-3-chloropropane	50	51.3	103	72-131
124-48-1	Dibromochloromethane	50	49.9	100	80-128
106-93-4	1,2-Dibromoethane	50	47.2	94	58-145
95-50-1	1,2-Dichlorobenzene	50	43.9	88	83-117
541-73-1	1,3-Dichlorobenzene	50	44.3	89	82-114
106-46-7	1,4-Dichlorobenzene	50	45.4	91	79-114
75-71-8	Dichlorodifluoromethane	50	60.3	121	49-146
75-34-3	1,1-Dichloroethane	50	48.7	97	76-126
107-06-2	1,2-Dichloroethane	50	50.4	101	76-118
75-35-4	1,1-Dichloroethene	50	43.4	87	72-125
156-59-2	cis-1,2-Dichloroethene	50	44.3	89	80-118
156-60-5	trans-1,2-Dichloroethene	50	43.8	88	76-122
78-87-5	1,2-Dichloropropane	50	47.4	95	82-123
10061-01-5	cis-1,3-Dichloropropene	50	46.0	92	83-123
10061-02-6	trans-1,3-Dichloropropene	50	48.5	97	83-123
100-41-4	Ethylbenzene	50	43.8	88	83-115
76-13-1	Freon 113	50	46.9	94	65-132
591-78-6	2-Hexanone	200	192	96	73-138
98-82-8	Isopropylbenzene	50	45.8	92	81-122
79-20-9	Methyl Acetate	50	54.3	109	63-142
108-87-2	Methylcyclohexane	50	43.3	87	73-126
1634-04-4	Methyl Tert Butyl Ether	50	47.0	94	75-126

* = Outside of Control Limits.

Blank Spike Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
V1C8643-BS	1C199822.D	1	03/08/24	PS	n/a	n/a	V1C8643

The QC reported here applies to the following samples: **Method:** SW846 8260D

JD83927-1, JD83927-2, JD83927-3, JD83927-4, JD83927-5, JD83927-6, JD83927-7, JD83927-8, JD83927-9, JD83927-10, JD83927-11, JD83927-12, JD83927-13

CAS No.	Compound	Spike ug/kg	BSP ug/kg	BSP %	Limits
108-10-1	4-Methyl-2-pentanone(MIBK)	200	188	94	71-138
75-09-2	Methylene chloride	50	45.3	91	73-122
100-42-5	Styrene	50	44.5	89	84-122
79-34-5	1,1,2,2-Tetrachloroethane	50	43.2	86	75-127
127-18-4	Tetrachloroethene	50	46.0	92	73-125
108-88-3	Toluene	50	44.7	89	82-118
87-61-6	1,2,3-Trichlorobenzene	50	46.0	92	68-132
120-82-1	1,2,4-Trichlorobenzene	50	44.4	89	72-133
71-55-6	1,1,1-Trichloroethane	50	50.7	101	77-124
79-00-5	1,1,2-Trichloroethane	50	48.4	97	83-122
79-01-6	Trichloroethene	50	50.7	101	80-122
75-69-4	Trichlorofluoromethane	50	56.8	114	69-132
75-01-4	Vinyl chloride	50	56.4	113	60-144
	m,p-Xylene	100	86.9	87	82-119
95-47-6	o-Xylene	50	44.8	90	84-120
1330-20-7	Xylene (total)	150	132	88	83-119

CAS No.	Surrogate Recoveries	BSP	Limits
1868-53-7	Dibromofluoromethane	105%	80-124%
17060-07-0	1,2-Dichloroethane-D4	107%	75-133%
2037-26-5	Toluene-D8	93%	79-125%
460-00-4	4-Bromofluorobenzene	97%	58-148%

* = Outside of Control Limits.

Matrix Spike/Matrix Spike Duplicate Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
JD83895-4MS	Y206957.D	1	03/08/24	PS	n/a	n/a	VY8980
JD83895-4MSD	Y206958.D	1	03/08/24	PS	n/a	n/a	VY8980
JD83895-4	Y206953.D	1	03/08/24	PS	n/a	n/a	VY8980

The QC reported here applies to the following samples: **Method:** SW846 8260D

JD83927-14, JD83927-15, JD83927-16, JD83927-17, JD83927-18

CAS No.	Compound	JD83895-4 ug/kg	Q	Spike ug/kg	MS ug/kg	MS %	Spike ug/kg	MSD ug/kg	MSD %	RPD	Limits Rec/RPD
67-64-1	Acetone	ND		210	134	64	207	117	57	14	10-170/24
71-43-2	Benzene	ND		52.5	45.7	87	51.7	42.6	82	7	61-132/13
74-97-5	Bromochloromethane	ND		52.5	45.3	86	51.7	42.1	81	7	68-126/13
75-27-4	Bromodichloromethane	ND		52.5	46.1	88	51.7	43.3	84	6	65-129/12
75-25-2	Bromoform	ND		52.5	42.0	80	51.7	38.0	74	10	52-136/16
74-83-9	Bromomethane	ND		52.5	52.7	100	51.7	47.4	92	11	23-158/29
78-93-3	2-Butanone (MEK)	ND		210	151	72	207	147	71	3	45-142/14
75-15-0	Carbon disulfide	ND		52.5	38.8	74	51.7	35.9	69	8	50-140/18
56-23-5	Carbon tetrachloride	ND		52.5	42.8	81	51.7	40.7	79	5	54-139/21
108-90-7	Chlorobenzene	ND		52.5	43.8	83	51.7	39.6	77	10	57-127/15
75-00-3	Chloroethane	ND		52.5	49.5	94	51.7	46.1	89	7	30-157/29
67-66-3	Chloroform	ND		52.5	39.2	75	51.7	39.1	76	0	59-127/16
74-87-3	Chloromethane	ND		52.5	43.4	83	51.7	41.1	80	5	49-145/21
110-82-7	Cyclohexane	ND		52.5	44.6	85	51.7	41.7	81	7	39-147/21
96-12-8	1,2-Dibromo-3-chloropropane	ND		52.5	42.4	81	51.7	39.0	75	8	35-140/17
124-48-1	Dibromochloromethane	ND		52.5	46.8	89	51.7	42.3	82	10	63-129/12
106-93-4	1,2-Dibromoethane	ND		52.5	46.0	88	51.7	42.4	82	8	45-141/12
95-50-1	1,2-Dichlorobenzene	ND		52.5	42.9	82	51.7	37.6	73	13	38-136/19
541-73-1	1,3-Dichlorobenzene	ND		52.5	42.5	81	51.7	37.2	72	13	37-135/19
106-46-7	1,4-Dichlorobenzene	ND		52.5	42.7	81	51.7	37.8	73	12	36-134/19
75-71-8	Dichlorodifluoromethane	ND		52.5	46.2	88	51.7	42.9	83	7	33-152/17
75-34-3	1,1-Dichloroethane	ND		52.5	44.9	85	51.7	41.2	80	9	68-131/13
107-06-2	1,2-Dichloroethane	ND		52.5	40.9	78	51.7	38.9	75	5	64-119/12
75-35-4	1,1-Dichloroethene	ND		52.5	43.2	82	51.7	40.8	79	6	60-133/15
156-59-2	cis-1,2-Dichloroethene	ND		52.5	44.7	85	51.7	41.2	80	8	58-133/15
156-60-5	trans-1,2-Dichloroethene	ND		52.5	43.6	83	51.7	40.9	79	6	62-130/16
78-87-5	1,2-Dichloropropane	ND		52.5	48.1	92	51.7	44.6	86	8	70-127/12
10061-01-5	cis-1,3-Dichloropropene	ND		52.5	42.2	80	51.7	39.2	76	7	64-126/16
10061-02-6	trans-1,3-Dichloropropene	ND		52.5	41.5	79	51.7	37.9	73	9	61-127/13
100-41-4	Ethylbenzene	ND		52.5	42.5	81	51.7	38.1	74	11	51-133/19
76-13-1	Freon 113	ND		52.5	40.2	77	51.7	37.4	72	7	46-138/17
591-78-6	2-Hexanone	ND		210	163	78	207	145	70	12	45-144/16
98-82-8	Isopropylbenzene	ND		52.5	40.5	77	51.7	36.8	71	10	44-142/21
79-20-9	Methyl Acetate	ND		52.5	37.0	70	51.7	34.7	67	6	14-192/21
108-87-2	Methylcyclohexane	ND		52.5	40.6	77	51.7	36.6	71	10	27-149/23
1634-04-4	Methyl Tert Butyl Ether	ND		52.5	44.4	85	51.7	41.6	80	7	62-125/12

* = Outside of Control Limits.

Matrix Spike/Matrix Spike Duplicate Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
JD83895-4MS	Y206957.D	1	03/08/24	PS	n/a	n/a	VY8980
JD83895-4MSD	Y206958.D	1	03/08/24	PS	n/a	n/a	VY8980
JD83895-4	Y206953.D	1	03/08/24	PS	n/a	n/a	VY8980

The QC reported here applies to the following samples: **Method:** SW846 8260D

JD83927-14, JD83927-15, JD83927-16, JD83927-17, JD83927-18

CAS No.	Compound	JD83895-4 ug/kg	Q	Spike ug/kg	MS ug/kg	MS %	Spike ug/kg	MSD ug/kg	MSD %	RPD	Limits Rec/RPD
108-10-1	4-Methyl-2-pentanone(MIBK)	ND		210	170	81	207	160	77	6	50-138/14
75-09-2	Methylene chloride	ND		52.5	42.0	80	51.7	39.3	76	7	63-127/15
100-42-5	Styrene	ND		52.5	41.6	79	51.7	37.1	72	11	48-143/18
79-34-5	1,1,2,2-Tetrachloroethane	ND		52.5	36.6	70	51.7	33.0	64	10	44-135/20
127-18-4	Tetrachloroethene	ND		52.5	44.5	85	51.7	40.7	79	9	38-146/17
108-88-3	Toluene	ND		52.5	45.5	87	51.7	41.0	79	10	56-135/15
87-61-6	1,2,3-Trichlorobenzene	ND		52.5	37.4	71	51.7	31.2	60	18	10-153/27
120-82-1	1,2,4-Trichlorobenzene	ND		52.5	37.4	71	51.7	32.1	62	15	10-158/27
71-55-6	1,1,1-Trichloroethane	ND		52.5	45.2	86	51.7	42.5	82	6	61-134/14
79-00-5	1,1,2-Trichloroethane	ND		52.5	48.1	92	51.7	43.1	83	11	62-133/17
79-01-6	Trichloroethene	ND		52.5	57.4	109	51.7	53.2	103	8	52-144/15
75-69-4	Trichlorofluoromethane	ND		52.5	45.2	86	51.7	41.8	81	8	50-141/18
75-01-4	Vinyl chloride	ND		52.5	47.5	90	51.7	44.0	85	8	48-151/18
	m,p-Xylene	ND		105	82.7	79	103	73.7	71	12	51-135/18
95-47-6	o-Xylene	ND		52.5	41.6	79	51.7	37.3	72	11	52-137/18
1330-20-7	Xylene (total)	ND		158	124	79	155	111	72	11	50-138/17

CAS No.	Surrogate Recoveries	MS	MSD	JD83895-4	Limits
1868-53-7	Dibromofluoromethane	92%	91%	94%	80-124%
17060-07-0	1,2-Dichloroethane-D4	85%	86%	102%	75-133%
2037-26-5	Toluene-D8	100%	98%	102%	79-125%
460-00-4	4-Bromofluorobenzene	103%	103%	107%	58-148%

* = Outside of Control Limits.

Matrix Spike/Matrix Spike Duplicate Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
JD83927-1MS [a]	1C199826.D	1	03/09/24	PS	n/a	n/a	V1C8643
JD83927-1MSD [a]	1C199827.D	1	03/09/24	PS	n/a	n/a	V1C8643
JD83927-1	1C199825.D	1	03/09/24	PS	n/a	n/a	V1C8643

The QC reported here applies to the following samples: **Method:** SW846 8260D

JD83927-1, JD83927-2, JD83927-3, JD83927-4, JD83927-5, JD83927-6, JD83927-7, JD83927-8, JD83927-9, JD83927-10, JD83927-11, JD83927-12, JD83927-13

CAS No.	Compound	JD83927-1 ug/kg	Q	Spike ug/kg	MS ug/kg	MS %	Spike ug/kg	MSD ug/kg	MSD %	RPD	Limits Rec/RPD
67-64-1	Acetone	ND		237	212	90	237	205	87	3	10-170/24
71-43-2	Benzene	ND		59.2	48.5	82	59.2	50.9	86	5	61-132/13
74-97-5	Bromochloromethane	ND		59.2	55.0	93	59.2	56.0	95	2	68-126/13
75-27-4	Bromodichloromethane	ND		59.2	51.7	87	59.2	53.7	91	4	65-129/12
75-25-2	Bromoform	ND		59.2	51.6	87	59.2	51.5	87	0	52-136/16
74-83-9	Bromomethane	ND		59.2	49.7	84	59.2	50.5	85	2	23-158/29
78-93-3	2-Butanone (MEK)	ND		237	184	78	237	186	79	1	45-142/14
75-15-0	Carbon disulfide	ND		59.2	49.9	84	59.2	48.1	81	4	50-140/18
56-23-5	Carbon tetrachloride	ND		59.2	57.7	98	59.2	58.0	98	1	54-139/21
108-90-7	Chlorobenzene	ND		59.2	50.0	85	59.2	49.4	83	1	57-127/15
75-00-3	Chloroethane	ND		59.2	56.1	95	59.2	54.5	92	3	30-157/29
67-66-3	Chloroform	ND		59.2	52.6	89	59.2	52.1	88	1	59-127/16
74-87-3	Chloromethane	ND		59.2	53.4	90	59.2	53.9	91	1	49-145/21
110-82-7	Cyclohexane	ND		59.2	49.4	83	59.2	49.3	83	0	39-147/21
96-12-8	1,2-Dibromo-3-chloropropane	ND		59.2	46.8	79	59.2	48.7	82	4	35-140/17
124-48-1	Dibromochloromethane	ND		59.2	52.7	89	59.2	53.6	91	2	63-129/12
106-93-4	1,2-Dibromoethane	ND		59.2	49.4	83	59.2	49.3	83	0	45-141/12
95-50-1	1,2-Dichlorobenzene	ND		59.2	50.5	85	59.2	49.2	83	3	38-136/19
541-73-1	1,3-Dichlorobenzene	ND		59.2	48.2	81	59.2	48.3	82	0	37-135/19
106-46-7	1,4-Dichlorobenzene	ND		59.2	49.4	83	59.2	49.1	83	1	36-134/19
75-71-8	Dichlorodifluoromethane	ND		59.2	53.7	91	59.2	51.8	88	4	33-152/17
75-34-3	1,1-Dichloroethane	ND		59.2	56.2	95	59.2	55.2	93	2	68-131/13
107-06-2	1,2-Dichloroethane	ND		59.2	52.9	89	59.2	53.3	90	1	64-119/12
75-35-4	1,1-Dichloroethene	ND		59.2	49.4	83	59.2	50.6	86	2	60-133/15
156-59-2	cis-1,2-Dichloroethene	ND		59.2	48.4	82	59.2	49.6	84	2	58-133/15
156-60-5	trans-1,2-Dichloroethene	ND		59.2	49.6	84	59.2	49.3	83	1	62-130/16
78-87-5	1,2-Dichloropropane	ND		59.2	51.4	87	59.2	51.2	87	0	70-127/12
10061-01-5	cis-1,3-Dichloropropene	ND		59.2	44.0	74	59.2	45.9	78	4	64-126/16
10061-02-6	trans-1,3-Dichloropropene	ND		59.2	47.5	80	59.2	47.4	80	0	61-127/13
100-41-4	Ethylbenzene	ND		59.2	48.2	81	59.2	51.6	87	7	51-133/19
76-13-1	Freon 113	ND		59.2	53.8	91	59.2	52.1	88	3	46-138/17
591-78-6	2-Hexanone	ND		237	180	76	237	188	79	4	45-144/16
98-82-8	Isopropylbenzene	ND		59.2	49.9	84	59.2	50.8	86	2	44-142/21
79-20-9	Methyl Acetate	ND		59.2	51.7	87	59.2	47.2	80	9	14-192/21
108-87-2	Methylcyclohexane	ND		59.2	47.3	80	59.2	45.2	76	5	27-149/23
1634-04-4	Methyl Tert Butyl Ether	ND		59.2	50.7	86	59.2	49.6	84	2	62-125/12

* = Outside of Control Limits.

Matrix Spike/Matrix Spike Duplicate Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
JD83927-1MS [a]	1C199826.D	1	03/09/24	PS	n/a	n/a	V1C8643
JD83927-1MSD [a]	1C199827.D	1	03/09/24	PS	n/a	n/a	V1C8643
JD83927-1	1C199825.D	1	03/09/24	PS	n/a	n/a	V1C8643

The QC reported here applies to the following samples: **Method:** SW846 8260D

JD83927-1, JD83927-2, JD83927-3, JD83927-4, JD83927-5, JD83927-6, JD83927-7, JD83927-8, JD83927-9, JD83927-10, JD83927-11, JD83927-12, JD83927-13

CAS No.	Compound	JD83927-1 ug/kg	Q	Spike ug/kg	MS ug/kg	MS %	Spike ug/kg	MSD ug/kg	MSD %	RPD	Limits Rec/RPD
108-10-1	4-Methyl-2-pentanone(MIBK)	ND		237	189	80	237	188	79	1	50-138/14
75-09-2	Methylene chloride	ND		59.2	50.8	86	59.2	49.9	84	2	63-127/15
100-42-5	Styrene	ND		59.2	48.7	82	59.2	48.2	81	1	48-143/18
79-34-5	1,1,2,2-Tetrachloroethane	ND		59.2	32.4	55	59.2	30.3	51	7	44-135/20
127-18-4	Tetrachloroethene	ND		59.2	49.9	84	59.2	52.2	88	5	38-146/17
108-88-3	Toluene	ND		59.2	49.9	84	59.2	48.8	82	2	56-135/15
87-61-6	1,2,3-Trichlorobenzene	ND		59.2	47.9	81	59.2	47.9	81	0	10-153/27
120-82-1	1,2,4-Trichlorobenzene	ND		59.2	44.8	76	59.2	45.5	77	2	10-158/27
71-55-6	1,1,1-Trichloroethane	ND		59.2	56.9	96	59.2	57.1	97	0	61-134/14
79-00-5	1,1,2-Trichloroethane	ND		59.2	49.0	83	59.2	50.7	86	3	62-133/17
79-01-6	Trichloroethene	ND		59.2	67.5	114	59.2	68.4	116	1	52-144/15
75-69-4	Trichlorofluoromethane	ND		59.2	60.1	102	59.2	57.2	97	5	50-141/18
75-01-4	Vinyl chloride	ND		59.2	57.1	97	59.2	57.4	97	1	48-151/18
	m,p-Xylene	ND		118	99.2	84	118	99.9	84	1	51-135/18
95-47-6	o-Xylene	ND		59.2	49.6	84	59.2	46.9	79	6	52-137/18
1330-20-7	Xylene (total)	ND		177	149	84	177	147	83	1	50-138/17

CAS No.	Surrogate Recoveries	MS	MSD	JD83927-1	Limits
1868-53-7	Dibromofluoromethane	106%	105%	105%	80-124%
17060-07-0	1,2-Dichloroethane-D4	105%	107%	112%	75-133%
2037-26-5	Toluene-D8	95%	103%	99%	79-125%
460-00-4	4-Bromofluorobenzene	101%	101%	99%	58-148%

(a) Sample prepped from intact soil.

* = Outside of Control Limits.

Instrument Performance Check (BFB)

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: V1C8625-BFB
Lab File ID: 1C199346.D
Instrument ID: GCMS1C
Injection Date: 02/17/24
Injection Time: 15:03

m/e	Ion Abundance Criteria	Raw Abundance	% Relative Abundance		Pass/Fail
50	14.99 - 40.0% of mass 95	14862	20.4		Pass
75	30.0 - 60.0% of mass 95	34114	46.8		Pass
95	Base peak, 100% relative abundance	72954	100.0		Pass
96	5.0 - 9.0% of mass 95	4902	6.72		Pass
173	Less than 2.0% of mass 174	0	0.00	(0.00) [a]	Pass
174	50.0 - 120.0% of mass 95	79546	109.0		Pass
175	5.0 - 9.0% of mass 174	6356	8.71	(7.99) [a]	Pass
176	95.0 - 101.0% of mass 174	78914	108.2	(99.2) [a]	Pass
177	5.0 - 9.0% of mass 176	5025	6.89	(6.37) [b]	Pass

(a) Value is % of mass 174
(b) Value is % of mass 176

This check applies to the following Samples, MS, MSD, Blanks, and Standards:

Lab Sample ID	Lab File ID	Date Analyzed	Time Analyzed	Hours Lapsed	Client Sample ID
V1C8625-IC8625	1C199347.D	02/17/24	15:38	00:35	Initial cal 0.2
V1C8625-IC8625	1C199348.D	02/17/24	16:04	01:01	Initial cal 0.5
V1C8625-IC8625	1C199349.D	02/17/24	16:31	01:28	Initial cal 1
V1C8625-IC8625	1C199350.D	02/17/24	16:57	01:54	Initial cal 2
V1C8625-IC8625	1C199351.D	02/17/24	17:23	02:20	Initial cal 4
V1C8625-IC8625	1C199352.D	02/17/24	17:49	02:46	Initial cal 8
V1C8625-IC8625	1C199353.D	02/17/24	18:16	03:13	Initial cal 20
V1C8625-ICC8625	1C199354.D	02/17/24	18:42	03:39	Initial cal 50
V1C8625-IC8625	1C199355.D	02/17/24	19:09	04:06	Initial cal 100
V1C8625-IC8625	1C199356.D	02/17/24	19:35	04:32	Initial cal 200
V1C8625-ICV8625	1C199359.D	02/17/24	20:54	05:51	Initial cal verification 50
V1C8625-ICV8625	1C199360.D	02/17/24	21:20	06:17	Initial cal verification 50

Instrument Performance Check (BFB)

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: VY8957-BFB
Lab File ID: Y206260.D
Instrument ID: GCMSY
Injection Date: 02/12/24
Injection Time: 21:18

m/e	Ion Abundance Criteria	Raw Abundance	% Relative Abundance		Pass/Fail
50	15.0 - 40.0% of mass 95	37493	22.5		Pass
75	30.0 - 60.0% of mass 95	88080	52.8		Pass
95	Base peak, 100% relative abundance	166707	100.0		Pass
96	5.0 - 9.0% of mass 95	11128	6.68		Pass
173	Less than 2.0% of mass 174	0	0.00	(0.00) [a]	Pass
174	50.0 - 120.0% of mass 95	126395	75.8		Pass
175	5.0 - 9.0% of mass 174	9462	5.68	(7.49) [a]	Pass
176	95.0 - 101.0% of mass 174	123192	73.9	(97.5) [a]	Pass
177	5.0 - 9.0% of mass 176	8493	5.09	(6.89) [b]	Pass

(a) Value is % of mass 174
(b) Value is % of mass 176

This check applies to the following Samples, MS, MSD, Blanks, and Standards:

Lab Sample ID	Lab File ID	Date Analyzed	Time Analyzed	Hours Lapsed	Client Sample ID
VY8957-IC8957	Y206261.D	02/12/24	21:41	00:23	Initial cal 0.2
VY8957-IC8957	Y206262.D	02/12/24	22:02	00:44	Initial cal 0.5
VY8957-IC8957	Y206263.D	02/12/24	22:24	01:06	Initial cal 1
VY8957-IC8957	Y206264.D	02/12/24	22:46	01:28	Initial cal 2
VY8957-IC8957	Y206265.D	02/12/24	23:08	01:50	Initial cal 4
VY8957-IC8957	Y206266.D	02/12/24	23:29	02:11	Initial cal 8
VY8957-IC8957	Y206267.D	02/12/24	23:51	02:33	Initial cal 20
VY8957-ICC8957	Y206268.D	02/13/24	00:13	02:55	Initial cal 50
VY8957-IC8957	Y206269.D	02/13/24	00:35	03:17	Initial cal 100
VY8957-IC8957	Y206270.D	02/13/24	00:56	03:38	Initial cal 200
VY8957-ICV8957	Y206273.D	02/13/24	02:02	04:44	Initial cal verification 50
VY8957-ICV8957	Y206274.D	02/13/24	02:24	05:06	Initial cal verification 50
VY8958-CC8957	Y206278.D	02/13/24	17:10	19:52	Continuing cal 50
VY8958-CC8957	Y206279.D	02/13/24	17:45	20:27	Continuing cal 2
VY8958-BS	Y206280.D	02/13/24	18:07	20:49	Blank Spike
VY8958-MB	Y206282.D	02/13/24	19:16	21:58	Method Blank
JD82215-1	Y206283.D	02/13/24	19:38	22:20	(used for QC only; not part of job JD83927)
JD82215-1MS	Y206284.D	02/13/24	20:00	22:42	Matrix Spike
JD82215-1MSD	Y206285.D	02/13/24	20:22	23:04	Matrix Spike Duplicate
ZZZZZZ	Y206287.D	02/13/24	21:05	23:47	(unrelated sample)
ZZZZZZ	Y206288.D	02/13/24	21:27	24:09	(unrelated sample)
ZZZZZZ	Y206289.D	02/13/24	21:49	24:31	(unrelated sample)
ZZZZZZ	Y206290.D	02/13/24	22:11	24:53	(unrelated sample)

Internal Standard Area Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Check Std: V1C8643-CC8625 **Injection Date:** 03/08/24
Lab File ID: 1C199819.D **Injection Time:** 22:11
Instrument ID: GCMS1C **Method:** SW846 8260D

	IS 1 AREA	RT	IS 2 AREA	RT	IS 3 AREA	RT	IS 4 AREA	RT	IS 5 AREA	RT
Check Std	61400	7.04	215721	9.29	320010	10.21	244745	13.38	130234	15.70
Upper Limit [a]	122800	7.54	431442	9.79	640020	10.71	489490	13.88	260468	16.20
Lower Limit [b]	30700	6.54	107861	8.79	160005	9.71	122373	12.88	65117	15.20

Lab Sample ID	IS 1 AREA	RT	IS 2 AREA	RT	IS 3 AREA	RT	IS 4 AREA	RT	IS 5 AREA	RT
V1C8643-BS	67023	7.04	222195	9.29	332622	10.21	247509	13.38	136676	15.70
V1C8643-MB	57302	7.04	224892	9.29	317374	10.21	239833	13.38	129185	15.70
JD83927-1	60784	7.04	224961	9.29	326310	10.21	244080	13.38	135121	15.70
JD83927-1MS [c]	56417	7.04	216396	9.29	329597	10.21	246442	13.38	128012	15.70
JD83927-1MSD [c]	51842	7.04	221467	9.29	327778	10.21	244095	13.38	127080	15.70
JD83927-2	63244	7.04	234342	9.29	342941	10.21	253352	13.38	131851	15.70
JD83927-3	61804	7.04	228117	9.29	329850	10.21	238504	13.38	134019	15.70
JD83927-4	53782	7.04	225729	9.29	328748	10.20	253824	13.38	131932	15.70
JD83927-5	58501	7.04	218996	9.29	319618	10.21	246749	13.38	127849	15.70
JD83927-6	60856	7.03	225284	9.29	312437	10.21	252046	13.38	134361	15.70
JD83927-7	58805	7.03	226219	9.29	322844	10.21	247865	13.38	126815	15.70
JD83927-8	59713	7.03	223382	9.29	326198	10.21	249670	13.38	128457	15.70
JD83927-9	52770	7.04	224199	9.29	327614	10.21	241680	13.38	129999	15.70
JD83927-10	58092	7.03	221002	9.29	322480	10.21	243919	13.38	130483	15.70
JD83927-11	59920	7.03	218026	9.29	316553	10.21	241386	13.38	128917	15.70
JD83927-12	60243	7.04	223127	9.29	323137	10.21	240736	13.38	128605	15.70
JD83927-13	56528	7.04	221555	9.29	320717	10.21	235492	13.38	124929	15.70
ZZZZZZ	78436	7.04	219220	9.29	320597	10.21	241335	13.38	137472	15.70
ZZZZZZ	61052	7.03	214516	9.29	312345	10.21	240873	13.38	124668	15.70
ZZZZZZ	64198	7.03	218642	9.29	320296	10.21	257474	13.38	134729	15.70
ZZZZZZ	57407	7.03	219076	9.29	321403	10.21	239702	13.38	126524	15.70
ZZZZZZ	61914	7.03	219251	9.29	318409	10.21	230169	13.38	132111	15.70
ZZZZZZ	67100	7.04	221770	9.29	321734	10.21	250113	13.38	127555	15.70

IS 1 = Tert Butyl Alcohol-D9
IS 2 = Pentafluorobenzene
IS 3 = 1,4-Difluorobenzene
IS 4 = Chlorobenzene-D5
IS 5 = 1,4-Dichlorobenzene-d4

(a) Upper Limit = + 100% of check standard area; Retention time + 0.5 minutes.
(b) Lower Limit = -50% of check standard area; Retention time -0.5 minutes.
(c) Sample prepped from intact soil.

Internal Standard Area Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Check Std: VY8980-CC8957 **Injection Date:** 03/08/24
Lab File ID: Y206949.D **Injection Time:** 10:38
Instrument ID: GCMSY **Method:** SW846 8260D

	IS 1 AREA	RT	IS 2 AREA	RT	IS 3 AREA	RT	IS 4 AREA	RT	IS 5 AREA	RT
Check Std	129512	1.83	225515	2.92	442294	3.48	380693	5.94	209450	7.83
Upper Limit [a]	259024	2.33	451030	3.42	884588	3.98	761386	6.44	418900	8.33
Lower Limit [b]	64756	1.33	112758	2.42	221147	2.98	190347	5.44	104725	7.33

Lab Sample ID	IS 1 AREA	RT	IS 2 AREA	RT	IS 3 AREA	RT	IS 4 AREA	RT	IS 5 AREA	RT
VY8980-BS	141711	1.83	246524	2.93	456171	3.48	418875	5.94	230845	7.82
VY8980-MB	98765	1.82	241652	2.92	435573	3.48	384061	5.94	220834	7.83
JD83895-4	107790	1.83	242005	2.93	442059	3.48	383906	5.94	210359	7.82
ZZZZZZ	101683	1.83	231297	2.93	418579	3.48	369681	5.94	205036	7.83
ZZZZZZ	99628	1.82	222675	2.92	410150	3.48	360119	5.94	203612	7.83
ZZZZZZ	86495	1.83	226524	2.92	413172	3.48	361289	5.94	200034	7.83
JD83895-4MS	81487	1.83	237825	2.93	472345	3.48	397550	5.94	211318	7.83
JD83895-4MSD	95293	1.83	241703	2.93	474224	3.48	407279	5.94	213452	7.82
ZZZZZZ	105674	1.82	229377	2.92	412689	3.48	363098	5.94	206620	7.83
ZZZZZZ	124712	1.83	237013	2.93	432629	3.48	380662	5.94	209449	7.83
ZZZZZZ	102280	1.83	237259	2.93	437202	3.48	385299	5.94	213473	7.82
ZZZZZZ	102273	1.83	242398	2.93	449170	3.48	389478	5.94	216532	7.83
ZZZZZZ	108014	1.83	233801	2.93	431082	3.48	385491	5.94	214914	7.83
ZZZZZZ	121142	1.82	237237	2.92	434601	3.48	381927	5.94	219051	7.82
ZZZZZZ	116218	1.83	235835	2.93	432308	3.48	384364	5.94	215278	7.82
ZZZZZZ	104563	1.83	227472	2.93	419160	3.48	370051	5.94	199998	7.83
ZZZZZZ	98413	1.82	228929	2.92	416094	3.48	369303	5.94	205711	7.82
ZZZZZZ	88109	1.82	217120	2.92	403618	3.47	356231	5.94	197865	7.82
ZZZZZZ	93485	1.83	220168	2.93	402965	3.48	359716	5.94	200340	7.83
ZZZZZZ	68096	1.82	198131	2.92	357295	3.48	295079	5.94	148408	7.82
JD83927-14	94426	1.83	223737	2.93	409038	3.48	357772	5.94	194857	7.83
JD83927-15	116911	1.82	223285	2.92	409586	3.48	362693	5.94	205715	7.82
JD83927-16	108424	1.83	218156	2.93	403459	3.48	359839	5.94	203138	7.83
JD83927-17	110539	1.83	221179	2.93	408009	3.48	360055	5.94	203817	7.83
JD83927-18	94544	1.82	222750	2.92	411783	3.48	369343	5.94	208573	7.83

IS 1 = Tert Butyl Alcohol-D9
IS 2 = Pentafluorobenzene
IS 3 = 1,4-Difluorobenzene
IS 4 = Chlorobenzene-D5
IS 5 = 1,4-Dichlorobenzene-d4

(a) Upper Limit = + 100% of check standard area; Retention time + 0.5 minutes.
(b) Lower Limit = -50% of check standard area; Retention time -0.5 minutes.

Surrogate Recovery Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Method: SW846 8260D **Matrix:** SO

Samples and QC shown here apply to the above method

Lab Sample ID	Lab File ID	S1	S2	S3	S4
JD83927-1	1C199825.D	105	112	99	99
JD83927-2	1C199829.D	104	105	101	97
JD83927-3	1C199830.D	107	110	103	101
JD83927-4	1C199831.D	107	111	96	98
JD83927-5	1C199832.D	103	110	97	98
JD83927-6	1C199833.D	106	116	99	93
JD83927-7	1C199834.D	104	110	97	97
JD83927-8	1C199835.D	105	108	96	96
JD83927-9	1C199836.D	103	110	102	94
JD83927-10	1C199837.D	103	109	97	97
JD83927-11	1C199838.D	107	110	102	95
JD83927-12	1C199839.D	102	111	99	97
JD83927-13	1C199840.D	104	110	105	96
JD83927-14	Y206973.D	93	102	102	107
JD83927-15	Y206974.D	94	103	102	104
JD83927-16	Y206975.D	96	102	100	103
JD83927-17	Y206976.D	94	103	101	104
JD83927-18	Y206977.D	94	101	99	104
JD83895-4MS	Y206957.D	92	85	100	103
JD83895-4MSD	Y206958.D	91	86	98	103
JD83927-1MS	1C199826.D	106	105	95	101
JD83927-1MSD	1C199827.D	105	107	103	101
V1C8643-BS	1C199822.D	105	107	93	97
V1C8643-MB	1C199824.D	102	108	100	91
VY8980-BS	Y206950.D	92	94	97	104
VY8980-MB	Y206952.D	93	100	101	101

Surrogate Compounds	Recovery Limits
S1 = Dibromofluoromethane	80-124%
S2 = 1,2-Dichloroethane-D4	75-133%
S3 = Toluene-D8	79-125%
S4 = 4-Bromofluorobenzene	58-148%

Initial Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: V1C8625-ICC8625
Lab FileID: 1C199354.D

Response Factor Report GCMS1C

Method : C:\MSDCHEM\1\METHODS\M1C8625.M (RTE Integrator)
Title : SW846 8260C/D, DB-624 60 m x 0.25 mm x 1.4 um
Last Update : Fri Feb 23 10:56:52 2024
Response via : Initial Calibration

Calibration Files
1 =1C199349.D 0.5 =1C199348.D 100 =1C199355.D 50 =1C199354.D
20 =1C199353.D 200 =1C199356.D 4 =1C199351.D 2 =1C199350.D
8 =1C199352.D 0.2 =1C199347.D = =

Compound	1	0.5	100	50	20	200	4	2	8	0.2	Avg	%RSD
1) tert butyl alcohol-d9	----------ISTD----------											
2) tertiary butyl alcohol			1.308	1.210	1.169	1.222	1.358	1.254	1.170		1.242	5.69
3) ethanol	0.152		0.158	0.145	0.147	0.150	0.159	0.143	0.140		0.149	4.47
4) 1,4-dioxane			0.116	0.110	0.114	0.113	0.122		0.112		0.115	3.51
5) I pentafluorobenzene	----------ISTD----------											
6) dichlorodifluoromethane	0.385	0.434	0.456	0.421	0.409	0.437	0.459	0.427	0.465		0.433	5.95
7) chlorodifluoromethane	0.714	0.700	0.649	0.610	0.618	0.618	0.712	0.631	0.670		0.658	6.45
8) chloromethane	0.592	0.633	0.567	0.548	0.548	0.549	0.629	0.574	0.586		0.581	5.64
9) vinyl chloride	0.370	0.359	0.447	0.434	0.410	0.443	0.462	0.426	0.435		0.421	8.33
10) 1,3-butadiene	0.452	0.384	0.408	0.388	0.392	0.385	0.437	0.377	0.433		0.406	6.81
11) bromomethane			0.245	0.226	0.235	0.244	0.310	0.283	0.269		0.259	11.51
12) chloroethane	0.181		0.222	0.216	0.213	0.219	0.237	0.212	0.217		0.215	7.25
13) trichlorofluoromethane	0.595	0.527	0.657	0.626	0.604	0.639	0.659	0.581	0.652		0.616	7.09
14) ethyl ether	0.140		0.149	0.145	0.147	0.144	0.142	0.122	0.132		0.140	6.27
15) acrolein			0.054	0.050	0.048	0.051	0.038		0.046		0.048	11.51
16) freon 113	0.352	0.299	0.335	0.323	0.327	0.332	0.358	0.295	0.335		0.329	6.42
17) 1,1-dichloroethene	0.383	0.395	0.322	0.313	0.311	0.312	0.372	0.311	0.322		0.338	10.31
18) acetone			0.029	0.026	0.025	0.028	0.028	0.016	0.024		0.025	18.34
19) acetonitrile			0.045	0.044	0.044	0.041	0.052		0.043		0.045	8.80
20) iodomethane			0.549	0.490	0.380	0.535	0.268		0.299		0.420	29.00
----- Linear regression ----- Coefficient = 0.9968												
Response Ratio = -0.03170 + 0.54154 *A												
21) carbon disulfide	1.367		1.165	1.112	1.163	1.119	1.307	1.105	1.219		1.195	8.09

Initial Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: V1C8625-ICC8625
Lab FileID: 1C199354.D

22) methylene chloride
0.432 0.335 0.319 0.340 0.319 0.401 0.374 0.337 0.357 11.53
23) methyl acetate
0.039 0.036 0.035 0.036 0.030 0.028 0.034 11.74
24) methyl tert butyl ether
0.851 0.843 0.871 0.822 0.795 0.808 0.883 0.755 0.794 0.825 4.97
25) trans-1,2-dichloroethene
0.445 0.472 0.354 0.349 0.353 0.343 0.415 0.335 0.369 0.382 13.01
26) di-isopropyl ether
1.424 1.335 1.426 1.404 1.407 1.394 1.525 1.286 1.399 1.353 1.395 4.55
27) 2-butanone
0.029 0.027 0.027 0.027 0.028 0.016 0.027 0.026 17.26
28) 1,1-dichloroethane
0.733 0.714 0.714 0.676 0.709 0.674 0.811 0.651 0.702 0.667 0.705 6.40
29) chloroprene
0.647 0.610 0.648 0.615 0.627 0.619 0.687 0.596 0.678 0.636 4.86
30) acrylonitrile
0.126 0.116 0.112 0.111 0.090 0.101 0.109 11.28
31) hexane
0.787 0.752 0.673 0.649 0.669 0.635 0.739 0.634 0.690 0.692 7.97
32) vinyl acetate
0.038 0.033 0.033 0.033 0.025 0.027 0.031 15.18
33) ethyl tert-butyl ether
1.141 1.074 1.196 1.131 1.129 1.155 1.286 1.027 1.142 1.011 1.129 7.08
34) ethyl acetate
0.054 0.051 0.058 0.048 0.051 0.040 0.051 0.050 10.86
35) 2,2-dichloropropane
0.600 0.555 0.566 0.552 0.569 0.556 0.646 0.517 0.585 0.572 6.31
36) cis-1,2-dichloroethene
0.483 0.483 0.382 0.377 0.387 0.377 0.466 0.405 0.408 0.419 10.89
37) methyl acrylate
0.039 0.036 0.037 0.037 0.022 0.028 0.033 20.58
----- Linear regression ----- Coefficient = 0.9988
Response Ratio = -0.00127 + 0.03794 *A

38) propionitrile
0.042 0.043 0.043 0.043 0.041 0.045 0.035 0.041 0.042 7.50
39) bromochloromethane
0.161 0.192 0.177 0.174 0.179 0.170 0.196 0.156 0.182 0.176 7.34
40) tetrahydrofuran
0.111 0.107 0.104 0.099 0.124 0.115 0.106 0.109 7.55
41) chloroform
0.530 0.581 0.439 0.433 0.444 0.432 0.535 0.440 0.448 0.476 11.91
42) t-butyl formate
0.124 0.120 0.106 0.115 0.121 0.089 0.111 0.112 10.87
43) dibromofluoromethane (s)
0.457 0.464 0.467 0.454 0.459 0.470 0.459 0.451 0.465 0.445 0.459 1.71
44) methacrylonitrile
0.109 0.106 0.107 0.105 0.107 0.101 0.106 2.61
45) 1,1,1-trichloroethane
0.670 0.615 0.626 0.600 0.605 0.618 0.699 0.553 0.648 0.626 6.74
46) cyclohexane
0.418 0.477 0.481 0.464 0.451 0.460 0.492 0.436 0.485 0.462 5.28
47) 1,1-dichloropropene
0.516 0.465 0.499 0.481 0.504 0.494 0.554 0.430 0.531 0.497 7.33
48) iso-butyl alcohol
0.017 0.015 0.015 0.015 0.018 0.013 0.016 0.015 11.55
49) carbon tetrachloride
0.638 0.536 0.598 0.575 0.592 0.583 0.641 0.540 0.598 0.627 0.593 6.15
50) tert amyl alcohol

Initial Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: V1C8625-ICC8625
Lab FileID: 1C199354.D

```
                  0.014 0.013 0.013 0.013 0.014       0.013        0.013    3.82

51) I   1,4-difluorobenzene   ----------------ISTD--------------------
52)  1,2-dichloroethane-d4 (s)
      0.295 0.298 0.305 0.316 0.319 0.306 0.305 0.310 0.311 0.288  0.305    3.13
53)  n-butyl alcohol
                  0.007 0.007 0.006 0.007 0.006 0.004 0.006        0.006#  14.37
54)  2,2,4-trimethylpentane
      1.323 1.222 1.174 1.150 1.089 1.082 1.303 1.128 1.222        1.188    7.28
55)  benzene
      1.037 1.000 0.970 0.977 0.909 0.937 1.086 0.960 0.993 1.057  0.993    5.48
56)  tert-amyl methyl ether
      0.129       0.154 0.153 0.138 0.146 0.165 0.134 0.147        0.146    8.13
57)  heptane
      0.215 0.215 0.192 0.199 0.194 0.177 0.210 0.201 0.204        0.201    6.06
58)  isopropyl acetate
                  0.033 0.034 0.031 0.031 0.027       0.031        0.031    7.49
59)  1,2-dichloroethane
      0.347 0.361 0.339 0.339 0.319 0.323 0.369 0.342 0.337        0.342    4.65
60)  trichloroethene
      0.309 0.304 0.283 0.294 0.293 0.284 0.324 0.272 0.296 0.228  0.289    8.97
61)  ethyl acrylate
                  0.265 0.273 0.259 0.253 0.271 0.226 0.257        0.258    6.13
62)  2-nitropropane
                                                                   0.000#  -1.00
63)  2-chloroethyl vinyl ether
      0.095 0.093 0.112 0.113 0.106 0.112 0.114 0.095 0.104        0.105    8.07
64)  methyl methacrylate
                  0.046 0.043 0.041 0.040 0.040       0.038        0.041    6.82
65)  1,2-dichloropropane
      0.277 0.240 0.275 0.269 0.259 0.258 0.298 0.264 0.279        0.269    6.09
66)  dibromomethane
      0.152 0.130 0.155 0.152 0.145 0.145 0.156 0.139 0.141        0.146    5.94
67)  methylcyclohexane
      0.417 0.427 0.390 0.397 0.389 0.384 0.422 0.385 0.402        0.401    4.11
68)  bromodichloromethane
      0.330 0.352 0.334 0.341 0.326 0.335 0.369 0.326 0.338 0.346  0.340    3.89
69)  epichlorohydrin
                  0.020 0.020 0.020 0.019 0.021       0.019        0.020    4.19
70)  cis-1,3-dichloropropene
      0.376 0.360 0.385 0.383 0.363 0.391 0.412 0.332 0.375        0.375    5.94
71)  4-methyl-2-pentanone
      0.071 0.063 0.076 0.076 0.074 0.075 0.080 0.070 0.074        0.073    6.71
72)  3-methyl-1-butanol
                  0.011 0.010 0.009 0.011 0.010 0.008 0.009        0.010#   9.86

73) I   chlorobenzene-d5      ----------------ISTD--------------------
74)  toluene-d8 (s)
      1.341 1.382 1.329 1.368 1.372 1.329 1.455 1.387 1.366 1.417  1.375    2.86
75)  toluene
      0.825 0.750 0.738 0.714 0.733 0.709 0.886 0.737 0.750        0.760    7.60
76)  trans-1,3-dichloropropene
      0.413 0.373 0.435 0.436 0.418 0.406 0.475 0.351 0.410        0.413    8.71
77)  ethyl methacrylate
      0.218       0.271 0.264 0.256 0.245 0.279 0.228 0.246        0.251    8.33
78)  1,1,2-trichloroethane
      0.209 0.178 0.203 0.202 0.200 0.194 0.234 0.176 0.199        0.199    8.58
79)  tetrachloroethene
      0.340 0.246 0.300 0.308 0.304 0.287 0.362 0.289 0.310        0.305   10.70
80)  1,3-dichloropropane
```

Initial Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: V1C8625-ICC8625
Lab FileID: 1C199354.D

	0.334	0.308	0.340	0.362	0.354	0.326	0.427	0.332	0.324		0.345	10.04
81)	2-hexanone											
	0.085		0.095	0.099	0.095	0.090	0.111	0.077	0.090		0.093	10.87
82)	butyl acetate											
	0.161		0.160	0.161	0.148	0.151	0.188	0.124	0.150		0.155	11.50
83)	dibromochloromethane											
	0.376	0.321	0.364	0.352	0.334	0.337	0.409	0.306	0.336	0.331	0.347	8.59
84)	1,2-dibromoethane											
	0.268	0.219	0.249	0.252	0.246	0.242	0.296	0.216	0.239		0.248	9.83
85)	n-butyl ether											
	1.244	1.259	1.224	1.201	1.178	1.127	1.398	1.177	1.206		1.224	6.23
86)	chlorobenzene											
	0.845	0.816	0.803	0.786	0.789	0.764	0.945	0.778	0.793		0.813	6.71
87)	1,1,1,2-tetrachloroethane											
	0.291	0.259	0.337	0.336	0.316	0.309	0.382	0.291	0.310		0.315	11.10
88)	ethylbenzene											
	1.404	1.414	1.321	1.324	1.295	1.224	1.550	1.281	1.314		1.347	7.12
89)	m,p-xylene											
	0.549	0.527	0.488	0.488	0.488	0.484	0.598	0.477	0.524	0.598	0.522	8.86
90)	o-xylene											
	0.490	0.458	0.496	0.491	0.497	0.463	0.579	0.435	0.497	0.574	0.498	9.31
91)	styrene											
	0.815	0.792	0.817	0.797	0.799	0.777	0.936	0.722	0.798	0.938	0.819	8.25
92)	bromoform											
	0.238	0.192	0.258	0.239	0.224	0.247	0.263	0.206	0.215		0.231	10.38
93)	butyl acrylate											
	0.438	0.449	0.555	0.532	0.474	0.488	0.558	0.405	0.467		0.485	11.00
94)	isopropylbenzene											
	1.303	1.151	1.189	1.179	1.177	1.159	1.354	1.079	1.193		1.198	6.87
95)	cis-1,4-dichloro-2-butene											
	0.088		0.118	0.109	0.107	0.111	0.105	0.082	0.096		0.102	12.06
96)	I 1,4-dichlorobenzene-d ----------ISTD----------											
97)	4-bromofluorobenzene (s)											
	0.816	0.880	0.848	0.812	0.851	0.818	0.855	0.820	0.819	0.825	0.834	2.73
98)	bromobenzene											
	0.692	0.667	0.742	0.700	0.684	0.681	0.812	0.710	0.729		0.713	6.16
99)	1,1,2,2-tetrachloroethane											
	0.481	0.506	0.538	0.501	0.485	0.487	0.543	0.471	0.480		0.499	5.16
100)	trans-1,4-dichloro-2-butene											
			0.174	0.167	0.159	0.167	0.187	0.145	0.168		0.167	7.85
101)	1,2,3-trichloropropane											
			0.129	0.123	0.116	0.117	0.131	0.098	0.113		0.118	9.52
102)	n-propylbenzene											
	2.950	2.942	2.853	2.742	2.727	2.561	3.105	2.672	2.907		2.829	5.93
103)	2-chlorotoluene											
	0.652	0.660	0.653	0.612	0.580	0.592	0.678	0.588	0.621		0.626	5.71
104)	4-chlorotoluene											
	1.881	1.818	1.726	1.631	1.566	1.699	1.887	1.663	1.736		1.734	6.36
105)	1,3,5-trimethylbenzene											
	2.014	2.161	2.125	1.992	1.830	1.951	2.169	1.895	2.025		2.018	5.83
106)	tert-butylbenzene											
	0.357	0.329	0.376	0.332	0.313	0.339	0.365	0.315	0.335		0.340	6.38
107)	1,2,4-trimethylbenzene											
	2.047	2.113	2.119	1.891	1.879	1.909	1.996	1.765	2.030		1.972	6.02
108)	sec-butylbenzene											
	2.679	2.540	2.678	2.557	2.535	2.354	2.874	2.286	2.637		2.571	6.87
109)	1,3-dichlorobenzene											
	1.351	1.505	1.365	1.242	1.233	1.165	1.449	1.278	1.285		1.319	8.24
110)	p-isopropyltoluene											

Initial Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: V1C8625-ICC8625
Lab FileID: 1C199354.D

```
       2.371 2.481 2.347 2.219 2.136 2.187 2.498 2.056 2.322        2.291    6.63
111)  1,2,3-trimethylbenzene
       1.990 2.154 2.067 1.935 1.880 1.850 2.255 1.842 1.961        1.993    7.10
112)  1,4-dichlorobenzene
       1.373 1.490 1.326 1.250 1.228 1.188 1.463 1.248 1.334        1.322    7.93
113)  benzyl chloride
       0.896 0.899 1.058 0.996 0.934 0.963 1.050 0.923 0.911        0.959    6.52
114)  1,2-dichlorobenzene
       1.324 1.433 1.331 1.227 1.123 1.156 1.356 1.197 1.188        1.259    8.34
115)  n-butylbenzene
       1.184 1.255 1.250 1.126 1.050 1.046 1.230 1.034 1.176        1.150    7.78
116)  1,2-dibromo-3-chloropropane
                   0.117 0.113 0.099 0.101 0.119 0.087 0.108        0.106   10.60
117)  1,3,5-trichlorobenzene
       1.176 1.384 1.148 1.150 1.099 0.979 1.254 0.986 1.110        1.143   10.98
118)  1,2,4-trichlorobenzene
       1.019 1.104 0.947 0.922 0.837 0.774 0.958 0.905 0.921        0.932   10.26
119)  hexachlorobutadiene
       0.686 0.663 0.634 0.603 0.586 0.553 0.682 0.583 0.639        0.625    7.52
120)  naphthalene
       1.724 1.952 1.691 1.474 1.479 1.357 1.615 1.418 1.541        1.583   11.65
121)  1,2,3-trichlorobenzene
       0.858 0.926 0.864 0.833 0.785 0.729 0.872 0.775 0.797        0.826    7.29
122)  hexachloroethane
       0.479 0.378 0.579 0.527 0.468 0.513 0.494 0.424 0.472        0.482   12.08
123)  2-methylnaphthalene
       0.831       1.073 0.911 0.780 0.862 0.693 0.676 0.777        0.825   15.49

124)     pentafluorobenzene(a) ----------------ISTD---------------------
125)  vinyl bromide
       0.342       0.361 0.339 0.328 0.343 0.312 0.327 0.320        0.334    4.61

126)     1,4-dichlorobenzene-d ----------------ISTD---------------------
127)  pentachloroethane
                                                                    0.000#  -1.00
 ------------------------------------------------------------------------------
 (#) = Out of Range  ###  Number of calibration levels exceeded format  ###

           M1C8625.M         Fri Feb 23 10:57:34 2024
```

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: V1C8625-ICV8625
Lab FileID: 1C199359.D

Evaluate Continuing Calibration Report

Data File : C:\msdchem\1\DATA\V1C8625\1C199359.D Vial: 15
Acq On : 17 Feb 2024 8:54 pm Operator: PrashanS
Sample : ICV8625-50 Inst : GCMS1C
Misc : MS77669,V1C8625,5.0,,,,1 Multiplr: 1.00
MS Integration Params: rteint.p

Method : C:\MSDCHEM\1\METHODS\M1C8625.M (RTE Integrator)
Title : SW846 8260C/D, DB-624 60 m x 0.25 mm x 1.4 um
Last Update : Tue Feb 20 11:56:58 2024
Response via : Multiple Level Calibration

Min. RRF : 0.010 Min. Rel. Area : 50% Max. R.T. Dev 0.50min
Max. RRF Dev : 30% Max. Rel. Area : 200%

		Compound	AvgRF	CCRF	%Dev	Area%	Dev(min)	R.T.
1		tert butyl alcohol-d9	1.000	1.000	0.0	104	-0.01	7.04
2	M	tertiary butyl alcohol	1.242	1.208	2.7	104	0.00	7.16
3		ethanol	0.149	0.153	-2.7	110	0.00	5.80
4	M	1,4-dioxane	0.115	0.116	-0.9	110	0.00	10.94
5	I	pentafluorobenzene	1.000	1.000	0.0	99	0.00	9.29
6	M	dichlorodifluoromethane	0.433	0.514	-18.7	121	0.00	3.64
7		chlorodifluoromethane		----------NA----------				
8	M	chloromethane	0.581	0.635	-9.3	115	0.00	4.04
9	M	vinyl chloride	0.421	0.480	-14.0	110	0.00	4.26
10		1,3-butadiene	0.406	0.355	12.6	91	0.00	4.33
11	M	bromomethane	0.259	0.303	-17.0	134	0.02	4.91
12	M	chloroethane	0.215	0.242	-12.6	112	0.01	5.09
13	M	trichlorofluoromethane	0.616	0.635	-3.1	101	0.00	5.51
14	M	ethyl ether	0.140	0.142	-1.4	97	0.00	5.95
15	M	acrolein	0.048	0.046	4.2	92	0.00	6.21
16		freon 113	0.329	0.333	-1.2	102	0.00	6.31
17	M	1,1-dichloroethene	0.338	0.327	3.3	104	0.00	6.36
18	M	acetone	0.025	0.029	-16.0	109	0.00	6.43
19	M	acetonitrile		----------NA----------				
		----------	True	Calc.	% Drift	----------		
20	M	iodomethane	50.000	43.737	12.5	90	0.00	6.65
		----------	AvgRF	CCRF	% Dev	----------		
21	M	carbon disulfide	1.195	1.199	-0.3	107	0.00	6.76
22	M	methylene chloride	0.357	0.333	6.7	104	0.00	7.09
23	M	methyl acetate	0.034	0.041	-20.6	113	0.00	6.89
24	M	methyl tert butyl ether	0.825	0.832	-0.8	101	0.00	7.39
25	M	trans-1,2-dichloroethene	0.382	0.361	5.5	103	0.00	7.46
26	M	di-isopropyl ether	1.395	1.441	-3.3	102	0.00	8.00
27	M	2-butanone	0.026	0.030	-15.4	109	0.00	8.73
28	M	1,1-dichloroethane	0.705	0.716	-1.6	105	0.00	8.03
29	M	chloroprene	0.636	0.682	-7.2	110	0.00	8.14
30	M	acrylonitrile	0.109	0.120	-10.1	103	0.00	7.43
31		hexane	0.692	0.682	1.4	105	0.00	7.75
32	M	vinyl acetate	0.031	0.034	-9.7	101	0.00	8.02
33	M	ethyl tert-butyl ether	1.129	1.158	-2.6	102	0.00	8.46
34	M	ethyl acetate	0.050	0.051	-2.0	100	0.00	8.75
35	M	2,2-dichloropropane	0.572	0.563	1.6	101	0.00	8.75
36	M	cis-1,2-dichloroethene	0.419	0.379	9.5	100	0.00	8.77

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: V1C8625-ICV8625
Lab FileID: 1C199359.D

			True	Calc.	% Drift			
37		methyl acrylate	50.000	60.178	-20.4	121	0.00	8.84
			AvgRF	CCRF	% Dev			
38	M	propionitrile	0.042	0.046	-9.5	108	0.00	8.84
39	M	bromochloromethane	0.176	0.180	-2.3	103	0.00	9.08
40	M	tetrahydrofuran	0.109	0.109	0.0	101	0.00	9.12
41	M	chloroform	0.476	0.453	4.8	104	0.00	9.14
42	M	t-butyl formate	0.112	0.136	-21.4	113	0.00	9.16
43	S	dibromofluoromethane (s)	0.459	0.460	-0.2	101	0.00	9.34
44	M	methacrylonitrile	0.106	0.107	-0.9	101	0.00	9.03
45	M	1,1,1-trichloroethane	0.626	0.626	0.0	104	0.00	9.38
46		cyclohexane	0.462	0.478	-3.5	103	0.00	9.45
47		1,1-dichloropropene	0.497	0.513	-3.2	106	0.00	9.57
48		iso-butyl alcohol	0.015	0.014	6.7	97	0.00	9.59
49		carbon tetrachloride	0.593	0.598	-0.8	103	0.00	9.59
50		tert amyl alcohol	0.013	0.013	0.0	101	0.00	9.70
51	I	1,4-difluorobenzene	1.000	1.000	0.0	106	0.00	10.21
52	S	1,2-dichloroethane-d4 (s)	0.305	0.298	2.3	101	0.00	9.76
53	M	n-butyl alcohol	0.006	0.006#	0.0	102	0.00	10.34
54		2,2,4-trimethylpentane	1.188	1.140	4.0	106	0.00	9.81
55	M	benzene	0.993	0.956	3.7	104	0.00	9.83
56	M	tert-amyl methyl ether	0.146	0.140	4.1	97	0.00	9.85
57	M	heptane	0.201	0.198	1.5	106	0.00	9.99
58	M	isopropyl acetate	0.031	0.032	-3.2	99	0.00	9.76
59	M	1,2-dichloroethane	0.342	0.326	4.7	102	0.00	9.85
60	M	trichloroethene	0.289	0.288	0.3	104	0.00	10.55
61		ethyl acrylate	0.258	0.271	-5.0	106	0.00	10.56
62	M	2-nitropropane		----------NA----------				
63	M	2-chloroethyl vinyl ether	0.105	0.120	-14.3	113	0.00	11.36
64	M	methyl methacrylate	0.041	0.047	-14.6	114	0.00	10.83
65	M	1,2-dichloropropane	0.269	0.264	1.9	105	0.00	10.82
66	M	dibromomethane	0.146	0.142	2.7	100	0.00	10.99
67	M	methylcyclohexane	0.401	0.412	-2.7	110	0.00	10.76
68	M	bromodichloromethane	0.340	0.328	3.5	102	0.00	11.11
69		epichlorohydrin	0.020	0.019	5.0	100	0.00	11.48
70	M	cis-1,3-dichloropropene	0.375	0.370	1.3	103	0.00	11.57
71	M	4-methyl-2-pentanone	0.073	0.074	-1.4	104	0.00	11.67
72	M	3-methyl-1-butanol	0.010	0.010	0.0	108	0.00	11.69
73	I	chlorobenzene-d5	1.000	1.000	0.0	105	0.00	13.38
74	S	toluene-d8 (s)	1.375	1.306	5.0	101	0.00	11.86
75		toluene	0.760	0.714	6.1	105	0.00	11.93
76		trans-1,3-dichloropropene	0.413	0.418	-1.2	101	0.00	12.14
77		ethyl methacrylate	0.251	0.270	-7.6	108	0.00	12.13
78		1,1,2-trichloroethane	0.199	0.193	3.0	101	0.00	12.36
79	M	tetrachloroethene		----------NA----------				
80	M	1,3-dichloropropane	0.345	0.352	-2.0	102	0.00	12.54
81		2-hexanone	0.093	0.096	-3.2	101	0.00	12.53
82	M	butyl acetate	0.155	0.156	-0.6	102	0.00	12.60
83	M	dibromochloromethane	0.347	0.331	4.6	99	0.00	12.80
84	M	1,2-dibromoethane	0.248	0.248	0.0	104	0.00	12.95
85		n-butyl ether	1.224	1.286	-5.1	113	0.00	13.32
86	M	chlorobenzene	0.813	0.789	3.0	106	0.00	13.41
87	M	1,1,1,2-tetrachloroethane	0.315	0.311	1.3	97	0.00	13.47
88	M	ethylbenzene	1.347	1.262	6.3	100	0.00	13.46
89	M	m,p-xylene	0.522	0.492	5.7	106	0.00	13.57
90	M	o-xylene	0.498	0.483	3.0	104	0.00	13.99
91	M	styrene	0.819	0.770	6.0	102	0.00	14.00

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: V1C8625-ICV8625
Lab FileID: 1C199359.D

92	M	bromoform	0.231	0.233	-0.9	102	0.00	14.27
93		butyl acrylate	0.485	0.497	-2.5	98	0.00	13.82
94		isopropylbenzene	1.198	1.191	0.6	106	0.00	14.32
95		cis-1,4-dichloro-2-butene	0.102	0.103	-1.0	99	0.00	14.41
96	I	1,4-dichlorobenzene-d4	1.000	1.000	0.0	107	0.00	15.70
97	S	4-bromofluorobenzene (s)	0.834	0.812	2.6	107	0.00	14.54
98	M	bromobenzene	0.713	0.671	5.9	102	0.00	14.73
99	M	1,1,2,2-tetrachloroethane	0.499	0.477	4.4	102	0.00	14.64
100	M	trans-1,4-dichloro-2-bute	0.167	0.164	1.8	104	0.00	14.69
101	M	1,2,3-trichloropropane	0.118	0.111	5.9	96	0.00	14.72
102	M	n-propylbenzene	2.829	2.584	8.7	101	0.00	14.74
103	M	2-chlorotoluene	0.626	0.556	11.2	97	0.00	14.88
104	M	4-chlorotoluene	1.734	1.549	10.7	101	0.00	14.98
105	M	1,3,5-trimethylbenzene	2.018	1.790	11.3	96	0.00	14.88
106	M	tert-butylbenzene	0.340	0.327	3.8	105	0.00	15.23
107	M	1,2,4-trimethylbenzene	1.972	1.851	6.1	104	0.00	15.28
108	M	sec-butylbenzene	2.571	2.408	6.3	101	0.00	15.45
109	M	1,3-dichlorobenzene	1.319	1.239	6.1	106	0.00	15.64
110	M	p-isopropyltoluene	2.291	2.130	7.0	102	0.00	15.57
111		1,2,3-trimethylbenzene		----------NA----------				
112	M	1,4-dichlorobenzene	1.322	1.252	5.3	107	0.00	15.73
113		benzyl chloride	0.959	0.862	10.1	92	0.00	15.85
114	M	1,2-dichlorobenzene	1.259	1.158	8.0	101	0.00	16.13
115	M	n-butylbenzene	1.150	1.095	4.8	104	0.00	15.99
116	M	1,2-dibromo-3-chloropropa	0.106	0.099	6.6	94	0.00	16.92
117		1,3,5-trichlorobenzene	1.143	1.130	1.1	105	0.00	17.10
118	M	1,2,4-trichlorobenzene	0.932	0.875	6.1	101	0.00	17.68
119	M	hexachlorobutadiene	0.625	0.573	8.3	101	0.00	17.78
120	M	naphthalene	1.583	1.517	4.2	110	0.00	17.93
121	M	1,2,3-trichlorobenzene	0.826	0.774	6.3	99	0.00	18.14
122	m	hexachloroethane	0.482	0.524	-8.7	106	0.00	16.39
123		2-methylnaphthalene	0.825	0.889	-7.8	104	0.00	18.90
124		pentafluorobenzene(a)	1.000	1.000	0.0	99	0.00	9.29
125		vinyl bromide		----------NA----------				
126		1,4-dichlorobenzene-d4(a)	1.000	1.000	0.0	107	0.00	15.70
127		pentachloroethane		----------NA----------				

(#) = Out of Range SPCC's out = 0 CCC's out = 0
1C199354.D M1C8625.M Tue Feb 20 12:07:32 2024

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: V1C8625-ICV8625
Lab FileID: 1C199360.D

Evaluate Continuing Calibration Report

Data File : C:\msdchem\1\DATA\V1C8625\1C199360.D Vial: 16
Acq On : 17 Feb 2024 9:20 pm Operator: PrashanS
Sample : ICV8625-50 Inst : GCMS1C
Misc : MS77669,V1C8625,5.0,,,,1 Multiplr: 1.00
MS Integration Params: rteint.p

Method : C:\MSDCHEM\1\METHODS\M1C8625.M (RTE Integrator)
Title : SW846 8260C/D, DB-624 60 m x 0.25 mm x 1.4 um
Last Update : Tue Feb 20 11:56:58 2024
Response via : Multiple Level Calibration

Min. RRF : 0.010 Min. Rel. Area : 50% Max. R.T. Dev 0.50min
Max. RRF Dev : 30% Max. Rel. Area : 200%

		Compound	AvgRF	CCRF	%Dev	Area%	Dev(min)	R.T.
1		tert butyl alcohol-d9	1.000	1.000	0.0	94	-0.01	7.04
2	M	tertiary butyl alcohol		----------NA----------				
3		ethanol		----------NA----------				
4	M	1,4-dioxane		----------NA----------				
5	I	pentafluorobenzene	1.000	1.000	0.0	103	0.00	9.29
6	M	dichlorodifluoromethane		----------NA----------				
7		chlorodifluoromethane	0.658	0.705	-7.1	119	0.00	3.67
8	M	chloromethane		----------NA----------				
9	M	vinyl chloride		----------NA----------				
10		1,3-butadiene		----------NA----------				
11	M	bromomethane		----------NA----------				
12	M	chloroethane		----------NA----------				
13	M	trichlorofluoromethane		----------NA----------				
14	M	ethyl ether		----------NA----------				
15	M	acrolein		----------NA----------				
16		freon 113		----------NA----------				
17	M	1,1-dichloroethene		----------NA----------				
18	M	acetone		----------NA----------				
19	M	acetonitrile	0.045	0.041	8.9	97	0.00	6.87
		----------	True	Calc.	% Drift	----------		
20	M	iodomethane		----------NA----------				
		----------	AvgRF	CCRF	% Dev	----------		
21	M	carbon disulfide		----------NA----------				
22	M	methylene chloride		----------NA----------				
23	M	methyl acetate		----------NA----------				
24	M	methyl tert butyl ether		----------NA----------				
25	M	trans-1,2-dichloroethene		----------NA----------				
26	M	di-isopropyl ether		----------NA----------				
27	M	2-butanone		----------NA----------				
28	M	1,1-dichloroethane		----------NA----------				
29	M	chloroprene		----------NA----------				
30	M	acrylonitrile	0.109	0.109	0.0	97	0.00	7.43
31		hexane		----------NA----------				
32	M	vinyl acetate		----------NA----------				
33	M	ethyl tert-butyl ether		----------NA----------				
34	M	ethyl acetate		----------NA----------				
35	M	2,2-dichloropropane		----------NA----------				
36	M	cis-1,2-dichloroethene		----------NA----------				

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: V1C8625-ICV8625
Lab FileID: 1C199360.D

			True	Calc.	% Drift			
37		methyl acrylate		NA				
			AvgRF	**CCRF**	**% Dev**			
38	M	propionitrile		NA				
39	M	bromochloromethane		NA				
40	M	tetrahydrofuran		NA				
41	M	chloroform		NA				
42	M	t-butyl formate		NA				
43	S	dibromofluoromethane (s)	0.459	0.454	1.1	103	0.00	9.34
44	M	methacrylonitrile		NA				
45	M	1,1,1-trichloroethane		NA				
46		cyclohexane		NA				
47		1,1-dichloropropene		NA				
48		iso-butyl alcohol		NA				
49		carbon tetrachloride		NA				
50		tert amyl alcohol		NA				
51	I	1,4-difluorobenzene	1.000	1.000	0.0	108	0.00	10.21
52	S	1,2-dichloroethane-d4 (s)	0.305	0.297	2.6	101	0.00	9.76
53	M	n-butyl alcohol		NA				
54		2,2,4-trimethylpentane		NA				
55	M	benzene		NA				
56	M	tert-amyl methyl ether		NA				
57	M	heptane		NA				
58	M	isopropyl acetate		NA				
59	M	1,2-dichloroethane		NA				
60	M	trichloroethene		NA				
61		ethyl acrylate		NA				
62	M	2-nitropropane		NA				
63	M	2-chloroethyl vinyl ether		NA				
64	M	methyl methacrylate		NA				
65	M	1,2-dichloropropane		NA				
66	M	dibromomethane		NA				
67	M	methylcyclohexane		NA				
68	M	bromodichloromethane		NA				
69		epichlorohydrin		NA				
70	M	cis-1,3-dichloropropene		NA				
71	M	4-methyl-2-pentanone		NA				
72	M	3-methyl-1-butanol		NA				
73	I	chlorobenzene-d5	1.000	1.000	0.0	104	0.00	13.38
74	S	toluene-d8 (s)	1.375	1.367	0.6	104	0.00	11.86
75		toluene		NA				
76		trans-1,3-dichloropropene		NA				
77		ethyl methacrylate		NA				
78		1,1,2-trichloroethane		NA				
79	M	tetrachloroethene	0.305	0.310	-1.6	104	0.00	12.52
80	M	1,3-dichloropropane		NA				
81		2-hexanone		NA				
82	M	butyl acetate		NA				
83	M	dibromochloromethane		NA				
84	M	1,2-dibromoethane		NA				
85		n-butyl ether		NA				
86	M	chlorobenzene		NA				
87	M	1,1,1,2-tetrachloroethane		NA				
88	M	ethylbenzene		NA				
89	M	m,p-xylene		NA				
90	M	o-xylene		NA				
91	M	styrene		NA				

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: V1C8625-ICV8625
Lab FileID: 1C199360.D

92	M	bromoform		----------NA----------				
93		butyl acrylate		----------NA----------				
94		isopropylbenzene		----------NA----------				
95		cis-1,4-dichloro-2-butene		----------NA----------				
96	I	1,4-dichlorobenzene-d4	1.000	1.000	0.0	107	0.00	15.70
97	S	4-bromofluorobenzene (s)	0.834	0.807	3.2	106	0.00	14.54
98	M	bromobenzene		----------NA----------				
99	M	1,1,2,2-tetrachloroethane		----------NA----------				
100	M	trans-1,4-dichloro-2-bute		----------NA----------				
101	M	1,2,3-trichloropropane		----------NA----------				
102	M	n-propylbenzene		----------NA----------				
103	M	2-chlorotoluene		----------NA----------				
104	M	4-chlorotoluene		----------NA----------				
105	M	1,3,5-trimethylbenzene		----------NA----------				
106	M	tert-butylbenzene		----------NA----------				
107	M	1,2,4-trimethylbenzene		----------NA----------				
108	M	sec-butylbenzene		----------NA----------				
109	M	1,3-dichlorobenzene		----------NA----------				
110	M	p-isopropyltoluene		----------NA----------				
111		1,2,3-trimethylbenzene	1.993	1.951	2.1	107	0.00	15.73
112	M	1,4-dichlorobenzene		----------NA----------				
113		benzyl chloride		----------NA----------				
114	M	1,2-dichlorobenzene		----------NA----------				
115	M	n-butylbenzene		----------NA----------				
116	M	1,2-dibromo-3-chloropropa		----------NA----------				
117		1,3,5-trichlorobenzene		----------NA----------				
118	M	1,2,4-trichlorobenzene		----------NA----------				
119	M	hexachlorobutadiene		----------NA----------				
120	M	naphthalene		----------NA----------				
121	M	1,2,3-trichlorobenzene		----------NA----------				
122	m	hexachloroethane		----------NA----------				
123		2-methylnaphthalene		----------NA----------				
124		pentafluorobenzene(a)	1.000	1.000	0.0	103	0.00	9.29
125		vinyl bromide		----------NA----------				
126		1,4-dichlorobenzene-d4(a)	1.000	1.000	0.0	107	0.00	15.70
127		pentachloroethane		----------NA----------				

(#) = Out of Range SPCC's out = 0 CCC's out = 0
1C199354.D M1C8625.M Tue Feb 20 12:05:47 2024

Continuing Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: V1C8643-CC8625
Lab FileID: 1C199819.D

Evaluate Continuing Calibration Report

Data File : X:\Dayton VOA GCMS\m...11\V1C8643\1C199819.D Vial: 1
Acq On : 8 Mar 2024 10:11 pm Operator: PrashanS
Sample : CC8625-50 Inst : GCMS1C
Misc : MS78570,V1C8643,5.0,,,,1 Multiplr: 1.00
MS Integration Params: rteint.p

Method : C:\msdchem\1\methods\M1C8625.M (RTE Integrator)
Title : SW846 8260C/D, DB-624 60 m x 0.25 mm x 1.4 um
Last Update : Mon Feb 26 10:02:23 2024
Response via : Multiple Level Calibration

Min. RRF : 0.010 Min. Rel. Area : 50% Max. R.T. Dev 0.50min
Max. RRF Dev : 20% Max. Rel. Area : 200%

		Compound	AvgRF	CCRF	%Dev	Area%	Dev(min)	R.T.
1		tert butyl alcohol-d9	1.000	1.000	0.0	78	-0.01	7.04
2	M	tertiary butyl alcohol	1.242	1.292	-4.0	83	0.00	7.16
3		ethanol	0.149	0.160	-7.4	86	-0.01	5.80
4	M	1,4-dioxane	0.115	0.115	0.0	81	0.00	10.94
5	I	pentafluorobenzene	1.000	1.000	0.0	81	0.00	9.29
6	M	dichlorodifluoromethane	0.433	0.527	-21.7#	102	0.00	3.64
7		chlorodifluoromethane	0.658	0.640	2.7	85	0.00	3.67
8	M	chloromethane	0.581	0.623	-7.2	92	0.00	4.04
9	M	vinyl chloride	0.421	0.485	-15.2	91	0.00	4.26
10		1,3-butadiene	0.406	0.375	7.6	78	0.00	4.33
11	M	bromomethane	0.259	0.256	1.2	92	0.02	4.91
12	M	chloroethane	0.215	0.240	-11.6	90	0.00	5.08
13	M	trichlorofluoromethane	0.616	0.729	-18.3	95	0.00	5.51
14	M	ethyl ether	0.140	0.137	2.1	77	0.00	5.95
15	M	acrolein	0.048	0.038	20.8#	62	0.00	6.21
16		freon 113	0.329	0.314	4.6	79	0.00	6.31
17	M	1,1-dichloroethene	0.338	0.299	11.5	78	0.00	6.36
18	M	acetone	0.025	0.028	-12.0	88	0.00	6.42
19	M	acetonitrile	0.045	0.046	-2.2	84	0.00	6.87
		----------	True	Calc.	% Drift	----------		
20	M	iodomethane	50.000	43.465	13.1	73	0.00	6.64
		----------	AvgRF	CCRF	% Dev	----------		
21	M	carbon disulfide	1.195	1.034	13.5	76	0.00	6.76
22	M	methylene chloride	0.357	0.318	10.9	81	0.00	7.09
23	M	methyl acetate	0.034	0.036	-5.9	81	0.01	6.89
24	M	methyl tert butyl ether	0.825	0.820	0.6	81	0.00	7.39
25	M	trans-1,2-dichloroethene	0.382	0.351	8.1	82	0.00	7.46
26	M	di-isopropyl ether	1.395	1.486	-6.5	86	0.00	8.00
27	M	2-butanone	0.026	0.027	-3.8	80	0.00	8.74
28	M	1,1-dichloroethane	0.705	0.705	0.0	85	0.00	8.03
29	M	chloroprene	0.636	0.679	-6.8	90	0.00	8.13
30	M	acrylonitrile	0.109	0.112	-2.8	79	0.00	7.43
31		hexane	0.692	0.614	11.3	77	0.00	7.76
32	M	vinyl acetate	0.031	0.027	12.9	67	0.00	8.02
33	M	ethyl tert-butyl ether	1.129	1.135	-0.5	82	0.00	8.46
34	M	ethyl acetate	0.050	0.050	0.0	80	0.00	8.75
35	M	2,2-dichloropropane	0.572	0.520	9.1	77	0.00	8.76
36	M	cis-1,2-dichloroethene	0.419	0.373	11.0	80	0.00	8.77

Continuing Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: V1C8643-CC8625
Lab FileID: 1C199819.D

			True	Calc.	% Drift			
37		methyl acrylate	50.000	47.374	5.3	77	0.00	8.84
			AvgRF	CCRF	% Dev			
38	M	propionitrile	0.042	0.043	-2.4	82	0.00	8.84
39	M	bromochloromethane	0.176	0.184	-4.5	86	0.00	9.08
40	M	tetrahydrofuran	0.109	0.107	1.8	81	0.00	9.12
41	M	chloroform	0.476	0.460	3.4	86	0.00	9.14
42	M	t-butyl formate	0.112	0.078	30.4#	52	0.00	9.16
43	S	dibromofluoromethane (s)	0.459	0.485	-5.7	87	0.00	9.34
44	M	methacrylonitrile	0.106	0.101	4.7	78	0.00	9.03
45	M	1,1,1-trichloroethane	0.626	0.638	-1.9	86	0.00	9.38
46		cyclohexane	0.462	0.457	1.1	80	0.00	9.45
47		1,1-dichloropropene	0.497	0.506	-1.8	86	0.00	9.57
48		iso-butyl alcohol	0.015	0.014	6.7	77	0.00	9.58
49		carbon tetrachloride	0.593	0.633	-6.7	90	0.00	9.58
50		tert amyl alcohol	0.013	0.013	0.0	82	-0.01	9.70
51	I	1,4-difluorobenzene	1.000	1.000	0.0	87	0.00	10.21
52	S	1,2-dichloroethane-d4 (s)	0.305	0.338	-10.8	93	0.00	9.76
53	M	n-butyl alcohol	0.006	0.006#	0.0	77	0.00	10.34
54		2,2,4-trimethylpentane	1.188	1.044	12.1	79	0.00	9.81
55	M	benzene	0.993	0.914	8.0	81	0.00	9.83
56	M	tert-amyl methyl ether	0.146	0.142	2.7	80	0.00	9.85
57	M	heptane	0.201	0.160	20.4#	69	0.00	9.99
58	M	isopropyl acetate	0.031	0.031	0.0	79	0.00	9.76
59	M	1,2-dichloroethane	0.342	0.350	-2.3	89	0.00	9.85
60	M	trichloroethene	0.289	0.294	-1.7	87	0.00	10.55
61		ethyl acrylate	0.258	0.253	1.9	80	0.00	10.55
62	M	2-nitropropane		----------NA----------				
63	M	2-chloroethyl vinyl ether	0.105	0.101	3.8	77	0.00	11.35
64	M	methyl methacrylate	0.041	0.037	9.8	74	0.00	10.82
65	M	1,2-dichloropropane	0.269	0.258	4.1	83	0.00	10.82
66	M	dibromomethane	0.146	0.148	-1.4	85	0.00	10.98
67	M	methylcyclohexane	0.401	0.369	8.0	80	0.00	10.75
68	M	bromodichloromethane	0.340	0.332	2.4	84	0.00	11.11
69		epichlorohydrin	0.020	0.019	5.0	83	0.00	11.48
70	M	cis-1,3-dichloropropene	0.375	0.366	2.4	83	0.00	11.57
71	M	4-methyl-2-pentanone	0.073	0.073	0.0	83	0.00	11.67
72	M	3-methyl-1-butanol	0.010	0.009#	10.0	81	0.00	11.69
73	I	chlorobenzene-d5	1.000	1.000	0.0	86	0.00	13.38
74	S	toluene-d8 (s)	1.375	1.367	0.6	86	0.00	11.86
75		toluene	0.760	0.715	5.9	87	0.00	11.93
76		trans-1,3-dichloropropene	0.413	0.407	1.5	81	0.00	12.14
77		ethyl methacrylate	0.251	0.244	2.8	80	0.00	12.13
78		1,1,2-trichloroethane	0.199	0.190	4.5	82	0.00	12.36
79	M	tetrachloroethene	0.305	0.290	4.9	81	0.00	12.52
80	M	1,3-dichloropropane	0.345	0.340	1.4	81	0.00	12.54
81		2-hexanone	0.093	0.089	4.3	78	0.00	12.53
82	M	butyl acetate	0.155	0.152	1.9	82	0.00	12.60
83	M	dibromochloromethane	0.347	0.342	1.4	84	0.00	12.80
84	M	1,2-dibromoethane	0.248	0.237	4.4	81	0.00	12.95
85		n-butyl ether	1.224	1.165	4.8	84	0.00	13.32
86	M	chlorobenzene	0.813	0.759	6.6	83	0.00	13.41
87	M	1,1,1,2-tetrachloroethane	0.315	0.322	-2.2	83	0.00	13.47
88	M	ethylbenzene	1.347	1.202	10.8	78	0.00	13.46
89	M	m,p-xylene	0.522	0.465	10.9	82	0.00	13.57
90	M	o-xylene	0.498	0.451	9.4	79	0.00	13.98
91	M	styrene	0.819	0.767	6.3	83	0.00	14.00

Continuing Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: V1C8643-CC8625
Lab FileID: 1C199819.D

92	M	bromoform	0.231	0.232	-0.4	84	0.00	14.27
93		butyl acrylate	0.485	0.475	2.1	77	0.00	13.82
94		isopropylbenzene	1.198	1.110	7.3	81	0.00	14.32
95		cis-1,4-dichloro-2-butene	0.102	0.106	-3.9	84	0.00	14.41
96	I	1,4-dichlorobenzene-d4	1.000	1.000	0.0	86	0.00	15.70
97	S	4-bromofluorobenzene (s)	0.834	0.804	3.6	86	0.00	14.53
98	M	bromobenzene	0.713	0.701	1.7	87	0.00	14.73
99	M	1,1,2,2-tetrachloroethane	0.499	0.444	11.0	77	0.00	14.65
100	M	trans-1,4-dichloro-2-bute	0.167	0.172	-3.0	89	0.00	14.69
101	M	1,2,3-trichloropropane	0.118	0.118	0.0	82	0.00	14.72
102	M	n-propylbenzene	2.829	2.616	7.5	82	0.00	14.73
103	M	2-chlorotoluene	0.626	0.594	5.1	84	0.00	14.88
104	M	4-chlorotoluene	1.734	1.626	6.2	86	0.00	14.98
105	M	1,3,5-trimethylbenzene	2.018	1.857	8.0	81	0.00	14.88
106	M	tert-butylbenzene	0.340	0.345	-1.5	90	0.00	15.23
107	M	1,2,4-trimethylbenzene	1.972	1.853	6.0	85	0.00	15.28
108	M	sec-butylbenzene	2.571	2.508	2.5	85	0.00	15.45
109	M	1,3-dichlorobenzene	1.319	1.243	5.8	86	0.00	15.64
110	M	p-isopropyltoluene	2.291	2.154	6.0	84	0.00	15.57
111		1,2,3-trimethylbenzene	1.993	1.837	7.8	82	0.00	15.73
112	M	1,4-dichlorobenzene	1.322	1.214	8.2	84	0.00	15.73
113		benzyl chloride	0.959	0.757	21.1#	66	0.00	15.85
114	M	1,2-dichlorobenzene	1.259	1.218	3.3	86	0.00	16.13
115	M	n-butylbenzene	1.150	1.080	6.1	83	0.00	15.99
116	M	1,2-dibromo-3-chloropropa	0.106	0.106	0.0	81	0.00	16.92
117		1,3,5-trichlorobenzene	1.143	1.075	5.9	81	0.00	17.10
118	M	1,2,4-trichlorobenzene	0.932	0.866	7.1	81	0.00	17.68
119	M	hexachlorobutadiene	0.625	0.601	3.8	86	0.00	17.78
120	M	naphthalene	1.583	1.432	9.5	84	0.00	17.92
121	M	1,2,3-trichlorobenzene	0.826	0.771	6.7	80	0.00	18.14
122	m	hexachloroethane	0.482	0.508	-5.4	83	0.00	16.39
123		2-methylnaphthalene	0.825	0.740	10.3	70	0.00	18.90
124		pentafluorobenzene(a)	1.000	1.000	0.0	88	0.00	9.29
125		vinyl bromide	----------NA----------					
126		1,4-dichlorobenzene-d4(a)	1.000	1.000	0.0	86	0.00	15.70
127		pentachloroethane	----------NA----------					

(#) = Out of Range SPCC's out = 0 CCC's out = 0
1C199354.D M1C8625.M Mon Mar 11 02:39:44 2024

Continuing Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: V1C8643-CC8625
Lab FileID: 1C199820.D

Evaluate Continuing Calibration Report

Data File : X:\Dayton VOA GCMS\m...11\V1C8643\1C199820.D Vial: 2
Acq On : 8 Mar 2024 10:37 pm Operator: PrashanS
Sample : CC8625-2 Inst : GCMS1C
Misc : MS78570,V1C8643,5.0,,,,1 Multiplr: 1.00
MS Integration Params: rteint.p

Method : C:\msdchem\1\methods\M1C8625.M (RTE Integrator)
Title : SW846 8260C/D, DB-624 60 m x 0.25 mm x 1.4 um
Last Update : Mon Feb 26 10:02:23 2024
Response via : Multiple Level Calibration

Min. RRF : 0.010 Min. Rel. Area : 50% Max. R.T. Dev 0.50min
Max. RRF Dev : 200% Max. Rel. Area : 200%

		Compound	AvgRF	CCRF	%Dev	Area%	Dev(min)	R.T.
1		tert butyl alcohol-d9	1.000	1.000	0.0	78	-0.02	7.03
2	M	tertiary butyl alcohol		----------NA----------				
3		ethanol		----------NA----------				
4	M	1,4-dioxane		----------NA----------				
5	I	pentafluorobenzene	1.000	1.000	0.0	85	0.00	9.29
6	M	dichlorodifluoromethane		----------NA----------				
7		chlorodifluoromethane		----------NA----------				
8	M	chloromethane		----------NA----------				
9	M	vinyl chloride		----------NA----------				
10		1,3-butadiene		----------NA----------				
11	M	bromomethane		----------NA----------				
12	M	chloroethane		----------NA----------				
13	M	trichlorofluoromethane		----------NA----------				
14	M	ethyl ether		----------NA----------				
15	M	acrolein		----------NA----------				
16		freon 113		----------NA----------				
17	M	1,1-dichloroethene		----------NA----------				
18	M	acetone		----------NA----------				
19	M	acetonitrile		----------NA----------				
		----------	True	Calc.	% Drift	----------		
20	M	iodomethane		----------NA----------				
		----------	AvgRF	CCRF	% Dev	----------		
21	M	carbon disulfide		----------NA----------				
22	M	methylene chloride		----------NA----------				
23	M	methyl acetate		----------NA----------				
24	M	methyl tert butyl ether		----------NA----------				
25	M	trans-1,2-dichloroethene		----------NA----------				
26	M	di-isopropyl ether		----------NA----------				
27	M	2-butanone		----------NA----------				
28	M	1,1-dichloroethane		----------NA----------				
29	M	chloroprene		----------NA----------				
30	M	acrylonitrile		----------NA----------				
31		hexane		----------NA----------				
32	M	vinyl acetate		----------NA----------				
33	M	ethyl tert-butyl ether		----------NA----------				
34	M	ethyl acetate		----------NA----------				
35	M	2,2-dichloropropane		----------NA----------				
36	M	cis-1,2-dichloroethene		----------NA----------				

Continuing Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: V1C8643-CC8625
Lab FileID: 1C199820.D

			True	Calc.	% Drift			
37		methyl acrylate		NA				
			AvgRF	CCRF	% Dev			
38	M	propionitrile		NA				
39	M	bromochloromethane		NA				
40	M	tetrahydrofuran		NA				
41	M	chloroform		NA				
42	M	t-butyl formate		NA				
43	S	dibromofluoromethane (s)	0.459	0.478	-4.1	91	0.00	9.34
44	M	methacrylonitrile		NA				
45	M	1,1,1-trichloroethane		NA				
46		cyclohexane		NA				
47		1,1-dichloropropene		NA				
48		iso-butyl alcohol		NA				
49		carbon tetrachloride		NA				
50		tert amyl alcohol		NA				
51	I	1,4-difluorobenzene	1.000	1.000	0.0	86	0.00	10.21
52	S	1,2-dichloroethane-d4 (s)	0.305	0.318	-4.3	89	0.00	9.76
53	M	n-butyl alcohol		NA				
54		2,2,4-trimethylpentane		NA				
55	M	benzene		NA				
56	M	tert-amyl methyl ether		NA				
57	M	heptane	0.201	0.055	72.6	23#	-0.14	9.85
58	M	isopropyl acetate		NA				
59	M	1,2-dichloroethane		NA				
60	M	trichloroethene		NA				
61		ethyl acrylate		NA				
62	M	2-nitropropane		NA				
63	M	2-chloroethyl vinyl ether		NA				
64	M	methyl methacrylate		NA				
65	M	1,2-dichloropropane		NA				
66	M	dibromomethane		NA				
67	M	methylcyclohexane		NA				
68	M	bromodichloromethane		NA				
69		epichlorohydrin		NA				
70	M	cis-1,3-dichloropropene		NA				
71	M	4-methyl-2-pentanone		NA				
72	M	3-methyl-1-butanol		NA				
73	I	chlorobenzene-d5	1.000	1.000	0.0	89	0.00	13.38
74	S	toluene-d8 (s)	1.375	1.292	6.0	83	0.00	11.86
75		toluene		NA				
76		trans-1,3-dichloropropene		NA				
77		ethyl methacrylate		NA				
78		1,1,2-trichloroethane		NA				
79	M	tetrachloroethene		NA				
80	M	1,3-dichloropropane		NA				
81		2-hexanone		NA				
82	M	butyl acetate		NA				
83	M	dibromochloromethane		NA				
84	M	1,2-dibromoethane		NA				
85		n-butyl ether		NA				
86	M	chlorobenzene		NA				
87	M	1,1,1,2-tetrachloroethane		NA				
88	M	ethylbenzene		NA				
89	M	m,p-xylene		NA				
90	M	o-xylene		NA				
91	M	styrene		NA				

Continuing Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: V1C8643-CC8625
Lab FileID: 1C199820.D

92	M	bromoform		----------NA----------				
93		butyl acrylate		----------NA----------				
94		isopropylbenzene		----------NA----------				
95		cis-1,4-dichloro-2-butene		----------NA----------				
96	I	1,4-dichlorobenzene-d4	1.000	1.000	0.0	88	0.00	15.70
97	S	4-bromofluorobenzene (s)	0.834	0.809	3.0	86	0.00	14.54
98	M	bromobenzene		----------NA----------				
99	M	1,1,2,2-tetrachloroethane		----------NA----------				
100	M	trans-1,4-dichloro-2-bute		----------NA----------				
101	M	1,2,3-trichloropropane		----------NA----------				
102	M	n-propylbenzene		----------NA----------				
103	M	2-chlorotoluene		----------NA----------				
104	M	4-chlorotoluene		----------NA----------				
105	M	1,3,5-trimethylbenzene		----------NA----------				
106	M	tert-butylbenzene		----------NA----------				
107	M	1,2,4-trimethylbenzene		----------NA----------				
108	M	sec-butylbenzene		----------NA----------				
109	M	1,3-dichlorobenzene		----------NA----------				
110	M	p-isopropyltoluene		----------NA----------				
111		1,2,3-trimethylbenzene		----------NA----------				
112	M	1,4-dichlorobenzene		----------NA----------				
113		benzyl chloride		----------NA----------				
114	M	1,2-dichlorobenzene		----------NA----------				
115	M	n-butylbenzene		----------NA----------				
116	M	1,2-dibromo-3-chloropropa		----------NA----------				
117		1,3,5-trichlorobenzene		----------NA----------				
118	M	1,2,4-trichlorobenzene		----------NA----------				
119	M	hexachlorobutadiene		----------NA----------				
120	M	naphthalene		----------NA----------				
121	M	1,2,3-trichlorobenzene		----------NA----------				
122	m	hexachloroethane		----------NA----------				
123		2-methylnaphthalene		----------NA----------				
124		pentafluorobenzene(a)	1.000	1.000	0.0	89	0.00	9.29
125		vinyl bromide		----------NA----------				
126		1,4-dichlorobenzene-d4(a)	1.000	1.000	0.0	88	0.00	15.70
127		pentachloroethane		----------NA----------				

(#) = Out of Range SPCC's out = 0 CCC's out = 0
1C199350.D M1C8625.M Mon Mar 11 03:11:16 2024

Continuing Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: V1C8643-CC8625
Lab FileID: 1C199821.D

Evaluate Continuing Calibration Report

Data File : R:\MSVOA\Done\Batch\...ap\V1C8643\1C199821.D Vial: 3
Acq On : 8 Mar 2024 11:03 pm Operator: PrashanS
Sample : CC8625-4 Inst : GCMS1C
Misc : MS78570,V1C8643,5.0,,,,1 Multiplr: 1.00
MS Integration Params: rteint.p

Method : C:\msdchem\1\methods\M1C8625.M (RTE Integrator)
Title : SW846 8260C/D, DB-624 60 m x 0.25 mm x 1.4 um
Last Update : Mon Feb 26 10:02:23 2024
Response via : Multiple Level Calibration

Min. RRF : 0.010 Min. Rel. Area : 50% Max. R.T. Dev 0.50min
Max. RRF Dev : 200% Max. Rel. Area : 200%

		Compound	AvgRF	CCRF	%Dev	Area%	Dev(min)	R.T.
1		tert butyl alcohol-d9	1.000	1.000	0.0	75	-0.01	7.04
2	M	tertiary butyl alcohol		----------NA----------				
3		ethanol		----------NA----------				
4	M	1,4-dioxane		----------NA----------				
5	I	pentafluorobenzene	1.000	1.000	0.0	85	0.00	9.29
6	M	dichlorodifluoromethane		----------NA----------				
7		chlorodifluoromethane		----------NA----------				
8	M	chloromethane		----------NA----------				
9	M	vinyl chloride		----------NA----------				
10		1,3-butadiene		----------NA----------				
11	M	bromomethane		----------NA----------				
12	M	chloroethane		----------NA----------				
13	M	trichlorofluoromethane		----------NA----------				
14	M	ethyl ether		----------NA----------				
15	M	acrolein		----------NA----------				
16		freon 113		----------NA----------				
17	M	1,1-dichloroethene		----------NA----------				
18	M	acetone		----------NA----------				
19	M	acetonitrile		----------NA----------				
		----------	True	Calc.	% Drift	----------		
20	M	iodomethane		----------NA----------				
		----------	AvgRF	CCRF	% Dev	----------		
21	M	carbon disulfide		----------NA----------				
22	M	methylene chloride		----------NA----------				
23	M	methyl acetate		----------NA----------				
24	M	methyl tert butyl ether		----------NA----------				
25	M	trans-1,2-dichloroethene		----------NA----------				
26	M	di-isopropyl ether		----------NA----------				
27	M	2-butanone		----------NA----------				
28	M	1,1-dichloroethane		----------NA----------				
29	M	chloroprene		----------NA----------				
30	M	acrylonitrile		----------NA----------				
31		hexane		----------NA----------				
32	M	vinyl acetate		----------NA----------				
33	M	ethyl tert-butyl ether		----------NA----------				
34	M	ethyl acetate		----------NA----------				
35	M	2,2-dichloropropane		----------NA----------				
36	M	cis-1,2-dichloroethene		----------NA----------				

Continuing Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: V1C8643-CC8625
Lab FileID: 1C199821.D

			True	Calc.	% Drift			
37		methyl acrylate		NA				
			AvgRF	CCRF	% Dev			
38	M	propionitrile		NA				
39	M	bromochloromethane		NA				
40	M	tetrahydrofuran		NA				
41	M	chloroform		NA				
42	M	t-butyl formate		NA				
43	S	dibromofluoromethane (s)	0.459	0.465	-1.3	86	0.00	9.35
44	M	methacrylonitrile		NA				
45	M	1,1,1-trichloroethane		NA				
46		cyclohexane		NA				
47		1,1-dichloropropene		NA				
48		iso-butyl alcohol		NA				
49		carbon tetrachloride		NA				
50		tert amyl alcohol		NA				
51	I	1,4-difluorobenzene	1.000	1.000	0.0	84	0.00	10.21
52	S	1,2-dichloroethane-d4 (s)	0.305	0.330	-8.2	91	0.00	9.76
53	M	n-butyl alcohol		NA				
54		2,2,4-trimethylpentane		NA				
55	M	benzene		NA				
56	M	tert-amyl methyl ether		NA				
57	M	heptane	0.201	0.025	87.6	10	0.01	10.00
58	M	isopropyl acetate		NA				
59	M	1,2-dichloroethane		NA				
60	M	trichloroethene		NA				
61		ethyl acrylate		NA				
62	M	2-nitropropane		NA				
63	M	2-chloroethyl vinyl ether		NA				
64	M	methyl methacrylate		NA				
65	M	1,2-dichloropropane		NA				
66	M	dibromomethane		NA				
67	M	methylcyclohexane		NA				
68	M	bromodichloromethane		NA				
69		epichlorohydrin		NA				
70	M	cis-1,3-dichloropropene		NA				
71	M	4-methyl-2-pentanone		NA				
72	M	3-methyl-1-butanol		NA				
73	I	chlorobenzene-d5	1.000	1.000	0.0	86	0.00	13.38
74	S	toluene-d8 (s)	1.375	1.413	-2.8	84	0.00	11.86
75		toluene		NA				
76		trans-1,3-dichloropropene		NA				
77		ethyl methacrylate		NA				
78		1,1,2-trichloroethane		NA				
79	M	tetrachloroethene		NA				
80	M	1,3-dichloropropane		NA				
81		2-hexanone		NA				
82	M	butyl acetate		NA				
83	M	dibromochloromethane		NA				
84	M	1,2-dibromoethane		NA				
85		n-butyl ether		NA				
86	M	chlorobenzene		NA				
87	M	1,1,1,2-tetrachloroethane		NA				
88	M	ethylbenzene		NA				
89	M	m,p-xylene		NA				
90	M	o-xylene		NA				
91	M	styrene		NA				

Continuing Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: V1C8643-CC8625
Lab FileID: 1C199821.D

92	M	bromoform		----------NA----------				
93		butyl acrylate		----------NA----------				
94		isopropylbenzene		----------NA----------				
95		cis-1,4-dichloro-2-butene		----------NA----------				
96	I	1,4-dichlorobenzene-d4	1.000	1.000	0.0	85	0.00	15.70
97	S	4-bromofluorobenzene (s)	0.834	0.828	0.7	83	0.00	14.54
98	M	bromobenzene		----------NA----------				
99	M	1,1,2,2-tetrachloroethane		----------NA----------				
100	M	trans-1,4-dichloro-2-bute		----------NA----------				
101	M	1,2,3-trichloropropane		----------NA----------				
102	M	n-propylbenzene		----------NA----------				
103	M	2-chlorotoluene		----------NA----------				
104	M	4-chlorotoluene		----------NA----------				
105	M	1,3,5-trimethylbenzene		----------NA----------				
106	M	tert-butylbenzene		----------NA----------				
107	M	1,2,4-trimethylbenzene		----------NA----------				
108	M	sec-butylbenzene		----------NA----------				
109	M	1,3-dichlorobenzene		----------NA----------				
110	M	p-isopropyltoluene		----------NA----------				
111		1,2,3-trimethylbenzene		----------NA----------				
112	M	1,4-dichlorobenzene		----------NA----------				
113		benzyl chloride		----------NA----------				
114	M	1,2-dichlorobenzene		----------NA----------				
115	M	n-butylbenzene		----------NA----------				
116	M	1,2-dibromo-3-chloropropa		----------NA----------				
117		1,3,5-trichlorobenzene		----------NA----------				
118	M	1,2,4-trichlorobenzene		----------NA----------				
119	M	hexachlorobutadiene		----------NA----------				
120	M	naphthalene		----------NA----------				
121	M	1,2,3-trichlorobenzene		----------NA----------				
122	m	hexachloroethane		----------NA----------				
123		2-methylnaphthalene		----------NA----------				
124		pentafluorobenzene(a)	1.000	1.000	0.0	86	0.00	9.29
125		vinyl bromide		----------NA----------				
126		1,4-dichlorobenzene-d4(a)	1.000	1.000	0.0	85	0.00	15.70
127		pentachloroethane		----------NA----------				

(#) = Out of Range SPCC's out = 0 CCC's out = 0

1C199351.D M1C8625.M Mon Mar 11 15:52:17 2024

Initial Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: VY8957-ICC8957
Lab FileID: Y206268.D

Response Factor Report MSY

Method : C:\MSDCHEM\1\METHODS\MY8957.M (RTE Integrator)
Title : Method SW846 8260C/D, Rxi624 20m x 0.18mm x 1.0um
Last Update : Mon Sep 13 11:48:20 2010
Response via : Initial Calibration

Calibration Files
4 =Y206265.D 8 =Y206266.D 0.5 =Y206262.D 50 =Y206268.D
100 =Y206269.D 1 =Y206263.D 200 =Y206270.D 20 =Y206267.D
2 =Y206264.D 0.2 =Y206261.D = =

Compound	4	8	0.5	50	100	1	200	20	2	0.2	Avg	%RSD
1) I tert butyl alcohol-d9	----------ISTD----------											
2) ethanol	0.123	0.112		0.080	0.057		0.102	0.128		0.100		27.13
	----- Quadratic regression ----- Coefficient = 0.9991											
	Response Ratio = 0.01168 + 0.10643 *A + -0.00253 *A^2											
3) tertiary butyl alcohol	1.205	1.138	1.181	1.028	1.108	1.158	0.926	1.195	1.113		1.117	8.03
4) 1,4-dioxane	0.117	0.119		0.120	0.129		0.117	0.131	0.094		0.118	10.10
5) I pentafluorobenzene	----------ISTD----------											
6) dichlorodifluoromethane	0.853	0.822	0.763	0.808	0.814	0.773	0.711	0.816	0.816	0.858	0.803	5.46
7) chlorodifluoromethane	1.311	1.236		1.143	1.133	1.273	0.960	1.160	1.241		1.182	9.30
8) chloromethane	1.026	0.947		0.892	0.878	1.040	0.754	0.917	1.033		0.936	10.47
9) 1,3-butadiene	0.681	0.661	0.601	0.654	0.647	0.645	0.559	0.650	0.655	0.727	0.648	6.83
10) vinyl chloride	0.856	0.847	0.744	0.809	0.796	0.757	0.686	0.807	0.776	0.639	0.772	8.84
11) bromomethane	0.691	0.563		0.425	0.427		0.472				0.516	21.93
	----- Linear regression ----- Coefficient = 0.9997											
	Response Ratio = 0.02284 + 0.41177 *A											
12) chloroethane	0.486	0.475	0.381	0.467	0.472	0.444	0.418	0.460	0.429	0.550	0.458	9.88
13) trichlorofluoromethane	0.982	0.997	1.035	0.975	0.970	0.950	0.843	0.977	0.977	0.960	0.967	5.06
14) ethyl ether	0.286	0.285	0.229	0.288	0.297	0.266	0.267	0.277	0.273		0.274	7.17
15) acrolein	0.086	0.079		0.088	0.093		0.084	0.086	0.068		0.084	9.66
16) freon 113	0.463	0.455	0.406	0.455	0.457	0.414	0.407	0.439	0.406		0.434	5.81
17) 1,1-dichloroethene	0.536	0.507	0.451	0.503	0.506	0.496	0.451	0.502	0.515	0.493	0.496	5.33
18) acetone	0.081	0.081	0.077	0.074	0.084	0.085	0.077	0.077	0.079		0.080	4.59
19) acetonitrile	0.093	0.085		0.072	0.073		0.059	0.078			0.077	15.63
20) iodomethane												

```
      0.264 0.452       0.749 0.768       0.676 0.633             0.590   33.13
            ----- Linear regression -----  Coefficient =  0.9945
              Response Ratio = -0.03543 + 0.72607 *A

21)  carbon disulfide
      2.189 2.082       2.113 2.075       1.819 1.955 2.102       2.048    5.98
22)  methylene chloride
      0.759 0.680       0.651 0.659       0.578 0.671             0.666    8.76
23)  methyl acetate
      0.082 0.069       0.074 0.082       0.081 0.074             0.077    6.93
24)  methyl tert butyl ether
      1.286 1.327       1.401 1.504 1.102 1.352 1.333 1.148       1.307    9.96
25)  trans-1,2-dichloroethene
      0.546 0.540 0.433 0.524 0.551 0.531 0.498 0.519 0.514       0.517    6.94
26)  hexane
      1.076 1.036 1.124 1.079 1.096 1.074 0.970 1.011 0.998 1.122 1.059    4.99
27)  di-isopropyl ether
      1.896 2.006 1.740 2.078 2.187 1.800 1.952 1.996 1.644 1.728 1.903    9.07
28)  ethyl tert-butyl ether
      1.649 1.734       1.946 2.041 1.507 1.891 1.818 1.550       1.767   10.80
29)  2-butanone
      0.060 0.061       0.061 0.070       0.064 0.065 0.047       0.061   11.40
30)  1,1-dichloroethane
      1.207 1.183 0.994 1.155 1.166 1.114 1.047 1.141 1.038 1.007 1.105    7.01
31)  chloroprene
      0.967 0.932       1.008 1.025 0.863 0.930 0.928 0.830       0.935    7.08
32)  acrylonitrile
      0.185 0.172       0.180 0.193 0.160 0.185 0.181 0.186       0.180    5.61
33)  vinyl acetate
      0.070 0.076       0.096 0.096       0.087 0.084             0.085   12.50
34)  ethyl acetate
      0.073 0.076       0.074 0.077       0.072 0.072 0.062       0.072    6.91
35)  2,2-dichloropropane
      0.992 0.937 0.824 1.017 1.065 0.931 0.960 0.922 0.858 0.926 0.943    7.53
36)  cis-1,2-dichloroethene
      0.595 0.567 0.567 0.562 0.589 0.539 0.578 0.595 0.507 0.425 0.553    9.45
37)  propionitrile
      0.077 0.082 0.073 0.078 0.084 0.070 0.080 0.079 0.065       0.076    7.70
38)  bromochloromethane
      0.357 0.352       0.324 0.362 0.283 0.324 0.348 0.312       0.333    8.08
39)  tetrahydrofuran
      0.204 0.182       0.157 0.163       0.152 0.174 0.170       0.172   10.09
40)  chloroform
      1.168 1.063 1.226 1.033 1.074 1.125 0.969 1.020 1.011       1.077    7.63
41)  tert-butyl formate
      0.217 0.222       0.263 0.280       0.257 0.234 0.204       0.240   11.54
42)  isobutyl alcohol
      0.071 0.060 0.071 0.067 0.068 0.063 0.056 0.065 0.066       0.065    7.50
43)  dibromofluoromethane (s)
      0.574 0.557 0.572 0.547 0.549 0.564 0.553 0.551 0.572 0.573 0.561    1.97
44)  methacrylonitrile
      0.178 0.178       0.187 0.201 0.140 0.186 0.170 0.170       0.176   10.12
45)  1,1,1-trichloroethane
      0.958 0.930 0.797 0.984 1.026 0.920 0.918 0.951 0.830 0.774 0.909    9.08
46)  cyclohexane
      0.799 0.778 0.732 0.934 0.948 0.781 0.838 0.944 0.797 0.772 0.832    9.62
47)  1,1-dichloropropene
      0.240 0.237       0.295 0.311 0.218 0.276 0.251 0.235       0.258   12.71
48)  tert-amyl alcohol
      0.052 0.052       0.048 0.050 0.050 0.033 0.052 0.047       0.048   12.91
```

Initial Calibration Summary

Job Number: JD83927 **Sample:** VY8957-ICC8957
Account: SESINJPB SESI Consulting Engineers **Lab FileID:** Y206268.D
Project: 100 Main Street, White Plains, NY

49) carbon tetrachloride
0.723 0.755 0.815 0.856 0.765 0.766 0.645 0.761 8.81

50) I 1,4-difluorobenzene ----------ISTD----------
51) 1,2-dichloroethane-d4 (s)
0.338 0.338 0.340 0.302 0.299 0.338 0.310 0.329 0.339 0.338 0.327 5.08
52) 2,2,4-trimethylpentane
1.363 1.277 1.123 1.263 1.261 1.238 1.116 1.227 1.178 1.388 1.243 7.21
53) tert-amyl methyl ether
0.777 0.740 0.635 0.752 0.785 0.635 0.821 0.709 0.663 0.724 9.37
54) n-butyl alcohol
0.009 0.009 0.009 0.010 0.009 0.009 0.008 0.009 8.03
55) benzene
1.196 1.156 1.088 1.151 1.149 1.189 1.043 1.122 1.062 1.160 1.132 4.58
56) heptane
0.294 0.278 0.230 0.272 0.261 0.288 0.235 0.264 0.266 0.265 8.12
57) isopropyl acetate
0.207 0.222 0.229 0.241 0.229 0.216 0.171 0.216 10.55
58) 1,2-dichloroethane
0.375 0.357 0.418 0.330 0.357 0.351 0.341 0.332 0.348 0.400 0.361 7.97
59) trichloroethene
0.284 0.293 0.254 0.310 0.313 0.273 0.284 0.288 0.241 0.282 8.33
60) ethyl acrylate
0.778 0.751 0.740 0.722 0.730 0.750 0.658 0.721 0.692 0.800 0.734 5.53
61) 2-nitropropane
0.115 0.115 0.113 0.116 0.108 0.106 0.112 0.101 0.111 4.68
62) 2-chloroethyl vinyl ether
0.103 0.104 0.090 0.110 0.110 0.089 0.103 0.105 0.089 0.100 8.56
63) methyl methacrylate
0.046 0.050 0.057 0.059 0.055 0.053 0.053 8.51
64) 1,2-dichloropropane
0.287 0.284 0.303 0.311 0.232 0.287 0.281 0.236 0.278 10.39
65) methylcyclohexane
0.525 0.524 0.446 0.523 0.527 0.489 0.475 0.509 0.467 0.470 0.495 6.01
66) dibromomethane
0.173 0.173 0.139 0.164 0.172 0.145 0.159 0.163 0.136 0.158 9.30
67) bromodichloromethane
0.382 0.378 0.331 0.401 0.418 0.375 0.388 0.379 0.338 0.323 0.371 8.31
68) epichlorohydrin
0.029 0.032 0.029 0.030 0.030 0.024 0.029 0.030 0.028 0.029 7.12
69) cis-1,3-dichloropropene
0.449 0.473 0.486 0.504 0.388 0.468 0.463 0.375 0.451 10.15
70) 4-methyl-2-pentanone
0.038 0.039 0.038 0.040 0.029 0.039 0.039 0.029 0.037 12.31
71) 3-methyl-1-butanol
0.016 0.014 0.012 0.013 0.013 0.013 0.018 0.014 14.32

72) I chlorobenzene-d5 ----------ISTD----------
73) toluene-d8 (s)
1.327 1.298 1.303 1.286 1.257 1.318 1.207 1.302 1.280 1.310 1.289 2.72
74) toluene
0.852 0.827 0.913 0.815 0.829 0.797 0.740 0.803 0.757 0.809 0.814 5.88
75) trans-1,3-dichloropropene
0.466 0.467 0.508 0.546 0.409 0.490 0.481 0.393 0.470 10.59
76) ethyl methacrylate
0.342 0.330 0.318 0.318 0.325 0.334 0.296 0.324 0.289 0.320 5.37
77) 1,1,2-trichloroethane
0.216 0.219 0.227 0.245 0.192 0.222 0.217 0.168 0.213 10.92
78) 2-hexanone
0.122 0.121 0.110 0.114 0.118 0.116 0.109 0.120 0.097 0.114 6.83

Initial Calibration Summary

Job Number: JD83927 **Sample:** VY8957-ICC8957
Account: SESINJPB SESI Consulting Engineers **Lab FileID:** Y206268.D
Project: 100 Main Street, White Plains, NY

79) tetrachloroethene
0.373 0.334 0.286 0.342 0.345 0.320 0.305 0.334 0.299 0.326 8.20
80) 1,3-dichloropropane
0.453 0.441 0.397 0.459 0.492 0.400 0.453 0.441 0.397 0.437 7.54
81) butyl acetate
0.195 0.187 0.162 0.175 0.186 0.188 0.170 0.184 0.180 0.181 5.55
82) dibromochloromethane
0.298 0.307 0.266 0.312 0.334 0.272 0.309 0.301 0.257 0.295 8.45
83) 1,2-dibromoethane
0.243 0.268 0.275 0.290 0.228 0.269 0.266 0.230 0.259 8.72
84) n-butyl ether
1.606 1.515 1.613 1.420 1.385 1.574 1.207 1.458 1.430 1.653 1.486 9.06
85) chlorobenzene
0.898 0.876 0.905 0.837 0.864 0.857 0.769 0.832 0.795 0.859 0.849 5.01
86) 1,1,1,2-tetrachloroethane
0.283 0.291 0.286 0.305 0.253 0.283 0.281 0.226 0.276 9.06
87) ethylbenzene
1.744 1.666 1.671 1.522 1.501 1.771 1.310 1.573 1.609 1.596 8.85
88) m,p-xylene
0.707 0.655 0.687 0.604 0.604 0.696 0.540 0.629 0.642 0.646 0.641 7.85
89) o-xylene
1.520 1.413 1.489 1.317 1.313 1.517 1.174 1.371 1.364 1.651 1.413 9.58
90) styrene
1.136 1.068 1.127 0.996 1.007 1.060 0.940 1.046 1.010 1.080 1.047 5.77
91) bromoform
0.209 0.199 0.214 0.232 0.224 0.205 0.169 0.207 9.84
92) butyl acrylate
0.690 0.659 0.708 0.596 0.608 0.617 0.548 0.643 0.617 0.641 0.633 7.36
93) isopropylbenzene
1.661 1.544 1.671 1.479 1.511 1.580 1.368 1.535 1.471 1.865 1.568 8.76
94) cis-1,4-dichloro-2-butene
0.122 0.129 0.140 0.151 0.150 0.133 0.138 8.51

95) I 1,4-dichlorobenzene-d ----------ISTD----------
96) 4-bromofluorobenzene (s)
0.908 0.924 0.896 0.923 0.890 0.911 0.888 0.918 0.904 0.919 0.908 1.46
97) bromobenzene
0.688 0.680 0.582 0.656 0.663 0.654 0.609 0.640 0.614 0.570 0.636 6.33
98) 1,1,2,2-tetrachloroethane
0.541 0.542 0.564 0.581 0.476 0.548 0.542 0.447 0.530 8.54
99) trans-1,4-dichloro-2-butene
0.092 0.100 0.105 0.111 0.111 0.098 0.095 0.102 7.24
100) 1,2,3-trichloropropane
0.158 0.155 0.153 0.163 0.159 0.149 0.127 0.152 7.76
101) n-propylbenzene
3.751 3.616 3.702 3.435 3.338 3.591 2.930 3.483 3.366 4.238 3.545 9.51
102) 2-chlorotoluene
0.698 0.672 0.589 0.649 0.652 0.646 0.595 0.641 0.622 0.751 0.651 7.36
103) 4-chlorotoluene
0.703 0.702 0.752 0.676 0.682 0.751 0.618 0.688 0.667 0.606 0.684 6.98
104) 1,3,5-trimethylbenzene
2.696 2.589 2.584 2.561 2.555 2.638 2.228 2.576 2.428 2.670 2.553 5.32
105) tert-butylbenzene
2.209 2.149 2.024 2.119 2.155 2.146 1.897 2.108 1.978 2.060 2.084 4.54
106) 1,2,4-trimethylbenzene
2.672 2.673 2.567 2.647 2.652 2.606 2.305 2.568 2.376 2.563 5.21
107) sec-butylbenzene
3.454 3.480 3.456 3.281 3.313 3.305 2.885 3.292 3.122 4.038 3.363 8.82
108) 1,3-dichlorobenzene
1.424 1.350 1.337 1.317 1.328 1.397 1.177 1.302 1.270 1.630 1.353 8.75

Initial Calibration Summary

Job Number: JD83927 **Sample:** VY8957-ICC8957
Account: SESINJPB SESI Consulting Engineers **Lab FileID:** Y206268.D
Project: 100 Main Street, White Plains, NY

```
109)  p-isopropyltoluene
       3.014 2.928 2.909 2.810 2.774 2.912 2.367 2.834 2.662 3.157  2.837    7.51
110)  1,4-dichlorobenzene
       1.349 1.337 1.428 1.280 1.313 1.353 1.186 1.260 1.209        1.302    5.85
111)  1,2,3-trimethylbenzene
       2.642 2.627 2.571 2.592 2.616 2.676 2.288 2.536 2.363 2.924  2.583    6.69
112)  1,2-dichlorobenzene
       1.321 1.311 1.422 1.243 1.271 1.333 1.134 1.232 1.140 1.491  1.290    8.71
113)  n-butylbenzene
       1.651 1.607 1.655 1.638 1.638 1.449 1.381 1.560 1.378        1.551    7.50
114)  1,2-dibromo-3-chloropropane
       0.142 0.158       0.159 0.173       0.155 0.159 0.124        0.153   10.35
115)  1,3,5-trichlorobenzene
       1.186 1.192 1.200 1.241 1.214 1.270 1.016 1.193 1.087 1.276  1.188    6.76
116)  1,2,4-trichlorobenzene
       1.107 1.089 1.287 1.141 1.114 1.154 0.927 1.082 0.987        1.099    9.28
117)  hexachlorobutadiene
       0.678 0.691 0.690 0.663 0.626 0.699 0.532 0.646 0.628 0.663  0.652    7.56
118)  naphthalene
       2.439 2.442 2.755 2.480 2.415 2.306 2.076 2.423 2.187        2.391    8.02
119)  1,2,3-trichlorobenzene
       1.050 1.088 1.115 1.072 1.027 1.039 0.863 1.037 0.960        1.028    7.35
120)  hexachloroethane
       0.353 0.383       0.411 0.443 0.359 0.413 0.387 0.315        0.383   10.55
121)  benzyl chloride
       0.285 0.286 0.252 0.288 0.304 0.223 0.285 0.277 0.265        0.274    8.84
122)  2-methylnaphthalene
       1.477 1.409       1.311 1.215       1.050 1.341 1.409        1.316   10.95

123)     pentafluorobenzene(a) ----------------ISTD---------------------
124)  vinyl bromide
                                                                     0.000   -1.00

125)     1,4-dichlorobenzene-d ----------------ISTD---------------------
126)  4-ethyltoluene
                                                                     0.000   -1.00
127)  1,4-diethylbenzene
                                                                     0.000   -1.00
128)  1,2,4,5-tetramethylbenzene
                                                                     0.000   -1.00
 ---------------------------------------------------------------------------
 (#) = Out of Range  ###  Number of calibration levels exceeded format  ###

           MY8957.M          Wed Feb 14 16:42:48 2024
```

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: VY8957-ICV8957
Lab FileID: Y206273.D

Evaluate Continuing Calibration Report

Data File : C:\msdchem\1\data\VY8957\Y206273.D Vial: 15
Acq On : 13 Feb 2024 2:02 am Operator: PrashanS
Sample : ICV8957-50 Inst : MSY
Misc : MS76933,VY8957,5.0,,,,1 Multiplr: 1.00
MS Integration Params: RTEINT.P

Method : C:\MSDCHEM\1\METHODS\MY8957.M (RTE Integrator)
Title : Method SW846 8260C/D, Rxi624 20m x 0.18mm x 1.0um
Last Update : Mon Sep 13 11:48:20 2010
Response via : Multiple Level Calibration

Min. RRF : 0.000 Min. Rel. Area : 50% Max. R.T. Dev 0.50min
Max. RRF Dev : 30% Max. Rel. Area : 200%

	Compound	AvgRF	CCRF	%Dev	Area%	Dev(min)	R.T.
1 I	tert butyl alcohol-d9	1.000	1.000	0.0	100	0.00	1.83
	---------- True	Calc.	% Drift	----------			
2	ethanol	5000.000	4885.037	2.3	101	0.00	1.43
	---------- AvgRF	CCRF	% Dev	----------			
3	tertiary butyl alcohol	1.117	1.070	4.2	104	0.00	1.87
4	1,4-dioxane	0.118	0.131	-11.0	109	0.00	4.00
5 I	pentafluorobenzene	1.000	1.000	0.0	104	0.00	2.93
6	dichlorodifluoromethane	0.803	1.037	-29.1	134	0.00	0.89
7	chlorodifluoromethane		----------NA----------				
8	chloromethane	0.936	1.037	-10.8	121	0.00	0.99
9	1,3-butadiene	0.648	0.604	6.8	96	0.00	1.04
10	vinyl chloride	0.772	0.897	-16.2	116	0.00	1.04
	---------- True	Calc.	% Drift	----------			
11	bromomethane	50.000	64.318	-28.6	135	0.00	1.19
	---------- AvgRF	CCRF	% Dev	----------			
12	chloroethane	0.458	0.489	-6.8	109	0.00	1.23
13	trichlorofluoromethane	0.967	0.973	-0.6	104	0.00	1.33
14	ethyl ether	0.274	0.283	-3.3	103	0.00	1.45
15	acrolein	0.084	0.084	0.0	100	0.00	1.56
16	freon 113	0.434	0.446	-2.8	102	0.01	1.56
17	1,1-dichloroethene	0.496	0.509	-2.6	105	0.00	1.59
18	acetone	0.080	0.080	0.0	112	0.00	1.63
19	acetonitrile		----------NA----------				
	---------- True	Calc.	% Drift	----------			
20	iodomethane	50.000	48.702	2.6	94	0.01	1.69
	---------- AvgRF	CCRF	% Dev	----------			
21	carbon disulfide	2.048	1.970	3.8	97	0.01	1.71
22	methylene chloride	0.666	0.645	3.2	103	0.00	1.86
23	methyl acetate	0.077	0.077	0.0	107	0.00	1.77
24	methyl tert butyl ether	1.307	1.421	-8.7	106	0.00	1.95
25	trans-1,2-dichloroethene	0.517	0.527	-1.9	105	0.00	1.97
26	hexane	1.059	1.059	0.0	102	0.00	2.07
27	di-isopropyl ether	1.903	2.092	-9.9	105	0.00	2.20
28	ethyl tert-butyl ether	1.767	1.898	-7.4	102	0.00	2.42
29	2-butanone	0.061	0.071	-16.4	121	0.00	2.60

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: VY8957-ICV8957
Lab FileID: Y206273.D

30		1,1-dichloroethane	1.105	1.122	-1.5	101	0.00	2.23
31		chloroprene	0.935	0.991	-6.0	103	0.00	2.27
32		acrylonitrile		----------NA----------				
33		vinyl acetate	0.085	0.083	2.4	91	0.00	2.23
34		ethyl acetate	0.072	0.074	-2.8	105	0.00	2.60
35		2,2-dichloropropane	0.943	1.034	-9.7	106	0.00	2.57
36		cis-1,2-dichloroethene	0.553	0.563	-1.8	104	0.00	2.59
37		propionitrile	0.076	0.082	-7.9	110	0.00	2.70
38		bromochloromethane	0.333	0.356	-6.9	115	0.00	2.76
39		tetrahydrofuran	0.172	0.155	9.9	103	0.00	2.75
40		chloroform	1.077	1.042	3.2	105	0.00	2.79
41		tert-butyl formate	0.240	0.285	-18.7	113	0.00	2.80
42		isobutyl alcohol	0.065	0.071	-9.2	111	0.00	2.89
43	S	dibromofluoromethane (s)	0.561	0.542	3.4	103	0.00	2.91
44		methacrylonitrile	0.176	0.180	-2.3	100	0.00	2.77
45		1,1,1-trichloroethane	0.909	0.987	-8.6	105	0.00	2.90
46		cyclohexane	0.832	1.019	-22.5	114	0.00	2.89
47		1,1-dichloropropene	0.258	0.294	-14.0	104	0.00	3.02
48		tert-amyl alcohol	0.048	0.050	-4.2	107	0.00	3.16
49		carbon tetrachloride	0.761	0.817	-7.4	105	0.00	2.99
50	I	1,4-difluorobenzene	1.000	1.000	0.0	104	0.00	3.48
51	S	1,2-dichloroethane-d4 (s)	0.327	0.294	10.1	101	0.00	3.18
52		2,2,4-trimethylpentane	1.243	1.255	-1.0	103	0.00	3.14
53		tert-amyl methyl ether	0.724	0.731	-1.0	101	0.00	3.21
54		n-butyl alcohol	0.009	0.010	-11.1	107	0.00	3.63
55		benzene	1.132	1.152	-1.8	104	0.00	3.16
56		heptane	0.265	0.283	-6.8	108	0.00	3.29
57		isopropyl acetate	0.216	0.228	-5.6	103	0.00	3.21
58		1,2-dichloroethane	0.361	0.337	6.6	106	0.00	3.23
59		trichloroethene	0.282	0.313	-11.0	105	0.00	3.67
60		ethyl acrylate	0.734	0.732	0.3	105	0.00	3.77
61		2-nitropropane	0.111	0.117	-5.4	107	0.00	4.40
62		2-chloroethyl vinyl ether	0.100	0.124	-24.0	117	0.00	4.41
63		methyl methacrylate	0.053	0.063	-18.9	116	0.00	3.97
64		1,2-dichloropropane	0.278	0.301	-8.3	103	0.00	3.90
65		methylcyclohexane	0.495	0.544	-9.9	108	0.00	3.77
66		dibromomethane	0.158	0.163	-3.2	103	0.00	4.01
67		bromodichloromethane	0.371	0.400	-7.8	104	0.00	4.13
68		epichlorohydrin	0.029	0.031	-6.9	108	0.00	4.49
69		cis-1,3-dichloropropene	0.451	0.491	-8.9	105	0.00	4.53
70		4-methyl-2-pentanone	0.037	0.038	-2.7	103	0.00	4.66
71		3-methyl-1-butanol	0.014	0.012	14.3	104	0.00	4.72
72	I	chlorobenzene-d5	1.000	1.000	0.0	102	0.00	5.95
73	S	toluene-d8 (s)	1.289	1.258	2.4	100	0.00	4.71
74		toluene	0.814	0.826	-1.5	104	0.00	4.77
75		trans-1,3-dichloropropene	0.470	0.519	-10.4	104	0.00	5.03
76		ethyl methacrylate	0.320	0.348	-8.7	112	0.00	5.06
77		1,1,2-trichloroethane	0.213	0.240	-12.7	108	0.00	5.18
78		2-hexanone	0.114	0.116	-1.8	104	0.00	5.38
79		tetrachloroethene		----------NA----------				
80		1,3-dichloropropane	0.437	0.479	-9.6	107	0.00	5.33
81		butyl acetate	0.181	0.190	-5.0	111	0.00	5.46
82		dibromochloromethane	0.295	0.324	-9.8	106	0.00	5.49
83		1,2-dibromoethane	0.259	0.289	-11.6	107	0.00	5.59
84		n-butyl ether	1.486	1.564	-5.2	113	0.00	6.02
85		chlorobenzene	0.849	0.860	-1.3	105	0.00	5.97
86		1,1,1,2-tetrachloroethane	0.276	0.294	-6.5	105	0.00	6.05
87		ethylbenzene	1.596	1.542	3.4	104	0.00	6.04

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: VY8957-ICV8957
Lab FileID: Y206273.D

88		m,p-xylene	0.641	0.623	2.8	105	0.00	6.14
89		o-xylene	1.413	1.364	3.5	106	0.00	6.46
90		styrene	1.047	1.015	3.1	104	0.00	6.49
91		bromoform	0.207	0.223	-7.7	106	0.00	6.65
92		butyl acrylate	0.633	0.635	-0.3	109	0.00	6.46
93		isopropylbenzene	1.568	1.575	-0.4	109	0.00	6.75
94		cis-1,4-dichloro-2-butene	0.138	0.140	-1.4	102	0.00	6.88
95	I	1,4-dichlorobenzene-d4	1.000	1.000	0.0	102	0.00	7.83
96	S	4-bromofluorobenzene (s)	0.908	0.921	-1.4	102	0.00	6.91
97		bromobenzene	0.636	0.679	-6.8	106	0.00	7.02
98		1,1,2,2-tetrachloroethane	0.530	0.578	-9.1	105	0.00	7.07
99		trans-1,4-dichloro-2-bute	0.102	0.112	-9.8	109	0.00	7.12
100		1,2,3-trichloropropane	0.152	0.163	-7.2	109	0.00	7.10
101		n-propylbenzene	3.545	3.552	-0.2	106	0.00	7.08
102		2-chlorotoluene	0.651	0.659	-1.2	104	0.00	7.17
103		4-chlorotoluene	0.684	0.693	-1.3	105	0.00	7.27
104		1,3,5-trimethylbenzene	2.553	2.549	0.2	102	0.00	7.23
105		tert-butylbenzene	2.084	2.158	-3.6	104	0.00	7.48
106		1,2,4-trimethylbenzene	2.563	2.692	-5.0	104	0.00	7.53
107		sec-butylbenzene	3.363	3.372	-0.3	105	0.00	7.65
108		1,3-dichlorobenzene	1.353	1.330	1.7	103	0.00	7.77
109		p-isopropyltoluene	2.837	2.822	0.5	103	0.00	7.77
110		1,4-dichlorobenzene	1.302	1.317	-1.2	105	0.00	7.85
111		1,2,3-trimethylbenzene		----------NA----------				
112		1,2-dichlorobenzene	1.290	1.285	0.4	106	0.00	8.13
113		n-butylbenzene	1.551	1.640	-5.7	102	0.00	8.09
114		1,2-dibromo-3-chloropropa	0.153	0.168	-9.8	108	0.00	8.77
115		1,3,5-trichlorobenzene	1.188	1.341	-12.9	110	0.00	8.88
116		1,2,4-trichlorobenzene	1.099	1.165	-6.0	104	0.00	9.37
117		hexachlorobutadiene	0.652	0.671	-2.9	104	0.00	9.46
118		naphthalene	2.391	2.525	-5.6	104	0.00	9.56
119		1,2,3-trichlorobenzene	1.028	1.071	-4.2	102	0.00	9.75
120		hexachloroethane	0.383	0.424	-10.7	106	0.00	8.29
121		benzyl chloride	0.274	0.298	-8.8	106	0.00	7.97
122		2-methylnaphthalene	1.316	1.343	-2.1	105	0.00	10.42
123		pentafluorobenzene(a)	1.000	1.000	0.0	104	0.00	2.93
124		vinyl bromide		----------NA----------				
125		1,4-dichlorobenzene-d4(a)	1.000	1.000	0.0	102	0.00	7.83
126		4-ethyltoluene		----------NA----------				
127		1,4-diethylbenzene		----------NA----------				
128		1,2,4,5-tetramethylbenzen		----------NA----------				

(#) = Out of Range SPCC's out = 0 CCC's out = 0
Y206268.D MY8957.M Wed Feb 14 16:42:30 2024

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: VY8957-ICV8957
Lab FileID: Y206274.D

Evaluate Continuing Calibration Report

Data File : C:\msdchem\1\data\VY8957\Y206274.D Vial: 16
Acq On : 13 Feb 2024 2:24 am Operator: PrashanS
Sample : ICV8957-50 Inst : MSY
Misc : MS76933,VY8957,5.0,,,,1 Multiplr: 1.00
MS Integration Params: RTEINT.P

Method : C:\MSDCHEM\1\METHODS\MY8957.M (RTE Integrator)
Title : Method SW846 8260C/D, Rxi624 20m x 0.18mm x 1.0um
Last Update : Mon Sep 13 11:48:20 2010
Response via : Multiple Level Calibration

Min. RRF : 0.000 Min. Rel. Area : 50% Max. R.T. Dev 0.50min
Max. RRF Dev : 30% Max. Rel. Area : 200%

		Compound	AvgRF	CCRF	%Dev	Area%	Dev(min)	R.T.
1	I	tert butyl alcohol-d9	1.000	1.000	0.0	77	0.00	1.82
		---------- True	Calc.	% Drift	----------			
2		ethanol		NA				
		---------- AvgRF	CCRF	% Dev	----------			
3		tertiary butyl alcohol		NA				
4		1,4-dioxane		NA				
5	I	pentafluorobenzene	1.000	1.000	0.0	107	0.00	2.92
6		dichlorodifluoromethane		NA				
7		chlorodifluoromethane	1.182	1.259	-6.5	118	0.00	0.90
8		chloromethane		NA				
9		1,3-butadiene		NA				
10		vinyl chloride		NA				
		---------- True	Calc.	% Drift	----------			
11		bromomethane		NA				
		---------- AvgRF	CCRF	% Dev	----------			
12		chloroethane		NA				
13		trichlorofluoromethane		NA				
14		ethyl ether		NA				
15		acrolein		NA				
16		freon 113		NA				
17		1,1-dichloroethene		NA				
18		acetone		NA				
19		acetonitrile	0.077	0.071	7.8	106	0.00	1.81
		---------- True	Calc.	% Drift	----------			
20		iodomethane		NA				
		---------- AvgRF	CCRF	% Dev	----------			
21		carbon disulfide		NA				
22		methylene chloride		NA				
23		methyl acetate		NA				
24		methyl tert butyl ether		NA				
25		trans-1,2-dichloroethene		NA				
26		hexane		NA				
27		di-isopropyl ether		NA				
28		ethyl tert-butyl ether		NA				
29		2-butanone		NA				

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: VY8957-ICV8957
Lab FileID: Y206274.D

30		1,1-dichloroethane		----------NA----------				
31		chloroprene		----------NA----------				
32		acrylonitrile	0.180	0.171	5.0	102	0.00	2.01
33		vinyl acetate		----------NA----------				
34		ethyl acetate		----------NA----------				
35		2,2-dichloropropane		----------NA----------				
36		cis-1,2-dichloroethene		----------NA----------				
37		propionitrile		----------NA----------				
38		bromochloromethane		----------NA----------				
39		tetrahydrofuran		----------NA----------				
40		chloroform		----------NA----------				
41		tert-butyl formate		----------NA----------				
42		isobutyl alcohol		----------NA----------				
43	S	dibromofluoromethane (s)	0.561	0.503	10.3	99	0.00	2.90
44		methacrylonitrile		----------NA----------				
45		1,1,1-trichloroethane		----------NA----------				
46		cyclohexane		----------NA----------				
47		1,1-dichloropropene		----------NA----------				
48		tert-amyl alcohol		----------NA----------				
49		carbon tetrachloride		----------NA----------				
50	I	1,4-difluorobenzene	1.000	1.000	0.0	95	0.00	3.48
51	S	1,2-dichloroethane-d4 (s)	0.327	0.328	-0.3	103	0.00	3.17
52		2,2,4-trimethylpentane		----------NA----------				
53		tert-amyl methyl ether		----------NA----------				
54		n-butyl alcohol		----------NA----------				
55		benzene		----------NA----------				
56		heptane		----------NA----------				
57		isopropyl acetate		----------NA----------				
58		1,2-dichloroethane		----------NA----------				
59		trichloroethene		----------NA----------				
60		ethyl acrylate		----------NA----------				
61		2-nitropropane		----------NA----------				
62		2-chloroethyl vinyl ether		----------NA----------				
63		methyl methacrylate		----------NA----------				
64		1,2-dichloropropane		----------NA----------				
65		methylcyclohexane		----------NA----------				
66		dibromomethane		----------NA----------				
67		bromodichloromethane		----------NA----------				
68		epichlorohydrin		----------NA----------				
69		cis-1,3-dichloropropene		----------NA----------				
70		4-methyl-2-pentanone		----------NA----------				
71		3-methyl-1-butanol		----------NA----------				
72	I	chlorobenzene-d5	1.000	1.000	0.0	97	0.00	5.94
73	S	toluene-d8 (s)	1.289	1.314	-1.9	99	0.00	4.71
74		toluene		----------NA----------				
75		trans-1,3-dichloropropene		----------NA----------				
76		ethyl methacrylate		----------NA----------				
77		1,1,2-trichloroethane		----------NA----------				
78		2-hexanone		----------NA----------				
79		tetrachloroethene	0.326	0.320	1.8	91	0.00	5.20
80		1,3-dichloropropane		----------NA----------				
81		butyl acetate		----------NA----------				
82		dibromochloromethane		----------NA----------				
83		1,2-dibromoethane		----------NA----------				
84		n-butyl ether		----------NA----------				
85		chlorobenzene		----------NA----------				
86		1,1,1,2-tetrachloroethane		----------NA----------				
87		ethylbenzene		----------NA----------				

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: VY8957-ICV8957
Lab FileID: Y206274.D

88		m,p-xylene		----------NA----------				
89		o-xylene		----------NA----------				
90		styrene		----------NA----------				
91		bromoform		----------NA----------				
92		butyl acrylate		----------NA----------				
93		isopropylbenzene		----------NA----------				
94		cis-1,4-dichloro-2-butene		----------NA----------				
95	I	1,4-dichlorobenzene-d4	1.000	1.000	0.0	102	0.00	7.82
96	S	4-bromofluorobenzene (s)	0.908	0.913	-0.6	101	0.00	6.91
97		bromobenzene		----------NA----------				
98		1,1,2,2-tetrachloroethane		----------NA----------				
99		trans-1,4-dichloro-2-bute		----------NA----------				
100		1,2,3-trichloropropane		----------NA----------				
101		n-propylbenzene		----------NA----------				
102		2-chlorotoluene		----------NA----------				
103		4-chlorotoluene		----------NA----------				
104		1,3,5-trimethylbenzene		----------NA----------				
105		tert-butylbenzene		----------NA----------				
106		1,2,4-trimethylbenzene		----------NA----------				
107		sec-butylbenzene		----------NA----------				
108		1,3-dichlorobenzene		----------NA----------				
109		p-isopropyltoluene		----------NA----------				
110		1,4-dichlorobenzene		----------NA----------				
111		1,2,3-trimethylbenzene	2.583	2.566	0.7	101	0.00	7.86
112		1,2-dichlorobenzene		----------NA----------				
113		n-butylbenzene		----------NA----------				
114		1,2-dibromo-3-chloropropa		----------NA----------				
115		1,3,5-trichlorobenzene		----------NA----------				
116		1,2,4-trichlorobenzene		----------NA----------				
117		hexachlorobutadiene		----------NA----------				
118		naphthalene		----------NA----------				
119		1,2,3-trichlorobenzene		----------NA----------				
120		hexachloroethane		----------NA----------				
121		benzyl chloride		----------NA----------				
122		2-methylnaphthalene		----------NA----------				
123		pentafluorobenzene(a)	1.000	1.000	0.0	107	0.00	2.92
124		vinyl bromide		----------NA----------				
125		1,4-dichlorobenzene-d4(a)	1.000	1.000	0.0	102	0.00	7.82
126		4-ethyltoluene		----------NA----------				
127		1,4-diethylbenzene		----------NA----------				
128		1,2,4,5-tetramethylbenzen		----------NA----------				

(#) = Out of Range SPCC's out = 0 CCC's out = 0

Y206268.D MY8957.M Wed Feb 14 16:42:32 2024

Continuing Calibration Summary

Job Number: JD83927 **Sample:** VY8980-CC8957
Account: SESINJPB SESI Consulting Engineers **Lab FileID:** Y206949.D
Project: 100 Main Street, White Plains, NY

Evaluate Continuing Calibration Report

Data File : X:\Dayton VOA GCMS\k...1124\vy8980\Y206949.D Vial: 3
Acq On : 8 Mar 2024 10:38 am Operator: PrashanS
Sample : CC8957-50 Inst : MSY
Misc : MS78532,VY8980,5.0,,,,1 Multiplr: 1.00
MS Integration Params: RTEINT.P

Method : X:\Dayton VOA GC...Methods\MY8957.M (RTE Integrator)
Title : Method SW846 8260C/D, Rxi624 20m x 0.18mm x 1.0um
Last Update : Mon Sep 13 11:48:20 2010
Response via : Multiple Level Calibration

Min. RRF : 0.000 Min. Rel. Area : 50% Max. R.T. Dev 0.50min
Max. RRF Dev : 20% Max. Rel. Area : 200%

	Compound	AvgRF	CCRF	%Dev	Area%	Dev(min)	R.T.
1 I	tert butyl alcohol-d9	1.000	1.000	0.0	81	0.00	1.83
	---------- True	Calc.	% Drift	----------			
2	ethanol	5000.000	4766.587	4.7	80	0.00	1.43
	---------- AvgRF	CCRF	% Dev	----------			
3	tertiary butyl alcohol	1.117	1.138	-1.9	89	0.00	1.87
4	1,4-dioxane	0.118	0.133	-12.7	89	0.00	3.99
5 I	pentafluorobenzene	1.000	1.000	0.0	89	0.00	2.92
6	dichlorodifluoromethane	0.803	1.010	-25.8#	111	0.00	0.89
7	chlorodifluoromethane	1.182	1.030	12.9	80	0.00	0.91
8	chloromethane	0.936	0.995	-6.3	99	0.00	0.99
9	1,3-butadiene	0.648	0.552	14.8	75	0.00	1.04
10	vinyl chloride	0.772	0.875	-13.3	96	0.00	1.03
	---------- True	Calc.	% Drift	----------			
11	bromomethane	50.000	65.516	-31.0#	117	0.00	1.19
	---------- AvgRF	CCRF	% Dev	----------			
12	chloroethane	0.458	0.525	-14.6	100	0.00	1.23
13	trichlorofluoromethane	0.967	1.009	-4.3	92	0.00	1.32
14	ethyl ether	0.274	0.272	0.7	84	0.00	1.45
15	acrolein	0.084	0.069	17.9	70	0.00	1.56
16	freon 113	0.434	0.377	13.1	73	0.00	1.55
17	1,1-dichloroethene	0.496	0.434	12.5	77	0.00	1.58
18	acetone	0.080	0.093	-16.2	111	0.00	1.63
19	acetonitrile	0.077	0.067	13.0	83	0.00	1.81
	---------- True	Calc.	% Drift	----------			
20	iodomethane	50.000	37.455	25.1#	60	0.00	1.68
	---------- AvgRF	CCRF	% Dev	----------			
21	carbon disulfide	2.048	1.645	19.7	69	0.00	1.71
22	methylene chloride	0.666	0.574	13.8	78	0.00	1.85
23	methyl acetate	0.077	0.074	3.9	88	0.00	1.77
24	methyl tert butyl ether	1.307	1.290	1.3	82	0.00	1.94
25	trans-1,2-dichloroethene	0.517	0.469	9.3	80	0.00	1.97
26	hexane	1.059	0.871	17.8	72	0.00	2.07
27	di-isopropyl ether	1.903	1.901	0.1	81	0.00	2.20
28	ethyl tert-butyl ether	1.767	1.783	-0.9	81	0.00	2.41
29	2-butanone	0.061	0.068	-11.5	99	0.00	2.59

Continuing Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: VY8980-CC8957
Lab FileID: Y206949.D

30		1,1-dichloroethane	1.105	1.020	7.7	78	0.00	2.23
31		chloroprene	0.935	0.866	7.4	76	0.00	2.26
32		acrylonitrile	0.180	0.157	12.8	78	0.00	2.01
33		vinyl acetate	0.085	0.100	-17.6	93	0.00	2.23
34		ethyl acetate	0.072	0.073	-1.4	88	0.00	2.59
35		2,2-dichloropropane	0.943	0.886	6.0	77	0.00	2.57
36		cis-1,2-dichloroethene	0.553	0.512	7.4	81	0.00	2.59
37		propionitrile	0.076	0.077	-1.3	88	0.00	2.69
38		bromochloromethane	0.333	0.306	8.1	84	0.00	2.76
39		tetrahydrofuran	0.172	0.172	0.0	98	0.00	2.75
40		chloroform	1.077	0.934	13.3	80	0.00	2.79
41		tert-butyl formate	0.240	0.141	41.3#	48#	0.00	2.80
42		isobutyl alcohol	0.065	0.060	7.7	79	0.00	2.89
43	S	dibromofluoromethane (s)	0.561	0.513	8.6	83	0.00	2.91
44		methacrylonitrile	0.176	0.183	-4.0	87	0.00	2.77
45		1,1,1-trichloroethane	0.909	0.859	5.5	77	0.00	2.90
46		cyclohexane	0.832	0.857	-3.0	82	0.00	2.89
47		1,1-dichloropropene	0.258	0.254	1.6	76	0.00	3.01
48		tert-amyl alcohol	0.048	0.047	2.1	86	0.00	3.15
49		carbon tetrachloride	0.761	0.688	9.6	75	0.00	2.99
50	I	1,4-difluorobenzene	1.000	1.000	0.0	84	0.00	3.48
51	S	1,2-dichloroethane-d4 (s)	0.327	0.291	11.0	81	0.00	3.17
52		2,2,4-trimethylpentane	1.243	1.097	11.7	73	0.00	3.13
53		tert-amyl methyl ether	0.724	0.738	-1.9	83	0.00	3.21
54		n-butyl alcohol	0.009	0.009	0.0	82	0.00	3.63
55		benzene	1.132	1.092	3.5	80	0.00	3.16
56		heptane	0.265	0.244	7.9	76	0.00	3.28
57		isopropyl acetate	0.216	0.228	-5.6	84	0.00	3.20
58		1,2-dichloroethane	0.361	0.330	8.6	84	0.00	3.23
59		trichloroethene	0.282	0.287	-1.8	78	0.00	3.66
60		ethyl acrylate	0.734	0.692	5.7	81	0.00	3.76
61		2-nitropropane	0.111	0.110	0.9	82	0.00	4.40
62		2-chloroethyl vinyl ether	0.100	0.114	-14.0	87	0.00	4.41
63		methyl methacrylate	0.053	0.058	-9.4	86	0.00	3.97
64		1,2-dichloropropane	0.278	0.287	-3.2	80	0.00	3.90
65		methylcyclohexane	0.495	0.469	5.3	76	0.00	3.76
66		dibromomethane	0.158	0.164	-3.8	84	0.00	4.00
67		bromodichloromethane	0.371	0.381	-2.7	80	0.00	4.13
68		epichlorohydrin	0.029	0.030	-3.4	86	0.00	4.48
69		cis-1,3-dichloropropene	0.451	0.470	-4.2	82	0.00	4.53
70		4-methyl-2-pentanone	0.037	0.041	-10.8	90	0.00	4.66
71		3-methyl-1-butanol	0.014	0.012	14.3	81	0.00	4.71
72	I	chlorobenzene-d5	1.000	1.000	0.0	85	0.00	5.94
73	S	toluene-d8 (s)	1.289	1.255	2.6	83	0.00	4.71
74		toluene	0.814	0.773	5.0	80	0.00	4.77
75		trans-1,3-dichloropropene	0.470	0.491	-4.5	82	0.00	5.03
76		ethyl methacrylate	0.320	0.322	-0.6	86	0.00	5.06
77		1,1,2-trichloroethane	0.213	0.227	-6.6	85	0.00	5.18
78		2-hexanone	0.114	0.135	-18.4	100	0.00	5.38
79		tetrachloroethene	0.326	0.328	-0.6	81	0.00	5.20
80		1,3-dichloropropane	0.437	0.455	-4.1	84	0.00	5.32
81		butyl acetate	0.181	0.180	0.6	87	0.00	5.46
82		dibromochloromethane	0.295	0.306	-3.7	83	0.00	5.48
83		1,2-dibromoethane	0.259	0.271	-4.6	83	0.00	5.58
84		n-butyl ether	1.486	1.354	8.9	81	0.00	6.02
85		chlorobenzene	0.849	0.826	2.7	84	0.00	5.97
86		1,1,1,2-tetrachloroethane	0.276	0.282	-2.2	84	0.00	6.05
87		ethylbenzene	1.596	1.453	9.0	81	0.00	6.04

Continuing Calibration Summary

Job Number: JD83927 **Sample:** VY8980-CC8957
Account: SESINJPB SESI Consulting Engineers **Lab FileID:** Y206949.D
Project: 100 Main Street, White Plains, NY

88		m,p-xylene	0.641	0.581	9.4	82	0.00	6.14
89		o-xylene	1.413	1.270	10.1	82	0.00	6.46
90		styrene	1.047	0.980	6.4	83	0.00	6.49
91		bromoform	0.207	0.207	0.0	82	0.00	6.65
92		butyl acrylate	0.633	0.599	5.4	85	0.00	6.45
93		isopropylbenzene	1.568	1.418	9.6	81	0.00	6.75
94		cis-1,4-dichloro-2-butene	0.138	0.137	0.7	83	0.00	6.88
95	I	1,4-dichlorobenzene-d4	1.000	1.000	0.0	81	0.00	7.83
96	S	4-bromofluorobenzene (s)	0.908	0.909	-0.1	80	0.00	6.91
97		bromobenzene	0.636	0.674	-6.0	84	0.00	7.02
98		1,1,2,2-tetrachloroethane	0.530	0.605	-14.2	87	0.00	7.06
99		trans-1,4-dichloro-2-bute	0.102	0.105	-2.9	81	0.00	7.12
100		1,2,3-trichloropropane	0.152	0.167	-9.9	89	0.00	7.10
101		n-propylbenzene	3.545	3.423	3.4	81	0.00	7.08
102		2-chlorotoluene	0.651	0.654	-0.5	82	0.00	7.17
103		4-chlorotoluene	0.684	0.694	-1.5	84	0.00	7.26
104		1,3,5-trimethylbenzene	2.553	2.526	1.1	80	0.00	7.23
105		tert-butylbenzene	2.084	2.067	0.8	79	0.00	7.47
106		1,2,4-trimethylbenzene	2.563	2.598	-1.4	80	0.00	7.53
107		sec-butylbenzene	3.363	3.262	3.0	81	0.00	7.65
108		1,3-dichlorobenzene	1.353	1.357	-0.3	84	0.00	7.76
109		p-isopropyltoluene	2.837	2.776	2.2	80	0.00	7.77
110		1,4-dichlorobenzene	1.302	1.336	-2.6	85	0.00	7.84
111		1,2,3-trimethylbenzene	2.583	2.564	0.7	81	0.00	7.86
112		1,2-dichlorobenzene	1.290	1.313	-1.8	86	0.00	8.13
113		n-butylbenzene	1.551	1.618	-4.3	80	0.00	8.09
114		1,2-dibromo-3-chloropropa	0.153	0.178	-16.3	91	0.00	8.76
115		1,3,5-trichlorobenzene	1.188	1.311	-10.4	86	0.00	8.88
116		1,2,4-trichlorobenzene	1.099	1.189	-8.2	85	0.00	9.37
117		hexachlorobutadiene	0.652	0.612	6.1	75	0.00	9.46
118		naphthalene	2.391	2.529	-5.8	83	0.00	9.56
119		1,2,3-trichlorobenzene	1.028	1.097	-6.7	83	0.00	9.75
120		hexachloroethane	0.383	0.382	0.3	76	0.00	8.29
121		benzyl chloride	0.274	0.297	-8.4	84	0.00	7.96
122		2-methylnaphthalene	1.316	1.326	-0.8	82	0.00	10.42
123		pentafluorobenzene(a)	1.000	1.000	0.0	89	0.00	2.92
124		vinyl bromide		----------NA----------				
125		1,4-dichlorobenzene-d4(a)	1.000	1.000	0.0	81	0.00	7.83
126		4-ethyltoluene		----------NA----------				
127		1,4-diethylbenzene		----------NA----------				
128		1,2,4,5-tetramethylbenzen		----------NA----------				

(#) = Out of Range SPCC's out = 0 CCC's out = 0
Y206268.D MY8957.M Mon Mar 11 02:27:06 2024

Run Sequence Report

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Run ID: V1C8625	**Method:** SW846 8260D	**Instrument ID:** GCMS1C

Lab Sample ID	Lab File ID	Date/Time Analyzed	Prep QC Batch	Client Sample ID
V1C8625-BFB	1C199346.D	02/17/24 15:03	n/a	BFB Tune
V1C8625-IC8625	1C199347.D	02/17/24 15:38	n/a	Initial cal 0.2
V1C8625-IC8625	1C199348.D	02/17/24 16:04	n/a	Initial cal 0.5
V1C8625-IC8625	1C199349.D	02/17/24 16:31	n/a	Initial cal 1
V1C8625-IC8625	1C199350.D	02/17/24 16:57	n/a	Initial cal 2
V1C8625-IC8625	1C199351.D	02/17/24 17:23	n/a	Initial cal 4
V1C8625-IC8625	1C199352.D	02/17/24 17:49	n/a	Initial cal 8
V1C8625-IC8625	1C199353.D	02/17/24 18:16	n/a	Initial cal 20
V1C8625-ICC8625	1C199354.D	02/17/24 18:42	n/a	Initial cal 50
V1C8625-IC8625	1C199355.D	02/17/24 19:09	n/a	Initial cal 100
V1C8625-IC8625	1C199356.D	02/17/24 19:35	n/a	Initial cal 200
V1C8625-ICV8625	1C199359.D	02/17/24 20:54	n/a	Initial cal verification 50
V1C8625-ICV8625	1C199360.D	02/17/24 21:20	n/a	Initial cal verification 50

Run Sequence Report

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Run ID: V1C8643	**Method:** SW846 8260D	**Instrument ID:** GCMS1C

Lab Sample ID	Lab File ID	Date/Time Analyzed	Prep QC Batch	Client Sample ID
V1C8643-CC8625	1C199819.D	03/08/24 22:11	n/a	Continuing cal 50
V1C8643-CC8625	1C199820.D	03/08/24 22:37	n/a	Continuing cal 2
V1C8643-CC8625	1C199821.D	03/08/24 23:03	n/a	Continuing cal 4
V1C8643-BS	1C199822.D	03/08/24 23:29	n/a	Blank Spike
V1C8643-MB	1C199824.D	03/09/24 00:22	n/a	Method Blank
JD83927-1	1C199825.D	03/09/24 00:48	n/a	SB-7(4-4.5)030724
JD83927-1MS	1C199826.D	03/09/24 01:14	n/a	Matrix Spike
JD83927-1MSD	1C199827.D	03/09/24 01:40	n/a	Matrix Spike Duplicate
JD83927-2	1C199829.D	03/09/24 02:32	n/a	SB-7(7-7.5)030724
JD83927-3	1C199830.D	03/09/24 02:59	n/a	SB-8(4-4.5)030724
JD83927-4	1C199831.D	03/09/24 03:25	n/a	SB-8(7.5-8)030724
JD83927-5	1C199832.D	03/09/24 03:51	n/a	SB-9(3.5-4)030724
JD83927-6	1C199833.D	03/09/24 04:17	n/a	SB-10(3.5-4)030724
JD83927-7	1C199834.D	03/09/24 04:43	n/a	SB-10(7-5.5)030724
JD83927-8	1C199835.D	03/09/24 05:09	n/a	SB-11(3.5-4)030724
JD83927-9	1C199836.D	03/09/24 05:35	n/a	SB-11(8-8.5)030724
JD83927-10	1C199837.D	03/09/24 06:01	n/a	SB-16(3-3.5)030724
JD83927-11	1C199838.D	03/09/24 06:28	n/a	SB-16(7.5-8)030724
JD83927-12	1C199839.D	03/09/24 06:54	n/a	SB-19(4-4.5)030724
JD83927-13	1C199840.D	03/09/24 07:19	n/a	SB-19(7-7.5)030724
ZZZZZZ	1C199841.D	03/09/24 07:46	n/a	(unrelated sample)
ZZZZZZ	1C199842.D	03/09/24 08:12	n/a	(unrelated sample)
ZZZZZZ	1C199843.D	03/09/24 08:38	n/a	(unrelated sample)
ZZZZZZ	1C199844.D	03/09/24 09:04	n/a	(unrelated sample)
ZZZZZZ	1C199845.D	03/09/24 09:31	n/a	(unrelated sample)
ZZZZZZ	1C199846.D	03/09/24 09:56	n/a	(unrelated sample)

Run Sequence Report

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Run ID: VY8957	**Method:** SW846 8260D	**Instrument ID:** GCMSY

Lab Sample ID	Lab File ID	Date/Time Analyzed	Prep QC Batch	Client Sample ID
VY8957-BFB	Y206260.D	02/12/24 21:18	n/a	BFB Tune
VY8957-IC8957	Y206261.D	02/12/24 21:41	n/a	Initial cal 0.2
VY8957-IC8957	Y206262.D	02/12/24 22:02	n/a	Initial cal 0.5
VY8957-IC8957	Y206263.D	02/12/24 22:24	n/a	Initial cal 1
VY8957-IC8957	Y206264.D	02/12/24 22:46	n/a	Initial cal 2
VY8957-IC8957	Y206265.D	02/12/24 23:08	n/a	Initial cal 4
VY8957-IC8957	Y206266.D	02/12/24 23:29	n/a	Initial cal 8
VY8957-IC8957	Y206267.D	02/12/24 23:51	n/a	Initial cal 20
VY8957-ICC8957	Y206268.D	02/13/24 00:13	n/a	Initial cal 50
VY8957-IC8957	Y206269.D	02/13/24 00:35	n/a	Initial cal 100
VY8957-IC8957	Y206270.D	02/13/24 00:56	n/a	Initial cal 200
VY8957-ICV8957	Y206273.D	02/13/24 02:02	n/a	Initial cal verification 50
VY8957-ICV8957	Y206274.D	02/13/24 02:24	n/a	Initial cal verification 50

Run Sequence Report

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Run ID: VY8980	**Method:** SW846 8260D	**Instrument ID:** GCMSY

Lab Sample ID	Lab File ID	Date/Time Analyzed	Prep QC Batch	Client Sample ID
VY8980-CC8957	Y206949.D	03/08/24 10:38	n/a	Continuing cal 50
VY8980-BS	Y206950.D	03/08/24 11:38	n/a	Blank Spike
VY8980-MB	Y206952.D	03/08/24 12:55	n/a	Method Blank
JD83895-4	Y206953.D	03/08/24 13:17	n/a	(used for QC only; not part of job JD83927)
ZZZZZZ	Y206954.D	03/08/24 13:40	n/a	(unrelated sample)
ZZZZZZ	Y206955.D	03/08/24 14:02	n/a	(unrelated sample)
ZZZZZZ	Y206956.D	03/08/24 14:24	n/a	(unrelated sample)
JD83895-4MS	Y206957.D	03/08/24 14:46	n/a	Matrix Spike
JD83895-4MSD	Y206958.D	03/08/24 15:08	n/a	Matrix Spike Duplicate
ZZZZZZ	Y206960.D	03/08/24 15:52	n/a	(unrelated sample)
ZZZZZZ	Y206961.D	03/08/24 16:14	n/a	(unrelated sample)
ZZZZZZ	Y206962.D	03/08/24 16:36	n/a	(unrelated sample)
ZZZZZZ	Y206963.D	03/08/24 16:59	n/a	(unrelated sample)
ZZZZZZ	Y206964.D	03/08/24 17:21	n/a	(unrelated sample)
ZZZZZZ	Y206965.D	03/08/24 17:43	n/a	(unrelated sample)
ZZZZZZ	Y206966.D	03/08/24 18:05	n/a	(unrelated sample)
ZZZZZZ	Y206967.D	03/08/24 18:27	n/a	(unrelated sample)
ZZZZZZ	Y206968.D	03/08/24 18:49	n/a	(unrelated sample)
ZZZZZZ	Y206969.D	03/08/24 19:11	n/a	(unrelated sample)
ZZZZZZ	Y206970.D	03/08/24 19:33	n/a	(unrelated sample)
ZZZZZZ	Y206971.D	03/08/24 19:56	n/a	(unrelated sample)
JD83927-14	Y206973.D	03/08/24 20:40	n/a	SB-22(3.5-4)030724
JD83927-15	Y206974.D	03/08/24 21:01	n/a	SB-22(8-8.5)030724
JD83927-16	Y206975.D	03/08/24 21:23	n/a	SB-25(1.5-2)030724
JD83927-17	Y206976.D	03/08/24 21:45	n/a	SB-25(3-3.5)030724
JD83927-18	Y206977.D	03/08/24 22:07	n/a	SB-25(7.5-8)030724

MS Semi-volatiles

6

QC Data Summaries

Includes the following where applicable:

- Method Blank Summaries
- Blank Spike Summaries
- Matrix Spike and Duplicate Summaries
- Instrument Performance Checks (DFTPP)
- Internal Standard Area Summaries
- Surrogate Recovery Summaries
- Initial and Continuing Calibration Summaries
- Run Sequence Reports

Method Blank Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
OP53010-MB1	Z166825.D	1	03/11/24	JY	03/09/24	OP53010	EZ8267

The QC reported here applies to the following samples: **Method:** SW846 8270E

JD83927-1, JD83927-2, JD83927-3, JD83927-4, JD83927-5, JD83927-6, JD83927-7, JD83927-8, JD83927-9, JD83927-10, JD83927-11, JD83927-12, JD83927-13, JD83927-14, JD83927-15, JD83927-16, JD83927-17, JD83927-18

CAS No.	Compound	Result	RL	MDL	Units	Q
95-57-8	2-Chlorophenol	ND	67	16	ug/kg	
59-50-7	4-Chloro-3-methyl phenol	ND	170	20	ug/kg	
120-83-2	2,4-Dichlorophenol	ND	170	28	ug/kg	
105-67-9	2,4-Dimethylphenol	ND	170	59	ug/kg	
51-28-5	2,4-Dinitrophenol	ND	170	130	ug/kg	
534-52-1	4,6-Dinitro-o-cresol	ND	170	36	ug/kg	
95-48-7	2-Methylphenol	ND	67	21	ug/kg	
	3&4-Methylphenol	ND	67	27	ug/kg	
88-75-5	2-Nitrophenol	ND	170	22	ug/kg	
100-02-7	4-Nitrophenol	ND	330	89	ug/kg	
87-86-5	Pentachlorophenol	ND	130	31	ug/kg	
108-95-2	Phenol	ND	67	17	ug/kg	
58-90-2	2,3,4,6-Tetrachlorophenol	ND	170	22	ug/kg	
95-95-4	2,4,5-Trichlorophenol	ND	170	25	ug/kg	
88-06-2	2,4,6-Trichlorophenol	ND	170	20	ug/kg	
83-32-9	Acenaphthene	ND	33	11	ug/kg	
208-96-8	Acenaphthylene	ND	33	17	ug/kg	
98-86-2	Acetophenone	ND	170	7.2	ug/kg	
120-12-7	Anthracene	ND	33	20	ug/kg	
1912-24-9	Atrazine	ND	67	14	ug/kg	
56-55-3	Benzo(a)anthracene	ND	33	9.4	ug/kg	
50-32-8	Benzo(a)pyrene	ND	33	15	ug/kg	
205-99-2	Benzo(b)fluoranthene	ND	33	15	ug/kg	
191-24-2	Benzo(g,h,i)perylene	ND	33	17	ug/kg	
207-08-9	Benzo(k)fluoranthene	ND	33	16	ug/kg	
101-55-3	4-Bromophenyl phenyl ether	ND	67	13	ug/kg	
85-68-7	Butyl benzyl phthalate	ND	67	8.1	ug/kg	
92-52-4	1,1'-Biphenyl	ND	67	4.6	ug/kg	
100-52-7	Benzaldehyde	ND	170	8.3	ug/kg	
91-58-7	2-Chloronaphthalene	ND	67	7.9	ug/kg	
106-47-8	4-Chloroaniline	ND	170	12	ug/kg	
86-74-8	Carbazole	ND	67	4.8	ug/kg	
105-60-2	Caprolactam	ND	67	13	ug/kg	
218-01-9	Chrysene	ND	33	10	ug/kg	
111-91-1	bis(2-Chloroethoxy)methane	ND	67	7.1	ug/kg	
111-44-4	bis(2-Chloroethyl)ether	ND	67	14	ug/kg	

Method Blank Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
OP53010-MB1	Z166825.D	1	03/11/24	JY	03/09/24	OP53010	EZ8267

The QC reported here applies to the following samples: **Method:** SW846 8270E

JD83927-1, JD83927-2, JD83927-3, JD83927-4, JD83927-5, JD83927-6, JD83927-7, JD83927-8, JD83927-9, JD83927-10, JD83927-11, JD83927-12, JD83927-13, JD83927-14, JD83927-15, JD83927-16, JD83927-17, JD83927-18

CAS No.	Compound	Result	RL	MDL	Units	Q
108-60-1	2,2'-Oxybis(1-chloropropane)	ND	67	12	ug/kg	
7005-72-3	4-Chlorophenyl phenyl ether	ND	67	11	ug/kg	
121-14-2	2,4-Dinitrotoluene	ND	33	10	ug/kg	
606-20-2	2,6-Dinitrotoluene	ND	33	17	ug/kg	
91-94-1	3,3'-Dichlorobenzidine	ND	67	28	ug/kg	
123-91-1	1,4-Dioxane	ND	33	22	ug/kg	
53-70-3	Dibenzo(a,h)anthracene	ND	33	15	ug/kg	
132-64-9	Dibenzofuran	ND	67	14	ug/kg	
84-74-2	Di-n-butyl phthalate	ND	67	5.4	ug/kg	
117-84-0	Di-n-octyl phthalate	ND	67	8.3	ug/kg	
84-66-2	Diethyl phthalate	ND	67	7.1	ug/kg	
131-11-3	Dimethyl phthalate	ND	67	5.9	ug/kg	
117-81-7	bis(2-Ethylhexyl)phthalate	ND	67	7.8	ug/kg	
206-44-0	Fluoranthene	ND	33	15	ug/kg	
86-73-7	Fluorene	ND	33	15	ug/kg	
118-74-1	Hexachlorobenzene	ND	67	8.4	ug/kg	
87-68-3	Hexachlorobutadiene	ND	33	13	ug/kg	
77-47-4	Hexachlorocyclopentadiene	ND	330	13	ug/kg	
67-72-1	Hexachloroethane	ND	170	16	ug/kg	
193-39-5	Indeno(1,2,3-cd)pyrene	ND	33	16	ug/kg	
78-59-1	Isophorone	ND	67	7.1	ug/kg	
91-57-6	2-Methylnaphthalene	ND	33	7.5	ug/kg	
88-74-4	2-Nitroaniline	ND	170	7.9	ug/kg	
99-09-2	3-Nitroaniline	ND	170	8.3	ug/kg	
100-01-6	4-Nitroaniline	ND	170	8.6	ug/kg	
91-20-3	Naphthalene	ND	33	9.4	ug/kg	
98-95-3	Nitrobenzene	ND	67	13	ug/kg	
621-64-7	N-Nitroso-di-n-propylamine	ND	67	9.6	ug/kg	
86-30-6	N-Nitrosodiphenylamine	ND	170	12	ug/kg	
85-01-8	Phenanthrene	ND	33	11	ug/kg	
129-00-0	Pyrene	ND	33	11	ug/kg	
95-94-3	1,2,4,5-Tetrachlorobenzene	ND	170	8.5	ug/kg	

Method Blank Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
OP53010-MB1	Z166825.D	1	03/11/24	JY	03/09/24	OP53010	EZ8267

The QC reported here applies to the following samples: **Method:** SW846 8270E

JD83927-1, JD83927-2, JD83927-3, JD83927-4, JD83927-5, JD83927-6, JD83927-7, JD83927-8, JD83927-9, JD83927-10, JD83927-11, JD83927-12, JD83927-13, JD83927-14, JD83927-15, JD83927-16, JD83927-17, JD83927-18

CAS No.	Surrogate Recoveries		Limits
367-12-4	2-Fluorophenol	60%	10-99%
4165-62-2	Phenol-d5	61%	10-96%
118-79-6	2,4,6-Tribromophenol	59%	10-123%
4165-60-0	Nitrobenzene-d5	62%	10-109%
321-60-8	2-Fluorobiphenyl	58%	11-109%
1718-51-0	Terphenyl-d14	71%	10-120%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Total TIC, Semi-Volatile		0	ug/kg	

Blank Spike Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
OP53010-BS1	Z166826.D	1	03/11/24	JY	03/09/24	OP53010	EZ8267

The QC reported here applies to the following samples: **Method:** SW846 8270E

JD83927-1, JD83927-2, JD83927-3, JD83927-4, JD83927-5, JD83927-6, JD83927-7, JD83927-8, JD83927-9, JD83927-10, JD83927-11, JD83927-12, JD83927-13, JD83927-14, JD83927-15, JD83927-16, JD83927-17, JD83927-18

CAS No.	Compound	Spike ug/kg	BSP ug/kg	BSP %	Limits
95-57-8	2-Chlorophenol	1670	974	58	10-135
59-50-7	4-Chloro-3-methyl phenol	1670	1170	70	10-141
120-83-2	2,4-Dichlorophenol	1670	1070	64	10-139
105-67-9	2,4-Dimethylphenol	1670	1080	65	10-141
51-28-5	2,4-Dinitrophenol	3330	2120	64	10-138
534-52-1	4,6-Dinitro-o-cresol	1670	1130	68	10-156
95-48-7	2-Methylphenol	1670	1030	62	10-139
	3&4-Methylphenol	3330	2040	61	10-174
88-75-5	2-Nitrophenol	1670	989	59	10-142
100-02-7	4-Nitrophenol	1670	1130	68	10-144
87-86-5	Pentachlorophenol	3330	2250	68	10-165
108-95-2	Phenol	1670	1020	61	23-115
58-90-2	2,3,4,6-Tetrachlorophenol	1670	1060	64	10-146
95-95-4	2,4,5-Trichlorophenol	1670	1070	64	13-136
88-06-2	2,4,6-Trichlorophenol	1670	1010	61	10-142
83-32-9	Acenaphthene	1670	954	57	10-141
208-96-8	Acenaphthylene	1670	1040	62	10-133
98-86-2	Acetophenone	1670	913	55	23-115
120-12-7	Anthracene	1670	1080	65	10-144
1912-24-9	Atrazine	1670	1190	71	17-149
56-55-3	Benzo(a)anthracene	1670	1090	65	11-139
50-32-8	Benzo(a)pyrene	1670	1320	79	13-141
205-99-2	Benzo(b)fluoranthene	1670	1320	79	14-140
191-24-2	Benzo(g,h,i)perylene	1670	1330	80	13-138
207-08-9	Benzo(k)fluoranthene	1670	1240	74	12-140
101-55-3	4-Bromophenyl phenyl ether	1670	1130	68	10-146
85-68-7	Butyl benzyl phthalate	1670	1240	74	10-150
92-52-4	1,1'-Biphenyl	1670	991	59	10-141
100-52-7	Benzaldehyde	1670	1000	60	10-146
91-58-7	2-Chloronaphthalene	1670	992	60	10-142
106-47-8	4-Chloroaniline	1670	784	47	10-108
86-74-8	Carbazole	1670	1090	65	10-145
105-60-2	Caprolactam	1670	1230	74	10-187
218-01-9	Chrysene	1670	1110	67	11-139
111-91-1	bis(2-Chloroethoxy)methane	1670	1040	62	10-144
111-44-4	bis(2-Chloroethyl)ether	1670	994	60	10-145

* = Outside of Control Limits.

Blank Spike Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
OP53010-BS1	Z166826.D	1	03/11/24	JY	03/09/24	OP53010	EZ8267

The QC reported here applies to the following samples: **Method:** SW846 8270E

JD83927-1, JD83927-2, JD83927-3, JD83927-4, JD83927-5, JD83927-6, JD83927-7, JD83927-8, JD83927-9, JD83927-10, JD83927-11, JD83927-12, JD83927-13, JD83927-14, JD83927-15, JD83927-16, JD83927-17, JD83927-18

CAS No.	Compound	Spike ug/kg	BSP ug/kg	BSP %	Limits
108-60-1	2,2'-Oxybis(1-chloropropane)	1670	969	58	10-145
7005-72-3	4-Chlorophenyl phenyl ether	1670	1080	65	10-145
121-14-2	2,4-Dinitrotoluene	1670	1110	67	10-148
606-20-2	2,6-Dinitrotoluene	1670	1070	64	12-145
91-94-1	3,3'-Dichlorobenzidine	1670	755	45	10-100
123-91-1	1,4-Dioxane	1670	611	37	10-97
53-70-3	Dibenzo(a,h)anthracene	1670	1340	80	14-142
132-64-9	Dibenzofuran	1670	1010	61	10-140
84-74-2	Di-n-butyl phthalate	1670	1120	67	11-147
117-84-0	Di-n-octyl phthalate	1670	1190	71	15-145
84-66-2	Diethyl phthalate	1670	1060	64	10-145
131-11-3	Dimethyl phthalate	1670	1050	63	10-144
117-81-7	bis(2-Ethylhexyl)phthalate	1670	1160	70	26-132
206-44-0	Fluoranthene	1670	1140	68	10-147
86-73-7	Fluorene	1670	984	59	12-139
118-74-1	Hexachlorobenzene	1670	991	59	10-144
87-68-3	Hexachlorobutadiene	1670	1030	62	10-142
77-47-4	Hexachlorocyclopentadiene	3330	2110	63	10-120
67-72-1	Hexachloroethane	1670	963	58	10-141
193-39-5	Indeno(1,2,3-cd)pyrene	1670	1360	82	13-144
78-59-1	Isophorone	1670	987	59	10-139
91-57-6	2-Methylnaphthalene	1670	1040	62	10-140
88-74-4	2-Nitroaniline	1670	1060	64	10-148
99-09-2	3-Nitroaniline	1670	845	51	10-127
100-01-6	4-Nitroaniline	1670	1080	65	10-143
91-20-3	Naphthalene	1670	962	58	10-141
98-95-3	Nitrobenzene	1670	964	58	10-139
621-64-7	N-Nitroso-di-n-propylamine	1670	983	59	10-143
86-30-6	N-Nitrosodiphenylamine	1670	1080	65	10-145
85-01-8	Phenanthrene	1670	1040	62	10-142
129-00-0	Pyrene	1670	1050	63	13-141
95-94-3	1,2,4,5-Tetrachlorobenzene	1670	943	57	10-143

* = Outside of Control Limits.

Blank Spike Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
OP53010-BS1	Z166826.D	1	03/11/24	JY	03/09/24	OP53010	EZ8267

The QC reported here applies to the following samples: **Method:** SW846 8270E

JD83927-1, JD83927-2, JD83927-3, JD83927-4, JD83927-5, JD83927-6, JD83927-7, JD83927-8, JD83927-9, JD83927-10, JD83927-11, JD83927-12, JD83927-13, JD83927-14, JD83927-15, JD83927-16, JD83927-17, JD83927-18

CAS No.	Surrogate Recoveries	BSP	Limits
367-12-4	2-Fluorophenol	54%	10-99%
4165-62-2	Phenol-d5	56%	10-96%
118-79-6	2,4,6-Tribromophenol	66%	10-123%
4165-60-0	Nitrobenzene-d5	59%	10-109%
321-60-8	2-Fluorobiphenyl	56%	11-109%
1718-51-0	Terphenyl-d14	63%	10-120%

* = Outside of Control Limits.

Matrix Spike/Matrix Spike Duplicate Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
OP53010-MS	Z166846.D	1	03/11/24	JY	03/09/24	OP53010	EZ8267
OP53010-MSD	Z166847.D	1	03/11/24	JY	03/09/24	OP53010	EZ8267
JD83927-1	Z166829.D	1	03/11/24	JY	03/09/24	OP53010	EZ8267

The QC reported here applies to the following samples: **Method:** SW846 8270E

JD83927-1, JD83927-2, JD83927-3, JD83927-4, JD83927-5, JD83927-6, JD83927-7, JD83927-8, JD83927-9, JD83927-10, JD83927-11, JD83927-12, JD83927-13, JD83927-14, JD83927-15, JD83927-16, JD83927-17, JD83927-18

CAS No.	Compound	JD83927-1 ug/kg	Q	Spike ug/kg	MS ug/kg	MS %	Spike ug/kg	MSD ug/kg	MSD %	RPD	Limits Rec/RPD
95-57-8	2-Chlorophenol	ND		1730	893	51	1760	1010	57	12	10-137/86
59-50-7	4-Chloro-3-methyl phenol	ND		1730	1040	60	1760	1100	63	6	10-146/84
120-83-2	2,4-Dichlorophenol	ND		1730	974	56	1760	1050	60	8	10-145/86
105-67-9	2,4-Dimethylphenol	ND		1730	980	57	1760	1040	59	6	10-148/87
51-28-5	2,4-Dinitrophenol	ND		3470	1690	49	3510	1730	49	2	10-118/90
534-52-1	4,6-Dinitro-o-cresol	ND		1730	935	54	1760	999	57	7	10-131/97
95-48-7	2-Methylphenol	ND		1730	942	54	1760	1040	59	10	10-143/86
	3&4-Methylphenol	ND		3470	1850	53	3510	2020	57	9	10-162/87
88-75-5	2-Nitrophenol	ND		1730	933	54	1760	1080	61	15	10-147/93
100-02-7	4-Nitrophenol	ND		1730	1030	59	1760	1150	65	11	10-152/85
87-86-5	Pentachlorophenol	ND		3470	1880	54	3510	2120	60	12	10-146/89
108-95-2	Phenol	ND		1730	907	52	1760	1050	60	15	10-118/84
58-90-2	2,3,4,6-Tetrachlorophenol	ND		1730	993	57	1760	1170	67	16	10-139/87
95-95-4	2,4,5-Trichlorophenol	ND		1730	1010	58	1760	1150	65	13	10-140/86
88-06-2	2,4,6-Trichlorophenol	ND		1730	995	57	1760	1070	61	7	10-141/86
83-32-9	Acenaphthene	ND		1730	940	54	1760	1030	59	9	10-156/87
208-96-8	Acenaphthylene	ND		1730	1020	59	1760	1150	65	12	10-143/84
98-86-2	Acetophenone	ND		1730	859	50	1760	980	56	13	10-130/90
120-12-7	Anthracene	ND		1730	989	57	1760	1060	60	7	10-166/88
1912-24-9	Atrazine	ND		1730	1100	63	1760	1190	68	8	10-148/86
56-55-3	Benzo(a)anthracene	ND		1730	1030	59	1760	1090	62	6	10-163/88
50-32-8	Benzo(a)pyrene	ND		1730	1120	65	1760	1210	69	8	10-163/89
205-99-2	Benzo(b)fluoranthene	ND		1730	1060	61	1760	1140	65	7	10-156/91
191-24-2	Benzo(g,h,i)perylene	ND		1730	1110	64	1760	1190	68	7	10-158/89
207-08-9	Benzo(k)fluoranthene	ND		1730	1070	62	1760	1160	66	8	10-157/86
101-55-3	4-Bromophenyl phenyl ether	ND		1730	1020	59	1760	1120	64	9	10-143/87
85-68-7	Butyl benzyl phthalate	ND		1730	1190	69	1760	1260	72	6	10-161/89
92-52-4	1,1'-Biphenyl	ND		1730	907	52	1760	1030	59	13	10-143/86
100-52-7	Benzaldehyde	ND		1730	912	53	1760	1090	62	18	10-148/88
91-58-7	2-Chloronaphthalene	ND		1730	953	55	1760	1110	63	15	10-145/86
106-47-8	4-Chloroaniline	ND		1730	696	40	1760	867	49	22	10-109/87
86-74-8	Carbazole	ND		1730	1010	58	1760	1080	61	7	10-158/87
105-60-2	Caprolactam	ND		1730	1100	63	1760	1130	64	3	10-150/82
218-01-9	Chrysene	ND		1730	1030	59	1760	1130	64	9	10-164/87
111-91-1	bis(2-Chloroethoxy)methane	ND		1730	962	55	1760	1050	60	9	10-152/86
111-44-4	bis(2-Chloroethyl)ether	ND		1730	855	49	1760	999	57	16	10-147/86

* = Outside of Control Limits.

Matrix Spike/Matrix Spike Duplicate Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
OP53010-MS	Z166846.D	1	03/11/24	JY	03/09/24	OP53010	EZ8267
OP53010-MSD	Z166847.D	1	03/11/24	JY	03/09/24	OP53010	EZ8267
JD83927-1	Z166829.D	1	03/11/24	JY	03/09/24	OP53010	EZ8267

The QC reported here applies to the following samples: **Method:** SW846 8270E

JD83927-1, JD83927-2, JD83927-3, JD83927-4, JD83927-5, JD83927-6, JD83927-7, JD83927-8, JD83927-9, JD83927-10, JD83927-11, JD83927-12, JD83927-13, JD83927-14, JD83927-15, JD83927-16, JD83927-17, JD83927-18

CAS No.	Compound	JD83927-1 ug/kg	Q	Spike ug/kg	MS ug/kg	MS %	Spike ug/kg	MSD ug/kg	MSD %	RPD	Limits Rec/RPD
108-60-1	2,2'-Oxybis(1-chloropropane)	ND		1730	894	52	1760	1040	59	15	10-134/88
7005-72-3	4-Chlorophenyl phenyl ether	ND		1730	1020	59	1760	1110	63	8	10-142/87
121-14-2	2,4-Dinitrotoluene	ND		1730	1010	58	1760	1150	65	13	10-147/86
606-20-2	2,6-Dinitrotoluene	ND		1730	1090	63	1760	1200	68	10	10-147/88
91-94-1	3,3'-Dichlorobenzidine	ND		1730	951	55	1760	1110	63	15	10-106/93
123-91-1	1,4-Dioxane	ND		1730	578	33	1760	689	39	18	10-102/85
53-70-3	Dibenzo(a,h)anthracene	ND		1730	1100	63	1760	1170	67	6	10-149/89
132-64-9	Dibenzofuran	ND		1730	941	54	1760	1070	61	13	10-155/86
84-74-2	Di-n-butyl phthalate	ND		1730	1040	60	1760	1120	64	7	10-158/86
117-84-0	Di-n-octyl phthalate	ND		1730	1040	60	1760	1140	65	9	10-154/84
84-66-2	Diethyl phthalate	ND		1730	997	57	1760	1100	63	10	10-148/84
131-11-3	Dimethyl phthalate	ND		1730	967	56	1760	1080	61	11	10-144/85
117-81-7	bis(2-Ethylhexyl)phthalate	ND		1730	1070	62	1760	1170	67	9	10-153/84
206-44-0	Fluoranthene	ND		1730	1060	61	1760	1140	65	7	10-165/93
86-73-7	Fluorene	ND		1730	952	55	1760	1070	61	12	10-158/87
118-74-1	Hexachlorobenzene	ND		1730	932	54	1760	1020	58	9	10-139/85
87-68-3	Hexachlorobutadiene	ND		1730	903	52	1760	1050	60	15	10-139/88
77-47-4	Hexachlorocyclopentadiene	ND		3470	1940	56	3510	2290	65	17	10-116/30
67-72-1	Hexachloroethane	ND		1730	867	50	1760	990	56	13	10-141/93
193-39-5	Indeno(1,2,3-cd)pyrene	ND		1730	1150	66	1760	1250	71	8	10-160/91
78-59-1	Isophorone	ND		1730	927	53	1760	1030	59	11	10-150/86
91-57-6	2-Methylnaphthalene	ND		1730	943	54	1760	1070	61	13	10-145/86
88-74-4	2-Nitroaniline	ND		1730	1010	58	1760	1150	65	13	10-152/77
99-09-2	3-Nitroaniline	ND		1730	847	49	1760	1050	60	21	10-136/83
100-01-6	4-Nitroaniline	ND		1730	999	58	1760	1120	64	11	10-140/81
91-20-3	Naphthalene	ND		1730	879	51	1760	1000	57	13	10-146/87
98-95-3	Nitrobenzene	ND		1730	888	51	1760	1050	60	17	10-146/88
621-64-7	N-Nitroso-di-n-propylamine	ND		1730	857	49	1760	1030	59	18	10-147/77
86-30-6	N-Nitrosodiphenylamine	ND		1730	968	56	1760	1110	63	14	10-159/78
85-01-8	Phenanthrene	ND		1730	979	56	1760	1050	60	7	10-158/95
129-00-0	Pyrene	ND		1730	1010	58	1760	1080	61	7	10-176/90
95-94-3	1,2,4,5-Tetrachlorobenzene	ND		1730	926	53	1760	1050	60	13	10-137/87

* = Outside of Control Limits.

Matrix Spike/Matrix Spike Duplicate Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
OP53010-MS	Z166846.D	1	03/11/24	JY	03/09/24	OP53010	EZ8267
OP53010-MSD	Z166847.D	1	03/11/24	JY	03/09/24	OP53010	EZ8267
JD83927-1	Z166829.D	1	03/11/24	JY	03/09/24	OP53010	EZ8267

The QC reported here applies to the following samples: **Method:** SW846 8270E

JD83927-1, JD83927-2, JD83927-3, JD83927-4, JD83927-5, JD83927-6, JD83927-7, JD83927-8, JD83927-9, JD83927-10, JD83927-11, JD83927-12, JD83927-13, JD83927-14, JD83927-15, JD83927-16, JD83927-17, JD83927-18

CAS No.	Surrogate Recoveries	MS	MSD	JD83927-1	Limits
367-12-4	2-Fluorophenol	47%	53%	33%	10-99%
4165-62-2	Phenol-d5	51%	55%	32%	10-96%
118-79-6	2,4,6-Tribromophenol	57%	69%	33%	10-123%
4165-60-0	Nitrobenzene-d5	51%	59%	35%	10-109%
321-60-8	2-Fluorobiphenyl	52%	59%	33%	11-109%
1718-51-0	Terphenyl-d14	56%	59%	42%	10-120%

* = Outside of Control Limits.

Instrument Performance Check (DFTPP)

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample:	E2P5327-DFTPP	**Injection Date:**	03/05/24
Lab File ID:	2P118217.D	**Injection Time:**	08:55
Instrument ID:	GCMS2P		

m/e	Ion Abundance Criteria	Raw Abundance	% Relative Abundance		Pass/Fail
51	30.0 - 60.0% of mass 198	29010	41.7		Pass
68	Less than 2.0% of mass 69	531	0.76	(1.85) [a]	Pass
69	Mass 69 relative abundance	28775	41.4		Pass
70	Less than 2.0% of mass 69	215	0.31	(0.75) [a]	Pass
127	40.0 - 60.0% of mass 198	31635	45.5		Pass
197	Less than 1.0% of mass 198	0	0.00		Pass
198	Base peak, 100% relative abundance	69563	100.0		Pass
199	5.0 - 9.0% of mass 198	4938	7.10		Pass
275	10.0 - 30.0% of mass 198	17912	25.7		Pass
365	1.0 - 100.0% of mass 198	2116	3.04		Pass
441	Present, but less than mass 443	9281	13.3	(84.3) [b]	Pass
442	40.0 - 100.0% of mass 198	55864	80.3		Pass
443	17.0 - 23.0% of mass 442	11015	15.8	(19.7) [c]	Pass

(a) Value is % of mass 69
(b) Value is % of mass 443
(c) Value is % of mass 442

This check applies to the following Samples, MS, MSD, Blanks, and Standards:

Lab Sample ID	Lab File ID	Date Analyzed	Time Analyzed	Hours Lapsed	Client Sample ID
E2P5327-ICC5327	2P118218.D	03/05/24	09:05	00:10	Initial cal 50
E2P5327-IC5327	2P118219.D	03/05/24	09:41	00:46	Initial cal 2
E2P5327-IC5327	2P118220.D	03/05/24	10:00	01:05	Initial cal 1
E2P5327-IC5327	2P118221.D	03/05/24	10:19	01:24	Initial cal 5
E2P5327-IC5327	2P118222.D	03/05/24	10:38	01:43	Initial cal 10
E2P5327-IC5327	2P118223.D	03/05/24	10:57	02:02	Initial cal 25
E2P5327-IC5327	2P118224.D	03/05/24	11:17	02:22	Initial cal 80
E2P5327-IC5327	2P118225.D	03/05/24	11:36	02:41	Initial cal 100
E2P5327-ICV5327	2P118226.D	03/05/24	11:56	03:01	Initial cal verification 50
E2P5327-ICV5327	2P118227.D	03/05/24	12:15	03:20	Initial cal verification 50
E2P5327-ICV5327	2P118228.D	03/05/24	12:34	03:39	Initial cal verification 50

Instrument Performance Check (DFTPP)

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: E2P5328-DFTPP
Lab File ID: 2P118229.D
Instrument ID: GCMS2P
Injection Date: 03/05/24
Injection Time: 16:24

m/e	Ion Abundance Criteria	Raw Abundance	% Relative Abundance		Pass/Fail
51	30.0 - 60.0% of mass 198	63471	39.4		Pass
68	Less than 2.0% of mass 69	963	0.60	(1.55) [a]	Pass
69	Mass 69 relative abundance	62076	38.5		Pass
70	Less than 2.0% of mass 69	341	0.21	(0.55) [a]	Pass
127	40.0 - 60.0% of mass 198	69883	43.3		Pass
197	Less than 1.0% of mass 198	0	0.00		Pass
198	Base peak, 100% relative abundance	161264	100.0		Pass
199	5.0 - 9.0% of mass 198	10995	6.82		Pass
275	10.0 - 30.0% of mass 198	41512	25.7		Pass
365	1.0 - 100.0% of mass 198	5441	3.37		Pass
441	Present, but less than mass 443	24536	15.2	(88.4) [b]	Pass
442	40.0 - 100.0% of mass 198	144891	89.8		Pass
443	17.0 - 23.0% of mass 442	27757	17.2	(19.2) [c]	Pass

(a) Value is % of mass 69
(b) Value is % of mass 443
(c) Value is % of mass 442

This check applies to the following Samples, MS, MSD, Blanks, and Standards:

Lab Sample ID	Lab File ID	Date Analyzed	Time Analyzed	Hours Lapsed	Client Sample ID
E2P5328-ICC5328	2P118230.D	03/05/24	16:34	00:10	Initial cal 50
E2P5328-IC5328	2P118231.D	03/05/24	16:53	00:29	Initial cal 1
E2P5328-IC5328	2P118232.D	03/05/24	17:13	00:49	Initial cal 2
E2P5328-IC5328	2P118233.D	03/05/24	17:33	01:09	Initial cal 5
E2P5328-IC5328	2P118234.D	03/05/24	17:52	01:28	Initial cal 10
E2P5328-IC5328	2P118235.D	03/05/24	18:12	01:48	Initial cal 25
E2P5328-IC5328	2P118236.D	03/05/24	18:31	02:07	Initial cal 80
E2P5328-IC5328	2P118237.D	03/05/24	18:51	02:27	Initial cal 100
E2P5328-ICV5328	2P118238.D	03/05/24	19:11	02:47	Initial cal verification 50
E2P5329-CC5327	2P118241.D	03/06/24	14:14	21:50	Continuing cal 50
E2P5329-CC5328	2P118242.D	03/06/24	14:32	22:08	Continuing cal 50
OP52913-MB1	2P118245.D	03/06/24	15:32	23:08	Method Blank
OP52913-BS1	2P118246.D	03/06/24	15:51	23:27	Blank Spike
OP52925-MB1	2P118247.D	03/06/24	16:10	23:46	Method Blank

Instrument Performance Check (DFTPP)

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: E2P5334-DFTPP
Lab File ID: 2P118373.D
Instrument ID: GCMS2P
Injection Date: 03/12/24
Injection Time: 06:35

m/e	Ion Abundance Criteria	Raw Abundance	% Relative Abundance		Pass/Fail
51	30.0 - 60.0% of mass 198	37332	38.5		Pass
68	Less than 2.0% of mass 69	599	0.62	(1.57) [a]	Pass
69	Mass 69 relative abundance	38075	39.3		Pass
70	Less than 2.0% of mass 69	162	0.17	(0.43) [a]	Pass
127	40.0 - 60.0% of mass 198	43317	44.7		Pass
197	Less than 1.0% of mass 198	0	0.00		Pass
198	Base peak, 100% relative abundance	96987	100.0		Pass
199	5.0 - 9.0% of mass 198	6609	6.81		Pass
275	10.0 - 30.0% of mass 198	25211	26.0		Pass
365	1.0 - 100.0% of mass 198	3019	3.11		Pass
441	Present, but less than mass 443	14862	15.3	(87.0) [b]	Pass
442	40.0 - 100.0% of mass 198	86733	89.4		Pass
443	17.0 - 23.0% of mass 442	17075	17.6	(19.7) [c]	Pass

(a) Value is % of mass 69
(b) Value is % of mass 443
(c) Value is % of mass 442

This check applies to the following Samples, MS, MSD, Blanks, and Standards:

Lab Sample ID	Lab File ID	Date Analyzed	Time Analyzed	Hours Lapsed	Client Sample ID
E2P5334-CC5327	2P118374.D	03/12/24	06:46	00:11	Continuing cal 50
E2P5334-CC5328	2P118375.D	03/12/24	07:06	00:31	Continuing cal 50
OP51647-MB2	2P118378.D	03/12/24	08:31	01:56	Method Blank
ZZZZZZ	2P118379.D	03/12/24	08:50	02:15	(unrelated sample)
OP51638-MB2	2P118380.D	03/12/24	09:10	02:35	Method Blank
ZZZZZZ	2P118381.D	03/12/24	09:29	02:54	(unrelated sample)
JD83927-16	2P118382.D	03/12/24	09:49	03:14	SB-25(1.5-2)030724
ZZZZZZ	2P118383.D	03/12/24	10:09	03:34	(unrelated sample)
ZZZZZZ	2P118384.D	03/12/24	11:43	05:08	(unrelated sample)
ZZZZZZ	2P118385.D	03/12/24	12:04	05:29	(unrelated sample)
ZZZZZZ	2P118386.D	03/12/24	12:27	05:52	(unrelated sample)
ZZZZZZ	2P118387.D	03/12/24	12:51	06:16	(unrelated sample)
ZZZZZZ	2P118388.D	03/12/24	13:17	06:42	(unrelated sample)
ZZZZZZ	2P118389.D	03/12/24	13:45	07:10	(unrelated sample)
ZZZZZZ	2P118390.D	03/12/24	14:10	07:35	(unrelated sample)
ZZZZZZ	2P118391.D	03/12/24	14:37	08:02	(unrelated sample)
ZZZZZZ	2P118392.D	03/12/24	15:00	08:25	(unrelated sample)
ZZZZZZ	2P118393.D	03/12/24	15:22	08:47	(unrelated sample)
ZZZZZZ	2P118394.D	03/12/24	15:43	09:08	(unrelated sample)

Instrument Performance Check (DFTPP)

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample:	E2P5334-DFTPP	**Injection Date:**	03/12/24
Lab File ID:	2P118373.D	**Injection Time:**	06:35
Instrument ID:	GCMS2P		

Lab Sample ID	Lab File ID	Date Analyzed	Time Analyzed	Hours Lapsed	Client Sample ID
ZZZZZZ	2P118395.D	03/12/24	16:04	09:29	(unrelated sample)
ZZZZZZ	2P118396.D	03/12/24	16:25	09:50	(unrelated sample)
ZZZZZZ	2P118397.D	03/12/24	16:46	10:11	(unrelated sample)

Instrument Performance Check (DFTPP)

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: EZ8263-DFTPP
Lab File ID: Z166757.D
Instrument ID: GCMSZ
Injection Date: 03/07/24
Injection Time: 10:45

m/e	Ion Abundance Criteria	Raw Abundance	% Relative Abundance		Pass/Fail
51	30.0 - 60.0% of mass 198	12080	40.8		Pass
68	Less than 2.0% of mass 69	0	0.00	(0.00) [a]	Pass
69	Mass 69 relative abundance	13601	46.0		Pass
70	Less than 2.0% of mass 69	0	0.00	(0.00) [a]	Pass
127	40.0 - 60.0% of mass 198	16025	54.2		Pass
197	Less than 1.0% of mass 198	0	0.00		Pass
198	Base peak, 100% relative abundance	29578	100.0		Pass
199	5.0 - 9.0% of mass 198	1886	6.38		Pass
275	10.0 - 30.0% of mass 198	6587	22.3		Pass
365	1.0 - 100.0% of mass 198	1012	3.42		Pass
441	Present, but less than mass 443	4937	16.7	(80.1) [b]	Pass
442	40.0 - 100.0% of mass 198	29235	98.8		Pass
443	17.0 - 23.0% of mass 442	6164	20.8	(21.1) [c]	Pass

(a) Value is % of mass 69
(b) Value is % of mass 443
(c) Value is % of mass 442

This check applies to the following Samples, MS, MSD, Blanks, and Standards:

Lab Sample ID	Lab File ID	Date Analyzed	Time Analyzed	Hours Lapsed	Client Sample ID
EZ8263-ICC8263	Z166761.D	03/07/24	12:10	01:25	Initial cal 50
EZ8263-IC8263	Z166762.D	03/07/24	12:34	01:49	Initial cal 1
EZ8263-IC8263	Z166763.D	03/07/24	12:57	02:12	Initial cal 2
EZ8263-IC8263	Z166764.D	03/07/24	13:20	02:35	Initial cal 5
EZ8263-IC8263	Z166765.D	03/07/24	13:44	02:59	Initial cal 10
EZ8263-IC8263	Z166766.D	03/07/24	14:07	03:22	Initial cal 25
EZ8263-IC8263	Z166767.D	03/07/24	14:30	03:45	Initial cal 80
EZ8263-IC8263	Z166768.D	03/07/24	14:54	04:09	Initial cal 100
EZ8263-ICV8263	Z166769.D	03/07/24	15:17	04:32	Initial cal verification 50
EZ8263-ICV8263	Z166770.D	03/07/24	15:40	04:55	Initial cal verification 50
EZ8263-ICV8263	Z166771.D	03/07/24	16:04	05:19	Initial cal verification 50

Instrument Performance Check (DFTPP)

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample:	EZ8264-DFTPP	**Injection Date:**	03/07/24
Lab File ID:	Z166772.D	**Injection Time:**	16:26
Instrument ID:	GCMSZ		

m/e	Ion Abundance Criteria	Raw Abundance	% Relative Abundance		Pass/Fail
51	30.0 - 60.0% of mass 198	26674	42.5		Pass
68	Less than 2.0% of mass 69	0	0.00	(0.00) [a]	Pass
69	Mass 69 relative abundance	27614	44.0		Pass
70	Less than 2.0% of mass 69	0	0.00	(0.00) [a]	Pass
127	40.0 - 60.0% of mass 198	34668	55.3		Pass
197	Less than 1.0% of mass 198	0	0.00		Pass
198	Base peak, 100% relative abundance	62695	100.0		Pass
199	5.0 - 9.0% of mass 198	4226	6.74		Pass
275	10.0 - 30.0% of mass 198	14390	23.0		Pass
365	1.0 - 100.0% of mass 198	1813	2.89		Pass
441	Present, but less than mass 443	9748	15.5	(85.2) [b]	Pass
442	40.0 - 100.0% of mass 198	58304	93.0		Pass
443	17.0 - 23.0% of mass 442	11438	18.2	(19.6) [c]	Pass

(a) Value is % of mass 69
(b) Value is % of mass 443
(c) Value is % of mass 442

This check applies to the following Samples, MS, MSD, Blanks, and Standards:

Lab Sample ID	Lab File ID	Date Analyzed	Time Analyzed	Hours Lapsed	Client Sample ID
EZ8264-ICC8264	Z166773.D	03/07/24	16:41	00:15	Initial cal 50
EZ8264-IC8264	Z166774.D	03/07/24	17:04	00:38	Initial cal 1
EZ8264-IC8264	Z166775.D	03/07/24	17:27	01:01	Initial cal 2
EZ8264-IC8264	Z166776.D	03/07/24	17:50	01:24	Initial cal 5
EZ8264-IC8264	Z166777.D	03/07/24	18:14	01:48	Initial cal 10
EZ8264-IC8264	Z166778.D	03/07/24	18:37	02:11	Initial cal 25
EZ8264-IC8264	Z166779.D	03/07/24	19:01	02:35	Initial cal 80
EZ8264-IC8264	Z166780.D	03/07/24	19:24	02:58	Initial cal 100
EZ8264-ICV8264	Z166781.D	03/07/24	19:48	03:22	Initial cal verification 50

Internal Standard Area Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Check Std: E2P5334-CC5327 **Injection Date:** 03/12/24
Lab File ID: 2P118374.D **Injection Time:** 06:46
Instrument ID: GCMS2P **Method:** SW846 8270E

	IS 1 AREA	RT	IS 2 AREA	RT	IS 3 AREA	RT	IS 4 AREA	RT	IS 5 AREA	RT	IS 6 AREA	RT
Initial Cal [a]	42818	3.75	153676	4.43	82866	5.56	160793	6.75	134825	9.22	138100	10.63
Check Std [b]	46943	3.73	162916	4.42	91173	5.54	173644	6.73	144067	9.20	148739	10.60
Upper Limit [c]	93886	3.90	325832	4.59	182346	5.71	347288	6.90	288134	9.37	297478	10.77
Lower Limit [d]	23472	3.56	81458	4.25	45587	5.37	86822	6.56	72034	9.03	74370	10.43
Lab Sample ID	**IS 1 AREA**	**RT**	**IS 2 AREA**	**RT**	**IS 3 AREA**	**RT**	**IS 4 AREA**	**RT**	**IS 5 AREA**	**RT**	**IS 6 AREA**	**RT**
OP51647-MB2 [e]	43084	3.73	118998	4.41	8297*	5.53	24537*	6.72	226*	9.14	0*	0.00*
ZZZZZZ	52228	3.73	189939	4.41	108564	5.53	209994	6.72	160246	9.19	78444	10.59
OP51638-MB2	57695	3.73	209017	4.41	113015	5.53	211075	6.72	155632	9.19	130609	10.59
ZZZZZZ	55918	3.73	201499	4.41	108368	5.53	200760	6.72	150538	9.19	150040	10.59
JD83927-16	50657	3.73	185826	4.41	107952	5.53	210153	6.72	175008	9.19	179086	10.59
ZZZZZZ	58866	3.73	200820	4.41	97098	5.54	181593	6.72	161153	9.19	180846	10.59
ZZZZZZ	72481	3.73	256238	4.43	138247	5.55	252892	6.74	187519	9.21	197073	10.61
ZZZZZZ	52584	3.73	195809	4.42	110303	5.54	198991	6.72	145290	9.20	165944	10.62
ZZZZZZ	69764	3.73	255475	4.42	146739	5.54	265786	6.73	192104	9.20	210436	10.61
ZZZZZZ	67538	3.73	248621	4.42	146844	5.54	274172	6.73	195291	9.20	210161	10.60
ZZZZZZ	57367	3.73	205711	4.42	118539	5.54	224456	6.73	167717	9.20	178234	10.61
ZZZZZZ	57229	3.73	205971	4.42	119610	5.54	225973	6.73	163816	9.20	175361	10.61
ZZZZZZ	55131	3.73	201475	4.42	117084	5.54	219680	6.73	161111	9.20	175047	10.61
ZZZZZZ	78588	3.73	283055	4.42	169057	5.54	315487	6.73	228694	9.20	232369	10.61
ZZZZZZ	64732	3.73	240160	4.42	141113	5.54	267797	6.73	197725	9.20	207033	10.61
ZZZZZZ	65240	3.73	238721	4.42	139564	5.54	267377	6.73	201776	9.20	211936	10.61
ZZZZZZ	59027	3.73	220002	4.42	125330	5.54	237650	6.72	180543	9.20	180918	10.60
ZZZZZZ	53111	3.73	191454	4.42	101630	5.54	186840	6.73	158862	9.20	171746	10.60
ZZZZZZ	49654	3.73	177601	4.42	101723	5.54	204423	6.72	165650	9.20	166947	10.60
ZZZZZZ	48865	3.73	178872	4.41	102789	5.53	204338	6.72	158892	9.20	161140	10.60

IS 1 = 1,4-Dichlorobenzene-d4
IS 2 = Naphthalene-d8
IS 3 = Acenaphthene-D10
IS 4 = Phenanthrene-d10
IS 5 = Chrysene-d12
IS 6 = Perylene-d12

(a) Initial Cal is: E2P5327-ICC5327 2P118218.D 03/05/24 09:05
(b) Check Std Limit = -50 to + 100% of initial cal area.
(c) Upper Limit = + 100% of check standard area; Retention time + 0.167 minutes.
(d) Lower Limit = -50% of check standard area; Retention time -0.167 minutes.
(e) corr ISTD out

Internal Standard Area Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Check Std: EZ8267-CC8263 **Injection Date:** 03/11/24
Lab File ID: Z166821.D **Injection Time:** 10:34
Instrument ID: GCMSZ **Method:** SW846 8270E

	IS 1 AREA	RT	IS 2 AREA	RT	IS 3 AREA	RT	IS 4 AREA	RT	IS 5 AREA	RT	IS 6 AREA	RT
Initial Cal [a]	32969	3.75	130452	4.44	67872	5.56	122655	6.75	99933	9.21	85023	10.60
Check Std [b]	56735	3.74	216693	4.43	106855	5.55	189495	6.73	143129	9.19	120487	10.59
Upper Limit [c]	113470	3.91	433386	4.60	213710	5.72	378990	6.90	286258	9.36	240974	10.76
Lower Limit [d]	28368	3.57	108347	4.26	53428	5.38	94748	6.56	71565	9.02	60244	10.42

Lab Sample ID	IS 1 AREA	RT	IS 2 AREA	RT	IS 3 AREA	RT	IS 4 AREA	RT	IS 5 AREA	RT	IS 6 AREA	RT
OP53010-MB1	57122	3.73	223794	4.42	118194	5.55	211888	6.73	138883	9.19	126770	10.58
OP53010-BS1	59090	3.74	220657	4.42	119980	5.55	209009	6.73	168246	9.19	140999	10.59
OP53012-MB1	56281	3.73	209030	4.42	104495	5.55	182898	6.73	125593	9.19	127108	10.59
OP53012-BS1	50674	3.74	190312	4.42	95271	5.55	165263	6.73	131427	9.19	125082	10.59
JD83927-1	53735	3.73	212146	4.42	118820	5.55	222783	6.73	144491	9.19	127382	10.58
JD83927-2	61001	3.73	242018	4.42	136852	5.55	244096	6.73	168896	9.19	149497	10.58
JD83927-3	60026	3.73	233287	4.42	129360	5.55	232677	6.73	159216	9.19	140379	10.58
JD83927-4	55990	3.73	228578	4.42	128048	5.55	235238	6.73	155052	9.19	136620	10.58
JD83927-5	61189	3.73	238063	4.42	131616	5.55	245491	6.73	163309	9.19	143844	10.58
JD83927-6	64724	3.73	250204	4.42	140573	5.55	260903	6.73	177295	9.19	146908	10.58
JD83927-7	57945	3.74	230525	4.42	127178	5.55	236233	6.73	159444	9.19	137300	10.58
JD83927-8	66503	3.73	252783	4.42	138061	5.55	255099	6.73	173534	9.19	153867	10.59
JD83927-9	61921	3.73	245436	4.42	133275	5.55	246523	6.73	166643	9.19	145630	10.58
JD83927-10	63480	3.73	245286	4.42	139602	5.55	252668	6.73	170332	9.19	149345	10.58
JD83927-11	65631	3.74	259927	4.42	143065	5.55	257518	6.73	174506	9.19	153784	10.59
JD83927-12	62917	3.73	255434	4.42	136766	5.55	253931	6.73	177022	9.19	152161	10.58
JD83927-13	59842	3.73	236142	4.43	132910	5.55	234321	6.73	161547	9.19	141737	10.59
JD83927-15	53363	3.73	209944	4.43	104937	5.55	188629	6.73	141239	9.19	132918	10.58
JD83927-17	53871	3.74	205931	4.42	100086	5.55	182757	6.73	145375	9.19	135302	10.59
JD83927-18	57473	3.74	213334	4.43	107868	5.55	190143	6.73	147832	9.19	137397	10.58
OP53010-MS	54464	3.74	202103	4.43	103969	5.55	186892	6.73	148957	9.19	136598	10.59
OP53010-MSD	52595	3.74	196522	4.43	97632	5.55	176166	6.73	141978	9.19	130206	10.59
JD83927-14	55176	3.73	206535	4.42	108869	5.55	198446	6.73	156850	9.20	147566	10.59
JD83927-16	58943	3.73	221190	4.42	109928	5.55	199365	6.73	164004	9.20	156532	10.61
OP53012-MS	57912	3.74	210244	4.42	105045	5.55	192640	6.73	161174	9.19	153484	10.59
OP53012-MSD	57679	3.74	215983	4.42	107535	5.55	199571	6.73	162178	9.19	152166	10.59
JD83939-11	57470	3.74	217970	4.42	108749	5.55	197611	6.73	152433	9.19	148178	10.58
ZZZZZZ	56370	3.73	213879	4.42	113119	5.55	203142	6.73	159077	9.19	152435	10.59

IS 1 = 1,4-Dichlorobenzene-d4
IS 2 = Naphthalene-d8
IS 3 = Acenaphthene-D10
IS 4 = Phenanthrene-d10

Internal Standard Area Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Check Std:	EZ8267-CC8263	**Injection Date:**	03/11/24
Lab File ID:	Z166821.D	**Injection Time:**	10:34
Instrument ID:	GCMSZ	**Method:**	SW846 8270E

Lab Sample ID	IS 1 AREA	IS 1 RT	IS 2 AREA	IS 2 RT	IS 3 AREA	IS 3 RT	IS 4 AREA	IS 4 RT	IS 5 AREA	IS 5 RT	IS 6 AREA	IS 6 RT

IS 5 = Chrysene-d12
IS 6 = Perylene-d12

(a) Initial Cal is: EZ8263-ICC8263 Z166761.D 03/07/24 12:10
(b) Check Std Limit = -50 to + 100% of initial cal area.
(c) Upper Limit = + 100% of check standard area; Retention time + 0.167 minutes.
(d) Lower Limit = -50% of check standard area; Retention time -0.167 minutes.

Surrogate Recovery Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Method: SW846 8270E **Matrix:** SO

Samples and QC shown here apply to the above method

Lab Sample ID	Lab File ID	S1	S2	S3	S4	S5	S6
JD83927-1	Z166829.D	33	32	33	35	33	42
JD83927-2	Z166830.D	35	35	36	38	34	45
JD83927-3	Z166831.D	34	33	36	37	34	41
JD83927-4	Z166832.D	44	45	45	46	42	55
JD83927-5	Z166833.D	41	43	43	44	42	54
JD83927-6	Z166834.D	24	26	29	26	26	34
JD83927-7	Z166835.D	34	33	37	34	32	44
JD83927-8	Z166836.D	32	33	31	37	33	37
JD83927-9	Z166837.D	37	40	38	39	38	45
JD83927-10	Z166838.D	34	35	35	36	33	41
JD83927-11	Z166839.D	41	44	45	44	42	51
JD83927-12	Z166840.D	44	45	48	46	44	53
JD83927-13	Z166841.D	46	46	45	47	41	50
JD83927-14	Z166848.D	49	54	63	55	55	63
JD83927-15	Z166842.D	42	46	51	43	46	54
JD83927-16	2P118382.D	46	45	42	47	53	53
JD83927-16	Z166849.D	44	48	62	47	53	56
JD83927-17	Z166843.D	43	46	49	45	50	53
JD83927-18	Z166844.D	33	35	44	39	37	44
OP53010-BS1	Z166826.D	54	56	66	59	56	63
OP53010-MB1	Z166825.D	60	61	59	62	58	71
OP53010-MS	Z166846.D	47	51	57	51	52	56
OP53010-MSD	Z166847.D	53	55	69	59	59	59

Surrogate Compounds	Recovery Limits
S1 = 2-Fluorophenol	10-99%
S2 = Phenol-d5	10-96%
S3 = 2,4,6-Tribromophenol	10-123%
S4 = Nitrobenzene-d5	10-109%
S5 = 2-Fluorobiphenyl	11-109%
S6 = Terphenyl-d14	10-120%

Initial Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: E2P5327-ICC5327
Lab FileID: 2P118218.D

Response Factor Report GCMS2P

Method : C:\msdchem\1\METHODS\M2P5327.M (RTE Integrator)
Title : Semi Volatile Extractables by GC/MS
Last Update : Wed Mar 06 08:48:15 2024
Response via : Initial Calibration

Calibration Files
2 =2p118219.D 5 =2p118221.D 25 =2p118223.D 80 =2p118224.D
100 =2p118225.D 50 =2p118218.D 1 =2p118220.D 10 =2p118222.D

Compound	2	5	25	80	100	50	1	10	Avg	%RSD
1) I 1,4-Dichlorobenzene-d	ISTD									
2) 1,4-Dioxane	0.482	0.516	0.468	0.486	0.471	0.513	0.398	0.519	0.482	8.18
3) Pyridine	1.373	1.385	1.363	1.397	1.325	1.480	1.350	1.435	1.388	3.55
4) N-Nitrosodim	0.669	0.719	0.675	0.697	0.685	0.747	0.559	0.716	0.683	8.28
5) 2-Fluorophen	1.045	1.175	1.092	1.131	1.105	1.219	0.866	1.157	1.099	9.85
6) Indene	1.961	2.070	1.974	1.973	1.844	2.109	1.668	2.071	1.959	7.36
7) Cumene	2.312	2.518	2.327	2.423	2.328	2.534	2.209	2.552	2.400	5.22
8) Phenol-d5	1.254	1.414	1.341	1.376	1.334	1.459	1.098	1.373	1.331	8.39
9) Phenol	1.364	1.537	1.458	1.511	1.436	1.610	1.234	1.545	1.462	8.14
10) Aniline	1.742	2.083	1.947	1.888	1.739	2.060	1.614	2.107	1.898	9.70
11) bis(2-Chloro	1.022	0.972	0.977	1.043	1.075	1.137	0.825	0.960	1.001	9.26
12) 2-Chlorophen	1.154	1.235	1.178	1.215	1.146	1.306	0.930	1.252	1.177	9.60
13) Decane	1.399	1.449	1.421	1.460	1.394	1.532	1.429	1.522	1.451	3.60
14) 1,3-Dichloro	1.335	1.481	1.410	1.422	1.357	1.520	1.240	1.505	1.409	6.77
15) 1,4-Dichloro	1.331	1.582	1.411	1.440	1.382	1.551	1.252	1.542	1.436	8.07
16) Benzyl alcoh	0.698	0.769	0.741	0.748	0.708	0.824	0.583	0.769	0.730	9.74
17) 1,2-Dichloro	1.342	1.457	1.383	1.349	1.290	1.469	1.144	1.454	1.361	7.99
18) Acetophenone	1.747	1.923	1.762	1.781	1.644	1.902	1.625	1.907	1.786	6.52
19) 2-Methylphen	1.046	1.112	1.043	1.053	0.997	1.139	0.938	1.119	1.056	6.38
20) 2,2'-oxybis(	0.306	0.326	0.308	0.300	0.288	0.330	0.284	0.325	0.308	5.61
21) 3&4-Methylph	1.050	1.132	1.114	1.118	1.034	1.194	0.926	1.155	1.091	7.74
22) n-Nitroso-di	0.874	0.904	0.878	0.888	0.823	0.936	0.762	0.926	0.874	6.52
23) Hexachloroet	0.521	0.575	0.563	0.562	0.524	0.592	0.506	0.600	0.555	6.22
24) I Naphthalene-d8	ISTD									
25) Nitrobenzene	0.383	0.418	0.406	0.357	0.353	0.431	0.329	0.415	0.387	9.50
26) Nitrobenzene	0.334	0.373	0.362	0.357	0.358	0.381	0.352	0.376	0.362	4.16
27) Quinoline	0.603	0.657	0.633	0.613	0.586	0.656	0.568	0.657	0.621	5.57
28) Isophorone	0.619	0.667	0.646	0.637	0.637	0.686	0.560	0.665	0.640	6.03
29) 2-Nitropheno	0.146	0.163	0.164	0.175	0.175	0.182	0.142	0.162	0.164	8.51
30) 2,4-Dimethyl	0.315	0.360	0.342	0.342	0.333	0.365	0.284	0.348	0.336	7.74
31) Benzoic acid		0.131	0.193	0.202	0.200	0.217		0.166	0.185	16.96
32) bis(2-Chloro	0.383	0.429	0.411	0.403	0.392	0.439	0.353	0.418	0.403	6.77
33) 2,4-Dichloro	0.269	0.300	0.298	0.299	0.291	0.313	0.242	0.305	0.290	8.04
34) 2,6-Dichloro	0.261	0.305	0.291	0.292	0.288	0.309	0.255	0.302	0.288	6.87
35) 1,3,5-Trichl	0.333	0.385	0.382	0.379	0.373	0.395	0.313	0.381	0.367	7.77
36) 1,2,4-Trichl	0.319	0.366	0.352	0.349	0.343	0.367	0.284	0.362	0.343	8.32
37) 1,2,3-Trichl	0.312	0.368	0.346	0.335	0.324	0.358	0.309	0.358	0.339	6.60
38) Naphthalene	0.939	0.974	0.948	0.944	0.915	1.002	0.854	0.987	0.945	4.90
39) 4-Chloroanil	0.379	0.431	0.420	0.413	0.411	0.438	0.343	0.425	0.408	7.75
40) 2,3-Dichloro	0.305	0.363	0.344	0.346	0.339	0.363	0.290	0.365	0.340	8.17
41) Hydroquinone	0.265	0.301	0.287	0.278		0.300	0.237	0.293	0.280	8.16
42) Hexachlorobu	0.199	0.219	0.210	0.206	0.206	0.218	0.187	0.216	0.207	5.23
43) 4-Chloro-3-m	0.255	0.276	0.271	0.264	0.258	0.285	0.230	0.278	0.265	6.52
44) 2-Methylnaph	0.566	0.606	0.593	0.582	0.572	0.617	0.508	0.611	0.582	6.02
45) 1-Methylnaph	0.549	0.582	0.553	0.546	0.541	0.577	0.511	0.570	0.554	4.16

Initial Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: E2P5327-ICC5327
Lab FileID: 2P118218.D

46)	I Acenaphthene-d10					ISTD					
47)	Hexachlorocy	0.361	0.436	0.456	0.448	0.483		0.387	0.428	10.65	
48)	1,2,4,5-Tetr	0.586	0.651	0.642	0.631	0.632	0.687	0.543	0.643	0.627	6.99
49)	2,4,6-Trichl	0.340	0.388	0.397	0.394	0.393	0.437	0.293	0.397	0.380	11.51
50)	2,4,5-Trichl	0.356	0.438	0.431	0.421	0.423	0.459	0.327	0.438	0.412	11.09
51)	2-Fluorobiph	1.255	1.418	1.380	1.326	1.307	1.463	1.136	1.427	1.339	8.01
52)	2-Chloronaph	1.112	1.192	1.154	1.127	1.120	1.256	0.961	1.191	1.139	7.59
53)	Biphenyl	1.323	1.502	1.446	1.432	1.400	1.552	1.236	1.440	1.416	7.03
54)	2-Nitroanili	0.317	0.343	0.327	0.323	0.318	0.355	0.336	0.334	0.332	4.02
55)	Dimethylphth	1.268	1.377	1.342	1.279	1.261	1.414	1.182	1.350	1.309	5.75
56)	Acenaphthyle	1.577	1.808	1.746	1.668	1.639	1.820	1.535	1.764	1.695	6.27
57)	2,6-Dinitrot	0.222	0.252	0.262	0.257	0.257	0.280	0.240	0.254	0.253	6.63
58)	3-Nitroanili	0.307	0.294	0.305	0.291	0.287	0.319	0.269	0.290	0.295	5.08
59)	Acenaphthene	1.115	1.268	1.229	1.191	1.186	1.286	1.089	1.265	1.203	6.02
60)	2,4-Dinitrop	0.086	0.094	0.131	0.144	0.148	0.156		0.109	0.124	22.39

---- Quadratic regression ---- Coefficient = 0.9967
Response Ratio = -0.00837 + 0.14149 *A + 0.00188 *A^2

61)	4-Nitropheno	0.142	0.153	0.168	0.164	0.158	0.180	0.129	0.165	0.157	10.11
62)	Dibenzofuran	1.619	1.710	1.667	1.578	1.543	1.737	1.456	1.706	1.627	5.96
63)	2,4-Dinitrot	0.305	0.357	0.358	0.355	0.351	0.391	0.287	0.347	0.344	9.51
64)	2,3,4,6-Tetr	0.300	0.328	0.340	0.337	0.331	0.356	0.255	0.328	0.322	9.68
65)	Diethylphtha	1.246	1.384	1.335	1.290	1.259	1.426	1.136	1.341	1.302	6.94
66)	Fluorene	1.197	1.331	1.286	1.233	1.223	1.359	1.130	1.304	1.258	6.03
67)	4-Chlorophen	0.563	0.660	0.637	0.605	0.604	0.662	0.535	0.643	0.614	7.51
68)	4-Nitroanili	0.288	0.313	0.305	0.301	0.292	0.327	0.250	0.302	0.297	7.69
69)	I Phenanthrene-d10					ISTD					
70)	4,6-Dinitro-	0.068	0.080	0.097	0.103	0.103	0.108		0.090	0.093	15.28
71)	n-Nitrosodip	0.562	0.599	0.562	0.548	0.542	0.591	0.505	0.573	0.560	5.28
72)	Pentachloron	0.034	0.043	0.044	0.046	0.044	0.048	0.037	0.042	0.042#	11.11
73)	1,2-Diphenyl	0.616	0.697	0.672	0.645	0.634	0.710	0.605	0.674	0.657	5.74
74)	2,4,6-Tribro	0.139	0.138	0.121	0.124	0.122	0.131	0.113	0.123	0.126	7.04
75)	4-Bromopheny	0.178	0.215	0.209	0.207	0.203	0.216	0.182	0.206	0.202	7.03
76)	Hexachlorobe	0.240	0.263	0.260	0.260	0.256	0.269	0.225	0.264	0.255	5.76
77)	Pentachlorop	0.098	0.118	0.139	0.149	0.150	0.153		0.127	0.134	15.22
78)	Phenanthrene	0.957	1.063	1.005	0.976	0.961	1.042	0.904	1.012	0.990	5.15
79)	Anthracene	0.945	1.066	1.022	1.004	0.990	1.070	0.865	1.029	0.999	6.74
80)	Carbazole	0.853	0.949	0.927	0.915	0.897	0.972	0.793	0.951	0.907	6.52
81)	Di-n-butylph	1.074	1.176	1.200	1.187	1.161	1.256	0.988	1.186	1.154	7.26
82)	Fluoranthene	1.040	1.163	1.144	1.146	1.132	1.200	0.944	1.150	1.115	7.42
83)	Octadecane	0.339	0.378	0.377	0.369	0.354	0.392	0.339	0.380	0.366	5.45
84)	I Chrysene-d12					ISTD					
85)	Benzidine	0.778	0.830	0.838	0.805	0.719	0.908	0.622	0.719	0.777	11.41
86)	Pyrene	1.381	1.462	1.423	1.335	1.244	1.480	1.269	1.448	1.380	6.48
87)	Terphenyl-d1	1.121	1.173	1.105	1.052	1.003	1.164	0.993	1.152	1.095	6.52
88)	Butylbenzylp	0.612	0.623	0.620	0.595	0.562	0.642	0.533	0.615	0.600	6.00
89)	Benzo[a]anth	1.318	1.403	1.344	1.289	1.232	1.375	1.281	1.346	1.324	4.18
90)	3,3'-Dichlor	0.539	0.577	0.545	0.530	0.507	0.562	0.496	0.522	0.535	5.09
91)	Chrysene	1.141	1.277	1.244	1.175	1.111	1.272	1.109	1.256	1.198	6.04
92)	bis(2-Ethylh	0.884	0.950	0.940	0.912	0.877	0.979	0.844	0.932	0.915	4.83
93)	I Perylene-d12					ISTD					
94)	Di-n-octylph	1.422	1.511	1.476	1.446	1.420	1.516	1.352	1.488	1.454	3.81
95)	Benzo[b]fluo	1.202	1.367	1.263	1.333	1.345	1.398	1.145	1.313	1.296	6.68
96)	Benzo[k]fluo	1.156	1.234	1.221	1.122	1.081	1.181	1.040	1.199	1.154	5.94
97)	Benzo[a]pyre	1.065	1.138	1.104	1.089	1.061	1.163	1.060	1.102	1.098	3.43
98)	Indeno[1,2,3	1.370	1.490	1.466	1.434	1.419	1.561	1.258	1.454	1.432	6.25

Initial Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: E2P5327-ICC5327
Lab FileID: 2P118218.D

```
 99) Dibenz(a,h)a 0.897 1.006 0.978 0.951 0.934 1.019 0.810 0.984 0.948   7.20
100) Dibenz[a,h]a 1.092 1.178 1.151 1.123 1.119 1.237 1.037 1.127 1.133   5.22
101) 7,12-Dimethy 0.512 0.535 0.527 0.531 0.525 0.554 0.468 0.528 0.522   4.77
102) Benzo[g,h,i] 1.035 1.120 1.096 1.065 1.037 1.166 1.035 1.102 1.082   4.38


 ------------------------------------------------------------------------------
 (#) = Out of Range  ###  Number of calibration levels exceeded format  ###

           M2P5327.M         Wed Mar 06 10:10:41 2024
```

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: E2P5327-ICV5327
Lab FileID: 2P118226.D

Evaluate Continuing Calibration Report

Data File : C:\msdchem\1\DATA\E2P5327\2p118226.D Vial: 10
Acq On : 5 Mar 2024 11:56 am Operator: karimam
Sample : icv5327-50 Inst : GCMS2P
Misc : op52153,E2P5327,30.0,,,1,1 Multiplr: 1.00
MS Integration Params: lscint.p

Method : C:\msdchem\1\METHODS\M2P5327.M (RTE Integrator)
Title : Semi Volatile Extractables by GC/MS
Last Update : Wed Mar 06 08:48:15 2024
Response via : Multiple Level Calibration

Min. RRF : 0.050 Min. Rel. Area : 50% Max. R.T. Dev 0.50min
Max. RRF Dev : 30% Max. Rel. Area : 200%

		Compound	AvgRF	CCRF	%Dev	Area%	Dev(min)	R.T.
1	I	1,4-Dichlorobenzene-d4	1.000	1.000	0.0	100	0.00	3.75
2	t	1,4-Dioxane	0.482	0.527	-9.3	103	0.00	2.50
6	t	Indene	1.959	2.110	-7.7	100	0.00	3.88
7	t	Cumene	2.400	2.804	-16.8	111	0.00	3.37
11	t	bis(2-Chloroethyl)ether	1.001	1.223	-22.2	108	0.00	3.60
13	t	Decane	1.451	1.564	-7.8	102	0.00	3.64
14	t	1,3-Dichlorobenzene	1.409	1.569	-11.4	103	0.00	3.72
15	t	1,4-Dichlorobenzene	1.436	1.596	-11.1	103	0.00	3.76
16	t	Benzyl alcohol	0.730	0.792	-8.5	96	0.00	3.81
17	t	1,2-Dichlorobenzene	1.361	1.512	-11.1	103	0.00	3.83
18	t	Acetophenone	1.786	1.894	-6.0	100	0.00	3.94
20	t	2,2'-oxybis(1-Chloropropa	0.308	0.328	-6.5	99	0.00	3.86
23	t	Hexachloroethane	0.555	0.619	-11.5	105	0.00	4.01
24	I	Naphthalene-d8	1.000	1.000	0.0	99	0.00	4.43
26	t	Nitrobenzene	0.362	0.391	-8.0	102	0.00	4.04
27	t	Quinoline	0.621	0.664	-6.9	100	-0.01	4.64
28	t	Isophorone	0.640	0.721	-12.7	104	0.00	4.16
32	t	bis(2-Chloroethoxy)methan	0.403	0.440	-9.2	99	0.00	4.27
35		1,3,5-Trichlorobenzene	0.367	0.411	-12.0	103	0.00	4.21
36	t	1,2,4-Trichlorobenzene	0.343	0.397	-15.7	107	0.00	4.39
37		1,2,3-Trichlorobenzene	0.339	0.382	-12.7	105	0.00	4.52
38	t	Naphthalene	0.945	1.061	-12.3	105	0.00	4.44
40	t	2,3-Dichloroaniline	0.340	0.371	-9.1	101	0.00	5.04
42	t	Hexachlorobutadiene	0.207	0.231	-11.6	105	0.00	4.50
44	t	2-Methylnaphthalene	0.582	0.630	-8.2	101	0.00	4.85
45	t	1-Methylnaphthalene	0.554	0.604	-9.0	103	0.00	4.92
46	I	Acenaphthene-d10	1.000	1.000	0.0	101	0.00	5.55
47	t	Hexachlorocyclopentadiene	0.428	0.370	13.6	78	0.00	4.95
48	t	1,2,4,5-Tetrachlorobenzen	0.627	0.720	-14.8	106	0.00	4.96

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: E2P5327-ICV5327
Lab FileID: 2P118226.D

52	t	2-Chloronaphthalene	1.139	1.295	-13.7	105	0.00	5.18
53	t	Biphenyl	1.416	1.640	-15.8	107	0.00	5.15
55	t	Dimethylphthalate	1.309	1.463	-11.8	105	0.00	5.35
56	t	Acenaphthylene	1.695	1.652	2.5	92	0.00	5.46
57	t	2,6-Dinitrotoluene	0.253	0.292	-15.4	105	0.00	5.39
59	t	Acenaphthene	1.203	1.398	-16.2	110	0.00	5.58
62	t	Dibenzofuran	1.627	1.843	-13.3	108	0.00	5.70
63	t	2,4-Dinitrotoluene	0.344	0.385	-11.9	100	0.00	5.68
65	t	Diethylphthalate	1.302	1.480	-13.7	105	0.00	5.85
66	t	Fluorene	1.258	1.426	-13.4	106	0.00	5.97
67	t	4-Chlorophenyl-phenylethe	0.614	0.703	-14.5	108	0.00	5.96
69	I	Phenanthrene-d10	1.000	1.000	0.0	101	0.00	6.74
72	t	Pentachloronitrobenzene	0.042	0.047#	-11.9	99	0.00	6.58
73	t	1,2-Diphenylhydrazine	0.657	0.734	-11.7	105	0.00	6.08
75	t	4-Bromophenyl-phenylether	0.202	0.230	-13.9	108	0.00	6.35
76	t	Hexachlorobenzene	0.255	0.286	-12.2	108	0.00	6.41
78	t	Phenanthrene	0.990	1.106	-11.7	108	0.00	6.76
79	t	Anthracene	0.999	1.128	-12.9	107	0.00	6.81
80	t	Carbazole	0.907	1.031	-13.7	108	0.00	6.95
81	t	Di-n-butylphthalate	1.154	1.339	-16.0	108	0.00	7.25
82	t	Fluoranthene	1.115	1.259	-12.9	106	0.00	7.84
83	t	Octadecane	0.366	0.410	-12.0	106	0.00	6.61
84	I	Chrysene-d12	1.000	1.000	0.0	107	0.00	9.22
86	t	Pyrene	1.380	1.509	-9.3	109	0.00	8.06
88	t	Butylbenzylphthalate	0.600	0.650	-8.3	108	0.00	8.67
89	t	Benzo[a]anthracene	1.324	1.417	-7.0	110	0.00	9.21
91	t	Chrysene	1.198	1.338	-11.7	112	0.00	9.25
92	t	bis(2-Ethylhexyl)phthalat	0.915	1.008	-10.2	110	0.00	9.22
93	I	Perylene-d12	1.000	1.000	0.0	107	0.00	10.63
94	t	Di-n-octylphthalate	1.454	1.567	-7.8	111	0.00	9.83
95	t	Benzo[b]fluoranthene	1.296	1.441	-11.2	110	0.00	10.23
96	t	Benzo[k]fluoranthene	1.154	1.180	-2.3	107	0.00	10.26
97	t	Benzo[a]pyrene	1.098	1.108	-0.9	102	0.00	10.57
98	t	Indeno[1,2,3-cd]pyrene	1.432	1.411	1.5	97	0.00	11.93
99	t	Dibenz(a,h)acridine	0.948	1.016	-7.2	107	0.00	11.61
100	t	Dibenz[a,h]anthracene	1.133	1.202	-6.1	104	0.00	11.95
101	t	7,12-Dimethylbenz(a)anthr	0.522	0.534	-2.3	103	0.00	10.22
102	t	Benzo[g,h,i]perylene	1.082	1.197	-10.6	110	0.00	12.32

(#) = Out of Range SPCC's out = 0 CCC's out = 0
2p118218.D M2P5327.M Wed Mar 06 08:52:56 2024

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: E2P5327-ICV5327
Lab FileID: 2P118227.D

Evaluate Continuing Calibration Report

Data File : C:\msdchem\1\DATA\E2P5327\2p118227.D Vial: 11
Acq On : 5 Mar 2024 12:15 pm Operator: karimam
Sample : icv5327-50 Inst : GCMS2P
Misc : op52153,E2P5327,30.0,,,1,1 Multiplr: 1.00
MS Integration Params: lscint.p

Method : C:\msdchem\1\METHODS\M2P5327.M (RTE Integrator)
Title : Semi Volatile Extractables by GC/MS
Last Update : Wed Mar 06 08:48:15 2024
Response via : Multiple Level Calibration

Min. RRF : 0.050 Min. Rel. Area : 50% Max. R.T. Dev 0.50min
Max. RRF Dev : 30% Max. Rel. Area : 200%

		Compound	AvgRF	CCRF	%Dev	Area%	Dev(min)	R.T.
1	I	1,4-Dichlorobenzene-d4	1.000	1.000	0.0	117	0.00	3.75
9	t	Phenol	1.462	1.320	9.7	96	0.00	3.54
12	t	2-Chlorophenol	1.177	1.087	7.6	98	0.00	3.64
19	t	2-Methylphenol	1.056	0.945	10.5	97	0.00	3.85
21	t	3&4-Methylphenol	1.091	1.019	6.6	100	0.00	3.93
24	I	Naphthalene-d8	1.000	1.000	0.0	119	0.00	4.43
29	t	2-Nitrophenol	0.164	0.150	8.5	98	0.00	4.21
30	t	2,4-Dimethylphenol	0.336	0.305	9.2	100	0.00	4.22
31	t	Benzoic acid	0.185	0.190	-2.7	104	0.00	4.29
33	t	2,4-Dichlorophenol	0.290	0.267	7.9	102	0.00	4.34
34	t	2,6-Dichlorophenol	0.288	0.265	8.0	102	0.00	4.47
41	t	Hydroquinone	0.280	0.297	-6.1	118	0.00	4.67
43	t	4-Chloro-3-methylphenol	0.265	0.244	7.9	102	0.00	4.74
46	I	Acenaphthene-d10	1.000	1.000	0.0	126	0.00	5.55
49	t	2,4,6-Trichlorophenol	0.380	0.358	5.8	103	0.00	5.03
50	t	2,4,5-Trichlorophenol	0.412	0.382	7.3	105	0.00	5.05
		----------	True	Calc.	% Drift	----------		
60	t	2,4-Dinitrophenol	100.000	88.953	11.0	102	0.00	5.59
		----------	AvgRF	CCRF	% Dev	----------		
61	t	4-Nitrophenol	0.157	0.153	2.5	107	0.00	5.62
64		2,3,4,6-Tetrachlorophenol	0.322	0.312	3.1	110	0.00	5.79
69	I	Phenanthrene-d10	1.000	1.000	0.0	126	0.00	6.74
70	t	4,6-Dinitro-2-methylpheno	0.093	0.085	8.6	99	0.00	5.99

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: E2P5327-ICV5327
Lab FileID: 2P118227.D

77	t	Pentachlorophenol	0.134	0.128	4.5	106	0.00	6.57	

(#) = Out of Range SPCC's out = 0 CCC's out = 0
2p118218.D M2P5327.M Wed Mar 06 08:55:49 2024

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: E2P5327-ICV5327
Lab FileID: 2P118228.D

Evaluate Continuing Calibration Report

Data File : C:\msdchem\1\DATA\E2P5327\2p118228.D Vial: 12
Acq On : 5 Mar 2024 12:34 pm Operator: karimam
Sample : icv5327-50 Inst : GCMS2P
Misc : op52153,E2P5327,30.0,,,1,1 Multiplr: 1.00
MS Integration Params: lscint.p

Method : C:\msdchem\1\METHODS\M2P5327.M (RTE Integrator)
Title : Semi Volatile Extractables by GC/MS
Last Update : Wed Mar 06 08:48:15 2024
Response via : Multiple Level Calibration

Min. RRF : 0.050 Min. Rel. Area : 50% Max. R.T. Dev 0.50min
Max. RRF Dev : 30% Max. Rel. Area : 200%

		Compound	AvgRF	CCRF	%Dev	Area%	Dev(min)	R.T.
1	I	1,4-Dichlorobenzene-d4	1.000	1.000	0.0	126	0.00	3.75
3	t	Pyridine	1.388	1.212	12.7	103	0.00	2.63
4	t	N-Nitrosodimethylamine	0.683	0.672	1.6	113	0.00	2.61
10		Aniline	1.898	1.719	9.4	105	0.00	3.58
22	t	n-Nitroso-di-n-propylamin	0.874	0.819	6.3	110	0.00	3.93
24	I	Naphthalene-d8	1.000	1.000	0.0	130	0.00	4.43
39	t	4-Chloroaniline	0.408	0.370	9.3	110	0.00	4.47
46	I	Acenaphthene-d10	1.000	1.000	0.0	139	0.00	5.55
58	t	3-Nitroaniline	0.295	0.275	6.8	120	-0.01	5.52
68	t	4-Nitroaniline	0.297	0.262	11.8	111	0.00	5.98
69	I	Phenanthrene-d10	1.000	1.000	0.0	140	0.00	6.74
71	t	n-Nitrosodiphenylamine	0.560	0.507	9.5	120	0.00	6.05
84	I	Chrysene-d12	1.000	1.000	0.0	139	0.00	9.22
85	t	Benzidine	0.777	0.872	-12.2	134	0.00	7.97
90	t	3,3'-Dichlorobenzidine	0.535	0.491	8.2	121	0.00	9.18

(#) = Out of Range SPCC's out = 0 CCC's out = 0
2p118218.D M2P5327.M Wed Mar 06 08:57:57 2024

Initial Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: E2P5328-ICC5328
Lab FileID: 2P118230.D

Response Factor Report GCMS2P

Method : C:\msdchem\1\METHODS\M2P5328.M (RTE Integrator)
Title : Semi Volatile Extractables by GC/MS
Last Update : Wed Mar 06 10:50:19 2024
Response via : Initial Calibration

Calibration Files
2 =2p118232.D 5 =2p118233.D 25 =2p118235.D 80 =2p118236.D
100 =2p118237.D 50 =2p118230.D 1 =2p118231.D 10 =2p118234.D

Compound	2	5	25	80	100	50	1	10	Avg	%RSD
103) I 1,4-Dichlorobenzene-d	ISTD									
104) Benzaldehyde	0.832	0.813	1.006	1.040	1.038	1.016	0.773	0.979	0.937	11.87
105) I Naphthalene-d8a	ISTD									
106) Caprolactam	0.146	0.111	0.152	0.156	0.155	0.156	0.127	0.136	0.143	11.57
107) I Phenanthrene-d10a	ISTD									
108) Atrazine	0.062	0.057	0.078	0.081	0.082	0.081	0.058	0.075	0.072	15.10
114) I Phenanthrene-d10b	ISTD									
115) 1-Chloroocta	0.255	0.239	0.300	0.314	0.318	0.303		0.280	0.287	10.52
116) o-terphenyl	0.399	0.396	0.508	0.522	0.529	0.513	0.377	0.484	0.466	13.77

(#) = Out of Range ### Number of calibration levels exceeded format ###

M2P5327.M Wed Mar 06 10:52:57 2024

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: E2P5328-ICV5328
Lab FileID: 2P118238.D

Evaluate Continuing Calibration Report

Data File : C:\msdchem\1\DATA\E2P5328\2p118238.D Vial: 10
Acq On : 5 Mar 2024 7:11 pm Operator: karimam
Sample : icv5328-50 Inst : GCMS2P
Misc : op52153,E2P5328,30.0,,,1,1 Multiplr: 1.00
MS Integration Params: lscint.p

Method : C:\msdchem\1\METHODS\M2P5327.M (RTE Integrator)
Title : Semi Volatile Extractables by GC/MS
Last Update : Wed Mar 06 10:50:19 2024
Response via : Multiple Level Calibration

Min. RRF : 0.050 Min. Rel. Area : 50% Max. R.T. Dev 0.50min
Max. RRF Dev : 30% Max. Rel. Area : 200%

		Compound	AvgRF	CCRF	%Dev	Area%	Dev(min)	R.T.
103	I	1,4-Dichlorobenzene-d4a	1.000	1.000	0.0	111	0.00	3.75
104		Benzaldehyde	0.937	1.022	-9.1	112	0.00	3.54
105	I	Naphthalene-d8a	1.000	1.000	0.0	113	0.00	4.43
106	t	Caprolactam	0.143	0.150	-4.9	109	0.00	4.68
107	I	Phenanthrene-d10a	1.000	1.000	0.0	111	0.00	6.74
108		Atrazine	0.072	0.082	-13.9	113	0.00	6.47

(#) = Out of Range SPCC's out = 0 CCC's out = 0
2p118230a.D M2P5327.M Wed Mar 06 10:53:15 2024

Continuing Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: E2P5334-CC5327
Lab FileID: 2P118374.D

Evaluate Continuing Calibration Report

Data File : X:\Dayton SVOA GCMS\...se\e2p5334\2p118374.d Vial: 3
Acq On : 12 Mar 2024 6:46 am Operator: karimam
Sample : cc5327-50 Inst : GCMS2P
Misc : op52153,E2P5334,30.0,,,1,1 Multiplr: 1.00
MS Integration Params: lscint.p

Method : X:\Dayton SVOA G...ethods\M2P5327.M (RTE Integrator)
Title : Semi Volatile Extractables by GC/MS
Last Update : Wed Mar 06 10:50:19 2024
Response via : Multiple Level Calibration

Min. RRF : 0.050 Min. Rel. Area : 50% Max. R.T. Dev 0.50min
Max. RRF Dev : 20% Max. Rel. Area : 200%

		Compound	AvgRF	CCRF	%Dev	Area%	Dev(min)	R.T.
1	I	1,4-Dichlorobenzene-d4	1.000	1.000	0.0	110	-0.02	3.73
2	t	1,4-Dioxane	0.482	0.497	-3.1	106	-0.03	2.47
3	t	Pyridine	1.388	1.438	-3.6	107	-0.03	2.61
4	t	N-Nitrosodimethylamine	0.683	0.725	-6.1	106	-0.02	2.59
5	S	2-Fluorophenol	1.099	1.197	-8.9	108	-0.02	3.12
6	t	Indene	1.959	2.053	-4.8	107	-0.02	3.86
7	t	Cumene	2.400	2.547	-6.1	110	-0.02	3.35
8	S	Phenol-d5	1.331	1.449	-8.9	109	-0.02	3.52
9	t	Phenol	1.462	1.546	-5.7	105	-0.01	3.53
10		Aniline	1.898	2.036	-7.3	108	-0.02	3.57
11	t	bis(2-Chloroethyl)ether	1.001	1.068	-6.7	103	-0.02	3.58
12	t	2-Chlorophenol	1.177	1.270	-7.9	107	-0.02	3.63
13	t	Decane	1.451	1.508	-3.9	108	-0.02	3.62
14	t	1,3-Dichlorobenzene	1.409	1.503	-6.7	108	-0.02	3.70
15	t	1,4-Dichlorobenzene	1.436	1.529	-6.5	108	-0.02	3.74
16	t	Benzyl alcohol	0.730	0.772	-5.8	103	-0.02	3.79
17	t	1,2-Dichlorobenzene	1.361	1.450	-6.5	108	-0.02	3.82
18	t	Acetophenone	1.786	1.830	-2.5	106	-0.02	3.93
19	t	2-Methylphenol	1.056	1.093	-3.5	105	-0.02	3.84
20	t	2,2'-oxybis(1-Chloropropa	0.308	0.323	-4.9	107	-0.02	3.85
21	t	3&4-Methylphenol	1.091	1.140	-4.5	105	-0.02	3.92
22	t	n-Nitroso-di-n-propylamin	0.874	0.909	-4.0	107	-0.02	3.92
23	t	Hexachloroethane	0.555	0.593	-6.8	110	-0.02	3.99
24	I	Naphthalene-d8	1.000	1.000	0.0	106	-0.02	4.42
25	S	Nitrobenzene-d5	0.387	0.386	0.3	95	-0.02	4.01
26	t	Nitrobenzene	0.362	0.380	-5.0	106	-0.02	4.03
27	t	Quinoline	0.621	0.653	-5.2	106	-0.02	4.63
28	t	Isophorone	0.640	0.687	-7.3	106	-0.02	4.15
29	t	2-Nitrophenol	0.164	0.188	-14.6	110	-0.02	4.20
30	t	2,4-Dimethylphenol	0.336	0.358	-6.5	104	-0.02	4.21
31	t	Benzoic acid	0.185	0.206	-11.4	101	-0.01	4.28
32	t	bis(2-Chloroethoxy)methan	0.403	0.436	-8.2	105	-0.02	4.26
33	t	2,4-Dichlorophenol	0.290	0.318	-9.7	108	-0.02	4.33
34	t	2,6-Dichlorophenol	0.288	0.312	-8.3	107	-0.02	4.46
35		1,3,5-Trichlorobenzene	0.367	0.400	-9.0	107	-0.02	4.20
36	t	1,2,4-Trichlorobenzene	0.343	0.376	-9.6	108	-0.02	4.37
37		1,2,3-Trichlorobenzene	0.339	0.364	-7.4	108	-0.02	4.51
38	t	Naphthalene	0.945	0.987	-4.4	104	-0.02	4.43
39	t	4-Chloroaniline	0.408	0.439	-7.6	106	-0.02	4.45
40	t	2,3-Dichloroaniline	0.340	0.369	-8.5	108	-0.02	5.01
41	t	Hydroquinone	0.280	0.303	-8.2	107	-0.02	4.66

Continuing Calibration Summary

Job Number: JD83927 **Sample:** E2P5334-CC5327
Account: SESINJPB SESI Consulting Engineers **Lab FileID:** 2P118374.D
Project: 100 Main Street, White Plains, NY

42	t	Hexachlorobutadiene	0.207	0.222	-7.2	108	-0.02	4.49
43	t	4-Chloro-3-methylphenol	0.265	0.287	-8.3	107	-0.02	4.73
44	t	2-Methylnaphthalene	0.582	0.620	-6.5	106	-0.02	4.84
45	t	1-Methylnaphthalene	0.554	0.592	-6.9	109	-0.02	4.90
46	I	Acenaphthene-d10	1.000	1.000	0.0	110	-0.02	5.54
47	t	Hexachlorocyclopentadiene	0.428	0.420	1.9	96	-0.02	4.93
48	t	1,2,4,5-Tetrachlorobenzen	0.627	0.677	-8.0	108	-0.02	4.94
49	t	2,4,6-Trichlorophenol	0.380	0.413	-8.7	104	-0.02	5.01
50	t	2,4,5-Trichlorophenol	0.412	0.459	-11.4	110	-0.02	5.04
51	S	2-Fluorobiphenyl	1.339	1.430	-6.8	108	-0.02	5.06
52	t	2-Chloronaphthalene	1.139	1.230	-8.0	108	-0.02	5.15
53	t	Biphenyl	1.416	1.518	-7.2	108	-0.02	5.13
54	t	2-Nitroaniline	0.332	0.356	-7.2	110	-0.02	5.22
55	t	Dimethylphthalate	1.309	1.372	-4.8	107	-0.02	5.32
56	t	Acenaphthylene	1.695	1.815	-7.1	110	-0.02	5.44
57	t	2,6-Dinitrotoluene	0.253	0.288	-13.8	113	-0.02	5.38
58	t	3-Nitroaniline	0.295	0.326	-10.5	113	-0.02	5.51
59	t	Acenaphthene	1.203	1.272	-5.7	109	-0.02	5.56
		----------	True	Calc.	% Drift	----------		
60	t	2,4-Dinitrophenol	100.000	106.592	-6.6	108	-0.02	5.58
		----------	AvgRF	CCRF	% Dev	----------		
61	t	4-Nitrophenol	0.157	0.169	-7.6	103	-0.02	5.61
62	t	Dibenzofuran	1.627	1.718	-5.6	109	-0.02	5.69
63	t	2,4-Dinitrotoluene	0.344	0.397	-15.4	111	-0.02	5.67
64		2,3,4,6-Tetrachlorophenol	0.322	0.355	-10.2	110	-0.02	5.77
65	t	Diethylphthalate	1.302	1.387	-6.5	107	-0.02	5.84
66	t	Fluorene	1.258	1.356	-7.8	110	-0.03	5.95
67	t	4-Chlorophenyl-phenylethe	0.614	0.653	-6.4	108	-0.02	5.93
68	t	4-Nitroaniline	0.297	0.321	-8.1	108	-0.02	5.97
69	I	Phenanthrene-d10	1.000	1.000	0.0	108	-0.02	6.73
70	t	4,6-Dinitro-2-methylpheno	0.093	0.114	-22.6#	114	-0.02	5.98
71	t	n-Nitrosodiphenylamine	0.560	0.600	-7.1	110	-0.02	6.03
72	t	Pentachloronitrobenzene	0.042	0.048#	-14.3	108	-0.03	6.56
73	t	1,2-Diphenylhydrazine	0.657	0.684	-4.1	104	-0.02	6.06
74	S	2,4,6-Tribromophenol	0.126	0.132	-4.8	110	-0.02	6.14
75	t	4-Bromophenyl-phenylether	0.202	0.221	-9.4	111	-0.02	6.33
76	t	Hexachlorobenzene	0.255	0.274	-7.5	110	-0.02	6.39
77	t	Pentachlorophenol	0.134	0.143	-6.7	101	-0.02	6.56
78	t	Phenanthrene	0.990	1.054	-6.5	109	-0.03	6.74
79	t	Anthracene	0.999	1.077	-7.8	109	-0.02	6.79
80	t	Carbazole	0.907	0.973	-7.3	108	-0.02	6.92
81	t	Di-n-butylphthalate	1.154	1.247	-8.1	107	-0.02	7.22
82	t	Fluoranthene	1.115	1.196	-7.3	108	-0.02	7.82
83	t	Octadecane	0.366	0.385	-5.2	106	-0.03	6.59
84	I	Chrysene-d12	1.000	1.000	0.0	107	-0.03	9.20
85	t	Benzidine	0.777	0.883	-13.6	104	-0.03	7.95
86	t	Pyrene	1.380	1.488	-7.8	107	-0.03	8.04
87	S	Terphenyl-d14	1.095	1.175	-7.3	108	-0.02	8.18
88	t	Butylbenzylphthalate	0.600	0.637	-6.2	106	-0.03	8.65
89	t	Benzo[a]anthracene	1.324	1.372	-3.6	107	-0.02	9.19
90	t	3,3'-Dichlorobenzidine	0.535	0.559	-4.5	106	-0.03	9.16
91	t	Chrysene	1.198	1.262	-5.3	106	-0.02	9.22
92	t	bis(2-Ethylhexyl)phthalat	0.915	0.967	-5.7	105	-0.03	9.20
93	I	Perylene-d12	1.000	1.000	0.0	108	-0.03	10.60

Continuing Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: E2P5334-CC5327
Lab FileID: 2P118374.D

94	t	Di-n-octylphthalate	1.454	1.509	-3.8	107	-0.03	9.81
95	t	Benzo[b]fluoranthene	1.296	1.325	-2.2	102	-0.03	10.20
96	t	Benzo[k]fluoranthene	1.154	1.241	-7.5	113	-0.03	10.23
97	t	Benzo[a]pyrene	1.098	1.145	-4.3	106	-0.03	10.54
98	t	Indeno[1,2,3-cd]pyrene	1.432	1.556	-8.7	107	-0.04	11.89
99	t	Dibenz(a,h)acridine	0.948	1.032	-8.9	109	-0.04	11.58
100	t	Dibenz[a,h]anthracene	1.133	1.206	-6.4	105	-0.05	11.91
101	t	7,12-Dimethylbenz(a)anthr	0.522	0.550	-5.4	107	-0.03	10.19
102	t	Benzo[g,h,i]perylene	1.082	1.169	-8.0	108	-0.05	12.27

(#) = Out of Range SPCC's out = 0 CCC's out = 0
2p118230a.D M2P5327.M Tue Mar 12 14:02:21 2024

6.7.7

6

Continuing Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: E2P5334-CC5328
Lab FileID: 2P118375.D

Evaluate Continuing Calibration Report

Data File : X:\Dayton SVOA GCMS\...se\e2p5334\2p118375.d Vial: 4
Acq On : 12 Mar 2024 7:06 am Operator: karimam
Sample : cc5328-50 Inst : GCMS2P
Misc : op52153,E2P5334,30.0,,,1,1 Multiplr: 1.00
MS Integration Params: lscint.p

Method : X:\Dayton SVOA G...ethods\M2P5327.M (RTE Integrator)
Title : Semi Volatile Extractables by GC/MS
Last Update : Wed Mar 06 10:50:19 2024
Response via : Multiple Level Calibration

Min. RRF : 0.050 Min. Rel. Area : 50% Max. R.T. Dev 0.50min
Max. RRF Dev : 20% Max. Rel. Area : 200%

		Compound	AvgRF	CCRF	%Dev	Area%	Dev(min)	R.T.
103	I	1,4-Dichlorobenzene-d4a	1.000	1.000	0.0	104	-0.02	3.73
104		Benzaldehyde	0.937	0.988	-5.4	101	-0.02	3.52
105	I	Naphthalene-d8a	1.000	1.000	0.0	104	-0.02	4.41
106	t	Caprolactam	0.143	0.149	-4.2	99	-0.02	4.66
107	I	Phenanthrene-d10a	1.000	1.000	0.0	102	-0.03	6.72
108		Atrazine	0.072	0.081	-12.5	103	-0.03	6.45
114	I	Phenanthrene-d10b	1.000	1.000	0.0	102	-0.03	6.72
115	s	1-Chlorooctadecane	0.287	0.308	-7.3	104	-0.03	7.69
116	s	o-terphenyl	0.466	0.514	-10.3	102	-0.03	7.05

-

(#) = Out of Range SPCC's out = 0 CCC's out = 0
2p118230a.D M2P5327.M Tue Mar 12 14:02:23 2024

Initial Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: EZ8263-ICC8263
Lab FileID: Z166761.D

Response Factor Report GCMSZ

Method : C:\MSDCHEM\1\METHODS\MZ8263.M (RTE Integrator)
Title : Semi Volatile GC/MS, ZB-5MS 15m x .25mm x .25um
Last Update : Thu Mar 07 17:34:20 2024
Response via : Initial Calibration

Calibration Files
100 =Z166768.D 80 =Z166767.D 50 =Z166761.D 25 =Z166766.D
10 =Z166765.D 5 =Z166764.D 2 =Z166763.D 1 =Z166762.D

Compound	100	80	50	25	10	5	2	1	Avg	%RSD
1) I 1,4-Dichlorobenzene-d	ISTD									
2) 1,4-Dioxane	0.610	0.632	0.497	0.576	0.593	0.657	0.515	0.409	0.561	14.64
3) Pyridine	1.661	1.743	1.442	1.587	1.651	1.685	1.386	0.959	1.514	16.87
4) N-Nitrosodim	0.873	0.894	0.733	0.847	0.887	0.811	0.737		0.826	8.26
5) 2-Fluorophen	1.325	1.333	1.239	1.201	1.290	1.373	1.191		1.279	5.48
6) Indene	2.264	2.264	2.389	2.238	2.321	2.385	2.249	1.895	2.251	6.90
7) Cumene	3.368	3.282	2.846	2.760	2.968	2.988	2.585	2.542	2.917	10.25
8) Phenol-d5	1.624	1.647	1.617	1.508	1.608	1.647	1.414	1.274	1.542	8.78
9) Phenol	1.730	1.771	1.688	1.606	1.726	1.552	1.391	1.312	1.597	10.54
10) Aniline	2.131	2.139	2.091	2.168	2.414	2.427	2.137	1.950	2.182	7.40
11) bis(2-Chloro	1.138	1.355	1.251	1.122	1.091	1.100	0.898		1.137	12.51
12) 2-Chlorophen	1.374	1.443	1.410	1.312	1.385	1.380	1.327	1.091	1.340	8.13
13) Decane	1.602	1.772	1.641	1.570	1.761	1.659	1.563	1.298	1.608	9.21
14) 1,3-Dichloro	1.541	1.572	1.532	1.441	1.535	1.471	1.532	1.195	1.477	8.21
15) 1,4-Dichloro	1.588	1.599	1.614	1.489	1.620	1.628	1.592	1.234	1.546	8.61
16) Benzyl alcoh	0.878	0.914	0.907	0.846	0.949	0.864	0.852	0.608	0.852	12.29
17) 1,2-Dichloro	1.482	1.523	1.518	1.389	1.482	1.493	1.318	1.122	1.416	9.75
18) Acetophenone	1.923	1.979	2.080	1.951	2.087	2.135	1.771	1.702	1.953	7.86
19) 2-Methylphen	1.179	1.254	1.268	1.204	1.245	1.090	1.126	0.958	1.165	8.97
20) 2,2'-oxybis(	0.359	0.375	0.387	0.372	0.387	0.369	0.330	0.242	0.353	13.68
21) 3&4-Methylph	1.289	1.322	1.312	1.256	1.328	1.305	1.173	0.965	1.244	9.91
22) n-Nitroso-di	0.983	1.026	1.013	0.985	1.102	1.043	1.012	0.656	0.977	13.82
23) Hexachloroet	0.499	0.502	0.521	0.472	0.485	0.472	0.350	0.356	0.457	14.45
24) I Naphthalene-d8	ISTD									
25) Nitrobenzene	0.384	0.386	0.383	0.367	0.386	0.358	0.356	0.281	0.362	9.75
26) Nitrobenzene	0.395	0.399	0.392	0.374	0.394	0.379	0.343	0.344	0.378	5.94
27) Quinoline	0.655	0.658	0.680	0.655	0.667	0.637	0.571	0.468	0.624	11.39
28) Isophorone	0.647	0.683	0.672	0.643	0.665	0.684	0.588	0.631	0.652	4.93
29) 2-Nitropheno	0.212	0.185	0.173	0.152	0.136	0.137			0.166	18.03
30) 2,4-Dimethyl	0.369	0.369	0.375	0.359	0.366	0.367	0.304	0.275	0.348	10.72
31) Benzoic Acid	0.262	0.265	0.181	0.241	0.209	0.162			0.220	19.41
32) bis(2-Chloro	0.407	0.409	0.421	0.403	0.423	0.409	0.350	0.297	0.390	11.26
33) 2,4-Dichloro	0.302	0.286	0.288	0.270	0.253	0.252	0.237		0.270	8.63
34) 2,6-Dichloro	0.316	0.288	0.304	0.263	0.277	0.254	0.224	0.182	0.263	16.63
35) 1,3,5-Trichl	0.390	0.343	0.351	0.317	0.337	0.323	0.262	0.249	0.322	14.41
36) 1,2,4-Trichl	0.326	0.315	0.316	0.298	0.298	0.299	0.253	0.236	0.293	10.77
37) 1,2,3-Trichl	0.311	0.293	0.313	0.284	0.290	0.291	0.245	0.185	0.277	15.34
38) Naphthalene	1.109	1.068	1.099	1.040	1.064	1.096	0.977	0.912	1.046	6.56
39) 4-Chloroanil	0.479	0.448	0.448	0.423	0.431	0.408	0.409	0.310	0.419	11.95
40) 2,3-Dichloro	0.357	0.336	0.337	0.302	0.310	0.297	0.255	0.226	0.302	14.55
41) Hydroquinone	0.250	0.283	0.280	0.265	0.278	0.274	0.243	0.238	0.264	6.70
42) Hexachlorobu	0.174	0.169	0.180	0.156	0.161	0.152	0.126	0.158	0.160	10.31
43) 4-Chloro-3-m	0.290	0.280	0.275	0.274	0.257	0.266	0.242	0.182	0.258	13.14
44) 2-Methylnaph	0.658	0.635	0.664	0.602	0.622	0.600	0.512	0.486	0.597	10.94
45) 1-Methylnaph	0.702	0.671	0.722	0.642	0.653	0.640	0.485	0.450	0.621	15.98

Initial Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: EZ8263-ICC8263
Lab FileID: Z166761.D

```
46) I   Acenaphthene-d10      ----------------ISTD--------------------
47) Hexachlorocy 0.311 0.292 0.439 0.372 0.341 0.293             0.341  16.61
48) 1,2,4,5-tetr 0.601 0.599 0.590 0.541 0.577 0.535 0.484 0.546 0.559   7.19
49) 2,4,6-Trichl 0.422 0.408 0.380 0.378 0.358 0.332 0.339       0.374   8.98
50) 2,4,5-Trichl 0.415 0.414 0.422 0.386 0.398 0.400 0.271 0.332 0.380  13.76
51) 2-Fluorobiph 1.448 1.436 1.411 1.384 1.380 1.406 1.267 1.252 1.373   5.37
52) 2-Chloronaph 1.201 1.215 1.240 1.155 1.137 1.150 1.059 0.860 1.127  10.79
53) Biphenyl     1.638 1.655 1.587 1.558 1.553 1.601 1.265 1.395 1.532   8.74
54) 2-Nitroanili 0.361 0.379 0.371 0.367 0.329 0.320 0.255 0.300 0.335  12.81
55) Dimethylphth 1.353 1.374 1.405 1.338 1.318 1.334 1.221 1.119 1.308   7.13
56) Acenaphthyle 1.607 1.607 1.904 1.869 1.778 1.802 1.591 1.237 1.674  12.87
57) 2,6-Dinitrot 0.277 0.279 0.274 0.272 0.241 0.206 0.168 0.235 0.244  16.42
58) 3-Nitroanili 0.344 0.345 0.346 0.326 0.303 0.342 0.231       0.320  13.20
59) Acenaphthene 1.397 1.385 1.340 1.254 1.281 1.334 1.168 1.136 1.287   7.47
60) 2,4-Dinitrop 0.187 0.178 0.163 0.152 0.118 0.091 0.078       0.138  30.89
         ----- Quadratic regression -----              Coefficient =  0.9993
              Response Ratio = -0.00866 + 0.14152 *A + 0.00953 *A^2

61) 4-Nitropheno 0.208 0.218 0.212 0.203 0.193 0.188 0.136       0.194  14.32
62) Dibenzofuran 1.884 1.772 1.813 1.684 1.669 1.719 1.513 1.448 1.688   8.69
63) 2,4-Dinitrot 0.420 0.399 0.379 0.385 0.353 0.349 0.269 0.230 0.348  18.86
64) 2,3,4,6-Tetr 0.310 0.302 0.297 0.275 0.250 0.261 0.216       0.273  12.27
65) Diethylphtha 1.477 1.448 1.481 1.350 1.381 1.334 1.205 1.116 1.349   9.71
66) Fluorene     1.459 1.423 1.456 1.338 1.323 1.388 1.178 1.234 1.350   7.60
67) 4-Chlorophen 0.666 0.647 0.651 0.578 0.553 0.545 0.477 0.467 0.573  13.50
68) 4-Nitroanili 0.318 0.329 0.378 0.336 0.331 0.286 0.251 0.225 0.307  16.24

69) I   Phenanthrene-d10      ----------------ISTD--------------------
70) 4,6-Dinitro- 0.124 0.119 0.109 0.099 0.085 0.052             0.098  27.17
         ----- Quadratic regression -----              Coefficient =  0.9999
              Response Ratio = -0.00599 + 0.10219 *A + 0.00977 *A^2

71) n-Nitrosodip 0.654 0.635 0.668 0.619 0.576 0.619 0.540 0.470 0.597  11.03
72) Pentachloron 0.031 0.028 0.030 0.024 0.024 0.011             0.024# 30.31
         ----- Quadratic regression -----              Coefficient =  0.9956
              Response Ratio = -0.00206 + 0.02886 *A + 0.00076 *A^2

73) 1,2-Diphenyl 0.848 0.883 0.924 0.879 0.866 0.863 0.766 0.698 0.841   8.68
74) 2,4,6-Tribro 0.069 0.064 0.063 0.057 0.054 0.060 0.050       0.059  10.66
75) 4-Bromopheny 0.183 0.171 0.179 0.170 0.150 0.146 0.133       0.162  11.56
76) Hexachlorobe 0.186 0.173 0.190 0.159 0.168 0.165 0.129 0.092 0.158  20.52
         ----- Quadratic regression -----              Coefficient =  0.9977
              Response Ratio = -0.00199 + 0.17250 *A + 0.00468 *A^2

77) Pentachlorop 0.150 0.128 0.122 0.105 0.097 0.079 0.071       0.107  26.07
         ----- Quadratic regression -----              Coefficient =  0.9985
              Response Ratio = -0.00223 + 0.09145 *A + 0.01114 *A^2

78) Phenanthrene 1.156 1.116 1.121 1.040 1.044 1.015 1.021 0.962 1.059   6.18
79) Anthracene   1.160 1.115 1.171 1.065 1.017 0.983 0.940 0.850 1.038  10.78
80) Carbazole    1.102 1.075 1.080 0.991 0.978 0.957 0.865 0.750 0.975  12.29
81) Di-n-butylph 1.499 1.441 1.408 1.317 1.216 1.152 1.050 0.906 1.249  16.49
82) Fluoranthene 1.309 1.188 1.185 1.086 1.008 1.018 0.932 0.864 1.074  13.76
83) Octadecane   0.487 0.481 0.506 0.514 0.474 0.464 0.421 0.378 0.466   9.71

84) I   Chrysene-d12         ----------------ISTD--------------------
85) Benzidine    0.807 0.862 0.899 0.913 0.866 0.758             0.851   6.88
86) Pyrene       1.451 1.426 1.570 1.552 1.473 1.524 1.472 1.257 1.466   6.70
87) Terphenyl-d1 1.004 0.947 1.042 1.000 0.975 0.989 0.847 0.920 0.966   6.26
```

Initial Calibration Summary

Job Number: JD83927 **Sample:** EZ8263-ICC8263
Account: SESINJPB SESI Consulting Engineers **Lab FileID:** Z166761.D
Project: 100 Main Street, White Plains, NY

```
 88) Butylbenzylp 0.700 0.667 0.705 0.689 0.617 0.529 0.400       0.615  18.42
 89) Benzo[a]anth 1.464 1.357 1.442 1.372 1.310 1.289 1.298 1.160 1.336   7.19
 90) 3,3'-Dichlor 0.498 0.452 0.483 0.444 0.435 0.415 0.376 0.311 0.427  14.09
 91) Chrysene     1.183 1.178 1.304 1.271 1.295 1.338 1.242 1.188 1.250   4.92
 92) bis(2-Ethylh 1.282 1.197 1.253 1.204 1.100 0.968 0.712       1.102  18.31

 93) I   Perylene-d12          ----------------ISTD---------------------
 94) Di-n-octylph 2.188 2.134 2.137 1.899 1.747 1.541 0.876       1.789  26.12
          ----- Quadratic regression -----                Coefficient =  0.9996
               Response Ratio = -0.06010 + 2.01232 *A + 0.08200 *A^2

 95) Benzo[b]fluo 1.592 1.499 1.498 1.395 1.347 1.424 1.147 1.036 1.367  13.77
 96) Benzo[k]fluo 1.264 1.269 1.408 1.303 1.345 1.270 1.087 0.980 1.241  11.26
 97) Benzo[a]pyre 1.172 1.108 1.283 1.168 1.139 1.111 0.855 0.812 1.081  15.04
 98) Indeno[1,2,3 1.297 1.238 1.400 1.290 1.295 1.202 0.899 0.833 1.182  17.25
 99) Dibenz(a,h)a 0.913 0.858 0.897 0.838 0.772 0.695 0.569       0.791  15.62
100) Dibenz[a,h]a 1.189 1.077 1.122 1.016 0.993 0.960 0.871 0.604 0.979  18.45
101) 7,12-Dimethy 0.569 0.547 0.577 0.504 0.489 0.439 0.328       0.493  17.77
102) Benzo[g,h,i] 1.077 1.051 1.008 0.975 0.954 0.873 0.774 0.680 0.924  15.02


 ------------------------------------------------------------------------------
 (#) = Out of Range  ###  Number of calibration levels exceeded format  ###

           MZ8263.M          Thu Mar 07 18:04:09 2024
```

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: EZ8263-ICV8263
Lab FileID: Z166769.D

Evaluate Continuing Calibration Report

Data File : C:\msdchem\1\DATA\EZ8263\Z166769.D Vial: 10
Acq On : 7 Mar 2024 3:17 pm Operator: ninap
Sample : icv8263-50 Inst : GCMSZ
Misc : op52762,ez8263,1000,,,1,1 Multiplr: 1.00
MS Integration Params: lscint.p

Method : C:\MSDCHEM\1\METHODS\MZ8263.M (RTE Integrator)
Title : Semi Volatile GC/MS, ZB-5MS 15m x .25mm x .25um
Last Update : Thu Mar 07 17:34:20 2024
Response via : Multiple Level Calibration

Min. RRF : 0.050 Min. Rel. Area : 50% Max. R.T. Dev 0.50min
Max. RRF Dev : 30% Max. Rel. Area : 200%

		Compound	AvgRF	CCRF	%Dev	Area%	Dev(min)	R.T.
1	I	1,4-Dichlorobenzene-d4	1.000	1.000	0.0	124	0.00	3.75
2		1,4-Dioxane	0.561	0.647	-15.3	162	0.00	2.52
6	t	Indene	2.251	2.395	-6.4	125	0.00	3.88
7	t	Cumene	2.917	3.362	-15.3	147	0.00	3.37
11	t	bis(2-Chloroethyl)ether	1.137	1.389	-22.2	138	0.00	3.60
13	t	Decane	1.608	1.744	-8.5	132	0.00	3.63
14	t	1,3-Dichlorobenzene	1.477	1.645	-11.4	134	0.00	3.72
15	t	1,4-Dichlorobenzene	1.546	1.693	-9.5	130	0.00	3.76
16	t	Benzyl alcohol	0.852	0.976	-14.6	134	0.00	3.81
17	t	1,2-Dichlorobenzene	1.416	1.560	-10.2	128	0.00	3.84
18	t	Acetophenone	1.953	2.077	-6.3	124	0.00	3.95
20	t	2,2'-oxybis(1-Chloropropa	0.353	0.396	-12.2	127	0.00	3.87
23	t	Hexachloroethane	0.457	0.533	-16.6	127	0.00	4.01
24	I	Naphthalene-d8	1.000	1.000	0.0	117	0.00	4.44
26	t	Nitrobenzene	0.378	0.430	-13.8	128	0.00	4.05
27	t	Quinoline	0.624	0.698	-11.9	120	-0.03	4.65
28	t	Isophorone	0.652	0.737	-13.0	128	-0.02	4.17
32	t	bis(2-Chloroethoxy)methan	0.390	0.460	-17.9	128	0.00	4.28
35	t	1,3,5-Trichlorobenzene	0.322	0.361	-12.1	120	0.00	4.22
36	t	1,2,4-Trichlorobenzene	0.293	0.336	-14.7	124	0.00	4.40
37	t	1,2,3-Trichlorobenzene	0.277	0.331	-19.5	123	0.00	4.53
38	t	Naphthalene	1.046	1.163	-11.2	124	0.00	4.45
40	t	2,3-Dichloroaniline	0.302	0.337	-11.6	117	0.00	5.04
42	t	Hexachlorobutadiene	0.160	0.187	-16.9	121	0.00	4.50
44	t	2-Methylnaphthalene	0.597	0.673	-12.7	118	0.00	4.86
45	t	1-Methylnaphthalene	0.621	0.708	-14.0	115	0.00	4.92
46	I	Acenaphthene-d10	1.000	1.000	0.0	110	0.00	5.56
47	t	Hexachlorocyclopentadiene	0.341	0.332	2.6	84	0.00	4.94
48	t	1,2,4,5-tetrachlorobenzen	0.559	0.652	-16.6	122	0.00	4.96

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: EZ8263-ICV8263
Lab FileID: Z166769.D

52	t	2-Chloronaphthalene	1.127	1.335	-18.5	119	0.00	5.18
53	t	Biphenyl	1.532	1.799	-17.4	125	0.00	5.16
55	t	Dimethylphthalate	1.308	1.522	-16.4	120	0.00	5.35
56	t	Acenaphthylene	1.674	1.778	-6.2	103	0.00	5.46
57	t	2,6-Dinitrotoluene	0.244	0.307	-25.8	124	0.00	5.41
59	t	Acenaphthene	1.287	1.510	-17.3	124	0.00	5.58
62	t	Dibenzofuran	1.688	1.959	-16.1	119	0.00	5.71
63	t	2,4-Dinitrotoluene	0.348	0.403	-15.8	118	-0.01	5.69
65	t	Diethylphthalate	1.349	1.647	-22.1	123	-0.01	5.86
66	t	Fluorene	1.350	1.573	-16.5	119	0.00	5.97
67	t	4-Chlorophenyl-phenylethe	0.573	0.693	-20.9	118	0.00	5.96
69	I	Phenanthrene-d10	1.000	1.000	0.0	115	0.00	6.74
			True	Calc.	% Drift			
72	t	Pentachloronitrobenzene	50.000	49.002	2.0	105	0.00	6.57
			AvgRF	CCRF	% Dev			
73	t	1,2-Diphenylhydrazine	0.841	0.952	-13.2	118	0.00	6.08
75	t	4-Bromophenyl-phenylether	0.162	0.184	-13.6	118	0.00	6.35
			True	Calc.	% Drift			
76	t	Hexachlorobenzene	50.000	53.315	-6.6	114	0.00	6.40
			AvgRF	CCRF	% Dev			
78	t	Phenanthrene	1.059	1.188	-12.2	122	0.00	6.76
79	t	Anthracene	1.038	1.175	-13.2	115	0.00	6.81
80	t	Carbazole	0.975	1.115	-14.4	119	0.00	6.95
81	t	Di-n-butylphthalate	1.249	1.462	-17.1	119	0.00	7.24
82	t	Fluoranthene	1.074	1.268	-18.1	123	0.00	7.84
83	t	Octadecane	0.466	0.546	-17.2	124	0.00	6.60
84	I	Chrysene-d12	1.000	1.000	0.0	110	0.00	9.20
86	t	Pyrene	1.466	1.680	-14.6	117	0.00	8.05
88	t	Butylbenzylphthalate	0.615	0.772	-25.5	120	0.00	8.66
89	t	Benzo[a]anthracene	1.336	1.484	-11.1	113	0.00	9.19
91	t	Chrysene	1.250	1.362	-9.0	115	0.00	9.23
92	t	bis(2-Ethylhexyl)phthalat	1.102	1.297	-17.7	114	0.00	9.20
93	I	Perylene-d12	1.000	1.000	0.0	116	0.00	10.60
			True	Calc.	% Drift			
94	t	Di-n-octylphthalate	50.000	52.841	-5.7	119	0.00	9.81
			AvgRF	CCRF	% Dev			
95	t	Benzo[b]fluoranthene	1.367	1.580	-15.6	122	0.00	10.20
96	t	Benzo[k]fluoranthene	1.241	1.333	-7.4	110	0.00	10.23

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: EZ8263-ICV8263
Lab FileID: Z166769.D

97	t	Benzo[a]pyrene	1.081	1.199	-10.9	108	0.00	10.54
98	t	Indeno[1,2,3-cd]pyrene	1.182	1.302	-10.2	108	0.00	11.89
99	t	Dibenz(a,h)acridine	0.791	0.909	-14.9	118	0.00	11.58
100	t	Dibenz[a,h]anthracene	0.979	1.153	-17.8	119	0.00	11.91
101	t	7,12-Dimethylbenz(a)anthr	0.493	0.507	-2.8	102	0.00	10.19
102	t	Benzo[g,h,i]perylene	0.924	1.095	-18.5	126	0.00	12.28

(#) = Out of Range SPCC's out = 0 CCC's out = 0
Z166761.D MZ8263.M Thu Mar 07 18:04:29 2024

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: EZ8263-ICV8263
Lab FileID: Z166770.D

Evaluate Continuing Calibration Report

Data File : C:\msdchem\1\DATA\EZ8263\Z166770.D Vial: 11
Acq On : 7 Mar 2024 3:40 pm Operator: ninap
Sample : icv8263-50 Inst : GCMSZ
Misc : op52762,ez8263,1000,,,1,1 Multiplr: 1.00
MS Integration Params: lscint.p

Method : C:\MSDCHEM\1\METHODS\MZ8263.M (RTE Integrator)
Title : Semi Volatile GC/MS, ZB-5MS 15m x .25mm x .25um
Last Update : Thu Mar 07 17:34:20 2024
Response via : Multiple Level Calibration

Min. RRF : 0.050 Min. Rel. Area : 50% Max. R.T. Dev 0.50min
Max. RRF Dev : 30% Max. Rel. Area : 200%

		Compound	AvgRF	CCRF	%Dev	Area%	Dev(min)	R.T.
1	I	1,4-Dichlorobenzene-d4	1.000	1.000	0.0	173	0.00	3.75
9	t	Phenol	1.597	1.590	0.4	163	0.00	3.54
12	t	2-Chlorophenol	1.340	1.321	1.4	162	0.00	3.64
19	t	2-Methylphenol	1.165	1.168	-0.3	159	0.00	3.85
21	t	3&4-Methylphenol	1.244	1.262	-1.4	166	0.00	3.93
24	I	Naphthalene-d8	1.000	1.000	0.0	166	0.00	4.43
29	t	2-Nitrophenol	0.166	0.169	-1.8	162	0.00	4.22
30	t	2,4-Dimethylphenol	0.348	0.350	-0.6	155	0.00	4.22
31		Benzoic Acid	0.220	0.252	-14.5	231#	0.00	4.32
33	t	2,4-Dichlorophenol	0.270	0.275	-1.9	159	0.00	4.34
34		2,6-Dichlorophenol	0.263	0.269	-2.3	147	0.00	4.48
41	t	Hydroquinone	0.264	0.325	-23.1	192	0.03	4.70
43	t	4-Chloro-3-methylphenol	0.258	0.267	-3.5	162	0.00	4.74
46	I	Acenaphthene-d10	1.000	1.000	0.0	154	0.00	5.56
49	t	2,4,6-Trichlorophenol	0.374	0.396	-5.9	160	0.00	5.03
50	t	2,4,5-Trichlorophenol	0.380	0.427	-12.4	156	-0.01	5.05
		----------	True	Calc.	% Drift	----------		
60	t	2,4-Dinitrophenol	100.000	106.706	-6.7	165	-0.01	5.60
		----------	AvgRF	CCRF	% Dev	----------		
61	t	4-Nitrophenol	0.194	0.219	-12.9	159	0.00	5.62
64		2,3,4,6-Tetrachlorophenol	0.273	0.304	-11.4	157	0.00	5.79
69	I	Phenanthrene-d10	1.000	1.000	0.0	163	0.00	6.74

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: EZ8263-ICV8263
Lab FileID: Z166770.D

			True	Calc.	% Drift			
70	t	4,6-Dinitro-2-methylpheno	50.000	49.994	0.0	164	-0.01	5.99
77	t	Pentachlorophenol	100.000	93.824	6.2	147	0.00	6.56

(#) = Out of Range SPCC's out = 0 CCC's out = 0
Z166761.D MZ8263.M Thu Mar 07 18:04:31 2024

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: EZ8263-ICV8263
Lab FileID: Z166771.D

Evaluate Continuing Calibration Report

Data File : C:\msdchem\1\DATA\EZ8263\Z166771.D Vial: 12
Acq On : 7 Mar 2024 4:04 pm Operator: ninap
Sample : icv8263-50 Inst : GCMSZ
Misc : op52762,ez8263,1000,,,1,1 Multiplr: 1.00
MS Integration Params: lscint.p

Method : C:\MSDCHEM\1\METHODS\MZ8263.M (RTE Integrator)
Title : Semi Volatile GC/MS, ZB-5MS 15m x .25mm x .25um
Last Update : Thu Mar 07 17:34:20 2024
Response via : Multiple Level Calibration

Min. RRF : 0.050 Min. Rel. Area : 50% Max. R.T. Dev 0.50min
Max. RRF Dev : 30% Max. Rel. Area : 200%

		Compound	AvgRF	CCRF	%Dev	Area%	Dev(min)	R.T.
1	I	1,4-Dichlorobenzene-d4	1.000	1.000	0.0	130	0.00	3.75
3	t	Pyridine	1.514	1.496	1.2	135	0.00	2.66
4	t	N-Nitrosodimethylamine	0.826	0.868	-5.1	154	0.00	2.63
10	t	Aniline	2.182	1.983	9.1	123	0.00	3.59
22	t	n-Nitroso-di-n-propylamin	0.977	0.944	3.4	121	-0.02	3.94
24	I	Naphthalene-d8	1.000	1.000	0.0	124	0.00	4.44
39	t	4-Chloroaniline	0.419	0.406	3.1	113	0.00	4.48
46	I	Acenaphthene-d10	1.000	1.000	0.0	120	0.00	5.56
54	t	2-Nitroaniline	0.335	0.355	-6.0	115	0.00	5.24
58	t	3-Nitroaniline	0.320	0.315	1.6	109	-0.01	5.53
68	t	4-Nitroaniline	0.307	0.297	3.3	95	-0.01	5.99
69	I	Phenanthrene-d10	1.000	1.000	0.0	118	0.00	6.74
71	t	n-Nitrosodiphenylamine	0.597	0.602	-0.8	107	0.00	6.05
84	I	Chrysene-d12	1.000	1.000	0.0	101	0.00	9.20
85	t	Benzidine	0.851	1.083	-27.3	122	0.00	7.97
90	t	3,3'-Dichlorobenzidine	0.427	0.483	-13.1	101	0.00	9.17
93	I	Perylene-d12	1.000	1.000	0.0	109	0.00	10.59

(#) = Out of Range SPCC's out = 0 CCC's out = 0
Z166761.D MZ8263.M Thu Mar 07 18:04:33 2024

Initial Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: EZ8264-ICC8264
Lab FileID: Z166773.D

Response Factor Report GCMSZ

Method : C:\MSDCHEM\1\METHODS\MZ8264.M (RTE Integrator)
Title : Semi Volatile GC/MS, ZB-5MS 15m x .25mm x .25um
Last Update : Fri Mar 08 09:55:07 2024
Response via : Initial Calibration

Calibration Files
100 =Z166780.D 80 =Z166779.D 50 =Z166773.D 25 =Z166778.D
10 =Z166777.D 5 =Z166776.D 2 =Z166775.D 1 =Z166774.D

Compound	100	80	50	25	10	5	2	1	Avg	%RSD
103) 1,4-Dichlorobenzene-d	ISTD									
104) Benzaldehyde	1.121	1.117	1.097	1.124	1.030	0.822	0.861	0.872	1.005	13.08
105) Phenanthrene-d10a	ISTD									
106) Atrazine	0.087	0.083	0.087	0.076	0.070	0.049	0.039		0.070	27.11
----- Quadratic regression ----- Coefficient = 0.9985										
Response Ratio = -0.00262 + 0.08038 *A + 0.00298 *A^2										
107) I Naphthalene-d8a	ISTD									
108) Caprolactam	0.137	0.135	0.135	0.128	0.114	0.072	0.081		0.115	23.68
----- Quadratic regression ----- Coefficient = 0.9986										
Response Ratio = -0.00374 + 0.12983 *A + 0.00389 *A^2										
109) Phenanthrene-d10b	ISTD									
110) 1-chloroocta	0.336	0.324	0.315	0.321	0.259	0.211			0.294	16.61
111) o-terphenyl	0.540	0.503	0.467	0.466	0.421	0.322	0.355		0.439	17.83

(#) = Out of Range ### Number of calibration levels exceeded format ###

MZ8263.M Fri Mar 08 09:59:35 2024

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: EZ8264-ICV8264
Lab FileID: Z166781.D

Evaluate Continuing Calibration Report

Data File : C:\msdchem\1\DATA\EZ8264\Z166781.D Vial: 10
Acq On : 7 Mar 2024 7:48 pm Operator: kaleigh
Sample : icv8264-50 Inst : GCMSZ
Misc : op52762,ez8264,1000,,,1,1 Multiplr: 1.00
MS Integration Params: lscint.p

Method : C:\MSDCHEM\1\METHODS\MZ8263.M (RTE Integrator)
Title : Semi Volatile GC/MS, ZB-5MS 15m x .25mm x .25um
Last Update : Fri Mar 08 09:55:07 2024
Response via : Multiple Level Calibration

Min. RRF : 0.050 Min. Rel. Area : 50% Max. R.T. Dev 0.50min
Max. RRF Dev : 30% Max. Rel. Area : 200%

	Compound	AvgRF	CCRF	%Dev	Area%	Dev(min)	R.T.
103	1,4-Dichlorobenzene-d4a	1.000	1.000	0.0	140	0.00	3.75
104	Benzaldehyde	1.005	1.107	-10.1	141	0.00	3.54
105	Phenanthrene-d10a	1.000	1.000	0.0	135	0.00	6.74
	----------	True	Calc.	% Drift	----------		
106	Atrazine	50.000	49.778	0.4	127	0.00	6.48
	----------	AvgRF	CCRF	% Dev	----------		
107 I	Naphthalene-d8a	1.000	1.000	0.0	139	0.00	4.44
	----------	True	Calc.	% Drift	----------		
108 t	Caprolactam	50.000	50.959	-1.9	139	0.00	4.70

(#) = Out of Range SPCC's out = 0 CCC's out = 0
Z166773a.D MZ8263.M Fri Mar 08 09:59:58 2024

Continuing Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: EZ8267-CC8263
Lab FileID: Z166821.D

Evaluate Continuing Calibration Report

Data File : X:\Dayton SVOA GCMS\...2-24\EZ8267\Z166821.D Vial: 1
Acq On : 11 Mar 2024 10:34 am Operator: jackleey
Sample : cc8263-50 Inst : GCMSZ
Misc : op52762,ez8267,1000,,,1,1 Multiplr: 1.00
MS Integration Params: lscint.p

Method : X:\Dayton SVOA G...methods\MZ8263.M (RTE Integrator)
Title : Semi Volatile GC/MS, ZB-5MS 15m x .25mm x .25um
Last Update : Tue Mar 12 01:34:36 2024
Response via : Multiple Level Calibration

Min. RRF : 0.050 Min. Rel. Area : 50% Max. R.T. Dev 0.50min
Max. RRF Dev : 20% Max. Rel. Area : 200%

		Compound	AvgRF	CCRF	%Dev	Area%	Dev(min)	R.T.
1	I	1,4-Dichlorobenzene-d4	1.000	1.000	0.0	172	0.00	3.74
2		1,4-Dioxane	0.561	0.665	-18.5	230#	0.00	2.51
3	t	Pyridine	1.514	1.770	-16.9	211#	0.00	2.64
4	t	N-Nitrosodimethylamine	0.826	0.910	-10.2	214#	0.00	2.62
5	S	2-Fluorophenol	1.279	1.209	5.5	168	0.00	3.12
6	t	Indene	2.251	1.905	15.4	137	0.00	3.87
7	t	Cumene	2.917	2.542	12.9	154	0.00	3.36
8	S	Phenol-d5	1.542	1.376	10.8	146	0.00	3.52
9	t	Phenol	1.597	1.513	5.3	154	0.00	3.53
10	t	Aniline	2.182	1.858	14.8	153	0.00	3.58
11	t	bis(2-Chloroethyl)ether	1.137	1.097	3.5	151	0.00	3.60
12	t	2-Chlorophenol	1.340	1.159	13.5	141	0.00	3.63
13	t	Decane	1.608	1.416	11.9	148	0.00	3.62
14	t	1,3-Dichlorobenzene	1.477	1.226	17.0	138	0.00	3.71
15	t	1,4-Dichlorobenzene	1.546	1.232	20.3#	131	0.00	3.75
16	t	Benzyl alcohol	0.852	0.753	11.6	143	0.00	3.80
17	t	1,2-Dichlorobenzene	1.416	1.183	16.5	134	0.00	3.83
18	t	Acetophenone	1.953	1.626	16.7	134	0.00	3.95
19	t	2-Methylphenol	1.165	1.050	9.9	143	0.00	3.84
20	t	2,2'-oxybis(1-Chloropropa	0.353	0.302	14.4	134	0.00	3.86
21	t	3&4-Methylphenol	1.244	1.058	15.0	139	0.00	3.93
22	t	n-Nitroso-di-n-propylamin	0.977	0.829	15.1	141	0.00	3.94
23	t	Hexachloroethane	0.457	0.381	16.6	126	0.00	4.00
24	I	Naphthalene-d8	1.000	1.000	0.0	166	0.00	4.43
25	S	Nitrobenzene-d5	0.362	0.320	11.6	139	0.00	4.03
26	t	Nitrobenzene	0.378	0.332	12.2	141	0.00	4.04
27	t	Quinoline	0.624	0.552	11.5	135	0.00	4.66
28	t	Isophorone	0.652	0.566	13.2	140	0.00	4.17
29	t	2-Nitrophenol	0.166	0.147	11.4	141	0.00	4.21
30	t	2,4-Dimethylphenol	0.348	0.298	14.4	132	0.00	4.22
31		Benzoic Acid	0.220	0.184	16.4	169	0.00	4.31
32	t	bis(2-Chloroethoxy)methan	0.390	0.342	12.3	135	0.00	4.27
33	t	2,4-Dichlorophenol	0.270	0.220	18.5	127	0.00	4.34
34		2,6-Dichlorophenol	0.263	0.222	15.6	121	0.00	4.47
35	t	1,3,5-Trichlorobenzene	0.322	0.260	19.3	123	0.00	4.20
36	t	1,2,4-Trichlorobenzene	0.293	0.236	19.5	124	0.00	4.39
37	t	1,2,3-Trichlorobenzene	0.277	0.227	18.1	121	0.00	4.52
38	t	Naphthalene	1.046	0.834	20.3#	126	0.00	4.44
39	t	4-Chloroaniline	0.419	0.352	16.0	131	0.00	4.47
40	t	2,3-Dichloroaniline	0.302	0.236	21.9#	116	0.00	5.03
41	t	Hydroquinone	0.264	0.240	9.1	142	0.00	4.65

Continuing Calibration Summary

Job Number: JD83927 **Sample:** EZ8267-CC8263
Account: SESINJPB SESI Consulting Engineers **Lab FileID:** Z166821.D
Project: 100 Main Street, White Plains, NY

42	t	Hexachlorobutadiene	0.160	0.121	24.4#	112	0.00	4.49
43	t	4-Chloro-3-methylphenol	0.258	0.228	11.6	138	0.00	4.74
44	t	2-Methylnaphthalene	0.597	0.488	18.3	122	0.00	4.85
45	t	1-Methylnaphthalene	0.621	0.538	13.4	124	0.00	4.91
46	I	Acenaphthene-d10	1.000	1.000	0.0	157	0.00	5.55
47	t	Hexachlorocyclopentadiene	0.341	0.317	7.0	114	0.00	4.93
48	t	1,2,4,5-tetrachlorobenzen	0.559	0.451	19.3	120	0.00	4.95
49	t	2,4,6-Trichlorophenol	0.374	0.301	19.5	125	0.00	5.02
50	t	2,4,5-Trichlorophenol	0.380	0.319	16.1	119	0.00	5.04
51	S	2-Fluorobiphenyl	1.373	1.072	21.9#	120	0.00	5.08
52	t	2-Chloronaphthalene	1.127	0.930	17.5	118	0.00	5.17
53	t	Biphenyl	1.532	1.234	19.5	122	0.00	5.14
54	t	2-Nitroaniline	0.335	0.304	9.3	129	0.00	5.24
55	t	Dimethylphthalate	1.308	1.080	17.4	121	0.00	5.34
56	t	Acenaphthylene	1.674	1.509	9.9	125	0.00	5.45
57	t	2,6-Dinitrotoluene	0.244	0.214	12.3	123	0.00	5.40
58	t	3-Nitroaniline	0.320	0.281	12.2	128	0.00	5.52
59	t	Acenaphthene	1.287	1.002	22.1#	118	0.00	5.57
			True	Calc.	% Drift			
60	t	2,4-Dinitrophenol	100.000	91.447	8.6	141	0.00	5.59
			AvgRF	CCRF	% Dev			
61	t	4-Nitrophenol	0.194	0.182	6.2	135	0.00	5.62
62	t	Dibenzofuran	1.688	1.317	22.0#	114	0.00	5.70
63	t	2,4-Dinitrotoluene	0.348	0.300	13.8	125	0.00	5.68
64		2,3,4,6-Tetrachlorophenol	0.273	0.222	18.7	117	0.00	5.78
65	t	Diethylphthalate	1.349	1.145	15.1	122	0.00	5.85
66	t	Fluorene	1.350	1.055	21.9#	114	0.00	5.96
67	t	4-Chlorophenyl-phenylethe	0.573	0.474	17.3	115	0.00	5.95
68	t	4-Nitroaniline	0.307	0.281	8.5	117	0.00	5.98
69	I	Phenanthrene-d10	1.000	1.000	0.0	154	0.00	6.73
			True	Calc.	% Drift			
70	t	4,6-Dinitro-2-methylpheno	50.000	44.674	10.7	137	0.00	5.99
			AvgRF	CCRF	% Dev			
71	t	n-Nitrosodiphenylamine	0.597	0.498	16.6	115	0.00	6.04
			True	Calc.	% Drift			
72	t	Pentachloronitrobenzene	50.000	41.532	16.9	118	0.00	6.56
			AvgRF	CCRF	% Dev			
73	t	1,2-Diphenylhydrazine	0.841	0.713	15.2	119	0.00	6.07
74	S	2,4,6-Tribromophenol	0.059	0.052	11.9	127	0.00	6.14
75	t	4-Bromophenyl-phenylether	0.162	0.133	17.9	114	0.00	6.34
			True	Calc.	% Drift			
76	t	Hexachlorobenzene	50.000	38.239	23.5#	109	0.00	6.38
77	t	Pentachlorophenol	100.000	80.812	19.2	116	0.00	6.56
			AvgRF	CCRF	% Dev			
78	t	Phenanthrene	1.059	0.829	21.7#	114	0.00	6.75
79	t	Anthracene	1.038	0.840	19.1	111	0.00	6.80
80	t	Carbazole	0.975	0.827	15.2	118	0.00	6.93
81	t	Di-n-butylphthalate	1.249	1.111	11.0	122	0.00	7.23
82	t	Fluoranthene	1.074	0.905	15.7	118	0.00	7.83
83	t	Octadecane	0.466	0.412	11.6	126	0.00	6.59

Continuing Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: EZ8267-CC8263
Lab FileID: Z166821.D

84	I	Chrysene-d12	1.000	1.000	0.0	143	0.00	9.19
85	t	Benzidine	0.851	0.741	12.9	118	0.00	7.96
86	t	Pyrene	1.466	1.262	13.9	115	0.00	8.04
87	S	Terphenyl-d14	0.966	0.838	13.3	115	0.00	8.18
88	t	Butylbenzylphthalate	0.615	0.630	-2.4	128	0.00	8.65
89	t	Benzo[a]anthracene	1.336	1.154	13.6	115	0.00	9.18
90	t	3,3'-Dichlorobenzidine	0.427	0.383	10.3	113	0.00	9.16
91	t	Chrysene	1.250	1.047	16.2	115	0.00	9.22
92	t	bis(2-Ethylhexyl)phthalat	1.102	1.016	7.8	116	0.00	9.19
93	I	Perylene-d12	1.000	1.000	0.0	142	0.00	10.59
			True	Calc.	% Drift			
94	t	Di-n-octylphthalate	50.000	45.840	8.3	125	0.00	9.80
			AvgRF	CCRF	% Dev			
95	t	Benzo[b]fluoranthene	1.367	1.297	5.1	123	0.00	10.19
96	t	Benzo[k]fluoranthene	1.241	1.132	8.8	114	0.00	10.22
97	t	Benzo[a]pyrene	1.081	1.067	1.3	118	0.00	10.53
98	t	Indeno[1,2,3-cd]pyrene	1.182	1.150	2.7	116	0.00	11.88
99	t	Dibenz(a,h)acridine	0.791	0.762	3.7	120	0.00	11.57
100	t	Dibenz[a,h]anthracene	0.979	0.942	3.8	119	0.00	11.90
101	t	7,12-Dimethylbenz(a)anthr	0.493	0.486	1.4	119	0.00	10.18
102	t	Benzo[g,h,i]perylene	0.924	0.853	7.7	120	0.00	12.26

(#) = Out of Range SPCC's out = 0 CCC's out = 0
Z166821.D MZ8263.M Tue Mar 12 01:35:31 2024

Continuing Calibration Summary

Job Number: JD83927 **Sample:** EZ8267-CC8264
Account: SESINJPB SESI Consulting Engineers **Lab FileID:** Z166822.D
Project: 100 Main Street, White Plains, NY

Evaluate Continuing Calibration Report

Data File : X:\Dayton SVOA GCMS\...2-24\EZ8267\Z166822.D Vial: 2
Acq On : 11 Mar 2024 10:57 am Operator: jackleey
Sample : cc8264-50 Inst : GCMSZ
Misc : op52762,ez8267,1000,,,1,1 Multiplr: 1.00
MS Integration Params: lscint.p

Method : X:\Dayton SVOA G...methods\MZ8263.M (RTE Integrator)
Title : Semi Volatile GC/MS, ZB-5MS 15m x .25mm x .25um
Last Update : Tue Mar 12 01:34:36 2024
Response via : Multiple Level Calibration

Min. RRF : 0.050 Min. Rel. Area : 50% Max. R.T. Dev 0.50min
Max. RRF Dev : 20% Max. Rel. Area : 200%

	Compound	AvgRF	CCRF	%Dev	Area%	Dev(min)	R.T.
103	1,4-Dichlorobenzene-d4a	1.000	1.000	0.0	93	0.00	3.73
104	Benzaldehyde	1.005	1.215	-20.9#	103	0.00	3.53
105	Phenanthrene-d10a	1.000	1.000	0.0	96	0.00	6.73
	----------	True	Calc.	% Drift	----------		
106	Atrazine	50.000	56.537	-13.1	104	0.00	6.47
	----------	AvgRF	CCRF	% Dev	----------		
107 I	Naphthalene-d8a	1.000	1.000	0.0	91	0.00	4.42
	----------	True	Calc.	% Drift	----------		
108 t	Caprolactam	50.000	57.310	-14.6	103	0.00	4.69
	----------	AvgRF	CCRF	% Dev	----------		
109	Phenanthrene-d10b	1.000	1.000	0.0	96	0.00	6.73
110 s	1-chlorooctadecane	0.294	0.356	-21.1#	109	0.00	7.68
111 s	o-terphenyl	0.439	0.538	-22.6#	111	0.00	7.05

(#) = Out of Range SPCC's out = 0 CCC's out = 0
Z166821.D MZ8263.M Tue Mar 12 01:35:33 2024

Continuing Calibration Summary

Job Number: JD83927 **Sample:** EZ8267-CC8263
Account: SESINJPB SESI Consulting Engineers **Lab FileID:** Z166823.D
Project: 100 Main Street, White Plains, NY

Low Level Verification Report

Data File : X:\Dayton SVOA GCMS\...2-24\EZ8267\Z166823.D Vial: 3
Acq On : 11 Mar 2024 11:19 am Operator: jackleey
Sample : cc8263-1 Inst : GCMSZ
Misc : op52762,ez8267,1000,,,1,1 Multiplr: 1.00
MS Integration Params: lscint.p

Method : X:\Dayton SVOA G...methods\MZ8263.M (RTE Integrator)
Title : Semi Volatile GC/MS, ZB-5MS 15m x .25mm x .25um
Last Update : Tue Mar 12 01:34:36 2024
Response via : Multiple Level Calibration

Min. RRF : 0.050 Min. Rel. Area : 50% Max. R.T. Dev 0.50min
Max. RRF Dev : 100% Max. Rel. Area : 200%

		Compound	AvgRF	CCRF	%Dev	Area%	Dev(min)	R.T.
1	I	1,4-Dichlorobenzene-d4	1.000	1.000	0.0	133	0.00	3.73
15	t	1,4-Dichlorobenzene	1.546	1.237	20.0	133	0.00	3.75
24	I	Naphthalene-d8	1.000	1.000	0.0	133	0.00	4.42
38	t	Naphthalene	1.046	0.927	11.4	135	0.00	4.43
40	t	2,3-Dichloroaniline	0.302	0.229	24.2	135	0.00	5.03
42	t	Hexachlorobutadiene	0.160	0.129	19.4	108	0.00	4.49
46	I	Acenaphthene-d10	1.000	1.000	0.0	136	0.00	5.55
51	S	2-Fluorobiphenyl	1.373	1.247	9.2	135	0.00	5.07
59	t	Acenaphthene	1.287	1.099	14.6	131	0.00	5.57
62	t	Dibenzofuran	1.688	1.472	12.8	138	0.00	5.69
66	t	Fluorene	1.350	1.142	15.4	126	0.00	5.95
69	I	Phenanthrene-d10	1.000	1.000	0.0	145	0.00	6.73
		----------	True	Calc.	% Drift	----------		
76	t	Hexachlorobenzene	1.000	1.002	-0.2	146	0.00	6.38
		----------	AvgRF	CCRF	% Dev	----------		
78	t	Phenanthrene	1.059	0.923	12.8	139	0.00	6.75

(#) = Out of Range SPCC's out = 0 CCC's out = 0
Z166774a.D MZ8263.M Tue Mar 12 01:43:25 2024

Run Sequence Report

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Run ID: E2P5327	**Method:** SW846 8270E	**Instrument ID:** GCMS2P

Lab Sample ID	Lab File ID	Date/Time Analyzed	Prep QC Batch	Client Sample ID
E2P5327-DFTPP	2P118217.D	03/05/24 08:55	n/a	DFTPP Tune
E2P5327-ICC5327	2P118218.D	03/05/24 09:05	n/a	Initial cal 50
E2P5327-IC5327	2P118219.D	03/05/24 09:41	n/a	Initial cal 2
E2P5327-IC5327	2P118220.D	03/05/24 10:00	n/a	Initial cal 1
E2P5327-IC5327	2P118221.D	03/05/24 10:19	n/a	Initial cal 5
E2P5327-IC5327	2P118222.D	03/05/24 10:38	n/a	Initial cal 10
E2P5327-IC5327	2P118223.D	03/05/24 10:57	n/a	Initial cal 25
E2P5327-IC5327	2P118224.D	03/05/24 11:17	n/a	Initial cal 80
E2P5327-IC5327	2P118225.D	03/05/24 11:36	n/a	Initial cal 100
E2P5327-ICV5327	2P118226.D	03/05/24 11:56	n/a	Initial cal verification 50
E2P5327-ICV5327	2P118227.D	03/05/24 12:15	n/a	Initial cal verification 50
E2P5327-ICV5327	2P118228.D	03/05/24 12:34	n/a	Initial cal verification 50

Run Sequence Report

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Run ID: E2P5328	**Method:** SW846 8270E	**Instrument ID:** GCMS2P

Lab Sample ID	Lab File ID	Date/Time Analyzed	Prep QC Batch	Client Sample ID
E2P5328-DFTPP	2P118229.D	03/05/24 16:24	n/a	DFTPP Tune
E2P5328-ICC5328	2P118230.D	03/05/24 16:34	n/a	Initial cal 50
E2P5328-IC5328	2P118231.D	03/05/24 16:53	n/a	Initial cal 1
E2P5328-IC5328	2P118232.D	03/05/24 17:13	n/a	Initial cal 2
E2P5328-IC5328	2P118233.D	03/05/24 17:33	n/a	Initial cal 5
E2P5328-IC5328	2P118234.D	03/05/24 17:52	n/a	Initial cal 10
E2P5328-IC5328	2P118235.D	03/05/24 18:12	n/a	Initial cal 25
E2P5328-IC5328	2P118236.D	03/05/24 18:31	n/a	Initial cal 80
E2P5328-IC5328	2P118237.D	03/05/24 18:51	n/a	Initial cal 100
E2P5328-ICV5328	2P118238.D	03/05/24 19:11	n/a	Initial cal verification 50

Run Sequence Report

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Run ID: E2P5334	**Method:** SW846 8270E	**Instrument ID:** GCMS2P

Lab Sample ID	Lab File ID	Date/Time Analyzed	Prep QC Batch	Client Sample ID
E2P5334-DFTPP	2P118373.D	03/12/24 06:35	n/a	DFTPP Tune
E2P5334-CC5327	2P118374.D	03/12/24 06:46	n/a	Continuing cal 50
E2P5334-CC5328	2P118375.D	03/12/24 07:06	n/a	Continuing cal 50
OP51647-MB2	2P118378.D	03/12/24 08:31	OP51647	Method Blank
ZZZZZZ	2P118379.D	03/12/24 08:50	OP51647	(unrelated sample)
OP51638-MB2	2P118380.D	03/12/24 09:10	OP51638	Method Blank
ZZZZZZ	2P118381.D	03/12/24 09:29	OP51638	(unrelated sample)
JD83927-16	2P118382.D	03/12/24 09:49	OP53010	SB-25(1.5-2)030724
ZZZZZZ	2P118383.D	03/12/24 10:09	OP53012	(unrelated sample)
ZZZZZZ	2P118384.D	03/12/24 11:43	OP53012	(unrelated sample)
ZZZZZZ	2P118385.D	03/12/24 12:04	OP53009	(unrelated sample)
ZZZZZZ	2P118386.D	03/12/24 12:27	OP53012	(unrelated sample)
ZZZZZZ	2P118387.D	03/12/24 12:51	OP53012	(unrelated sample)
ZZZZZZ	2P118388.D	03/12/24 13:17	OP53011	(unrelated sample)
ZZZZZZ	2P118389.D	03/12/24 13:45	OP53011	(unrelated sample)
ZZZZZZ	2P118390.D	03/12/24 14:10	OP53011	(unrelated sample)
ZZZZZZ	2P118391.D	03/12/24 14:37	OP52995	(unrelated sample)
ZZZZZZ	2P118392.D	03/12/24 15:00	OP53011	(unrelated sample)
ZZZZZZ	2P118393.D	03/12/24 15:22	OP53011	(unrelated sample)
ZZZZZZ	2P118394.D	03/12/24 15:43	OP53008	(unrelated sample)
ZZZZZZ	2P118395.D	03/12/24 16:04	OP53009	(unrelated sample)
ZZZZZZ	2P118396.D	03/12/24 16:25	OP53008	(unrelated sample)
ZZZZZZ	2P118397.D	03/12/24 16:46	OP52997	(unrelated sample)

Run Sequence Report

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Run ID: EZ8263	**Method:** SW846 8270E	**Instrument ID:** GCMSZ

Lab Sample ID	Lab File ID	Date/Time Analyzed	Prep QC Batch	Client Sample ID
EZ8263-DFTPP	Z166757.D	03/07/24 10:45	n/a	DFTPP Tune
EZ8263-ICC8263	Z166761.D	03/07/24 12:10	n/a	Initial cal 50
EZ8263-IC8263	Z166762.D	03/07/24 12:34	n/a	Initial cal 1
EZ8263-IC8263	Z166763.D	03/07/24 12:57	n/a	Initial cal 2
EZ8263-IC8263	Z166764.D	03/07/24 13:20	n/a	Initial cal 5
EZ8263-IC8263	Z166765.D	03/07/24 13:44	n/a	Initial cal 10
EZ8263-IC8263	Z166766.D	03/07/24 14:07	n/a	Initial cal 25
EZ8263-IC8263	Z166767.D	03/07/24 14:30	n/a	Initial cal 80
EZ8263-IC8263	Z166768.D	03/07/24 14:54	n/a	Initial cal 100
EZ8263-ICV8263	Z166769.D	03/07/24 15:17	n/a	Initial cal verification 50
EZ8263-ICV8263	Z166770.D	03/07/24 15:40	n/a	Initial cal verification 50
EZ8263-ICV8263	Z166771.D	03/07/24 16:04	n/a	Initial cal verification 50

Run Sequence Report

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Run ID: EZ8264	**Method:** SW846 8270E	**Instrument ID:** GCMSZ

Lab Sample ID	Lab File ID	Date/Time Analyzed	Prep QC Batch	Client Sample ID
EZ8264-DFTPP	Z166772.D	03/07/24 16:26	n/a	DFTPP Tune
EZ8264-ICC8264	Z166773.D	03/07/24 16:41	n/a	Initial cal 50
EZ8264-IC8264	Z166774.D	03/07/24 17:04	n/a	Initial cal 1
EZ8264-IC8264	Z166775.D	03/07/24 17:27	n/a	Initial cal 2
EZ8264-IC8264	Z166776.D	03/07/24 17:50	n/a	Initial cal 5
EZ8264-IC8264	Z166777.D	03/07/24 18:14	n/a	Initial cal 10
EZ8264-IC8264	Z166778.D	03/07/24 18:37	n/a	Initial cal 25
EZ8264-IC8264	Z166779.D	03/07/24 19:01	n/a	Initial cal 80
EZ8264-IC8264	Z166780.D	03/07/24 19:24	n/a	Initial cal 100
EZ8264-ICV8264	Z166781.D	03/07/24 19:48	n/a	Initial cal verification 50

Run Sequence Report

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Run ID: EZ8267	**Method:** SW846 8270E	**Instrument ID:** GCMSZ

Lab Sample ID	Lab File ID	Date/Time Analyzed	Prep QC Batch	Client Sample ID
EZ8267-CC8263	Z166821.D	03/11/24 10:34	n/a	Continuing cal 50
EZ8267-CC8264	Z166822.D	03/11/24 10:57	n/a	Continuing cal 50
EZ8267-CC8263	Z166823.D	03/11/24 11:19	n/a	Continuing cal 1
OP53010-MB1	Z166825.D	03/11/24 12:04	OP53010	Method Blank
OP53010-BS1	Z166826.D	03/11/24 12:26	OP53010	Blank Spike
OP53012-MB1	Z166827.D	03/11/24 12:49	OP53012	Method Blank
OP53012-BS1	Z166828.D	03/11/24 13:11	OP53012	Blank Spike
JD83927-1	Z166829.D	03/11/24 13:34	OP53010	SB-7(4-4.5)030724
JD83927-2	Z166830.D	03/11/24 13:57	OP53010	SB-7(7-7.5)030724
JD83927-3	Z166831.D	03/11/24 14:20	OP53010	SB-8(4-4.5)030724
JD83927-4	Z166832.D	03/11/24 14:43	OP53010	SB-8(7.5-8)030724
JD83927-5	Z166833.D	03/11/24 15:06	OP53010	SB-9(3.5-4)030724
JD83927-6	Z166834.D	03/11/24 15:29	OP53010	SB-10(3.5-4)030724
JD83927-7	Z166835.D	03/11/24 15:52	OP53010	SB-10(7-5.5)030724
JD83927-8	Z166836.D	03/11/24 16:15	OP53010	SB-11(3.5-4)030724
JD83927-9	Z166837.D	03/11/24 16:38	OP53010	SB-11(8-8.5)030724
JD83927-10	Z166838.D	03/11/24 17:01	OP53010	SB-16(3-3.5)030724
JD83927-11	Z166839.D	03/11/24 17:24	OP53010	SB-16(7.5-8)030724
JD83927-12	Z166840.D	03/11/24 17:47	OP53010	SB-19(4-4.5)030724
JD83927-13	Z166841.D	03/11/24 18:11	OP53010	SB-19(7-7.5)030724
JD83927-15	Z166842.D	03/11/24 18:34	OP53010	SB-22(8-8.5)030724
JD83927-17	Z166843.D	03/11/24 18:58	OP53010	SB-25(3-3.5)030724
JD83927-18	Z166844.D	03/11/24 19:21	OP53010	SB-25(7.5-8)030724
OP53010-MS	Z166846.D	03/11/24 19:44	OP53010	Matrix Spike
OP53010-MSD	Z166847.D	03/11/24 20:07	OP53010	Matrix Spike Duplicate
JD83927-14	Z166848.D	03/11/24 20:31	OP53010	SB-22(3.5-4)030724
JD83927-16	Z166849.D	03/11/24 20:54	OP53010	SB-25(1.5-2)030724
OP53012-MS	Z166851.D	03/11/24 21:17	OP53012	Matrix Spike
OP53012-MSD	Z166852.D	03/11/24 21:40	OP53012	Matrix Spike Duplicate
JD83939-11	Z166853.D	03/11/24 22:04	OP53012	(used for QC only; not part of job JD83927)
ZZZZZZ	Z166854.D	03/11/24 22:27	OP53012	(unrelated sample)

GC/LC Semi-volatiles

QC Data Summaries

Includes the following where applicable:

- Method Blank Summaries
- Blank Spike Summaries
- Matrix Spike and Duplicate Summaries
- Internal Standard Area Summaries
- DDT/Endrin Breakdown Checks
- GC Identification Summaries (Hits)
- Surrogate Recovery Summaries
- GC Surrogate Retention Time Summaries
- Initial and Continuing Calibration Summaries
- Run Sequence Reports

Method Blank Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
OP53021-MB1	4G9737018A.D	1	03/11/24	CP	03/09/24	OP53021	G4G4306

The QC reported here applies to the following samples: **Method:** SW846 8081B

JD83927-1, JD83927-2, JD83927-3, JD83927-4, JD83927-5, JD83927-6, JD83927-7, JD83927-8, JD83927-9, JD83927-10, JD83927-11, JD83927-12, JD83927-13, JD83927-14, JD83927-15, JD83927-16, JD83927-17, JD83927-18

CAS No.	Compound	Result	RL	MDL	Units	Q
309-00-2	Aldrin	ND	0.40	0.078	ug/kg	
319-84-6	alpha-BHC	ND	0.40	0.046	ug/kg	
319-85-7	beta-BHC	ND	0.40	0.058	ug/kg	
319-86-8	delta-BHC	ND	0.40	0.060	ug/kg	
58-89-9	gamma-BHC (Lindane)	ND	0.40	0.070	ug/kg	
5103-71-9	alpha-Chlordane	ND	0.40	0.054	ug/kg	
5103-74-2	gamma-Chlordane	ND	0.40	0.060	ug/kg	
60-57-1	Dieldrin	ND	0.40	0.064	ug/kg	
72-54-8	4,4'-DDD	ND	0.40	0.042	ug/kg	
72-55-9	4,4'-DDE	ND	0.40	0.048	ug/kg	
50-29-3	4,4'-DDT	ND	0.40	0.070	ug/kg	
72-20-8	Endrin	ND	0.40	0.058	ug/kg	
1031-07-8	Endosulfan sulfate	ND	0.40	0.048	ug/kg	
7421-93-4	Endrin aldehyde	ND	0.40	0.12	ug/kg	
959-98-8	Endosulfan-I	ND	0.40	0.054	ug/kg	
33213-65-9	Endosulfan-II	ND	0.40	0.056	ug/kg	
76-44-8	Heptachlor	ND	0.40	0.052	ug/kg	
1024-57-3	Heptachlor epoxide	ND	0.40	0.072	ug/kg	
72-43-5	Methoxychlor	ND	0.40	0.16	ug/kg	
53494-70-5	Endrin ketone	ND	0.40	0.064	ug/kg	
8001-35-2	Toxaphene	ND	5.0	3.3	ug/kg	

CAS No.	Surrogate Recoveries		Limits
877-09-8	Tetrachloro-m-xylene	84%	66-150%
877-09-8	Tetrachloro-m-xylene	90%	66-150%
2051-24-3	Decachlorobiphenyl	85%	40-150%
2051-24-3	Decachlorobiphenyl	70%	40-150%

Method Blank Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
OP53022-MB1	2G231124.D	1	03/10/24	TP	03/09/24	OP53022	G2G6058

The QC reported here applies to the following samples: **Method:** SW846 8082A

JD83927-1, JD83927-2, JD83927-3, JD83927-4, JD83927-5, JD83927-6, JD83927-7, JD83927-8, JD83927-9, JD83927-10, JD83927-11, JD83927-12, JD83927-13, JD83927-14, JD83927-15, JD83927-16, JD83927-17, JD83927-18

CAS No.	Compound	Result	RL	MDL	Units	Q
12674-11-2	Aroclor 1016	ND	20	8.5	ug/kg	
11104-28-2	Aroclor 1221	ND	20	6.7	ug/kg	
11141-16-5	Aroclor 1232	ND	20	17	ug/kg	
53469-21-9	Aroclor 1242	ND	20	12	ug/kg	
12672-29-6	Aroclor 1248	ND	20	4.3	ug/kg	
11097-69-1	Aroclor 1254	ND	20	2.2	ug/kg	
11096-82-5	Aroclor 1260	ND	20	6.9	ug/kg	
11100-14-4	Aroclor 1268	ND	20	2.0	ug/kg	
37324-23-5	Aroclor 1262	ND	20	1.7	ug/kg	

CAS No.	Surrogate Recoveries		Limits
877-09-8	Tetrachloro-m-xylene	100%	42-159%
877-09-8	Tetrachloro-m-xylene	101%	42-159%
2051-24-3	Decachlorobiphenyl	115%	18-154%
2051-24-3	Decachlorobiphenyl	111%	18-154%

Blank Spike Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
OP53021-BS1	4G9737019.D	1	03/11/24	CP	03/09/24	OP53021	G4G4306

The QC reported here applies to the following samples: **Method:** SW846 8081B

JD83927-1, JD83927-2, JD83927-3, JD83927-4, JD83927-5, JD83927-6, JD83927-7, JD83927-8, JD83927-9, JD83927-10, JD83927-11, JD83927-12, JD83927-13, JD83927-14, JD83927-15, JD83927-16, JD83927-17, JD83927-18

CAS No.	Compound	Spike ug/kg	BSP ug/kg	BSP %	Limits
309-00-2	Aldrin	5	4.0	80	75-150
319-84-6	alpha-BHC	5	4.3	86	72-150
319-85-7	beta-BHC	5	4.2	84	75-150
319-86-8	delta-BHC	5	4.2	84	58-150
58-89-9	gamma-BHC (Lindane)	5	4.2	84	72-150
5103-71-9	alpha-Chlordane	5	3.8	76	68-150
5103-74-2	gamma-Chlordane	5	3.7	74	72-150
60-57-1	Dieldrin	5	3.8	76	72-150
72-54-8	4,4'-DDD	5	4.1	82	67-150
72-55-9	4,4'-DDE	5	3.8	76	72-150
50-29-3	4,4'-DDT	5	3.5	70	48-150
72-20-8	Endrin	5	3.8	76	73-150
1031-07-8	Endosulfan sulfate	5	3.8	76	69-150
7421-93-4	Endrin aldehyde	5	4.2	84	36-150
959-98-8	Endosulfan-I	5	3.5	70	70-150
33213-65-9	Endosulfan-II	5	3.9	78	75-150
76-44-8	Heptachlor	5	4.0	80	70-150
1024-57-3	Heptachlor epoxide	5	3.9	78	73-150
72-43-5	Methoxychlor	5	3.4	68	54-150
53494-70-5	Endrin ketone	5	4.0	80	73-150

CAS No.	Surrogate Recoveries	BSP	Limits
877-09-8	Tetrachloro-m-xylene	84%	66-150%
877-09-8	Tetrachloro-m-xylene	92%	66-150%
2051-24-3	Decachlorobiphenyl	83%	40-150%
2051-24-3	Decachlorobiphenyl	73%	40-150%

* = Outside of Control Limits.

Blank Spike Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
OP53022-BS1	2G231125.D	1	03/10/24	TP	03/09/24	OP53022	G2G6058

The QC reported here applies to the following samples: **Method:** SW846 8082A

JD83927-1, JD83927-2, JD83927-3, JD83927-4, JD83927-5, JD83927-6, JD83927-7, JD83927-8, JD83927-9, JD83927-10, JD83927-11, JD83927-12, JD83927-13, JD83927-14, JD83927-15, JD83927-16, JD83927-17, JD83927-18

CAS No.	Compound	Spike ug/kg	BSP ug/kg	BSP %	Limits
12674-11-2	Aroclor 1016	40	42.5	106	74-153
11104-28-2	Aroclor 1221		ND		50-150
11141-16-5	Aroclor 1232		ND		50-150
53469-21-9	Aroclor 1242		ND		50-150
12672-29-6	Aroclor 1248		ND		50-150
11097-69-1	Aroclor 1254		ND		50-150
11096-82-5	Aroclor 1260	40	45.0	113	68-147
11100-14-4	Aroclor 1268		ND		50-150
37324-23-5	Aroclor 1262		ND		50-150

CAS No.	Surrogate Recoveries	BSP	Limits
877-09-8	Tetrachloro-m-xylene	102%	42-159%
877-09-8	Tetrachloro-m-xylene	101%	42-159%
2051-24-3	Decachlorobiphenyl	122%	18-154%
2051-24-3	Decachlorobiphenyl	110%	18-154%

* = Outside of Control Limits.

Matrix Spike/Matrix Spike Duplicate Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
OP53021-MS	4G9737020.D	1	03/11/24	CP	03/09/24	OP53021	G4G4306
OP53021-MSD	4G9737021.D	1	03/11/24	CP	03/09/24	OP53021	G4G4306
JD83927-4	4G9737025.D	1	03/11/24	CP	03/09/24	OP53021	G4G4306

The QC reported here applies to the following samples: **Method:** SW846 8081B

JD83927-1, JD83927-2, JD83927-3, JD83927-4, JD83927-5, JD83927-6, JD83927-7, JD83927-8, JD83927-9, JD83927-10, JD83927-11, JD83927-12, JD83927-13, JD83927-14, JD83927-15, JD83927-16, JD83927-17, JD83927-18

CAS No.	Compound	JD83927-4 ug/kg	Q	Spike ug/kg	MS ug/kg	MS %	Spike ug/kg	MSD ug/kg	MSD %	RPD	Limits Rec/RPD
309-00-2	Aldrin	ND		5.29	4.3	81	5.5	4.6	84	7	10-200/38
319-84-6	alpha-BHC	ND		5.29	4.2	79	5.5	4.2	76	0	43-183/37
319-85-7	beta-BHC	ND		5.29	2.2	42	5.5	3.2	58	37	10-202/52
319-86-8	delta-BHC	ND		5.29	3.9	74	5.5	4.1	75	5	10-191/28
58-89-9	gamma-BHC (Lindane)	ND		5.29	4.3	81	5.5	4.4	80	2	43-168/33
5103-71-9	alpha-Chlordane	0.52		5.29	4.5	75	5.5	4.7	76	4	10-194/46
5103-74-2	gamma-Chlordane	0.52		5.29	3.6	58	5.5	3.9	62	8	10-180/40
60-57-1	Dieldrin	0.66		5.29	5.0	82	5.5	5.0	79	0	12-197/40
72-54-8	4,4'-DDD	0.12	J	5.29	3.9	71	5.5	4.0	71	3	10-193/47
72-55-9	4,4'-DDE	0.15	J	5.29	3.6	65	5.5	3.8	66	5	10-207/50
50-29-3	4,4'-DDT	0.59		5.29	4.7	78	5.5	4.5	71	4	10-241/60
72-20-8	Endrin	ND		5.29	4.6	87	5.5	4.1	75	11	21-214/48
1031-07-8	Endosulfan sulfate	ND		5.29	4.0	76	5.5	4.2	76	5	10-183/53
7421-93-4	Endrin aldehyde	ND		5.29	4.1	78	5.5	4.3	78	5	10-205/53
959-98-8	Endosulfan-I	ND		5.29	3.6	68	5.5	3.7	67	3	10-186/40
33213-65-9	Endosulfan-II	ND		5.29	3.9	74	5.5	3.9	71	0	10-185/44
76-44-8	Heptachlor	ND		5.29	4.3	81	5.5	4.2	76	2	10-184/41
1024-57-3	Heptachlor epoxide	ND		5.29	4.1	78	5.5	4.4	80	7	10-210/35
72-43-5	Methoxychlor	ND		5.29	4.3	81	5.5	3.8	69	12	10-222/65
53494-70-5	Endrin ketone	ND		5.29	4.8	91	5.5	4.3	78	11	10-230/53
8001-35-2	Toxaphene	ND			ND			ND		nc	50-150/30

CAS No.	Surrogate Recoveries	MS	MSD	JD83927-4	Limits
877-09-8	Tetrachloro-m-xylene	74%	75%	83%	66-150%
877-09-8	Tetrachloro-m-xylene	76%	84%	93%	66-150%
2051-24-3	Decachlorobiphenyl	75%	71%	75%	40-150%
2051-24-3	Decachlorobiphenyl	95%	108%	100%	40-150%

* = Outside of Control Limits.

Matrix Spike/Matrix Spike Duplicate Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
OP53022-MS	2G231126.D	1	03/10/24	TP	03/09/24	OP53022	G2G6058
OP53022-MSD	2G231127.D	1	03/10/24	TP	03/09/24	OP53022	G2G6058
JD83927-5	2G231128.D	1	03/10/24	TP	03/09/24	OP53022	G2G6058

The QC reported here applies to the following samples: **Method:** SW846 8082A

JD83927-1, JD83927-2, JD83927-3, JD83927-4, JD83927-5, JD83927-6, JD83927-7, JD83927-8, JD83927-9, JD83927-10, JD83927-11, JD83927-12, JD83927-13, JD83927-14, JD83927-15, JD83927-16, JD83927-17, JD83927-18

CAS No.	Compound	JD83927-5 ug/kg	Q	Spike ug/kg	MS ug/kg	MS %	Spike ug/kg	MSD ug/kg	MSD %	RPD	Limits Rec/RPD
12674-11-2	Aroclor 1016	ND		41.9	40.8	97	41.9	41.4	99	1	41-167/46
11104-28-2	Aroclor 1221	ND			ND			ND		nc	50-150/30
11141-16-5	Aroclor 1232	ND			ND			ND		nc	50-150/30
53469-21-9	Aroclor 1242	ND			ND			ND		nc	50-150/17
12672-29-6	Aroclor 1248	ND			ND			ND		nc	50-150/16
11097-69-1	Aroclor 1254	ND			ND			ND		nc	10-165/38
11096-82-5	Aroclor 1260	ND		41.9	48.4	115	41.9	48.9	117	1	13-183/49
11100-14-4	Aroclor 1268	ND			ND			ND		nc	50-150/30
37324-23-5	Aroclor 1262	ND			ND			ND		nc	50-150/11

CAS No.	Surrogate Recoveries	MS	MSD	JD83927-5	Limits
877-09-8	Tetrachloro-m-xylene	94%	91%	92%	42-159%
877-09-8	Tetrachloro-m-xylene	92%	89%	93%	42-159%
2051-24-3	Decachlorobiphenyl	118%	115%	100%	18-154%
2051-24-3	Decachlorobiphenyl	112%	115%	110%	18-154%

* = Outside of Control Limits.

Internal Standard Area Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Check Std:	G4G4306-CC4300	**Injection Date:**	03/11/24
Lab File ID:	4G9737016.D	**Injection Time:**	00:14
Instrument ID:	GC4G	**Method:**	SW846 8081B

	IS 1 AREA	IS 1 RT	IS 2 AREA	IS 2 RT
Initial Cal [a]	367500242	5.24	854349477	4.87
Check Std [b]	393839080	5.23	881628883	4.86
Upper Limit [c]	551250363	5.73	1281524216	5.36
Lower Limit [d]	183750121	4.73	427174739	4.36

Lab Sample ID	IS 1 AREA	IS 1 RT	IS 2 AREA	IS 2 RT
OP53021-MB1	447544114	5.27	942272568	4.89
OP53021-BS1	444683524	5.23	955250637	4.86
OP53021-MS	426259081	5.23	958922057	4.86
OP53021-MSD	421832237	5.23	976007168	4.86
JD83927-1	410706302	5.23	880844764	4.86
JD83927-2	402418290	5.24	880544692	4.87
JD83927-3	380363918	5.23	860535412	4.86
JD83927-4	395360163	5.23	893324787	4.86
JD83927-5	388971086	5.23	856728800	4.86
JD83927-6	328228138	5.23	708880320	4.86
JD83927-7	334462874	5.23	798237740	4.86
JD83927-8	357865204	5.23	784752789	4.86
JD83927-9	348743621	5.23	770281228	4.86
JD83927-10	347776182	5.23	756046478	4.86
JD83927-11	379548557	5.23	804537238	4.86
JD83927-12	387337705	5.23	796742791	4.86
JD83927-13	366348612	5.23	768776350	4.86
JD83927-14	457934817	5.23	900400762	4.86
JD83927-15	340869072	5.23	716298925	4.86

IS 1 = 1-Bromo-2-nitrobenzene (Signal #2)
IS 2 = 1-Bromo-2-nitrobenzene (Signal #1)

(a) Initial Cal is: G4G4300-ICC4300 4G9736853.D 03/06/24 10:21. Area is AVERAGE of initial cal points.
(b) Check Std Limit = -50 to + 50% of initial cal area.
(c) Upper Limit = + 50% of initial standard area; Retention time + 0.5 minutes of check standard.
(d) Lower Limit = -50% of initial standard area; Retention time -0.5 minutes of check standard.

Internal Standard Area Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Check Std:	G5G3550-CC3509	**Injection Date:**	03/11/24
Lab File ID:	5G136411.D	**Injection Time:**	01:14
Instrument ID:	GC5G	**Method:**	SW846 8081B

	IS 1 AREA	IS 1 RT	IS 2 AREA	IS 2 RT
Initial Cal [a]	1564193221	5.18	1924768414	4.98
Check Std [b]	1627163827	5.06	1237938893	4.85
Upper Limit [c]	2346289832	5.56	2887152621	5.35
Lower Limit [d]	782096611	4.56	962384207	4.35

Lab Sample ID	IS 1 AREA	IS 1 RT	IS 2 AREA	IS 2 RT
ZZZZZZ	1548742088	5.06	1210850349	4.85
ZZZZZZ	1613967960	5.06	1284861674	4.85
ZZZZZZ	1616174363	5.08	1389917765	4.86
ZZZZZZ	1640131100	5.06	3636924045*	4.86
JD83927-16	1299878222	5.06	1358949548	4.84
JD83927-17	1164814701	5.06	1099933110	4.85
JD83927-18	1365828383	5.06	1121115960	4.85
ZZZZZZ	1349073672	5.06	1073135899	4.85
ZZZZZZ	1482237855	5.06	1101455959	4.85
ZZZZZZ	1245564968	5.06	1153468190	4.85
JD83334-2	1513344061	5.06	1217820893	4.85
ZZZZZZ	1543950163	5.06	1178992367	4.85
ZZZZZZ	1510442409	5.06	1152881593	4.85
ZZZZZZ	1552249560	5.06	1173112966	4.85

IS 1 = 1-Bromo-2-nitrobenzene (Signal #2)
IS 2 = 1-Bromo-2-nitrobenzene (Signal #1)

(a) Initial Cal is: G5G3509-ICC3509 5G135533.D 02/05/24 02:28. Area is AVERAGE of initial cal points.
(b) Check Std Limit = -50 to + 50% of initial cal area.
(c) Upper Limit = + 50% of initial standard area; Retention time + 0.5 minutes of check standard.
(d) Lower Limit = -50% of initial standard area; Retention time -0.5 minutes of check standard.

DDT/Endrin Breakdown Check

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample:	G4G4300-DDT	**Injection Date:**	03/06/24
Lab File ID:	4G9736847.D	**Injection Time:**	08:25
Instrument ID:	GC4G		

Compound	Response Signal 1	Response Signal 2
4,4'-DDD	59747305	157750840
4,4'-DDE	6838185	7808800
4,4'-DDT	2532224502	6839433210
DDT Breakdown [a]	2.6 %	2.4 %
Endrin aldehyde	25149750	49900711
Endrin ketone	36504986	120556190
Endrin	1577449554	4646755077
Endrin Breakdown [b]	3.8 %	3.5 %

(a) Calculated as: (DDD + DDE) / (DDD + DDE + DDT) x 100
(b) Calculated as: (Endrin Aldehyde + Endrin Ketone) / (Endrin Aldehyde + Endrin Ketone + Endrin) x 100

This check applies to the following Samples, MS, MSD, Blanks, and Standards:

Lab Sample ID	Lab File ID	Date Analyzed	Time Analyzed	Hours Lapsed	Client Sample ID
G4G4300-IC4300	4G9736850.D	03/06/24	09:23	00:58	Initial cal 0.2
G4G4300-IC4300	4G9736851.D	03/06/24	09:42	01:17	Initial cal 0.5
G4G4300-IC4300	4G9736852.D	03/06/24	10:02	01:37	Initial cal 1
G4G4300-ICC4300	4G9736853.D	03/06/24	10:21	01:56	Initial cal 2.5
G4G4300-IC4300	4G9736854.D	03/06/24	10:41	02:16	Initial cal 5
G4G4300-IC4300	4G9736855.D	03/06/24	11:00	02:35	Initial cal 7.5
G4G4300-IC4300	4G9736856.D	03/06/24	11:19	02:54	Initial cal 10
G4G4300-IC4300	4G9736857.D	03/06/24	11:39	03:14	Initial cal 50
G4G4300-IC4300	4G9736858.D	03/06/24	11:58	03:33	Initial cal 50
G4G4300-ICV4300	4G9736859.D	03/06/24	12:18	03:53	Initial cal verification 2.5
G4G4300-ICV4300	4G9736860.D	03/06/24	12:37	04:12	Initial cal verification 50
G4G4300-ICV4300	4G9736861.D	03/06/24	12:56	04:31	Initial cal verification 50
G4G4301-CC4300	4G9736862.D	03/06/24	15:10	06:45	Continuing cal 2.5
OP52787-MB1	4G9736864.D	03/06/24	16:21	07:56	Method Blank
OP52787-BS1	4G9736865.D	03/06/24	16:41	08:16	Blank Spike
OP52787-MS	4G9736866.D	03/06/24	17:00	08:35	Matrix Spike
OP52787-MSD	4G9736867.D	03/06/24	17:20	08:55	Matrix Spike Duplicate
JD83049-5	4G9736868.D	03/06/24	17:39	09:14	(used for QC only; not part of job JD83927)
ZZZZZZ	4G9736869.D	03/06/24	17:58	09:33	(unrelated sample)
ZZZZZZ	4G9736870.D	03/06/24	18:18	09:53	(unrelated sample)
ZZZZZZ	4G9736871.D	03/06/24	18:37	10:12	(unrelated sample)
ZZZZZZ	4G9736872.D	03/06/24	18:57	10:32	(unrelated sample)
ZZZZZZ	4G9736873.D	03/06/24	19:16	10:51	(unrelated sample)
ZZZZZZ	4G9736874.D	03/06/24	19:35	11:10	(unrelated sample)

DDT/Endrin Breakdown Check

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample:	G4G4300-DDT	**Injection Date:**	03/06/24
Lab File ID:	4G9736847.D	**Injection Time:**	08:25
Instrument ID:	GC4G		

Lab Sample ID	Lab File ID	Date Analyzed	Time Analyzed	Hours Lapsed	Client Sample ID
ZZZZZZ	4G9736875.D	03/06/24	19:55	11:30	(unrelated sample)
ZZZZZZ	4G9736876.D	03/06/24	20:14	11:49	(unrelated sample)

DDT/Endrin Breakdown Check

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample:	G4G4306-DDT	**Injection Date:**	03/10/24
Lab File ID:	4G9737015.D	**Injection Time:**	23:55
Instrument ID:	GC4G		

Compound	Response Signal 1	Response Signal 2
4,4'-DDD	47283989	214221595
4,4'-DDE	5892608	23441511
4,4'-DDT	2232833832	8189094953
DDT Breakdown [a]	2.3 %	2.8 %
Endrin aldehyde	23644081	32026097
Endrin ketone	30251831	167217422
Endrin	1421147342	4541647660
Endrin Breakdown [b]	3.7 %	4.2 %

(a) Calculated as: (DDD + DDE) / (DDD + DDE + DDT) x 100
(b) Calculated as: (Endrin Aldehyde + Endrin Ketone) / (Endrin Aldehyde + Endrin Ketone + Endrin) x 100

This check applies to the following Samples, MS, MSD, Blanks, and Standards:

Lab Sample ID	Lab File ID	Date Analyzed	Time Analyzed	Hours Lapsed	Client Sample ID
G4G4306-CC4300	4G9737016.D	03/11/24	00:14	00:19	Continuing cal 2.5
OP53021-MB1	4G9737018A.D	03/11/24	01:38	01:43	Method Blank
OP53021-BS1	4G9737019.D	03/11/24	01:57	02:02	Blank Spike
OP53021-MS	4G9737020.D	03/11/24	02:17	02:22	Matrix Spike
OP53021-MSD	4G9737021.D	03/11/24	02:36	02:41	Matrix Spike Duplicate
JD83927-1	4G9737022.D	03/11/24	02:56	03:01	SB-7(4-4.5)030724
JD83927-2	4G9737023.D	03/11/24	03:19	03:24	SB-7(7-7.5)030724
JD83927-3	4G9737024.D	03/11/24	03:39	03:44	SB-8(4-4.5)030724
JD83927-4	4G9737025.D	03/11/24	03:58	04:03	SB-8(7.5-8)030724
JD83927-5	4G9737026.D	03/11/24	04:18	04:23	SB-9(3.5-4)030724
JD83927-6	4G9737027.D	03/11/24	04:37	04:42	SB-10(3.5-4)030724
JD83927-7	4G9737028.D	03/11/24	04:56	05:01	SB-10(7-5.5)030724
JD83927-8	4G9737029.D	03/11/24	05:16	05:21	SB-11(3.5-4)030724
JD83927-9	4G9737030.D	03/11/24	05:35	05:40	SB-11(8-8.5)030724
JD83927-10	4G9737031.D	03/11/24	05:54	05:59	SB-16(3-3.5)030724
JD83927-11	4G9737032.D	03/11/24	06:14	06:19	SB-16(7.5-8)030724
JD83927-12	4G9737033.D	03/11/24	06:33	06:38	SB-19(4-4.5)030724
JD83927-13	4G9737034.D	03/11/24	06:52	06:57	SB-19(7-7.5)030724
JD83927-14	4G9737035.D	03/11/24	07:12	07:17	SB-22(3.5-4)030724
JD83927-15	4G9737036.D	03/11/24	07:31	07:36	SB-22(8-8.5)030724

DDT/Endrin Breakdown Check

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample:	G5G3509-DDT	**Injection Date:**	02/04/24
Lab File ID:	5G135526.D	**Injection Time:**	23:04
Instrument ID:	GC5G		

Compound	Response Signal 1	Response Signal 2
4,4'-DDD	43732293	36380032
4,4'-DDE	0	0
4,4'-DDT	4893516391	2985757759
DDT Breakdown [a]	0.9 %	1.2 %
Endrin aldehyde	96660619	49884974
Endrin ketone	101464290	51593293
Endrin	2283841991	1540075544
Endrin Breakdown [b]	8 %	6.2 %

(a) Calculated as: (DDD + DDE) / (DDD + DDE + DDT) x 100
(b) Calculated as: (Endrin Aldehyde + Endrin Ketone) / (Endrin Aldehyde + Endrin Ketone + Endrin) x 100

This check applies to the following Samples, MS, MSD, Blanks, and Standards:

Lab Sample ID	Lab File ID	Date Analyzed	Time Analyzed	Hours Lapsed	Client Sample ID
G5G3509-IC3509	5G135530.D	02/05/24	01:25	02:21	Initial cal 0.2
G5G3509-IC3509	5G135531.D	02/05/24	01:46	02:42	Initial cal 0.5
G5G3509-IC3509	5G135532.D	02/05/24	02:07	03:03	Initial cal 1.0
G5G3509-ICC3509	5G135533.D	02/05/24	02:28	03:24	Initial cal 2.5
G5G3509-IC3509	5G135534.D	02/05/24	02:50	03:46	Initial cal 5.0
G5G3509-IC3509	5G135535.D	02/05/24	03:11	04:07	Initial cal 7.5
G5G3509-IC3509	5G135536.D	02/05/24	03:32	04:28	Initial cal 10
G5G3509-IC3509	5G135537.D	02/05/24	03:53	04:49	Initial cal 50
G5G3509-IC3509	5G135538.D	02/05/24	04:15	05:11	Initial cal 50
G5G3509-ICV3509	5G135539.D	02/05/24	04:36	05:32	Initial cal verification 2.5
G5G3509-ICV3509	5G135540.D	02/05/24	04:57	05:53	Initial cal verification 50
G5G3509-ICV3509	5G135541.D	02/05/24	05:19	06:15	Initial cal verification 50

DDT/Endrin Breakdown Check

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample:	G5G3550-DDT	**Injection Date:**	03/11/24
Lab File ID:	5G136408.D	**Injection Time:**	00:09
Instrument ID:	GC5G		

Compound	Response Signal 1	Response Signal 2
4,4'-DDD	34396062	47448424
4,4'-DDE	3435113	6743326
4,4'-DDT	2460271500	2509742370
DDT Breakdown [a]	1.5 %	2.1 %
Endrin aldehyde	60273552	42930639
Endrin ketone	41080024	44403931
Endrin	1449425511	1356867747
Endrin Breakdown [b]	6.5 %	6 %

(a) Calculated as: (DDD + DDE) / (DDD + DDE + DDT) x 100
(b) Calculated as: (Endrin Aldehyde + Endrin Ketone) / (Endrin Aldehyde + Endrin Ketone + Endrin) x 100

This check applies to the following Samples, MS, MSD, Blanks, and Standards:

Lab Sample ID	Lab File ID	Date Analyzed	Time Analyzed	Hours Lapsed	Client Sample ID
G5G3550-CC3509	5G136411.D	03/11/24	01:14	01:05	Continuing cal 2.5
ZZZZZZ	5G136413.D	03/11/24	01:58	01:49	(unrelated sample)
ZZZZZZ	5G136414.D	03/11/24	02:19	02:10	(unrelated sample)
ZZZZZZ	5G136415.D	03/11/24	02:50	02:41	(unrelated sample)
ZZZZZZ	5G136416.D	03/11/24	03:12	03:03	(unrelated sample)
JD83927-16	5G136417.D	03/11/24	03:33	03:24	SB-25(1.5-2)030724
JD83927-17	5G136418.D	03/11/24	03:55	03:46	SB-25(3-3.5)030724
JD83927-18	5G136419.D	03/11/24	04:16	04:07	SB-25(7.5-8)030724
ZZZZZZ	5G136420.D	03/11/24	04:38	04:29	(unrelated sample)
ZZZZZZ	5G136421.D	03/11/24	05:00	04:51	(unrelated sample)
ZZZZZZ	5G136422.D	03/11/24	05:21	05:12	(unrelated sample)
JD83334-2	5G136424.D	03/11/24	06:04	05:55	(used for QC only; not part of job JD83927)
ZZZZZZ	5G136425.D	03/11/24	06:26	06:17	(unrelated sample)
ZZZZZZ	5G136426.D	03/11/24	06:48	06:39	(unrelated sample)
ZZZZZZ	5G136427.D	03/11/24	07:09	07:00	(unrelated sample)

GC Identification Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Check Std:	G4G4306-CC4300	**Injection Date:**	03/11/24
Lab File ID:	4G9737016.D	**Injection Time:**	00:14
Instrument ID:	GC4G	**Method:**	SW846 8081B

Sample ID:	JD83927-3	**Injection Date:**	03/11/24
Lab File ID:	4G9737024.D	**Injection Time:**	03:39
Client ID:	SB-8(4-4.5)030724		

Compound	Column	RT	StdRT	Conc	Q	Units	RPD Conc
alpha-Chlordane	1	8.29	8.30	0.48		ug/kg	52.6
alpha-Chlordane [a]	2 [b]	9.83	9.83	0.28	J	ug/kg	
gamma-Chlordane	1	8.12	8.12	0.38	J	ug/kg	23.5
gamma-Chlordane	2 [b]	9.59	9.60	0.30	J	ug/kg	
Dieldrin	1	8.80	8.80	0.37	J	ug/kg	11.4
Dieldrin	2 [b]	10.37	10.38	0.33	J	ug/kg	
4,4'-DDD	1 [b]	9.25	9.27	0.075	J	ug/kg	25.6
4,4'-DDD	2	11.07	11.07	0.097	J	ug/kg	
4,4'-DDE	1 [b]	8.40	8.42	0.092	J	ug/kg	6.3
4,4'-DDE	2	10.09	10.10	0.098	J	ug/kg	
4,4'-DDT	1	9.67	9.68	0.40		ug/kg	19.2
4,4'-DDT	2 [b]	11.61	11.61	0.33	J	ug/kg	

(a) More than 40 % RPD for detected concentrations between the two GC columns.
(b) Final result reported from this column.

GC Identification Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Check Std:	G4G4306-CC4300	**Injection Date:**	03/11/24
Lab File ID:	4G9737016.D	**Injection Time:**	00:14
Instrument ID:	GC4G	**Method:**	SW846 8081B

Sample ID:	JD83927-4	**Injection Date:**	03/11/24
Lab File ID:	4G9737025.D	**Injection Time:**	03:58
Client ID:	SB-8(7.5-8)030724		

Compound	Column	RT	StdRT	Conc	Q	Units	RPD Conc
alpha-Chlordane	1	8.29	8.30	0.88		ug/kg	51.4
alpha-Chlordane [a]	2 [b]	9.83	9.83	0.52		ug/kg	
gamma-Chlordane	1	8.11	8.12	0.62		ug/kg	17.5
gamma-Chlordane	2 [b]	9.59	9.60	0.52		ug/kg	
Dieldrin	1	8.80	8.80	0.76		ug/kg	14.1
Dieldrin	2 [b]	10.38	10.38	0.66		ug/kg	
4,4'-DDD	1	9.25	9.27	0.16	J	ug/kg	28.6
4,4'-DDD	2 [b]	11.07	11.07	0.12	J	ug/kg	
4,4'-DDE	1 [b]	8.40	8.42	0.15	J	ug/kg	28.6
4,4'-DDE	2	10.09	10.10	0.20	J	ug/kg	
4,4'-DDT	1	9.67	9.68	0.73		ug/kg	21.2
4,4'-DDT	2 [b]	11.61	11.61	0.59		ug/kg	

(a) More than 40 % RPD for detected concentrations between the two GC columns.
(b) Final result reported from this column.

GC Identification Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Check Std:	G4G4306-CC4300	**Injection Date:**	03/11/24
Lab File ID:	4G9737016.D	**Injection Time:**	00:14
Instrument ID:	GC4G	**Method:**	SW846 8081B

Sample ID:	JD83927-5	**Injection Date:**	03/11/24
Lab File ID:	4G9737026.D	**Injection Time:**	04:18
Client ID:	SB-9(3.5-4)030724		

Compound	Column	RT	StdRT	Conc	Q	Units	RPD Conc
alpha-Chlordane	1	8.28	8.30	0.18	J	ug/kg	48.3
alpha-Chlordane [a]	2 [b]	9.83	9.83	0.11	J	ug/kg	
gamma-Chlordane	1	8.11	8.12	0.16	J	ug/kg	20.7
gamma-Chlordane	2 [b]	9.59	9.60	0.13	J	ug/kg	
Dieldrin	1	8.80	8.80	0.10	J	ug/kg	18.6
Dieldrin	2 [b]	10.38	10.38	0.083	J	ug/kg	
4,4'-DDT	1 [b]	9.67	9.68	0.095	J	ug/kg	14.6
4,4'-DDT	2	11.61	11.61	0.11	J	ug/kg	

(a) More than 40 % RPD for detected concentrations between the two GC columns.
(b) Final result reported from this column.

GC Identification Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Check Std:	G4G4306-CC4300	**Injection Date:**	03/11/24
Lab File ID:	4G9737016.D	**Injection Time:**	00:14
Instrument ID:	GC4G	**Method:**	SW846 8081B

Sample ID:	JD83927-6	**Injection Date:**	03/11/24
Lab File ID:	4G9737027.D	**Injection Time:**	04:37
Client ID:	SB-10(3.5-4)030724		

Compound	Column	RT	StdRT	Conc	Q	Units	RPD Conc
alpha-Chlordane	1	8.29	8.30	0.40		ug/kg	58.1
alpha-Chlordane [a]	2 [b]	9.83	9.83	0.22	J	ug/kg	
gamma-Chlordane	1	8.12	8.12	0.30	J	ug/kg	22.2
gamma-Chlordane	2 [b]	9.59	9.60	0.24	J	ug/kg	
4,4'-DDT	1	9.67	9.68	0.12	J	ug/kg	35.3
4,4'-DDT	2 [b]	11.61	11.61	0.084	J	ug/kg	

(a) More than 40 % RPD for detected concentrations between the two GC columns.
(b) Final result reported from this column.

GC Identification Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Check Std:	G4G4306-CC4300	**Injection Date:**	03/11/24
Lab File ID:	4G9737016.D	**Injection Time:**	00:14
Instrument ID:	GC4G	**Method:**	SW846 8081B

Sample ID:	JD83927-7	**Injection Date:**	03/11/24
Lab File ID:	4G9737028.D	**Injection Time:**	04:56
Client ID:	SB-10(7-5.5)030724		

Compound	Column	RT	StdRT	Conc	Q	Units	RPD Conc
alpha-Chlordane	1	8.28	8.30	0.21	J	ug/kg	47.1
alpha-Chlordane [a]	2 [b]	9.82	9.83	0.13	J	ug/kg	
gamma-Chlordane	1	8.11	8.12	0.14	J	ug/kg	7.4
gamma-Chlordane	2 [b]	9.59	9.60	0.13	J	ug/kg	
Dieldrin	1	8.81	8.80	0.12	J	ug/kg	34.1
Dieldrin	2 [b]	10.37	10.38	0.085	J	ug/kg	
4,4'-DDD	1 [b]	9.25	9.27	0.20	J	ug/kg	0.0
4,4'-DDD	2	11.06	11.07	0.20	J	ug/kg	
4,4'-DDE	1	8.40	8.42	0.13	J	ug/kg	8.0
4,4'-DDE	2 [b]	10.09	10.10	0.12	J	ug/kg	
4,4'-DDT [a]	1 [b]	9.67	9.68	0.16	J	ug/kg	47.6
4,4'-DDT [a]	2	11.61	11.61	0.26	J	ug/kg	

(a) More than 40 % RPD for detected concentrations between the two GC columns.
(b) Final result reported from this column.

GC Identification Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Check Std:	G4G4306-CC4300	**Injection Date:**	03/11/24
Lab File ID:	4G9737016.D	**Injection Time:**	00:14
Instrument ID:	GC4G	**Method:**	SW846 8081B

Sample ID:	JD83927-8	**Injection Date:**	03/11/24
Lab File ID:	4G9737029.D	**Injection Time:**	05:16
Client ID:	SB-11(3.5-4)030724		

Compound	Column	RT	StdRT	Conc	Q	Units	RPD Conc
alpha-Chlordane	1	8.28	8.30	0.37	J	ug/kg	46.7
alpha-Chlordane [a]	2 [b]	9.83	9.83	0.23	J	ug/kg	
gamma-Chlordane	1	8.12	8.12	0.24	J	ug/kg	8.7
gamma-Chlordane	2 [b]	9.59	9.60	0.22	J	ug/kg	
Dieldrin	1	8.80	8.80	0.30	J	ug/kg	30.8
Dieldrin	2 [b]	10.37	10.38	0.22	J	ug/kg	
4,4'-DDE	1	8.40	8.42	0.13	J	ug/kg	26.1
4,4'-DDE	2 [b]	10.09	10.10	0.10	J	ug/kg	
4,4'-DDT	1 [b]	9.67	9.68	0.35	J	ug/kg	15.8
4,4'-DDT	2	11.61	11.61	0.41	J	ug/kg	

(a) More than 40 % RPD for detected concentrations between the two GC columns.
(b) Final result reported from this column.

GC Identification Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Check Std:	G4G4306-CC4300	**Injection Date:**	03/11/24
Lab File ID:	4G9737016.D	**Injection Time:**	00:14
Instrument ID:	GC4G	**Method:**	SW846 8081B

Sample ID:	JD83927-14	**Injection Date:**	03/11/24
Lab File ID:	4G9737035.D	**Injection Time:**	07:12
Client ID:	SB-22(3.5-4)030724		

Compound	Column	RT	StdRT	Conc	Q	Units	RPD Conc
beta-BHC	1	6.45	6.47	101	E	ug/kg	167.6
beta-BHC [a]	2 [b]	7.47	7.46	8.9		ug/kg	
gamma-BHC (Lindane)	1	6.35	6.36	12.5		ug/kg	32.6
gamma-BHC (Lindane)	2 [b]	7.34	7.35	9.0		ug/kg	
Dieldrin	1	8.78	8.80	13.6		ug/kg	36.5
Dieldrin	2 [b]	10.36	10.38	9.4		ug/kg	
4,4'-DDT	1 [b]	9.67	9.68	5.4		ug/kg	35.1
4,4'-DDT	2	11.59	11.61	7.7		ug/kg	
Heptachlor	1	6.89	6.87	23.3	E	ug/kg	157.1
Heptachlor [a]	2 [b]	7.97	7.97	2.8		ug/kg	

(a) More than 40 % RPD for detected concentrations between the two GC columns.
(b) Final result reported from this column.

GC Identification Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Check Std:	G4G4306-CC4300	**Injection Date:**	03/11/24
Lab File ID:	4G9737016.D	**Injection Time:**	00:14
Instrument ID:	GC4G	**Method:**	SW846 8081B

Sample ID:	JD83927-15	**Injection Date:**	03/11/24
Lab File ID:	4G9737036.D	**Injection Time:**	07:31
Client ID:	SB-22(8-8.5)030724		

Compound	Column	RT	StdRT	Conc	Q	Units	RPD Conc
gamma-BHC (Lindane)	1 [a]	6.36	6.36	0.47		ug/kg	4.2
gamma-BHC (Lindane)	2	7.34	7.35	0.49		ug/kg	
gamma-Chlordane	1	8.11	8.12	0.42		ug/kg	43.5
gamma-Chlordane [b]	2 [a]	9.59	9.60	0.27	J	ug/kg	
Dieldrin	1 [a]	8.79	8.80	0.29	J	ug/kg	12.9
Dieldrin	2	10.36	10.38	0.33	J	ug/kg	
4,4'-DDT	1 [a]	9.67	9.68	0.45		ug/kg	14.4
4,4'-DDT	2	11.62	11.61	0.52		ug/kg	

(a) Final result reported from this column.
(b) More than 40 % RPD for detected concentrations between the two GC columns.

GC Identification Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Check Std:	G5G3550-CC3509	**Injection Date:**	03/11/24
Lab File ID:	5G136411.D	**Injection Time:**	01:14
Instrument ID:	GC5G	**Method:**	SW846 8081B

Sample ID:	JD83927-16	**Injection Date:**	03/11/24
Lab File ID:	5G136417.D	**Injection Time:**	03:33
Client ID:	SB-25(1.5-2)030724		

Compound	Column	RT	StdRT	Conc	Q	Units	RPD Conc
Aldrin [a]	1	7.21	7.18	0.30	J	ug/kg	40.0
Aldrin [a]	2 [b]	8.06	8.04	0.20	J	ug/kg	
alpha-BHC [c]	1 [b]	6.01	6.02	0.078	J	ug/kg	42.4
alpha-BHC [c]	2	6.58	6.59	0.12	J	ug/kg	
delta-BHC [a]	1	6.61	6.61	0.13	J	ug/kg	51.4
delta-BHC [d]	2 [b]	7.50	7.50	0.22	J	ug/kg	
Dieldrin	1 [b]	8.76	8.76	2.1		ug/kg	21.3
Dieldrin	2	9.89	9.89	2.6		ug/kg	
4,4'-DDD	1	9.23	9.21	0.80		ug/kg	136.8
4,4'-DDD [c]	2 [b]	10.58	10.58	0.15	J	ug/kg	
4,4'-DDE	1	8.36	8.37	0.42		ug/kg	71.0
4,4'-DDE [c]	2 [b]	9.63	9.63	0.20	J	ug/kg	
4,4'-DDT [c]	1 [b]	9.63	9.63	0.84		ug/kg	56.4
4,4'-DDT [c]	2	11.11	11.11	1.5		ug/kg	
Heptachlor epoxide	1	7.91	7.91	0.18	J	ug/kg	48.3
Heptachlor epoxide [c]	2 [b]	8.86	8.86	0.11	J	ug/kg	

(a) Associated CCV outside of control limits high.
(b) Final result reported from this column.
(c) More than 40 % RPD for detected concentrations between the two GC columns.
(d) Reported from the 2nd signal. The %D of the CCV on the 1st signal exceeds the method criteria of 20%, so it being used for confirmation only. More than 40 % RPD for detected concentrations between the two GC columns.

GC Identification Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Check Std:	G5G3550-CC3509	**Injection Date:**	03/11/24
Lab File ID:	5G136411.D	**Injection Time:**	01:14
Instrument ID:	GC5G	**Method:**	SW846 8081B

Sample ID:	JD83927-17	**Injection Date:**	03/11/24
Lab File ID:	5G136418.D	**Injection Time:**	03:55
Client ID:	SB-25(3-3.5)030724		

Compound	Column	RT	StdRT	Conc	Q	Units	RPD Conc
4,4'-DDT [a]	1 [b]	9.63	9.63	0.80		ug/kg	76.9
4,4'-DDT [a]	2	11.10	11.11	1.8		ug/kg	

(a) More than 40 % RPD for detected concentrations between the two GC columns.
(b) Final result reported from this column.

GC Identification Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Check Std:	G4G4306-CC4300	**Injection Date:**	03/11/24
Lab File ID:	4G9737016.D	**Injection Time:**	00:14
Instrument ID:	GC4G	**Method:**	SW846 8081B

Sample ID:	OP53021-BS1	**Injection Date:**	03/11/24
Lab File ID:	4G9737019.D	**Injection Time:**	01:57
Client ID:	Blank Spike		

Compound	Column	RT	StdRT	Conc	Q	Units	RPD Conc
Aldrin	1	7.22	7.22	4.4		ug/kg	9.5
Aldrin	2 [a]	8.45	8.45	4.0		ug/kg	
alpha-BHC	1 [a]	6.05	6.05	4.3		ug/kg	2.3
alpha-BHC	2	6.89	6.89	4.4		ug/kg	
beta-BHC	1 [a]	6.47	6.47	4.2		ug/kg	2.4
beta-BHC	2	7.46	7.46	4.3		ug/kg	
delta-BHC	1	6.66	6.66	4.2		ug/kg	0.0
delta-BHC	2 [a]	7.88	7.88	4.2		ug/kg	
gamma-BHC (Lindane)	1	6.36	6.36	4.4		ug/kg	4.7
gamma-BHC (Lindane)	2 [a]	7.36	7.35	4.2		ug/kg	
alpha-Chlordane	1	8.30	8.30	3.8		ug/kg	0.0
alpha-Chlordane	2 [a]	9.83	9.83	3.8		ug/kg	
gamma-Chlordane	1 [a]	8.13	8.12	3.7		ug/kg	2.7
gamma-Chlordane	2	9.60	9.60	3.8		ug/kg	
Dieldrin	1	8.81	8.80	3.9		ug/kg	2.6
Dieldrin	2 [a]	10.38	10.38	3.8		ug/kg	
4,4'-DDD	1	9.27	9.27	4.2		ug/kg	2.4
4,4'-DDD	2 [a]	11.07	11.07	4.1		ug/kg	
4,4'-DDE	1	8.42	8.42	4.0		ug/kg	5.1
4,4'-DDE	2 [a]	10.10	10.10	3.8		ug/kg	
4,4'-DDT	1 [a]	9.68	9.68	3.5		ug/kg	2.8
4,4'-DDT	2	11.61	11.61	3.6		ug/kg	
Endrin	1	9.14	9.13	4.0		ug/kg	5.1
Endrin	2 [a]	10.90	10.90	3.8		ug/kg	
Endosulfan sulfate	1	10.79	10.79	4.1		ug/kg	7.6
Endosulfan sulfate	2 [a]	12.31	12.31	3.8		ug/kg	
Endrin aldehyde	1	10.10	10.09	4.3		ug/kg	2.4
Endrin aldehyde	2 [a]	11.84	11.84	4.2		ug/kg	
Endosulfan-I	1	8.48	8.48	3.8		ug/kg	8.2
Endosulfan-I	2 [a]	9.94	9.93	3.5		ug/kg	
Endosulfan-II	1	9.47	9.46	4.1		ug/kg	5.0
Endosulfan-II	2 [a]	11.26	11.26	3.9		ug/kg	
Heptachlor	1	6.88	6.87	4.3		ug/kg	7.2
Heptachlor	2 [a]	7.97	7.97	4.0		ug/kg	
Heptachlor epoxide	1	7.96	7.96	4.1		ug/kg	5.0
Heptachlor epoxide	2 [a]	9.31	9.30	3.9		ug/kg	
Methoxychlor	1 [a]	10.47	10.47	3.4		ug/kg	8.5
Methoxychlor	2	12.85	12.85	3.7		ug/kg	
Endrin ketone	1	11.23	11.23	4.1		ug/kg	2.5
Endrin ketone	2 [a]	13.24	13.23	4.0		ug/kg	

(a) QC results reported from this column.

GC Identification Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Check Std:	G4G4306-CC4300	**Injection Date:**	03/11/24
Lab File ID:	4G9737016.D	**Injection Time:**	00:14
Instrument ID:	GC4G	**Method:**	SW846 8081B

Sample ID:	OP53021-MS	**Injection Date:**	03/11/24
Lab File ID:	4G9737020.D	**Injection Time:**	02:17
Client ID:	Matrix Spike		

Compound	Column	RT	StdRT	Conc	Q	Units	RPD Conc
Aldrin	1 [a]	7.21	7.22	4.3		ug/kg	15.0
Aldrin	2	8.44	8.45	3.7		ug/kg	
alpha-BHC	1 [a]	6.05	6.05	4.2		ug/kg	2.4
alpha-BHC	2	6.89	6.89	4.1		ug/kg	
beta-BHC	1 [a]	6.48	6.47	2.2		ug/kg	40.0
beta-BHC	2	7.45	7.46	3.3		ug/kg	
delta-BHC	1 [a]	6.64	6.66	3.9		ug/kg	12.0
delta-BHC	2	7.87	7.88	4.4		ug/kg	
gamma-BHC (Lindane)	1 [a]	6.36	6.36	4.3		ug/kg	8.9
gamma-BHC (Lindane)	2	7.35	7.35	4.7		ug/kg	
alpha-Chlordane	1	8.29	8.30	4.3		ug/kg	4.5
alpha-Chlordane	2 [a]	9.83	9.83	4.5		ug/kg	
gamma-Chlordane	1	8.12	8.12	4.2		ug/kg	15.4
gamma-Chlordane	2 [a]	9.60	9.60	3.6		ug/kg	
Dieldrin	1	8.80	8.80	4.4		ug/kg	12.8
Dieldrin	2 [a]	10.38	10.38	5.0		ug/kg	
4,4'-DDD	1	9.25	9.27	3.9		ug/kg	0.0
4,4'-DDD	2 [a]	11.06	11.07	3.9		ug/kg	
4,4'-DDE	1 [a]	8.40	8.42	3.6		ug/kg	8.0
4,4'-DDE	2	10.09	10.10	3.9		ug/kg	
4,4'-DDT	1	9.67	9.68	5.0		ug/kg	6.2
4,4'-DDT	2 [a]	11.61	11.61	4.7		ug/kg	
Endrin	1 [a]	9.13	9.13	4.6		ug/kg	19.0
Endrin	2	10.89	10.90	3.8		ug/kg	
Endosulfan sulfate	1 [a]	10.78	10.79	4.0		ug/kg	4.9
Endosulfan sulfate	2	12.31	12.31	4.2		ug/kg	
Endrin aldehyde	1 [a]	10.09	10.09	4.1		ug/kg	7.1
Endrin aldehyde	2	11.83	11.84	4.4		ug/kg	
Endosulfan-I	1 [a]	8.47	8.48	3.6		ug/kg	0.0
Endosulfan-I	2	9.93	9.93	3.6		ug/kg	
Endosulfan-II	1 [a]	9.46	9.46	3.9		ug/kg	0.0
Endosulfan-II	2	11.25	11.26	3.9		ug/kg	
Heptachlor	1 [a]	6.87	6.87	4.3		ug/kg	4.8
Heptachlor	2	7.96	7.97	4.1		ug/kg	
Heptachlor epoxide	1	7.95	7.96	4.3		ug/kg	4.8
Heptachlor epoxide	2 [a]	9.30	9.30	4.1		ug/kg	
Methoxychlor	1 [a]	10.46	10.47	4.3		ug/kg	23.4
Methoxychlor	2	12.84	12.85	3.4		ug/kg	
Endrin ketone	1 [a]	11.22	11.23	4.8		ug/kg	11.0
Endrin ketone	2	13.23	13.23	4.3		ug/kg	

(a) QC results reported from this column.

GC Identification Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Check Std:	G4G4306-CC4300	**Injection Date:**	03/11/24
Lab File ID:	4G9737016.D	**Injection Time:**	00:14
Instrument ID:	GC4G	**Method:**	SW846 8081B

Sample ID:	OP53021-MSD	**Injection Date:**	03/11/24
Lab File ID:	4G9737021.D	**Injection Time:**	02:36
Client ID:	Matrix Spike Duplicate		

Compound	Column	RT	StdRT	Conc	Q	Units	RPD Conc
Aldrin	1 [a]	7.22	7.22	4.6		ug/kg	11.5
Aldrin	2	8.44	8.45	4.1		ug/kg	
alpha-BHC	1 [a]	6.05	6.05	4.2		ug/kg	6.9
alpha-BHC	2	6.89	6.89	4.5		ug/kg	
beta-BHC	1 [a]	6.45	6.47	3.2		ug/kg	11.8
beta-BHC	2	7.45	7.46	3.6		ug/kg	
delta-BHC	1 [a]	6.64	6.66	4.1		ug/kg	11.5
delta-BHC	2	7.87	7.88	4.6		ug/kg	
gamma-BHC (Lindane)	1 [a]	6.36	6.36	4.4		ug/kg	4.4
gamma-BHC (Lindane)	2	7.35	7.35	4.6		ug/kg	
alpha-Chlordane	1	8.29	8.30	4.3		ug/kg	8.9
alpha-Chlordane	2 [a]	9.83	9.83	4.7		ug/kg	
gamma-Chlordane	1	8.12	8.12	4.1		ug/kg	5.0
gamma-Chlordane	2 [a]	9.59	9.60	3.9		ug/kg	
Dieldrin	1	8.80	8.80	4.5		ug/kg	10.5
Dieldrin	2 [a]	10.38	10.38	5.0		ug/kg	
4,4'-DDD	1	9.25	9.27	3.8		ug/kg	5.1
4,4'-DDD	2 [a]	11.06	11.07	4.0		ug/kg	
4,4'-DDE	1 [a]	8.40	8.42	3.8		ug/kg	7.6
4,4'-DDE	2	10.09	10.10	4.1		ug/kg	
4,4'-DDT	1	9.67	9.68	4.7		ug/kg	4.3
4,4'-DDT	2 [a]	11.61	11.61	4.5		ug/kg	
Endrin	1 [a]	9.13	9.13	4.1		ug/kg	5.0
Endrin	2	10.90	10.90	3.9		ug/kg	
Endosulfan sulfate	1 [a]	10.78	10.79	4.2		ug/kg	7.4
Endosulfan sulfate	2	12.31	12.31	3.9		ug/kg	
Endrin aldehyde	1 [a]	10.09	10.09	4.3		ug/kg	4.5
Endrin aldehyde	2	11.83	11.84	4.5		ug/kg	
Endosulfan-I	1 [a]	8.47	8.48	3.7		ug/kg	7.8
Endosulfan-I	2	9.93	9.93	4.0		ug/kg	
Endosulfan-II	1 [a]	9.45	9.46	3.9		ug/kg	2.5
Endosulfan-II	2	11.25	11.26	4.0		ug/kg	
Heptachlor	1 [a]	6.87	6.87	4.2		ug/kg	0.0
Heptachlor	2	7.96	7.97	4.2		ug/kg	
Heptachlor epoxide	1	7.95	7.96	4.4		ug/kg	0.0
Heptachlor epoxide	2 [a]	9.30	9.30	4.4		ug/kg	
Methoxychlor	1 [a]	10.46	10.47	3.8		ug/kg	12.3
Methoxychlor	2	12.85	12.85	4.3		ug/kg	
Endrin ketone	1 [a]	11.22	11.23	4.3		ug/kg	24.5
Endrin ketone	2	13.23	13.23	5.5		ug/kg	

(a) QC results reported from this column.

GC Identification Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Check Std:	G2G6058-CC6015	**Injection Date:**	03/10/24
Lab File ID:	2G231121.D	**Injection Time:**	19:28
Instrument ID:	GC2G	**Method:**	SW846 8082A

Sample ID:	OP53022-BS1	**Injection Date:**	03/10/24
Lab File ID:	2G231125.D	**Injection Time:**	21:06
Client ID:	Blank Spike		

Compound	Column	RT	StdRT	Conc	Q	Units	RPD Conc
Aroclor 1016	1 [a]			42.5		ug/kg	4.6
Aroclor 1016	2			44.5		ug/kg	
AR1016-A	1	4.99	4.99	46.8		ug/kg	
AR1016-A	2	5.67	5.67	51.3		ug/kg	
AR1016-B	1	5.27	5.27	42.1		ug/kg	
AR1016-B	2	6.06	6.06	40.0		ug/kg	
AR1016-C	1	5.64	5.64	39.1		ug/kg	
AR1016-C	2	6.57	6.57	46.9		ug/kg	
AR1016-D	1	5.76	5.76	45.5		ug/kg	
AR1016-D	2	6.73	6.74	43.3		ug/kg	
AR1016-E	1	6.12	6.12	39.1		ug/kg	
AR1016-E	2	7.39	7.39	41.0		ug/kg	
Aroclor 1260	1			48.9		ug/kg	8.3
Aroclor 1260	2 [a]			45.0		ug/kg	
AR1260-A	1	8.58	8.58	46.6		ug/kg	
AR1260-A	2	10.46	10.46	44.3		ug/kg	
AR1260-B	1	8.82	8.82	49.0		ug/kg	
AR1260-B	2	10.56	10.56	45.1		ug/kg	
AR1260-C	1	9.28	9.28	47.8		ug/kg	
AR1260-C	2	10.89	10.89	44.1		ug/kg	
AR1260-D	1	9.77	9.77	53.1		ug/kg	
AR1260-D	2	11.13	11.13	49.1		ug/kg	
AR1260-E	1	10.15	10.15	48.1		ug/kg	
AR1260-E	2	11.49	11.49	42.2		ug/kg	

(a) QC results reported from this column.

GC Identification Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Check Std:	G2G6058-CC6015	**Injection Date:**	03/10/24
Lab File ID:	2G231121.D	**Injection Time:**	19:28
Instrument ID:	GC2G	**Method:**	SW846 8082A

Sample ID:	OP53022-MS	**Injection Date:**	03/10/24
Lab File ID:	2G231126.D	**Injection Time:**	21:31
Client ID:	Matrix Spike		

Compound	Column	RT	StdRT	Conc	Q	Units	RPD Conc
Aroclor 1016	1 [a]			40.8		ug/kg	11.1
Aroclor 1016	2			45.6		ug/kg	
AR1016-A	1	4.99	4.99	39.2		ug/kg	
AR1016-A	2	5.66	5.67	53.5		ug/kg	
AR1016-B	1	5.27	5.27	41.0		ug/kg	
AR1016-B	2	6.06	6.06	41.8		ug/kg	
AR1016-C	1	5.64	5.64	38.1		ug/kg	
AR1016-C	2	6.57	6.57	46.3		ug/kg	
AR1016-D	1	5.76	5.76	45.4		ug/kg	
AR1016-D	2	6.73	6.74	44.3		ug/kg	
AR1016-E	1	6.12	6.12	40.0		ug/kg	
AR1016-E	2	7.39	7.39	42.2		ug/kg	
Aroclor 1260	1 [a]			48.4		ug/kg	2.9
Aroclor 1260	2			49.8		ug/kg	
AR1260-A	1	8.58	8.58	50.0		ug/kg	
AR1260-A	2	10.46	10.46	48.8		ug/kg	
AR1260-B	1	8.82	8.82	49.5		ug/kg	
AR1260-B	2	10.56	10.56	51.4		ug/kg	
AR1260-C	1	9.28	9.28	42.5		ug/kg	
AR1260-C	2	10.89	10.89	49.6		ug/kg	
AR1260-D	1	9.77	9.77	51.4		ug/kg	
AR1260-D	2	11.13	11.13	54.2		ug/kg	
AR1260-E	1	10.15	10.15	48.8		ug/kg	
AR1260-E	2	11.49	11.49	44.8		ug/kg	

(a) QC results reported from this column.

GC Identification Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Check Std:	G2G6058-CC6015	**Injection Date:**	03/10/24
Lab File ID:	2G231121.D	**Injection Time:**	19:28
Instrument ID:	GC2G	**Method:**	SW846 8082A

Sample ID:	OP53022-MSD	**Injection Date:**	03/10/24
Lab File ID:	2G231127.D	**Injection Time:**	21:55
Client ID:	Matrix Spike Duplicate		

Compound	Column	RT	StdRT	Conc	Q	Units	RPD Conc
Aroclor 1016	1 [a]			41.4		ug/kg	11.4
Aroclor 1016	2			46.4		ug/kg	
AR1016-A	1	4.99	4.99	39.8		ug/kg	
AR1016-A	2	5.66	5.67	54.4		ug/kg	
AR1016-B	1	5.27	5.27	42.0		ug/kg	
AR1016-B	2	6.05	6.06	42.3		ug/kg	
AR1016-C	1	5.64	5.64	39.0		ug/kg	
AR1016-C	2	6.56	6.57	49.6		ug/kg	
AR1016-D	1	5.76	5.76	46.0		ug/kg	
AR1016-D	2	6.73	6.74	43.5		ug/kg	
AR1016-E	1	6.12	6.12	40.4		ug/kg	
AR1016-E	2	7.39	7.39	42.2		ug/kg	
Aroclor 1260	1 [a]			48.9		ug/kg	2.4
Aroclor 1260	2			50.1		ug/kg	
AR1260-A	1	8.57	8.58	49.1		ug/kg	
AR1260-A	2	10.46	10.46	47.7		ug/kg	
AR1260-B	1	8.82	8.82	48.9		ug/kg	
AR1260-B	2	10.55	10.56	47.1		ug/kg	
AR1260-C	1	9.28	9.28	44.7		ug/kg	
AR1260-C	2	10.89	10.89	53.0		ug/kg	
AR1260-D	1	9.77	9.77	52.1		ug/kg	
AR1260-D	2	11.13	11.13	55.8		ug/kg	
AR1260-E	1	10.15	10.15	49.4		ug/kg	
AR1260-E	2	11.49	11.49	46.8		ug/kg	

(a) QC results reported from this column.

Surrogate Recovery Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Method: SW846 8081B **Matrix:** SO

Samples and QC shown here apply to the above method

Lab Sample ID	Lab File ID	S1 [a]	S1 [b]	S2 [a]	S2 [b]
JD83927-1	4G9737022.D	87	93	79	77
JD83927-2	4G9737023.D	81	86	73	64
JD83927-3	4G9737024.D	86	94	80	86
JD83927-4	4G9737025.D	83	93	75	100
JD83927-5	4G9737026.D	84	94	71	87
JD83927-6	4G9737027.D	102	110	89	89
JD83927-7	4G9737028.D	89	101	83	79
JD83927-8	4G9737029.D	95	103	83	81
JD83927-9	4G9737030.D	95	112	88	81
JD83927-10	4G9737031.D	99	115	92	73
JD83927-11	4G9737032.D	94	102	85	69
JD83927-12	4G9737033.D	93	99	84	68
JD83927-13	4G9737034.D	86	97	80	68
JD83927-14	4G9737035.D	439* [c]	248* [c]	80	83
JD83927-15	4G9737036.D	93	89	93	92
JD83927-16	5G136417.D	73	80	2050* [c]	496* [c]
JD83927-17	5G136418.D	102	96	552* [c]	204* [c]
JD83927-18	5G136419.D	107	92	123	95
OP53021-BS1	4G9737019.D	84	92	83	73
OP53021-MB1	4G9737018A.D	84	90	85	70
OP53021-MS	4G9737020.D	74	76	75	95
OP53021-MSD	4G9737021.D	75	84	71	108

Surrogate Compounds	Recovery Limits
S1 = Tetrachloro-m-xylene	66-150%
S2 = Decachlorobiphenyl	40-150%

(a) Recovery from GC signal #1
(b) Recovery from GC signal #2
(c) Outside control limits due to matrix interference.

Surrogate Recovery Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Method: SW846 8082A **Matrix:** SO

Samples and QC shown here apply to the above method

Lab Sample ID	Lab File ID	S1 [a]	S1 [b]	S2 [a]	S2 [b]
JD83927-1	2G231129.D	92	95	96	106
JD83927-2	2G231134.D	87	89	99	108
JD83927-3	2G231135.D	92	90	105	113
JD83927-4	2G231136.D	91	92	107	117
JD83927-5	2G231128.D	92	93	100	110
JD83927-6	2G231137.D	95	98	105	109
JD83927-7	2G231138.D	92	91	108	112
JD83927-8	2G231139.D	94	94	109	113
JD83927-9	2G231140.D	96	97	116	112
JD83927-10	2G231145.D	97	102	111	119
JD83927-11	2G231146.D	96	99	117	119
JD83927-12	2G231147.D	94	98	111	118
JD83927-13	2G231148.D	86	89	98	106
JD83927-14	2G231149.D	61	58	98	120
JD83927-15	2G231150.D	86	85	99	126
JD83927-16	2G231151.D	84	79	94	138
JD83927-17	2G231156.D	79	78	96	137
JD83927-18	2G231157.D	87	86	96	110
OP53022-BS1	2G231125.D	102	101	122	110
OP53022-MB1	2G231124.D	100	101	115	111
OP53022-MS	2G231126.D	94	92	118	112
OP53022-MSD	2G231127.D	91	89	115	115

Surrogate Compounds	Recovery Limits
S1 = Tetrachloro-m-xylene	42-159%
S2 = Decachlorobiphenyl	18-154%

(a) Recovery from GC signal #1
(b) Recovery from GC signal #2

GC Surrogate Retention Time Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Check Std:	G4G4306-CC4300	**Injection Date:**	03/11/24
Lab File ID:	4G9737016.D	**Injection Time:**	00:14
Instrument ID:	GC4G	**Method:**	SW846 8081B

	S1 [a] RT	S1 [b] RT	S2 [a] RT	S2 [b] RT
Check Std	5.54	6.16	13.00	14.79

Lab Sample ID	Lab File ID	Date Analyzed	Time Analyzed	S1 [a] RT	S1 [b] RT	S2 [a] RT	S2 [b] RT
OP53021-MB1	4G9737018A.D	03/11/24	01:38	5.58	6.20	13.03	14.80
OP53021-BS1	4G9737019.D	03/11/24	01:57	5.54	6.16	13.00	14.79
OP53021-MS	4G9737020.D	03/11/24	02:17	5.54	6.16	13.00	14.79
OP53021-MSD	4G9737021.D	03/11/24	02:36	5.53	6.16	13.00	14.79
JD83927-1	4G9737022.D	03/11/24	02:56	5.53	6.16	13.00	14.79
JD83927-2	4G9737023.D	03/11/24	03:19	5.55	6.17	13.00	14.79
JD83927-3	4G9737024.D	03/11/24	03:39	5.54	6.16	13.00	14.79
JD83927-4	4G9737025.D	03/11/24	03:58	5.54	6.16	13.00	14.79
JD83927-5	4G9737026.D	03/11/24	04:18	5.53	6.16	13.00	14.79
JD83927-6	4G9737027.D	03/11/24	04:37	5.53	6.16	13.00	14.79
JD83927-7	4G9737028.D	03/11/24	04:56	5.53	6.16	13.00	14.79
JD83927-8	4G9737029.D	03/11/24	05:16	5.53	6.16	12.99	14.79
JD83927-9	4G9737030.D	03/11/24	05:35	5.54	6.16	13.00	14.79
JD83927-10	4G9737031.D	03/11/24	05:54	5.54	6.16	13.00	14.79
JD83927-11	4G9737032.D	03/11/24	06:14	5.54	6.16	13.00	14.79
JD83927-12	4G9737033.D	03/11/24	06:33	5.54	6.16	13.00	14.79
JD83927-13	4G9737034.D	03/11/24	06:52	5.54	6.16	13.00	14.79
JD83927-14	4G9737035.D	03/11/24	07:12	5.53	6.16	13.00	14.79
JD83927-15	4G9737036.D	03/11/24	07:31	5.53	6.16	13.00	14.79

Surrogate Compounds

S1 = Tetrachloro-m-xylene
S2 = Decachlorobiphenyl

(a) Retention time from GC signal #1
(b) Retention time from GC signal #2

GC Surrogate Retention Time Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Check Std:	G5G3550-CC3509	**Injection Date:**	03/11/24
Lab File ID:	5G136411.D	**Injection Time:**	01:14
Instrument ID:	GC5G	**Method:**	SW846 8081B

	S1 [a] RT	S1 [b] RT	S2 [a] RT	S2 [b] RT
Check Std	5.51	5.92	12.97	14.45

Lab Sample ID	Lab File ID	Date Analyzed	Time Analyzed	S1 [a] RT	S1 [b] RT	S2 [a] RT	S2 [b] RT
ZZZZZZ	5G136413.D	03/11/24	01:58	5.51	5.92	12.96	14.45
ZZZZZZ	5G136414.D	03/11/24	02:19	5.51	5.92	12.97	14.45
ZZZZZZ	5G136415.D	03/11/24	02:50	5.53	5.94	12.97	14.45
ZZZZZZ	5G136416.D	03/11/24	03:12	5.51	5.92	12.96	14.45
JD83927-16	5G136417.D	03/11/24	03:33	5.51	5.92	13.03	14.45
JD83927-17	5G136418.D	03/11/24	03:55	5.51	5.92	13.03	14.45
JD83927-18	5G136419.D	03/11/24	04:16	5.51	5.92	12.96	14.45
ZZZZZZ	5G136420.D	03/11/24	04:38	5.51	5.92	12.96	14.45
ZZZZZZ	5G136421.D	03/11/24	05:00	5.51	5.92	12.97	14.45
ZZZZZZ	5G136422.D	03/11/24	05:21	5.51	5.92	12.96	14.45
JD83334-2	5G136424.D	03/11/24	06:04	5.51	5.92	12.96	14.45
ZZZZZZ	5G136425.D	03/11/24	06:26	5.51	5.92	12.96	14.45
ZZZZZZ	5G136426.D	03/11/24	06:48	5.51	5.92	12.96	14.45
ZZZZZZ	5G136427.D	03/11/24	07:09	5.51	5.92	12.96	14.45

Surrogate Compounds

S1 = Tetrachloro-m-xylene
S2 = Decachlorobiphenyl

(a) Retention time from GC signal #1
(b) Retention time from GC signal #2

GC Surrogate Retention Time Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Check Std:	G2G6058-CC6015	**Injection Date:**	03/10/24
Lab File ID:	2G231121.D	**Injection Time:**	19:28
Instrument ID:	GC2G	**Method:**	SW846 8082A

	S1 [a] RT	S1 [b] RT	S2 [a] RT	S2 [b] RT
Check Std	4.70	5.21	11.33	12.47

Lab Sample ID	Lab File ID	Date Analyzed	Time Analyzed	S1 [a] RT	S1 [b] RT	S2 [a] RT	S2 [b] RT
ZZZZZZ	2G231123.D	03/10/24	20:17	4.71	5.21	11.33	12.47
OP53022-MB1	2G231124.D	03/10/24	20:41	4.70	5.21	11.33	12.47
OP53022-BS1	2G231125.D	03/10/24	21:06	4.70	5.21	11.33	12.47
OP53022-MS	2G231126.D	03/10/24	21:31	4.70	5.21	11.33	12.47
OP53022-MSD	2G231127.D	03/10/24	21:55	4.70	5.21	11.33	12.47
JD83927-5	2G231128.D	03/10/24	22:19	4.70	5.21	11.33	12.47
JD83927-1	2G231129.D	03/10/24	22:44	4.70	5.21	11.33	12.47

Surrogate Compounds

S1 = Tetrachloro-m-xylene
S2 = Decachlorobiphenyl

(a) Retention time from GC signal #1
(b) Retention time from GC signal #2

GC Surrogate Retention Time Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Check Std:	G2G6058-CC6015	**Injection Date:**	03/10/24
Lab File ID:	2G231132.D	**Injection Time:**	23:57
Instrument ID:	GC2G	**Method:**	SW846 8082A

	S1 [a] RT	S1 [b] RT	S2 [a] RT	S2 [b] RT
Check Std	4.70	5.21	11.33	12.47

Lab Sample ID	Lab File ID	Date Analyzed	Time Analyzed	S1 [a] RT	S1 [b] RT	S2 [a] RT	S2 [b] RT
JD83927-2	2G231134.D	03/11/24	00:45	4.70	5.21	11.33	12.47
JD83927-3	2G231135.D	03/11/24	01:09	4.70	5.21	11.33	12.47
JD83927-4	2G231136.D	03/11/24	01:34	4.70	5.21	11.33	12.47
JD83927-6	2G231137.D	03/11/24	01:58	4.70	5.21	11.33	12.47
JD83927-7	2G231138.D	03/11/24	02:22	4.70	5.21	11.33	12.47
JD83927-8	2G231139.D	03/11/24	02:46	4.70	5.21	11.33	12.47
JD83927-9	2G231140.D	03/11/24	03:11	4.70	5.21	11.33	12.47

Surrogate Compounds

S1 = Tetrachloro-m-xylene
S2 = Decachlorobiphenyl

(a) Retention time from GC signal #1
(b) Retention time from GC signal #2

GC Surrogate Retention Time Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Check Std:	G2G6058-CC6015	**Injection Date:**	03/11/24
Lab File ID:	2G231143.D	**Injection Time:**	04:24
Instrument ID:	GC2G	**Method:**	SW846 8082A

	S1 [a] RT	S1 [b] RT	S2 [a] RT	S2 [b] RT
Check Std	4.70	5.21	11.33	12.47

Lab Sample ID	Lab File ID	Date Analyzed	Time Analyzed	S1 [a] RT	S1 [b] RT	S2 [a] RT	S2 [b] RT
JD83927-10	2G231145.D	03/11/24	05:12	4.70	5.21	11.33	12.47
JD83927-11	2G231146.D	03/11/24	05:36	4.70	5.21	11.33	12.47
JD83927-12	2G231147.D	03/11/24	06:01	4.70	5.21	11.33	12.47
JD83927-13	2G231148.D	03/11/24	06:25	4.70	5.21	11.33	12.47
JD83927-14	2G231149.D	03/11/24	06:49	4.71	5.21	11.33	12.47
JD83927-15	2G231150.D	03/11/24	07:13	4.70	5.21	11.33	12.47
JD83927-16	2G231151.D	03/11/24	07:38	4.70	5.21	11.33	12.47

Surrogate Compounds

S1 = Tetrachloro-m-xylene
S2 = Decachlorobiphenyl

(a) Retention time from GC signal #1
(b) Retention time from GC signal #2

GC Surrogate Retention Time Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Check Std:	G2G6058-CC6015	**Injection Date:**	03/11/24
Lab File ID:	2G231154.D	**Injection Time:**	08:51
Instrument ID:	GC2G	**Method:**	SW846 8082A

	S1 [a] RT	S1 [b] RT	S2 [a] RT	S2 [b] RT
Check Std	4.71	5.21	11.33	12.47

Lab Sample ID	Lab File ID	Date Analyzed	Time Analyzed	S1 [a] RT	S1 [b] RT	S2 [a] RT	S2 [b] RT
JD83927-17	2G231156.D	03/11/24	09:40	4.70	5.21	11.33	12.47
JD83927-18	2G231157.D	03/11/24	10:04	4.70	5.21	11.33	12.46

Surrogate Compounds

S1 = Tetrachloro-m-xylene
S2 = Decachlorobiphenyl

(a) Retention time from GC signal #1
(b) Retention time from GC signal #2

Initial Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G2G6015-ICC6015
Lab FileID: 2G229471.D

Response Factor Report GC2G

Method : C:\msdchem\1\METHODS\2PCBLVI6015a.M (ChemStation Integrator)
Title :
Last Update : Wed Jan 03 05:47:14 2024
Response via : Initial Calibration

Calibration Files
50 =2G229467.d 250 =2G229499.d 500 =2G229500.d 1000=2G229501.d
2000=2G229502a.d 3000=2G229503.d 5000=2G229474.d 10k =2G229475.d
20k =2G229476.d 100 =2G229505.d = =

Compound	50	250	500	1000	2000	3000	5000	10k	20k	100	Avg	%RSD
1) Tetrachloro-m-xylene	2.855	2.841	2.823	3.000	3.031	2.940	2.857	2.784		2.984	2.902 E8	3.04
2) AR1221-A				2.186							2.186 E6	0.00
3) AR1221-B				2.622							2.622 E6	0.00
4) AR1221-C				8.329							8.329 E6	0.00
5) AR1221-D				1.375							1.375 E6	0.00
6) AR1221-E				2.147							2.147 E6	0.00
7) AR1232-A				4.946							4.946 E6	0.00
8) AR1232-B				3.616							3.616 E6	0.00
9) AR1232-C				6.458							6.458 E6	0.00
10) AR1232-D				2.416							2.416 E6	0.00
11) AR1232-E				2.610							2.610 E6	0.00
12) AR1242-A	7.796	7.514	7.345	6.916	6.626					8.511	7.451 E6	8.95
13) AR1242-B	1.579	1.491	1.500	1.457	1.420					1.679	1.521 E7	6.16
14) AR1242-C	6.023	5.697	5.662	5.453	5.310					6.482	5.771 E6	7.35
15) AR1242-D	7.358	6.782	6.591	6.436	6.355					7.964	6.914 E6	9.06
16) AR1242-E	1.095	1.010	1.012	0.963	0.976					1.203	1.043 E7	8.71
17) AR1248-A	3.386	3.103	3.253	2.977	3.061					3.918	3.283 E6	10.46
18) AR1248-B	0.956	0.867	0.918	0.839	0.672					1.123	0.896 E7	16.55
19) AR1248-C	0.978	0.930	0.988	0.862	0.951					1.132	0.974 E7	9.22
20) AR1248-D	0.979	0.901	0.964	0.846	0.941					1.136	0.961 E7	10.19
21) AR1248-E	0.975	0.895	0.951	0.834	0.929					1.131	0.952 E7	10.51
22) AR1248-F	1.478	1.050	1.181	1.030	1.149					1.310	1.200 E7	14.14
23) AR1248-G												

		1.669	1.422	1.499	1.338	1.549			1.877	1.559 E7	12.32
24)	AR1254-A											
		8.880	8.328	8.499	8.166	8.216			9.943	8.672 E6	7.77
25)	AR1254-B											
		1.653	1.556	1.604	1.545	1.539			1.830	1.621 E7	6.87
26)	AR1254-C											
		0.933	0.878	0.915	0.882	0.887			1.015	0.918 E7	5.65
27)	AR1254-D											
		1.776	1.678	1.741	1.680	1.674			1.921	1.745 E7	5.47
28)	AR1254-E											
		1.207	1.148	1.151	1.130	1.120			1.247	1.167 E7	4.24
29)	AR1254-F											
		1.245	1.167	1.197	1.144	1.134			1.299	1.198 E7	5.33
30)	AR1254-G											
		1.609	1.533	1.595	1.546	1.538			1.577	1.567 E7	2.04
31)	AR1016-A											
		6.935	5.628	5.386	5.566	5.196	4.954	4.745	4.612	6.344	5.485 E6	13.75
32)	AR1016-B											
		1.184	1.070	0.959	0.999	0.949	0.910	0.866	0.831	1.187	0.995 E7	12.92
33)	AR1016-C											
		2.395	2.183	2.134	2.192	2.136	2.072	1.996	1.930	2.341	2.153 E7	6.92
34)	AR1016-D											
		9.783	7.989	7.877	7.829	7.761	7.498	7.219	7.113	9.402	8.052 E6	11.51
35)	AR1016-E											
		1.081	0.960	0.937	0.919	0.902	0.876	0.850	0.837	1.049	0.935 E7	9.00
36)	AR1260-A											
		2.315	2.091	2.069	2.151	2.145	2.108	2.084	2.035	2.196	2.133 E7	3.93
37)	AR1260-B											
		1.410	1.257	1.228	1.255	1.249	1.221	1.198	1.157	1.340	1.257 E7	6.03
38)	AR1260-C											
		1.479	1.287	1.260	1.290	1.320	1.262	1.270	1.230	1.424	1.314 E7	6.33
39)	AR1260-D											
		3.186	2.952	2.928	3.025	3.018	2.969	2.917	2.814	3.175	2.998 E7	4.02
40)	AR1260-E											
		3.407	2.895	2.870	2.879	2.891	2.842	2.829	2.836	3.386	2.982 E7	7.93
41)	AR1262-A											
					1.052						1.052 E7	0.00
42)	AR1262-B											
					1.536						1.536 E7	0.00
43)	AR1262-C											
					1.383						1.383 E7	0.00
44)	AR1262-D											
					2.853						2.853 E7	0.00
45)	AR1262-E											
					3.137						3.137 E7	0.00
46)	AR1268-A											
					3.312						3.312 E7	0.00
47)	AR1268-B											
					3.720						3.720 E7	0.00
48)	AR1268-C											
					2.875						2.875 E7	0.00
49)	AR1268-D											
					1.099						1.099 E7	0.00
50)	AR1268-E											
					8.128						8.128 E7	0.00
51)	Decachlorobiphenyl											
		2.181	2.081	2.113	2.075	2.027	2.019			2.467	2.138 E8	7.26

Signal #2

Initial Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G2G6015-ICC6015
Lab FileID: 2G229471.D

1)	Tetrachloro-m-xylene											
	6.645	5.465	4.563	4.993	5.102	5.136	5.112	5.042	6.192	5.361	E8	12.17
2)	AR1221-A											
				2.221						2.221	E6	0.00
3)	AR1221-B											
				5.046						5.046	E6	0.00
4)	AR1221-C											
				1.203						1.203	E7	0.00
5)	AR1221-D											
				4.566						4.566	E6	0.00
6)	AR1221-E											
				2.581						2.581	E6	0.00
7)	AR1232-A											
				7.786						7.786	E6	0.00
8)	AR1232-B											
				6.502						6.502	E6	0.00
9)	AR1232-C											
				1.394						1.394	E7	0.00
10)	AR1232-D											
				5.116						5.116	E6	0.00
11)	AR1232-E											
				3.876						3.876	E6	0.00
12)	AR1242-A											
	1.377	1.343	1.328	1.289	1.267				1.424	1.338	E7	4.30
13)	AR1242-B											
	2.658	2.706	2.639	2.796	2.657				2.771	2.704	E7	2.43
14)	AR1242-C											
	1.114	1.151	1.135	1.173	1.163				1.231	1.161	E7	3.44
15)	AR1242-D											
	1.001	1.024	0.959	0.966	0.977				1.067	0.999	E7	4.10
16)	AR1242-E											
	1.227	1.233	1.352	1.250	1.265				1.296	1.271	E7	3.68
17)	AR1248-A											
	5.832	5.502	6.038	5.583	5.912				6.043	5.818	E6	3.94
18)	AR1248-B											
	1.339	1.437	1.671	1.571	1.721				1.401	1.523	E7	10.15
19)	AR1248-C											
	1.089	1.051	1.170	1.042	1.157				1.184	1.115	E7	5.63
20)	AR1248-D											
	1.246	1.202	1.591	1.382	1.526				1.648	1.432	E7	12.90
21)	AR1248-E											
	1.408	1.462	1.531	1.366	1.488				1.508	1.461	E7	4.28
22)	AR1248-F											
	1.956	2.075	2.269	2.092	2.239				2.233	2.144	E7	5.73
23)	AR1248-G											
	1.838	1.998	2.101	1.904	2.051				2.101	1.999	E7	5.41
24)	AR1254-A											
	2.107	2.007	2.087	2.114	2.048				2.169	2.089	E7	2.68
25)	AR1254-B											
	2.793	2.685	2.777	2.740	2.674				2.775	2.741	E7	1.85
26)	AR1254-C											
	1.644	1.670	1.731	1.748	1.677				1.530	1.667	E7	4.66
27)	AR1254-D											
	3.111	3.109	3.242	3.225	3.139				3.155	3.163	E7	1.81
28)	AR1254-E											
	2.865	2.830	2.863	2.883	2.789				2.729	2.826	E7	2.06
29)	AR1254-F											
	2.101	2.163	2.305	2.299	2.242				2.200	2.219	E7	3.59
30)	AR1254-G											
	2.709	2.671	2.943	2.981	2.323				2.792	2.737	E7	8.67

Initial Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G2G6015-ICC6015
Lab FileID: 2G229471.D

```
31)  AR1016-A
          7.454 7.723 7.412 7.970 7.761 7.564 7.498 7.386       7.300  7.563 E6    2.84
32)  AR1016-B
          2.356 2.020 1.770 1.758 1.816 1.666 1.618 1.550       2.297  1.872 E7   15.51
33)  AR1016-C
          3.843 2.788 2.488 3.733 3.544 3.772 3.667 3.633       3.631  3.456 E7   13.82
34)  AR1016-D
          1.811 1.609 1.571 1.604 1.613 1.559 1.535 1.482       1.631  1.602 E7    5.69
35)  AR1016-E
          1.491 1.373 1.340 1.426 1.372 1.296 1.308 1.270       1.394  1.363 E7    5.06
36)  AR1260-A
          3.842 3.859 3.668 4.006 3.999 4.002 4.011 3.998       3.987  3.930 E7    3.00
37)  AR1260-B
          2.839 2.735 2.552 2.886 2.876 2.834 2.814 2.740       2.847  2.791 E7    3.73
38)  AR1260-C
          2.056 2.066 2.088 2.374 2.285 2.289 2.307 2.323       1.983  2.197 E7    6.65
39)  AR1260-D
          5.080 4.666 4.487 5.571 5.517 5.473 5.334 3.753       5.110  4.999 E7   12.00
40)  AR1260-E
          5.726 4.716 4.599 4.762 4.865 4.884 4.835 4.888       4.698  4.886 E7    6.75
41)  AR1262-A
                              2.731                                    2.731 E7    0.00
42)  AR1262-B
                              2.731                                    2.731 E7    0.00
43)  AR1262-C
                              3.575                                    3.575 E7    0.00
44)  AR1262-D
                              5.514                                    5.514 E7    0.00
45)  AR1262-E
                              5.454                                    5.454 E7    0.00
46)  AR1268-A
                              6.309                                    6.309 E7    0.00
47)  AR1268-B
                              5.634                                    5.634 E7    0.00
48)  AR1268-C
                              4.722                                    4.722 E7    0.00
49)  AR1268-D
                              1.813                                    1.813 E7    0.00
50)  AR1268-E
                              1.287                                    1.287 E8    0.00
51)  Decachlorobiphenyl
          2.913 2.819 2.878 2.853 2.988 2.902 2.896 2.965       2.891  2.901 E8    1.79
-----------------------------------------------------------------------------
(#) = Out of Range  ###  Number of calibration levels exceeded format  ###

          2PCBLVI6015a.M        Wed Jan 03 05:59:15 2024
```

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G2G6015-ICV6015
Lab FileID: 2G229481.D

Evaluate Continuing Calibration Report

Data Path : C:\msdchem\1\DATA\2G6015\
Data File : 2G229481.d
Signal(s) : Signal #1: ECD1A.CH Signal #2: ECD2B.CH
Acq On   : 01 Dec 2023   0:48 am
Operator : mahalial
Sample   : icv6015-100 (Sig #1); icv6014-100 (Sig #2)
Misc   : op50027,G2G6015,5.0,,,10,1
ALS Vial : 0 (Sig #1); 16 (Sig #2)   Sample Multiplier: 1

Integration File signal 1: autoint1.e
Integration File signal 2: autoint2.e
Quant Time: Dec 20 06:20:30 2023
Quant Method : C:\msdchem\1\METHODS\2PCBLVI6015.M
Quant Title :
QLast Update : Wed Dec 20 06:17:54 2023
Response via : Initial Calibration
Integrator: ChemStation   6890 Scale Mode: Large solvent peaks clipped

Volume Inj.   : 1ul
Signal #1 Phase : ZBCLP-1   Signal #2 Phase: ZBCLP-2
Signal #1 Info : 30m X 0.32mm(.32u Signal #2 Info : 30m X 0.32 mm (.25um)

Min. RRF   :   0.000 Min. Rel. Area : 50% Max. R.T. Dev 0.50min
Max. RRF Dev : 20%   Max. Rel. Area : 150%

		Compound	AvgRF	CCRF	%Dev	Area%	Dev(Min)
1	S	Tetrachloro-m-xylene	290.165	314.969 E6	-8.5	105	0.00
31		AR1016-A	5.485	5.730 E6	-4.5	103	0.00
32		AR1016-B	9.949	11.118 E6	-11.7	111	0.00
33		AR1016-C	21.532	24.695 E6	-14.7	113	0.00
34		AR1016-D	8.052	9.069 E6	-12.6	116	-0.02
35		AR1016-E	9.345	10.000 E6	-7.0	109	0.00
36		AR1260-A	21.329	26.302 E6	-23.3#	122	0.00
37		AR1260-B	12.574	11.900 E6	5.4	95	0.00
38		AR1260-C	13.137	12.920 E6	1.7	100	0.00
39		AR1260-D	29.983	30.094 E6	-0.4	99	0.00
40		AR1260-E	29.818	27.399 E6	8.1	95	0.00
51	S	Decachlorobiphenyl	213.773	216.834 E6	-1.4	103	0.00

Signal #2

1	S	Tetrachloro-m-xylene	536.119	531.476 E6	0.9	106	0.00
31		AR1016-A	7.563	8.747 E6	-15.7	110	0.00
32		AR1016-B	18.723	19.892 E6	-6.2	113	0.00
33		AR1016-C	34.555	41.915 E6	-21.3#	112	0.03
34		AR1016-D	16.015	18.405 E6	-14.9	115	0.00
35		AR1016-E	13.632	14.800 E6	-8.6	104	0.00
36		AR1260-A	39.304	46.860 E6	-19.2	117	0.00
37		AR1260-B	27.915	25.503 E6	8.6	88	0.00
38		AR1260-C	21.967	22.042 E6	-0.3	93	0.00
39		AR1260-D	49.990	52.106 E6	-4.2	94	0.00
40		AR1260-E	48.858	43.088 E6	11.8	90	0.02
51	S	Decachlorobiphenyl	290.069	279.189 E6	3.8	98	0.00

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G2G6015-ICV6015
Lab FileID: 2G229481.D

(#) = Out of Range SPCC's out = 0 CCC's out = 0

2PCBLVI6015.M Thu Dec 21 09:19:06 2023

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G2G6015-ICV6015
Lab FileID: 2G229482.D

Evaluate Continuing Calibration Report

Data Path : C:\msdchem\1\DATA\2G6015\
Data File : 2G229482.d
Signal(s) : Signal #1: ECD1A.CH Signal #2: ECD2B.CH
Acq On   : 01 Dec 2023   1:12 am
Operator : mahalial
Sample   : icv6015-100 (Sig #1); icv6014-100 (Sig #2)
Misc   : op50027,G2G6015,5.0,,,10,1
ALS Vial : 0 (Sig #1); 17 (Sig #2)   Sample Multiplier: 1

Integration File signal 1: autoint1.e
Integration File signal 2: autoint2.e
Quant Time: Dec 18 20:39:44 2023
Quant Method : C:\msdchem\1\METHODS\2PCBLVI6015.M
Quant Title :
QLast Update : Mon Dec 18 20:31:06 2023
Response via : Initial Calibration
Integrator: ChemStation   6890 Scale Mode: Large solvent peaks clipped

Volume Inj.   : 1ul
Signal #1 Phase : ZBCLP-1   Signal #2 Phase: ZBCLP-2
Signal #1 Info : 30m X 0.32mm(.32u Signal #2 Info : 30m X 0.32 mm (.25um)

Min. RRF   :   0.000 Min. Rel. Area : 50% Max. R.T. Dev 0.50min
Max. RRF Dev : 20%   Max. Rel. Area : 150%

		Compound	AvgRF	CCRF	%Dev	Area%	Dev(Min)
1	S	Tetrachloro-m-xylene	290.165	318.132 E6	-9.6	106	0.00
2		AR1221-A	2.186	2.461 E6	-12.6	113	0.00
3		AR1221-B	2.622	3.024 E6	-15.3	115	0.00
4		AR1221-C	8.329	9.017 E6	-8.3	108	0.00
5		AR1221-D	1.375	1.171 E6	14.8	85	0.00
6		AR1221-E	2.147	2.013 E6	6.2	94	0.00
24		AR1254-A	9.626	10.834 E6	-12.5	113	0.00
25		AR1254-B	17.654	19.381 E6	-9.8	110	0.00
26		AR1254-C	9.589	10.930 E6	-14.0	114	0.00
27		AR1254-D	18.203	20.837 E6	-14.5	114	0.00
28		AR1254-E	11.830	13.236 E6	-11.9	112	0.00
29		AR1254-F	11.886	13.585 E6	-14.3	114	0.00
30		AR1254-G	17.022	19.904 E6	-16.9	117	0.00
51	S	Decachlorobiphenyl	213.773	208.150 E6	2.6	99	0.00

Signal #2

1	S	Tetrachloro-m-xylene	536.119	541.328 E6	-1.0	108	0.00
2		AR1221-A	2.221	2.486 E6	-11.9	112	0.00
3		AR1221-B	5.046	5.055 E6	-0.2	100	0.00
4		AR1221-C	12.032	12.258 E6	-1.9	102	0.00
5		AR1221-D	4.566	4.285 E6	6.2	94	0.00
6		AR1221-E	2.581	2.072 E6	19.7	80	0.00
24		AR1254-A	21.758	25.023 E6	-15.0	115	0.00
25		AR1254-B	28.247	32.461 E6	-14.9	115	0.00
26		AR1254-C	17.734	19.583 E6	-10.4	110	0.00
27		AR1254-D	32.736	38.446 E6	-17.4	117	0.00
28		AR1254-E	29.182	34.733 E6	-19.0	119	0.00
29		AR1254-F	24.128	26.581 E6	-10.2	110	0.00
30		AR1254-G	24.491	28.268 E6	-15.4	115	0.00

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G2G6015-ICV6015
Lab FileID: 2G229482.D

51	S	Decachlorobiphenyl	290.069	291.475	E6	-0.5	102	0.00

(#) = Out of Range SPCC's out = 0 CCC's out = 0

2PCBLVI6015.M Thu Dec 21 09:19:08 2023

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G2G6015-ICV6015
Lab FileID: 2G229484.D

Evaluate Continuing Calibration Report

Data Path : C:\msdchem\1\DATA\2G6015\
Data File : 2G229484.d
Signal(s) : Signal #1: ECD1A.CH Signal #2: ECD2B.CH
Acq On   : 01 Dec 2023   2:00 am
Operator : mahalial
Sample   : icv6015-100 (Sig #1); icv6014-100 (Sig #2)
Misc   : op50027,G2G6015,5.0,,,10,1
ALS Vial : 0 (Sig #1); 19 (Sig #2)   Sample Multiplier: 1

Integration File signal 1: autoint1.e
Integration File signal 2: autoint2.e
Quant Time: Dec 18 20:48:14 2023
Quant Method : C:\msdchem\1\METHODS\2PCBLVI6015.M
Quant Title :
QLast Update : Mon Dec 18 20:31:06 2023
Response via : Initial Calibration
Integrator: ChemStation   6890 Scale Mode: Large solvent peaks clipped

Volume Inj.   : 1ul
Signal #1 Phase : ZBCLP-1   Signal #2 Phase: ZBCLP-2
Signal #1 Info : 30m X 0.32mm(.32u Signal #2 Info : 30m X 0.32 mm (.25um)

Min. RRF   :   0.000 Min. Rel. Area : 50% Max. R.T. Dev 0.50min
Max. RRF Dev : 20%   Max. Rel. Area : 150%

		Compound	AvgRF	CCRF	%Dev	Area%	Dev(Min)
1	S	Tetrachloro-m-xylene	290.165	267.887 E6	7.7	89	0.00
12		AR1242-A	7.571	8.563 E6	-13.1	113	0.00
13		AR1242-B	16.410	18.444 E6	-12.4	112	0.00
14		AR1242-C	6.075	6.935 E6	-14.2	114	0.00
15		AR1242-D	6.733	7.711 E6	-14.5	115	0.00
16		AR1242-E	7.044	7.373 E6	-4.7	105	0.00
46		AR1268-A	33.123	32.875 E6	0.7	99	0.00
47		AR1268-B	37.201	36.597 E6	1.6	98	0.00
48		AR1268-C	28.752	28.603 E6	0.5	99	0.00
49		AR1268-D	10.986	11.026 E6	-0.4	100	0.00
50		AR1268-E	81.277	80.843 E6	0.5	99	0.00
51	S	Decachlorobiphenyl	213.773	598.421 E6	-179.9#	283#	0.00

Signal #2

1	S	Tetrachloro-m-xylene	536.119	484.578 E6	9.6	97	0.00
12		AR1242-A	13.517	16.652 E6	-23.2#	123	0.00
13		AR1242-B	29.004	31.118 E6	-7.3	107	-0.03
14		AR1242-C	12.151	14.529 E6	-19.6	120	0.00
15		AR1242-D	9.962	11.767 E6	-18.1	118	0.00
16		AR1242-E	12.962	14.275 E6	-10.1	110	0.00
46		AR1268-A	63.088	62.283 E6	1.3	99	0.00
47		AR1268-B	56.340	53.828 E6	4.5	96	0.00
48		AR1268-C	47.224	45.991 E6	2.6	97	0.00
49		AR1268-D	18.131	18.404 E6	-1.5	102	0.00
50		AR1268-E	128.678	129.034 E6	-0.3	100	0.00
51	S	Decachlorobiphenyl	290.069	811.828 E6	-179.9#	285#	0.00

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G2G6015-ICV6015
Lab FileID: 2G229484.D

(#) = Out of Range SPCC's out = 0 CCC's out = 0

2PCBLVI6015.M Thu Dec 21 09:19:10 2023

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G2G6015-ICV6015
Lab FileID: 2G229504.D

Evaluate Continuing Calibration Report

Data Path : C:\msdchem\1\DATA\2G6016\
Data File : 2G229504.d
Signal(s) : Signal #1: ECD1A.CH Signal #2: ECD2B.CH
Acq On   : 17 Dec 2023 22:51 pm
Operator : rebeccak
Sample   : icv6016-100
Misc   : op50027,G2G6016,5.0,,,10,1
ALS Vial : 0 (Sig #1); 8 (Sig #2)   Sample Multiplier: 1

Integration File signal 1: autoint1.e
Integration File signal 2: autoint2.e
Quant Time: Dec 21 09:33:00 2023
Quant Method : C:\msdchem\1\METHODS\2PCBLVI6015a.M
Quant Title :
QLast Update : Wed Dec 20 11:45:34 2023
Response via : Initial Calibration
Integrator: ChemStation   6890 Scale Mode: Large solvent peaks clipped

Volume Inj.   : 1ul
Signal #1 Phase : ZBCLP-1   Signal #2 Phase: ZBCLP-2
Signal #1 Info : 30m X 0.32mm(.32u Signal #2 Info : 30m X 0.32 mm (.25um)

Min. RRF   :   0.000 Min. Rel. Area : 50% Max. R.T. Dev 0.50min
Max. RRF Dev : 20%   Max. Rel. Area : 150%

	Compound	AvgRF	CCRF	%Dev	Area%	Dev(Min)
17	AR1248-A	3.283	3.385 E6	-3.1	104	0.00
18	AR1248-B	8.957	9.599 E6	-7.2	105	0.00
19	AR1248-C	9.736	10.212 E6	-4.9	103	0.00
20	AR1248-D	9.610	10.004 E6	-4.1	104	0.00
21	AR1248-E	9.524	9.959 E6	-4.6	105	0.00
22	AR1248-F	11.998	12.239 E6	-2.0	104	0.00
23	AR1248-G	15.590	16.484 E6	-5.7	110	0.00
Signal #2						
17	AR1248-A	5.818	6.297 E6	-8.2	104	0.00
18	AR1248-B	15.232	17.658 E6	-15.9	106	0.00
19	AR1248-C	11.154	12.163 E6	-9.0	104	0.00
20	AR1248-D	14.324	16.326 E6	-14.0	103	0.00
21	AR1248-E	14.607	15.636 E6	-7.0	102	0.00
22	AR1248-F	21.440	23.917 E6	-11.6	105	0.00
23	AR1248-G	19.988	21.839 E6	-9.3	104	0.00

(#) = Out of Range SPCC's out = 0 CCC's out = 0

2PCBLVI6015a.M Thu Dec 21 09:33:24 2023

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G2G6015-ICV6015
Lab FileID: 2G229511.D

Evaluate Continuing Calibration Report

Signal #1 : C:\msdchem\1\DATA\2G6016\2G229511.d\ECD1A.CH Vial: 0
Signal #2 : C:\msdchem\1\DATA\2G6016\2G229511.d\ECD2B.CH
Acq On : 18 Dec 2023 1:38 am Operator: rebeccak
Sample : icv6016-100 Inst : GC2G
Misc : op50027,G2G6016,5.0,,,10,1 Multiplr: 1.00
IntFile Signal #1: autoint1.e IntFile Signal #2: autoint2.e

Method : C:\msdchem\1\METHODS\2PCBLVI6015a.M (ChemStation Integrator)
Title :
Last Update : Wed Jan 03 05:47:14 2024
Response via : Multiple Level Calibration

Min. RRF : 0.000 Min. Rel. Area : 50% Max. R.T. Dev 0.50min
Max. RRF Dev : 20% Max. Rel. Area : 150%

	Compound	AvgRF	CCRF	%Dev	Area%	Dev(min)	RT Window
1 S	Tetrachloro-m-xylene		----------NA----------				
2	AR1221-A		----------NA----------				
3	AR1221-B		----------NA----------				
4	AR1221-C		----------NA----------				
5	AR1221-D		----------NA----------				
6	AR1221-E		----------NA----------				
7	AR1232-A		----------NA----------				
8	AR1232-B		----------NA----------				
9	AR1232-C		----------NA----------				
10	AR1232-D		----------NA----------				
11	AR1232-E		----------NA----------				
12	AR1242-A		----------NA----------				
13	AR1242-B		----------NA----------				
14	AR1242-C		----------NA----------				
15	AR1242-D		----------NA----------				
16	AR1242-E		----------NA----------				
17	AR1248-A		----------NA----------				
18	AR1248-B		----------NA----------				
19	AR1248-C		----------NA----------				
20	AR1248-D		----------NA----------				
21	AR1248-E		----------NA----------				
22	AR1248-F		----------NA----------				
23	AR1248-G		----------NA----------				
24	AR1254-A	8.672	8.515 E6	1.8	100	0.00	6.25- 7.25
25	AR1254-B	16.211	15.859 E6	2.2	99	0.00	6.96- 7.16
26	AR1254-C	9.183	9.001 E6	2.0	98	0.00	7.35- 7.55
27	AR1254-D	17.451	17.288 E6	0.9	99	0.00	7.53- 7.73
28	AR1254-E	11.673	11.572 E6	0.9	100	0.00	7.99- 8.19
29	AR1254-F	11.977	12.112 E6	-1.1	101	0.00	8.34- 8.54
30	AR1254-G	15.667	16.131 E6	-3.0	101	0.00	8.90- 9.10
31	AR1016-A		----------NA----------				
32	AR1016-B		----------NA----------				
33	AR1016-C		----------NA----------				
34	AR1016-D		----------NA----------				
35	AR1016-E		----------NA----------				
36	AR1260-A		----------NA----------				
37	AR1260-B		----------NA----------				
38	AR1260-C		----------NA----------				
39	AR1260-D		----------NA----------				
40	AR1260-E		----------NA----------				
41	AR1262-A		----------NA----------				

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G2G6015-ICV6015
Lab FileID: 2G229511.D

42		AR1262-B			----------NA----------			
43		AR1262-C			----------NA----------			
44		AR1262-D			----------NA----------			
45		AR1262-E			----------NA----------			
46		AR1268-A			----------NA----------			
47		AR1268-B			----------NA----------			
48		AR1268-C			----------NA----------			
49		AR1268-D			----------NA----------			
50		AR1268-E			----------NA----------			
51	S	Decachlorobiphenyl			----------NA----------			
*****		Signal #2 *****						
1	S	Tetrachloro-m-xylene			----------NA----------			
2		AR1221-A			----------NA----------			
3		AR1221-B			----------NA----------			
4		AR1221-C			----------NA----------			
5		AR1221-D			----------NA----------			
6		AR1221-E			----------NA----------			
7		AR1232-A			----------NA----------			
8		AR1232-B			----------NA----------			
9		AR1232-C			----------NA----------			
10		AR1232-D			----------NA----------			
11		AR1232-E			----------NA----------			
12		AR1242-A			----------NA----------			
13		AR1242-B			----------NA----------			
14		AR1242-C			----------NA----------			
15		AR1242-D			----------NA----------			
16		AR1242-E			----------NA----------			
17		AR1248-A			----------NA----------			
18		AR1248-B			----------NA----------			
19		AR1248-C			----------NA----------			
20		AR1248-D			----------NA----------			
21		AR1248-E			----------NA----------			
22		AR1248-F			----------NA----------			
23		AR1248-G			----------NA----------			
24		AR1254-A	20.887	22.963 E6	-9.9	110	0.00	7.87- 8.87
25		AR1254-B	27.407	28.363 E6	-3.5	102	0.00	8.64- 8.84
26		AR1254-C	16.665	17.885 E6	-7.3	103	0.00	9.32- 9.52
27		AR1254-D	31.634	32.708 E6	-3.4	101	0.00	9.50- 9.70
28		AR1254-E	28.263	29.211 E6	-3.4	102	0.00	9.82-10.02
29		AR1254-F	22.185	23.848 E6	-7.5	103	0.00	10.26-10.46
30		AR1254-G	27.365	24.355 E6	11.0	83	0.00	10.51-10.71
31		AR1016-A			----------NA----------			
32		AR1016-B			----------NA----------			
33		AR1016-C			----------NA----------			
34		AR1016-D			----------NA----------			
35		AR1016-E			----------NA----------			
36		AR1260-A			----------NA----------			
37		AR1260-B			----------NA----------			
38		AR1260-C			----------NA----------			
39		AR1260-D			----------NA----------			
40		AR1260-E			----------NA----------			
41		AR1262-A			----------NA----------			
42		AR1262-B			----------NA----------			
43		AR1262-C			----------NA----------			
44		AR1262-D			----------NA----------			
45		AR1262-E			----------NA----------			
46		AR1268-A			----------NA----------			
47		AR1268-B			----------NA----------			

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G2G6015-ICV6015
Lab FileID: 2G229511.D

```
48      AR1268-C                              ----------NA----------
49      AR1268-D                              ----------NA----------
50      AR1268-E                              ----------NA----------
51 S    Decachlorobiphenyl                    ----------NA----------
------------------------------------------------------------------------------
------------------------------------------------------------------------------

   (#) = Out of Range                 SPCC's out = 0  CCC's out = 0
    2G229501.d 2PCBLVI6015a.M         Wed Jan 03 05:57:18 2024
```

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G2G6015-ICV6015
Lab FileID: 2G229518.D

Evaluate Continuing Calibration Report

Data Path : C:\msdchem\1\DATA\2G6016\
Data File : 2G229518.d
Signal(s) : Signal #1: ECD1A.CH Signal #2: ECD2B.CH
Acq On   : 18 Dec 2023   4:47 am
Operator : rebeccak
Sample   : icv6016-100
Misc   : op50027,G2G6016,5.0,,,10,1
ALS Vial : 0 (Sig #1); 22 (Sig #2)   Sample Multiplier: 1

Integration File signal 1: autoint1.e
Integration File signal 2: autoint2.e
Quant Time: Dec 21 09:29:44 2023
Quant Method : C:\msdchem\1\METHODS\2PCBLVI6015a.M
Quant Title :
QLast Update : Wed Dec 20 11:45:34 2023
Response via : Initial Calibration
Integrator: ChemStation   6890 Scale Mode: Large solvent peaks clipped

Volume Inj.   : 1ul
Signal #1 Phase : ZBCLP-1   Signal #2 Phase: ZBCLP-2
Signal #1 Info : 30m X 0.32mm(.32u Signal #2 Info : 30m X 0.32 mm (.25um)

Min. RRF   :   0.000 Min. Rel. Area : 50% Max. R.T. Dev 0.50min
Max. RRF Dev : 20%   Max. Rel. Area : 150%

	Compound	AvgRF	CCRF	%Dev	Area%	Dev(Min)
12	AR1242-A	7.451	8.307 E6	-11.5	113	0.00
13	AR1242-B	15.212	16.906 E6	-11.1	113	0.00
14	AR1242-C	5.771	6.347 E6	-10.0	112	0.00
15	AR1242-D	6.914	7.326 E6	-6.0	111	0.00
16	AR1242-E	10.433	10.842 E6	-3.9	107	0.00
Signal #2						
12	AR1242-A	13.379	15.467 E6	-15.6	116	0.00
13	AR1242-B	27.045	32.728 E6	-21.0#	124	0.03
14	AR1242-C	11.611	13.890 E6	-19.6	122	0.00
15	AR1242-D	9.990	11.290 E6	-13.0	118	0.00
16	AR1242-E	12.706	13.913 E6	-9.5	103	0.00

(#) = Out of Range SPCC's out = 0 CCC's out = 0

2PCBLVI6015a.M Thu Dec 21 09:33:28 2023

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G2G6015-ICV6015
Lab FileID: 2G229526.D

Evaluate Continuing Calibration Report

Data Path : C:\msdchem\1\DATA\2G6017\
Data File : 2G229526.d
Signal(s) : Signal #1: ECD1A.CH Signal #2: ECD2B.CH
Acq On   : 20 Dec 2023   8:25 am
Operator : rebeccak
Sample   : icv6015-100 (ar1262)
Misc   : op50027,G2G6017,5.0,,,10,1
ALS Vial : 0 (Sig #1); 29 (Sig #2)   Sample Multiplier: 1

Integration File signal 1: autoint1.e
Integration File signal 2: autoint2.e
Quant Time: Dec 21 09:22:35 2023
Quant Method : C:\msdchem\1\METHODS\2PCBLVI6015.M
Quant Title :
QLast Update : Thu Dec 21 09:21:59 2023
Response via : Initial Calibration
Integrator: ChemStation   6890 Scale Mode: Large solvent peaks clipped

Volume Inj.   : 1ul
Signal #1 Phase : ZBCLP-1   Signal #2 Phase: ZBCLP-2
Signal #1 Info : 30m X 0.32mm(.32u Signal #2 Info : 30m X 0.32 mm (.25um)

Min. RRF   :   0.000 Min. Rel. Area : 50% Max. R.T. Dev 0.50min
Max. RRF Dev : 20%   Max. Rel. Area : 150%

	Compound	AvgRF	CCRF	%Dev	Area%	Dev(Min)
41	AR1262-A	10.519	10.426 E6	0.9	99	-0.03
42	AR1262-B	15.362	15.059 E6	2.0	98	-0.03
43	AR1262-C	13.828	13.556 E6	2.0	98	-0.03
44	AR1262-D	28.526	28.126 E6	1.4	99	-0.02
45	AR1262-E	31.369	30.866 E6	1.6	98	-0.02
Signal #2						
41	AR1262-A	27.308	26.522 E6	2.9	97	-0.02
42	AR1262-B	35.745	35.142 E6	1.7	98	-0.02
43	AR1262-C	24.755	24.394 E6	1.5	99	-0.02
44	AR1262-D	55.141	53.510 E6	3.0	97	-0.01
45	AR1262-E	54.536	52.926 E6	3.0	97	-0.02

(#) = Out of Range SPCC's out = 0 CCC's out = 0

2PCBLVI6015.M Thu Dec 21 09:24:32 2023

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G2G6015-ICV6015
Lab FileID: 2G229528.D

Evaluate Continuing Calibration Report

Data Path : C:\msdchem\1\DATA\2G6017\
Data File : 2G229528.d
Signal(s) : Signal #1: ECD1A.CH Signal #2: ECD2B.CH
Acq On   : 20 Dec 2023 10:27 am
Operator : rebeccak
Sample   : icv6015-100 (ar1232)
Misc   : op50027,G2G6017,5.0,,,10,1
ALS Vial : 0 (Sig #1); 31 (Sig #2)   Sample Multiplier: 1

Integration File signal 1: autoint1.e
Integration File signal 2: autoint2.e
Quant Time: Dec 21 09:24:09 2023
Quant Method : C:\msdchem\1\METHODS\2PCBLVI6015.M
Quant Title :
QLast Update : Thu Dec 21 09:21:59 2023
Response via : Initial Calibration
Integrator: ChemStation   6890 Scale Mode: Large solvent peaks clipped

Volume Inj.   : 1ul
Signal #1 Phase : ZBCLP-1   Signal #2 Phase: ZBCLP-2
Signal #1 Info : 30m X 0.32mm(.32u Signal #2 Info : 30m X 0.32 mm (.25um)

Min. RRF   :   0.000 Min. Rel. Area : 50% Max. R.T. Dev 0.50min
Max. RRF Dev : 20%   Max. Rel. Area : 150%

	Compound	AvgRF	CCRF	%Dev	Area%	Dev(Min)
7	AR1232-A	4.946	5.645 E6	-14.1	114	-0.02
8	AR1232-B	3.616	4.198 E6	-16.1	116	-0.01
9	AR1232-C	6.458	7.885 E6	-22.1#	122	-0.01
10	AR1232-D	2.416	2.916 E6	-20.7#	121	-0.01
11	AR1232-E	2.610	3.177 E6	-21.7#	122	-0.02

Signal #2

7	AR1232-A	7.786	8.848 E6	-13.6	114	-0.01
8	AR1232-B	6.502	7.704 E6	-18.5	118	-0.02
9	AR1232-C	13.936	15.140 E6	-8.6	109	-0.02
10	AR1232-D	5.116	6.121 E6	-19.6	120	-0.02
11	AR1232-E	3.876	4.701 E6	-21.3#	121	-0.03

(#) = Out of Range SPCC's out = 0 CCC's out = 0

2PCBLVI6015.M Thu Dec 21 09:24:34 2023

Continuing Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G2G6058-CC6015
Lab FileID: 2G231121.D

Evaluate Continuing Calibration Report

Signal #1 : C:\msdchem\1\data\an...8\2G231121.d\ECD1A.CH Vial: 0
Signal #2 : C:\msdchem\1\data\anndg\2G6058\2G231121.d\ECD2B.CH
Acq On : 10-Mar-24, 19:28:12 Operator: tilakp
Sample : cc6015-50 Inst : GC2G
Misc : op52994,G2G6058,5.0,,,10,1 Multiplr: 1.00
IntFile Signal #1: autoint1.e IntFile Signal #2: autoint2.e

Method : C:\msdchem\1\dat...LVI6015aupdate.M (ChemStation Integrator)
Title :
Last Update : Mon Mar 11 10:55:11 2024
Response via : Multiple Level Calibration

Min. RRF : 0.000 Min. Rel. Area : 50% Max. R.T. Dev 0.50min
Max. RRF Dev : 20% Max. Rel. Area : 150%

		Compound	AvgRF	CCRF	%Dev	Area%	Dev(min)	RT Window
1	S	Tetrachloro-m-xylene	290.165	300.127 E6	-3.4	106	0.00	4.67- 4.73
2		AR1221-A		----------NA----------				
3		AR1221-B		----------NA----------				
4		AR1221-C		----------NA----------				
5		AR1221-D		----------NA----------				
6		AR1221-E		----------NA----------				
7		AR1232-A		----------NA----------				
8		AR1232-B		----------NA----------				
9		AR1232-C		----------NA----------				
10		AR1232-D		----------NA----------				
11		AR1232-E		----------NA----------				
12		AR1242-A		----------NA----------				
13		AR1242-B		----------NA----------				
14		AR1242-C		----------NA----------				
15		AR1242-D		----------NA----------				
16		AR1242-E		----------NA----------				
17		AR1248-A		----------NA----------				
18		AR1248-B		----------NA----------				
19		AR1248-C		----------NA----------				
20		AR1248-D		----------NA----------				
21		AR1248-E		----------NA----------				
22		AR1248-F		----------NA----------				
23		AR1248-G		----------NA----------				
24		AR1254-A		----------NA----------				
25		AR1254-B		----------NA----------				
26		AR1254-C		----------NA----------				
27		AR1254-D		----------NA----------				
28		AR1254-E		----------NA----------				
29		AR1254-F		----------NA----------				
30		AR1254-G		----------NA----------				
31		AR1016-A	5.485	5.395 E6	1.6	100	0.00	4.96- 5.02
32		AR1016-B	9.949	9.522 E6	4.3	99	0.00	5.24- 5.30
33		AR1016-C	21.532	20.559 E6	4.5	96	0.00	5.61- 5.67
34		AR1016-D	8.052	8.201 E6	-1.9	104	0.00	5.73- 5.79
35		AR1016-E	9.345	7.688 E6	17.7	82	0.00	6.09- 6.15
36		AR1260-A	21.329	23.612 E6	-10.7	114	0.00	8.55- 8.61
37		AR1260-B	12.574	14.044 E6	-11.7	114	0.00	8.79- 8.85
38		AR1260-C	13.137	14.419 E6	-9.8	114	0.00	9.25- 9.31
39		AR1260-D	29.983	37.486 E6	-25.0#	128	0.00	9.74- 9.80
40		AR1260-E	29.818	34.696 E6	-16.4	121	0.00	10.07-10.23
41		AR1262-A		----------NA----------				

Continuing Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G2G6058-CC6015
Lab FileID: 2G231121.D

42		AR1262-B			----------NA----------				
43		AR1262-C			----------NA----------				
44		AR1262-D			----------NA----------				
45		AR1262-E			----------NA----------				
46		AR1268-A			----------NA----------				
47		AR1268-B			----------NA----------				
48		AR1268-C			----------NA----------				
49		AR1268-D			----------NA----------				
50		AR1268-E			----------NA----------				
51	S	Decachlorobiphenyl	213.773	235.905	E6 -10.4	113	0.00	11.30-11.36	
*****		Signal #2 *****							
1	S	Tetrachloro-m-xylene	536.119	546.475	E6 -1.9	120	0.00	5.18- 5.24	
2		AR1221-A			----------NA----------				
3		AR1221-B			----------NA----------				
4		AR1221-C			----------NA----------				
5		AR1221-D			----------NA----------				
6		AR1221-E			----------NA----------				
7		AR1232-A			----------NA----------				
8		AR1232-B			----------NA----------				
9		AR1232-C			----------NA----------				
10		AR1232-D			----------NA----------				
11		AR1232-E			----------NA----------				
12		AR1242-A			----------NA----------				
13		AR1242-B			----------NA----------				
14		AR1242-C			----------NA----------				
15		AR1242-D			----------NA----------				
16		AR1242-E			----------NA----------				
17		AR1248-A			----------NA----------				
18		AR1248-B			----------NA----------				
19		AR1248-C			----------NA----------				
20		AR1248-D			----------NA----------				
21		AR1248-E			----------NA----------				
22		AR1248-F			----------NA----------				
23		AR1248-G			----------NA----------				
24		AR1254-A			----------NA----------				
25		AR1254-B			----------NA----------				
26		AR1254-C			----------NA----------				
27		AR1254-D			----------NA----------				
28		AR1254-E			----------NA----------				
29		AR1254-F			----------NA----------				
30		AR1254-G			----------NA----------				
31		AR1016-A	7.563	8.454	E6 -11.8	114	0.00	5.64- 5.70	
32		AR1016-B	18.723	17.786	E6 5.0	100	0.00	6.03- 6.09	
33		AR1016-C	34.555	40.911	E6 -18.4	164#	0.00	6.54- 6.60	
34		AR1016-D	16.015	16.235	E6 -1.4	103	0.00	6.71- 6.77	
35		AR1016-E	13.632	13.197	E6 3.2	99	0.00	7.36- 7.42	
36		AR1260-A	39.304	43.373	E6 -10.4	118	0.00	10.43-10.49	
37		AR1260-B	27.915	30.409	E6 -8.9	119	0.00	10.53-10.59	
38		AR1260-C	21.967	19.643	E6 10.6	94	0.00	10.86-10.92	
39		AR1260-D	49.990	61.917	E6 -23.9#	138	0.00	11.10-11.16	
40		AR1260-E	48.858	53.056	E6 -8.6	115	0.00	11.46-11.52	
41		AR1262-A			----------NA----------				
42		AR1262-B			----------NA----------				
43		AR1262-C			----------NA----------				
44		AR1262-D			----------NA----------				
45		AR1262-E			----------NA----------				
46		AR1268-A			----------NA----------				
47		AR1268-B			----------NA----------				

Continuing Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G2G6058-CC6015
Lab FileID: 2G231121.D

48		AR1268-C				----------NA----------			
49		AR1268-D				----------NA----------			
50		AR1268-E				----------NA----------			
51	S	Decachlorobiphenyl	290.069	308.125	E6	-6.2	107	0.00	12.44-12.50

(#) = Out of Range SPCC's out = 0 CCC's out = 0
2G231099.d 2PCBLVI6015aupdate.M Mon Mar 11 13:07:03 2024

Continuing Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G2G6058-CC6015
Lab FileID: 2G231132.D

Evaluate Continuing Calibration Report

Data File : C:\msdchem\1\data\2G6058\2G231132.d\ECD1A.CH Vial: 0
Acq On : 10-Mar-24, 23:57:01 Operator: tilakp
Sample : cc6015-100 Inst : GC2G
Misc : op53022,G2G6058,5.0,,,10,1 Multiplr: 1.00
IntFile : autoint1.e

Data File : C:\msdchem\1\data\2G6058\2G231132.d\ECD2B.CH Vial: 83
Acq On : 10-Mar-24, 23:57:00 Operator: tilakp
Sample : cc6015-100 Inst : GC2G
Misc : op53022,G2G6058,5.0,,,10,1 Multiplr: 1.00
IntFile : autoint2.e

Method : C:\msdchem\1\dat...LVI6015aupdate.M (ChemStation Integrator)
Title :
Last Update : Mon Mar 11 10:55:11 2024
Response via : Multiple Level Calibration

Min. RRF : 0.000 Min. Rel. Area : 50% Max. R.T. Dev 0.50min
Max. RRF Dev : 20% Max. Rel. Area : 150%

		Compound	AvgRF	CCRF	%Dev	Area%	Dev(min)	RT Window
1	S	Tetrachloro-m-xylene	290.165	297.965 E6	-2.7	99	0.00	4.67- 4.73
2		AR1221-A		----------NA----------				
3		AR1221-B		----------NA----------				
4		AR1221-C		----------NA----------				
5		AR1221-D		----------NA----------				
6		AR1221-E		----------NA----------				
7		AR1232-A		----------NA----------				
8		AR1232-B		----------NA----------				
9		AR1232-C		----------NA----------				
10		AR1232-D		----------NA----------				
11		AR1232-E		----------NA----------				
12		AR1242-A		----------NA----------				
13		AR1242-B		----------NA----------				
14		AR1242-C		----------NA----------				
15		AR1242-D		----------NA----------				
16		AR1242-E		----------NA----------				
17		AR1248-A		----------NA----------				
18		AR1248-B		----------NA----------				
19		AR1248-C		----------NA----------				
20		AR1248-D		----------NA----------				
21		AR1248-E		----------NA----------				
22		AR1248-F		----------NA----------				
23		AR1248-G		----------NA----------				
24		AR1254-A		----------NA----------				
25		AR1254-B		----------NA----------				
26		AR1254-C		----------NA----------				
27		AR1254-D		----------NA----------				
28		AR1254-E		----------NA----------				
29		AR1254-F		----------NA----------				
30		AR1254-G		----------NA----------				
31		AR1016-A	5.485	5.070 E6	7.6	91	0.00	4.96- 5.02
32		AR1016-B	9.949	9.113 E6	8.4	91	0.00	5.24- 5.30
33		AR1016-C	21.532	20.018 E6	7.0	91	0.00	5.61- 5.67
34		AR1016-D	8.052	7.513 E6	6.7	96	0.00	5.73- 5.79
35		AR1016-E	9.345	7.623 E6	18.4	83	0.00	6.09- 6.15
36		AR1260-A	21.329	23.504 E6	-10.2	109	0.00	8.55- 8.61

Continuing Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G2G6058-CC6015
Lab FileID: 2G231132.D

37		AR1260-B	12.574	14.085	E6	-12.0	112	0.00	8.79- 8.85
38		AR1260-C	13.137	13.912	E6	-5.9	108	0.00	9.25- 9.31
39		AR1260-D	29.983	37.706	E6	-25.8#	125	0.00	9.74- 9.80
40		AR1260-E	29.818	34.308	E6	-15.1	119	0.00	10.07-10.23
41		AR1262-A	----------NA----------						
42		AR1262-B	----------NA----------						
43		AR1262-C	----------NA----------						
44		AR1262-D	----------NA----------						
45		AR1262-E	----------NA----------						
46		AR1268-A	----------NA----------						
47		AR1268-B	----------NA----------						
48		AR1268-C	----------NA----------						
49		AR1268-D	----------NA----------						
50		AR1268-E	----------NA----------						
51	S	Decachlorobiphenyl	213.773	233.656	E6	-9.3	111	0.00	11.30-11.36

***** Signal #2 *****

1	S	Tetrachloro-m-xylene	536.119	543.315	E6	-1.3	109	0.00	5.18- 5.24
2		AR1221-A	----------NA----------						
3		AR1221-B	----------NA----------						
4		AR1221-C	----------NA----------						
5		AR1221-D	----------NA----------						
6		AR1221-E	----------NA----------						
7		AR1232-A	----------NA----------						
8		AR1232-B	----------NA----------						
9		AR1232-C	----------NA----------						
10		AR1232-D	----------NA----------						
11		AR1232-E	----------NA----------						
12		AR1242-A	----------NA----------						
13		AR1242-B	----------NA----------						
14		AR1242-C	----------NA----------						
15		AR1242-D	----------NA----------						
16		AR1242-E	----------NA----------						
17		AR1248-A	----------NA----------						
18		AR1248-B	----------NA----------						
19		AR1248-C	----------NA----------						
20		AR1248-D	----------NA----------						
21		AR1248-E	----------NA----------						
22		AR1248-F	----------NA----------						
23		AR1248-G	----------NA----------						
24		AR1254-A	----------NA----------						
25		AR1254-B	----------NA----------						
26		AR1254-C	----------NA----------						
27		AR1254-D	----------NA----------						
28		AR1254-E	----------NA----------						
29		AR1254-F	----------NA----------						
30		AR1254-G	----------NA----------						
31		AR1016-A	7.563	8.026	E6	-6.1	101	0.00	5.63- 5.69
32		AR1016-B	18.723	17.240	E6	7.9	98	0.00	6.02- 6.08
33		AR1016-C	34.555	34.540	E6	0.0	93	-0.03	6.51- 6.57
34		AR1016-D	16.015	15.797	E6	1.4	98	0.00	6.70- 6.76
35		AR1016-E	13.632	13.215	E6	3.1	93	0.00	7.36- 7.42
36		AR1260-A	39.304	42.072	E6	-7.0	105	0.00	10.43-10.49
37		AR1260-B	27.915	30.140	E6	-8.0	104	0.00	10.52-10.58
38		AR1260-C	21.967	19.364	E6	11.8	82	0.00	10.86-10.92
39		AR1260-D	49.990	59.095	E6	-18.2	106	0.00	11.10-11.16
40		AR1260-E	48.858	51.489	E6	-5.4	108	0.00	11.46-11.52
41		AR1262-A	----------NA----------						
42		AR1262-B	----------NA----------						

Continuing Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G2G6058-CC6015
Lab FileID: 2G231132.D

43		AR1262-C			----------NA----------			
44		AR1262-D			----------NA----------			
45		AR1262-E			----------NA----------			
46		AR1268-A			----------NA----------			
47		AR1268-B			----------NA----------			
48		AR1268-C			----------NA----------			
49		AR1268-D			----------NA----------			
50		AR1268-E			----------NA----------			
51	S	Decachlorobiphenyl	290.069	322.919 E6	-11.3	113	0.00	12.44-12.50

(#) = Out of Range SPCC's out = 0 CCC's out = 0
2G229501.d 2PCBLVI6015aupdate.M Mon Mar 11 15:03:30 2024

7.9.11

7

Continuing Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G2G6058-CC6015
Lab FileID: 2G231143.D

Evaluate Continuing Calibration Report

```
Signal #1 : C:\msdchem\1\data\an...8\2G231143.d\ECD1A.CH Vial: 0
Signal #2 : C:\msdchem\1\data\anndg\2G6058\2G231143.d\ECD2B.CH
Acq On    : 11-Mar-24, 04:24:03                    Operator: tilakp
Sample    : cc6015-50                              Inst    : GC2G
Misc      : op53022,G2G6058,5.0,,,10,1             Multiplr: 1.00
IntFile Signal #1: autoint1.e   IntFile Signal #2: autoint2.e

Method       : C:\msdchem\1\dat...LVI6015aupdate.M (ChemStation Integrator)
Title        :
Last Update  : Mon Mar 11 10:55:11 2024
Response via : Multiple Level Calibration

Min. RRF     :   0.000  Min. Rel. Area :  50%  Max. R.T. Dev  0.50min
Max. RRF Dev :  20%     Max. Rel. Area : 150%
```

		Compound	AvgRF	CCRF	%Dev	Area%	Dev(min)	RT Window
1	S	Tetrachloro-m-xylene	290.165	298.253 E6	-2.8	106	0.00	4.67- 4.73
2		AR1221-A		----------NA----------				
3		AR1221-B		----------NA----------				
4		AR1221-C		----------NA----------				
5		AR1221-D		----------NA----------				
6		AR1221-E		----------NA----------				
7		AR1232-A		----------NA----------				
8		AR1232-B		----------NA----------				
9		AR1232-C		----------NA----------				
10		AR1232-D		----------NA----------				
11		AR1232-E		----------NA----------				
12		AR1242-A		----------NA----------				
13		AR1242-B		----------NA----------				
14		AR1242-C		----------NA----------				
15		AR1242-D		----------NA----------				
16		AR1242-E		----------NA----------				
17		AR1248-A		----------NA----------				
18		AR1248-B		----------NA----------				
19		AR1248-C		----------NA----------				
20		AR1248-D		----------NA----------				
21		AR1248-E		----------NA----------				
22		AR1248-F		----------NA----------				
23		AR1248-G		----------NA----------				
24		AR1254-A		----------NA----------				
25		AR1254-B		----------NA----------				
26		AR1254-C		----------NA----------				
27		AR1254-D		----------NA----------				
28		AR1254-E		----------NA----------				
29		AR1254-F		----------NA----------				
30		AR1254-G		----------NA----------				
31		AR1016-A	5.485	5.234 E6	4.6	97	0.00	4.96- 5.02
32		AR1016-B	9.949	9.459 E6	4.9	99	0.00	5.24- 5.30
33		AR1016-C	21.532	20.779 E6	3.5	97	0.00	5.61- 5.67
34		AR1016-D	8.052	7.736 E6	3.9	98	0.00	5.73- 5.79
35		AR1016-E	9.345	7.524 E6	19.5	80	0.00	6.09- 6.15
36		AR1260-A	21.329	23.486 E6	-10.1	114	0.00	8.55- 8.61
37		AR1260-B	12.574	14.145 E6	-12.5	115	-0.01	8.79- 8.85
38		AR1260-C	13.137	14.210 E6	-8.2	113	0.00	9.25- 9.31
39		AR1260-D	29.983	37.024 E6	-23.5#	126	0.00	9.74- 9.80
40		AR1260-E	29.818	35.340 E6	-18.5	123	0.00	10.07-10.23
41		AR1262-A		----------NA----------				

Continuing Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G2G6058-CC6015
Lab FileID: 2G231143.D

42		AR1262-B			----------NA----------				
43		AR1262-C			----------NA----------				
44		AR1262-D			----------NA----------				
45		AR1262-E			----------NA----------				
46		AR1268-A			----------NA----------				
47		AR1268-B			----------NA----------				
48		AR1268-C			----------NA----------				
49		AR1268-D			----------NA----------				
50		AR1268-E			----------NA----------				
51	S	Decachlorobiphenyl	213.773	244.129	E6 -14.2	117	0.00	11.30-11.36	
*****		Signal #2 *****							
1	S	Tetrachloro-m-xylene	536.119	537.454	E6 -0.2	118	0.00	5.18- 5.24	
2		AR1221-A			----------NA----------				
3		AR1221-B			----------NA----------				
4		AR1221-C			----------NA----------				
5		AR1221-D			----------NA----------				
6		AR1221-E			----------NA----------				
7		AR1232-A			----------NA----------				
8		AR1232-B			----------NA----------				
9		AR1232-C			----------NA----------				
10		AR1232-D			----------NA----------				
11		AR1232-E			----------NA----------				
12		AR1242-A			----------NA----------				
13		AR1242-B			----------NA----------				
14		AR1242-C			----------NA----------				
15		AR1242-D			----------NA----------				
16		AR1242-E			----------NA----------				
17		AR1248-A			----------NA----------				
18		AR1248-B			----------NA----------				
19		AR1248-C			----------NA----------				
20		AR1248-D			----------NA----------				
21		AR1248-E			----------NA----------				
22		AR1248-F			----------NA----------				
23		AR1248-G			----------NA----------				
24		AR1254-A			----------NA----------				
25		AR1254-B			----------NA----------				
26		AR1254-C			----------NA----------				
27		AR1254-D			----------NA----------				
28		AR1254-E			----------NA----------				
29		AR1254-F			----------NA----------				
30		AR1254-G			----------NA----------				
31		AR1016-A	7.563	8.322	E6 -10.0	112	0.00	5.63- 5.69	
32		AR1016-B	18.723	17.807	E6 4.9	101	0.00	6.02- 6.08	
33		AR1016-C	34.555	39.566	E6 -14.5	159#	0.00	6.54- 6.60	
34		AR1016-D	16.015	15.733	E6 1.8	100	0.00	6.70- 6.76	
35		AR1016-E	13.632	13.234	E6 2.9	99	0.00	7.36- 7.42	
36		AR1260-A	39.304	44.502	E6 -13.2	121	0.00	10.43-10.49	
37		AR1260-B	27.915	30.964	E6 -10.9	121	0.00	10.52-10.58	
38		AR1260-C	21.967	18.708	E6 14.8	90	0.00	10.86-10.92	
39		AR1260-D	49.990	63.279	E6 -26.6#	141	0.00	11.10-11.16	
40		AR1260-E	48.858	54.016	E6 -10.6	117	0.00	11.46-11.52	
41		AR1262-A			----------NA----------				
42		AR1262-B			----------NA----------				
43		AR1262-C			----------NA----------				
44		AR1262-D			----------NA----------				
45		AR1262-E			----------NA----------				
46		AR1268-A			----------NA----------				
47		AR1268-B			----------NA----------				

Continuing Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G2G6058-CC6015
Lab FileID: 2G231143.D

48		AR1268-C				----------NA----------			
49		AR1268-D				----------NA----------			
50		AR1268-E				----------NA----------			
51	S	Decachlorobiphenyl	290.069	340.950	E6	-17.5	118	0.00	12.44-12.50

(#) = Out of Range SPCC's out = 0 CCC's out = 0
2G231099.d 2PCBLVI6015aupdate.M Mon Mar 11 12:38:12 2024

Continuing Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G2G6058-CC6015
Lab FileID: 2G231154.D

Evaluate Continuing Calibration Report

Signal #1 : C:\msdchem\1\data\2G6058\2G231154.d\ECD1A.CH Vial: 0
Signal #2 : C:\msdchem\1\data\2G6058\2G231154.d\ECD2B.CH
Acq On : 11-Mar-24, 08:51:15 Operator: tilakp
Sample : cc6015-100 Inst : GC2G
Misc : op53022,G2G6058,5.0,,,10,1 Multiplr: 1.00
IntFile Signal #1: autoint1.e IntFile Signal #2: autoint2.e

Method : C:\msdchem\1\dat...LVI6015aupdate.M (ChemStation Integrator)
Title :
Last Update : Mon Mar 11 10:55:11 2024
Response via : Multiple Level Calibration

Min. RRF : 0.000 Min. Rel. Area : 50% Max. R.T. Dev 0.50min
Max. RRF Dev : 20% Max. Rel. Area : 150%

	Compound	AvgRF	CCRF	%Dev	Area%	Dev(min)	RT Window
1 S	Tetrachloro-m-xylene	290.165	286.477 E6	1.3	96	0.00	4.68- 4.74
2	AR1221-A		----------NA----------				
3	AR1221-B		----------NA----------				
4	AR1221-C		----------NA----------				
5	AR1221-D		----------NA----------				
6	AR1221-E		----------NA----------				
7	AR1232-A		----------NA----------				
8	AR1232-B		----------NA----------				
9	AR1232-C		----------NA----------				
10	AR1232-D		----------NA----------				
11	AR1232-E		----------NA----------				
12	AR1242-A		----------NA----------				
13	AR1242-B		----------NA----------				
14	AR1242-C		----------NA----------				
15	AR1242-D		----------NA----------				
16	AR1242-E		----------NA----------				
17	AR1248-A		----------NA----------				
18	AR1248-B		----------NA----------				
19	AR1248-C		----------NA----------				
20	AR1248-D		----------NA----------				
21	AR1248-E		----------NA----------				
22	AR1248-F		----------NA----------				
23	AR1248-G		----------NA----------				
24	AR1254-A		----------NA----------				
25	AR1254-B		----------NA----------				
26	AR1254-C		----------NA----------				
27	AR1254-D		----------NA----------				
28	AR1254-E		----------NA----------				
29	AR1254-F		----------NA----------				
30	AR1254-G		----------NA----------				
31	AR1016-A	5.485	4.842 E6	11.7	87	0.00	4.96- 5.02
32	AR1016-B	9.949	8.872 E6	10.8	89	0.00	5.24- 5.30
33	AR1016-C	21.532	19.030 E6	11.6	87	0.00	5.61- 5.67
34	AR1016-D	8.052	7.359 E6	8.6	94	0.00	5.73- 5.79
35	AR1016-E	9.345	7.240 E6	22.5#	79	0.00	6.09- 6.15
36	AR1260-A	21.329	22.181 E6	-4.0	103	0.00	8.55- 8.61
37	AR1260-B	12.574	13.240 E6	-5.3	105	0.00	8.79- 8.85
38	AR1260-C	13.137	13.329 E6	-1.5	103	0.00	9.25- 9.31
39	AR1260-D	29.983	33.928 E6	-13.2	112	0.00	9.74- 9.80
40	AR1260-E	29.818	30.093 E6	-0.9	105	0.00	10.07-10.23
41	AR1262-A		----------NA----------				

Continuing Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G2G6058-CC6015
Lab FileID: 2G231154.D

42		AR1262-B			----------NA----------				
43		AR1262-C			----------NA----------				
44		AR1262-D			----------NA----------				
45		AR1262-E			----------NA----------				
46		AR1268-A			----------NA----------				
47		AR1268-B			----------NA----------				
48		AR1268-C			----------NA----------				
49		AR1268-D			----------NA----------				
50		AR1268-E			----------NA----------				
51	S	Decachlorobiphenyl	213.773	213.202	E6	0.3	101	0.00	11.30-11.36
*****		Signal #2 *****							
1	S	Tetrachloro-m-xylene	536.119	526.367	E6	1.8	105	0.00	5.18- 5.24
2		AR1221-A			----------NA----------				
3		AR1221-B			----------NA----------				
4		AR1221-C			----------NA----------				
5		AR1221-D			----------NA----------				
6		AR1221-E			----------NA----------				
7		AR1232-A			----------NA----------				
8		AR1232-B			----------NA----------				
9		AR1232-C			----------NA----------				
10		AR1232-D			----------NA----------				
11		AR1232-E			----------NA----------				
12		AR1242-A			----------NA----------				
13		AR1242-B			----------NA----------				
14		AR1242-C			----------NA----------				
15		AR1242-D			----------NA----------				
16		AR1242-E			----------NA----------				
17		AR1248-A			----------NA----------				
18		AR1248-B			----------NA----------				
19		AR1248-C			----------NA----------				
20		AR1248-D			----------NA----------				
21		AR1248-E			----------NA----------				
22		AR1248-F			----------NA----------				
23		AR1248-G			----------NA----------				
24		AR1254-A			----------NA----------				
25		AR1254-B			----------NA----------				
26		AR1254-C			----------NA----------				
27		AR1254-D			----------NA----------				
28		AR1254-E			----------NA----------				
29		AR1254-F			----------NA----------				
30		AR1254-G			----------NA----------				
31		AR1016-A	7.563	7.580	E6	-0.2	95	0.00	5.64- 5.70
32		AR1016-B	18.723	16.010	E6	14.5	91	0.00	6.03- 6.09
33		AR1016-C	34.555	36.243	E6	-4.9	97	0.00	6.54- 6.60
34		AR1016-D	16.015	14.454	E6	9.7	90	0.00	6.70- 6.76
35		AR1016-E	13.632	12.215	E6	10.4	86	0.00	7.36- 7.42
36		AR1260-A	39.304	37.108	E6	5.6	93	0.00	10.43-10.49
37		AR1260-B	27.915	26.042	E6	6.7	90	0.00	10.53-10.58
38		AR1260-C	21.967	17.822	E6	18.9	75	0.00	10.86-10.92
39		AR1260-D	49.990	54.480	E6	-9.0	98	0.00	11.10-11.16
40		AR1260-E	48.858	46.764	E6	4.3	98	0.00	11.46-11.52
41		AR1262-A			----------NA----------				
42		AR1262-B			----------NA----------				
43		AR1262-C			----------NA----------				
44		AR1262-D			----------NA----------				
45		AR1262-E			----------NA----------				
46		AR1268-A			----------NA----------				
47		AR1268-B			----------NA----------				

Continuing Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G2G6058-CC6015
Lab FileID: 2G231154.D

48		AR1268-C				----------NA----------			
49		AR1268-D				----------NA----------			
50		AR1268-E				----------NA----------			
51	S	Decachlorobiphenyl	290.069	306.594	E6	-5.7	107	0.00	12.44-12.50

(#) = Out of Range SPCC's out = 0 CCC's out = 0
2G229501.d 2PCBLVI6015aupdate.M Mon Mar 11 14:21:14 2024

Continuing Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G2G6058-CC6015
Lab FileID: 2G231159.D

Evaluate Continuing Calibration Report

Signal #1 : C:\msdchem\1\data\2G6058\2G231159.d\ECD1A.CH Vial: 0
Signal #2 : C:\msdchem\1\data\2G6058\2G231159.d\ECD2B.CH
Acq On : 11-Mar-24, 10:53:51 Operator: tilakp
Sample : cc6015-50 Inst : GC2G
Misc : op53022,G2G6058,5.0,,,10,1 Multiplr: 1.00
IntFile Signal #1: autoint1.e IntFile Signal #2: autoint2.e

Method : C:\msdchem\1\dat...LVI6015aupdate.M (ChemStation Integrator)
Title :
Last Update : Mon Mar 11 10:55:11 2024
Response via : Multiple Level Calibration

Min. RRF : 0.000 Min. Rel. Area : 50% Max. R.T. Dev 0.50min
Max. RRF Dev : 20% Max. Rel. Area : 150%

	Compound	AvgRF	CCRF	%Dev	Area%	Dev(min)	RT Window
1 S	Tetrachloro-m-xylene	290.165	291.794 E6	-0.6	103	0.00	4.67- 4.73
2	AR1221-A		----------NA----------				
3	AR1221-B		----------NA----------				
4	AR1221-C		----------NA----------				
5	AR1221-D		----------NA----------				
6	AR1221-E		----------NA----------				
7	AR1232-A		----------NA----------				
8	AR1232-B		----------NA----------				
9	AR1232-C		----------NA----------				
10	AR1232-D		----------NA----------				
11	AR1232-E		----------NA----------				
12	AR1242-A		----------NA----------				
13	AR1242-B		----------NA----------				
14	AR1242-C		----------NA----------				
15	AR1242-D		----------NA----------				
16	AR1242-E		----------NA----------				
17	AR1248-A		----------NA----------				
18	AR1248-B		----------NA----------				
19	AR1248-C		----------NA----------				
20	AR1248-D		----------NA----------				
21	AR1248-E		----------NA----------				
22	AR1248-F		----------NA----------				
23	AR1248-G		----------NA----------				
24	AR1254-A		----------NA----------				
25	AR1254-B		----------NA----------				
26	AR1254-C		----------NA----------				
27	AR1254-D		----------NA----------				
28	AR1254-E		----------NA----------				
29	AR1254-F		----------NA----------				
30	AR1254-G		----------NA----------				
31	AR1016-A	5.485	5.075 E6	7.5	94	0.00	4.96- 5.02
32	AR1016-B	9.949	9.202 E6	7.5	96	0.00	5.24- 5.30
33	AR1016-C	21.532	19.891 E6	7.6	93	0.00	5.61- 5.67
34	AR1016-D	8.052	7.463 E6	7.3	95	0.00	5.73- 5.79
35	AR1016-E	9.345	7.245 E6	22.5#	77	0.00	6.08- 6.14
36	AR1260-A	21.329	23.294 E6	-9.2	113	-0.01	8.54- 8.60
37	AR1260-B	12.574	13.961 E6	-11.0	114	-0.01	8.79- 8.85
38	AR1260-C	13.137	13.924 E6	-6.0	111	0.00	9.25- 9.31
39	AR1260-D	29.983	36.003 E6	-20.1#	123	0.00	9.74- 9.80
40	AR1260-E	29.818	33.851 E6	-13.5	118	0.00	10.07-10.23
41	AR1262-A		----------NA----------				

Continuing Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G2G6058-CC6015
Lab FileID: 2G231159.D

42		AR1262-B			----------NA----------				
43		AR1262-C			----------NA----------				
44		AR1262-D			----------NA----------				
45		AR1262-E			----------NA----------				
46		AR1268-A			----------NA----------				
47		AR1268-B			----------NA----------				
48		AR1268-C			----------NA----------				
49		AR1268-D			----------NA----------				
50		AR1268-E			----------NA----------				
51	S	Decachlorobiphenyl	213.773	247.893	E6	-16.0	119	0.00	11.30-11.36
*****		Signal #2 *****							
1	S	Tetrachloro-m-xylene	536.119	535.979	E6	0.0	117	0.00	5.18- 5.24
2		AR1221-A			----------NA----------				
3		AR1221-B			----------NA----------				
4		AR1221-C			----------NA----------				
5		AR1221-D			----------NA----------				
6		AR1221-E			----------NA----------				
7		AR1232-A			----------NA----------				
8		AR1232-B			----------NA----------				
9		AR1232-C			----------NA----------				
10		AR1232-D			----------NA----------				
11		AR1232-E			----------NA----------				
12		AR1242-A			----------NA----------				
13		AR1242-B			----------NA----------				
14		AR1242-C			----------NA----------				
15		AR1242-D			----------NA----------				
16		AR1242-E			----------NA----------				
17		AR1248-A			----------NA----------				
18		AR1248-B			----------NA----------				
19		AR1248-C			----------NA----------				
20		AR1248-D			----------NA----------				
21		AR1248-E			----------NA----------				
22		AR1248-F			----------NA----------				
23		AR1248-G			----------NA----------				
24		AR1254-A			----------NA----------				
25		AR1254-B			----------NA----------				
26		AR1254-C			----------NA----------				
27		AR1254-D			----------NA----------				
28		AR1254-E			----------NA----------				
29		AR1254-F			----------NA----------				
30		AR1254-G			----------NA----------				
31		AR1016-A	7.563	8.128	E6	-7.5	110	0.00	5.63- 5.69
32		AR1016-B	18.723	17.398	E6	7.1	98	0.00	6.02- 6.08
33		AR1016-C	34.555	40.060	E6	-15.9	161#	0.00	6.53- 6.59
34		AR1016-D	16.015	15.720	E6	1.8	100	0.00	6.70- 6.76
35		AR1016-E	13.632	13.002	E6	4.6	97	0.00	7.36- 7.42
36		AR1260-A	39.304	40.566	E6	-3.2	111	0.00	10.43-10.49
37		AR1260-B	27.915	28.394	E6	-1.7	111	0.00	10.52-10.58
38		AR1260-C	21.967	18.102	E6	17.6	87	0.00	10.86-10.92
39		AR1260-D	49.990	58.021	E6	-16.1	129	0.00	11.10-11.16
40		AR1260-E	48.858	48.567	E6	0.6	106	0.00	11.46-11.52
41		AR1262-A			----------NA----------				
42		AR1262-B			----------NA----------				
43		AR1262-C			----------NA----------				
44		AR1262-D			----------NA----------				
45		AR1262-E			----------NA----------				
46		AR1268-A			----------NA----------				
47		AR1268-B			----------NA----------				

Continuing Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G2G6058-CC6015
Lab FileID: 2G231159.D

48		AR1268-C				----------NA----------			
49		AR1268-D				----------NA----------			
50		AR1268-E				----------NA----------			
51	S	Decachlorobiphenyl	290.069	325.264	E6	-12.1	113	0.00	12.43-12.49

(#) = Out of Range SPCC's out = 0 CCC's out = 0
2G229500.d 2PCBLVI6015aupdate.M Mon Mar 11 15:15:11 2024

Initial Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G4G4300-ICC4300
Lab FileID: 4G9736853.D

Response Factor Report GC4G

Method : C:\msdchem\1\methods\4PSTLVI4300A.M (ChemStation Integrator)
Title : PEST/PCB
Last Update : Thu Mar 07 23:30:55 2024
Response via : Initial Calibration

Calibration Files
2 =4g9736850.d 5 =4g9736851.d 10 =4g9736852.d 25 =4g9736853.d
50 =4g9736854.d 100 =4g9736856.d 75 =4g9736855.d =

Compound	2	5	10	25	50	100	75	Avg	%RSD
1) I 1-bromo-2-nitrobenzen	ISTD								
2) Tetrachloro-	1.073	1.056	1.030	0.992	0.969	0.932	0.938	0.998	5.60
3) hexachlorobe	1.316	1.315	1.269	1.246	1.215	1.151	1.161	1.239	5.41
4) alpha-BHC	1.668	1.797	1.800	1.803	1.771	1.696	1.702	1.748	3.30
5) gamma-BHC	1.493	1.534	1.545	1.519	1.520	1.459	1.472	1.506	2.14
6) Heptachlor	1.351	1.405	1.408	1.421	1.491	1.415	1.403	1.413	2.92
7) beta-BHC	0.719	0.707	0.697	0.685	0.709	0.683	0.681	0.697	2.15
8) delta-BHC	1.700	1.621	1.547	1.594	1.655	1.598	1.590	1.615	3.08
9) Aldrin	1.374	1.464	1.471	1.442	1.459	1.409	1.420	1.434	2.44
10) alachlor		0.246	0.232	0.226	0.243	0.228	0.228	0.234	3.57
11) Heptachlor E	1.320	1.358	1.370	1.350	1.355	1.256	1.305	1.331	3.00
12) gamma-Chlord	1.382	1.537	1.561	1.443	1.431	1.363	1.393	1.444	5.34
13) alpha-Chlord	1.374	1.387	1.395	1.370	1.367	1.290	1.301	1.355	3.09
14) Endosulfan I	1.329	1.374	1.432	1.456	1.437	1.324	1.340	1.385	4.06
15) 4,4'-DDE	1.196	1.269	1.321	1.335	1.334	1.249	1.254	1.280	4.09
16) Dieldrin	1.453	1.523	1.507	1.484	1.464	1.378	1.396	1.458	3.71
17) Endrin	1.274	1.297	1.313	1.263	1.250	1.196	1.212	1.258	3.38
18) 4,4'-DDD	1.141	1.158	1.211	1.188	1.182	1.124	1.134	1.163	2.76
19) Endosulfan I	1.292	1.258	1.340	1.312	1.261	1.182	1.200	1.264	4.53
20) 4,4'-DDT	0.809	0.830	0.922	0.980	1.042	1.055	1.054	0.956	10.94
21) Endrin Aldeh	1.057	0.982	0.964	0.902	0.875	0.862	0.864	0.929	7.96
22) Endosulfan S	1.141	1.153	1.153	1.160	1.161	1.117	1.125	1.144	1.53
23) Methoxychlor	0.572	0.568	0.594	0.571	0.596	0.589	0.591	0.583	2.05
24) Mirex	1.011	0.979	0.951	0.928	0.924	0.874	0.884	0.936	5.25
25) Endrin Keton	1.400	1.456	1.441	1.407	1.389	1.292	1.309	1.385	4.50
26) Decachlorobi	1.224	1.189	1.170	1.151	1.139	1.034	1.055	1.137	6.10
27) I 1-bromo-2-nitrobenzen	ISTD								
28) Toxaphene{A}				0.007				0.007	0.00
29) Toxaphene{B}				0.011				0.011	0.00
30) Toxaphene{C}				0.014				0.014	0.00
31) Toxaphene{D}				0.013				0.013	0.00
32) Toxaphene{E}				0.031				0.031	0.00
33) I 1-bromo-2-nitrobenzen	ISTD								
34) Chlordane {A				0.081				0.081	0.00
35) Chlordane {B				0.055				0.055	0.00
36) Chlordane {C				0.173				0.173	0.00
37) Chlordane {D				0.273				0.273	0.00
38) Chlordane {E				0.044				0.044	0.00

Signal #2

Compound	2	5	10	25	50	100	75	Avg	%RSD
1) I 1-bromo-2-nitrobenzen	ISTD								
2) Tetrachloro-	0.855	0.868	0.856	0.849	0.869	0.889	0.873	0.865	1.55

7.9.15

7

Initial Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G4G4300-ICC4300
Lab FileID: 4G9736853.D

3)	hexachlorobe	1.263	1.273	1.245	1.242	1.297	1.341	1.329	1.284	3.06
4)	alpha-BHC	1.341	1.438	1.514	1.581	1.658	1.756	1.715	1.572	9.58
5)	gamma-BHC	1.167	1.177	1.189	1.222	1.291	1.361	1.341	1.250	6.44
6)	Heptachlor	0.966	0.993	0.985	0.986	1.038	1.049	1.044	1.009	3.35
7)	beta-BHC	0.499	0.479	0.464	0.471	0.484	0.500	0.496	0.485	2.94
8)	delta-BHC	0.948	0.955	0.931	1.033	1.119	1.124	1.122	1.033	8.59
9)	Aldrin	1.242	1.053	0.976	0.930	0.976	0.990	0.983	1.021	10.16
10)	alachlor		0.150	0.133	0.121	0.119	0.110	0.112	0.124	12.32
11)	Heptachlor E	0.986	0.916	0.915	0.892	0.940	0.943	0.935	0.932	3.17
12)	gamma-Chlord	0.941	0.904	0.940	0.903	0.948	0.969	0.958	0.938	2.74
13)	alpha-Chlord	0.943	0.906	0.890	0.866	0.904	0.910	0.906	0.903	2.56
14)	Endosulfan I	1.118	0.941	0.896	0.850	0.878	0.872	0.876	0.919	10.03
15)	4,4'-DDE	0.935	0.913	0.907	0.894	0.915	0.916	0.936	0.917	1.62
16)	Dieldrin	1.053	0.977	0.970	0.956	1.001	1.016	1.015	0.998	3.34
17)	Endrin	0.934	0.869	0.890	0.834	0.861	0.884	0.879	0.879	3.48
18)	4,4'-DDD	0.814	0.787	0.816	0.777	0.814	0.824	0.817	0.807	2.17
19)	Endosulfan I	0.927	0.890	0.878	0.847	0.869	0.882	0.875	0.881	2.74
20)	4,4'-DDT	0.697	0.688	0.705	0.705	0.770	0.824	0.807	0.742	7.65
21)	Endrin Aldeh	0.774	0.700	0.622	0.616	0.610	0.598	0.589	0.644	10.52
22)	Endosulfan S	0.893	0.838	0.809	0.782	0.805	0.820	0.811	0.822	4.29
23)	Methoxychlor	0.450	0.406	0.412	0.381	0.399	0.402	0.396	0.407	5.30
24)	Mirex	0.785	0.681	0.635	0.575	0.579	0.585	0.580	0.631	12.40
25)	Endrin Keton	1.004	0.938	0.910	0.880	0.912	0.912	0.899	0.922	4.32
26)	Decachlorobi	0.819	0.743	0.723	0.689	0.690	0.708	0.695	0.724	6.40

27)	I 1-bromo-2-nitrobenzen	----------ISTD----------		
28)	Toxaphene{A}	0.008	0.008	0.00
29)	Toxaphene{B}	0.006	0.006	0.00
30)	Toxaphene{C}	0.010	0.010	0.00
31)	Toxaphene{D}	0.016	0.016	0.00
32)	Toxaphene{E}	0.022	0.022	0.00

33)	I 1-bromo-2-nitrobenzen	----------ISTD----------		
34)	Chlordane {A	0.055	0.055	0.00
35)	Chlordane {B	0.029	0.029	0.00
36)	Chlordane {C	0.110	0.110	0.00
37)	Chlordane {D	0.182	0.182	0.00
38)	Chlordane {E	0.029	0.029	0.00

(#) = Out of Range ### Number of calibration levels exceeded format ###

4PSTLVI4300A.M Thu Mar 07 23:32:33 2024

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G4G4300-ICV4300
Lab FileID: 4G9736859.D

Evaluate Continuing Calibration Report

```
Signal #1 : C:\msdchem\1\data\G4...\4g9736859.d\ECD1A.ch Vial: 21
Signal #2 : C:\msdchem\1\data\G4G4300\4g9736859.d\ECD2B.ch
Acq On    :  6 Mar 2024  12:18 pm                    Operator: rebeccak
Sample    : icv4300-2.5 (pest mix)                   Inst    : GC4G
Misc      : op52624,g4g4300,5.0,,,10,1               Multiplr: 1.00
IntFile Signal #1: autoint1.e   IntFile Signal #2: autoint2.e

Method       : C:\msdchem\1\met...\4PSTLVI4300AB.M (ChemStation Integrator)
Title        : PEST/PCB
Last Update  : Thu Mar 07 23:30:55 2024
Response via : Multiple Level Calibration

Min. RRF     :   0.000  Min. Rel. Area :  50%  Max. R.T. Dev  0.50min
Max. RRF Dev :  20%     Max. Rel. Area : 150%
```

		Compound	AvgRF	CCRF	%Dev	Area%	Dev(min)	RT Window
1	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	105	0.00	4.37- 5.37
2	SAB	Tetrachloro-m-xylene	0.998	1.021	-2.3	108	0.00	5.51- 5.57
3		hexachlorobenzene	1.239	1.399	-12.9	118	0.00	5.87- 5.93
4	A	alpha-BHC	1.748	1.758	-0.6	103	0.00	6.02- 6.08
5	MA	gamma-BHC	1.506	1.510	-0.3	105	0.00	6.34- 6.40
6	MA	Heptachlor	1.413	1.465	-3.7	108	0.00	6.85- 6.91
7	B	beta-BHC	0.697	0.674	3.3	104	0.00	6.44- 6.50
8	B	delta-BHC	1.615	1.607	0.5	106	0.00	6.63- 6.69
9	MB	Aldrin	1.434	1.462	-2.0	107	0.00	7.20- 7.26
10		alachlor	0.234	0.205	12.4	95	0.00	7.36- 7.42
11	B	Heptachlor Epoxide	1.331	1.320	0.8	103	0.00	7.93- 7.99
12	B	gamma-Chlordane	1.444	1.431	0.9	104	0.00	8.10- 8.16
13	B	alpha-Chlordane	1.355	1.343	0.9	103	0.00	8.27- 8.33
14	A	Endosulfan I	1.385	1.328	4.1	96	0.00	8.46- 8.52
15	B	4,4'-DDE	1.280	1.317	-2.9	104	0.00	8.39- 8.45
16	MA	Dieldrin	1.458	1.445	0.9	102	0.00	8.78- 8.84
17	MA	Endrin	1.258	1.287	-2.3	107	0.00	9.11- 9.17
18	A	4,4'-DDD	1.163	1.138	2.1	101	0.00	9.24- 9.30
19	B	Endosulfan II	1.264	1.239	2.0	99	0.00	9.44- 9.50
20	MA	4,4'-DDT	0.956	0.980	-2.5	105	0.00	9.66- 9.72
21	B	Endrin Aldehyde	0.929	1.018	-9.6	119	0.00	10.07-10.13
22	B	Endosulfan Sulfate	1.144	1.140	0.3	103	0.00	10.76-10.82
23	A	Methoxychlor	0.583	0.566	2.9	104	0.00	10.44-10.50
24		Mirex	0.936	1.040	-11.1	118	0.00	10.59-10.65
25	B	Endrin Ketone	1.385	1.384	0.1	103	0.00	11.20-11.26
26	SA	Decachlorobiphenyl	1.137	1.145	-0.7	105	0.00	12.98-13.04
27	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	105	0.00	4.37- 5.37
28	L8	Toxaphene{A}		----------NA----------				
29	L8	Toxaphene{B}		----------NA----------				
30	L8	Toxaphene{C}		----------NA----------				
31	L8	Toxaphene{D}		----------NA----------				
32	L8	Toxaphene{E}		----------NA----------				
33	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	105	0.00	4.37- 5.37
34		Chlordane {A}		----------NA----------				
35		Chlordane {B}		----------NA----------				
36		Chlordane {C}		----------NA----------				
37		Chlordane {D}		----------NA----------				
38		Chlordane {E}		----------NA----------				

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G4G4300-ICV4300
Lab FileID: 4G9736859.D

***** Signal #2 *****

1	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	109	0.00	4.74- 5.74
2	SAB	Tetrachloro-m-xylene	0.865	0.859	0.7	110	0.00	6.14- 6.20
3		hexachlorobenzene	1.284	1.375	-7.1	120	0.00	6.70- 6.76
4	A	alpha-BHC	1.572	1.463	6.9	101	0.00	6.87- 6.93
5	MA	gamma-BHC	1.250	1.180	5.6	105	0.00	7.33- 7.39
6	MA	Heptachlor	1.009	0.956	5.3	105	0.00	7.95- 8.01
7	B	beta-BHC	0.485	0.456	6.0	105	0.00	7.43- 7.49
8	B	delta-BHC	1.033	1.023	1.0	108	0.00	7.85- 7.91
9	MB	Aldrin	1.021	0.914	10.5	107	0.00	8.43- 8.49
10		alachlor	0.124	0.117	5.6	105	0.00	8.22- 8.28
11	B	Heptachlor Epoxide	0.932	0.874	6.2	106	0.00	9.28- 9.34
12	B	gamma-Chlordane	0.938	0.894	4.7	108	0.00	9.58- 9.64
13	B	alpha-Chlordane	0.903	0.858	5.0	108	0.00	9.81- 9.87
14	A	Endosulfan I	0.919	0.814	11.4	104	0.00	9.91- 9.97
15	B	4,4'-DDE	0.917	0.869	5.2	106	0.00	10.07-10.13
16	MA	Dieldrin	0.998	0.939	5.9	107	0.00	10.36-10.42
17	MA	Endrin	0.879	0.835	5.0	109	0.00	10.88-10.94
18	A	4,4'-DDD	0.807	0.764	5.3	107	0.00	11.05-11.11
19	B	Endosulfan II	0.881	0.825	6.4	106	0.00	11.23-11.29
20	MA	4,4'-DDT	0.742	0.701	5.5	108	0.00	11.59-11.65
21	B	Endrin Aldehyde	0.644	0.646	-0.3	114	0.00	11.81-11.87
22	B	Endosulfan Sulfate	0.822	0.773	6.0	107	0.00	12.29-12.35
23	A	Methoxychlor	0.407	0.380	6.6	108	0.00	12.83-12.89
24		Mirex	0.631	0.657	-4.1	124	0.00	13.16-13.22
25	B	Endrin Ketone	0.922	0.860	6.7	106	0.00	13.21-13.27
26	SA	Decachlorobiphenyl	0.724	0.692	4.4	109	0.00	14.77-14.83
27	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	109	0.00	4.74- 5.74
28	L8	Toxaphene{A}	----------NA----------					
29	L8	Toxaphene{B}	----------NA----------					
30	L8	Toxaphene{C}	----------NA----------					
31	L8	Toxaphene{D}	----------NA----------					
32	L8	Toxaphene{E}	----------NA----------					
33	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	109	0.00	4.74- 5.74
34		Chlordane {A}	----------NA----------					
35		Chlordane {B}	----------NA----------					
36		Chlordane {C}	----------NA----------					
37		Chlordane {D}	----------NA----------					
38		Chlordane {E}	----------NA----------					

(#) = Out of Range SPCC's out = 0 CCC's out = 0
4g9736853.d 4PSTLVI4300AB.M Thu Mar 07 23:34:56 2024

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G4G4300-ICV4300
Lab FileID: 4G9736860.D

Evaluate Continuing Calibration Report

```
Signal #1 : C:\msdchem\1\data\G4...\4g9736860.d\ECD1A.ch Vial: 22
Signal #2 : C:\msdchem\1\data\G4G4300\4g9736860.d\ECD2B.ch
Acq On    :  6 Mar 2024  12:37 pm                    Operator: rebeccak
Sample    : icv4300-50 (chlordane)                   Inst    : GC4G
Misc      : op52624,g4g4300,5.0,,,10,1               Multiplr: 1.00
IntFile Signal #1: autoint1.e   IntFile Signal #2: autoint2.e

Method       : C:\msdchem\1\methods\4PSTLVI4300A.M (ChemStation Integrator)
Title        : PEST/PCB
Last Update  : Wed Mar 06 15:10:55 2024
Response via : Multiple Level Calibration

Min. RRF     :   0.000  Min. Rel. Area :  50%  Max. R.T. Dev  0.50min
Max. RRF Dev :  20%     Max. Rel. Area : 150%
```

		Compound	AvgRF	CCRF	%Dev	Area%	Dev(min)	RT Window
1	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	104	0.00	4.37- 5.37
2	SAB	Tetrachloro-m-xylene	0.998	0.977	2.1	105	0.00	5.51- 5.57
3		hexachlorobenzene		----------NA----------				
4	A	alpha-BHC		----------NA----------				
5	MA	gamma-BHC		----------NA----------				
6	MA	Heptachlor		----------NA----------				
7	B	beta-BHC		----------NA----------				
8	B	delta-BHC		----------NA----------				
9	MB	Aldrin		----------NA----------				
10		alachlor		----------NA----------				
11	B	Heptachlor Epoxide		----------NA----------				
12	B	gamma-Chlordane		----------NA----------				
13	B	alpha-Chlordane		----------NA----------				
14	A	Endosulfan I		----------NA----------				
15	B	4,4'-DDE		----------NA----------				
16	MA	Dieldrin		----------NA----------				
17	MA	Endrin		----------NA----------				
18	A	4,4'-DDD		----------NA----------				
19	B	Endosulfan II		----------NA----------				
20	MA	4,4'-DDT		----------NA----------				
21	B	Endrin Aldehyde		----------NA----------				
22	B	Endosulfan Sulfate		----------NA----------				
23	A	Methoxychlor		----------NA----------				
24		Mirex		----------NA----------				
25	B	Endrin Ketone		----------NA----------				
26	SA	Decachlorobiphenyl	1.137	1.086	4.5	99	0.00	12.98-13.04
27	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	99	0.00	4.37- 5.37
28	L8	Toxaphene{A}		----------NA----------				
29	L8	Toxaphene{B}		----------NA----------				
30	L8	Toxaphene{C}		----------NA----------				
31	L8	Toxaphene{D}		----------NA----------				
32	L8	Toxaphene{E}		----------NA----------				
33	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	98	0.00	4.37- 5.37
34		Chlordane {A}	0.081	0.074	8.6	89	0.00	6.78- 6.98
35		Chlordane {B}	0.055	0.047	14.5	84	0.00	7.28- 7.48
36		Chlordane {C}	0.173	0.159	8.1	90	0.00	8.03- 8.23
37		Chlordane {D}	0.273	0.250	8.4	90	0.00	8.20- 8.40
38		Chlordane {E}	0.044	0.040	9.1	90	0.00	9.27- 9.47

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G4G4300-ICV4300
Lab FileID: 4G9736860.D

***** Signal #2 *****

1	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	106	0.00	4.74- 5.74
2	SAB	Tetrachloro-m-xylene	0.865	0.833	3.7	101	0.00	6.14- 6.20
3		hexachlorobenzene		----------NA----------				
4	A	alpha-BHC		----------NA----------				
5	MA	gamma-BHC		----------NA----------				
6	MA	Heptachlor		----------NA----------				
7	B	beta-BHC		----------NA----------				
8	B	delta-BHC		----------NA----------				
9	MB	Aldrin		----------NA----------				
10		alachlor		----------NA----------				
11	B	Heptachlor Epoxide		----------NA----------				
12	B	gamma-Chlordane		----------NA----------				
13	B	alpha-Chlordane		----------NA----------				
14	A	Endosulfan I		----------NA----------				
15	B	4,4'-DDE		----------NA----------				
16	MA	Dieldrin		----------NA----------				
17	MA	Endrin		----------NA----------				
18	A	4,4'-DDD		----------NA----------				
19	B	Endosulfan II		----------NA----------				
20	MA	4,4'-DDT		----------NA----------				
21	B	Endrin Aldehyde		----------NA----------				
22	B	Endosulfan Sulfate		----------NA----------				
23	A	Methoxychlor		----------NA----------				
24		Mirex		----------NA----------				
25	B	Endrin Ketone		----------NA----------				
26	SA	Decachlorobiphenyl	0.724	0.675	6.8	103	0.00	14.77-14.83
27	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	99	0.00	4.74- 5.74
28	L8	Toxaphene{A}		----------NA----------				
29	L8	Toxaphene{B}		----------NA----------				
30	L8	Toxaphene{C}		----------NA----------				
31	L8	Toxaphene{D}		----------NA----------				
32	L8	Toxaphene{E}		----------NA----------				
33	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	99	0.00	4.74- 5.74
34		Chlordane {A}	0.055	0.048	12.7	86	0.00	7.88- 8.08
35		Chlordane {B}	0.029	0.027	6.9	91	0.00	8.56- 8.76
36		Chlordane {C}	0.110	0.098	10.9	88	0.00	9.51- 9.71
37		Chlordane {D}	0.182	0.167	8.2	91	0.00	9.74- 9.94
38		Chlordane {E}	0.029	0.027	6.9	92	0.00	11.25-11.45

(#) = Out of Range SPCC's out = 0 CCC's out = 0
4g9736854.d 4PSTLVI4300A.M Wed Mar 06 15:18:16 2024

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G4G4300-ICV4300
Lab FileID: 4G9736861.D

Evaluate Continuing Calibration Report

```
Signal #1 : C:\msdchem\1\data\G4...\4g9736861.d\ECD1A.ch Vial: 23
Signal #2 : C:\msdchem\1\data\G4G4300\4g9736861.d\ECD2B.ch
Acq On    :  6 Mar 2024  12:56 pm                    Operator: rebeccak
Sample    : icv4300-50 (toxaphene)                   Inst    : GC4G
Misc      : op52624,g4g4300,5.0,,,10,1               Multiplr: 1.00
IntFile Signal #1: autoint1.e   IntFile Signal #2: autoint2.e

Method       : C:\msdchem\1\methods\4PSTLVI4300A.M (ChemStation Integrator)
Title        : PEST/PCB
Last Update  : Wed Mar 06 15:10:55 2024
Response via : Multiple Level Calibration

Min. RRF     :   0.000  Min. Rel. Area :  50%  Max. R.T. Dev  0.50min
Max. RRF Dev :  20%     Max. Rel. Area : 150%
```

		Compound	AvgRF	CCRF	%Dev	Area%	Dev(min)	RT Window
1	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	104	0.00	4.37- 5.37
2	SAB	Tetrachloro-m-xylene	0.998	0.979	1.9	105	0.00	5.51- 5.57
3		hexachlorobenzene		----------NA----------				
4	A	alpha-BHC		----------NA----------				
5	MA	gamma-BHC		----------NA----------				
6	MA	Heptachlor		----------NA----------				
7	B	beta-BHC		----------NA----------				
8	B	delta-BHC		----------NA----------				
9	MB	Aldrin		----------NA----------				
10		alachlor		----------NA----------				
11	B	Heptachlor Epoxide		----------NA----------				
12	B	gamma-Chlordane		----------NA----------				
13	B	alpha-Chlordane		----------NA----------				
14	A	Endosulfan I		----------NA----------				
15	B	4,4'-DDE		----------NA----------				
16	MA	Dieldrin		----------NA----------				
17	MA	Endrin		----------NA----------				
18	A	4,4'-DDD		----------NA----------				
19	B	Endosulfan II		----------NA----------				
20	MA	4,4'-DDT		----------NA----------				
21	B	Endrin Aldehyde		----------NA----------				
22	B	Endosulfan Sulfate		----------NA----------				
23	A	Methoxychlor		----------NA----------				
24		Mirex		----------NA----------				
25	B	Endrin Ketone		----------NA----------				
26	SA	Decachlorobiphenyl	1.137	1.116	1.8	102	0.00	12.98-13.04
27	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	99	0.00	4.37- 5.37
28	L8	Toxaphene{A}	0.007	0.007	0.0	101	-0.02	8.17- 8.37
29	L8	Toxaphene{B}	0.011	0.017	-54.5#	149	0.00	9.88-10.08
30	L8	Toxaphene{C}	0.014	0.014	0.0	100	0.00	10.21-10.41
31	L8	Toxaphene{D}	0.013	0.013	0.0	104	0.00	10.38-10.58
32	L8	Toxaphene{E}	0.031	0.027	12.9	86	0.00	10.53-10.73
33	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	99	0.00	4.37- 5.37
34		Chlordane {A}		----------NA----------				
35		Chlordane {B}		----------NA----------				
36		Chlordane {C}		----------NA----------				
37		Chlordane {D}		----------NA----------				
38		Chlordane {E}		----------NA----------				

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G4G4300-ICV4300
Lab FileID: 4G9736861.D

***** Signal #2 *****

1	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	105	0.00	4.74- 5.74
2	SAB	Tetrachloro-m-xylene	0.865	0.900	-4.0	109	0.00	6.14- 6.20
3		hexachlorobenzene		----------NA----------				
4	A	alpha-BHC		----------NA----------				
5	MA	gamma-BHC		----------NA----------				
6	MA	Heptachlor		----------NA----------				
7	B	beta-BHC		----------NA----------				
8	B	delta-BHC		----------NA----------				
9	MB	Aldrin		----------NA----------				
10		alachlor		----------NA----------				
11	B	Heptachlor Epoxide		----------NA----------				
12	B	gamma-Chlordane		----------NA----------				
13	B	alpha-Chlordane		----------NA----------				
14	A	Endosulfan I		----------NA----------				
15	B	4,4'-DDE		----------NA----------				
16	MA	Dieldrin		----------NA----------				
17	MA	Endrin		----------NA----------				
18	A	4,4'-DDD		----------NA----------				
19	B	Endosulfan II		----------NA----------				
20	MA	4,4'-DDT		----------NA----------				
21	B	Endrin Aldehyde		----------NA----------				
22	B	Endosulfan Sulfate		----------NA----------				
23	A	Methoxychlor		----------NA----------				
24		Mirex		----------NA----------				
25	B	Endrin Ketone		----------NA----------				
26	SA	Decachlorobiphenyl	0.724	0.699	3.5	106	0.00	14.77-14.83
27	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	98	0.00	4.74- 5.74
28	L8	Toxaphene{A}	0.008	0.008	0.0	93	0.00	10.26-10.46
29	L8	Toxaphene{B}	0.006	0.006	0.0	98	0.00	11.44-11.64
30	L8	Toxaphene{C}	0.010	0.011	-10.0	105	0.00	11.62-11.82
31	L8	Toxaphene{D}	0.016	0.016	0.0	99	0.00	11.74-11.94
32	L8	Toxaphene{E}	0.022	0.021	4.5	93	0.00	12.66-12.86
33	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	99	0.00	4.74- 5.74
34		Chlordane {A}		----------NA----------				
35		Chlordane {B}		----------NA----------				
36		Chlordane {C}		----------NA----------				
37		Chlordane {D}		----------NA----------				
38		Chlordane {E}		----------NA----------				

(#) = Out of Range SPCC's out = 0 CCC's out = 0
4g9736854.d 4PSTLVI4300A.M Wed Mar 06 15:18:28 2024

Continuing Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G4G4306-CC4300
Lab FileID: 4G9737016.D

Evaluate Continuing Calibration Report

```
Signal #1 : C:\msdchem\1\data\ni...\4g9737016.d\ECD1A.ch Vial: 2
Signal #2 : C:\msdchem\1\data\nicks\...4306\4g9737016.d\ECD2B.ch
Acq On    : 11 Mar 2024  12:14 am                    Operator: christp
Sample    : cc4300-2.5                               Inst    : GC4G
Misc      : op52882,g4g4306,5.0,,,10,1               Multiplr: 1.00
IntFile Signal #1: autoint1.e   IntFile Signal #2: autoint2.e

Method       : C:\msdchem\1\dat...\4PSTLVI4300AB.M (ChemStation Integrator)
Title        : PEST/PCB
Last Update  : Mon Mar 11 13:03:38 2024
Response via : Multiple Level Calibration

Min. RRF     :   0.000  Min. Rel. Area :  50%  Max. R.T. Dev  0.50min
Max. RRF Dev :  20%     Max. Rel. Area : 150%
```

		Compound	AvgRF	CCRF	%Dev	Area%	Dev(min)	RT Window
1	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	108	0.00	4.36- 5.36
2	SAB	Tetrachloro-m-xylene	0.998	0.936	6.2	102	0.00	5.51- 5.57
3		hexachlorobenzene	1.239	1.200	3.1	104	0.00	5.86- 5.92
4	A	alpha-BHC	1.748	1.757	-0.5	105	0.00	6.02- 6.08
5	MA	gamma-BHC	1.506	1.501	0.3	106	0.00	6.33- 6.39
6	MA	Heptachlor	1.413	1.388	1.8	105	0.00	6.84- 6.90
7	B	beta-BHC	0.697	0.656	5.9	103	0.00	6.44- 6.50
8	B	delta-BHC	1.615	1.504	6.9	102	0.00	6.63- 6.69
9	MB	Aldrin	1.434	1.426	0.6	106	0.00	7.19- 7.25
10		alachlor	0.234	0.223	4.7	106	0.00	7.35- 7.41
11	B	Heptachlor Epoxide	1.331	1.318	1.0	105	0.00	7.93- 7.99
12	B	gamma-Chlordane	1.444	1.395	3.4	104	0.00	8.09- 8.15
13	B	alpha-Chlordane	1.355	1.327	2.1	104	0.00	8.27- 8.33
14	A	Endosulfan I	1.385	1.414	-2.1	105	0.00	8.45- 8.51
15	B	4,4'-DDE	1.280	1.242	3.0	100	0.00	8.39- 8.45
16	MA	Dieldrin	1.458	1.413	3.1	102	0.00	8.77- 8.83
17	MA	Endrin	1.258	1.212	3.7	103	0.00	9.10- 9.16
18	A	4,4'-DDD	1.163	1.160	0.3	105	0.00	9.24- 9.30
19	B	Endosulfan II	1.264	1.219	3.6	100	0.00	9.43- 9.49
20	MA	4,4'-DDT	0.956	0.854	10.7	94	0.00	9.65- 9.71
21	B	Endrin Aldehyde	0.929	0.883	5.0	105	0.00	10.06-10.12
22	B	Endosulfan Sulfate	1.144	1.104	3.5	102	0.00	10.76-10.82
23	A	Methoxychlor	0.583	0.503	13.7	95	0.00	10.44-10.50
24		Mirex	0.936	0.877	6.3	102	0.00	10.59-10.65
25	B	Endrin Ketone	1.385	1.367	1.3	105	0.00	11.20-11.26
26	SA	Decachlorobiphenyl	1.137	1.084	4.7	101	0.00	12.97-13.03
27	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	108	0.00	4.36- 5.36
28	L8	Toxaphene{A}		----------NA----------				
29	L8	Toxaphene{B}		----------NA----------				
30	L8	Toxaphene{C}		----------NA----------				
31	L8	Toxaphene{D}		----------NA----------				
32	L8	Toxaphene{E}		----------NA----------				
33	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	108	0.00	4.36- 5.36
34		Chlordane {A}		----------NA----------				
35		Chlordane {B}		----------NA----------				
36		Chlordane {C}		----------NA----------				
37		Chlordane {D}		----------NA----------				
38		Chlordane {E}		----------NA----------				

Continuing Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G4G4306-CC4300
Lab FileID: 4G9737016.D

***** Signal #2 *****

1	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	111	0.00	4.73- 5.73
2	SAB	Tetrachloro-m-xylene	0.865	0.882	-2.0	116	0.00	6.13- 6.19
3		hexachlorobenzene	1.284	1.271	1.0	114	0.00	6.69- 6.75
4	A	alpha-BHC	1.572	1.636	-4.1	115	0.00	6.86- 6.92
5	MA	gamma-BHC	1.250	1.224	2.1	112	0.00	7.32- 7.38
6	MA	Heptachlor	1.009	1.004	0.5	113	0.00	7.94- 8.00
7	B	beta-BHC	0.485	0.479	1.2	113	0.00	7.43- 7.49
8	B	delta-BHC	1.033	0.996	3.6	107	0.00	7.85- 7.91
9	MB	Aldrin	1.021	0.933	8.6	112	0.00	8.42- 8.48
10		alachlor	0.124	0.113	8.9	104	0.00	8.21- 8.27
11	B	Heptachlor Epoxide	0.932	0.886	4.9	111	0.00	9.27- 9.33
12	B	gamma-Chlordane	0.938	0.890	5.1	110	0.00	9.57- 9.63
13	B	alpha-Chlordane	0.903	0.855	5.3	110	0.00	9.80- 9.86
14	A	Endosulfan I	0.919	0.825	10.2	108	0.00	9.90- 9.96
15	B	4,4'-DDE	0.917	0.866	5.6	108	0.00	10.07-10.13
16	MA	Dieldrin	0.998	0.941	5.7	110	0.00	10.35-10.41
17	MA	Endrin	0.879	0.826	6.0	110	0.00	10.87-10.93
18	A	4,4'-DDD	0.807	0.789	2.2	113	0.00	11.04-11.10
19	B	Endosulfan II	0.881	0.840	4.7	110	0.00	11.23-11.29
20	MA	4,4'-DDT	0.742	0.675	9.0	107	0.00	11.58-11.64
21	B	Endrin Aldehyde	0.644	0.565	12.3	102	0.00	11.81-11.87
22	B	Endosulfan Sulfate	0.822	0.748	9.0	107	0.00	12.28-12.34
23	A	Methoxychlor	0.407	0.361	11.3	106	0.00	12.82-12.88
24		Mirex	0.631	0.559	11.4	108	0.00	13.15-13.21
25	B	Endrin Ketone	0.922	0.845	8.4	107	0.00	13.20-13.26
26	SA	Decachlorobiphenyl	0.724	0.596	17.7	96	0.00	14.76-14.82
27	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	111	0.00	4.73- 5.73
28	L8	Toxaphene{A}		----------NA----------				
29	L8	Toxaphene{B}		----------NA----------				
30	L8	Toxaphene{C}		----------NA----------				
31	L8	Toxaphene{D}		----------NA----------				
32	L8	Toxaphene{E}		----------NA----------				
33	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	111	0.00	4.73- 5.73
34		Chlordane {A}		----------NA----------				
35		Chlordane {B}		----------NA----------				
36		Chlordane {C}		----------NA----------				
37		Chlordane {D}		----------NA----------				
38		Chlordane {E}		----------NA----------				

(#) = Out of Range SPCC's out = 0 CCC's out = 0
4g9736853.d 4PSTLVI4300AB.M Mon Mar 11 13:04:20 2024

Continuing Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G4G4307-CC4300
Lab FileID: 4G9737041.D

Evaluate Continuing Calibration Report

```
Signal #1 : C:\msdchem\1\data\na...\4g9737041.d\ECD1A.ch Vial: 4
Signal #2 : C:\msdchem\1\data\nazary...4307\4g9737041.d\ECD2B.ch
Acq On    : 11 Mar 2024  11:19 am                    Operator: rebeccak
Sample    : cc4300-5                                 Inst    : GC4G
Misc      : op53021,g4g4307,5.5,,,10,1               Multiplr: 1.00
IntFile Signal #1: autoint1.e   IntFile Signal #2: autoint2.e

Method       : C:\msdchem\1\dat...\4PSTLVI4300AB.M (ChemStation Integrator)
Title        : PEST/PCB
Last Update  : Tue Mar 12 00:33:26 2024
Response via : Multiple Level Calibration

Min. RRF     :   0.000  Min. Rel. Area :  50%  Max. R.T. Dev  0.50min
Max. RRF Dev :  20%     Max. Rel. Area : 150%
```

		Compound	AvgRF	CCRF	%Dev	Area%	Dev(min)	RT Window
1	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	100	0.00	4.36- 5.36
2	SAB	Tetrachloro-m-xylene	0.998	0.931	6.7	96	0.00	5.50- 5.56
3		hexachlorobenzene	1.239	1.146	7.5	94	0.00	5.86- 5.92
4	A	alpha-BHC	1.748	1.691	3.3	96	0.00	6.02- 6.08
5	MA	gamma-BHC	1.506	1.439	4.4	95	0.00	6.33- 6.39
6	MA	Heptachlor	1.413	1.416	-0.2	95	0.00	6.84- 6.90
7	B	beta-BHC	0.697	0.637	8.6	90	0.00	6.43- 6.49
8	B	delta-BHC	1.615	1.443	10.7	87	0.00	6.62- 6.68
9	MB	Aldrin	1.434	1.379	3.8	95	0.00	7.19- 7.25
10		alachlor	0.234	0.204	12.8	84	0.00	7.35- 7.41
11	B	Heptachlor Epoxide	1.331	1.182	11.2	87	0.00	7.93- 7.99
12	B	gamma-Chlordane	1.444	1.331	7.8	93	0.00	8.09- 8.15
13	B	alpha-Chlordane	1.355	1.267	6.5	93	0.00	8.26- 8.32
14	A	Endosulfan I	1.385	1.335	3.6	93	0.00	8.45- 8.51
15	B	4,4'-DDE	1.280	1.173	8.4	88	0.00	8.39- 8.45
16	MA	Dieldrin	1.458	1.355	7.1	93	0.00	8.77- 8.83
17	MA	Endrin	1.258	1.153	8.3	92	0.00	9.10- 9.16
18	A	4,4'-DDD	1.163	1.098	5.6	93	0.00	9.23- 9.29
19	B	Endosulfan II	1.264	1.151	8.9	91	0.00	9.43- 9.49
20	MA	4,4'-DDT	0.956	0.901	5.8	87	0.00	9.65- 9.71
21	B	Endrin Aldehyde	0.929	0.824	11.3	94	0.00	10.06-10.12
22	B	Endosulfan Sulfate	1.144	1.023	10.6	88	0.00	10.75-10.81
23	A	Methoxychlor	0.583	0.522	10.5	88	0.00	10.44-10.50
24		Mirex	0.936	0.833	11.0	90	0.00	10.58-10.64
25	B	Endrin Ketone	1.385	1.246	10.0	90	0.00	11.19-11.25
26	SA	Decachlorobiphenyl	1.137	0.988	13.1	87	0.00	12.97-13.03
27	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	95	0.00	4.36- 5.36
28	L8	Toxaphene{A}		----------NA----------				
29	L8	Toxaphene{B}		----------NA----------				
30	L8	Toxaphene{C}		----------NA----------				
31	L8	Toxaphene{D}		----------NA----------				
32	L8	Toxaphene{E}		----------NA----------				
33	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	94	0.00	4.36- 5.36
34		Chlordane {A}		----------NA----------				
35		Chlordane {B}		----------NA----------				
36		Chlordane {C}		----------NA----------				
37		Chlordane {D}		----------NA----------				
38		Chlordane {E}		----------NA----------				

Continuing Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G4G4307-CC4300
Lab FileID: 4G9737041.D

***** Signal #2 *****

1	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	116	0.00	4.73- 5.73
2	SAB	Tetrachloro-m-xylene	0.865	0.865	0.0	116	0.00	6.13- 6.19
3		hexachlorobenzene	1.284	1.302	-1.4	117	0.00	6.69- 6.75
4	A	alpha-BHC	1.572	1.674	-6.5	117	0.00	6.86- 6.92
5	MA	gamma-BHC	1.250	1.243	0.6	112	0.00	7.32- 7.38
6	MA	Heptachlor	1.009	1.021	-1.2	114	0.00	7.94- 8.00
7	B	beta-BHC	0.485	0.458	5.6	110	0.00	7.43- 7.49
8	B	delta-BHC	1.033	0.968	6.3	101	0.00	7.84- 7.90
9	MB	Aldrin	1.021	0.941	7.8	112	0.00	8.41- 8.47
10		alachlor	0.124	0.100	19.4	98	0.00	8.21- 8.27
11	B	Heptachlor Epoxide	0.932	0.880	5.6	109	0.00	9.27- 9.33
12	B	gamma-Chlordane	0.938	0.881	6.1	108	0.00	9.57- 9.63
13	B	alpha-Chlordane	0.903	0.839	7.1	108	0.00	9.80- 9.86
14	A	Endosulfan I	0.919	0.811	11.8	107	0.00	9.90- 9.96
15	B	4,4'-DDE	0.917	0.836	8.8	106	0.00	10.06-10.12
16	MA	Dieldrin	0.998	0.929	6.9	108	0.00	10.35-10.41
17	MA	Endrin	0.879	0.779	11.4	105	0.00	10.87-10.93
18	A	4,4'-DDD	0.807	0.744	7.8	106	0.00	11.04-11.10
19	B	Endosulfan II	0.881	0.777	11.8	104	0.00	11.22-11.28
20	MA	4,4'-DDT	0.742	0.653	12.0	99	0.00	11.58-11.64
21	B	Endrin Aldehyde	0.644	0.509	21.0#	97	0.00	11.80-11.86
22	B	Endosulfan Sulfate	0.822	0.670	18.5	97	0.00	12.28-12.34
23	A	Methoxychlor	0.407	0.334	17.9	97	0.00	12.82-12.88
24		Mirex	0.631	0.498	21.1#	100	0.00	13.15-13.21
25	B	Endrin Ketone	0.922	0.791	14.2	101	0.00	13.20-13.26
26	SA	Decachlorobiphenyl	0.724	0.551	23.9#	93	0.00	14.76-14.82
27	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	108	0.00	4.73- 5.73
28	L8	Toxaphene{A}	----------NA----------					
29	L8	Toxaphene{B}	----------NA----------					
30	L8	Toxaphene{C}	----------NA----------					
31	L8	Toxaphene{D}	----------NA----------					
32	L8	Toxaphene{E}	----------NA----------					
33	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	109	0.00	4.73- 5.73
34		Chlordane {A}	----------NA----------					
35		Chlordane {B}	----------NA----------					
36		Chlordane {C}	----------NA----------					
37		Chlordane {D}	----------NA----------					
38		Chlordane {E}	----------NA----------					

(#) = Out of Range SPCC's out = 0 CCC's out = 0
4g9737041.d 4PSTLVI4300AB.M Tue Mar 12 01:25:12 2024

Initial Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G5G3509-ICC3509
Lab FileID: 5G135533.D

Response Factor Report GC5G

Method : C:\msdchem\1\METHODS\5pstlvi3509.M (ChemStation Integrator)
Title : PEST/PCB
Last Update : Wed Feb 07 07:01:05 2024
Response via : Initial Calibration

Calibration Files
2 =5G135530.d 5 =5G135531.d 10 =5G135532.d 25 =5G135533.d
50 =5G135534.d 100 =5G135536.d 75 =5G135535.d =

Compound	2	5	10	25	50	100	75	Avg	%RSD
1) I 1-bromo-2-nitrobenzen	ISTD								
2) Tetrachloro-	0.676	0.657	0.640	0.627	0.613	0.612	0.611	0.634	3.95
3) hexachlorobe	1.785	1.771	1.745	1.655	1.696	1.693	1.643	1.713	3.24
4) alpha-BHC	1.813	1.869	1.879	1.903	1.880	1.959	1.892	1.885	2.31
5) gamma-BHC	1.370	1.427	1.575	1.594	1.578	1.717	1.640	1.557	7.72
6) Heptachlor	0.856	1.109	1.178	1.185	1.147	1.366	1.317	1.166	14.16
7) beta-BHC	0.492	0.533	0.595	0.549	0.520	0.556	0.542	0.541	5.90
8) delta-BHC	1.383	1.370	1.415	1.420	1.421	1.697	1.595	1.471	8.44
9) Aldrin	1.260	1.264	1.274	1.275	1.270	1.391	1.297	1.290	3.58
10) alachlor		0.156	0.133	0.119	0.119	0.101	0.104	0.122	16.65
11) Heptachlor E	1.655	1.386	1.254	1.114	1.176	1.157	1.149	1.270	15.16
12) gamma-Chlord	1.348	1.413	1.520	1.285	1.286	1.255	1.244	1.336	7.49
13) alpha-Chlord	1.162	1.237	0.969	1.077	1.132	0.870	1.128	1.082	11.47
14) Endosulfan I	1.373	1.216	1.137	1.063	1.104	1.056	1.051	1.143	10.26
15) 4,4'-DDE	1.096	1.105	1.102	1.015	1.116	1.094	1.053	1.083	3.31
16) Dieldrin	1.541	1.399	1.287	1.231	1.298	1.224	1.214	1.313	9.05
17) Endrin	1.063	1.105	1.033	1.023	1.084	1.036	1.021	1.052	3.12
18) 4,4'-DDD	0.776	0.966	0.907	0.886	0.873	0.860	0.901	0.881	6.54
19) Endosulfan I	1.182	1.176	1.105	1.020	1.028	0.980	1.018	1.073	7.61
20) 4,4'-DDT	1.050	1.097	1.042	0.993	1.032	1.015	1.017	1.035	3.20
21) Endrin Aldeh	1.773	1.115	0.943	0.813	0.799	0.755	0.760	0.994	36.91
----- Quadratic regression ----- Coefficient = 0.9998									
Response Ratio = 0.03710 + 0.76094 *A + -0.01285 *A^2									
22) Endosulfan S	1.295	1.166	1.057	0.987	1.041	0.999	0.982	1.075	10.76
23) Methoxychlor	0.702	0.638	0.579	0.537	0.535	0.509	0.527	0.575	12.27
24) Mirex	1.027	0.924	0.823	0.744	0.725	0.702	0.683	0.804	16.02
25) Endrin Keton	1.417	1.322	1.188	1.118	1.145	1.089	1.060	1.191	11.01
26) Decachlorobi	1.476	1.291	1.194	1.099	1.081	1.068	0.987	1.171	14.20
27) I 1-bromo-2-nitrobenzen	ISTD								
28) Toxaphene{A}				0.002				0.002	0.00
29) Toxaphene{B}				0.005				0.005	0.00
30) Toxaphene{C}				0.011				0.011	0.00
31) Toxaphene{D}				0.009				0.009	0.00
32) Toxaphene{E}				0.028				0.028	0.00
33) I 1-bromo-2-nitrobenzen	ISTD								
34) Chlordane {A				0.081				0.081	0.00
35) Chlordane {B				0.039				0.039	0.00
36) Chlordane {C				0.158				0.158	0.00
37) Chlordane {D				0.237				0.237	0.00
38) Chlordane {E				0.036				0.036	0.00

Signal #2

Initial Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G5G3509-ICC3509
Lab FileID: 5G135533.D

1)	I 1-bromo-2-nitrobenzen	----------ISTD----------								
2)	Tetrachloro-	1.213	1.156	1.126	1.076	1.055	1.032	1.027	1.098	6.33
3)	hexachlorobe	1.666	1.615	1.590	1.457	1.417	1.396	1.398	1.506	7.61
4)	alpha-BHC	1.642	1.635	1.858	1.809	1.758	1.776	1.770	1.750	4.74
5)	gamma-BHC	1.427	1.432	1.588	1.528	1.448	1.529	1.521	1.496	4.08
6)	Heptachlor	1.145	1.206	1.222	1.200	1.087	1.220	1.203	1.183	4.21
7)	beta-BHC	0.672	0.622	0.714	0.621	0.569	0.605	0.605	0.630	7.64
8)	delta-BHC	1.219	1.210	1.246	1.120	1.151	1.310	1.300	1.222	5.77
9)	Aldrin	1.008	1.622	1.355	1.177	1.075	1.167	1.134	1.220	16.99
10)	alachlor		0.180	0.160	0.138	0.133	0.118	0.122	0.142	16.77
11)	Heptachlor E	1.024	1.055	0.986	0.928	0.933	0.931	0.919	0.968	5.61
12)	gamma-Chlord	1.100	1.070	0.984	0.956	0.975	0.954	0.942	0.997	6.23
13)	alpha-Chlord	1.006	1.040	0.959	0.837	0.923	0.883	0.881	0.933	7.83
14)	Endosulfan I	0.650	0.853	0.762	0.781	0.781	0.765	0.757	0.764	7.84
15)	4,4'-DDE	0.960	0.973	0.900	0.858	0.896	0.870	0.855	0.902	5.26
16)	Dieldrin	1.001	1.035	0.960	0.926	0.947	0.923	0.915	0.958	4.68
17)	Endrin	0.890	0.863	0.782	0.721	0.779	0.759	0.745	0.791	7.89
18)	4,4'-DDD	0.729	0.739	0.674	0.626	0.633	0.620	0.620	0.663	7.84
19)	Endosulfan I	0.939	0.933	0.846	0.791	0.800	0.778	0.775	0.838	8.51
20)	4,4'-DDT	0.664	0.708	0.656	0.644	0.665	0.662	0.643	0.663	3.27
21)	Endrin Aldeh	0.597	0.619	0.574	0.527	0.533	0.516	0.514	0.554	7.63
22)	Endosulfan S	0.861	0.839	0.770	0.718	0.728	0.714	0.709	0.763	8.29
23)	Methoxychlor	0.348	0.328	0.301	0.266	0.269	0.266	0.260	0.291	12.05
24)	Mirex	0.610	0.589	0.533	0.490	0.482	0.471	0.463	0.520	11.39
25)	Endrin Keton	0.915	0.895	0.817	0.772	0.779	0.770	0.752	0.814	8.02
26)	Decachlorobi	0.788	0.769	0.699	0.672	0.668	0.658	0.648	0.700	8.00
27)	I 1-bromo-2-nitrobenzen	----------ISTD----------								
28)	Toxaphene{A}					0.009			0.009	0.00
29)	Toxaphene{B}					0.005			0.005	0.00
30)	Toxaphene{C}					0.025			0.025	0.00
31)	Toxaphene{D}					0.017			0.017	0.00
32)	Toxaphene{E}					0.021			0.021	0.00
33)	I 1-bromo-2-nitrobenzen	----------ISTD----------								
34)	Chlordane {A					0.071			0.071	0.00
35)	Chlordane {B					0.036			0.036	0.00
36)	Chlordane {C					0.125			0.125	0.00
37)	Chlordane {D					0.194			0.194	0.00
38)	Chlordane {E					0.026			0.026	0.00

(#) = Out of Range ### Number of calibration levels exceeded format ###

5pstlvi3509.M Wed Feb 07 07:11:10 2024

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G5G3509-ICV3509
Lab FileID: 5G135539.D

Evaluate Continuing Calibration Report

Signal #1 : C:\msdchem\1\DATA\g5...9\5G135539.d\ECD1A.ch Vial: 13
Signal #2 : C:\msdchem\1\DATA\g5g3509\5G135539.d\ECD2B.ch
Acq On : 5 Feb 2024 4:36 am Operator: christp
Sample : icv3509-2.5 (pest mix) Inst : GC5G
Misc : op52060,G5G3509,5.0,,,10,1 Multiplr: 1.00
IntFile Signal #1: autoint1.e IntFile Signal #2: autoint2.e

Method : C:\msdchem\1\METHODS\5pstlvi3509.M (ChemStation Integrator)
Title : PEST/PCB
Last Update : Wed Feb 07 07:01:05 2024
Response via : Multiple Level Calibration

Min. RRF : 0.000 Min. Rel. Area : 50% Max. R.T. Dev 0.50min
Max. RRF Dev : 20% Max. Rel. Area : 150%

		Compound	AvgRF	CCRF	%Dev	Area%	Dev(min)	RT Window
1	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	102	0.00	4.48- 5.48
2	SAB	Tetrachloro-m-xylene	0.634	0.664	-4.7	108	0.00	5.63- 5.69
3		hexachlorobenzene	1.713	1.959	-14.4	121	0.00	6.00- 6.06
4	A	alpha-BHC	1.885	1.757	6.8	94	0.00	6.16- 6.22
5	MA	gamma-BHC	1.557	1.475	5.3	95	0.00	6.47- 6.53
6	MA	Heptachlor	1.166	1.365	-17.1	118	0.00	7.00- 7.06
7	B	beta-BHC	0.541	0.505	6.7	94	0.00	6.56- 6.62
8	B	delta-BHC	1.471	1.382	6.1	99	0.00	6.75- 6.81
9	MB	Aldrin	1.290	1.323	-2.6	106	0.00	7.35- 7.41
10		alachlor	0.122	0.135	-10.7	117	0.00	7.51- 7.57
11	B	Heptachlor Epoxide	1.270	1.217	4.2	112	0.00	8.10- 8.16
12	B	gamma-Chlordane	1.336	1.274	4.6	101	0.00	8.27- 8.33
13	B	alpha-Chlordane	1.082	1.217	-12.5	115	0.00	8.44- 8.50
14	A	Endosulfan I	1.143	1.137	0.5	109	0.00	8.63- 8.69
15	B	4,4'-DDE	1.083	1.156	-6.7	116	0.00	8.56- 8.62
16	MA	Dieldrin	1.313	1.297	1.2	108	0.00	8.96- 9.02
17	MA	Endrin	1.052	0.980	6.8	98	0.00	9.30- 9.36
18	A	4,4'-DDD	0.881	1.019	-15.7	117	0.00	9.41- 9.47
19	B	Endosulfan II	1.073	1.112	-3.6	111	0.00	9.63- 9.69
20	MA	4,4'-DDT	1.035	1.018	1.6	105	0.00	9.84- 9.90
			True	Calc.	% Drift			
21	B	Endrin Aldehyde	2.500	2.818	-12.7	116	0.00	10.27-10.33
			AvgRF	CCRF	% Dev			
22	B	Endosulfan Sulfate	1.075	1.051	2.2	109	0.00	10.98-11.04
23	A	Methoxychlor	0.575	0.546	5.0	104	0.00	10.63-10.69
24		Mirex	0.804	0.875	-8.8	120	0.00	10.79-10.85
25	B	Endrin Ketone	1.191	1.217	-2.2	111	0.00	11.42-11.48
26	SA	Decachlorobiphenyl	1.171	1.243	-6.1	116	0.00	13.17-13.23
27	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	102	0.00	4.48- 5.48
28	L8	Toxaphene{A}		----------NA----------				
29	L8	Toxaphene{B}		----------NA----------				
30	L8	Toxaphene{C}		----------NA----------				
31	L8	Toxaphene{D}		----------NA----------				
32	L8	Toxaphene{E}		----------NA----------				
33	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	102	0.00	4.48- 5.48
34		Chlordane {A}		----------NA----------				
35		Chlordane {B}		----------NA----------				

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G5G3509-ICV3509
Lab FileID: 5G135539.D

36		Chlordane {C}			----------NA----------			
37		Chlordane {D}			----------NA----------			
38		Chlordane {E}			----------NA----------			
*****		Signal #2 *****						
1	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	97	0.00	4.68- 5.68
2	SAB	Tetrachloro-m-xylene	1.098	1.162	-5.8	105	0.00	6.03- 6.09
3		hexachlorobenzene	1.506	1.744	-15.8	116	0.00	6.57- 6.63
4	A	alpha-BHC	1.750	1.751	-0.1	94	0.00	6.73- 6.79
5	MA	gamma-BHC	1.496	1.450	3.1	92	0.00	7.17- 7.23
6	MA	Heptachlor	1.183	1.195	-1.0	97	0.00	7.76- 7.82
7	B	beta-BHC	0.630	0.607	3.7	95	0.00	7.26- 7.32
8	B	delta-BHC	1.222	1.240	-1.5	108	0.00	7.66- 7.72
9	MB	Aldrin	1.220	1.137	6.8	94	0.00	8.22- 8.28
10		alachlor	0.142	0.169	-19.0	119	0.00	8.03- 8.09
11	B	Heptachlor Epoxide	0.968	1.028	-6.2	108	0.00	9.06- 9.12
12	B	gamma-Chlordane	0.997	1.084	-8.7	110	0.00	9.34- 9.40
13	B	alpha-Chlordane	0.933	1.013	-8.6	118	0.00	9.57- 9.63
14	A	Endosulfan I	0.764	0.913	-19.5	114	0.00	9.67- 9.73
15	B	4,4'-DDE	0.902	0.958	-6.2	108	0.00	9.84- 9.90
16	MA	Dieldrin	0.958	1.041	-8.7	109	0.00	10.11-10.17
17	MA	Endrin	0.791	0.780	1.4	105	0.00	10.62-10.68
18	A	4,4'-DDD	0.663	0.710	-7.1	110	0.00	10.79-10.85
19	B	Endosulfan II	0.838	0.931	-11.1	114	0.00	10.97-11.03
20	MA	4,4'-DDT	0.663	0.695	-4.8	105	0.00	11.33-11.39
21	B	Endrin Aldehyde	0.554	0.664	-19.9	122	0.00	11.54-11.60
22	B	Endosulfan Sulfate	0.763	0.816	-6.9	110	0.00	12.02-12.08
23	A	Methoxychlor	0.291	0.324	-11.3	118	0.00	12.58-12.64
24		Mirex	0.520	0.631	-21.3#	125	0.00	12.90-12.96
25	B	Endrin Ketone	0.814	0.889	-9.2	112	0.00	12.96-13.02
26	SA	Decachlorobiphenyl	0.700	0.768	-9.7	111	0.00	14.60-14.66
27	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	97	0.00	4.68- 5.68
28	L8	Toxaphene{A}			----------NA----------			
29	L8	Toxaphene{B}			----------NA----------			
30	L8	Toxaphene{C}			----------NA----------			
31	L8	Toxaphene{D}			----------NA----------			
32	L8	Toxaphene{E}			----------NA----------			
33	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	97	0.00	4.68- 5.68
34		Chlordane {A}			----------NA----------			
35		Chlordane {B}			----------NA----------			
36		Chlordane {C}			----------NA----------			
37		Chlordane {D}			----------NA----------			
38		Chlordane {E}			----------NA----------			

(#) = Out of Range SPCC's out = 0 CCC's out = 0
5G135533.d 5pstlvi3509.M Wed Feb 07 07:09:52 2024

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G5G3509-ICV3509
Lab FileID: 5G135540.D

Evaluate Continuing Calibration Report

Data File : C:\msdchem\1\DATA\g5...9\5G135540.d\ECD1A.ch Vial: 14
Acq On : 5 Feb 2024 4:57 am Operator: christp
Sample : icv3509-50 (toxaphene) Inst : GC5G
Misc : op52060,G5G3509,5.0,,,10,1 Multiplr: 1.00
IntFile : autoint1.e

Data File : C:\msdchem\1\DATA\g5g3509\5G135540.d\ECD2B.ch Vial: 14
Acq On : 5 Feb 2024 4:57 am Operator: christp
Sample : icv3509-50 (chlordane) Inst : GC5G
Misc : op52060,G5G3509,5.0,,,10,1 Multiplr: 1.00
IntFile : autoint2.e

Method : C:\msdchem\1\METHODS\5pstlvi3509.M (ChemStation Integrator)
Title : PEST/PCB
Last Update : Wed Feb 07 07:01:05 2024
Response via : Multiple Level Calibration

Min. RRF : 0.000 Min. Rel. Area : 50% Max. R.T. Dev 0.50min
Max. RRF Dev : 20% Max. Rel. Area : 150%

		Compound	AvgRF	CCRF	%Dev	Area%	Dev(min)	RT Window
1	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	89	0.00	4.48- 5.48
2	SAB	Tetrachloro-m-xylene	0.634	0.640	-0.9	93	0.00	5.63- 5.69
3		hexachlorobenzene		----------NA----------				
4	A	alpha-BHC		----------NA----------				
5	MA	gamma-BHC		----------NA----------				
6	MA	Heptachlor		----------NA----------				
7	B	beta-BHC		----------NA----------				
8	B	delta-BHC		----------NA----------				
9	MB	Aldrin		----------NA----------				
10		alachlor		----------NA----------				
11	B	Heptachlor Epoxide		----------NA----------				
12	B	gamma-Chlordane		----------NA----------				
13	B	alpha-Chlordane		----------NA----------				
14	A	Endosulfan I		----------NA----------				
15	B	4,4'-DDE		----------NA----------				
16	MA	Dieldrin		----------NA----------				
17	MA	Endrin		----------NA----------				
18	A	4,4'-DDD		----------NA----------				
19	B	Endosulfan II		----------NA----------				
20	MA	4,4'-DDT		----------NA----------				
		---------- True Calc. % Drift ----------						
21	B	Endrin Aldehyde		----------NA----------				
		---------- AvgRF CCRF % Dev ----------						
22	B	Endosulfan Sulfate		----------NA----------				
23	A	Methoxychlor		----------NA----------				
24		Mirex		----------NA----------				
25	B	Endrin Ketone		----------NA----------				
26	SA	Decachlorobiphenyl	1.171	1.134	3.2	94	0.00	13.17-13.23
27	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	100	0.00	4.48- 5.48
28	L8	Toxaphene{A}	0.002	0.003	-50.0#	112	0.00	8.49- 8.69
29	L8	Toxaphene{B}	0.005	0.005	0.0	85	0.00	9.18- 9.38
30	L8	Toxaphene{C}	0.011	0.014	-27.3#	127	0.01	9.97-10.17
31	L8	Toxaphene{D}	0.009	0.012	-33.3#	132	0.00	10.25-10.45

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G5G3509-ICV3509
Lab FileID: 5G135540.D

32	L8	Toxaphene{E}	0.028	0.012	57.1#	42#	0.00	10.82-11.02
33	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	101	0.00	4.48- 5.48
34		Chlordane {A}		----------NA----------				
35		Chlordane {B}		----------NA----------				
36		Chlordane {C}		----------NA----------				
37		Chlordane {D}		----------NA----------				
38		Chlordane {E}		----------NA----------				

***** Signal #2 *****

1	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	84	0.00	4.68- 5.68
2	SAB	Tetrachloro-m-xylene	1.098	1.117	-1.7	89	0.00	6.04- 6.10
3		hexachlorobenzene		----------NA----------				
4	A	alpha-BHC		----------NA----------				
5	MA	gamma-BHC		----------NA----------				
6	MA	Heptachlor		----------NA----------				
7	B	beta-BHC		----------NA----------				
8	B	delta-BHC		----------NA----------				
9	MB	Aldrin		----------NA----------				
10		alachlor		----------NA----------				
11	B	Heptachlor Epoxide		----------NA----------				
12	B	gamma-Chlordane		----------NA----------				
13	B	alpha-Chlordane		----------NA----------				
14	A	Endosulfan I		----------NA----------				
15	B	4,4'-DDE		----------NA----------				
16	MA	Dieldrin		----------NA----------				
17	MA	Endrin		----------NA----------				
18	A	4,4'-DDD		----------NA----------				
19	B	Endosulfan II		----------NA----------				
20	MA	4,4'-DDT		----------NA----------				
21	B	Endrin Aldehyde		----------NA----------				
22	B	Endosulfan Sulfate		----------NA----------				
23	A	Methoxychlor		----------NA----------				
24		Mirex		----------NA----------				
25	B	Endrin Ketone		----------NA----------				
26	SA	Decachlorobiphenyl	0.700	0.689	1.6	86	0.00	14.60-14.66
27	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	100	0.00	4.68- 5.68
28	L8	Toxaphene{A}	0.009	0.011	-22.2#	120	0.00	10.00-10.20
29	L8	Toxaphene{B}	0.005	0.006	-20.0	123	0.00	10.18-10.38
30	L8	Toxaphene{C}	0.025	0.031	-24.0#	121	0.00	11.03-11.23
31	L8	Toxaphene{D}	0.017	0.017	0.0	98	0.00	11.47-11.67
32	L8	Toxaphene{E}	0.021	0.019	9.5	92	0.00	12.38-12.58
33	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	103	0.00	4.68- 5.68
34		Chlordane {A}		----------NA----------				
35		Chlordane {B}		----------NA----------				
36		Chlordane {C}		----------NA----------				
37		Chlordane {D}		----------NA----------				
38		Chlordane {E}		----------NA----------				

(#) = Out of Range SPCC's out = 0 CCC's out = 0
5G135534.d 5pstlvi3509.M Wed Feb 07 07:10:26 2024

7.9.23

7

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G5G3509-ICV3509
Lab FileID: 5G135541.D

Evaluate Continuing Calibration Report

Data File : C:\msdchem\1\DATA\g5...9\5G135541.d\ECD1A.ch Vial: 15
Acq On : 5 Feb 2024 5:19 am Operator: christp
Sample : icv3509-50 (chlordane) Inst : GC5G
Misc : op52060,G5G3509,5.0,,,10,1 Multiplr: 1.00
IntFile : autoint1.e

Data File : C:\msdchem\1\DATA\g5g3509\5G135541.d\ECD2B.ch Vial: 15
Acq On : 5 Feb 2024 5:19 am Operator: christp
Sample : icv3509-50 (toxaphene) Inst : GC5G
Misc : op52060,G5G3509,5.0,,,10,1 Multiplr: 1.00
IntFile : autoint2.e

Method : C:\msdchem\1\METHODS\5pstlvi3509.M (ChemStation Integrator)
Title : PEST/PCB
Last Update : Wed Feb 07 07:01:05 2024
Response via : Multiple Level Calibration

Min. RRF : 0.000 Min. Rel. Area : 50% Max. R.T. Dev 0.50min
Max. RRF Dev : 20% Max. Rel. Area : 150%

		Compound	AvgRF	CCRF	%Dev	Area%	Dev(min)	RT Window
1	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	86	0.00	4.48- 5.48
2	SAB	Tetrachloro-m-xylene	0.634	0.620	2.2	87	0.00	5.63- 5.69
3		hexachlorobenzene		----------NA----------				
4	A	alpha-BHC		----------NA----------				
5	MA	gamma-BHC		----------NA----------				
6	MA	Heptachlor		----------NA----------				
7	B	beta-BHC		----------NA----------				
8	B	delta-BHC		----------NA----------				
9	MB	Aldrin		----------NA----------				
10		alachlor		----------NA----------				
11	B	Heptachlor Epoxide		----------NA----------				
12	B	gamma-Chlordane		----------NA----------				
13	B	alpha-Chlordane		----------NA----------				
14	A	Endosulfan I		----------NA----------				
15	B	4,4'-DDE		----------NA----------				
16	MA	Dieldrin		----------NA----------				
17	MA	Endrin		----------NA----------				
18	A	4,4'-DDD		----------NA----------				
19	B	Endosulfan II		----------NA----------				
20	MA	4,4'-DDT		----------NA----------				
		---------- True Calc. % Drift ----------						
21	B	Endrin Aldehyde		----------NA----------				
		---------- AvgRF CCRF % Dev ----------						
22	B	Endosulfan Sulfate		----------NA----------				
23	A	Methoxychlor		----------NA----------				
24		Mirex		----------NA----------				
25	B	Endrin Ketone		----------NA----------				
26	SA	Decachlorobiphenyl	1.171	1.144	2.3	91	0.00	13.17-13.23
27	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	96	0.00	4.48- 5.48
28	L8	Toxaphene{A}		----------NA----------				
29	L8	Toxaphene{B}		----------NA----------				
30	L8	Toxaphene{C}		----------NA----------				
31	L8	Toxaphene{D}		----------NA----------				

Initial Calibration Verification

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G5G3509-ICV3509
Lab FileID: 5G135541.D

32	L8	Toxaphene{E}		----------NA----------				
33	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	97	0.00	4.48- 5.48
34		Chlordane {A}	0.081	0.067	17.3	81	0.00	6.93- 7.13
35		Chlordane {B}	0.039	0.035	10.3	87	0.00	7.44- 7.64
36		Chlordane {C}	0.158	0.145	8.2	88	0.00	8.20- 8.40
37		Chlordane {D}	0.237	0.225	5.1	92	0.00	8.37- 8.57
38		Chlordane {E}	0.036	0.034	5.6	92	0.00	9.46- 9.66

***** Signal #2 *****

1	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	82	0.00	4.68- 5.68
2	SAB	Tetrachloro-m-xylene	1.098	1.069	2.6	83	0.00	6.04- 6.10
3		hexachlorobenzene		----------NA----------				
4	A	alpha-BHC		----------NA----------				
5	MA	gamma-BHC		----------NA----------				
6	MA	Heptachlor		----------NA----------				
7	B	beta-BHC		----------NA----------				
8	B	delta-BHC		----------NA----------				
9	MB	Aldrin		----------NA----------				
10		alachlor		----------NA----------				
11	B	Heptachlor Epoxide		----------NA----------				
12	B	gamma-Chlordane		----------NA----------				
13	B	alpha-Chlordane		----------NA----------				
14	A	Endosulfan I		----------NA----------				
15	B	4,4'-DDE		----------NA----------				
16	MA	Dieldrin		----------NA----------				
17	MA	Endrin		----------NA----------				
18	A	4,4'-DDD		----------NA----------				
19	B	Endosulfan II		----------NA----------				
20	MA	4,4'-DDT		----------NA----------				
21	B	Endrin Aldehyde		----------NA----------				
22	B	Endosulfan Sulfate		----------NA----------				
23	A	Methoxychlor		----------NA----------				
24		Mirex		----------NA----------				
25	B	Endrin Ketone		----------NA----------				
26	SA	Decachlorobiphenyl	0.700	0.680	2.9	84	0.00	14.60-14.66
27	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	98	0.00	4.68- 5.68
28	L8	Toxaphene{A}		----------NA----------				
29	L8	Toxaphene{B}		----------NA----------				
30	L8	Toxaphene{C}		----------NA----------				
31	L8	Toxaphene{D}		----------NA----------				
32	L8	Toxaphene{E}		----------NA----------				
33	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	101	0.00	4.68- 5.68
34		Chlordane {A}	0.071	0.056	21.1#	80	0.00	7.69- 7.89
35		Chlordane {B}	0.036	0.032	11.1	88	0.00	8.35- 8.55
36		Chlordane {C}	0.125	0.110	12.0	88	0.00	9.27- 9.47
37		Chlordane {D}	0.194	0.177	8.8	92	0.00	9.50- 9.70
38		Chlordane {E}	0.026	0.024	7.7	92	0.00	10.98-11.18

(#) = Out of Range SPCC's out = 0 CCC's out = 0
5G135534.d 5pstlvi3509.M Wed Feb 07 07:10:28 2024

7.9.24

7

Continuing Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G5G3550-CC3509
Lab FileID: 5G136411.D

Evaluate Continuing Calibration Report

Signal #1 : C:\msdchem\1\data\ca...0\5G136411.d\ECD1A.ch Vial: 2
Signal #2 : C:\msdchem\1\data\carlos\g5g3550\5G136411.d\ECD2B.ch
Acq On : 11 Mar 2024 1:14 am Operator: christp
Sample : cc3509-2.5 Inst : GC5G
Misc : op52976,G5G3550,5.0,,,10,1 Multiplr: 1.00
IntFile Signal #1: autoint1.e IntFile Signal #2: autoint2.e

Method : C:\msdchem\1\dat...50\5pstlvi3509.M (ChemStation Integrator)
Title : PEST/PCB
Last Update : Mon Mar 11 16:33:01 2024
Response via : Multiple Level Calibration

Min. RRF : 0.000 Min. Rel. Area : 50% Max. R.T. Dev 0.50min
Max. RRF Dev : 20% Max. Rel. Area : 150%

		Compound	AvgRF	CCRF	%Dev	Area%	Dev(min)	RT Window
1	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	71	0.00	4.35- 5.35
2	SAB	Tetrachloro-m-xylene	0.634	0.768	-21.1#	87	0.00	5.48- 5.54
3		hexachlorobenzene	1.713	1.970	-15.0	85	0.00	5.83- 5.89
4	A	alpha-BHC	1.885	1.964	-4.2	73	0.00	5.99- 6.05
5	MA	gamma-BHC	1.557	1.671	-7.3	74	0.00	6.30- 6.36
6	MA	Heptachlor	1.166	1.640	-40.7#	98	0.00	6.81- 6.87
7	B	beta-BHC	0.541	0.671	-24.0#	87	0.00	6.39- 6.45
8	B	delta-BHC	1.471	1.780	-21.0#	89	0.00	6.58- 6.64
9	MB	Aldrin	1.290	1.658	-28.5#	92	0.00	7.15- 7.21
10		alachlor	0.122	0.166	-36.1#	99	0.00	7.31- 7.37
11	B	Heptachlor Epoxide	1.270	1.339	-5.4	85	0.00	7.88- 7.94
12	B	gamma-Chlordane	1.336	1.317	1.4	73	0.00	8.05- 8.11
13	B	alpha-Chlordane	1.082	1.227	-13.4	81	0.00	8.22- 8.28
14	A	Endosulfan I	1.143	1.230	-7.6	82	0.00	8.40- 8.46
15	B	4,4'-DDE	1.083	1.117	-3.1	78	0.00	8.34- 8.40
16	MA	Dieldrin	1.313	1.269	3.4	73	0.00	8.73- 8.79
17	MA	Endrin	1.052	0.989	6.0	69	0.00	9.06- 9.12
18	A	4,4'-DDD	0.881	0.872	1.0	70	0.00	9.18- 9.24
19	B	Endosulfan II	1.073	1.062	1.0	74	0.00	9.38- 9.44
20	MA	4,4'-DDT	1.035	0.873	15.7	62	0.00	9.60- 9.66
		---------- True	Calc.	% Drift	----------			
21	B	Endrin Aldehyde	2.500	2.595	-3.8	75	0.00	10.02-10.08
		---------- AvgRF	CCRF	% Dev	----------			
22	B	Endosulfan Sulfate	1.075	0.894	16.8	64	0.00	10.71-10.77
23	A	Methoxychlor	0.575	0.491	14.6	65	0.00	10.39-10.45
24		Mirex	0.804	0.708	11.9	68	0.00	10.54-10.60
25	B	Endrin Ketone	1.191	1.047	12.1	67	0.00	11.15-11.21
26	SA	Decachlorobiphenyl	1.171	0.983	16.1	64	0.00	12.94-13.00
27	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	71	0.00	4.35- 5.35
28	L8	Toxaphene{A}	----------NA----------					
29	L8	Toxaphene{B}	----------NA----------					
30	L8	Toxaphene{C}	----------NA----------					
31	L8	Toxaphene{D}	----------NA----------					
32	L8	Toxaphene{E}	----------NA----------					
33	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	71	0.00	4.35- 5.35
34		Chlordane {A}	----------NA----------					
35		Chlordane {B}	----------NA----------					

Continuing Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G5G3550-CC3509
Lab FileID: 5G136411.D

36		Chlordane {C}			----------NA----------			
37		Chlordane {D}			----------NA----------			
38		Chlordane {E}			----------NA----------			
*****		Signal #2 *****						
1	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	112	0.00	4.56- 5.56
2	SAB	Tetrachloro-m-xylene	1.098	1.102	-0.4	115	0.00	5.89- 5.95
3		hexachlorobenzene	1.506	1.486	1.3	114	0.00	6.40- 6.46
4	A	alpha-BHC	1.750	1.806	-3.2	112	0.00	6.56- 6.62
5	MA	gamma-BHC	1.496	1.550	-3.6	114	0.00	6.99- 7.05
6	MA	Heptachlor	1.183	1.221	-3.2	114	0.00	7.56- 7.62
7	B	beta-BHC	0.630	0.672	-6.7	121	0.00	7.08- 7.14
8	B	delta-BHC	1.222	1.422	-16.4	142	0.00	7.47- 7.53
9	MB	Aldrin	1.220	1.250	-2.5	119	0.00	8.01- 8.07
10		alachlor	0.142	0.137	3.5	111	0.00	7.83- 7.89
11	B	Heptachlor Epoxide	0.968	0.993	-2.6	120	0.00	8.83- 8.89
12	B	gamma-Chlordane	0.997	1.000	-0.3	117	0.00	9.11- 9.17
13	B	alpha-Chlordane	0.933	0.964	-3.3	129	0.00	9.34- 9.40
14	A	Endosulfan I	0.764	0.931	-21.9#	134	0.00	9.43- 9.49
15	B	4,4'-DDE	0.902	0.959	-6.3	125	0.00	9.60- 9.66
16	MA	Dieldrin	0.958	0.939	2.0	114	0.00	9.86- 9.92
17	MA	Endrin	0.791	0.695	12.1	108	0.00	10.36-10.42
18	A	4,4'-DDD	0.663	0.672	-1.4	120	0.00	10.55-10.61
19	B	Endosulfan II	0.838	0.714	14.8	101	0.00	10.71-10.77
20	MA	4,4'-DDT	0.663	0.627	5.4	109	0.00	11.08-11.14
21	B	Endrin Aldehyde	0.554	0.525	5.2	112	0.00	11.28-11.34
22	B	Endosulfan Sulfate	0.763	0.634	16.9	99	0.00	11.74-11.80
23	A	Methoxychlor	0.291	0.310	-6.5	131	0.00	12.32-12.38
24		Mirex	0.520	0.410	21.2#	94	0.00	12.63-12.69
25	B	Endrin Ketone	0.814	0.694	14.7	101	0.00	12.70-12.76
26	SA	Decachlorobiphenyl	0.700	0.460	34.3#	77	0.00	14.42-14.48
27	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	112	0.00	4.56- 5.56
28	L8	Toxaphene{A}			----------NA----------			
29	L8	Toxaphene{B}			----------NA----------			
30	L8	Toxaphene{C}			----------NA----------			
31	L8	Toxaphene{D}			----------NA----------			
32	L8	Toxaphene{E}			----------NA----------			
33	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	112	0.00	4.56- 5.56
34		Chlordane {A}			----------NA----------			
35		Chlordane {B}			----------NA----------			
36		Chlordane {C}			----------NA----------			
37		Chlordane {D}			----------NA----------			
38		Chlordane {E}			----------NA----------			

(#) = Out of Range SPCC's out = 0 CCC's out = 0
5G136405.d 5pstlvi3509.M Mon Mar 11 16:41:39 2024

Continuing Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G5G3551-CC3509
Lab FileID: 5G136436.D

Evaluate Continuing Calibration Report

Signal #1 : C:\msdchem\1\data\ch...1\5G136436.d\ECD1A.ch Vial: 4
Signal #2 : C:\msdchem\1\data\chrisc...g3551\5G136436.d\ECD2B.ch
Acq On : 11 Mar 2024 6:40 pm Operator: ninap
Sample : cc3509-5 Inst : GC5G
Misc : op52976,G5G3551,5.0,,,10,1 Multiplr: 1.00
IntFile Signal #1: autoint1.e IntFile Signal #2: autoint2.e

Method : C:\msdchem\1\dat...51\5pstlvi3509.M (ChemStation Integrator)
Title : PEST/PCB
Last Update : Tue Mar 12 07:24:06 2024
Response via : Multiple Level Calibration

Min. RRF : 0.000 Min. Rel. Area : 50% Max. R.T. Dev 0.50min
Max. RRF Dev : 20% Max. Rel. Area : 150%

		Compound	AvgRF	CCRF	%Dev	Area%	Dev(min)	RT Window
1	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	67	0.00	4.35- 5.35
2	SAB	Tetrachloro-m-xylene	0.634	0.751	-18.5	83	0.00	5.48- 5.54
3		hexachlorobenzene	1.713	1.862	-8.7	74	0.00	5.83- 5.89
4	A	alpha-BHC	1.885	2.020	-7.2	72	0.00	5.99- 6.05
5	MA	gamma-BHC	1.557	1.541	1.0	66	0.00	6.30- 6.36
6	MA	Heptachlor	1.166	1.778	-52.5#	105	0.00	6.81- 6.87
7	B	beta-BHC	0.541	0.618	-14.2	80	0.00	6.39- 6.45
8	B	delta-BHC	1.471	1.802	-22.5#	86	0.00	6.58- 6.64
9	MB	Aldrin	1.290	1.681	-30.3#	89	0.00	7.15- 7.21
10		alachlor	0.122	0.130	-6.6	74	0.00	7.32- 7.38
11	B	Heptachlor Epoxide	1.270	1.431	-12.7	82	0.00	7.89- 7.95
12	B	gamma-Chlordane	1.336	1.508	-12.9	79	0.00	8.05- 8.11
13	B	alpha-Chlordane	1.082	1.525	-40.9#	91	0.00	8.22- 8.28
14	A	Endosulfan I	1.143	1.471	-28.7#	90	0.00	8.40- 8.46
15	B	4,4'-DDE	1.083	1.414	-30.6#	85	0.00	8.34- 8.40
16	MA	Dieldrin	1.313	1.543	-17.5	80	0.00	8.73- 8.79
17	MA	Endrin	1.052	1.349	-28.2#	84	0.00	9.06- 9.12
18	A	4,4'-DDD	0.881	1.099	-24.7#	85	0.00	9.18- 9.24
19	B	Endosulfan II	1.073	1.314	-22.5#	86	0.00	9.38- 9.44
20	MA	4,4'-DDT	1.035	1.255	-21.3#	82	0.00	9.60- 9.66
			True	Calc.	% Drift			
21	B	Endrin Aldehyde	5.000	5.738	-14.8	75	0.00	10.02-10.08
			AvgRF	CCRF	% Dev			
22	B	Endosulfan Sulfate	1.075	1.221	-13.6	79	0.00	10.71-10.77
23	A	Methoxychlor	0.575	0.616	-7.1	78	0.00	10.39-10.45
24		Mirex	0.804	0.957	-19.0	89	0.00	10.54-10.60
25	B	Endrin Ketone	1.191	1.373	-15.3	81	0.00	11.15-11.21
26	SA	Decachlorobiphenyl	1.171	1.455	-24.3#	91	0.00	12.93-12.99
27	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	75	0.00	4.35- 5.35
28	L8	Toxaphene{A}		----------NA----------				
29	L8	Toxaphene{B}		----------NA----------				
30	L8	Toxaphene{C}		----------NA----------				
31	L8	Toxaphene{D}		----------NA----------				
32	L8	Toxaphene{E}		----------NA----------				
33	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	76	0.00	4.35- 5.35
34		Chlordane {A}		----------NA----------				
35		Chlordane {B}		----------NA----------				

Continuing Calibration Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: G5G3551-CC3509
Lab FileID: 5G136436.D

36		Chlordane {C}			----------NA----------			
37		Chlordane {D}			----------NA----------			
38		Chlordane {E}			----------NA----------			
*****		Signal #2 *****						
1	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	115	0.00	4.56- 5.56
2	SAB	Tetrachloro-m-xylene	1.098	1.029	6.3	112	0.00	5.89- 5.95
3		hexachlorobenzene	1.506	1.395	7.4	113	0.00	6.40- 6.46
4	A	alpha-BHC	1.750	1.710	2.3	112	0.00	6.56- 6.62
5	MA	gamma-BHC	1.496	1.524	-1.9	121	0.00	6.99- 7.05
6	MA	Heptachlor	1.183	1.356	-14.6	144	0.00	7.56- 7.62
7	B	beta-BHC	0.630	0.647	-2.7	131	0.00	7.08- 7.14
8	B	delta-BHC	1.222	1.404	-14.9	140	0.00	7.47- 7.53
9	MB	Aldrin	1.220	1.256	-3.0	135	0.00	8.01- 8.07
10		alachlor	0.142	0.166	-16.9	144	0.00	7.83- 7.89
11	B	Heptachlor Epoxide	0.968	1.069	-10.4	132	0.00	8.83- 8.89
12	B	gamma-Chlordane	0.997	1.096	-9.9	129	0.00	9.11- 9.17
13	B	alpha-Chlordane	0.933	1.053	-12.9	131	0.00	9.34- 9.40
14	A	Endosulfan I	0.764	0.989	-29.5#	146	0.00	9.43- 9.49
15	B	4,4'-DDE	0.902	1.027	-13.9	132	0.00	9.60- 9.66
16	MA	Dieldrin	0.958	1.059	-10.5	129	0.00	9.86- 9.92
17	MA	Endrin	0.791	0.956	-20.9#	141	0.00	10.36-10.42
18	A	4,4'-DDD	0.663	0.790	-19.2	144	0.00	10.54-10.60
19	B	Endosulfan II	0.838	0.840	-0.2	121	0.00	10.71-10.77
20	MA	4,4'-DDT	0.663	0.834	-25.8#	144	0.00	11.07-11.13
21	B	Endrin Aldehyde	0.554	0.582	-5.1	126	0.00	11.27-11.33
22	B	Endosulfan Sulfate	0.763	0.777	-1.8	123	0.00	11.74-11.80
23	A	Methoxychlor	0.291	0.424	-45.7#	181#	0.00	12.31-12.37
24		Mirex	0.520	0.499	4.0	119	0.00	12.63-12.69
25	B	Endrin Ketone	0.814	0.812	0.2	120	0.00	12.69-12.75
26	SA	Decachlorobiphenyl	0.700	0.539	23.0#	93	0.00	14.42-14.48
27	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	137	0.00	4.56- 5.56
28	L8	Toxaphene{A}			----------NA----------			
29	L8	Toxaphene{B}			----------NA----------			
30	L8	Toxaphene{C}			----------NA----------			
31	L8	Toxaphene{D}			----------NA----------			
32	L8	Toxaphene{E}			----------NA----------			
33	I	1-bromo-2-nitrobenzene	1.000	1.000	0.0	141	0.00	4.56- 5.56
34		Chlordane {A}			----------NA----------			
35		Chlordane {B}			----------NA----------			
36		Chlordane {C}			----------NA----------			
37		Chlordane {D}			----------NA----------			
38		Chlordane {E}			----------NA----------			

(#) = Out of Range SPCC's out = 0 CCC's out = 0
5G136411.d 5pstlvi3509.M Tue Mar 12 08:24:41 2024

Run Sequence Report

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Run ID: G2G6015 **Method:** SW846 8082A **Instrument ID:** GC2G

Lab Sample ID	Lab File ID	Date/Time Analyzed	Prep QC Batch	Client Sample ID
G2G6015-IC6015	2G229467.D	11/30/23 19:12	n/a	Initial cal 5
G2G6015-IC6015	2G229468.D	11/30/23 19:36	n/a	Initial cal 10
G2G6015-IC6015	2G229469.D	11/30/23 20:00	n/a	Initial cal 25
G2G6015-IC6015	2G229470.D	11/30/23 20:24	n/a	Initial cal 50
G2G6015-ICC6015	2G229471.D	11/30/23 20:48	n/a	Initial cal 100
G2G6015-IC6015	2G229472.D	11/30/23 21:12	n/a	Initial cal 200
G2G6015-IC6015	2G229473.D	11/30/23 21:36	n/a	Initial cal 300
G2G6015-IC6015	2G229474.D	11/30/23 22:00	n/a	Initial cal 500
G2G6015-IC6015	2G229475.D	11/30/23 22:24	n/a	Initial cal 1000
G2G6015-IC6015	2G229476.D	11/30/23 22:48	n/a	Initial cal 2000
G2G6015-IC6015	2G229477.D	11/30/23 23:12	n/a	Initial cal 100
G2G6015-IC6015	2G229478.D	11/30/23 23:36	n/a	Initial cal 100
G2G6015-IC6015	2G229479.D	12/01/23 00:00	n/a	Initial cal 100
G2G6015-IC6015	2G229479.D	12/01/23 00:00	n/a	Initial cal 100
G2G6015-IC6015	2G229480.D	12/01/23 00:24	n/a	Initial cal 100
G2G6015-ICV6015	2G229481.D	12/01/23 00:48	n/a	Initial cal verification 100
G2G6015-ICV6015	2G229482.D	12/01/23 01:12	n/a	Initial cal verification 100
G2G6015-ICV6015	2G229484.D	12/01/23 02:00	n/a	Initial cal verification 100
G2G6015-IC6016	2G229498.D	12/17/23 16:50	n/a	Initial cal 10
G2G6015-IC6016	2G229499.D	12/17/23 17:13	n/a	Initial cal 25
G2G6015-IC6016	2G229500.D	12/17/23 17:37	n/a	Initial cal 50
G2G6015-IC6016	2G229502A.D	12/17/23 22:04	n/a	Initial cal 200
G2G6015-IC6016	2G229503.D	12/17/23 22:27	n/a	Initial cal 300
G2G6015-ICV6015	2G229504.D	12/17/23 22:51	n/a	Initial cal verification 100
G2G6015-IC6016	2G229505.D	12/17/23 23:14	n/a	Initial cal 10
G2G6015-IC6016	2G229506.D	12/17/23 23:38	n/a	Initial cal 25
G2G6015-IC6016	2G229507.D	12/18/23 00:02	n/a	Initial cal 50
G2G6015-IC6016	2G229508.D	12/18/23 00:26	n/a	Initial cal 100
G2G6015-IC6016	2G229509.D	12/18/23 00:50	n/a	Initial cal 200
G2G6015-IC6016	2G229510.D	12/18/23 01:14	n/a	Initial cal 300
G2G6015-ICV6015	2G229511.D	12/18/23 01:38	n/a	Initial cal verification 100
G2G6015-IC6016	2G229512.D	12/18/23 02:01	n/a	Initial cal 10
G2G6015-IC6016	2G229513.D	12/18/23 02:26	n/a	Initial cal 25
G2G6015-IC6016	2G229514.D	12/18/23 02:50	n/a	Initial cal 50
G2G6015-IC6016	2G229515A.D	12/18/23 03:35	n/a	Initial cal 100
G2G6015-IC6016	2G229516.D	12/18/23 03:59	n/a	Initial cal 200
G2G6015-IC6016	2G229517.D	12/18/23 04:23	n/a	Initial cal 300
G2G6015-ICV6015	2G229518.D	12/18/23 04:47	n/a	Initial cal verification 100
G2G6015-IC6015	2G229523.D	12/20/23 07:14	n/a	Initial cal 100
G2G6015-IC6015	2G229524.D	12/20/23 07:38	n/a	Initial cal 100
G2G6015-ICV6015	2G229526.D	12/20/23 08:25	n/a	Initial cal verification 100
G2G6015-ICV6015	2G229528.D	12/20/23 10:27	n/a	Initial cal verification 100

Run Sequence Report

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Run ID: G2G6058	**Method:** SW846 8082A	**Instrument ID:** GC2G

Lab Sample ID	Lab File ID	Date/Time Analyzed	Prep QC Batch	Client Sample ID
G2G6058-CC6015	2G231099.D	03/10/24 09:50	n/a	Continuing cal 50
OP52994-MB1	2G231101.D	03/10/24 11:15	OP52994	Method Blank
OP52994-BS1	2G231102.D	03/10/24 11:39	OP52994	Blank Spike
OP52994-MS	2G231103.D	03/10/24 12:03	OP52994	Matrix Spike
OP52994-MSD	2G231104.D	03/10/24 12:28	OP52994	Matrix Spike Duplicate
JD83862-2	2G231105.D	03/10/24 12:53	OP52994	(used for QC only; not part of job JD83927)
ZZZZZZ	2G231106.D	03/10/24 13:17	OP52994	(unrelated sample)
ZZZZZZ	2G231107.D	03/10/24 13:42	OP52994	(unrelated sample)
G2G6058-CC6015	2G231110.D	03/10/24 14:56	n/a	Continuing cal 100
ZZZZZZ	2G231112.D	03/10/24 15:46	OP52994	(unrelated sample)
ZZZZZZ	2G231113.D	03/10/24 16:11	OP52994	(unrelated sample)
ZZZZZZ	2G231114.D	03/10/24 16:35	OP52994	(unrelated sample)
ZZZZZZ	2G231115.D	03/10/24 17:00	OP52994	(unrelated sample)
ZZZZZZ	2G231116.D	03/10/24 17:25	OP52994	(unrelated sample)
ZZZZZZ	2G231117.D	03/10/24 17:49	OP52994	(unrelated sample)
ZZZZZZ	2G231118.D	03/10/24 18:14	OP52994	(unrelated sample)
G2G6058-CC6015	2G231121.D	03/10/24 19:28	n/a	Continuing cal 50
ZZZZZZ	2G231123.D	03/10/24 20:17	OP52994	(unrelated sample)
OP53022-MB1	2G231124.D	03/10/24 20:41	OP53022	Method Blank
OP53022-BS1	2G231125.D	03/10/24 21:06	OP53022	Blank Spike
OP53022-MS	2G231126.D	03/10/24 21:31	OP53022	Matrix Spike
OP53022-MSD	2G231127.D	03/10/24 21:55	OP53022	Matrix Spike Duplicate
JD83927-5	2G231128.D	03/10/24 22:19	OP53022	SB-9(3.5-4)030724
JD83927-1	2G231129.D	03/10/24 22:44	OP53022	SB-7(4-4.5)030724
G2G6058-CC6015	2G231132.D	03/10/24 23:57	n/a	Continuing cal 100
JD83927-2	2G231134.D	03/11/24 00:45	OP53022	SB-7(7-7.5)030724
JD83927-3	2G231135.D	03/11/24 01:09	OP53022	SB-8(4-4.5)030724
JD83927-4	2G231136.D	03/11/24 01:34	OP53022	SB-8(7.5-8)030724
JD83927-6	2G231137.D	03/11/24 01:58	OP53022	SB-10(3.5-4)030724
JD83927-7	2G231138.D	03/11/24 02:22	OP53022	SB-10(7-5.5)030724
JD83927-8	2G231139.D	03/11/24 02:46	OP53022	SB-11(3.5-4)030724
JD83927-9	2G231140.D	03/11/24 03:11	OP53022	SB-11(8-8.5)030724
G2G6058-CC6015	2G231143.D	03/11/24 04:24	n/a	Continuing cal 50
JD83927-10	2G231145.D	03/11/24 05:12	OP53022	SB-16(3-3.5)030724
JD83927-11	2G231146.D	03/11/24 05:36	OP53022	SB-16(7.5-8)030724
JD83927-12	2G231147.D	03/11/24 06:01	OP53022	SB-19(4-4.5)030724
JD83927-13	2G231148.D	03/11/24 06:25	OP53022	SB-19(7-7.5)030724
JD83927-14	2G231149.D	03/11/24 06:49	OP53022	SB-22(3.5-4)030724
JD83927-15	2G231150.D	03/11/24 07:13	OP53022	SB-22(8-8.5)030724
JD83927-16	2G231151.D	03/11/24 07:38	OP53022	SB-25(1.5-2)030724
G2G6058-CC6015	2G231154.D	03/11/24 08:51	n/a	Continuing cal 100
JD83927-17	2G231156.D	03/11/24 09:40	OP53022	SB-25(3-3.5)030724
JD83927-18	2G231157.D	03/11/24 10:04	OP53022	SB-25(7.5-8)030724
G2G6058-CC6015	2G231159.D	03/11/24 10:53	n/a	Continuing cal 50

Run Sequence Report

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Run ID: G4G4300	**Method:** SW846 8081B	**Instrument ID:** GC4G

Lab Sample ID	Lab File ID	Date/Time Analyzed	Prep QC Batch	Client Sample ID
G4G4300-DDT	4G9736847.D	03/06/24 08:25	n/a	DDT/Endrin Breakdown Check
G4G4300-IC4300	4G9736850.D	03/06/24 09:23	n/a	Initial cal 0.2
G4G4300-IC4300	4G9736851.D	03/06/24 09:42	n/a	Initial cal 0.5
G4G4300-IC4300	4G9736852.D	03/06/24 10:02	n/a	Initial cal 1
G4G4300-ICC4300	4G9736853.D	03/06/24 10:21	n/a	Initial cal 2.5
G4G4300-IC4300	4G9736854.D	03/06/24 10:41	n/a	Initial cal 5
G4G4300-IC4300	4G9736855.D	03/06/24 11:00	n/a	Initial cal 7.5
G4G4300-IC4300	4G9736856.D	03/06/24 11:19	n/a	Initial cal 10
G4G4300-IC4300	4G9736857.D	03/06/24 11:39	n/a	Initial cal 50
G4G4300-IC4300	4G9736858.D	03/06/24 11:58	n/a	Initial cal 50
G4G4300-ICV4300	4G9736859.D	03/06/24 12:18	n/a	Initial cal verification 2.5
G4G4300-ICV4300	4G9736860.D	03/06/24 12:37	n/a	Initial cal verification 50
G4G4300-ICV4300	4G9736861.D	03/06/24 12:56	n/a	Initial cal verification 50

Run Sequence Report

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Run ID: G4G4306 **Method:** SW846 8081B **Instrument ID:** GC4G

Lab Sample ID	Lab File ID	Date/Time Analyzed	Prep QC Batch	Client Sample ID
G4G4306-DDT	4G9737015.D	03/10/24 23:55	n/a	DDT/Endrin Breakdown Check
G4G4306-CC4300	4G9737016.D	03/11/24 00:14	n/a	Continuing cal 2.5
OP53021-MB1	4G9737018A.D	03/11/24 01:38	OP53021	Method Blank
OP53021-BS1	4G9737019.D	03/11/24 01:57	OP53021	Blank Spike
OP53021-MS	4G9737020.D	03/11/24 02:17	OP53021	Matrix Spike
OP53021-MSD	4G9737021.D	03/11/24 02:36	OP53021	Matrix Spike Duplicate
JD83927-1	4G9737022.D	03/11/24 02:56	OP53021	SB-7(4-4.5)030724
JD83927-2	4G9737023.D	03/11/24 03:19	OP53021	SB-7(7-7.5)030724
JD83927-3	4G9737024.D	03/11/24 03:39	OP53021	SB-8(4-4.5)030724
JD83927-4	4G9737025.D	03/11/24 03:58	OP53021	SB-8(7.5-8)030724
JD83927-5	4G9737026.D	03/11/24 04:18	OP53021	SB-9(3.5-4)030724
JD83927-6	4G9737027.D	03/11/24 04:37	OP53021	SB-10(3.5-4)030724
JD83927-7	4G9737028.D	03/11/24 04:56	OP53021	SB-10(7-5.5)030724
JD83927-8	4G9737029.D	03/11/24 05:16	OP53021	SB-11(3.5-4)030724
JD83927-9	4G9737030.D	03/11/24 05:35	OP53021	SB-11(8-8.5)030724
JD83927-10	4G9737031.D	03/11/24 05:54	OP53021	SB-16(3-3.5)030724
JD83927-11	4G9737032.D	03/11/24 06:14	OP53021	SB-16(7.5-8)030724
JD83927-12	4G9737033.D	03/11/24 06:33	OP53021	SB-19(4-4.5)030724
JD83927-13	4G9737034.D	03/11/24 06:52	OP53021	SB-19(7-7.5)030724
JD83927-14	4G9737035.D	03/11/24 07:12	OP53021	SB-22(3.5-4)030724
JD83927-15	4G9737036.D	03/11/24 07:31	OP53021	SB-22(8-8.5)030724

Run Sequence Report

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Run ID: G4G4307	**Method:** SW846 8081B	**Instrument ID:** GC4G

Lab Sample ID	Lab File ID	Date/Time Analyzed	Prep QC Batch	Client Sample ID
G4G4307-DDT	4G9737040.D	03/11/24 11:00	n/a	DDT/Endrin Breakdown Check
G4G4307-CC4300	4G9737041.D	03/11/24 11:19	n/a	Continuing cal 5
OP53017-MB1	4G9737043.D	03/11/24 11:58	OP53017	Method Blank
OP53017-BS1	4G9737044.D	03/11/24 12:17	OP53017	Blank Spike
ZZZZZZ	4G9737047.D	03/11/24 13:16	OP53017	(unrelated sample)
ZZZZZZ	4G9737048.D	03/11/24 13:35	OP53017	(unrelated sample)
ZZZZZZ	4G9737049.D	03/11/24 13:54	OP53017	(unrelated sample)
ZZZZZZ	4G9737050.D	03/11/24 14:14	OP53017	(unrelated sample)
ZZZZZZ	4G9737051.D	03/11/24 14:33	OP53017	(unrelated sample)
ZZZZZZ	4G9737052.D	03/11/24 14:52	OP53017	(unrelated sample)
ZZZZZZ	4G9737053.D	03/11/24 15:12	OP53017	(unrelated sample)
ZZZZZZ	4G9737054.D	03/11/24 15:31	OP53017	(unrelated sample)
ZZZZZZ	4G9737055.D	03/11/24 15:51	OP53017	(unrelated sample)
ZZZZZZ	4G9737056.D	03/11/24 16:10	OP53017	(unrelated sample)

Run Sequence Report

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Run ID: G5G3509	**Method:** SW846 8081B	**Instrument ID:** GC5G

Lab Sample ID	Lab File ID	Date/Time Analyzed	Prep QC Batch	Client Sample ID
G5G3509-DDT	5G135526.D	02/04/24 23:04	n/a	DDT/Endrin Breakdown Check
G5G3509-IC3509	5G135530.D	02/05/24 01:25	n/a	Initial cal 0.2
G5G3509-IC3509	5G135531.D	02/05/24 01:46	n/a	Initial cal 0.5
G5G3509-IC3509	5G135532.D	02/05/24 02:07	n/a	Initial cal 1.0
G5G3509-ICC3509	5G135533.D	02/05/24 02:28	n/a	Initial cal 2.5
G5G3509-IC3509	5G135534.D	02/05/24 02:50	n/a	Initial cal 5.0
G5G3509-IC3509	5G135535.D	02/05/24 03:11	n/a	Initial cal 7.5
G5G3509-IC3509	5G135536.D	02/05/24 03:32	n/a	Initial cal 10
G5G3509-IC3509	5G135537.D	02/05/24 03:53	n/a	Initial cal 50
G5G3509-IC3509	5G135538.D	02/05/24 04:15	n/a	Initial cal 50
G5G3509-ICV3509	5G135539.D	02/05/24 04:36	n/a	Initial cal verification 2.5
G5G3509-ICV3509	5G135540.D	02/05/24 04:57	n/a	Initial cal verification 50
G5G3509-ICV3509	5G135541.D	02/05/24 05:19	n/a	Initial cal verification 50

Run Sequence Report

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Run ID: G5G3550	**Method:** SW846 8081B	**Instrument ID:** GC5G

Lab Sample ID	Lab File ID	Date/Time Analyzed	Prep QC Batch	Client Sample ID
G5G3550-DDT	5G136408.D	03/11/24 00:09	n/a	DDT/Endrin Breakdown Check
G5G3550-CC3509	5G136411.D	03/11/24 01:14	n/a	Continuing cal 2.5
ZZZZZZ	5G136413.D	03/11/24 01:58	OP52804	(unrelated sample)
ZZZZZZ	5G136414.D	03/11/24 02:19	OP52804	(unrelated sample)
ZZZZZZ	5G136415.D	03/11/24 02:50	OP52989	(unrelated sample)
ZZZZZZ	5G136416.D	03/11/24 03:12	OP52989	(unrelated sample)
JD83927-16	5G136417.D	03/11/24 03:33	OP53021	SB-25(1.5-2)030724
JD83927-17	5G136418.D	03/11/24 03:55	OP53021	SB-25(3-3.5)030724
JD83927-18	5G136419.D	03/11/24 04:16	OP53021	SB-25(7.5-8)030724
ZZZZZZ	5G136420.D	03/11/24 04:38	OP52989	(unrelated sample)
ZZZZZZ	5G136421.D	03/11/24 05:00	OP52802	(unrelated sample)
ZZZZZZ	5G136422.D	03/11/24 05:21	OP52804	(unrelated sample)
JD83334-2	5G136424.D	03/11/24 06:04	OP52875	(used for QC only; not part of job JD83927)
ZZZZZZ	5G136425.D	03/11/24 06:26	OP52875	(unrelated sample)
ZZZZZZ	5G136426.D	03/11/24 06:48	OP52875	(unrelated sample)
ZZZZZZ	5G136427.D	03/11/24 07:09	OP52875	(unrelated sample)

Run Sequence Report

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Run ID: G5G3551	**Method:** SW846 8081B	**Instrument ID:** GC5G

Lab Sample ID	Lab File ID	Date/Time Analyzed	Prep QC Batch	Client Sample ID
G5G3551-DDT	5G136435.D	03/11/24 18:18	n/a	DDT/Endrin Breakdown Check
G5G3551-CC3509	5G136436.D	03/11/24 18:40	n/a	Continuing cal 5
LA98652-1	5G136438A.D	03/11/24 21:47	OP52879	(used for QC only; not part of job JD83927)
ZZZZZZ	5G136439B.D	03/12/24 00:07	OP52910	(unrelated sample)
ZZZZZZ	5G136440A.D	03/12/24 00:34	OP52910	(unrelated sample)
ZZZZZZ	5G136441A.D	03/12/24 00:55	OP52910	(unrelated sample)
ZZZZZZ	5G136443.D	03/12/24 01:38	OP52976	(unrelated sample)
ZZZZZZ	5G136445.D	03/12/24 02:22	OP52974	(unrelated sample)
ZZZZZZ	5G136452.D	03/12/24 04:56	OP52976	(unrelated sample)

Metals Analysis

QC Data Summaries

Includes the following where applicable:

- Instrument Runlogs
- Initial and Continuing Calibration Blanks
- Initial and Continuing Calibration Checks
- High and Low Check Standards
- Interfering Element Check Standards
- Method Blank Summaries
- Matrix Spike and Duplicate Summaries
- Blank Spike and Lab Control Sample Summaries
- Serial Dilution Summaries
- IDL and Linear Range Summaries

SGS Instrument Runlog
Inorganics Analyses

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SF031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
Analyst: KP Run ID: MA55686
Parameters: Al,Sb,As,Ba,Be,Cd,Ca,Cr,Co,Cu,Fe,Pb,Mg,Mn,Ni,K,Se,Ag,Na,Tl,V,Zn

Time	Sample Description	Dilution Factor	PS Recov	Comments
09:59	MA55686-STD1	1		STDA
10:04	MA55686-STD2	1		STDB
10:09	MA55686-ICV1	1		
10:15	MA55686-ICB1	1		
10:21	MA55686-ICV2	1		
10:27	MA55686-ICB2	1		
10:32	MA55686-ICCV1	1		
10:41	MA55686-CCB1	1		
10:46	MA55686-CRI1	1		
10:51	MA55686-CRID1	1		
10:56	MA55686-ICSA1	1		
11:01	MA55686-ICSAB1	1		
11:06	MA55686-HSTD1	1		
11:12	MA55686-HSTD2	1		
11:17	ZZZZZZ	1		
11:22	ZZZZZZ	1		
11:27	MA55686-CRID2	1		
11:32	ZZZZZZ	1		
11:37	MA55686-CCV1	1		
11:42	MA55686-CCB2	1		
11:47	MP45202-MB1	1		
11:52	MP45202-B1	1		
11:57	MP45202-S1	1		FE high
12:02	MP45202-S2	1		FE high
12:07	JD83844-1	1		(sample used for QC only; not part of login JD83927)
12:12	MP45202-SD1	5		FE high
12:17	MP45202-PS1	1		
12:22	ZZZZZZ	1		
12:27	ZZZZZZ	1		
12:32	ZZZZZZ	1		
12:37	MA55686-CCV2	1		
12:42	MA55686-CCB3	1		
12:47	ZZZZZZ	1		

SGS Instrument Runlog
Inorganics Analyses

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SF031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
Analyst: KP Run ID: MA55686
Parameters: Al,Sb,As,Ba,Be,Cd,Ca,Cr,Co,Cu,Fe,Pb,Mg,Mn,Ni,K,Se,Ag,Na,Tl,V,Zn

Time	Sample Description	Dilution Factor	PS Recov	Comments
12:52	ZZZZZZ	1		
12:57	ZZZZZZ	1		
13:02	ZZZZZZ	1		
13:07	ZZZZZZ	1		
13:12	ZZZZZZ	1		
13:17	ZZZZZZ	1		
13:22	ZZZZZZ	1		
13:27	ZZZZZZ	1		
13:32	ZZZZZZ	1		
13:37	MA55686-CCV3	1		
13:42	MA55686-CCB4	1		
13:47	ZZZZZZ	1		
13:52	ZZZZZZ	1		
13:57	ZZZZZZ	1		
14:02	ZZZZZZ	1		
14:07	ZZZZZZ	1		
14:12	MP45216-MB1	1		
14:17	MA55686-CCV4	1		
14:21	MA55686-CCB5	1		
14:27	MP45216-B1	1		
14:31	MP45216-S1	1		
14:36	MP45216-S2	1		
14:41	JD83326-1	1		(sample used for QC only; not part of login JD83927)
14:46	MP45216-SD1	5		
14:51	MP45216-PS1	1		
---------->	Last reportable sample/prep for job JD83927			
14:56	ZZZZZZ	1		
15:01	ZZZZZZ	1		
15:06	ZZZZZZ	10		
15:11	ZZZZZZ	1		
15:16	MA55686-CCV5	1		
15:21	MA55686-CCB6	1		
---------->	Last reportable CCB for job JD83927			
15:26	MP45159-MB1	1		
15:31	MP45159-B1	1		

SGS Instrument Runlog
Inorganics Analyses

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SF031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
Analyst: KP Run ID: MA55686
Parameters: Al,Sb,As,Ba,Be,Cd,Ca,Cr,Co,Cu,Fe,Pb,Mg,Mn,Ni,K,Se,Ag,Na,Tl,V,Zn

Time	Sample Description	Dilution Factor	PS Recov	Comments
15:36	MP45159-S1	1		Ca high
15:41	MP45159-S2	1		Ca high
15:45	JD83749-5	1		(sample used for QC only; not part of login JD83927)
15:50	MP45159-SD1	5		Ca high
15:55	MP45159-PS1	1		
16:00	ZZZZZZ	1		
16:05	ZZZZZZ	1		
16:10	ZZZZZZ	1		
16:16	MA55686-CCV6	1		
16:20	MA55686-CCB7	1		
16:26	ZZZZZZ	1		
16:31	ZZZZZZ	1		
16:37	ZZZZZZ	1		
16:42	ZZZZZZ	1		
16:47	ZZZZZZ	1		
16:52	ZZZZZZ	1		
16:57	ZZZZZZ	1		
17:02	ZZZZZZ	1		
17:07	ZZZZZZ	1		
17:12	ZZZZZZ	1		
17:17	MA55686-CCV7	1		
17:22	MA55686-CCB8	1		
17:27	ZZZZZZ	1		
17:32	ZZZZZZ	1		

Refer to raw data for calibration curve and standards.

REPORTED ELEMENTS SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SF031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
Analyst: KP Run ID: MA55686
Parameters: Al,Sb,As,Ba,Be,Cd,Ca,Cr,Co,Cu,Fe,Pb,Mg,Mn,Ni,K,Se,Ag,Na,Tl,V,Zn

Time	Sample Description	Element: / Dilution	Al	Sb	As	Ba	Be	Cd	Ca	Cr	Co	Cu	Fe	Pb	Mg	Mn	Ni	K	Se	Ag	Na	Tl	V	Zn	
10:09	MA55686-ICV1	1																							
10:15	MA55686-ICB1	1																							
10:21	MA55686-ICV2	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
10:27	MA55686-ICB2	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
10:32	MA55686-ICCV1	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
10:41	MA55686-CCB1	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
10:46	MA55686-CRI1	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
10:51	MA55686-CRID1	1																							
10:56	MA55686-ICSA1	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
11:01	MA55686-ICSAB1	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
11:06	MA55686-HSTD1	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
11:12	MA55686-HSTD2	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
11:17	ZZZZZZ	1																							
11:22	ZZZZZZ	1																							
11:27	MA55686-CRID2	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
11:32	ZZZZZZ	1																							
11:37	MA55686-CCV1	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
11:42	MA55686-CCB2	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
11:47	MP45202-MB1	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
11:52	MP45202-B1	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
11:57	MP45202-S1	1	X	X		X	X	X	X		X				X	X	X	X			X		X	X	
12:02	MP45202-S2	1	X	X		X	X	X	X		X				X	X	X	X			X		X	X	
12:07	JD83844-1	1	X	X		X	X	X	X		X				X	X	X	X			X		X	X	(a)
12:12	MP45202-SD1	5	X	X		X	X	X	X		X				X	X	X	X			X		X	X	
12:17	MP45202-PS1	1		X												X								X	
12:22	ZZZZZZ	1																							
12:27	ZZZZZZ	1																							
12:32	ZZZZZZ	1																							
12:37	MA55686-CCV2	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
12:42	MA55686-CCB3	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
12:47	ZZZZZZ	1																							
12:52	ZZZZZZ	1																							
12:57	ZZZZZZ	1																							
		Element: /	Al	Sb	As	Ba	Be	Cd	Ca	Cr	Co	Cu	Fe	Pb	Mg	Mn	Ni	K	Se	Ag	Na	Tl	V	Zn	

REPORTED ELEMENTS SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SF031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
Analyst: KP Run ID: MA55686
Parameters: Al,Sb,As,Ba,Be,Cd,Ca,Cr,Co,Cu,Fe,Pb,Mg,Mn,Ni,K,Se,Ag,Na,Tl,V,Zn

Time	Sample Description	Element: / Dilution	Al	Sb	As	Ba	Be	Cd	Ca	Cr	Co	Cu	Fe	Pb	Mg	Mn	Ni	K	Se	Ag	Na	Tl	V	Zn	
13:02	ZZZZZZ	1																							
13:07	ZZZZZZ	1																							
13:12	ZZZZZZ	1																							
13:17	ZZZZZZ	1																							
13:22	ZZZZZZ	1																							
13:27	ZZZZZZ	1																							
13:32	ZZZZZZ	1																							
13:37	MA55686-CCV3	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
13:42	MA55686-CCB4	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
13:47	ZZZZZZ	1																							
13:52	ZZZZZZ	1																							
13:57	ZZZZZZ	1																							
14:02	ZZZZZZ	1																							
14:07	ZZZZZZ	1																							
14:12	MP45216-MB1	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
14:17	MA55686-CCV4	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
14:21	MA55686-CCB5	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
14:27	MP45216-B1	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
14:31	MP45216-S1	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
14:36	MP45216-S2	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
14:41	JD83326-1	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	(a)
14:46	MP45216-SD1	5	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
14:51	MP45216-PS1	1		X																					
14:56	ZZZZZZ	1																							
15:01	ZZZZZZ	1																							
15:06	ZZZZZZ	10																							
15:11	ZZZZZZ	1																							
15:16	MA55686-CCV5	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
15:21	MA55686-CCB6	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
15:26	MP45159-MB1	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
15:31	MP45159-B1	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
15:36	MP45159-S1	1	X	X	X	X	X	X		X	X	X		X	X	X	X	X	X	X	X	X	X	X	
15:41	MP45159-S2	1	X	X	X	X	X	X		X	X	X		X	X	X	X	X	X	X	X	X	X	X	
		Element:	Al	Sb	As	Ba	Be	Cd	Ca	Cr	Co	Cu	Fe	Pb	Mg	Mn	Ni	K	Se	Ag	Na	Tl	V	Zn	

REPORTED ELEMENTS SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SF031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
Analyst: KP Run ID: MA55686
Parameters: Al,Sb,As,Ba,Be,Cd,Ca,Cr,Co,Cu,Fe,Pb,Mg,Mn,Ni,K,Se,Ag,Na,Tl,V,Zn

Time	Sample Description	Element: Dilution	Al	Sb	As	Ba	Be	Cd	Ca	Cr	Co	Cu	Fe	Pb	Mg	Mn	Ni	K	Se	Ag	Na	Tl	V	Zn	
15:45	JD83749-5	1	X	X	X	X	X	X		X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X (a)
15:50	MP45159-SD1	5	X	X	X	X	X	X		X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
15:55	MP45159-PS1	1		X										X		X		X							
16:00	ZZZZZZ	1																							
16:05	ZZZZZZ	1																							
16:10	ZZZZZZ	1																							
16:16	MA55686-CCV6	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
16:20	MA55686-CCB7	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
16:26	ZZZZZZ	1																							
16:31	ZZZZZZ	1																							
16:37	ZZZZZZ	1																							
16:42	ZZZZZZ	1																							
16:47	ZZZZZZ	1																							
16:52	ZZZZZZ	1																							
16:57	ZZZZZZ	1																							
17:02	ZZZZZZ	1																							
17:07	ZZZZZZ	1																							
17:12	ZZZZZZ	1																							
17:17	MA55686-CCV7	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
17:22	MA55686-CCB8	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
17:27	ZZZZZZ	1																							
17:32	ZZZZZZ	1																							

(a) Sample used for QC only; not part of login JD83927.

Element: Al Sb As Ba Be Cd Ca Cr Co Cu Fe Pb Mg Mn Ni K Se Ag Na Tl V Zn

INTERNAL STANDARD SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SF031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
Analyst: KP Run ID: MA55686
Parameters: Al,Sb,As,Ba,Be,Cd,Ca,Cr,Co,Cu,Fe,Pb,Mg,Mn,Ni,K,Se,Ag,Na,Tl,V,Zn

Time	Sample Description	Istd#1	Istd#2	Istd#3	Istd#4
09:59	MA55686-STD1	2819 R	114590 R	9421 R	6306 R
10:04	MA55686-STD2	2707	111960	9186	5805
10:09	MA55686-ICV1	No results reported for the elements associated with this internal standard.			
10:15	MA55686-ICB1	No results reported for the elements associated with this internal standard.			
10:21	MA55686-ICV2	2771	113300	9405	5940
10:27	MA55686-ICB2	2828	115060	9511	6305
10:32	MA55686-ICCV1	2765	113080	9443	5873
10:41	MA55686-CCB1	2842	115170	9563	6317
10:46	MA55686-CRI1	2822	115310	9618	6213
10:51	MA55686-CRID1	No results reported for the elements associated with this internal standard.			
10:56	MA55686-ICSA1	2620	106970	9345	5369
11:01	MA55686-ICSAB1	2620	106300	9315	5378
11:06	MA55686-HSTD1	2796	114840	9693	6242
11:12	MA55686-HSTD2	2633	108040	9318	5378
11:17	ZZZZZZ	2805	115170	9608	6334
11:22	ZZZZZZ	2788	114880	9626	6224
11:27	MA55686-CRID2	2831	114820	9591	6225
11:32	ZZZZZZ	2836	114440	9535	6243
11:37	MA55686-CCV1	2784	112480	9454	5863
11:42	MA55686-CCB2	2852	114700	9663	6267
11:47	MP45202-MB1	2860	116490	9785	6302
11:52	MP45202-B1	2815	113850	9582	5985
11:57	MP45202-S1	2689	111500	9701	6397
12:02	MP45202-S2	2738	112610	9705	6316
12:07	JD83844-1	2822	117270	10056	6487
12:12	MP45202-SD1	2852	114580	9818	6231
12:17	MP45202-PS1	2776	115440	10001	6390
12:22	ZZZZZZ	3083	123170	10614	6183
12:27	ZZZZZZ	2831	114980	9618	6226
12:32	ZZZZZZ	3062	121090	10543	6152
12:37	MA55686-CCV2	2806	113250	9601	5878
12:42	MA55686-CCB3	2861	115820	9683	6288
12:47	ZZZZZZ	2918	118670	10218	6281

INTERNAL STANDARD SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SF031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
Analyst: KP Run ID: MA55686
Parameters: Al,Sb,As,Ba,Be,Cd,Ca,Cr,Co,Cu,Fe,Pb,Mg,Mn,Ni,K,Se,Ag,Na,Tl,V,Zn

Time	Sample Description	Istd#1	Istd#2	Istd#3	Istd#4
12:52	ZZZZZZ	2903	119100	10299	6390
12:57	ZZZZZZ	2882	116920	9785	6280
13:02	ZZZZZZ	2883	116360	9934	6231
13:07	ZZZZZZ	2811	115780	9911	5777
13:12	ZZZZZZ	2808	116590	9975	5741
13:17	ZZZZZZ	2836	117180	10069	5848
13:22	ZZZZZZ	2804	116150	9935	5768
13:27	ZZZZZZ	2805	116060	9913	5798
13:32	ZZZZZZ	2788	115550	9921	5784
13:37	MA55686-CCV3	2813	114370	9605	5914
13:42	MA55686-CCB4	2864	115690	9739	6298
13:47	ZZZZZZ	2851	117500	10061	5896
13:52	ZZZZZZ	2838	117170	9939	5830
13:57	ZZZZZZ	2872	117680	10089	5935
14:02	ZZZZZZ	2869	118160	10031	5944
14:07	ZZZZZZ	2873	117860	10042	5920
14:12	MP45216-MB1	2841	116220	9797	6282
14:17	MA55686-CCV4	2810	113580	9671	5879
14:21	MA55686-CCB5	2872	116430	9729	6296
14:27	MP45216-B1	2831	114940	9724	6015
14:31	MP45216-S1	2857	116930	10000	6054
14:36	MP45216-S2	2865	116400	9889	6069
14:41	JD83326-1	2900	117810	10087	6235
14:46	MP45216-SD1	2905	116870	9869	6258
14:51	MP45216-PS1	2827	116120	9958	6033
14:56	ZZZZZZ	2899	117390	9990	6204
15:01	ZZZZZZ	2833	115220	9669	6207
15:06	ZZZZZZ	2939	118800	9969	6226
15:11	ZZZZZZ	2857	115480	9778	6237
15:16	MA55686-CCV5	2834	114130	9628	5919
15:21	MA55686-CCB6	2881	116280	9743	6269
15:26	MP45159-MB1	2888	117700	9839	6327
15:31	MP45159-B1	2850	115750	9816	6004

INTERNAL STANDARD SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SF031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
Analyst: KP Run ID: MA55686
Parameters: Al,Sb,As,Ba,Be,Cd,Ca,Cr,Co,Cu,Fe,Pb,Mg,Mn,Ni,K,Se,Ag,Na,Tl,V,Zn

Time	Sample Description	Istd#1	Istd#2	Istd#3	Istd#4
15:36	MP45159-S1	2797	116570	10181	5518
15:41	MP45159-S2	2889	118700	10224	5712
15:45	JD83749-5	2881	118670	10160	5723
15:50	MP45159-SD1	2890	116370	9777	6039
15:55	MP45159-PS1	2853	117750	10122	5651
16:00	ZZZZZZ	2893	118520	10177	5909
16:05	ZZZZZZ	2837	115900	10038	5613
16:10	ZZZZZZ	2787	115020	10076	5298
16:16	MA55686-CCV6	2820	114060	9665	5852
16:20	MA55686-CCB7	2880	115740	9675	6260
16:26	ZZZZZZ	2824	113950	9590	5858
16:31	ZZZZZZ	2851	116590	10090	5648
16:37	ZZZZZZ	3090	127210	10936	5687
16:42	ZZZZZZ	2898	117480	10004	5931
16:47	ZZZZZZ	2888	116900	9923	6161
16:52	ZZZZZZ	2906	118990	10189	5899
16:57	ZZZZZZ	8513 !	274800 !	19072 !	17128 !
17:02	ZZZZZZ	2875	117680	10143	5834
17:07	ZZZZZZ	2895	118780	10161	5893
17:12	ZZZZZZ	2889	116910	10121	5887
17:17	MA55686-CCV7	2811	113600	9574	5825
17:22	MA55686-CCB8	2874	115800	9696	6243
17:27	ZZZZZZ	3043	114000	10002	5779
17:32	ZZZZZZ	2662	112070	9388	5566

R = Reference for ISTD limits. ! = Outside limits.

LEGEND:

Istd#	Parameter	Limits
Istd#1	Yttrium (2243)	70-130 %
Istd#2	Yttrium (3600)	70-130 %
Istd#3	Yttrium (3710)	70-130 %
Istd#4	Indium	70-130 %

BLANK RESULTS SUMMARY
Part 1 - Initial and Continuing Calibration Blanks

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SF031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
QC Limits: result < RL Run ID: MA55686 Units: ug/l

Time: / Sample ID:			10:27 ICB2		10:41 CCB1		11:42 CCB2		12:42 CCB3	
Metal	RL	IDL	raw	final	raw	final	raw	final	raw	final
Aluminum	200	9.2	-14.1	<200	-11.0	<200	-21.3	<200	-13.9	<200
Antimony	6.0	2.8	0.900	<6.0	0.400	<6.0	0.200	<6.0	-0.400	<6.0
Arsenic	3.0	2.6	0.700	<3.0	1.10	<3.0	1.20	<3.0	0.600	<3.0
Barium	200	.2	-0.100	<200	-0.200	<200	-0.400	<200	-0.400	<200
Beryllium	1.0	.2	0.00	<1.0	0.00	<1.0	-0.100	<1.0	0.00	<1.0
Bismuth	20	2.5								
Boron	100	1.8								
Cadmium	3.0	.4	0.100	<3.0	0.00	<3.0	0.00	<3.0	0.00	<3.0
Calcium	5000	13	-1.00	<5000	-0.900	<5000	-0.800	<5000	-2.80	<5000
Cerium	100									
Chromium	10	.7	-0.200	<10	0.00	<10	-0.100	<10	0.100	<10
Cobalt	50	.6	0.00	<50	0.00	<50	-0.200	<50	0.100	<50
Copper	10	.7	-0.200	<10	2.10	<10	2.90	<10	2.50	<10
Iron	100	3.3	0.900	<100	3.00	<100	2.50	<100	3.70	<100
Lead	3.0	2	0.600	<3.0	0.00	<3.0	-1.00	<3.0	0.400	<3.0
Lithium	50	1.5								
Magnesium	5000	25	-23.9	<5000	-9.50	<5000	-28.5	<5000	-22.5	<5000
Manganese	15	.1	-0.100	<15	-0.100	<15	-0.100	<15	-0.100	<15
Molybdenum	20	.6								
Nickel	10	.8	0.00	<10	-0.100	<10	-0.100	<10	-0.200	<10
Phosphorus	50	7								
Potassium	10000	35	-8.30	<10000	-4.50	<10000	-5.90	<10000	-8.20	<10000
Selenium	10	3.6	1.00	<10	0.00	<10	-0.500	<10	-0.300	<10
Silicon	200	2.2								
Silver	10	.6	0.100	<10	0.200	<10	0.300	<10	0.200	<10
Sodium	10000	14	-2.00	<10000	-3.50	<10000	-10.4	<10000	-16.6	<10000
Strontium	10	.1								
Sulfur	50	3.7								
Thallium	10	5.2	1.70	<10	1.90	<10	2.40	<10	-0.900	<10
Tin	10	1.4								
Titanium	10	.8								
Tungsten	50	1.3								
Vanadium	50	.5	0.00	<50	-0.100	<50	-0.100	<50	0.100	<50

BLANK RESULTS SUMMARY
Part 1 - Initial and Continuing Calibration Blanks

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SF031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
QC Limits: result < RL Run ID: MA55686 Units: ug/l

Time: / Sample ID:			10:27 ICB2		10:41 CCB1		11:42 CCB2		12:42 CCB3	
Metal	RL	IDL	raw	final	raw	final	raw	final	raw	final
Zinc	20	.3	1.10	<20	2.60	<20	2.60	<20	2.60	<20
Zirconium	10	.5								

(*) Outside of QC limits
(anr) Analyte not requested

BLANK RESULTS SUMMARY
Part 1 - Initial and Continuing Calibration Blanks

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SF031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
QC Limits: result < RL Run ID: MA55686 Units: ug/l

Time:			13:42		14:21		15:21	
Sample ID:			CCB4		CCB5		CCB6	
Metal	RL	IDL	raw	final	raw	final	raw	final
Aluminum	200	9.2	-15.8	<200	-10.4	<200	-13.6	<200
Antimony	6.0	2.8	1.80	<6.0	0.500	<6.0	0.500	<6.0
Arsenic	3.0	2.6	0.500	<3.0	0.100	<3.0	0.300	<3.0
Barium	200	.2	-0.500	<200	-0.100	<200	-0.300	<200
Beryllium	1.0	.2	0.00	<1.0	-0.100	<1.0	-0.100	<1.0
Bismuth	20	2.5						
Boron	100	1.8						
Cadmium	3.0	.4	0.00	<3.0	0.00	<3.0	0.100	<3.0
Calcium	5000	13	1.00	<5000	0.00	<5000	2.10	<5000
Cerium	100							
Chromium	10	.7	-0.100	<10	0.00	<10	0.00	<10
Cobalt	50	.6	0.100	<50	-0.100	<50	-0.100	<50
Copper	10	.7	2.40	<10	2.50	<10	2.70	<10
Iron	100	3.3	1.60	<100	0.900	<100	1.60	<100
Lead	3.0	2	-0.600	<3.0	-0.200	<3.0	0.500	<3.0
Lithium	50	1.5						
Magnesium	5000	25	-22.4	<5000	-30.0	<5000	-30.0	<5000
Manganese	15	.1	-0.100	<15	-0.100	<15	-0.100	<15
Molybdenum	20	.6						
Nickel	10	.8	-0.200	<10	0.300	<10	-0.300	<10
Phosphorus	50	7						
Potassium	10000	35	-12.0	<10000	-17.3	<10000	11.4	<10000
Selenium	10	3.6	-0.600	<10	0.300	<10	1.30	<10
Silicon	200	2.2						
Silver	10	.6	0.500	<10	0.200	<10	0.600	<10
Sodium	10000	14	-17.2	<10000	-17.1	<10000	-18.1	<10000
Strontium	10	.1						
Sulfur	50	3.7						
Thallium	10	5.2	2.60	<10	1.70	<10	0.200	<10
Tin	10	1.4						
Titanium	10	.8						
Tungsten	50	1.3						
Vanadium	50	.5	-0.200	<50	-0.200	<50	0.100	<50

BLANK RESULTS SUMMARY
Part 1 - Initial and Continuing Calibration Blanks

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SF031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
QC Limits: result < RL Run ID: MA55686 Units: ug/l

Time:			13:42		14:21		15:21	
Sample ID:			CCB4		CCB5		CCB6	
Metal	RL	IDL	raw	final	raw	final	raw	final
Zinc	20	.3	2.30	<20	2.40	<20	2.20	<20
Zirconium	10	.5						

(*) Outside of QC limits
(anr) Analyte not requested

CALIBRATION CHECK STANDARDS SUMMARY
Initial Continuing Calibration Check

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SF031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
QC Limits: to % Recovery Run ID: MA55686 Units: ug/l

Time:		10:32	
Sample ID:	ICCV	ICCV1	
Metal	True	Results	% Rec
Aluminum	40000	38200	95.5
Antimony	2000	2000	100.0
Arsenic	2000	1990	99.5
Barium	2000	1960	98.0
Beryllium	2000	1940	97.0
Bismuth			
Boron			
Cadmium	2000	1990	99.5
Calcium	40000	38600	96.5
Cerium			
Chromium	2000	2030	101.5
Cobalt	2000	2030	101.5
Copper	2000	1940	97.0
Iron	40000	39600	99.0
Lead	2000	2050	102.5
Lithium			
Magnesium	40000	39500	98.8
Manganese	2000	2010	100.5
Molybdenum			
Nickel	2000	2060	103.0
Phosphorus			
Potassium	40000	39000	97.5
Selenium	2000	1990	99.5
Silicon			
Silver	250	245	98.0
Sodium	40000	38600	96.5
Strontium			
Sulfur			
Thallium	2000	2080	104.0
Tin			
Titanium			
Tungsten			
Vanadium	2000	2020	101.0

CALIBRATION CHECK STANDARDS SUMMARY
Initial Continuing Calibration Check

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SF031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
QC Limits: to % Recovery Run ID: MA55686 Units: ug/l

Time:		10:32	
Sample ID:	ICCV	ICCV1	
Metal	True	Results	% Rec
Zinc	2000	2020	101.0
Zirconium			

(*) Outside of QC limits
(anr) Analyte not requested

CALIBRATION CHECK STANDARDS SUMMARY
Initial and Continuing Calibration Checks

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SF031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
QC Limits: 95 to 105 % Recovery Run ID: MA55686 Units: ug/l

Time:		10:21			11:37			12:37	
Sample ID:	ICV	ICV2		CCV	CCV1		CCV	CCV2	
Metal	True	Results	% Rec	True	Results	% Rec	True	Results	% Rec
Aluminum	40000	37400	93.5*(a)	40000	38100	95.3	40000	37700	94.3
Antimony	2000	2020	101.0	2000	1990	99.5	2000	1980	99.0
Arsenic	2000	2050	102.5	2000	1970	98.5	2000	1960	98.0
Barium	2000	1990	99.5	2000	1970	98.5	2000	1970	98.5
Beryllium	2000	2010	100.5	2000	1920	96.0	2000	1890	94.5
Bismuth									
Boron									
Cadmium	2000	1970	98.5	2000	1970	98.5	2000	1960	98.0
Calcium	40000	39100	97.8	40000	38400	96.0	40000	37800	94.5
Cerium									
Chromium	2000	2010	100.5	2000	2050	102.5	2000	2050	102.5
Cobalt	2000	2020	101.0	2000	2030	101.5	2000	2030	101.5
Copper	2000	1990	99.5	2000	1940	97.0	2000	1940	97.0
Iron	40000	39200	98.0	40000	39800	99.5	40000	39300	98.3
Lead	2000	2050	102.5	2000	2050	102.5	2000	2050	102.5
Lithium									
Magnesium	40000	38500	96.3	40000	39600	99.0	40000	39200	98.0
Manganese	2000	2050	102.5	2000	2000	100.0	2000	1980	99.0
Molybdenum									
Nickel	2000	2040	102.0	2000	2070	103.5	2000	2070	103.5
Phosphorus									
Potassium	40000	37700	94.3*(a)	40000	39100	97.8	40000	38900	97.3
Selenium	2000	1970	98.5	2000	1970	98.5	2000	1970	98.5
Silicon									
Silver	250	248	99.2	250	246	98.4	250	246	98.4
Sodium	40000	38600	96.5	40000	38500	96.3	40000	38100	95.3
Strontium									
Sulfur									
Thallium	2000	2060	103.0	2000	2080	104.0	2000	2070	103.5
Tin									
Titanium									
Tungsten									
Vanadium	2000	2010	100.5	2000	2030	101.5	2000	2040	102.0

CALIBRATION CHECK STANDARDS SUMMARY
Initial and Continuing Calibration Checks

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SF031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
QC Limits: 95 to 105 % Recovery Run ID: MA55686 Units: ug/l

Time:		10:21			11:37			12:37	
Sample ID:	ICV	ICV2		CCV	CCV1		CCV	CCV2	
Metal	True	Results	% Rec	True	Results	% Rec	True	Results	% Rec
Zinc	2000	2060	103.0	2000	1990	99.5	2000	1980	99.0
Zirconium									

(*) Outside of QC limits
(anr) Analyte not requested
(a) Within 90 to 110 percent limits required for SW846 6010. No EPA 200.7 samples reported for this element in the area bracketed by this QC.

CALIBRATION CHECK STANDARDS SUMMARY
Initial and Continuing Calibration Checks

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SF031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
QC Limits: 95 to 105 % Recovery Run ID: MA55686 Units: ug/l

Time:		13:37			14:17			15:16	
Sample ID:	CCV	CCV3		CCV	CCV4		CCV	CCV5	
Metal	True	Results	% Rec	True	Results	% Rec	True	Results	% Rec
Aluminum	40000	38000	95.0	40000	37600	94.0	40000	37800	94.5
Antimony	2000	1980	99.0	2000	1990	99.5	2000	1990	99.5
Arsenic	2000	1960	98.0	2000	1980	99.0	2000	1970	98.5
Barium	2000	1970	98.5	2000	1980	99.0	2000	1980	99.0
Beryllium	2000	1900	95.0	2000	1890	94.5	2000	1900	95.0
Bismuth									
Boron									
Cadmium	2000	1960	98.0	2000	1970	98.5	2000	1970	98.5
Calcium	40000	38000	95.0	40000	37500	93.8	40000	37900	94.8
Cerium									
Chromium	2000	2020	101.0	2000	2050	102.5	2000	2060	103.0
Cobalt	2000	2010	100.5	2000	2040	102.0	2000	2040	102.0
Copper	2000	1930	96.5	2000	1950	97.5	2000	1950	97.5
Iron	40000	39300	98.3	40000	39000	97.5	40000	39300	98.3
Lead	2000	2040	102.0	2000	2060	103.0	2000	2070	103.5
Lithium									
Magnesium	40000	38800	97.0	40000	38600	96.5	40000	39000	97.5
Manganese	2000	1980	99.0	2000	1980	99.0	2000	1990	99.5
Molybdenum									
Nickel	2000	2060	103.0	2000	2080	104.0	2000	2100	105.0
Phosphorus									
Potassium	40000	38800	97.0	40000	38600	96.5	40000	38900	97.3
Selenium	2000	1970	98.5	2000	1980	99.0	2000	1990	99.5
Silicon									
Silver	250	244	97.6	250	246	98.4	250	247	98.8
Sodium	40000	38300	95.8	40000	37900	94.8	40000	38100	95.3
Strontium									
Sulfur									
Thallium	2000	2060	103.0	2000	2090	104.5	2000	2090	104.5
Tin									
Titanium									
Tungsten									
Vanadium	2000	2010	100.5	2000	2050	102.5	2000	2040	102.0

CALIBRATION CHECK STANDARDS SUMMARY
Initial and Continuing Calibration Checks

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SF031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
QC Limits: 95 to 105 % Recovery Run ID: MA55686 Units: ug/l

Time:		13:37			14:17			15:16	
Sample ID:	CCV	CCV3		CCV	CCV4		CCV	CCV5	
Metal	True	Results	% Rec	True	Results	% Rec	True	Results	% Rec
Zinc	2000	1970	98.5	2000	1990	99.5	2000	2000	100.0
Zirconium									

(*) Outside of QC limits
(anr) Analyte not requested

HIGH STANDARD CHECK SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SF031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
QC Limits: 90 to 110 % Recovery Run ID: MA55686 Units: ug/l

Time:		11:06			11:12	
Sample ID:	HSTD	HSTD1		HSTD	HSTD2	
Metal	True	Results	% Rec	True	Results	% Rec
Aluminum				300000	291000	97.0
Antimony	8000	8190	102.4			
Arsenic	8000	8040	100.5			
Barium	8000	7780	97.3			
Beryllium	8000	7760	97.0			
Bismuth						
Boron						
Cadmium	8000	7890	98.6			
Calcium				200000	184000	92.0
Cerium						
Chromium	8000	8270	103.4			
Cobalt	8000	8130	101.6			
Copper	8000	7600	95.0			
Iron				200000	188000	94.0
Lead	8000	8150	101.9			
Lithium						
Magnesium				300000	294000	98.0
Manganese	8000	7860	98.3			
Molybdenum						
Nickel	8000	8160	102.0			
Phosphorus						
Potassium				200000	198000	99.0
Selenium	8000	8030	100.4			
Silicon						
Silver	625	610	97.6			
Sodium				200000	191000	95.5
Strontium						
Sulfur						
Thallium	8000	8270	103.4			
Tin						
Titanium						
Tungsten						
Vanadium	8000	8160	102.0			

HIGH STANDARD CHECK SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SF031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
QC Limits: 90 to 110 % Recovery Run ID: MA55686 Units: ug/l

Time:		11:06			11:12	
Sample ID:	HSTD	HSTD1		HSTD	HSTD2	
Metal	True	Results	% Rec	True	Results	% Rec
Zinc	8000	8220	102.8			
Zirconium						

(*) Outside of QC limits
(anr) Analyte not requested

LOW CALIBRATION CHECK STANDARDS SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SF031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
QC Limits: CRI 80-120% CRIA 80-120% Run ID: MA55686 Units: ug/l

Time:				10:46		11:27	
Sample ID:	CRI	CRIA	CRID	CRI1		CRID2	
Metal	True	True	True	Results	% Rec	Results	% Rec
Aluminum	200	500	100	187	93.5	86.5	86.5
Antimony	6.0	20	3.0	6.80	113.3		
Arsenic	8.0	20	3.0	7.50	93.8	3.30	110.0
Barium	200		4.0	189	94.5	4.00	100.0
Beryllium	2.0		1.0	1.80	90.0	0.900	90.0
Bismuth	20						
Boron	100		10				
Cadmium	3.0		1.0	2.90	96.7	1.20	120.0
Calcium	5000	2000	1000	4590	91.8	966	96.6
Cerium							
Chromium	10		2.0	10.0	100.0	2.10	105.0
Cobalt	50		3.0	48.9	97.8	3.00	100.0
Copper	10		2.0	9.70	97.0		
Iron	100	500		103	103.0		
Lead	3.0	20	2.5	3.20	106.7		
Lithium	50						
Magnesium	5000	2000	100	4810	96.2	80.2	80.2
Manganese	15		3.0	14.5	96.7	3.00	100.0
Molybdenum	20						
Nickel	10		4.0	10.0	100.0	4.00	100.0
Phosphorus	50						
Potassium	5000		2000	4640	92.8	1940	97.0
Selenium	10	20	5.0	11.2	112.0		
Silicon	200						
Silver	5.0		2.0	4.90	98.0		
Sodium	5000		1000	4540	90.8	945	94.5
Strontium	10						
Sulfur	50						
Thallium	10		2.0	10.8	108.0		
Tin	10						
Titanium	10						
Tungsten	50						
Vanadium	50		2.0	48.9	97.8	2.20	110.0

LOW CALIBRATION CHECK STANDARDS SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SF031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
QC Limits: CRI 80-120% CRIA 80-120% Run ID: MA55686 Units: ug/l

Time:				10:46		11:27	
Sample ID:	CRI	CRIA	CRID	CRI1		CRID2	
Metal	True	True	True	Results	% Rec	Results	% Rec
Zinc	20		10	21.6	108.0	12.0	120.0
Zirconium	10						

(*) Outside of QC limits
(anr) Analyte not requested

INTERFERING ELEMENT CHECK STANDARDS SUMMARY
Part 1 - ICSA and ICSAB Standards

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SF031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
QC Limits: 80 to 120 % Recovery Run ID: MA55686 Units: ug/l

Time:			10:56		11:01	
Sample ID:	ICSA	ICSAB	ICSA1		ICSAB1	
Metal	True	True	Results	% Rec	Results	% Rec
Aluminum	500000	500000	484000	96.8	477000	95.4
Antimony		1000	-0.800		1000	100.0
Arsenic		1000	-1.80		1010	101.0
Barium		500	3.70		494	98.8
Beryllium		500	0.00		470	94.0
Bismuth		500	0.500		491	98.2
Boron		500	0.100		467	93.4
Cadmium		1000	1.60		1030	103.0
Calcium	400000	400000	357000	89.3	360000	90.0
Cerium			21.9		21.9	
Chromium		500	2.40		495	99.0
Cobalt		500	0.200		488	97.6
Copper		500	3.90		537	107.4
Iron	200000	200000	186000	93.0	187000	93.5
Lead		1000	1.20		965	96.5
Lithium		500	0.100		472	94.4
Magnesium	500000	500000	478000	95.6	486000	97.2
Manganese		500	1.20		505	101.0
Molybdenum		500	0.200		470	94.0
Nickel		1000	4.40		961	96.1
Phosphorus		500	26.7		506	101.2
Potassium			84.4		103	
Selenium		1000	-2.00		944	94.4
Silicon		500	-3.70		457	91.4
Silver		1000	1.10		1060	106.0
Sodium			8.10		15.5	
Strontium		500	-0.100		486	97.2
Sulfur		500	14.1		502	100.4
Thallium		1000	-2.80		953	95.3
Tin		500	-1.60		460	92.0
Titanium		500	2.00		511	102.2
Tungsten		500	6.30		475	95.0
Vanadium		500	-0.300		515	103.0

INTERFERING ELEMENT CHECK STANDARDS SUMMARY
Part 1 - ICSA and ICSAB Standards

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SF031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
QC Limits: 80 to 120 % Recovery Run ID: MA55686 Units: ug/l

Time:			10:56		11:01	
Sample ID:	ICSA	ICSAB	ICSA1		ICSAB1	
Metal	True	True	Results	% Rec	Results	% Rec
Zinc		1000	-4.50		878	87.8
Zirconium		500	1.30		468	93.6

(*) Outside of QC limits
(anr) Analyte not requested

SGS Instrument Runlog
Inorganics Analyses

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: H8031424S1.CSV Date Analyzed: 03/14/24 Methods: SW846 7471B
Analyst: LM Run ID: MA55688
Parameters: Hg

Time	Sample Description	Dilution Factor	PS Recov	Comments
15:08	MA55688-STD1	1		b=1.0862e-004,c=-1.8865e-002,rho=0.9999502
15:09	MA55688-STD2	1		STDB
15:10	MA55688-STD3	1		STDC
15:12	MA55688-STD4	1		STDD
15:14	MA55688-STD5	1		STDE
15:15	MA55688-STD6	1		STDF
15:19	ZZZZZZ	1		
15:20	MA55688-ICV1	1		
15:22	MA55688-ICB1	1		
15:24	MA55688-CCV1	1		
15:25	MA55688-CCB1	1		
15:27	MA55688-CRI1	1		
15:28	MP45276-MB1	1		
15:30	MP45276-B1	1		
15:31	MP45276-S1	1		
15:33	MP45276-S2	1		
15:35	JD83840-2	1		(sample used for QC only; not part of login JD83927)
15:37	ZZZZZZ	1		
15:39	ZZZZZZ	1		
15:41	MA55688-CCV2	1		
15:42	MA55688-CCB2	1		
15:44	ZZZZZZ	1		
15:46	ZZZZZZ	1		
15:48	ZZZZZZ	1		
15:49	ZZZZZZ	1		
15:51	ZZZZZZ	1		
15:53	ZZZZZZ	1		
15:55	ZZZZZZ	1		
15:56	ZZZZZZ	1		
15:58	MA55688-CCV3	1		
15:59	MA55688-CCB3	1		
16:01	ZZZZZZ	1		
16:03	ZZZZZZ	1		

SGS Instrument Runlog
Inorganics Analyses

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: H8031424S1.CSV Date Analyzed: 03/14/24 Methods: SW846 7471B
Analyst: LM Run ID: MA55688
Parameters: Hg

Time	Sample Description	Dilution Factor	PS Recov	Comments
16:04	ZZZZZZ	1		
16:06	ZZZZZZ	1		
16:07	ZZZZZZ	1		
16:09	ZZZZZZ	1		
16:10	ZZZZZZ	1		
16:12	ZZZZZZ	1		
16:13	MA55688-CCV4	1		
16:15	MA55688-CCB4	1		
16:17	MP45277-MB1	1		
16:18	MP45277-B1	1		
16:20	MP45277-S1	1		
16:21	MP45277-S2	1		
16:23	JD83895-4	1		(sample used for QC only; not part of login JD83927)
16:25	ZZZZZZ	1		
16:27	ZZZZZZ	1		
16:28	MA55688-CCV5	1		
16:30	MA55688-CCB5	1		
16:32	ZZZZZZ	1		
16:33	ZZZZZZ	1		
16:35	ZZZZZZ	1		
16:36	ZZZZZZ	1		
16:38	ZZZZZZ	1		
16:39	ZZZZZZ	1		
16:41	ZZZZZZ	1		
16:42	ZZZZZZ	1		
16:44	MA55688-CCV6	1		
16:45	MA55688-CCB6	1		
16:47	ZZZZZZ	1		
16:48	ZZZZZZ	1		
16:50	ZZZZZZ	1		
16:51	ZZZZZZ	1		
16:53	ZZZZZZ	1		
16:54	ZZZZZZ	1		

SGS Instrument Runlog
Inorganics Analyses

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: H8031424S1.CSV Date Analyzed: 03/14/24 Methods: SW846 7471B
Analyst: LM Run ID: MA55688
Parameters: Hg

Time	Sample Description	Dilution Factor	PS Recov	Comments
16:56	ZZZZZZ	1		
16:57	MA55688-CCV7	1		
16:59	MA55688-CCB7	1		
17:01	MP45278-MB1	1		
17:03	MP45278-B1	1		
17:04	MP45278-S1	1		
17:06	MP45278-S2	1		
17:08	JD83927-1	1		
17:09	JD83927-2	1		
17:11	JD83927-3	1		
17:12	MA55688-CCV8	1		
17:14	MA55688-CCB8	1		
17:16	JD83927-4	1		
17:17	JD83927-5	1		
17:19	JD83927-6	1		
17:21	JD83927-7	1		
17:22	JD83927-9	1		
17:24	JD83927-10	1		
17:25	JD83927-11	1		
17:27	JD83927-12	1		
17:28	MA55688-CCV9	1		
17:30	MA55688-CCB9	1		
17:31	JD83927-13	1		
17:33	JD83927-14	1		
17:34	JD83927-15	1		
17:36	JD83927-16	1		
17:37	JD83927-17	1		
17:39	JD83927-18	1		
---------->	Last reportable sample/prep for job JD83927			
17:41	ZZZZZZ	1		
17:42	ZZZZZZ	1		
17:44	MA55688-CCV10	1		
17:45	MA55688-CCB10	1		
---------->	Last reportable CCB for job JD83927			
17:47	MP45279-MB1	1		

SGS Instrument Runlog
Inorganics Analyses

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: H8031424S1.CSV Date Analyzed: 03/14/24 Methods: SW846 7471B
Analyst: LM Run ID: MA55688
Parameters: Hg

Time	Sample Description	Dilution Factor	PS Recov	Comments
17:49	MP45279-B1	1		
17:50	MP45279-S1	1		
17:52	MP45279-S2	1		
17:54	JD84072-1	1		(sample used for QC only; not part of login JD83927)
17:56	ZZZZZZ	1		
17:57	ZZZZZZ	1		
17:59	ZZZZZZ	1		
18:00	MA55688-CCV11	1		
18:02	MA55688-CCB11	1		
18:04	ZZZZZZ	1		
18:05	ZZZZZZ	1		
18:06	ZZZZZZ	1		
18:08	ZZZZZZ	1		
18:09	ZZZZZZ	1		
18:11	ZZZZZZ	1		
18:12	ZZZZZZ	1		
18:14	ZZZZZZ	1		
18:15	ZZZZZZ	1		
18:18	MA55688-CCV12	1		
18:20	MA55688-CCB12	1		
18:22	ZZZZZZ	1		
18:23	ZZZZZZ	1		
18:25	ZZZZZZ	1		
18:26	ZZZZZZ	1		
18:28	ZZZZZZ	1		
18:29	ZZZZZZ	1		
18:31	ZZZZZZ	1		
18:32	ZZZZZZ	1		
18:34	ZZZZZZ	1		
18:36	MA55688-CCV13	1		
18:37	MA55688-CCB13	1		
18:42	MP45276-S2	5		
18:43	MP45276-PS1	1		

SGS Instrument Runlog
Inorganics Analyses

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: H8031424S1.CSV Date Analyzed: 03/14/24 Methods: SW846 7471B
Analyst: LM Run ID: MA55688
Parameters: Hg

Time	Sample Description	Dilution Factor	PS Recov	Comments
18:45	ZZZZZZ	5		
18:47	ZZZZZZ	50		
18:49	MA55688-CCV14	1		
18:51	MA55688-CCB14	1		

Refer to raw data for calibration curve and standards.

REPORTED ELEMENTS SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: H8031424S1.CSV Date Analyzed: 03/14/24 Methods: SW846 7471B
Analyst: LM Run ID: MA55688
Parameters: Hg

Time	Sample Description	Element: Dilution	Hg	
15:19	ZZZZZZ	1		
15:20	MA55688-ICV1	1	X	
15:22	MA55688-ICB1	1	X	
15:24	MA55688-CCV1	1	X	
15:25	MA55688-CCB1	1	X	
15:27	MA55688-CRI1	1	X	
15:28	MP45276-MB1	1	X	
15:30	MP45276-B1	1	X	
15:31	MP45276-S1	1	X	
15:33	MP45276-S2	1		
15:35	JD83840-2	1	X	(a)
15:37	ZZZZZZ	1		
15:39	ZZZZZZ	1		
15:41	MA55688-CCV2	1	X	
15:42	MA55688-CCB2	1	X	
15:44	ZZZZZZ	1		
15:46	ZZZZZZ	1		
15:48	ZZZZZZ	1		
15:49	ZZZZZZ	1		
15:51	ZZZZZZ	1		
15:53	ZZZZZZ	1		
15:55	ZZZZZZ	1		
15:56	ZZZZZZ	1		
15:58	MA55688-CCV3	1	X	
15:59	MA55688-CCB3	1	X	
16:01	ZZZZZZ	1		
16:03	ZZZZZZ	1		
16:04	ZZZZZZ	1		
16:06	ZZZZZZ	1		
16:07	ZZZZZZ	1		
16:09	ZZZZZZ	1		
16:10	ZZZZZZ	1		
16:12	ZZZZZZ	1		
		Element:	Hg	

REPORTED ELEMENTS SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: H8031424S1.CSV Date Analyzed: 03/14/24 Methods: SW846 7471B
Analyst: LM Run ID: MA55688
Parameters: Hg

Time	Sample Description	Element: Dilution	Hg	
16:13	MA55688-CCV4	1	X	
16:15	MA55688-CCB4	1	X	
16:17	MP45277-MB1	1	X	
16:18	MP45277-B1	1	X	
16:20	MP45277-S1	1	X	
16:21	MP45277-S2	1	X	
16:23	JD83895-4	1	X	(a)
16:25	ZZZZZZ	1		
16:27	ZZZZZZ	1		
16:28	MA55688-CCV5	1	X	
16:30	MA55688-CCB5	1	X	
16:32	ZZZZZZ	1		
16:33	ZZZZZZ	1		
16:35	ZZZZZZ	1		
16:36	ZZZZZZ	1		
16:38	ZZZZZZ	1		
16:39	ZZZZZZ	1		
16:41	ZZZZZZ	1		
16:42	ZZZZZZ	1		
16:44	MA55688-CCV6	1	X	
16:45	MA55688-CCB6	1	X	
16:47	ZZZZZZ	1		
16:48	ZZZZZZ	1		
16:50	ZZZZZZ	1		
16:51	ZZZZZZ	1		
16:53	ZZZZZZ	1		
16:54	ZZZZZZ	1		
16:56	ZZZZZZ	1		
16:57	MA55688-CCV7	1	X	
16:59	MA55688-CCB7	1	X	
17:01	MP45278-MB1	1	X	
17:03	MP45278-B1	1	X	
17:04	MP45278-S1	1	X	
		Element:	Hg	

REPORTED ELEMENTS SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: H8031424S1.CSV Date Analyzed: 03/14/24 Methods: SW846 7471B
Analyst: LM Run ID: MA55688
Parameters: Hg

Time	Sample Description	Element: Dilution	Hg	
17:06	MP45278-S2	1	X	
17:08	JD83927-1	1	X	
17:09	JD83927-2	1	X	
17:11	JD83927-3	1	X	
17:12	MA55688-CCV8	1	X	
17:14	MA55688-CCB8	1	X	
17:16	JD83927-4	1	X	
17:17	JD83927-5	1	X	
17:19	JD83927-6	1	X	
17:21	JD83927-7	1	X	
17:22	JD83927-9	1	X	
17:24	JD83927-10	1	X	
17:25	JD83927-11	1	X	
17:27	JD83927-12	1	X	
17:28	MA55688-CCV9	1	X	
17:30	MA55688-CCB9	1	X	
17:31	JD83927-13	1	X	
17:33	JD83927-14	1	X	
17:34	JD83927-15	1	X	
17:36	JD83927-16	1	X	
17:37	JD83927-17	1	X	
17:39	JD83927-18	1	X	
17:41	ZZZZZZ	1		
17:42	ZZZZZZ	1		
17:44	MA55688-CCV10	1	X	
17:45	MA55688-CCB10	1	X	
17:47	MP45279-MB1	1	X	
17:49	MP45279-B1	1	X	
17:50	MP45279-S1	1	X	
17:52	MP45279-S2	1	X	
17:54	JD84072-1	1	X	(a)
17:56	ZZZZZZ	1		
17:57	ZZZZZZ	1		
		Element:	Hg	

REPORTED ELEMENTS SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: H8031424S1.CSV Date Analyzed: 03/14/24 Methods: SW846 7471B
Analyst: LM Run ID: MA55688
Parameters: Hg

Time	Sample Description	Element: Dilution	Hg
17:59	ZZZZZZ	1	
18:00	MA55688-CCV11	1	X
18:02	MA55688-CCB11	1	X
18:04	ZZZZZZ	1	
18:05	ZZZZZZ	1	
18:06	ZZZZZZ	1	
18:08	ZZZZZZ	1	
18:09	ZZZZZZ	1	
18:11	ZZZZZZ	1	
18:12	ZZZZZZ	1	
18:14	ZZZZZZ	1	
18:15	ZZZZZZ	1	
18:18	MA55688-CCV12	1	X
18:20	MA55688-CCB12	1	X
18:22	ZZZZZZ	1	
18:23	ZZZZZZ	1	
18:25	ZZZZZZ	1	
18:26	ZZZZZZ	1	
18:28	ZZZZZZ	1	
18:29	ZZZZZZ	1	
18:31	ZZZZZZ	1	
18:32	ZZZZZZ	1	
18:34	ZZZZZZ	1	
18:36	MA55688-CCV13	1	X
18:37	MA55688-CCB13	1	X
18:42	MP45276-S2	5	X
18:43	MP45276-PS1	1	X
18:45	ZZZZZZ	5	
18:47	ZZZZZZ	50	
18:49	MA55688-CCV14	1	X
18:51	MA55688-CCB14	1	X

(a) Sample used for QC only; not part of login JD83927.

Element: Hg

BLANK RESULTS SUMMARY
Part 1 - Initial and Continuing Calibration Blanks

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: H8031424S1.CSV Date Analyzed: 03/14/24 Methods: SW846 7471B
QC Limits: result < RL Run ID: MA55688 Units: ug/l

Time: / Sample ID:			15:22 ICB1		15:25 CCB1		15:42 CCB2		15:59 CCB3	
Metal	RL	IDL	raw	final	raw	final	raw	final	raw	final
Mercury	0.20	.013	-0.0238	<0.20	-0.0120	<0.20	-0.0283	<0.20	-0.0165	<0.20

(*) Outside of QC limits
(anr) Analyte not requested

BLANK RESULTS SUMMARY
Part 1 - Initial and Continuing Calibration Blanks

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: H8031424S1.CSV Date Analyzed: 03/14/24 Methods: SW846 7471B
QC Limits: result < RL Run ID: MA55688 Units: ug/l

Time: / Sample ID:			16:15 CCB4		16:30 CCB5		16:45 CCB6		16:59 CCB7	
Metal	RL	IDL	raw	final	raw	final	raw	final	raw	final
Mercury	0.20	.013	-0.0153	<0.20	-0.00920	<0.20	-0.0168	<0.20	-0.0121	<0.20

(*) Outside of QC limits
(anr) Analyte not requested

BLANK RESULTS SUMMARY
Part 1 - Initial and Continuing Calibration Blanks

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: H8031424S1.CSV Date Analyzed: 03/14/24 Methods: SW846 7471B
QC Limits: result < RL Run ID: MA55688 Units: ug/l

Time:			17:14		17:30		17:45	
Sample ID:			CCB8		CCB9		CCB10	
Metal	RL	IDL	raw	final	raw	final	raw	final
Mercury	0.20	.013	-0.0214	<0.20	-0.00970	<0.20	-0.0154	<0.20

(*) Outside of QC limits
(anr) Analyte not requested

CALIBRATION CHECK STANDARDS SUMMARY
Initial and Continuing Calibration Checks

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: H8031424S1.CSV Date Analyzed: 03/14/24 Methods: SW846 7471B
QC Limits: 90 to 110 % Recovery Run ID: MA55688 Units: ug/l

Time:		15:20			15:24			15:41	
Sample ID:	ICV	ICV1		CCV	CCV1		CCV	CCV2	
Metal	True	Results	% Rec	True	Results	% Rec	True	Results	% Rec
Mercury	3	3.03	101.0	2.5	2.58	103.2	2.5	2.47	98.8

(*) Outside of QC limits
(anr) Analyte not requested

CALIBRATION CHECK STANDARDS SUMMARY
Initial and Continuing Calibration Checks

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: H8031424S1.CSV Date Analyzed: 03/14/24 Methods: SW846 7471B
QC Limits: 90 to 110 % Recovery Run ID: MA55688 Units: ug/l

Time:		15:58			16:13			16:28	
Sample ID:	CCV	CCV3		CCV	CCV4		CCV	CCV5	
Metal	True	Results	% Rec	True	Results	% Rec	True	Results	% Rec
Mercury	2.5	2.48	99.2	2.5	2.51	100.4	2.5	2.49	99.6

(*) Outside of QC limits
(anr) Analyte not requested

CALIBRATION CHECK STANDARDS SUMMARY
Initial and Continuing Calibration Checks

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: H8031424S1.CSV Date Analyzed: 03/14/24 Methods: SW846 7471B
QC Limits: 90 to 110 % Recovery Run ID: MA55688 Units: ug/l

Time:		16:44			16:57			17:12	
Sample ID:	CCV	CCV6		CCV	CCV7		CCV	CCV8	
Metal	True	Results	% Rec	True	Results	% Rec	True	Results	% Rec
Mercury	2.5	2.49	99.6	2.5	2.48	99.2	2.5	2.46	98.4

(*) Outside of QC limits
(anr) Analyte not requested

CALIBRATION CHECK STANDARDS SUMMARY
Initial and Continuing Calibration Checks

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: H8031424S1.CSV Date Analyzed: 03/14/24 Methods: SW846 7471B
QC Limits: 90 to 110 % Recovery Run ID: MA55688 Units: ug/l

Time:		17:28			17:44	
Sample ID:	CCV	CCV9		CCV	CCV10	
Metal	True	Results	% Rec	True	Results	% Rec
Mercury	2.5	2.47	98.8	2.5	2.45	98.0

(*) Outside of QC limits
(anr) Analyte not requested

LOW CALIBRATION CHECK STANDARDS SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: H8031424S1.CSV Date Analyzed: 03/14/24 Methods: SW846 7471B
QC Limits: 70 to 130 % Recovery Run ID: MA55688 Units: ug/l

Time:			15:27	
Sample ID:	CRI	CRIA	CRI1	
Metal	True	True	Results	% Rec
Mercury	0.20		0.194	97.0

(*) Outside of QC limits
(anr) Analyte not requested

SGS Instrument Runlog
Inorganics Analyses

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SC031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
Analyst: MM Run ID: MA55691
Parameters: Al,Sb,As,Ba,Be,Cd,Ca,Cr,Co,Cu,Fe,Pb,Mg,Mn,Ni,K,Se,Ag,Na,Tl,V,Zn

Time	Sample Description	Dilution Factor	PS Recov	Comments
12:42	MA55691-STD1	1		STDA
12:47	MA55691-STD2	1		STDB
12:52	MA55691-ICV1	1		
12:59	MA55691-ICB1	1		
13:06	MA55691-ICCV1	1		
13:12	MA55691-CCB1	1		
13:19	MA55691-CRI1	1		
13:24	MA55691-CRID1	1		
13:29	MA55691-ICSA1	1		
13:34	MA55691-ICSAB1	1		
13:39	MA55691-HSTD1	1		
13:45	MA55691-HSTD2	1		
13:50	ZZZZZZ	1		
13:55	ZZZZZZ	1		
14:00	ZZZZZZ	1		
14:05	MA55691-CCV1	1		
14:10	MA55691-CCB2	1		
14:15	ZZZZZZ	1		
14:20	ZZZZZZ	1		
14:25	JD83927-1	1		
14:30	JD83927-2	1		
14:34	JD83927-3	1		
14:39	JD83927-4	1		
14:44	JD83927-5	1		
14:49	JD83927-6	1		
14:54	JD83927-7	1		
14:59	JD83927-8	1		
15:04	MA55691-CCV2	1		
15:09	MA55691-CCB3	1		
15:14	ZZZZZZ	1		
15:19	ZZZZZZ	1		
15:24	ZZZZZZ	1		
15:29	ZZZZZZ	1		

SGS Instrument Runlog
Inorganics Analyses

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SC031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
Analyst: MM Run ID: MA55691
Parameters: Al,Sb,As,Ba,Be,Cd,Ca,Cr,Co,Cu,Fe,Pb,Mg,Mn,Ni,K,Se,Ag,Na,Tl,V,Zn

Time	Sample Description	Dilution Factor	PS Recov	Comments
15:34	ZZZZZZ	1		
15:39	ZZZZZZ	1		
15:43	ZZZZZZ	1		
15:48	ZZZZZZ	1		
15:53	ZZZZZZ	1		
15:58	ZZZZZZ	1		
16:03	ZZZZZZ	1		
16:08	ZZZZZZ	1		
16:13	ZZZZZZ	1		
16:18	ZZZZZZ	1		
16:23	ZZZZZZ	1		
16:28	ZZZZZZ	1		
16:33	MA55691-CCV3	1		
16:38	MA55691-CCB4	1		
16:43	JD83927-9	1		
16:48	JD83927-10	1		
16:53	JD83927-11	1		
16:58	JD83927-12	1		
17:03	JD83927-13	1		
17:08	JD83927-14	1		
17:12	JD83927-15	1		
17:17	JD83927-16	1		
17:22	JD83927-17	1		
17:27	JD83927-18	1		
---------->	Last reportable sample/prep for job JD83927			
17:32	MA55691-CCV4	1		
17:37	MA55691-CCB5	1		
---------->	Last reportable CCB for job JD83927			
17:42	ZZZZZZ	1		
17:47	ZZZZZZ	1		
17:52	ZZZZZZ	1		
17:57	ZZZZZZ	1		
18:01	ZZZZZZ	1		
18:06	ZZZZZZ	1		
18:11	ZZZZZZ	1		

SGS Instrument Runlog
Inorganics Analyses

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SC031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
Analyst: MM Run ID: MA55691
Parameters: Al,Sb,As,Ba,Be,Cd,Ca,Cr,Co,Cu,Fe,Pb,Mg,Mn,Ni,K,Se,Ag,Na,Tl,V,Zn

Time	Sample Description	Dilution Factor	PS Recov	Comments
18:16	ZZZZZZ	1		
18:21	ZZZZZZ	1		
18:26	MP45190-B1	1		Batch to redigest, spk blank failes
18:31	MA55691-CCV5	1		
18:35	MA55691-CCB6	1		
18:40	MP45190-MB1	1		
18:45	MP45190-B2	1		
18:50	MP45190-S1	1		
18:55	MP45190-S2	1		
19:00	JD83832-2	1		(sample used for QC only; not part of login JD83927)
19:04	MP45190-SD1	5		
19:09	ZZZZZZ	1		
19:14	ZZZZZZ	1		
19:19	ZZZZZZ	1		
19:24	ZZZZZZ	1		
19:29	MA55691-CCV6	1		
19:34	MA55691-CCB7	1		
19:39	JD83786-5F	1		(sample used for QC only; not part of login JD83927)
19:44	ZZZZZZ	1		
19:48	ZZZZZZ	1		
19:54	ZZZZZZ	1		
19:59	ZZZZZZ	1		
20:04	ZZZZZZ	1		
20:09	ZZZZZZ	1		
20:14	ZZZZZZ	1		
20:19	ZZZZZZ	1		
20:24	ZZZZZZ	1		
20:29	MA55691-CCV7	1		
20:33	MA55691-CCB8	1		
20:38	ZZZZZZ	1		
20:43	ZZZZZZ	1		
20:48	ZZZZZZ	1		
20:53	ZZZZZZ	1		

SGS Instrument Runlog
Inorganics Analyses

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SC031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
Analyst: MM Run ID: MA55691
Parameters: Al,Sb,As,Ba,Be,Cd,Ca,Cr,Co,Cu,Fe,Pb,Mg,Mn,Ni,K,Se,Ag,Na,Tl,V,Zn

Time	Sample Description	Dilution Factor	PS Recov	Comments
20:58	ZZZZZZ	1		
21:03	ZZZZZZ	1		
21:08	MP45202-S1	10		needs post spike on dilution for CR and Ag
21:12	MP45202-S2	10		
21:17	JD83844-1	10		(sample used for QC only; not part of login JD83927)
21:22	MP45202-SD1	50		
21:27	MA55691-CCV8	1		
21:31	MA55691-CCB9	1		
21:36	ZZZZZZ	5		
21:41	ZZZZZZ	2		
21:46	ZZZZZZ	5		
21:51	ZZZZZZ	10		
21:56	ZZZZZZ	2		
22:01	ZZZZZZ	2		
22:06	MP45235-MB1	1		
22:10	MP45235-B1	1		
22:15	MP45235-S1	1		
22:20	MP45235-S2	1		
22:25	MA55691-CCV9	1		
22:30	MA55691-CCB10	1		
22:35	JD83234-1	1		(sample used for QC only; not part of login JD83927)
22:39	MP45235-SD1	5		
22:44	MP45235-PS1	1		
22:49	ZZZZZZ	1		
22:54	ZZZZZZ	1		
22:59	ZZZZZZ	1		
23:03	ZZZZZZ	1		
23:09	MP45217-MB1	1		
23:13	MP45217-B1	1		
23:18	MP45217-S1	1		
23:23	MA55691-CCV10	1		
23:28	MA55691-CCB11	1		
23:33	MP45217-S2	1		

SGS Instrument Runlog
Inorganics Analyses

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SC031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
Analyst: MM Run ID: MA55691
Parameters: Al,Sb,As,Ba,Be,Cd,Ca,Cr,Co,Cu,Fe,Pb,Mg,Mn,Ni,K,Se,Ag,Na,Tl,V,Zn

Time	Sample Description	Dilution Factor	PS Recov	Comments
23:38	JD83721-21	1		(sample used for QC only; not part of login JD83927)
23:42	MP45217-SD1	5		
23:47	ZZZZZZ	1		
23:52	ZZZZZZ	1		
23:57	ZZZZZZ	1		
00:02	ZZZZZZ	1		
00:07	ZZZZZZ	1		
00:12	ZZZZZZ	1		
00:16	ZZZZZZ	1		
00:21	MA55691-CCV11	1		
00:26	MA55691-CCB12	1		
00:31	ZZZZZZ	1		
00:36	ZZZZZZ	1		
00:41	ZZZZZZ	1		
00:46	ZZZZZZ	1		
00:51	ZZZZZZ	1		
00:56	ZZZZZZ	1		
01:00	ZZZZZZ	1		
01:05	ZZZZZZ	1		
01:10	ZZZZZZ	1		
01:15	ZZZZZZ	1		
01:20	MA55691-CCV12	1		
01:24	MA55691-CCB13	1		
01:29	ZZZZZZ	1		
01:34	ZZZZZZ	1		
01:39	MP45159-S1	2		Ca stil high
01:44	MP45159-S2	2		rerun with _s1 for ca
01:49	JD83749-5	2		(sample used for QC only; not part of login JD83927)
01:54	MP45159-SD1	10		
01:59	ZZZZZZ	5		
02:03	ZZZZZZ	10		
02:08	ZZZZZZ	5		
02:13	ZZZZZZ	2		

SGS Instrument Runlog
Inorganics Analyses

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SC031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
Analyst: MM Run ID: MA55691
Parameters: Al,Sb,As,Ba,Be,Cd,Ca,Cr,Co,Cu,Fe,Pb,Mg,Mn,Ni,K,Se,Ag,Na,Tl,V,Zn

Time	Sample Description	Dilution Factor	PS Recov	Comments
02:18	MA55691-CCV13	1		
02:23	MA55691-CCB14	1		
02:28	ZZZZZZ	2		
02:33	ZZZZZZ	2		
02:38	ZZZZZZ	1		
02:43	ZZZZZZ	1		
02:48	ZZZZZZ	1		
02:53	ZZZZZZ	1		
02:58	ZZZZZZ	1		
03:03	MA55691-CCV14	1		
03:08	MA55691-CCB15	1		
08:45	ZZZZZZ	1		

Refer to raw data for calibration curve and standards.

REPORTED ELEMENTS SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SC031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
Analyst: MM Run ID: MA55691
Parameters: Al,Sb,As,Ba,Be,Cd,Ca,Cr,Co,Cu,Fe,Pb,Mg,Mn,Ni,K,Se,Ag,Na,Tl,V,Zn

Time	Sample Description	Element: Dilution	Al	Sb	As	Ba	Be	Cd	Ca	Cr	Co	Cu	Fe	Pb	Mg	Mn	Ni	K	Se	Ag	Na	Tl	V	Zn
12:52	MA55691-ICV1	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
12:59	MA55691-ICB1	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
13:06	MA55691-ICCV1	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
13:12	MA55691-CCB1	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
13:19	MA55691-CRI1	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
13:24	MA55691-CRID1	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
13:29	MA55691-ICSA1	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
13:34	MA55691-ICSAB1	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
13:39	MA55691-HSTD1	1	X	X	X	X	X	X	X	X	X		X	X	X	X	X	X	X	X	X	X	X	X
13:45	MA55691-HSTD2	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
13:50	ZZZZZZ	1																						
13:55	ZZZZZZ	1																						
14:00	ZZZZZZ	1																						
14:05	MA55691-CCV1	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
14:10	MA55691-CCB2	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
14:15	ZZZZZZ	1																						
14:20	ZZZZZZ	1																						
14:25	JD83927-1	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
14:30	JD83927-2	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
14:34	JD83927-3	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
14:39	JD83927-4	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
14:44	JD83927-5	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
14:49	JD83927-6	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
14:54	JD83927-7	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
14:59	JD83927-8	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
15:04	MA55691-CCV2	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
15:09	MA55691-CCB3	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
15:14	ZZZZZZ	1																						
15:19	ZZZZZZ	1																						
15:24	ZZZZZZ	1																						
15:29	ZZZZZZ	1																						
15:34	ZZZZZZ	1																						
15:39	ZZZZZZ	1																						
		Element:	Al	Sb	As	Ba	Be	Cd	Ca	Cr	Co	Cu	Fe	Pb	Mg	Mn	Ni	K	Se	Ag	Na	Tl	V	Zn

REPORTED ELEMENTS SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SC031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
Analyst: MM Run ID: MA55691
Parameters: Al,Sb,As,Ba,Be,Cd,Ca,Cr,Co,Cu,Fe,Pb,Mg,Mn,Ni,K,Se,Ag,Na,Tl,V,Zn

Time	Sample Description	Element: Dilution	Al	Sb	As	Ba	Be	Cd	Ca	Cr	Co	Cu	Fe	Pb	Mg	Mn	Ni	K	Se	Ag	Na	Tl	V	Zn
15:43	ZZZZZZ	1																						
15:48	ZZZZZZ	1																						
15:53	ZZZZZZ	1																						
15:58	ZZZZZZ	1																						
16:03	ZZZZZZ	1																						
16:08	ZZZZZZ	1																						
16:13	ZZZZZZ	1																						
16:18	ZZZZZZ	1																						
16:23	ZZZZZZ	1																						
16:28	ZZZZZZ	1																						
16:33	MA55691-CCV3	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
16:38	MA55691-CCB4	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
16:43	JD83927-9	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
16:48	JD83927-10	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
16:53	JD83927-11	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
16:58	JD83927-12	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
17:03	JD83927-13	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
17:08	JD83927-14	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
17:12	JD83927-15	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
17:17	JD83927-16	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
17:22	JD83927-17	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
17:27	JD83927-18	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
17:32	MA55691-CCV4	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
17:37	MA55691-CCB5	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
17:42	ZZZZZZ	1																						
17:47	ZZZZZZ	1																						
17:52	ZZZZZZ	1																						
17:57	ZZZZZZ	1																						
18:01	ZZZZZZ	1																						
18:06	ZZZZZZ	1																						
18:11	ZZZZZZ	1																						
18:16	ZZZZZZ	1																						
18:21	ZZZZZZ	1																						
		Element:	Al	Sb	As	Ba	Be	Cd	Ca	Cr	Co	Cu	Fe	Pb	Mg	Mn	Ni	K	Se	Ag	Na	Tl	V	Zn

REPORTED ELEMENTS SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SC031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
Analyst: MM Run ID: MA55691
Parameters: Al,Sb,As,Ba,Be,Cd,Ca,Cr,Co,Cu,Fe,Pb,Mg,Mn,Ni,K,Se,Ag,Na,Tl,V,Zn

Time	Sample Description	Element: / Dilution	Al	Sb	As	Ba	Be	Cd	Ca	Cr	Co	Cu	Fe	Pb	Mg	Mn	Ni	K	Se	Ag	Na	Tl	V	Zn
18:26	MP45190-B1	1	Batch to redigest, spk blank failes																					
18:31	MA55691-CCV5	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
18:35	MA55691-CCB6	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
18:40	MP45190-MB1	1																						
18:45	MP45190-B2	1																						
18:50	MP45190-S1	1																						
18:55	MP45190-S2	1																						
19:00	JD83832-2	1																						
19:04	MP45190-SD1	5																						
19:09	ZZZZZZ	1																						
19:14	ZZZZZZ	1																						
19:19	ZZZZZZ	1																						
19:24	ZZZZZZ	1																						
19:29	MA55691-CCV6	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
19:34	MA55691-CCB7	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
19:39	JD83786-5F	1																						
19:44	ZZZZZZ	1																						
19:48	ZZZZZZ	1																						
19:54	ZZZZZZ	1																						
19:59	ZZZZZZ	1																						
20:04	ZZZZZZ	1																						
20:09	ZZZZZZ	1																						
20:14	ZZZZZZ	1																						
20:19	ZZZZZZ	1																						
20:24	ZZZZZZ	1																						
20:29	MA55691-CCV7	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
20:33	MA55691-CCB8	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
20:38	ZZZZZZ	1																						
20:43	ZZZZZZ	1																						
20:48	ZZZZZZ	1																						
20:53	ZZZZZZ	1																						
20:58	ZZZZZZ	1																						
21:03	ZZZZZZ	1																						
		Element:	Al	Sb	As	Ba	Be	Cd	Ca	Cr	Co	Cu	Fe	Pb	Mg	Mn	Ni	K	Se	Ag	Na	Tl	V	Zn

REPORTED ELEMENTS SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SC031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
Analyst: MM Run ID: MA55691
Parameters: Al,Sb,As,Ba,Be,Cd,Ca,Cr,Co,Cu,Fe,Pb,Mg,Mn,Ni,K,Se,Ag,Na,Tl,V,Zn

Time	Sample Description	Element: Dilution	Al	Sb	As	Ba	Be	Cd	Ca	Cr	Co	Cu	Fe	Pb	Mg	Mn	Ni	K	Se	Ag	Na	Tl	V	Zn	
21:08	MP45202-S1	10			X					X		X	X	X					X	X		X			
21:12	MP45202-S2	10			X					X		X	X	X					X	X		X			
21:17	JD83844-1	10			X					X		X	X	X					X	X		X			(a)
21:22	MP45202-SD1	50			X					X		X	X	X					X	X		X			
21:27	MA55691-CCV8	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
21:31	MA55691-CCB9	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
21:36	ZZZZZZ	5																							
21:41	ZZZZZZ	2																							
21:46	ZZZZZZ	5																							
21:51	ZZZZZZ	10																							
21:56	ZZZZZZ	2																							
22:01	ZZZZZZ	2																							
22:06	MP45235-MB1	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
22:10	MP45235-B1	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
22:15	MP45235-S1	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
22:20	MP45235-S2	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
22:25	MA55691-CCV9	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
22:30	MA55691-CCB10	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
22:35	JD83234-1	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	(a)
22:39	MP45235-SD1	5	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
22:44	MP45235-PS1	1		X																X					
22:49	ZZZZZZ	1																							
22:54	ZZZZZZ	1																							
22:59	ZZZZZZ	1																							
23:03	ZZZZZZ	1																							
23:09	MP45217-MB1	1			X									X											
23:13	MP45217-B1	1			X									X											
23:18	MP45217-S1	1			X									X											
23:23	MA55691-CCV10	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
23:28	MA55691-CCB11	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
23:33	MP45217-S2	1			X									X											
23:38	JD83721-21	1			X																				(a)
23:42	MP45217-SD1	5			X									X											
		Element:	Al	Sb	As	Ba	Be	Cd	Ca	Cr	Co	Cu	Fe	Pb	Mg	Mn	Ni	K	Se	Ag	Na	Tl	V	Zn	

REPORTED ELEMENTS SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SC031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
Analyst: MM Run ID: MA55691
Parameters: Al,Sb,As,Ba,Be,Cd,Ca,Cr,Co,Cu,Fe,Pb,Mg,Mn,Ni,K,Se,Ag,Na,Tl,V,Zn

Time	Sample Description	Element: Dilution	Al	Sb	As	Ba	Be	Cd	Ca	Cr	Co	Cu	Fe	Pb	Mg	Mn	Ni	K	Se	Ag	Na	Tl	V	Zn	
23:47	ZZZZZZ	1																							
23:52	ZZZZZZ	1																							
23:57	ZZZZZZ	1																							
00:02	ZZZZZZ	1																							
00:07	ZZZZZZ	1																							
00:12	ZZZZZZ	1																							
00:16	ZZZZZZ	1																							
00:21	MA55691-CCV11	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
00:26	MA55691-CCB12	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
00:31	ZZZZZZ	1																							
00:36	ZZZZZZ	1																							
00:41	ZZZZZZ	1																							
00:46	ZZZZZZ	1																							
00:51	ZZZZZZ	1																							
00:56	ZZZZZZ	1																							
01:00	ZZZZZZ	1																							
01:05	ZZZZZZ	1																							
01:10	ZZZZZZ	1																							
01:15	ZZZZZZ	1																							
01:20	MA55691-CCV12	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
01:24	MA55691-CCB13	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
01:29	ZZZZZZ	1																							
01:34	ZZZZZZ	1																							
01:39	MP45159-S1	2											X												
01:44	MP45159-S2	2											X												
01:49	JD83749-5	2							X																(a)
01:54	MP45159-SD1	10							X																
01:59	ZZZZZZ	5																							
02:03	ZZZZZZ	10																							
02:08	ZZZZZZ	5																							
02:13	ZZZZZZ	2																							
02:18	MA55691-CCV13	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
02:23	MA55691-CCB14	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
		Element:	Al	Sb	As	Ba	Be	Cd	Ca	Cr	Co	Cu	Fe	Pb	Mg	Mn	Ni	K	Se	Ag	Na	Tl	V	Zn	

REPORTED ELEMENTS SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SC031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
Analyst: MM Run ID: MA55691
Parameters: Al,Sb,As,Ba,Be,Cd,Ca,Cr,Co,Cu,Fe,Pb,Mg,Mn,Ni,K,Se,Ag,Na,Tl,V,Zn

Time	Sample Description	Element: Dilution	Al	Sb	As	Ba	Be	Cd	Ca	Cr	Co	Cu	Fe	Pb	Mg	Mn	Ni	K	Se	Ag	Na	Tl	V	Zn
02:28	ZZZZZZ	2																						
02:33	ZZZZZZ	2																						
02:38	ZZZZZZ	1																						
02:43	ZZZZZZ	1																						
02:48	ZZZZZZ	1																						
02:53	ZZZZZZ	1																						
02:58	ZZZZZZ	1																						
03:03	MA55691-CCV14	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
03:08	MA55691-CCB15	1	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
08:45	ZZZZZZ	1																						

(a) Sample used for QC only; not part of login JD83927.

Element: Al Sb As Ba Be Cd Ca Cr Co Cu Fe Pb Mg Mn Ni K Se Ag Na Tl V Zn

INTERNAL STANDARD SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SC031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
Analyst: MM Run ID: MA55691
Parameters: Al,Sb,As,Ba,Be,Cd,Ca,Cr,Co,Cu,Fe,Pb,Mg,Mn,Ni,K,Se,Ag,Na,Tl,V,Zn

Time	Sample Description	Istd#1	Istd#2	Istd#3	Istd#4
12:42	MA55691-STD1	6196 R	103820 R	10759 R	10120 R
12:47	MA55691-STD2	5924	98400	10609	9448
12:52	MA55691-ICV1	6018	100570	10583	9623
12:59	MA55691-ICB1	6131	102700	10535	10043
13:06	MA55691-ICCV1	5972	98656	10383	9566
13:12	MA55691-CCB1	6066	102290	10414	9965
13:19	MA55691-CRI1	6062	101120	10176	9897
13:24	MA55691-CRID1	6083	101010	10311	9968
13:29	MA55691-ICSA1	5578	90732	10036	8944
13:34	MA55691-ICSAB1	5763	94665	10545	9159
13:39	MA55691-HSTD1	6295	104950	10956	10265
13:45	MA55691-HSTD2	5803	95797	10529	9151
13:50	ZZZZZZ	6277	105540	10878	10517
13:55	ZZZZZZ	6317	106520	10871	10355
14:00	ZZZZZZ	6358	107320	10942	10358
14:05	MA55691-CCV1	6196	103010	10870	9867
14:10	MA55691-CCB2	6381	106960	10965	10398
14:15	ZZZZZZ	6349	107210	10992	10291
14:20	ZZZZZZ	6410	107740	11177	10470
14:25	JD83927-1	6334	105800	11586	9747
14:30	JD83927-2	6445	107970	11588	10066
14:34	JD83927-3	6493	108440	11755	10009
14:39	JD83927-4	6447	107660	11625	9994
14:44	JD83927-5	6510	108400	11625	10171
14:49	JD83927-6	6465	108230	11730	10007
14:54	JD83927-7	6417	107460	11600	9977
14:59	JD83927-8	6506	108620	11769	10011
15:04	MA55691-CCV2	6323	104910	11077	10021
15:09	MA55691-CCB3	6446	108170	11134	10486
15:14	ZZZZZZ	6558	108960	11664	10307
15:19	ZZZZZZ	6657	110490	11850	10254
15:24	ZZZZZZ	6723	111490	11871	10355
15:29	ZZZZZZ	6675	110580	11829	10267

INTERNAL STANDARD SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SC031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
Analyst: MM Run ID: MA55691
Parameters: Al,Sb,As,Ba,Be,Cd,Ca,Cr,Co,Cu,Fe,Pb,Mg,Mn,Ni,K,Se,Ag,Na,Tl,V,Zn

Time	Sample Description	Istd#1	Istd#2	Istd#3	Istd#4
15:34	ZZZZZZ	6772	112160	11868	10468
15:39	ZZZZZZ	6538	108760	11774	10073
15:43	ZZZZZZ	6598	108710	11669	10297
15:48	ZZZZZZ	6586	109460	11876	10175
15:53	ZZZZZZ	6615	109820	11882	10215
15:58	ZZZZZZ	6650	111340	11938	10228
16:03	ZZZZZZ	6652	111680	11585	10736
16:08	ZZZZZZ	7024	115500	12329	10596
16:13	ZZZZZZ	6912	113280	12212	10559
16:18	ZZZZZZ	7016	114180	12337	10605
16:23	ZZZZZZ	6855	113440	12249	10455
16:28	ZZZZZZ	6835	112750	11976	10658
16:33	MA55691-CCV3	6485	107230	11366	10212
16:38	MA55691-CCB4	6660	111700	11345	10748
16:43	JD83927-9	6850	113080	12048	10686
16:48	JD83927-10	6960	114090	12223	10629
16:53	JD83927-11	6981	115050	12274	10676
16:58	JD83927-12	7000	114600	12311	10673
17:03	JD83927-13	6981	114820	12042	10731
17:08	JD83927-14	6755	111530	11903	10337
17:12	JD83927-15	6762	111150	11766	10506
17:17	JD83927-16	6733	110540	11818	10354
17:22	JD83927-17	6683	110200	11712	10305
17:27	JD83927-18	6753	109380	11797	10355
17:32	MA55691-CCV4	6582	107700	11285	10343
17:37	MA55691-CCB5	6717	111190	11404	10829
17:42	ZZZZZZ	6760	112260	11446	10877
17:47	ZZZZZZ	7113	115260	12302	10714
17:52	ZZZZZZ	6990	113630	12091	10658
17:57	ZZZZZZ	7086	115110	12218	10700
18:01	ZZZZZZ	6960	113630	12131	10586
18:06	ZZZZZZ	6963	113930	11963	10837
18:11	ZZZZZZ	7062	114520	12121	10850

INTERNAL STANDARD SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SC031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
Analyst: MM Run ID: MA55691
Parameters: Al,Sb,As,Ba,Be,Cd,Ca,Cr,Co,Cu,Fe,Pb,Mg,Mn,Ni,K,Se,Ag,Na,Tl,V,Zn

Time	Sample Description	Istd#1	Istd#2	Istd#3	Istd#4
18:16	ZZZZZZ	7100	114560	12197	10794
18:21	ZZZZZZ	7042	114850	12121	10705
18:26	MP45190-B1	No results reported for the elements associated with this internal standard.			
18:31	MA55691-CCV5	6586	108500	11315	10346
18:35	MA55691-CCB6	6774	112180	11268	10918
18:40	MP45190-MB1	No results reported for the elements associated with this internal standard.			
18:45	MP45190-B2	No results reported for the elements associated with this internal standard.			
18:50	MP45190-S1	No results reported for the elements associated with this internal standard.			
18:55	MP45190-S2	No results reported for the elements associated with this internal standard.			
19:00	JD83832-2	No results reported for the elements associated with this internal standard.			
19:04	MP45190-SD1	No results reported for the elements associated with this internal standard.			
19:09	ZZZZZZ	No results reported for the elements associated with this internal standard.			
19:14	ZZZZZZ	No results reported for the elements associated with this internal standard.			
19:19	ZZZZZZ	No results reported for the elements associated with this internal standard.			
19:24	ZZZZZZ	No results reported for the elements associated with this internal standard.			
19:29	MA55691-CCV6	6598	108080	11276	10384
19:34	MA55691-CCB7	6751	112120	11203	10881
19:39	JD83786-5F	No results reported for the elements associated with this internal standard.			
19:44	ZZZZZZ	No results reported for the elements associated with this internal standard.			
19:48	ZZZZZZ	No results reported for the elements associated with this internal standard.			
19:54	ZZZZZZ	No results reported for the elements associated with this internal standard.			
19:59	ZZZZZZ	No results reported for the elements associated with this internal standard.			
20:04	ZZZZZZ	No results reported for the elements associated with this internal standard.			
20:09	ZZZZZZ	No results reported for the elements associated with this internal standard.			
20:14	ZZZZZZ	No results reported for the elements associated with this internal standard.			
20:19	ZZZZZZ	No results reported for the elements associated with this internal standard.			
20:24	ZZZZZZ	No results reported for the elements associated with this internal standard.			
20:29	MA55691-CCV7	6616	108880	11220	10410
20:33	MA55691-CCB8	6727	111910	11172	10862
20:38	ZZZZZZ	No results reported for the elements associated with this internal standard.			
20:43	ZZZZZZ	No results reported for the elements associated with this internal standard.			
20:48	ZZZZZZ	No results reported for the elements associated with this internal standard.			
20:53	ZZZZZZ	No results reported for the elements associated with this internal standard.			

INTERNAL STANDARD SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SC031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
Analyst: MM Run ID: MA55691
Parameters: Al,Sb,As,Ba,Be,Cd,Ca,Cr,Co,Cu,Fe,Pb,Mg,Mn,Ni,K,Se,Ag,Na,Tl,V,Zn

Time	Sample Description	Istd#1	Istd#2	Istd#3	Istd#4
20:58	ZZZZZZ	No results reported for the elements associated with this internal standard.			
21:03	ZZZZZZ	6778	112330	11414	10908
21:08	MP45202-S1	6761	110890	11270	10868
21:12	MP45202-S2	6769	111530	11310	10845
21:17	JD83844-1	6820	112130	11321	10938
21:22	MP45202-SD1	6759	112440	11306	10867
21:27	MA55691-CCV8	6617	108680	11186	10396
21:31	MA55691-CCB9	6757	111980	11245	10888
21:36	ZZZZZZ	6919	113200	11527	10825
21:41	ZZZZZZ	7032	114330	11748	10834
21:46	ZZZZZZ	6881	111560	11471	10880
21:51	ZZZZZZ	6868	112510	11410	10917
21:56	ZZZZZZ	6844	112680	11471	10898
22:01	ZZZZZZ	6740	110730	11411	10519
22:06	MP45235-MB1	6832	113690	11413	10985
22:10	MP45235-B1	6651	109290	11258	10540
22:15	MP45235-S1	6780	111070	11595	10588
22:20	MP45235-S2	6830	111890	11610	10661
22:25	MA55691-CCV9	6621	108390	11179	10411
22:30	MA55691-CCB10	6807	112640	11200	10966
22:35	JD83234-1	6886	111900	11558	10789
22:39	MP45235-SD1	6846	112370	11314	10906
22:44	MP45235-PS1	6693	109680	11209	10581
22:49	ZZZZZZ	6872	112730	11597	10722
22:54	ZZZZZZ	6899	112440	11602	10790
22:59	ZZZZZZ	6915	113350	11689	10775
23:03	ZZZZZZ	6511	105960	11512	10029
23:09	MP45217-MB1	6833	113470	11457	10975
23:13	MP45217-B1	6736	110290	11371	10641
23:18	MP45217-S1	6874	112630	11630	10705
23:23	MA55691-CCV10	6671	109040	11260	10471
23:28	MA55691-CCB11	6845	113400	11259	10999
23:33	MP45217-S2	6919	112720	11719	10746

INTERNAL STANDARD SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SC031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
Analyst: MM Run ID: MA55691
Parameters: Al,Sb,As,Ba,Be,Cd,Ca,Cr,Co,Cu,Fe,Pb,Mg,Mn,Ni,K,Se,Ag,Na,Tl,V,Zn

Time	Sample Description	Istd#1	Istd#2	Istd#3	Istd#4
23:38	JD83721-21	7085	115380	11847	11008
23:42	MP45217-SD1	6927	113850	11438	10999
23:47	ZZZZZZ	7086	114840	12064	11071
23:52	ZZZZZZ	6936	113020	11697	10920
23:57	ZZZZZZ	6887	111090	11866	11258
00:02	ZZZZZZ	7059	115330	11874	10930
00:07	ZZZZZZ	7014	113990	11736	11015
00:12	ZZZZZZ	7027	113920	11987	11055
00:16	ZZZZZZ	7142	115170	12321	11351
00:21	MA55691-CCV11	6695	109460	11193	10494
00:26	MA55691-CCB12	6865	112970	11189	11033
00:31	ZZZZZZ	6831	111100	11539	10789
00:36	ZZZZZZ	6753	109610	11663	11438
00:41	ZZZZZZ	7174	115680	12181	10705
00:46	ZZZZZZ	6849	110660	11329	10827
00:51	ZZZZZZ	6800	110250	11594	11307
00:56	ZZZZZZ	6918	112340	11943	11286
01:00	ZZZZZZ	6966	112450	11781	10848
01:05	ZZZZZZ	7188	116940	12124	10916
01:10	ZZZZZZ	6897	110810	11739	11036
01:15	ZZZZZZ	No results reported for the elements associated with this internal standard.			
01:20	MA55691-CCV12	6688	109420	11248	10478
01:24	MA55691-CCB13	6835	112930	11224	10998
01:29	ZZZZZZ	6890	111500	11814	11127
01:34	ZZZZZZ	6834	113240	11341	10980
01:39	MP45159-S1	6726	110550	11636	10216
01:44	MP45159-S2	6848	112430	11639	10515
01:49	JD83749-5	6854	112580	11599	10517
01:54	MP45159-SD1	6863	113640	11418	10887
01:59	ZZZZZZ	6832	112370	11381	10707
02:03	ZZZZZZ	6789	111670	11295	10681
02:08	ZZZZZZ	6846	112450	11401	10732
02:13	ZZZZZZ	7161	117020	12051	10518

INTERNAL STANDARD SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SC031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
Analyst: MM Run ID: MA55691
Parameters: Al,Sb,As,Ba,Be,Cd,Ca,Cr,Co,Cu,Fe,Pb,Mg,Mn,Ni,K,Se,Ag,Na,Tl,V,Zn

Time	Sample Description	Istd#1	Istd#2	Istd#3	Istd#4
02:18	MA55691-CCV13	6701	109440	11176	10515
02:23	MA55691-CCB14	6817	113160	11190	10986
02:28	ZZZZZZ	6860	112020	11447	10736
02:33	ZZZZZZ	6881	112640	11419	10940
02:38	ZZZZZZ	6842	113540	11242	11020
02:43	ZZZZZZ	6495	107820	11009	10148
02:48	ZZZZZZ	6867	113880	11251	11024
02:53	ZZZZZZ	6877	114100	11275	11069
02:58	ZZZZZZ	6860	114540	11293	11035
03:03	MA55691-CCV14	6727	110020	11253	10560
03:08	MA55691-CCB15	6883	114040	11350	11081
08:45	ZZZZZZ	6916	114430	11155	11113

R = Reference for ISTD limits. ! = Outside limits.

LEGEND:

Istd#	Parameter	Limits
Istd#1	Yttrium (2243)	70-130 %
Istd#2	Yttrium (3600)	70-130 %
Istd#3	Yttrium (3710)	70-130 %
Istd#4	Indium	70-130 %

BLANK RESULTS SUMMARY
Part 1 - Initial and Continuing Calibration Blanks

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SC031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
QC Limits: result < RL Run ID: MA55691 Units: ug/l

Time:			12:59		13:12		14:10		15:09	
Sample ID:			ICB1		CCB1		CCB2		CCB3	
Metal	RL	IDL	raw	final	raw	final	raw	final	raw	final
Aluminum	200	17	-15.1	<200	0.500	<200	-17.1	<200	-34.1	<200
Antimony	6.0	1.7	1.20	<6.0	1.20	<6.0	0.100	<6.0	2.00	<6.0
Arsenic	3.0	2.1	-0.100	<3.0	-0.300	<3.0	0.200	<3.0	-1.00	<3.0
Barium	200	.8	0.300	<200	0.400	<200	-0.200	<200	-0.400	<200
Beryllium	1.0	.3	-0.100	<1.0	0.100	<1.0	0.00	<1.0	0.100	<1.0
Bismuth	20	2.3								
Boron	100	2.3								
Cadmium	3.0	.3	0.00	<3.0	0.100	<3.0	0.00	<3.0	0.00	<3.0
Calcium	5000	6.6	-3.40	<5000	0.200	<5000	0.300	<5000	1.50	<5000
Cerium	100									
Chromium	10	.3	0.00	<10	0.100	<10	0.00	<10	0.200	<10
Cobalt	50	.4	0.00	<50	-0.200	<50	-0.100	<50	-0.200	<50
Copper	10	.8	0.300	<10	0.200	<10	0.200	<10	0.400	<10
Iron	100	5.3	-1.50	<100	-2.40	<100	-0.500	<100	0.00	<100
Lead	3.0	1.1	0.600	<3.0	0.400	<3.0	-0.600	<3.0	-0.200	<3.0
Lithium	50	4.8								
Magnesium	5000	32	-10.3	<5000	15.5	<5000	1.30	<5000	3.20	<5000
Manganese	15	.1	0.00	<15	0.00	<15	0.00	<15	0.00	<15
Molybdenum	20	.6								
Nickel	10	.4	0.00	<10	0.200	<10	0.200	<10	0.100	<10
Phosphorus	50	1.2								
Potassium	10000	77	32.7	<10000	18.3	<10000	6.90	<10000	35.8	<10000
Selenium	10	3.2	2.10	<10	0.700	<10	0.00	<10	-1.20	<10
Silicon	200	1.7								
Silver	10	1	0.100	<10	0.500	<10	0.100	<10	0.200	<10
Sodium	10000	34	1.50	<10000	-5.30	<10000	-2.30	<10000	9.20	<10000
Strontium	10	.3								
Sulfur	50	3								
Thallium	10	1.8	-0.200	<10	-1.60	<10	1.50	<10	-0.600	<10
Tin	10	.8								
Titanium	10	.5								
Tungsten	50	2.6								
Vanadium	50	.6	0.100	<50	-0.200	<50	-0.200	<50	-0.100	<50

BLANK RESULTS SUMMARY
Part 1 - Initial and Continuing Calibration Blanks

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SC031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
QC Limits: result < RL Run ID: MA55691 Units: ug/l

Time: / Sample ID:			12:59 ICB1		13:12 CCB1		14:10 CCB2		15:09 CCB3	
Metal	RL	IDL	raw	final	raw	final	raw	final	raw	final
Zinc	20	.1	-1.00	<20	-0.900	<20	-0.700	<20	-0.900	<20
Zirconium	10	.3								

(*) Outside of QC limits
(anr) Analyte not requested

BLANK RESULTS SUMMARY
Part 1 - Initial and Continuing Calibration Blanks

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SC031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
QC Limits: result < RL Run ID: MA55691 Units: ug/l

Time:			16:38		17:37	
Sample ID:			CCB4		CCB5	
Metal	RL	IDL	raw	final	raw	final
Aluminum	200	17	-25.0	<200	0.00	<200
Antimony	6.0	1.7	-0.100	<6.0	0.200	<6.0
Arsenic	3.0	2.1	-2.00	<3.0	-0.800	<3.0
Barium	200	.8	-0.300	<200	-0.600	<200
Beryllium	1.0	.3	0.00	<1.0	0.00	<1.0
Bismuth	20	2.3				
Boron	100	2.3				
Cadmium	3.0	.3	0.00	<3.0	0.100	<3.0
Calcium	5000	6.6	0.800	<5000	1.70	<5000
Cerium	100					
Chromium	10	.3	-0.100	<10	0.00	<10
Cobalt	50	.4	-0.200	<50	-0.100	<50
Copper	10	.8	0.900	<10	0.300	<10
Iron	100	5.3	-0.700	<100	2.00	<100
Lead	3.0	1.1	-0.600	<3.0	-0.500	<3.0
Lithium	50	4.8				
Magnesium	5000	32	-11.7	<5000	2.70	<5000
Manganese	15	.1	0.00	<15	0.00	<15
Molybdenum	20	.6				
Nickel	10	.4	0.200	<10	0.00	<10
Phosphorus	50	1.2				
Potassium	10000	77	22.5	<10000	46.3	<10000
Selenium	10	3.2	2.30	<10	0.900	<10
Silicon	200	1.7				
Silver	10	1	0.500	<10	0.700	<10
Sodium	10000	34	8.40	<10000	-9.40	<10000
Strontium	10	.3				
Sulfur	50	3				
Thallium	10	1.8	-1.00	<10	-0.500	<10
Tin	10	.8				
Titanium	10	.5				
Tungsten	50	2.6				
Vanadium	50	.6	0.00	<50	0.00	<50

BLANK RESULTS SUMMARY
Part 1 - Initial and Continuing Calibration Blanks

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SC031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
QC Limits: result < RL Run ID: MA55691 Units: ug/l

Time:			16:38		17:37	
Sample ID:			CCB4		CCB5	
Metal	RL	IDL	raw	final	raw	final
Zinc	20	.1	0.800	<20	-0.800	<20
Zirconium	10	.3				

(*) Outside of QC limits
(anr) Analyte not requested

CALIBRATION CHECK STANDARDS SUMMARY
Initial Continuing Calibration Check

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SC031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
QC Limits: to % Recovery Run ID: MA55691 Units: ug/l

Time:		13:06	
Sample ID:	ICCV	ICCV1	
Metal	True	Results	% Rec
Aluminum	40000	39800	99.5
Antimony	2000	2020	101.0
Arsenic	2000	2030	101.5
Barium	2000	2000	100.0
Beryllium	2000	2030	101.5
Bismuth			
Boron			
Cadmium	2000	2040	102.0
Calcium	40000	40600	101.5
Cerium			
Chromium	2000	2040	102.0
Cobalt	2000	2040	102.0
Copper	2000	1990	99.5
Iron	40000	40600	101.5
Lead	2000	2030	101.5
Lithium			
Magnesium	40000	40900	102.3
Manganese	2000	2040	102.0
Molybdenum			
Nickel	2000	2040	102.0
Phosphorus			
Potassium	40000	40000	100.0
Selenium	2000	2020	101.0
Silicon			
Silver	250	251	100.4
Sodium	40000	40400	101.0
Strontium			
Sulfur			
Thallium	2000	2070	103.5
Tin			
Titanium			
Tungsten			
Vanadium	2000	2030	101.5

CALIBRATION CHECK STANDARDS SUMMARY
Initial Continuing Calibration Check

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SC031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
QC Limits: to % Recovery Run ID: MA55691 Units: ug/l

Time:		13:06	
Sample ID:	ICCV	ICCV1	
Metal	True	Results	% Rec
Zinc	2000	2090	104.5
Zirconium			

(*) Outside of QC limits
(anr) Analyte not requested

CALIBRATION CHECK STANDARDS SUMMARY
Initial and Continuing Calibration Checks

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SC031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
QC Limits: 95 to 105 % Recovery Run ID: MA55691 Units: ug/l

Time:		12:52			14:05			15:04	
Sample ID:	ICV	ICV1		CCV	CCV1		CCV	CCV2	
Metal	True	Results	% Rec	True	Results	% Rec	True	Results	% Rec
Aluminum	40000	38400	96.0	40000	38300	95.8	40000	37700	94.3
Antimony	2000	2020	101.0	2000	1970	98.5	2000	1940	97.0
Arsenic	2000	2070	103.5	2000	1980	99.0	2000	1950	97.5
Barium	2000	1990	99.5	2000	1930	96.5	2000	1900	95.0
Beryllium	2000	2040	102.0	2000	1960	98.0	2000	1930	96.5
Bismuth									
Boron									
Cadmium	2000	1980	99.0	2000	2000	100.0	2000	1960	98.0
Calcium	40000	40400	101.0	40000	39500	98.8	40000	38600	96.5
Cerium									
Chromium	2000	1990	99.5	2000	1980	99.0	2000	1950	97.5
Cobalt	2000	2020	101.0	2000	2000	100.0	2000	1980	99.0
Copper	2000	2020	101.0	2000	1950	97.5	2000	1910	95.5
Iron	40000	39900	99.8	40000	39400	98.5	40000	38800	97.0
Lead	2000	2010	100.5	2000	2000	100.0	2000	1970	98.5
Lithium									
Magnesium	40000	39400	98.5	40000	39800	99.5	40000	38900	97.3
Manganese	2000	2010	100.5	2000	1990	99.5	2000	1950	97.5
Molybdenum									
Nickel	2000	2020	101.0	2000	2010	100.5	2000	1980	99.0
Phosphorus									
Potassium	40000	38600	96.5	40000	38800	97.0	40000	38200	95.5
Selenium	2000	1960	98.0	2000	1960	98.0	2000	1940	97.0
Silicon									
Silver	250	252	100.8	250	245	98.0	250	241	96.4
Sodium	40000	40000	100.0	40000	39400	98.5	40000	38700	96.8
Strontium									
Sulfur									
Thallium	2000	2050	102.5	2000	2010	100.5	2000	2020	101.0
Tin									
Titanium									
Tungsten									
Vanadium	2000	1990	99.5	2000	1980	99.0	2000	1940	97.0

CALIBRATION CHECK STANDARDS SUMMARY
Initial and Continuing Calibration Checks

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SC031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
QC Limits: 95 to 105 % Recovery Run ID: MA55691 Units: ug/l

Time:		12:52			14:05			15:04	
Sample ID:	ICV	ICV1		CCV	CCV1		CCV	CCV2	
Metal	True	Results	% Rec	True	Results	% Rec	True	Results	% Rec
Zinc	2000	2050	102.5	2000	2030	101.5	2000	1990	99.5
Zirconium									

(*) Outside of QC limits
(anr) Analyte not requested

CALIBRATION CHECK STANDARDS SUMMARY
Initial and Continuing Calibration Checks

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SC031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
QC Limits: 95 to 105 % Recovery Run ID: MA55691 Units: ug/l

Time:		16:33			17:32	
Sample ID:	CCV	CCV3		CCV	CCV4	
Metal	True	Results	% Rec	True	Results	% Rec
Aluminum	40000	37700	94.3	40000	37500	93.8
Antimony	2000	1900	95.0	2000	1880	94.0
Arsenic	2000	1900	95.0	2000	1870	93.5
Barium	2000	1900	95.0	2000	1900	95.0
Beryllium	2000	1900	95.0	2000	1880	94.0
Bismuth						
Boron						
Cadmium	2000	1910	95.5	2000	1870	93.5
Calcium	40000	38000	95.0	40000	37300	93.3
Cerium						
Chromium	2000	1910	95.5	2000	1880	94.0
Cobalt	2000	1940	97.0	2000	1910	95.5
Copper	2000	1880	94.0	2000	1860	93.0
Iron	40000	38500	96.3	40000	38000	95.0
Lead	2000	1920	96.0	2000	1890	94.5
Lithium						
Magnesium	40000	38100	95.3	40000	37300	93.3
Manganese	2000	1910	95.5	2000	1900	95.0
Molybdenum						
Nickel	2000	1940	97.0	2000	1910	95.5
Phosphorus						
Potassium	40000	37900	94.8	40000	37200	93.0
Selenium	2000	1910	95.5	2000	1890	94.5
Silicon						
Silver	250	239	95.6	250	237	94.8
Sodium	40000	38100	95.3	40000	37300	93.3
Strontium						
Sulfur						
Thallium	2000	2010	100.5	2000	2010	100.5
Tin						
Titanium						
Tungsten						
Vanadium	2000	1900	95.0	2000	1870	93.5

CALIBRATION CHECK STANDARDS SUMMARY
Initial and Continuing Calibration Checks

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SC031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
QC Limits: 95 to 105 % Recovery Run ID: MA55691 Units: ug/l

Time:		16:33			17:32	
Sample ID:	CCV	CCV3		CCV	CCV4	
Metal	True	Results	% Rec	True	Results	% Rec
Zinc	2000	1910	95.5	2000	1910	95.5
Zirconium						

(*) Outside of QC limits
(anr) Analyte not requested

HIGH STANDARD CHECK SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SC031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
QC Limits: 90 to 110 % Recovery Run ID: MA55691 Units: ug/l

Time:		13:39			13:45	
Sample ID:	HSTD	HSTD1		HSTD	HSTD2	
Metal	True	Results	% Rec	True	Results	% Rec
Aluminum				300000	290000	96.7
Antimony	8000	7820	97.8			
Arsenic	8000	7850	98.1			
Barium	8000	7680	96.0			
Beryllium	8000	7860	98.3			
Bismuth						
Boron						
Cadmium	8000	7520	94.0			
Calcium				200000	189000	94.5
Cerium						
Chromium	8000	7920	99.0			
Cobalt	8000	7880	98.5			
Copper	8000	7630	95.4			
Iron				200000	189000	94.5
Lead	8000	8020	100.3			
Lithium						
Magnesium				300000	294000	98.0
Manganese	8000	7760	97.0			
Molybdenum						
Nickel	8000	7920	99.0			
Phosphorus						
Potassium				200000	195000	97.5
Selenium	8000	7670	95.9			
Silicon						
Silver	625	617	98.7			
Sodium				200000	192000	96.0
Strontium						
Sulfur						
Thallium	8000	7850	98.1			
Tin						
Titanium						
Tungsten						
Vanadium	8000	7850	98.1			

HIGH STANDARD CHECK SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SC031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
QC Limits: 90 to 110 % Recovery Run ID: MA55691 Units: ug/l

Time:		13:39			13:45	
Sample ID:	HSTD	HSTD1		HSTD	HSTD2	
Metal	True	Results	% Rec	True	Results	% Rec
Zinc	8000	7950	99.4			
Zirconium						

(*) Outside of QC limits
(anr) Analyte not requested

LOW CALIBRATION CHECK STANDARDS SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SC031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
QC Limits: CRI 80-120% CRIA 80-120% Run ID: MA55691 Units: ug/l

Time:				13:19		13:24	
Sample ID:	CRI	CRIA	CRID	CRI1		CRID1	
Metal	True	True	True	Results	% Rec	Results	% Rec
Aluminum	200	500	100	196	98.0	81.4	81.4
Antimony	6.0	20	3.0	6.20	103.3		
Arsenic	8.0	20	3.0	7.40	92.5	2.60	86.7
Barium	200		4.0	189	94.5	4.70	117.5
Beryllium	2.0		1.0	2.30	115.0	1.00	100.0
Bismuth	20						
Boron	100		10				
Cadmium	3.0		1.0	3.00	100.0	1.10	110.0
Calcium	5000	2000	1000	4950	99.0	1040	104.0
Cerium							
Chromium	10		2.0	9.90	99.0	2.20	110.0
Cobalt	50		3.0	48.7	97.4	2.90	96.7
Copper	10		2.0	9.20	92.0		
Iron	100	500		107	107.0		
Lead	3.0	20	2.5	2.90	96.7		
Lithium	50						
Magnesium	5000	2000	100	5080	101.6	116	116.0
Manganese	15		3.0	14.9	99.3	3.10	103.3
Molybdenum	20						
Nickel	10		4.0	10.1	101.0	4.10	102.5
Phosphorus	50						
Potassium	5000		2000	4810	96.2	1980	99.0
Selenium	10	20	5.0	11.1	111.0		
Silicon	200						
Silver	5.0		2.0	4.50	90.0		
Sodium	5000		1000	4860	97.2	994	99.4
Strontium	10						
Sulfur	50						
Thallium	10		2.0	9.40	94.0		
Tin	10						
Titanium	10						
Tungsten	50						
Vanadium	50		2.0	47.1	94.2	2.00	100.0

LOW CALIBRATION CHECK STANDARDS SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SC031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
QC Limits: CRI 80-120% CRIA 80-120% Run ID: MA55691 Units: ug/l

Time:				13:19		13:24	
Sample ID:	CRI	CRIA	CRID	CRI1		CRID1	
Metal	True	True	True	Results	% Rec	Results	% Rec
Zinc	20		10	20.9	104.5	10.5	105.0
Zirconium	10						

(*) Outside of QC limits
(anr) Analyte not requested

INTERFERING ELEMENT CHECK STANDARDS SUMMARY
Part 1 - ICSA and ICSAB Standards

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SC031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
QC Limits: 80 to 120 % Recovery Run ID: MA55691 Units: ug/l

Time:			13:29		13:34	
Sample ID:	ICSA	ICSAB	ICSA1		ICSAB1	
Metal	True	True	Results	% Rec	Results	% Rec
Aluminum	500000	500000	492000	98.4	486000	97.2
Antimony		1000	1.10		991	99.1
Arsenic		1000	1.70		1010	101.0
Barium		500	6.30		487	97.4
Beryllium		500	0.00		488	97.6
Bismuth		500	-6.40		506	101.2
Boron		500	-3.70		483	96.6
Cadmium		1000	0.200		1050	105.0
Calcium	400000	400000	388000	97.0	382000	95.5
Cerium			-16.6		-8.90	
Chromium		500	0.200		475	95.0
Cobalt		500	1.40		483	96.6
Copper		500	-0.900		509	101.8
Iron	200000	200000	191000	95.5	192000	96.0
Lead		1000	-1.60		910	91.0
Lithium		500	6.50		537	107.4
Magnesium	500000	500000	489000	97.8	490000	98.0
Manganese		500	-0.400		505	101.0
Molybdenum		500	3.20		479	95.8
Nickel		1000	-1.60		929	92.9
Phosphorus		500	-12.5		444	88.8
Potassium			-13.2		-74.9	
Selenium		1000	2.30		965	96.5
Silicon		500	7.30		492	98.4
Silver		1000	0.700		1040	104.0
Sodium			76.4		78.6	
Strontium		500	-2.40		491	98.2
Sulfur		500	-10.4		490	98.0
Thallium		1000	9.20		1090	109.0
Tin		500	-0.100		476	95.2
Titanium		500	-1.90		494	98.8
Tungsten		500	1.30		475	95.0
Vanadium		500	3.90		497	99.4

INTERFERING ELEMENT CHECK STANDARDS SUMMARY
Part 1 - ICSA and ICSAB Standards

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: SC031124M1.ICP Date Analyzed: 03/11/24 Methods: EPA 200.7, SW846 6010D
QC Limits: 80 to 120 % Recovery Run ID: MA55691 Units: ug/l

Time:			13:29		13:34	
Sample ID:	ICSA	ICSAB	ICSA1		ICSAB1	
Metal	True	True	Results	% Rec	Results	% Rec
Zinc		1000	0.400		943	94.3
Zirconium		500	2.90		469	93.8

(*) Outside of QC limits
(anr) Analyte not requested

SGS Instrument Runlog
Inorganics Analyses

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: H9031524S1.CSV Date Analyzed: 03/15/24 Methods: SW846 7471B
Analyst: LM Run ID: MA55725
Parameters: Hg

Time	Sample Description	Dilution Factor	PS Recov	Comments
19:29	MA55725-STD1	1		b=9.9768e-005,c=-2.7006e-002,rho=0.9999227
19:30	MA55725-STD2	1		STDB
19:32	MA55725-STD3	1		STDC
19:33	MA55725-STD4	1		STDD
19:35	MA55725-STD5	1		STDE
19:37	MA55725-STD6	1		STDF
19:39	MA55725-STD7	1		STDA
19:42	ZZZZZZ	1		
19:43	MA55725-ICV1	1		
19:44	MA55725-ICB1	1		
19:46	MA55725-CCV1	1		
19:48	MA55725-CCB1	1		
19:50	MA55725-CRI1	1		
19:51	MP45340-MB1	1		
19:53	MP45340-B1	1		
19:54	ZZZZZZ	1		
19:56	MP45340-S2	1		
19:58	DA62500-1	1		(sample used for QC only; not part of login JD83927)
20:00	ZZZZZZ	1		
20:02	ZZZZZZ	1		
20:03	MA55725-CCV2	1		
20:05	MA55725-CCB2	1		
20:07	ZZZZZZ	1		
20:08	ZZZZZZ	1		
20:10	ZZZZZZ	1		
20:11	ZZZZZZ	1		
20:13	ZZZZZZ	1		
20:14	ZZZZZZ	1		
20:16	ZZZZZZ	1		
20:18	ZZZZZZ	1		
20:20	MA55725-CCV3	1		
20:22	MA55725-CCB3	1		
20:24	ZZZZZZ	1		

SGS Instrument Runlog
Inorganics Analyses

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: H9031524S1.CSV Date Analyzed: 03/15/24 Methods: SW846 7471B
Analyst: LM Run ID: MA55725
Parameters: Hg

Time	Sample Description	Dilution Factor	PS Recov	Comments
20:25	ZZZZZZ	1		
20:27	ZZZZZZ	1		
20:29	ZZZZZZ	1		
20:30	ZZZZZZ	1		
20:32	ZZZZZZ	1		
20:34	ZZZZZZ	1		
20:35	ZZZZZZ	1		
20:37	MA55725-CCV4	1		
20:39	MA55725-CCB4	1		
20:41	MP45341-MB1	1		
20:42	ZZZZZZ	1		
20:43	MP45341-S1	1		
20:45	MP45341-S2	1		
20:47	JD84074-1	1		(sample used for QC only; not part of login JD83927)
20:49	ZZZZZZ	1		
20:51	MA55725-CCV5	1		
20:52	MA55725-CCB5	1		
20:54	ZZZZZZ	1		
20:56	ZZZZZZ	1		
20:58	ZZZZZZ	1		
20:59	ZZZZZZ	1		
21:01	ZZZZZZ	1		
21:03	ZZZZZZ	1		
21:04	ZZZZZZ	1		
21:06	MA55725-CCV6	1		
21:07	MA55725-CCB6	1		
21:09	ZZZZZZ	1		
21:11	ZZZZZZ	1		
21:12	ZZZZZZ	1		
21:14	ZZZZZZ	1		
21:16	ZZZZZZ	1		
21:17	ZZZZZZ	1		
21:19	ZZZZZZ	1		

SGS Instrument Runlog
Inorganics Analyses

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: H9031524S1.CSV Date Analyzed: 03/15/24 Methods: SW846 7471B
Analyst: LM Run ID: MA55725
Parameters: Hg

Time	Sample Description	Dilution Factor	PS Recov	Comments
21:20	MA55725-CCV7	1		
21:22	MA55725-CCB7	1		
21:24	MP45342-MB1	1		
21:25	MP45342-B1	1		
21:27	MP45342-S1	1		
21:29	MP45342-S2	1		
21:31	JD84019-2	1		(sample used for QC only; not part of login JD83927)
21:33	ZZZZZZ	1		
21:34	MA55725-CCV8	1		
21:36	MA55725-CCB8	1		
21:38	ZZZZZZ	1		
21:39	ZZZZZZ	1		
21:41	ZZZZZZ	1		
21:42	ZZZZZZ	1		
21:44	ZZZZZZ	1		
21:46	ZZZZZZ	1		
21:47	JD83927-8	1		
---------->	Last reportable sample/prep for job JD83927			
21:49	MA55725-CCV9	1		
21:50	MA55725-CCB9	1		
---------->	Last reportable CCB for job JD83927			
21:52	ZZZZZZ	2		
21:54	ZZZZZZ	5		
21:55	MP45341-B1	1		
21:59	ZZZZZZ	1		
22:02	MP45340-S1	1		
22:04	MA55725-CCV10	1		
22:06	MA55725-CCB10	1		
22:08	ZZZZZZ	1		
22:09	ZZZZZZ	1		
22:11	ZZZZZZ	50		
22:12	ZZZZZZ	50		
22:15	ZZZZZZ	50		
22:17	ZZZZZZ	50		
22:19	ZZZZZZ	50		

SGS Instrument Runlog
Inorganics Analyses

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: H9031524S1.CSV Date Analyzed: 03/15/24 Methods: SW846 7471B
Analyst: LM Run ID: MA55725
Parameters: Hg

Time	Sample Description	Dilution Factor	PS Recov	Comments
22:20	ZZZZZZ	1		
22:27	MA55725-CCV11	1		
22:29	MA55725-CCB11	1		
22:30	ZZZZZZ	50		
22:32	ZZZZZZ	50		
22:34	ZZZZZZ	500		
22:39	ZZZZZZ	500		
22:41	ZZZZZZ	1000		
22:42	ZZZZZZ	1000		
22:44	MA55725-CCV12	1		
22:46	MA55725-CCB12	1		
22:49	ZZZZZZ	500		
22:50	ZZZZZZ	500		
23:00	ZZZZZZ	500		
23:01	ZZZZZZ	500		
23:03	ZZZZZZ	20000		
23:05	ZZZZZZ	20000		
23:08	ZZZZZZ	50		
23:09	ZZZZZZ	10000		
23:11	MA55725-CCV13	1		
23:13	MA55725-CCB13	1		
23:43	ZZZZZZ	1		
23:45	ZZZZZZ	1		
23:48	ZZZZZZ	10		
23:50	ZZZZZZ	10000		
23:51	ZZZZZZ	50		
23:53	ZZZZZZ	20000		
23:55	ZZZZZZ	20000		
23:57	ZZZZZZ	20000		
23:59	ZZZZZZ	1		
00:05	ZZZZZZ	1		
00:07	ZZZZZZ	400000		
00:18	MA55725-CCV14	1		

SGS Instrument Runlog
Inorganics Analyses

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: H9031524S1.CSV Date Analyzed: 03/15/24 Methods: SW846 7471B
Analyst: LM Run ID: MA55725
Parameters: Hg

Time	Sample Description	Dilution Factor	PS Recov	Comments
00:21	MA55725-CCB14	1		
00:23	ZZZZZZ	10000		
00:24	ZZZZZZ	50		
00:26	ZZZZZZ	20000		
00:27	ZZZZZZ	20000		
00:29	ZZZZZZ	10		
00:31	ZZZZZZ	400000		
00:36	ZZZZZZ	4000000		
00:38	ZZZZZZ	1		
00:39	MA55725-CCV15	1		
00:41	MA55725-CCB15	1		

Refer to raw data for calibration curve and standards.

REPORTED ELEMENTS SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: H9031524S1.CSV Date Analyzed: 03/15/24 Methods: SW846 7471B
Analyst: LM Run ID: MA55725
Parameters: Hg

Time	Sample Description	Element: Dilution	Hg	
19:42	ZZZZZZ	1		
19:43	MA55725-ICV1	1	X	
19:44	MA55725-ICB1	1	X	
19:46	MA55725-CCV1	1	X	
19:48	MA55725-CCB1	1	X	
19:50	MA55725-CRI1	1	X	
19:51	MP45340-MB1	1	X	
19:53	MP45340-B1	1	X	
19:54	ZZZZZZ	1		
19:56	MP45340-S2	1	X	
19:58	DA62500-1	1	X	(a)
20:00	ZZZZZZ	1		
20:02	ZZZZZZ	1		
20:03	MA55725-CCV2	1	X	
20:05	MA55725-CCB2	1	X	
20:07	ZZZZZZ	1		
20:08	ZZZZZZ	1		
20:10	ZZZZZZ	1		
20:11	ZZZZZZ	1		
20:13	ZZZZZZ	1		
20:14	ZZZZZZ	1		
20:16	ZZZZZZ	1		
20:18	ZZZZZZ	1		
20:20	MA55725-CCV3	1	X	
20:22	MA55725-CCB3	1	X	
20:24	ZZZZZZ	1		
20:25	ZZZZZZ	1		
20:27	ZZZZZZ	1		
20:29	ZZZZZZ	1		
20:30	ZZZZZZ	1		
20:32	ZZZZZZ	1		
20:34	ZZZZZZ	1		
20:35	ZZZZZZ	1		
		Element:	Hg	

REPORTED ELEMENTS SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: H9031524S1.CSV Date Analyzed: 03/15/24 Methods: SW846 7471B
Analyst: LM Run ID: MA55725
Parameters: Hg

Time	Sample Description	Element: Dilution	Hg	
20:37	MA55725-CCV4	1	X	
20:39	MA55725-CCB4	1	X	
20:41	MP45341-MB1	1	X	
20:42	ZZZZZZ	1		
20:43	MP45341-S1	1	X	
20:45	MP45341-S2	1	X	
20:47	JD84074-1	1	X	(a)
20:49	ZZZZZZ	1		
20:51	MA55725-CCV5	1	X	
20:52	MA55725-CCB5	1	X	
20:54	ZZZZZZ	1		
20:56	ZZZZZZ	1		
20:58	ZZZZZZ	1		
20:59	ZZZZZZ	1		
21:01	ZZZZZZ	1		
21:03	ZZZZZZ	1		
21:04	ZZZZZZ	1		
21:06	MA55725-CCV6	1	X	
21:07	MA55725-CCB6	1	X	
21:09	ZZZZZZ	1		
21:11	ZZZZZZ	1		
21:12	ZZZZZZ	1		
21:14	ZZZZZZ	1		
21:16	ZZZZZZ	1		
21:17	ZZZZZZ	1		
21:19	ZZZZZZ	1		
21:20	MA55725-CCV7	1	X	
21:22	MA55725-CCB7	1	X	
21:24	MP45342-MB1	1	X	
21:25	MP45342-B1	1	X	
21:27	MP45342-S1	1	X	
21:29	MP45342-S2	1	X	
21:31	JD84019-2	1	X	(a)
		Element:	Hg	

REPORTED ELEMENTS SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: H9031524S1.CSV Date Analyzed: 03/15/24 Methods: SW846 7471B
Analyst: LM Run ID: MA55725
Parameters: Hg

Time	Sample Description	Element: Dilution	Hg
21:33	ZZZZZZ	1	
21:34	MA55725-CCV8	1	X
21:36	MA55725-CCB8	1	X
21:38	ZZZZZZ	1	
21:39	ZZZZZZ	1	
21:41	ZZZZZZ	1	
21:42	ZZZZZZ	1	
21:44	ZZZZZZ	1	
21:46	ZZZZZZ	1	
21:47	JD83927-8	1	X
21:49	MA55725-CCV9	1	X
21:50	MA55725-CCB9	1	X
21:52	ZZZZZZ	2	
21:54	ZZZZZZ	5	
21:55	MP45341-B1	1	X
21:59	ZZZZZZ	1	
22:02	MP45340-S1	1	X
22:04	MA55725-CCV10	1	X
22:06	MA55725-CCB10	1	X
22:08	ZZZZZZ	1	
22:09	ZZZZZZ	1	
22:11	ZZZZZZ	50	
22:12	ZZZZZZ	50	
22:15	ZZZZZZ	50	
22:17	ZZZZZZ	50	
22:19	ZZZZZZ	50	
22:20	ZZZZZZ	1	
22:27	MA55725-CCV11	1	X
22:29	MA55725-CCB11	1	X
22:30	ZZZZZZ	50	
22:32	ZZZZZZ	50	
22:34	ZZZZZZ	500	
22:39	ZZZZZZ	500	
		Element:	Hg

REPORTED ELEMENTS SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: H9031524S1.CSV Date Analyzed: 03/15/24 Methods: SW846 7471B
Analyst: LM Run ID: MA55725
Parameters: Hg

Time	Sample Description	Element: Dilution	Hg
22:41	ZZZZZZ	1000	
22:42	ZZZZZZ	1000	
22:44	MA55725-CCV12	1	X
22:46	MA55725-CCB12	1	X
22:49	ZZZZZZ	500	
22:50	ZZZZZZ	500	
23:00	ZZZZZZ	500	
23:01	ZZZZZZ	500	
23:03	ZZZZZZ	20000	
23:05	ZZZZZZ	20000	
23:08	ZZZZZZ	50	
23:09	ZZZZZZ	10000	
23:11	MA55725-CCV13	1	X
23:13	MA55725-CCB13	1	X
23:43	ZZZZZZ	1	
23:45	ZZZZZZ	1	
23:48	ZZZZZZ	10	
23:50	ZZZZZZ	10000	
23:51	ZZZZZZ	50	
23:53	ZZZZZZ	20000	
23:55	ZZZZZZ	20000	
23:57	ZZZZZZ	20000	
23:59	ZZZZZZ	1	
00:05	ZZZZZZ	1	
00:07	ZZZZZZ	400000	
00:18	MA55725-CCV14	1	X
00:21	MA55725-CCB14	1	X
00:23	ZZZZZZ	10000	
00:24	ZZZZZZ	50	
00:26	ZZZZZZ	20000	
00:27	ZZZZZZ	20000	
00:29	ZZZZZZ	10	
00:31	ZZZZZZ	400000	
		Element:	Hg

REPORTED ELEMENTS SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: H9031524S1.CSV Date Analyzed: 03/15/24 Methods: SW846 7471B
Analyst: LM Run ID: MA55725
Parameters: Hg

Time	Sample Description	Element: H Dilution g	
00:36	ZZZZZZ	4000000	
00:38	ZZZZZZ	1	
00:39	MA55725-CCV15	1	X
00:41	MA55725-CCB15	1	X

(a) Sample used for QC only; not part of login JD83927.

Element: H
g

BLANK RESULTS SUMMARY
Part 1 - Initial and Continuing Calibration Blanks

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: H9031524S1.CSV Date Analyzed: 03/15/24 Methods: SW846 7471B
QC Limits: result < RL Run ID: MA55725 Units: ug/l

Time:			19:44		19:48		20:05		20:22	
Sample ID:			ICB1		CCB1		CCB2		CCB3	
Metal	RL	IDL	raw	final	raw	final	raw	final	raw	final
Mercury	0.20	.04	0.0350	<0.20	0.0631	<0.20	0.0573	<0.20	0.0508	<0.20

(*) Outside of QC limits
(anr) Analyte not requested

BLANK RESULTS SUMMARY
Part 1 - Initial and Continuing Calibration Blanks

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: H9031524S1.CSV Date Analyzed: 03/15/24 Methods: SW846 7471B
QC Limits: result < RL Run ID: MA55725 Units: ug/l

Time:			20:39		20:52		21:07		21:22	
Sample ID:			CCB4		CCB5		CCB6		CCB7	
Metal	RL	IDL	raw	final	raw	final	raw	final	raw	final
Mercury	0.20	.04	0.0530	<0.20	0.0457	<0.20	0.0594	<0.20	0.0587	<0.20

(*) Outside of QC limits
(anr) Analyte not requested

BLANK RESULTS SUMMARY
Part 1 - Initial and Continuing Calibration Blanks

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: H9031524S1.CSV Date Analyzed: 03/15/24 Methods: SW846 7471B
QC Limits: result < RL Run ID: MA55725 Units: ug/l

Time:			21:36		21:50	
Sample ID:			CCB8		CCB9	
Metal	RL	IDL	raw	final	raw	final
Mercury	0.20	.04	0.0509	<0.20	0.0491	<0.20

(*) Outside of QC limits
(anr) Analyte not requested

CALIBRATION CHECK STANDARDS SUMMARY
Initial and Continuing Calibration Checks

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: H9031524S1.CSV Date Analyzed: 03/15/24 Methods: SW846 7471B
QC Limits: 90 to 110 % Recovery Run ID: MA55725 Units: ug/l

Time:		19:43			19:46			20:03	
Sample ID:	ICV	ICV1		CCV	CCV1		CCV	CCV2	
Metal	True	Results	% Rec	True	Results	% Rec	True	Results	% Rec
Mercury	3	3.08	102.7	2.5	2.49	99.6	2.5	2.45	98.0

(*) Outside of QC limits
(anr) Analyte not requested

CALIBRATION CHECK STANDARDS SUMMARY
Initial and Continuing Calibration Checks

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: H9031524S1.CSV Date Analyzed: 03/15/24 Methods: SW846 7471B
QC Limits: 90 to 110 % Recovery Run ID: MA55725 Units: ug/l

Time:		20:20			20:37			20:51	
Sample ID:	CCV	CCV3		CCV	CCV4		CCV	CCV5	
Metal	True	Results	% Rec	True	Results	% Rec	True	Results	% Rec
Mercury	2.5	2.53	101.2	2.5	2.49	99.6	2.5	2.52	100.8

(*) Outside of QC limits
(anr) Analyte not requested

CALIBRATION CHECK STANDARDS SUMMARY
Initial and Continuing Calibration Checks

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: H9031524S1.CSV Date Analyzed: 03/15/24 Methods: SW846 7471B
QC Limits: 90 to 110 % Recovery Run ID: MA55725 Units: ug/l

Time:		21:06			21:20			21:34	
Sample ID:	CCV	CCV6		CCV	CCV7		CCV	CCV8	
Metal	True	Results	% Rec	True	Results	% Rec	True	Results	% Rec
Mercury	2.5	2.52	100.8	2.5	2.49	99.6	2.5	2.42	96.8

(*) Outside of QC limits
(anr) Analyte not requested

CALIBRATION CHECK STANDARDS SUMMARY
Initial and Continuing Calibration Checks

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: H9031524S1.CSV Date Analyzed: 03/15/24 Methods: SW846 7471B
QC Limits: 90 to 110 % Recovery Run ID: MA55725 Units: ug/l

Time:		21:49	
Sample ID:	CCV	CCV9	
Metal	True	Results	% Rec
Mercury	2.5	2.45	98.0

(*) Outside of QC limits
(anr) Analyte not requested

LOW CALIBRATION CHECK STANDARDS SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: H9031524S1.CSV Date Analyzed: 03/15/24 Methods: SW846 7471B
QC Limits: 70 to 130 % Recovery Run ID: MA55725 Units: ug/l

Time:			19:50	
Sample ID:	CRI	CRIA	CRI1	
Metal	True	True	Results	% Rec
Mercury	0.20		0.176	88.0

(*) Outside of QC limits
(anr) Analyte not requested

BLANK RESULTS SUMMARY
Part 2 - Method Blanks

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

QC Batch ID: MP45216
Matrix Type: SOLID

Methods: SW846 6010D
Units: mg/kg

Prep Date: 03/08/24

Metal	RL	IDL	MDL	MB raw	final
Aluminum	50	.92	8.1	0.050	<50
Antimony	2.0	.28	.41	-0.050	<2.0
Arsenic	2.0	.26	.28	0.24	<2.0
Barium	20	.02	1.9	-0.020	<20
Beryllium	0.20	.02	.08	-0.010	<0.20
Bismuth	2.0	.25	.52		
Boron	10	.18	3.7		
Cadmium	0.50	.04	.07	-0.030	<0.50
Calcium	500	1.3	21	6.3	<500
Chromium	1.0	.07	.37	0.010	<1.0
Cobalt	5.0	.06	.28	0.040	<5.0
Copper	2.5	.07	.84	0.25	<2.5
Iron	50	.33	19	2.7	<50
Lead	2.0	.2	.41	-0.020	<2.0
Lithium	5.0	.15	.92		
Magnesium	500	2.5	14	-0.81	<500
Manganese	1.5	.01	.41	0.030	<1.5
Molybdenum	2.0	.06	.32		
Nickel	4.0	.08	.35	0.080	<4.0
Phosphorus	20	.7	3.3		
Potassium	1000	3.5	32	-1.9	<1000
Selenium	2.0	.36	.65	0.020	<2.0
Silicon	20	.22	11		
Silver	0.50	.06	.17	0.050	<0.50
Sodium	1000	1.4	78	0.85	<1000
Strontium	5.0	.01	.18		
Sulfur	10	.37	3.9		
Thallium	1.0	.52	.58	0.39	<1.0
Tin	20	.14	3.8		
Titanium	1.0	.08	.34		
Tungsten	5.0	.13	1.8		
Vanadium	5.0	.05	.19	0.010	<5.0
Zinc	5.0	.03	2.3	0.30	<5.0

BLANK RESULTS SUMMARY
Part 2 - Method Blanks

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

QC Batch ID: MP45216
Matrix Type: SOLID

Methods: SW846 6010D
Units: mg/kg

Prep Date: 03/08/24

Metal	RL	IDL	MDL	MB raw	final
Zirconium	2.0	.05	.54		

Associated samples MP45216: JD83927-1, JD83927-2, JD83927-3, JD83927-4, JD83927-5, JD83927-6, JD83927-7, JD83927-8, JD83927-9, JD83927-10, JD83927-11, JD83927-12, JD83927-13, JD83927-14, JD83927-15, JD83927-16, JD83927-17, JD83927-18

Results < IDL are shown as zero for calculation purposes
(*) Outside of QC limits
(anr) Analyte not requested

MATRIX SPIKE AND DUPLICATE RESULTS SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

QC Batch ID: MP45216
Matrix Type: SOLID

Methods: SW846 6010D
Units: mg/kg

Prep Date: 03/08/24

Metal	JD83326-1 Original	MS	Spikelot MPSPK2	% Rec	QC Limits
Aluminum	5050	9220	2610	159.8N(a	75-125
Antimony	0.0	131	209	62.7N(a)	75-125
Arsenic	9.2	203	209	92.8	75-125
Barium	10.9	203	209	92.0	75-125
Beryllium	0.41	183	209	87.4	75-125
Bismuth					
Boron					
Cadmium	0.15	193	209	92.4	75-125
Calcium	95.8	2390	2610	87.9	75-125
Chromium	21.1	217	209	93.8	75-125
Cobalt	1.6	196	209	93.1	75-125
Copper	1.6	191	209	90.7	75-125
Iron	15600	16700	2610	42.1 (b)	75-125
Lead	5.5	201	209	93.6	75-125
Lithium					
Magnesium	465	2890	2610	92.9	75-125
Manganese	29.8	220	209	91.1	75-125
Molybdenum					
Nickel	5.2	205	209	95.7	75-125
Phosphorus					
Potassium	734	3320	2610	99.1	75-125
Selenium	0.0	195	209	93.4	75-125
Silicon					
Silver	0.099	24.8	26.1	94.6	75-125
Sodium	17.6	2360	2610	89.7	75-125
Strontium					
Sulfur					
Thallium	0.0	201	209	96.3	75-125
Tin					
Titanium					
Tungsten					
Vanadium	38.2	233	209	93.3	75-125
Zinc	22.7	213	209	91.1	75-125

MATRIX SPIKE AND DUPLICATE RESULTS SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

QC Batch ID: MP45216
Matrix Type: SOLID

Methods: SW846 6010D
Units: mg/kg

Prep Date: 03/08/24

Metal	JD83326-1 Original MS	Spikelot MPSPK2	% Rec	QC Limits
Zirconium				

Associated samples MP45216: JD83927-1, JD83927-2, JD83927-3, JD83927-4, JD83927-5, JD83927-6, JD83927-7, JD83927-8, JD83927-9, JD83927-10, JD83927-11, JD83927-12, JD83927-13, JD83927-14, JD83927-15, JD83927-16, JD83927-17, JD83927-18

Results < IDL are shown as zero for calculation purposes
(*) Outside of QC limits
(N) Matrix Spike Rec. outside of QC limits
(anr) Analyte not requested
(a) Spike recovery indicates possible matrix interference and/or sample nonhomogeneity.
(b) Spike amount low relative to the sample amount. Refer to lab control or spike blank for recovery information.

MATRIX SPIKE AND DUPLICATE RESULTS SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

QC Batch ID: MP45216
Matrix Type: SOLID

Methods: SW846 6010D
Units: mg/kg

Prep Date: 03/08/24

Metal	JD83326-1 Original	MSD	Spikelot MPSPK2	% Rec	MSD RPD	QC Limit
Aluminum	5050	8940	2800	139.0N(a	3.1	20
Antimony	0.0	149	224	66.6N(a)	12.9	20
Arsenic	9.2	220	224	94.2	8.0	20
Barium	10.9	219	224	93.0	7.6	20
Beryllium	0.41	199	224	88.7	8.4	20
Bismuth						
Boron						
Cadmium	0.15	210	224	93.7	8.4	20
Calcium	95.8	2600	2800	89.5	8.4	20
Chromium	21.1	234	224	95.1	7.5	20
Cobalt	1.6	213	224	94.4	8.3	20
Copper	1.6	206	224	91.3	7.6	20
Iron	15600	16000	2800	14.3 (b)	4.3	20
Lead	5.5	219	224	95.4	8.6	20
Lithium						
Magnesium	465	3080	2800	93.4	6.4	20
Manganese	29.8	234	224	91.2	6.2	20
Molybdenum						
Nickel	5.2	222	224	96.8	8.0	20
Phosphorus						
Potassium	734	3460	2800	97.4	4.1	20
Selenium	0.0	212	224	94.7	8.4	20
Silicon						
Silver	0.099	27.0	28	96.1	8.5	20
Sodium	17.6	2570	2800	91.2	8.5	20
Strontium						
Sulfur						
Thallium	0.0	220	224	98.3	9.0	20
Tin						
Titanium						
Tungsten						
Vanadium	38.2	247	224	93.3	5.8	20
Zinc	22.7	228	224	91.7	6.8	20

MATRIX SPIKE AND DUPLICATE RESULTS SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

QC Batch ID: MP45216 Methods: SW846 6010D
Matrix Type: SOLID Units: mg/kg

Prep Date: 03/08/24

Metal	JD83326-1 Original	MSD	Spikelot MPSPK2	% Rec	MSD RPD	QC Limit
Zirconium						

Associated samples MP45216: JD83927-1, JD83927-2, JD83927-3, JD83927-4, JD83927-5, JD83927-6, JD83927-7, JD83927-8, JD83927-9, JD83927-10, JD83927-11, JD83927-12, JD83927-13, JD83927-14, JD83927-15, JD83927-16, JD83927-17, JD83927-18

Results < IDL are shown as zero for calculation purposes
(*) Outside of QC limits
(N) Matrix Spike Rec. outside of QC limits
(anr) Analyte not requested
(a) Spike recovery indicates possible matrix interference and/or sample nonhomogeneity.
(b) Spike amount low relative to the sample amount. Refer to lab control or spike blank for recovery information.

SPIKE BLANK AND LAB CONTROL SAMPLE SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

QC Batch ID: MP45216
Matrix Type: SOLID

Methods: SW846 6010D
Units: mg/kg

Prep Date: 03/08/24

Metal	BSP Result	Spikelot MPSPK2	% Rec	QC Limits
Aluminum	2210	2500	88.4	80-120
Antimony	192	200	96.0	80-120
Arsenic	191	200	95.5	80-120
Barium	179	200	89.5	80-120
Beryllium	174	200	87.0	80-120
Bismuth				
Boron				
Cadmium	185	200	92.5	80-120
Calcium	2200	2500	88.0	80-120
Chromium	187	200	93.5	80-120
Cobalt	187	200	93.5	80-120
Copper	174	200	87.0	80-120
Iron	2320	2500	92.8	80-120
Lead	190	200	95.0	80-120
Lithium				
Magnesium	2300	2500	92.0	80-120
Manganese	182	200	91.0	80-120
Molybdenum				
Nickel	192	200	96.0	80-120
Phosphorus				
Potassium	2280	2500	91.2	80-120
Selenium	194	200	97.0	80-120
Silicon				
Silver	23.4	25	93.6	80-120
Sodium	2230	2500	89.2	80-120
Strontium				
Sulfur				
Thallium	198	200	99.0	80-120
Tin				
Titanium				
Tungsten				
Vanadium	183	200	91.5	80-120
Zinc	185	200	92.5	80-120

SPIKE BLANK AND LAB CONTROL SAMPLE SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

QC Batch ID: MP45216
Matrix Type: SOLID

Methods: SW846 6010D
Units: mg/kg

Prep Date: 03/08/24

Metal	BSP Result	Spikelot MPSPK2	% Rec	QC Limits
Zirconium				

Associated samples MP45216: JD83927-1, JD83927-2, JD83927-3, JD83927-4, JD83927-5, JD83927-6, JD83927-7, JD83927-8, JD83927-9, JD83927-10, JD83927-11, JD83927-12, JD83927-13, JD83927-14, JD83927-15, JD83927-16, JD83927-17, JD83927-18

Results < IDL are shown as zero for calculation purposes
(*) Outside of QC limits
(anr) Analyte not requested

SERIAL DILUTION RESULTS SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

QC Batch ID: MP45216
Matrix Type: SOLID

Methods: SW846 6010D
Units: ug/l

Prep Date: 03/08/24

Metal	JD83326-1 Original	SDL 1:5	%DIF	QC Limits
Aluminum	46100	44300	3.8	0-10
Antimony	0.00	0.00	NC	0-10
Arsenic	83.7	87.4	4.4	0-10
Barium	99.0	95.8	3.2	0-10
Beryllium	3.70	3.00	18.9 (a)	0-10
Bismuth				
Boron				
Cadmium	1.40	0.00	100.0(a)	0-10
Calcium	873	855	2.0	0-10
Chromium	193	192	0.6	0-10
Cobalt	15.0	14.8	1.3	0-10
Copper	15.0	20.0	33.3 (a)	0-10
Iron	142000	141000	1.0	0-10
Lead	50.5	50.6	0.2	0-10
Lithium				
Magnesium	4240	4140	2.5	0-10
Manganese	271	267	1.7	0-10
Molybdenum				
Nickel	47.8	46.3	3.1	0-10
Phosphorus				
Potassium	6700	6300	5.9	0-10
Selenium	0.00	0.00	NC	0-10
Silicon				
Silver	0.900	0.00	100.0(a)	0-10
Sodium	161	90.4	43.7 (a)	0-10
Strontium				
Sulfur				
Thallium	0.00	0.00	NC	0-10
Tin				
Titanium				
Tungsten				
Vanadium	348	346	0.6	0-10
Zinc	207	207	0.2	0-10

SERIAL DILUTION RESULTS SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

QC Batch ID: MP45216
Matrix Type: SOLID

Methods: SW846 6010D
Units: ug/l

Prep Date: 03/08/24

Metal	JD83326-1 Original SDL 1:5	%DIF	QC Limits
Zirconium			

Associated samples MP45216: JD83927-1, JD83927-2, JD83927-3, JD83927-4, JD83927-5, JD83927-6, JD83927-7, JD83927-8, JD83927-9, JD83927-10, JD83927-11, JD83927-12, JD83927-13, JD83927-14, JD83927-15, JD83927-16, JD83927-17, JD83927-18

Results < IDL are shown as zero for calculation purposes
(*) Outside of QC limits
(anr) Analyte not requested
(a) Percent difference acceptable due to low initial sample concentration (< 50 times IDL).

POST DIGESTATE SPIKE SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

QC Batch ID: MP45216
Matrix Type: SOLID

Methods: SW846 6010D
Units: ug/l

Prep Date: 03/08/24

Metal	Sample ml	Final ml	JD83326-1 Raw	JD83326-1 Corr.**	PS ug/l	Spike ml	Spike ug/ml	Spike ug/l	% Rec	QC Limits
Aluminum										
Antimony	19.25	20			2025	0.2	200	2000	101.3	80-120
Arsenic										
Barium										
Beryllium										
Bismuth										
Boron										
Cadmium										
Calcium										
Chromium										
Cobalt										
Copper										
Iron										
Lead										
Lithium										
Magnesium										
Manganese										
Molybdenum										
Nickel										
Phosphorus										
Potassium										
Selenium										
Silicon										
Silver										
Sodium										
Strontium										
Sulfur										
Thallium										
Tin										
Titanium										
Tungsten										
Vanadium										
Zinc										

POST DIGESTATE SPIKE SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

QC Batch ID: MP45216 Methods: SW846 6010D
Matrix Type: SOLID Units: ug/l

Prep Date: 03/08/24

Metal	Sample ml	Final ml	JD83326-1 Raw	Corr.**	PS ug/l	Spike ml	Spike ug/ml	Spike ug/l	% Rec	QC Limits
Zirconium										

Associated samples MP45216: JD83927-1, JD83927-2, JD83927-3, JD83927-4, JD83927-5, JD83927-6, JD83927-7, JD83927-8, JD83927-9, JD83927-10, JD83927-11, JD83927-12, JD83927-13, JD83927-14, JD83927-15, JD83927-16, JD83927-17, JD83927-18

Results < IDL are shown as zero for calculation purposes
(*) Outside of QC limits
(**) Corr. sample result = Raw * (sample volume / final volume)
(anr) Analyte not requested

BLANK RESULTS SUMMARY
Part 2 - Method Blanks

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

QC Batch ID: MP45278
Matrix Type: SOLID

Methods: SW846 7471B
Units: mg/kg

Prep Date: 03/13/24

Metal	RL	IDL	MDL	MB raw	final
Mercury	0.033	.0022	.015	0.0057	<0.033

Associated samples MP45278: JD83927-1, JD83927-2, JD83927-3, JD83927-4, JD83927-5, JD83927-6, JD83927-7, JD83927-9, JD83927-10, JD83927-11, JD83927-12, JD83927-13, JD83927-14, JD83927-15, JD83927-16, JD83927-17, JD83927-18

Results < IDL are shown as zero for calculation purposes
(*) Outside of QC limits
(anr) Analyte not requested

MATRIX SPIKE AND DUPLICATE RESULTS SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

QC Batch ID: MP45278
Matrix Type: SOLID

Methods: SW846 7471B
Units: mg/kg

Prep Date: 03/13/24

Metal	JD83927-1 Original	MS	Spikelot HGPWS1	% Rec	QC Limits
Mercury	0.010	0.40	0.345	113.1	80-120

Associated samples MP45278: JD83927-1, JD83927-2, JD83927-3, JD83927-4, JD83927-5, JD83927-6, JD83927-7, JD83927-9, JD83927-10, JD83927-11, JD83927-12, JD83927-13, JD83927-14, JD83927-15, JD83927-16, JD83927-17, JD83927-18

Results < IDL are shown as zero for calculation purposes
(*) Outside of QC limits
(N) Matrix Spike Rec. outside of QC limits
(anr) Analyte not requested

MATRIX SPIKE AND DUPLICATE RESULTS SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

QC Batch ID: MP45278 Methods: SW846 7471B
Matrix Type: SOLID Units: mg/kg

Prep Date: 03/13/24

Metal	JD83927-1 Original	MSD	Spikelot HGPWS1	% Rec	MSD RPD	QC Limit
Mercury	0.010	0.39	0.336	113.0	2.5	20

Associated samples MP45278: JD83927-1, JD83927-2, JD83927-3, JD83927-4, JD83927-5, JD83927-6, JD83927-7, JD83927-9, JD83927-10, JD83927-11, JD83927-12, JD83927-13, JD83927-14, JD83927-15, JD83927-16, JD83927-17, JD83927-18

Results < IDL are shown as zero for calculation purposes
(*) Outside of QC limits
(N) Matrix Spike Rec. outside of QC limits
(anr) Analyte not requested

SPIKE BLANK AND LAB CONTROL SAMPLE SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

QC Batch ID: MP45278
Matrix Type: SOLID

Methods: SW846 7471B
Units: mg/kg

Prep Date: 03/13/24

Metal	BSP Result	Spikelot HGPWS1	% Rec	QC Limits
Mercury	0.38	0.333	114.0	80-120

Associated samples MP45278: JD83927-1, JD83927-2, JD83927-3, JD83927-4, JD83927-5, JD83927-6, JD83927-7, JD83927-9, JD83927-10, JD83927-11, JD83927-12, JD83927-13, JD83927-14, JD83927-15, JD83927-16, JD83927-17, JD83927-18

Results < IDL are shown as zero for calculation purposes
(*) Outside of QC limits
(anr) Analyte not requested

BLANK RESULTS SUMMARY
Part 2 - Method Blanks

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

QC Batch ID: MP45342
Matrix Type: SOLID

Methods: SW846 7471B
Units: mg/kg

Prep Date: 03/14/24

Metal	RL	IDL	MDL	MB raw	final
Mercury	0.033	.0066	.015	0.0025	<0.033

Associated samples MP45342: JD83927-8

Results < IDL are shown as zero for calculation purposes
(*) Outside of QC limits
(anr) Analyte not requested

MATRIX SPIKE AND DUPLICATE RESULTS SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

QC Batch ID: MP45342
Matrix Type: SOLID

Methods: SW846 7471B
Units: mg/kg

Prep Date: 03/14/24

Metal	JD84019-2 Original	MS	Spikelot HGPWS1	% Rec	QC Limits
Mercury	0.19	0.53	0.331	102.7	80-120

Associated samples MP45342: JD83927-8

Results < IDL are shown as zero for calculation purposes
(*) Outside of QC limits
(N) Matrix Spike Rec. outside of QC limits
(anr) Analyte not requested

MATRIX SPIKE AND DUPLICATE RESULTS SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

QC Batch ID: MP45342 Methods: SW846 7471B
Matrix Type: SOLID Units: mg/kg

Prep Date: 03/14/24

Metal	JD84019-2 Original	MSD	Spikelot HGPWS1	% Rec	MSD RPD	QC Limit
Mercury	0.19	0.53	0.312	109.1	0.0	20

Associated samples MP45342: JD83927-8

Results < IDL are shown as zero for calculation purposes
(*) Outside of QC limits
(N) Matrix Spike Rec. outside of QC limits
(anr) Analyte not requested

SPIKE BLANK AND LAB CONTROL SAMPLE SUMMARY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

QC Batch ID: MP45342
Matrix Type: SOLID

Methods: SW846 7471B
Units: mg/kg

Prep Date: 03/14/24

Metal	BSP Result	Spikelot HGPWS1	% Rec	QC Limits
Mercury	0.35	0.333	105.0	80-120

Associated samples MP45342: JD83927-8

Results < IDL are shown as zero for calculation purposes
(*) Outside of QC limits
(anr) Analyte not requested

Instrument Detection Limits

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Instrument ID: LEEMANHG8 **Effective Date:** 01/09/24

Analyte	IDL ug/l
Mercury	.013

The above applies to the following instrument runs:
MA55688

Instrument Detection Limits

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Instrument ID: LEEMANHG9 **Effective Date:** 01/09/24

Analyte	IDL ug/l
Mercury	.0396

The above applies to the following instrument runs:
MA55725

Instrument Detection Limits

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Instrument ID: SSTRACE3 **Effective Date:** 02/11/21

Analyte	IDL ug/l
Aluminum	16.6
Antimony	1.7
Arsenic	2.1
Barium	.8
Beryllium	.3
Bismuth	2.3
Boron	2.3
Cadmium	.3
Calcium	6.6
Chromium	.3
Cobalt	.4
Copper	.8
Iron	5.3
Lead	1.1
Lithium	4.8
Magnesium	32.3
Manganese	.1
Molybdenum	.6
Nickel	.4
Phosphorus	1.2
Potassium	76.5
Selenium	3.2
Silicon	1.7
Silver	1
Sodium	34.4
Sulfur	3
Strontium	.3
Thallium	1.8
Tin	.8
Titanium	.5
Tungsten	2.6
Vanadium	.6
Yttrium	5
Zinc	.1
Zirconium	.3

The above applies to the following instrument runs:
MA55691

Instrument Detection Limits

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Instrument ID: SSTRACE6 **Effective Date:** 02/11/21

Analyte	IDL ug/l
Aluminum	9.2
Antimony	2.8
Arsenic	2.6
Barium	.2
Beryllium	.2
Bismuth	2.5
Boron	1.8
Cadmium	.4
Calcium	13
Chromium	.7
Cobalt	.6
Copper	.7
Iron	3.3
Lead	2
Lithium	1.5
Magnesium	24.8
Manganese	.1
Molybdenum	.6
Nickel	.8
Phosphorus	7
Potassium	34.5
Selenium	3.6
Silicon	2.2
Silver	.6
Sodium	13.9
Sulfur	3.7
Strontium	.1
Thallium	5.2
Tin	1.4
Titanium	.8
Tungsten	1.3
Vanadium	.5
Zinc	.3
Zirconium	.5

The above applies to the following instrument runs:
MA55686

Instrument Linear Ranges

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Instrument ID: LEEMANHG8 **Effective Date:** 03/10/17

Analyte	Linear Range ug/l
Mercury	5

The above applies to the following instrument runs:
MA55688

Instrument Linear Ranges

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Instrument ID: LEEMANHG9 **Effective Date:** 02/26/18

Analyte	Linear Range ug/l
Mercury	5

The above applies to the following instrument runs:
MA55725

Instrument Linear Ranges

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Instrument ID: SSTRACE3 **Effective Date:** 08/22/19

Analyte	Linear Range ug/l
Aluminum	300000
Antimony	8000
Arsenic	8000
Barium	8000
Beryllium	8000
Bismuth	8000
Boron	8000
Cadmium	8000
Calcium	200000
Cerium	8000
Chromium	8000
Cobalt	8000
Copper	8000
Iron	200000
Lead	8000
Lithium	8000
Magnesium	300000
Manganese	8000
Molybdenum	8000
Nickel	8000
Palladium	8000
Phosphorus	8000
Potassium	200000
Selenium	8000
Silicon	25000
Silver	625
Sodium	200000
Sulfur	100000
Strontium	8000
Thallium	8000
Tin	8000
Titanium	8000
Tungsten	8000
Vanadium	8000
Zinc	8000
Zirconium	8000

The above applies to the following instrument runs:
MA55691

Instrument Linear Ranges

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Instrument ID: SSTRACE6 **Effective Date:** 08/22/19

Analyte	Linear Range ug/l
Aluminum	300000
Antimony	8000
Arsenic	8000
Barium	8000
Beryllium	8000
Bismuth	8000
Boron	8000
Cadmium	8000
Calcium	200000
Cerium	8000
Chromium	8000
Cobalt	8000
Copper	8000
Iron	200000
Lead	8000
Lithium	8000
Magnesium	300000
Manganese	8000
Molybdenum	8000
Nickel	8000
Palladium	8000
Phosphorus	8000
Potassium	200000
Selenium	8000
Silicon	25000
Silver	625
Sodium	200000
Sulfur	100000
Strontium	8000
Thallium	8000
Tin	8000
Titanium	8000
Tungsten	8000
Vanadium	8000
Zinc	8000
Zirconium	8000

The above applies to the following instrument runs:
MA55686

General Chemistry

QC Data Summaries

Includes the following where applicable:

- Method Blank and Blank Spike Summaries
- Duplicate Summaries
- Matrix Spike Summaries
- Instrument Runlogs/QC
- Percent Solids Raw Data Summary

METHOD BLANK AND SPIKE RESULTS SUMMARY
GENERAL CHEMISTRY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Analyte	Batch ID	RL	MB Result	Units	Spike Amount	BSP Result	BSP %Recov	QC Limits
Cyanide	GP52614/GN52269	0.24	0.0	mg/kg	4.8	5.09	106.0	90-110%
Cyanide	GP52615/GN52269	0.24	0.0	mg/kg	4.8	4.82	100.4	90-110%

Associated Samples:
Batch GP52614: JD83927-9, JD83927-10, JD83927-11, JD83927-12, JD83927-13, JD83927-14, JD83927-15, JD83927-16, JD83927-17, JD83927-18
Batch GP52615: JD83927-1, JD83927-2, JD83927-3, JD83927-4, JD83927-5, JD83927-6, JD83927-7, JD83927-8
(*) Outside of QC limits

DUPLICATE RESULTS SUMMARY
GENERAL CHEMISTRY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Analyte	Batch ID	QC Sample	Units	Original Result	DUP Result	RPD	QC Limits
Cyanide	GP52614/GN52269	JD83927-9	mg/kg	0.0	0.0	0.0	0-49%
Cyanide	GP52615/GN52269	JD83895-4	mg/kg	0.0	0.0	0.0	0-49%
Solids, Percent	GN52142	JD83698-1	%	87.9	87.3	0.7	0-10%

Associated Samples:
Batch GN52142: JD83927-1, JD83927-2, JD83927-3, JD83927-4, JD83927-5, JD83927-6, JD83927-7, JD83927-8, JD83927-9, JD83927-10, JD83927-11, JD83927-12, JD83927-13, JD83927-14, JD83927-15, JD83927-16, JD83927-17, JD83927-18
Batch GP52614: JD83927-9, JD83927-10, JD83927-11, JD83927-12, JD83927-13, JD83927-14, JD83927-15, JD83927-16, JD83927-17, JD83927-18
Batch GP52615: JD83927-1, JD83927-2, JD83927-3, JD83927-4, JD83927-5, JD83927-6, JD83927-7, JD83927-8
(*) Outside of QC limits

MATRIX SPIKE RESULTS SUMMARY
GENERAL CHEMISTRY

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Analyte	Batch ID	QC Sample	Units	Original Result	Spike Amount	MS Result	%Rec	QC Limits
Cyanide	GP52614/GN52269	JD83927-9	mg/kg	0.0	4.97	4.9	98.6	75-125%
Cyanide	GP52615/GN52269	JD83895-4	mg/kg	0.0	5.6	5.4	96.3	75-125%

Associated Samples:
Batch GP52614: JD83927-9, JD83927-10, JD83927-11, JD83927-12, JD83927-13, JD83927-14, JD83927-15, JD83927-16, JD83927-17, JD83927-18
Batch GP52615: JD83927-1, JD83927-2, JD83927-3, JD83927-4, JD83927-5, JD83927-6, JD83927-7, JD83927-8
(*) Outside of QC limits
(N) Matrix Spike Rec. outside of QC limits

SGS Instrument Runlog
Inorganics Analyses

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: D031224W1.CN Date Analyzed: 03/12/24 Methods: EPA 335.4/LACHAT, SW846 9012B/LACHAT
Analyst: JD Run ID: GN52269
Parameters: Cyanide

Time	Sample Description	Dilution Factor	PS Recov	Comments
17:32	GN52269-STD1	1		STDA
17:33	GN52269-STD2	1		STDB
17:34	GN52269-STD3	1		STDC
17:35	GN52269-STD4	1		STDD
17:36	GN52269-STD5	1		STDE
17:37	GN52269-STD6	1		STDF
17:38	GN52269-STD7	1		STDG
17:39	GN52269-ICV1	1		
17:40	GN52269-ICB1	1		
17:41	ZZZZZZ	1		
17:42	GN52269-CCV1	1		
17:43	GN52269-CCB1	1		
17:44	GP52593-MB1	1		
17:44	GP52593-B1	1		
17:45	GP52593-S1	1		
17:46	GP52593-S2	1		
17:47	GP52593-D1	1		
17:48	LA98782-1	1		(sample used for QC only; not part of login JD83927)
17:49	ZZZZZZ	1		
17:50	ZZZZZZ	1		
17:51	ZZZZZZ	1		
17:52	ZZZZZZ	1		
17:53	GN52269-CCV2	1		
17:54	GN52269-CCB2	1		
17:54	ZZZZZZ	1		
17:55	ZZZZZZ	1		
17:56	ZZZZZZ	1		
17:57	ZZZZZZ	1		
17:58	ZZZZZZ	1		
17:59	ZZZZZZ	1		
18:00	JD83832-1	1		(sample used for QC only; not part of login JD83927)
18:01	ZZZZZZ	1		
18:02	ZZZZZZ	1		

SGS Instrument Runlog
Inorganics Analyses

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: D031224W1.CN Date Analyzed: 03/12/24 Methods: EPA 335.4/LACHAT, SW846 9012B/LACHAT
Analyst: JD Run ID: GN52269
Parameters: Cyanide

Time	Sample Description	Dilution Factor	PS Recov	Comments
18:03	ZZZZZZ	1		
18:04	GN52269-CCV3	1		
18:04	GN52269-CCB3	1		
18:05	ZZZZZZ	1		
18:06	ZZZZZZ	1		
18:07	ZZZZZZ	1		
18:08	ZZZZZZ	1		
18:09	GP52594-MB1	1		
18:11	GP52594-S1	1		
18:12	GP52594-D1	1		
18:13	ZZZZZZ	1		
18:14	JD83880-1	1		(sample used for QC only; not part of login JD83927)
18:15	GN52269-CCV4	1		
18:15	GN52269-CCB4	1		
18:16	GP52591-MB1	1		
18:17	GP52591-B1	1		
18:18	GP52591-S1	1		
18:19	GP52591-S2	1		
18:20	GP52591-D1	1		
18:21	JD83959-1	1		(sample used for QC only; not part of login JD83927)
18:22	ZZZZZZ	1		
18:23	ZZZZZZ	1		
18:24	ZZZZZZ	1		
18:25	ZZZZZZ	1		
18:25	GN52269-CCV5	1		
18:26	GN52269-CCB5	1		
18:27	ZZZZZZ	1		
18:28	JD83862-1	1		(sample used for QC only; not part of login JD83927)
18:29	ZZZZZZ	1		
18:30	ZZZZZZ	1		
18:31	ZZZZZZ	1		
18:32	ZZZZZZ	1		
18:33	ZZZZZZ	1		

SGS Instrument Runlog
Inorganics Analyses

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: D031224W1.CN Date Analyzed: 03/12/24 Methods: EPA 335.4/LACHAT, SW846 9012B/LACHAT
Analyst: JD Run ID: GN52269
Parameters: Cyanide

Time	Sample Description	Dilution Factor	PS Recov	Comments
18:34	ZZZZZZ	1		
18:34	ZZZZZZ	1		
18:35	ZZZZZZ	1		
18:36	GN52269-CCV6	1		
18:37	GN52269-CCB6	1		
18:38	ZZZZZZ	1		
18:39	ZZZZZZ	1		
18:40	GP52592-MB1	1		
18:41	GP52592-B1	1		
18:42	GP52592-S1	1		
18:43	GP52592-S2	1		
18:44	GP52592-D1	1		
18:45	JD83234-1	1		(sample used for QC only; not part of login JD83927)
18:45	ZZZZZZ	1		
18:46	ZZZZZZ	1		
18:47	GN52269-CCV7	1		
18:48	GN52269-CCB7	1		
18:49	ZZZZZZ	1		
18:50	ZZZZZZ	1		
18:51	ZZZZZZ	1		
18:52	ZZZZZZ	1		
18:53	JD83956-1	1		(sample used for QC only; not part of login JD83927)
18:54	ZZZZZZ	1		
18:54	ZZZZZZ	1		
18:55	ZZZZZZ	1		
18:56	ZZZZZZ	1		
18:57	ZZZZZZ	1		
18:58	GN52269-CCV8	1		
18:59	GN52269-CCB8	1		
19:00	GP52594-B1	1		
19:01	GP52612-MB1	1		
19:02	GP52612-B1	1		
19:03	GP52612-S1	1		

SGS Instrument Runlog
Inorganics Analyses

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: D031224W1.CN Date Analyzed: 03/12/24 Methods: EPA 335.4/LACHAT, SW846 9012B/LACHAT
Analyst: JD Run ID: GN52269
Parameters: Cyanide

Time	Sample Description	Dilution Factor	PS Recov	Comments
19:04	GP52612-S2	1		
19:04	GP52612-D1	1		
19:05	ZZZZZZ	1		
19:06	ZZZZZZ	1		
19:07	JD84072-1	1		(sample used for QC only; not part of login JD83927)
19:08	JD84072-2	1		(sample used for QC only; not part of login JD83927)
19:09	GN52269-CCV9	1		
19:10	GN52269-CCB9	1		
19:11	ZZZZZZ	1		
19:12	ZZZZZZ	1		
19:13	ZZZZZZ	1		
19:14	ZZZZZZ	1		
19:14	ZZZZZZ	1		
19:15	ZZZZZZ	1		
19:16	ZZZZZZ	1		
19:17	ZZZZZZ	1		
19:18	ZZZZZZ	1		
19:19	ZZZZZZ	1		
19:20	GN52269-CCV10	1		
19:21	GN52269-CCB10	1		
19:22	ZZZZZZ	1		
19:23	ZZZZZZ	1		
19:24	ZZZZZZ	1		
19:24	ZZZZZZ	1		
19:25	ZZZZZZ	1		
19:26	ZZZZZZ	1		
19:27	GP52613-MB1	1		
19:28	GP52613-B1	1		
19:29	GP52613-S1	1		
19:30	GP52613-D1	1		
19:31	GN52269-CCV11	1		
19:32	GN52269-CCB11	1		
19:33	ZZZZZZ	1		

SGS Instrument Runlog
Inorganics Analyses

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: D031224W1.CN Date Analyzed: 03/12/24 Methods: EPA 335.4/LACHAT, SW846 9012B/LACHAT
Analyst: JD Run ID: GN52269
Parameters: Cyanide

Time	Sample Description	Dilution Factor	PS Recov	Comments
19:34	ZZZZZZ	1		
19:34	ZZZZZZ	1		
19:35	JD83950-2	1		(sample used for QC only; not part of login JD83927)
19:36	ZZZZZZ	1		
19:37	ZZZZZZ	1		
19:38	ZZZZZZ	1		
19:39	ZZZZZZ	1		
19:40	GP52614-MB1	1		
19:41	GP52614-B1	1		
19:42	GN52269-CCV12	1		
19:43	GN52269-CCB12	1		
19:44	GP52614-S1	1		
19:44	GP52614-S2	1		
19:45	GP52614-D1	1		
19:46	JD83927-9	1		
19:47	JD83927-10	1		
19:48	JD83927-11	1		
19:49	JD83927-12	1		
19:50	JD83927-13	1		
19:51	JD83927-14	1		
19:52	JD83927-15	1		
19:53	GN52269-CCV13	1		
19:54	GN52269-CCB13	1		
19:54	JD83927-16	1		
19:55	JD83927-17	1		
19:56	JD83927-18	1		
19:57	ZZZZZZ	1		
19:58	ZZZZZZ	1		
19:59	ZZZZZZ	1		
20:00	ZZZZZZ	1		
20:01	JD84074-1	1		(sample used for QC only; not part of login JD83927)
20:02	ZZZZZZ	1		
20:03	ZZZZZZ	1		

SGS Instrument Runlog
Inorganics Analyses

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: D031224W1.CN Date Analyzed: 03/12/24 Methods: EPA 335.4/LACHAT, SW846 9012B/LACHAT
Analyst: JD Run ID: GN52269
Parameters: Cyanide

Time	Sample Description	Dilution Factor	PS Recov	Comments
20:04	GN52269-CCV14	1		
20:05	GN52269-CCB14	1		
20:05	ZZZZZZ	1		
20:06	ZZZZZZ	1		
20:07	GP52615-MB1	1		
20:08	GP52615-B1	1		
20:09	GP52615-S1	1		
20:10	GP52615-S2	1		
20:11	GP52615-D1	1		
20:12	ZZZZZZ	1		
20:13	JD83890-2	1		(sample used for QC only; not part of login JD83927)
20:14	ZZZZZZ	1		
20:15	GN52269-CCV15	1		
20:15	GN52269-CCB15	1		
20:16	ZZZZZZ	1		
20:17	ZZZZZZ	1		
20:18	ZZZZZZ	1		
20:19	ZZZZZZ	1		
20:20	ZZZZZZ	1		
20:21	JD83895-4	1		(sample used for QC only; not part of login JD83927)
20:22	ZZZZZZ	1		
20:23	ZZZZZZ	1		
20:24	JD83927-1	1		
20:25	JD83927-2	1		
20:26	GN52269-CCV16	1		
20:26	GN52269-CCB16	1		
20:27	JD83927-3	1		
20:28	JD83927-4	1		
20:29	JD83927-5	1		
20:30	JD83927-6	1		
20:31	JD83927-7	1		
20:32	JD83927-8	1		
20:37	GN52269-CCV17	1		

SGS Instrument Runlog
Inorganics Analyses

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: D031224W1.CN Date Analyzed: 03/12/24 Methods: EPA 335.4/LACHAT, SW846 9012B/LACHAT
Analyst: JD Run ID: GN52269
Parameters: Cyanide

Time	Sample Description	Dilution Factor	PS Recov	Comments
20:37	GN52269-CCB17	1		

Refer to raw data for calibration curve and standards.

Instrument QC Summary
Inorganics Analyses

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: D031224W1.CN Date Analyzed: 03/12/24 Methods: EPA 335.4/LACHAT, SW846 9012B/LACHAT
Run ID: GN52269 Units: mg/l

Sample Number	Parameter	Result	RL	IDL/MDL	True Value	% Recov.	QC Limits
GN52269-ICV1	Cyanide	0.328	0.010	0.0041	.3	109.3	90-110
GN52269-ICB1	Cyanide	-0.00954	0.010	0.0041			
GN52269-CCV1	Cyanide	0.423	0.010	0.0041	.4	105.8	90-110
GN52269-CCB1	Cyanide	-0.00966	0.010	0.0041			
GN52269-CCV2	Cyanide	0.422	0.010	0.0041	.4	105.5	90-110
GN52269-CCB2	Cyanide	-0.0101 <	0.010	0.0041			
GN52269-CCV3	Cyanide	0.419	0.010	0.0041	.4	104.8	90-110
GN52269-CCB3	Cyanide	-0.00807	0.010	0.0041			
GN52269-CCV4	Cyanide	0.427	0.010	0.0041	.4	106.8	90-110
GN52269-CCB4	Cyanide	-0.00693	0.010	0.0041			
GN52269-CCV5	Cyanide	0.422	0.010	0.0041	.4	105.5	90-110
GN52269-CCB5	Cyanide	-0.00534	0.010	0.0041			
GN52269-CCV6	Cyanide	0.426	0.010	0.0041	.4	106.5	90-110
GN52269-CCB6	Cyanide	-0.0102 <	0.010	0.0041			
GN52269-CCV7	Cyanide	0.420	0.010	0.0041	.4	105.0	90-110
GN52269-CCB7	Cyanide	-0.00621	0.010	0.0041			
GN52269-CCV8	Cyanide	0.416	0.010	0.0041	.4	104.0	90-110
GN52269-CCB8	Cyanide	-0.00993	0.010	0.0041			
GN52269-CCV9	Cyanide	0.418	0.010	0.0041	.4	104.5	90-110
GN52269-CCB9	Cyanide	-0.00936	0.010	0.0041			
GN52269-CCV10	Cyanide	0.418	0.010	0.0041	.4	104.5	90-110
GN52269-CCB10	Cyanide	-0.0101 <	0.010	0.0041			
GN52269-CCV11	Cyanide	0.418	0.010	0.0041	.4	104.5	90-110
GN52269-CCB11	Cyanide	-0.00852	0.010	0.0041			
GN52269-CCV12	Cyanide	0.417	0.010	0.0041	.4	104.3	90-110
GN52269-CCB12	Cyanide	-0.00980	0.010	0.0041			
GN52269-CCV13	Cyanide	0.418	0.010	0.0041	.4	104.5	90-110
GN52269-CCB13	Cyanide	-0.0103 <	0.010	0.0041			
GN52269-CCV14	Cyanide	0.427	0.010	0.0041	.4	106.8	90-110
GN52269-CCB14	Cyanide	-0.0104 <	0.010	0.0041			
GN52269-CCV15	Cyanide	0.416	0.010	0.0041	.4	104.0	90-110
GN52269-CCB15	Cyanide	-0.00882	0.010	0.0041			
GN52269-CCV16	Cyanide	0.414	0.010	0.0041	.4	103.5	90-110
GN52269-CCB16	Cyanide	-0.00582	0.010	0.0041			

Instrument QC Summary
Inorganics Analyses

Login Number: JD83927
Account: SESINJPB - SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

File ID: D031224W1.CN Date Analyzed: 03/12/24 Methods: EPA 335.4/LACHAT, SW846 9012B/LACHAT
Run ID: GN52269 Units: mg/l

Sample Number	Parameter	Result	RL	IDL/MDL	True Value	% Recov.	QC Limits
GN52269-CCV17	Cyanide	0.414	0.010	0.0041	.4	103.5	90-110
GN52269-CCB17	Cyanide	-0.00988	0.010	0.0041			

(!) Outside of QC limits

Percent Solids Raw Data Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: JD83927-1 **Analyzed:** 08-MAR-24 by SC **Method:** SM2540 G 18TH ED MOD
ClientID: SB-7(4-4.5)030724

Wet Weight (Total)	32	g
Tare Weight	26.25	g
Dry Weight (Total)	31.65	g
Solids, Percent	93.9	%

Sample: JD83927-2 **Analyzed:** 08-MAR-24 by SC **Method:** SM2540 G 18TH ED MOD
ClientID: SB-7(7-7.5)030724

Wet Weight (Total)	34.63	g
Tare Weight	26.89	g
Dry Weight (Total)	33.72	g
Solids, Percent	88.2	%

Sample: JD83927-3 **Analyzed:** 08-MAR-24 by SC **Method:** SM2540 G 18TH ED M
ClientID: SB-8(4-4.5)030724

Wet Weight (Total)	37.1	g
Tare Weight	30.96	g
Dry Weight (Total)	36.68	g
Solids, Percent	93.2	%

Sample: JD83927-4 **Analyzed:** 08-MAR-24 by SC **Method:** SM2540 G 18TH ED MOD
ClientID: SB-8(7.5-8)030724

Wet Weight (Total)	35.94	g
Tare Weight	29.45	g
Dry Weight (Total)	35.24	g
Solids, Percent	89.2	%

Sample: JD83927-5 **Analyzed:** 08-MAR-24 by SC **Method:** SM2540 G 18TH ED MOD
ClientID: SB-9(3.5-4)030724

Wet Weight (Total)	30.44	g
Tare Weight	24.78	g
Dry Weight (Total)	30.18	g
Solids, Percent	95.4	%

Sample: JD83927-6 **Analyzed:** 08-MAR-24 by SC **Method:** SM2540 G 18TH ED MOD
ClientID: SB-10(3.5-4)030724

Wet Weight (Total)	39.52	g
Tare Weight	33.02	g
Dry Weight (Total)	39.05	g
Solids, Percent	92.8	%

Percent Solids Raw Data Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: JD83927-7 **Analyzed:** 08-MAR-24 by SC **Method:** SM2540 G 18TH ED MOD
ClientID: SB-10(7-5.5)030724

Wet Weight (Total)	27.06	g
Tare Weight	19.57	g
Dry Weight (Total)	26.06	g
Solids, Percent	86.6	%

Sample: JD83927-8 **Analyzed:** 08-MAR-24 by SC **Method:** SM2540 G 18TH ED MOD
ClientID: SB-11(3.5-4)030724

Wet Weight (Total)	30.83	g
Tare Weight	25.34	g
Dry Weight (Total)	30.27	g
Solids, Percent	89.8	%

Sample: JD83927-9 **Analyzed:** 08-MAR-24 by SC **Method:** SM2540 G 18TH ED M
ClientID: SB-11(8-8.5)030724

Wet Weight (Total)	31.86	g
Tare Weight	26.35	g
Dry Weight (Total)	31.1	g
Solids, Percent	86.2	%

Sample: JD83927-10 **Analyzed:** 08-MAR-24 by SC **Method:** SM2540 G 18TH ED MOD
ClientID: SB-16(3-3.5)030724

Wet Weight (Total)	36.63	g
Tare Weight	31.34	g
Dry Weight (Total)	36.11	g
Solids, Percent	90.2	%

Sample: JD83927-11 **Analyzed:** 08-MAR-24 by SC **Method:** SM2540 G 18TH ED MOD
ClientID: SB-16(7.5-8)030724

Wet Weight (Total)	34.01	g
Tare Weight	27.27	g
Dry Weight (Total)	33.08	g
Solids, Percent	86.2	%

Sample: JD83927-12 **Analyzed:** 08-MAR-24 by SC **Method:** SM2540 G 18TH ED MOD
ClientID: SB-19(4-4.5)030724

Wet Weight (Total)	26.02	g
Tare Weight	20.51	g
Dry Weight (Total)	25.36	g
Solids, Percent	88	%

Percent Solids Raw Data Summary

Job Number: JD83927
Account: SESINJPB SESI Consulting Engineers
Project: 100 Main Street, White Plains, NY

Sample: JD83927-13 **Analyzed:** 08-MAR-24 by SC **Method:** SM2540 G 18TH ED MOD
ClientID: SB-19(7-7.5)030724

Wet Weight (Total)	34.57	g
Tare Weight	28.69	g
Dry Weight (Total)	33.52	g
Solids, Percent	82.1	%

Sample: JD83927-14 **Analyzed:** 08-MAR-24 by SC **Method:** SM2540 G 18TH ED MOD
ClientID: SB-22(3.5-4)030724

Wet Weight (Total)	33.89	g
Tare Weight	28.44	g
Dry Weight (Total)	33.64	g
Solids, Percent	95.4	%

Sample: JD83927-15 **Analyzed:** 08-MAR-24 by SC **Method:** SM2540 G 18TH ED M
ClientID: SB-22(8-8.5)030724

Wet Weight (Total)	33.49	g
Tare Weight	27.36	g
Dry Weight (Total)	33.2	g
Solids, Percent	95.3	%

Sample: JD83927-16 **Analyzed:** 08-MAR-24 by SC **Method:** SM2540 G 18TH ED MOD
ClientID: SB-25(1.5-2)030724

Wet Weight (Total)	33.5	g
Tare Weight	28.07	g
Dry Weight (Total)	33.2	g
Solids, Percent	94.5	%

Sample: JD83927-17 **Analyzed:** 08-MAR-24 by SC **Method:** SM2540 G 18TH ED MOD
ClientID: SB-25(3-3.5)030724

Wet Weight (Total)	29.71	g
Tare Weight	24.51	g
Dry Weight (Total)	29.41	g
Solids, Percent	94.2	%

Sample: JD83927-18 **Analyzed:** 08-MAR-24 by SC **Method:** SM2540 G 18TH ED MOD
ClientID: SB-25(7.5-8)030724

Wet Weight (Total)	42.2	g
Tare Weight	34.38	g
Dry Weight (Total)	41.68	g
Solids, Percent	93.4	%

Appendix E:

Site Photo Log

Photograph 1
Northeastern face of the Galleria Mall on Main Street, Macys Side loading bay doors.

Photograph 2
Southwestern parking facility entrance on Martine Ave.

Photograph 3
Adjacent property to the northeast of Galleria Mall across Main Street.

Photograph 4
Adjacent building to the west of Galleria Mall, across N Lexington Ave.

Photograph 5
Another adjacent building to the west of Galleria Mall, across N Lexington Ave.

Photograph 6
Adjacent property to the south across Martine Ave.

Photograph 7
Another adjacent property to the south across Martine Ave.

Photograph 8
Electrical control panel on the western portion of Galleria Mall.

Photograph 9
Another AST located in the western loading bay of Galleria Mall.

Photograph 10
Tank manufacturer logo on the side of the AST located in the western loading bay or Galleria Mall.

Photograph 11
Storage container located in the midwestern loading area of Galleria Mall.



Photograph 12
Chemical storage closet located in the midwestern loading area of Galleria Mall.



Photograph 13
Drum with used oil in chemical and fluid closet located in the midsection of Galleria Mall.

Photograph 14
Example of sewer system in the back of the midsection of Galleria Mall.



Photograph 15
Old closed UST location located in the western underground parking area of Galleria Mall.

Photograph 16
Another closed UST location on the ramp to MLK Blvd from the western underground parking area.



Photograph 17
Another view of closed UST location.

Photograph 18
Used cooking oil storage location in underground western parking area.

Photograph 19
Pit located on the western portion of Blink Fitness.

Photograph 20
Main entry point in west portion of Blink Fitness.

Photograph 21
Pit located in the western portion of Blink Fitness.



Photograph 22
Blink Fitness rooms of the western portion of the Galleria Mall.

Photograph 23
Electrical panel in the western area Blink Fitness room.



Photograph 24
Second floor of the Galleria Mall.

Photograph 25
Fourth floor view of western portion units of the Galleria Mall.