



1221 E. Henrietta Rd.
Rochester, NY 14623
Telephone (585) 424-2310
Fax (585) 424-1733
☎ 1-800-952-5952 ☎

February 9, 2015

ICM Properties, LLC
550 Bernard Street
Rochester, New York 14621

ATTN: Mr. Greg Stahl, President

RE: Industrial Hygiene Services - 10 Chapin Street, Canandaigua, New York

Dear Mr. Stahl:

In regard to our recent agreement, TES ENVIRONMENTAL CORPORATION has provided industrial hygiene services during the asbestos abatement project completed within 10 Chapin Street, Canandaigua, New York. Based on the information provided, the industrial hygiene services consisted of air sample collection, sample analysis and inspection services. To the best of our knowledge, CRAL Contracting of Syracuse, NY, completed the work in accordance with all local, state and federal regulations. The asbestos abatement project consisted of the removal and decontamination of building materials located in the lower section of the building. The industrial hygiene services were provided in direct regard to the New York State Department of Labor-Code Rule 56. The phase contrast microscopy samples were analyzed by TES ENVIRONMENTAL CORPORATION. TES ENVIRONMENTAL CORPORATION is licensed by the New York State Department of Health (#10890). The samples were analyzed by phase contrast microscopy in accordance with the NIOSH 7400 Method. The inspection services were performed by Certified Project Monitors, Joseph Fowler (#01-12814) and Jerry Milne (#88-00808).

SE AREA

The work area preparation was activated on November 10, 2014 and completed on November 12, 2014. Air sampling was completed throughout the preparation phase with air sample results of less than 0.01 fibers per cubic centimeter. The removal was activated on November 13, 2014. Environmental sampling was completed throughout the abatement phase. The air sample results were well within acceptable levels. The removal was halted on December 15, 2014 due to exterior water leaking into the area. The area was sealed until the water could be cleaned up. The area was reactivated on January 5, 2015. The abatement was completed on January 7, 2015. A final visual inspection was completed prior to the activation of aggressive sampling techniques. The area was free of any visible debris. The final air levels established by Code Rule-56.

NORTH AREA

The work area preparation was activated on November 28, 2014 and completed on December 16, 2014. Air sampling was completed throughout the preparation phase, with air sample results of less than 0.01 fibers per cubic centimeter. The removal was activated on December 17, 2014 and completed on December 31, 2014. Environmental sample results were less than 0.01 fibers per cubic centimeter. A final visual inspection was completed on January 2, 2015 and the area was deemed free of any visible debris. Aggressive sampling techniques were activated on January 2, 2015.

The final air sampling results were less than 0.003 fibers per cubic centimeter, well within the clearance sample levels established by Code Rule-56. The laboratory results have been enclosed for your review.

I trust this information meets your needs. If you have any further questions, please don't hesitate to contact me.

Sincerely,

Charles M. Blake

Charles M. Blake

President

LABORATORY ANALYSIS REPORT

1221 E. Henrietta Rd.
Rochester, NY 14623
Telephone (585) 424-2310
Fax (585) 424-1733
☎ 1-800-952-5952 ☎

Client: ICM Properties, LLC**Date Rec'd:** 11/11/14**Address:** 550 Bernard Street, Rochester, New York 14621**JOB Location:** 10 CHAPIN ST, CANANDAIGUA, NY – SE AREA

Disturbance Area #1

TES Job #: 14A-017**Client Job #:****Analytical Method:** PCM- NIOSH 7400 **ELAP:** 10890**Make & Model Olympus BH2:** 225048

SAMPLE ID	VOLUME liters	RESULTS		LOCATION	SAMPLE TYPE	DATE SAMPLED
		STRUCT/mm ²	FIBERS/cm ³			
1	1100	<8.9	<0.003	DECON	PRE	11/10/14
2	1100	<8.9	<0.003	AMBIENT AIR	PRE	11/10/14
3	1100	<8.9	<0.003	CRITICAL 1	PRE	11/10/14
4	1100	<8.9	<0.003	WASTE DECON	PRE	11/10/14
5	1100	<8.9	<0.003	CRITICAL 2	PRE	11/10/14
6	1100	<8.9	<0.003	NAU BANK	PRE	11/10/14
7			0	FIELD BLANK		11/10/14
8			0	FIELD BLANK		11/10/14

BCK = Background •PRE = Preabatement•ENV = Environmental•FNL=Final•PER = Personal•EXC = Excursion•(<) Below detectable level

TES air samples are collected as described by NYSDOL Code Rule 56 utilizing air rotometers with inherent accuracy of +/- 0.5 liters. Air samples analyzed by Phase Contrast Microscopy follow NIOSH 7400 Method, Issue 2, dated August 15, 1994. The analytical results relate only to the samples submitted for testing, in the condition received by the laboratory. This report shall not be reproduced except in full, without the written approval of the laboratory.

CV: High to low 0.213 to 0.079

SUBMITTED BY: _____

APPROVED BY: Charles M. Blake DATE: 11/11/14

Charles M. Blake, Laboratory Manager

LABORATORY ANALYSIS REPORT

1221 E. Henrietta Rd.
Rochester, NY 14623
Telephone (585) 424-2310
Fax (585) 424-1733
☎ 1-800-952-5952 ☎

Client: ICM Properties, LLC**Date Rec'd:** 11/12/14**Address:** 550 Bernard Street, Rochester, New York 14621**JOB Location:** 10 CHAPIN ST, CANANDAIGUA, NY – SE AREA**TES Job #:** 14A-017**Client Job #:****Analytical Method:** PCM- NIOSH 7400 **ELAP:** 10890**Make & Model Olympus BH2:** 225048

SAMPLE ID	VOLUME liters	RESULTS		LOCATION	SAMPLE TYPE	DATE SAMPLED
		STRUCT/mm ²	FIBERS/cm ³			
1p	1260	<8.9	<0.003	NEG AIR	PRE	11/11/14
2p	1260	<8.9	<0.003	AMBIENT AIR	PRE	11/11/14
3p	1260	<8.9	<0.003	WASTE OUT	PRE	11/11/14
4p	1260	<8.9	<0.003	PERSONAL DECON	PRE	11/11/14
5p	1260	<8.9	<0.003	CRITICAL	PRE	11/11/14
6p	1260	<8.9	<0.003	CRITICAL	PRE	11/11/14
7p			0	FIELD BLANK		11/11/14
8p			0	FIELD BLANK		11/11/14

BCK = Background •PRE = Preabatement•ENV = Environmental•FNL=Final•PER = Personal•EXC = Excursion•(<) Below detectable level

TES air samples are collected as described by NYSDOL Code Rule 56 utilizing air rotometers with inherent accuracy of +/- 0.5 liters. Air samples analyzed by Phase Contrast Microscopy follow NIOSH 7400 Method, Issue 2, dated August 15, 1994. The analytical results relate only to the samples submitted for testing, in the condition received by the laboratory. This report shall not be reproduced except in full, without the written approval of the laboratory.

CV: High to low 0.213 to 0.079

SUBMITTED BY: _____

APPROVED BY: Charles M. Blake

DATE: 11/12/14

Charles M. Blake, Laboratory Manager

LABORATORY ANALYSIS REPORT

T.E.S. ENVIRONMENTAL CORP.

1221 E. Henrietta Rd.
Rochester, NY 14623
Telephone (585) 424-2310
Fax (585) 424-1733

☎ 1-800-952-5952 ☎

Client: ICM Properties, LLC**Date Rec'd:** 11/13/14**Address:** 550 Bernard Street, Rochester, New York 14621**JOB Location:** 10 CHAPIN ST, CANANDAIGUA, NY – SE SECTION

REAR BLDG

TES Job #: 14A-017**Client Job #:****Analytical Method:** PCM- NIOSH 7400 **ELAP:** 10890**Make & Model Olympus BH2:** 225048

SAMPLE ID	VOLUME liters	RESULTS		LOCATION	SAMPLE TYPE	DATE SAMPLED
		STRUCT/mm ²	FIBERS/cm ³			
1	1200	<8.9	<0.003	DECON	PRE	11/12/14
2	1200	<8.9	<0.003	WASTE DECON	PRE	11/12/14
3	1200	<8.9	<0.003	NAU BANK 1	PRE	11/12/14
4	1200	<8.9	<0.003	NAU BANK 2	PRE	11/12/14
5	1200	<8.9	<0.003	CRITICAL 1	PRE	11/12/14
6	1200	<8.9	<0.003	CRITICAL 2	PRE	11/12/14
7			0	FIELD BLANK		11/12/14
8			0	FIELD BLANK		11/12/14
9	1200	<8.9	<0.003	AMBIENT AIR	PRE	11/12/14

BCK = Background •PRE = Preabatement•ENV = Environmental•FNL=Final•PER = Personal•EXC = Excursion•(<) Below detectable level

TES air samples are collected as described by NYSDOL Code Rule 56 utilizing air rotometers with inherent accuracy of +/- 0.5 liters. Air samples analyzed by Phase Contrast Microscopy follow NIOSH 7400 Method, Issue 2, dated August 15, 1994. The analytical results relate only to the samples submitted for testing, in the condition received by the laboratory. This report shall not be reproduced except in full, without the written approval of the laboratory.

CV: High to low 0.213 to 0.079

SUBMITTED BY: _____

APPROVED BY: Charles M. Blake

DATE: 11/13/14

Charles M. Blake, Laboratory Manager

LABORATORY ANALYSIS REPORT

1221 E. Henrietta Rd.
Rochester, NY 14623
Telephone (585) 424-2310
Fax (585) 424-1733
☎ 1-800-952-5952 ☎

Client: ICM Properties, LLC**Date Rec'd:** 11/14/14**Address:** 550 Bernard Street, Rochester, New York 14621**JOB Location:** 10 CHAPIN ST, CANANDAIGUA, NY – SE AREA**TES Job #:** 14A-017**Client Job #:****Analytical Method:** PCM- NIOSH 7400 **ELAP:** 10890**Make & Model Olympus BH2:** 225048

SAMPLE ID	VOLUME liters	RESULTS		LOCATION	SAMPLE TYPE	DATE SAMPLED
		STRUCT/mm ²	FIBERS/cm ³			
1	1110	<8.9	<0.003	PERSONAL DECON	ENV	11/13/14
2	1101	<8.9	<0.003	WASTE DECON	ENV	11/13/14
3	1110	<8.9	<0.003	ISOLATION BARRIER 1	ENV	11/13/14
4	1098	<8.9	<0.003	ISOLATION BARRIER 2	ENV	11/13/14
5	1104	<8.9	<0.003	NAU 1	ENV	11/13/14
6	1104	<8.9	<0.003	NAU 2	ENV	11/13/14
7	740	<8.9	<0.005	EEA REAR PARKING LOT	ENV	11/13/14
8			0	FIELD BLANK		11/13/14
9			0	FIELD BLANK		11/13/14

BCK = Background •PRE = Preabatement•ENV = Environmental•FNL=Final•PER = Personal•EXC = Excursion•(<) Below detectable level

TES air samples are collected as described by NYSDOL Code Rule 56 utilizing air rotometers with inherent accuracy of +/- 0.5 liters. Air samples analyzed by Phase Contrast Microscopy follow NIOSH 7400 Method, Issue 2, dated August 15, 1994. The analytical results relate only to the samples submitted for testing, in the condition received by the laboratory. This report shall not be reproduced except in full, without the written approval of the laboratory.

CV: High to low 0.213 to 0.079

SUBMITTED BY: _____

APPROVED BY: Charles M. Blake DATE: 11/14/14

Charles M. Blake, Laboratory Manager

LABORATORY ANALYSIS REPORT

1221 E. Henrietta Rd.
Rochester, NY 14623
Telephone (585) 424-2310
Fax (585) 424-1733
☎ 1-800-952-5952 ☎

Client: ICM Properties, LLC**Date Rec'd:** 11/15/14**Address:** 550 Bernard Street, Rochester, New York 14621**JOB Location:** 10 CHAPIN ST, CANANDAIGUA, NY – SE AREA I.D.#1**TES Job #:** 14A-017**Client Job #:****Analytical Method:** PCM- NIOSH 7400 **ELAP:** 10890**Make & Model Olympus BH2:** 225048

SAMPLE ID	VOLUME liters	RESULTS		LOCATION	SAMPLE TYPE	DATE SAMPLED
		STRUCT/mm ²	FIBERS/cm ³			
1	1080	<8.9	<0.003	PERSONAL DECON	ENV	11/14/14
2	1080	<8.9	<0.003	WASTE DECON	ENV	11/14/14
3	1080	<8.9	<0.003	ISOLATION BARRIER 1	ENV	11/14/14
4	1080	<8.9	<0.003	ISOLATION BARRIER 2	ENV	11/14/14
5	1080	<8.9	<0.003	NAU 1	ENV	11/14/14
6	1080	<8.9	<0.003	NAU 2	ENV	11/14/14
7	720	<8.9	<0.005	EEA REAR PARKING LOT	ENV	11/14/14
8			0	FIELD BLANK		11/14/14
9			0	FIELD BLANK		11/14/14

BCK = Background •PRE = Preabatement•ENV = Environmental•FNL=Final•PER = Personal•EXC = Excursion•(<) Below detectable level

TES air samples are collected as described by NYSDOL Code Rule 56 utilizing air rotometers with inherent accuracy of +/- 0.5 liters. Air samples analyzed by Phase Contrast Microscopy follow NIOSH 7400 Method, Issue 2, dated August 15, 1994. The analytical results relate only to the samples submitted for testing, in the condition received by the laboratory. This report shall not be reproduced except in full, without the written approval of the laboratory.

CV: High to low 0.213 to 0.079

SUBMITTED BY: _____

APPROVED BY: Charles M. Blake DATE: 11/15/14

Charles M. Blake, Laboratory Manager

LABORATORY ANALYSIS REPORT

T.E.S. ENVIRONMENTAL CORP.

1221 E. Henrietta Rd.
Rochester, NY 14623
Telephone (585) 424-2310
Fax (585) 424-1733

☎ 1-800-952-5952 ☎

Client: ICM Properties, LLC**Date Rec'd:** 11/18/14**Address:** 550 Bernard Street, Rochester, New York 14621**JOB Location:** 10 CHAPIN ST, CANANDAIGUA, NY – SE AREA I.D.#1**TES Job #:** 14A-017**Client Job #:****Analytical Method:** PCM- NIOSH 7400 **ELAP:** 10890**Make & Model Olympus BH2:** 225048

SAMPLE ID	VOLUME liters	RESULTS		LOCATION	SAMPLE TYPE	DATE SAMPLED
		STRUCT/mm ²	FIBERS/cm ³			
1	1360	<8.9	<0.003	PERSONAL DECON	ENV	11/17/14
2	1360	<8.9	<0.003	WASTE DECON	ENV	11/17/14
3	1360	<8.9	<0.003	ISOLATION BARRIER 1	ENV	11/17/14
4	1360	<8.9	<0.003	ISOLATION BARRIER 2	ENV	11/17/14
5	1360	<8.9	<0.003	NAU 1	ENV	11/17/14
6	1360	<8.9	<0.003	NAU 2	ENV	11/17/14
7	1020	<8.9	<0.003	EEA REAR PARKING LOT	ENV	11/17/14
8			0	FIELD BLANK		11/17/14
9			0	FIELD BLANK		11/17/14

BCK = Background •PRE = Preabatement•ENV = Environmental•FNL=Final•PER = Personal•EXC = Excursion•(<) Below detectable level

TES air samples are collected as described by NYSDOL Code Rule 56 utilizing air rotometers with inherent accuracy of +/- 0.5 liters. Air samples analyzed by Phase Contrast Microscopy follow NIOSH 7400 Method, Issue 2, dated August 15, 1994. The analytical results relate only to the samples submitted for testing, in the condition received by the laboratory. This report shall not be reproduced except in full, without the written approval of the laboratory.

CV: High to low 0.213 to 0.079

SUBMITTED BY: _____

APPROVED BY: Charles M. Blake
Charles M. Blake, Laboratory Manager

DATE: 11/18/14

LABORATORY ANALYSIS REPORT

1221 E. Henrietta Rd.
Rochester, NY 14623
Telephone (585) 424-2310
Fax (585) 424-1733
☎ 1-800-952-5952 ☎

Client: ICM Properties, LLC**Date Rec'd:** 11/20/14**Address:** 550 Bernard Street, Rochester, New York 14621**JOB Location:** 10 CHAPIN ST, CANANDAIGUA, NY – SE AREA WA 1**TES Job #:** 14A-017**Client Job #:****Analytical Method:** PCM- NIOSH 7400 **ELAP:** 10890**Make & Model Olympus BH2:** 225048

SAMPLE ID	VOLUME liters	RESULTS		LOCATION	SAMPLE TYPE	DATE SAMPLED
		STRUCT/mm ²	FIBERS/cm ³			
1	1460	<8.9	<0.002	AMBIENT AIR	ENV	11/19/14
2	1460	<8.9	<0.002	DECON	ENV	11/19/14
3	1460	<8.9	<0.002	CRITICAL 1	ENV	11/19/14
4	1460	<8.9	<0.002	WASTE DECON	ENV	11/19/14
5	1456	<8.9	<0.002	CRITICAL 2	ENV	11/19/14
6	1456	<8.9	<0.002	NAU BANK LEFT	ENV	11/19/14
7	1456	<8.9	<0.002	NAU BANK RIGHT	ENV	11/19/14
8			0	FIELD BLANK		11/19/14
9			0	FIELD BLANK		11/19/14

BCK = Background •PRE = Preabatement•ENV = Environmental•FNL=Final•PER = Personal•EXC = Excursion•(<) Below detectable level

TES air samples are collected as described by NYSDOL Code Rule 56 utilizing air rotometers with inherent accuracy of +/- 0.5 liters. Air samples analyzed by Phase Contrast Microscopy follow NIOSH 7400 Method, Issue 2, dated August 15, 1994. The analytical results relate only to the samples submitted for testing, in the condition received by the laboratory. This report shall not be reproduced except in full, without the written approval of the laboratory.

CV: High to low 0.213 to 0.079

SUBMITTED BY: _____

APPROVED BY: Charles M. Blake DATE: 11/20/14

Charles M. Blake, Laboratory Manager

LABORATORY ANALYSIS REPORT

1221 E. Henrietta Rd.
Rochester, NY 14623
Telephone (585) 424-2310
Fax (585) 424-1733
☎ 1-800-952-5952 ☎

Client: ICM Properties, LLC**Date Rec'd:** 11/21/14**Address:** 550 Bernard Street, Rochester, New York 14621**JOB Location:** 10 CHAPIN ST, CANANDAIGUA, NY – SE AREA I.D.#1**TES Job #:** 14A-017**Client Job #:****Analytical Method:** PCM- NIOSH 7400 **ELAP:** 10890**Make & Model Olympus BH2:** 225048

SAMPLE ID	VOLUME liters	RESULTS		LOCATION	SAMPLE TYPE	DATE SAMPLED
		STRUCT/mm ²	FIBERS/cm ³			
1	1230	<8.9	<0.003	AMBIENT	ENV	11/20/14
2	1230	<8.9	<0.003	NAU 1	ENV	11/20/14
3	1230	<8.9	<0.003	NAU 2	ENV	11/20/14
4	1230	<8.9	<0.003	CRITICAL 1	ENV	11/20/14
5	1230	<8.9	<0.003	WASTE OUT	ENV	11/20/14
6	1230	<8.9	<0.003	CRITICAL 2	ENV	11/20/14
7	1230	<8.9	<0.003	DECON	ENV	11/20/14
8			0	FIELD BLANK		11/20/14
9			0	FIELD BLANK		11/20/14

BCK = Background •PRE = Preabatement•ENV = Environmental•FNL=Final•PER = Personal•EXC = Excursion•(<) Below detectable level

TES air samples are collected as described by NYSDOL Code Rule 56 utilizing air rotometers with inherent accuracy of +/- 0.5 liters. Air samples analyzed by Phase Contrast Microscopy follow NIOSH 7400 Method, Issue 2, dated August 15, 1994. The analytical results relate only to the samples submitted for testing, in the condition received by the laboratory. This report shall not be reproduced except in full, without the written approval of the laboratory.

CV: High to low 0.213 to 0.079

SUBMITTED BY: _____

APPROVED BY: Charles M. Blake DATE: 11/21/14

Charles M. Blake, Laboratory Manager

LABORATORY ANALYSIS REPORT

1221 E. Henrietta Rd.
Rochester, NY 14623
Telephone (585) 424-2310
Fax (585) 424-1733
☎ 1-800-952-5952 ☎

Client: ICM Properties, LLC**Date Rec'd:** 11/22/14**Address:** 550 Bernard Street, Rochester, New York 14621**JOB Location:** 10 CHAPIN ST, CANANDAIGUA, NY – SE AREA I.D.#1**TES Job #:** 14A-017**Client Job #:****Analytical Method:** PCM- NIOSH 7400 **ELAP:** 10890**Make & Model Olympus BH2:** 225048

SAMPLE ID	VOLUME liters	RESULTS		LOCATION	SAMPLE TYPE	DATE SAMPLED
		STRUCT/mm ²	FIBERS/cm ³			
1	1000	<8.9	<0.003	AMBIENT	ENV	11/21/14
2	1000	<8.9	<0.003	NAU 1	ENV	11/21/14
3	1000	<8.9	<0.003	NAU 2	ENV	11/21/14
4	1000	<8.9	<0.003	WASTE DECON	ENV	11/21/14
5	1000	<8.9	<0.003	CRITICAL 1	ENV	11/21/14
6	1000	<8.9	<0.003	PERSONAL DECON	ENV	11/21/14
7	1000	<8.9	<0.003	CRITICAL 2	ENV	11/21/14
8			0	FIELD BLANK		11/21/14
9			0	FIELD BLANK		11/21/14

BCK = Background •PRE = Preabatement•ENV = Environmental•FNL=Final•PER = Personal•EXC = Excursion•(<) Below detectable level

TES air samples are collected as described by NYSDOL Code Rule 56 utilizing air rotometers with inherent accuracy of +/- 0.5 liters. Air samples analyzed by Phase Contrast Microscopy follow NIOSH 7400 Method, Issue 2, dated August 15, 1994. The analytical results relate only to the samples submitted for testing, in the condition received by the laboratory. This report shall not be reproduced except in full, without the written approval of the laboratory.

CV: High to low 0.213 to 0.079

SUBMITTED BY: _____

APPROVED BY: Charles M. Blake DATE: 11/22/14

Charles M. Blake, Laboratory Manager

LABORATORY ANALYSIS REPORT

1221 E. Henrietta Rd.
Rochester, NY 14623
Telephone (585) 424-2310
Fax (585) 424-1733
☎ 1-800-952-5952 ☎

Client: ICM Properties, LLC**Date Rec'd:** 11/25/14**Address:** 550 Bernard Street, Rochester, New York 14621**JOB Location:** 10 CHAPIN ST, CANANDAIGUA, NY – SE AREA**TES Job #:** 14A-017**Client Job #:****Analytical Method:** PCM- NIOSH 7400 **ELAP:** 10890**Make & Model Olympus BH2:** 225048

SAMPLE ID	VOLUME liters	RESULTS		LOCATION	SAMPLE TYPE	DATE SAMPLED
		STRUCT/mm ²	FIBERS/cm ³			
1	1440	<8.9	<0.002	PERSONAL DECON	ENV	11/24/14
2	1440	<8.9	<0.002	WASTE DECON	ENV	11/24/14
3	1440	<8.9	<0.002	ISOLATION BARRIER 1	ENV	11/24/14
4	1440	<8.9	<0.002	ISOLATION BARRIER 2	ENV	11/24/14
5	1440	<8.9	<0.002	NAU 1	ENV	11/24/14
6	1440	<8.9	<0.002	NAU 2	ENV	11/24/14
7	1440	<8.9	<0.002	EAA PARKING REAR	ENV	11/24/14
8			0	FIELD BLANK		11/24/14
9			0	FIELD BLANK		11/24/14

BCK = Background •PRE = Preabatement•ENV = Environmental•FNL=Final•PER = Personal•EXC = Excursion•(<) Below detectable level

TES air samples are collected as described by NYSDOL Code Rule 56 utilizing air rotometers with inherent accuracy of +/- 0.5 liters. Air samples analyzed by Phase Contrast Microscopy follow NIOSH 7400 Method, Issue 2, dated August 15, 1994. The analytical results relate only to the samples submitted for testing, in the condition received by the laboratory. This report shall not be reproduced except in full, without the written approval of the laboratory.

CV: High to low 0.213 to 0.079

SUBMITTED BY: _____

APPROVED BY: Charles M. Blake DATE: 11/25/14

Charles M. Blake, Laboratory Manager

LABORATORY ANALYSIS REPORT

1221 E. Henrietta Rd.
Rochester, NY 14623
Telephone (585) 424-2310
Fax (585) 424-1733
☎ 1-800-952-5952 ☎

Client: ICM Properties, LLC**Date Rec'd:** 11/26/14**Address:** 550 Bernard Street, Rochester, New York 14621**JOB Location:** 10 CHAPIN ST, CANANDAIGUA, NY – SE AREA**TES Job #:** 14A-017**Client Job #:****Analytical Method:** PCM- NIOSH 7400 **ELAP:** 10890**Make & Model Olympus BH2:** 225048

SAMPLE ID	VOLUME liters	RESULTS		LOCATION	SAMPLE TYPE	DATE SAMPLED
		STRUCT/mm ²	FIBERS/cm ³			
1	1320	<8.9	<0.003	PERSONAL DECON	ENV	11/25/14
2	1320	<8.9	<0.003	WASTE DECON	ENV	11/25/14
3	1320	<8.9	<0.003	ISOLATION BARRIER 1	ENV	11/25/14
4	1320	<8.9	<0.003	ISOLATION BARRIER 2	ENV	11/25/14
5	1320	<8.9	<0.003	NAU 1	ENV	11/25/14
6	1320	<8.9	<0.003	NAU 2	ENV	11/25/14
7	1230	<8.9	<0.003	EAA PARKING REAR	ENV	11/25/14
8			0	FIELD BLANK		11/25/14
9			0	FIELD BLANK		11/25/14

BCK = Background •PRE = Preabatement•ENV = Environmental•FNL=Final•PER = Personal•EXC = Excursion•(<) Below detectable level

TES air samples are collected as described by NYSDOL Code Rule 56 utilizing air rotometers with inherent accuracy of +/- 0.5 liters. Air samples analyzed by Phase Contrast Microscopy follow NIOSH 7400 Method, Issue 2, dated August 15, 1994. The analytical results relate only to the samples submitted for testing, in the condition received by the laboratory. This report shall not be reproduced except in full, without the written approval of the laboratory.

CV: High to low 0.213 to 0.079

SUBMITTED BY: _____

APPROVED BY: Charles M. Blake DATE: 11/26/14

Charles M. Blake, Laboratory Manager

LABORATORY ANALYSIS REPORT

1221 E. Henrietta Rd.
Rochester, NY 14623
Telephone (585) 424-2310
Fax (585) 424-1733
☎ 1-800-952-5952 ☎

Client: ICM Properties, LLC**Date Rec'd:** 11/27/14**Address:** 550 Bernard Street, Rochester, New York 14621**JOB Location:** 10 CHAPIN ST, CANANDAIGUA, NY – SE AREA I.D. #1**TES Job #:** 14A-017**Client Job #:****Analytical Method:** PCM- NIOSH 7400 **ELAP:** 10890**Make & Model Olympus BH2:** 225048

SAMPLE ID	VOLUME liters	RESULTS		LOCATION	SAMPLE TYPE	DATE SAMPLED
		STRUCT/mm ²	FIBERS/cm ³			
1	1173	<8.9	<0.003	PERSONAL DECON	ENV	11/26/14
2	1173	<8.9	<0.003	WASTE DECON	ENV	11/26/14
3	1173	<8.9	<0.003	ISOLATION BARRIER 1	ENV	11/26/14
4	1173	<8.9	<0.003	ISOLATION BARRIER 2	ENV	11/26/14
5	1215	<8.9	<0.003	NAU 1	ENV	11/26/14
6	1215	<8.9	<0.003	NAU 2	ENV	11/26/14
7	1116	<8.9	<0.003	EAA PARKING REAR	ENV	11/26/14
8			0	FIELD BLANK		11/26/14
9			0	FIELD BLANK		11/26/14

BCK = Background •PRE = Preabatement•ENV = Environmental•FNL=Final•PER = Personal•EXC = Excursion•(<) Below detectable level

TES air samples are collected as described by NYSDOL Code Rule 56 utilizing air rotometers with inherent accuracy of +/- 0.5 liters. Air samples analyzed by Phase Contrast Microscopy follow NIOSH 7400 Method, Issue 2, dated August 15, 1994. The analytical results relate only to the samples submitted for testing, in the condition received by the laboratory. This report shall not be reproduced except in full, without the written approval of the laboratory.

CV: High to low 0.213 to 0.079

SUBMITTED BY: _____

APPROVED BY: Charles M. Blake DATE: 11/27/14

Charles M. Blake, Laboratory Manager

LABORATORY ANALYSIS REPORT

1221 E. Henrietta Rd.
Rochester, NY 14623
Telephone (585) 424-2310
Fax (585) 424-1733
☎ 1-800-952-5952 ☎

Client: ICM Properties, LLC**Date Rec'd:** 11/29/14**Address:** 550 Bernard Street, Rochester, New York 14621**JOB Location:** 10 CHAPIN ST, CANANDAIGUA, NY – SE AREA #1**TES Job #:** 14A-017**Client Job #:****Analytical Method:** PCM- NIOSH 7400 **ELAP:** 10890**Make & Model Olympus BH2:** 225048

SAMPLE ID	VOLUME liters	RESULTS		LOCATION	SAMPLE TYPE	DATE SAMPLED
		STRUCT/mm ²	FIBERS/cm ³			
1	1110	<8.9	<0.003	PERSONAL DECON	ENV	11/28/14
2	1110	<8.9	<0.003	WASTE DECON	ENV	11/28/14
3	1110	<8.9	<0.003	ISOLATION BARRIER 1	ENV	11/28/14
4	1110	<8.9	<0.003	ISOLATION BARRIER 2	ENV	11/28/14
5	1110	<8.9	<0.003	NAU 1	ENV	11/28/14
6	1110	<8.9	<0.003	NAU 2	ENV	11/28/14
7	1008	<8.9	<0.003	EAA PARKING REAR	ENV	11/28/14
8			0	FIELD BLANK		11/28/14
9			0	FIELD BLANK		11/28/14

BCK = Background •PRE = Preabatement•ENV = Environmental•FNL=Final•PER = Personal•EXC = Excursion•(<) Below detectable level

TES air samples are collected as described by NYSDOL Code Rule 56 utilizing air rotometers with inherent accuracy of +/- 0.5 liters. Air samples analyzed by Phase Contrast Microscopy follow NIOSH 7400 Method, Issue 2, dated August 15, 1994. The analytical results relate only to the samples submitted for testing, in the condition received by the laboratory. This report shall not be reproduced except in full, without the written approval of the laboratory.

CV: High to low 0.213 to 0.079

SUBMITTED BY: _____

APPROVED BY: Charles M. Blake DATE: 11/29/14

Charles M. Blake, Laboratory Manager

LABORATORY ANALYSIS REPORT

1221 E. Henrietta Rd.
Rochester, NY 14623
Telephone (585) 424-2310
Fax (585) 424-1733
☎ 1-800-952-5952 ☎

Client: ICM Properties, LLC**Date Rec'd:** 11/29/14**Address:** 550 Bernard Street, Rochester, New York 14621**JOB Location:** 10 CHAPIN ST, CANANDAIGUA, NY – NORTH AREA

PHASE 2

TES Job #: 14A-017**Client Job #:****Analytical Method:** PCM- NIOSH 7400 **ELAP:** 10890**Make & Model Olympus BH2:** 225048

SAMPLE ID	VOLUME liters	RESULTS		LOCATION	SAMPLE TYPE	DATE SAMPLED
		STRUCT/mm ²	FIBERS/cm ³			
10	990	<8.9	<0.003	PERSONAL DECON	PRE	11/28/14
11	662	<8.9	<0.005	WASTE DECON	PRE	11/28/14
12	660	<8.9	<0.005	ISOLATION BARRIER 1	PRE	11/28/14
13	660	<8.9	<0.005	ISOLATION BARRIER 2	PRE	11/28/14
14	660	<8.9	<0.005	EAA LOADING DOCK	PRE	11/28/14
15			0	FIELD BLANK		11/28/14
16			0	FIELD BLANK		11/28/14

BCK = Background •PRE = Preabatement•ENV = Environmental•FNL=Final•PER = Personal•EXC = Excursion•(<) Below detectable level

TES air samples are collected as described by NYSDOL Code Rule 56 utilizing air rotometers with inherent accuracy of +/- 0.5 liters. Air samples analyzed by Phase Contrast Microscopy follow NIOSH 7400 Method, Issue 2, dated August 15, 1994. The analytical results relate only to the samples submitted for testing, in the condition received by the laboratory. This report shall not be reproduced except in full, without the written approval of the laboratory.

CV: High to low 0.213 to 0.079

SUBMITTED BY: _____

APPROVED BY: Charles M. Blake
Charles M. Blake, Laboratory Manager

DATE: 11/29/14

LABORATORY ANALYSIS REPORT

T.E.S. ENVIRONMENTAL CORP.

1221 E. Henrietta Rd.
Rochester, NY 14623
Telephone (585) 424-2310
Fax (585) 424-1733

☎ 1-800-952-5952 ☎

Client: ICM Properties, LLC**Date Rec'd:** 12/1/14**Address:** 550 Bernard Street, Rochester, New York 14621**JOB Location:** 10 CHAPIN ST, CANANDAIGUA, NY – SE AREA

PHASE 1

TES Job #: 14A-017**Client Job #:****Analytical Method:** PCM- NIOSH 7400 **ELAP:** 10890**Make & Model Olympus BH2:** 225048

SAMPLE ID	VOLUME liters	RESULTS		LOCATION	SAMPLE TYPE	DATE SAMPLED
		STRUCT/mm ²	FIBERS/cm ³			
1	1320	<8.9	<0.003	PERSONAL DECON	ENV	12/1/14
2	1320	<8.9	<0.003	WASTE DECON	ENV	12/1/14
3	1320	<8.9	<0.003	ISOLATION BARRIER 1	ENV	12/1/14
4	1320	<8.9	<0.003	ISOLATION BARRIER 2	ENV	12/1/14
5	1320	<8.9	<0.003	NAU 1	ENV	12/1/14
6	1320	<8.9	<0.003	NAU 2	ENV	12/1/14
7	1320	<8.9	<0.003	EAA PARKING REAR	ENV	12/1/14
8			0	FIELD BLANK		12/1/14
9			0	FIELD BLANK		12/1/14

BCK = Background •PRE = Preabatement•ENV = Environmental•FNL=Final•PER = Personal•EXC = Excursion•(<) Below detectable level

TES air samples are collected as described by NYSDOL Code Rule 56 utilizing air rotometers with inherent accuracy of +/- 0.5 liters. Air samples analyzed by Phase Contrast Microscopy follow NIOSH 7400 Method, Issue 2, dated August 15, 1994. The analytical results relate only to the samples submitted for testing, in the condition received by the laboratory. This report shall not be reproduced except in full, without the written approval of the laboratory.

CV: High to low 0.213 to 0.079

SUBMITTED BY: _____

APPROVED BY: Charles M. Blake

DATE: 12/2/14

Charles M. Blake, Laboratory Manager

LABORATORY ANALYSIS REPORT

1221 E. Henrietta Rd.
Rochester, NY 14623
Telephone (585) 424-2310
Fax (585) 424-1733
☎ 1-800-952-5952 ☎

Client: ICM Properties, LLC**Date Rec'd:** 12/2/14**Address:** 550 Bernard Street, Rochester, New York 14621**JOB Location:** 10 CHAPIN ST, CANANDAIGUA, NY – SE AREA

PHASE 1

TES Job #: 14A-017**Client Job #:****Analytical Method:** PCM- NIOSH 7400 **ELAP:** 10890**Make & Model Olympus BH2:** 225048

SAMPLE ID	VOLUME liters	RESULTS		LOCATION	SAMPLE TYPE	DATE SAMPLED
		STRUCT/mm ²	FIBERS/cm ³			
1	1410	<8.9	<0.002	PERSONAL DECON	ENV	12/2/14
2	1410	<8.9	<0.002	WASTE DECON	ENV	12/2/14
3	1410	<8.9	<0.002	ISOLATION BARRIER 1	ENV	12/2/14
4	1410	<8.9	<0.002	ISOLATION BARRIER 2	ENV	12/2/14
5	1410	<8.9	<0.002	NAU 1	ENV	12/2/14
6	1410	<8.9	<0.002	NAU 2	ENV	12/2/14
7	1398	<8.9	<0.002	EAA PARKING REAR	ENV	12/2/14
8			0	FIELD BLANK		12/2/14
9			0	FIELD BLANK		12/2/14

BCK = Background •PRE = Preabatement•ENV = Environmental•FNL=Final•PER = Personal•EXC = Excursion•(<) Below detectable level

TES air samples are collected as described by NYSDOL Code Rule 56 utilizing air rotometers with inherent accuracy of +/- 0.5 liters. Air samples analyzed by Phase Contrast Microscopy follow NIOSH 7400 Method, Issue 2, dated August 15, 1994. The analytical results relate only to the samples submitted for testing, in the condition received by the laboratory. This report shall not be reproduced except in full, without the written approval of the laboratory.

CV: High to low 0.213 to 0.079

SUBMITTED BY: _____

APPROVED BY: Charles M. Blake

DATE: 12/2/14

Charles M. Blake, Laboratory Manager

LABORATORY ANALYSIS REPORT



1221 E. Henrietta Rd.
Rochester, NY 14623
Telephone (585) 424-2310
Fax (585) 424-1733
☎ 1-800-952-5952 ☎

Client: ICM Properties, LLC

Date Rec'd: 12/3/14

Address: 550 Bernard Street, Rochester, New York 14621

JOB Location: 10 CHAPIN ST, CANANDAIGUA, NY – SE AREA

PHASE 1

TES Job #: 14A-017

Client Job #:

Analytical Method: PCM- NIOSH 7400 **ELAP:** 10890

Make & Model Olympus BH2: 225048

SAMPLE ID	VOLUME liters	RESULTS		LOCATION	SAMPLE TYPE	DATE SAMPLED
		STRUCT/mm ²	FIBERS/cm ³			
1	1350	<8.9	<0.003	PERSONAL DECON	ENV	12/3/14
2	1350	<8.9	<0.003	WASTE DECON	ENV	12/3/14
3	1350	<8.9	<0.003	ISOLATION BARRIER 1	ENV	12/3/14
4	1350	<8.9	<0.003	ISOLATION BARRIER 2	ENV	12/3/14
5	1380	<8.9	<0.002	NAU 1	ENV	12/3/14
6	1380	<8.9	<0.002	NAU 2	ENV	12/3/14
7	1440	<8.9	<0.002	EAA PARKING REAR	ENV	12/3/14
8			0	FIELD BLANK		12/3/14
9			0	FIELD BLANK		12/3/14

BCK = Background •PRE = Preabatement•ENV = Environmental•FNL=Final•PER = Personal•EXC = Excursion•(<) Below detectable level

TES air samples are collected as described by NYSDOL Code Rule 56 utilizing air rotometers with inherent accuracy of +/- 0.5 liters. Air samples analyzed by Phase Contrast Microscopy follow NIOSH 7400 Method, Issue 2, dated August 15, 1994. The analytical results relate only to the samples submitted for testing, in the condition received by the laboratory. This report shall not be reproduced except in full, without the written approval of the laboratory.

CV: High to low 0.213 to 0.079

SUBMITTED BY: _____

APPROVED BY: Charles M. Blake

DATE: 12/3/14

Charles M. Blake, Laboratory Manager

LABORATORY ANALYSIS REPORT

1221 E. Henrietta Rd.
Rochester, NY 14623
Telephone (585) 424-2310
Fax (585) 424-1733
☎ 1-800-952-5952 ☎

Client: ICM Properties, LLC**Date Rec'd:** 12/5/14**Address:** 550 Bernard Street, Rochester, New York 14621**JOB Location:** 10 CHAPIN ST, CANANDAIGUA, NY – N AREA

PHASE 2

TES Job #: 14A-017**Client Job #:****Analytical Method:** PCM- NIOSH 7400 **ELAP:** 10890**Make & Model Olympus BH2:** 225048

SAMPLE ID	VOLUME liters	RESULTS		LOCATION	SAMPLE TYPE	DATE SAMPLED
		STRUCT/mm ²	FIBERS/cm ³			
1	1326	<8.9	<0.003	PERSONAL DECON	PRE	12/4/14
2	1332	<8.9	<0.003	WASTE DECON	PRE	12/4/14
3	1347	<8.9	<0.003	ISOLATION BARRIER 1	PRE	12/4/14
4	1323	<8.9	<0.003	ISOLATION BARRIER 2	PRE	12/4/14
5	1323	<8.9	<0.003	NAU 1	PRE	12/4/14
6	1323	<8.9	<0.003	NAU 2	PRE	12/4/14
7	1290	<8.9	<0.003	EAA PARKING REAR	PRE	12/4/14
8			0	FIELD BLANK		12/4/14
9			0	FIELD BLANK		12/4/14

BCK = Background •PRE = Preabatement•ENV = Environmental•FNL=Final•PER = Personal•EXC = Excursion•(<) Below detectable level

TES air samples are collected as described by NYSDOL Code Rule 56 utilizing air rotometers with inherent accuracy of +/- 0.5 liters. Air samples analyzed by Phase Contrast Microscopy follow NIOSH 7400 Method, Issue 2, dated August 15, 1994. The analytical results relate only to the samples submitted for testing, in the condition received by the laboratory. This report shall not be reproduced except in full, without the written approval of the laboratory.

CV: High to low 0.213 to 0.079

SUBMITTED BY: _____

APPROVED BY: Charles M. Blake

DATE: 12/5/14

Charles M. Blake, Laboratory Manager

LABORATORY ANALYSIS REPORT



1221 E. Henrietta Rd.
Rochester, NY 14623
Telephone (585) 424-2310
Fax (585) 424-1733
☎ 1-800-952-5952 ☎

Client: ICM Properties, LLC

Date Rec'd: 12/6/14

Address: 550 Bernard Street, Rochester, New York 14621

JOB Location: 10 CHAPIN ST, CANANDAIGUA, NY – SE AREA

PHASE 1

TES Job #: 14A-017

Client Job #:

Analytical Method: PCM- NIOSH 7400 **ELAP:** 10890

Make & Model Olympus BH2: 225048

SAMPLE ID	VOLUME liters	RESULTS		LOCATION	SAMPLE TYPE	DATE SAMPLED
		STRUCT/mm ²	FIBERS/cm ³			
1	1260	<8.9	<0.003	PERSONAL DECON	ENV	12/5/14
2	1260	<8.9	<0.003	WASTE DECON	ENV	12/5/14
3	1260	<8.9	<0.003	ISOLATION BARRIER 1	ENV	12/5/14
4	1260	<8.9	<0.003	ISOLATION BARRIER 2	ENV	12/5/14
5	1260	<8.9	<0.003	NAU 1	ENV	12/5/14
6	1260	<8.9	<0.003	NAU 2	ENV	12/5/14
7	1260	<8.9	<0.003	EAA PARKING REAR	ENV	12/5/14
8			0	FIELD BLANK		12/5/14
9			0	FIELD BLANK		12/5/14

BCK = Background •PRE = Preabatement•ENV = Environmental•FNL=Final•PER = Personal•EXC = Excursion•(<) Below detectable level

TES air samples are collected as described by NYSDOL Code Rule 56 utilizing air rotometers with inherent accuracy of +/- 0.5 liters. Air samples analyzed by Phase Contrast Microscopy follow NIOSH 7400 Method, Issue 2, dated August 15, 1994. The analytical results relate only to the samples submitted for testing, in the condition received by the laboratory. This report shall not be reproduced except in full, without the written approval of the laboratory.

CV: High to low 0.213 to 0.079

SUBMITTED BY: _____

APPROVED BY: Charles M. Blake

DATE: 12/6/14

Charles M. Blake, Laboratory Manager

LABORATORY ANALYSIS REPORT

1221 E. Henrietta Rd.
Rochester, NY 14623
Telephone (585) 424-2310
Fax (585) 424-1733
☎ 1-800-952-5952 ☎

Client: ICM Properties, LLC**Date Rec'd:** 12/6/14**Address:** 550 Bernard Street, Rochester, New York 14621**JOB Location:** 10 CHAPIN ST, CANANDAIGUA, NY – NORTH AREA

PHASE 2

TES Job #: 14A-017**Client Job #:****Analytical Method:** PCM- NIOSH 7400 **ELAP:** 10890**Make & Model Olympus BH2:** 225048

SAMPLE ID	VOLUME liters	RESULTS		LOCATION	SAMPLE TYPE	DATE SAMPLED
		STRUCT/mm ²	FIBERS/cm ³			
10	1350	<8.9	<0.003	PERSONAL DECON	PRE	12/5/14
11	1350	<8.9	<0.003	WASTE DECON	PRE	12/5/14
12	1350	<8.9	<0.003	ISOLATION BARRIER 1	PRE	12/5/14
13	1350	<8.9	<0.003	ISOLATION BARRIER 2	PRE	12/5/14
14	1350	<8.9	<0.003	EAA PARKING LOT	PRE	12/5/14
15			0	FIELD BLANK		12/5/14
16			0	FIELD BLANK		12/5/14

BCK = Background •PRE = Preabatement•ENV = Environmental•FNL=Final•PER = Personal•EXC = Excursion•(<) Below detectable level

TES air samples are collected as described by NYSDOL Code Rule 56 utilizing air rotometers with inherent accuracy of +/- 0.5 liters. Air samples analyzed by Phase Contrast Microscopy follow NIOSH 7400 Method, Issue 2, dated August 15, 1994. The analytical results relate only to the samples submitted for testing, in the condition received by the laboratory. This report shall not be reproduced except in full, without the written approval of the laboratory.

CV: High to low 0.213 to 0.079

SUBMITTED BY: _____

APPROVED BY: Charles M. BlakeDATE: 12/5/14

Charles M. Blake, Laboratory Manager

LABORATORY ANALYSIS REPORT

T.E.S. ENVIRONMENTAL CORP.

1221 E. Henrietta Rd.
Rochester, NY 14623
Telephone (585) 424-2310
Fax (585) 424-1733

☎ 1-800-952-5952 ☎

Client: ICM Properties, LLC**Date Rec'd:** 12/10/14**Address:** 550 Bernard Street, Rochester, New York 14621**JOB Location:** 10 CHAPIN ST, CANANDAIGUA, NY – SE AREA

PHASE 1

TES Job #: 14A-017**Client Job #:****Analytical Method:** PCM- NIOSH 7400 **ELAP:** 10890**Make & Model Olympus BH2:** 225048

SAMPLE ID	VOLUME liters	RESULTS		LOCATION	SAMPLE TYPE	DATE SAMPLED
		STRUCT/mm ²	FIBERS/cm ³			
1	1230	<8.9	<0.003	PERSONAL DECON	ENV	12/9/14
2	1230	<8.9	<0.003	WASTE DECON	ENV	12/9/14
3	1230	<8.9	<0.003	ISOLATION BARRIER 1	ENV	12/9/14
4	1230	<8.9	<0.003	ISOLATION BARRIER 2	ENV	12/9/14
5	1200	<8.9	<0.003	NAU 1	ENV	12/9/14
6	1200	<8.9	<0.003	NAU 2	ENV	12/9/14
7	1260	<8.9	<0.003	EAA PARKING REAR	ENV	12/9/14
8			0	FIELD BLANK		12/9/14
9			0	FIELD BLANK		12/9/14

BCK = Background •PRE = Preabatement•ENV = Environmental•FNL=Final•PER = Personal•EXC = Excursion•(<) Below detectable level

TES air samples are collected as described by NYSDOL Code Rule 56 utilizing air rotometers with inherent accuracy of +/- 0.5 liters. Air samples analyzed by Phase Contrast Microscopy follow NIOSH 7400 Method, Issue 2, dated August 15, 1994. The analytical results relate only to the samples submitted for testing, in the condition received by the laboratory. This report shall not be reproduced except in full, without the written approval of the laboratory.

CV: High to low 0.213 to 0.079

SUBMITTED BY: _____

APPROVED BY: Charles M. Blake

DATE: 12/10/14

Charles M. Blake, Laboratory Manager

LABORATORY ANALYSIS REPORT



T.E.S. ENVIRONMENTAL CORP.

1221 E. Henrietta Rd.
Rochester, NY 14623
Telephone (585) 424-2310
Fax (585) 424-1733
☎ 1-800-952-5952 ☎

Client: ICM Properties, LLC

Date Rec'd: 12/11/14

Address: 550 Bernard Street, Rochester, New York 14621

JOB Location: 10 CHAPIN ST, CANANDAIGUA, NY – SE AREA

PHASE 1

TES Job #: 14A-017

Client Job #:

Analytical Method: PCM- NIOSH 7400 **ELAP:** 10890

Make & Model Olympus BH2: 225048

SAMPLE ID	VOLUME liters	RESULTS		LOCATION	SAMPLE TYPE	DATE SAMPLED
		STRUCT/mm ²	FIBERS/cm ³			
1	1230	<8.9	<0.003	PERSONAL DECON	ENV	12/10/14
2	1230	<8.9	<0.003	WASTE DECON	ENV	12/10/14
3	1230	<8.9	<0.003	ISOLATION BARRIER 1	ENV	12/10/14
4	1230	<8.9	<0.003	ISOLATION BARRIER 2	ENV	12/10/14
5	1230	<8.9	<0.003	NAU 1	ENV	12/10/14
6	1230	<8.9	<0.003	NAU 2	ENV	12/10/14
7	1200	<8.9	<0.003	EAA PARKING REAR	ENV	12/10/14
8			0	FIELD BLANK		12/10/14
9			0	FIELD BLANK		12/10/14

BCK = Background •PRE = Preabatement•ENV = Environmental•FNL=Final•PER = Personal•EXC = Excursion•(<) Below detectable level

TES air samples are collected as described by NYSDOL Code Rule 56 utilizing air rotometers with inherent accuracy of +/- 0.5 liters. Air samples analyzed by Phase Contrast Microscopy follow NIOSH 7400 Method, Issue 2, dated August 15, 1994. The analytical results relate only to the samples submitted for testing, in the condition received by the laboratory. This report shall not be reproduced except in full, without the written approval of the laboratory.

CV: High to low 0.213 to 0.079

SUBMITTED BY: _____

APPROVED BY: Charles M. Blake

DATE: 12/11/14

Charles M. Blake, Laboratory Manager

LABORATORY ANALYSIS REPORT

1221 E. Henrietta Rd.
Rochester, NY 14623
Telephone (585) 424-2310
Fax (585) 424-1733
☎ 1-800-952-5952 ☎

Client: ICM Properties, LLC**Date Rec'd:** 12/12/14**Address:** 550 Bernard Street, Rochester, New York 14621**JOB Location:** 10 CHAPIN ST, CANANDAIGUA, NY – SE AREA

PHASE 1

TES Job #: 14A-017**Client Job #:****Analytical Method:** PCM- NIOSH 7400 **ELAP:** 10890**Make & Model Olympus BH2:** 225048

SAMPLE ID	VOLUME liters	RESULTS		LOCATION	SAMPLE TYPE	DATE SAMPLED
		STRUCT/mm ²	FIBERS/cm ³			
1	1140	<8.9	<0.003	PERSONAL DECON	ENV	12/11/14
2	1170	<8.9	<0.003	WASTE DECON	ENV	12/11/14
3	1110	<8.9	<0.003	ISOLATION BARRIER 1	ENV	12/11/14
4	1140	<8.9	<0.003	ISOLATION BARRIER 2	ENV	12/11/14
5	1110	<8.9	<0.003	NAU 1	ENV	12/11/14
6	1110	<8.9	<0.003	NAU 2	ENV	12/11/14
7	1140	<8.9	<0.003	EAA PARKING REAR	ENV	12/11/14
8			0	FIELD BLANK		12/11/14
9			0	FIELD BLANK		12/11/14

BCK = Background •PRE = Preabatement•ENV = Environmental•FNL=Final•PER = Personal•EXC = Excursion•(<) Below detectable level

TES air samples are collected as described by NYSDOL Code Rule 56 utilizing air rotometers with inherent accuracy of +/- 0.5 liters. Air samples analyzed by Phase Contrast Microscopy follow NIOSH 7400 Method, Issue 2, dated August 15, 1994. The analytical results relate only to the samples submitted for testing, in the condition received by the laboratory. This report shall not be reproduced except in full, without the written approval of the laboratory.

CV: High to low 0.213 to 0.079

SUBMITTED BY: _____

APPROVED BY: Charles M. Blake

DATE: 12/12/14

Charles M. Blake, Laboratory Manager

LABORATORY ANALYSIS REPORT

T.E.S. ENVIRONMENTAL CORP.

1221 E. Henrietta Rd.
Rochester, NY 14623
Telephone (585) 424-2310
Fax (585) 424-1733

☎ 1-800-952-5952 ☎

Client: ICM Properties, LLC**Date Rec'd:** 12/13/14**Address:** 550 Bernard Street, Rochester, New York 14621**JOB Location:** 10 CHAPIN ST, CANANDAIGUA, NY – SE AREA

PHASE 1

TES Job #: 14A-017**Client Job #:****Analytical Method:** PCM- NIOSH 7400 **ELAP:** 10890**Make & Model Olympus BH2:** 225048

SAMPLE ID	VOLUME liters	RESULTS		LOCATION	SAMPLE TYPE	DATE SAMPLED
		STRUCT/mm ²	FIBERS/cm ³			
1	1075	<8.9	<0.003	AMBIENT AIR	ENV	12/12/14
2	1075	<8.9	<0.003	CRITICAL 1	ENV	12/12/14
3	1075	<8.9	<0.003	DECON	ENV	12/12/14
4	1075	<8.9	<0.003	CRITICAL 2	ENV	12/12/14
5	1075	<8.9	<0.003	WASTE DECON	ENV	12/12/14
6	1075	<8.9	<0.003	NAU LEFT	ENV	12/12/14
7	1075	<8.9	<0.003	NAU RIGHT	ENV	12/12/14
8			0	FIELD BLANK		12/12/14
9			0	FIELD BLANK		12/12/14

BCK = Background •PRE = Preabatement•ENV = Environmental•FNL=Final•PER = Personal•EXC = Excursion•(<) Below detectable level

TES air samples are collected as described by NYSDOL Code Rule 56 utilizing air rotometers with inherent accuracy of +/- 0.5 liters. Air samples analyzed by Phase Contrast Microscopy follow NIOSH 7400 Method, Issue 2, dated August 15, 1994. The analytical results relate only to the samples submitted for testing, in the condition received by the laboratory. This report shall not be reproduced except in full, without the written approval of the laboratory.

CV: High to low 0.213 to 0.079

SUBMITTED BY: _____

APPROVED BY: Charles M. Blake

DATE: 12/13/14

Charles M. Blake, Laboratory Manager

LABORATORY ANALYSIS REPORT

T.E.S. ENVIRONMENTAL CORP.

1221 E. Henrietta Rd.
Rochester, NY 14623
Telephone (585) 424-2310
Fax (585) 424-1733

☎ 1-800-952-5952 ☎

Client: ICM Properties, LLC**Date Rec'd:** 12/16/14**Address:** 550 Bernard Street, Rochester, New York 14621**JOB Location:** 10 CHAPIN ST, CANANDAIGUA, NY – SE AREA

PHASE 1

TES Job #: 14A-017**Client Job #:****Analytical Method:** PCM- NIOSH 7400 **ELAP:** 10890**Make & Model Olympus BH2:** 225048

SAMPLE ID	VOLUME liters	RESULTS		LOCATION	SAMPLE TYPE	DATE SAMPLED
		STRUCT/mm ²	FIBERS/cm ³			
1	1030	<8.9	<0.003	PERSONAL DECON	ENV	12/15/14
2	1090	<8.9	<0.003	WASTE DECON	ENV	12/15/14
3	1030	<8.9	<0.003	ISOLATION BARRIER 1	ENV	12/15/14
4	1070	<8.9	<0.003	ISOLATION BARRIER 2	ENV	12/15/14
5	1200	<8.9	<0.003	NAU 1	ENV	12/15/14
6	1200	<8.9	<0.003	NAU 2	ENV	12/15/14
7	1200	<8.9	<0.003	EAA PARKING REAR	ENV	12/15/14
8			0	FIELD BLANK		12/15/14
9			0	FIELD BLANK		12/15/14

BCK = Background •PRE = Preabatement•ENV = Environmental•FNL=Final•PER = Personal•EXC = Excursion•(<) Below detectable level

TES air samples are collected as described by NYSDOL Code Rule 56 utilizing air rotometers with inherent accuracy of +/- 0.5 liters. Air samples analyzed by Phase Contrast Microscopy follow NIOSH 7400 Method, Issue 2, dated August 15, 1994. The analytical results relate only to the samples submitted for testing, in the condition received by the laboratory. This report shall not be reproduced except in full, without the written approval of the laboratory.

CV: High to low 0.213 to 0.079

SUBMITTED BY: _____

APPROVED BY: Charles M. Blake

DATE: 12/16/14

Charles M. Blake, Laboratory Manager

LABORATORY ANALYSIS REPORT



1221 E. Henrietta Rd.
Rochester, NY 14623
Telephone (585) 424-2310
Fax (585) 424-1733
☎ 1-800-952-5952 ☎

Client: ICM Properties, LLC

Date Rec'd: 12/17/14

Address: 550 Bernard Street, Rochester, New York 14621

JOB Location: 10 CHAPIN ST, CANANDAIGUA, NY – N AREA

PHASE 2

TES Job #: 14A-017

Client Job #:

Analytical Method: PCM- NIOSH 7400 **ELAP:** 10890

Make & Model Olympus BH2: 225048

SAMPLE ID	VOLUME liters	RESULTS		LOCATION	SAMPLE TYPE	DATE SAMPLED
		STRUCT/mm ²	FIBERS/cm ³			
1	1140	<8.9	<0.003	PERSONAL DECON	PRE	12/16/14
2	1140	<8.9	<0.003	WASTE DECON	PRE	12/16/14
3	1140	<8.9	<0.003	ISOLATION BARRIER 1	PRE	12/16/14
4	1140	<8.9	<0.003	ISOLATION BARRIER 2	PRE	12/16/14
5	1140	10.8	0.004	NAU 1	PRE	12/16/14
6	1140	<8.9	<0.003	NAU 2	PRE	12/16/14
7	1140	<8.9	<0.003	EAA PARKING REAR	PRE	12/16/14
8			0	FIELD BLANK		12/16/14
9			0	FIELD BLANK		12/16/14

BCK = Background •PRE = Preabatement•ENV = Environmental•FNL=Final•PER = Personal•EXC = Excursion•(<) Below detectable level

TES air samples are collected as described by NYSDOL Code Rule 56 utilizing air rotometers with inherent accuracy of +/- 0.5 liters. Air samples analyzed by Phase Contrast Microscopy follow NIOSH 7400 Method, Issue 2, dated August 15, 1994. The analytical results relate only to the samples submitted for testing, in the condition received by the laboratory. This report shall not be reproduced except in full, without the written approval of the laboratory.

CV: High to low 0.213 to 0.079

SUBMITTED BY: _____

APPROVED BY: Charles M. Blake

DATE: 12/17/14

Charles M. Blake, Laboratory Manager

LABORATORY ANALYSIS REPORT



T.E.S. ENVIRONMENTAL CORP.

1221 E. Henrietta Rd.
Rochester, NY 14623
Telephone (585) 424-2310
Fax (585) 424-1733

☎ 1-800-952-5952 ☎

Client: ICM Properties, LLC

Date Rec'd: 12/18/14

Address: 550 Bernard Street, Rochester, New York 14621

JOB Location: 10 CHAPIN ST, CANANDAIGUA, NY – N AREA

PHASE 2 WORK AREA

TES Job #: 14A-017

Client Job #:

Analytical Method: PCM- NIOSH 7400 **ELAP:** 10890

Make & Model Olympus BH2: 225048

SAMPLE ID	VOLUME liters	RESULTS		LOCATION	SAMPLE TYPE	DATE SAMPLED
		STRUCT/mm ²	FIBERS/cm ³			
1	1164	<8.9	<0.003	DECON	ENV	12/17/14
2	1164	<8.9	<0.003	WASTE DECON	ENV	12/17/14
3	1164	<8.9	<0.003	CRITICAL 1	ENV	12/17/14
4	1164	<8.9	<0.003	CRITICAL 2	ENV	12/17/14
5	1164	<8.9	<0.003	NAU 1	ENV	12/17/14
6	1164	<8.9	<0.003	NAU 2	ENV	12/17/14
7	1164	<8.9	<0.003	AMBIENT AIR	ENV	12/17/14
8			0	FIELD BLANK		12/17/14
9			0	FIELD BLANK		12/17/14

BCK = Background •PRE = Preabatement•ENV = Environmental•FNL=Final•PER = Personal•EXC = Excursion•(<) Below detectable level

TES air samples are collected as described by NYSDOL Code Rule 56 utilizing air rotometers with inherent accuracy of +/- 0.5 liters. Air samples analyzed by Phase Contrast Microscopy follow NIOSH 7400 Method, Issue 2, dated August 15, 1994. The analytical results relate only to the samples submitted for testing, in the condition received by the laboratory. This report shall not be reproduced except in full, without the written approval of the laboratory.

CV: High to low 0.213 to 0.079

SUBMITTED BY: _____

APPROVED BY: Charles M. Blake

DATE: 12/18/14

Charles M. Blake, Laboratory Manager

LABORATORY ANALYSIS REPORT

1221 E. Henrietta Rd.
Rochester, NY 14623
Telephone (585) 424-2310
Fax (585) 424-1733
☎ 1-800-952-5952 ☎

Client: ICM Properties, LLC**Date Rec'd:** 12/19/14**Address:** 550 Bernard Street, Rochester, New York 14621**JOB Location:** 10 CHAPIN ST, CANANDAIGUA, NY – N AREA

PHASE 2 WORK AREA

TES Job #: 14A-017**Client Job #:****Analytical Method:** PCM- NIOSH 7400 **ELAP:** 10890**Make & Model Olympus BH2:** 225048

SAMPLE ID	VOLUME liters	RESULTS		LOCATION	SAMPLE TYPE	DATE SAMPLED
		STRUCT/mm ²	FIBERS/cm ³			
1	1263	<8.9	<0.003	DECON	ENV	12/18/14
2	1263	<8.9	<0.003	WASTE DECON	ENV	12/18/14
3	1263	<8.9	<0.003	CRITICAL 1	ENV	12/18/14
4	1263	<8.9	<0.003	CRITICAL 2	ENV	12/18/14
5	1263	<8.9	<0.003	NAU 1	ENV	12/18/14
6	1263	<8.9	<0.003	NAU 2	ENV	12/18/14
7	1263	<8.9	<0.003	AMBIENT AIR	ENV	12/18/14
8			0	FIELD BLANK		12/18/14
9			0	FIELD BLANK		12/18/14

BCK = Background •PRE = Preabatement•ENV = Environmental•FNL=Final•PER = Personal•EXC = Excursion•(<) Below detectable level

TES air samples are collected as described by NYSDOL Code Rule 56 utilizing air rotometers with inherent accuracy of +/- 0.5 liters. Air samples analyzed by Phase Contrast Microscopy follow NIOSH 7400 Method, Issue 2, dated August 15, 1994. The analytical results relate only to the samples submitted for testing, in the condition received by the laboratory. This report shall not be reproduced except in full, without the written approval of the laboratory.

CV: High to low 0.213 to 0.079

SUBMITTED BY: _____

APPROVED BY: Charles M. Blake

DATE: 12/19/14

Charles M. Blake, Laboratory Manager

LABORATORY ANALYSIS REPORT

T.E.S. ENVIRONMENTAL CORP.

1221 E. Henrietta Rd.
Rochester, NY 14623
Telephone (585) 424-2310
Fax (585) 424-1733

☎ 1-800-952-5952 ☎

Client: ICM Properties, LLC**Date Rec'd:** 12/20/14**Address:** 550 Bernard Street, Rochester, New York 14621**JOB Location:** 10 CHAPIN ST, CANANDAIGUA, NY – N AREA

PHASE 2 WORK AREA

TES Job #: 14A-017**Client Job #:****Analytical Method:** PCM- NIOSH 7400 **ELAP:** 10890**Make & Model Olympus BH2:** 225048

SAMPLE ID	VOLUME liters	RESULTS		LOCATION	SAMPLE TYPE	DATE SAMPLED
		STRUCT/mm ²	FIBERS/cm ³			
1	1010	<8.9	<0.003	DECON	ENV	12/19/14
2	1010	<8.9	<0.003	WASTE DECON	ENV	12/19/14
3	1010	<8.9	<0.003	CRITICAL 1	ENV	12/19/14
4	1010	<8.9	<0.003	CRITICAL 2	ENV	12/19/14
5	1010	<8.9	<0.003	NAU 1	ENV	12/19/14
6	1010	<8.9	<0.003	NAU 2	ENV	12/19/14
7	1010	<8.9	<0.003	AMBIENT AIR	ENV	12/19/14
8			0	FIELD BLANK		12/19/14
9			0	FIELD BLANK		12/19/14

BCK = Background •PRE = Preabatement•ENV = Environmental•FNL=Final•PER = Personal•EXC = Excursion•(<) Below detectable level

TES air samples are collected as described by NYSDOL Code Rule 56 utilizing air rotometers with inherent accuracy of +/- 0.5 liters. Air samples analyzed by Phase Contrast Microscopy follow NIOSH 7400 Method, Issue 2, dated August 15, 1994. The analytical results relate only to the samples submitted for testing, in the condition received by the laboratory. This report shall not be reproduced except in full, without the written approval of the laboratory.

CV: High to low 0.213 to 0.079

SUBMITTED BY: _____

APPROVED BY: Charles M. Blake

DATE: 12/20/14

Charles M. Blake, Laboratory Manager

LABORATORY ANALYSIS REPORT

1221 E. Henrietta Rd.
Rochester, NY 14623
Telephone (585) 424-2310
Fax (585) 424-1733
☎ 1-800-952-5952 ☎

Client: ICM Properties, LLC**Date Rec'd:** 12/23/14**Address:** 550 Bernard Street, Rochester, New York 14621**JOB Location:** 10 CHAPIN ST, CANANDAIGUA, NY – N AREA

PHASE 2 WORK AREA

TES Job #: 14A-017**Client Job #:****Analytical Method:** PCM- NIOSH 7400 **ELAP:** 10890**Make & Model Olympus BH2:** 225048

SAMPLE ID	VOLUME liters	RESULTS		LOCATION	SAMPLE TYPE	DATE SAMPLED
		STRUCT/mm ²	FIBERS/cm ³			
1	1206	<8.9	<0.003	DECON	ENV	12/22/14
2	1206	<8.9	<0.003	WASTE DECON	ENV	12/22/14
3	1206	<8.9	<0.003	CRITICAL 1	ENV	12/22/14
4	1206	<8.9	<0.003	CRITICAL 2	ENV	12/22/14
5	1206	<8.9	<0.003	NAU 1	ENV	12/22/14
6	1206	<8.9	<0.003	NAU 2	ENV	12/22/14
7	1206	<8.9	<0.003	AMBIENT AIR	ENV	12/22/14
8			0	FIELD BLANK		12/22/14
9			0	FIELD BLANK		12/22/14

BCK = Background •PRE = Preabatement•ENV = Environmental•FNL=Final•PER = Personal•EXC = Excursion•(<) Below detectable level

TES air samples are collected as described by NYSDOL Code Rule 56 utilizing air rotometers with inherent accuracy of +/- 0.5 liters. Air samples analyzed by Phase Contrast Microscopy follow NIOSH 7400 Method, Issue 2, dated August 15, 1994. The analytical results relate only to the samples submitted for testing, in the condition received by the laboratory. This report shall not be reproduced except in full, without the written approval of the laboratory.

CV: High to low 0.213 to 0.079

SUBMITTED BY: _____

APPROVED BY: Charles M. Blake

DATE: 12/23/14

Charles M. Blake, Laboratory Manager

LABORATORY ANALYSIS REPORT



T.E.S. ENVIRONMENTAL CORP.

1221 E. Henrietta Rd.
Rochester, NY 14623
Telephone (585) 424-2310
Fax (585) 424-1733
☎ 1-800-952-5952 ☎

Client: ICM Properties, LLC

Date Rec'd: 12/24/14

Address: 550 Bernard Street, Rochester, New York 14621

JOB Location: 10 CHAPIN ST, CANANDAIGUA, NY – N AREA

PHASE 2 WORK AREA

TES Job #: 14A-017

Client Job #:

Analytical Method: PCM- NIOSH 7400 **ELAP:** 10890

Make & Model Olympus BH2: 225048

SAMPLE ID	VOLUME liters	RESULTS		LOCATION	SAMPLE TYPE	DATE SAMPLED
		STRUCT/mm ²	FIBERS/cm ³			
1	1173	<8.9	<0.003	DECON	ENV	12/23/14
2	1173	<8.9	<0.003	WASTE DECON	ENV	12/23/14
3	1173	<8.9	<0.003	CRITICAL 1	ENV	12/23/14
4	1173	<8.9	<0.003	CRITICAL 2	ENV	12/23/14
5	1173	<8.9	<0.003	NAU 1	ENV	12/23/14
6	1173	<8.9	<0.003	NAU 2	ENV	12/23/14
7	1173	<8.9	<0.003	AMBIENT AIR	ENV	12/23/14
8			0	FIELD BLANK		12/23/14
9			0	FIELD BLANK		12/23/14

BCK = Background •PRE = Preabatement•ENV = Environmental•FNL=Final•PER = Personal•EXC = Excursion•(<) Below detectable level

TES air samples are collected as described by NYSDOL Code Rule 56 utilizing air rotometers with inherent accuracy of +/- 0.5 liters. Air samples analyzed by Phase Contrast Microscopy follow NIOSH 7400 Method, Issue 2, dated August 15, 1994. The analytical results relate only to the samples submitted for testing, in the condition received by the laboratory. This report shall not be reproduced except in full, without the written approval of the laboratory.

CV: High to low 0.213 to 0.079

SUBMITTED BY: _____

APPROVED BY: Charles M. Blake

DATE: 12/24/14

Charles M. Blake, Laboratory Manager

LABORATORY ANALYSIS REPORT

T.E.S. ENVIRONMENTAL CORP.

1221 E. Henrietta Rd.
Rochester, NY 14623
Telephone (585) 424-2310
Fax (585) 424-1733

☎ 1-800-952-5952 ☎

Client: ICM Properties, LLC**Date Rec'd:** 12/24/14**Address:** 550 Bernard Street, Rochester, New York 14621**JOB Location:** 10 CHAPIN ST, CANANDAIGUA, NY – N AREA

PHASE 2 WORK AREA

TES Job #: 14A-017**Client Job #:****Analytical Method:** PCM- NIOSH 7400 **ELAP:** 10890**Make & Model Olympus BH2:** 225048

SAMPLE ID	VOLUME liters	RESULTS		LOCATION	SAMPLE TYPE	DATE SAMPLED
		STRUCT/mm ²	FIBERS/cm ³			
1	992	<8.9	<0.003	DECON	ENV	12/24/14
2	992	<8.9	<0.003	WASTE DECON	ENV	12/24/14
3	992	<8.9	<0.003	CRITICAL 1	ENV	12/24/14
4	992	<8.9	<0.003	CRITICAL 2	ENV	12/24/14
5	992	<8.9	<0.003	NAU 1	ENV	12/24/14
6	992	<8.9	<0.003	NAU 2	ENV	12/24/14
7	992	<8.9	<0.003	AMBIENT AIR	ENV	12/24/14
8			0	FIELD BLANK		12/24/14
9			0	FIELD BLANK		12/24/14

BCK = Background •PRE = Preabatement•ENV = Environmental•FNL=Final•PER = Personal•EXC = Excursion•(<) Below detectable level

TES air samples are collected as described by NYSDOL Code Rule 56 utilizing air rotometers with inherent accuracy of +/- 0.5 liters. Air samples analyzed by Phase Contrast Microscopy follow NIOSH 7400 Method, Issue 2, dated August 15, 1994. The analytical results relate only to the samples submitted for testing, in the condition received by the laboratory. This report shall not be reproduced except in full, without the written approval of the laboratory.

CV: High to low 0.213 to 0.079

SUBMITTED BY: _____

APPROVED BY: Charles M. Blake

DATE: 12/26/14

Charles M. Blake, Laboratory Manager

LABORATORY ANALYSIS REPORT



T.E.S. ENVIRONMENTAL CORP.

1221 E. Henrietta Rd.
Rochester, NY 14623
Telephone (585) 424-2310
Fax (585) 424-1733

☎ 1-800-952-5952 ☎

Client: ICM Properties, LLC

Date Rec'd: 12/27/14

Address: 550 Bernard Street, Rochester, New York 14621

JOB Location: 10 CHAPIN ST, CANANDAIGUA, NY – N AREA

PHASE 2 WORK AREA

TES Job #: 14A-017

Client Job #:

Analytical Method: PCM- NIOSH 7400 **ELAP:** 10890

Make & Model Olympus BH2: 225048

SAMPLE ID	VOLUME liters	RESULTS		LOCATION	SAMPLE TYPE	DATE SAMPLED
		STRUCT/mm ²	FIBERS/cm ³			
1	1200	<8.9	<0.003	DECON	ENV	12/26/14
2	1200	<8.9	<0.003	WASTE DECON	ENV	12/26/14
3	1200	<8.9	<0.003	CRITICAL 1	ENV	12/26/14
4	1200	<8.9	<0.003	CRITICAL 2	ENV	12/26/14
5	1200	<8.9	<0.003	NAU 1	ENV	12/26/14
6	1200	<8.9	<0.003	NAU 2	ENV	12/26/14
7	1200	<8.9	<0.003	AMBIENT AIR	ENV	12/26/14
8			0	FIELD BLANK		12/26/14
9			0	FIELD BLANK		12/26/14

BCK = Background •PRE = Preabatement•ENV = Environmental•FNL=Final•PER = Personal•EXC = Excursion•(<) Below detectable level

TES air samples are collected as described by NYSDOL Code Rule 56 utilizing air rotometers with inherent accuracy of +/- 0.5 liters. Air samples analyzed by Phase Contrast Microscopy follow NIOSH 7400 Method, Issue 2, dated August 15, 1994. The analytical results relate only to the samples submitted for testing, in the condition received by the laboratory. This report shall not be reproduced except in full, without the written approval of the laboratory.

CV: High to low 0.213 to 0.079

SUBMITTED BY: _____

APPROVED BY: Charles M. Blake

DATE: 12/27/14

Charles M. Blake, Laboratory Manager

LABORATORY ANALYSIS REPORT



T.E.S. ENVIRONMENTAL CORP.

1221 E. Henrietta Rd.
Rochester, NY 14623
Telephone (585) 424-2310
Fax (585) 424-1733
☎ 1-800-952-5952 ☎

Client: ICM Properties, LLC

Date Rec'd: 12/30/14

Address: 550 Bernard Street, Rochester, New York 14621

JOB Location: 10 CHAPIN ST, CANANDAIGUA, NY – N AREA

PHASE 2 WORK AREA

TES Job #: 14A-017

Client Job #:

Analytical Method: PCM- NIOSH 7400 **ELAP:** 10890

Make & Model Olympus BH2: 225048

SAMPLE ID	VOLUME liters	RESULTS		LOCATION	SAMPLE TYPE	DATE SAMPLED
		STRUCT/mm ²	FIBERS/cm ³			
1	1440	<8.9	<0.002	PERSONAL DECON	ENV	12/29/14
2	1440	<8.9	<0.002	WASTE DECON	ENV	12/29/14
3	1440	<8.9	<0.002	ISOLATION BARRIER 1	ENV	12/29/14
4	1440	<8.9	<0.002	ISOLATION BARRIER 2	ENV	12/29/14
5	1440	<8.9	<0.002	NAU 1	ENV	12/29/14
6	1440	<8.9	<0.002	NAU 2	ENV	12/29/14
7	1440	<8.9	<0.002	EAA DRIVEWAY	ENV	12/29/14
8			0	FIELD BLANK		12/29/14
9			0	FIELD BLANK		12/29/14

BCK = Background •PRE = Preabatement•ENV = Environmental•FNL=Final•PER = Personal•EXC = Excursion•(<) Below detectable level

TES air samples are collected as described by NYSDOL Code Rule 56 utilizing air rotometers with inherent accuracy of +/- 0.5 liters. Air samples analyzed by Phase Contrast Microscopy follow NIOSH 7400 Method, Issue 2, dated August 15, 1994. The analytical results relate only to the samples submitted for testing, in the condition received by the laboratory. This report shall not be reproduced except in full, without the written approval of the laboratory.

CV: High to low 0.213 to 0.079

SUBMITTED BY: _____

APPROVED BY: Charles M. Blake

DATE: 12/30/14

Charles M. Blake, Laboratory Manager

LABORATORY ANALYSIS REPORT

T.E.S. ENVIRONMENTAL CORP.

1221 E. Henrietta Rd.
Rochester, NY 14623
Telephone (585) 424-2310
Fax (585) 424-1733

☎ 1-800-952-5952 ☎

Client: ICM Properties, LLC**Date Rec'd:** 12/31/14**Address:** 550 Bernard Street, Rochester, New York 14621**JOB Location:** 10 CHAPIN ST, CANANDAIGUA, NY – N AREA

PHASE 2 WORK AREA

TES Job #: 14A-017**Client Job #:****Analytical Method:** PCM- NIOSH 7400 **ELAP:** 10890**Make & Model Olympus BH2:** 225048

SAMPLE ID	VOLUME liters	RESULTS		LOCATION	SAMPLE TYPE	DATE SAMPLED
		STRUCT/mm ²	FIBERS/cm ³			
1	1440	<8.9	<0.002	PERSONAL DECON	ENV	12/30/14
2	1440	<8.9	<0.002	WASTE DECON	ENV	12/30/14
3	1440	<8.9	<0.002	ISOLATION BARRIER 1	ENV	12/30/14
4	1440	<8.9	<0.002	ISOLATION BARRIER 2	ENV	12/30/14
5	1440	<8.9	<0.002	NAU 1	ENV	12/30/14
6	1440	<8.9	<0.002	NAU 2	ENV	12/30/14
7	1440	<8.9	<0.002	EAA DRIVEWAY	ENV	12/30/14
8			0	FIELD BLANK		12/30/14
9			0	FIELD BLANK		12/30/14

BCK = Background •PRE = Preabatement•ENV = Environmental•FNL=Final•PER = Personal•EXC = Excursion•(<) Below detectable level

TES air samples are collected as described by NYSDOL Code Rule 56 utilizing air rotometers with inherent accuracy of +/- 0.5 liters. Air samples analyzed by Phase Contrast Microscopy follow NIOSH 7400 Method, Issue 2, dated August 15, 1994. The analytical results relate only to the samples submitted for testing, in the condition received by the laboratory. This report shall not be reproduced except in full, without the written approval of the laboratory.

CV: High to low 0.213 to 0.079

SUBMITTED BY: _____

APPROVED BY: Charles M. Blake

DATE: 12/31/14

Charles M. Blake, Laboratory Manager

LABORATORY ANALYSIS REPORT



T.E.S. ENVIRONMENTAL CORP.

1221 E. Henrietta Rd.
Rochester, NY 14623
Telephone (585) 424-2310
Fax (585) 424-1733
☎ 1-800-952-5952 ☎

Client: ICM Properties, LLC

Date Rec'd: 12/31/14

Address: 550 Bernard Street, Rochester, New York 14621

JOB Location: 10 CHAPIN ST, CANANDAIGUA, NY – N AREA

PHASE 2 WORK AREA

TES Job #: 14A-017

Client Job #:

Analytical Method: PCM- NIOSH 7400 **ELAP:** 10890

Make & Model Olympus BH2: 225048

SAMPLE ID	VOLUME liters	RESULTS		LOCATION	SAMPLE TYPE	DATE SAMPLED
		STRUCT/mm ²	FIBERS/cm ³			
1	1440	<8.9	<0.002	PERSONAL DECON	ENV	12/31/14
2	1440	<8.9	<0.002	WASTE DECON	ENV	12/31/14
3	1440	<8.9	<0.002	ISOLATION BARRIER 1	ENV	12/31/14
4	1440	<8.9	<0.002	ISOLATION BARRIER 2	ENV	12/31/14
5	1440	<8.9	<0.002	NAU 1	ENV	12/31/14
6	1440	<8.9	<0.002	NAU 2	ENV	12/31/14
7	1440	<8.9	<0.002	EAA DRIVEWAY	ENV	12/31/14
8			0	FIELD BLANK		12/31/14
9			0	FIELD BLANK		12/31/14

BCK = Background •PRE = Preabatement•ENV = Environmental•FNL=Final•PER = Personal•EXC = Excursion•(<) Below detectable level

TES air samples are collected as described by NYSDOL Code Rule 56 utilizing air rotometers with inherent accuracy of +/- 0.5 liters. Air samples analyzed by Phase Contrast Microscopy follow NIOSH 7400 Method, Issue 2, dated August 15, 1994. The analytical results relate only to the samples submitted for testing, in the condition received by the laboratory. This report shall not be reproduced except in full, without the written approval of the laboratory.

CV: High to low 0.213 to 0.079

SUBMITTED BY: _____

APPROVED BY: Charles M. Blake

DATE: 1/5/15

Charles M. Blake, Laboratory Manager

LABORATORY ANALYSIS REPORT

T.E.S. ENVIRONMENTAL CORP.

1221 E. Henrietta Rd.
Rochester, NY 14623
Telephone (585) 424-2310
Fax (585) 424-1733

☎ 1-800-952-5952 ☎

Client: ICM Properties, LLC**Date Rec'd:** 1/6/2015**Address:** 550 Bernard Street, Rochester, New York 14621**JOB Location:** 10 CHAPIN ST, CANANDAIGUA, NY – SE AREA

PHASE 1

TES Job #: 15A-004**Client Job #:****Analytical Method:** PCM- NIOSH 7400 **ELAP:** 10890**Make & Model Olympus BH2:** 225048

SAMPLE ID	VOLUME liters	RESULTS		LOCATION	SAMPLE TYPE	DATE SAMPLED
		STRUCT/mm ²	FIBERS/cm ³			
1	1100	<8.9	<0.003	PERSONAL DECON	ENV	1/5/15
2	1100	<8.9	<0.003	WASTE DECON	ENV	1/5/15
3	1100	<8.9	<0.003	ISOLATION BARRIER 1	ENV	1/5/15
4	1100	<8.9	<0.003	ISOLATION BARRIER 2	ENV	1/5/15
5	1100	<8.9	<0.003	NAU 1	ENV	1/5/15
6	1100	<8.9	<0.003	NAU 2	ENV	1/5/15
7	1100	<8.9	<0.003	EAA PARKING LOT	ENV	1/5/15
8			0	FIELD BLANK		1/5/15
9			0	FIELD BLANK		1/5/15

BCK = Background •PRE = Preabatement•ENV = Environmental•FNL=Final•PER = Personal•EXC = Excursion•(<) Below detectable level

TES air samples are collected as described by NYSDOL Code Rule 56 utilizing air rotometers with inherent accuracy of +/- 0.5 liters. Air samples analyzed by Phase Contrast Microscopy follow NIOSH 7400 Method, Issue 2, dated August 15, 1994. The analytical results relate only to the samples submitted for testing, in the condition received by the laboratory. This report shall not be reproduced except in full, without the written approval of the laboratory.

CV: High to low 0.213 to 0.079

SUBMITTED BY: _____

APPROVED BY: Charles M. Blake

DATE: 1/6/15

Charles M. Blake, Laboratory Manager

LABORATORY ANALYSIS REPORT

T.E.S. ENVIRONMENTAL CORP.

1221 E. Henrietta Rd.
Rochester, NY 14623
Telephone (585) 424-2310
Fax (585) 424-1733

☎ 1-800-952-5952 ☎

Client: ICM Properties, LLC**Date Rec'd:** 1/7/2015**Address:** 550 Bernard Street, Rochester, New York 14621**JOB Location:** 10 CHAPIN ST, CANANDAIGUA, NY – SE AREA

PHASE 1

TES Job #: 15A-004**Client Job #:****Analytical Method:** PCM- NIOSH 7400 **ELAP:** 10890**Make & Model Olympus BH2:** 225048

SAMPLE ID	VOLUME liters	RESULTS		LOCATION	SAMPLE TYPE	DATE SAMPLED
		STRUCT/mm ²	FIBERS/cm ³			
1	1360	<8.9	<0.003	PERSONAL DECON	ENV	1/6/15
2	1360	<8.9	<0.003	WASTE DECON	ENV	1/6/15
3	1360	<8.9	<0.003	ISOLATION BARRIER 1	ENV	1/6/15
4	1360	<8.9	<0.003	ISOLATION BARRIER 2	ENV	1/6/15
5	1360	<8.9	<0.003	NAU 1	ENV	1/6/15
6	1360	<8.9	<0.003	NAU 2	ENV	1/6/15
7	1360	<8.9	<0.003	EAA PARKING LOT	ENV	1/6/15
8			0	FIELD BLANK		1/6/15
9			0	FIELD BLANK		1/6/15

BCK = Background •PRE = Preabatement•ENV = Environmental•FNL=Final•PER = Personal•EXC = Excursion•(<) Below detectable level

TES air samples are collected as described by NYSDOL Code Rule 56 utilizing air rotometers with inherent accuracy of +/- 0.5 liters. Air samples analyzed by Phase Contrast Microscopy follow NIOSH 7400 Method, Issue 2, dated August 15, 1994. The analytical results relate only to the samples submitted for testing, in the condition received by the laboratory. This report shall not be reproduced except in full, without the written approval of the laboratory.

CV: High to low 0.213 to 0.079

SUBMITTED BY: _____

APPROVED BY: Charles M. Blake

DATE: 1/7/15

Charles M. Blake, Laboratory Manager

LABORATORY ANALYSIS REPORT



T.E.S. ENVIRONMENTAL CORP.

1221 E. Henrietta Rd.
Rochester, NY 14623
Telephone (585) 424-2310
Fax (585) 424-1733

☎ 1-800-952-5952 ☎

Client: ICM Properties, LLC

Date Rec'd: 1/7/2015

Address: 550 Bernard Street, Rochester, New York 14621

JOB Location: 10 CHAPIN ST, CANANDAIGUA, NY – SE AREA

PHASE 1

TES Job #: 15A-004

Client Job #:

Analytical Method: PCM- NIOSH 7400 ELAP: 10890

Make & Model Olympus BH2: 225048

SAMPLE ID	VOLUME liters	RESULTS		LOCATION	SAMPLE TYPE	DATE SAMPLED
		STRUCT/mm ²	FIBERS/cm ³			
1	1200	<8.9	<0.003	IWA - SE AREA	FNL	1/7/15
2	1200	<8.9	<0.003	IWA - SW AREA	FNL	1/7/15
3	1200	<8.9	<0.003	IWA CENTER	FNL	1/7/15
4	1200	<8.9	<0.003	IWA - NE AREA	FNL	1/7/15
5	1200	<8.9	<0.003	IWA - NW AREA	FNL	1/7/15
6	1200	<8.9	<0.003	OWA - SW CORNER NAU	FNL	1/7/15
7	1200	<8.9	<0.003	OWA - ADJ TO WASTE DECON	FNL	1/7/15
8	1200	<8.9	<0.003	OWA - ADJ TO PERSONAL DECON	FNL	1/7/15
9	1200	<8.9	<0.003	OWA - ADJ TO LOADING DOCK	FNL	1/7/15
10	1200	<8.9	<0.003	OWA - REAR OF BLDG	FNL	1/7/15
11			0	FIELD BLANK		1/7/15
12			0	FIELD BLANK		1/7/15

BCK = Background •PRE = Preabatement•ENV = Environmental•FNL=Final•PER = Personal•EXC = Excursion•(<) Below detectable level

TES air samples are collected as described by NYS DOL Code Rule 56 utilizing air rotometers with inherent accuracy of +/- 0.5 liters. Air samples analyzed by Phase Contrast Microscopy follow NIOSH 7400 Method, Issue 2, dated August 15, 1994. The analytical results relate only to the samples submitted for testing, in the condition received by the laboratory. This report shall not be reproduced except in full, without the written approval of the laboratory.

CV: High to low 0.213 to 0.079

SUBMITTED BY: _____

APPROVED BY: Charles M. Blake

DATE: 1/7/15

Charles M. Blake, Laboratory Manager

LABORATORY ANALYSIS REPORT



T.E.S. ENVIRONMENTAL CORP.

1221 E. Henrietta Rd.
Rochester, NY 14623
Telephone (585) 424-2310
Fax (585) 424-1733
☎ 1-800-952-5952 ☎

Client: ICM Properties, LLC

Date Rec'd: 1/2/2015

Address: 550 Bernard Street, Rochester, New York 14621

JOB Location: 10 CHAPIN ST, CANANDAIGUA, NY – N AREA

PHASE 2

TES Job #: 15A-004

Client Job #:

Analytical Method: PCM- NIOSH 7400 **ELAP:** 10890

Make & Model Olympus BH2: 225048

SAMPLE ID	VOLUME liters	RESULTS		LOCATION	SAMPLE TYPE	DATE SAMPLED
		STRUCT/mm ²	FIBERS/cm ³			
1	1200	<8.9	<0.003	IWA - AREA 1 ADJ OFFICE	FNL	1/2/15
2	1200	<8.9	<0.003	IWA - AREA 1 ADJ RAMP	FNL	1/2/15
3	1200	<8.9	<0.003	IWA - AREA 2 CENTER	FNL	1/2/15
4	1200	<8.9	<0.003	IWA - AREA 2 BELOW PLATFORM	FNL	1/2/15
5	1200	<8.9	<0.003	IWA - AREA 4 BOTTOM RAMP	FNL	1/2/15
6	1250	<8.9	<0.003	OWA - PERSONAL DECON	FNL	1/2/15
7	1250	<8.9	<0.003	OWA - WATER SUPPLY	FNL	1/2/15
8	1250	<8.9	<0.003	OWA - ADJ TO STORAGE	FNL	1/2/15
9	1250	<8.9	<0.003	OWA - REOR OF BLDG RAMP	FNL	1/2/15
10	1250	<8.9	<0.003	OWA - REAR OF BLDG METAL DOOR	FNL	1/2/15
11			0	FIELD BLANK		1/2/15
12			0	FIELD BLANK		1/2/15

BCK = Background •PRE = Preabatement•ENV = Environmental•FNL=Final•PER = Personal•EXC = Excursion•(<) Below detectable level

TES air samples are collected as described by NYSDOL Code Rule 56 utilizing air rotometers with inherent accuracy of +/- 0.5 liters. Air samples analyzed by Phase Contrast Microscopy follow NIOSH 7400 Method, Issue 2, dated August 15, 1994. The analytical results relate only to the samples submitted for testing, in the condition received by the laboratory. This report shall not be reproduced except in full, without the written approval of the laboratory.

CV: High to low 0.213 to 0.079

SUBMITTED BY: _____

APPROVED BY: Charles M. Blake

DATE: 1/2/15

Charles M. Blake, Laboratory Manager