

**Seneca Market BCP Site  
Watkins Glen, NY**

**Weekly Progress Meeting  
January 8-15, 2007**

---

**Work completed in the previous week:**

- Contractor began excavation for building foundation/footers
- Former building foundation encountered during excavation of North foundation wall. The eastern portion of North foundation wall excavation contained potentially impacted soils at a varying thickness of 1-5'.
- Impacted soils excavated and placed on plastic sheeting.
- Contractor placing non-impacted soils from foundation excavation in stockpile on south side of site.
- Setup Community Air monitoring equipment.

**Work anticipated next week:**

- Continue to excavate south and east for building footer /foundation
- Excavate for footer piers
- Community Air monitoring

**Environmental sampling completed or anticipated:**

- Collected samples from non-impacted soil stockpile
- Scheduled to collect samples from stockpile containing impacted soils

Seneca Market BCP Site  
Watkins Glen, NY

Weekly Progress Meeting  
January 22-26, 2007

---

Work completed in the previous week:

- Contractor continued excavating building foundation/footers (S wall going W) (Monday only).
- Contractor continued pouring concrete foundations and footers.
- Potentially impacted soils and excavated non-impacted overburden from work completed 1/8/07 – 1/12/07 were sampled last week. Results show no exceedances of SSALs.
- Non-impacted soil stockpile from previous grading activities were sampled. Results show no exceedances of SSALs.
- GW treatment system is plumbed with bag filter and two carbon vessels and is ready for GW discharge. Bob Long of DEC was on-site to inspect the GW treatment system during assembly.
- Community air monitoring during intrusive activities.

Work anticipated next week:

- Continue to excavate south building footer/foundation wall and pouring foundations.
- Excavate/pour footer piers.
- GW discharge.
- Additional sampling of excavated soil as warranted.
- Community Air monitoring during intrusive activities.

Other:

- Previous weekly construction reports, recent sampling results of on-site soil and ASD system design was forwarded to DEC.
- Results of non-impacted staged soil from previous grading activities are attached.

Date: 01/26/2007  
 Time: 16:49:09

Benchmark  
 Watkins Glen  
 METHOD 8260 - TCL VOLATILE ORGANICS

Rept: AN0326

Client ID Job No Sample Date	Lab ID	NON IMPACT SOIL STOC A07-0743 01/23/2007	A7074301						
Analyte	Units	Sample Value	Reporting Limit	Sample Value	Reporting Limit	Sample Value	Reporting Limit	Sample Value	Reporting Limit
Acetone	UG/KG	ND	29	NA		NA		NA	
Benzene	UG/KG	ND	6	NA		NA		NA	
Bromodichloromethane	UG/KG	ND	6	NA		NA		NA	
Bromoform	UG/KG	ND	6	NA		NA		NA	
2-Butanone	UG/KG	ND	29	NA		NA		NA	
Carbon Disulfide	UG/KG	ND	6	NA		NA		NA	
Carbon Tetrachloride	UG/KG	ND	6	NA		NA		NA	
Chlorobenzene	UG/KG	ND	6	NA		NA		NA	
Chloroethane	UG/KG	ND	6	NA		NA		NA	
Chloroform	UG/KG	ND	6	NA		NA		NA	
Chloromethane	UG/KG	ND	6	NA		NA		NA	
Cyclohexane	UG/KG	ND	6	NA		NA		NA	
1,2-Dibromo-3-chloropropane	UG/KG	ND	6	NA		NA		NA	
Dibromochloromethane	UG/KG	ND	6	NA		NA		NA	
Dichlorodifluoromethane	UG/KG	ND	6	NA		NA		NA	
1,2-Dibromoethane	UG/KG	ND	6	NA		NA		NA	
1,2-Dichlorobenzene	UG/KG	ND	6	NA		NA		NA	
1,3-Dichlorobenzene	UG/KG	ND	6	NA		NA		NA	
1,4-Dichlorobenzene	UG/KG	ND	6	NA		NA		NA	
1,1-Dichloroethane	UG/KG	ND	6	NA		NA		NA	
1,2-Dichloroethane	UG/KG	ND	6	NA		NA		NA	
1,1-Dichloroethene	UG/KG	ND	6	NA		NA		NA	
cis-1,2-Dichloroethene	UG/KG	ND	6	NA		NA		NA	
trans-1,2-Dichloroethene	UG/KG	ND	6	NA		NA		NA	
1,2-Dichloropropane	UG/KG	ND	6	NA		NA		NA	
cis-1,3-Dichloropropene	UG/KG	ND	6	NA		NA		NA	
trans-1,3-Dichloropropene	UG/KG	ND	6	NA		NA		NA	
Ethylbenzene	UG/KG	ND	6	NA		NA		NA	
2-Hexanone	UG/KG	ND	29	NA		NA		NA	
Isopropylbenzene	UG/KG	ND	1 J	NA		NA		NA	
Methyl acetate	UG/KG	ND	6	NA		NA		NA	
Methylene chloride	UG/KG	ND	15 B	NA		NA		NA	
Methyl-t-Butyl Ether (MTBE)	UG/KG	ND	6	NA		NA		NA	
4-Methyl-2-pentanone	UG/KG	ND	29	NA		NA		NA	
Methylcyclohexane	UG/KG	ND	5 J	NA		NA		NA	
Styrene	UG/KG	ND	6	NA		NA		NA	
1,1,2,2-Tetrachloroethane	UG/KG	ND	6	NA		NA		NA	
Tetrachloroethene	UG/KG	ND	6	NA		NA		NA	
Toluene	UG/KG	ND	6	NA		NA		NA	
1,2,4-Trichlorobenzene	UG/KG	ND	6	NA		NA		NA	
1,1,1-Trichloroethane	UG/KG	ND	6	NA		NA		NA	
1,1,2-Trichloroethane	UG/KG	ND	6	NA		NA		NA	

NA = Not Applicable ND = Not Detected

STL Buffalo

Date: 01/26/2007  
Time: 16:49:09

Benchmark  
Watkins Glen  
METHOD 8260 - TCL VOLATILE ORGANICS

Rept: AN0326

Client ID	Lab ID	NON IMPACT SOIL STOC							
Job No		A07-0743	A/074301						
Sample Date		01/23/2007							
Analyte	Units	Sample Value	Reporting Limit	Sample Value	Reporting Limit	Sample Value	Reporting Limit	Sample Value	Reporting Limit
1,1,2-Trichloro-1,2,2-trifluor	UG/KG	ND	6	NA		NA		NA	
Trichloroethene	UG/KG	ND	6	NA		NA		NA	
Trichlorofluoromethane	UG/KG	ND	6	NA		NA		NA	
Vinyl chloride	UG/KG	ND	11	NA		NA		NA	
Total Xylenes	UG/KG	6 J	17	NA		NA		NA	
IS/SURROGATE(S)									
Chlorobenzene-D5	%	82	50-200	NA		NA		NA	
1,4-Difluorobenzene	%	79	50-200	NA		NA		NA	
1,4-Dichlorobenzene-D4	%	80	50-200	NA		NA		NA	
Toluene-D8	%	108	71-125	NA		NA		NA	
p-Bromofluorobenzene	%	104	68-124	NA		NA		NA	
1,2-Dichloroethane-D4	%	119	61-136	NA		NA		NA	

NA = Not Applicable ND = Not Detected

STL Buffalo

Date: 01/26/2007  
Time: 16:49:09

Benchmark  
Watkins Glen  
METHOD 8270 - TCL SEMI-VOLATILE ORGANICS

Rept: AN0326

Client ID Job No Sample Date	Lab ID	NON IMPACT SOIL STOC A07-0743 01/23/2007	A074301						
Analyte	Units	Sample Value	Reporting Limit	Sample Value	Reporting Limit	Sample Value	Reporting Limit	Sample Value	Reporting Limit
Acenaphthene	UG/KG	ND	1900	NA	1900	NA	1900	NA	1900
Acenaphthylene	UG/KG	42 J	1900	NA	1900	NA	1900	NA	1900
Acetophenone	UG/KG	ND	1900	NA	1900	NA	1900	NA	1900
Anthracene	UG/KG	ND	1900	NA	1900	NA	1900	NA	1900
Atrazine	UG/KG	ND	1900	NA	1900	NA	1900	NA	1900
Benzaldehyde	UG/KG	ND	1900	NA	1900	NA	1900	NA	1900
Benzo(a)anthracene	UG/KG	160 J	1900	NA	1900	NA	1900	NA	1900
Benzo(b)fluoranthene	UG/KG	240 J	1900	NA	1900	NA	1900	NA	1900
Benzo(k)fluoranthene	UG/KG	97 J	1900	NA	1900	NA	1900	NA	1900
Benzo(ghi)perylene	UG/KG	190 J	1900	NA	1900	NA	1900	NA	1900
Benzo(a)pyrene	UG/KG	150 J	1900	NA	1900	NA	1900	NA	1900
Biphenyl	UG/KG	ND	1900	NA	1900	NA	1900	NA	1900
Bis(2-chloroethoxy) methane	UG/KG	ND	1900	NA	1900	NA	1900	NA	1900
Bis(2-chloroethyl) ether	UG/KG	ND	1900	NA	1900	NA	1900	NA	1900
2,2'-Oxybis(1-Chloropropane)	UG/KG	ND	1900	NA	1900	NA	1900	NA	1900
Bis(2-ethylhexyl) phthalate	UG/KG	ND	1900	NA	1900	NA	1900	NA	1900
4-Bromophenyl phenyl ether	UG/KG	ND	1900	NA	1900	NA	1900	NA	1900
Butyl benzyl phthalate	UG/KG	ND	1900	NA	1900	NA	1900	NA	1900
Caprolactam	UG/KG	ND	1900	NA	1900	NA	1900	NA	1900
4-Chloroaniline	UG/KG	ND	1900	NA	1900	NA	1900	NA	1900
4-Chloro-3-methylphenol	UG/KG	ND	1900	NA	1900	NA	1900	NA	1900
2-Chloronaphthalene	UG/KG	ND	1900	NA	1900	NA	1900	NA	1900
2-Chlorophenol	UG/KG	ND	1900	NA	1900	NA	1900	NA	1900
4-Chlorophenyl phenyl ether	UG/KG	ND	1900	NA	1900	NA	1900	NA	1900
Carbazole	UG/KG	ND	1900	NA	1900	NA	1900	NA	1900
Chrysene	UG/KG	180 J	1900	NA	1900	NA	1900	NA	1900
Dibenzo(a,h)anthracene	UG/KG	66 J	1900	NA	1900	NA	1900	NA	1900
Dibenzofuran	UG/KG	ND	1900	NA	1900	NA	1900	NA	1900
Di-n-butyl phthalate	UG/KG	ND	1900	NA	1900	NA	1900	NA	1900
3,3'-Dichlorobenzidine	UG/KG	ND	1900	NA	1900	NA	1900	NA	1900
2,4-Dichlorophenol	UG/KG	ND	1900	NA	1900	NA	1900	NA	1900
Diethyl phthalate	UG/KG	ND	1900	NA	1900	NA	1900	NA	1900
2,4-Dimethylphenol	UG/KG	ND	1900	NA	1900	NA	1900	NA	1900
Dimethyl phthalate	UG/KG	ND	1900	NA	1900	NA	1900	NA	1900
4,6-Dinitro-2-methylphenol	UG/KG	ND	9100	NA	9100	NA	9100	NA	9100
2,4-Dinitrophenol	UG/KG	ND	1900	NA	1900	NA	1900	NA	1900
2,4-Dinitrotoluene	UG/KG	ND	1900	NA	1900	NA	1900	NA	1900
2,6-Dinitrotoluene	UG/KG	ND	1900	NA	1900	NA	1900	NA	1900
Di-n-octyl phthalate	UG/KG	ND	1900	NA	1900	NA	1900	NA	1900
Fluoranthene	UG/KG	210 J	1900	NA	1900	NA	1900	NA	1900
Fluorene	UG/KG	39 J	1900	NA	1900	NA	1900	NA	1900
Hexachlorobenzene	UG/KG	ND	1900	NA	1900	NA	1900	NA	1900
Hexachlorobutadiene	UG/KG	ND	1900	NA	1900	NA	1900	NA	1900

NA = Not Applicable ND = Not Detected

STL Buffalo

Date: 01/26/2007  
Time: 16:49:09

Benchmark  
Watkins Glen  
METHOD 8270 - TCL SEMI-VOLATILE ORGANICS

Rept: AN0326

Client ID Job No Sample Date	Lab ID	Sample Value	Reporting Limit	Sample Value	Reporting Limit	Sample Value	Reporting Limit	Sample Value	Reporting Limit
NON IMPACT SOIL STOC A07-0743 01/23/2007		A7074301							
Hexachlorocyclopentadiene	UG/KG	ND	1900	NA	NA	NA	NA	NA	NA
Hexachloroethane	UG/KG	ND	1900	NA	NA	NA	NA	NA	NA
Indenol(1,2,3-cd)pyrene	UG/KG	150 J	1900	NA	NA	NA	NA	NA	NA
Isophorone	UG/KG	ND	1900	NA	NA	NA	NA	NA	NA
2-Methylnaphthalene	UG/KG	390 J	1900	NA	NA	NA	NA	NA	NA
2-Methylphenol	UG/KG	ND	1900	NA	NA	NA	NA	NA	NA
4-Methylphenol	UG/KG	ND	1900	NA	NA	NA	NA	NA	NA
Naphthalene	UG/KG	210 J	1900	NA	NA	NA	NA	NA	NA
2-Nitroaniline	UG/KG	ND	9100	NA	NA	NA	NA	NA	NA
3-Nitroaniline	UG/KG	ND	9100	NA	NA	NA	NA	NA	NA
4-Nitroaniline	UG/KG	ND	9100	NA	NA	NA	NA	NA	NA
Nitrobenzene	UG/KG	ND	1900	NA	NA	NA	NA	NA	NA
2-Nitrophenol	UG/KG	ND	1900	NA	NA	NA	NA	NA	NA
4-Nitrophenol	UG/KG	ND	1900	NA	NA	NA	NA	NA	NA
N-nitrosodiphenylamine	UG/KG	ND	1900	NA	NA	NA	NA	NA	NA
N-Nitroso-D1-n-propylamine	UG/KG	ND	1900	NA	NA	NA	NA	NA	NA
Pentachlorophenol	UG/KG	160 J	9100	NA	NA	NA	NA	NA	NA
Phenanthrene	UG/KG	ND	1900	NA	NA	NA	NA	NA	NA
Phenol	UG/KG	ND	1900	NA	NA	NA	NA	NA	NA
Pyrene	UG/KG	190 J	1900	NA	NA	NA	NA	NA	NA
2,4,5-Trichlorophenol	UG/KG	ND	4500	NA	NA	NA	NA	NA	NA
2,4,6-Trichlorophenol	UG/KG	ND	1900	NA	NA	NA	NA	NA	NA
IS/SURROGATE(S)									
1,4-Dichlorobenzene-D4	%	84	50-200	NA	NA	NA	NA	NA	NA
Naphthalene-D8	%	98	50-200	NA	NA	NA	NA	NA	NA
Acenaphthene-D10	%	105	50-200	NA	NA	NA	NA	NA	NA
Phenanthrene-D10	%	107	50-200	NA	NA	NA	NA	NA	NA
Chrysene-D12	%	115	50-200	NA	NA	NA	NA	NA	NA
Perylene-D12	%	122	50-200	NA	NA	NA	NA	NA	NA
Nitrobenzene-D5	%	66	35-120	NA	NA	NA	NA	NA	NA
2-Fluorobiphenyl	%	86	45-120	NA	NA	NA	NA	NA	NA
p-Terphenyl-d14	%	88	54-135	NA	NA	NA	NA	NA	NA
Phenol-D5	%	77	40-120	NA	NA	NA	NA	NA	NA
2-Fluorophenol	%	65	30-120	NA	NA	NA	NA	NA	NA
2,4,6-Tribromophenol	%	65	46-129	NA	NA	NA	NA	NA	NA

NA = Not Applicable ND = Not Detected

STL Buffalo

**Seneca Market BCP Site  
Watkins Glen, NY**

**Weekly Progress Meeting  
January 15-19, 2007**

---

**Work completed in the previous week:**

- Contractor continued building foundation/footers (E wall going S and S wall going W).
- Minimal GW encountered during foundation work.
- Impacted soils encountered last week were sampled and sent to STL. Results have not been returned yet.
- Non-impacted soils from foundation excavation in stockpile on south side of site were sampled. VOC and SVOC results show no exceedances of SSALs.
- Continued community air monitoring.

**Work anticipated next week:**

- Continue to excavate south building footer/foundation wall.
- Excavate for footer piers.
- GW discharge- DEC granted approval per the RD work plan provided water is discharged to the sanitary sewer.
- Additional sampling of excavated soil as warranted.
- Community Air monitoring.

**Other:**

- Advised Tim to forward PID and CAM results to Benchmark.

Seneca Market BCP Site  
Watkins Glen, NY

Weekly Progress Meeting #5  
February 5-9, 2007

---

Work completed in the previous week:

- No work Monday –Wednesday due to weather.
- No excavation activities all week; no impacted materials encountered.
- Contractor continued backfilling of foundation on N wall.
- Contractor continued pouring footers on S wall heading W and E Wall heading N.
- GW treatment system is plumbed with bag filter and two carbon vessels and is ready for GW discharge as weather permits.
- Community air monitoring during intrusive activities.

Work anticipated next week:

- Continue to excavate south building footer/foundation wall and pouring foundations, if weather permits.
- GW discharge if weather permits.
- Additional sampling of excavated soil as warranted.
- Community Air monitoring during intrusive activities.

Other:

- None



Seneca Market BCP Site  
Watkins Glen, NY

Weekly Progress Meeting #4  
January 29- February 2, 2007

---

Work completed in the previous week:

- Contractor continued excavating building foundation/footers (S wall going W to the building mid-point).
- No impacted materials encountered.
- Contractor continued pouring concrete foundations and footers.
- GW treatment system is plumbed with bag filter and two carbon vessels and is ready for GW discharge. Approximately 500 G of water was discharged. Remaining water will be discharged as weather permits.
- Community air monitoring during intrusive activities.

Work anticipated next week:

- Continue to excavate south building footer/foundation wall and pouring foundations.
- Excavate/pour footer piers.
- GW discharge if weather permits.
- Additional sampling of excavated soil as warranted.
- Community Air monitoring during intrusive activities.

Other:

- None