



**NEW YORK STATE
DEPARTMENT OF ENVIRONMENTAL CONSERVATION**



Request to Import/Reuse Fill or Soil

This form is based on the information required by DER-10, Section 5.4(e) and 6NYCRR Part 360.13. Use of this form is not a substitute for reading the applicable regulations and Technical Guidance document.

SECTION 1 – SITE BACKGROUND

Site Name:

Site Number:

The allowable site use is:

Have Ecological Resources been identified?

Is this soil originating from the site?

How many cubic yards of soil will be imported/reused?

If greater than 1000 cubic yards will be imported, enter volume to be imported:

SECTION 2 – MATERIAL OTHER THAN SOIL

Is the material to be imported gravel, rock or stone?

Does it contain less than 10%, by weight, material that passes a size 100 sieve?

Is this virgin material from a permitted mine or quarry?

Is this material recycled concrete or brick from a DEC registered processing facility?

SECTION 3 - SAMPLING

Provide a brief description of the number and type of samples collected in the space below:

Example Text: 5 discrete samples were collected and analyzed for VOCs. 2 composite samples were collected and analyzed for SVOCs, Inorganics & PCBs/Pesticides.

If the material meets requirements of DER-10 section 5.4(e)5 (other material), no chemical testing needed.

SECTION 3 CONT'D - SAMPLING

Provide a brief written summary of the sampling results or attach evaluation tables (compare to DER-10, Appendix 5):

Example Text: Arsenic was detected up to 17 ppm in 1 (of 5) samples; the allowable level is 16 ppm.

If Ecological Resources have been identified use the "If Ecological Resources are Present" column in Appendix 5.

SECTION 4 – SOURCE OF FILL

Name of person providing fill and relationship to the source:

Name and address of fill source:

Location where fill was obtained:

Identification of any state or local approvals as a fill source:


If no approvals are available, provide a brief history of the use of the property that is the fill source:

Provide a list of supporting documentation included with this request:

--

The information provided on this form is accurate and complete.

_____ Signature	_____ Date
_____ Print Name	Resigned by Thomas Bohlen on 10/13/25 (issues with digital signature)
_____ Firm	





NEW ENTERPRISE STONE & LIME CO., INC.

500 Como Park Boulevard • Buffalo NY 14227

Office: (716) 826-7310

Fax: (716) 826-1342

Dispatch: (716) 566-9690

October 13, 2025

David Meyer
Thomann Asphalt
56 Gunville Rd
Lancaster, NY 14086

Re: Station 12 Buildings A & B

Dear David,

The 2" Crusher Run Stone to be supplied to the above referenced project was extracted, crushed & screened at our Lancaster, NY facility. The material is produced from a virgin stone source, un-impacted by hazardous materials or contaminants and free of loam, organic matter including clay. The quarry is a NYSDOT approved source; the Wehrle Drive source number is 5-3R and our mining permit # is 90018.

Sincerely,

Robert Warrington

Material Test Report

Report ID: MAT:04-25-2621-01

Issue No: 1

This issue replaces all previous issues of this report

Client: New Enterprise Stone & Lime Co., Inc **CC:** Buffalo Admin
Paul Juda

Project: 2500154 - 2025 Materials Testing

Location: Williamsville, NY

This report and the results contained herein are the exclusive property of CME Associates, Inc. and shall only be reproduced in full when written consent is provided by CME Associates, Inc. The results in this report relate only to the items inspected or tested.



Submitted By: Charlie Froment, P.E., PE, Project Manager
Date of Issue: 6/2/2025

Sample Details

Sample ID 04-25-2621-01
Date Sampled 5/29/2025
Source NESL Wehrle #5-3R
Material 2" Minus R.O.C. Limestone
Location Wehrle Drive Stockpile 5-3R


Other Test Results

Description	Method	Result	Limits
Cu	ASTM D2487	28.51	
Cc		3.42	
Procedure	ASTM C117	B	

Particle Size Distribution

ASTM C136

Drying By: None
Date Tested: 5/31/2025
Tested By: Austin Glasier



Sieve Size	% Passing	Limits
3in	100	
2in	100	
1 1/2in	100	
1in	89	
3/4in	76	
1/2in	56	
3/8in	46	
1/4in	35	
No.4	30	
No.10	19	
No.20	12	
No.40	10	
No.80	7	
No.100	7	
No.200	6.0	

COBBLES	GRAVEL (70%)		SAND (24%)			SILT/CLAY
	COARSE	FINE	COARSE	MEDIUM	FINE	
0%	24.2%	45.6%	11.2%	9.5%	3.6%	6%

Comments

N/A