



**NEW YORK STATE
DEPARTMENT OF ENVIRONMENTAL CONSERVATION**



Request to Import/Reuse Fill or Soil

This form is based on the information required by DER-10, Section 5.4(e) and 6NYCRR Part 360.13. Use of this form is not a substitute for reading the applicable regulations and Technical Guidance document.

SECTION 1 – SITE BACKGROUND

Site Name:

Site Number:

The allowable site use is:

Have Ecological Resources been identified?

Is this soil originating from the site?

How many cubic yards of soil will be imported/reused?

If greater than 1000 cubic yards will be imported, enter volume to be imported:

SECTION 2 – MATERIAL OTHER THAN SOIL

Is the material to be imported gravel, rock or stone?

Does it contain less than 10%, by weight, material that passes a size 100 sieve?

Is this virgin material from a permitted mine or quarry?

Is this material recycled concrete or brick from a DEC registered processing facility?

SECTION 3 - SAMPLING

Provide a brief description of the number and type of samples collected in the space below:

Example Text: 5 discrete samples were collected and analyzed for VOCs. 2 composite samples were collected and analyzed for SVOCs, Inorganics & PCBs/Pesticides.

If the material meets requirements of DER-10 section 5.4(e)5 (other material), no chemical testing needed.

SECTION 3 CONT'D - SAMPLING

Provide a brief written summary of the sampling results or attach evaluation tables (compare to DER-10, Appendix 5):

Example Text: Arsenic was detected up to 17 ppm in 1 (of 5) samples; the allowable level is 16 ppm.

If Ecological Resources have been identified use the "If Ecological Resources are Present" column in Appendix 5.

SECTION 4 – SOURCE OF FILL

Name of person providing fill and relationship to the source:

Name and address of fill source:

Location where fill was obtained:

Identification of any state or local approvals as a fill source:


If no approvals are available, provide a brief history of the use of the property that is the fill source:

Provide a list of supporting documentation included with this request:

--

The information provided on this form is accurate and complete.

_____ Signature	_____ Date
_____ Print Name	Resigned by Thomas Bohlen on 10/28/25 (issues with digital signature)
_____ Firm	



Submittal

Submittal # **591**
 Date **10/23/2025**

From **Thomann Asphalt Paving Corp**
David Meyer
davidm@tapc.net

Project **Station Twelve - Bldgs A & B**
#25631
3055 Sheridan Drive
Amherst , NY 14226

For **Turner Construction Company**
Jessica Nowak
jlnowak@tcco.com

Product **BSH #2 Limestone**

Description **#57 Alternative**

Spec Section

Spec Paragraph

Comments **Gas Permeable Aggregate Layer**

Vendor **County Line Stone Co. Inc.**
4515 Crittenden Rd
Akron, NY 14001

- APPROVED
- APPROVED AS NOTED**
- REJECTED
- REVISE AND RESUBMIT
- EXAMINED

“Approved As Noted” or Comments made on the shop drawings during this review do not relieve contractor from compliance with requirements of the drawings and specifications. This check is only for review of general conformance with the design concept of the project and general compliance with the information given in contract documents. The contractor is responsible for confirming and correlating all quantities and dimensions, selecting fabrication processes and techniques of construction, coordinating his work with that of all other trades and performing his work in safe satisfactory manner.

 GeoEnvironmental of New York
 300 Pearl Street, Suite 700, Buffalo, NY 14202

Date: October 24, 2025 By:  Stephen M. Kline, P.E.

1. Product requires Request for Import approval from the NYSDEC prior to delivery to the BCP Site.

County Line STONE CO., INC.

4515 CRITTENDEN ROAD, AKRON, N.Y. 14001

Phone 716-542-5435

Fax 716-542-5442

ALL SIZES CRUSHED STONE

BITUMINOUS CONCRETE

AGRICULTURAL LIME

Material

BSH #2 Limestone

Date

10/23/2025

Sieve	Test Result	Range	Specification
4"(100mm)			
3"(75mm)			
2 1/2"(63mm)			
2"(50mm)			
1 1/2"(37.5mm)	100	100	100
1"(25mm)	94.8	90-97	90-100
3/4"(19mm)	52.1	40-60	2-55
5/8"(16.0mm)			
1/2"(12.5mm)	6.9	4-10	0-5
3/8"(9.5mm)			
5/16 "(8.0mm)			
1/4"(6.3mm)			
#4(4.75mm)			
1/8"(3.2mm)			
#8(2.36mm)			
#16(1.18mm)			
#20(850um)			
#30(600um)			
#40(425um)			
#50(300um)			
#80(180um)			
#100(150um)			
#200(75um)	0.6	0-1	0
PAN			
TOTAL			

New York State Specifications

Size Designation	Screen Sizes												
	4"	3"	2 1/2"	2"	1 1/2"	1"	1/2"	1/4"	1/8"	No 40	No 80	No 200	
Screenings							100	90-100					0-1.0
1B								100	90-100		0-15		0-1.0
1A							100	90-100	0-15				0-1.0
1ST							100	0-15					0-1.0
1						100	90-100	0-15					0-1.0
2					100	90-100	0-15						0-1.0
3A				100	90-100	0-15							0-0.7
3			100	90-100	35-70	0-15							0-0.7
4A		100	90-100		0-20								0-0.7
4	100	90-100		0-15									0-0.7
5	90-100	0-15											0-0.7
TYPE 1		100		90-100					30-65		5-40		0-10
TYPE 2				100					25-60		5-40		0-10
TYPE 3	100								30-75		5-40		0-10
TYPE 4				100					30-65		5-40		0-10

Comments: Meets all requirements of NYSDOT Item No. 703-02

NYSDOT Source 5-7RS