Haley & Aldrich of New York 200 Town Centre Drive Suite 2 Rochester, NY 14623-4264



Tel: 585.359.9000 Fax: 585.359.4650 HaleyAldrich.com

9 November 2012 File No. 36795-027/029

New York State Department of Environmental Conservation Division of Environmental Remediation, Region 9 270 Michigan Avenue Buffalo, New York 14203

Attention: Mr. Glenn May

Environmental Geologist II

Subject: Sub-Slab Depressurization Systems Pilot Testing Report

Interim Remedial Measures (IRM) Work Plan Buildings 7 and 8 BCP Sites # C932138 / C932139

200 Upper Mountain Road Lockport, New York

Dear Mr. May:

On behalf of GM Components Holdings, LLC, (GMCH) Haley & Aldrich of New York (Haley & Aldrich) has prepared this report of Pre-Design Investigation (PDI) activities and the proposed Interim Remedial Measures (IRMs) for the GMCH Lockport facility located at 200 Upper Mountain Road, Lockport, New York.

The PDI was conducted in accordance with the work plan for the Pre-Design Investigation – Sub-Slab Depressurization Systems (SSDS) Buildings 7 and 8, BCP Sites #C932138 / C932139, 200 Upper Mountain Road, Lockport, New York. The goals of the PDI were to determine the design parameters for the installation and operation of a sub-slab depressurization system (SSDS) as part of the proposed remedy for Building 7 (BCP Site #C932138) and Building 8 (BCP Site #C932139) as outlined in each building's respective Draft Remedial Work Plan (RWP) submitted to the NYSDEC on 29 December 2011.

SSDS pilot testing activities were conducted from 29 May through 13 June 2012. Sections 1 through 3 presents a summary of the activities conducted, a tabulation of data collected, analytical testing results, observations and findings. Section 4 provides recommendations for implementation of the sub-slab depressurization system (SSDS) remedy with a proposed schedule for implementation.

1. SUB-SLAB DEPRESSURIZATION PILOT TESTING ACTIVITIES

Two (2) pilot test locations within Building 7 and one (1) pilot test location within Building 8 were selected based on current plant operations and the results of sub-slab vapor samples collected during the Remedial Investigation (RI). The PDI provided data and information to assess the following system specifications:

- Determine the number of suction points to maintain sub-slab depressurization (vacuum) for the area of sub-slab vapor impacts identified during the RI. Applied vacuum measurements were collected from installed temporary vacuum measurement points using a handheld micromanometer;
- Determine the annual potential to emit (PTE) of hazardous air pollutants (HAP) from the proposed SSDS within each building based on the analysis of the vacuum blower effluent obtained during the PDI to determine chemical-specific discharge rates.

1.1 Suction Pit Installations

During the period from 29 May through 1 June 2012, three (3) suction pits were installed, two (2) located within Building 7 and one (1) located within Building 8. Refer to Figures 1 and 2 for pit locations, Figure 3 for details regarding pit construction and blower system set-up, and the Photo Log Summary in Attachment 1A.

The suction pits were completed utilizing an electric 10-inch diameter coring machine, hand excavation to approximately 18-inch below the bottom of the concrete slab, and backfilling a mix of number 1 and 2 stone. The horizontal trenching work was completed with a propane-powered concrete saw cutting machine to cut the concrete, an electrical jackhammer for concrete material removal, hand excavation of the sub-based materials to approximately 12-inches below the bottom of the existing slabs. 4-inch diameter schedule-40 PVC pipe and fittings were installed in each trench from the suction pit for the horizontal run to the nearest building column, and number 1 and 2 stone were backfilled around the PVC piping before restoration.

At the nearest column, the suction pit piping was routed vertically and terminated at approximate 5-feet above the top of the existing slab. Restoration of the concrete floor was completed by placing a vapor barrier over the stone backfill, installing 3/8-inch reinforcement pins lagged and epoxy sealed into the existing slab at approximately 12-inch centers and pouring 4,000 psi concrete into the trenched area. Concrete, sub-based soils, and gravel materials removed during completion of the work were placed in GMCH provided waste containers for management by the facility. Real time ambient air monitoring was conducted around the work area utilizing a MiniRAE organic vapor meter (OVM) equipped with a photo-ionization detector (PID) with a 10.6eV lamp during the installation of the suction pits.

1.2 Blower System Set-up, Operation, and PDI Data Collection

Eight (8) temporary sub-slab vacuum measurement (VM) points were initially installed around each test location by drilling 1/2-inch diameter holes through the concrete floor to a depth of approximately 1/2-inch below the slab. Sub-slab vacuum measurements were collected from each VM point prior to start-

9 November 2012 Page 3

up of the blower system utilizing a handheld Testo 506–500Pa/2 IWC micro-manometer. The micro manometer was connected to 1/4-inch high density polyethylene (HDPE) tubing extended through the floor surface and temporarily sealed with clay to provide an air-tight surface seal, to determine background conditions. Refer to Figures 5, 6, and 7 for locations of the installed VM points at test locations located in Buildings 8, 7-East and 7-West, respectively.

A three (3) horsepower (Hp) explosion proof regenerative blower system was utilized to conduct the PDI testing. During the period 4 through 13 June 2012, the blower operating parameters ranged from:

- 74 to 98 cubic feet per minute (CFM);
- 14 to 60-inches of water column ("W.C.) vacuum, and
- 4 to 23 inches W.C. discharge pressure under steady state operations.

The blower system inlet (vacuum) side and discharge (pressure) side piping were equipped with adjustable valves, vacuum and pressure gauges and in-line flow sensors with magnehelic gauges to measure differential pressure used to calculate vapor discharge flow rates. Conveyance piping to and from the blower unit consisted of 2-inch flex hose connected from the trench vertical PVC piping at the column to the blower inlet piping, and from the blower discharge piping routed through existing roof penetrations above each test location. At each test location, the blower system was operated for approximately 44 to 51 hours during which the following data collection, monitoring, and sampling were completed.

- Real-time ambient air monitoring utilizing the referenced OVM;
- Vacuum measurements at the respective VM points;
- Blower discharge OVM readings:
- Blower system operating data;
- Installation of additional VM points to further define potential extents of vacuum influence; and
- Blower system vapor effluent samples using Tedlar® sampling bags and analyzed for VOCs using EPA Method 8260B.

Vapor samples were collected during steady state operating conditions in which the system achieved either maximum or stable blower vacuum or air flow rates. A summary of the blower operating conditions, corresponding VM point readings, blower discharge OVM readings, blower vapor phase effluent analytical results, and blower discharge vapor flow rates for each of these test locations are provided in Tables 1A through 1C.

2. OBSERVATIONS

Extent and Degree of Sub-Surface Depressurization (Vacuum) Influence

As indicated in the Draft RWP developed for the Building 7 BCP Site and Building 8 BCP Site, the assumed design parameters for each pit installation included an estimated maximum area of vacuum influence of approximately 50,000 square feet (SF). As shown on Figures 5, 6 and 7, the extent of vacuum influence and measurements varied with each test location.

The observed estimated maximum vacuum influence for each pilot test location was estimated at:

- Building 8 10,000 SF;
- Building 7-East 36,150 SF; and
- Building Bldg 7-West 31,850 SF.

The observed variance from the initial assumed design parameters relative to coverage area per suction pit location could potentially be attributed to limited building slab sub-base thickness observed during pit installations, the presence of shallow sub-grade utilities and/or concrete floor penetrations within each pilot test area. The building slab sub-base thickness ranged from 1 to 3-inches of bank run and crusher run gravel materials. More uniform sub-bases thickness and material typically provide greater pore space thus greater air volume capacity to support greater propagation of vacuum influence within the sub-surface.

Sub-grade features such as utility piping and conduits (i.e., vertical roof drains and associated conductors), equipment or building foundations, floor penetrations, or imperfections in the concrete surface in the form of cracks or abutting flooring systems, may also contribute to preferential air flow pathways. These apparent air-flow preferential pathways or obstructions are evidenced by the non-radial vacuum influence contours that appear to align with known sub-slab features. One area affected by these potential conditions was the Building 7-West location in which several large cracks and seams in the concrete were observed proximal to the test pit area.

A simple field test was conducted by temporarily sealing these cracked areas with sealing tape and measuring the vacuum influence range under the taped areas and at target VM points. The results of the field test indicated that an increase in VM point readings from 0.062-inches to 0.074-inches at point E-1 and from 0.044-inches to 0.070-inches in point W-1, and the cracked area ranged from no measurable readings to exceeding the upper micro-manometer range of 2-inches W.C. after sealing, suggesting that the limited vacuum influence could be due to these types of floor surface conditions.

3. FINDINGS

Based on the pilot testing results, field observations, and existing site conditions proximal to the pilot testing areas, the features of the pilot test blower system and associated suction pits appear feasible for full-scale implementation of the proposed SSDS in each building area as identified in the Draft RWP with the following final design considerations.

Target Depressurization Levels and Areas of Vacuum Influence

A vacuum level of 0.002-inches water column (W.C.) is prescribed as the criteria to demonstrate subslab depressurization in the USEPA standards for the control of radon gas and the NYSDOH guidance for the control of soil vapor intrusion¹. In the Draft RWP, a sub-slab vacuum level of 0.025-inches W.C. was identified as the target sub-slab vacuum level for the development of the preliminary design and cost estimates of the proposed full-scale SSDS within Building 7 and 8. The following areas of influence in square feet of floor space (SF) for each target sub-slab vacuum level estimated from the pilot test sub-slab vacuum monitoring data are presented below:

Suction Pit	Vacuum	Approximate Area	Vacuum	Approximate Area
Location	Measurement	of Influence (SF)	Measurement	of Influence (SF)
	(inches W.C.)		(inches W.C.)	
Bldg 8	0.025	8,145	0.002	10,000
Bldg 7-East	0.025	25,000	0.002	36,150
Bldg 7-West	0.025	9,470	0.002	31,850

The sub-slab vacuum monitoring data collected during the SSDS pilot testing suggests that the area of the influence of the blower system was potentially limited by sub-surface utility structures, facility floor penetrations for floor and roof drains and settling cracks near existing and former equipment locations.

Based on the pilot testing data collected, the full-scale SSDS should be designed and installed at a spacing to meet the minimum sub-slab depressurization vacuum level of 0.002-inches W.C. between each suction pit location. In addition, with the flooring conditions observed, sealing of floor cracks, voids, seams or other observable floor penetrations should be completed to extent practical to maximize the effectiveness of the blower systems and potentially increase the area of vacuum influence. A contingency to install additional suction pits should be performed if during commissioning of the full scale SSDS sub-slab vacuum measurements indicate that the sub-slab vacuum of 0.002- inches W.C. is not achieved at the vacuum monitoring points installed between suction pit locations.

Extracted Vapor Flow Rates and Potential to Emit

Representative vapor samples of the blower effluent were collected during the performance of the SSD pilot testing program. The effluent samples were collected from a port installed in the side of the 2-inch piping connection on the discharge side of the vacuum blower system. The samples were collected

¹ New York State Department of Health, (2006). <u>Guidance for Evaluating Soil Vapor Intrusion in the State of New York.</u> Center for Environmental Health, Bureau of Environmental Exposure Investigation, October 2006. Radon Prevention in the Design and Construction of Schools and Other Large Buildings EPA [EPA 625-R-92-016, June 1994]

9 November 2012 Page 6

in pre-cleaned Tedlar[®] sampling bags and submitted under a chain of custody to a NYSDOH certified environmental laboratory for the analysis of volatile organic compounds (VOC) via USEPA Method 8260B.

A worst-case analysis of the short term and projected annual emissions or Potential-to-Emit (PTE) from the discharge of the SSDS was conducted using calculations provided in the NYSDEC *Guidelines for the Control of Toxic Ambient Air Contaminants* (DAR-1) published 12 November 1997. Using the blower system effluent sample analysis results and the observed discharge flow rates in cubic feet per minute (CFM), the short term or annual impacts for the SSDS for Building 8 and Building 7 were calculated and compared to the Short-Term and Annual Guideline Concentration (SGC/AGC) values published by NYSDEC on 18 October 2010.

The calculated SGC/AGC for each VOC detected at each suction pit during the pilot test was over oneorder of magnitude below the current NYSDEC guideline values indicating that the direct discharge of the proposed SSDS will not require VOC emission controls. Therefore, vapor phase treatment, typically in the form of granulated activated carbon (GAC), would likely not be required for the effluent from the full-scale SSDS installations proposed in the Draft RWP for each building.

The results of the laboratory analyses and the process discharge flow rates calculated from the observed vacuum level at the discharge of the blower system was also used to calculate the amount of each VOC that could be emitted from the system for comparison to the Major Source thresholds for hazardous air pollutants (HAP). Based on the analytical results and blower operating data at each pilot test location, the annual HAP PTE rates were calculated as follows:

Suction Pit Location	Analyte	Concentration (mg/m³) A	Flow Rate (CFM) B	HAPs PTE (lb/yr)	HAPs PTE (ton/yr)
Dida 0	Trichloroethene*	1.82 J	74	4.4	0.0022
Bldg 8	Total HAPs	1.82	/4	4.4	0.0022
	cis-1,2-Dichloroethene	2.83		NA	NA
Dida 7 Foot	Trichloroethene*	2.84	98	9.1	0.0046
Bldg 7-East	Tetrachloroethene*	1.67 J	98	5.4	0.0027
	Total HAPs	4.51		14.5	0.0073
	cis-1,2-Dichloroethene	0.712		NA	NA
Bldg 7- West	Tetrachloroethene*	4.97	78	12.7	0.0064
*** CSt	Total HAPs	4.97		12.7	0.0064

J - Estimated Concentration

NA – Not Applicable

Example equation:
$$A \frac{mg}{m^3} \times \frac{1 lb}{453,592.37 mg} \times B \frac{ft^3}{min} \times \frac{m^3}{35.31 ft^3} \times \frac{525,600 min}{1 yr} = C \frac{lb}{yr} \times \frac{ton}{2000 lb} = D \frac{ton}{yr}$$

^{* -} hazardous air pollutant (HAP)

9 November 2012 Page 7

Based on the data and information collected during the SSD pilot testing activities, the maximum HAPs PTE for Building 8 is estimated to be approximately 0.022 tons/yr with a per-pit average emission rate of 0.0022 tons/yr. The HAP PTE estimate assumes the installation of 10 suction pits over approximately a 100,000 SF area where sub-slab vapor Site COC concentrations greater than 250 ug/m³ was identified during the RI.

For Building 7 and 7A, the maximum HAP PTE is estimated at 0.139 tons/yr with a per-pit average emission rate of 0.0073 tons/yr. The PTE estimate assumes the installation of 19 suction pits over approximately 620,000 SF where sub-slab vapor Site COC concentrations greater than 250 ug/m³ was identified during the RI.

Thus, the maximum increase in the facility HAP PTE from the assumed annual operation of the maximum number of SSDS suction pits that could be installed in Building 7/7A and Building 8 would be approximately 0.16 tons/yr. The estimate of maximum PTE for the installation of the proposed SSDS within Buildings 7/7A and 8 is well below the USEPA regulatory threshold of 10 tons/yr and should not affect the facility's current status as an Area (Minor) Source of HAP.

The calculations used in the evaluation of the short term and projected annual emissions from the SSDS, the sample chain of custody documentation and the final laboratory reports are provided in Attachments 1B and 1C respectively.

ovember 2012 Page 8

4. RECOMMENDATIONS/ SSDS INSTALLATION WORK PLAN

Due to the variability in Site conditions as evidenced by the range in the approximate areas of vacuum influence and pilot test system operating parameters (i.e. vapor flow rate and VOC concentration), implementation of the full-scale SSDS remedy for each building should be implemented in the following steps:

4.1 SSDS Installation

Install suction pits/blower systems in the areas where the Site COC were detected in the sub-slab vapor during the RI for each building at concentrations above 1,000 ug/m³. Based on the areas of vacuum influence observed during the pilot testing program install:

- six (6) additional suctions pits in the Building 7-West area;
- two (2) suction pits in Building 7A; and
- seven (7) additional suction pits in Building 8.

(Note: No additional pits need to be installed in the Building 7 East area)

• In addition, seal visually identified cracks, seams, and other potential short-circuit pathways in the concrete floor for the proposed areas of operation to improve vacuum influence;

Final pit and monitoring point locations will be determined and adjusted during final design based on field conditions and plant operating requirements. This proposed SSDS installation area covers approximately 235,000 SF within Building 7/7A and approximately 80,000 SF within Building 8. Proposed locations for additional suction pits and sub-slab vacuum monitoring points are presented on Figure 8 (for Building 7/7A) and Figure 9 (for Building 8) Construction details for suction pit and fans installations at each location are shown on Figure 10.

4.2 SSDS Operations, Monitoring, and Testing

- Operate and monitor the installed SSDS for three (3)-months to determine vacuum influence and associated coverage areas; and
- After the initial three (3) months of operation, conduct an indoor-air and sub slab vapor quality sampling event at locations in each building where the observed vacuum influence is below (<) 0.002 inches WC.

Upon receipt of the analytical results from the sampling event and compiling of the system operations data and vacuum measurements obtained during the initial operating period, GMCH will confer with the Department to determine if additional actions are needed to achieve the Remedial Action Objectives (RAO) for indoor air.

If additional actions are deemed necessary; additional suction pits and associated blower systems should be installed to extend the vacuum influence. Prior to the additional suction pit installations, floor 9 November 2012 Page 9

sealing in the additional areas for SSDS operations should be performed as presented above. If additional suction pits are installed, operations, monitoring and testing should be completed as prescribed above.

The proposed schedule for full-scale SSDS installation and monitoring program is provided at the end of this report. Schedule for implementation is contingent upon manufacturing activities in the area targeted for system installation and subcontractor selection and availability.

CLOSING

This report has provided a summary of the PDI activities performed and proposed SSDS IRM Work Plan associated with the GMCH Lockport facility located at 200 Upper Mountain Road, Lockport, New York. The PDI was conducted in accordance with the work plan for the Pre-Design Investigation – Sub-Slab Depressurization Systems (H&A, 14 May 2012).

The PDI provided sufficient data to proceed with the full-scale installation and operation of the proposed SSDS remedy for Building 7 (BCP Site #C932138) and Building 8 (BCP Site #C932139) as outlined in Draft RWP for each building.

GMCH requests your review and concurrence with the implementation approach presented in this report so that the SSDS design and installation can proceed concurrent with the Department's development of the Proposed Decision Documents (PDD) for the GMCH Lockport facility BCP Sites.

If there are questions or any require additional information concerning the information provided in this report, please do not hesitate to contact us 585.321.4245.

E. Quinn Lewis, P.E.

Senior Engineer

Sincerely yours,

HALEY & ALDRICH OF NEW YORK

Denis Conley

Project Manager

David Hagen Sr. Vice President

Schedule Tables

Figures

Attachments

G:\Projects\36795_GM Lockport\027 Remedial Action Implementation\2012_1109_GMCH SSDS Pilot Testing _IRM Work Plan_F.docx

Schedule

Pre-Design Investigation (PDI) - Sub-Slab Depressurization Systems/ Interim Remedial Measures (IRM) Work Plan

BCP Sites #C932138/932139

GMCH Lockport Facility

200 Upper Mountain Road

ID	_	Task Name	Duration	Start	Finish	ter			1st Qua	arter		2nd Qua	arter	
	0					Nov	De	ec	Jan	Feb	Mar	Apr	May	Jun
1		SSDS IRM Installation	150 days	Fri 11/9/12	Thu 6/6/13									
2		IRM Work Plan Approval	10 days	Fri 11/9/12	Thu 11/22/12		7							
3		IRM Work Plan submission to NYSDEC	0 days	Fri 11/9/12	Fri 11/9/12	∳ _11	/9							
4		NYSDEC Review	2 wks	Fri 11/9/12	Thu 11/22/12		ь							
5		NYSDEC Approval	0 days	Thu 11/22/12	Thu 11/22/12		11/22	2						
6		Final Design / Pre-Construction	30 days	Fri 11/9/12	Thu 12/20/12	* ±		₽ 1						
7		Complete Final Design/ Bid Spec	3 wks	Fri 11/9/12	Thu 11/29/12									
8		Contractor Prequalification	3 wks	Fri 11/9/12	Thu 11/29/12									
9		Bid Phase/ Contract Award	2 wks	Fri 11/30/12	Thu 12/13/12			<u>. </u>						
10		Pre-mob site reviews / plant coordination/ set-up	1 wk	Fri 12/14/12	Thu 12/20/12			5						
11		Construction - Bldg 7/7A/8	40 days	Fri 12/21/12	Thu 2/14/13									
12		Pit installations/ Floor Sealing - Critical Plant Areas	2 wks	Fri 12/21/12	Thu 1/3/13									
13		Pit installations/ Floor Sealing - Remaining areas	2 wks	Fri 1/4/13	Thu 1/17/13									
14		Submittal Review/ Order & Receive Mech/ Elec Equip	3 wks	Fri 12/21/12	Thu 1/10/13									
15		Fan/ Piping/ Elec/ Controls Installations	4 wks	Fri 1/11/13	Thu 2/7/13									
16		System Commissioning	1 wk	Fri 2/8/13	Thu 2/14/13					<u> </u>				
17		System Monitoring	80 days	Fri 2/15/13	Thu 6/6/13							1		
18		System Operations	3 mons	Fri 2/15/13	Thu 5/9/13									
19		Indoor Air/ Sub-Slab Vapor Sampling	1 wk	Fri 5/10/13	Thu 5/16/13									
20		Analytical Results/ Data Summary	3 wks	Fri 5/17/13	Thu 6/6/13									

GMCH Lockport Facility
Project: SSDS Installation
Date: Fri 11/9/12

Task
Split
Summary
Project Summary
Project Summary
Project Summary
Project Summary
Project Summary
Project Summary
Page 1


Figures


Pre-Design Investigation (PDI) - Sub-Slab Depressurization Systems/ Interim Remedial Measures (IRM) Work Plan

BCP Sites #C932138/932139


GMCH Lockport Facility

200 Upper Mountain Road





LockportlCAD\36795-BLDG7-DTLS-1.dwg







SUB-SLAB DEPRESSURIZATION SYSTEM PILOT TEST GMCH LOCKPORT FACILITY 200 UPPER MOUNTAIN ROAD LOCKPORT, NEW YORK


SCHEMATIC FOR TYPICAL SUB-SLAB VACUUM MONITORING POINT


SCALE: NOT TO SCALE MAY 2012


FIGURE 4














GENERAL NOTES:

- ALL COMPONENTS OF THE SUB-SLAB DEPRESSURIZATION (SSDS) SYSTEM SHALL BE INSTALLED BY A LICENSED CONTRACTOR IN COMPLIANCE WITH APPLICABLE MECHANICAL, ELECTRICAL, PLUMBING, ENERGY, AND FIRE PREVENTION CODES, STANDARDS, AND REGULATIONS OF THE LOCAL JURISDICTION AND PLANT STANDARDS.
- ALL PENETRATIONS TO THE SLAB ARE TO BE SEALED WITH HIGH ADHESIVE POLYURETHANE SEALANT, PLASTIC SEAL™ BY HERCULES OR EQUIVALENT.
- ALL SYSTEM PIPING SHALL BE LABELED AS "SUB-SLAB DEPRESSURIZATION SYSTEM".
- DISCHARGE POINT SHALL BE A MINIMUM OF 25 FEET AWAY FROM ANY AIR INTAKE TO THE BUILDING.
- DISCHARGE POINT SHALL BE LOCATED A MINIMUM OF 10 FEET FROM ANY OPENING OR INTAKE INTO CONDITIONED SPACE (I.E. WINDOW OR DOOR) OR AT LEAST 2 FEET ABOVE ANY SUCH OBJECT.
- ANY HORIZONTAL PIPING SHALL BE SLOPED A MINIMUM OF 1/8 INCH PER 1 FOOT TO PERMIT DRAINAGE BACK TO THE SUCTION PIT.
- PIPE FITTINGS AND CONNECTIONS ARE TO BE AIR TIGHT. CONNECT A LOW PRESSURE PNEUMATIC TEST FOR TIGHTNESS.
- PIPES SHALL BE FASTENED TO THE STRUCTURE OF THE BUILDING WITH HANGERS, STRAPPING OR OTHER SUPPORTS THAT WILL ADEQUATELY SECURE THE VENT PIPING.
- SUPPORTS FOR VERTICAL VENT PIPES SHALL BE INSTALLED EITHER ABOVE OR BELOW THE POINTS OF PENETRATIONS THROUGH FLOORS, CEILINGS, AND ROOFS, OR AT LEAST EVERY 8 FEET ON RUNS THAT DO NOT PENETRATE FLOORS.
- 10. PIPES SHALL NOT BLOCK ACCESS TO ANY AREAS REQUIRING MAINTENANCE OR INSPECTION.
- 11. ACTIVATION RANGE OF PRESSURE SWITCHES INDICATING FAN OPERATIONS SHALL BE ADJUSTED AFTER FIELD TESTING OF THE SYSTEM.
- 12. SYSTEM PIPING SHALL BE CARBON STEEL IF ROUTED IN A FIRE RATED

ELECTRICAL AND CONTROL NOTES

- 1. ONE CIRCUIT BREAKER AND LOCAL DISCONNECT FOR EACH SUB SLAB VENT SHALL BE INSTALLED TO PERMIT DEACTIVATION OF THE FAN FOR MAINTENANCE OR REPAIR.
- 2. FOR EACH SUB-SLAB VENT FAN, SYSTEM FAILURE INDICATION DEVICES CONSISTING OF A PRESSURE SWITCH IN THE RISER ON THE SUCTION SIDE OF THE FAN AND PRESSURE INDICATOR LIGHTS MOUNTED PROXIMAL TO THE PIT LOCATIONS SHALL BE INSTALLED PRIOR TO SYSTEM OPERATION. PRESSURE SWITCHES SHALL BE INSTALLED IN LOCATIONS ACCESSIBLE FOR MAINTENANCE.



GM COMPONENTS HOLDINGS, LLC. ALDRICH LOCKPORT FACILITY
200 UPPER MOUNTAIN ROAD LOCKPORT, NEW YORK

SSDS INSTALLATION DETAILS

SCALE: NONE NOVEMBER 2012

FIGURE 10

Tables

Pre-Design Investigation (PDI) - Sub-Slab Depressurization Systems/ Interim Remedial Measures (IRM) Work Plan

BCP Sites #C932138/932139

GMCH Lockport Facility

200 Upper Mountain Road

TABLE - 1A SSDS Pilot Testing - Log Sheet Summary

GMCH Lockport Facility

Bldg No.: 8

Project No.: 36795-029
November 2012

	Date:	6/4/2012	6/4	/2012	6/4/2012	6/4	/2012	6/4/2012	6/4/2012	6/4	/2012	6/4/2012	6/4/	2012	6/4/2012	6/5/2012	6/5	2012	6/5/2012	6/5/2	012	6/5/2012	6/6/2012	6/6/2	2012
Measure	ement Time Range:	12:15	12:45	5-13:00	13:00	13:37	7-15:15	15:30	15:35	15:40	0-16:17	16:30	16:45	-17:12	17:30	9:15	9:3	-9:45	13:00	13:00-	14:25	14:40	9:15	9:10-	10:22
Sub Slab Monitoring Point ID	Proximal Column Reference		Vacuum Reading Low (in.w.c.)	Vacuum Reading High (in.w.c.)		Vacuum Reading Low (in.w.c.)	Vacuum Reading High (in.w.c.)			Vacuum Reading Low (in.w.c.)	Vacuum Reading High (in.w.c.)		Vacuum Reading Low (in.w.c.)	Vacuum Reading High (in.w.c.)			Vacuum Reading Low (in.w.c.)	Vacuum Reading High (in.w.c.)		Vacuum Reading Low (in.w.c.)	Vacuum Reading High (in.w.c.)			Vacuum Reading Low (in.w.c.)	Vacuum Reading High (in.w.c.)
N-1	HH-89		0.005	0.007		0.011	0.014			0.013	0.02		0.018	0.027			Steady	0.021		Steady	0.026			Steady	0.028
E-1	KK-87		0.017	0.021		0.086	0.088			0.059	0.072		0.161	0.168			Steady	0.168		Steady	0.198			Steady	0.174
W-2	DD-87		0	0		0.011	0.016			0.036	0.039		0.048	0.054			Steady	0.048		Steady	0.056			Steady	0.056
NW-2	DD-91		0	0		0	0			0	0		0	0			0	0		0	0			0	0
NE-2	MM-91		0	0		0	0			0	0		0	0			0	0		0	0			0	0
S-2	HH-83		0	0		0	0			0	0		0	0			0	0		0	0			0	0
N-3	HH-93		NM	NM		0	0			0	0		0	0			0	0		0	0			0	0
E-3	PP-87	Blower	NM	NM	Blower	0	0	Blower	Blower Adjustment	0	0	Blower	0	0	Blower Adjustment	Blower Data Collection	0	0	Blower Adjustment	0	0	Blower	Blower Data Collection	0	0
W-1	FF-87	Adjustment			Adjustment	0.108	0.115	Adjustment	Adjustment	0.139	0.147	Adjustment	0.185	0.187	Adjustment	Collection	Steady	0.198	Adjustment	Steady	0.218	Adjustment	Collection	0.198	0.202
S-1	HH-85					0	0			0	0		0	0			0	0		0	0			0	0
S-0.5	HH-85					0.035	0.046			0.062	0.072		0.074	0.079			Steady	0.059		0.065	0.071			0.068	0.074
E-2	Wall					0	0			0	0		0.005	0.014			0	0		0.002	0.007			0	0
SE-1.5	KK-85												0	0			0	0		0	0			0	0
W-3	BB-87																			0	0			0	0
N-1.5	HH-89																			0	0			0	0
NE-1.5	KK-89																			0.001	0.010			0	0
NW-1.5	FF-89																			0	0			0	0
W-2.5	BB-87																							0	0
Test Blower Data Point	Units	Reading			Reading			Reading	Reading			Reading			Reading	Reading			Reading			Reading	Reading		
By-pass Valve Position	% Open	25%	1		50%	1		50%	75%			100%			75%	75%	1		100%	1	Ī	75%	75%		
Inlet Vacuum	in. w.c.	15	1		46	1		45	60			76			60	59	1		72	1	Ī	60	60		
Inlet Pressure Diff.	in. w.c.	0.2			1.0			0.9	1.2			1.8			NM	1.2			1.4			NM	1.2		
Inlet Temp.	°F	72			72			72	72			72			NM	70			74		Ī	NM	74	Vapor Monitor	ing Point Data
Outlet Pressure	in. w.c.	2.0		oring Point Data	0.5		oring Point Data	0.5	1.0		oring Point Data	3.5		ring Point Data	NM	2		ring Point Data	5	Vapor Monitori	0	NM	4	Collection & B	
Outlet Pressure Diff.	in. w.c.	0.5	Coll	ection	1.3	Coll	ection	1.1	1.5	Coll	ection	1.5	Colle	ection	NM	1.6	Coll	ection	1.9	Collec	HOII	NM	1.7	Vapor Sam	ple (10:50)
Outlet Temp.	°F	85	1		100	1		100	110			120			NM	115	1		120	1	Ţ	NM	115		
PID Reading at Blower Discharge	ppm	1.8			0.4			NM	0.4			0.6			NM	0.2			0.4		Ī	NM	0.3		
Vapor Discharge Flow Rate	CFM	40			63			NM	66			65			NM	68			74			NM	70		

Notes:

in. w.c. inches of water column

NM Indicated point not measured

Indicates monitoring point not installed at time of measurement

ppm parts per million

or degrees Fahrenheit

CFM cubic feet per minute

74 indicates vapor flow rate value used for mass removal estimates

Steady indicates vacuum reading did not fluctuate during measurement

TABLE - 1B SSDS Pilot Testing - Log Sheet Summary

GMCH Lockport Facility

 Bldg No.:
 7-East

 Project No.:
 36795-027

November 2012

	Date:	6/6/2012	6/6/	2012	6/6/2012	6/6/	2012	6/7/2012	6/7/	/2012	6/7/2012	6/7/2012	6/7/	2012	6/8/2012	6/8/	2012
Measu	rement Time Range:	14:07	14:13	-14:33	15:00	15:00	-16;30	9:30	9:33	3-9:48	10:20	15:00	15:21	-15:31	9:15	9:10)-9:35
Sub Slab Monitoring Point ID	Proximal Column Reference		Vacuum Reading Low (in.w.c.)	Vacuum Reading High (in.w.c.)		Vacuum Reading Low (in.w.c.)	Vacuum Reading High (in.w.c.)		Vacuum Reading Low (in.w.c.)	Vacuum Reading High (in.w.c.)			Vacuum Reading Low (in.w.c.)	Vacuum Reading High (in.w.c.)		Vacuum Reading Low (in.w.c.)	Vacuum Reading High (in.w.c.)
N-1	HH-35		Steady	0.056		Steady	0.077		Steady	0.077	1		Steady	0.042	1	Steady	0.065
E-1	KK-33		Steady	0.017		Steady	0.023		Steady	0.020			Steady	0.016		Steady	0.020
E-2	MM-33		Steady	0.052		Steady	0.062		Steady	0.064			Steady	0.035		Steady	0.059
NE-2	MM-37		Steady	0.049		Steady	0.056		Steady	0.056			Steady	0.033		Steady	0.026
S-2	HH-29		Steady	0.030		Steady	0.032		Steady	0.032	1		Steady	0.018	1	Steady	0.026
W-2	DD-33	Blower	Steady	0.003	Blower Data	0	0.003	Blower Data	0	0	Blower Data	Blower Data	0	0	Blower Data	0	0
NW-2	DD-37	Adjustment	0	0	Collection	0	0	Collection	0	0	Collection	Collection	0	0	Collection	0	0
N-3	HH-39	3	Steady	0.030		Steady	0.055		Steady	0.032			Steady	0.004		Steady	0.042
NW-1	F-35					Steady	0.053		Steady	0.011	1		0	0	1	0	0
W-1	FF-33					Steady	0.077		Steady	0.060	1		0	0	1	Steady	0.018
S-3	HH27					Steady	0.191		Steady	0.218	1		0	0	1	Steady	0.014
N-4	HH-41										1		0	0	1	0	0
S-2.5	HH-27										1		Steady	0.013	1	Steady	0.023
SW-1	FF-31															0.011	0.032
SW-2	DD-31															0	0
Test Blower Data Point	Units	Reading			Reading			Reading			Reading	Reading			Reading		
By-pass Valve Position	% Open	100%			100%	1		100%	1		100%	100%	1		100%	1	
Inlet Vacuum	in. w.c.	15	1		17	-		17	1		17	7	1		14	1	
Inlet Pressure Diff.	in. w.c.	2.6	1		4.0	†		3.9	1		2.7	1	1		2.7	†	
Inlet Temp.	°F	78	1		79	†		76	1		74	70	1		78	1,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	
Outlet Pressure	in. w.c.	24.0		ring Point Data	28		ring Point Data	28		ring Point Data	28	12		ring Point Data	23		ring Point Data Blower Effluent
Outlet Pressure Diff.	in. w.c.	4	Colle	ection	10	Colle	ection	10	Colle	ection	3.9	1.2	Colle	ection	3		nple (11:30)
Outlet Temp.	°F	92	1			1		100	1		100	110	1		100	1	. , ,
PID Reading at Blower Discharge	ppm	4.6			3.7	1		1.3			NM	1.3			1.7	1	
Vapor Discharge Flow Rate	CFM	115			178]		180			NM	60			98		



in. w.c. inches of water column

NM Indicated point not measured

Indicates monitoring point not installed at time of measurement

ppm parts per million

or degrees Fahrenheit

CFM cubic feet per minute

98

indicates vapor flow rate value used for mass removal estimates

Steady indicates vacuum reading did not fluctuate during measurement

TABLE - 1C

SSDS Pilot Testing - Log Sheet Summary

GMCH Lockport Facility

 Bldg No.:
 7-West

 Project No.:
 36795-027

 November 2012

	Date:	6/11/2012	6/11	/2012	6/11/2012	6/11	/2012	6/11/2012	6/11/	2012	6/11/2012	6/11/2012	6/11	/2012	6/12/2012	6/12	2/2012	6/12/2012	6/12	/2012	6/13/2012	6/13/	2012	6/13/2012	6/13/	2012
Measu	rement Time Range:	10:15	10:16	5-10:30	10;50	10:55	5-11:04	11:15	11:17-	11:26	13:30	15:20	15:24	-15:37	8:40	8:41	1-8:55	11:30	11:29	-11:47	9:30	9:35-	10:02	12:30	12:40-	-12:59
Sub Slab Monitoring Point ID	Proximal Column Reference		Vacuum Reading Low (in.w.c.)	Vacuum Reading High (in.w.c.)		Vacuum Reading Low (in.w.c.)	Vacuum Reading High (in.w.c.)		Vacuum Reading Low (in.w.c.)	Vacuum Reading High (in.w.c.)			Vacuum Reading Low (in.w.c.)	Vacuum Reading High (in.w.c.)		(in.w.c.)	Vacuum Reading High (in.w.c.)									
N-1	L-51		0	0		Steady	0.009		Steady	0.014			Steady	0.009		Steady	0.015		Steady	0.011		Steady	0.015		Steady	0.015
N-3	L-55		0	0		Steady	0.006		0.003	0.007			0	0		Steady	0.004		0	0		Steady	0.012		0	0.004
E-1	N-49		Steady	0.011		Steady	0.036		Steady	0.062			Steady	0.063		Steady	0.071		Steady	0.074		Steady	0.061		Steady	0.074
E-3	S-49		0	0		0	0		0	0			0	0		0	0		0	0		0	0		0	0
SE-2	O-47			0.014		0	0.017		O Charadan	0.056			0	0.069		0	0.044		0	0.023		0	0.012		0	0.035
S-2 W-2	J-45 G-49		Steady	0.014		Steady	0.017		Steady	0.056	-		Steady 0	0.069		Steady Steady	0.044		Steady 0	0.023	-	Steady Steady	0.012		Steady 0	0.035
NW-2	E-53	Blower Adjustment	0	0	Blower Adjustment	0	0	Blower Adjustment	0	0	Blower Data Collection	Blower Data Collection	0	0	Blower Data Collection	0	0.011	Blower Data Collection	0	0.014	Blower Data Collection	0	0.004	Blower Data Collection	0	0
W-1	J-49	Adjustment			Adjustment	0	Ů.	Adjustment	0	0	Collection	Collection	Steady	0.068	Collection	Steady	0.026	Collection	Steady	0.086	Collection	Steady	0.044	Collection	Steady	0.070
E-2	O-49												0	0		0	0		Steady	0.011		0	0		0	0
S-3	J-43												0	0		0	0		0	0		0	0		0	0
NE-1	L-49										1		Steady	0.028		Steady	0.038		Steady	0.038	1	Steady	0.026		Steady	0.032
SSE-2	N-45												0	0		0	0		0	0		0	0		Steady	0.004
W-2.5	E-49																		0	0		Steady	0.001		0	0
SW-2	E-47																		0	0		Steady	0.004		Steady	0.002
SE-1.5	N-45																		0	0		0	0		Steady	0.003
NE-2.5	Q-53																		0	0		0	0		0	0
Test Blower Data Point	Units	Reading			Reading			Reading			Reading	Reading			Reading			Reading			Reading			Reading		
By-pass Valve Position	% Open	25 %	1		50%	1		100%			100%	100%			100%			100%			100%			100%		
Inlet Vacuum	in. w.c.	15			30			51			51	52			52			52			50			50		
Inlet Pressure Diff.	in. w.c.	0.4		_	0.4			1.5			1.4	1.4			1.4			1.4			1.5		_	1.5		
Inlet Temp.	°F	80	Vapor Monito	ring Point Data	80	Vapor Monitor	ring Point Data	80	Vapor Monitori	ng Point Data	80	80	Vapor Monito	ring Point Data	78	Vapor Monito	oring Point Data	81	Vapor Monito	ring Point Data	70	Vapor Monitor		75	Vapor Monitori	ing Point Data
Outlet Pressure	in. w.c.	3		ection	5		ection	14	Colle		13	13		ection	12		ection	12	Colle		13	Collection & B		14	Collection -	
Outlet Pressure Diff.	in. w.c.	0.4		-	0.9			2			1.9	1.9			1.9			1.9			2.0	Vapor Sam	ple (10:30)	2.2		
Outlet Temp.	°F	100	4		115	4		115			115	120	4		115	4		115	4		110	Í	-	115		
PID Reading at Blower Discharge	ppm	1.8			1.8			2.3			2.1	2.7			2.1			2.0			1.6		_	1.6		
Vapor Discharge Flow Rate	CFM	35			51			77			75	74			75			75			78			81		

N	ot	es

in. w.c. inches of water column

NM Indicated point not measured

Indicates monitoring point not installed at time of measurement

ppm parts per million

°F degrees Fahrenheit

CFM cubic feet per minute

indicates vapor flow rate value used for mass removal estimates

indicates vacuum reading did not fluctuate during measurement

1. Vacuum data collected at points E-1 and W-1 after temporary sealing of observed cracks and seeams in existing concrete at areas North, East, and West of the test pit.

Vacuum measurement under temporary sealant was measured at >2.000 inches W.C. (limits of micromanometer) at approximately 6-feet South of column L49.

Attachment 1A

Photo Log Summary

Pre-Design Investigation (PDI) - Sub-Slab Depressurization Systems/ Interim Remedial Measures (IRM) Work Plan

BCP Sites #C932138/932139

GMCH Lockport Facility

200 Upper Mountain Road



Bldg 8 – Construction of suction pit



Bldg 7 West – Completed suction pit



Bldg 8 – Completed suction pit



Bldg 7 East – Completed suction pit



3 Hp Blower System



Micromanometer at Vacuum Monitoring Point



Bldg 7-West Concrete Floor with Cracks and Seams



Bldg 7-West Concrete Floor with Temporary Sealing

Attachment 1B

NYSDEC DAR-1 Area Source Method Analysis

Pre-Design Investigation (PDI) - Sub-Slab Depressurization Systems/ Interim Remedial Measures (IRM) Work Plan

BCP Sites #C932138/932139

GMCH Lockport Facility

200 Upper Mountain Road

Air Guide -1 Review

Area Source Method - SSDS Pilot Testing

GMCH - Lockport Facility

Bldg No: 8
Project No.: 36795-029

s - Bldg side length (ft) 800 (Assumes area source is a square)

Contaminant	No. of Suction Pits (pilot test)	Q (lb/hr)	Q _a (lb/yr)	С _а (µg/m ³)	С _р (µg/m ³)	AGC (µg/m³)	$C_{st} (\mu g/m^3)$	SGC (µg/m3)
Bldg 8	1							
trichloroethene		0.0005	4.38	0.002	0.002	0.5	0.05	14000

P	otential No. of Suction Pits (full-scale)	Q (lb/hr)	Q _a (lb/yr)	$C_a (\mu g/m^3)$	$C_p (\mu g/m^3)$	AGC (μg/m³)	C _{st} (µg/m ³)	SGC (µg/m3)
	10							
	·	0.005	43.80	0.020	0.020	0.5	0.50	14000

Assumptions

Method used to determine the maximum overall actual annual, potential annual, and short term impacts from an area source.

Calculations

 $\begin{array}{ll} Q{:}\;\; Hourly\; Emissions\; (lbs/hr) \\ Q_{a:}\;\; Annual\; Emissions\; Rate\; (lbs/yr) \end{array}$

s: Building Side Dimension (feet)

SGC: Short-Term Guidance Concentrations - Guidance Values AGC: Annual Guidance Concentrations - Guidance Valves

μg/m3 micro-grams per cubic meter

Area Source Method - SSDS Pilot Testing

GMCH - Lockport Facility

Bldg No: 7
Project No.: 36795-027

s - Bldg side length (ft) 1200 (Assumes area source is a square)

Contaminant	No. of Suction Pits (pilot test)	Q (lb/hr)	Q _a (lb/yr)	C _a (μg/m ³)	С _p (µg/m ³)	AGC (μg/m³)	C _{st} (µg/m ³)	SGC (µg/m3)
Bldg 7E	1							
cis, 1-2 dichloroethene		0.001	8.76	0.0019	0.0019	63.0	0.05	NGV
trichloroethene		0.001	8.76	0.0019	0.0019	0.5	0.05	14000
tetrachloroethene		0.00061	5.34	0.0012	0.0012	1.0	0.03	1000
Bldg 7W	1							
cis, 1-2 dichloroethene		0.00021	1.84	0.00040	0.00040	63.0	0.01	NGV
tetrachloroethene		0.00145	12.7	0.0028	0.0028	1.0	0.07	1000

Totals	2							
cis, 1-2 dichloroethene		0.00121	10.6	0.0023	0.0023	63.0	0.06	NGV
trichloroethene		0.001	8.76	0.0019	0.0019	0.5	0.05	14000
tetrachloroethene		0.00206	18.0	0.0040	0.0040	1.0	0.10	1000

Potential No. of Suction Pits (full-scale)	Q (lb/hr)	Q _a (lb/yr)	C _a (μg/m ³)	C _p (μg/m ³)	AGC (μg/m³)	C _{st} (µg/m ³)	SGC (µg/m3)
9							1
	0.009	78.84	0.017	0.017	63.0	0.43	NGV
	0.009	78.84	0.017	0.017	0.5	0.43	14000
	0.00549	48.09	0.011	0.011	1.0	0.26	1000
·					•		
10							
	0.0021	18.40	0.0040	0.0040	63.0	0.10	NGV
	0.0145	127.02	0.028	0.028	1.0	0.70	1000
19							
	0.02299	201.39	0.044	0.044	63.0	1.11	NGV
	0.019	166.44	0.037	0.037	0.5	0.91	14000
	0.03914	342.87	0.075	0.075	1.0	1.88	1000

Assumptions

Method used to determine the maximum overall actual annual, potential annual, and short term impacts from an area source.

Calculations

Q: Hourly Emissions (lbs/hr)
Qa: Annual Emissions Rate (lbs/yr)
s: Building Side Dimension (feet)

SGC: Short-Term Guidance Concentrations - Guidance Values AGC: Annual Guidance Concentrations - Guidance Valves

NGV: No Guidance Value

μg/m³ micro-grams per cubic meter

Attachment 1C

Chain of Custody Documentation Final Laboratory Reports

Pre-Design Investigation (PDI) - Sub-Slab Depressurization Systems/ Interim Remedial Measures (IRM) Work Plan

BCP Sites #C932138/932139

GMCH Lockport Facility

200 Upper Mountain Road



Analytical Report Cover Page

Haley & Aldrich

For Lab Project # 12:2412
Issued June 7, 2012
Re-Issued June 18, 2012
This report contains a total of 7 pages

This project has been amended to report the sample with "J" flags, per client request.

The reported results relate only to the samples as they have been received by the laboratory.

Any noncompliant QC parameters having impact on the data are flagged or documented on the final report.

All soil/sludge samples have been reported on a dry weight basis, unless qualified "reported as received". Other solids are reported as received.

Each page of this document is part of a multipage report. This document may not be reproduced except in its entirety, without the prior consent of Paradigm Environmental Services, Inc.

The Chain of Custody provides additional information, including compliance with sample condition requirements upon receipt. Sample condition requirements are defined under the 2003 NELAC Standard, sections 5.5.8.3.1 and 5.5.8.3.2. Aliquots separated for certain tests, such as TCLP, are indicated on the Chain of Custody and final reports with an "A" suffix.

NYSDOH ELAP does not certify for all parameters. Paradigm Environmental Services or the indicated subcontracted laboratory does hold certification for all analytes where certification is offered by ELAP unless otherwise specified.

Data qualifiers are used, when necessary, to provide additional information about the data. This information may be communicated as a flag or as text at the bottom of the report. Please refer to the following list of frequently used data flags and their meaning:

[&]quot;<" = analyzed for but not detected at or above the reporting limit.

[&]quot;E" = Result has been estimated, calibration limit exceeded.

[&]quot;Z" = See case narrative.

[&]quot;D" = Duplicate results outside QC limits. May indicate a non-homogenous matrix.

[&]quot;M" = Matrix spike recoveries outside OC limits. Matrix bias indicated.

[&]quot;B" = Method blank contained trace levels of analyte. Refer to included method blank report.



Volatile Analysis Report for Air

Client: Haley & Aldrich

Client Job Site:

N/A

Lab Project Number: 12:2412

Lab Sample Number: 12:2412-01

Client Job Number: Field Location:

36795-027

B8 PTEFF-20120606-1050

Date Sampled:

06/06/2012

Field ID Number: Sample Type:

N/A Air

Date Received: Date Analyzed: 06/07/2012 06/08/2012

Date Reissued:

06/18/2012

Compound	Results in mg / m3	Compound	Results in mg / m3
Bromodichloromethane	< 2.00	1,1-Dichloroethene	< 2.00
Bromoform	< 5.00	cis-1,2-Dichloroethene	< 2.00
Bromomethane	< 2.00	trans-1,2-Dichloroethene	< 2.00
Carbon Tetrachloride	< 2.00	1,2-Dichloropropane	< 2.00
Chlorobenzene	< 2.00	cis-1,3-Dichloropropene	< 2.00
Chloroethane	< 2.00	trans-1,3-Dichloropropene	< 2.00
2-Chloroethyl vinyl Ether	< 10.0	Methylene chloride	< 5.00
Chloroform	< 2.00	1,1,2,2-Tetrachloroethane	< 2.00
Chloromethane	< 2.00	Tetrachloroethene	< 2.00
Dibromochloromethane	< 2.00	1,1,1-Trichloroethane	< 2.00
1,2-Dichlorobenzene	< 2.00	1,1,2-Trichloroethane	< 2.00
1,3-Dichlorobenzene	< 2.00	Trichloroethene	J 1.82
1,4-Dichlorobenzene	< 2.00	Trichlorofluoromethane	< 2.00
1,1-Dichloroethane	< 2.00	Vinyl chloride	< 2.00
1,2-Dichloroethane	< 2.00		

ELAP Number 10958

Method: EPA 8260B

Data File: V97832.D

Modified for Tedlar Bag

Comments: mg / m3 = milligram per cubic meter

Signature:

Bruce Hoogesteger: Technical Director



Volatile Analysis Report for Air

Client: Haley & Aldrich

Client Job Site:

N/A

Lab Project Number: 12:2412

Lab Sample Number: LRB 06/07

Client Job Number:

36795-027

Field Location:

N/A

Date Sampled:

N/A

Field ID Number:

N/A

Date Received:

N/A

Sample Type:

Air

Date Analyzed:

06/07/2012

Compound	Results in mg / m3	Compound	Results in mg / m3
Bromodichloromethane	< 2.00	1,1-Dichloroethene	< 2.00
Bromoform	< 5.00	cis-1,2-Dichloroethene	< 2.00
Bromomethane	< 2.00	trans-1,2-Dichloroethene	< 2.00
Carbon Tetrachloride	< 2.00	1,2-Dichloropropane	< 2.00
Chlorobenzene	< 2.00	cis-1,3-Dichloropropene	< 2.00
Chloroethane	< 2.00	trans-1,3-Dichloropropene	< 2.00
2-Chloroethyl vinyl Ether	< 10.0	Methylene chloride	< 5.00
Chloroform	< 2.00	1,1,2,2-Tetrachloroethane	< 2.00
Chloromethane	< 2.00	Tetrachloroethene	< 2.00
Dibromochloromethane	< 2.00	1,1,1-Trichloroethane	< 2.00
1,2-Dichlorobenzene	< 2.00	1,1,2-Trichloroethane	< 2.00
1,3-Dichlorobenzene	< 2.00	Trichloroethene	< 2.00
1,4-Dichlorobenzene	< 2.00	Trichlorofluoromethane	< 2.00
1,1-Dichloroethane	< 2.00	Vinyl chloride	< 2.00
1,2-Dichloroethane	< 2.00		

ELAP Number 10958

Method: EPA 8260B Modified for Tedlar Bag Data File: V97819.D

Comments: mg / m3 = milligram per cubic meter

Signature:

Bruce Hoogesteger: Technical Director



Client: Haley & Aldrich

Client Job Site:

N/A

Lab Project Number: 12:2412

Lab Sample Number: LCS 06/07

SDG#: N/A

Client Job Number: 36795-027

N/A

Date Sampled: Date Received: N/A N/A

Field Location: Field ID Number: Sample Type:

N/A Air

Date Analyzed:

06/07/2012

Spiked Compound	Blank Results	LCS Spiked	LCS Results	LCS Percent	MSD Spiked	MSD Results	MSD Percent	MS / MSD
	in mg / m3	in mg/m3	in mg/m3	Recovery	in mg/m3	in mg / m3	Recovery	% RPD
1,1-Dichloroethene	< 4.00	100	89.6	89.6	N/A	N/A	N/A	N/A
Benzene	< 4.00	100	94.9	94.9	N/A	N/A	N/A	N/A
Trichloroethene	< 4.00	100	88.7	88.7	N/A	N/A	N/A	N/A
Toluene	< 4.00	100	90.9	90.9	N/A	N/A	N/A	N/A
Chlorobenzene	< 4.00	100	90.5	90.5	N/A	N/A	N/A	N/A
								•
						:		
								1

ELAP Number 10958

Data File: V97819.D

Data File: V97818.D



 \mathbf{C}

Volatile Analysis Report for Air

Client: Haley & Aldrich

Client Job Site:

N/A

Lab Project Number: 12:2412

SDG Group:

N/A

Client Job Number: 36795-027

Date Sampled: Date Received: 06/06/2012 06/07/2012

Sample Type:

Air

Date Analyzed:

06/07/2012

Lab Sample Number	Field Number	Field Location	Pentafluorobenzene % Recovery	1,2-Dichloroethane-d4 % Recovery	Toluene-d8 % Recovery	4-BFB % Recovery
LCS 06/07	N/A	N/A	104	99.8	106	102
LRB 06/07	N/A	N/A	97.7	103	102	94.8
12:2412-01	N/A	B8PTEFF-20120606-1050	108	119	96.9	96.1
]		

ELAP Number 10958

Method: EPA 8260B



Volatile Analysis QC Limits

Limits effective:

Jun 05,2012

Through:

Jun 30,2012

Spiked Compound	Soil Sp	ike Limits	Soil %	RPD Limits	Water Sp	ike Limits	Water % RP	D Limits
	Lower %	Upper %	Lower %	Upper %	Lower %	Upper %	Lower %	Upper %
1,1-Dichloroethene	67.4	120	0	29.2	70.4	117	0	21.8
Benzene	82.7	107	0	15.4	81.0	110	0	15.1
Trichloroethene	82.2	106	0	12.0	78.2	112	0	16.0
Toluene	81.9	104	0	14.2	79.2	110	0	16.6
Chlorobenzene	81.1	104	0	16.5	78.3	109	0	14.5
Surrogate*	Soil Surre	ogate Limits		7.5	Water Surr	ogate Limits		
	Lower %	Upper %			Lower %	Upper %		
Pentafluorobenzene	80.0	120			80.0	120		
1,2-Dichloroethane-d4	80.0	120]		80.0	120		
Toluene-D8	80.0	120			80.0	120		
4-Bromofluorobenzene	80.0	120			80.0	120		

ELAP Number 10958 Method: EPA 8260B

^{* -} Due to an equipment change, generic limits are being used for surrogates until enough data are collected to generate new limits.

CHAIN OF CUSTODY

$ \mathbb{P}$ \mathbb{P} \mathbb{A}	RADIG	M			REPORT T							NVOIC	E TO:								
			COMPAN	Y: Haley	AAld	rich	of N	17	COMPAN	Y: (San	1e 🕥				LAB PRO	DJECT #:	CLIE	NT PROJ	ECT#:	77
			ADDRESS	TO TOWN	Centr	e D	r.		ADDRESS	3:						112.	, 9 ₁₁	30	<i>o</i> 145	-0	127
		P	CITY: Q	Haley 50 Town schester	STA	ATE: N	ZIP:	4623	CITY:				STAT	Ε:	ZIP:	TURNAR	OUND TIM	E: (WORKI	(G DAYS		
			PHONE	(321 4	241 FAX:				PHONE:			F	XX:			7			STD	(OTHER
ROJECT NAME/SIT	E NAME:		ATTN: -	Denis		ley		- V-1100-1100-211-3-111-	ATTN:			auswrum + assess			······································	1	2	3	X 5		ining (Managaran (Managaran)
			COMMEN.		V-100		- 100		<u> </u>		*******			****		Touch	ation #			<u></u> 80	
										RE	QUES	TED A	NALY	SIS		Rance	auon #				
DATE	TIME	C O M P O S I T E	G R A B		PLE LOCATION/			M A T R I X	CONNUTMABIENRS	20078/201							ARKS		1	ADIGM LE NU	I LAB MBER
6/6/12	1050	***************************************	X	B8 PT	EFF-20	1206	06-105	d Air	_ (X					Chlo	Xihat	ed Vo	ics	OL		
2																					
}																					
		ATTACA			42 - 42 - 43									11						\Box	
)											11		$\top \top$								
)					4						$\dashv \dashv$		$\top \top$	\Box	D.Ba	10	. On	allan	,		
7					<u></u>			,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,				77	11		1/1/2	LDC hen g	18-60	12			
}		14101									+	+	1-+			amp				\vdash	
<u> </u>											+		++		10	<u>v mga</u>	<u>LL CU</u> L	<u>acc</u>		$\vdash \vdash$	
0													++		0/	26 (A	<u> </u>				
*LAB USE C	NLY BELO	W THIS LII	VE**												1	-1-	20 11				
ample Conditi	on: Per NELA Receipt Par		41/242/2		Compliance			<u> </u>													
				Y I	N		4		$\cdot \cdot (\cdot)$	λ	1 h	6	/6/	12	105	0		ı			
omments:	Container T	r Ba	9_	·	"—		Sample	d By	7//	manufacture (minute)	1		Date	/Time	(53)		T ot	al Cost:			
omments:	Preservation	on:	(Υ 🔲	N		Relipqui	ished B	<u>U</u> sanianianianianianianianianianianianiania			kir		//2- /Time	(5)	93	-		***************************************		
omments:	Holding Tir 子の	ne: <i>h/s</i>		Υ 🔲	N		Receive	3		")			211	了) Time		303) P.I.	F. [
omments:	Poom Temperatu	re: Semper A	towe	_ Y	N		Receive	d @ Lai	b By	4	20	201	Date	/Time	12	155	32_				



Analytical Report Cover Page

Haley & Aldrich

For Lab Project # 12:2443
Issued June 12, 2012
Re-Issued June 18, 2012
This report contains a total of 7 pages

This project has been amended to report the sample with "J" flags, per client request.

The reported results relate only to the samples as they have been received by the laboratory.

Any noncompliant QC parameters having impact on the data are flagged or documented on the final report.

All soil/sludge samples have been reported on a dry weight basis, unless qualified "reported as received". Other solids are reported as received.

Each page of this document is part of a multipage report. This document may not be reproduced except in its entirety, without the prior consent of Paradigm Environmental Services, Inc.

The Chain of Custody provides additional information, including compliance with sample condition requirements upon receipt. Sample condition requirements are defined under the 2003 NELAC Standard, sections 5.5.8.3.1 and 5.5.8.3.2. Aliquots separated for certain tests, such as TCLP, are indicated on the Chain of Custody and final reports with an "A" suffix.

NYSDOH ELAP does not certify for all parameters. Paradigm Environmental Services or the indicated subcontracted laboratory does hold certification for all analytes where certification is offered by ELAP unless otherwise specified.

Data qualifiers are used, when necessary, to provide additional information about the data. This information may be communicated as a flag or as text at the bottom of the report. Please refer to the following list of frequently used data flags and their meaning:

[&]quot;<" = analyzed for but not detected at or above the reporting limit.

[&]quot;E" = Result has been estimated, calibration limit exceeded.

[&]quot;Z" = See case narrative.

[&]quot;D" = Duplicate results outside QC limits. May indicate a non-homogenous matrix.

[&]quot;M" = Matrix spike recoveries outside QC limits. Matrix bias indicated.

[&]quot;B" = Method blank contained trace levels of analyte. Refer to included method blank report.

179 Lake Avenue Rochester, New York 14608 (585) 647 - 2530 FAX (585) 647 - 3311

Volatile Analysis Report for Air

Client: Haley & Aldrich

Client Job Site:

N/A

Lab Project Number: 12:2443

Lab Sample Number: 12:2443-01

Client Job Number:

Field Location:

BTEPTEFF-20120608-1130

Date Sampled:

06/08/2012

Field ID Number: Sample Type:

N/A Air

36795-027

Date Received:

06/11/2012

Date Analyzed:

06/11/2012

Date Reissued:

06/18/2012

Compound	Results in mg / m3	Compound	Results in mg / m3
Bromodichloromethane	< 2.00	1,1-Dichloroethene	< 2.00
Bromoform	< 5.00	cis-1,2-Dichloroethene	2.83
Bromomethane	< 2.00	trans-1,2-Dichloroethene	< 2.00
Carbon Tetrachloride	< 2.00	1,2-Dichloropropane	< 2.00
Chlorobenzene	< 2.00	cis-1,3-Dichloropropene	< 2.00
Chloroethane	< 2.00	trans-1,3-Dichloropropene	< 2.00
2-Chloroethyl vinyl Ether	< 10.0	Methylene chloride	< 5.00
Chloroform	< 2.00	1,1,2,2-Tetrachloroethane	< 2.00
Chloromethane	< 2.00	Tetrachloroethene	J 1.67
Dibromochloromethane	< 2.00	1,1,1-Trichloroethane	< 2.00
1,2-Dichlorobenzene	< 2.00	1,1,2-Trichloroethane	< 2.00
1,3-Dichlorobenzene	< 2.00	Trichloroethene	2.84
1,4-Dichlorobenzene	< 2.00	Trichlorofluoromethane	< 2.00
1,1-Dichloroethane	< 2.00	Vinyl chloride	< 2.00
1,2-Dichloroethane	< 2.00		

ELAP Number 10958

Method: EPA 8260B

Data File: V97893.D

Modified for Tedlar Bag

Comments: mg / m3 = milligram per cubic meter

Signature:



Client: Haley & Aldrich

Client Job Site: N/A

Lab Project Number: 12:2443

Lab Sample Number: LRB 06/11

Client Job Number: 36795-027

N/A

Date Sampled:

N/A

Field Location: Field ID Number:

N/A

Date Received:

N/A

Sample Type: Air

Date Analyzed:

06/11/2012

Compound	Results in mg / m3	Compound	Results in mg / m3
Bromodichloromethane	< 2.00	1,1-Dichloroethene	< 2.00
Bromoform	< 5.00	cis-1,2-Dichloroethene	< 2.00
Bromomethane	< 2.00	trans-1,2-Dichloroethene	< 2.00
Carbon Tetrachloride	< 2.00	1,2-Dichloropropane	< 2.00
Chlorobenzene	< 2.00	cis-1,3-Dichloropropene	< 2.00
Chloroethane	< 2.00	trans-1,3-Dichloropropene	< 2.00
2-Chloroethyl vinyl Ether	< 10.0	Methylene chloride	< 5.00
Chloroform	< 2.00	1,1,2,2-Tetrachloroethane	< 2.00
Chloromethane	< 2.00	Tetrachloroethene	< 2.00
Dibromochloromethane	< 2.00	1,1,1-Trichloroethane	< 2.00
1,2-Dichlorobenzene	< 2.00	1,1,2-Trichloroethane	< 2.00
1,3-Dichlorobenzene	< 2.00	Trichloroethene	< 2.00
1,4-Dichlorobenzene	< 2.00	Trichlorofluoromethane	< 2.00
1,1-Dichloroethane	< 2.00	Vinyl chloride	< 2.00
1,2-Dichloroethane	< 2.00	•	

ELAP Number 10958

Method: EPA 8260B Modified for Tedlar Bag Data File: V97892.D

Comments: mg / m3 = milligram per cubic meter

Signature:

Bruce Hoogesteger: Technical Director



Client: Haley & Aldrich

Client Job Site:

N/A

Lab Project Number: 12:2443 Lab Sample Number: LCS 06/11

SDG#: N/A

Client Job Number: 36795-027

Field Location: Field ID Number:

N/A N/A Date Sampled: **Date Received:**

N/A N/A

Sample Type:

Air

Date Analyzed:

06/11/2012

Blank Results	LCS Spiked	LCS Results	LCS Percent			MSD Percent	MS / MSD
in mg/m3	in mg/m3	in mg / m3	Recovery	in mg/m3	in mg / m3	Recovery	% RPD
< 4.00	100	108	108	N/A	N/A	N/A	N/A
< 4.00	100	102	102	N/A	N/A	N/A	N/A
< 4.00	100	101	101	N/A	N/A	N/A	N/A
< 4.00	100	102	102	N/A	N/A	N/A	N/A
< 4.00	100	100	100	N/A	N/A	N/A	N/A
				·			
					:		
	in mg / m3 < 4.00 < 4.00 < 4.00 < 4.00 < 4.00	in mg / m3 in mg / m3 < 4.00 100 < 4.00 100 < 4.00 100 < 4.00 100 < 4.00 100	in mg / m3 in mg / m3 in mg / m3 < 4.00	in mg / m3 in mg / m3 in mg / m3 Recovery < 4.00	in mg / m3 in mg / m3 in mg / m3 Recovery in mg / m3 < 4.00	in mg / m3 in mg / m3 in mg / m3 Recovery in mg / m3 in mg / m3 < 4.00	in mg / m3 in mg / m3 in mg / m3 Recovery in mg / m3 in mg / m3 Recovery < 4.00

ELAP Number 10958

Data File: V97892.D

Data File: V97891.D



 \mathbf{C}

Volatile Analysis Report for Surrogate Recoveries

Client: Haley & Aldrich

Client Job Site:

N/A

Lab Project Number: 12:2443

SDG Group:

N/A

Client Job Number: 36795-027

Date Sampled:

06/08/2012

Date Received:

06/11/2012

Sample Type:

Air

Date Analyzed:

06/11/2012

Lab Sample Number	Field Number	Field Location	Pentafluorobenzene % Recovery	1,2-Dichloroethane-d4 % Recovery	Toluene-d8 % Recovery	4-BFB % Recovery
LCS 06/11	N/A	MW-1	97.7			·
				98.2	100	100
LRB 06/11	N/A	MW-2	106	112	105	100
12:2443-01	N/A	BTEPTEFF-20120608-1130	96.3	106	95.1	91.0
]
				1		
						1
				·		
					<u> </u>	

ELAP Number 10958



Volatile Analysis QC Limits

Limits effective:

Jun 05,2012

Through:

Jun 30,2012

Soil Sp	ike Limits	Soil %	RPD Limits	Water Sp	ike Limits	Water % RF	D Limits
Lower %	Upper %	Lower %	Upper %	Lower %	Upper %	Lower %	Upper %
67.4	120	0	29.2	70.4	117	0	21.8
82.7	107	0	15.4	81.0	110	0	15.1
82.2	106	0	12.0	78.2	112	0	16.0
81.9	104	0	14.2	79.2	110	0	16.6
81.1	104	0	16.5	78.3	109	0	14.5
Soil Surre	ogate Limits			Water Surr	ogate Limits		
Lower %	Upper %			Lower %	Upper %		
80.0	120			80.0	120		
80.0	120			80.0	120		
80.0	120			80.0	120		
80.0	120			80.0	120		
	Lower % 67.4 82.7 82.2 81.9 81.1 Soil Surrough	120 82.7 107 82.2 106 81.9 104 81.1 104	Lower % Upper % Lower % 67.4 120 0 82.7 107 0 82.2 106 0 81.9 104 0 81.1 104 0 Soil Surrogate Limits Lower % Upper % 80.0 120 80.0 120 80.0 120 80.0 120	Lower % Upper % Lower % Upper % 67.4 120 0 29.2 82.7 107 0 15.4 82.2 106 0 12.0 81.9 104 0 14.2 81.1 104 0 16.5 Soil Surrogate Limits Lower % Upper % 80.0 80.0 120 80.0 120 80.0 120	Lower % Upper % Lower % Upper % Lower % 67.4 120 0 29.2 70.4 82.7 107 0 15.4 81.0 82.2 106 0 12.0 78.2 81.9 104 0 14.2 79.2 81.1 104 0 16.5 78.3 Soil Surrogate Limits Water Surr Lower % Upper % Upper % 80.0 80.0 120 80.0 80.0 120 80.0 80.0 80.0 80.0	Lower % Upper % Lower % Upper % Lower % Upper % 67.4 120 0 29.2 70.4 117 82.7 107 0 15.4 81.0 110 82.2 106 0 12.0 78.2 112 81.9 104 0 14.2 79.2 110 81.1 104 0 16.5 78.3 109 Soil Surrogate Limits Lower % Upper % Water Surrogate Limits Lower % Upper % 80.0 120 80.0 120 80.0 120 80.0 120 80.0 120 80.0 120	Lower % Upper % Lower % Upper % Lower % Upper % Lower % 67.4 120 0 29.2 70.4 117 0 82.7 107 0 15.4 81.0 110 0 82.2 106 0 12.0 78.2 112 0 81.9 104 0 14.2 79.2 110 0 81.1 104 0 16.5 78.3 109 0 Soil Surrogate Limits Lower % Upper % Upper % Upper % Upper % 80.0 120 80.0 120 80.0 120 80.0 120 80.0 120 80.0 120

ELAP Number 10958 Method: EPA 8260B

^{* -} Due to an equipment change, generic limits are being used for surrogates until enough data are collected to generate new limits.

CHAIN OF CUSTODY

PARADIGM REPORT TO:							:TO:									
COMPANY: HALEY & ALDRICH OF NY		COMPAN	Y:	<u> (</u> Sa	ame	7			Manager Division	LAB PROJ	ECT#:	CLIENT	PRO	JECT ;	t:	
COMPANY: HALBY & ALONICH OF NY ADDRESS: 200 TOWN CENTIE DAWS CITY: ROCHEST & NY PHONE: FAX:	<u> </u>	ADDRESS	S:							12:0	2443	36	79	5-	027	.
CITY: ROCHES STATE: ZIP	, 2	CITY:					STAT	E:	ZI	P: TURNARO	und time: (wo	ORKING	DAYS	(12		ヿ
PHONE: FAX:	, <u> </u>	PHONE:			<u> </u>	FA	X:				day pe	, Ja St	ນ D	W1-	AB OTHE	H G FR
		ATTN:									2] 3 X	7 ₅		Ţ	movement)
COMMENTS:		<u> </u>		······································				······································			80000-000				<u> </u>	
,					en 64 alla lea	- Px A I		/OIO		Quota	tion#					(Arres
		_	T I	EQUI	=31E	:UAI	NAL	(313					September 1			12002
DATE TIME O A SAMPLE LOCATION/FIELD ID B I T E	M A T R I X	C O N T A I N E R R S	Voc/8260B							REMA	RKS	-			M LAB UMBER	
6/8/12 1130 - X BTEPTER - 20120600 - 1130	ALR	l	X							CHLORINA	ED Vocs		1			
			П				\Box								П	
			\Box	_		\top	+ + +		T	N			\top	1	一十	_
						\dashv	+		+				+	╁	一十	\dashv
	-		-	-	╂┯┼	\dashv	+						╁	╫	┝┼	-
	1		\vdash		╀╌┼		+		\vdash			_	_	-	┝	_
			\sqcup		\vdash		\bot		\bot				_	<u> </u>	$\vdash \vdash$	_
															$\sqcup \! \! \! \! \! \! \! \! \! \! \! \! \! \! \! \! \! \! \!$	
0																
*LAB USE ONLY BELOW THIS LINE**																
ample Condition: Per NELAC/ELAP 210/241/242/243/244 Receipt Parameter NELAC Compliance	\supset	7														
Container Type: Y X N	PA	Dr	a V	~			6	/81/	12	11:30		Ţ				_
omments: Sample	ed By	7/1	1				Date	/Time		^	Total Co	ost:				
Preservation: V/A Y N Reling	uished B	ela XI	2			····	6/ Date	<u>/ () / (</u> e/Time	<u> </u>	11:30 Z:10						
Holding Time: Y N N Receiv		10		22		· S		//c /Time	>_	1210	P.I.F.			7		
omments: Y N Receiv	ed @ La	efth 6 By	<u>_ C</u>	L 4-1	<u>on</u>	d		(<i>o)</i> / / / e/Time	112	1240				-		



Analytical Report Cover Page

Haley & Aldrich

For Lab Project # 12:2522 Issued June 18, 2012 This report contains a total of 8 pages

The reported results relate only to the samples as they have been received by the laboratory.

Any noncompliant QC parameters having impact on the data are flagged or documented on the final report.

All soil/sludge samples have been reported on a dry weight basis, unless qualified "reported as received". Other solids are reported as received.

Each page of this document is part of a multipage report. This document may not be reproduced except in its entirety, without the prior consent of Paradigm Environmental Services, Inc.

The Chain of Custody provides additional information, including compliance with sample condition requirements upon receipt. Sample condition requirements are defined under the 2003 NELAC Standard, sections 5.5.8.3.1 and 5.5.8.3.2. Aliquots separated for certain tests, such as TCLP, are indicated on the Chain of Custody and final reports with an "A" suffix.

NYSDOH ELAP does not certify for all parameters. Paradigm Environmental Services or the indicated subcontracted laboratory does hold certification for all analytes where certification is offered by ELAP unless otherwise specified.

Data qualifiers are used, when necessary, to provide additional information about the data. This information may be communicated as a flag or as text at the bottom of the report. Please refer to the following list of frequently used data flags and their meaning:

[&]quot;<" = analyzed for but not detected at or above the reporting limit.

[&]quot;E" = Result has been estimated, calibration limit exceeded.

[&]quot;Z" = See case narrative.

[&]quot;D" = Duplicate results outside QC limits. May indicate a non-homogenous matrix.

[&]quot;M" = Matrix spike recoveries outside QC limits. Matrix bias indicated.

[&]quot;B" = Method blank contained trace levels of analyte. Refer to included method blank report.



Client: Haley & Aldrich

Client Job Site: N/A Lab Project Number: 12:2522

Lab Sample Number: 12:2522-01

Client Job Number: 36795-027

B7WPTEFF-20120613-1030

Date Sampled:

06/13/2012

Field Location: Field ID Number:

N/A

Date Received:

06/14/2012

Sample Type:

ELAP Number 10958

Air

Date Analyzed:

06/14/2012

Compound	Results in mg / m3	Compound	Results in mg / m3
Bromodichloromethane	< 0.500	1,1-Dichloroethene	< 0.500
Bromoform	< 2.50	cis-1,2-Dichloroethene	0.712
Bromomethane	< 0.500	trans-1,2-Dichloroethene	< 0.500
Carbon Tetrachloride	< 0.500	1,2-Dichloropropane	< 0.500
Chlorobenzene	< 0.500	cis-1,3-Dichloropropene	< 0.500
Chloroethane	< 0.500	trans-1,3-Dichloropropene	< 0.500
2-Chloroethyl vinyl Ether	< 2.50	Methylene chloride	< 2.50
Chloroform	< 0.500	1,1,2,2-Tetrachloroethane	< 0.500
Chloromethane	< 0.500	Tetrachloroethene	4.97
Dibromochloromethane	< 0.500	1,1,1-Trichloroethane	< 0.500
1,2-Dichlorobenzene	< 0.500	1,1,2-Trichloroethane	< 0.500
1,3-Dichlorobenzene	< 0.500	Trichloroethene	< 0.500
1,4-Dichlorobenzene	< 0.500	Trichlorofluoromethane	< 0.500
1,1-Dichloroethane	< 0.500	Vinyl chloride	< 0.500
1,2-Dichloroethane	< 0.500	-	

Method: EPA 8260B

Data File: V98017.D

Modified for Tedlar Bag

Comments: mg / Kg = milligram per Kilogram

Signature:



Client: Haley & Aldrich

Client Job Site:

N/A

Lab Project Number: 12:2522

Lab Sample Number: LRB

Client Job Number:

Field Location:

36795-027 N/A

Date Sampled:

N/A

Field ID Number:

N/A

Date Received:

N/A

Date Analyzed: Sample Type: Air

06/14/2012

Compound	Results in mg / m3	Compound	Results in mg / m3
Bromodichloromethane	< 0.500	1,1-Dichloroethene	< 0.500
Bromoform	< 2.50	cis-1,2-Dichloroethene	< 0.500
Bromomethane	< 0.500	trans-1,2-Dichloroethene	< 0.500
Carbon Tetrachloride	< 0.500	1,2-Dichloropropane	< 0.500
Chlorobenzene	< 0.500	cis-1,3-Dichloropropene	< 0.500
Chloroethane	< 0.500	trans-1,3-Dichloropropene	< 0.500
2-Chloroethyl vinyl Ether	< 2.50	Methylene chloride	< 2.50
Chloroform	< 0.500	1,1,2,2-Tetrachloroethane	< 0.500
Chloromethane	< 0.500	Tetrachloroethene	< 0.500
Dibromochloromethane	< 0.500	1,1,1-Trichloroethane	< 0.500
1,2-Dichlorobenzene	< 0.500	1,1,2-Trichloroethane	< 0.500
1,3-Dichlorobenzene	< 0.500	Trichloroethene	< 0.500
1,4-Dichlorobenzene	< 0.500	Trichlorofluoromethane	< 0.500
1,1-Dichloroethane	< 0.500	Vinyl chloride	< 0.500
1,2-Dichloroethane	< 0.500		

ELAP Number 10958

Method: EPA 8260B

Data File: V97998b.D

Modified for Tedlar Bag

Comments: mg / m3 = milligram per cubic meter

Signature:

Bruce Hoogesteger: Technical Director



Volatile Analysis Report for Non-potable Water

Client: Haley & Aldrich

Client Job Site:

N/A

Lab Project Number: 12:2522 Lab Sample Number: LCS

SDG#: N/A

Client Job Number: 36795-027

Field Location:

N/A

N/A

Date Sampled: **Date Received:**

N/A N/A

Field ID Number: Sample Type:

Water

Date Analyzed:

06/14/2012

Spiked Compound	Blank Results	LCS Spiked	LCS Results	LCS Percent	MSD Spiked		MSD Percent	MS / MSD
	in mg / m3	in mg / m3	in mg / m3	Recovery	in mg / m3	in mg / m3	Recovery	% RPD
1,1-Dichloroethene	< 0.500	25.0	22.7	90.8	N/A	N/A	N/A	N/A
Benzene	< 0.500	25.0	21.4	85.6	N/A	N/A	N/A	N/A
Trichloroethene	< 0.500	25.0	21.0	84.0	N/A	N/A	N/A	N/A
Toluene	< 0.500	25.0	21.3	85.2	N/A	N/A	N/A	N/A
Chlorobenzene	< 0.500	25.0	21.3	85.2	N/A	N/A	N/A	N/A
:								
					Ŀ			

ELAP Number 10958

Data File: V97998b.D

Data File: V97997a.D



Volatile Analysis Report for Surrogate Recoveries

Client: Haley & Aldrich

Client Job Site:

N/A

Lab Project Number: 12:2522

SDG Group:

N/A

Client Job Number: 36795-027

Date Sampled: Date Received:

07/27/2009 07/28/2009

06/14/2012 Sample Type: Water Date Analyzed:

Lab Sample Number	Field Number	Field Location	Pentafluorobenzene	1,2-Dichloroethane-d4	Toluene-d8	4-BFB
	<u> L</u>		% Recovery	% Recovery	% Recovery	% Recovery
LCS 06/14	N/A	N/A	95.0	88.2	88.3	83.5
LRB 06/14	N/A	N/A	114	108	106	98.7
12:2522-01	N/A	B7WPTEFF-20120613-1030	93.0	83.4	90.3	89.6

ELAP Number 10958



Volatile Analysis QC Limits

Limits effective:

Jun 05,2012

Through:

Jun 30,2012

Spiked Compound	Soil Sp	ike Limits	Soil %	RPD Limits	Water Spike Limits		Water % RF	D Limits
	Lower %	Upper %	Lower %	Upper %	Lower %	Upper %	Lower %	Upper %
1,1-Dichloroethene	67.4	120	0	29.2	70.4	117	0	21.8
Benzene	82.7	107	0	15.4	81.0	110	0	15.1
Trichloroethene	82.2	106	0	12.0	78.2	112	0	16.0
Toluene	81.9	104	0	14.2	79.2	110	0	16.6
Chlorobenzene	81.1	104	0	16.5	78.3	109	0	14.5
Surrogate*	Soil Surrogate Limits			Water Surr	ogate Limits			
	Lower %	Upper %			Lower %	Upper %		
Pentafluorobenzene	80.0	120			80.0	120		
1,2-Dichloroethane-d4	80.0	120			80.0	120		
Toluene-D8	80.0	120			80.0	120		
4-Bromofluorobenzene	80.0	120			80.0	120		
			[[
					}			

ELAP Number 10958 Method: EPA 8260B

^{* -} Due to an equipment change, generic limits are being used for surrogates until enough data are collected to generate new limits.



CHAIN OF CUSTODY

PΔ	RADIO	3 M		REPORT TO	A				INVOIC	ETO:								
	AND AT ALL SERVICE		COMPAN'	Y: HALEY EALORI	ed of NY		COMPAN	Y: (Same)				LAB PROJEC		CLIEN	r PROJI	ECT #:	
- English			ADDRESS	S: 200 TOWN CENT	LE OR.		ADDRES	S:					12:25		"		5-0	27
			CITY:	RECHECTS! STAT	IE: ZIP:	623	CITY:			STATE		ZIP:	TURNAROUN	ID TIME: (W	ORKING	DAYS)		4
			PHONE:	Y: HALEY EALORI S: 200 TOWN CONT ROCHESTER N FOS 321 4245 FAX:			PHONE:			FAX:			12	day pe	ir QC S	∕∕ U≀ TD	<i>ا (ی)</i> د o	THER
ROJECT NAME/SIT	E NAME:		ATTN:	DENIS CONLEY			ATTN:					7	fy) r	7, [\int_{3}	Ž 5	Ť	
			COMMEN	ITS:					ALGEANIA		***				1 0 1			Stallinovik domenide
			1. Digetorial est					DENI	JESTED .	ANIALVO	ne.		Quotati	on#				
		C	T				С		JESTED.	AIVALIS). 						A.E. Tipidizidi	
DATE	ТІМЕ	O M P O S I T E	G R A B	SAMPLE LOCATION/F	EELD ID	M A T R I	N T A B I N R R S	Voc /8260 B					REMARK	(S			ADIGM L LE NUM	
6/13/12	1030		X	BTWPTEFF-20	120613-103	· AIR	1	Х				CHL	ORINAT	50 Vo	· es (0/1		
<u> </u>													-					
												Perl)C/JD-	need		\top		1
										\dashv		RL.	of 0.5	maln	, 3	+	十	+
			-								1			EAH 6,		+	$\vdash \vdash$	+
								\vdash	+		\dashv	<u> </u>	4	2000	77	+	$\vdash +$	+-
								┞┈┼┈┼				-			_	+	$\vdash \vdash$	+
								\blacksquare			4-4-	1					$\vdash \vdash$	
		. 20.00								<u> </u>	44							
														4				
0					amazooke													
LAB USE C																		
ample Condition	Receipt Pa		241/242/2	NELAC Compliance	- 1		\checkmark)										
omments: 7		ype: S BAG	ieep.		Sample	I By		1		6/ /Date/1	/3//2 Time		1030	Total C	ost:			
omments:	Preservat			Y N	Relinqui	shed B		· .		6/ (L Date/)	<u>4/(2</u> Time ,	- ATTENDED	:37					
omments:	Holding Ti 48 HNS	me:		Y N	Receive	T By	<u> </u>	5	######################################	6	114	12	113	TARN	^_г			
omments: R	Temperati	ure: DENAZUNE	•	Y	Received	1 @ Lal	o By	<u>la</u>	Hon	Date/1	<i>©/14</i> Time	112	<u> 130</u> 5	ī			ļ	



Chain of Custody Supplement

	Client:	H+A									
	Lab Projec	et ID: $12:252:$	12:2522								
			tion Requirements 210/241/242/243/244								
NELAC compliance with the sample condition requirements upon receipt Condition Yes No N/A											
Container Type											
	Comments										
Transferred to met											
Headspace (<1 mL)	Comments										
Preservation	Comments										
		· · · · · · · · · · · · · · · · · · ·									
Chlorine Absent (<0.05 ppm per t	est strip) Comments										
Holding Time	Comments										
Temperature	Comments										
Sufficient Sample	Ouantity										
ouncient sample	Comments		<u> </u>								