



Ecosystems Strategies, Inc.

24 Davis Avenue, Poughkeepsie, NY 12603

phone 845.452.1658 | fax 845.485.7083 | ecosystemsstrategies.com

January 21, 2010

Chris Kenyon
Scenic Hudson, Inc.
1 Civic Center Plaza, Suite 200
Poughkeepsie, NY 12601

via EMAIL: ckenyon@scenichudson.org

Re: Building Demolition conducted at the Former Sakmann Restaurant Corp. property located at 706 U.S. Route 9W, Town of Highlands, Orange County, New York
ESI File: SF01123.45
Voluntary Cleanup Site Number: V-00083-3

Dear Mr. Kenyon:

This Letter Report of Building Demolition (Letter Report) summarizes fieldwork performed by Ecosystems Strategies, Inc. (ESI), and ESI's designated subcontractors on the above-referenced property (hereafter referred to as the "Site"). The work summarized in this Letter Report was performed to document building demolition and off-site disposal of the debris associated with the former "Trading Post" restaurant located at the above-referenced property, which was accepted into the New York State Department of Environmental Conservation (NYSDEC) Voluntary Cleanup Program (VCP) in November 2003.

Demolition and Site restoration activities were conducted between November 2 and November 6, 2009. All demolition activities were performed by personnel from Rogan Brothers Sanitation, Inc. (Rogan). A Fieldwork Map indicating the former building location and associated selected Site features is provided as Attachment A to this Letter Report.

Site Preparation Services

Prior to demolition activities, a request for a complete utility markout of the Site was submitted by ESI and a visual inspection was conducted by personnel from Scenic Hudson, Inc. to confirm that any electrical lines running between the former building and the associated utility pole had been physically removed.

Prior to the demolition of the building, a Demolition Survey for Asbestos Containing Materials (Adelaide Report) was issued by Adelaide Environmental Health Associates, Inc. in October 2009. The Adelaide Report documented the collection and laboratory analysis of suspect asbestos containing materials (ACMs) associated with the on-site building. According to the Adelaide Report, no ACMs were detected in any of the seventeen samples collected from the interior and exterior of the building. A copy of the Adelaide Report is provided as Attachment B to this letter report.

All on-site activities were conducted in accordance with a NYSDEC approved Site Management Plan, which was prepared for the subject property by ESI in October 2007 and revised in January 2009, with the exception that NYSDEC notification was not given prior to building demolition. Mr. John Rashak of the NYSDEC was notified subsequent to on-site activities and gave verbal approval for the activities that had taken place. Mr. Rashak indicated that a copy of a final demolition report should be provided to the NYSDEC and the New York State Department of Health (NYSDOH).

C. Kenyon
January 21, 2010
ESI File: SF01123.45
Page 2 of 3

Building Demolition

Building demolition was conducted between November 2, 2009 and November 4, 2009. Demolition activities included the complete removal of the on-site building (including the foundation), and the removal of a concrete patio area located to the south of the former building. Photographs documenting demolition activities are provided as Attachment C to this Letter Report. Approximately 383 yards of construction and demolition debris and approximately 175 yards of concrete were properly disposed of off-site between November 3 and 5, 2009. Manifests documenting the proper off-site disposal of all materials are provided as Attachment D. Additionally, debris and associated trash were removed from the slope near the eastern property line by personnel from Rogan subsequent to building demolition activities. This debris generally consisted of scattered trash and non-construction debris.

Importation of Clean Fill and Site Restoration

Approximately 685 yards of clean fill, provided by Rogan, was imported to the Site between November 4 and 6, 2009. No field evidence of contamination was observed in any of the soils imported to the Site. ESI was provided with laboratory results of two samples collected from the clean fill at the facility providing the fill. A discussion of the laboratory results is provided below. A copy of the laboratory report is provided as Attachment E. Following the importation of clean fill, the Site was restored to the approximate original grade.

Guidance Levels

The term "guidance level," as defined in this Letter Report, refers to the concentration of a particular contaminant above which the imported fill would not be considered acceptable for re-use on-site. The overall objective of setting guidance levels is to assess the integrity of the proposed fill relative to conditions which are likely to present a threat to public health or the environment, given the existing and probable future uses of the Site. No independent risk assessment was performed as part of this investigation.

Guidance levels for all compounds detected in soils are based on the NYSDEC Brownfields Program (6 NYCRR Part 375-6) Table 375-6.8(a): Unrestricted Use Soil Cleanup Objectives (SCOs). All data presented in this Letter Report have been analyzed in accordance with applicable guidance levels.

Laboratory Results

No volatile organic compounds (VOCs) or semi-volatile organic compounds (SVOCs) were detected above guidance levels. Low-level concentrations of several VOC and SVOC compounds were detected in both samples.

Chromium was detected slightly above the guidance level of 30 parts per million (ppm) in one sample (42.4 ppm) and below the guidance level in the second sample (22.7 ppm). The average concentration of the two samples is 32.55 ppm. It is ESI's opinion that the slightly elevated concentration of chromium is not representative of the chromium level of the entire fill,

C. Kenyon
January 21, 2010
ESI File: SF01123.45
Page 3 of 3

based on the result of the second sample. In addition, placement of the soil at the Site likely dispersed the chromium; the level of chromium in the fill is not likely to represent a significant threat to human health or the environment. Low-level concentrations of several other metals were detected below guidance levels.

No pesticides or polychlorinated biphenyls (PCBs) were detected above minimum detection limits (MDLs).

Conclusions and Recommendations

The laboratory data, and the lack of field evidence of contamination in the imported soils, support the conclusion that the fill material was acceptable for on-site use. All materials associated with the former on-site structure have been disposed of off-site in accordance with all applicable regulations.

It is recommended that this document be submitted to the NYSDEC and the NYSDOH.

Please review this document and call me at (845) 452-1658 should you have any questions or comments.

I appreciate the opportunity to provide this service to you and look forward to working with you in the future.

Sincerely,

ECOSYSTEMS STRATEGIES, INC.



Paul H. Ciminello
President

PHC:bmb:kad

Attachments: A: Fieldwork Map
B: Adelaide Report
C: Photographs
D: Disposal Manifests
E: Laboratory Report


cc: File



Ecosystems Strategies, Inc.

ATTACHMENT A

Fieldwork Map






All feature locations are approximate. This map is intended as a schematic to be used in conjunction with the associated report, and it should not be relied upon as a survey for planning or other activities.

Fieldwork Map

Former Sakmann Restaurant Corp. Property
 706 U.S. Route 9W
 Town of Highlands
 Orange County, New York

Legend:

-  subject property border
-  supply well location
-  edge of asphalt

ESI File: SF01123.45

January 2009

Scale: 1" = 40' approximately

Attachment A



ATTACHMENT B

Adelaide Report



Adelaide Environmental Health Associates, Inc.

DEMOLITION SURVEY FOR ASBESTOS CONTAINING MATERIALS

PERFORMED AT:

**Former Sakmann Restaurant
US Route 9W Town of Highlands
Fort Montgomery, New York
Adelaide Project# ECOS: 09149.00-IN**

PREPARED FOR:

**Ecosystems Strategies, Inc.
24 Davis Avenue
Poughkeepsie, New York 12603**

PREPARED BY:

**Adelaide Environmental Health Associates, Inc.
1511 Route 22, Suite C24
Brewster, New York 10509**

DATED:

October 14, 2009

Submitted by:

**John W. Soter
Senior Vice-President**

DEMOLITION SURVEY FOR ASBESTOS

TABLE OF CONTENTS

1.0	Executive Summary	1
	Homogenous Area List	1
2.0	Asbestos Field Procedures and Analysis Methodology	2
2.1	Inspection	2
2.2	Sampling	2
2.3	Analysis	3
3.0	Conclusions and Recommendations	4
4.0	Areas not Accessible	4
5.0	Report Certifications	4
6.0	Transmittal of Building Survey	5

1.0 EXECUTIVE SUMMARY

At your request, Adelaide Environmental Health Associates representative, Chad Kidd, performed a demolition survey for asbestos at the Former Sakmann Restaurant in Fort Montgomery, New York. Adelaide collected forty two (42) asbestos samples from the above-mentioned areas on October 12, 2009. Zero (0) samples/homogenous areas tested positive for asbestos.

The following samples tested positive for the presence of asbestos:

- ***No Samples Tested Positive for Asbestos***

Negative Homogenous Area List

The following is a list of the homogeneous areas that tested negative during this inspection:

- Exterior Skim Coat
- Roof Shingles
- Grey cove base and Black Mastic under cove base behind bar
- White 12x12 floor tile and associated mastic
- Exterior Window Caulk
- Interior Window caulk
- Stone Floor Tile and Mastic
- Stone Tile Mortar
- Ceiling Tile
- Interior Caulk in Men's Room
- Plaster
- Interior window caulk in bathrooms
- Brown Paper flooring beneath rug in dining area
- Mortar behind firebrick wall
- Mortar under red brick
- Grey Caulk around door frames in front of building
- Adhesive behind bathroom ceramic tiles

2.0 ASBESTOS FIELD PROCEDURES AND ANALYSIS METHODOLOGY

2.1 INSPECTION

Guidelines used for the inspection were established by the U.S. Environmental Protection Agency (EPA) in the Guidance for Controlling Asbestos Containing Materials in Buildings, Office of Pesticides and Toxic Substances, DOC# 560/5-85-024 and 40 CFR Part 763, Asbestos Hazard Emergency Response Act (AHERA). Field information was organized as per the AHERA concept of a homogeneous area (HA); that is, suspect Asbestos Containing Materials (ACM) with similar age, appearance, and texture were grouped together, sampled and assessed for condition.

For the purposes of this inspection, suspect ACM has been placed in three material categories: thermal, surfacing, and miscellaneous.

Surfacing materials are those that are sprayed on, troweled on or otherwise applied to surfaces for fireproofing, acoustical, or decorative purposes (e.g., wall and ceiling plaster).

Thermal materials are those applied to heat pipes or other structural components to prevent heat loss or gain or prevent water condensation (e.g., pipe and fitting insulation, duct insulation, boiler flue).

Miscellaneous materials are interior building materials on structural components, structural members or fixtures, such as floor and ceiling tiles, etc. and do not include surfacing material or thermal system insulation.

2.2 SAMPLING

SURFACING MATERIALS

Surfacing materials were grouped into homogeneous sampling areas. A homogeneous area contains material that is uniform in color and texture and appears identical in every other respect. Materials installed at different times belong to different sampling areas. Homogeneous areas were determined on per floor basis.

The following protocol was used for determining the number of samples to be collected:

- At least three bulk samples were collected from each homogeneous area that is 1,000 square feet or less.
- At least five bulk samples were collected from each homogeneous area that is greater than 1,000 square feet but less than or equal to 5,000 square feet.
- At least seven bulk samples were collected from each homogeneous area that is greater than 5,000 square feet.

THERMAL SYSTEM INSULATION (TSI)

The concept of homogeneous sampling areas applies equally well to thermal insulation as to surfacing material. A "typical" building may contain multiple insulated pipe runs from any combination of the following categories:

- Hot water supply and/or return
- Cold water supply
- Chilled water supply
- Steam supply and/or return
- Roof or system drain

The following protocol was used for determining the number of samples to be collected.

- Collect at least three bulk samples from each homogeneous area of thermal system insulation.
- Collect at least one bulk sample from each homogeneous area of patched thermal system insulation if the patched section is less than 6 linear or square feet.
- In a manner sufficient to determine whether the material is ACM or not ACM, collect a minimum of three bulk samples from each homogeneous insulated mechanical system tee, elbow, and valve.

Bulk samples are not collected from any homogeneous area where the certified inspector has determined that the thermal system insulation is fiberglass, foam glass, or rubber.

MISCELLANEOUS MATERIALS

Miscellaneous materials are grouped into different homogeneous areas and at least two bulk samples are collected from each homogeneous area as per the clarification letter from the EPA and the Professional Abatement Contractors of New York, Inc in November of 2007.

2.3 ANALYSIS

Bulk samples of suspect ACM were analyzed by Polarized Light Microscopy (PLM) with dispersion staining, as described in 40CFR Part 763 and the National Emissions Standard for Hazardous Air Pollutants (NESHAPS).

The New York State (NYS) Department of Health has recently revised the PLM Stratified Point Counting Method. The new method, Polarized Light Microscopy for Identifying and Quantitating Asbestos in Bulk Samples can be found as Item 198.1 in the Environmental Laboratory Accreditation Program (ELAP) Certification manual.

The State of New York ELAP has determined that analysis of NOB materials is not reliably performed by PLM. Therefore, if PLM yields negative results for a non-friable material, it must be confirmed by Transmission Electron Microscopy (TEM) analysis.

All NOB samples were initially analyzed by utilizing TEM methodology.

An asbestos containing material is any material containing greater than one percent (1%) of asbestos by weight. All materials that tested trace or less than one percent are non asbestos.

3.0 CONCLUSIONS AND RECOMMENDATIONS

This survey concluded that the none of the materials listed in Section 1.0 Executive Summary tested positive for the presence of asbestos.

4.0 AREAS NOT ACCESSIBLE

Adelaide Environmental Health Associates inspected and sampled materials which were visible and/or accessible to the survey team. Adelaide does not inspect physically inaccessible areas, such as between walls, above fixed ceilings, under concrete slabs, etc. This report makes no representations as to the content of these areas or materials.

All materials present in those not accessible areas shall be assumed positive until tested.

5.0 REPORT CERTIFICATIONS

Adelaide Environmental Health Associates certifies that the information contained herein is based on the physical and visual inspections conducted by Adelaide and data collected during the inspection survey.

6.0 TRANSMITTAL OF BUILDING/STRUCTURE ASBESTOS SURVEY

One (1) copy of the results of the building/structure asbestos survey shall be immediately transmitted by the building/structure owner as follows:

- (1) One (1) copy of the completed asbestos survey shall be sent by the owner or their agent to the local government entity charged with issuing a permit for such demolition, renovation, remodeling or repair work under applicable State or local laws.
- (2) The completed asbestos survey for controlled demolition (as per Subpart 56-11.5) or pre-demolition asbestos projects shall also be submitted to the appropriate Asbestos Control Bureau district office.
- (3) The completed asbestos survey shall be kept on the construction site with the asbestos notification and variance, if required, throughout the duration of the asbestos project and any associated demolition, renovation, remodeling or repair project.

APPENDIX A
ASBESTOS ANALYTICAL RESULTS


AMERISCI
AmeriSci New York
 117 EAST 30TH ST.
 NEW YORK, NY 10016
 TEL: (212) 679-8600 • FAX: (212) 679-3114
PLM Bulk Asbestos Report
 Adelaide Environmental Health
 Attn: John Soter
 1511 Rt. 22 Suite C24
 Brewster, NY 10509

 Date Received 10/13/09 AmeriSci Job # 209102176
 Date Examined 10/13/09 P.O. #
 ELAP # 11480 Page 1 of 4
 RE: ECOS: 09149.00-IN; Former Sakmann Restaurant; US Rt.
 9W Ft. Montgomery; Town Of Highlands, NY (Report Amended
 10/13/2009)

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
1 1 Location: Exterior, Skimcoat, White w/Gravel	209102176-01	No	NAD (by NYS ELAP 198.1) by Ella Babayeva on 10/13/09
Analyst Description: White, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 100 %			
2 1 Location: Exterior, Skimcoat, White w/Gravel	209102176-02	No	NAD (by NYS ELAP 198.1) by Ella Babayeva on 10/13/09
Analyst Description: White, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 100 %			
3 1 Location: Exterior, Skimcoat, White w/Gravel	209102176-03	No	NAD (by NYS ELAP 198.1) by Ella Babayeva on 10/13/09
Analyst Description: White, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 100 %			
18 Location: 1st Floor; Stone Floor Tile, Grey, Dark Grey, Red	209102176-04	No	NAD (by NYS ELAP 198.1) by Ella Babayeva on 10/13/09
Analyst Description: Grey, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 100 %			
19 9 Location: 1st Floor; Stone Floor Tile, Grey, Dark Grey, Red	209102176-05	No	NAD (by NYS ELAP 198.1) by Ella Babayeva on 10/13/09
Analyst Description: Grey, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 100 %			

See Reporting notes on last page

AmeriSci Job #: 209102176

Page 2 of 4

Client Name: Adelaide Environmental Health

PLM Bulk Asbestos Report

ECOS: 09149.00-IN; Former Sakmann Restaurant; US Rt. 9W
Ft. Montgomery; Town Of Highlands, NY (Report Amended
10/13/2009)

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
22 11	209102176-06 Location: 1st Floor; Mortar Of Stone Tile	No	NAD (by NYS ELAP 198.1) by Ella Babayeva on 10/13/09
Analyst Description: Tan, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Cellulose Trace, Non-fibrous 100 %			
23 11	209102176-07 Location: 1st Floor; Mortar Of Stone Tile	No	NAD (by NYS ELAP 198.1) by Ella Babayeva on 10/13/09
Analyst Description: Tan, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Cellulose Trace, Non-fibrous 100 %			
24 12	209102176-08 Location: 1st Floor; Ceiling Tile, White	No	NAD (by NYS ELAP 198.1) by Ella Babayeva on 10/13/09
Analyst Description: White/Beige, Homogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Cellulose Trace, Fibrous glass 85 %, Non-fibrous 15 %			
25 12	209102176-09 Location: 1st Floor; Ceiling Tile, White	No	NAD (by NYS ELAP 198.1) by Ella Babayeva on 10/13/09
Analyst Description: White/Beige, Homogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Cellulose Trace, Fibrous glass 80 %, Non-fibrous 20 %			
28 14	209102176-10 Location: 1st Floor; Plaster, White	No	NAD (by NYS ELAP 198.1) by Ella Babayeva on 10/13/09
Analyst Description: White, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 100 %			
29 14	209102176-11 Location: 1st Floor; Plaster, White	No	NAD (by NYS ELAP 198.1) by Ella Babayeva on 10/13/09
Analyst Description: White, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 100 %			

See Reporting notes on last page

AmetiSci Job #: 209102176

Page 3 of 4

Client Name: Adelaide Environmental Health

PLM Bulk Asbestos Report

ECOS: 09149.00-IN; Former Sakmann Restaurant; US Rt. 9W
Ft. Montgomery; Town Of Highlands, NY (Report Amended
10/13/2009)

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
30 14	209102176-12 Location: 1st Floor; Plaster, White	No	NAD (by NYS ELAP 198.1) by Ella Babayeva on 10/13/09
Analyst Description: White/Grey, Heterogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 100 %			
33 16	209102176-13 Location: 1st Floor; Flooring Beneath Rug, Lobby, Dining Area, Brown Paper	No	NAD (by NYS ELAP 198.1) by Ella Babayeva on 10/13/09
Analyst Description: Brown, Homogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Cellulose 95 %, Non-fibrous 5 %			
34 16	209102176-14 Location: 1st Floor; Flooring Beneath Rug, Lobby, Dining Area, Brown Paper	No	NAD (by NYS ELAP 198.1) by Ella Babayeva on 10/13/09
Analyst Description: Brown, Homogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Cellulose 97 %, Non-fibrous 3 %			
35 17	209102176-15 Location: 1st Floor; Mortar Behind Fire Brick Wall, Dark Grey/Black	No	NAD (by NYS ELAP 198.1) by Ella Babayeva on 10/13/09
Analyst Description: Dark Grey, Homogeneous, Non-Fibrous, Cementitious, Bulk Material Asbestos Types: Other Material: Non-fibrous 100 %			
36 17	209102176-16 Location: 1st Floor; Mortar Behind Fire Brick Wall, Dark Grey/Black	No	NAD (by NYS ELAP 198.1) by Ella Babayeva on 10/13/09
Analyst Description: Dark Grey, Homogeneous, Non-Fibrous, Cementitious, Bulk Material Asbestos Types: Other Material: Non-fibrous 100 %			
37 18	209102176-17 Location: 1st Floor; Mortar Under Red Brick, Floor Lobby, Light Grey	No	NAD (by NYS ELAP 198.1) by Ella Babayeva on 10/13/09
Analyst Description: Light Grey, Homogeneous, Non-Fibrous, Cementitious, Bulk Material Asbestos Types: Other Material: Non-fibrous 100 %			

See Reporting notes on last page

AmeriSci Job #: 209102176

Page 4 of 4

Client Name: Adelaide Environmental Health

PLM Bulk Asbestos Report

ECOS: 09149.00-IN; Former Sakmann Restaurant; US Rt. 9W
 Ft. Montgomery; Town Of Highlands, NY (Report Amended
 10/13/2009)

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
38 18	209102176-18 Location: 1st Floor; Mortar Under Red Brick, Floor Lobby, Light Grey	No	NAD (by NYS ELAP 198.1) by Ella Babayeva on 10/13/09
Analyst Description: Light Grey, Homogeneous, Non-Fibrous, Cementitious, Bulk Material Asbestos Types: Other Material: Non-fibrous 100 %			

Reporting Notes:

Analyzed by: Ella Babayeva



*NAD/NSD =no asbestos detected; NA =not analyzed; N/A/PS=not analyzed/positive stop; PLM Bulk Asbestos Analysis by EPA 800/M4-82-020 per 40 CFR 763 (NYS/LAP Lab Code 200546-0), ELAP PLM Method 198.1 for NY friable samples or 198.6 for NOB samples (NY ELAP Lab ID11480); Note:PLM is not consistently reliable in detecting asbestos in floor coverings and similar non-friable organically bound materials. NAD or Trace results by PLM are inconclusive, TEM is currently the only method that can be used to determine if this material can be considered or treated as non asbestos-containing in NY State (also see EPA Advisory for floor tile,FR 59,146,38970,8/1/94). National Institute of Standards and Technology Accreditation requirements mandate that this report must not be reproduced except in full without the approval of the lab. This PLM report relates ONLY to the items tested. AIHA Lab # 102843.

Reviewed By: _____





END OF REPORT _____

Adelaide Environmental Health Associates, Inc

1511 Rte. 22, Suite C24
 Brewster, NY 10509
 845-278-7710
 845-278-7750 - fax

20102176

Site Address: Former Sakmann Restaurant		Date: 10/12/09	Inspector(s) Chad Kidd			
US Rt. 9W Ft Montgomery		Project #: ECOS:09149.00-IN				
Sample ID #	Homogeneous Area	Floor Level	Sample Location/Description	Quantity (In Feet)	Frangible	Condition
1	1	Ext	Exterior, Skin Coat white w/gravel	100 ^{5g}	N	G
2	1	Ext	↓	↓	↓	↓
3	1	Ext	↓	↓	↓	↓
4	2	Inst	Roof Shingles Black	1,00 ^{5g}	N	G
5	2		↓	↓	↓	↓
6	3	Inst	Black Mastic under Covebase behind Bar	30 ^{LF}	N	G
7	3		↓	↓	↓	↓
8	4		Black mastic under 12x12 white Floor tile	200 ^g	N	G
9	4		↓	↓	↓	↓
10	5		Grey Cove base Behind BAR	30 ^{LF}	N	G
11	5		↓	↓	↓	↓
12	6		Caulk around exterior windows	30 ^{1F}	N	G
13	6	↓	↓	↓	↓	↓

Relinquished by: 
 Received by: 
 Relinquished by: 
 Received by: 

24 hr TAT

TEM on NOB's only - No PLM on NOB's
 Stop at 1st Positive per Homogenous Area
 Fax Results to 845-278-7750
 E-mail Results to AdelaideLabResults@adelaideilc.com

Special Instructions/ Turnaround Time:

Site Address: Former Sakmann Restaurant		Date: 10/12/09	Inspector(s): Chad Kidd
US Rt. 9W Ft Montgomery		Project #: ECOS:09149.00-IN	
Town of Highlands, NY		Sample Location/Description	
Sample ID #	Homogeneous Area	Floor Level	Condition
14	7	1st	D
15	7		↓
16	8		G
17	8		↓
18	9		D
19	9		↓
20	10		G
21	10		↓
22	11		G
23	11		↓
24	12		G
25	12		↓
26	13		G

Special Instructions/ Turnaround Time: **24 hr TAT**

TEM on NOB's only - No PLM on NOB's
 Stop at 1st Positive per Homogenous Area
 Fax Results to 845-278-7750
 E-mail Results to AdelaideLabResults@adelaideilc.com

Relinquished by: _____
 Received by: _____
 Relinquished by: _____
 Received by: _____

209102176

Site Address: Former Sakmann Restaurant		Date: 10/12/09		Inspector(s) Chad Kidd			
US Rt. 9W Ft Montgomery		Project #: ECOS:09149.00-IN					
Town of Highlands, NY		Sample Location/Description					
Sample ID #	Homogeneous Area	Floor Level	Sample Location/Description		Quantity (in Feet)	Table NonFrable	Condition g. d. sd
27	13	1st	Interior, caulk, memo foam, Between pages		10 ^{LF}	N	G
28	14		Plaster, white		500 ^{sq}	F	D
29	14		↓				
30	14		↓				
31	15		Interior, caulk, Bathrooms, around window frames		20 ^{LF}	N	G
32	15		↓				
33	16		Flooring Beneath reg. lobby, Dining area, Brown Paper		500 ^{sq}	N	G
34	16		↓				
35	17		mortar behind Fire Brick Wall, Dark grey/Black		100 ^{sq}	N	G
36	17		↓				
37	18		mortar under red brick, Floor lobby, light Grey		20 ^{sq}	N	G
38	18		↓				
39	19		Grey Caulk around Door Frames front of Bldg		10 ^{LF}	N	G
Special Instructions/ Turnaround Time:							
TEM on NOB's only - No PLM on NOB's							
Stop at 1st Positive per Homogenous Area							
Fax Results to 845-278-7750							
E-mail Results to AdelaideLabResults@adelaideehc.com							
Relinquished by: <i>[Signature]</i>				Received by: <i>[Signature]</i>			
Relinquished for:				Received by:			

24 hr TAT

209102176

Site Address: Former Sakmann Restaurant		Date: 10/12/09		Inspector(s): Chad Kidd		
US Rt. 9W Ft Montgomery		Town of Highlands, NY		Project #: ECOS:09149.00-IN		
Sample ID #	Homogeneous Area	Floor Level	Sample Location/Description	Quantity (in Feet)	Frangible	Condition
40	19	1st	Grey Caulk around door Frame, Front of Bldg	10 LF	N	G
41	20	↓	Adhesive behind Ceramic tile, Bathrooms, yellow	100%	N	G
42	20	↓	↓	↓	↓	↓

Special Instructions/ Turnaround Time: **24 hr IAI**

TEM on NOB's only - No PLM on NOB's
 Stop at 1st Positive per Homogenous Area
 Fax Results to 845-278-7750
 E-mail Results to AdelaideLabResults@adelaideilc.com


Relinquished by: 
 Received by: _____
 Relinquished by: _____
 Received by: _____

Table I
Summary of Bulk Asbestos Analysis Results by NYS ELAP 198.4 NOB Method
 ECOS: 09149.00-IN; Former Sakmann Restaurant; US Rt. 9W Ft. Montgomery, Town Of Highlands, NY

AmeriSci Sample #	Client Sample#	HG Area	Sample Weight (gram)	Heat Sensitive Organic %	Acid Soluble Inorganic %	Insoluble Non-Asbestos Inorganic %	** Asbestos % by TEM
01	4	2	0.507	23.5	21.3	55.2	NAD
Location: 1st Floor; Roof Shingles, Black							
02	5	2	0.632	20.4	35.3	44.3	NAD
Location: 1st Floor; Roof Shingles, Black							
03	6	3	0.213	83.6	4.2	12.2	NAD
Location: 1st Floor; Black Mastic Under Covebase Behind Bar							
04	7	3	0.230	76.1	3.0	20.9	NAD
Location: 1st Floor; Black Mastic Under Covebase Behind Bar							
05	8	4	0.210	39.0	51.4	9.6	NAD
Location: 1st Floor; Black Mastic Under 12x12 White Floor Tile							
06	9	4	0.239	58.6	30.1	11.3	NAD
Location: 1st Floor; Black Mastic Under 12x12 White Floor Tile							
07	10	5	0.388	47.7	20.9	31.4	NAD
Location: 1st Floor; Grey Covebase Behind Bar							
08	11	5	0.309	51.8	15.2	33.0	NAD
Location: 1st Floor; Grey Covebase Behind Bar							
09	12	6	0.583	25.6	68.3	6.1	Chrysotile Trace
Location: 1st Floor; Caulk Around Exterior Windows							
10	13	6	0.470	25.7	68.7	5.4	Chrysotile Trace
Location: 1st Floor; Caulk Around Exterior Windows							
11	14	7	0.512	17.6	60.0	22.5	NAD
Location: 1st Floor; 12x12 White Floor Tile							
12	15	7	0.356	17.7	61.0	21.3	NAD
Location: 1st Floor; 12x12 White Floor Tile							
13	16	8	0.161	70.2	27.3	2.5	NAD
Location: 1st Floor; Caulk, Interior, Behind Bar Windows, Grey							
14	17	8	0.203	71.4	27.6	1.0	NAD
Location: 1st Floor; Caulk, Interior, Behind Bar Windows, Grey							
15	20	10	0.171	56.1	12.3	31.5	Chrysotile Trace
Location: 1st Floor; Adhesive Beneath Stone Tile, Yellow							

See Reporting notes on last page

Table I

Summary of Bulk Asbestos Analysis Results by NYS ELAP 198.4 NOB Method
 ECOS: 09149.00-IN; Former Sakmann Restaurant; US Rt. 9W Ft. Montgomery; Town Of Highlands, NY

ECOS: 09149.00-IN; Former Sakmann Restaurant; US Rt. 9W Ft. Montgomery; Town Of Highlands, NY

AmeriSci Sample #	Client Sample#	HG Area	Sample Weight (gram)	Heat Sensitive Organic %	Acid Soluble Inorganic %	Insoluble Non-Asbestos Inorganic %	** Asbestos % by TEM
16	21	10	0.146	67.1	6.8	25.9	Chrysotile Trace
Location: 1st Floor; Adhesive Beneath Stone Tile, Yellow							
17	26	13	0.397	27.7	67.3	5.0	NAD
Location: 1st Floor; Interior Caulk, Mens Room Between Paynes							
18	27	13	0.241	27.0	69.7	3.3	NAD
Location: 1st Floor; Interior Caulk, Mens Room Between Paynes							
19	31	15	0.359	36.2	30.1	33.7	NAD
Location: 1st Floor; Interior, Caulk, Bathrooms, Around Window Frames							
20	32	15	0.377	36.3	27.9	35.8	NAD
Location: 1st Floor; Interior, Caulk, Bathrooms, Around Window Frames							
21	39	19	0.356	63.5	1.1	35.4	NAD
Location: 1st Floor; Grey Caulk Around Door Frames, Front Of Bldg.							
22	40	19	0.658	61.7	2.6	35.7	NAD
Location: 1st Floor; Grey Caulk Around Door Frames, Front Of Bldg.							
23	41	20	0.237	80.2	6.3	13.5	NAD
Location: 1st Floor; Adhesive Behind Ceramic Tile, Bathrooms, Yellow							
24	42	20	0.188	60.6	12.8	26.6	NAD
Location: 1st Floor; Adhesive Behind Ceramic Tile, Bathrooms, Yellow							

Analyzed by: Marik Peysakhov; Date Analyzed: 10/14/2009

**Quantitative Analysis (Semi/Full): Bulk Asbestos Analysis - PLM by EPA 600/M4-82-020 per 40 CFR or ELAP 198.1 for New York friable samples or ELAP 198.6 for New York NOB samples; TEM (Semi/Full) by EPA 600/R-93/116 (not covered by NVLAP Bulk accreditation); or ELAP 198.4 for New York samples; NAD = no asbestos detected during a quantitative analysis; NA = not analyzed; Trace = <1%; Quantitation for beginning weights of <0.1 grams should be considered as qualitative only; Qualitative Analysis: Asbestos analysis results of "Present" or "N/A = No Visible Asbestos" represents results for Qualitative PLM or TEM Analysis only (no accreditation coverage available from any regulatory agency for qualitative analyses); AIHA Lab # 102843, NVLAP Lab Code 200546-0, NYSDOH ELAP LAB ID 11480.

Warning Note: PLM limitation, only TEM will resolve fibers <0.25 micrometers in diameter. TEM bulk analysis is representative of the fine grained matrix material and may not be representative of non-uniformly dispersed debris for which PLM evaluation is recommended (i.e. soils and other heterogeneous materials).

Reviewed By: _____

Adeelaide Environmental Health Associates, Inc

1511 Rte. 22, Suite C24
 Brewster, NY 10509
 845-278-7710
 845-278-7750 - fax

209102175

Site Address: Former Sakmann Restaurant		Date: 10/12/09	Inspector(s): Chad Kidd	
US Rt. 9W Ft Montgomery		Project #: ECOS:09149.00-IN		
Town of Highlands, NY		Sample Location/Description		
Sample ID #	Homogeneous Area	Floor Level	Quantity (In Feet)	Condition
1	1	Exte	100 ^{3/8}	N ↓
2	1	Exte	↓	↓
3	1	EXTR	↓	↓
4	2	Inst	100 ^{3/8}	N ↓
5	2	↓	↓	↓
6	3	Inst	30 ^{LF}	N ↓
7	3	↓	↓	↓
8	4	↓	200 ^F	N ↓
9	4	↓	↓	↓
10	5	↓	30 ^{LF}	N ↓
11	5	↓	↓	↓
12	6	↓	30 ^{1F}	N ↓
13	6	↓	↓	↓

Special Instructions/ Turnaround Time: **24 hr TAT**

Reinquished by: *[Signature]*
 Received by:
 Reinquished by:
 Received by:

TEM on NOB's only - No PLM on NOB's
 Stop at 1st Positive per Homogenous Area
 Fax Results to 845-278-7750
 E-mail Results to AdelaideLabResults@adelaidellc.com

Adelaide Environmental Health Associates, Inc

1511 Rte. 22, Suite C24
 Brewster, NY 10509
 845-278-7710
 845-278-7750 - fax

209102175

Site Address:		Date: 10/12/09		Inspector(s): Chad Kidd		
Former Sakmann Restaurant		US Rt. 9W Ft Montgomery		Project #: ECOS:09149.00-IN		
Sample ID #	Homogeneous Area	Floor Level	Sample Location/Description	Quantity (In Feet)	Nonflame	Condition
14	7	1st	12x12 white floor tile	200 ^{sq}	N	D
15	7		↓	↓	↓	↓
16	8		Caulk, Interior, behind bar windows, grey	20 ^{LF}	N	G
17	8		↓	↓	↓	↓
18	9		Stone floor tile, grey, Dark grey, red	500 ^{sq}	N	D
19	9		↓	↓	↓	↓
20	10		Adhesive Beneath Stone Tile, yellow	50 ^{sq}	N	G
21	10		↓	↓	↓	↓
22	11		Mortar of stone tile	500 ^{sq}	N	G
23	11		↓	↓	↓	↓
24	12		Cieling tile, white	600 ^{sq}	F	G
25	12		↓	↓	↓	↓
26	13	↓	Interior Caulk, memo Room Between Payvon	10 ^{LF}	N	G

Special Instructions/ Turnaround Time:
 TEM on NOB's only - No PLM on NOB's
 Stop at 1st Positive per Homogenous Area
 Fax Results to 845-278-7750
 E-mail Results to AdelaideLabResults@adelaideinc.com



24 hr TAT

Relinquished by:
 Received by:
 Relinquished by:
 Received by:

Adelaide Environmental Health Associates, Inc

1511 Rte. 22, Suite C24
 Brewster, NY 10509
 845-278-7710
 845-278-7750 - fax

209102175

Site Address:		Former Sakmann Restaurant		Date:	10/12/09		Inspector(s)		Chad Kidd		
US Rt. 9W Ft Montgomery		Town of Highlands, NY		Project #:		ECOS:09149.00-IN					
Sample ID #	Homogeneous Area	Floor Level	Sample Location/Description								
27	13	1st	Interior, caulk, mens room, Between payers								
28	14		Plaster white								
29	14		↓								
30	14		↓								
31	15		Interior, caulk, Bathrooms, around window frames								
32	15		↓								
33	16		Flooring Beneath rug, lobby, Dining area, Brown Paper								
34	16		↓								
35	17		Mortar behind Fire Brick wall, Dark grey/Black								
36	17		↓								
37	18		Mortar under red brick, Floor lobby, light grey								
38	18		↓								
39	19		Grey caulk around door frames front of Bldg								
Special Instructions/ Turnaround Time: Relinquished by:  Received by:  Relinquished by: Received by: Relinquished by: Received by:											
TEM on NOB's only - No PLM on NOB's Stop at 1st Positive per Homogenous Area Fax Results to 845-278-7750 E-mail Results to Adelaide.LabResults@adelaideinc.com 24 hr TAT											

Site Address: Former Sakmann Restaurant		Date: 10/12/09		Inspector(s) Chad Kidd		
US Rt. 9W Ft Montgomery		Project #: ECOS:09149.00-IN				
Town of Highlands, NY		Sample Location/Description				
Sample ID #	Homogeneous Area	Floor Level	Quantity (in Feet)	NonFriable	Condition	g. d. sd
40	19	1st	Grey Caulk around door Framed, Front of Bldg	N	G	10 LF
41	20	↓	Adhesive behind Ceramic tile, Bathrooms, yellow	N	G	100%
42	20	↓	↓	↓	↓	↓


Special Instructions/ Turnaround Time:

TEM on NOB's only - No PLM or NOB's

Stop at 1st Positive per Homogenous Area

Fax Results to 845-278-7750

E-mail Results to AdelaideLabResults@adelaideinc.com

Reinquished by: 

Received by:

Reinquished by:

Received by:

APPENDIX B
PERSONNEL AND LABORATORY
CERTIFICATIONS

NEW YORK STATE - DEPARTMENT OF LABOR

DIVISION OF SAFETY AND HEALTH
LICENSE AND CERTIFICATE UNIT
STATE CAMPUS BUILDING 12
ALBANY, NY 12240

ASBESTOS HANDLING LICENSE

Adelaide Environmental Health Associates, Inc.
Suite C24
1511 Route 22
Brewster, NY 10509

FILE NUMBER: 99-0656
LICENSE NUMBER: 29305
LICENSE CLASS: RESTRICTED
DATE OF ISSUE: 07/08/2009
EXPIRATION DATE: 07/31/2010

Duly Authorized Representative: John Soter

This license has been issued in accordance with applicable provisions of Article 30 of the Labor Law of New York State and of the New York State Codes, Rules and Regulations (12 NYCRR Part 56). It is subject to suspension or revocation for a (1) serious violation of state, federal or local laws with regard to the conduct of an asbestos project, or (2) demonstrated lack of responsibility in the conduct of any job involving asbestos or asbestos material.

This license is valid only for the contractor named above and this license or a photocopy must be prominently displayed at the asbestos project worksite. This license verifies that all persons employed by the licensee on an asbestos project in New York State have been issued an Asbestos Certificate, appropriate for the type of work they perform, by the New York State Department of Labor.

Maureen A. Cox

Maureen A. Cox, Director
FOR THE COMMISSIONER OF LABOR

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER
RICHARD F. DAINES, M.D.



Expires 12:01 AM April 01, 2010
Issued April 01, 2009

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MR. PAUL MUCHA
AMERICA SCIENCE TEAM NEW YORK INC
117 EAST 30TH ST
NEW YORK, NY 10016

NY Lab Id No: 11480
EPA Lab Code: NY01378

*is hereby APPROVED as an Environmental Laboratory for the category
ENVIRONMENTAL ANALYSES SOLID AND HAZARDOUS WASTE
All approved subcategories and/or analytes are listed below:*

Miscellaneous

Asbestos in Friable Material	EPA 600/M4/82/020 Item 198.1 of Manual
Asbestos in Non-Friable Material-PLM	Item 198.6 of Manual (NOB by PLM)
Asbestos in Non-Friable Material-TEM	ITEM 198.4 OF MANUAL


Serial No.: 38968

Property of the New York State Department of Health. Valid only at the address shown. Must be conspicuously posted. Valid certificates have a raised seal. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify laboratory's accreditation status.

STATE OF NEW YORK - DEPARTMENT OF LABOR
ASBESTOS CERTIFICATE



CHAD K. KLOB
CLASS EXPIRES
C/ATEC(01/10) D/INSP(01/10)
H/PM (01/10)



CERT# 04-11383
DMV# 936445879


MUST BE CARRIED ON ASBESTOS PROJECTS



EYES BRO
HAIR BRO
HGT 5' 08"

IF FOUND RETURN TO:
NYS DOL - L&C UNIT
ROOM 161A BUILDING 12
STATE OFFICE CAMPUS
ALBANY NY 12240

APPENDIX C
SAMPLE LOCATION MAP



PROJECT MONITOR / INSPECTOR:
C. Kidd
Adelaide
 Environmental Health Associates, Inc.
 adelaidemail@adelaidelic.com

DATE:
Oct 12 09

1511 Route 22, Suite C24, Brewster, NY 10509
 Phone: 845.278.7710 Fax: 845.278.7750
 Metro Center, 49 Court St., Binghamton, NY 13901
 Phone: 607.722.6839 Fax: 607.771.0752
 1207 Delaware Avenue, Buffalo, NY 14209
 Phone: 716.402.4580 Fax: 716.877.9570

PROJECT NAME:
Former Sakmann Restaurant Site

KEY:
 IWA = INSIDE WORK AREA
 OWA = OUTSIDE WORK AREA
 BK = BULK SAMPLES
 BG = BACKGROUND AIRS
 DL = DAILY/DURING AIRS
 FC = FINAL/CLEARANCE AIRS
 RF = REFERENCE AIRS

PROJECT NO:
ECOS 09149.00 - Insp.



ATTACHMENT C

Photographs



PHOTOGRAPHS



1. Initial building demolition activities.



2. Demolition of the northern portion of the building.



PHOTOGRAPHS



3. Complete building demolition with the exception of the northern exterior wall.



4. Demolition of northern exterior wall.



PHOTOGRAPHS



5. Loading of demolition debris for off-site disposal.



6. Demolition debris consisting of concrete block and foundation.



PHOTOGRAPHS



7. Area of former on-site building following Site restoration.



8. Area of former on-site building following Site restoration.



ATTACHMENT D

Disposal Manifests

**CONSTRUCTION AND DEMOLITION DEBRIS
TRACKING DOCUMENT**

Please read all instructions before completing this tracking document

Please TYPE or PRINT clearly

INSTRUCTIONS: 1. Generating C&D Processing Facility; complete numbers 1-6, retain Copy #4 and give remaining copies to the Hauler. 2. Hauler; complete numbers 7 and 8, retain Copy #3, and give remaining copies to the Receiving Facility. 3. Receiving Facility; complete numbers 9 and 10, retain Copy #2 and return Copy #1 to the Generating C&D Processing Facility within two weeks.														
GENERATING C&D PROCESSING FACILITY SECTION														
1. GENERATING C&D PROCESSING FACILITY NAME AND ADDRESS: ECO-SYSTEMS - SAKMANN REST Mailing Address RTE 9W C,T,V/State/Zip FT. MONTGOMERY / TOWN OF HIGHLANDS Telephone Number 845-452-1658	2. HAULER NAME AND MAILING ADDRESS ROGAN BROS. SANITATION Mailing Address P.O. Box 1076 C,T,V/State/Zip YONKERS, NY 10703 Telephone Number (914) 476 2838													
3. Part 360 Permit Number 3-5520-00071/2 Date of Permit Expiration ___/___/___	5. MATERIALS TRANSPORTED (use additional sheets if necessary) <table style="width:100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 60%;">TYPE</th> <th style="width: 40%;">QUANTITY (indicate tons or cubic yards)</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">C&D</td> <td style="text-align: center;">40yds</td> </tr> <tr> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> </tr> </tbody> </table>		TYPE	QUANTITY (indicate tons or cubic yards)	C&D	40yds								
TYPE			QUANTITY (indicate tons or cubic yards)											
C&D			40yds											
4. DESTINATION FACILITY NAME AND MAILING ADDRESS ROGAN BROS. SANITATION Mailing Address P.O. Box 1076 C,T,V/State/Zip YONKERS NY 10703 Telephone Number (914) 476 2838														
6. GENERATOR'S CERTIFICATION: I hereby affirm under penalty of perjury that information provided on this document and attached statements and exhibits was prepared by me or under my supervision and direction and is true to the best of my knowledge and belief, and that I have the authority as <u>Agent of generator</u> (title) of <u>Scenic Hudson Inc</u> (Entity) to sign this tracking document pursuant to 6 NYCRR Part 360. I am aware that any false statement made herein is punishable as a Class A misdemeanor pursuant to Section 210.45 of the Penal Law.														
Printed/Typed Name <u>Brian Branch</u>	Signature <u>Brian Branch</u>	Mo. Day Year 												
HAULER SECTION														
7. HAULER SECTION (Certification of Receipt of Construction and Demolition Debris as described in item 5)														
Printed/Typed Name <u>Jim MacDonald</u>	Signature <u>James MacDonald</u>	Mo. Day Year 1 1 0 2 0 9												
8. HAULER DISCREPANCY BOX (Any discrepancies in items 2, 4 or 5 should be noted here and by the item number)														
RECEIVING FACILITY SECTION (Transfer, Recycling, Disposal)														
9. RECEIVING FACILITY SECTION (Certification of Receipt of Construction and Demolition Debris as described in item 5)														
Printed/Typed Name <u>Vinny Sabatini</u>	Signature <u>Vinny Sabatini</u>	Mo. Day Year 11 0 20 9												
10. RECEIVING FACILITY DISCREPANCY BOX (Any discrepancies in items 2, 4 or 5 should be noted here and by the item no.)														

**CONSTRUCTION AND DEMOLITION DEBRIS
TRACKING DOCUMENT**

Please read all instructions before completing this tracking document

Please TYPE or PRINT clearly

INSTRUCTIONS: 1. Generating C&D Processing Facility; complete numbers 1-6, retain Copy #4 and give remaining copies to the Hauler. 2. Hauler; complete numbers 7 and 8, retain Copy #3, and give remaining copies to the Receiving Facility. 3. Receiving Facility; complete numbers 9 and 10, retain Copy #2 and return Copy #1 to the Generating C&D Processing Facility within two weeks.														
GENERATING C&D PROCESSING FACILITY SECTION														
1. GENERATING C&D PROCESSING FACILITY NAME AND ADDRESS: ECO-SYSTEMS-SAKMAN Rest	2. HAULER NAME AND MAILING ADDRESS ROGAN BROS. SANITATION													
Mailing Address RTE 9W	Mailing Address P.O. BOX 1076													
C,T,V/State/Zip FT MONTGOMERY / TOWN OF HIGHLANDS	C,T,V/State/Zip YONKERS NY 10703													
Telephone Number 845-452-1658	Telephone Number (914) 476 2838													
3. Part 360 Permit Number 3-5520-00071/2 Date of Permit Expiration ___/___/___	5. MATERIALS TRANSPORTED (use additional sheets if necessary) <table style="width:100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 60%; text-align: center;">TYPE</th> <th style="width: 40%; text-align: center;">QUANTITY (indicate tons or cubic yards)</th> </tr> </thead> <tbody> <tr> <td style="text-align: center; border-bottom: 1px solid black;">C&D</td> <td style="text-align: center; border-bottom: 1px solid black;">40yds</td> </tr> <tr> <td style="border-bottom: 1px solid black;"> </td> <td style="border-bottom: 1px solid black;"> </td> </tr> <tr> <td style="border-bottom: 1px solid black;"> </td> <td style="border-bottom: 1px solid black;"> </td> </tr> <tr> <td style="border-bottom: 1px solid black;"> </td> <td style="border-bottom: 1px solid black;"> </td> </tr> <tr> <td style="border-bottom: 1px solid black;"> </td> <td style="border-bottom: 1px solid black;"> </td> </tr> </tbody> </table>		TYPE	QUANTITY (indicate tons or cubic yards)	C&D	40yds								
TYPE	QUANTITY (indicate tons or cubic yards)													
C&D	40yds													
4. DESTINATION FACILITY NAME AND MAILING ADDRESS ROGAN BROS.	(Continuation of Section 5)													
Mailing Address P.O. BOX 1076														
C,T,V/State/Zip YONKERS NY 10703														
Telephone Number (914) 476 2838														
6. GENERATOR'S CERTIFICATION: I hereby affirm under penalty of perjury that information provided on this document and attached statements and exhibits was prepared by me or under my supervision and direction and is true to the best of my knowledge and belief, and that I have the authority as <u>owner of generator</u> (title) of <u>Scene Hudson Inc</u> (Entity) to sign this tracking document pursuant to 6 NYCRR Part 360. I am aware that any false statement made herein is punishable as a Class A misdemeanor pursuant to Section 210.45 of the Penal Law.														
Printed/Typed Name Brian Bannick	Signature 	Mo. Day Year 												
HAULER SECTION														
7. HAULER SECTION (Certification of Receipt of Construction and Demolition Debris as described in item 5)														
Printed/Typed Name JIM MACDONALD	Signature 	Mo. Day Year 11 0 20 09												
8. HAULER DISCREPANCY BOX (Any discrepancies in items 2, 4 or 5 should be noted here and by the item number)														
RECEIVING FACILITY SECTION (Transfer, Recycling, Disposal)														
9. RECEIVING FACILITY SECTION (Certification of Receipt of Construction and Demolition Debris as described in item 5)														
Printed/Typed Name VINNY SABATINI	Signature 	Mo. Day Year 11 0 20 09												
10. RECEIVING FACILITY DISCREPANCY BOX (Any discrepancies in items 2, 4 or 5 should be noted here and by the item no.)														

**CONSTRUCTION AND DEMOLITION DEBRIS
TRACKING DOCUMENT**

Please read all instructions before completing this tracking document

Please TYPE or PRINT clearly

INSTRUCTIONS: 1. Generating C&D Processing Facility; complete numbers 1-6, retain Copy #4 and give remaining copies to the Hauler. 2. Hauler; complete numbers 7 and 8, retain Copy #3, and give remaining copies to the Receiving Facility. 3. Receiving Facility; complete numbers 9 and 10, retain Copy #2 and return Copy #1 to the Generating C&D Processing Facility within two weeks.														
GENERATING C&D PROCESSING FACILITY SECTION														
1. GENERATING C&D PROCESSING FACILITY NAME AND ADDRESS: ECO-SYSTEMS-SARMANU Rest Mailing Address RTE 9W C,T,V/State/Zip FT GOMERY / TOWN OF HIGHLANDS Telephone Number 845-452 1658	2. HAULER NAME AND MAILING ADDRESS ROGAN Bros. Sanitation Mailing Address PO Box 1076 C,T,V/State/Zip YONKERS NY 10703 Telephone Number (914) 476 2838													
3. Part 360 Permit Number 3-5520-00071/2 Date of Permit Expiration ___/___/___	5. MATERIALS TRANSPORTED (use additional sheets if necessary) <table style="width:100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 60%;">TYPE</th> <th style="width: 40%;">QUANTITY (indicate tons or cubic yards)</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">C&D</td> <td style="text-align: center;">50 yards</td> </tr> <tr> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> </tr> </tbody> </table>		TYPE	QUANTITY (indicate tons or cubic yards)	C&D	50 yards								
TYPE			QUANTITY (indicate tons or cubic yards)											
C&D			50 yards											
4. DESTINATION FACILITY NAME AND MAILING ADDRESS Rogan Bros. Sanitation Mailing Address P.O. Box 1076 C,T,V/State/Zip YONKERS NJ 10703 Telephone Number (914) 476 2838														
6. GENERATOR'S CERTIFICATION: I hereby affirm under penalty of perjury that information provided on this document and attached statements and exhibits was prepared by me or under my supervision and direction and is true to the best of my knowledge and belief, and that I have the authority as <u>Agent of generator</u> (title) of <u>Scenic Hudson Inc</u> (Entity) to sign this tracking document pursuant to 6 NYCRR Part 360. I am aware that any false statement made herein is punishable as a Class A misdemeanor pursuant to Section 210.45 of the Penal Law.														
Printed/Typed Name <u>Brian Kramick</u>	Signature <u>Brian Kramick</u>	Mo. Day Year 11 03 09												
HAULER SECTION														
7. HAULER SECTION (Certification of Receipt of Construction and Demolition Debris as described in item 5)														
Printed/Typed Name <u>AL COLAZZI</u>	Signature <u>Al Colazzi</u>	Mo. Day Year 11 03 09												
8. HAULER DISCREPANCY BOX (Any discrepancies in items 2, 4 or 5 should be noted here and by the item number)														
RECEIVING FACILITY SECTION (Transfer, Recycling, Disposal)														
9. RECEIVING FACILITY SECTION (Certification of Receipt of Construction and Demolition Debris as described in item 5)														
Printed/Typed Name <u>Vinny Gabbiani</u>	Signature <u>Vinny Gabbiani</u>	Mo. Day Year 11 03 09												
10. RECEIVING FACILITY DISCREPANCY BOX (Any discrepancies in items 2, 4 or 5 should be noted here and by the item no.)														

**CONSTRUCTION AND DEMOLITION DEBRIS
 TRACKING DOCUMENT**

Please read all instructions before completing this tracking document

Please TYPE or PRINT clearly

INSTRUCTIONS: 1. Generating C&D Processing Facility; complete numbers 1-6, retain Copy #4 and give remaining copies to the Hauler. 2. Hauler; complete numbers 7 and 8, retain Copy #3, and give remaining copies to the Receiving Facility. 3. Receiving Facility; complete numbers 9 and 10, retain Copy #2 and return Copy #1 to the Generating C&D Processing Facility within two weeks.														
GENERATING C&D PROCESSING FACILITY SECTION														
1. GENERATING C&D PROCESSING FACILITY NAME AND ADDRESS: <u>ECO-SYSTEMS-SALMANN REST</u> Mailing Address <u>RTE 9W</u> C,T,V/State/Zip <u>FT MONTGOMERY / TOWN OF HIGHLANDS</u> Telephone Number <u>845-452-1658</u>	2. HAULER NAME AND MAILING ADDRESS <u>ROGAN BROS. SANITATION</u> Mailing Address <u>P.O. Box 1076</u> C,T,V/State/Zip <u>YONKERS NY 10703</u> Telephone Number <u>(914) 476 2838</u>													
3. Part 360 Permit Number <u>3-5520-00071/2</u> Date of Permit Expiration <u> / / </u>	5. MATERIALS TRANSPORTED (use additional sheets if necessary) <table style="width:100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 60%; text-align: center;">TYPE</th> <th style="width: 40%; text-align: center;">QUANTITY (indicate tons or cubic yards)</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;"><u>C&D</u></td> <td style="text-align: center;"><u>40 yds</u></td> </tr> <tr> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> </tr> </tbody> </table>		TYPE	QUANTITY (indicate tons or cubic yards)	<u>C&D</u>	<u>40 yds</u>								
TYPE	QUANTITY (indicate tons or cubic yards)													
<u>C&D</u>	<u>40 yds</u>													
4. DESTINATION FACILITY NAME AND MAILING ADDRESS <u>ROGAN BROS. SANITATION</u> Mailing Address <u>P.O. Box 1076</u> C,T,V/State/Zip <u>YONKERS NY 10703</u> Telephone Number <u>(914) 476 2838</u>														
6. GENERATOR'S CERTIFICATION: I hereby affirm under penalty of perjury that information provided on this document and attached statements and exhibits was prepared by me or under my supervision and direction and is true to the best of my knowledge and belief, and that I have the authority as <u>Asst. of General</u> (title) of <u>Sterco-Tyson Inc</u> (Entity) to sign this tracking document pursuant to 6 NYCRR Part 360. I am aware that any false statement made herein is punishable as a Class A misdemeanor pursuant to Section 210.45 of the Penal Law.														
Printed/Typed Name <u>Brian Barnack</u>	Signature <u>[Signature]</u>	Mo. Day Year <u>11</u> <u>03</u> <u>09</u>												
HAULER SECTION														
7. HAULER SECTION (Certification of Receipt of Construction and Demolition Debris as described in item 5)														
Printed/Typed Name <u>Jose Perez</u>	Signature <u>[Signature]</u>	Mo. Day Year <u>11</u> <u>03</u> <u>09</u>												
8. HAULER DISCREPANCY BOX (Any discrepancies in items 2, 4 or 5 should be noted here and by the item number)														
RECEIVING FACILITY SECTION (Transfer, Recycling, Disposal)														
9. RECEIVING FACILITY SECTION (Certification of Receipt of Construction and Demolition Debris as described in item 5)														
Printed/Typed Name <u>Vinay Sabadini</u>	Signature <u>[Signature]</u>	Mo. Day Year <u>11</u> <u>03</u> <u>09</u>												
10. RECEIVING FACILITY DISCREPANCY BOX (Any discrepancies in items 2, 4 or 5 should be noted here and by the item no.)														

SIGN AND RETURN TO GENERATING C&D PROCESSING FACILITY WITHIN TWO (2) WEEKS

**CONSTRUCTION AND DEMOLITION DEBRIS
TRACKING DOCUMENT**

Please read all instructions before completing this tracking document




Please TYPE or PRINT clearly

INSTRUCTIONS: 1. Generating C&D Processing Facility; complete numbers 1-6, retain Copy #4 and give remaining copies to the Hauler. 2. Hauler; complete numbers 7 and 8, retain Copy #3, and give remaining copies to the Receiving Facility. 3. Receiving Facility; complete numbers 9 and 10, retain Copy #2 and return Copy #1 to the Generating C&D Processing Facility within two weeks.														
GENERATING C&D PROCESSING FACILITY SECTION														
1. GENERATING C&D PROCESSING FACILITY NAME AND ADDRESS: ECO-SYSTEMS - SALMANN REST Mailing Address: RTE 9W C,T,V/State/Zip: TOWN OF FT MONTGOMERY / HIGHLANDS Telephone Number: 845-452 1658	2. HAULER NAME AND MAILING ADDRESS ROGAN BROS. SANITATION Mailing Address: P.O. Box 1076 C,T,V/State/Zip: YONKERS NY 10703 Telephone Number: (914) 476 2838													
3. Part 360 Permit Number 3-5520-00071/2 Date of Permit Expiration: ___/___/___	5. MATERIALS TRANSPORTED (use additional sheets if necessary) <table style="width:100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 60%;">TYPE</th> <th style="width: 40%;">QUANTITY (indicate tons or cubic yards)</th> </tr> </thead> <tbody> <tr> <td style="text-align: center; border-bottom: 1px solid black;">C&D</td> <td style="text-align: center; border-bottom: 1px solid black;">40yds</td> </tr> <tr> <td style="border-bottom: 1px solid black;"> </td> <td style="border-bottom: 1px solid black;"> </td> </tr> <tr> <td style="border-bottom: 1px solid black;"> </td> <td style="border-bottom: 1px solid black;"> </td> </tr> <tr> <td style="border-bottom: 1px solid black;"> </td> <td style="border-bottom: 1px solid black;"> </td> </tr> <tr> <td style="border-bottom: 1px solid black;"> </td> <td style="border-bottom: 1px solid black;"> </td> </tr> </tbody> </table>		TYPE	QUANTITY (indicate tons or cubic yards)	C&D	40yds								
TYPE	QUANTITY (indicate tons or cubic yards)													
C&D	40yds													
4. DESTINATION FACILITY NAME AND MAILING ADDRESS ROGAN BROTHERS SANITATION Mailing Address: P.O. Box 1076 C,T,V/State/Zip: YONKERS, NY 10703 Telephone Number: (914) 476-2838														
6. GENERATOR'S CERTIFICATION: I hereby affirm under penalty of perjury that information provided on this document and attached statements and exhibits was prepared by me or under my supervision and direction and is true to the best of my knowledge and belief, and that I have the authority as <u>Agent of Generator</u> (title) of <u>Scarlottos Inc</u> (Entity) to sign this tracking document pursuant to 6 NYCRR Part 360. I am aware that any false statement made herein is punishable as a Class A misdemeanor pursuant to Section 210.45 of the Penal Law.														
Printed/Typed Name: <u>Brian Blamich</u>	Signature: <u>Brian Blamich</u>	Mo. Day Year: <u>1</u> <u>1</u> <u>03</u> <u>09</u>												
HAULER SECTION														
7. HAULER SECTION (Certification of Receipt of Construction and Demolition Debris as described in item 5)														
Printed/Typed Name: <u>SAL FICARROTTA</u>	Signature: <u>Sal Ficarrotta</u>	Mo. Day Year: <u>1</u> <u>1</u> <u>03</u> <u>09</u>												
8. HAULER DISCREPANCY BOX (Any discrepancies in items 2, 4 or 5 should be noted here and by the item number)														
RECEIVING FACILITY SECTION (Transfer, Recycling, Disposal)														
9. RECEIVING FACILITY SECTION (Certification of Receipt of Construction and Demolition Debris as described in item 5)														
Printed/Typed Name: <u>Vinny Sabatini</u>	Signature: <u>Vinny Sabatini</u>	Mo. Day Year: <u>1</u> <u>1</u> <u>03</u> <u>09</u>												
10. RECEIVING FACILITY DISCREPANCY BOX (Any discrepancies in items 2, 4 or 5 should be noted here and by the item no.)														

**CONSTRUCTION AND DEMOLITION DEBRIS
TRACKING DOCUMENT**

Please read all instructions before completing this tracking document

Please TYPE or PRINT clearly

INSTRUCTIONS: 1. Generating C&D Processing Facility; complete numbers 1-6, retain Copy #4 and give remaining copies to the Hauler. 2. Hauler; complete numbers 7 and 8, retain Copy #3, and give remaining copies to the Receiving Facility. 3. Receiving Facility; complete numbers 9 and 10, retain Copy #2 and return Copy #1 to the Generating C&D Processing Facility within two weeks.												
GENERATING C&D PROCESSING FACILITY SECTION												
1. GENERATING C&D PROCESSING FACILITY NAME AND ADDRESS: ECD-SYSTEMS-SAKMANN Rest	2. HAULER NAME AND MAILING ADDRESS ROGAN BROS. SANITATION											
Mailing Address RTE 9W	Mailing Address P.O. Box 1076											
C,T,V/State/Zip FT MONTGOMERY / TOWN OF HIGHLANDS	C,T,V/State/Zip YONKERS NY 10703											
Telephone Number 845-452-1658	Telephone Number (914) 476-2838											
3. Part 360 Permit Number <u>3-5520-00071/2</u> Date of Permit Expiration <u> </u> / <u> </u> / <u> </u>	5. MATERIALS TRANSPORTED (use additional sheets if necessary) <table style="width:100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 60%;">TYPE</th> <th style="width: 40%;">QUANTITY (indicate tons or cubic yards)</th> </tr> </thead> <tbody> <tr> <td style="text-align: center; border-bottom: 1px solid black;">C&D</td> <td style="text-align: center; border-bottom: 1px solid black;">40yds</td> </tr> <tr> <td style="border-bottom: 1px solid black;"> </td> <td style="border-bottom: 1px solid black;"> </td> </tr> <tr> <td style="border-bottom: 1px solid black;"> </td> <td style="border-bottom: 1px solid black;"> </td> </tr> <tr> <td style="border-bottom: 1px solid black;"> </td> <td style="border-bottom: 1px solid black;"> </td> </tr> </tbody> </table>		TYPE	QUANTITY (indicate tons or cubic yards)	C&D	40yds						
TYPE			QUANTITY (indicate tons or cubic yards)									
C&D			40yds									
4. DESTINATION FACILITY NAME AND MAILING ADDRESS ROGAN BROS. SANITATION	(This area is covered by item 5)											
Mailing Address P.O. Box 1076												
C,T,V/State/Zip YONKERS NY 10703												
Telephone Number (914) 476-2838												
6. GENERATOR'S CERTIFICATION: I hereby affirm under penalty of perjury that information provided on this document and attached statements and exhibits was prepared by me or under my supervision and direction and is true to the best of my knowledge and belief, and that I have the authority as <u>Agent of generator</u> (title) of <u>Scenic Hudson, Inc</u> (Entity) to sign this tracking document pursuant to 6 NYCRR Part 360. I am aware that any false statement made herein is punishable as a Class A misdemeanor pursuant to Section 210.45 of the Penal Law.												
Printed/Typed Name Brian Berman	Signature 	Mo. Day Year 11 03 09										
HAULER SECTION												
7. HAULER SECTION (Certification of Receipt of Construction and Demolition Debris as described in item 5)												
Printed/Typed Name SAL FICAROTTA	Signature 	Mo. Day Year 11 03 09										
8. HAULER DISCREPANCY BOX (Any discrepancies in items 2, 4 or 5 should be noted here and by the item number)												
RECEIVING FACILITY SECTION (Transfer, Recycling, Disposal)												
9. RECEIVING FACILITY SECTION (Certification of Receipt of Construction and Demolition Debris as described in item 5)												
Printed/Typed Name Vinny Sabatini	Signature 	Mo. Day Year 11 03 09										
10. RECEIVING FACILITY DISCREPANCY BOX (Any discrepancies in items 2, 4 or 5 should be noted here and by the item no.)												

**CONSTRUCTION AND DEMOLITION DEBRIS
TRACKING DOCUMENT**

Please read all instructions before completing this tracking document

Please TYPE or PRINT clearly

INSTRUCTIONS:

1. Generating C&D Processing Facility; complete numbers 1-6, retain Copy #4 and give remaining copies to the Hauler.
2. Hauler; complete numbers 7 and 8, retain Copy #3, and give remaining copies to the Receiving Facility.
3. Receiving Facility; complete numbers 9 and 10, retain Copy #2 and return Copy #1 to the Generating C&D Processing Facility within two weeks.

GENERATING C&D PROCESSING FACILITY SECTION

1. GENERATING C&D PROCESSING FACILITY NAME AND ADDRESS:

ECO-SYSTEMS-SAKMANN REST

Mailing Address RTE 9W

C,T,V/State/Zip FT MONTEAGUE / TOWN OF HIGHLANDS

Telephone Number 845-452-1658

2. HAULER NAME AND MAILING ADDRESS

ROGAN Bros Sanitation

Mailing Address P.O. BOX 1076

C,T,V/State/Zip YONKERS, NY 10703

Telephone Number (914) 476 2838

3. Part 360 Permit Number 3-5520-00071/2

Date of Permit Expiration ___/___/___

5. MATERIALS TRANSPORTED (use additional sheets if necessary)

TYPE	QUANTITY (indicate tons or cubic yards)
C&D	41 yds

4. DESTINATION FACILITY NAME AND MAILING ADDRESS

ROGAN BROS SANITATION

Mailing Address

P.O. BOX 1076

C,T,V/State/Zip

YONKERS NY 10703

Telephone Number

(914) 476 2838

6. GENERATOR'S CERTIFICATION:

I hereby affirm under penalty of perjury that information provided on this document and attached statements and exhibits was prepared by me or under my supervision and direction and is true to the best of my knowledge and belief, and that I have the authority as Agent of generator (title) of Scenic Hudson (Entity) to sign this tracking document pursuant to 6 NYCRR Part 360. I am aware that any false statement made herein is punishable as a Class A misdemeanor pursuant to Section 210.45 of the Penal Law.

Printed/Typed Name

Ann Barich

Signature

Ann Barich

Mo. Day Year

11 | 03 | 09

HAULER SECTION

7. HAULER SECTION (Certification of Receipt of Construction and Demolition Debris as described in item 5)

Printed/Typed Name

AL COLAZZI

Signature

Al Colazzi

Mo. Day Year

11 | 10 | 09

8. HAULER DISCREPANCY BOX (Any discrepancies in items 2, 4 or 5 should be noted here and by the item number)

RECEIVING FACILITY SECTION (Transfer, Recycling, Disposal)

9. RECEIVING FACILITY SECTION (Certification of Receipt of Construction and Demolition Debris as described in item 5)

Printed/Typed Name

Vinny Sabatini

Signature

Vinny Sabatini

Mo. Day Year

11 | 10 | 09

10. RECEIVING FACILITY DISCREPANCY BOX (Any discrepancies in items 2, 4 or 5 should be noted here and by the item no.)

**CONSTRUCTION AND DEMOLITION DEBRIS
TRACKING DOCUMENT**

Please read all instructions before completing this tracking document

Please TYPE or PRINT clearly

INSTRUCTIONS:

1. Generating C&D Processing Facility; complete numbers 1-6, retain Copy #4 and give remaining copies to the Hauler.
2. Hauler; complete numbers 7 and 8, retain Copy #3, and give remaining copies to the Receiving Facility.
3. Receiving Facility; complete numbers 9 and 10, retain Copy #2 and return Copy #1 to the Generating C&D Processing Facility within two weeks.

GENERATING C&D PROCESSING FACILITY SECTION

1. GENERATING C&D PROCESSING FACILITY NAME AND ADDRESS:

ECO-SYSTEMS-SAKMANN REST

Mailing Address 12E 9W

C,T,V/State/Zip FT MONTGOMERY / TOWN OF HIGHLANDS

Telephone Number

2. HAULER NAME AND MAILING ADDRESS

ROGAN BROS. Sanitation

Mailing Address PO BOX 1076

C,T,V/State/Zip YONKERS NY 10703

Telephone Number (914) 476 2838

3. Part 360 Permit Number 3-5520-00071/2

Date of Permit Expiration ___/___/___

5. MATERIALS TRANSPORTED (use additional sheets if necessary)

TYPE	QUANTITY (indicate tons or cubic yards)
C&D	52 yds

4. DESTINATION FACILITY NAME AND MAILING ADDRESS

ROGAN BROS. SANITATION

Mailing Address PO BOX 1076

C,T,V/State/Zip YONKERS NY 10703

Telephone Number (914) 476 2838

6. GENERATOR'S CERTIFICATION:

I hereby affirm under penalty of perjury that information provided on this document and attached statements and exhibits was prepared by me or under my supervision and direction and is true to the best of my knowledge and belief, and that I have the authority as Asst. Director (title) of Scene Hudson (Entity) to sign this tracking document pursuant to 6 NYCRR Part 360. I am aware that any false statement made herein is punishable as a Class A misdemeanor pursuant to Section 210.45 of the Penal Law.

Printed/Typed Name

Brian Branick

Signature

Brian Branick

No. Day Year

11 03 09

HAULER SECTION

7. HAULER SECTION (Certification of Receipt of Construction and Demolition Debris as described in item 5)

Printed/Typed Name

STEVE RUSSELL

Signature

Steve Russell

No. Day Year

11 03 09

8. HAULER DISCREPANCY BOX (Any discrepancies in items 2, 4 or 5 should be noted here and by the item number)

RECEIVING FACILITY SECTION (Transfer, Recycling, Disposal)

9. RECEIVING FACILITY SECTION (Certification of Receipt of Construction and Demolition Debris as described in item 5)

Printed/Typed Name

Vinny Sabatini

Signature

Vinny Sabatini

No. Day Year

11 03 09

10. RECEIVING FACILITY DISCREPANCY BOX (Any discrepancies in items 2, 4 or 5 should be noted here and by the item no.)

**CONSTRUCTION AND DEMOLITION DEBRIS
TRACKING DOCUMENT**

Please read all instructions before completing this tracking document

Please TYPE or PRINT clearly

INSTRUCTIONS:

1. Generating C&D Processing Facility; complete numbers 1-6, retain Copy #4 and give remaining copies to the Hauler.
2. Hauler; complete numbers 7 and 8, retain Copy #3, and give remaining copies to the Receiving Facility.
3. Receiving Facility; complete numbers 9 and 10, retain Copy #2 and return Copy #1 to the Generating C&D Processing Facility within two weeks.

GENERATING C&D PROCESSING FACILITY SECTION

1. GENERATING C&D PROCESSING FACILITY NAME AND ADDRESS:

ECO-SYSTEMS/SAKUNN REST

Mailing Address RTE 9W

C,T,V/State/Zip FT MONTGOMERY / TOWN OF HIGHLANDS

Telephone Number 845-452-1658

2. HAULER NAME AND MAILING ADDRESS

ROGAN BOS. SANITATION

Mailing Address P.O. BOX 1076

C,T,V/State/Zip YONKERS NY 10703

Telephone Number (914) 476 2838

3. Part 360 Permit Number 3-5520-00071/2

Date of Permit Expiration ___/___/___

5. MATERIALS TRANSPORTED (use additional sheets if necessary)

TYPE	QUANTITY (indicate tons or cubic yards)
C&D	40 yds

4. DESTINATION FACILITY NAME AND MAILING ADDRESS

ROGAN BOS. SANITATION

Mailing Address P.O. Box 1076

C,T,V/State/Zip YONKERS NY 10703

Telephone Number 914 476 2838

6. GENERATOR'S CERTIFICATION:

I hereby affirm under penalty of perjury that information provided on this document and attached statements and exhibits was prepared by me or under my supervision and direction and is true to the best of my knowledge and belief, and that I have the authority as President/owner (title) of Scenic Hudson (Entity) to sign this tracking document pursuant to 6 NYCRR Part 360. I am aware that any false statement made herein is punishable as a Class A misdemeanor pursuant to Section 210.45 of the Penal Law.

Printed/Typed Name Brian Branick

Signature *Brian Branick*

Mo. Day Year 11 | 05 | 09

HAULER SECTION

7. HAULER SECTION (Certification of Receipt of Construction and Demolition Debris as described in item 5)

Printed/Typed Name SAL ZAFFUTO

Signature *S. Zaffuto*

Mo. Day Year 11 | 05 | 09

8. HAULER DISCREPANCY BOX (Any discrepancies in items 2, 4 or 5 should be noted here and by the item number)

RECEIVING FACILITY SECTION (Transfer, Recycling, Disposal)

9. RECEIVING FACILITY SECTION (Certification of Receipt of Construction and Demolition Debris as described in item 5)

Printed/Typed Name Vinny Sabatini

Signature *Vinny Sabatini*




Mo. Day Year 11 | 05 | 09

10. RECEIVING FACILITY DISCREPANCY BOX (Any discrepancies in items 2, 4 or 5 should be noted here and by the item no.)

**CONSTRUCTION AND DEMOLITION DEBRIS
TRACKING DOCUMENT**

Please read all instructions before completing this tracking document

Please TYPE or PRINT clearly

INSTRUCTIONS: 1. Generating C&D Processing Facility; complete numbers 1-6, retain Copy #4 and give remaining copies to the Hauler. 2. Hauler; complete numbers 7 and 8, retain Copy #3, and give remaining copies to the Receiving Facility. 3. Receiving Facility; complete numbers 9 and 10, retain Copy #2 and return Copy #1 to the Generating C&D Processing Facility within two weeks.												
GENERATING C&D PROCESSING FACILITY SECTION												
1. GENERATING C&D PROCESSING FACILITY NAME AND ADDRESS: ECO-SYSTEMS-SAKMANN REST Mailing Address: RTE 9W C,T,V/State/Zip: FT MONTGOMERY / TOWN OF HIGHLANDS NY Telephone Number: 845-452-1658	2. HAULER NAME AND MAILING ADDRESS ROGAN BROS. SANITATION Mailing Address: PO BOX 1076 C,T,V/State/Zip: YONKERS NY 10703 Telephone Number: (914) 476-2838											
3. Part 360 Permit Number 3-5520-00071/2 / 160W10 Date of Permit Expiration ___/___/___	5. MATERIALS TRANSPORTED (use additional sheets if necessary) <table style="width:100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 60%;">TYPE</th> <th style="width: 40%;">QUANTITY (indicate tons or cubic yards)</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">CONCRETE</td> <td style="text-align: center;">35 yds</td> </tr> <tr> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> </tr> </tbody> </table>		TYPE	QUANTITY (indicate tons or cubic yards)	CONCRETE	35 yds						
TYPE	QUANTITY (indicate tons or cubic yards)											
CONCRETE	35 yds											
4. DESTINATION FACILITY NAME AND MAILING ADDRESS A.R.J.R. TRUCKING CORP Mailing Address: PO BOX 1076 C,T,V/State/Zip: YONKERS NY 10703 Telephone Number: (914) 476-2838												
6. GENERATOR'S CERTIFICATION: I hereby affirm under penalty of perjury that information provided on this document and attached statements and exhibits was prepared by me or under my supervision and direction and is true to the best of my knowledge and belief, and that I have the authority as <u>Gen. Mgr.</u> (title) of <u>Sacramento</u> (Entity) to sign this tracking document pursuant to 6 NYCRR Part 360. I am aware that any false statement made herein is punishable as a Class A misdemeanor pursuant to Section 210.45 of the Penal Law.												
Printed/Typed Name <u>Bruce Barnick</u>	Signature 	No. <u>11</u> Day <u>03</u> Year <u>09</u>										
HAULER SECTION												
7. HAULER SECTION (Certification of Receipt of Construction and Demolition Debris as described in item 5)												
Printed/Typed Name <u>Sal Ficarrota</u>	Signature 	No. <u>11</u> Day <u>03</u> Year <u>09</u>										
8. HAULER DISCREPANCY BOX (Any discrepancies in items 2, 4 or 5 should be noted here and by the item number)												
RECEIVING FACILITY SECTION (Transfer, Recycling, Disposal)												
9. RECEIVING FACILITY SECTION (Certification of Receipt of Construction and Demolition Debris as described in item 5)												
Printed/Typed Name <u>Joe Ragusso</u>	Signature 	No. <u>11</u> Day <u>03</u> Year <u>09</u>										
10. RECEIVING FACILITY DISCREPANCY BOX (Any discrepancies in items 2, 4 or 5 should be noted here and by the item no.)												

**CONSTRUCTION AND DEMOLITION DEBRIS
TRACKING DOCUMENT**

Please read all instructions before completing this tracking document




Please TYPE or PRINT clearly

INSTRUCTIONS: 1. Generating C&D Processing Facility; complete numbers 1-6, retain Copy #4 and give remaining copies to the Hauler. 2. Hauler; complete numbers 7 and 8, retain Copy #3, and give remaining copies to the Receiving Facility. 3. Receiving Facility; complete numbers 9 and 10, retain Copy #2 and return Copy #1 to the Generating C&D Processing Facility within two weeks.														
GENERATING C&D PROCESSING FACILITY SECTION														
1. GENERATING C&D PROCESSING FACILITY NAME AND ADDRESS: ECO-SYSTEMS-SAKMANN REST Mailing Address: Rte 9W C,T,V/State/Zip: ET MONTGOMERY / TOWN OF HIGHLANDS Telephone Number: 845-452-1658	2. HAULER NAME AND MAILING ADDRESS FOGAN BROS. SANITATION Mailing Address: PO BOX 1076 C,T,V/State/Zip: YONKERS NY 10703 Telephone Number: (914) 476-2838													
3. Part 360 Permit Number 3-5520-00071/2/60W10 Date of Permit Expiration ___/___/___	5. MATERIALS TRANSPORTED (use additional sheets if necessary) <table border="1"> <thead> <tr> <th>TYPE</th> <th>QUANTITY (indicate tons or cubic yards)</th> </tr> </thead> <tbody> <tr> <td>CONCRETE</td> <td>35 yds</td> </tr> <tr> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> </tr> </tbody> </table>		TYPE	QUANTITY (indicate tons or cubic yards)	CONCRETE	35 yds								
TYPE	QUANTITY (indicate tons or cubic yards)													
CONCRETE	35 yds													
4. DESTINATION FACILITY NAME AND MAILING ADDRESS A.R.J.R. TRUCKING Mailing Address: PO BOX 1076 C,T,V/State/Zip: YONKERS NY 10703 Telephone Number: (914) 476-2838														
6. GENERATOR'S CERTIFICATION: I hereby affirm under penalty of perjury that information provided on this document and attached statements and exhibits was prepared by me or under my supervision and direction and is true to the best of my knowledge and belief, and that I have the authority as <u>Agent of generator</u> (title) of <u>Seneca Hudson</u> (Entity) to sign this tracking document pursuant to 6 NYCRR Part 360. I am aware that any false statement made herein is punishable as a Class A misdemeanor pursuant to Section 210.45 of the Penal Law.														
Printed/Typed Name Brian Bassuch	Signature <i>Brian Bassuch</i>	Mo. Day Year 11 03 09												
HAULER SECTION														
7. HAULER SECTION (Certification of Receipt of Construction and Demolition Debris as described in item 5)														
Printed/Typed Name Jim MacDonald	Signature <i>Jim MacDonald</i>	Mo. Day Year 11 03 09												
8. HAULER DISCREPANCY BOX (Any discrepancies in items 2, 4 or 5 should be noted here and by the item number)														
RECEIVING FACILITY SECTION (Transfer, Recycling, Disposal)														
9. RECEIVING FACILITY SECTION (Certification of Receipt of Construction and Demolition Debris as described in item 5)														
Printed/Typed Name Joe Ragusso	Signature <i>Joe Ragusso</i>	Mo. Day Year 11 03 09												
10. RECEIVING FACILITY DISCREPANCY BOX (Any discrepancies in items 2, 4 or 5 should be noted here and by the item no.)														

**CONSTRUCTION AND DEMOLITION DEBRIS
 TRACKING DOCUMENT**

Please read all instructions before completing this tracking document




Please TYPE or PRINT clearly

INSTRUCTIONS: 1. Generating C&D Processing Facility; complete numbers 1-6, retain Copy #4 and give remaining copies to the Hauler. 2. Hauler; complete numbers 7 and 8, retain Copy #3, and give remaining copies to the Receiving Facility. 3. Receiving Facility; complete numbers 9 and 10, retain Copy #2 and return Copy #1 to the Generating C&D Processing Facility within two weeks.														
GENERATING C&D PROCESSING FACILITY SECTION														
1. GENERATING C&D PROCESSING FACILITY NAME AND ADDRESS: ECC-SYSTEMS-SALMON REST	2. HAULER NAME AND MAILING ADDRESS ROGAN BROS. SANITATION													
Mailing Address RTE 9W	Mailing Address PO Box 1076													
C,T,V/State/Zip ET MONTGOMERY / TOWN OF HIGHLANDS	C,T,V/State/Zip YONKERS NY 10703													
Telephone Number 845-452-1658	Telephone Number (914) 476-2838													
3. Part 360 Permit Number 3-5520-00071/2 / 60W10 Date of Permit Expiration 1/1/11	5. MATERIALS TRANSPORTED (use additional sheets if necessary) <table style="width:100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 60%; text-align: center;">TYPE</th> <th style="width: 40%; text-align: center;">QUANTITY (indicate tons or cubic yards)</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">Concrete</td> <td style="text-align: center;">35 yds</td> </tr> <tr> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> </tr> </tbody> </table>		TYPE	QUANTITY (indicate tons or cubic yards)	Concrete	35 yds								
TYPE	QUANTITY (indicate tons or cubic yards)													
Concrete	35 yds													
4. DESTINATION FACILITY NAME AND MAILING ADDRESS A.R.J.R. TRUCKING	(Continuation of item 5)													
Mailing Address PO Box 1076														
C,T,V/State/Zip YONKERS NY 10703														
Telephone Number 914 476 2838														
6. GENERATOR'S CERTIFICATION: I hereby affirm under penalty of perjury that information provided on this document and attached statements and exhibits was prepared by me or under my supervision and direction and is true to the best of my knowledge and belief, and that I have the authority as Asst of Gen Sec (title) of Sec of Env Con (Entity) to sign this tracking document pursuant to 6 NYCRR Part 360. I am aware that any false statement made herein is punishable as a Class A misdemeanor pursuant to Section 210.45 of the Penal Law.														
Printed/Typed Name Brian Barick	Signature 	Mo. Day Year 11 05 09												
HAULER SECTION														
7. HAULER SECTION (Certification of Receipt of Construction and Demolition Debris as described in item 5)														
Printed/Typed Name JOSE PEREZ	Signature 	Mo. Day Year 11 05 09												
8. HAULER DISCREPANCY BOX (Any discrepancies in items 2, 4 or 5 should be noted here and by the item number)														
RECEIVING FACILITY SECTION (Transfer, Recycling, Disposal)														
9. RECEIVING FACILITY SECTION (Certification of Receipt of Construction and Demolition Debris as described in item 5)														
Printed/Typed Name Joe Ragusso	Signature 	Mo. Day Year 11 05 09												
10. RECEIVING FACILITY DISCREPANCY BOX (Any discrepancies in items 2, 4 or 5 should be noted here and by the item no.)														

**CONSTRUCTION AND DEMOLITION DEBRIS
TRACKING DOCUMENT**

Please read all instructions before completing this tracking document

Please TYPE or PRINT clearly

INSTRUCTIONS: 1. Generating C&D Processing Facility; complete numbers 1-6, retain Copy #4 and give remaining copies to the Hauler. 2. Hauler; complete numbers 7 and 8, retain Copy #3, and give remaining copies to the Receiving Facility. 3. Receiving Facility; complete numbers 9 and 10, retain Copy #2 and return Copy #1 to the Generating C&D Processing Facility within two weeks.												
GENERATING C&D PROCESSING FACILITY SECTION												
1. GENERATING C&D PROCESSING FACILITY NAME AND ADDRESS: ECO-SYSTEMS / SAEMANN ROST	2. HAULER NAME AND MAILING ADDRESS ROGAN BROS. SANITATION											
Mailing Address RTE 9W	Mailing Address P.O. BOX 1076											
C,T,V/State/Zip FT MONTGOMERY / TOWN OF HIGHLANDS	C,T,V/State/Zip YONKERS NY 10703											
Telephone Number 845-452-1658	Telephone Number (914) 476 2838											
3. Part 360 Permit Number 3-5520-00071/2/100W10 Date of Permit Expiration ___/___/___	5. MATERIALS TRANSPORTED (use additional sheets if necessary) <table style="width:100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 60%; text-align: center;">TYPE</th> <th style="width: 40%; text-align: center;">QUANTITY (indicate tons or cubic yards)</th> </tr> </thead> <tbody> <tr> <td style="text-align: center; border-bottom: 1px solid black;">CONCRETE</td> <td style="text-align: center; border-bottom: 1px solid black;">35 yds</td> </tr> <tr> <td style="border-bottom: 1px solid black;"> </td> <td style="border-bottom: 1px solid black;"> </td> </tr> <tr> <td style="border-bottom: 1px solid black;"> </td> <td style="border-bottom: 1px solid black;"> </td> </tr> <tr> <td style="border-bottom: 1px solid black;"> </td> <td style="border-bottom: 1px solid black;"> </td> </tr> </tbody> </table>		TYPE	QUANTITY (indicate tons or cubic yards)	CONCRETE	35 yds						
TYPE	QUANTITY (indicate tons or cubic yards)											
CONCRETE	35 yds											
4. DESTINATION FACILITY NAME AND MAILING ADDRESS A.R.J.R. TRUCKING	(Continuation of item 5)											
Mailing Address P.O. BOX 1076												
C,T,V/State/Zip YONKERS NY 10703												
Telephone Number 914 476 2838												
6. GENERATOR'S CERTIFICATION: I hereby affirm under penalty of perjury that information provided on this document and attached statements and exhibits was prepared by me or under my supervision and direction and is true to the best of my knowledge and belief, and that I have the authority as General Manager (title) of SAEMANN ROST (Entity) to sign this tracking document pursuant to 6 NYCRR Part 360. I am aware that any false statement made herein is punishable as a Class A misdemeanor pursuant to Section 210.45 of the Penal Law.												
Printed/Typed Name Brian Baumh	Signature 	Mo. Day Year 11 05 09										
HAULER SECTION												
7. HAULER SECTION (Certification of Receipt of Construction and Demolition Debris as described in item 5)												
Printed/Typed Name DOUG COSTA	Signature 	Mo. Day Year 11 05 09										
8. HAULER DISCREPANCY BOX (Any discrepancies in items 2, 4 or 5 should be noted here and by the item number)												
RECEIVING FACILITY SECTION (Transfer, Recycling, Disposal)												
9. RECEIVING FACILITY SECTION (Certification of Receipt of Construction and Demolition Debris as described in item 5)												
Printed/Typed Name Joe Ragusso	Signature 	Mo. Day Year 11 05 09										
10. RECEIVING FACILITY DISCREPANCY BOX (Any discrepancies in items 2, 4 or 5 should be noted here and by the item no.)												

**CONSTRUCTION AND DEMOLITION DEBRIS
TRACKING DOCUMENT**

Please read all instructions before completing this tracking document

Please TYPE or PRINT clearly

INSTRUCTIONS: 1. Generating C&D Processing Facility; complete numbers 1-6, retain Copy #4 and give remaining copies to the Hauler. 2. Hauler; complete numbers 7 and 8, retain Copy #3, and give remaining copies to the Receiving Facility. 3. Receiving Facility; complete numbers 9 and 10, retain Copy #2 and return Copy #1 to the Generating C&D Processing Facility within two weeks.												
GENERATING C&D PROCESSING FACILITY SECTION												
1. GENERATING C&D PROCESSING FACILITY NAME AND ADDRESS: LECO-SYSTEMS-SAKMANN Rest Mailing Address Rte 9W C,T,V/State/Zip FT MONTAIGNEY / TOWN OF HIGHLANDS Telephone Number 845 452 1658	2. HAULER NAME AND MAILING ADDRESS ROGAN BIOS-SANITATION Mailing Address P.O. Box 1076 C,T,V/State/Zip Yonkers NY 10703 Telephone Number (914) 476 2838											
3. Part 360 Permit Number 3-5520-00071/2 / 100W10 Date of Permit Expiration ___/___/___	5. MATERIALS TRANSPORTED (use additional sheets if necessary) <table style="width:100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 60%; text-align: center;">TYPE</th> <th style="width: 40%; text-align: center;">QUANTITY (indicate tons or cubic yards)</th> </tr> </thead> <tbody> <tr> <td style="text-align: center; border-bottom: 1px solid black;">concrete</td> <td style="text-align: center; border-bottom: 1px solid black;">35 yds</td> </tr> <tr> <td style="text-align: center; border-bottom: 1px solid black;"> </td> <td style="text-align: center; border-bottom: 1px solid black;"> </td> </tr> <tr> <td style="text-align: center; border-bottom: 1px solid black;"> </td> <td style="text-align: center; border-bottom: 1px solid black;"> </td> </tr> <tr> <td style="text-align: center; border-bottom: 1px solid black;"> </td> <td style="text-align: center; border-bottom: 1px solid black;"> </td> </tr> </tbody> </table>		TYPE	QUANTITY (indicate tons or cubic yards)	concrete	35 yds						
TYPE	QUANTITY (indicate tons or cubic yards)											
concrete	35 yds											
4. DESTINATION FACILITY NAME AND MAILING ADDRESS A.R.J.R. TRUCKING Mailing Address P.O. Box 1076 C,T,V/State/Zip YONKERS NY 10703 Telephone Number (914) 476 2838												
6. GENERATOR'S CERTIFICATION: I hereby affirm under penalty of perjury that information provided on this document and attached statements and exhibits was prepared by me or under my supervision and direction and is true to the best of my knowledge and belief, and that I have the authority as <u>Ken Gendron</u> (title) of <u>LeCo Systems</u> (Entity) to sign this tracking document pursuant to 6 NYCRR Part 360. I am aware that any false statement made herein is punishable as a Class A misdemeanor pursuant to Section 210.45 of the Penal Law.												
Printed/Typed Name <u>Brian Bunn</u>	Signature <u>Brian Bunn</u>	Mo. Day Year <u>11</u> <u>05</u> <u>09</u>										
HAULER SECTION												
7. HAULER SECTION (Certification of Receipt of Construction and Demolition Debris as described in item 5)												
Printed/Typed Name <u>Steve Russillo</u>	Signature <u>Steve Russillo</u>	Mo. Day Year <u>11</u> <u>05</u> <u>09</u>										
8. HAULER DISCREPANCY BOX (Any discrepancies in items 2, 4 or 5 should be noted here and by the item number)												
RECEIVING FACILITY SECTION (Transfer, Recycling, Disposal)												
9. RECEIVING FACILITY SECTION (Certification of Receipt of Construction and Demolition Debris as described in item 5)												
Printed/Typed Name <u>Joe Ragusa</u>	Signature <u>Joe Ragusa</u>	Mo. Day Year <u>11</u> <u>05</u> <u>09</u>										
10. RECEIVING FACILITY DISCREPANCY BOX (Any discrepancies in items 2, 4 or 5 should be noted here and by the item no.)												



ATTACHMENT E

Laboratory Report



LONG ISLAND ANALYTICAL LABORATORIES, INC. DATA REPORTING FLAGS

For reporting results, the following "Flags" are used:

- A: Time not supplied by client, may have exceeded holding time
- B: Holding time exceeded, results cannot be used for regulatory purposes
- C: Minimum detection limit raised due to matrix interference
- D: Minimum detection limit raised due to target compound interference
- E: Minimum detection limit raised due to non-target compound interference
- F: Minimum detection limit raised due to insufficient sample volume
- G: Sample received in incorrect container
- H: Sample not preserved, corrected upon receipt
- I: Dilution Water does not meet QC Criteria
- J: Estimated concentration, exceeds calibration range
- K: Target compound found in blank
- L: Subcontractor ELAP #11398
- M: Subcontractor ELAP #10320
- N: Subcontractor NVLAP #102047.0
- O: Subcontractor AIHA #103005
- P: Subcontractor A2LA 2004-01
- Q: Subcontractor ELAP #11026
- R: Subcontractor ELAP #10155
- S: Subcontractor ELAP #11501
- T: Subcontractor CTC
- U: Subcontractor ELAP #11685
- V: QC affected by matrix
- W: Subcontractor ELAP #10248
- X: QC does not meet acceptance criteria
- Y: Sample container received with head space
- Z: Insufficient sample volume received
- AA: Preliminary results, cannot be used for regulatory purposes.
- BB: Spike recovery does not meet QC criteria due to high target concentration
- CC: Data reported below the lower limit of quantitation and should be considered to have an increased quantitative uncertainty.
- DD: Sampling information not supplied and/or sample not taken by qualified technician, therefore verifiability of the report is limited to results only. Report cannot be used for regulatory purposes.
- EE: Subcontractor ELAP : #11777
- FF: Unable to verify that the wipe samples submitted conform to ASTM E1792 or specifications issued by the EPA.
- GG: Level found exceeds the maximum contaminant level (MCL) as set by local, state or federal agencies.
- HH: Subcontractor ELAP #10750
- II: Subcontractor ELAP #10145
- JJ: Subcontractor ELAP #11838
- KK: Cassette received without tap(s)
- LL: Spike duplicate recovery out of range due to matrix inconsistency
- MM: Estimated value, result is less than the sample quantitation limit but greater than zero.

Sorry for delay!

Attn: ~~Joe~~ Aida

of 16 pages

I was
a 914
#

Client: Northbrook Contracting	Client ID: Bronx/Yonkers (Rogan Bros.)
Date received: 5/1/09	Laboratory ID: 1178399
Date extracted: 5/4/09	Matrix: Soil
Date analyzed: 5/4/09	ELAP #: 11693

VOLATILE ANALYSIS

PARAMETER	CAS No.	MDL ug/kg	RESULTS ug/kg	FLAG
1,1,1-TRICHLOROETHANE	71-55-6	5.27	<5.27	
1,1-DICHLOROETHANE	75-34-3	5.27	<5.27	
1,1-DICHLOROETHENE	75-35-4	5.27	<5.27	
1,2-DICHLOROBENZENE	98-50-1	5.27	<5.27	
1,2-DICHLOROETHANE	107-08-2	5.27	<5.27	
cis[Z]-1,2-DICHLOROETHENE	158-58-2	5.27	<5.27	
trans[E]-1,2-DICHLOROETHENE	158-60-5	5.27	<5.27	
1,3-DICHLOROBENZENE	541-73-1	5.27	<5.27	
1,4-DICHLOROBENZENE	108-46-7	5.27	<5.27	
ACETONE	67-64-1	52.70	<52.70	
BENZENE	71-43-2	5.27	<5.27	
n-BUTYLBENZENE	104-51-8	5.27	<5.27	
CARBON TETRACHLORIDE	68-23-5	5.27	<5.27	
CHLOROBENZENE	108-90-7	5.27	<5.27	
CHLOROFORM	67-68-3	5.27	<5.27	
ETHYLBENZENE	100-41-4	5.27	<5.27	
2-BUTANONE (MEK)	78-93-3	10.50	<10.50	
MTBE	1634-04-4	5.27	<5.27	
METHYLENE CHLORIDE	75-09-2	5.27	5.58	K
n-PROPYLBENZENE	103-65-1	5.27	<5.27	
sec-BUTYLBENZENE	135-98-8	5.27	<5.27	
tert-BUTYLBENZENE	98-06-6	5.27	<5.27	
TETRACHLOROETHYLENE	127-18-4	5.27	<5.27	
TOLUENE	108-88-3	5.27	<5.27	
TRICHLOROETHYLENE	79-01-6	5.27	<5.27	
1,2,4-TRIMETHYLBENZENE	85-63-5	5.27	<5.27	
1,3,5-TRIMETHYLBENZENE	108-87-8	5.27	<5.27	
CHLOROETHENE (VINYL CHLORIDE)	75-01-4	5.27	<5.27	
p&m-XYLENE	1330-20-7	10.50	<10.50	
o-XYLENE	95-47-6	5.27	<5.27	
1,4-DIOXANE	123-81-1	5.27	<5.27	

MDL = Minimum Detection Limit
EPA METHOD 8260

Calculated on a dry weight basis

Michael Veraldi

Michael Veraldi-Laboratory Director



LONG
ISLAND
ANALYTICAL
LABORATORIES INC.

110 Collin Drive • Holbrook, New York 11741

Phone (831) 472-3400 • Fax (831) 472-8508 • Email: LIAL@lialinc.com

8 of 16 pages

Client: Northbrook Contracting	Client ID: Bronx/Yonkers (Rogan Bros.)
Date received: 5/1/09	Laboratory ID: 1176399
Date extracted: 5/5/09	Matrix: Soil
Date analyzed: 5/5/09	ELAP #: 11693

SEMI-VOLATILE ANALYSIS

PARAMETER	CAS No.	MDL ug/kg	RESULTS ug/kg	FLAG
HEXACHLOROBENZENE	118-74-1	42.20	<42.20	CC
ACENAPHTHENE	83-32-9	42.20	<42.20	CC
ACENAPHTHYLENE	208-96-8	42.20	64	CC
ANTHRACENE	120-12-7	42.20	123	CC
BENZO-a-ANTHRACENE	56-55-3	42.20	463	
BENZO-a-PYRENE	50-32-8	42.20	289	CC
BENZO-b-FLUOROANTHENE	205-99-2	42.20	454	
BENZO-g,h,i-PERYLENE	191-24-2	42.20	147	CC
BENZO-k-FLUOROANTHENE	207-08-9	42.20	187	CC
CHRYSENE	218-01-9	42.20	394	
DIBENZO-a,h-ANTHRACENE	53-70-3	42.20	49.90	CC
FLUORANTHENE	206-44-0	42.20	869	
FLUORENE	86-73-7	42.20	<42.20	CC
INDENO(1,2,3-c,d)PYRENE	193-39-5	42.20	164	CC
3+4-METHYLPHENOL	15831-10-4	42.20	<42.20	CC
2-METHYLPHENOL	95-48-7	42.20	<42.20	CC
NAPHTHALENE	91-20-3	42.20	<42.20	CC
PENTACHLOROPHENOL	87-86-5	42.20	<42.20	CC
PHENANTHRENE	85-01-8	42.20	459	
PHENOL	108-95-2	42.20	<42.20	CC
PYRENE	129-00-0	42.20	815	
DIBENZOFURAN	132-64-9	42.20	<42.20	CC

MDL = Minimum Detection Limit.
EPA METHOD 8270

Calculated on a dry weight basis

Michael Veraldi

Michael Veraldi-Laboratory Director



**LONG
ISLAND
ANALYTICAL
LABORATORIES INC.**

110 Colin Drive • Holbrook, New York 11741

TOMORROW'S ANALYTICAL SOLUTIONS TODAY™

Phone (631) 472-3400 • Fax (631) 472-8505 • Email: LIAL@lialinc.com

9 of 16 pages

Client: Northbrook Contracting	Client ID: Bronx/Yonkers (Rogan Bros.)
Date received: 5/1/09	Laboratory ID: 1176399
Date extracted: 5/5/09	Matrix: Soil
Date analyzed: 5/6/09	ELAP #: 11693

PESTICIDES/PCB ANALYSIS

COMPOUND	CAS No.	MDL	RESULTS ug/kg	FLAG
4,4'-DDE	72-55-9	5.3 ug/kg	<5.3	
4,4'-DDT	50-29-3	5.3 ug/kg	<5.3	
4,4'-DDD	72-54-8	5.3 ug/kg	<5.3	
Aldrin	309-00-2	5.3 ug/kg	<5.3	
α - BHC	319-84-6	5.3 ug/kg	<5.3	
β - BHC	319-85-7	5.3 ug/kg	<5.3	
Chlordane	12789-03-6	15.8 ug/kg	<15.8	
δ - BHC	319-86-8	5.3 ug/kg	<5.3	
Dieldrin	60-57-1	5.3 ug/kg	<5.3	
Endosulfan I	959-98-8	5.3 ug/kg	<5.3	
Endosulfan II	33212-65-9	5.3 ug/kg	<5.3	
Endosulfan sulfate	1031-07-8	5.3 ug/kg	<5.3	
Endrin	72-20-8	5.3 ug/kg	<5.3	
Heptachlor	76-44-8	5.3 ug/kg	<5.3	
γ - BHC (Lindane)	58-89-9	5.3 ug/kg	<5.3	
Arochlor 1016	12674-11-2	211 ug/kg	<211	
Arochlor 1221	1104-28-2	211 ug/kg	<211	
Arochlor 1232	11141-16-5	211 ug/kg	<211	
Arochlor 1242	53469-21-9	211 ug/kg	<211	
Arochlor 1248	12672-29-6	211 ug/kg	<211	
Arochlor 1254	11097-69-1	211 ug/kg	<211	
Arochlor 1260	11096-82-5	211 ug/kg	<211	

MDL = Minimum Detection Limit.
EPA METHOD 8081/8082

Calculated on a dry weight basis

Michael Veraldi

Michael Veraldi-Laboratory Director



**LONG
ISLAND
ANALYTICAL
LABORATORIES INC.**

110 Colin Drive • Holbrook, New York 11741

"TOMORROWS ANALYTICAL SOLUTIONS TODAY"

Phone (631) 472-3400 • Fax (631) 472-8505 • Email: LIAL@lialinc.com

10 of 16 pages

Client: Northbrook Contracting	Client ID: Bronx/Yonkers (Rogan Bros.)
Date received: 5/1/09	Laboratory ID: 1176399
Date extracted: 5/4/09	Matrix: Soil
Date analyzed: 5/6/09	ELAP #: 11693

HERBICIDE ANALYSIS

PARAMETER	CAS #	MDL	RESULTS ug/kg	FLAG
SILVEX(2,4,5-TP)	93-72-1	50 ug/kg	<50	

MDL = Minimum Detection Limit.
EPA METHOD 8151

Calculated on a dry weight basis

Michael Veraldi

Michael Veraldi-Laboratory Director



**LONG
ISLAND
ANALYTICAL
LABORATORIES INC.**

110 Colin Drive - Holbrook, New York 11741

"TOMORROW'S ANALYTICAL SOLUTIONS TODAY"

Phone (631) 472-3400 - Fax (631) 472-8505 - Email: LIAL@lialinc.com

11 of 16 pages

Client: Northbrook Contracting	Client ID: Bronx/Yonkers (Rogan Bros.)
Date received: 5/1/09	Laboratory ID: 1176399
Date analyzed: See Below	Matrix: Soil

TOTAL METALS ANALYSIS

PARAMETER	MDL	DATE ANALYZED	RESULTS mg/kg	FLAG
ARSENIC, As	1.65 mg/kg	5/5/09	<1.65	
BARIUM, Ba	3.33 mg/kg	5/5/09	132	V
BERYLLIUM, Be	1.65 mg/kg	5/5/09	<1.65	
CADMIUM, Cd	1.00 mg/kg	5/5/09	1.13	
HEXAVALENT CHROMIUM	1.06 mg/kg	5/6/09	<1.06	
TRIVALENT CHROMIUM	1.65 mg/kg	5/5/09	42.4	
COPPER, Cu	1.65 mg/kg	5/5/09	45.3	
CYANIDE, Cn	0.10 mg/kg	5/4/09	<0.10	
LEAD, Pb	1.65 mg/kg	5/5/09	39.9	
MANGANESE, Mn	1.65 mg/kg	5/6/09	372	
MERCURY, Hg*	0.02 mg/kg	5/5/09	0.095	
NICKEL, Ni	1.65 mg/kg	5/5/09	28.4	
SELENIUM, Se	1.65 mg/kg	5/5/09	<1.65	
SILVER, Ag	1.65 mg/kg	5/5/09	<1.65	
ZINC, Zn	1.65 mg/kg	5/5/09	72.8	

MDL = Minimum Detection Limit.
 Performed by EPA Method 6010B
 *Method: SM18(4500-CN-D)
 #Method: EPA 7471A

Calculated on a dry weight basis

Michael Veraldi

Michael Veraldi-Laboratory Director



LONG ISLAND ANALYTICAL LABORATORIES INC.

TOMORROW'S ANALYTICAL SOLUTIONS TODAY™

110 Colin Drive - Holbrook, New York 11741
 Phone (631) 472-3400 • Fax (631) 472-8505 • Email: LIAL@lialinc.com

12 of 16 pages

Client: Northbrook Contracting	Client ID: Bronx/Yonkers (Riverdale Avenue)
Date received: 5/1/09	Laboratory ID: 1176400
Date extracted: 5/4/09	Matrix: Soil
Date analyzed: 5/4/09	ELAP #: 11693

VOLATILE ANALYSIS

PARAMETER	CAS No.	MDL ug/kg	RESULTS ug/kg	FLAG
1,1,1-TRICHLOROETHANE	71-55-6	5.07	<5.07	
1,1-DICHLOROETHANE	75-34-3	5.07	<5.07	
1,1-DICHLOROETHENE	75-35-4	5.07	<5.07	
1,2-DICHLOROBENZENE	95-50-1	5.07	<5.07	
1,2-DICHLOROETHANE	107-06-2	5.07	<5.07	
cis[Z]-1,2DICHLOROETHENE	156-59-2	5.07	<5.07	
trans[E]-1,2-DICHLOROETHENE	156-60-5	5.07	<5.07	
1,3-DICHLOROBENZENE	541-73-1	5.07	<5.07	
1,4-DICHLOROBENZENE	106-46-7	5.07	<5.07	
ACETONE	67-64-1	50.70	<50.70	
BENZENE	71-43-2	5.07	<5.07	
n-BUTYLBENZENE	104-51-8	5.07	<5.07	
CARBON TETRACHLORIDE	56-23-5	5.07	<5.07	
CHLOROBENZENE	108-90-7	5.07	<5.07	
CHLOROFORM	67-66-3	5.07	<5.07	
ETHYLBENZENE	100-41-4	5.07	<5.07	
2-BUTANONE (MEK)	78-93-3	10.10	<10.10	
MTBE	1634-04-4	5.07	<5.07	
METHYLENE CHLORIDE	75-09-2	5.07	<5.07	
n-PROPYLBENZENE	103-65-1	5.07	<5.07	
sec-BUTYLBENZENE	135-98-8	5.07	<5.07	
tert-BUTYLBENZENE	98-06-6	5.07	<5.07	
TETRACHLOROETHYLENE	127-18-4	5.07	<5.07	
TOLUENE	108-88-3	5.07	<5.07	
TRICHLOROETHYLENE	79-01-6	5.07	<5.07	
1,2,4-TRIMETHYLBENZENE	95-63-6	5.07	<5.07	
1,3,5-TRIMETHYLBENZENE	108-67-8	5.07	<5.07	
CHLOROETHENE (VINYL CHLORIDE)	75-01-4	5.07	<5.07	
p&m-XYLENE	1330-20-7	10.10	<10.10	
o-XYLENE	95-47-6	5.07	<5.07	
1,4-DIOXANE	123-91-1	5.07	<5.07	

MDL = Minimum Detection Limit.
EPA METHOD 8260

Calculated on a dry weight basis

Michael Veraldi

Michael Veraldi-Laboratory Director



LONG
ISLAND
ANALYTICAL
LABORATORIES INC.

"TOMORROW'S ANALYTICAL SOLUTIONS TODAY"

110 Colin Drive • Holbrook, New York 11741
Phone (631) 472-3400 • Fax (631) 472-8505 • Email: LIAL@lialinc.com

13 of 16 pages

Client: Northbrook Contracting	Client ID: Bronx/Yonkers (Riverdale Avenue)
Date received: 5/1/09	Laboratory ID: 1176400
Date extracted: 5/5/09	Matrix: Soil
Date analyzed: 5/5/09	ELAP #: 11693

SEMI-VOLATILE ANALYSIS

PARAMETER	CAS No.	MDL ug/kg	RESULTS ug/kg	FLAG
HEXACHLORO BENZENE	118-74-1	40.50	<40.50	CC
ACENAPHTHENE	83-32-9	40.50	<40.50	CC
ACENAPHTHYLENE	208-96-8	40.50	<40.50	CC
ANTHRACENE	120-12-7	40.50	<40.50	CC
BENZO-a-ANTHRACENE	56-55-3	40.50	48	CC
BENZO-a-PYRENE	50-32-8	40.50	<40.50	CC
BENZO-b-FLUOROANTHENE	205-99-2	40.50	47.30	CC
BENZO-g,h,i-PERYLENE	191-24-2	40.50	<40.50	CC
BENZO-k-FLUOROANTHENE	207-08-9	40.50	<40.50	CC
CHRYSENE	218-01-9	40.50	43.20	CC
DIBENZO-a,h-ANTHRACENE	53-70-3	40.50	<10.50	CC
FLUORANTHENE	206-44-0	40.50	105	CC
FLUORENE	86-73-7	40.50	<40.50	CC
INDENO(1,2,3-c,d)PYRENE	193-39-5	40.50	<40.50	CC
3+4-METHYLPHENOL	15831-10-4	40.50	<40.50	CC
2-METHYLPHENOL	95-48-7	40.50	<40.50	CC
NAPHTHALENE	91-20-3	40.50	<40.50	CC
PENTACHLOROPHENOL	87-86-5	40.50	<40.50	CC
PHENANTHRENE	85-01-8	40.50	81.80	CC
PHENOL	108-95-2	40.50	<40.50	CC
PYRENE	129-00-0	40.50	89.90	CC
DIBENZOFURAN	132-84-9	40.50	<40.50	CC

Calculated on a dry weight basis

MDL - Minimum Detection Limit
EPA METHOD 8270*Michael Veraldi*

Michael Veraldi-Laboratory Director



**LONG
ISLAND
ANALYTICAL
LABORATORIES INC.**

110 Colin Drive • Holbrook, New York 11741
 Phone (631) 472-3400 • Fax (631) 472-8505 • Email: LIAL@lialinc.com

TOMORROW'S ANALYTICAL SOLUTIONS TODAY

14 of 16 pages

Client: Northbrook Contracting	Client ID: Bronx/Yonkers (Riverdale Avenue)
Date received: 5/1/09	Laboratory ID: 1176400
Date extracted: 5/5/09	Matrix: Soil
Date analyzed: 5/6/09	ELAP #: 11693

PESTICIDES/PCB ANALYSIS

COMPOUND	CAS No.	MDL	RESULTS ug/kg	FLAG
4,4'-DDE	72-55-9	5.1 ug/kg	<5.1	
4,4'-DDT	50-29-3	5.1 ug/kg	<5.1	
4,4'-DDD	72-54-8	5.1 ug/kg	<5.1	
Aldrin	309-00-2	5.1 ug/kg	<5.1	
α - BHC	319-84-6	5.1 ug/kg	<5.1	
β - BHC	319-85-7	5.1 ug/kg	<5.1	
Chlordane	12789-03-6	15.2 ug/kg	<15.2	
δ - BHC	319-86-8	5.1 ug/kg	<5.1	
Dieldrin	60-57-1	5.1 ug/kg	<5.1	
Endosulfan I	959-98-8	5.1 ug/kg	<5.1	
Endosulfan II	33212-65-9	5.1 ug/kg	<5.1	
Endosulfan sulfate	1031-07-8	5.1 ug/kg	<5.1	
Endrin	72-20-8	5.1 ug/kg	<5.1	
Heptachlor	76-44-8	5.1 ug/kg	<5.1	
γ - BHC (Lindane)	58-89-9	5.1 ug/kg	<5.1	
Arochlor 1016	12674-11-2	203 ug/kg	<203	
Arochlor 1221	1104-28-2	203 ug/kg	<203	
Arochlor 1232	11141-16-5	203 ug/kg	<203	
Arochlor 1242	53469-21-9	203 ug/kg	<203	
Arochlor 1248	12672-29-6	203 ug/kg	<203	
Arochlor 1254	11097-69-1	203 ug/kg	<203	
Arochlor 1260	11096-82-5	203 ug/kg	<203	

MDL = Minimum Detection Limit.
EPA METHOD 8081/8082

Calculated on a dry weight basis

Michael Veraldi

Michael Veraldi-Laboratory Director



LONG ISLAND ANALYTICAL LABORATORIES INC.

TOMORROW'S ANALYTICAL SOLUTIONS TODAY™

110 Colin Drive • Holbrook, New York 11741

Phone (631) 472-3400 • Fax (631) 472-8505 • Email: LIAL@lialinc.com

15 of 16 pages

Client: Northbrook Contracting	Client ID: Bronx/Yonkers (Riverdale Avenue)
Date received: 5/1/09	Laboratory ID: 1176400
Date extracted: 5/4/09	Matrix: Soil
Date analyzed: 5/6/09	ELAP #: 11693

HERBICIDE ANALYSIS

PARAMETER	CAS #	MDL	RESULTS ug/kg	FLAG
SILVEX(2,4,5-TP)	93-72-1	50 ug/kg	<50	

MDL = Minimum Detection Limit.
EPA METHOD 8151

Calculated on a dry weight basis

Michael Veraldi

Michael Veraldi-Laboratory Director



**LONG
ISLAND
ANALYTICAL
LABORATORIES INC.**

"TOMORROW'S ANALYTICAL SOLUTIONS TODAY"

110 Colin Drive • Holbrook, New York 11741

Phone (631) 472-3400 • Fax (631) 472-8505 • Email: LIAL@liaiinc.com

16 of 16 pages

Client: Northbrook Contracting	Client ID: Bronx/Yonkers (Riverdale Avenue)
Date received: 5/1/09	Laboratory ID: 1176400
Date analyzed: See Below	Matrix: Soil

TOTAL METALS ANALYSIS

PARAMETER	MDL	DATE ANALYZED	RESULTS mg/kg	FLAG
ARSENIC, As	1.65 mg/kg	5/6/09	<1.65	
BARIUM, Ba	3.33 mg/kg	5/6/09	44.4	
BERYLLIUM, Be	1.65 mg/kg	5/6/09	<1.65	
CADMIUM, Cd	1.00 mg/kg	5/6/09	<1.00	
HEXAVALENT CHROMIUM	1.01 mg/kg	5/6/09	<1.01	
TRIVALENT CHROMIUM	1.65 mg/kg	5/6/09	22.7	
COPPER, Cu	1.65 mg/kg	5/6/09	24.1	
CYANIDE, Cn	0.10 mg/kg	5/4/09	<0.10	
LEAD, Pb	1.65 mg/kg	5/6/09	11.4	
MANGANESE, Mn	1.65 mg/kg	5/6/09	382	
MERCURY, Hg*	0.02 mg/kg	5/6/09	<0.020	
NICKEL, Ni	1.65 mg/kg	5/6/09	16.3	
SELENIUM, Se	1.65 mg/kg	5/6/09	<1.65	
SILVER, Ag	1.65 mg/kg	5/6/09	<1.65	
ZINC, Zn	1.65 mg/kg	5/6/09	34.1	

MDL = Minimum Detection Limit.
 Performed by EPA Method 8010B
 *Method: SM18(4500-CN-D)
 •Method: EPA 7471A

Calculated on a dry weight basis

Michael Veraldi

Michael Veraldi-Laboratory Director



LONG ISLAND ANALYTICAL LABORATORIES INC.

TOMORROW'S ANALYTICAL SOLUTIONS TODAY™

110 Colin Drive - Holbrook, New York 11741
 Phone (631) 472-3400 - Fax (631) 472-8505 • Email: LIAL@lialinc.com