

Demolition of Mineral Springs Building #8

National Fuel Gas Distribution Corporation demolished Mineral Springs Building #8 during 2012. Several steps were completed to safely demolish the building, properly dispose of the demolition debris, and transform the former building site to a functional area.

Prior to the demolition a building asbestos survey was conducted, which found asbestos in the mastic used to adhere the floor tiles, pipe insulation and a transite stack. An asbestos removal project was then conducted, which was supported by airborne asbestos sampling. Copies are attached of the asbestos survey report, the asbestos close out report, and the air monitoring report.

Fluorescent light bulbs were removed and properly disposed of through the Waste Management Lamp Tracker program. Light ballasts were properly disposed of after each label was checked to confirm they did not contain PCBs. Metal materials were also removed and sent for recycling by the demolition contractor prior to demolition.

Some of the building walls had been painted many years ago with a lead containing paint, so representative samples of the painted brick walls were submitted for TCLP analysis prior to demolition. Copies of the analysis reports are attached. After characterization the painted brick and other building materials were approved for disposal at Allied Waste Niagara Falls Landfill. Copies of disposal tickets are attached for 766 tons of this material.

After the upper portion of the building (including the walls, the second floor and the roof) was removed the contractor began removing the bottom floor concrete slab. A black sub base material was encountered below the slab. By observation it was determined the black material was a 6" to 8" deep layer of coal slag or bottom ash placed on grade within the perimeter of the building footer wall (there was no basement in the building). Information about this type of material is available at this EPA weblink: <http://www.epa.gov/wastes/conserves/imr/ccps/bottomash.htm> After discussion with the landfill operators about testing requirements a sample of material was sent to Test America for analysis and found to be non hazardous. A copy of the analysis report is attached. After receiving approval from the landfill 490 tons of coal slag, concrete floor and footer wall brick were sent to Allied Waste Niagara Falls Landfill. Copies of disposal receipts are attached.

A storm water drainage system, including two catch basins and approximately 100' of 8" diameter solid drain pipe was installed within the demolished building footprint and connected to the facility combined sewer system. Then a crushed stone sub base was placed on the soil and compacted with a vibratory roller. Asphalt was then placed over the 7000 square foot work area and matched to the existing pavement.

Pictures of the project are found below.



Demolition of Mineral Springs Building #8.



Water spray was used for dust control during building demolition.



The concrete floor surface became exposed as debris was prepared for loading out.




Coal slag material used for bedding was exposed after removing the concrete floor surface.



Coal slag bedding was about 6" to 8" thick.



Concrete floor debris piled on top of floor bedding.



A storm water drainage system was installed after building debris was cleared.



Drain pipe installed in trench.



Second storm water catch basin.



Technician conducting Proctor Test to check compaction of new crushed stone sub base.



Looking south at new asphalt pavement.



Looking north at new asphalt pavement.

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

ANALYTICAL REPORT

TestAmerica Laboratories, Inc.

TestAmerica Buffalo
10 Hazelwood Drive
Amherst, NY 14228-2298
Tel: (716)691-2600

TestAmerica Job ID: 480-14022-1
Client Project/Site: MSW#8 Demo

For:
National Fuel Gas Company
6363 Main Street
Buffalo, New York 14221

Attn: James Clark



Authorized for release by:
12/30/2011 5:17:36 PM

Denise Giglia
Project Manager I
denise.giglia@testamericainc.com

LINKS

Review your project
results through
TotalAccess

Have a Question?



Visit us at:
www.testamericainc.com

The test results in this report meet all 2003 NELAC and 2009 TNI requirements for accredited parameters, exceptions are noted in this report. This report may not be reproduced except in full, and with written approval from the laboratory. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

This report has been electronically signed and authorized by the signatory. Electronic signature is intended to be the legally binding equivalent of a traditionally handwritten signature.

Results relate only to the items tested and the sample(s) as received by the laboratory.

1

2

3

4

5

6

7

8

9

10

11

12

13

14



Table of Contents

Cover Page	1
Table of Contents	2
Definitions/Glossary	3
Case Narrative	4
Detection Summary	5
Client Sample Results	6
QC Sample Results	7
QC Association Summary	10
Lab Chronicle	11
Certification Summary	12
Method Summary	13
Sample Summary	14
Chain of Custody	15
Receipt Checklists	16

Definitions/Glossary

Client: National Fuel Gas Company
Project/Site: MSW#8 Demo

TestAmerica Job ID: 480-14022-1

Qualifiers

Metals

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.
B	Compound was found in the blank and sample.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☼	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CNF	Contains no Free Liquid
DL, RA, RE, IN	Indicates a Dilution, Reanalysis, Re-extraction, or additional Initial metals/anion analysis of the sample
EDL	Estimated Detection Limit
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
ND	Not detected at the reporting limit (or MDL or EDL if shown)
PQL	Practical Quantitation Limit
QC	Quality Control
RL	Reporting Limit
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)

Case Narrative

Client: National Fuel Gas Company
Project/Site: MSW#8 Demo

TestAmerica Job ID: 480-14022-1

Job ID: 480-14022-1

Laboratory: TestAmerica Buffalo

Narrative

Job Narrative 480-14022-1

Comments

No additional comments.

Receipt

All samples were received in good condition within temperature requirements.

Metals

Method 6010B: The TCLP Extractor Blank, 480-44714 for batch 480-44858 contained total cadmium above the method detection limit. This target analyte concentration was less than the reporting limit (RL); therefore, re-extraction and/or re-analysis of sample BRICK (480-14022-2) was not performed.


Method 6010B: The analytes total barium and chromium were detected in the TCLP Extractor Blank BRICK (480-14022-2) at concentrations above the TestAmerica Laboratories standard quantitation limits. Sample BRICK (480-14022-2) associated with the blank was evaluated and determined to be at least five times less than the TCLP Regulatory Limits. The sample data was therefore accepted and no corrective action was performed.

Method 6010B: Samples (480-14022-2 MS), (480-14022-2 MSD), (480-14022-2 PDS), (480-14022-2 SD), BRICK (480-14022-2), from batch 480-44858, were re-analyzed for the analyte silver at a five-fold dilution due to limited digestate volume. With the dilution, the adjusted reporting limits are still below the TCLP regulatory limit for silver, therefore data is accepted.

No other analytical or quality issues were noted.

Organic Prep

No analytical or quality issues were noted.



Detection Summary

Client: National Fuel Gas Company
Project/Site: MSW#8 Demo

TestAmerica Job ID: 480-14022-1

Client Sample ID: BRICK W/ PAINT

Lab Sample ID: 480-14022-1

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Mercury	0.00016	J	0.00020	0.00012	mg/L	1		7470A	TCLP

Client Sample ID: BRICK

Lab Sample ID: 480-14022-2

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Arsenic	0.025		0.010	0.0056	mg/L	1		6010B	TCLP
Barium	0.29	B	0.0020	0.00070	mg/L	1		6010B	TCLP
Cadmium	0.010	B	0.0010	0.00033	mg/L	1		6010B	TCLP
Chromium	0.0072	B	0.0040	0.00087	mg/L	1		6010B	TCLP
Lead	0.047		0.0050	0.0030	mg/L	1		6010B	TCLP

Client Sample Results

Client: National Fuel Gas Company
 Project/Site: MSW#8 Demo

TestAmerica Job ID: 480-14022-1

Client Sample ID: BRICK W/ PAINT

Date Collected: 12/14/11 09:10
 Date Received: 12/14/11 10:25

Lab Sample ID: 480-14022-1

Matrix: Solid

Method: 7470A - Mercury (CVAA) - TCLP

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Mercury	0.00016	J	0.00020	0.00012	mg/L		12/16/11 13:15	12/16/11 17:01	1

Client Sample ID: BRICK

Date Collected: 12/14/11 09:15
 Date Received: 12/14/11 10:25

Lab Sample ID: 480-14022-2

Matrix: Solid

Method: 6010B - Metals (ICP) - TCLP

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Arsenic	0.025		0.010	0.0056	mg/L		12/16/11 11:45	12/21/11 18:54	1
Barium	0.29	B	0.0020	0.00070	mg/L		12/16/11 11:45	12/21/11 18:54	1
Cadmium	0.010	B	0.0010	0.00033	mg/L		12/16/11 11:45	12/21/11 18:54	1
Chromium	0.0072	B	0.0040	0.00087	mg/L		12/16/11 11:45	12/21/11 18:54	1
Lead	0.047		0.0050	0.0030	mg/L		12/16/11 11:45	12/21/11 18:54	1
Selenium	ND		0.015	0.0087	mg/L		12/16/11 11:45	12/21/11 18:54	1
Silver	ND		0.015	0.0062	mg/L		12/16/11 11:45	12/22/11 11:06	5

Method: 7470A - Mercury (CVAA) - TCLP

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Mercury	ND		0.00020	0.00012	mg/L		12/16/11 13:15	12/16/11 17:03	1

QC Sample Results

Client: National Fuel Gas Company
Project/Site: MSW#8 Demo

TestAmerica Job ID: 480-14022-1

Method: 6010B - Metals (ICP)

Lab Sample ID: MB 480-44858/2-A
Matrix: Solid
Analysis Batch: 45664

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 44858

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Arsenic	ND		0.010	0.0056	mg/L		12/16/11 11:45	12/21/11 18:45	1
Barium	ND		0.0020	0.00070	mg/L		12/16/11 11:45	12/21/11 18:45	1
Cadmium	ND		0.0010	0.00033	mg/L		12/16/11 11:45	12/21/11 18:45	1
Chromium	ND		0.0040	0.00087	mg/L		12/16/11 11:45	12/21/11 18:45	1
Lead	ND		0.0050	0.0030	mg/L		12/16/11 11:45	12/21/11 18:45	1
Selenium	ND		0.015	0.0087	mg/L		12/16/11 11:45	12/21/11 18:45	1
Silver	ND		0.0030	0.0012	mg/L		12/16/11 11:45	12/21/11 18:45	1

Lab Sample ID: LCS 480-44858/3-A
Matrix: Solid
Analysis Batch: 45871

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 44858

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits
Arsenic	1.00	1.07		mg/L		107	80 - 120
Barium	1.00	1.03		mg/L		103	80 - 120
Cadmium	1.00	1.02		mg/L		102	80 - 120
Chromium	1.00	1.03		mg/L		103	80 - 120
Lead	1.00	1.04		mg/L		104	80 - 120
Selenium	1.00	1.07		mg/L		107	80 - 120
Silver	1.00	1.03		mg/L		103	80 - 120

Lab Sample ID: LB 480-44714/1-B LB
Matrix: Solid
Analysis Batch: 45664

Client Sample ID: Method Blank
Prep Type: TCLP
Prep Batch: 44858

Analyte	LB Result	LB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Arsenic	ND		0.010	0.0056	mg/L		12/16/11 11:45	12/21/11 18:43	1
Barium	0.0748		0.0020	0.00070	mg/L		12/16/11 11:45	12/21/11 18:43	1
Cadmium	0.000520	J	0.0010	0.00033	mg/L		12/16/11 11:45	12/21/11 18:43	1
Chromium	0.00463		0.0040	0.00087	mg/L		12/16/11 11:45	12/21/11 18:43	1
Lead	ND		0.0050	0.0030	mg/L		12/16/11 11:45	12/21/11 18:43	1
Selenium	ND		0.015	0.0087	mg/L		12/16/11 11:45	12/21/11 18:43	1
Silver	ND		0.0030	0.0012	mg/L		12/16/11 11:45	12/21/11 18:43	1

Lab Sample ID: 480-14022-2 MS
Matrix: Solid
Analysis Batch: 45664

Client Sample ID: BRICK
Prep Type: TCLP
Prep Batch: 44858

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec. Limits
Arsenic	0.025		1.00	1.08		mg/L		106	75 - 125
Barium	0.29	B	1.00	1.27		mg/L		98	75 - 125
Cadmium	0.010	B	1.00	1.01		mg/L		100	75 - 125
Chromium	0.0072	B	1.00	1.02		mg/L		102	75 - 125
Lead	0.047		1.00	1.07		mg/L		103	75 - 125
Selenium	ND		1.00	1.04		mg/L		104	75 - 125

QC Sample Results

Client: National Fuel Gas Company
Project/Site: MSW#8 Demo

TestAmerica Job ID: 480-14022-1

Method: 6010B - Metals (ICP) (Continued)

Lab Sample ID: 480-14022-2 MS

Matrix: Solid

Analysis Batch: 45871

Client Sample ID: BRICK

Prep Type: TCLP

Prep Batch: 44858

Analyte	Sample	Sample	Spike	MS	MS	Unit	D	%Rec	%Rec.	Limits
	Result	Qualifier	Added	Result	Qualifier					
Arsenic	0.030		1.00	1.04		mg/L		101		75 - 125
Barium	0.31		1.00	1.26		mg/L		96		75 - 125
Cadmium	0.011		1.00	1.00		mg/L		99		75 - 125
Chromium	0.0051		1.00	1.01		mg/L		100		75 - 125
Lead	0.049		1.00	1.05		mg/L		100		75 - 125
Selenium	ND		1.00	1.03		mg/L		103		75 - 125
Silver	ND		1.00	0.961		mg/L		96		75 - 125

Lab Sample ID: 480-14022-2 MSD

Matrix: Solid

Analysis Batch: 45664

Client Sample ID: BRICK

Prep Type: TCLP

Prep Batch: 44858

Analyte	Sample	Sample	Spike	MSD	MSD	Unit	D	%Rec	%Rec.	Limits	RPD	Limit
	Result	Qualifier	Added	Result	Qualifier							
Arsenic	0.025		1.00	1.10		mg/L		107		75 - 125	1	20
Barium	0.29	B	1.00	1.28		mg/L		100		75 - 125	1	20
Cadmium	0.010	B	1.00	1.03		mg/L		101		75 - 125	2	20
Chromium	0.0072	B	1.00	1.03		mg/L		102		75 - 125	0	20
Lead	0.047		1.00	1.08		mg/L		103		75 - 125	1	20
Selenium	ND		1.00	1.04		mg/L		104		75 - 125	0	20

Lab Sample ID: 480-14022-2 MSD

Matrix: Solid

Analysis Batch: 45871

Client Sample ID: BRICK

Prep Type: TCLP

Prep Batch: 44858

Analyte	Sample	Sample	Spike	MSD	MSD	Unit	D	%Rec	%Rec.	Limits	RPD	Limit
	Result	Qualifier	Added	Result	Qualifier							
Arsenic	0.030		1.00	1.07		mg/L		103		75 - 125	2	20
Barium	0.31		1.00	1.27		mg/L		96		75 - 125	1	20
Cadmium	0.011		1.00	1.02		mg/L		101		75 - 125	2	20
Chromium	0.0051		1.00	1.02		mg/L		101		75 - 125	1	20
Lead	0.049		1.00	1.08		mg/L		103		75 - 125	3	20
Selenium	ND		1.00	1.05		mg/L		105		75 - 125	1	20
Silver	ND		1.00	0.959		mg/L		96		75 - 125	0	20

Method: 7470A - Mercury (CVAA)

Lab Sample ID: MB 480-44874/9-A

Matrix: Solid

Analysis Batch: 44952

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 44874

Analyte	MB	MB	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
Mercury	ND		0.00020	0.00012	mg/L		12/16/11 13:15	12/16/11 17:15	1

Lab Sample ID: LCS 480-44874/8-A

Matrix: Solid

Analysis Batch: 44952

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 44874

Analyte	Spike	LCS	LCS	Unit	D	%Rec	%Rec.	Limits
Mercury	0.00668	0.00538		mg/L		81		80 - 120

QC Sample Results

Client: National Fuel Gas Company
Project/Site: MSW#8 Demo

TestAmerica Job ID: 480-14022-1

Method: 7470A - Mercury (CVAA) (Continued)

Lab Sample ID: LB 480-44714/1-C LB
Matrix: Solid
Analysis Batch: 44952

Client Sample ID: Method Blank
Prep Type: TCLP
Prep Batch: 44874

Analyte	LB Result	LB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Mercury	ND		0.00020	0.00012	mg/L		12/16/11 13:15	12/16/11 17:11	1

Lab Sample ID: 480-14022-2 MS
Matrix: Solid
Analysis Batch: 44952

Client Sample ID: BRICK
Prep Type: TCLP
Prep Batch: 44874

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec. Limits
Mercury	ND		0.00668	0.00602		mg/L		90	75 - 125

Lab Sample ID: 480-14022-2 MSD
Matrix: Solid
Analysis Batch: 44952

Client Sample ID: BRICK
Prep Type: TCLP
Prep Batch: 44874

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec. Limits	RPD	RPD Limit
Mercury	ND		0.00668	0.00587		mg/L		88	75 - 125	3	20

QC Association Summary

Client: National Fuel Gas Company
Project/Site: MSW#8 Demo

TestAmerica Job ID: 480-14022-1

Metals

Leach Batch: 44714

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
480-14022-1	BRICK W/ PAINT	TCLP	Solid	1311	
480-14022-2	BRICK	TCLP	Solid	1311	
480-14022-2 MS	BRICK	TCLP	Solid	1311	
480-14022-2 MSD	BRICK	TCLP	Solid	1311	
LB 480-44714/1-B LB	Method Blank	TCLP	Solid	1311	
LB 480-44714/1-C LB	Method Blank	TCLP	Solid	1311	

Prep Batch: 44858

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
480-14022-2	BRICK	TCLP	Solid	3010A	44714
480-14022-2 MS	BRICK	TCLP	Solid	3010A	44714
480-14022-2 MSD	BRICK	TCLP	Solid	3010A	44714
LB 480-44714/1-B LB	Method Blank	TCLP	Solid	3010A	44714
LCS 480-44858/3-A	Lab Control Sample	Total/NA	Solid	3010A	
MB 480-44858/2-A	Method Blank	Total/NA	Solid	3010A	

Prep Batch: 44874

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
480-14022-1	BRICK W/ PAINT	TCLP	Solid	7470A	44714
480-14022-2	BRICK	TCLP	Solid	7470A	44714
480-14022-2 MS	BRICK	TCLP	Solid	7470A	44714
480-14022-2 MSD	BRICK	TCLP	Solid	7470A	44714
LB 480-44714/1-C LB	Method Blank	TCLP	Solid	7470A	44714
LCS 480-44874/8-A	Lab Control Sample	Total/NA	Solid	7470A	
MB 480-44874/9-A	Method Blank	Total/NA	Solid	7470A	

Analysis Batch: 44952

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
480-14022-1	BRICK W/ PAINT	TCLP	Solid	7470A	44874
480-14022-2	BRICK	TCLP	Solid	7470A	44874
480-14022-2 MS	BRICK	TCLP	Solid	7470A	44874
480-14022-2 MSD	BRICK	TCLP	Solid	7470A	44874
LB 480-44714/1-C LB	Method Blank	TCLP	Solid	7470A	44874
LCS 480-44874/8-A	Lab Control Sample	Total/NA	Solid	7470A	44874
MB 480-44874/9-A	Method Blank	Total/NA	Solid	7470A	44874

Analysis Batch: 45664

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
480-14022-2	BRICK	TCLP	Solid	6010B	44858
480-14022-2 MS	BRICK	TCLP	Solid	6010B	44858
480-14022-2 MSD	BRICK	TCLP	Solid	6010B	44858
LB 480-44714/1-B LB	Method Blank	TCLP	Solid	6010B	44858
MB 480-44858/2-A	Method Blank	Total/NA	Solid	6010B	44858

Analysis Batch: 45871

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
480-14022-2	BRICK	TCLP	Solid	6010B	44858
480-14022-2 MS	BRICK	TCLP	Solid	6010B	44858
480-14022-2 MSD	BRICK	TCLP	Solid	6010B	44858
LCS 480-44858/3-A	Lab Control Sample	Total/NA	Solid	6010B	44858

Lab Chronicle

Client: National Fuel Gas Company
 Project/Site: MSW#8 Demo

TestAmerica Job ID: 480-14022-1

Client Sample ID: BRICK W/ PAINT

Lab Sample ID: 480-14022-1

Date Collected: 12/14/11 09:10

Matrix: Solid

Date Received: 12/14/11 10:25

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
TCLP	Leach	1311			44714	12/15/11 16:20	TR	TAL BUF
TCLP	Prep	7470A			44874	12/16/11 13:15	MM	TAL BUF
TCLP	Analysis	7470A		1	44952	12/16/11 17:01	MM	TAL BUF

Client Sample ID: BRICK

Lab Sample ID: 480-14022-2

Date Collected: 12/14/11 09:15

Matrix: Solid

Date Received: 12/14/11 10:25

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
TCLP	Leach	1311			44714	12/15/11 16:20	TR	TAL BUF
TCLP	Prep	7470A			44874	12/16/11 13:15	MM	TAL BUF
TCLP	Analysis	7470A		1	44952	12/16/11 17:03	MM	TAL BUF
TCLP	Prep	3010A			44858	12/16/11 11:45	JM	TAL BUF
TCLP	Analysis	6010B		1	45664	12/21/11 18:54	JRK	TAL BUF
TCLP	Analysis	6010B		5	45871	12/22/11 11:06	JRK	TAL BUF

Laboratory References:

TAL BUF = TestAmerica Buffalo, 10 Hazelwood Drive, Amherst, NY 14228-2298, TEL (716)691-2600

Certification Summary

Client: National Fuel Gas Company
 Project/Site: MSW#8 Demo

TestAmerica Job ID: 480-14022-1

Laboratory	Authority	Program	EPA Region	Certification ID
TestAmerica Buffalo	Arkansas	State Program	6	88-0686
TestAmerica Buffalo	California	NELAC	9	1169CA
TestAmerica Buffalo	Connecticut	State Program	1	PH-0568
TestAmerica Buffalo	Florida	NELAC	4	E87672
TestAmerica Buffalo	Georgia	Georgia EPD	4	N/A
TestAmerica Buffalo	Georgia	State Program	4	956
TestAmerica Buffalo	Illinois	NELAC	5	100325 / 200003
TestAmerica Buffalo	Iowa	State Program	7	374
TestAmerica Buffalo	Kansas	NELAC	7	E-10187
TestAmerica Buffalo	Kentucky	Kentucky UST	4	30
TestAmerica Buffalo	Kentucky	State Program	4	90029
TestAmerica Buffalo	Louisiana	NELAC	6	02031
TestAmerica Buffalo	Maine	State Program	1	NY0044
TestAmerica Buffalo	Maryland	State Program	3	294
TestAmerica Buffalo	Massachusetts	State Program	1	M-NY044
TestAmerica Buffalo	Michigan	State Program	5	9937
TestAmerica Buffalo	Minnesota	NELAC	5	036-999-337
TestAmerica Buffalo	New Hampshire	NELAC	1	2337
TestAmerica Buffalo	New Hampshire	NELAC	1	68-00281
TestAmerica Buffalo	New Jersey	NELAC	2	NY455
TestAmerica Buffalo	New York	NELAC	2	10026
TestAmerica Buffalo	North Dakota	State Program	8	R-176
TestAmerica Buffalo	Oklahoma	State Program	6	9421
TestAmerica Buffalo	Oregon	NELAC	10	NY200003
TestAmerica Buffalo	Pennsylvania	NELAC	3	68-00281
TestAmerica Buffalo	Tennessee	State Program	4	TN02970
TestAmerica Buffalo	Texas	NELAC	6	T104704412-08-TX
TestAmerica Buffalo	USDA	USDA		P330-08-00242
TestAmerica Buffalo	Virginia	NELAC Secondary AB	3	460185
TestAmerica Buffalo	Virginia	State Program	3	278
TestAmerica Buffalo	Washington	State Program	10	C1677
TestAmerica Buffalo	Wisconsin	State Program	5	998310390

Accreditation may not be offered or required for all methods and analytes reported in this package. Please contact your project manager for the laboratory's current list of certified methods and analytes.

Method Summary

Client: National Fuel Gas Company
Project/Site: MSW#8 Demo

TestAmerica Job ID: 480-14022-1

Method	Method Description	Protocol	Laboratory
6010B	Metals (ICP)	SW846	TAL BUF
7470A	Mercury (CVAA)	SW846	TAL BUF

Protocol References:

SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

Laboratory References:

TAL BUF = TestAmerica Buffalo, 10 Hazelwood Drive, Amherst, NY 14228-2298, TEL (716)691-2600

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14

Sample Summary

Client: National Fuel Gas Company
Project/Site: MSW#8 Demo

TestAmerica Job ID: 480-14022-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
480-14022-1	BRICK W/ PAINT	Solid	12/14/11 09:10	12/14/11 10:25
480-14022-2	BRICK	Solid	12/14/11 09:15	12/14/11 10:25

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

Temperature on Receipt _____
 Drinking Water? Yes No

Chain of Custody Record

TAL-4124 (1007)

Project Manager: John Clark Date: 12-14 Chain of Custody Number: 199178
 Address: National Fuel Gas Telephone Number (Area Code)/Fax Number: 667-5557 Page 1 of 1
 City: Orchard Park State: NY Zip Code: 14127 Lab Number:
 Project Name and Location (State): M5w #8 Demo Site Contact:
 Carrier/Waybill Number:

Sample I.D. No. and Description (Containers for each sample may be combined on one line)	Date	Time	Matrix					Containers & Preservatives					Analysis (Attach list if more space is needed)	Special Instructions/ Conditions of Receipt	
			WOOD	SOIL	SLURRY	SLUDGE	SLIMES	PCB	PCP	PCDD	PCDF	PCMX			PCOX
Dricks w/Paint	12-14	11:10													
Brick	12-14	7:15													

Possible Hazard Identification: Non-Hazard Flammable Skin Irritant Poison B Unknown Return to Client Disposal By Lab Archiving For _____ Months (A fee may be assessed if samples are retained longer than 1 month)

Turn Around Time Required: 24 Hours 48 Hours 7 Days 14 Days 21 Days Other _____

1. Requisitioned By: John Clark Date: 12-14 Time: 10:25
 2. Requisitioned By: _____ Date: _____ Time: _____
 3. Requisitioned By: _____ Date: _____ Time: _____

1. Received By: Paul AM Date: 12/14/11 Time: 10:25
 2. Received By: _____ Date: _____ Time: _____
 3. Received By: _____ Date: _____ Time: _____

Comments:
 DISTRIBUTION: WHITE - Returned to Client with Report. CANARY - Slays with the Sample. PINK - Field Copy

Login Sample Receipt Checklist

Client: National Fuel Gas Company

Job Number: 480-14022-1

Login Number: 14022

List Source: TestAmerica Buffalo

List Number: 1

Creator: Janish, Carl

Question	Answer	Comment
Radioactivity either was not measured or, if measured, is at or below background	True	
The cooler's custody seal, if present, is intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	N/A	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Sampling Company provided.	True	NFG
Samples received within 48 hours of sampling.	True	
Samples requiring field filtration have been filtered in the field.	N/A	
Chlorine Residual checked.	N/A	

Report for the

Airborne Asbestos Sampling

at

**National Fuel
365 Mineral Springs Road
Buffalo, New York
(Building #8)**

Performed at the request of

**Mr. James Clark
National Fuel
5955 New Taylor Road
Orchard Park, New York 14127**

by

IsleChem, LLC.
2801 Long Road
Grand Island, NY 14072

NY202061

February 2012

COPY

National Fuel
Building #8
NY202061

1.0 PROJECT SUMMARY


Environmental field sampling was provided by IsleChem, LLC during the asbestos abatement project in Building #8 at National Fuel 365 Mineral Springs Road, Buffalo, New York. The project involved removal of asbestos floor and mastic, pipe insulation and transite stack. Empire Building Diagnostics was the asbestos removal contractor. All air samples collected were performed in accordance with the New York State Industrial Code Rule 56.

The asbestos flooring removal project was identified as NY202061 and was classified as a large project. Air samples were collected on February 8, 2012 to determine the background level of airborne fibers. Samples were collected February 13, 2012 – February 17, 2012 during the removal of asbestos containing materials. Samples were collected on February 20, 2012 to test the air following completion of all asbestos removal. The laboratory report(s) enclosed summarize the sample results.

The asbestos pipe insulation removal project was identified as NY20206-01 and was classified as a minor project. Samples were collected on February 13, 2012 to test the air following completion of all asbestos removal. The laboratory report(s) enclosed summarize the sample results.

Enclosed within this report are the asbestos air sampling and analysis protocols; analytical results, technician chain of custody form(s) and pertinent laboratory certifications. All of these services are subject to IsleChem, LLC's current terms and conditions for the sale of services, including the company's standard warranty and limitation of liability provisions.

Submitted by:



Scott Hammond
Field Services Manager

National Fuel
Building #8
NY202061

2.0 AIR SAMPLING PROTOCOLS

All air sampling was provided by a representative of IsleChem. Sampling used a mixed cellulose ester (MCE) filter membrane, 25 mm in diameter, with a .8 μm pore size and using techniques in accordance with the NIOSH 7400 Method. Air sampling equipment was calibrated using soap film primary calibrator. In the field, the pumps were calibrated using a secondary standard visifloat rotometer. The pumps used for area sample collection were classified as high volume, capable of one to 15 liters/minute.

The sample numbers incorporate the job number, date, running number and type of sample. For instance, a sample number with a format such as:

100-0106-32

- 100 would be the last three digits of the job number
- 0106 represents the date - January 6
- 32 is the running sample number

National Fuel
Building #8
NY202061

3.0 ASBESTOS ANALYSIS PROTOCOLS

Air Samples by Phase Contrast Microscopy

Method Reference: NIOSH 7400

The NIOSH 7400 method uses a Phase Contrast Microscope (PCM) to assess the number of fibers collected on air samples taken before, during and after asbestos abatement. The NIOSH 7400 is directed for use in abatement situations by the USEPA under AHERA and by the New York State Department of Labor under ICR 56. The method requires that one hundred (100) fields or one hundred (100) fibers with a minimum of twenty (20) fields be counted at 400X. All fibers or fiber-like particles measuring five (5) microns in length and having a length to width ratio of 3:1 are counted. It must be mentioned that the NIOSH method is nonspecific for asbestos. In other words, it cannot be assumed that all the fibers counted are asbestos, since every fiber and fiber-like particle meeting the NIOSH dimension criteria must be counted. The Phase Contrast Microscope has an optical resolution of .25 microns in diameter and asbestos fibers can be smaller than .25 micron in diameter.

Air Samples by Transmission Electron Microscopy

TEM (Transmission Electron Microscopy) is the only conclusive method for determining ambient levels of airborne asbestos. TEM is the only viable technique for measuring, identifying, and quantifying asbestos fibers following an abatement project. The analysis of asbestos fibers consists of an elemental chemical composition determination by energy dispersive spectroscopy (EDS), identification by fiber morphology, and selected area electron diffraction (SAED) which determines the crystalline structure of the fiber. Each one of the 6 types of asbestos is different and can be differentiated by these techniques supplemented by the measurement of and interpretation of micrographs of SAED patterns.

Method Reference: NIOSH 7402

The NIOSH 7402 method was created in 1989 to work in conjunction with the NIOSH 7400 PCM method to identify fibers as asbestos or non-asbestos from the same filter. It is particularly useful when there are elevated PCM results (> 0.01 f/cc) and it is imperative to establish whether or not there is asbestos in the air. By using the NIOSH 7402 method, it is possible to create a distinction between the fibers found via PCM analysis and actual asbestos fibers. The samples are analyzed at a magnification of between 2,000 and 10,000 and structures are identified at 20,000X by the above means. Structures meeting the definition of a fiber (having substantially parallel sides), meeting the minimum length of 5 microns and having a length to width ratio of 3:1 and are then classified as chrysotile, amphibole or non-asbestos. With each set of samples, individual laboratory blanks are prepared and analyzed to assure that there is no laboratory or filter contamination.

National Fuel
Building #8
NY202061

Method Reference: AHERA Method 40 CFR, Part 763 October 30, 1987

The AHERA (Asbestos Hazard Emergency Response Act) method was created in 1986 by the US EPA and is used to determine whether an abatement site is sufficiently clean in order for containment barriers to be removed. In a typical setting, there are 5 inside samples, 5 outside samples and 3 blanks taken. The samples are required to average less than 70s/mm² per set in order for a containment area to be considered safe and ready to re-enter. The samples are analyzed at a magnification of between 15,000 and 20,000X and asbestos structures are identified by SAED and EDS determination. Structures meeting the definition of a fiber (having substantially parallel sides), meeting the minimum length of 5 microns and having a length to width ratio of 5:1 and are then classified as chrysotile or amphibole asbestos in correlation with the definitions set forth by AHERA. With each set of samples, individual laboratory blanks are prepared and analyzed to assure that there is no laboratory or filter contamination.

National Fuel
Building #8
NY202061

Project Monitor Final Visual Inspection

IsleChem, LLC
Grand Island, NY

PROJECT MONITOR FINAL INSPECTION

Project Name: NAT. Fuel, Bldg. 8 Job Number: NY202061

Work Area: 1st + 2nd Floor, Floor TILE + MASTIC

Project Monitor Visual Inspection within the specific work area in order to comply with ICR 56-9.1 has been done by a project monitor from IsleChem.

Project Monitor Visual Inspection. An appropriately trained and certified project monitor, contracted by the building/structure owner, independent of the asbestos abatement contractor, shall complete the visual inspection. The project monitor visual inspection for completeness of abatement and completeness of cleanup shall be performed as per the provisions of the current ASTM Standard E1368 "Standard Practice for Visual Inspection of Asbestos Abatement Projects". If the property owner is the asbestos abatement contractor for the asbestos project, the owner shall contract with an independent project monitoring firm asbestos contractor for the necessary visual inspection on the asbestos project. The asbestos abatement contractor and property owner, prior to the scheduling of the required visual inspection, shall provide a complete abatement scope of work for the asbestos project to the project monitor. An entry shall be made into the asbestos abatement contractor supervisor's daily log by both the supervisor and the individual performing the inspection, detailing the findings of the visual inspection. The full name and NYSDOL asbestos handling certificate number of the certified individual performing the inspection shall also be documented in the supervisor's daily log.

56-9.3(c) Once the asbestos abatement contractor receives satisfactory clearance air sample results, or an acceptable visual inspection for an exempt regulated abatement work area, and all tools and equipment are removed, all remaining polyethylene, duct tape, expandable foam and other barrier materials shall be bagged, wrapped or containerized and labeled as asbestos waste. Temporary hardwall barriers must be dismantled and removed from the site. If any debris/residue is observed behind barriers, it shall be removed and bagged/containerized followed by HEPA-vacuuming and wetcleaning of the surfaces that were hidden behind the barrier. All waste generated shall be removed to the holding area, lockable trailer or lockable hardtop dumpster as per Section 8.9 of this Part. The asbestos abatement contractor's supervisor shall then conduct a final inspection of the regulated abatement work area to certify that the abatement work is complete and no debris/residue remains. The results of the final inspection for each regulated abatement work area shall be noted in the asbestos abatement contractor supervisor's daily project log.

DATE 2/20/12 TIME 7:30

Project Monitor Name: Anthony Ford Signature: AF
Project Monitor License #: 08-151410

DATE _____ TIME _____
Contractor's Supervisor Name: _____ Signature: _____

Comments: No visible ACM on floor where mastic + tiles were removed @ time of inspection.

IsleChem, LLC
2801 Long Road
Grand Island, NY 14072
(716) 773-8100
(800) 699-8606

www.islechem.com

IsleChem, LLC
Grand Island, NY

PROJECT MONITOR FINAL INSPECTION

Project Name: Natural Fuel Bldg 8 Job Number: NY202-061-01

Work Area: Rm 1001 tent

Project Monitor Visual Inspection within the specific work area in order to comply with ICR 56-9.1 has been done by a project monitor from IsleChem.

Project Monitor Visual Inspection. An appropriately trained and certified project monitor, contracted by the building/structure owner, independent of the asbestos abatement contractor, shall complete the visual inspection. The project monitor visual inspection for completeness of abatement and completeness of cleanup shall be performed as per the provisions of the current ASTM Standard E1368 "Standard Practice for Visual Inspection of Asbestos Abatement Projects". If the property owner is the asbestos abatement contractor for the asbestos project, the owner shall contract with an independent project monitoring firm asbestos contractor for the necessary visual inspection on the asbestos project. The asbestos abatement contractor and property owner, prior to the scheduling of the required visual inspection, shall provide a complete abatement scope of work for the asbestos project to the project monitor. An entry shall be made into the asbestos abatement contractor supervisor's daily log by both the supervisor and the individual performing the inspection, detailing the findings of the visual inspection. The full name and NYSDOL asbestos handling certificate number of the certified individual performing the inspection shall also be documented in the supervisor's daily log.

56-9.3(c) Once the asbestos abatement contractor receives satisfactory clearance air sample results, or an acceptable visual inspection for an exempt regulated abatement work area, and all tools and equipment are removed, all remaining polyethylene, duct tape, expandable foam and other barrier materials shall be bagged, wrapped or containerized and labeled as asbestos waste. Temporary hardwall barriers must be dismantled and removed from the site. If any debris/residue is observed behind barriers, it shall be removed and bagged/containerized followed by HEPA-vacuuming and wetcleaning of the surfaces that were hidden behind the barrier. All waste generated shall be removed to the holding area, lockable trailer or lockable hardtop dumpster as per Section 8.9 of this Part. The asbestos abatement contractor's supervisor shall then conduct a final inspection of the regulated abatement work area to certify that the abatement work is complete and no debris/residue remains. The results of the final inspection for each regulated abatement work area shall be noted in the asbestos abatement contractor supervisor's daily project log.

DATE 2-13-12 TIME 1400

Project Monitor Name: Daniel Janish
Project Monitor License #: 09-14211

Signature: 

DATE 2-13-12 TIME 200

Contractor's Supervisor Name: Erik Kelkenberg

Signature: 

Comments: Asm pipe wrap was removed from Bldg 8 Rm 1001. The area was cleaned and no visible debris was observed.

isleChem, LLC
2801 Long Road
Grand Island, NY 14072
(716) 773-8100
(800) 699-8606

www.islechem.com

IsleChem, LLC
Grand Island, NY

PROJECT MONITOR FINAL INSPECTION

Project Name: National Fuel Bldg 8 Job Number: NY202-061

Work Area: Exterior

Project Monitor Visual Inspection within the specific work area in order to comply with ICR 56-9.1 has been done by a project monitor from IsleChem.

Project Monitor Visual Inspection. An appropriately trained and certified project monitor, contracted by the building/structure owner, independent of the asbestos abatement contractor, shall complete the visual inspection. The project monitor visual inspection for completeness of abatement and completeness of cleanup shall be performed as per the provisions of the current ASTM Standard E1368 "Standard Practice for Visual Inspection of Asbestos Abatement Projects". If the property owner is the asbestos abatement contractor for the asbestos project, the owner shall contract with an independent project monitoring firm asbestos contractor for the necessary visual inspection on the asbestos project. The asbestos abatement contractor and property owner, prior to the scheduling of the required visual inspection, shall provide a complete abatement scope of work for the asbestos project to the project monitor. An entry shall be made into the asbestos abatement contractor supervisor's daily log by both the supervisor and the individual performing the inspection, detailing the findings of the visual inspection. The full name and NYSDOL asbestos handling certificate number of the certified individual performing the inspection shall also be documented in the supervisor's daily log.

56-9.3(c) Once the asbestos abatement contractor receives satisfactory clearance air sample results, or an acceptable visual inspection for an exempt regulated abatement work area, and all tools and equipment are removed, all remaining polyethylene, duct tape, expandable foam and other barrier materials shall be bagged, wrapped or containerized and labeled as asbestos waste. Temporary hardwall barriers must be dismantled and removed from the site. If any debris/residue is observed behind barriers, it shall be removed and bagged/containerized followed by HEPA-vacuuming and wetcleaning of the surfaces that were hidden behind the barrier. All waste generated shall be removed to the holding area, lockable trailer or lockable hardtop dumpster as per Section 8.9 of this Part. The asbestos abatement contractor's supervisor shall then conduct a final inspection of the regulated abatement work area to certify that the abatement work is complete and no debris/residue remains. The results of the final inspection for each regulated abatement work area shall be noted in the asbestos abatement contractor supervisor's daily project log.

DATE 2-14-12 TIME 1430

Project Monitor Name: Daniel Janish
Project Monitor License #: 08-19211

Signature: 

DATE 2-14-12 TIME 230

Contractor's Supervisor Name: ERIK KEIKENBAUM

Signature: 

Comments: A transite stack on the right exterior of Bldg 8 was removed. Area was cleaned. No visible debris.

IsleChem, LLC
2801 Long Road
Grand Island, NY 14072
(716) 773-8100
(800) 699-8606

www.islechem.com

National Fuel
Building #8
NY202061

Results and Chain of Custody Documents

for

**Flooring Removal
Job # NY202061**



Analysis Report

Client: James A. Clark
National Fuel
5955 New Taylor Rd.

Project: Air Samples for Fiber Counting Analysis
Buffalo, NY
365 Mineral Springs Rd.

Orchard Park, NY 14127 USA

Report Date: Thursday, February 09, 2012

Report ID: NY202061.0.28279

PO# / Release# /

Reference #:

Sample Date: Wednesday, February 08, 2012

Report Status: Final

Phase: Building 8 Floor Tile/Pipe

Batch: Backgrounds

Test Method: Fibers in Air by NIOSH 7400 A Rules

Authorized Signature: *Fred Bozek*

Fred Bozek, Director of Asbestos Testing

Sample ID	Lab Sample #	Location / Description	Sample Volume	Analytical Sensitivity		Sample Results		Analyst Date
				f/m ³	f/cc	f/m ³	f/cc	
061-0208-01	148528	A - Room 1001 - Background - IWA	600 L	7.01	0.0045	<7.01	<0.0045	FB 2/9/2012
061-0208-02	148529	B - Room 1002 - Background - IWA	600 L	7.01	0.0045	<7.01	<0.0045	FB 2/9/2012
061-0208-03	148530	C - Room 1003 - Background - IWA	600 L	7.01	0.0045	<7.01	<0.0045	FB 2/9/2012
061-0208-04	148531	D - Room 2004 - Background - IWA	600 L	7.01	0.0045	<7.01	<0.0045	FB 2/9/2012
061-0208-05	148532	E - Room 2007 - Background - IWA	600 L	7.01	0.0045	<7.01	<0.0045	FB 2/9/2012

The following result table is for 12 samples received by IsleChem LLC on 02/08/2012 sampled by Daniel Janish of IsleChem LLC on 02/08/2012. Also enclosed is the paperwork submitted with the samples.

Sample ID	Lab Sample # Lab Vessel ID	Location / Description	Sample Volume	Analytical Sensitivity f/min2	f/cc	Sample Results f/min2	f/cc	Analysf Date
061-0208-06	148533	F - Right Exterior - Background - OWA	600 L	7.01	0.0045	<7.01	<0.0045	FB 2/9/2012
061-0208-07	148534	G - Room 1005 - Background - OWA	600 L	7.01	0.0045	<7.01	<0.0045	FB 2/9/2012
061-0208-08	148535	H - Left Exterior Door - Background - OWA	600 L	7.01	0.0045	<7.01	<0.0045	FB 2/9/2012
061-0208-09	148536	I - Room 2001 - Background - OWA	600 L	7.01	0.0045	<7.01	<0.0045	FB 2/9/2012
061-0208-10	148537	J - Room 2002 - Background - OWA	600 L	7.01	0.0045	<7.01	<0.0045	FB 2/9/2012
061-0208-11	148538	Box Blank - Blank	0 L	7.01		<7.01		FB 2/9/2012
061-0208-12	148539	Field Blank - Blank	0 L	7.01		<7.01		FB 2/9/2012

IsleChem LLC

2801 Long Road, Grand Island NY 14072

NYS DOH ELAP ID# 11862

EPA Lab Code: NY01086

(716) 773-8401

Project: NY202061.0.28279

www.islechem.com

Page: 2 of 3

Sample ID	Lab Sample #	Location / Description	Sample Volume	Analytical Sensitivity	Sample Results	Analyst Date
	Lab Vessel ID		fmm2	fmm2	fmm2	

General Comments:

Technique Specific Disclaimer (PCM)

Asbestos testing using Phase Contrast Microscopy (PCM) techniques quantifies all fibers or fiber-like particles measuring five (5) microns in length, having a length to width ratio of 3:1, and are greater than 0.25 microns in diameter. It cannot be assumed that all the fibers counted are asbestos, since every fiber and fiber-like particle meeting the NIOSH dimension criteria must be counted. Additionally the Phase Contrast Microscope has an optical resolution of 0.25 microns in diameter and asbestos fibers can be significantly smaller than 0.25 microns in diameter.

If the sample(s) represented by these test results were not collected by IsleChem LLC then IsleChem LLC makes no representation regarding the accuracy of the fibers per cubic centimeter (f/cc) calculation presented.

All NIOSH 7400 final sample results are blank corrected unless field blank samples are not submitted with the sample set.

Fiber counts above 1300 fibers/mm squared and fiber counts from samples with > 50% of the filter area covered with particulate should be reported as "uncountable" or "probably biased". Other fiber counts outside the 100-1300 fibers/mm squared range should be reported as having "greater than optimal variability" and as being "probably biased".

General Disclaimer

The test results are submitted pursuant to IsleChem LLC's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which the results are used or interpreted.

This report is issued for the benefit of and may be relied upon by the client named above. The client bears full responsibility for deciding the level of testing for sample submitted to IsleChem LLC.

These results pertain only to the items tested.

This report shall not be reproduced except in full.

If the sample(s) represented by these test results were not collected by IsleChem LLC then the test results are limited to the reported values determined by the analytical testing process. IsleChem LLC makes no representation regarding the number of samples submitted, sample's collection technique, condition, volume, times, homogeneity or any other aspect of the sample(s) prior to IsleChem LLC taking possession of the sample(s) and the influence it may have on the results.

Unless notified in writing to return the samples covered by this report, IsleChem LLC will store what remains of the sample(s), if anything, for a period of 60 days before discarding, unless otherwise required by law. A shipping and handling fee will be charged for the return of any sample(s).

Relative Standard Deviations

Intra-Laboratory Ranges:	
5-20 Fibers	27.24
20-50 Fibers	22.14
50-100 Fibers	17.85
>100 Fibers	17.67

FB-Ranges:	
5-20 Fibers	27.23
20-50 Fibers	25.20
50-100 Fibers	14.82
>100 Fibers	16.08

KB-Ranges:	
5-20 Fibers	27.25
20-50 Fibers	19.07
50-100 Fibers	20.88
>100 Fibers	19.26

Analysis performed on Nikon Labophot Phase Contrast Microscope

NA = Not Analyzed

<XXX = Less than the quantitation limit

IsleChem LLC

2801 Long Road, Grand Island NY 14072

NYS DOH ELAP ID# 11862

EPA Lab Code: NY01086

(716) 773-8401

Project: NY202061.0.28279

(716) 773-8517

www.islechem.com

Page: 3 of 3



Analysis Report

Client: James A. Clark
National Fuel
5955 New Taylor Rd.

Project: Air Samples for Fiber Counting Analysis
Buffalo, NY
365 Mineral Springs Rd.

Orchard Park, NY 14127 USA

Report Date: Tuesday, February 14, 2012

Phase: Building 8 Floor Tile/Pipe

Report ID: NY202061.0.28356

PO# / Release# /

Batch: Environmentals

Reference #:

Test Method: Fibers in Air by NIOSH 7400 A Rules

Sample Date: Monday, February 13, 2012

Report Status: Final

Authorized Signature: *Fred Bozek*

Fred Bozek, Director of Asbestos Testing

Sample ID	Lab Sample #	Location / Description	Sample Volume	Analytical Sensitivity f/m ²	f/cc	Sample Results f/m ²	f/cc	Analyst	Date
061-0213-13	148812	K - Decon Entrance - Environmental - OWA	868 L	7.01	0.0031	<7.01	<0.0031	KB	2/14/2012
061-0213-14	148813	L - Decon Exit - Environmental - OWA	868 L	7.01	0.0031	<7.01	<0.0031	KB	2/14/2012
061-0213-15	148814	M - Critical - Rear Door - Environmental - OWA	880 L	7.01	0.0031	<7.01	<0.0031	KB	2/14/2012
061-0213-16	148815	N - Critical - Left Door - Environmental - OWA	880 L	7.01	0.0031	<7.01	<0.0031	KB	2/14/2012
061-0213-17	148816	O - Wastout - Environmental - OWA	878 L	7.01	0.0031	<7.01	<0.0031	KB	2/14/2012

The following result table is for 8 samples received by IsleChem LLC on 02/14/2012 sampled by Daniel Janish of IsleChem LLC on 02/13/2012. Also enclosed is the paperwork submitted with the samples.

Sample ID	Lab Sample # Lab Vessel ID	Location / Description	Sample Volume	Analytical Sensitivity		Sample Results		Analyst Date
				f/mm2	f/cc	f/mm2	f/cc	
061-0213-18	148817	P - Ambient - Environmental - OWA	880 L	7.01	0.0031	<7.01	<0.0031	KB 2/14/2012
061-0213-19	148818	Box Blank - Blank	0 L	7.01		<7.01		KB 2/14/2012
061-0213-20	148819	Field Blank - Blank	0 L	7.01		<7.01		KB 2/14/2012

Sample ID	Lab Sample #	Location / Description	Sample Volume	Analytical Sensitivity	Sample Results	Analyst
	Lab Vessel ID		f/mm2	f/mm2	f/mm2	Date

General Comments:

Technique Specific Disclaimer (PCMs)
 •Asbestos testing using Phase Contrast Microscopy (PCM) techniques quantifies all fibers or fiber-like particles measuring five (5) microns in length, having a length to width ratio of 3:1, and are greater than 0.25 microns in diameter. It cannot be assumed that all the fibers counted are asbestos, since every fiber and fiber-like particle meeting the NIOSH dimension criteria must be counted. Additionally the Phase Contrast Microscope has an optical resolution of 0.25 microns in diameter and asbestos fibers can be significantly smaller than 0.25 microns in diameter.
 •If the sample(s) represented by these test results were not collected by IsleChem LLC then IsleChem LLC makes no representation regarding the accuracy of the fibers per cubic centimeter (f/cc) calculation presented.
 •All NIOSH 7400 final sample results are blank corrected unless field blank samples are not submitted with the sample set.
 •Fiber counts above 1300 fibers/mm squared and fiber counts from samples with > 50% of the filter area covered with particulate should be reported as "uncountable" or "probably biased". Other fiber counts outside the 100-1300 fibers/mm squared range should be reported as having "greater than optimal variability" and as being "probably biased".

General Disclaimer

•The test results are submitted pursuant to IsleChem LLC's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which the results are used or interpreted.
 •This report is issued for the benefit of and may be relied upon by the client named above. The client bears full responsibility for deciding the level of testing for sample submitted to IsleChem LLC.
 •These results pertain only to the items tested.
 •This report shall not be reproduced except in full.
 •If the sample(s) represented by these test results were not collected by IsleChem LLC then the test results are limited to the reported values determined by the analytical testing process. IsleChem LLC makes no representation regarding the number of samples submitted, sample's collection technique, condition, volume, times, homogeneity or any other aspect of the sample(s) prior to IsleChem LLC taking possession of the sample(s) and the influence it may have on the results.
 •Unless notified in writing to return the samples covered by this report, IsleChem LLC will store what remains of the sample(s), if anything, for a period of 60 days before discarding, unless otherwise required by law. A shipping and handling fee will be charged for the return of any sample(s).

Relative Standard Deviations

Intra-Laboratory Ranges:

5-20 Fibers	27.24
20-50 Fibers	22.14
50-100 Fibers	17.85
>100 Fibers	17.67

FB-Ranges:

5-20 Fibers	27.23
20-50 Fibers	25.20
50-100 Fibers	14.82
>100 Fibers	16.08


KB-Ranges:

5-20 Fibers	27.25
20-50 Fibers	19.07
50-100 Fibers	20.88
>100 Fibers	19.26

Analysis performed on Nikon Labophot Phase Contrast Microscope

NA = Not Analyzed

<X.XX = Less than the quantitation limit



Analysis Report

Client: James A. Clark
National Fuel
5955 New Taylor Rd.

Project: Air Samples for Fiber Counting Analysis
Buffalo, NY
365 Mineral Springs Rd.

Orchard Park, NY 14127 USA
Report Date: Wednesday, February 15, 2012
Report ID: NY202061.0.28382
PO# / Release# /
Reference #: /
Sample Date: Tuesday, February 14, 2012
Report Status: Final

Phase: Building 8 Floor Tie/Pipe
Batch: Environmentals
Test Method: Fibers in Air by NIOSH 7400 A Rules

Authorized Signature: *Fred Bozek*

Fred Bozek, Director of Asbestos Testing

Sample ID	Lab Sample #	Lab Vessel ID	Location / Description	Sample Volume	from2	f/cc	Analytical Sensitivity	f/m ³	f/cc	Sample Results	Analyst	Date
061-0214-21	148904		K - Decon Entrance - Environmental - OWA	926 L	7.01	0.0029	0.0029	<7.01	<0.0029	<0.0029	FB	2/15/2012
061-0214-22	148905		L - Decon Ext. - Environmental - OWA	926 L	7.01	0.0029	0.0029	<7.01	<0.0029	<0.0029	FB	2/15/2012
061-0214-23	148906		M - Critical - Rear Door - Environmental - OWA	926 L	7.01	0.0029	0.0029	<7.01	<0.0029	<0.0029	FB	2/15/2012
061-0214-24	148907		N - Critical - Left Door - Environmental - OWA	926 L	7.01	0.0029	0.0029	<7.01	<0.0029	<0.0029	FB	2/15/2012
061-0214-25	148908		O - Wastewat - Environmental - OWA	926 L	7.01	0.0029	0.0029	<7.01	<0.0029	<0.0029	FB	2/15/2012

The following result table is for 8 samples received by IsleChem LLC on 02/15/2012 sampled by Daniel Janish of IsleChem LLC on 02/14/2012. Also enclosed is the paperwork submitted with the samples.

Sample ID	Lab Sample # Lab Vessel ID	Location / Description	Sample Volume	Analytical Sensitivity		Sample Results		Analyst Date
				f/mm2	f/cc	f/mm2	f/cc	
061-0214-26	148909	P - Ambient - Environmental - OWA	926 L	7.01	0.0029	<7.01	<0.0029	FB 2/15/2012
061-0214-27	148910	Box Blank - Blank	0 L	7.01		<7.01		FB 2/15/2012
061-0214-28	148911	Field Blank - Blank	0 L	7.01		<7.01		FB 2/15/2012

Sample ID	Lab Sample #	Location / Description	Sample Volume	Analytical Sensitivity	Sample Results	Analyst Date
	Lab Vessel ID		f/mm2	f/mm2	f/mm2	

General Comments:

Technique Specific Disclaimer (PC-M)
 •Asbestos testing using Phase Contrast Microscopy (PCM) techniques quantifies all fibers or fiber-like particles measuring five (5) microns in length, having a length to width ratio of 3:1, and are greater than 0.25 microns in diameter. It cannot be assumed that all the fibers counted are asbestos, since every fiber and fiber-like particle meeting the NIOSH dimension criteria must be counted. Additionally the Phase Contrast Microscope has an optical resolution of 0.25 microns in diameter and asbestos fibers can be significantly smaller than 0.25 microns in diameter.
 •If the sample(s) represented by these test results were not collected by IsleChem LLC, then IsleChem LLC makes no representation regarding the accuracy of the fibers per cubic centimeter (f/cc) calculation presented.
 •All NIOSH 7400 final sample results are blank corrected unless field blank samples are not submitted with the sample set.
 •Fiber counts above 1300 fibers/mm squared and fiber counts from samples with > 50% of the filter area covered with particulate should be reported as "unaccountable" or "probably biased". Other fiber counts outside the 100-1300 fibers/mm squared range should be reported as having "greater than optimal variability" and as being "probably biased".

General Disclaimer
 •The test results are submitted pursuant to IsleChem LLC's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which the results are used or interpreted.
 •This report is issued for the benefit of and may be relied upon by the client named above. The client bears full responsibility for deciding the level of testing for sample submitted to IsleChem LLC.
 •These results pertain only to the items tested.
 •This report shall not be reproduced except in full.
 •If the sample(s) represented by these test results were not collected by IsleChem LLC, then the test results are limited to the reported values determined by the analytical testing process. IsleChem LLC makes no representation regarding the number of samples submitted, sample's collection technique, condition, volume, times, homogeneity or any other aspect of the sample(s) prior to IsleChem LLC taking possession of the sample(s) and the influence it may have on the results.
 •Unless notified in writing to return the samples covered by this report, IsleChem LLC will store what remains of the sample(s), if anything, for a period of 60 days before discarding, unless otherwise required by law. A shipping and handling fee will be charged for the return of any sample(s).

Relative Standard Deviations

Intra-Laboratory Ranges:

5-20 Fibers	27.24
20-50 Fibers	22.14
50-100 Fibers	17.85
>100 Fibers	17.67

FB-Ranges:

5-20 Fibers	27.23
20-50 Fibers	25.20
50-100 Fibers	14.82
>100 Fibers	16.08


KB-Ranges:

5-20 Fibers	27.25
20-50 Fibers	19.07
50-100 Fibers	20.88
>100 Fibers	19.26

Analysis performed on Nikon Labophot Phase Contrast Microscope

NA = Not Analyzed

<X.XX = Less than the quantification limit



Analysis Report

Client: James A. Clark
National Fuel
5955 New Taylor Rd.

Project: Air Samples for Fiber Counting Analysis
Buffalo, NY
365 Mineral Springs Rd.

Orchard Park, NY 14127 USA
Report Date: Thursday, February 16, 2012
Report ID: NY202061.0.28406
PO# / Release# /
Reference #:
Sample Date: Wednesday, February 15, 2012
Report Status: Final

Phase: Building 8 Floor Tile/Pipe
Batch: Environmental
Test Method: Fibers in Air by NIOSH 7400 A Rules

Authorized Signature: *Fred Bozek*

Fred Bozek, Director of Asbestos Testing

Sample ID	Lab Sample #	Location / Description	Sample Volume	Analytical Sensitivity	Sample Results	Analyst Date
	Lab Vessel ID		f/m ³	f/cc	f/m ³	
<i>The following result table is for 8 samples received by IsleChem LLC on 02/16/2012 sampled by Daniel Janish of IsleChem LLC on 02/15/2012. Also enclosed is the paperwork submitted with the samples.</i>						
061-0215-29	148993	K - Decon Entrance - Environmental - OWA	900 L	7.01	0.0030	<7.01
						<0.0030
061-0215-30	148994	L - Decon Exit - Environmental - OWA	900 L	7.01	0.0030	<7.01
						<0.0030
061-0215-31	148995	M - Critical - Rear Door - Environmental - OWA	900 L	7.01	0.0030	<7.01
						<0.0030
061-0215-32	148996	N - Critical - Left Door - Environmental - OWA	900 L	7.01	0.0030	<7.01
						<0.0030
061-0215-33	148997	O - Wastecut - Environmental - OWA	900 L	7.01	0.0030	<7.01
						<0.0030

Sample ID	Lab Sample # Lab Vessel ID	Location / Description	Sample Volume	Analytical Sensitivity		Sample Results		Analyst Date
				f/mm2	f/cc	f/mm2	f/cc	
061-0215-34	148998	P - Ambient - Environmental - OWA	900 L	7.01	0.0030	<7.01	<0.0030	FB 2/16/2012
061-0215-35	148999	Box Blank - Blank	0 L	7.01		<7.01		FB 2/16/2012
061-0215-36	149000	Field Blank - Blank	0 L	7.01		<7.01		FB 2/16/2012

Sample ID	Lab Sample #	Location / Description	Sample Volume	Analytical Sensitivity	Sample Results	Analyst Date
	Lab Vessel ID		f/mm2	f/mm2	f/mm2	

General Comments:

Technique Specific Disclaimer (PCM):
 -Asbestos testing using Phase Contrast Microscopy (PCM) techniques quantifies all fibers or fiber-like particles measuring five (5) microns in length, having a length to width ratio of 3:1, and are greater than 0.25 microns in diameter. It cannot be assumed that all the fibers counted are asbestos, since every fiber and fiber-like particle meeting the NIOSH dimension criteria must be counted. Additionally the Phase Contrast Microscope has an optical resolution of 0.25 microns in diameter and asbestos fibers can be significantly smaller than 0.25 microns in diameter.
 -If the sample(s) represented by these test results were not collected by IsleChem LLC then IsleChem LLC makes no representation regarding the accuracy of the fibers per cubic centimeter (f/cc) calculation presented.
 -All NIOSH 7400 final sample results are blank corrected unless field blank samples are not submitted with the sample set.
 -Fiber counts above 1300 fibers/mm squared and fiber counts from samples with > 50% of the filter area covered with particulate should be reported as "uncountable" or "probably biased". Other fiber counts outside the 100-1300 fibers/mm squared range should be reported as having "greater than optimal variability" and as being "probably biased".

General Disclaimer
 -The test results are submitted pursuant to IsleChem LLC's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which the results are used or interpreted.
 -This report is issued for the benefit of and may be relied upon by the client named above. The client bears full responsibility for deciding the level of testing for sample submitted to IsleChem LLC.
 -These results pertain only to the items tested.
 -This report shall not be reproduced except in full.
 -If the sample(s) represented by these test results were not collected by IsleChem LLC then the test results are limited to the reported values determined by the analytical testing process. IsleChem LLC makes no representation regarding the number of samples submitted, sample's collection technique, condition, volume, times, homogeneity or any other aspect of the sample(s) prior to IsleChem LLC taking possession of the sample(s) and the influence it may have on the results.
 -Unless notified in writing to return the samples covered by this report, IsleChem LLC will store what remains of the sample(s), if anything, for a period of 60 days before discarding unless otherwise required by law. A shipping and handling fee will be charged for the return of any sample(s).

Relative Standard Deviations

Intra-Laboratory Ranges:

5-20 Fibers	27.24
20-50 Fibers	22.14
50-100 Fibers	17.85
>100 Fibers	17.67

FB-Ranges:


5-20 Fibers	27.23
20-50 Fibers	25.20
50-100 Fibers	14.82
>100 Fibers	15.08

KB-Ranges:

5-20 Fibers	27.25
20-50 Fibers	19.07
50-100 Fibers	20.88
>100 Fibers	19.26

Analysis performed on Nikon Labophot Phase Contrast Microscope

NA = Not Analyzed
 <X.XXX = Less than the quantitation limit



Analysis Report

Client: James A. Clark
 National Fuel
 5955 New Taylor Rd.
 Orchard Park, NY 14127 USA

Report Date: Friday, February 17, 2012
 Report ID: NY202061.0.28417
 PO# / Release# /
 Reference #: Thursday, February 16, 2012
 Sample Date: Thursday, February 16, 2012
 Report Status: Final

Project: Air Samples for Fiber Counting Analysis
 Buffalo, NY
 365 Mineral Springs Rd.

Phase: Building 8 Floor Tile/Pipe
 Batch: Environmentals
 Test Method: Fibers in Air by NIOSH 7400 A Rules

Authorized Signature: *Fred Bozek*

Fred Bozek, Director of Asbestos Testing

Sample ID	Lab Sample #	Location / Description	Sample Volume	f/min2	Analytical Sensitivity f/cc	f/min2	f/cc	Sample Results	Analyst Date
061-0216-37	149066	K - Decon Entrance - Environmental - OWA	960 L	7.01	0.0028	<7.01	<0.0028	FB 2/17/2012	
061-0216-38	149067	L - Decon Exit - Environmental - OWA	960 L	7.01	0.0028	<7.01	<0.0028	FB 2/17/2012	
061-0216-39	149068	M - Critical - Rear Door - Environmental - OWA	960 L	7.01	0.0028	<7.01	<0.0028	FB 2/17/2012	
061-0216-40	149069	N - Critical - Left Door - Environmental - OWA	960 L	7.01	0.0028	<7.01	<0.0028	FB 2/17/2012	
061-0216-41	149070	O - Wastecut - Environmental - OWA	960 L	7.01	0.0028	<7.01	<0.0028	FB 2/17/2012	

The following result table is for 8 samples received by IsleChem LLC on 02/16/2012 sampled by Daniel Janish of IsleChem LLC on 02/16/2012.
 Also enclosed is the paperwork submitted with the samples.

Sample ID	Lab Sample # Lab Vessel ID	Location / Description	Sample Volume	Analytical Sensitivity f/mm2	f/cc	Sample Results f/mm2	f/cc	Analyst Date
061-0216-42	149071	P - Ambient - Environmental - OWA	960 L	7.01	0.0028	<7.01	<0.0028	FB 2/17/2012
061-0216-43	149072	Box Blank - Blank	0 L	7.01		<7.01		FB 2/17/2012
061-0216-44	149073	Field Blank - Blank	0 L	7.01		<7.01		FB 2/17/2012

Sample ID	Lab Sample #	Location / Description	Sample Volume	Analytical Sensitivity	Sample Results	Analyst Date
	Lab Vessel ID		fmm2	fmm2	fmm2	

General Comments:

Technique Specific Disclaimer (PCM)
 •Asbestos testing using Phase Contrast Microscopy (PCM) techniques quantifies all fibers or fiber-like particles measuring five (5) microns in length, having a length to width ratio of 3:1, and are greater than 0.25 microns in diameter. It cannot be assumed that all the fibers counted are asbestos, since every fiber and fiber-like particle meeting the NIOSH dimension criteria must be counted. Additionally the Phase Contrast Microscope has an optical resolution of 0.23 microns in diameter and asbestos fibers can be significantly smaller than 0.25 microns in diameter.
 •If the sample(s) represented by these test results were not collected by IsieChem LLC, then IsieChem LLC makes no representation regarding the accuracy of the fibers per cubic centimeter (f/cc) calculation presented.
 •All NIOSH 7400 final sample results are blank corrected unless field blank samples are not submitted with the sample set.
 •Fiber counts above 1300 fibers/mm squared and fiber counts from samples with > 50% of the filter area covered with particulate should be reported as "uncountable" or "probably biased". Other fiber counts outside the 100-1300 fibers/mm squared range should be reported as having "greater than optimal variability" and as being "probably biased".

General Disclaimer

•The test results are submitted pursuant to IsieChem LLC's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which the results are used or interpreted.
 •This report is issued for the benefit of and may be relied upon by the client named above. The client bears full responsibility for deciding the level of testing for sample submitted to IsieChem LLC.
 •These results pertain only to the items tested.
 •This report shall not be reproduced except in full.
 •If the sample(s) represented by these test results were not collected by IsieChem LLC then the test results are limited to the reported values determined by the analytical testing process. IsieChem LLC makes no representation regarding the number of samples submitted, sample's collection technique, condition, volume, times, homogeneity or any other aspect of the sample(s) prior to IsieChem LLC taking possession of the sample(s) and the influence it may have on the results.
 •Unless notified in writing to return the samples covered by this report, IsieChem LLC will store what remains of the sample(s), if any, for a period of 60 days before discarding, unless otherwise required by law. A shipping and handling fee will be charged for the return of any sample(s).

Relative Standard Deviations

Intra-Laboratory Ranges:

5-20 Fibers	27.24
20-50 Fibers	22.44
50-100 Fibers	17.85
>100 Fibers	17.67

FB-Ranges:

5-20 Fibers	27.23
20-50 Fibers	25.20
50-100 Fibers	14.82
>100 Fibers	16.08


KB-Ranges:

5-20 Fibers	27.25
20-50 Fibers	19.67
50-100 Fibers	20.86
>100 Fibers	19.26

Analysis performed on Nikon Labophot Phase Contrast Microscope

NA = Not Analyzed

<X.XX = Less than the quantitation limit



Analysis Report

Client: James A. Clark
National Fuel
5955 New Taylor Rd.

Project: Air Samples for Fiber Counting Analysis
Buffalo, NY
365 Mineral Springs Rd.

Report Date: Orchard Park, NY 14127 USA
Wednesday, February 22, 2012
Report ID: NY202061.0.28464
PO# / Release#: /
Reference #: /
Sample Date: Friday, February 17, 2012
Report Status: Final

Phase: Building 8 Floor Tile/Pipe
Batch: Environmentals
Test Method: Fibers in Air by NIOSH 7400 A Rules

Authorized Signature: *Fred Bozek*

Fred Bozek, Director of Asbestos Testing

Sample ID	Lab Sample #	Location / Description	Sample Volume	Analytical Sensitivity	Sample Results	Analyt Date	
	Lab Vessel ID		f/m3	f/cc	f/mm2	f/cc	
<p><i>The following result table is for 8 samples received by IsleChem LLC on 02/21/2012 submitted by Anthony Ford</i></p> <p><i>Also enclosed is the paperwork submitted with the samples.</i></p>							
061-0217-45	149289	K - Decon Entrance Outside Work Area - Environmental - OWA	960 L	7.01	0.0028	<0.0028	FB 2/21/2012
061-0217-46	149290	L - Decon Ext. Outside Work Area - Environmental - OWA	960 L	7.01	0.0028	<0.0028	FB 2/21/2012
061-0217-47	149291	M - Critical - Rear Door Outside Work Area - Environmental - OWA	960 L	7.01	0.0028	<0.0028	FB 2/21/2012
061-0217-48	149292	N - Critical - Left Door Outside Work Area - Environmental - OWA	960 L	7.01	0.0028	<0.0028	FB 2/21/2012
061-0217-49	149293	O - Wastecut Outside Work Area - Environmental - OWA	960 L	7.01	0.0028	<0.0028	FB 2/21/2012

Sample ID	Lab Sample # Lab Vessel ID	Location / Description	Sample Volume	Analytical Sensitivity		Sample Results		Analyst Date
				f/min2	f/cc	f/min2	f/cc	
061-0217-50	149294	P - Ambient Outside Work Area - Environmental - OWA	960 L	7.01	0.0028	<7.01	<0.0028	FB 2/21/2012
061-0217-51	149295	Field Blank Blank - Blank	0 L	7.01		<7.01		FB 2/21/2012
061-0217-52	149296	Box Blank Blank - Blank	0 L	7.01		<7.01		FB 2/21/2012

Sample ID	Lab Sample #	Location / Description	Sample Volume	Analytical Sensitivity	Sample Results	Analyst
	Lab Vessel ID		fmm2	fmm2	fmm2	Date

General Comments:

Technique Specific Disclaimer (FCM)
 *Asbestos testing using Phase Contrast Microscopy (PCM) techniques quantifies all fibers or fiber-like particles measuring five (5) microns in length, having a length to width ratio of 3:1, and are greater than 0.25 microns in diameter. It cannot be assumed that all the fibers counted are asbestos, since every fiber and fiber-like particle meeting the NIOSH dimension criteria must be counted. Additionally, the Phase Contrast Microscope has an optical resolution of 0.25 microns in diameter and asbestos fibers can be significantly smaller than 0.25 microns in diameter.
 *If the sample(s) represented by these test results were not collected by IsleChem LLC then IsleChem LLC makes no representation regarding the accuracy of the fibers per cubic centimeter (f/cc) calculation presented.
 *40 NIOSH 7400 final sample results are blank corrected unless field blank samples are not submitted with the sample set.
 *Fiber counts above 1300 fibers/mm squared and fiber counts from samples with > 50% of the filter area covered with particulate should be reported as "uncountable" or "probably biased". Other fiber counts outside the 100-1300 fibers/mm squared range should be reported as having "greater than optimal variability" and as being "probably biased".

General Disclaimer

*The test results are submitted pursuant to IsleChem LLC's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which the results are used or interpreted.
 *This report is issued for the benefit of and may be relied upon by the client named above. The client bears full responsibility for deciding the level of testing for sample submitted to IsleChem LLC.
 *These results pertain only to the items tested.
 *This report shall not be reproduced except in full.
 *If the sample(s) represented by these test results were not collected by IsleChem LLC then the test results are limited to the reported values determined by the analytical testing process. IsleChem LLC makes no representation regarding the number of samples submitted, sample's collection technique, condition, volume, times, homogeneity, or any other aspect of the sample(s) prior to IsleChem LLC taking possession of the sample(s) and the influence it may have on the results.
 *Unless notified in writing to return the samples covered by this report, IsleChem LLC will store what remains of the sample(s), if anything, for a period of 60 days before discarding, unless otherwise required by law. A shipping and handling fee will be charged for the return of any sample(s).

Relative Standard Deviations

Intra-Laboratory Ranges:

5-20 Fibers	27.24
20-50 Fibers	22.14
50-100 Fibers	17.85
>100 Fibers	17.67

FB-Ranges:

5-20 Fibers	27.23
20-50 Fibers	25.20
50-100 Fibers	14.82
>100 Fibers	16.68


KB-Ranges:

5-20 Fibers	27.25
20-50 Fibers	19.07
50-100 Fibers	20.88
>100 Fibers	19.26

Analysis performed on Nikon Labophot Phase Contrast Microscope

NA = Not Analyzed

<X.XX = Less than the quantitation limit



Analysis Report

Client: James A. Clark
National Fuel
5955 New Taylor Rd.

Project: Air Samples for Fiber Counting Analysis
Buffalo, NY
365 Mineral Springs Rd.

Orchard Park, NY 14127 USA
Report Date: Wednesday, February 22, 2012
Report ID: NY202061.0.28465
PO# / Release# /
Reference #:
Sample Date: Monday, February 20, 2012
Report Status: Final

Phase: Building 8 Floor Tile/Pipe
Batch:
Test Method: Fibers in Air by NIOSH 7400 A Rules

Authorized Signature: *Fred Bozek*
Fred Bozek, Director of Asbestos Testing

Sample ID	Lab Sample # Lab Vessel ID	Location / Description	Sample Volume	Analytical Sensitivity f/mm2	f/cc	Sample Results f/mm2	f/cc	Analyst Date
061-0220-53	149297	A - In Room 1001 Inside Work Area - Final - IWA	600 L	7.01	0.0045	<7.01	<0.0045	FB 2/21/2012
061-0220-54	149298	B - In Room 1002 Inside Work Area - Final - IWA	600 L	7.01	0.0045	<7.01	<0.0045	FB 2/21/2012
061-0220-55	149299	C - In Room 1003 Inside Work Area - Final - IWA	600 L	7.01	0.0045	<7.01	<0.0045	FB 2/21/2012
061-0220-56	149300	D - In Room 2004 Inside Work Area - Final - IWA	600 L	7.01	0.0045	<7.01	<0.0045	FB 2/21/2012
061-0220-57	149301	E - In Room 2007 Inside Work Area - Final - IWA	600 L	7.01	0.0045	<7.01	<0.0045	FB 2/21/2012

The following result table is for 12 samples received by IsleChem LLC on 02/21/2012 submitted by Anthony Ford. Also enclosed is the paperwork submitted with the samples.

Sample ID	Lab Sample-# Lab Vessel ID	Location / Description	Sample Volume	Analytical Sensitivity		Sample Results		Analyst Date
				f/mm2	f/cc	f/mm2	f/cc	
061-0220-58	149302	F - At Right Exterior Door Outside Work Area - Final - OWA	600 L	7.01	0.0045	<7.01	<0.0045	FB 2/21/2012
061-0220-59	149303	G - In Room 1005 Outside Work Area - Final - OWA	600 L	7.01	0.0045	<7.01	<0.0045	FB 2/21/2012
061-0220-60	149304	H - At Left Exterior Door Outside Work Area - Final - OWA	600 L	7.01	0.0045	<7.01	<0.0045	FB 2/21/2012
061-0220-61	149305	I - In Room 2001 Outside Work Area - Final - OWA	600 L	7.01	0.0045	<7.01	<0.0045	FB 2/21/2012
061-0220-62	149306	J - In Room 2002 Outside Work Area - Final - OWA	600 L	7.01	0.0045	<7.01	<0.0045	FB 2/21/2012
061-0220-63	149307	Field Blank Blank - Blank	0 L	7.01		<7.01		FB 2/21/2012
061-0220-64	149308	Box Blank Blank - Blank	0 L	7.01		<7.01		FB 2/21/2012

Sample ID	Lab Sample #	Location / Description	Sample Volume	Analytical Sensitivity	Sample Results	Analyst Date
	Lab Vessel ID		f/mm2	f/mm2		

General Comments:

Technique Specific Disclaimer (PCM):
 •Asbestos testing using Phase Contrast Microscopy (PCM) techniques quantifies all fibers or fiber-like particles measuring fine (5) microns in length, having a length to width ratio of 3:1, and are greater than 0.25 microns in diameter. It cannot be assumed that all the fibers counted are asbestos, since every fiber and fiber-like particle meeting the NIOSH dimension criteria must be counted. Additionally the Phase Contrast Microscope has an optical resolution of 0.25 microns in diameter and asbestos fibers can be significantly smaller than 0.25 microns in diameter.
 •If the sample(s) represented by these test results were not collected by IsieChem LLC, then IsieChem LLC makes no representation regarding the accuracy of the fibers per cubic centimeter (f/cc) calculation presented.
 •All NIOSH 7400 final sample results are blank corrected unless field blank samples are not submitted with the sample set.
 •Fiber counts above 1300 fibers/mm squared and fiber counts from samples with > 50% of the filter area covered with particulate should be reported as "uncountable" or "probably biased". Other fiber counts outside the 100-1300 fibers/mm squared range should be reported as having "greater than optimal variability" and as being "probably biased".

General Disclaimer
 •The test results are submitted pursuant to IsieChem LLC's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which the results are used or interpreted.
 •This report is issued for the benefit of and may be relied upon by the client named above. The client bears full responsibility for deciding the level of testing for sample submitted to IsieChem LLC.
 •These results pertain only to the items tested.
 •This report shall not be reproduced except in full.
 •If the sample(s) represented by these test results were not collected by IsieChem LLC, then the test results are limited to the reported values determined by the analytical testing process. IsieChem LLC makes no representation regarding the number of samples submitted, sample's collection technique, condition, volume, times, homogeneity or any other aspect of the sample(s) prior to IsieChem LLC taking possession of the sample(s) and the influence it may have on the results.
 •Unless notified in writing to return the samples covered by this report, IsieChem LLC will store what remains of the sample(s), if anything, for a period of 60 days before discarding, unless otherwise required by law. A shipping and handling fee will be charged for the return of any sample(s).

Relative Standard Deviations

Intra-Laboratory Ranges:

5-20 Fibers	27.24
20-50 Fibers	22.14
50-100 Fibers	17.85
>100 Fibers	17.57

FB-Ranges:

5-20 Fibers	27.23
20-50 Fibers	25.20
50-100 Fibers	14.82
>100 Fibers	16.08

KB-Ranges:

5-20 Fibers	27.25
20-50 Fibers	19.07
50-100 Fibers	20.88
>100 Fibers	19.26

Analysis performed on Nikon Labophot Phase Contrast Microscope
 NA = Not Analyzed
 <X.XX = Less than the quantization limit

Customer Name National Fuel		Project Name National Fuel Bldg 8		NYS DOL ICR 56 Phase Designations Backgrounds		Cassette Filter Lot # 23674	
Street Address 365 Mineola Springs Rd		Project Address 365 Mineola Springs Rd		Work Area Designations Bldg 8		Rotameter # / Calibration Date IC-01 / 12-21-12	
City, State, ZIP Buffalo, NY 14210		City, State, ZIP Buffalo, NY 14210		Shift / Time 1st		IsleChem Project Number NY 202-061-0229	
Contact Person James Clark		Client PO / Release #		Sampled by D. Janish		Turnaround RUSH (24 hours)	
Phone and Fax#		Description of Work Floor tile paper		Sample Date 2-8-12		Analysis NIOSH 7400 - PCM	
clarkje@natfuel.com		Floor tile paper		2-8-12		48 hours 3-5 days 6-10 day	

Sample #	Loc	Location Description	IWA OWA	Type B P E F	Time (24 hr clock)		Total Minutes	Flow Rate (LPM)		Total Volume	Egas (%)
					Start	Stop		Start	Stop		
1	A	Rm 1001	Jwb	B	1127	1207	40	15	15	600	
2	B	Rm 1002	Jwb	B	1128	1208	40	15	15	600	
3	C	Rm 1003	Jwb	B	1129	1209	40	15	15	600	
4	D	Rm 2004	Jwb	B	1133	1213	40	15	15	600	
5	E	Rm 2007	Jwb	B	1136	1216	40	15	15	600	
6	F	Right exterior	OWA	B	1237	1317	40	15	15	600	
7	G	Rm 1005	OWA	B	1239	1319	40	15	15	600	
8	H	Left exterior door	OWA	B	1240	1320	40	15	15	600	
9	I	Rm 2001	OWA	B	1249	1329	40	15	15	600	
10	J	Rm 2002	OWA	B	1255	1335	40	15	15	600	
11		Box Blank									
12		Field Blank									

Comments:

Sampled by: *[Signature]*
 Date: 2-8-12 1335
 Returned by: *[Signature]*
 Date: 2-8-12 400pm

IsleChem, LLC
 2801 Long Road
 Grand Island, NY 14072
 716-773-8614 - FAX 716-773-8517
 Air Sample Log / Chain of Custody

by requesting these samples to IsleChem, LLC you are accepting the current IsleChem, LLC terms and conditions for the sale of services

Customer Name National Fuel	Project Name Bldg 8	NYS DOCS 408.56 Phase Designation Environmentals	Cassette Filter Lot #
Street Address 365 Mineral Springs Rd	Project Address 365 Mineral Springs Rd	Work Area Designation Bldg 8	Rotometer # / Calibration Date IC-01 - 12-21-11
City, State, ZIP Buffalo, NY	City, State, ZIP Buffalo, NY	Shift / Time 1st	IsleChem Project Number N/202-061-0-28550
Contact Person James A Clark	Client PO / Release #	Sampled by D Jansh	Turnaround RUSH 24 hours
Phone# and Fax#	Description of Work Tile / mastic	Sample Date 2-13-12	Analysis NIOSH 7400 - PCM
			48 hours 3-5 days 6-10 day

Sample #	Loc	Location Description	HWA OWA	Type BPEF	Time (24 hr clock)		Total Minutes	Flow Rate (LPM)		Total Volume	Lab ID
					Start	Stop		Start	Stop		
061-0213-13	K	Decon ent	OWA	6	0805	1519	434	2	2	868	
14	L	Decon ext	OWA	6	0806	1520	434	2	2	868	
15	M	Critical Rear door	OWA	6	0755	1515	440	2	2	880	
16	W	Critical left door	OWA	6	0756	1516	440	2	2	880	
17	O	Wasteout	OWA	6	0759	1518	439	2	2	878	
18	P	Ambient	OWA	6	0757	1517	440	2	2	880	
19		Box Blank									
20		Field Blank									

Comments:

Sampled by <i>[Signature]</i>	Date 2-13-12	Time 1520	Received by	Date	Time
Requisitioned by <i>[Signature]</i>	Date 2-13-12	Time 1600	Received by <i>[Signature]</i>	Date 2/14/12	Time 8:30 AM

IsleChem, LLC
 2801 Long Road
 Grand Island, NY 14072
 716-773-8614 - FAX 716-773-8517
Air Sample Log / Chain of Custody

by relinquishing these sample to IsleChem, LLC you are accepting the current IsleChem, LLC terms and conditions for the sale of services

Customer Name National Fuel		Project Name Bldg 8		NYS DCL ICR 56 Phase Designation Environmentals		Cassette Filter Lot # 23674	
Street Address 365 Mineral Springs Rd		Project Address 365 Mineral Springs		Work Area Designation Bldg 8		Rotameter # / Calibration Date TC-01 / 12-21-11	
City, State, ZIP Buffalo, NY		City, State, ZIP Buffalo, NY		Shift / Time 1st		IsleChem Project Number NT202-061-0-28312	
Contact Person James A. Clark		Client PC / Release #		Sampled by D. Jarvis		Turnaround RUSH 24 hours 48 hours 3-5 days 6-10 day	
Phone# and Fax#		Description of Work Tile/mastic		Sample Date 2-14-12		Analysis MOSH 7400 - PCM AHERA - TEM	

Sample #	Loc	Location Description	IWA OWA	Type B P E F	Time (24-hr clock)		Total Minutes	Flow Rate (LPM)	Total Volume	Leak ID
					Start	Stop				
061-0214-23	K	Decon ext	OWA	E	0717	1500	463	2	926	
2286	L	Decon ext	OWA	E	0718	1501	463	2	926	
2327	M	Critical rear door	OWA	E	0723	1506	463	2	926	
2428	N	Critical left door	OWA	E	0724	1507	463	2	926	
2527	O	Wastout	OWA	E	0722	1505	463	2	926	
2630	P	Ambient	OWA	E	0720	1503	463	2	926	
2721		Box Blank								
2832		Field Blank								
(D)										

Sampled by <i>[Signature]</i>	Date 2-14-12	Time 1507	Received by	Date	Time
Requested by <i>[Signature]</i>	Date 2-14-12	Time 1600	Received by <i>[Signature]</i>	Date 2/15/12	Time 8:30am

Comments:

IsleChem, LLC
2801 Long Road
Grand Island, NY 14072
716-773-8614 - FAX 716-773-8517
Air Sample Log / Chain of Custody

*We, LLC you are accepting the current/IsleChem, LLC terms and conditions for the sale of services.

National Fuel
 Site Address: **Bldg 8**
365 Mineral Springs Rd.
 City, State, ZIP: **Buffalo, NY**
 Contact Person: **James A. Clark**
 Phone# and Fax#

Project Name: **Bldg 8**
 Project Address: **365 Mineral Springs Rd.**
 City, State, ZIP: **Buffalo, NY**
 Client PO / Release #

MYS DOI ICR 56 Phase Designation: **Environmentals**
 Work Area Designation: **Bldg 8**
 Shift / Time: **1st**

Cassette Filler Lot #: **2473**
 Returner # / Calibration Date: **IC-01 / 12-21-11**
 IsieChem Project Number: **NY 202-0610-28106**

Sample #	Loc	Location Description	IWA OWA	Type BPEF	Time (24 hr clock)		Total Minutes	Flow Rate (LPM)		Total Volume	AHRA - TEM
					Start	Stop		Start	Stop		
29	K	Decon ent	OWA	6	0722	1:52	450	2	2	900	
30	L	Decon ext	OWA	6	0723	1:53	450	2	2	900	
31	M	Critical rear door	OWA	6	0719	1:48	450	2	2	900	
32	N	Critical left door	OWA	6	0717	1:47	450	2	2	900	
33	O	Waste ext	OWA	6	0720	1:50	450	2	2	900	
34	P	Ambient	OWA	6	0716	1:46	450	2	2	900	
35		Box Blank									
36		Field Blank									

Sampled by: *[Signature]* Date: **2-15-12** Time: **1453**
 Received by: *[Signature]* Date: **2-15-12** Time: **1530**

Sample Date: **2-15-12**
 Sampled by: **D. Jarvis**
 Analysis: **NIOSH 7400 - PCM**
 Turnaround: **RUSH 24 hours**
 48 hours 3-5 days
 6-10 day

IsieChem, LLC
 2801 Long Road
 Grand Island, NY 14072
 716-773-8614 - FAX 716-773-8517
 Air Sample Log / Chain of Custody

by relinquishing these samples to IsieChem, LLC you are accepting the current IsieChem, LLC terms and conditions for the sale of services

Customer Name: **National Fuel** Project Name: **Bldg 8** Cassette Filler Lot #: **84731**

Street Address: **365 Mineral Springs Rd** Project Address: **365 Mineral Springs Rd** Work Area Designation: **Environmentals** Relinometer # / Calibration Date: **IC-01 / 12-21-11**

City, State, Zip: **Buffalo, NY** City, State, Zip: **Buffalo, NY** Client PO / Release #: **NY 202-061-02847** SaleChem Project Number: **NY 202-061-02847**

Contact Person: **James A. Clark** Description of Work: **Floor tile/mastic** Turnaround: **RUSH 24 hours**

Phone# and Fax#: **2-16-12** Sample Date: **2-16-12** AHERA - TEM: **NIOSH 7400 - PCM**

Sampled by: **D. James** 48 hours 3-5 days 6-10 day

Sample #	Loc	Location Description	IWA	OWA	Type	Time (24 hr clock)		Total Minutes	Flow Rate (LPM)		Total Volume	Lab ID
						Start	Stop		Start	Stop		
061-0216-37	K	Decon ext	out		E	0710	1510	480	2	2	960	
38	L	Decon ext	out		E	0711	1511	480	2	2	960	
39	M	Critical Reservoir	out		E	0707	1507	480	2	2	960	
40	N	Critical Left door	out		E	0706	1506	480	2	2	960	
41	O	Wastest	out		E	0709	1509	480	2	2	960	
42	P	Ambient	out		E	0705	1505	480	2	2	960	
43		Box Blank										
44		Field Blank										

Comments:

Sampled by: *[Signature]* Date: **2-16-12** Time: **1500** Received by: **IsieChem, LLC** Date: **2/16/12** Time: **5:00 PM**

Relinquished by: *[Signature]* Date: **2-16-12** Time: **1555** Relinquished by: *[Signature]* Date: **2/16/12** Time: **5:00 PM**

Relinquishing these samples to IsieChem, LLC you are accepting the terms and conditions for the sale of services.

IsieChem, LLC
2801 Long Road
Grand Island, NY 14072
716-773-8614 - FAX 716-773-8517
Air Sample Log / Chain of Custody

Customer Name: **National Fuel** Project Name: **Bldg 8** Cassette Filler Lot #: **24274**

Street Address: **365 Mineral Springs Rd** Project Address: **365 Mineral Springs Rd** Rolometer # / Calibration Date: **IC-04 12/21/11**

City, State, Zip: **Buffalo, NY** City, State, Zip: **Buffalo, NY** Shift / Time: **1st** IsieChem Project Number: **NY 202-061**

Contact Person: **James A Clark** Client PO / Release #: **Em Pike** Sampled by: **Anthony**

Phone and Fax: **217/12** Description of Work: **Floor tile/mastic**

Turnaround: **RUSH 24 HOURS**
48 hours 3-5 days
6-10 day

Analysis: **NIOSH 7400 - PCM**
AHERA - TEM

Sample #	Loc	Location Description	IWA	CWA	Type	Time (24 hr clock)		Total Minutes	Flow Rate (LPM)		Total Volume
						Start	Stop		Start	Stop	
0610317-48	K	DECON EXT.	AWA		E	713	1513	480	2	2	960
46	L	DECON EXT.	AWA		E	716	1516	480	2	2	960
47	M	CERT REAR DOOR	AWA		E	717	1517	480	2	2	960
48	N	CERT LEFT DOOR	AWA		E	718	1518	480	2	2	960
49	O	WASTE OUT	AWA		E	719	1519	480	2	2	960
50	P	Ambient	AWA		E	720	1520	480	2	2	960
51	+	FB									
52	*	SB									

Comments:

Sampled by: **[Signature]** Date: **2/17/12** Time: **1520**

Received by: **[Signature]** Date: **2/21/12** Time: **8:30 AM**

IsieChem, LLC
2801 Long Road
Grand Island, NY 14072
716-773-8614 - FAX 716-773-8517
Air Sample Log / Chain of Custody

by returning these sample to IsieChem, LLC you are accepting the current IsieChem, LLC terms and conditions for the sale of services

Customer Name National Fuel		Project Name Bldg 8		MYS DOL ICR 56 Phase Designation Fuels		Cassette Filter Lot # 212741				
Street Address 365 Mineral Springs Rd		Project Address 365 Mineral Springs Rd		Work Area Designation Bldg 8		Relinometer # / Calibration Date IC-04 12/01/11				
City, State, Zip Buffalo, NY		City, State, Zip Buffalo, NY		Shift / Time 1st		IsleChem Project Number NY 202-061-0-28465				
Contact Person James A. Clark		Client PO / Release # Empire		Sampled by ANT Hays		Turnaround RUSH 24 hours 48 hours 3-5 days 6-10 day				
Phone and Fax#		Description of Work Floor tile/mastic		Sample Date 2/20/12		NIOSH 7400 - PCM Analysis				
Sample #	Loc	Location Description	IWA OWA	Type BPEF	Time (24 hr clock)		Flow Rate (LPM)		Total Volume	AHERA - TEM
					Start	Stop	Start	Stop		
061-022-53A		In Room 1001	FWA	F	748	848	10	10	600	9/100
54D		In Room 1002	FWA	F	750	850	10	10	600	9/100
55C		In Room 1003	FWA	F	752	852	10	10	600	9/100
56D		In Room 2001	FWA	F	756	856	10	10	600	9/100
57E		In Room 2007	FWA	F	758	858	10	10	600	9/100
58F		C RIGHT EXTERIOR DOOR	OWA	F	910	1010	10	10	600	9/100
59G		In Room 1005	OWA	F	912	1012	10	10	600	9/100
60H		C LEFT EXTERIOR DOOR	OWA	F	913	1013	10	10	600	9/100
61I		In Room 2001	OWA	F	914	1014	10	10	600	9/100
62J		In Room 2002	OWA	F	915	1015	10	10	600	9/100
63K		FB								9/100
64L		FB								9/100

Comments:

Sampled by ANT Hays	Date 2/20/12	Time 1040	Received by	Date	Time
Resampled by ANT Hays	Date 2/20/12	Time 1115	Received by James A. Clark	Date 2/20/12	Time 830am

IsleChem, LLC
2801 Long Road
Grand Island, NY 14072
716-773-8614 - FAX 716-773-8517
Air Sample Log / Chain of Custody

by relinquishing these samples to IsleChem, LLC you are accepting the current IsleChem, LLC terms and conditions for the sale of services

National Fuel
Building #8
NY202061

Results and Chain of Custody Documents

for

**Piping Removal
Job # NY202061-01**



Analysis Report

Client: James A. Clark
National Fuel
5955 New Taylor Rd.

Project: Air Samples for Fiber Counting Analysis
Buffalo, NY
365 Mineral Springs Rd.

Orchard Park, NY 14127 USA

Report Date: Tuesday, February 14, 2012

Report ID: NY202061.01.28357

PO# / Release# /

Reference #:

Sample Date: Monday, February 13, 2012

Report Status: Final

Phase: Room 1001 Tent Piping

Batch: Finals

Test Method: Fibers in Air by NIOSH 7400 A Rules

Authorized Signature: *Fred Bozek*

Fred Bozek, Director of Asbestos Testing

Sample ID	Lab Sample #	Location / Description	Sample Volume	f/mm2	Analytical Sensitivity f/cc	f/mm2	f/cc	Sample Results	Analyst Date
<i>The following result table is for 4 samples received by IsleChem LLC on 02/14/2012 sampled by Daniel Janish of IsleChem LLC on 02/13/2012. Also enclosed is the paperwork submitted with the samples.</i>									
0610213-01-01	148820	Q - Inside Room 1001 Tent - Final - IWA	600 L	7.01	0.0045	<7.01	<0.0045		KB 2/14/2012
0610213-01-02	148821	R - Outside Room 1001 Tent - Final - OWA	600 L	7.01	0.0045	<7.01	<0.0045		KB 2/14/2012
0610213-01-03	148822	Box Blank - Blank	0 L	7.01		<7.01			KB 2/14/2012
0610213-01-04	148823	Field Blank - Blank	0 L	7.01		<7.01			KB 2/14/2012

Sample ID	Lab Sample #	Location / Description	Sample Volume	Analytical Sensitivity	Sample Results	Analyst
	Lab Vessel ID		f/mm2	f/mm2	f/mm2	Date

General Comments:

Technique Specific Disclaimer (PCMF)

- Asbestos testing using Phase Contrast Microscopy (PCM) techniques quantifies all fibers or fiber-like particles measuring five (5) microns in length, having a length to width ratio of 3:1, and are greater than 0.25 microns in diameter. It cannot be assumed that all the fibers counted are asbestos, since every fiber and fiber-like particle meeting the NIOSH dimension criteria must be counted. Additionally the Phase Contrast Microscope has an optical resolution of 0.25 microns in diameter and asbestos fibers can be significantly smaller than 0.25 microns in diameter.
- If the sample(s) represented by these test results were not collected by IsleChem LLC then IsleChem LLC makes no representation regarding the accuracy of the fibers per cubic centimeter (f/cc) calculation presented.
- All NIOSH 7400 final sample results are blank corrected unless field blank samples are not submitted with the sample set.
- Fiber counts above 1300 fibers/mm squared and fiber counts from samples with > 50% of the filter area covered with particulate should be reported as "uncountable" or "probably biased". Other fiber counts outside the 100-1300 fibers/mm squared range should be reported as having "greater than optimal variability" and as being "probably biased".

General Disclaimer

- The test results are submitted pursuant to IsleChem LLC's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which the results are used or interpreted.
- This report is issued for the benefit of and may be relied upon by the client named above. The client bears full responsibility for deciding the level of testing for sample submitted to IsleChem LLC.
- These results pertain only to the items tested.
- This report shall not be reproduced except in full.
- If the sample(s) represented by these test results were not collected by IsleChem LLC then the test results are limited to the reported values determined by the analytical testing process. IsleChem LLC makes no representation regarding the number of samples submitted, sample's collection technique, condition, volume, times, homogeneity or any other aspect of the sample(s) prior to IsleChem LLC taking possession of the sample(s) and the influence it may have on the results.
- Unless notified in writing to return the samples covered by this report, IsleChem LLC will store what remains of the sample(s), if anything, for a period of 60 days before discarding, unless otherwise required by law. A shipping and handling fee will be charged for the return of any sample(s).

Relative Standard Deviations

Intra-Laboratory Ranges:

5-20 Fibers	27.24
20-50 Fibers	22.14
50-100 Fibers	17.85
>100 Fibers	17.67

FB-Ranges:

5-20 Fibers	27.23
20-50 Fibers	25.20
50-100 Fibers	14.82
>100 Fibers	16.08


KB-Ranges:

5-20 Fibers	27.25
20-50 Fibers	19.07
50-100 Fibers	20.88
>100 Fibers	19.26

Analysis performed on Nikon Labophot Phase Contrast Microscope

NA = Not Analyzed

<X.XX = Less than the quantization limit



AIR SAMPLE LOG / CHAIN OF CUSTODY

2801 Long Road, Grand Island, NY 14072 (716)773-8401 (716)773-8517 (Fax)

Customer Name		Project Name		NYS DCI ICR 56 Phase		Cassette Filter Lot #			
National Fuel Street Address		Building 8 Project Address		Finals		Rotometer # / Calibration Date			
365 Mineral Springs Road City, State, Zip		365 Mineral Springs Rd City, State, Zip		Room 1001 Tent Shift / Time		IC-01 / 12-21-11 IseChem Project Number			
Buffalo, NY Contact Person		Buffalo, NY City, State, Zip		1st Sampled By		MY202063-01 - 21327			
James A. Clark Phone # / Fax #		Direct POI Release # Contractor		Daniel Janish Sample Date		Turnaround RUSH 24 hours 48 hours 3-5 days 6-10 days			
716-667-5557 / 716-667-5530		Description of Work		2/13/2012					
Sample #	Loc	Sample Location	IWA	Type	Time (24 hr clock)	Total Minutes	Flow Rate (LPM)	Total Volume	Lab ID
			OWA	B P E F	Start Stop	Minutes	Start Stop	Avg	
0610213-01-01	Q	Inside Room 1001 Tent	IWA	F	14:17 14:57	40	15.0 15.0	15.0	600
0610213-01-02	R	Outside Room 1001 Tent	OWA	F	14:18 14:58	40	15.0 15.0	15.0	600
0610213-01-03		Box Blank							
0610213-01-04		Field Blank							

Comments: clarkj@natfuel.com

Relinquished by:	Date	Time	Received by:	Date	Time
	2/13/2012	14:58			
Relinquished by:	Date	Time	Received by:	Date	Time
	2/13/2012	16:00	Katherine Bronson	2/14/2012	7:14 AM

By relinquishing their sample to IseChem, LLC you are accepting the current IseChem, LLC terms and conditions for the sale of services

National Fuel
Building #8
NY202061

CERTIFICATIONS

NEW YORK STATE DEPARTMENT OF LABOR
DIVISION OF SAFETY AND HEALTH
LICENSE AND CERTIFICATE UNIT
STATE CAMPUS BUILDING 12
ALBANY, NY 12240

ASBESTOS HANDLING LICENSE

Islechem, LLC
2801 Long Road
Grand Island, NY 14072

FILE NUMBER: 0930886
LICENSE NUMBER: 19449
LICENSE CLASS: RESTRICTED
DATE OF ISSUE: 09/07/2011
EXPIRATION DATE: 09/30/2012

Solely Authorized Representative: Daniel O'Leary

This license has been issued in accordance with applicable provisions of Article 27 of the Labor Law of New York State and of the New York State Codes, Rules and Regulations, 12 NYCRR Part 96. It is subject to suspension or revocation for a (1) serious violation of state, federal or local laws with regard to the conduct of an asbestos project, or (2) demonstrated lack of responsibility in the conduct of any activity involving asbestos or asbestos material.

This license is valid only for the contractor named above and this license or a photocopy must be prominently displayed at the asbestos project work site. This license verifies that all persons employed by the licensee on an asbestos project in New York State have been issued an Asbestos Certificate, appropriate for the type of work they perform, by the New York State Department of Labor.

Maureen A. Cox

Maureen A. Cox, Director
FOR THE COMMISSIONER OF LABOR

Expires 12:01 AM April 11, 2012
Issued April 01, 2011



CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 402 Public Health Law of New York State

MR. MAJTIK, RUSZAI
ISELECHEM, LLC
2801 LONG ROAD
GRAND ISLAND, NY 14072-1295

NY Lab ID No. 11E362
EPA Lab Code: NSYO-056

is hereby APPROVED as an Environmental Laboratory for the category
ENVIRONMENTAL ANALYSES AIR AND EMISSIONS
All approved subcategories and/or analytes are listed below.

Miscellaneous Air
Fibers

NIOSH 7400-A FIBERS

Serial No: 74611

Facility of the New York State Department of Health. Certificates are valid only when the address shown matches completely posted, and are printed on secure paper. Consumers should always depend on the results only if printed on this Program. Consumers are directed to call (516) 402-3070 to verify the laboratory's accreditation status.

STATE OF NEW YORK - DEPARTMENT OF LABOR
ASBESTOS CERTIFICATE



SCOTT D HAMMOND
CLASS(EXPIRES)
C ATEC(11/12) D INSP(11/12)
H PM (11/12) I PD (11/12)

CERT# 08-10644
DMV# 990146967

MUST BE CARRIED ON ASBESTOS PROJECTS

STATE OF NEW YORK - DEPARTMENT OF LABOR
ASBESTOS CERTIFICATE



DEREKA NIZALEK
CLASS(EXPIRES)
C ATEC(08/12) D INSP(08/12)
H PM (08/12)

CERT# 97-19451
DMV# 360237988

MUST BE CARRIED ON ASBESTOS PROJECTS

STATE OF NEW YORK - DEPARTMENT OF LABOR
ASBESTOS CERTIFICATE



DANIEL J JANISH
CLASS(EXPIRES)
C ATEC(10/12) D INSP(10/12)
H PM (10/12)

CERT# 08-14211
DMV# 333624913

MUST BE CARRIED ON ASBESTOS PROJECTS

STATE OF NEW YORK - DEPARTMENT OF LABOR
ASBESTOS CERTIFICATE



JUSTIN J WALTON
CLASS(EXPIRES)
C ATEC(07/12) H PM (07/12)

CERT# 07-06206
DMV# 981819544

MUST BE CARRIED ON ASBESTOS PROJECTS

STATE OF NEW YORK - DEPARTMENT OF LABOR
ASBESTOS CERTIFICATE



ANTHONY J FORD
CLASS(EXPIRES)
C ATEC(02/12) H PM (02/12)

CERT# 08-15140
DMV# 442935764

MUST BE CARRIED ON ASBESTOS PROJECTS

STATE OF NEW YORK - DEPARTMENT OF LABOR
ASBESTOS CERTIFICATE




JACOB D LAMBERTY
CLASS(EXPIRES)
C ATEC(04/12) H PM (04/12)

CERT# 08-15136
DMV# 164693962

MUST BE CARRIED ON ASBESTOS PROJECTS

STATE OF NEW YORK - DEPARTMENT OF LABOR
ASBESTOS CERTIFICATE



RYAN M ROSS
CLASS(EXPIRES)
C ATEC(06/12) H PM (06/12)

CERT# 11-06944
DMV# 990095553

MUST BE CARRIED ON ASBESTOS PROJECTS

STATE OF NEW YORK - DEPARTMENT OF LABOR
ASBESTOS CERTIFICATE



AMANDA NOWOCIEK
CLASS(EXPIRES)
C ATEC(02/13) H PM (02/13)

CERT# 11-20731
DMV# 555939442

MUST BE CARRIED ON ASBESTOS PROJECTS

**IsleChem, LLC.
2801 Long Road
Grand Island, New York 14072**

**Asbestos Containing Material
Summary Report**

Performed at:

**National Fuel
365 Mineral Spring Road
Buffalo, New York 14210
(Building #8)**

Performed for:

**Mr. James Clark
National Fuel
365 Mineral Spring Road
Buffalo, New York 14210**

Performed by:

**IsleChem, LLC.
2801 Long Road
Grand Island, New York 14072**

Project # NY108068

August 2011

1.0 Project Summary

On August 8, 2011 IsleChem, LLC conducted a Pre-Demolition Asbestos Survey of Building #8 at 365 Mineral Spring Road, Buffalo, NY. The scope of work included identification of suspect asbestos-containing materials (ACM), evaluation for asbestos content by laboratory analysis, and the qualification of all confirmed ACM by material type, amount, and location.

The survey involved collected bulk material samples for identification of asbestos within the material. The inspection was performed by Mr. Derek Nizialek and Mr. Dan Janish of IsleChem, LLC. who our currently certified by New York State Department of Labor for asbestos building inspection for asbestos. Site-specific inspection protocols and analytical methodologies used are addressed in the report. Site-Specific protocols for asbestos inspections specifically means, that IsleChem will not and did not destroy areas in order to sample hidden materials for possible ACM.

The testing identified that the following materials were determined by Polarized Light Microscopy (PLM) and/or Transmission Electron Microscopy (TEM) to contain asbestos in excess of one percent (1%) asbestos or assumed to be asbestos containing.


12 x 12 White w/Grey Spec Floor Tile & Mastic
12 x 12 Cream w/White Spec Floor Tile & Mastic
White Pipe Insulation (mag)
Transite Stack

The following is contained within this report:

1. Project Summary
2. Background
3. Protocols and Techniques
4. Sampling & Result Summary
5. Recommendations

Appendix A – Sample Results
Appendix B – Chain of Custody Forms
Appendix C – Drawing
Appendix D – Asbestos License

Submitted by:



Scott Hammond
Field Services Manager

2.0 Background

2.1 Purpose

National Fuel retained IsleChem, LLC to conduct an inspection for suspect asbestos-containing materials (ACM). The inspections' objectives are to identify and test by analytical determination all suspect ACM of Building #8 at 365 Mineral Spring Road, Buffalo, NY. for the demolition project. After confirming the materials that contain asbestos, IsleChem, LLC performed estimations to document the quantity of said materials.

2.2 History

Asbestos is the name for a group of naturally occurring silicate minerals that can be separated into fibers. The fibers are strong, durable, and resistant to heat and fire. They are also long, thin and flexible, so that they can even be woven into cloth. Because of these qualities, asbestos has been used in thousands of consumer, industrial, maritime, automotive, scientific and building products. During the twentieth century, some 30 million tons of asbestos were used in industrial sites, homes, schools, shipyards and commercial buildings in the United States. There are several types of asbestos fibers, of which three have been used for commercial applications: (1) Chrysotile, or white asbestos, comes mainly from Canada, and has been very widely used in the US. It is white-gray in color and found in serpentine rock. (2) Amosite, or brown asbestos, comes from southern Africa. (3) Crocidolite, or blue asbestos, comes from southern Africa and Australia. Amosite and crocidolite are called amphiboles. This term refers to the nature of their geologic formation. Other asbestos fibers that have not been used commercially are tremolite, actinolite and anthophyllite, although they are sometimes contaminants in asbestos-containing products.

What is common to many asbestos-containing products is that they were (are) used to contain heat (i.e. thermal insulation.) It is impossible to list all of the products that have, at one time or another, contained asbestos. Some of the more common asbestos-containing products are pipe-covering, insulating cement, insulating block, asbestos cloth, gaskets, packing materials, thermal seals, refractory and boiler insulation materials, transite board, asbestos cement pipe, fireproofing spray, joint compound, vinyl floor tile, ceiling tile, mastics, adhesives, coatings, acoustical textures, duct insulation for heating, ventilation and air conditioning (HVAC) systems, roofing products, insulated electrical wire and panels, and brake and clutch assemblies. Some of these products contained a very high proportion of asbestos, while others contained small amounts.

Asbestos is still a problem because a great deal of it has been used in the United States and elsewhere, because many asbestos-containing products remain in buildings, ships, industrial facilities and other environments where the fibers can become airborne, and because of the serious human health hazards of inhaling asbestos fibers.

3.0 Protocols and Techniques

Survey information was collected by means of visual inspection, record review, personal interviews, sample collection, and sample analysis.

3.1 Inspection / Sampling Protocols

A room-by-room inspection was conducted for suspect ACBM. The area was separated into sections. Each section was assigned a functional space number (FS#).

Suspect materials were grouped according to homogeneity; that is, any suspect material that appeared to be of the same construction period, type, color and texture was assumed to be the same material regardless of its location in the building and assigned a discrete homogeneous area code. Samples representative of each categorized homogeneous material were then randomly collected and their location recorded. Each sample was labeled by its homogeneous area code and a discrete number.

In general, the following materials are not usually sampled (per EPA) because they are not considered suspect asbestos-containing materials: fiberglass insulating materials (yellow and pink colored), wood materials, ceramic tiles, plastic and glass materials, brick materials (except brick found within boilers), cinderblock, marble, rubber and certain synthetic materials including Styrofoam. All other materials were considered suspect and sampled accordingly. Samples were collected so as to minimize the potential for fiber release. Precautions taken during sampling may include pre-wetting the suspect material before sampling; encapsulating the material after sampling; and the donning of personal protective equipment, including a half-face respirator equipped with HEPA filters.

3.2 Laboratory Analysis

Qualitative and quantitative determinations for asbestos were by Polarized Light Microscopy (PLM). Each sample was first examined under the stereo microscope. The analyst looked for layering, colors, friability, fibrosity and general appearance. Approximately 0.5mg of the sample was then immersed in refractive index oil and observed under the microscope at 100 - 400X. The sample's components were then identified by six different criteria to determine fiber type and visual percentages. The optical criteria determined include morphology, pleochroism, birefringence, extinction, sign of elongation, and refractive index parallel and perpendicular to elongation.

Samples may also be analyzed by Transmission Electron Microscopy (TEM) in the event they meet the conditions established by New York Environmental Laboratory Approval Program (ELAP) for Non friable organically bound (NOB) Materials. All the non-friable organically bound material (NOB) were analyzed using Transmission Electron Microscopy (TEM) to confirm the absence of asbestos in accordance with the requirement of the New York State Environmental Laboratory Approval Program (ELAP). NOB materials typically encountered are roof coverings, floor tile, linoleum, mastics, and caulking materials.

3.3 Reporting

Materials that test positive for asbestos (containing one percent asbestos or greater as per OSHA 29 CFR Part 1926.1101.b, Subpart Z) were identified in accordance with EPA 40 CFR Part 763. In some instances, suspect materials may be assumed to contain asbestos, in lieu of testing, in order to avoid unnecessary damage to property or because of their inaccessibility to sampling.

Included in this report is a Homogeneous Material List, which is a list of materials that were tested. Note that each material was assigned a homogeneous material number (HA No.) in the first column of the list. The second column is the material description, and the third column gives indication of the existence of asbestos, (Y=yes, N=no). The fourth column of the list tells if the material is friable or not. The final column gives reference to the sample number or numbers which correspond to that material. The HA No. is included as the only numeric part of each sample number so that each sample can be referenced back to the suspect material. ACBM is listed by functional space on the ACM by Room Listing.

4.0 Sampling & Result Summary

Thirty-nine (39) samples were collected and tested for asbestos. Of these, fifteen (15) samples were analyzed in accordance with Polarized Light Microscopy (PLM)-ELAP method 198.1. The remaining twenty-four (24) samples were classified as non-friable organically bound materials (NOB) and analyzed in accordance with NYS ELAP Method 198.6, Polarized Light Microscopy and NYS ELAP Method 198.4. Transmission Electron Microscopy (TEM)-ELAP 198.4 NOB method. Of these, five (5) samples tested positive for asbestos.

4.1 Suspect Materials List

Table 1 provides a list of the materials that were sampled and tested for asbestos by Polarized Light Microscopy and/or Transmission Electron Microscopy as applicable. Table 1 summarizes the laboratory results; refer to the enclosed Laboratory Reports for each sample laboratory test result:

**TABLE 1
 HOMOGENEOUS MATERIALS LIST**

Homogeneous Area Number	Suspect Asbestos Containing Material	Confirmed ACM	Friable (Y/N)	Sample Number(s)
<i>Miscellaneous Materials</i>				
101	4" Grey Basecove & Mastic	No	N	1,2
102	4" Black Basecove & Mastic	No	N	3,4
103	4" Green Basecove & Mastic	No	N	5,6
<i>Thermal Insulation</i>				
201	White Pipe Insulation (mag)	Yes	Y	7,8
202	Fiberglass Pipe Insulation	No	Y	9,10
203	Mud Joint Fittings	No	Y	11,12
204	Spray-On Fireproofing	No	Y	13,14
<i>Flooring</i>				
301	12 x 12 White w/Grey Spec Floor Tile & Mastic	Yes	N	16,17
302	12 x 12 Cream w/White Spec Floor Tile & Mastic	Yes	N	18,19
303	12 x 12 Beige Floor Tile & Mastic	No	N	20,21
<i>Ceiling Material</i>				
401	2 x 4 Ceiling Tile	No	Y	22,23
402	2 x 4 Pinhole Ceiling Tile	No	Y	24,25
<i>Wall Material</i>				
501	Drywall	No	Y	26,27,28
502	Plaster	No	Y	29,30,31
503	Grey Cementitious Board	No	Y	32,33

**TABLE 1
 HOMOGENEOUS MATERIALS LIST**

Homogeneous Area Number	Suspect Asbestos Containing Material	Confirmed ACM	Friable (Y/N)	Sample Number(s)
	<i>Exterior Building Material</i>			
601	Roofing	No	N	34,35
602	Roofing Lower Tar	No	N	36,37
603	Brown/Black Window Caulking	No	N	38,39
604	Transite Stack	Assumed	N	Assumed

4.2 Summary of Asbestos Containing Material

The following table is a summary of the building materials that were determined to contain asbestos. The table identifies the location (function space), provides a description of the material, identifies the homogeneous material number (as found in table 1), and the approximate amount of asbestos material within the functional space.

**TABLE 2
 SUMMARY OF ASBESTOS CONTAINING MATERIALS**

Material Location Functional Space	Material Description	H.A. Number	Approximate Amount	Condition
FS 1001	White Pipe Insulation (mag)	201	10 ln ft	Fair
	12 x 12 White w/Grey Spec Floor Tile & Mastic	301	560 sq ft	Good
FS 1002	12 x 12 White w/Grey Spec Floor Tile & Mastic	301	590 sq ft	Good
FS 1003	12 x 12 White w/Grey Spec Floor Tile & Mastic	301	1,550 sq ft	Good
	12 x 12 Cream w/White Spec Floor Tile & Mastic	302	90 sq ft	Good
FS 1007	12 x 12 White w/Grey Spec Floor Tile & Mastic	301	20 sq ft	Good
FS 2003	12 x 12 White w/Grey Spec Floor Tile & Mastic	301	290 sq ft	Good
FS 2004	12 x 12 White w/Grey Spec Floor Tile & Mastic	301	400 sq ft	Good
FS 2006	12 x 12 White w/Grey Spec Floor Tile & Mastic	301	90 sq ft	Good
FS 2007	12 x 12 White w/Grey Spec Floor Tile & Mastic	301	950 sq ft	Good
FS 2008	12 x 12 White w/Grey Spec Floor Tile & Mastic	301	400 sq ft	Good
Exterior	Transite Stack	604	30 ln ft	Fair

5.0 Recommendations

Any activity that impacts (disturbs) asbestos containing materials must be conducted in accordance with all federal, state or local regulations including, but not limited to.

- New York State Industrial Code Rule 56
- Occupation Safety and Health Administration 29 CFR – 1926.1101
- United State Environmental Protection Agency 40 CFR - part 763

All of these services are subject to IsleChem, LLC.'s current terms and conditions for the sale of services, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which the results are used or interpreted.

This report is based on the condition and contents present at above referenced location at the time of inspection.

NY108068
Building #8
365 Mineral Springs
Buffalo, NY

Appendix A
Laboratory Results



EMSL Analytical, Inc.

480 Rowley Road, Depew, NY 14043
Phone: (716) 651-0030

Attn: **Islechem, LLC.**
2801 Long Road

Grand Island, NY 14072-1244

Customer ID: ISLE62
Customer PO: 3280
Received: 08/08/11 4:35 PM
EMSL Order: 141103747

Fax: (716) 773-8517
Project: NY106-068 / National Fuel Bldg 8, Mineral Springs

Phone: (716) 773-8401
EMSL Proj:

Test Report: Asbestos Analysis of Bulk Material

Sample Description	Test	Analyzed Date	Color	Fibrous	Non-Asbestos	Non-Fibrous	Asbestos	Comments
01	PLM NYS 198.1 Friable							Not Analyzed
141103747-0001	PLM NYS 198.6 NOB	8/11/2011	Gray			N/A	Inconclusive: None Detected	
grey base cove	TEM NYS 198.4 NOB	8/12/2011	Gray			N/A	None Detected	
01	PLM NYS 198.1 Friable							Not Analyzed
141103747-0002	PLM NYS 198.6 NOB	8/11/2011	Gray			N/A	Inconclusive: None Detected	
masfic	TEM NYS 198.4 NOB	8/12/2011	Gray			N/A	None Detected	
02	PLM NYS 198.1 Friable							Not Analyzed
141103747-0003	PLM NYS 198.6 NOB	8/11/2011	Gray			N/A	Inconclusive: None Detected	
grey base cove	TEM NYS 198.4 NOB	8/12/2011	Gray			N/A	None Detected	
02	PLM NYS 198.1 Friable							Not Analyzed
141103747-0004	PLM NYS 198.6 NOB	8/11/2011	Gray			N/A	Inconclusive: None Detected	
masfic	TEM NYS 198.4 NOB	8/12/2011	Gray			N/A	None Detected	
03	PLM NYS 198.1 Friable							Not Analyzed
141103747-0005	PLM NYS 198.6 NOB	8/11/2011	Black			N/A	Inconclusive: None Detected	
black base cove	TEM NYS 198.4 NOB	8/12/2011	Black			N/A	None Detected	
03	PLM NYS 198.1 Friable							Not Analyzed
141103747-0006	PLM NYS 198.6 NOB	8/11/2011	Black			N/A	Inconclusive: None Detected	
masfic	TEM NYS 198.4 NOB	8/12/2011	Black			N/A	None Detected	
04	PLM NYS 198.1 Friable							Not Analyzed
141103747-0007	PLM NYS 198.6 NOB	8/11/2011	Black			N/A	Inconclusive: None Detected	
black base cove	TEM NYS 198.4 NOB	8/12/2011	Black			N/A	None Detected	
04	PLM NYS 198.1 Friable							Not Analyzed
141103747-0008	PLM NYS 198.6 NOB	8/11/2011	Black			N/A	Inconclusive: None Detected	
masfic	TEM NYS 198.4 NOB	8/12/2011	Black			N/A	None Detected	



EMSL Analytical, Inc.

480 Rowley Road, Depew, NY 14043
Phone: (716) 851-0030

Attn: **Islechem, LLC.**
2801 Long Road

Grand Island, NY 14072-1244

Fax: (716) 773-8517 Phone: (716) 773-8401
Project: **NY108-068 / National Fuel Bldg 8, Mineral Springs**

Customer ID: ISLE62
Customer PO: 9290
Received: 08/08/11 4:35 PM
EMSL Order: 141103747

EMSL Proj:

Test Report: Asbestos Analysis of Bulk Material

Sample Description	Test	Analyzed Date	Color	Fibrous	Non-Fibrous	Asbestos	Comments
05 141103747-0009 green base cove	PLM NYS 198.1 Friable PLM NYS 198.6 NOB TEM NYS 198.4 NOB	8/11/2011 8/12/2011	Green Green	N/A N/A	N/A N/A	Inconclusive: None Detected None Detected	Not Analyzed
05 141103747-0010 mastic	PLM NYS 198.1 Friable PLM NYS 198.6 NOB TEM NYS 198.4 NOB	8/11/2011 8/12/2011	Green Green	N/A N/A	N/A N/A	Inconclusive: None Detected None Detected	Not Analyzed
06 141103747-0011 green base cove	PLM NYS 198.1 Friable PLM NYS 198.6 NOB TEM NYS 198.4 NOB	8/11/2011 8/12/2011	Green Green	N/A N/A	N/A N/A	Inconclusive: None Detected None Detected	Not Analyzed
06 141103747-0012 mastic	PLM NYS 198.1 Friable PLM NYS 198.6 NOB TEM NYS 198.4 NOB	8/11/2011 8/12/2011	Green Green	N/A N/A	N/A N/A	Inconclusive: None Detected None Detected	Not Analyzed
07 141103747-0013 1001	PLM NYS 198.1 Friable PLM NYS 198.6 NOB TEM NYS 198.4 NOB	8/12/2011	White	86.0%	N/A	14.00% Amosite	Not Analyzed
08 141103747-0014 1001	PLM NYS 198.1 Friable PLM NYS 198.6 NOB TEM NYS 198.4 NOB	8/12/2011	White	85.0%	N/A	15.00% Amosite	Not Analyzed
09 141103747-0015 fiberglass insulation/paper/foil	PLM NYS 198.1 Friable PLM NYS 198.6 NOB TEM NYS 198.4 NOB	8/11/2011 8/12/2011	Silver Silver	N/A N/A	N/A N/A	Inconclusive: None Detected None Detected	Not Analyzed
10 141103747-0016 fiberglass /paper/foil	PLM NYS 198.1 Friable PLM NYS 198.6 NOB TEM NYS 198.4 NOB	8/11/2011 8/12/2011	White/Silver White/Silver	N/A N/A	N/A N/A	Inconclusive: None Detected None Detected	Not Analyzed



EMSL Analytical, Inc.

490 Rowley Road, Depew, NY 14043
Phone: (716) 854-0030

Attn: **Islechem, LLC.**
2801 Long Road

Grand Island, NY 14072-1244

Fax: (716) 773-8517 Phone: (716) 773-8401
Project: **NY108-068 / National Fuel Bldg 8, Mineral Springs**

Customer ID: ISLE62
Customer PO: 9280
Received: 08/08/11 4:35 PM
EMSL Order: 141103747

EMSL Proj:

Test Report: Asbestos Analysis of Bulk Material

Sample Description	Test	Analyzed Date	Color	Fibrous	Non-Fibrous	Asbestos	Comments
11 141103747-0017	PLM NYS 198.1 Friable PLM NYS 198.6 NOB	8/12/2011	White		100%	None Detected	Not Analyzed
1003	TEM NYS 198.4 NOB			N/A			Not Analyzed
12 141103747-0018	PLM NYS 198.1 Friable PLM NYS 198.6 NOB	8/12/2011	Gray		100%	None Detected	Not Analyzed
1006	TEM NYS 198.4 NOB			N/A			Not Analyzed
13 141103747-0019	PLM NYS 198.1 Friable PLM NYS 198.6 NOB	8/12/2011	Gray		100%	None Detected	Not Analyzed
2005	TEM NYS 198.4 NOB			N/A			Not Analyzed
14 141103747-0020	PLM NYS 198.1 Friable PLM NYS 198.6 NOB	8/12/2011	Gray	60.00% Cellulose	40%	None Detected	Not Analyzed
2001	TEM NYS 198.4 NOB			N/A			Not Analyzed
15 141103747-0021	PLM NYS 198.1 Friable PLM NYS 198.6 NOB	8/12/2011	Gray	60.00% Cellulose	40%	None Detected	Not Analyzed
2004	TEM NYS 198.4 NOB			N/A			Not Analyzed
16 141103747-0022	PLM NYS 198.1 Friable PLM NYS 198.6 NOB	8/12/2011	Gray		N/A	Inconclusive: None Detected	Not Analyzed
tile, white w/gray spec	TEM NYS 198.4 NOB	8/12/2011	Gray		N/A	None Detected	Not Analyzed
15 141103747-0023	PLM NYS 198.1 Friable PLM NYS 198.6 NOB	8/12/2011	Gray		N/A	2.9% Chrysotile 2.9% Total	Not Analyzed
resiac	TEM NYS 198.4 NOB	8/12/2011			N/A	None Analyzed	Not Analyzed
17 141103747-0024	PLM NYS 198.1 Friable PLM NYS 198.6 NOB	8/12/2011	Gray		N/A	Inconclusive: None Detected	Not Analyzed
tile, white w/gray spec	TEM NYS 198.4 NOB	8/12/2011	Gray		N/A	None Detected	Not Analyzed



EMSL Analytical, Inc.

490 Rowley Road, Depew, NY 14043
Phone: (716) 651-0030

Attn: **Islechem, LLC.**
2801 Long Road

Grand Island, NY 14072-1244

Customer ID: ISLE62
Customer PO: 9280
Received: 08/08/11 4:35 PM
EMSL Order: 141103747

Fax: (716) 773-8517
Project: **NY108-068 / National Fuel Bldg 8, Mineral Springs**

Phone: (716) 773-8401

EMSL Proj:

Test Report: Asbestos Analysis of Bulk Material

Sample Description	Test	Analyzed Date	Color	Fibrous	Non-Fibrous	Asbestos	Comments
17 141103747-0025 mastic	PLM NYS 198.1 Friable PLM NYS 198.6 NOB	8/11/2011	Gray		N/A	3.4% Chrysotile 3.4% Total	Not Analyzed
18 141103747-0026 tile, cream w/white spec	TEM NYS 198.4 NOB PLM NYS 198.1 Friable	8/12/2011			N/A	Not Analyzed	Not Analyzed
18 141103747-0027	PLM NYS 198.4 NOB PLM NYS 198.6 NOB	8/11/2011	Tan		N/A	Inconclusive: None Detected None Detected	Not Analyzed
19 141103747-0028 tile, cream w/white spec	PLM NYS 198.1 Friable PLM NYS 198.5 NOB	8/12/2011	Tan		N/A	10.0% Chrysotile 10.0% Total	Not Analyzed
19 141103747-0029 mastic	TEM NYS 198.4 NOB PLM NYS 198.1 Friable	8/12/2011			N/A	Not Analyzed	Not Analyzed
20 141103747-0030 tile, beige	PLM NYS 198.5 NOB PLM NYS 198.4 NOB	8/11/2011	Tan		N/A	Inconclusive: None Detected None Detected	Not Analyzed
20 141103747-0031 mastic	PLM NYS 198.1 Friable PLM NYS 198.5 NOB	8/12/2011	Tan		N/A	None Detected	Not Analyzed
21 141103747-0032 tile, beige	PLM NYS 198.5 NOB PLM NYS 198.4 NOB	8/11/2011	Tan		N/A	Inconclusive: None Detected None Detected	Not Analyzed
21 141103747-0033 tile, beige	PLM NYS 198.1 Friable PLM NYS 198.5 NOB	8/12/2011	Tan		N/A	Inconclusive: None Detected None Detected	Not Analyzed
21 141103747-0034 tile, beige	PLM NYS 198.4 NOB PLM NYS 198.4 NOB	8/12/2011	Tan		N/A	Inconclusive: None Detected None Detected	Not Analyzed



EMSL Analytical, Inc.

490 Rowley Road, Depew, NY 14043
Phone: (716) 651-0036

Attn: **Islechem, L.L.C.**
2801 Long Road

Grand Island, NY 14072-1244

Customer ID: ISLE62
Customer PO: 9230
Received: 08/08/11 4:35 PM
EMSL Order: 141103747

Fax: (716) 773-9517 Phone: (716) 773-8401
Project: **NY108-068 / National Fuel Bldg 8, Mineral Springs**

EMSL Proj:

Test Report: Asbestos Analysis of Bulk Material

Sample Description	Test	Analyzed Date	Color	Fibrous	Non-Asbestos	Non-Fibrous	Asbestos	Comments
21 141103747-0033 mastic	PLM NYS 198.1 Friable PLM NYS 198.6 NOB TEM NYS 198.4 NOB	8/11/2011 8/12/2011 8/12/2011	Tan Tan Tan		N/A N/A N/A		Inconclusive: None Detected None Detected None Detected	Not Analyzed
22 141103747-0034 2x4 ceiling tile (fissure)	PLM NYS 198.1 Friable PLM NYS 198.6 NOB TEM NYS 198.4 NOB	8/11/2011 8/12/2011 8/12/2011	Tan Tan Tan		N/A N/A N/A		Inconclusive: None Detected None Detected None Detected	Not Analyzed
23 141103747-0035 2x4 ceiling tile (fissure)	PLM NYS 198.1 Friable PLM NYS 198.6 NOB TEM NYS 198.4 NOB	8/11/2011 8/12/2011 8/12/2011	Tan Tan Tan		N/A N/A N/A		Inconclusive: None Detected None Detected None Detected	Not Analyzed
24 141103747-0036 ceiling tile (pin hole)	PLM NYS 198.1 Friable PLM NYS 198.6 NOB TEM NYS 198.4 NOB	8/11/2011 8/12/2011 8/12/2011	White White White		N/A N/A N/A		Inconclusive: None Detected None Detected None Detected	Not Analyzed
25 141103747-0037 ceiling tile (pin hole)	PLM NYS 198.1 Friable PLM NYS 198.6 NOB TEM NYS 198.4 NOB	8/11/2011 8/12/2011 8/12/2011	White White White		N/A N/A N/A		Inconclusive: None Detected None Detected None Detected	Not Analyzed
26 141103747-0038 1002	PLM NYS 198.1 Friable PLM NYS 198.6 NOB TEM NYS 198.4 NOB	8/12/2011 8/12/2011 8/12/2011	Gray Gray Gray		100% N/A N/A		None Detected None Detected None Detected	Not Analyzed
27 141103747-0039 1003	PLM NYS 198.1 Friable PLM NYS 198.6 NOB TEM NYS 198.4 NOB	8/12/2011 8/12/2011 8/12/2011	Gray Gray Gray		100% N/A N/A		None Detected None Detected None Detected	Not Analyzed
28 141103747-0040 1005	PLM NYS 198.1 Friable PLM NYS 198.6 NOB TEM NYS 198.4 NOB	8/12/2011 8/12/2011 8/12/2011	Gray Gray Gray		100% N/A N/A		None Detected None Detected None Detected	Not Analyzed



EMSL Analytical, Inc.

490 Rowley Road, Depew, NY 14043
Phone: (716) 654-0030

Attn: **Islechem, LLC.**
2801 Long Road

Grand Island, NY 14072-1244

Fax: (716) 773-8517 Phone: (716) 773-8401
Project: NY108-088 / National Fuel Bldg 8, Mineral Springs

Customer ID: ISLE62
Customer PO: 9280
Received: 08/08/11 4:35 PM
EMSL Order: 141103747

EMSL Proj:

Test Report: Asbestos Analysis of Bulk Material

Sample Description	Test	Analyzed Date	Color	Fibrous	Non Asbestos Non-Fibrous	Asbestos	Comments
29 141103747-0041	PLM NYS 198.1 Friable PLM NYS 198.6 NOB	8/12/2011	Gray		100%	None Detected	Not Analyzed
1003	TEM NYS 198.4 NOB				N/A		Not Analyzed
30 141103747-0042	PLM NYS 198.1 Friable PLM NYS 198.6 NOB	8/12/2011	Gray		100%	None Detected	Not Analyzed
1005	TEM NYS 198.4 NOB				N/A		Not Analyzed
31 141103747-0043	PLM NYS 198.1 Friable PLM NYS 198.6 NOB	8/12/2011	Gray		100%	None Detected	Not Analyzed
1003	TEM NYS 198.4 NOB				N/A		Not Analyzed
32 141103747-0044	PLM NYS 198.1 Friable PLM NYS 198.6 NOB	8/12/2011	Black		100%	None Detected	Not Analyzed
1005	TEM NYS 198.4 NOB				N/A		Not Analyzed
33 141103747-0045	PLM NYS 198.1 Friable PLM NYS 198.6 NOB	8/12/2011	Gray		100%	None Detected	Not Analyzed
1005	TEM NYS 198.4 NOB				N/A		Not Analyzed
34 141103747-0046	PLM NYS 198.1 Friable PLM NYS 198.6 NOB	8/11/2011	Black/Yellow		N/A	Inconclusive: None Detected	Not Analyzed
roofing	TEM NYS 198.4 NOB	8/12/2011	Black/Yellow		N/A	None Detected	Not Analyzed
35 141103747-0047	PLM NYS 198.1 Friable PLM NYS 198.6 NOB	8/11/2011	Black/Yellow		N/A	Inconclusive: None Detected	Not Analyzed
roofing	TEM NYS 198.4 NOB	8/12/2011	Black/Yellow		N/A	None Detected	Not Analyzed
36 141103747-0048	PLM NYS 198.1 Friable PLM NYS 198.6 NOB	8/11/2011	Black/Yellow		N/A	Inconclusive: None Detected	Not Analyzed
lower tar layer	TEM NYS 198.4 NOB	8/12/2011	Black/Yellow		N/A	None Detected	Not Analyzed



EMSL Analytical, Inc.

490 Rowley Road, Depew, NY 14043
Phone: (716) 651-0058

Attn: **Islechem, LLC.**
2801 Long Road

Grand Island, NY 14072-1244

Customer ID: ISLE62
Customer PO: 9280
Received: 08/08/11 4:35 PM
EMSL Order: 141103747

Fax: (716) 773-9517
Project: NY108-068 / National Fuel Bldg 8, Mineral Springs

Phone: (716) 773-8401
EMSL Proj:

Test Report: Asbestos Analysis of Bulk Material

Sample Description	Test	Analyzed Date	Color	Fibrous	Non Asbestos Fibrous	Non-Fibrous	Asbestos	Comments
37 141103747-0049 lower tar layer	PLM NYS 198.1 Friable PLM NYS 198.6 NOB TEM NYS 198.4 NOB	8/11/2011 8/12/2011	Black /Yellow Black /Yellow			N/A N/A	Inconclusive: None Detected None Detected	Not Analyzed
38 141103747-0050 brown/black caulk	PLM NYS 198.1 Friable PLM NYS 198.6 NOB TEM NYS 198.4 NOB	8/11/2011 8/12/2011	Brown /Black Brown /Black			N/A N/A	Inconclusive: None Detected None Detected	Not Analyzed
39 141103747-0051 brown/black caulk	PLM NYS 198.1 Friable PLM NYS 198.6 NOB TEM NYS 198.4 NOB	8/11/2011 8/12/2011	Brown /Black Brown /Black			N/A N/A	Inconclusive: None Detected None Detected	Not Analyzed

NOB = Non Friable Organically Bound
N/A = Not Applicable

Analyst(s)
Rachel Giese
Taron Williams

Rhonda McGee
Rhonda McGee, Laboratory Manager
or other approved signatory

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be retested, except in full, without written approval by EMSL. The above test report relates only to the items tested. This test report must not be used to claim product endorsement by NALAP or any agency of the U.S. Government. EMSL bears no responsibility for sample collection activities or analytical method limitations. The results in this report meet all requirements of the NALAC Standards unless otherwise noted. The laboratory is not responsible for the accuracy of results when requested to physically separate and analyze layered samples. PLM is not consistently reliable in detecting asbestos in floor coverings and similar NOB's. Quantitative TEM is currently the only method that can be used to determine if a NOB material can be considered or treated as non-asbestos containing.

Samples analyzed by EMSL Analytical, Inc. Depew, NY NYS ELAP 11005

NY108068
Building #8
365 Mineral Springs
Buffalo, NY

Appendix B
Chain of Custody Documents

Organization Name Isle Chem	Project Name National Fed Bldg 5	Turnaround Time RUSH 24 hours 48 hours 3 day <u>4 day</u> 7 days 14 days
Street Address 2801 Long Rd	Project Location Mineral Springs	
City, State, ZIP Grand Island, NY	Client PO / Release #	
Contact Person S.H.H	IsleChem Project # NY02-06E	
Phone # and Fax # 316-3214	Sampled by D. H. H.	

Seq #	Sample Date	Sample Location	Material	Analyte	Lab ID
01	8/8/11	Grey Base Core 1001	Grey Base core/mastic	NOB	208765
02	8/8/11	Grey Base Core 1001	Grey Base core/mastic	NOB	208766
03	8/8/11	Black base C 1002	Black base core/mastic	NOB	208767
04	8/8/11	1003	Black base core/mastic	NOB	208768
05	8/8/11	1003	Green base core/mastic	NOB	208769
06	8/8/11	1003	Green base core/mastic	NOB	208770
07	8/8/11	1001	white pipe insulation	PLM	208771
08	8/8/11	1001	white pipe insulation	PLM	208772
09	8/8/11	1003	Fiberglass insulation/paper/fol	NOB	208773
10	8/8/11	1003	Fiberglass/paper/fol	NOB	208774
11	8/8/11	1003	mud joint fittings	PLM	208775
12	8/8/11	1006 1006	mud joint fittings	PLM	208776
13	8/8/11	2005 2005	mud joint fittings	PLM	208777
14	8/8/11	2001	Spray on insulation	PLM	208778
15	8/8/11	2004	Spray on insulation	PLM	208779
16	8/8/11	2004	tile - white w/ grey spec	NOB	208780
17	8/8/11	1003	tile - white w/ grey spec/mastic	NOB	208781
18	8/8/11	1003	tile - cream w/ white spec/mastic	NOB	208782
19	8/8/11	1003	tile - cream w/ white spec/mastic	NOB	208783
20	8/8/11	2003	tile - Beige	NOB	208784
21	8/8/11	2003	tile - Beige	NOB	208785

Comments:

Sampled by <i>[Signature]</i>	Date 8/8/11	Time 1100	Received by <i>[Signature]</i>	Date 8/8/11	Time 3:45 PM	IsleChem, LLC 2801 Long Road Grand Island, NY 14072 716-773-8401 FAX 716-773-8517
Relinquished by <i>[Signature]</i>	Date 8/8/11	Time 10:20	Received by lab	Date	Time	

by relinquishing these sample to IsleChem, LLC, Inc. you are accepting the current IsleChem, LLC. terms and conditions for the sale of services

Chain of Custody

Organization Name <i>Islechem</i>	Project Name <i>Kleaton 1 Res/Bldg 8</i>	Turnaround Time RUSH 24 hours 48 hours 3 day 4 day 7 days 14 days
Street Address <i>2301 Long Rd</i>	Project Location <i>Miner Springs</i>	
City, State, ZIP <i>Grand Island NY</i>	Client PO / Release #	
Contact Person <i>S. J. H.</i>	IsleChem Project # <i>X1409068</i>	
Phone # and Fax # <i>316-5214</i>	Sampled by <i>D. H. Allen</i>	

Seq #	Sample Date	Sample Location	Material	Analyte	Lab ID
22	8/8/11	1001	2x4 ceiling tile (fissure)	NOB	208786
23	8/8/11	2007	2x4 ceiling tile (fissure)	NOB	208787
24	8/8/11	2008	ceiling tile (pin hole)	NOB	208788
25	8/8/11	2008	Ceiling tile (pin hole)	NOB	208789
26	8/8/11	1002	Drywall	PLM	208790
27	8/8/11	1003	Drywall	PLM	208791
28	8/8/11	1005	Drywall	PLM	208792
29	8/8/11	1003	Plaster	PLM	208793
30	8/8/11	1005	Plaster	PLM	208794
31	8/8/11	1003	Plaster	PLM	208795
32	8/8/11	1005	cementitious board	NOB NOB	208796
33	8/8/11	1005	cementitious board	NOB	208797
34	8/8/11	Roof	Roofing	NOB	208798
35	8/8/11	Roof	Roofing	NOB	208799
36	8/8/11	Roof	Lower Tar layer	NOB	208800
37	8/8/11	Roof	Lower Tar layer	NOB	208801
38	8/8/11	ext window frame	Brown/Black caulk	NOB	208802
39	8/8/11	ext window frame	Brown/Black caulk	NOB	208803

Comments:

Sampled by <i>[Signature]</i>	Date 8/8/11	Time 14X	Received by <i>[Signature]</i>	Date 8/8/11	Time 3:45 pm	IsleChem, LLC 2801 Long Road Grand Island, NY 14072 716-773-8401 FAX 716-773-8517
Relinquished by <i>[Signature]</i>	Date 8/8/11	Time 1:00	Received by lab	Date	Time	

By relinquishing these samples to IsleChem, LLC, Inc. you are accepting the current IsleChem, LLC. terms and conditions for the sale of services

Chain of Custody

NY108068
Building #8
365 Mineral Springs
Buffalo, NY

Appendix C
Drawing

NY108068
Building #8
365 Mineral Springs
Buffalo, NY


Appendix D
Asbestos License

NEW YORK STATE DEPARTMENT OF LABOR
DIVISION OF SAFETY AND HEALTH
LICENSE AND CERTIFICATE UNIT
STATE CAMPUS BUILDING 12
ALBANY, NY 12240

ASBESTOS HANDLING LICENSE

Islechem, LLC
2801 Long Road
Grand Island, NY 14072

FILE NUMBER: 090886
LICENSE NUMBER: 29479
LICENSE CLASS: RESTRICTED
DATE OF ISSUE: 09/15/2010
EXPIRATION DATE: 09/30/2011



Duly Authorized Representative: Daniel Cabatan

This license has been issued in accordance with applicable provisions of Article 19 of the Labor Law of New York State and of the New York State Codes, Rules and Regulations (12 NYCRR Part 56). It is subject to suspension or revocation for a (1) serious violation of state, federal or local laws with regard to the conduct of any asbestos project, or (2) demonstrated lack of responsibility in the conduct of any project involving asbestos or asbestos material.

This license is valid only for the contractor named above and this license or a photocopy must be prominently displayed at the asbestos project worksite. This license verifies that all persons employed by the licensee on an asbestos project in New York State have been issued an Asbestos Certificate, appropriate for the type of work they perform, by the New York State Department of Labor.

Maureen A. Cox

Maureen A. Cox, Director
FOR THE COMMISSIONER OF LABOR

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2012
Issued April 01, 2011

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MS. RHONDA R. MCGEE
EMSL ANALYTICAL INC
490 ROWLEY ROAD
DEPEW, NY 14043

NY Lab Id No. 11606
EPA Lab Code: NY01278

is hereby **APPROVED** as an Environmental Laboratory for the category
ENVIRONMENTAL ANALYSES SOLID AND HAZARDOUS WASTE
All approved subcategories and/or analytes are listed below:

Miscellaneous

Asbestos in Friable Material	EPA 500/M4/82/020 Item 198.1 of Manual
Asbestos in Non-Friable Material-PLM	Item 198.6 of Manual (NOB by PLM)
Asbestos in Non-Friable Material-TEM	ITEM 198.4 OF MANUAL

Serial No.: 44394

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.

STATE OF NEW YORK - DEPARTMENT OF LABOR
ASBESTOS CERTIFICATE



SCOTT D. HAMMOND
CLASS(EXPIRES)
C-ATEC(11/11) D-NSP(11/11)
H-PM (11/11) I-PEL (11/11)



CERT# 96-10844
DMV# 910145067

MUST BE CARRIED ON ASBESTOS PROJECTS

STATE OF NEW YORK - DEPARTMENT OF LABOR
ASBESTOS CERTIFICATE



DEREK A. NIZIALEK
CLASS(EXPIRES)
C-ATEC(08/11) D-NSP(08/12)
H-PM (08/11)



CERT# 97-19451
DMV# 360237988

MUST BE CARRIED ON ASBESTOS PROJECTS

STATE OF NEW YORK - DEPARTMENT OF LABOR
ASBESTOS CERTIFICATE



DANIE J. MANISH
CLASS(EXPIRES)
C-ATEC(10/12) D-NSP(10/11)
H-PM (10/12)



CERT# 08-14211
DMV# 333024613

MUST BE CARRIED ON ASBESTOS PROJECTS

INVOICE

Empire Building Diagnostics, Inc
2 Main St.
PO Box 412
Depew, NY 14043
(716) 685-4588

Invoice ID: 522435
Invoice Date: 05-25-2012
Customer ID: Nat06
PO Number:
Job #: 212.099

To:
National Fuel
365 Mineral Springs Road
Buffalo, NY 14210

Job Location:
365 Mineral Springs Bldg 8
West Seneca, NY

<u>Item</u>	<u>Description</u>	<u>Qty</u>	<u>Unit Price</u>	<u>Amount</u>
1	For total demolition of building #8 as per Bid proposal items 1, 2, 3 & 4 dated March 12, 2012.			
2	Waste Disposal - Item 5 - 6 loads at 765.94 tons	765.94		

Please Note: If this is a tax exempt project please provide the applicable exempt certificate and omit the sales tax. Thank you!

Amount Billed
Total Tax

Retainage Held

Amount Due

DATE DUE: 06-30-2012

THANK YOU FOR YOUR BUSINESS

C.R. WEBER TRUCKING N^o 001954
32 WINDCREST DRIVE
CHEEKTOWAGA, NEW YORK 14225
(716) 892-6926


Sold By D-2/DT-2 Date 4/27/12
Name Empire Building Diagnostics
Job Location National Fuel Gas - Mineral Springs, W. Seneca
Job Description bricks to Allied Waste Niagara

Ticket #	Weight	Time	Rate
1	115560 - 38260 =	77,300	
2	115560 - 38260 =	77,300	
3	115560 - 38260 =	77,300	
4	117140 - 38260 =	78,880	

Travel AM
Start
Finish
Travel PM
Lunch Yes No TOTAL

Customers Signature:

Our Responsibility Ends at Curb



GUARANTEED CERTIFIED SCALES ENTER

Date 04/27/12 190812

Company DT

Truck DR Trailer DT

Weighmaster Signature Bob

Steer Axle	11840	(lb)s
Drive Axle	46720	(lb)s
Trailer Axle	58580	(lb)s
Gross Weight	117140	(lb)s

CERTIFIED

• Jim's weights are New York State Certified

• Jim's Guarantees Scale Accuracy

• Jim's checks Scale daily to confirm Accuracy


COUNTY OF ERIE
BUREAU of
WEIGHTS and MEASURES

281500
ORIGINAL

FEE 7.50 Standard

JIM'S TRUCK PLAZA
EXIT 52E OFF I90
2115 WALDEN AVENUE
BUFFALO, NY 14225

THANK YOU



GUARANTEED CERTIFIED

SCALES

ENTER

Date 04/27/12 DRT 190777

Company

Truck

Weighmaster

Signature

Trailer

D2 DTR
Bob

Steer Axle	11660	(lb)s
Drive Axle	45360	(lb)s
Trailer Axle	58540	(lb)s
Gross Weight	115560	(lb)s

CERTIFIED

- Jim's weights are New York State Certified
- Jim's Guarantees Scale Accuracy
- Jim's checks Scale daily to confirm Accuracy


COUNTY OF ERIE
BUREAU of
WEIGHTS and MEASURES

281465
ORIGINAL

FEE 150 Standard

JIM'S TRUCK PLAZA
EXIT 52E OFF I90
2115 WALDEN AVENUE
BUFFALO, NY 14225

THANK YOU



GUARANTEED CERTIFIED

SCALES

ENTER

Date 4/27/12 190771

Company Dave Rite

Truck D2 Trailer DT2

Weighmaster BCB
Signature

Steer Axle	10080	(lb)s
Drive Axle	16460	(lb)s
Trailer Axle	11720	(lb)s
Gross Weight	38260	(lb)s

CERTIFIED

- Jim's weights are New York State Certified
- Jim's Guarantees Scale Accuracy
- Jim's checks Scale daily to confirm Accuracy

COUNTY OF ERIE
BUREAU of
WEIGHTS and MEASURES

FEE 7.50 Standard

JIM'S TRUCK PLAZA
EXIT 52E OFF I90
2115 WALDEN AVENUE
BUFFALO, NY 14225

281459
ORIGINAL

THANK YOU

C.R. WEBER TRUCKING NO 0723
 32 WINDCREST DRIVE
 CHEEKTOWAGA, NEW YORK 14225
 716-983-1445

Sold By D-W Date 4-27-12

Name EBO

Job Location National Fuel Gas - Mineral Springs Rd


Job Description Concrete + Bricks To BFI

Ticket #	Weight	Time	Rate
LOAD-1	EMPTY	LOADED	TONS
Ticket 281458	34180	98560	32.19
LOAD-2	34180	98560	32.19
LOAD-3	34180	98560	32.19
LOAD-4	34180	116300	41.06
LOAD-5			32.19 TONS
			137.63

Travel AM _____
 Start _____
 Finish _____
 Travel PM _____
 Lunch Yes No _____

Customers Signature: _____

Our Responsibility Ends at Curb



GUARANTEED CERTIFIED SCALES ENTER

Date 4/27/12 190808

Company DRT

Truck D7 Trailer _____

Weighmaster Signature AP

Steer Axle	11600	(lb)s
Drive Axle	47800	(lb)s
Trailer Axle	56900	(lb)s
Gross Weight	116300	(lb)s

CERTIFIED

- Jim's weights are New York State Certified
- Jim's Guarantees Scale Accuracy
- Jim's checks Scale daily to confirm Accuracy


COUNTY OF ERIE
BUREAU of
WEIGHTS and MEASURES

281496
ORIGINAL

FEE 7.50 Standard

JIM'S TRUCK PLAZA
EXIT 52E OFF I90
2115 WALDEN AVENUE
BUFFALO, NY 14225

THANK YOU



GUARANTEED CERTIFIED

SCALES

ENTER

Date 04/27/12 DRT 190776

Company _____

Truck D1 Trailer _____

Weighmaster Barb
Signature _____

Steer Axle	11020	(lb)s
Drive Axle	39580	(lb)s
Trailer Axle	47960	(lb)s
Gross Weight	98560	(lb)s

CERTIFIED

FEE 7.50 Standard


- Jim's weights are New York State Certified
- Jim's Guarantees Scale Accuracy
- Jim's checks Scale daily to confirm Accuracy

COUNTY OF ERIE
BUREAU of
WEIGHTS and MEASURES

JIM'S TRUCK PLAZA
EXIT 52E OFF I90
2115 WALDEN AVENUE
BUFFALO, NY 14225

281464
ORIGINAL

THANK YOU



GUARANTEED CERTIFIED

SCALES

ENTER

Date 04/27/12 190770

Company DRT

Truck DI Trailer ---

Weighmaster Signature Bob

CERTIFIED

COUNTY OF ERIE
BUREAU of
WEIGHTS and MEASURES

- Jim's weights are New York State Certified
- Jim's Guarantees Scale Accuracy
- Jim's checks Scale daily to confirm Accuracy

281458
ORIGINAL

Steer Axle	9980	(lb)s
Drive Axle	14440	(lb)s
Trailer Axle	9760	(lb)s
Gross Weight	34180	(lb)s

FEE 7.50 Standard

JIM'S TRUCK PLAZA
EXIT 52E OFF I90
2115 WALDEN AVENUE
BUFFALO, NY 14225

THANK YOU


178290

C.R. WEBER TRUCKING No 001992
32 WINDCREST DRIVE
CHEEKTOWAGA, NEW YORK 14225
(716) 892-6926

Sold By <u>DW</u>		<u>D-1 DUMP-1</u>		Date <u>4-30-12</u>
Name <u>EBD</u>		<u>NATIONAL FUEL</u>		
Job Location <u>CONCRETE + BRICK TO BFI</u>				
Job Description		<u>EMPTY</u>	<u>LOAD</u>	<u>TON</u>
Ticket #	Weight	Time	Rate	
<u>LOAD-1</u>	<u>34180</u>	<u>116300</u>	<u>41.06</u>	
<u>LOAD 2</u>	<u>34180</u>	<u>116300</u>	<u>41.06</u>	
<u>LOAD-3</u>	<u>34180</u>	<u>113860</u>	<u>39.84</u>	
<u>LOAD-4</u>	<u>34180</u>	<u>113860</u>	<u>39.84</u>	
			<u>161.80</u>	
			<u>TON</u>	
Travel AM				
Start				
Finish				
Travel PM				
Lunch	Yes	No		

Customers Signature:

Our Responsibility Ends at Curb



GUARANTEED CERTIFIED SCALES ENTER

Date 4/30/12 190919

Company DRT

Truck Df Trailer CK

Weighmaster
Signature _____

Steer Axle	11280	(lb)s
Drive Axle	45140	(lb)s
Trailer Axle	57440	(lb)s
Gross Weight	113860	(lb)s

CERTIFIED

• Jim's weights are New York State Certified

• Jim's Guarantees Scale Accuracy

• Jim's checks Scale daily to confirm Accuracy

COUNTY OF ERIE
BUREAU of
WEIGHTS and MEASURES

281612
ORIGINAL

FEE7.50 Standard

JIM'S TRUCK PLAZA
EXIT 52E OFF I90
2115 WALDEN AVENUE
BUFFALO, NY 14225

THANK YOU

C.R. WEBER TRUCKING No 001993
 32 WINDCREST DRIVE
 CHEEKTOWAGA, NEW YORK 14225
 (716) 892-6926


Sold By D-2/DT-2 Date 4/30/12
 Name Empire Building Diagnostics
 Job Location National Fuel Gas - Mineral Springs Rd, W. Seneca
 Job Description Bricks to Allied Waste Niagara

Ticket #	Weight	Time	Rate
117140	38260		39.44
117140	38260		39.44
117780	38360		39.71
117780	38360		39.71
			158.63T

Travel AM _____
 Start _____
 Finish _____
 Travel PM _____
 Lunch Yes No _____

Customers Signature: _____

 Our Responsibility Ends at Curb



GUARANTEED CERTIFIED SCALES ENTER

Date 04/30/12 190913

Company DRT

Truck DA Trailer DTR

Weighmaster Signature [Signature]

CERTIFIED

- Jim's weights are New York State Certified
- Jim's Guarantees Scale Accuracy
- Jim's checks Scale daily to confirm Accuracy


COUNTY OF ERIE
BUREAU of
WEIGHTS and MEASURES

281606
ORIGINAL

Steer Axle	10180	(lb)s
Drive Axle	16360	(lb)s
Trailer Axle	11820	(lb)s
Gross Weight	38360	(lb)s

7.50 Standard
FEE

JIM'S TRUCK PLAZA
EXIT 52E OFF I90
2115 WALDEN AVENUE
BUFFALO, NY 14225
THANK YOU



GUARANTEED CERTIFIED

SCALES

ENTER

Date 04/30/12 DRT 190927

Company _____

Truck D2 Trailer DT2

Weighmaster _____
Signature bulb

CERTIFIED

COUNTY OF ERIE
BUREAU of
WEIGHTS and MEASURES

• Jim's weights are New York State Certified

• Jim's Guarantees Scale Accuracy

• Jim's checks Scale daily to confirm Accuracy

281620
ORIGINAL

Steer Axle	12040	(lb)s
Drive Axle	49400	(lb)s
Trailer Axle	56340	(lb)s
Gross Weight	117780	(lb)s

FEES 0.00 Re-Weigh

JIM'S TRUCK PLAZA
EXIT 52E OFF I90
2115 WALDEN AVENUE
BUFFALO, NY 14225

THANK YOU

C.R. WEBER TRUCKING
 32 WINDCREST DRIVE
 CHEEKTOWAGA, NEW YORK 14225
 (716) 892-6926

Nº 001956

Sold By D-2/DT-2 Date 5/1/12

Name Empire Building Diagnostics

Job Location National Fuel Gas, Mineral Springs Rd, W. Seneca

Job Description Bricks to Allied Waste Niagara

Ticket #	Weight	Time	Rate
① 117780 -	38360		39.71
② 115400 -	38140		38.63

Travel AM

Start


Finish

Travel PM

Lunch Yes No

Customers Signature:

Our Responsibility Ends at Curb



GUARANTEED CERTIFIED SCALES ENTER

Date 05/01/12 190990

Company DEI

Truck D1 Trailer _____

Weighmaster Signature [Signature] : 1015

CERTIFIED

- Jim's weights are New York State Certified
- Jim's Guarantees Scale Accuracy
- Jim's checks Scale daily to confirm Accuracy

COUNTY OF ERIE
BUREAU of
WEIGHTS and MEASURES


281683
ORIGINAL

Steer Axle	11320	(lb)s
Drive Axle	41260	(lb)s
Trailer Axle	50400	(lb)s
Gross Weight	102980	(lb)s

FEET 50 Standard

JIM'S TRUCK PLAZA
EXIT 52E OFF I90
2115 WALDEN AVENUE
BUFFALO, NY 14225

THANK YOU



GUARANTEED CERTIFIED

SCALES

ENTER

Date 05/01/12 190984

Company PKT

Truck D1 Trailer _____

Weighmaster Signature Bob

Steer Axle	10020	(lb)s
Drive Axle	14580	(lb)s
Trailer Axle	9760	(lb)s
Gross Weight	34360	(lb)s

CERTIFIED

- Jim's weights are New York State Certified
- Jim's Guarantees Scale Accuracy
- Jim's checks Scale daily to confirm Accuracy

COUNTY OF ERIE
BUREAU of
WEIGHTS and MEASURES

FEE 7.50 Standard

JIM'S TRUCK PLAZA
EXIT 52E OFF I90
2115 WALDEN AVENUE
BUFFALO, NY 14225

281677
ORIGINAL

THANK YOU

C.R. WEBER TRUCKING No 0458
 32 WINDCREST DRIVE
 CHEEKTOWAGA, NEW YORK 14225
 716-983-1445


Sold By D-1 Date 5-1-12
 Name EBO National Fuel Gas
 Job Location Mineral Springs Rd
 Job Description Brick + Concrete BFI

Ticket #	Weight	Time	Rate
LOAD 1	34180	113860	39.84 Ton
2	34360	102980	34.31 Ton
	LAST LOAD		
			74.15 TONS

Travel AM _____
 Start _____
 Finish _____
 Travel PM _____
 Lunch Yes No _____

Customers Signature: _____

 Our Responsibility Ends at Curb



GUARANTEED CERTIFIED SCALES ENTER

Date 05/01/12 190986

Company DTI

Truck D2 Trailer DT2

Weighmaster
Signature [Signature]

CERTIFIED

COUNTY OF ERIE
BUREAU of
WEIGHTS and MEASURES

Steer Axle	11800	(lb)s
Drive Axle	46480	(lb)s
Trailer Axle	57120	(lb)s
Gross Weight	115400	(lb)s

FEE 7.50 Standard

• Jim's weights are New York State Certified


• Jim's Guarantees Scale Accuracy

• Jim's checks Scale daily to confirm Accuracy

281679
ORIGINAL

JIM'S TRUCK PLAZA
EXIT 52E OFF I90
2115 WALDEN AVENUE
BUFFALO, NY 14225

THANK YOU



GUARANTEED CERTIFIED SCALES ENTER

Date 05/01/12 DET 190982

Company DET

Truck D2 Trailer DT2

Weighmaster
Signature [Signature]

CERTIFIED

• Jim's weights are New York State Certified

• Jim's Guarantees Scale Accuracy

• Jim's checks Scale daily to confirm Accuracy

COUNTY OF ERIE
BUREAU of
WEIGHTS and MEASURES


281675
ORIGINAL

Steer Axle	#	10100	(lb)s
Drive Axle		16160	(lb)s
Trailer Axle		11880	(lb)s
Gross Weight		38140	(lb)s

FEE 7.50 Standard

JIM'S TRUCK PLAZA
EXIT 52E OFF I90
2115 WALDEN AVENUE
BUFFALO, NY 14225

THANK YOU



EMPIRE BUILDING DIAGNOSTICS, INC.

P.O. Box 412, 2 Main Street
Depew, New York 14043-0412
Phone (716) 685-4588
Fax (716) 685-6055

ASBETSOS CLOSE OUT PACKAGE

National Fuel Gas
5955 New Taylor Road
Orchard Park, NY 14127

PROJECT: 365 Mineral Springs Rd. Bldg 8

Table of Contents

1. Company License
2. Waste Transporter Permit
3. Waste Manifest
4. Insurance Certificate
5. State/EPA Notification
6. Employee Accreditations
7. Daily Sign Ins & Project Logs

1. Company License

NEW YORK STATE DEPARTMENT OF LABOR
DIVISION OF SAFETY AND HEALTH
LICENSE AND CERTIFICATE UNIT
STATE CAMPUS BUILDING 12
ALBANY, NY 12240

ASBESTOS HANDLING LICENSE

Empire Building Diagnostics, Inc.
P.O. Box 412
Depew, NY 14043

FILE NUMBER: 990767
LICENSE NUMBER: 09328
LICENSE CLASS: FULL
DATE OF ISSUE: 08/18/2011
EXPIRATION DATE: 09/30/2012

Duly Authorized Representative: Mark Young

This license has been issued in accordance with applicable provisions of Article 14 of the Labor Law of New York State and of the New York State Codes, Rules and Regulations (12 NYCRR Part 59). It is subject to suspension or revocation for a (1) serious violation of state, federal or local laws with regard to the conduct of an asbestos project, or (2) demonstrated lack of responsibility in the conduct of any project involving asbestos or asbestos material.

This license is valid only for the contractor named above and this license or a photocopy must be prominently displayed at the asbestos project work site. This license verifies that all persons employed by the licensee on an asbestos project in New York State have been issued an Asbestos Certificate, appropriate for the type of work they perform, by the New York State Department of Labor.

Maureen A. Cox

Maureen A. Cox, Director
FOR THE COMMISSIONER OF LABOR

2. Waste Transporter Permit



NEW YORK STATE DEPARTMENT OF ENVIRONMENTAL CONSERVATION
DIVISION OF ENVIRONMENTAL REMEDIATION

PART 364

WASTE TRANSPORTER PERMIT NO. 9A-329

Pursuant to Article 27, Titles 3 and 15 of the Environmental Conservation Law and 6 NYCRR 364

PERMIT ISSUED TO:

EMPIRE BUILDING DIAGNOSTICS, INC.
P.O. BOX 412
2 MAIN STREET
DEPEW, NY 14043

PERMIT TYPE:

- NEW
- RENEWAL
- MODIFICATION

CONTACT NAME: MICHAEL YOUNG
COUNTY: ERIE
TELEPHONE NO: (716)685-4588

EFFECTIVE DATE: 01/05/2012
EXPIRATION DATE: 07/31/2012
US EPA ID NUMBER:

AUTHORIZED WASTE TYPES BY DESTINATION FACILITY:

The Permittee is Authorized to Transport the Following Waste Type(s) to the Destination Facility listed :

Destination Facility	Location	Waste Type(s)	Note
BFI NIAGARA FALLS LANDFILL FACILITY	NIAGARA FALLS , NY	Non-Hazardous Industrial/Commercial Asbestos	
CHAUTAUQUA COUNTY LANDFILL	JAMESTOWN , NY	Non-Hazardous Industrial/Commercial Asbestos	
CID LANDFILL, INC.	CHAFFEE , NY	Non-Hazardous Industrial/Commercial Asbestos	
MODERN LANDFILL	MODEL CITY , NY	Waste Tires Asbestos Petroleum Contaminated Soil	
MODERN LANDFILL, INC.	MODEL CITY , NY	Non-Hazardous Industrial/Commercial	
TONAWANDA (T) LANDFILL	TONAWANDA , NY	Petroleum Contaminated Soil	
WASTE MANAGEMENT	DEPEW , NY	Non-Hazardous Industrial/Commercial	
WASTE MANAGEMENT, INC. (FORMERLY CID LANDFILL, INC.)	CHAFFEE , NY	Non-Hazardous Industrial/Commercial Asbestos	

NOTE: By acceptance of this permit, the permittee agrees that the permit is contingent upon strict compliance with the Environmental Conservation Law, all applicable regulations, and the General Conditions printed on the back of this page.

ADDRESS:

New York State Department of Environmental Conservation
Division of Environmental Remediation - Waste Transporter Program
625 Broadway, 11th Floor
Albany, NY 12233-7020

AUTHORIZED SIGNATURE:

Jack A. Aversa

Date: 11/5/2012

NEW YORK STATE DEPARTMENT OF ENVIRONMENTAL CONSERVATION
DIVISION OF ENVIRONMENTAL REMEDIATION

PART 364

WASTE TRANSPORTER PERMIT NO. 9A-329

Pursuant to Article 27, Titles 3 and 15 of the Environmental Conservation Law and 6 NYCRR 364

PERMIT ISSUED TO:

EMPIRE BUILDING DIAGNOSTICS, INC.
P.O. BOX 412
2 MAIN STREET
DEPEW, NY 14043

PERMIT TYPE:

- NEW
 RENEWAL
 MODIFICATION

CONTACT NAME: MICHAEL YOUNG
COUNTY: ERIE
TELEPHONE NO: (716)685-4588

EFFECTIVE DATE: 01/05/2012
EXPIRATION DATE: 07/31/2012
US EPA ID NUMBER:

AUTHORIZED VEHICLES:

The Permittee is Authorized to Operate the Following Vehicles to Transport Waste:

(Vehicles enclosed in <>'s are authorized to haul Residential Raw Sewage and/or Septage only)

37 (Thirty Seven) Permitted Vehicle(s)

NY 24165JW
NY 26437JX
NY 26604JX
NY 39331JY
NY 39842JZ
NY 39843JZ
NY 44567MB
NY 49136JX
NY 53478KA
NY 56112JY
NY 56247JY
NY 60772JA
NY 61105JV
NY 70814JW
NY 71507JW
NY 71508JW
NY 71665JW
NY 71667JW
NY 74044JX
NY 74574KA
NY 77119MA
NY 77156MA
NY 78401JV
NY 79134KA
NY 89639JW
NY AS20606
NY AS59649
NY AS59699
NY AS59770
NY AS59801
NY AS60231
NY AT10655
NY AT16056
NY AU27377
NY AU27734
NY AU28152
NY BA26830
End of List

3. Waste Manifest

4. Insurance Certificate



CERTIFICATE OF LIABILITY INSURANCE

DATE (MM/DD/YYYY)
1/16/2012

THIS CERTIFICATE IS ISSUED AS A MATTER OF INFORMATION ONLY AND CONFERS NO RIGHTS UPON THE CERTIFICATE HOLDER. THIS CERTIFICATE DOES NOT AFFIRMATIVELY OR NEGATIVELY AMEND, EXTEND OR ALTER THE COVERAGE AFFORDED BY THE POLICIES BELOW. THIS CERTIFICATE OF INSURANCE DOES NOT CONSTITUTE A CONTRACT BETWEEN THE ISSUING INSURER(S), AUTHORIZED REPRESENTATIVE OR PRODUCER, AND THE CERTIFICATE HOLDER.

IMPORTANT: If the certificate holder is an ADDITIONAL INSURED, the policy(ies) must be endorsed. If SUBROGATION IS WAIVED, subject to the terms and conditions of the policy, certain policies may require an endorsement. A statement on this certificate does not confer rights to the certificate holder in lieu of such endorsement(s).

PRODUCER Tompkins Insurance Agencies, Inc. 90 Main Street Batavia NY 14020		CONTACT NAME: Joanne Kirsch PHONE (A/C, No, Ext): (585) 344-0833 FAX (A/C, No): (585) 344-1354 E-MAIL ADDRESS: jkirsch@tompkinsins.com PRODUCER CUSTOMER ID #: 00010446	
INSURED EMPIRE BUILDING DIAGNOSTICS INC 2 Main Street PO Box 412 Depew NY 14043		INSURER(S) AFFORDING COVERAGE INSURER A: Nautilus Insurance Company INSURER B: Great Divide Insurance Company INSURER C: First Rehabilitation Ins Co INSURER D: INSURER E: INSURER F:	

COVERAGES **CERTIFICATE NUMBER:** 2011 Sample #3 **REVISION NUMBER:**

THIS IS TO CERTIFY THAT THE POLICIES OF INSURANCE LISTED BELOW HAVE BEEN ISSUED TO THE INSURED NAMED ABOVE FOR THE POLICY PERIOD INDICATED. NOTWITHSTANDING ANY REQUIREMENT, TERM OR CONDITION OF ANY CONTRACT OR OTHER DOCUMENT WITH RESPECT TO WHICH THIS CERTIFICATE MAY BE ISSUED OR MAY PERTAIN, THE INSURANCE AFFORDED BY THE POLICIES DESCRIBED HEREIN IS SUBJECT TO ALL THE TERMS, EXCLUSIONS AND CONDITIONS OF SUCH POLICIES. LIMITS SHOWN MAY HAVE BEEN REDUCED BY PAID CLAIMS.

INSR LTR	TYPE OF INSURANCE	ADD'L SUBR INSR	POLICY NUMBER	POLICY EFF (MM/DD/YYYY)	POLICY EXP (MM/DD/YYYY)	LIMITS
A	GENERAL LIABILITY <input checked="" type="checkbox"/> COMMERCIAL GENERAL LIABILITY <input type="checkbox"/> CLAIMS-MADE <input checked="" type="checkbox"/> OCCUR GEN'L AGGREGATE LIMIT APPLIES PER: <input checked="" type="checkbox"/> POLICY <input type="checkbox"/> PROJECT <input type="checkbox"/> LOC		ECR052745410	3/28/2011	3/28/2012	EACH OCCURRENCE \$ 1,000,000 DAMAGE TO RENTED PREMISES (Ea occurrence) \$ 50,000 MED EXP (Any one person) \$ 5,000 PERSONAL & ADV INJURY \$ 1,000,000 GENERAL AGGREGATE \$ 2,000,000 PRODUCTS - COM/POP AGG \$ 2,000,000
	AUTOMOBILE LIABILITY <input checked="" type="checkbox"/> ANY AUTO <input type="checkbox"/> ALL OWNED AUTOS <input checked="" type="checkbox"/> SCHEDULED AUTOS <input checked="" type="checkbox"/> HIRED AUTOS <input checked="" type="checkbox"/> NON-OWNED AUTOS		BAP152964410	3/28/2011	3/28/2012	COMBINED SINGLE LIMIT (Ea accident) \$ 1,000,000 BODILY INJURY (Per person) \$ BODILY INJURY (Per accident) \$ PROPERTY DAMAGE (Per accident) \$ PIP-Basic \$ 50,000 PIP-Additional \$ 50,000
A	<input checked="" type="checkbox"/> UMBRELLA LIAB <input checked="" type="checkbox"/> OCCUR <input type="checkbox"/> EXCESS LIAB <input type="checkbox"/> CLAIMS-MADE DEDUCTIBLE <input checked="" type="checkbox"/> RETENTION \$ 10,000		FFX152745510	3/28/2011	3/28/2012	EACH OCCURRENCE \$ 5,000,000 AGGREGATE \$ 5,000,000
B	WORKERS COMPENSATION AND EMPLOYERS' LIABILITY ANY PROPRIETOR/PARTNER/EXECUTIVE OFFICER/MEMBER EXCLUDED? (Mandatory in NH) If yes, describe under DESCRIPTION OF OPERATIONS below	Y/N <input type="checkbox"/> N/A	WCA152964310	5/12/2011	5/12/2012	WC STATUTORY LIMITS OTHER E.L. EACH ACCIDENT \$ 1,000,000 E.L. DISEASE - EA EMPLOYEE \$ 1,000,000 E.L. DISEASE - POLICY LIMIT \$ 1,000,000
C			DBL267339	12/29/2011	12/29/2012	

DESCRIPTION OF OPERATIONS / LOCATIONS / VEHICLES (Attach ACORD 101, Additional Remarks Schedule, if Note Space is needed)
This certificate of insurance is for illustration purposes only. It is not intended to provide proof of coverage for any policy or insured. Misuse of this document can be construed as insurance fraud and parties could be subject to civil penalty and/or criminal prosecution

CERTIFICATE HOLDER 123 Company 456 Main St Nowhere, NY 11111	CANCELLATION SHOULD ANY OF THE ABOVE DESCRIBED POLICIES BE CANCELLED BEFORE THE EXPIRATION DATE THEREOF, NOTICE WILL BE DELIVERED IN ACCORDANCE WITH THE POLICY PROVISIONS.
	AUTHORIZED REPRESENTATIVE David Boyce/JMK <i>David S. Boyce</i>

5. State/EPA Notification



Asbestos Project Notification

Project Reference Number: 25893617	Type: Initial Notification
Status: Notification Received	Notification Received: 1/30/2012
Payment Status: Unpaid	Number of amendments: 0
Notification Entered By: Empire Building Diagnostics, Inc.	

Contractor Information	
FEIN:161315013	
Empire Building Diagnostics, Inc.	Mailing Address
2 Main Street	P.O. Box 412
Depew NY 14043	Depew NY 14043
Asbestos License Number: 29326	
Duly Authorized Representative	
Mark Young, Officer	
Phone Number:	716-685-4588
E-mail Address:	empire@ebdinc.com

Project Information
Project Start Date: 2/13/2012
Project End Date: 2/12/2013
Project Location County: Erie

Worker Compensation
Worker Compensation Policy#:
WC Exemption Certificate#:
Number of your employees you expect to be on project:
Will temporary workers be used?
If yes, name of temporary agency:

Project Location
Building Name: building 8
Room or Location: throughout, exterior
Bridge ID#:
Address Line 1: 365 Mineral Springs Road
Address Line 2:
City Town or Village: Buffalo
State: New York
Zip Code: 14210

Building Information	
Current Use: Vacant	
Prior Use: Other	
Approximate Year Built: 1924	
Size(sq.ft): 7200	
Is this fee exempt project?: NO	
Reason:	

Building Representative/Site Contact	
Name: Jim Clark	
Phone Number: 716-667-5557	
E-mail Address:	
Cell Phone Number:	

Phase Details				
Phase #	Phase Start Date	Phase End Date	Phase Location	Phase Scope

Sub-Contractor Details	
Name:	Asbestos License Number:

Night/Weekend/Shift Work Details	
typically 7:00 am to 5:30 pm; could also be any other time depending on work load or when necessary	

Party for Whom Work is being Performed			
First Name:		Last Name:	
Organization:	National Fuel Gas	Address Line 1:	6363 Main Street
Apt./Suite:		City Town or Village:	Williamsville
Address Line 2:		State:	NY
Province:		Country:	United States
Zip Code:	14221		
Contract Dollar Amount:			

Variance Information	
-----------------------------	--

Procedures and Type of Equipment and Ventilation Systems Used	
HEPA vacuums, industrial safety ladders, water filtration, decontamination unit, negative air machines	

Air Monitoring Firm	
Name:	Asbestos License Number:
Islechem, LLC	29449

Laboratory Performing Analysis	
Name:	ELAP Registration Number:
IsleChem, LLC	11862

Type of Asbestos Work			
Pipe Related:	Yes	Siding:	No
Clean up:	No	Vessel covering:	No
Caulking/mastic:	Yes	Spray-on insulation:	No
Roofing/flashing:	No	VAT:	Yes
Demolition:	No	Demolition Ref#:	
Other-specify:	transite		

Waste Transporter

Name: Empire Building Diagnostics, Inc.
 NYS DEC or EPA Permit Number: 9A-326
 Phone Number: 716-685-4588
 Apt./Suite:
 Address Line 1: 2 Main Street, PO Box 412
 Address Line 2:
 City Town or Village: Depew
 Province:
 State: NY
 Zip Code: 14043
 Country: United States

Landfill

Name: Allied Waste Niagara Falls Landfill
 Phone Number: 716-282-6381
 Apt./Suite:
 Address Line 1: 5600 Niagara Falls Boulevard
 Address Line 2:
 City Town or Village: Niagara Falls
 Province:
 State: NY
 Zip Code: 14304
 Country: United States

Type and Amount of Asbestos Containing Material

Friable linear feet:	10	Friable square feet:	0
Non-friable linear feet:	30	Non-friable square feet:	4940

Fee

Total linear feet: 40.0
 Total square feet: 4940.0
 Total Fee: 2000.0

Project Fee Schedule

If the notification was submitted prior to 4/7/09, the actual project fee is one half of the amount shown on the fee schedule

Linear Feet:	Fee	Square Feet:	Fee
0 - 259 feet:	\$0	0 - 159 feet:	\$0
260 - 429 feet:	\$200	160 - 259 feet:	\$200
430 - 824 feet:	\$400	260 - 499 feet:	\$400
825 - 1649 feet:	\$1000	500 - 999 feet:	\$1000
1650 or more feet:	\$2000	1000 or more feet:	\$2000

Remarks

6. Employee Accreditations

STATE OF NEW YORK - DEPARTMENT OF LABOR
ASBESTOS CERTIFICATE




LESLIE U MAY JR
CLASS(EXPIRES)
G SUPR(04/13)

CERT# 11-21032
DMV# 590274725

MUST BE CARRIED ON ASBESTOS PROJECTS

STATE OF NEW YORK - DEPARTMENT OF LABOR
ASBESTOS CERTIFICATE



JESSICA DALTON
CLASS (EXPIRES)
B SUPR (09/12)

CERT# 09-09121
DMV# 213339616

MUST BE CARRIED ON ASBESTOS PROJECTS



EYES GRN
HAIR RED
HGT 5' 07"

IF FOUND RETURN TO:
NYS DOL - L&C UNIT
ROOM 161A BUILDING 12
STATE OFFICE CAMPUS
ALBANY NY 12240

STATE OF NEW YORK - DEPARTMENT OF LABOR
ASBESTOS CERTIFICATE



CERT# 06-03764
DMV# 609619982

MUST BE CARRIED ON ASBESTOS PROJECTS



EYES BRO
HAIR BLK
HGT 6' 03"

IF FOUND RETURN TO:
NYS DOL - L&C UNIT
ROOM 161A BUILDING 12
STATE OFFICE CAMPUS
ALBANY NY 12240

**STATE OF NEW YORK - DEPARTMENT OF LABOR
ASBESTOS CERTIFICATE**



**CERT# 03-16665
DMV# 863544715**


MUST BE CARRIED ON ASBESTOS PROJECTS



**EYES BRO
HAIR BRO
HGT 6' 03"**

**IF FOUND RETURN TO:
NYS DOL - L&C UNIT
ROOM 161A BUILDING 12
STATE OFFICE CAMPUS
ALBANY, NY 12240**

STATE OF NEW YORK - DEPARTMENT OF LABOR
ASBESTOS CERTIFICATE



SEAN J. MYERS
CLASS EXPIRES
6/30/12

CERT# 11-07099
DMV# 157527312

MUST BE CARRIED ON ASBESTOS PROJECTS




EYES BRO
HAIR BRO
HGT 6' 02"

IF FOUND RETURN TO:
NYS DOL - L&C UNIT
ROOM 161A BUILDING 12
STATE OFFICE CAMPUS
ALBANY NY 12240

STATE OF NEW YORK - DEPARTMENT OF LABOR
ASBESTOS CERTIFICATE



RICHARD D OVERHOLT
CLASS(EXPIRES)
G.SUPR(10/12)



CERT# 09-01836
DMV# 190806003

MUST BE CARRIED ON ASBESTOS PROJECTS



EYES BLU
HAIR BLN
HGT 6' 00"

IF FOUND RETURN TO:
NYSOL - L&C UNIT
ROOM 161A BUILDING 12
STATE OFFICE CAMPUS
ALBANY NY 12240

7. Daily Sign Ins & Project Logs

Daily Sign In Sheet

Project Name 365 Mineral Springs Bldg 6 Date 2-13-12
 Supervisor KE Kenbert Job # 212-030

All persons, before entering the regulated abatement work area or enclosure, shall read and be familiar with all posted regulations, personal protection requirements, including regulated abatement work area entry and exit procedures and emergency procedures. By signing below I acknowledge that these procedures have been reviewed and understood prior to entry of work area.

EMPLOYEE NAME	IN	OUT	IN	OUT	TOTAL HRS
<u>Mike Caries</u>	<u>700</u>	<u>1200</u>	<u>1230</u>	<u>330</u>	
<u>Jessie Dalton</u>	<u>7:00</u>	<u>1200</u>	<u>1230</u>	<u>330</u>	
<u>Sean Myers</u>	<u>700</u>	<u>1200</u>	<u>1230</u>	<u>330</u>	
<u>Brian Walker</u>	<u>1000</u>	<u>1200</u>	<u>1230</u>	<u>330</u>	
<u>LESTER U. MAY JR</u>	<u>10:00 AM</u>	<u>12:00 PM</u>	<u>12:30 PM</u>	<u>3:30 PM</u>	

Visitors Log

NAME	ORGANIZATION	PURPOSE FOR VISIT	IN	OUT

Daily Project Log

Project Name: 365 Mineral Springs Bldg 8

Job #: 212.030

Supervisor (print): Kel Kenberg

Date: 2/13/12

- Testing of Barriers [56-8.2(f)] daily
- Negative Air System Inspection [56-7.8(a)(10)] daily
- HVAC Positive Pressurization [56-7.9(d)(3)] daily
- Barrier Inspections [56-8.2(d)] daily twice per shift
- Barrier Inspections [56-8.2(d)] daily twice per shift
- Daily cleaning of Enclosures [56-8.2(h)] daily at end of shift

	Completed	Time	Repairs Y/N **
	✓	830	N
	✓	1000	N
1st	✓	130	N
2nd	✓	230	N

** List any repairs made: _____

Manometer Readings [56-7.8(a)(4)] twice per shift
(Required for all OSHA Class I Large & Small Projects)

1st Reading	Time	2nd Reading	Time

Work Stoppage Due to High Air [56-7.3(a)] note high sample result, location, time of work cessation, results of barrier/neg air inspections and repairs or required cleaning: _____

Final Inspection (to be documented by supervisor at completion of asbestos project)
minor tent Good - EK

Fill in GENERAL comments on routine progress on this project on the above date. Detail major problems and action taken, injuries, hiring, firing of personnel and any other occurrence which may affect the project. This log may be utilized as a legal document.

Arrived on site Prepped minor tent
met w/ air monitor Began removal of pipe wrap
placed decon. Cleaned
Prep Bagged out

Began removal of VAT

Visual Inspection by Project Monitor [56-9.1(d), 9.2(e)]
 Project Monitor Name: Daniel Jansh NYSDOL Certificate #: 08-14211

Inspection Findings: Approximately 5' of ACM Pipe insulation was removed from Rm 7001. Area has been cleaned, no visible debris

Project Monitor Signature: [Signature]
 istchem

Supervisor signature: [Signature]

Daily Sign In Sheet

Project Name 365 Mineral Springs Bldg 8 Date 2-14-12
 Supervisor Ke Kentz et al Job # 212-030

All persons, before entering the regulated abatement work area or enclosure, shall read and be familiar with all posted regulations, personal protection requirements, including regulated abatement work area entry and exit procedures and emergency procedures. By signing below I acknowledge that these procedures have been reviewed and understood prior to entry of work area.

EMPLOYEE NAME	IN	OUT	IN	OUT	TOTAL HRS
Sean Myers	700	1200	1230	330	
Jessica Dalton	700	1200	1230	330	
Alvin Garces	700	1200	1230	330	

Visitors Log

NAME	ORGANIZATION	PURPOSE FOR VISIT	IN	OUT

Daily Project Log

Project Name: 365 Mineral Springs Bldg 8

Job #: 212-030

Supervisor (print): Kei Kenberg

Date: 2-14-12

Testing of Barriers [56-8.2(f)] daily
 Negative Air System Inspection [56-7.8(a)(10)] daily
 HVAC Positive Pressurization [56-7.9(d)(3)] daily
 Barrier Inspections [56-8.2(d)] daily twice per shift
 Barrier Inspections [56-8.2(d)] daily twice per shift
 Daily cleaning of Enclosures [56-8.2(h)] daily at end of shift

	Completed	Time	Repairs Y/N **
	✓	7:00	N
1st	✓	7:30	N
2nd	✓	2:30	N
	✓	3:00	

** List any repairs made: _____

Manometer Readings [56-7.8(a)(4)] twice per shift
 (Required for all OSHA Class I Large & Small Projects)

1st Reading	Time	2nd Reading	Time

Work Stoppage Due to High Air [56-7.3(a)] note high sample result, location, time of work cessation, results of barrier/neg air inspections and repairs or required cleaning: _____

Final Inspection (to be documented by supervisor at completion of asbestos project)
2 Areas Good - EK

Fill in GENERAL comments on routine progress on this project on the above date. Detail major problems and action taken, injuries, hiring, firing of personnel and any other occurrence which may affect the project. This log may be utilized as a legal document.

Arrived on site

Cont. Floor tile removal
Finished / cleaned / bagged out

Removed Transite stack
Cleaned / loaded out

Visual Inspection by Project Monitor [56-9.1(d), 9.2(e)]

Project Monitor Name: Daniel Janish NYSDOL Certificate #: 08-14211

Inspection Findings: ACM Transite pipe was removed from the
right side of Bldg 8. Area was cleaned. No visible debris
left behind.

Project Monitor Signature: [Signature]

Supervisor signature: [Signature]

Islechem

Daily Sign In Sheet

Project Name 365 Mineral Springs Bldg B Date 2-15-12

Supervisor Kel Kenberg Job # 22030

All persons, before entering the regulated abatement work area or enclosure, shall read and be familiar with all posted regulations, personal protection requirements, including regulated abatement work area entry and exit procedures and emergency procedures. By signing below I acknowledge that these procedures have been reviewed and understood prior to entry of work area.

EMPLOYEE NAME	IN	OUT	IN	OUT	TOTAL HRS
Kim Gattuso	7:00	12:00	12:30	3:30	
Jessica Aulhorn	7:00	12:00	12:30	3:30	

Visitors Log

NAME	ORGANIZATION	PURPOSE FOR VISIT	IN	OUT

Daily Project Log

Project Name: 365 Mineral Springs Bldg 8

Job #: 212-030

Supervisor (print): Kelkenberg

Date: 2-15-12

- Testing of Barriers [56-8.2(f)] daily
- Negative Air System Inspection [56-7.8(a)(10)] daily
- HVAC Positive Pressurization [56-7.9(d)(3)] daily
- Barrier Inspections [56-8.2(d)] daily twice per shift
- Barrier Inspections [56-8.2(d)] daily twice per shift
- Daily cleaning of Enclosures [56-8.2(h)] daily at end of shift

1st
2nd

Completed	Time	Repairs Y/N **
✓	700	N
✓	730	N
✓	130	N
✓	245	

** List any repairs made: _____

Manometer Readings [56-7.8(a)(4)] twice per shift
(Required for all OSHA Class I Large & Small Projects)

1st Reading	Time	2nd Reading	Time

Work Stoppage Due to High Air [56-7.3(a)] note high sample result, location, time of work cessation, results of barrier/neg air inspections and repairs or required cleaning: _____

Final Inspection (to be documented by supervisor at completion of asbestos project) _____

Fill in GENERAL comments on routine progress on this project on the above date. Detail major problems and action taken, injuries, hiring, firing of personnel and any other occurrence which may affect the project. This log may be utilized as a legal document.

Arrived on site
met w/ air monitor

Began mastic removal

Visual Inspection by Project Monitor [56-9.1(d), 9.2(e)]


Project Monitor Name: _____

NYSDOL Certificate #: _____

Inspection Findings: _____

Project Monitor Signature: _____

Supervisor signature: _____



Daily Sign In Sheet

Project Name 365 Mineral Springs OHG 8 Date 2-16-12

Supervisor Ke/Kenhardt Job # 212-030

All persons, before entering the regulated abatement work area or enclosure, shall read and be familiar with all posted regulations, personal protection requirements, including regulated abatement work area entry and exit procedures and emergency procedures. By signing below I acknowledge that these procedures have been reviewed and understood prior to entry of work area.

EMPLOYEE NAME	IN	OUT	IN	OUT	TOTAL HRS
Jessica Dalton	7:00	12:00	12:30	3:30	
KIM GAINES	7:00	12:00	12:30	3:30	

Visitors Log

NAME	ORGANIZATION	PURPOSE FOR VISIT	IN	OUT

Daily Project Log

Project Name: 365 Mineral Springs Bldg

Job #: 212-030

Supervisor (print): Kelkenberg

Date: 2-16-12

- Testing of Barriers [56-8.2(f)] daily
- Negative Air System Inspection [56-7.8(a)(10)] daily
- HVAC Positive Pressurization [56-7.9(d)(3)] daily
- Barrier Inspections [56-8.2(d)] daily twice per shift
- Barrier Inspections [56-8.2(d)] daily twice per shift
- Daily cleaning of Enclosures [56-8.2(h)] daily at end of shift

	Completed	Time	Repairs Y/N **
	✓	700	N
1st	✓	715	N
2nd	✓	200	N
	✓	300	

** List any repairs made: _____

Manometer Readings [56-7.8(a)(4)] twice per shift
(Required for all OSHA Class I Large & Small Projects)

1st Reading	Time	2nd Reading	Time

Work Stoppage Due to High Air [56-7.3(a)] note high sample result, location, time of work cessation, results of barrier/neg air inspections and repairs or required cleaning: _____

Final Inspection (to be documented by supervisor at completion of asbestos project) _____

Fill in GENERAL comments on routine progress on this project on the above date. Detail major problems and action taken, injuries, hiring, firing of personnel and any other occurrence which may affect the project. This log may be utilized as a legal document.

Arrived on site
met w/ air monitor
cont. waste removal


Visual Inspection by Project Monitor [56-9.1(d), 9.2(e)]

Project Monitor Name: _____

NYSDOL Certificate #: _____

Inspection Findings: _____

Project Monitor Signature: _____

Supervisor signature: 

Daily Sign In Sheet

Project Name 365 Mineral Springs Bldg 8 Date 2-17-12

Supervisor Ke/Kerber Job # 212.030

All persons, before entering the regulated abatement work area or enclosure, shall read and be familiar with all posted regulations, personal protection requirements, including regulated abatement work area entry and exit procedures and emergency procedures. By signing below I acknowledge that these procedures have been reviewed and understood prior to entry of work area.

EMPLOYEE NAME	IN	OUT	IN	OUT	TOTAL HRS
<i>Regina D. Han</i>	700	1200	1230	330	
<i>KIM GRAYES</i>	700	1200	1230	330	

Visitors Log

NAME	ORGANIZATION	PURPOSE FOR VISIT	IN	OUT

Daily Project Log

Project Name: 365 Mineral Springs Bldg 8

Job #: 212-630

Supervisor (print): kelkenberg

Date: 2-17-12

- Testing of Barriers [56-8.2(f)] daily
- Negative Air System Inspection [56-7.8(a)(10)] daily
- HVAC Positive Pressurization [56-7.9(d)(3)] daily
- Barrier Inspections [56-8.2(d)] daily twice per shift
- Barrier Inspections [56-8.2(d)] daily twice per shift
- Daily cleaning of Enclosures [56-8.2(h)] daily at end of shift

	Completed	Time	Repairs Y/N **
	✓	7 ⁰⁰	N
1st	✓	7 ¹⁰	N
2nd	✓	1 ³⁰	N
	✓	3 ⁰⁰	

** List any repairs made: _____

Manometer Readings [56-7.8(a)(4)] twice per shift
(Required for all OSHA Class I Large & Small Projects)

1st Reading	Time	2nd Reading	Time

Work Stoppage Due to High Air [56-7.3(a)] note high sample result, location, time of work cessation, results of barrier/neg air inspections and repairs or required cleaning: _____

Final Inspection (to be documented by supervisor at completion of asbestos project)
Area Good - Eik.

Fill in GENERAL comments on routine progress on this project on the above date. Detail major problems and action taken, injuries, hiring, firing of personnel and any other occurrence which may affect the project. This log may be utilized as a legal document.

Arrived on site

Finished mastic removal

Cleaning area

Visual Inspection by Project Monitor [56-9.1(d), 9.2(e)]

Project Monitor Name: Anthony Ferao NYSDOL Certificate #: 62-13110

Inspection Findings: NO VISIBLIS ACM @ TIME OF INSPECTION

Project Monitor Signature: AF

Supervisor signature: [Signature]

Daily Sign In Sheet

Project Name 365 Mineral Springs Bldg 2 Date 2/21/12
 Supervisor Rich Overholt Job # 212030

All persons, before entering the regulated abatement work area or enclosure, shall read and be familiar with all posted regulations, personal protection requirements, including regulated abatement work area entry and exit procedures and emergency procedures. By signing below I acknowledge that these procedures have been reviewed and understood prior to entry of work area.

EMPLOYEE NAME	IN	OUT	IN	OUT	TOTAL HRS
Kim Gaines	12:30	3:30			3
Rich Overholt	12:30	3:30			3

Visitors Log

NAME	ORGANIZATION	PURPOSE FOR VISIT	IN	OUT

Daily Project Log

Project Name: 365 Mineral Springs Bldg Job #: 212-030

Supervisor (print): Rich Overholt Date: 2/21/12

- Testing of Barriers [56-8.2(f)] daily
- Negative Air System Inspection [56-7.8(a)(10)] daily
- HVAC Positive Pressurization [56-7.9(d)(3)] daily
- Barrier Inspections [56-8.2(d)] daily twice per shift
- Barrier Inspections [56-8.2(d)] daily twice per shift
- Daily cleaning of Enclosures [56-8.2(h)] daily at end of shift

1st
2nd

Completed	Time	Repairs Y/N **

** List any repairs made: _____

Manometer Readings [56-7.8(a)(4)] twice per shift
(Required for all OSHA Class I Large & Small Projects)

1st Reading	Time	2nd Reading	Time

Work Stoppage Due to High Air [56-7.3(a)] note high sample result, location, time of work cessation, results of barrier/neg air inspections and repairs or required cleaning: _____

Final Inspection (to be documented by supervisor at completion of asbestos project)

No ACM Found Upon Teardown

Fill in GENERAL comments on routine progress on this project on the above date. Detail major problems and action taken, injuries, hiring, firing of personnel and any other occurrence which may affect the project. This log may be utilized as a legal document.

On Site, Signed In, Teardown, Signed Out Off Site

Visual Inspection by Project Monitor [56-9.1(d), 9.2(e)]

Project Monitor Name: _____ NYS DOL Certificate #: _____

Inspection Findings: _____

Project Monitor Signature: _____

Supervisor signature: [Signature]

INVOICE

Empire Building Diagnostics, Inc
2 Main St.
PO Box 412
Depew, NY 14043
(716) 685-4588

Invoice ID: 522524 REV
Invoice Date: 06-29-2012
Customer ID: Nat06
PO Number:
Job #: 212.099

To:
National Fuel
365 Mineral Springs Road
Buffalo, NY 14210

Job Location:
365 Mineral Springs Bldg 8
Soil Removal
West Seneca, NY

<u>Item</u>	<u>Description</u>	<u>Qty</u>	<u>Unit Price</u>	<u>Amount</u>
1	6/12/2012 - Break out and remove additional 4" of foundation.			
2	Labor-- Operator Hours	1.50		
3	Equipment - Excavator	1.50		
4	Waste Disposal	489.91		

Please Note: If this is a tax exempt or capital improvement project please provide the applicable exempt certificate and omit the sales tax. Thank you!

Amount Billed
Total Tax

Retainage Held

Amount Due

DATE DUE: 07-30-2012

THANK YOU FOR YOUR BUSINESS

14192507

NIAGARA FALLS LANDFILL
 56th Street & Niagara Falls Blvd
 Niagara Falls, NY 14304 (716)282-6381

202853
 EMPIRE BUILDING DIAGNOSTIC INC
 P O BOX 412
 DEPEW, NY 14043
 Contract: 4215128286

SITE	TICKET	GRID
58	482279	WEIGHMASTER
A500067 ALBERT S		
DATE IN	TIME IN	
8 June 2012	1:05 pm	
DATE OUT	TIME OUT	
8 June 2012	1:24 pm	
VEHICLE	ROLL OFF	
FAR222		
REFERENCE	ORIGIN	
575874	Inbound -NY-ERIE	

00 Gross Weight 61,980.00 lb
 Stored Tare Weight 24,180.00 lb
 Net Weight 37,800.00 lb

QTY	UNIT	DESCRIPTION	IB	5% IN	RATE	EXTENSION	TAX	TOTAL
18.90	TN	SW-SLAG						
1.00	LD	ENVIRONMENTAL FEE						
1.00	LD	FUEL RECOVERY FEE						
NATIONAL FUEL GAS								

NET AMOUNT
TENDERED
CHANGE
CHECK NO.

HAVE A NICE DAY

[Handwritten Signature]



REV 11/09

SIGNATURE

RS-F04

575894

If waste is asbestos waste, complete Sections I, II, III and IV
 If waste is **NOT** asbestos waste, complete Sections I, II and III

I. GENERATOR (Generator completes Ia-r)

a. Generator's US EPA ID Number		b. Manifest Document Number		c. Page 1 of	
d. Generator's Name and Location: National Fuel Gas 365 Mineral Springs Road Buffalo, NY 14210 Phone: (716) 807-3807			e. Generator's Mailing Address: National Fuel Gas 5955 New Taylor Road Orchard Park, NY 14 g. Phone:		
f. Owner of the generating facility differs from the generator, provide:					
h. Owner's Name:			i. Owner's Phone No.:		
j. Waste Profile #	k. Exp. Date	l. Waste Shipping Name and Description		m. Containers No.	n. Total Quantity
				Type	o. Unit Wt/Vol
A. 4215128286	5/7/2014	Coal Boiler Slag & Bottom Ash			

GENERATOR'S CERTIFICATION: I hereby certify that the above named material is not a hazardous waste as defined by 40 CFR 261 or any applicable state law, has been properly described, classified and packaged, and is in proper condition for transportation according to applicable regulations; AND, if this waste is a treatment residue of a previously restricted hazardous waste subject to the Land Disposal Restrictions. I certify and warrant that the waste has been treated in accordance with the requirements of 40 CFR 268 and is no longer a hazardous waste as defined by 40 CFR 261.

p. Generator Authorized Agent Name (Print)	q. Signature	r. Date
--	--------------	---------

II. TRANSPORTER (Generator completes IIa-b and Transporter completes IIc-e)

a. Transporter's Name and Address: National Transport 705-507-8844 Carmen M. Pariso # 292		
b. Phone:		
c. Driver Name (Print) John Smart	d. Signature <i>[Signature]</i>	e. Date 6-8-12

III. DESTINATION (Generator complete IIIa-c and Destination Site completes III d-g)

a. Disposal Facility and Site Address: Allen Waste Niagara Falls Landfill LLC 3600 Niagara Falls Boulevard Niagara Falls, NY 14304 716-285-3044	c. US EPA Number	d. Discrepancy Indication Space:
--	------------------	----------------------------------

I hereby certify that the above named material has been accepted and to the best of my knowledge the foregoing is true and accurate.

e. Name of Authorized Agent (Print) Al Smith	f. Signature <i>[Signature]</i>	g. Date 6-8-12
---	------------------------------------	-------------------

IV. ASBESTOS (Generator completes IVa-f and Operator complete IVg-i)

a. Operator's Name and Address:		c. Responsible Agency Name and Address:	
b. Phone:		d. Phone:	
e. Special Handling Instructions and Additional Information:			

f. Friable Non-Friable Both % Friable % Non-Friable

OPERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by the proper shipping name and are classified, packaged, marked and labeled/placarded, and are in all respects in proper condition for transport according to applicable international and national governmental regulations.

g. Operator's Name and Title (Print)	h. Signature	i. Date
--------------------------------------	--------------	---------

*Operator refers to the company which owns, leases, operates, controls, or supervises the facility being demolished or renovated, or the demolition or renovation operation or both.

14102480

NIAGARA FALLS LANDFILL
 56th Street & Niagara Falls Blvd
 Niagara Falls, NY 14304 (716)292-6881


202853
 EMPIRE BUILDING DIAGNOSTIC INC
 P O BOX 412
 DEPEW, NY 14043
 Contract: 4215128286

SITE	TICKET	GRID
5B	482252	
WEIGHMASTER		
PJS0000 PAM S		
DATE IN	TIME IN	
8 June 2012	11:13 am	
DATE OUT	TIME OUT	
8 June 2012	11:32 am	
VEHICLE	ROLL OFF	
PAR222		
REFERENCE	ORIGIN	
575893	Inbound -NY-ERIE	

00 Gross Weight 59,080.00 lb
 Stored Tare Weight 24,260.00 lb
 Net Weight 34,820.00 lb

QTY.	UNIT	DESCRIPTION	UNIT PRICE	EXTENSION	TAX	TOTAL
17.41	TN	SW-SLAB				
1.00	LD	ENVIRONMENTAL FEE				
1.00	LD	FUEL RECOVERY FEE				
NATIONAL FUEL GAS						

HAVE A NICE DAY




V 11/09

SIGNATURE

NET AMOUNT
TENDERED
CHANGE
CHECK NO.

RS-F04

575893

If waste is asbestos waste, complete Sections I, II, III and IV
 If waste is **NOT** asbestos waste, complete Sections I, II and III

I. GENERATOR (Generator completes Ia-r)

a. Generator's US EPA ID Number		b. Manifest Document Number		c. Page 1 of	
d. Generator's Name and Location: National Fuel Gas 365 Mineral Springs Road Buffalo, NY 14210			e. Generator's Mailing Address: National Fuel Gas 5055 New Taylor Road, Orchard Park, NY 14		
f. Phone: (716) 507-0501			g. Phone:		
If owner of the generating facility differs from the generator, provide:					
h. Owner's Name:			i. Owner's Phone No.:		
j. Waste Profile #	k. Exp. Date	l. Waste Shipping Name and Description	m. Containers No.	n. Total Quantity	o. Unit Wt/Vol
A. 4215128286	5/7/2014	Coal Boiler Slag & Bottom Ash	1	20	yds
B.					
C.					
GENERATOR'S CERTIFICATION: I hereby certify that the above named material is not a hazardous waste as defined by 40 CFR 261 or any applicable state law, has been properly described, classified and packaged, and is in proper condition for transportation according to applicable regulations; AND, if this waste is a treatment residue of a previously restricted hazardous waste subject to the Land Disposal Restrictions, I certify and warrant that the waste has been treated in accordance with the requirements of 40 CFR 268 and is no longer a hazardous waste as defined by 40 CFR 261.					
p. Generator Authorized Agent Name (Print)			q. Signature		r. Date

II. TRANSPORTER (Generator completes IIa-b and Transporter completes IIc-e)

a. Transporter's Name and Address: Hajnowski Transport Carmen Mo Pariso 222 383-597-9844		
b. Phone:		
c. Driver Name (Print) John Schrock		e. Date 6-8-12
d. Signature <i>John Schrock</i>		

III. DESTINATION (Generator complete IIIa-c and Destination Site completes IIId-g)

a. Disposal Facility and Site Address: Allied Waste Niagara Falls Landfill LLC 3600 Niagara Falls Boulevard Niagara Falls, NY 14304 716-285-3344		c. US EPA Number	d. Discrepancy Indication Space:
b. I hereby certify that the above named material has been accepted and to the best of my knowledge the foregoing is true and accurate.			
e. Name of Authorized Agent (Print) Claar		f. Signature <i>Brian Claar</i>	g. Date 6-8-12

IV. ASBESTOS (Generator completes IVa-f and Operator complete IVg-i)

a. Operator's Name and Address:		c. Responsible Agency Name and Address:	
b. Phone:		d. Phone:	
e. Special Handling Instructions and Additional Information:			
f. <input type="checkbox"/> Friable <input type="checkbox"/> Non-Friable <input type="checkbox"/> Both % Friable % Non-Friable			
OPERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by the proper shipping name and are classified, packaged, marked and labeled/placarded, and are in all respects in proper condition for transport according to applicable international and national governmental regulations.			
g. Operator's Name and Title (Print)		i. Date	
h. Signature		i. Date	
Operator refers to the company which owns, leases, operates, controls, or supervises the facility being demolished or renovated, or the demolition or renovation operation or both			

14132873

NIAGARA FALLS LANDFILL
56th Street & Niagara Falls Blvd
Niagara Falls, NY 14304 (716)282-6381

308253
EMPIRE BUILDING DIAGNOSTIC INC
P O BOX 412
DEPEN, NY 14043
Contract: 4210128286

SITE	TICKET	GRID
5B	48E643	
WEIGHMASTER		
PJ50000 PAM S		
DATE IN	TIME IN	
12 June 2012	7:46 am	
DATE OUT	TIME OUT	
12 June 2012	3:14 am	
VEHICLE	ROLL OFF	
PAR232		
REFERENCE	ORIGIN	
575876	Inbound -NY-ERIE	

00 Gross Weight 68,440.00 lb
Tare Weight 24,460.00 lb
Net Weight 43,980.00 lb

NATIONAL FUEL GAS

QTY	UNIT	DESCRIPTION	RATE	EXTENSION	TAX	TOTAL
1.00	TN	SW-SLAG				
1.00	LD	ENVIRONMENTAL FEE				
1.00	LD	FUEL RECOVERY FEE				

CONTINUED

HAVE A NICE DAY



V.11/09

SIGNATURE

NET AMOUNT
TENDERED
CHANGE
CHECK NO.

RS-F04

575896

If waste is asbestos waste, complete Sections I, II, III and IV
 If waste is **NOT** asbestos waste, complete Sections I, II and III

I. GENERATOR (Generator completes Ia-r)

a. Generator's US EPA ID Number		b. Manifest Document Number		c. Page 1 of	
d. Generator's Name and Location: National Fuel Gas 365 Mineral Springs Road Buffalo, NY 14210			e. Generator's Mailing Address: National Fuel Gas 6956 New Taylor Road Orchard Park, NY 14		
f. Phone: 716-871-5201			g. Phone:		
If owner of the generating facility differs from the generator, provide:					
h. Owner's Name:			i. Owner's Phone No.:		
j. Waste Profile #		k. Exp. Date	l. Waste Shipping Name and Description	m. Containers	
				n. Total Quantity	
				o. Unit Wt/Vol	
A. 4215128286		5/1/2014	Coal Bottom Slag & Bottom Ash	1 T 20 yds	
B.					
C.					

GENERATOR'S CERTIFICATION: I hereby certify that the above named material is not a hazardous waste as defined by 40 CFR 261 or any applicable state law, has been properly described, classified and packaged, and is in proper condition for transportation according to applicable regulations; AND, if this waste is a treatment residue of a previously restricted hazardous waste subject to the Land Disposal Restrictions, I certify and warrant that the waste has been treated in accordance with the requirements of 40 CFR 268 and is no longer a hazardous waste as defined by 40 CFR 261.

p. Generator Authorized Agent Name (Print)		q. Signature		r. Date	
--	--	--------------	--	---------	--

II. TRANSPORTER (Generator completes IIa-b and Transporter completes IIc-e)

a. Transporter's Name and Address: Hahnemann Transport 385-591-0244			CARMEN M. PARISO		232
b. Phone: 716-875-6168					
c. Driver Name (Print) L. P. H. H. H.		d. Signature		e. Date 6-12-12	

III. DESTINATION (Generator complete IIIa-c and Destination Site completes III d-g)

a. Disposal Facility and Site Address: Allied Waste Niagara Falls Landfill LLC 3600 Niagara Falls Boulevard Niagara Falls, NY 14304 716-286-3344		c. US EPA Number	d. Discrepancy Indication Space:		
b. I hereby certify that the above named material has been accepted and to the best of my knowledge the foregoing is true and accurate.					
e. Name of Authorized Agent (Print) Scott		f. Signature Kim Scott		g. Date 6/12/12	

IV. ASBESTOS (Generator completes IVa-f and Operator complete IVg-i)

a. Operator's Name and Address:			c. Responsible Agency Name and Address:		
b. Phone:			d. Phone:		
e. Special Handling Instructions and Additional Information:					
f. <input type="checkbox"/> Friable <input type="checkbox"/> Non-Friable <input type="checkbox"/> Both		% Friable		% Non-Friable	
OPERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by the proper shipping name and are classified, packaged, marked and labeled/placarded, and are in all respects in proper condition for transport according to applicable international and national governmental regulations.					
g. Operator's Name and Title (Print)			h. Signature		i. Date
*Operator refers to the company which owns, leases, operates, controls, or supervises the facility being demolished or renovated, or the demolition or renovation operation or both.					

4740441

683

NIAGARA FALLS LANDFILL
56th Street & Niagara Falls Blvd
Niagara Falls, NY 14304 (716)282-6381

202859
EMPIRE BUILDING DIAGNOSTIC INC
P O BOX 412
DEPEW, NY 14043
Contract: 4215128286

SITE 55	TICKET 452647	GRID
WEIGHMASTER PJ50000 PAM S		
DATE IN 12 June 2012		TIME IN 7:58 am
DATE OUT 12 June 2012		TIME OUT 3:24 am
VEHICLE PARC01		ROLL OFF
REFERENCE 575895	ORIGIN Inbound -NY-ERIE	

00 Gross Weight 67,840.00 lb
Tare Weight 26,020.00 lb
Net Weight 41,820.00 lb

NATIONAL FUEL GAS

QTY	UNIT	DESCRIPTION	CO.	PL	TN	RATE	EXTENSION	TAX	TOTAL
20.91	TN	SW-SLAG							
1.00	LD	ENVIRONMENTAL FEE							
1.00	LD	FUEL RECOVERY FEE							

HAVE A NICE DAY



7/11/09

SIGNATURE

[Handwritten Signature]

NET AMOUNT
TENDERED
CHANGE
CHECK NO.

RS-F04

575895

If waste is asbestos waste, complete Sections I, II, III and IV
 If waste is NOT asbestos waste, complete Sections I, II and III

I. GENERATOR (Generator completes Ia-r)

a. Generator's US EPA ID Number		b. Manifest Document Number		c. Page 1 of	
d. Generator's Name and Location: <i>National Fuel Gas 365 Mineral Springs Road Buffalo, NY 14210</i>			e. Generator's Mailing Address: <i>National Fuel Gas 6066 New Taylor Road Orchard Park, NY 14</i>		
f. Phone: <i>716-357-4201</i>			g. Phone:		
If owner of the generating facility differs from the generator, provide:					
h. Owner's Name:			i. Owner's Phone No.:		
j. Waste Profile #		k. Exp. Date	l. Waste Shipping Name and Description	m. Containers	
				n. Total Quantity	
				o. Unit Wt/Vol	
A. 4215128286		5/7/2014	Coal Boiler Slag & Bottom Ash	1	T 20 yds
B.					
C.					

GENERATOR'S CERTIFICATION: I hereby certify that the above named material is not a hazardous waste as defined by 40 CFR 261 or any applicable state law, has been properly described, classified and packaged, and is in proper condition for transportation according to applicable regulations; AND, if this waste is a treatment residue of a previously restricted hazardous waste subject to the Land Disposal Restrictions, I certify and warrant that the waste has been treated in accordance with the requirements of 40 CFR 268 and is no longer a hazardous waste as defined by 40 CFR 261.

p. Generator Authorized Agent Name (Print)	q. Signature	r. Date
--	--------------	---------

II. TRANSPORTER (Generator completes IIa-b and Transporter completes IIc-e)

a. Transporter's Name and Address: <i>Hightower Transport 585-591-0814</i>		
b. Phone: <i>716-875-6668</i>		
c. Driver Name (Print)	d. Signature	e. Date
	<i>CARMEN M. PARISO</i>	<i>6/12/12</i>

III. DESTINATION (Generator complete IIIa-c and Destination Site completes IIId-g)

a. Disposal Facility and Site Address: <i>Alfred Waste Niagara Falls Landfill LLC 5600 Niagara Falls Boulevard Niagara Falls, NY 14304 716-265-3344</i>	b. US EPA Number	c. Discrepancy Indication Space:
--	------------------	----------------------------------

I hereby certify that the above named material has been accepted and to the best of my knowledge the foregoing is true and accurate.

f. Name of Authorized Agent (Print)	g. Signature	h. Date
<i>Scott</i>	<i>KAM SCOTT</i>	<i>6/12/12</i>

IV. ASBESTOS (Generator completes IVa-f and Operator complete IVg-i)

a. Operator's Name and Address:	b. Responsible Agency Name and Address:
b. Phone:	d. Phone:
e. Special Handling Instructions and Additional Information:	

f. Friable Non-Friable Both % Friable % Non-Friable

OPERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by the proper shipping name and are classified, packaged, marked and labeled/placarded, and are in all respects in proper condition for transport according to applicable international and national governmental regulations.

g. Operator's Name and Title (Print)	h. Signature	i. Date
--------------------------------------	--------------	---------

*Operator refers to the company which owns, leases, operates, controls, or supervises the facility being demolished or renovated, or the demolition or renovation operation or both.

14102920

NIAGARA FALLS LANDFILL
 56th Street & Niagara Falls Blvd
 Niagara Falls, NY 14304 (716)282-6381

202853
 EMPIRE BUILDING DIAGNOSTIC INC
 P O BOX 412
 DEPEW, NY 14043
 Contract: 4215128286

SITE 58	TICKET 482690	GRID
WEIGHMASTER FJS0000 PAM 5		
DATE IN 12 June 2012		TIME IN 9:42 am
DATE OUT 12 June 2012		TIME OUT 10:08 am
VEHICLE PAR232		ROLL OFF
REFERENCE 575896	ORIGIN Inbound -NY-ERIE	

00 Gross Weight 69,440.00 lb
 Tare Weight 24,320.00 lb
 Net Weight 45,120.00 lb

NATIONAL FUEL GAS

QTY	UNIT	DESCRIPTION	22.56 TN	RATE	EXTENSION	TAX	TOTAL
22.56	TN	SW-SLAG					
1.00	LD	ENVIRONMENTAL FEE					
1.00	LD	FUEL RECOVERY FEE					

HAVE A NICE DAY



11/09

SIGNATURE

NET AMOUNT
TENDERED
CHANGE
CHECK NO.

RS.F04

575898

If waste is asbestos waste, complete Sections I, II, III and IV
 If waste is **NOT** asbestos waste, complete Sections I, II and III

I. GENERATOR (Generator completes Ia-r)

a. Generator's US EPA ID Number		b. Manifest Document Number		c. Page 1 of	
d. Generator's Name and Location: <i>National Fuel Gas 365 Mineral Springs Road Buffalo, NY 14210</i>			e. Generator's Mailing Address: <i>National Fuel Gas 5365 New Taylor Road Orchard Park, NY 14</i>		
f. Phone: <i>716-897-3907</i>			g. Phone:		
If owner of the generating facility differs from the generator, provide:					
h. Owner's Name:			i. Owner's Phone No.:		
j. Waste Profile #	k. Exp. Date	l. Waste Shipping Name and Description	m. Containers No.	n. Total Quantity	o. Unit Wt/Vol
<i>A. 4215128286</i>	<i>5/1/2014</i>	<i>Coal Boiler Slag & Bottom Ash</i>	<i>1</i>	<i>20</i>	<i>SPK</i>
<i>B.</i>					
<i>C.</i>					

GENERATOR'S CERTIFICATION: I hereby certify that the above named material is not a hazardous waste as defined by 40 CFR 261 or any applicable state law, has been properly described, classified and packaged, and is in proper condition for transportation according to applicable regulations; AND, if this waste is a treatment residue of a previously restricted hazardous waste subject to the Land Disposal Restrictions. I certify and warrant that the waste has been treated in accordance with the requirements of 40 CFR 268 and is no longer a hazardous waste as defined by 40 CFR 261.

p. Generator Authorized Agent Name (Print)	q. Signature	r. Date
--	--------------	---------

II. TRANSPORTER (Generator completes IIa-b and Transporter completes IIc-e)

a. Transporter's Name and Address: <i>Highway Transport 305-591-0844</i>			b. Phone: <i>716-875-6168</i>		
c. Driver Name (Print)	d. Signature	e. Date			

III. DESTINATION (Generator complete IIIa-c and Destination Site completes III d-g)

a. Disposal Facility and Site Address: <i>Allied Waste Niagara Falls Landfill LLC 5600 Niagara Falls Boulevard Niagara Falls, NY 14304 716-285-3344</i>		b. US EPA Number	c. Discrepancy Indication Space:
I hereby certify that the above named material has been accepted and to the best of my knowledge the foregoing is true and accurate.			
e. Name of Authorized Agent (Print) <i>Scott</i>	f. Signature <i>Kam Scott</i>	g. Date <i>6/12/12</i>	

IV. ASBESTOS (Generator completes IVa-f and Operator complete IVg-i)

a. Operator's Name and Address:		c. Responsible Agency Name and Address:	
b. Phone:		d. Phone:	
e. Special Handling Instructions and Additional Information:			

f. Friable Non-Friable Both % Friable % Non-Friable

OPERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by the proper shipping name and are classified, packaged, marked and labeled/placarded, and are in all respects in proper condition for transport according to applicable international and national governmental regulations.

g. Operator's Name and Title (Print)	h. Signature	i. Date
--------------------------------------	--------------	---------

*Operator refers to the company which owns, leases, operates, controls, or supervises the facility being demolished or renovated, or the demolition or renovation operation or both

NIAGARA FALLS LANDFILL
 56th Street & Niagara Falls Blvd
 Niagara Falls, NY 14304 (716)282-6981

802853
 EMPIRE BUILDING DIAGNOSTIC INC
 P.O. BOX 412
 DEPEW, NY 14043
 Contract: 4213128286

SITE 5B	TICKET 482693	GRID
WEIGHMASTER PJS0000 PAM S		
DATE IN 12 June 2012		TIME IN 9:58 am
DATE OUT 12 June 2012		TIME OUT 10:18 am
VEHICLE PAR201		ROLL OFF
REFERENCE 575297	ORIGIN Inbound -NY-ERIE	

00 Gross Weight 69,200.00 lb
 Tare Weight 25,940.00 lb
 Net Weight 43,260.00 lb

NATIONAL FUEL GAS

QTY	UNIT	DESCRIPTION	RATE	EXTENSION	TAX	TOTAL
21.63	TN	SW-SLAB				
1.00	LD	ENVIRONMENTAL FEE				
1.00	LD	FUEL RECOVERY FEE				

NET AMOUNT
TENDERED
CHANGE
CHECK NO.

HAVE A NICE DAY



SIGNATURE

[Handwritten Signature]

RS-FC

575897

If waste is asbestos waste, complete Sections I, II, III and IV
 If waste is **NOT** asbestos waste, complete Sections I, II and III

I. GENERATOR (Generator completes Ia-r)

a. Generator's US EPA ID Number		b. Manifest Document Number		c. Page 1 of		
d. Generator's Name and Location: National Fuel Gas 305 Mineral Springs Road Buffalo, NY 14210			e. Generator's Mailing Address: National Fuel Gas 5855 New Taylor Road Orchard Park, NY 14			
f. Phone: 716-891-5001			g. Phone:			
If owner of the generating facility differs from the generator, provide:						
h. Owner's Name:			i. Owner's Phone No.:			
j. Waste Profile #	k. Exp. Date	l. Waste Shipping Name and Description	m. Containers		n. Total Quantity	o. Unit W/Vol
			No.	Type		
A 4215128286	5/7/2014	Coal Boiler Slag & BOTTOM ASH	1	T	20	yds
B						
C						

GENERATOR'S CERTIFICATION: I hereby certify that the above named material is not a hazardous waste as defined by 40 CFR 261 or any applicable state law, has been properly described, classified and packaged, and is in proper condition for transportation according to applicable regulations; AND, if this waste is a treatment residue of a previously restricted hazardous waste subject to the Land Disposal Restrictions. I certify and warrant that the waste has been treated in accordance with the requirements of 40 CFR 268 and is no longer a hazardous waste as defined by 40 CFR 261.

p. Generator Authorized Agent Name (Print)	q. Signature	r. Date
--	--------------	---------

II. TRANSPORTER (Generator completes IIa-b and Transporter completes IIc-e)

a. Transporter's Name and Address: Hahnemann Transport 385-591-0844			CARMEN M. PARISO 716-875-6168		
b. Phone:			6-12-12		
c. Driver Name (Print)		d. Signature	e. Date		

III. DESTINATION (Generator complete IIIa-c and Destination Site completes III d-g)

a. Disposal Facility and Site Address: Solid Waste Niagara Falls Landfill LLC 5600 Niagara Falls Boulevard Niagara Falls, NY 14304 716-286-3344		c. US EPA Number	d. Discrepancy Indication Space:
b. I hereby certify that the above named material has been accepted and to the best of my knowledge the foregoing is true and accurate.			
e. Name of Authorized Agent (Print) SCOTT		f. Signature KAMICHTI	g. Date 6/12/12

IV. ASBESTOS (Generator completes IVa-f and Operator complete IVg-i)

a. Operator's Name and Address:		c. Responsible Agency Name and Address:	
b. Phone:		d. Phone:	
e. Special Handling Instructions and Additional Information:			
f. <input type="checkbox"/> Friable <input type="checkbox"/> Non-Friable <input type="checkbox"/> Both % Friable % Non-Friable			
OPERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by the proper shipping name and are classified, packaged, marked and labeled/placarded, and are in all respects in proper condition for transport according to applicable international and national governmental regulations.			
g. Operator's Name and Title (Print)		h. Signature	
		i. Date	
*Operator refers to the company which owns, leases, operates, controls, or supervises the facility being demolished or renovated, or the demolition or renovation operation or both			

14102004

NIAGARA FALLS LANDFILL
56th Street & Niagara Falls Blvd
Niagara Falls, NY 14304 (716)292-6381

209953
EMPIRE BUILDING DIAGNOSTIC INC
P O BOX 412
DEPEW, NY 14043
Contract: 4215128286

SITE 5B	TICKET 482734	GRID
WEIGHMASTER PJS0000 PAM 5		
DATE IN 12 June 2012		TIME IN 11:32 am
DATE OUT 12 June 2012		TIME OUT 12:05 pm
VEHICLE FAR232		ROLL OFF
REFERENCE 575899	ORIGIN Inbound -NY-ERIE	

00 Gross Weight 67,820.00 lb
Tare Weight 24,380.00 lb
Net Weight 43,440.00 lb

NATIONAL FUEL GAS

QTY	UNIT	DESCRIPTION	21.72 TN	RATE	EXTENSION	TAX	TOTAL
21.72	TN	SW-SLAG					
1.00	LD	ENVIRONMENTAL FEE					
1.00	LD	FUEL RECOVERY FEE					

NET AMOUNT
TENDERED
CHANGE
CHECK NO.

HAVE A NICE DAY



SIGNATURE

[Handwritten Signature]

RS-F04



NON-HAZARDOUS SPECIAL WASTE & ASBESTOS MANIFEST

575899

If waste is asbestos waste, complete Sections I, II, III and IV
If waste is NOT asbestos waste, complete Sections I, II and III

attor Barb

I. GENERATOR (Generator completes Ia-r)

a. Generator's US EPA ID Number
b. Manifest Document Number
c. Page 1 of
d. Generator's Name and Location: National Fuel Gas
e. Generator's Mailing Address: National Fuel Gas
f. Phone:
g. Phone:
h. Owner's Name:
i. Owner's Phone No.:

Table with columns: Waste Profile #, Exp. Date, Waste Shipping Name and Description, m. Containers No., m. Containers Type, n. Total Quantity, o. Unit Wt/Vol. Row A: 4215128286, 5/7/2014 Coal Boiler Slag & Bottom Ash, 1 T, 20, SK.

GENERATOR'S CERTIFICATION: I hereby certify that the above named material is not a hazardous waste as defined by 40 CFR 261 or any applicable state law, has been properly described, classified and packaged, and is in proper condition for transportation according to applicable regulations; AND, if this waste is a treatment residue of a previously restricted hazardous waste subject to the Land Disposal Restrictions. I certify and warrant that the waste has been treated in accordance with the requirements of 40 CFR 268 and is no longer a hazardous waste as defined by 40 CFR 261.

p. Generator Authorized Agent Name (Print): John Boyer
q. Signature
r. Date: 6-12-12

II. TRANSPORTER (Generator completes IIa-b and Transporter completes IIc-e)

a. Transporter's Name and Address: Hojnowski Transport
b. Phone:
c. Driver Name (Print): LAURA HOLLER
d. Signature
e. Date: 6-12-12

III. DESTINATION (Generator complete IIIa-c and Destination Site completes IIId-g)

a. Disposal Facility and Site Address: Allied Waste Niagara Falls Landfill LLC
b. US EPA Number
c. Discrepancy Indication Space:

I hereby certify that the above named material has been accepted and to the best of my knowledge the foregoing is true and accurate.
e. Name of Authorized Agent (Print)
f. Signature
g. Date: 6-12-12

IV. ASBESTOS (Generator completes IVa-f and Operator complete IVg-i)

a. Operator's Name and Address:
b. Phone:
c. Responsible Agency Name and Address:
d. Phone:
e. Special Handling Instructions and Additional Information:

Friable Non-Friable Both % Friable % Non-Friable

OPERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by the proper shipping name and are classified, packaged, marked and labeled/placarded, and are in all respects in proper condition for transport according to applicable international and national governmental regulations.

g. Operator's Name and Title (Print)
h. Signature
i. Date
*Operator refers to the company which owns, leases, operates, controls, or supervises the facility being demolished or renovated, or the demolition or renovation operation or both

NIAGARA FALLS LANDFILL
 56th Street & Niagara Falls Blvd
 Niagara Falls, NY 14304 (716)282-6381

202858
 EMPIRE BUILDING DIAGNOSTIC INC
 P O BOX 412
 DEPEW, NY 14043
 Contract: 4215128286

SITE 58	TICKET 482735	GRID
WEIGHMASTER		
PJ50000 PAM S		
DATE IN 12 June 2012		TIME IN 11:48 am
DATE OUT 12 June 2012		TIME OUT 12:17 pm
VEHICLE PAR201		ROLL OFF
REFERENCE 575900	ORIGIN Inbound -NY-ERIE	

00 Gross Weight 71,760.00 lb
 Tare Weight 26,040.00 lb
 Net Weight 45,720.00 lb

NATIONAL FUEL GAS

QTY	UNIT	DESCRIPTION	RE. BS TN	RATE	EXTENSION	TAX	TOTAL
22.86	TN	SW-SLAG					
1.00	LD	ENVIRONMENTAL FEE					
1.00	LD	FUEL RECOVERY FEE					

NET AMOUNT
TENDERED
CHANGE
CHECK NO.

HAVE A NICE DAY



SIGNATURE [Signature]

575900

If waste is asbestos waste, complete Sections I, II, III and IV
 If waste is **NOT** asbestos waste, complete Sections I, II and III

I. GENERATOR (Generator completes Ia-r)

a. Generator's US EPA ID Number		b. Manifest Document Number		c. Page 1 of	
d. Generator's Name and Location: <i>National Fuel Gas 365 Mineral Springs Road Buffalo, NY 14210</i>			e. Generator's Mailing Address: <i>National Fuel Gas 655 New Taylor Road Orchard Park, NY 14</i>		
f. Phone: <i>716-891-0001</i>			g. Phone:		
If owner of the generating facility differs from the generator, provide:					
h. Owner's Name:			i. Owner's Phone No.:		
j. Waste Profile #	k. Exp. Date	l. Waste Shipping Name and Description	m. Containers No.	n. Total Quantity	o. Unit W/Vol
<i>A 4215128286</i>	<i>5/1/2014</i>	<i>Cool Boiler Slag & Bottom Ash</i>	<i>1</i>	<i>20</i>	<i>yds</i>

GENERATOR'S CERTIFICATION: I hereby certify that the above named material is not a hazardous waste as defined by 40 CFR 261 or any applicable state law, has been properly described, classified and packaged, and is in proper condition for transportation according to applicable regulations; AND, if this waste is a treatment residue of a previously restricted hazardous waste, subject to the Land Disposal Restrictions. I certify and warrant that the waste has been treated in accordance with the requirements of 40 CFR 268 and is no longer a hazardous waste as defined by 40 CFR 261.

p. Generator Authorized Agent Name (Print)	q. Signature	r. Date
--	--------------	---------

II. TRANSPORTER (Generator completes IIa-b and Transporter completes IIc-e)

a. Transporter's Name and Address: <i>National Fuel Gas 585-591-0811</i>			CARMEN M. PARISO		
b. Phone:			716-875-6168		
c. Driver Name (Print)		d. Signature	e. Date		

III. DESTINATION (Generator complete IIIa-c and Destination Site completes III d-g)

a. Disposal Facility and Site Address: <i>Allied Waste Niagara Falls Landfill LLC 5600 Niagara Falls Boulevard Niagara Falls, NY 14304 716-266-3344</i>	c. US EPA Number	d. Discrepancy Indication Space:
--	------------------	----------------------------------

I hereby certify that the above named material has been accepted and to the best of my knowledge the foregoing is true and accurate.

e. Name of Authorized Agent (Print)	f. Signature	g. Date
-------------------------------------	--------------	---------

IV. ASBESTOS (Generator completes IVa-f and Operator complete IVg-i)

a. Operator's Name and Address:	c. Responsible Agency Name and Address:
b. Phone:	d. Phone:
e. Special Handling Instructions and Additional Information:	

f. Friable Non-Friable Both % Friable % Non-Friable

OPERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by the proper shipping name and are classified, packaged, marked and labeled/placarded, and are in all respects in proper condition for transport according to applicable international and national governmental regulations.

g. Operator's Name and Title (Print)	h. Signature	i. Date
--------------------------------------	--------------	---------

*Operator refers to the company which owns, leases, operates, controls, or supervises the facility being demolished or renovated, or the demolition or renovation operation or both

14102000

NIAGARA FALLS LANDFILL
56th Street & Niagara Falls Blvd
Niagara Falls, NY 14304 (716)282-6381

202853
EMPIRE BUILDING DIAGNOSTIC INC
P O BOX 412
DEPEW, NY 14043
Contract: 4215128286

SITE	TICKET	GRID
5B	481872	
WEIGHMASTER		
PJ50000 PAM S		
DATE IN	TIME IN	
6 June 2012	11:22 am	
DATE OUT	TIME OUT	
6 June 2012	11:48 am	
VEHICLE	ROLL OFF	
HQJ01		
REFERENCE	ORIGIN	
575701	INBOUND -NY-ERIE	

00	Gross Weight	95,400.00	lb
	Tare Weight	38,440.00	lb
	Net Weight	56,960.00	lb

NATIONAL FUEL GAS

QTY	UNIT	DESCRIPTION	ES	HS	N	RATE	EXTENSION	TAX	TOTAL
28.48	TN	SW-SLAB							
1.00	LD	ENVIRONMENTAL FEE							
1.00	LD	FUEL RECOVERY FEE							

NET AMOUNT
TENDERED
CHANGE
CHECK NO.

HAVE A NICE DAY

R. Hogan



REV 11/09

SIGNATURE

RS-F04

575701

If waste is asbestos waste, complete Sections I, II, III and IV
 If waste is **NOT** asbestos waste, complete Sections I, II and III

I. GENERATOR (Generator completes Ia-r)

a. Generator's US EPA ID Number		b. Manifest Document Number		c. Page 1 of	
d. Generator's Name and Location: <i>National Fuel Gas 365 Mineral Springs Road Buffalo, NY 14210</i>			e. Generator's Mailing Address: <i>National Fuel Gas 5955 New Taylor Road Orchard Park, NY 14</i>		
f. Phone: <i>(716) 801-5000</i>			g. Phone:		
h. If owner of the generating facility differs from the generator, provide:					
i. Owner's Name:			i. Owner's Phone No.:		
j. Waste Profile #	k. Exp. Date	l. Waste Shipping Name and Description	m. Containers No.	n. Total Quantity	o. Unit Wt/Vol
<i>A 4215128286</i>	<i>5/7/2014</i>	<i>Coal Boiler Slag & Bottom Ash</i>	<i>139</i>	<i>1 T</i>	<i>60 yds</i>
<i>B</i>					
<i>C</i>					
GENERATOR'S CERTIFICATION: I hereby certify that the above named material is not a hazardous waste as defined by 40 CFR 261 or any applicable state law, has been properly described, classified and packaged, and is in proper condition for transportation according to applicable regulations; AND, if this waste is a treatment residue of a previously restricted hazardous waste subject to the Land Disposal Restrictions. I certify and warrant that the waste has been treated in accordance with the requirements of 40 CFR 268 and is no longer a hazardous waste as defined by 40 CFR 261.					
p. Generator Authorized Agent Name (Print) <i>John Bogner</i>		q. Signature <i>[Signature]</i>		r. Date	

II. TRANSPORTER (Generator completes IIa-b and Transporter completes IIc-e)

a. Transporter's Name and Address: <i>Empire Building Diagnostics Inc. 716-685-1588</i>			b. Phone: <i>585-591-0844</i>		
c. Driver Name (Print) <i>Bob Hogan</i>			d. Signature <i>[Signature]</i>		e. Date <i>6-6-12</i>

III. DESTINATION (Generator complete IIIa-c and Destination Site completes III d-g)

a. Disposal Facility and Site Address: <i>Allied Waste Niagara Falls Landfill LLC 5600 Niagara Falls Boulevard Niagara Falls, NY 14304 716-286-3344</i>		c. US EPA Number	d. Discrepancy Indication Space:
b. I hereby certify that the above named material has been accepted and to the best of my knowledge the foregoing is true and accurate.			
e. Name of Authorized Agent (Print) <i>Clair</i>		f. Signature <i>[Signature]</i>	g. Date <i>6-6-12</i>

IV. ASBESTOS (Generator completes IVa-f and Operator complete IVg-i)

a. Operator's Name and Address:		c. Responsible Agency Name and Address:	
b. Phone:		d. Phone:	
e. Special Handling Instructions and Additional Information:			
f. <input type="checkbox"/> Friable <input type="checkbox"/> Non-Friable <input type="checkbox"/> Both % Friable % Non-Friable			
OPERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by the proper shipping name and are classified, packaged, marked and labeled/placarded, and are in all respects in proper condition for transport according to applicable international and national governmental regulations.			
g. Operator's Name and Title (Print)		i. Date	
h. Signature		i. Date	
*Operator refers to the company which owns, leases, operates, controls, or supervises the facility being demolished or renovated, or the demolition or renovation operation or both			

14192131

NIAGARA FALLS LANDFILL
 56th Street & Niagara Falls Blvd
 Niagara Falls, NY 14304 (716)282-6381

202853
 EMPIRE BUILDING DIAGNOSTIC INC
 P O BOX 412
 DEPEW, NY 14043
 Contract: 4215128286

SITE	TICKET	GRID
5B	481907	
WEIGHMASTER		
PJS0000 PAM S		
DATE IN	TIME IN	
6 June 2012	1:12 pm	
DATE OUT	TIME OUT	
6 June 2012	1:42 pm	
VEHICLE	ROLL OFF	
HQJD1		
REFERENCE	ORIGIN	
575702	Inbound -NY-ERIE	

QTY.	UNIT	DESCRIPTION	RATE	EXTENSION	TAX	TOTAL
00		Gross Weight		92,280.00		1b
		Tare Weight		38,100.00		1b
		Net Weight		55,180.00		1b
27.59	TN	SW-SLAG				
1.00	LD	ENVIRONMENTAL FEE				
1.00	LD	FUEL RECOVERY FEE				
NATIONAL FUEL GAS						

NET AMOUNT
TENDERED
CHANGE
CHECK NO.

HAVE A NICE DAY

R. V.



575702

If waste is asbestos waste, complete Sections I, II, III and IV
 If waste is **NOT** asbestos waste, complete Sections I, II and III

I. GENERATOR (Generator completes Ia-r)

a. Generator's US EPA ID Number		b. Manifest Document Number		c. Page 1 of										
d. Generator's Name and Location: National Fuel Gas 365 Mineral Springs Road Buffalo, NY 14210			e. Generator's Mailing Address: National Fuel Gas 5465 New Taylor Road Orchard Park, NY 14127											
f. Phone: (716) 517-0900			g. Phone:											
h. Owner's Name:			i. Owner's Phone No.:											
j. Waste Profile #		k. Exp. Date	l. Waste Shipping Name and Description		m. Containers									
A. 4215128286		5/7/2014	Coal Boiler Slag & Bottom Ash		<table border="1"> <tr> <th>No.</th> <th>Type</th> <th>n. Total Quantity</th> <th>o. Unit Wt/Vol</th> </tr> <tr> <td>1</td> <td>T</td> <td>60</td> <td>yds</td> </tr> </table>		No.	Type	n. Total Quantity	o. Unit Wt/Vol	1	T	60	yds
No.	Type	n. Total Quantity	o. Unit Wt/Vol											
1	T	60	yds											
GENERATOR'S CERTIFICATION: I hereby certify that the above named material is not a hazardous waste as defined by 40 CFR 261 or any applicable state law, has been properly described, classified and packaged, and is in proper condition for transportation according to applicable regulations; AND, if this waste is a treatment residue of a previously restricted hazardous waste subject to the Land Disposal Restrictions. I certify and warrant that the waste has been treated in accordance with the requirements of 40 CFR 268 and is no longer a hazardous waste as defined by 40 CFR 261.														
p. Generator Authorized Agent Name (Print) John Bogura			q. Signature <i>[Signature]</i>		r. Date 6/6/12									

II. TRANSPORTER (Generator completes IIa-b and Transporter completes IIc-e)

a. Transporter's Name and Address: Empire Building Diagnostics Inc. 716-685-4588			Atynowski Transport 1042 French Rd. Darien NY 14011 585-591-0844		
b. Phone:			c. Phone:		
d. Driver Name (Print) Robert E. Hogan		e. Signature <i>[Signature]</i>		f. Date 6/6/12	

III. DESTINATION (Generator complete IIIa-c and Destination Site completes IIId-g)

a. Disposal Facility and Site Address: Allied Waste Niagara Falls Landfill LLC 5600 Niagara Falls Boulevard Niagara Falls, NY 14304 716-286-3344		b. US EPA Number	c. Discrepancy Indication Space:
I hereby certify that the above named material has been accepted and to the best of my knowledge the foregoing is true and accurate.			
d. Name of Authorized Agent (Print) SCOTT		e. Signature <i>[Signature]</i>	
f. Date 6/6/12		g. Date	

IV. ASBESTOS (Generator completes IVa-f and Operator complete IVg-i)

a. Operator's Name and Address:		c. Responsible Agency Name and Address:	
b. Phone:		d. Phone:	
e. Special Handling Instructions and Additional Information:			
f. <input type="checkbox"/> Friable <input type="checkbox"/> Non-Friable <input type="checkbox"/> Both % Friable % Non-Friable			
OPERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by the proper shipping name and are classified, packaged, marked and labeled/placarded, and are in all respects in proper condition for transport according to applicable international and national governmental regulations.			
g. Operator's Name and Title (Print)		h. Signature	
i. Date		i. Date	
*Operator refers to the company which owns, leases, operates, controls, or supervises the facility being demolished or renovated, or the demolition or renovation operation or both			

14192160

NIAGARA FALLS LANDFILL
56th Street & Niagara Falls Blvd
Niagara Falls, NY 14204 (716)282-6381

202253
EMPIRE BUILDING DIAGNOSTIC INC
P O BOX 412
DEPEW, NY 14043
Contract: 4215128286

SITE	TICKET	GRID
5B	481944	
WEIGHMASTER		
AS00067 ALBERT S		
DATE IN	TIME IN	
6 June 2012	3:22 pm	
DATE OUT	TIME OUT	
6 June 2012	3:51 pm	
VEHICLE	ROLL OFF	
HQJ01		
REFERENCE	ORIGIN	
575699	Inbound -NY-ERIE	

00 Gross Weight 102,360.00 lb
Tare Weight 38,180.00 lb
Net Weight 64,180.00 lb

QTY	UNIT	DESCRIPTION	SE	US	IN	RATE	EXTENSION	TAX	TOTAL
32.07	TN	SW-SLAG							
1.00	LD	ENVIRONMENTAL FEE							
1.00	LD	FUEL RECOVERY FEE							

HAVE A NICE DAY



REV 11/09

SIGNATURE

R. A.

NET AMOUNT
TENDERED
CHANGE
CHECK NO.

RS-F04

575699

If waste is asbestos waste, complete Sections I, II, III and IV
 If waste is NOT asbestos waste, complete Sections I, II and III

I. GENERATOR (Generator completes Ia-r)

a. Generator's US EPA ID Number		b. Manifest Document Number		c. Page 1 of	
d. Generator's Name and Location: <i>National Fuel Gas 365 Mineral Springs Road Buffalo, NY 14210</i>			e. Generator's Mailing Address: <i>National Fuel Gas 5855 New Taylor Road Orchard Park, NY 14127</i>		
f. Phone: <i>(716) 685-7588</i>			g. Phone:		
If owner of the generating facility differs from the generator, provide:					
h. Owner's Name:			i. Owner's Phone No.:		
j. Waste Profile #	k. Exp. Date	l. Waste Shipping Name and Description		m. Containers No.	n. Total Quantity
				Type	o. Unit Wt/Vol
<i>A. 4215128280</i>	<i>5/7/2014</i>	<i>Coal Boiler Slag & Bottom Ash</i>			
<i>B.</i>					
<i>C.</i>					
GENERATOR'S CERTIFICATION: I hereby certify that the above named material is not a hazardous waste as defined by 40 CFR 261 or any applicable state law, has been properly described, classified and packaged, and is in proper condition for transportation according to applicable regulations; AND, if this waste is a treatment residue of a previously restricted hazardous waste subject to the Land Disposal Restrictions. I certify and warrant that the waste has been treated in accordance with the requirements of 40 CFR 268 and is no longer a hazardous waste as defined by 40 CFR 261.					
p. Generator Authorized Agent Name (Print) <i>John Deane</i>			q. Signature <i>[Signature]</i>		r. Date <i>6-6-12</i>

II. TRANSPORTER (Generator completes IIa-b and Transporter completes IIc-e)

a. Transporter's Name and Address: <i>Empire Building Diagnostics Inc. 1042 French Rd. Athens, GA 30611</i>			b. Phone: <i>585-591-0844</i>		
c. Driver Name (Print) <i>Robert Hogan</i>			d. Signature <i>[Signature]</i>		e. Date <i>6/6/12</i>

III. DESTINATION (Generator complete IIIa-c and Destination Site completes III d-g)

a. Disposal Facility and Site Address: <i>Allied Waste Niagara Falls Landfill LLC 5600 Niagara Falls Boulevard Niagara Falls, NY 14304 716-285-3344</i>		c. US EPA Number	d. Discrepancy Indication Space:
b. I hereby certify that the above named material has been accepted and to the best of my knowledge the foregoing is true and accurate.			
e. Name of Authorized Agent (Print) <i>ATM</i>		f. Signature <i>[Signature]</i>	g. Date <i>6-6-12</i>

IV. ASBESTOS (Generator completes IVa-f and Operator complete IVg-i)

a. Operator's Name and Address:		c. Responsible Agency Name and Address:	
b. Phone:		d. Phone:	
e. Special Handling Instructions and Additional Information:			
f. <input type="checkbox"/> Friable <input type="checkbox"/> Non-Friable <input type="checkbox"/> Both % Friable % Non-Friable			
OPERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by the proper shipping name and are classified, packaged, marked and labeled/placarded, and are in all respects in proper condition for transport according to applicable international and national governmental regulations.			
g. Operator's Name and Title (Print)		h. Signature	
		i. Date	
*Operator refers to the company which owns, leases, operates, controls, or supervises the facility being demolished or renovated, or the demolition or renovation operation or both			

14192235

NIAGARA FALLS LANDFILL
 56th Street & Niagara Falls Blvd
 Niagara Falls, NY 14304 (716)282-6381

202553
 EMPIRE BUILDING DIAGNOSTIC INC
 P O BOX 412
 DEPEW, NY 14043
 Contract: 4215128286

SITE	TICKET	GRID
5B	482007	
WEIGHMASTER		
PJ50000 PAM 5		
DATE IN	TIME IN	
7 June 2012	8:26 am	
DATE OUT	TIME OUT	
7 June 2012	8:57 am	
VEHICLE	ROLL OFF	
H0J01		
REFERENCE	ORIGIN	
575700	INBOUND	NY-ERIE

00 Gross Weight 103,640.00 lb
 Tare Weight 38,320.00 lb
 Net Weight 65,320.00 lb

NATIONAL FUEL GAS

QTY	UNIT	DESCRIPTION	SP	GS	TA	RATE	EXTENSION	TAX	TOTAL
92.66	TN	SW-SLAB							
1.00	LD	ENVIRONMENTAL FEE							
1.00	LD	FUEL RECOVERY FEE							

NET AMOUNT
TENDERED
CHANGE
CHECK NO.

HAVE A NICE DAY

R.V.

SIGNATURE



575700

If waste is asbestos waste, complete Sections I, II, III and IV
 If waste is **NOT** asbestos waste, complete Sections I, II and III

I. GENERATOR (Generator completes Ia-r)

a. Generator's US EPA ID Number		b. Manifest Document Number		c. Page 1 of		
d. Generator's Name and Location: <i>National Fuel Gas 365 Mineral Springs Road Buffalo, NY 14210</i>			e. Generator's Mailing Address: <i>National Fuel Gas 5955 New Taylor Road Orchard Park, NY 14</i>			
f. Phone: <i>(716) 871-5000</i>			g. Phone:			
If owner of the generating facility differs from the generator, provide:						
h. Owner's Name:			i. Owner's Phone No.:			
j. Waste Profile #		k. Exp. Date	l. Waste Shipping Name and Description	m. Containers No.	n. Total Quantity	o. Unit Wt/Vol
A. 4215128286		5/7/2014	Coal Boiler Slag & Bottom Ash	129	60	yds
B.				1	T	
C.						
GENERATOR'S CERTIFICATION: I hereby certify that the above named material is not a hazardous waste as defined by 40 CFR 261 or any applicable state law, has been properly described, classified and packaged, and is in proper condition for transportation according to applicable regulations; AND, if this waste is a treatment residue of a previously restricted hazardous waste subject to the Land Disposal Restrictions. I certify and warrant that the waste has been treated in accordance with the requirements of 40 CFR 268 and is no longer a hazardous waste as defined by 40 CFR 261.						
p. Generator Authorized Agent Name (Print)		q. Signature		r. Date		

II. TRANSPORTER (Generator completes IIa-b and Transporter completes IIc-e)

a. Transporter's Name and Address: <i>Empire Building Diagnostics Inc. 716-685-1588</i>			<i>Hojmanski Transport 139 1042 French Rd. Athens, NY 14011 585-591-0844</i>		
b. Phone:					
c. Driver Name (Print) <i>Robert Hogan</i>		d. Signature <i>Robert Hogan</i>		e. Date <i>6/7/12</i>	

III. DESTINATION (Generator complete IIIa-c and Destination Site completes III d-g)

a. Disposal Facility and Site Address: <i>Allied Waste Niagara Falls Landfill LLC 5600 Niagara Falls Boulevard Niagara Falls, NY 14304 716-285-3344</i>		c. US EPA Number	d. Discrepancy Indication Space:		
I hereby certify that the above named material has been accepted and to the best of my knowledge the foregoing is true and accurate.					
e. Name of Authorized Agent (Print) <i>Scott</i>		f. Signature <i>Scott</i>		g. Date <i>6/7/12</i>	

IV. ASBESTOS (Generator completes IVa-f and Operator complete IVg-i)

a. Operator's Name and Address:			c. Responsible Agency Name and Address:		
b. Phone:			d. Phone:		
e. Special Handling Instructions and Additional Information:					
f. <input type="checkbox"/> Friable <input type="checkbox"/> Non-Friable <input type="checkbox"/> Both % Friable % Non-Friable					
OPERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by the proper shipping name and are classified, packaged, marked and labeled/placarded, and are in all respects in proper condition for transport according to applicable international and national governmental regulations.					
g. Operator's Name and Title (Print)		h. Signature		i. Date	
*Operator refers to the company which owns, leases, operates, controls, or supervises the facility being demolished or renovated, or the demolition or renovation operation or both					

14192236

NIAGARA FALLS LANDFILL
 5th Street & Niagara Falls Blvd
 Niagara Falls, NY 14304 (716)282-6391

202553
 EMPIRE BUILDING DIAGNOSTIC INC
 P O BOX 412
 DEPEW, NY 14043
 Contract: 4215128286

SITE	TICKET	GRID
55	482008	
WEIGHMASTER		
PJ50000 PAM 5		
DATE IN	TIME IN	
7 JUNE 2012	8:28 am	
DATE OUT	TIME OUT	
7 JUNE 2012	9:01 am	
VEHICLE	ROLL OFF	
HQJ142		
REFERENCE	ORIGIN	
575698	Inbound -NY-ERIE	

QTY	UNIT	DESCRIPTION	27.27 LN	RATE	EXTENSION	TAX	TOTAL
00		Gross Weight		84,940.00	1b		
		Tare Weight		26,150.00	1b		
		Net Weight		58,790.00	1b		
29.39	TN	SW-SLAG					
1.00	LD	ENVIRONMENTAL FEE					
1.00	LD	FUEL RECOVERY FEE					
NATIONAL FUEL GAS							

NET AMOUNT
TENDERED
CHANGE
CHECK NO.

HAVE A NICE DAY

[Signature]

SIGNATURE



REV 11/09

RS-F04

575698

If waste is asbestos waste, complete Sections I, II, III and IV
 If waste is **NOT** asbestos waste, complete Sections I, II and III

I. GENERATOR (Generator completes Ia-r)

a. Generator's US EPA ID Number		b. Manifest Document Number		c. Page 1 of	
d. Generator's Name and Location: <i>National Fuel Gas 365 Mineral Springs Road Buffalo, NY 14210</i>			e. Generator's Mailing Address: <i>National Fuel Gas 5965 New Taylor Road Orchard Park, NY 14</i>		
f. Phone: <i>716-885-5500</i>			g. Phone:		
If owner of the generating facility differs from the generator, provide:					
h. Owner's Name:			i. Owner's Phone No.:		
j. Waste Profile #	k. Exp. Date	l. Waste Shipping Name and Description	m. Containers No.	n. Total Quantity	o. Unit Wt/Vol
<i>A 4213128286</i>	<i>5/7/2014</i>	<i>Coal Boiler Slag & Bottom Ash</i>	<i>1</i>	<i>20</i>	<i>yds</i>
GENERATOR'S CERTIFICATION: I hereby certify that the above named material is not a hazardous waste as defined by 40 CFR 261 or any applicable state law, has been properly described, classified and packaged, and is in proper condition for transportation according to applicable regulations; AND, if this waste is a treatment residue of a previously restricted hazardous waste subject to the Land Disposal Restrictions. I certify and warrant that the waste has been treated in accordance with the requirements of 40 CFR 268 and is no longer a hazardous waste as defined by 40 CFR 261.					
p. Generator Authorized Agent Name (Print)		q. Signature		r. Date	

II. TRANSPORTER (Generator completes IIa-b and Transporter completes IIc-e)

a. Transporter's Name and Address: <i>Empire Building Diagnostics Inc. 716-885-4588</i>			<i>Hoyonowski Transport 1077 French Rd. Attica, NY 14011</i>		
b. Phone:			<i>485-591-0844</i>		
c. Driver Name (Print) <i>PETER BOYZEN</i>		d. Signature <i>Peter Boyzen</i>		e. Date <i>6-7-12</i>	

III. DESTINATION (Generator complete IIIa-c and Destination Site completes III d-g)

a. Disposal Facility and Site Address: <i>Alfred Waste Niagara Falls Landfill LLC 5600 Niagara Falls Boulevard Niagara Falls, NY 14304 716-286-3344</i>		c. US EPA Number	d. Discrepancy Indication Space:
I hereby certify that the above named material has been accepted and to the best of my knowledge the foregoing is true and accurate.			
e. Name of Authorized Agent (Print) <i>SCOTT</i>		f. Signature <i>Kam Scott</i>	g. Date <i>6/7/12</i>

IV. ASBESTOS (Generator completes IVa-f and Operator complete IVg-i)

a. Operator's Name and Address:		c. Responsible Agency Name and Address:	
l. Phone:		d. Phone:	
e. Special Handling Instructions and Additional Information:			
f. <input type="checkbox"/> Friable <input type="checkbox"/> Non-Friable <input type="checkbox"/> Both % Friable % Non-Friable			
OPERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by the proper shipping name and are classified, packaged, marked and labeled/placarded, and are in all respects in proper condition for transport according to applicable international and national governmental regulations.			
g. Operator's Name and Title (Print)		i. Date	
h. Signature		i. Date	

*Operator refers to the company which owns, leases, operates, controls, or supervises the facility being demolished or renovated, or the demolition or renovation operation or both

14132290

NIAGARA FALLS LANDFILL
 56th Street & Niagara Falls Blvd
 Niagara Falls, NY 14304 (716)282-6381

 202253
 EMPIRE BUILDING DIAGNOSTIC INC
 P O BOX 412
 DEPEW, NY 14043
 Contract: 4215128286

SITE	TICKET	GRID
5B	482062	
WEIGHMASTER		
PJS0000 PAM B		
DATE IN	TIME IN	
7 June 2012	10:42 am	
DATE OUT	TIME OUT	
7 June 2012	11:07 am	
VEHICLE	ROLL OFF	
H0J142		
REFERENCE	ORIGIN	
575902	Inbound -NY-ERIE	

00 Gross Weight 79,080.00 lb
 Tare Weight 26,060.00 lb
 Net Weight 47,020.00 lb

QTY	UNIT	DESCRIPTION	UNIT PRICE	TAX	TOTAL
23.51	TN	SM-SLAG			
1.00	LD	ENVIRONMENTAL FEE			
1.00	LD	FUEL RECOVERY FEE			

HAVE A NICE DAY



REV 11/09

SIGNATURE *[Signature]*
 NET AMOUNT
 TENDERED
 CHANGE
 CHECK NO.

575902

If waste is asbestos waste, complete Sections I, II, III and IV
 If waste is **NOT** asbestos waste, complete Sections I, II and III

I. GENERATOR (Generator completes Ia-r)

a. Generator's US EPA ID Number		b. Manifest Document Number		c. Page 1 of	
d. Generator's Name and Location: National Fuel Gas 365 Mineral Springs Road Buffalo, NY 14216			e. Generator's Mailing Address: National Fuel Gas 5055 New Taylor Road Orchard Park, NY 14		
f. Phone: 716-637-5557			g. Phone:		
If owner of the generating facility differs from the generator, provide:					
h. Owner's Name:			i. Owner's Phone No.:		
j. Waste Profile #		k. Exp. Date	l. Waste Shipping Name and Description		m. Containers
					n. Total Quantity
					o. Unit Wt/Vol
A. 4215128286		5/7/2014	Coal Boiler Slag & Bottom Ash		20 yds
B.					
C.					
GENERATOR'S CERTIFICATION: I hereby certify that the above named material is not a hazardous waste as defined by 40 CFR 261 or any applicable state law, has been properly described, classified and packaged, and is in proper condition for transportation according to applicable regulations; AND, if this waste is a treatment residue of a previously restricted hazardous waste subject to the Land Disposal Restrictions, I certify and warrant that the waste has been treated in accordance with the requirements of 40 CFR 268 and is no longer a hazardous waste as defined by 40 CFR 261.					
p. Generator Authorized Agent Name (Print)			q. Signature		r. Date

II. TRANSPORTER (Generator completes IIa-b and Transporter completes IIc-e)

a. Transporter's Name and Address: Hojnowski Transport 385-591-0844			# 142		
b. Phone:					
c. Driver Name (Print) PETER BOYLEN		d. Signature Peter Boylen		e. Date 6-7-12	

III. DESTINATION (Generator complete IIIa-c and Destination Site completes III d-g)

a. Disposal Facility and Site Address: Albion Waste Niagara Falls Landfill LLC 3600 Niagara Falls Boulevard Niagara Falls, NY 14304 716-285-3344		c. US EPA Number	d. Discrepancy Indication Space:		
b. I hereby certify that the above named material has been accepted and to the best of my knowledge the foregoing is true and accurate.					
e. Name of Authorized Agent (Print) SCOTT		f. Signature Tom Scott		g. Date 6/7/12	

IV. ASBESTOS (Generator completes IVa-f and Operator complete IVg-i)

a. Operator's Name and Address:		c. Responsible Agency Name and Address:			
b. Phone:		d. Phone:			
e. Special Handling Instructions and Additional Information:					
f. <input type="checkbox"/> Friable <input type="checkbox"/> Non-Friable <input type="checkbox"/> Both % Friable % Non-Friable					
OPERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by the proper shipping name and are classified, packaged, marked and labeled/placarded, and are in all respects in proper condition for transport according to applicable international and national governmental regulations.					
g. Operator's Name and Title (Print)		h. Signature		i. Date	
*Operator refers to the company which owns, leases, operates, controls, or supervises the facility being demolished or renovated, or the demolition or renovation operation or both					

14192300

NIAGARA FALLS LANDFILL
 56th Street & Niagara Falls Blvd
 Niagara Falls, NY 14304 (716)282-6381

202853
 EMPIRE BUILDING DIAGNOSTIC INC
 P O BOX 412
 DEPEW, NY 14043
 Contract: 4215128284

SITE	TICKET	GRID
5B	482072	
WEIGHMASTER		
PJS0000 FAM S		
DATE IN	TIME IN	
7 June 2012	10:52 am	
DATE OUT	TIME OUT	
7 June 2012	11:32 am	
VEHICLE	ROLL OFF	
HQJ01		
REFERENCE	ORIGIN	
575901	Inbound -NY-ERIE	

00 Gross Weight 109,460.00 lb
 Tare Weight 38,300.00 lb
 Net Weight 71,160.00 lb

QTY	UNIT	DESCRIPTION	35.58 IN	RATE	EXTENSION	TAX	TOTAL
35.58	TN	SW-SLAG					
1.00	LD	ENVIRONMENTAL FEE					
1.00	LD	FUEL RECOVERY FEE					
NATIONAL FUEL GAS							

NET AMOUNT
TENDERED
CHANGE
CHECK NO.

HAVE A NICE DAY

R. H.

SIGNATURE



575901

If waste is asbestos waste, complete Sections I, II, III and IV
 If waste is **NOT** asbestos waste, complete Sections I, II and III

I. GENERATOR (Generator completes Ia-r)

a. Generator's US EPA ID Number		b. Manifest Document Number		c. Page 1 of	
d. Generator's Name and Location: 363 Mineral Springs Road Buffalo, NY 14210			e. Generator's Mailing Address: 5905 New Taylor Road Orchard Park, NY 14127		
f. Phone: 716-667-0007			g. Phone:		
h. Owner's Name:			i. Owner's Phone No.:		
j. Waste Profile #		k. Exp. Date	l. Waste Shipping Name and Description		o. Unit Wt/Vol
A. 4215128286		5/7/2014	Coal Boiler Slag & Bottom Ash		60 MB
GENERATOR'S CERTIFICATION: I hereby certify that the above named material is not a hazardous waste as defined by 40 CFR 261 or any applicable state law, has been properly described, classified and packaged, and is in proper condition for transportation according to applicable regulations; AND, if this waste is a treatment residue of a previously restricted hazardous waste subject to the Land Disposal Restrictions. I certify and warrant that the waste has been treated in accordance with the requirements of 40 CFR 268 and is no longer a hazardous waste as defined by 40 CFR 261.					
p. Generator Authorized Agent Name (Print)		q. Signature		r. Date	

II. TRANSPORTER (Generator completes IIa-b and Transporter completes IIc-e)

a. Transporter's Name and Address: Hojnowski Transport 585-591-0844			Hojnowski Trucks 139 Albion NY		
b. Phone:			6/7/12		
c. Driver Name (Print) ROBERT HOLOW		d. Signature R. Hojan		e. Date	

III. DESTINATION (Generator complete IIIa-c and Destination Site completes III d-g)

a. Disposal Facility and Site Address: Albion Waste Niagara Falls Landfill LLC 3600 Niagara Falls Boulevard Niagara Falls, NY 14304 716-285-3344		c. US EPA Number	d. Discrepancy Indication Space: Pam Scott
I hereby certify that the above named material has been accepted and to the best of my knowledge the foregoing is true and accurate.			
e. Name of Authorized Agent (Print) Robert Hojan		f. Signature R. Hojan	
g. Date 6/7/12			

IV. ASBESTOS (Generator completes IVa-f and Operator complete IVg-i)

a. Operator's Name and Address:		c. Responsible Agency Name and Address:	
b. Phone:		d. Phone:	
e. Special Handling Instructions and Additional Information:			
f. <input type="checkbox"/> Friable <input type="checkbox"/> Non-Friable <input type="checkbox"/> Both % Friable % Non-Friable			
OPERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by the proper shipping name and are classified, packaged, marked and labeled/placarded, and are in all respects in proper condition for transport according to applicable international and national governmental regulations.			
g. Operator's Name and Title (Print)		i. Date	
h. Signature			
*Operator refers to the company which owns, leases, operates, controls, or supervises the facility being demolished or renovated, or the demolition or renovation operation or both			

14102337

NIAGARA FALLS LANDFILL
 56th Street & Niagara Falls Blvd
 Niagara Falls, NY 14304 (716)282-6381

202853
 EMPIRE BUILDING DIAGNOSTIC INC
 P O BOX 412
 DEPEW, NY 14043
 Contract: 4215128284

SITE	TICKET	GRID
5B	482109	WEIGHMASTER
PJ90000 PAM 5		
DATE IN	TIME IN	
7 JUNE 2012	12:35 PM	
DATE OUT	TIME OUT	
7 JUNE 2012	1:05 PM	
VEHICLE	ROLL OFF	
HOJ142		
REFERENCE	ORIGIN	
575889	Inbound -NY-ERIE	

00 Gross Weight 71,440.00 lb
 Tare Weight 25,980.00 lb
 Net Weight 45,460.00 lb

QTY.	UNIT	DESCRIPTION	22.75 IN	RATE	EXTENSION	TAX	TOTAL
22.73	TN	SW-SLAG					
1.00	LD	ENVIRONMENTAL FEE					
1.00	LD	FUEL RECOVERY FEE					
NATIONAL FUEL GAS							

HAVE A NICE DAY



REV 11/09

SIGNATURE

[Handwritten Signature]

NET AMOUNT
TENDERED
CHANGE
CHECK NO.

RS-F04

575889

If waste is asbestos waste, complete Sections I, II, III and IV
 If waste is **NOT** asbestos waste, complete Sections I, II and III

I. GENERATOR (Generator completes Ia-r)

a. Generator's US EPA ID Number		b. Manifest Document Number		c. Page 1 of		
d. Generator's Name and Location: National Fuel Gas 365 Mineral Springs Road Buffalo, NY 14210			e. Generator's Mailing Address: 5855 New Taylor Road Orchard Park, NY 14			
f. Phone: (716) 651-3001			g. Phone:			
If owner of the generating facility differs from the generator, provide:						
h. Owner's Name:			i. Owner's Phone No.:			
j. Waste Profile #	k. Exp. Date	l. Waste Shipping Name and Description	m. Containers No.	Type	n. Total Quantity	o. Unit Wt/Vol
A. 4215128286	5/7/2014	Coal Boiler Slag & Bottom Ash	1	T	20	yds
B.						
C.						
GENERATOR'S CERTIFICATION: I hereby certify that the above named material is not a hazardous waste as defined by 40 CFR 261 or any applicable state law, has been properly described, classified and packaged, and is in proper condition for transportation according to applicable regulations; AND, if this waste is a treatment residue of a previously restricted hazardous waste subject to the Land Disposal Restrictions. I certify and warrant that the waste has been treated in accordance with the requirements of 40 CFR 268 and is no longer a hazardous waste as defined by 40 CFR 261.						
p. Generator Authorized Agent Name (Print)			q. Signature		r. Date	

II. TRANSPORTER (Generator completes IIa-b and Transporter completes IIc-e)

a. Transporter's Name and Address: Hajnowski Transport 585-591-0844		
b. Phone:		
c. Driver Name (Print) PETER BOWEN	d. Signature	e. Date 6/17/12

III. DESTINATION (Generator complete IIIa-c and Destination Site completes III d-g)

a. Disposal Facility and Site Address: Altera Waste Niagara Falls Landfill LLC 3600 Niagara Falls Boulevard Niagara Falls, NY 14304 716-285-3344	b.	c. US EPA Number	d. Discrepancy Indication Space:
I hereby certify that the above named material has been accepted and to the best of my knowledge the foregoing is true and accurate.			
e. Name of Authorized Agent (Print) SCOTT	f. Signature KATHY SCOTT	g. Date 6/17/12	

IV. ASBESTOS (Generator completes IVa-f and Operator complete IVg-i)

a. Operator's Name and Address:	c. Responsible Agency Name and Address:
b. Phone:	d. Phone:
e. Special Handling Instructions and Additional Information:	
f. <input type="checkbox"/> Friable <input type="checkbox"/> Non-Friable <input type="checkbox"/> Both % Friable % Non-Friable	
OPERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by the proper shipping name and are classified, packaged, marked and labeled/placarded, and are in all respects in proper condition for transport according to applicable international and national governmental regulations.	
g. Operator's Name and Title (Print)	i. Date
h. Signature	
*Operator refers to the company which owns, leases, operates, controls, or supervises the facility being demolished or renovated, or the demolition or renovation operation or both	

14192353

NIAGARA FALLS LANDFILL
 56th Street & Niagara Falls Blvd
 Niagara Falls, NY 14304 (716)282-6381

202853
 EMPIRE BUILDING DIAGNOSTIC INC
 P O BOX 412
 DEPEW, NY 14043
 Contract: 4215128286

SITE	TICKET	GRID
5B	482125	WEIGHMASTER
PJS0000 PAM S		
DATE IN	TIME IN	
7 JUNE 2012	1:03 PM	
DATE OUT	TIME OUT	
7 JUNE 2012	1:32 PM	
VEHICLE	ROLL OFF	
HQJ01		
REFERENCE	ORIGIN	
575870	INBOUND	NY-ERIE

QTY	UNIT	DESCRIPTION	33.57 / TN	RATE	EXTENSION	TAX	TOTAL
00		Gross Weight	106,320.00	lb			
		Tare Weight	39,180.00	lb			
		Net Weight	67,140.00	lb			
33.57	TN	SW-SLAG					
1.00	LD	ENVIRONMENTAL FEE					
1.00	LD	FUEL RECOVERY FEE					
NATIONAL FUEL GAS							

HAVE A NICE DAY



REV 11/09

SIGNATURE

[Handwritten Signature]

NET AMOUNT
TENDERED
CHANGE
CHECK NO.

RS-F04

575890

If waste is asbestos waste, complete Sections I, II, III and IV
 If waste is **NOT** asbestos waste, complete Sections I, II and III

I. GENERATOR (Generator completes Ia-r)

a. Generator's US EPA ID Number		b. Manifest Document Number		c. Page 1 of		
d. Generator's Name and Location: National Fuel Gas 365 Mineral Springs Road Buffalo, NY 14210			e. Generator's Mailing Address: National Fuel Gas 6955 New Taylor Road Orchard Park, NY 14			
f. Phone: 716-937-9937			g. Phone:			
If owner of the generating facility differs from the generator, provide:						
h. Owner's Name:			i. Owner's Phone No.:			
j. Waste Profile #		k. Exp. Date	l. Waste Shipping Name and Description	m. Containers No.	n. Total Quantity	o. Unit Wt/Vol
A. 4215128386		5/7/2014	Coal Boiler Slag & Bottom Ash	1	T	60 YDS
GENERATOR'S CERTIFICATION: I hereby certify that the above named material is not a hazardous waste as defined by 40 CFR 261 or any applicable state law, has been properly described, classified and packaged, and is in proper condition for transportation according to applicable regulations; AND, if this waste is a treatment residue of a previously restricted hazardous waste subject to the Land Disposal Restrictions. I certify and warrant that the waste has been treated in accordance with the requirements of 40 CFR 268 and is no longer a hazardous waste as defined by 40 CFR 261.						
p. Generator Authorized Agent Name (Print)			q. Signature		r. Date	

II. TRANSPORTER (Generator completes IIa-b and Transporter completes IIc-e)

a. Transporter's Name and Address: Hajnowski Transport 583-591-0844			Hajnowski Trans Africa NY		
b. Phone:			6/7/12		
c. Driver Name (Print) Robert Hogan		d. Signature R. Hogan		e. Date	

III. DESTINATION (Generator complete IIIa-c and Destination Site completes IIId-g)

a. Disposal Facility and Site Address: Allied Waste Niagara Falls Landfill LLC 5600 Niagara Falls Boulevard Niagara Falls, NY 14304 716-285-3344		c. US EPA Number	d. Discrepancy Indication Space:		
b. I hereby certify that the above named material has been accepted and to the best of my knowledge the foregoing is true and accurate.					
e. Name of Authorized Agent (Print) Scott		f. Signature Kam Scott		g. Date 6/7/12	

IV. ASBESTOS (Generator completes IVa-f and Operator complete IVg-i)

a. Operator's Name and Address:		c. Responsible Agency Name and Address:			
b. Phone:		d. Phone:			
e. Special Handling Instructions and Additional Information:					
f. <input type="checkbox"/> Friable <input type="checkbox"/> Non-Friable <input type="checkbox"/> Both		% Friable		% Non-Friable	
OPERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by the proper shipping name and are classified, packaged, marked and labeled/placarded, and are in all respects in proper condition for transport according to applicable international and national governmental regulations.					
g. Operator's Name and Title (Print)		h. Signature		i. Date	
*Operator refers to the company which owns, leases, operates, controls, or supervises the facility being demolished or renovated, or the demolition or renovation operation or both					

14192377

NIAGARA FALLS LANDFILL
56th Street & Niagara Falls Blvd
Niagara Falls, NY 14304 (716)282-6381
202853
EMPIRE BUILDING DIAGNOSTIC INC
P O BOX 41E
DEPEN, NY 14043
Contract: 4215128286

SITE	TICKET	GRID
SB	482149	
WEIGHMASTER		
AS00067 ALBERT B		
DATE IN	TIME IN	
7 June 2012	2:28 pm	
DATE OUT	TIME OUT	
7 June 2012	2:52 pm	
VEHICLE	ROLL OFF	
HQJ01		
REFERENCE	ORIGIN	
575891	Inbound -NY-ERIE	

00 Gross Weight 69,740.00 lb
Tare Weight 25,940.00 lb
Net Weight 43,800.00 lb

QTY	UNIT	DESCRIPTION	PRICE	EXTENSION	TAX	TOTAL
21.70	TN	SM-SLAG				
1.00	LD	ENVIRONMENTAL FEE				
1.00	LD	FUEL RECOVERY FEE				

NET AMOUNT
TENDERED
CHANGE
CHECK NO.

HAVE A NICE DAY



REV 11/09

SIGNATURE

[Handwritten Signature]

RS-F04

575891

If waste is asbestos waste, complete Sections I, II, III and IV
 If waste is **NOT** asbestos waste, complete Sections I, II and III

I. GENERATOR (Generator completes Ia-r)

a. Generator's US EPA ID Number		b. Manifest Document Number		c. Page 1 of		
d. Generator's Name and Location: 365 Mineral Springs Road Buffalo, NY 14210			e. Generator's Mailing Address: 5965 New Taylor Road Orchard Park, NY 14			
f. Phone: (16-057-5207)			g. Phone:			
If owner of the generating facility differs from the generator, provide:						
h. Owner's Name:			i. Owner's Phone No.:			
j. Waste Profile #	k. Exp. Date	l. Waste Shipping Name and Description		m. Containers No.	n. Total Quantity	o. Unit Wt/Vol
A. 4215128286	5/7/2014	Coal Boiler Slag & Bottom Ash				
B						
C						
GENERATOR'S CERTIFICATION: I hereby certify that the above named material is not a hazardous waste as defined by 40 CFR 261 or any applicable state law, has been properly described, classified and packaged, and is in proper condition for transportation according to applicable regulations; AND, if this waste is a treatment residue of a previously restricted hazardous waste subject to the Land Disposal Restrictions, I certify and warrant that the waste has been treated in accordance with the requirements of 40 CFR 268 and is no longer a hazardous waste as defined by 40 CFR 261.						
p. Generator Authorized Agent Name (Print) John Bogue			q. Signature <i>[Signature]</i>		r. Date 6-7-12	

II. TRANSPORTER (Generator completes IIa-b and Transporter completes IIc-e)

a. Transporter's Name and Address: Hajnoski Transport 585-391-0844		
b. Phone: 142		
c. Driver Name (Print) PETER BOYCEW	d. Signature <i>[Signature]</i>	e. Date 6-7-12

III. DESTINATION (Generator complete IIIa-c and Destination Site completes IIId-g)

a. Disposal Facility and Site Address: Albion Waste Niagara Falls Landfill LLC 5600 Niagara Falls Boulevard Niagara Falls, NY 14304 716-285-3344		c. US EPA Number	d. Discrepancy Indication Space:
b. I hereby certify that the above named material has been accepted and to the best of my knowledge the foregoing is true and accurate.			
e. Name of Authorized Agent (Print) Al Smith	f. Signature <i>[Signature]</i>	g. Date 6-7-12	

IV. ASBESTOS (Generator completes IVa-f and Operator complete IVg-i)

a. Operator's Name and Address:		c. Responsible Agency Name and Address:	
b. Phone:		d. Phone:	
e. Special Handling Instructions and Additional Information:			
f. <input type="checkbox"/> Friable <input type="checkbox"/> Non-Friable <input type="checkbox"/> Both % Friable % Non-Friable			
OPERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by the proper shipping name and are classified, packaged, marked and labeled/placarded, and are in all respects in proper condition for transport according to applicable international and national governmental regulations.			
g. Operator's Name and Title (Print)		h. Signature	
		i. Date	
*Operator refers to the company which owns, leases, operates, controls, or supervises the facility being demolished or renovated, or the demolition or renovation operation or both			

14102386

NIAGARA FALLS LANDFILL
56th Street & Niagara Falls Blvd
Niagara Falls, NY 14304 (716)282-6381

202853
EMPIRE BUILDING DIAGNOSTIC INC
P O BOX 412
DEPEN, NY 14043
Contract: 4215128286

SITE	TICKET	GRID
5B	482158	
WEIGHMASTER		
AS00067 ALBERT S		
DATE IN	TIME IN	
7 June 2012	3:00 pm	
DATE OUT	TIME OUT	
7 June 2012	3:22 pm	
VEHICLE	ROLL OFF	
HQJ01		
REFERENCE	ORIGIN	
575892	Inbound -NY-ERIE	

00 Gross Weight 103,600.00 lb
Tare Weight 38,140.00 lb
Net Weight 65,460.00 lb

NATIONAL FUEL GAS

QTY	UNIT	DESCRIPTION	SE	IN	EXTENSION	TAX	TOTAL
32.73	TN	SW-SLAS					
1.00	LD	ENVIRONMENTAL FEE					
1.00	LD	FUEL RECOVERY FEE					

HAVE A NICE DAY

R. Hos

SIGNATURE



REV 11/09

NET AMOUNT
TENDERED
CHANGE
CHECK NO.

RS-F04

575892

If waste is asbestos waste, complete Sections I, II, III and IV
 If waste is **NOT** asbestos waste, complete Sections I, II and III

I. GENERATOR (Generator completes Ia-r)

a. Generator's US EPA ID Number		b. Manifest Document Number		c. Page 1 of	
d. Generator's Name and Location: National Fuel Gas 365 Mineral Springs Road Buffalo, NY 14210			e. Generator's Mailing Address: National Fuel Gas 5965 New Taylor Road Orchard Park, NY 14		
f. Phone: 716-881-5500			g. Phone:		
If owner of the generating facility differs from the generator, provide:					
h. Owner's Name:			i. Owner's Phone No.:		
j. Waste Profile #		k. Exp. Date	l. Waste Shipping Name and Description	m. Containers	
				No.	Type
A. 4215128286		5/7/2014	Coal Boiler Slag & Bottom Ash	1	T
B					
C					
					n. Total Quantity
					60 YDS
					o. Unit Wt/Vol
GENERATOR'S CERTIFICATION: I hereby certify that the above named material is not a hazardous waste as defined by 40 CFR 261 or any applicable state law, has been properly described, classified and packaged, and is in proper condition for transportation according to applicable regulations; AND, if this waste is a treatment residue of a previously restricted hazardous waste, subject to the Land Disposal Restrictions, I certify and warrant that the waste has been treated in accordance with the requirements of 40 CFR 268 and is no longer a hazardous waste as defined by 40 CFR 261.					
p. Generator Authorized Agent Name (Print) John Beemer			q. Signature [Signature]		r. Date 6-7-12

II. TRANSPORTER (Generator completes IIa-b and Transporter completes IIc-e)

a. Transporter's Name and Address: Hojnowski Transport 585-591-0844			Hojnowski Trans ATTICA NY		
b. Phone:					
c. Driver Name (Print) Robert Hogan		d. Signature R. Hogan		e. Date 6/7/12	

III. DESTINATION (Generator complete IIIa-c and Destination Site completes III d-g)

a. Disposal Facility and Site Address: Allied Waste Niagara Falls Landfill LLC 5600 Niagara Falls Boulevard Niagara Falls, NY 14304 716-286-3344		c. US EPA Number	d. Discrepancy Indication Space:
b. I hereby certify that the above named material has been accepted and to the best of my knowledge the foregoing is true and accurate.			
e. Name of Authorized Agent (Print) Allimth		f. Signature [Signature]	
		g. Date 6-7-12	

IV. ASBESTOS (Generator completes IVa-f and Operator complete IVg-i)

a. Operator's Name and Address:		c. Responsible Agency Name and Address:	
b. Phone:		d. Phone:	
e. Special Handling Instructions and Additional Information:			
f. <input type="checkbox"/> Friable <input type="checkbox"/> Non-Friable <input type="checkbox"/> Both % Friable % Non-Friable			
OPERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by the proper shipping name and are classified, packaged, marked and labeled/placarded, and are in all respects in proper condition for transport according to applicable international and national governmental regulations.			
g. Operator's Name and Title (Print)		h. Signature	
		i. Date	
*Operator refers to the company which owns, leases, operates, controls, or supervises the facility being demolished or renovated, or the demolition or renovation operation or both			

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

ANALYTICAL REPORT

TestAmerica Laboratories, Inc.

TestAmerica Buffalo
10 Hazelwood Drive
Amherst, NY 14228-2298
Tel: (716)691-2600

TestAmerica Job ID: 480-14731-1
Client Project/Site: MSW#8 Demo

For:
National Fuel Gas Company
6363 Main Street
Williamsville, New York 14221

Attn: Tanya Alexander



Authorized for release by:
1/13/2012 8:58:02 AM
Melissa Deyo
Project Administrator
melissa.deyo@testamericainc.com
Designee for
Denise Giglia
Project Manager I
denise.giglia@testamericainc.com

LINKS

Review your project
results through
TotalAccess

Have a Question?



Visit us at:
www.testamericainc.com

The test results in this report meet all 2003 NELAC and 2009 TNI requirements for accredited parameters, exceptions are noted in this report. This report may not be reproduced except in full, and with written approval from the laboratory. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

This report has been electronically signed and authorized by the signatory. Electronic signature is intended to be the legally binding equivalent of a traditionally handwritten signature.

Results relate only to the items tested and the sample(s) as received by the laboratory.

1
2
3
4
5
6
7
8
9
10
11
12
13
14



Table of Contents

Cover Page	1
Table of Contents	2
Definitions/Glossary	3
Case Narrative	4
Detection Summary	5
Client Sample Results	6
QC Sample Results	7
QC Association Summary	8
Lab Chronicle	9
Certification Summary	10
Method Summary	11
Sample Summary	12
Chain of Custody	13
Receipt Checklists	14

Definitions/Glossary

Client: National Fuel Gas Company
Project/Site: MSW#8 Demo

TestAmerica Job ID: 480-14731-1

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☼	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CNF	Contains no Free Liquid
DL, RA, RE, IN	Indicates a Dilution, Reanalysis, Re-extraction, or additional Initial metals/anion analysis of the sample
EDL	Estimated Detection Limit
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
ND	Not detected at the reporting limit (or MDL or EDL if shown)
PQL	Practical Quantitation Limit
QC	Quality Control
RL	Reporting Limit
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)

Case Narrative

Client: National Fuel Gas Company
Project/Site: MSW#8 Demo

TestAmerica Job ID: 480-14731-1

Job ID: 480-14731-1

Laboratory: TestAmerica Buffalo

Narrative

Job Narrative
480-14731-1

Receipt

All samples were received in good condition within temperature requirements.

Metals

No analytical or quality issues were noted.

Organic Prep

No analytical or quality issues were noted.

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14

Detection Summary

Client: National Fuel Gas Company
Project/Site: MSW#8 Demo

TestAmerica Job ID: 480-14731-1

Client Sample ID: BRICK W/ PAINT

Lab Sample ID: 480-14731-1

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.61		0.0050	0.0030	mg/L	1		6010B	TCLP

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14

Client Sample Results

Client: National Fuel Gas Company
Project/Site: MSW#8 Demo

TestAmerica Job ID: 480-14731-1

Client Sample ID: BRICK W/ PAINT

Lab Sample ID: 480-14731-1

Date Collected: 12/14/11 09:10

Matrix: Solid

Date Received: 12/14/11 10:25

Method: 6010B - Metals (ICP) - TCLP

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.61		0.0050	0.0030	mg/L		01/09/12 11:40	01/10/12 17:07	1

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14

QC Sample Results

Client: National Fuel Gas Company
Project/Site: MSW#8 Demo

TestAmerica Job ID: 480-14731-1

Method: 6010B - Metals (ICP)

Lab Sample ID: MB 480-47285/2-A
Matrix: Solid
Analysis Batch: 47536

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 47285

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.0050	0.0030	mg/L		01/09/12 11:40	01/10/12 17:03	1

Lab Sample ID: LCS 480-47285/3-A
Matrix: Solid
Analysis Batch: 47536

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 47285

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	Limits
Lead	1.00	0.979		mg/L		98	80 - 120

Lab Sample ID: LB2 480-47236/1-B LB2
Matrix: Solid
Analysis Batch: 47536

Client Sample ID: Method Blank
Prep Type: TCLP
Prep Batch: 47285

Analyte	LB2 Result	LB2 Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.0050	0.0030	mg/L		01/09/12 11:40	01/10/12 17:00	1

Lab Sample ID: 480-14731-1 MS
Matrix: Solid
Analysis Batch: 47536

Client Sample ID: BRICK W/ PAINT
Prep Type: TCLP
Prep Batch: 47285

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	Limits
Lead	0.61		1.00	1.63		mg/L		102	75 - 125

Lab Sample ID: 480-14731-1 MSD
Matrix: Solid
Analysis Batch: 47536

Client Sample ID: BRICK W/ PAINT
Prep Type: TCLP
Prep Batch: 47285

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	Limits	RPD	RPD Limit
Lead	0.61		1.00	1.63		mg/L		102	75 - 125	0	20

QC Association Summary

Client: National Fuel Gas Company
Project/Site: MSW#8 Demo

TestAmerica Job ID: 480-14731-1

Metals

Leach Batch: 47236

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
480-14731-1	BRICK W/ PAINT	TCLP	Solid	1311	
480-14731-1 MS	BRICK W/ PAINT	TCLP	Solid	1311	
480-14731-1 MSD	BRICK W/ PAINT	TCLP	Solid	1311	
LB2 480-47236/1-B LB2	Method Blank	TCLP	Solid	1311	

Prep Batch: 47285

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
480-14731-1	BRICK W/ PAINT	TCLP	Solid	3010A	47236
480-14731-1 MS	BRICK W/ PAINT	TCLP	Solid	3010A	47236
480-14731-1 MSD	BRICK W/ PAINT	TCLP	Solid	3010A	47236
LB2 480-47236/1-B LB2	Method Blank	TCLP	Solid	3010A	47236
LCS 480-47285/3-A	Lab Control Sample	Total/NA	Solid	3010A	
MB 480-47285/2-A	Method Blank	Total/NA	Solid	3010A	

Analysis Batch: 47536

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
480-14731-1	BRICK W/ PAINT	TCLP	Solid	6010B	47285
480-14731-1 MS	BRICK W/ PAINT	TCLP	Solid	6010B	47285
480-14731-1 MSD	BRICK W/ PAINT	TCLP	Solid	6010B	47285
LB2 480-47236/1-B LB2	Method Blank	TCLP	Solid	6010B	47285
LCS 480-47285/3-A	Lab Control Sample	Total/NA	Solid	6010B	47285
MB 480-47285/2-A	Method Blank	Total/NA	Solid	6010B	47285

Lab Chronicle

Client: National Fuel Gas Company
Project/Site: MSW#8 Demo

TestAmerica Job ID: 480-14731-1

Client Sample ID: BRICK W/ PAINT

Lab Sample ID: 480-14731-1

Date Collected: 12/14/11 09:10

Matrix: Solid

Date Received: 12/14/11 10:25

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
TCLP	Leach	1311			47236	01/08/12 14:27	MF	TAL BUF
TCLP	Prep	3010A			47285	01/09/12 11:40	JM	TAL BUF
TCLP	Analysis	6010B		1	47536	01/10/12 17:07	AH	TAL BUF

Laboratory References:

TAL BUF = TestAmerica Buffalo, 10 Hazelwood Drive, Amherst, NY 14228-2298, TEL (716)691-2600

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14

Certification Summary

Client: National Fuel Gas Company
 Project/Site: MSW#8 Demo

TestAmerica Job ID: 480-14731-1

Laboratory	Authority	Program	EPA Region	Certification ID
TestAmerica Buffalo	Arkansas	State Program	6	88-0686
TestAmerica Buffalo	California	NELAC	9	1169CA
TestAmerica Buffalo	Connecticut	State Program	1	PH-0568
TestAmerica Buffalo	Florida	NELAC	4	E87672
TestAmerica Buffalo	Georgia	Georgia EPD	4	N/A
TestAmerica Buffalo	Georgia	State Program	4	956
TestAmerica Buffalo	Illinois	NELAC	5	100325 / 200003
TestAmerica Buffalo	Iowa	State Program	7	374
TestAmerica Buffalo	Kansas	NELAC	7	E-10187
TestAmerica Buffalo	Kentucky	Kentucky UST	4	30
TestAmerica Buffalo	Kentucky	State Program	4	90029
TestAmerica Buffalo	Louisiana	NELAC	6	02031
TestAmerica Buffalo	Maine	State Program	1	NY0044
TestAmerica Buffalo	Maryland	State Program	3	294
TestAmerica Buffalo	Massachusetts	State Program	1	M-NY044
TestAmerica Buffalo	Michigan	State Program	5	9937
TestAmerica Buffalo	Minnesota	NELAC	5	036-999-337
TestAmerica Buffalo	New Hampshire	NELAC	1	2337
TestAmerica Buffalo	New Hampshire	NELAC	1	68-00281
TestAmerica Buffalo	New Jersey	NELAC	2	NY455
TestAmerica Buffalo	New York	NELAC	2	10026
TestAmerica Buffalo	North Dakota	State Program	8	R-176
TestAmerica Buffalo	Oklahoma	State Program	6	9421
TestAmerica Buffalo	Oregon	NELAC	10	NY200003
TestAmerica Buffalo	Pennsylvania	NELAC	3	68-00281
TestAmerica Buffalo	Tennessee	State Program	4	TN02970
TestAmerica Buffalo	Texas	NELAC	6	T104704412-08-TX
TestAmerica Buffalo	USDA	USDA		P330-08-00242
TestAmerica Buffalo	Virginia	NELAC Secondary AB	3	460185
TestAmerica Buffalo	Virginia	State Program	3	278
TestAmerica Buffalo	Washington	State Program	10	C1677
TestAmerica Buffalo	Wisconsin	State Program	5	998310390

Accreditation may not be offered or required for all methods and analytes reported in this package. Please contact your project manager for the laboratory's current list of certified methods and analytes.

Method Summary

Client: National Fuel Gas Company
Project/Site: MSW#8 Demo

TestAmerica Job ID: 480-14731-1

Method	Method Description	Protocol	Laboratory
6010B	Metals (ICP)	SW846	TAL BUF

Protocol References:

SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

Laboratory References:

TAL BUF = TestAmerica Buffalo, 10 Hazelwood Drive, Amherst, NY 14228-2298, TEL (716)691-2600

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14

Sample Summary

Client: National Fuel Gas Company
Project/Site: MSW#8 Demo

TestAmerica Job ID: 480-14731-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
480-14731-1	BRICK W/ PAINT	Solid	12/14/11 09:10	12/14/11 10:25

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

Temperature on Receipt _____
 Drinking Water? Yes No

Chain of Custody Record

TAL-4124 (1007)

Client: National Fuel Gas
Address: 5955 New Taylor Rd
 Orchard Park, NY 14127
City: Orchard Park
State: NY
Project Name and Location (State): MSW #8 Demo
Contract/Purchase Order/Quote No.:

Project Manager: Jim Clark
Telephone Number (Area Code)/Fax Number: 667-5557
Site Contact:
Carrier/Waybill Number:

Chain of Custody Number: 199178
Date: 12-14
Lab Number: Page 1 of 1

Analysis (Attach list if more space is needed): TCEP H9, TCEP H9A

Sample I.D. No. and Description (Containers for each sample may be combined on one line)	Date	Time	Matrix					Containers & Preservatives																	
			Water	Soil	Sediment	Sludge	Other	GC/MS	HPLC	IC	Other														
Dricks w/Paint	12-14	7:10																							
Brick	12-14	7:15																							

Sample Disposal: Return To Client Disposal By Lab Archiving For _____ Months _____
 (A fee may be assessed if samples are retained longer than 1 month)

Turn Around Time Required: 24 Hours 48 Hours 7 Days 14 Days 21 Days Other _____

1. Requisitioned By: J Clark
Date: 12-14
Time: 10:25

2. Requisitioned By: _____
Date: _____
Time: _____

3. Requisitioned By: _____
Date: _____
Time: _____

OC Requirements (Specify):

1. Received By: J Clark
Date: 12/14/11
Time: 10:25

2. Received By: _____
Date: _____
Time: _____

3. Received By: _____
Date: _____
Time: _____

Comments:

DISTRIBUTION: WHITE - Returned to Client with Report. CANARY - Stays with the Sample. PINK - Field Copy

416

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14

Login Sample Receipt Checklist

Client: National Fuel Gas Company

Job Number: 480-14731-1

Login Number: 14731

List Number: 1

Creator: Janish, Carl

List Source: TestAmerica Buffalo

Question	Answer	Comment
Radioactivity either was not measured or, if measured, is at or below background	True	
The cooler's custody seal, if present, is intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	N/A	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Sampling Company provided.	True	NFG
Samples received within 48 hours of sampling.	True	
Samples requiring field filtration have been filtered in the field.	N/A	
Chlorine Residual checked.	N/A	

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

ANALYTICAL REPORT

TestAmerica Laboratories, Inc.

TestAmerica Buffalo
10 Hazelwood Drive
Amherst, NY 14228-2298
Tel: (716)691-2600

TestAmerica Job ID: 480-19387-1

Client Project/Site: National Fuel Gas - TCLP Analysis

For:

National Fuel Gas Supply Company
Risk Management MSW Building 11
365 Mineral Spring Road
Building 11
Buffalo, New York 14210

Attn: Mr. Charlie Burke



Authorized for release by:
5/7/2012 10:00:09 AM

John Schove
Project Manager I
john.schove@testamericainc.com

LINKS

Review your project
results through
TotalAccess

Have a Question?



Visit us at:
www.testamericainc.com

The test results in this report meet all 2003 NELAC and 2009 TNI requirements for accredited parameters, exceptions are noted in this report. This report may not be reproduced except in full, and with written approval from the laboratory. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

This report has been electronically signed and authorized by the signatory. Electronic signature is intended to be the legally binding equivalent of a traditionally handwritten signature.

Results relate only to the items tested and the sample(s) as received by the laboratory.

1

2

3

4

5

6

7

8

9

10

11

12

13

14




Table of Contents

Cover Page	1
Table of Contents	2
Definitions/Glossary	3
Case Narrative	4
Detection Summary	5
Client Sample Results	6
QC Sample Results	7
QC Association Summary	10
Lab Chronicle	11
Certification Summary	12
Method Summary	13
Sample Summary	14
Chain of Custody	15
Receipt Checklists	16

Definitions/Glossary

Client: National Fuel Gas Supply Company
Project/Site: National Fuel Gas - TCLP Analysis

TestAmerica Job ID: 480-19387-1

Qualifiers

Metals

Qualifier	Qualifier Description
B	Compound was found in the blank and sample.
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☼	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CNF	Contains no Free Liquid
DL, RA, RE, IN	Indicates a Dilution, Reanalysis, Re-extraction, or additional Initial metals/anion analysis of the sample
EDL	Estimated Detection Limit
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
ND	Not detected at the reporting limit (or MDL or EDL if shown)
PQL	Practical Quantitation Limit
QC	Quality Control
RL	Reporting Limit
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)

Case Narrative

Client: National Fuel Gas Supply Company
Project/Site: National Fuel Gas - TCLP Analysis

TestAmerica Job ID: 480-19387-1

Job ID: 480-19387-1

Laboratory: TestAmerica Buffalo

Narrative

Job Narrative 480-19387-1

Comments

No additional comments.

Receipt

The sample was received on 5/1/2012 10:30 AM; the sample arrived in good condition, properly preserved and on ice. The temperature of the cooler at receipt was 14.70 C.

Except:

The following sample was received at the laboratory outside the required temperature criteria: MSW 8 Floor (480-19387-1). The sample is considered acceptable since it was collected and submitted to the laboratory within one hour of sample collection.

Metals

Method(s) 6010B: The TCLP Extractor Blank LB 480-62533 for batch 480-62680 contained chromium above the method detection limit. This target analyte concentration was less than the reporting limit (RL); therefore, re-extraction and/or re-analysis of sample MSW 8 Floor (480-19387-1) was not performed.

Method(s) 6010B: The analytes barium and lead were detected in the TCLP Extractor Blank LB 480-62533, from batch 480-62680 at a concentration above the TestAmerica Laboratories standard quantitation limit. Sample MSW 8 Floor (480-19387-1) which was associated with that blank was evaluated and determined to be at least five times less than the TCLP Regulatory Limits. The sample data was therefore accepted and no corrective action was performed.

Method(s) 6010B: The Serial Dilution (480-19387-1 SD) in TCLP batch 480-62680, exhibited results outside the quality control limits for barium. However, the Post Digestion Spike was compliant so no corrective action was necessary.

No other analytical or quality issues were noted.

General Chemistry

No analytical or quality issues were noted.

Organic Prep

No analytical or quality issues were noted.

Detection Summary

Client: National Fuel Gas Supply Company
 Project/Site: National Fuel Gas - TCLP Analysis

TestAmerica Job ID: 480-19387-1

Client Sample ID: MSW 8 Floor

Lab Sample ID: 480-19387-1

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Barium	0.17	B	0.0020	0.00070	mg/L	1		6010B	TCLP
Cadmium	0.0042		0.0010	0.00050	mg/L	1		6010B	TCLP
Chromium	0.0028	J B	0.0040	0.0010	mg/L	1		6010B	TCLP
Lead	0.042	B	0.0050	0.0030	mg/L	1		6010B	TCLP
Analyte	Result	Qualifier	RL	RL	Unit	Dil Fac	D	Method	Prep Type
pH	8.51		0.100	0.100	SU	1		9045C	Total/NA

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14

Client Sample Results

Client: National Fuel Gas Supply Company
 Project/Site: National Fuel Gas - TCLP Analysis

TestAmerica Job ID: 480-19387-1

Client Sample ID: MSW 8 Floor

Lab Sample ID: 480-19387-1

Date Collected: 05/01/12 09:30

Matrix: Solid

Date Received: 05/01/12 10:30

Method: 6010B - Metals (ICP) - TCLP

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Arsenic	ND		0.010	0.0056	mg/L		05/02/12 13:00	05/03/12 19:22	1
Barium	0.17	B	0.0020	0.00070	mg/L		05/02/12 13:00	05/03/12 19:22	1
Cadmium	0.0042		0.0010	0.00050	mg/L		05/02/12 13:00	05/03/12 19:22	1
Chromium	0.0028	J B	0.0040	0.0010	mg/L		05/02/12 13:00	05/03/12 19:22	1
Lead	0.042	B	0.0050	0.0030	mg/L		05/02/12 13:00	05/03/12 19:22	1
Selenium	ND		0.015	0.0087	mg/L		05/02/12 13:00	05/03/12 19:22	1
Silver	ND		0.0030	0.0017	mg/L		05/02/12 13:00	05/03/12 19:22	1

Method: 7470A - Mercury (CVAA) - TCLP

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Mercury	ND		0.00020	0.00012	mg/L		05/02/12 13:09	05/02/12 17:19	1

General Chemistry

Analyte	Result	Qualifier	RL	RL	Unit	D	Prepared	Analyzed	Dil Fac
pH	8.51		0.100	0.100	SU			05/04/12 15:20	1

QC Sample Results

Client: National Fuel Gas Supply Company
 Project/Site: National Fuel Gas - TCLP Analysis

TestAmerica Job ID: 480-19387-1

Method: 6010B - Metals (ICP)

Lab Sample ID: MB 480-62680/2-A

Matrix: Solid

Analysis Batch: 63028

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 62680

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Arsenic	ND		0.010	0.0056	mg/L		05/02/12 13:00	05/03/12 19:15	1
Barium	ND		0.0020	0.00070	mg/L		05/02/12 13:00	05/03/12 19:15	1
Cadmium	ND		0.0010	0.00050	mg/L		05/02/12 13:00	05/03/12 19:15	1
Chromium	ND		0.0040	0.0010	mg/L		05/02/12 13:00	05/03/12 19:15	1
Lead	ND		0.0050	0.0030	mg/L		05/02/12 13:00	05/03/12 19:15	1
Selenium	ND		0.015	0.0087	mg/L		05/02/12 13:00	05/03/12 19:15	1
Silver	ND		0.0030	0.0017	mg/L		05/02/12 13:00	05/03/12 19:15	1

Lab Sample ID: LCS 480-62680/3-A

Matrix: Solid

Analysis Batch: 63028

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 62680

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Arsenic	1.00	1.04		mg/L		104	80 - 120
Barium	1.00	1.01		mg/L		101	80 - 120
Cadmium	1.00	1.03		mg/L		103	80 - 120
Chromium	1.00	0.967		mg/L		97	80 - 120
Lead	1.00	1.05		mg/L		105	80 - 120
Selenium	1.00	1.05		mg/L		105	80 - 120
Silver	1.00	1.08		mg/L		108	80 - 120

Lab Sample ID: LB 480-62533/5-B LB

Matrix: Solid

Analysis Batch: 63028

Client Sample ID: Method Blank

Prep Type: TCLP

Prep Batch: 62680

Analyte	LB Result	LB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Arsenic	ND		0.010	0.0056	mg/L		05/02/12 13:00	05/03/12 19:13	1
Barium	0.0270		0.0020	0.00070	mg/L		05/02/12 13:00	05/03/12 19:13	1
Cadmium	ND		0.0010	0.00050	mg/L		05/02/12 13:00	05/03/12 19:13	1
Chromium	0.00297	J	0.0040	0.0010	mg/L		05/02/12 13:00	05/03/12 19:13	1
Lead	0.0109		0.0050	0.0030	mg/L		05/02/12 13:00	05/03/12 19:13	1
Selenium	ND		0.015	0.0087	mg/L		05/02/12 13:00	05/03/12 19:13	1
Silver	ND		0.0030	0.0017	mg/L		05/02/12 13:00	05/03/12 19:13	1

Lab Sample ID: 480-19387-1 MS

Matrix: Solid

Analysis Batch: 63028

Client Sample ID: MSW 8 Floor

Prep Type: TCLP

Prep Batch: 62680

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Arsenic	ND		1.00	1.05		mg/L		105	75 - 125
Barium	0.17	B	1.00	1.16		mg/L		98	75 - 125
Cadmium	0.0042		1.00	1.04		mg/L		104	75 - 125
Chromium	0.0028	J B	1.00	0.956		mg/L		95	75 - 125
Lead	0.042	B	1.00	1.07		mg/L		103	75 - 125
Selenium	ND		1.00	1.07		mg/L		107	75 - 125
Silver	ND		1.00	1.07		mg/L		107	75 - 125

QC Sample Results

Client: National Fuel Gas Supply Company
 Project/Site: National Fuel Gas - TCLP Analysis

TestAmerica Job ID: 480-19387-1

Method: 6010B - Metals (ICP) (Continued)

Lab Sample ID: 480-19387-1 MSD

Matrix: Solid

Analysis Batch: 63028

Client Sample ID: MSW 8 Floor

Prep Type: TCLP

Prep Batch: 62680

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD		Unit	D	%Rec	%Rec.		RPD	Limit
				Result	Qualifier				Limits	RPD		
Arsenic	ND		1.00	1.05		mg/L		105	75 - 125	1	20	
Barium	0.17	B	1.00	1.17		mg/L		100	75 - 125	1	20	
Cadmium	0.0042		1.00	1.05		mg/L		105	75 - 125	1	20	
Chromium	0.0028	J B	1.00	0.953		mg/L		95	75 - 125	0	20	
Lead	0.042	B	1.00	1.08		mg/L		104	75 - 125	1	20	
Selenium	ND		1.00	1.08		mg/L		108	75 - 125	1	20	
Silver	ND		1.00	1.09		mg/L		109	75 - 125	1	20	

Method: 7470A - Mercury (CVAA)

Lab Sample ID: MB 480-62699/2-A

Matrix: Solid

Analysis Batch: 62784

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 62699

Analyte	MB MB		RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
Mercury	ND		0.00020	0.00012	mg/L		05/02/12 13:09	05/02/12 17:03	1

Lab Sample ID: LCS 480-62699/3-A

Matrix: Solid

Analysis Batch: 62784

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 62699

Analyte	Spike Added	LCS LCS		Unit	D	%Rec	%Rec.	
		Result	Qualifier				Limits	RPD
Mercury	0.00668	0.00637		mg/L		95	80 - 120	

Lab Sample ID: LB 480-62533/5-C LB

Matrix: Solid

Analysis Batch: 62784

Client Sample ID: Method Blank

Prep Type: TCLP

Prep Batch: 62699

Analyte	LB LB		RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
Mercury	ND		0.00020	0.00012	mg/L		05/02/12 13:09	05/02/12 17:01	1

Lab Sample ID: 480-19387-1 MS

Matrix: Solid

Analysis Batch: 62784

Client Sample ID: MSW 8 Floor

Prep Type: TCLP

Prep Batch: 62699

Analyte	Sample Result	Sample Qualifier	Spike Added	MS MS		Unit	D	%Rec	%Rec.	
				Result	Qualifier				Limits	RPD
Mercury	ND		0.00668	0.00653		mg/L		98	75 - 125	

Lab Sample ID: 480-19387-1 MSD

Matrix: Solid

Analysis Batch: 62784

Client Sample ID: MSW 8 Floor

Prep Type: TCLP

Prep Batch: 62699

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD MSD		Unit	D	%Rec	%Rec.		RPD	Limit
				Result	Qualifier				Limits	RPD		
Mercury	ND		0.00668	0.00697		mg/L		104	75 - 125	6	20	

QC Sample Results

Client: National Fuel Gas Supply Company
 Project/Site: National Fuel Gas - TCLP Analysis

TestAmerica Job ID: 480-19387-1

Method: 9045C - pH

Lab Sample ID: LCS 480-63144/1
 Matrix: Solid
 Analysis Batch: 63144

Client Sample ID: Lab Control Sample
 Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits
pH	7.00	7.030		SU		100	99 - 101

Lab Sample ID: 480-19387-1 DU
 Matrix: Solid
 Analysis Batch: 63144

Client Sample ID: MSW 8 Floor
 Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	DU Result	DU Qualifier	Unit	D	RPD	RPD Limit
pH	8.51		8.500		SU		0.1	5

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14

QC Association Summary

Client: National Fuel Gas Supply Company
 Project/Site: National Fuel Gas - TCLP Analysis

TestAmerica Job ID: 480-19387-1

Metals

Leach Batch: 62533

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
480-19387-1	MSW 8 Floor	TCLP	Solid	1311	
480-19387-1 MS	MSW 8 Floor	TCLP	Solid	1311	
480-19387-1 MSD	MSW 8 Floor	TCLP	Solid	1311	
LB 480-62533/5-B LB	Method Blank	TCLP	Solid	1311	
LB 480-62533/5-C LB	Method Blank	TCLP	Solid	1311	

Prep Batch: 62680

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
480-19387-1	MSW 8 Floor	TCLP	Solid	3010A	62533
480-19387-1 MS	MSW 8 Floor	TCLP	Solid	3010A	62533
480-19387-1 MSD	MSW 8 Floor	TCLP	Solid	3010A	62533
LB 480-62533/5-B LB	Method Blank	TCLP	Solid	3010A	62533
LCS 480-62680/3-A	Lab Control Sample	Total/NA	Solid	3010A	
MB 480-62680/2-A	Method Blank	Total/NA	Solid	3010A	

Prep Batch: 62699

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
480-19387-1	MSW 8 Floor	TCLP	Solid	7470A	62533
480-19387-1 MS	MSW 8 Floor	TCLP	Solid	7470A	62533
480-19387-1 MSD	MSW 8 Floor	TCLP	Solid	7470A	62533
LB 480-62533/5-C LB	Method Blank	TCLP	Solid	7470A	62533
LCS 480-62699/3-A	Lab Control Sample	Total/NA	Solid	7470A	
MB 480-62699/2-A	Method Blank	Total/NA	Solid	7470A	

Analysis Batch: 62784

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
480-19387-1	MSW 8 Floor	TCLP	Solid	7470A	62699
480-19387-1 MS	MSW 8 Floor	TCLP	Solid	7470A	62699
480-19387-1 MSD	MSW 8 Floor	TCLP	Solid	7470A	62699
LB 480-62533/5-C LB	Method Blank	TCLP	Solid	7470A	62699
LCS 480-62699/3-A	Lab Control Sample	Total/NA	Solid	7470A	62699
MB 480-62699/2-A	Method Blank	Total/NA	Solid	7470A	62699

Analysis Batch: 63028

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
480-19387-1	MSW 8 Floor	TCLP	Solid	6010B	62680
480-19387-1 MS	MSW 8 Floor	TCLP	Solid	6010B	62680
480-19387-1 MSD	MSW 8 Floor	TCLP	Solid	6010B	62680
LB 480-62533/5-B LB	Method Blank	TCLP	Solid	6010B	62680
LCS 480-62680/3-A	Lab Control Sample	Total/NA	Solid	6010B	62680
MB 480-62680/2-A	Method Blank	Total/NA	Solid	6010B	62680

General Chemistry

Analysis Batch: 63144

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
480-19387-1	MSW 8 Floor	Total/NA	Solid	9045C	
480-19387-1 DU	MSW 8 Floor	Total/NA	Solid	9045C	
LCS 480-63144/1	Lab Control Sample	Total/NA	Solid	9045C	

Lab Chronicle

Client: National Fuel Gas Supply Company
Project/Site: National Fuel Gas - TCLP Analysis

TestAmerica Job ID: 480-19387-1

Client Sample ID: MSW 8 Floor

Lab Sample ID: 480-19387-1

Date Collected: 05/01/12 09:30

Matrix: Solid

Date Received: 05/01/12 10:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
TCLP	Leach	1311			62533	05/01/12 16:14	KV	TAL BUF
TCLP	Prep	7470A			62699	05/02/12 13:09	JRK	TAL BUF
TCLP	Analysis	7470A		1	62784	05/02/12 17:19	JRK	TAL BUF
TCLP	Prep	3010A			62680	05/02/12 13:00	SS	TAL BUF
TCLP	Analysis	6010B		1	63028	05/03/12 19:22	AH	TAL BUF
Total/NA	Analysis	9045C		1	63144	05/04/12 15:20	JS	TAL BUF

Laboratory References:

TAL BUF = TestAmerica Buffalo, 10 Hazelwood Drive, Amherst, NY 14228-2298, TEL (716)691-2600



Certification Summary

Client: National Fuel Gas Supply Company
 Project/Site: National Fuel Gas - TCLP Analysis

TestAmerica Job ID: 480-19387-1

Laboratory	Authority	Program	EPA Region	Certification ID
TestAmerica Buffalo	Arkansas DEQ	State Program	6	88-0686
TestAmerica Buffalo	California	NELAC	9	1169CA
TestAmerica Buffalo	Connecticut	State Program	1	PH-0568
TestAmerica Buffalo	Florida	NELAC	4	E87672
TestAmerica Buffalo	Georgia	State Program	4	956
TestAmerica Buffalo	Georgia	State Program	4	N/A
TestAmerica Buffalo	Illinois	NELAC	5	100325 / 200003
TestAmerica Buffalo	Iowa	State Program	7	374
TestAmerica Buffalo	Kansas	NELAC	7	E-10187
TestAmerica Buffalo	Kentucky	State Program	4	90029
TestAmerica Buffalo	Kentucky (UST)	State Program	4	30
TestAmerica Buffalo	Louisiana	NELAC	6	02031
TestAmerica Buffalo	Maine	State Program	1	NY0044
TestAmerica Buffalo	Maryland	State Program	3	294
TestAmerica Buffalo	Massachusetts	State Program	1	M-NY044
TestAmerica Buffalo	Michigan	State Program	5	9937
TestAmerica Buffalo	Minnesota	NELAC	5	036-999-337
TestAmerica Buffalo	New Hampshire	NELAC	1	2337
TestAmerica Buffalo	New Hampshire	NELAC	1	68-00281
TestAmerica Buffalo	New Jersey	NELAC	2	NY455
TestAmerica Buffalo	New York	NELAC	2	10026
TestAmerica Buffalo	North Dakota	State Program	8	R-176
TestAmerica Buffalo	Oklahoma	State Program	6	9421
TestAmerica Buffalo	Oregon	NELAC	10	NY200003
TestAmerica Buffalo	Pennsylvania	NELAC	3	68-00281
TestAmerica Buffalo	Tennessee	State Program	4	TN02970
TestAmerica Buffalo	Texas	NELAC	6	T104704412-08-TX
TestAmerica Buffalo	USDA	Federal		P330-08-00242
TestAmerica Buffalo	Virginia	NELAC	3	460185
TestAmerica Buffalo	Virginia	State Program	3	278
TestAmerica Buffalo	Washington	State Program	10	C1677
TestAmerica Buffalo	West Virginia DEP	State Program	3	252
TestAmerica Buffalo	Wisconsin	State Program	5	998310390

Accreditation may not be offered or required for all methods and analytes reported in this package. Please contact your project manager for the laboratory's current list of certified methods and analytes.

Method Summary

Client: National Fuel Gas Supply Company
Project/Site: National Fuel Gas - TCLP Analysis

TestAmerica Job ID: 480-19387-1

Method	Method Description	Protocol	Laboratory
6010B	Metals (ICP)	SW846	TAL BUF
7470A	Mercury (CVAA)	SW846	TAL BUF
9045C	pH	SW846	TAL BUF

Protocol References:

SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

Laboratory References:

TAL BUF = TestAmerica Buffalo, 10 Hazelwood Drive, Amherst, NY 14228-2298, TEL (716)691-2600

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14

Sample Summary

Client: National Fuel Gas Supply Company
Project/Site: National Fuel Gas - TCLP Analysis

TestAmerica Job ID: 480-19387-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
480-19387-1	MSW 8 Floor	Solid	05/01/12 09:30	05/01/12 10:30

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

Temperature on Receipt _____
 Drinking Water? Yes No

Chain of Custody Record

TAL-4124 (1007)

Client: NATIONAL FUEL
 Address: 5955 NEW TAYLOR RD
 City: ORCHARDS PARK State: NY Zip Code: 14127
 Project Name and Location (State): MINERAL SPRINGS BLDG 8
 Contract/Purchase Order/Quote No.:

Project Manager: _____ Date: _____
 Telephone Number (Area Code)/Fax Number: _____ Lab Number: _____
 Chain of Custody Number: 218407 Page _____ of _____
 Site Contact: _____ Lab Contact: _____
 Carrier/Waybill Number: _____

Sample I.D. No. and Description (Containers for each sample may be combined on one line)	Date	Time	Containers & Preservatives						Special Instructions/ Conditions of Receipt		
			Unpres.	H2SO4	HNO3	HCl	NaOH	ZnAc		NaOH	
MSW 8 FLOOR	5/1/2012	9:30 A	Air								SMALL TO
			Soil								bunkeconaffuel.com
			Aqueous								667-5559
			Sed								
			Soil								

Possible Hazard Identification
 Non-Hazard Flammable Skin Irritant Poison B Unknown
 Return To Client Archive For _____ Months Disposal By Lab (A fee may be assessed if samples are retained longer than 1 month)

Turn Around Time Required
 24 Hours 48 Hours 7 Days 14 Days 21 Days Other _____

QC Requirements (Specify)
 1. Relinquished By: *Charles Butke* Date: 5/1/12 Time: 1030
 2. Relinquished By: _____ Date: _____ Time: _____
 3. Relinquished By: _____ Date: _____ Time: _____

Comments: 14.7° NO ICE



Login Sample Receipt Checklist

Client: National Fuel Gas Supply Company

Job Number: 480-19387-1

Login Number: 19387

List Number: 1

Creator: Wienke, Robert

List Source: TestAmerica Buffalo

Question	Answer	Comment
Radioactivity either was not measured or, if measured, is at or below background	True	
The cooler's custody seal, if present, is intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	False	Same day collection
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	True	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Sampling Company provided.	True	National Fuel
Samples received within 48 hours of sampling.	True	
Samples requiring field filtration have been filtered in the field.	N/A	
Chlorine Residual checked.	N/A	