



**PERMIT**  
**Under the Environmental Conservation Law (ECL)**

**IDENTIFICATION INFORMATION**

Permit Type: Air State Facility  
Permit ID: 1-4734-01810/00001  
Mod 0 Effective Date: 11/26/2013 Expiration Date: 11/25/2023  
Mod 1 Effective Date: 02/23/2015 Expiration Date: 11/25/2023

Permit Issued To: TOWN OF SMITHTOWN  
124 WEST MAIN ST  
P.O. BOX 9090  
SMITHTOWN, NY 11787

Contact: MICHAEL P ENGELMANN  
SMITHTOWN DEPT OF ENV & WATERWAYS  
124 W MAIN ST  
SMITHTOWN, NY 11787  
(631) 360-7514

Facility: SMITHTOWN MUNICIPAL SERVICES FACILITY  
85 OLD NORTHPORT RD  
KINGS PARK, NY 11754

Contact: RUSSELL K BARNETT  
DEPARTMENT OF ENVIRONMENT & WATERWAYS  
124 WEST MAIN STREET  
SMITHTOWN, NY 11787  
(631) 360-7514

Description:  
The facility is replacing a diesel-fired ICE with a similar, but larger, unit.

By acceptance of this permit, the permittee agrees that the permit is contingent upon strict compliance with the ECL, all applicable regulations, the General Conditions specified and any Special Conditions included as part of this permit.

Permit Administrator: SUSAN ACKERMAN  
NYSDEC - REGION 1 SUNY @ STONY BROOK  
50 CIRCLE RD  
STONY BROOK, NY 11790-3409

Authorized Signature: \_\_\_\_\_ Date: \_\_\_\_ / \_\_\_\_ / \_\_\_\_



**Notification of Other State Permittee Obligations**

**Item A: Permittee Accepts Legal Responsibility and Agrees to Indemnification**

The permittee expressly agrees to indemnify and hold harmless the Department of Environmental Conservation of the State of New York, its representatives, employees and agents ("DEC") for all claims, suits, actions, and damages, to the extent attributable to the permittee's acts or omissions in connection with the compliance permittee's undertaking of activities in connection with, or operation and maintenance of, the facility or facilities authorized by the permit whether in compliance or not in any compliance with the terms and conditions of the permit. This indemnification does not extend to any claims, suits, actions, or damages to the extent attributable to DEC's own negligent or intentional acts or omissions, or to any claims, suits, or actions naming the DEC and arising under article 78 of the New York Civil Practice Laws and Rules or any citizen suit or civil rights provision under federal or state laws.

**Item B: Permittee's Contractors to Comply with Permit**

The permittee is responsible for informing its independent contractors, employees, agents and assigns of their responsibility to comply with this permit, including all special conditions while acting as the permittee's agent with respect to the permitted activities, and such persons shall be subject to the same sanctions for violations of the Environmental Conservation Law as those prescribed for the permittee.

**Item C: Permittee Responsible for Obtaining Other Required Permits**

The permittee is responsible for obtaining any other permits, approvals, lands, easements and rights-of-way that may be required to carry out the activities that are authorized by this permit.

**Item D: No Right to Trespass or Interfere with Riparian Rights**

This permit does not convey to the permittee any right to trespass upon the lands or interfere with the riparian rights of others in order to perform the permitted work nor does it authorize the impairment of any rights, title, or interest in real or personal property held or vested in a person not a party to the permit.



**LIST OF CONDITIONS**

**DEC GENERAL CONDITIONS**

**General Provisions**

- Facility Inspection by the Department
- Relationship of this Permit to Other Department Orders and Determinations
- Applications for permit renewals, modifications and transfers
- Permit modifications, suspensions or revocations by the Department

**Facility Level**

- Submission of application for permit modification or renewal -

REGION 1 HEADQUARTERS



**DEC GENERAL CONDITIONS**  
**\*\*\*\* General Provisions \*\*\*\***  
**GENERAL CONDITIONS - Apply to ALL Authorized Permits.**

**Condition 1: Facility Inspection by the Department**

**Applicable State Requirement: ECL 19-0305**

**Item 1.1:**

The permitted site or facility, including relevant records, is subject to inspection at reasonable hours and intervals by an authorized representative of the Department of Environmental Conservation (the Department) to determine whether the permittee is complying with this permit and the ECL. Such representative may order the work suspended pursuant to ECL 71-0301 and SAPA 401(3).

**Item 1.2:**

The permittee shall provide a person to accompany the Department's representative during an inspection to the permit area when requested by the Department.

**Item 1.3:**

A copy of this permit, including all referenced maps, drawings and special conditions, must be available for inspection by the Department at all times at the project site or facility. Failure to produce a copy of the permit upon request by a Department representative is a violation of this permit.

**Condition 2: Relationship of this Permit to Other Department Orders and Determinations**

**Applicable State Requirement: ECL 3-0301 (2) (m)**

**Item 2.1:**

Unless expressly provided for by the Department, issuance of this permit does not modify, supersede or rescind any order or determination previously issued by the Department or any of the terms, conditions or requirements contained in such order or determination.

**Condition 3: Applications for permit renewals, modifications and transfers**

**Applicable State Requirement: 6 NYCRR 621.11**

**Item 3.1:**

The permittee must submit a separate written application to the Department for renewal, modification or transfer of this permit. Such application must include any forms or supplemental information the Department requires. Any renewal, modification or transfer granted by the Department must be in writing.

**Item 3.2:**

The permittee must submit a renewal application at least 180 days before expiration of permits for Title V Facility Permits, or at least 30 days before expiration of permits for State Facility Permits.

**Item 3.3:**

Permits are transferrable with the approval of the department unless specifically prohibited by the statute, regulation or another permit condition. Applications for permit transfer should be submitted prior to actual transfer of ownership.



**Condition 4: Permit modifications, suspensions or revocations by the Department**  
**Applicable State Requirement: 6 NYCRR 621.13**

**Item 4.1:**

The Department reserves the right to exercise all available authority to modify, suspend, or revoke this permit in accordance with 6NYCRR Part 621. The grounds for modification, suspension or revocation include:

- a) materially false or inaccurate statements in the permit application or supporting papers;
- b) failure by the permittee to comply with any terms or conditions of the permit;
- c) exceeding the scope of the project as described in the permit application;
- d) newly discovered material information or a material change in environmental conditions, relevant technology or applicable law or regulations since the issuance of the existing permit;
- e) noncompliance with previously issued permit conditions, orders of the commissioner, any provisions of the Environmental Conservation Law or regulations of the Department related to the permitted activity.

**\*\*\*\* Facility Level \*\*\*\***

**Condition 5: Submission of application for permit modification or renewal - REGION 1 HEADQUARTERS**  
**Applicable State Requirement: 6 NYCRR 621.6 (a)**

**Item 5.1:**

Applications for permit modification or renewal are to be submitted to:

NYSDEC Regional Permit Administrator  
Region 1 Headquarters  
Division of Environmental Permits  
Stony Brook University  
50 Circle Road  
Stony Brook, NY 11790-3409  
(631) 444-0365

**New York State Department of Environmental Conservation**

Permit ID: 1-4734-01810/00001

Facility DEC ID: 1473401810



**Permit Under the Environmental Conservation Law (ECL)**

**ARTICLE 19: AIR POLLUTION CONTROL - AIR STATE FACILITY  
PERMIT**

**IDENTIFICATION INFORMATION**

Permit Issued To: TOWN OF SMITHTOWN  
124 WEST MAIN ST  
P.O. BOX 9090  
SMITHTOWN, NY 11787

Facility: SMITHTOWN MUNICIPAL SERVICES FACILITY  
85 OLD NORTHPORT RD  
KINGS PARK, NY 11754

Authorized Activity By Standard Industrial Classification Code:  
4953 - REFUSE SYSTEMS  
8999 - SERVICES, NEC

Mod 0 Permit Effective Date: 11/26/2013

Permit Expiration Date: 11/25/2023

Mod 1 Permit Effective Date: 02/23/2015

Permit Expiration Date: 11/25/2023



## LIST OF CONDITIONS

### FEDERALLY ENFORCEABLE CONDITIONS

#### Facility Level

- 1 40CFR 82, Subpart F: Recycling and Emissions Reduction
- 2 6 NYCRR 201-7.1: Facility Permissible Emissions
- \*3 6 NYCRR 201-7.1: Capping Monitoring Condition
- 4 6 NYCRR 211.1: Air pollution prohibited
- 5 6 NYCRR 211.1: Preventative measures for fugitive particulate emissions.
- 1-1 6 NYCRR 225-1.2 (g): Compliance Demonstration
- 1-2 6 NYCRR 225-1.2 (h): Compliance Demonstration
- 6 6 NYCRR 227-1.7: Compliance Demonstration
- 1-3 40CFR 60, NSPS Subpart III: Applicability
- 1-4 40CFR 60, NSPS Subpart III: Compliance and Enforcement

#### Emission Unit Level

- 7 6 NYCRR 201-7.1: Process Permissible Emissions

#### EU=U-WDCPR

- 8 6 NYCRR 227-1.3: Compliance Demonstration

### STATE ONLY ENFORCEABLE CONDITIONS

#### Facility Level

- 9 ECL 19-0301: Contaminant List
- 10 6 NYCRR 201-1.4: Malfunctions and start-up/shutdown activities
- 11 6 NYCRR Subpart 201-5: Emission Unit Definition
- 12 6 NYCRR 201-5.2 (c): Renewal deadlines for state facility permits
- 13 6 NYCRR 201-5.3 (c): Compliance Demonstration
- 14 6 NYCRR 211.2: Visible Emissions Limited

#### Emission Unit Level

- 15 6 NYCRR Subpart 201-5: Emission Point Definition By Emission Unit
- 16 6 NYCRR Subpart 201-5: Process Definition By Emission Unit

#### EU=U-LNDFL

- 17 6 NYCRR 211.2: Compliance Demonstration

#### EU=U-WDCPR

- 18 6 NYCRR 211.2: Compliance Demonstration

NOTE: \* preceding the condition number indicates capping.



**FEDERALLY ENFORCEABLE CONDITIONS**  
**\*\*\*\* Facility Level \*\*\*\***

**NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS**

**This section contains terms and conditions which are federally enforceable. Permittees may also have other obligations under regulations of general applicability**

**Item A: Sealing - 6 NYCRR 200.5**

The Commissioner may seal an air contamination source to prevent its operation if compliance with 6 NYCRR Chapter III is not met within the time provided by an order of the Commissioner issued in the case of the violation.

Sealing means labeling or tagging a source to notify any person that operation of the source is prohibited, and also includes physical means of preventing the operation of an air contamination source without resulting in destruction of any equipment associated with such source, and includes, but is not limited to, bolting, chaining or wiring shut control panels, apertures or conduits associated with such source.

No person shall operate any air contamination source sealed by the Commissioner in accordance with this section unless a modification has been made which enables such source to comply with all requirements applicable to such modification.

Unless authorized by the Commissioner, no person shall remove or alter any seal affixed to any contamination source in accordance with this section.

**Item B: Acceptable Ambient Air Quality - 6 NYCRR 200.6**

Notwithstanding the provisions of 6 NYCRR Chapter III, Subchapter A, no person shall allow or permit any air contamination source to emit air contaminants in quantities which alone or in combination with emissions from other air contamination sources would contravene any applicable ambient air quality standard and/or cause air pollution. In such cases where contravention occurs or may occur, the Commissioner shall specify the degree and/or method of emission control required.

**Item C: Maintenance of Equipment - 6 NYCRR 200.7**

Any person who owns or operates an air contamination source which is equipped with an emission control device shall operate such device and keep it in a satisfactory state of maintenance and repair in accordance with ordinary and necessary practices, standards and procedures, inclusive of manufacturer's specifications,





required to operate such device effectively.

**Item D: Unpermitted Emission Sources - 6 NYCRR 201-1.2**

If an existing emission source was subject to the permitting requirements of 6 NYCRR Part 201 at the time of construction or modification, and the owner and/or operator failed to apply for a permit for such emission source then the following provisions apply:

- (a) The owner and/or operator must apply for a permit for such emission source or register the facility in accordance with the provisions of Part 201.
- (b) The emission source or facility is subject to all regulations that were applicable to it at the time of construction or modification and any subsequent requirements applicable to existing sources or facilities.

**Item E: Emergency Defense - 6 NYCRR 201-1.5**

An emergency constitutes an affirmative defense to an action brought for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

(a) The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:

- (1) An emergency occurred and that the facility owner and/or operator can identify the cause(s) of the emergency;
- (2) The equipment at the permitted facility causing the emergency was at the time being properly operated;
- (3) During the period of the emergency the facility owner and/or operator took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and
- (4) The facility owner and/or operator notified the Department within two working days after the event occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

(b) In any enforcement proceeding, the facility owner and/or operator seeking to establish the occurrence of an emergency has the burden of proof.



(c) This provision is in addition to any emergency or upset provision contained in any applicable requirement.

**Item F: Recycling and Salvage - 6 NYCRR 201-1.7**

Where practical, any person who owns or operates an air contamination source shall recycle or salvage air contaminants collected in an air cleaning device according to the requirements of 6 NYCRR.

**Item G: Prohibition of Reintroduction of Collected Contaminants to the Air - 6 NYCRR 201-1.8**

No person shall unnecessarily remove, handle, or cause to be handled, collected air contaminants from an air cleaning device for recycling, salvage or disposal in a manner that would reintroduce them to the outdoor atmosphere.

**Item H: Proof of Eligibility for Sources Defined as Exempt Activities - 6 NYCRR 201-3.2 (a)**

The owner and/or operator of an emission source or unit that is eligible to be exempt, may be required to certify that it operates within the specific criteria described in 6 NYCRR Subpart 201-3. The owner or operator of any such emission source must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility which contains emission sources or units subject to 6 NYCRR Subpart 201-3, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

**Item I: Proof of Eligibility for Sources Defined as Trivial Activities - 6 NYCRR 201-3.3 (a)**

The owner and/or operator of an emission source or unit that is listed as being trivial in 6 NYCRR Part 201 may be required to certify that it operates within the specific criteria described in 6 NYCRR Subpart 201-3. The owner or operator of any such emission source must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility which contains emission sources or units subject to 6 NYCRR Subpart 201-3, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

**Item J: Required Emission Tests - 6 NYCRR 202-1.1**



An acceptable report of measured emissions shall be submitted, as may be required by the Commissioner, to ascertain compliance or noncompliance with any air pollution code, rule, or regulation. Failure to submit a report acceptable to the Commissioner within the time stated shall be sufficient reason for the Commissioner to suspend or deny an operating permit. Notification and acceptable procedures are specified in 6 NYCRR Subpart 202-1.

**Item K: Open Fires Prohibitions - 6 NYCRR 215.2**

Except as allowed by section 215.3 of 6 NYCRR Part 215, no person shall burn, cause, suffer, allow or permit the burning of any materials in an open fire.

**Item L: Permit Exclusion - ECL 19-0305**

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York (NYCRR). The issuance of this permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.

**Item M: Federally Enforceable Requirements - 40 CFR 70.6 (b)**

All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

**FEDERAL APPLICABLE REQUIREMENTS**  
**The following conditions are federally enforceable.**

**Condition 1: Recycling and Emissions Reduction**



Effective between the dates of 11/26/2013 and 11/25/2023

Applicable Federal Requirement:40CFR 82, Subpart F

**Item 1.1:**

The permittee shall comply with all applicable provisions of 40 CFR Part 82.

**Condition 2: Facility Permissible Emissions**

Effective between the dates of 11/26/2013 and 11/25/2023

Applicable Federal Requirement:6 NYCRR 201-7.1

**Item 2.1:**

The sum of emissions from the emission units specified in this permit shall not equal or exceed the following

Potential To Emit (PTE) rate for each regulated contaminant:

CAS No: 0NY210-00-0 (From Mod 1) PTE: 49,000 pounds  
per year

Name: OXIDES OF NITROGEN

**Condition 3: Capping Monitoring Condition**

Effective between the dates of 11/26/2013 and 11/25/2023

Applicable Federal Requirement:6 NYCRR 201-7.1

**Item 3.1:**

Under the authority of 6 NYCRR Part 201-7, this condition contains an emission cap for the purpose of limiting emissions from the facility, emission unit or process to avoid being subject to the following applicable requirement(s) that the facility, emission unit or process would otherwise be subject to:

6 NYCRR Subpart 201-6

**Item 3.2:**

Operation of this facility shall take place in accordance with the approved criteria, emission limits, terms, conditions and standards in this permit.

**Item 3.3:**

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

**Item 3.4:**

On an annual basis, unless otherwise specified below, beginning one year after the granting of an emissions cap, the responsible official shall provide a certification to the Department that the facility has operated all emission units within the limits imposed by the emission cap. This certification shall include a brief summary of the emissions subject to the cap for that time period and a comparison to the threshold levels that would require compliance with an

New York State Department of Environmental Conservation

Permit ID: 1-4734-01810/00001

Facility DEC ID: 1473401810



applicable requirement.

**Item 3.5:**

The emission of pollutants that exceed the applicability thresholds for an applicable requirement, for which the facility has obtained an emissions cap, constitutes a violation of Part 201 and of the Act.

**Item 3.6:**

The Compliance Demonstration activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

**Item 3.7:**

Compliance Demonstration shall include the following monitoring:

Capping: Yes

Monitoring Type: MONITORING OF PROCESS OR CONTROL  
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

Facility total emission of Oxides of Nitrogen (NOx) will be limited to 24.5 tons per year with a federally enforceable emission cap. The facility wide 12-month rolling NOx cap of 24.5 tons/yr includes 22.1 tons/yr from the three (3) diesel-fired chipper/shredder engines and 2.4 tons/yr from the combustion of landfill gas in the flare. Facility must submit an annual report certifying the actual annual emission of NOx.

Parameter Monitored: OXIDES OF NITROGEN

Upper Permit Limit: 24.5 tons per year

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING  
DESCRIPTION

Averaging Method: ANNUAL TOTAL ROLLED MONTHLY

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2014.

Subsequent reports are due every 12 calendar month(s).

**Condition 4: Air pollution prohibited**

**Effective between the dates of 11/26/2013 and 11/25/2023**

**Applicable Federal Requirement: 6 NYCRR 211.1**

**Item 4.1:**

No person shall cause or allow emissions of air contaminants to the outdoor atmosphere of such quantity, characteristic or duration which are injurious to human, plant or animal life or to property, or which unreasonably interfere with the comfortable enjoyment of life or property. Notwithstanding the existence of specific air quality standards or emission limits, this prohibition applies, but is not limited to, any particulate, fume, gas, mist, odor, smoke, vapor, pollen, toxic or deleterious emission, either alone or in combination with others.



**Condition 5: Preventative measures for fugitive particulate emissions.  
Effective between the dates of 11/26/2013 and 11/25/2023**

**Applicable Federal Requirement:6 NYCRR 211.1**

**Item 5.1: Fugitive particulate emissions must be reasonably controlled at each site of operations.** The permittee shall use, but is not limited to water spray dust suppression equipment on all processes, storage piles, haul roads, etc. as needed to insure that no visible emissions extend beyond the property line of the facility. The permittee shall not operate any process emissions source at the facility without functional water spray dust suppression equipment. In the event of failure of such fugitive particulate emission control equipment due to weather, mechanical breakdown, or other conditions, the facility shall cease operation of its portable equipment if unable to operate within the permitted parameters without the use of such control equipment.

**Condition 1-1: Compliance Demonstration  
Effective between the dates of 02/23/2015 and 11/25/2023**

**Applicable Federal Requirement:6 NYCRR 225-1.2 (g)**

**Item 1-1.1:**

The Compliance Demonstration activity will be performed for the Facility.

**Item 1-1.2:**

Compliance Demonstration shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS

Monitoring Description:

Owners and/or operators of a stationary combustion installation that fires distillate oil other than number two heating oil are limited to the purchase of distillate oil with 0.0015 percent sulfur by weight or less on or after July 1, 2014. Compliance with this limit will be based on vendor certifications.

Data collected pursuant to this Subpart must be tabulated and summarized in a form acceptable to the Department, and must be retained for at least five years. The owner of a Title V facility must furnish to the Department such records and summaries, on a semiannual calendar basis, within 30 days after the end of the semiannual period. All other facility owners or distributors must submit these records and summaries upon request of the Department.

Work Practice Type: PARAMETER OF PROCESS MATERIAL  
Process Material: DISTILLATES - NUMBER 1 AND NUMBER 2 OIL  
Parameter Monitored: SULFUR CONTENT  
Upper Permit Limit: 0.0015 percent by weight  
Monitoring Frequency: PER DELIVERY



Averaging Method: MAXIMUM - NOT TO BE EXCEEDED AT ANY  
TIME (INSTANTANEOUS/DISCRETE OR GRAB)  
Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

**Condition 1-2: Compliance Demonstration**  
Effective between the dates of 02/23/2015 and 11/25/2023

**Applicable Federal Requirement:6 NYCRR 225-1.2 (h)**

**Item 1-2.1:**

The Compliance Demonstration activity will be performed for the Facility.

**Item 1-2.2:**

Compliance Demonstration shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC  
OPERATIONS

Monitoring Description:

Owners and/or operators of a stationary combustion installations that fire distillate oil are limited to the firing of distillate oil with 0.0015 percent sulfur by weight or less on or after July 1, 2016. Compliance with this limit will be based on vendor certifications.

Data collected pursuant to this Subpart must be tabulated and summarized in a form acceptable to the Department, and must be retained for at least five years. The owner of a Title V facility must furnish to the Department such records and summaries, on a semiannual calendar basis, within 30 days after the end of the semiannual period. All other facility owners or distributors must submit these records and summaries upon request of the Department.

Work Practice Type: PARAMETER OF PROCESS MATERIAL  
Process Material: DISTILLATES - NUMBER 1 AND NUMBER 2 OIL  
Parameter Monitored: SULFUR CONTENT  
Upper Permit Limit: 0.0015 percent by weight  
Monitoring Frequency: PER DELIVERY  
Averaging Method: MAXIMUM - NOT TO BE EXCEEDED AT ANY  
TIME (INSTANTANEOUS/DISCRETE OR GRAB)  
Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

**Condition 6: Compliance Demonstration**  
Effective between the dates of 11/26/2013 and 11/25/2023

**Applicable Federal Requirement:6 NYCRR 227-1.7**

**Item 6.1:**

The Compliance Demonstration activity will be performed for the Facility.

**Item 6.2:**

**New York State Department of Environmental Conservation**

Permit ID: 1-4734-01810/00001

Facility DEC ID: 1473401810



Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

(a) Emission data. Any person who owns or operates a stationary combustion installation described in 6 NYCRR Part 227-1 shall provide pertinent data concerning emissions when so requested by the commissioner.

(b) Test methods. Sampling, compositing and analysis of fuel samples shall be carried out in accordance with the most recent ASTM standard methods or equivalent methods acceptable to the commissioner.

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2014.

Subsequent reports are due every 12 calendar month(s).

**Condition 1-3: Applicability**

**Effective between the dates of 02/23/2015 and 11/25/2023**

**Applicable Federal Requirement:40CFR 60, NSPS Subpart III**

**Item 1-3.1:**

Facilities that have stationary compression ignition internal combustion engines must comply with applicable portions of 40 CFR 60 Subpart III.

**Condition 1-4: Compliance and Enforcement**

**Effective between the dates of 02/23/2015 and 11/25/2023**

**Applicable Federal Requirement:40CFR 60, NSPS Subpart III**

**Item 1-4.1:**

The Department has not accepted delegation of 40 CFR Part 60 Subpart III. Any questions concerning compliance and/or enforcement of this regulation should be referred to USEPA Region 2, 290 Broadway, 21st Floor, New York, NY 10007-1866; (212) 637-4080. Should the Department decide to accept delegation of 40 CFR Part 60 Subpart III during the term of this permit, enforcement of this regulation will revert to the Department as of the effective date of delegation.

\*\*\*\* Emission Unit Level \*\*\*\*

**Condition 7: Process Permissible Emissions**

**Effective between the dates of 11/26/2013 and 11/25/2023**

**Applicable Federal Requirement:6 NYCRR 201-7.1**



**New York State Department of Environmental Conservation**

Permit ID: 1-4734-01810/00001

Facility DEC ID: 1473401810



**Item 7.1:**

The sum of emissions from the regulated process cited shall not exceed the following Potential to Emit (PTE) rates for each regulated contaminant:

Emission Unit: U-LNDFL Process: 001  
CAS No: 0NY210-00-0 (From Mod 0)  
Name: OXIDES OF NITROGEN  
PTE(s): 0.54 pounds per hour  
4,710.3 pounds per year

Emission Unit: U-WDCPR Process: 002  
CAS No: 0NY210-00-0 (From Mod 1)  
Name: OXIDES OF NITROGEN  
PTE(s): 8.2 pounds per hour  
44,226 pounds per year

**Condition 8: Compliance Demonstration**  
**Effective between the dates of 11/26/2013 and 11/25/2023**

**Applicable Federal Requirement:6 NYCRR 227-1.3**

**Item 8.1:**

The Compliance Demonstration activity will be performed for:

Emission Unit: U-WDCPR

**Item 8.2:**

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Operators of oil-fired internal combustion engines which are not exempt from permitting and where a continuous opacity monitor is not utilized for measuring smoke emissions, shall be required to perform the following:

1) Observe the stack for each internal combustion engine which is operating on oil once per day for visible emissions. This observation(s) must be conducted during daylight hours except during adverse weather conditions (fog, rain, or snow).

2) The results of each observation must be recorded in a bound logbook or other format acceptable to the Department. The following data must be recorded for each stack:

- weather condition
- was a plume observed?



This logbook must be retained at the facility for five (5) years after the date of the last entry.

3) If the operator observes any visible emissions (other than steam - see below) two consecutive days firing oil (the firing of other fuels in between days of firing oil does not count as an interruption in the consecutive days of firing oil), then a Method 9 analysis (based upon a 6-minute mean) of the affected emission point(s) must be conducted within two (2) business days of such occurrence. The results of the Method 9 analysis must be recorded in the logbook. The operator must contact the Regional Air Pollution Control Engineer within one (1) business day of performing the Method 9 analysis if the opacity standard is contravened. Upon notification, any corrective actions or future compliance schedules shall be presented to the Department for acceptance.

**\*\* NOTE \*\*** Steam plumes generally form after leaving the top of the stack (this is known as a detached plume). The distance between the stack and the beginning of the detached plume may vary, however, there is (normally) a distinctive distance between the plume and stack. Steam plumes are white in color and have a billowy consistency. Steam plumes dissipate within a short distance of the stack (the colder the air the longer the steam plume will last) and leave no dispersion trail downwind of the stack.

Reports due 30 days after the reporting period.

Monitoring Frequency: DAILY

Reporting Requirements: UPON REQUEST BY REGULATORY AGENCY



**STATE ONLY ENFORCEABLE CONDITIONS**  
**\*\*\*\* Facility Level \*\*\*\***

**NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS**  
**This section contains terms and conditions which are not federally enforceable. Permittees may also have other obligations under regulations of general applicability**

**Item A: Public Access to Recordkeeping for Facilities With State Facility Permits - 6 NYCRR 201-1.10 (a)**

Where facility owners and/or operators keep records pursuant to compliance with the requirements of 6 NYCRR Subpart 201-5.4, and/or the emission capping requirements of 6 NYCRR Subpart 201-7, the Department will make such records available to the public upon request in accordance with 6 NYCRR Part 616 - Public Access to Records. Facility owners and/or operators must submit the records required to comply with the request within sixty working days of written notification by the Department.

**Item B: General Provisions for State Enforceable Permit Terms and Condition - 6 NYCRR Part 201-5**

Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all criteria, emission limits, terms, conditions, and standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

**STATE ONLY APPLICABLE REQUIREMENTS**

**The following conditions are state only enforceable.**

**Condition 9: Contaminant List**  
**Effective between the dates of 11/26/2013 and 11/25/2023**



**Applicable State Requirement:ECL 19-0301**

**Item 9.1:**

Emissions of the following contaminants are subject to contaminant specific requirements in this permit(emission limits, control requirements or compliance monitoring conditions).

CAS No: 0NY210-00-0

Name: OXIDES OF NITROGEN

**Condition 10: Malfunctions and start-up/shutdown activities  
Effective between the dates of 11/26/2013 and 11/25/2023**

**Applicable State Requirement:6 NYCRR 201-1.4**

**Item 10.1:**

(a) The facility owner or operator shall take all necessary and appropriate actions to prevent the emission of air pollutants that result in contravention of any applicable emission standard during periods of start-up, shutdown, or malfunction.

(b) The facility owner or operator shall compile and maintain records of all equipment malfunctions, maintenance, or start-up/shutdown activities when they can be expected to result in an exceedance of any applicable emission standard, and shall submit a report of such activities to the department when requested to do so, or when so required by a condition of a permit issued for the corresponding air contamination source. Such reports shall state whether any violations occurred and, if so, whether they were unavoidable, include the time, frequency and duration of the maintenance and/or start-up/shutdown activities, and an estimate of the emission rates of any air contaminants released. Such records shall be maintained for a period of at least five years and made available for review to department representatives upon request. Facility owners or operators subject to continuous stack monitoring and quarterly reporting requirements need not submit additional reports for equipment maintenance or start-up/shutdown activities for the facility to the department.

(c) In the event that emissions of air contaminants in excess of any emission standard in this Subchapter occur due to a malfunction, the facility owner or operator shall compile and maintain records of the malfunction and notify the department as soon as possible during normal working hours, but not later than two working days after becoming aware that the malfunction occurred. When requested by the department, the facility owner or operator shall submit a written report to the department describing the malfunction, the corrective action taken, identification of air contaminants, and an estimate of the emission rates.

(d) The department may also require the owner or operator to include, in reports described under Subdivisions (b) and (c) of this Section, an estimate of the maximum ground level concentration of each air contaminant emitted and the effect of such emissions.

(e) A violation of any applicable emission standard resulting from start-up, shutdown, or malfunction conditions at a permitted or registered facility may not be subject to an enforcement action by the department and/or penalty if the department determines, in its sole discretion, that such a violation was unavoidable. The actions and recordkeeping and reporting requirements listed above must be adhered to in such circumstances.



**Condition 11: Emission Unit Definition**  
**Effective between the dates of 11/26/2013 and 11/25/2023**

**Applicable State Requirement:6 NYCRR Subpart 201-5**

**Item 11.1(From Mod 1):**

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: U-WDCPR

Emission Unit Description:

This emission unit consists of three (3) ICE driven woodchipping/shredding units. The Town of Smithtown (Town) owns and operates three (3) woodchipping/shredding units at the Municipal Services Facility . Each unit is powered by a diesel-powered internal combustion engine (ICE). Two engines are rated at 630 horsepower and the third is rated at 765 horsepower. One of the three units is used only for back-up purposes, and as such, all three units will not operate simultaneously. The engines are capable of combusting diesel or a diesel/biodiesel formulation with a maximum biodiesel content of 5% (B5). Total hours of operation for all three units combined will be limited to 5,400 hours per year.

**Item 11.2(From Mod 0):**

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: U-LNDFL

Emission Unit Description:

Emission unit consists of landfill cells 1 through 6 ( Phases I and II ), an active gas collection system and a utility (open) flare used to combust the collected landfill gas. The landfill is closed and has not accepted waste since 1997. The Town of Smithtown (Town) owns and operates a landfill gas candlestick (open) flare as part of the landfill gas collection and control system at the Municipal Services Facility .

**Condition 12: Renewal deadlines for state facility permits**  
**Effective between the dates of 11/26/2013 and 11/25/2023**

**Applicable State Requirement:6 NYCRR 201-5.2 (c)**

**Item 12.1:**

The owner or operator of a facility having an issued state facility permit shall submit a complete application at least 180 days, but not more than eighteen months, prior to the date of permit expiration for permit renewal purposes.

**Condition 13: Compliance Demonstration**  
**Effective between the dates of 11/26/2013 and 11/25/2023**

**Applicable State Requirement:6 NYCRR 201-5.3 (c)**

**New York State Department of Environmental Conservation**

Permit ID: 1-4734-01810/00001

Facility DEC ID: 1473401810



**Item 13.1:**

The Compliance Demonstration activity will be performed for the Facility.

**Item 13.2:**

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Any reports or submissions required by this permit shall be submitted to the Regional Air Pollution Control Engineer (RAPCE) at the following address:

Division of Air Resources  
NYS Dept. of Environmental Conservation  
Region 1  
SUNY at Stony Brook  
Building 40  
Stony Brook, NY 11790-2356

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2014.

Subsequent reports are due every 12 calendar month(s).

**Condition 14: Visible Emissions Limited**  
**Effective between the dates of 11/26/2013 and 11/25/2023**

**Applicable State Requirement:6 NYCRR 211.2**

**Item 14.1:**

Except as permitted by a specific part of this Subchapter and for open fires for which a restricted burning permit has been issued, no person shall cause or allow any air contamination source to emit any material having an opacity equal to or greater than 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent opacity.

**\*\*\*\* Emission Unit Level \*\*\*\***

**Condition 15: Emission Point Definition By Emission Unit**  
**Effective between the dates of 11/26/2013 and 11/25/2023**

**Applicable State Requirement:6 NYCRR Subpart 201-5**

**Item 15.1(From Mod 1):**

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: U-WDCPR

Emission Point: 00004

Height (ft.): 12

Diameter (in.): 8

NYTMN (km.): 4526.093

NYTME (km.): 645.23



**Item 15.2(From Mod 0):**

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: U-LNDFL

Emission Point: 00001

Height (ft.): 23 Diameter (in.): 4  
NYTMN (km.): 4526.307 NYTME (km.): 645.035

**Item 15.3(From Mod 0):**

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: U-WDCPR

Emission Point: 00002

Height (ft.): 11 Diameter (in.): 5  
NYTMN (km.): 4526.088 NYTME (km.): 645.23

Emission Point: 00003

Height (ft.): 11 Diameter (in.): 5  
NYTMN (km.): 4526.088 NYTME (km.): 645.235

**Condition 16: Process Definition By Emission Unit  
Effective between the dates of 11/26/2013 and 11/25/2023**

**Applicable State Requirement:6 NYCRR Subpart 201-5**

**Item 16.1(From Mod 1):**

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-WDCPR

Process: 002 Source Classification Code: 2-02-001-07

Process Description:

Three (3) wood chipper/ shredder units firing biodiesel blended fuel. Fuel blend is 5% biodiesel (B5) and 95% conventional diesel (Distillate oil No. 2).

Emission Source/Control: 00WC1 - Combustion  
Design Capacity: 630 horsepower (mechanical)

Emission Source/Control: 00WC2 - Combustion  
Design Capacity: 630 horsepower (mechanical)

Emission Source/Control: 00WC4 - Combustion  
Design Capacity: 765 horsepower (mechanical)

**Item 16.2(From Mod 0):**

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-LNDFL

Process: 001 Source Classification Code: 5-03-006-01



Process Description:

Landfill gas is collected and directed to a utility (open) flare for combustion. The throughput information below represents methane generation through the EPA LandGEM model for the year 2010. Actual methane throughput is expected to be much less.

Emission Source/Control: FLARE - Control  
Control Type: FLARING

Emission Source/Control: LNDNFL - Process

**Condition 17: Compliance Demonstration**  
**Effective between the dates of 11/26/2013 and 11/25/2023**

**Applicable State Requirement:6 NYCRR 211.2**

**Item 17.1:**

The Compliance Demonstration activity will be performed for:

Emission Unit: U-LNDNFL

**Item 17.2:**

Compliance Demonstration shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL  
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

Except as permitted by a specific part of Title 6 of the NYCRR, no person shall cause or allow any air contamination source to emit any material having an opacity equal to or greater than 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent opacity.

Operators of air contamination sources that are not exempt from permitting and where a continuous opacity monitor is not utilized for measuring smoke emissions, shall be required to perform the following:

- 1) Observe the stack(s) or vent(s) once per week for visible emissions. This observation(s) must be conducted during daylight hours except during adverse weather conditions (fog, rain, or snow).
- 2) The results of each observation must be recorded in a bound logbook or other format acceptable to the Department. The following data must be recorded for each stack:
  - weather condition
  - was a plume observed?





This logbook must be retained at the facility for five (5) years after the date of the last entry.

3) If the operator observes any visible emissions (other than steam - see below) two consecutive days, then a Method 9 analysis (based upon a 6-minute mean) of the affected emission point(s) must be conducted within two (2) business days of such occurrence. The results of the Method 9 analysis must be recorded in the logbook. The operator must contact the Regional Air Pollution Control Engineer within one (1) business day of performing the Method 9 analysis if the opacity standard is contravened. Upon notification, any corrective actions or future compliance schedules shall be presented to the Department for acceptance.

**\*\* NOTE \*\*** Steam plumes generally form after leaving the top of the stack (this is known as a detached plume). The distance between the stack and the beginning of the detached plume may vary, however, there is (normally) a distinctive distance between the plume and stack. Steam plumes are white in color and have a billowy consistency. Steam plumes dissipate within a short distance of the stack (the colder the air the longer the steam plume will last) and leave no dispersion trail downwind of the stack.

Reports due 30 days after the reporting period.

Parameter Monitored: OPACITY

Upper Permit Limit: 20 percent

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Averaging Method: 6 MINUTE AVERAGE

Reporting Requirements: UPON REQUEST BY REGULATORY AGENCY

**Condition 18: Compliance Demonstration**  
**Effective between the dates of 11/26/2013 and 11/25/2023**

**Applicable State Requirement:6 NYCRR 211.2**

**Item 18.1:**

The Compliance Demonstration activity will be performed for:

Emission Unit: U-WDCPR

**Item 18.2:**

Compliance Demonstration shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL DEVICE PARAMETERS AS SURROGATE



Monitoring Description:

Except as permitted by a specific part of Title 6 of the NYCRR, no person shall cause or allow any air contamination source to emit any material having an opacity equal to or greater than 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent opacity.

Operators of air contamination sources that are not exempt from permitting and where a continuous opacity monitor is not utilized for measuring smoke emissions, shall be required to perform the following:

1) Observe the stack(s) or vent(s) once per day for visible emissions. This observation(s) must be conducted during daylight hours except during adverse weather conditions (fog, rain, or snow).

2) The results of each observation must be recorded in a bound logbook or other format acceptable to the Department. The following data must be recorded for each stack:

- weather condition
- was a plume observed?

This logbook must be retained at the facility for five (5) years after the date of the last entry.

3) If the operator observes any visible emissions (other than steam - see below) two consecutive days, then a Method 9 analysis (based upon a 6-minute mean) of the affected emission point(s) must be conducted within two (2) business days of such occurrence. The results of the Method 9 analysis must be recorded in the logbook. The operator must contact the Regional Air Pollution Control Engineer within one (1) business day of performing the Method 9 analysis if the opacity standard is contravened. Upon notification, any corrective actions or future compliance schedules shall be presented to the Department for acceptance.

**\*\* NOTE \*\*** Steam plumes generally form after leaving the top of the stack (this is known as a detached plume). The distance between the stack and the beginning of the detached plume may vary, however, there is (normally) a distinctive distance between the plume and stack. Steam plumes are white in color and have a billowy consistency. Steam plumes dissipate within a short distance of the stack (the colder the air the longer the steam plume will last) and leave no dispersion trail downwind of the stack.



Reports due 30 days after the reporting period.

Parameter Monitored: OPACITY  
Upper Permit Limit: 20 percent  
Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING  
DESCRIPTION  
Averaging Method: 6 MINUTE AVERAGE  
Reporting Requirements: UPON REQUEST BY REGULATORY AGENCY

