

Facility DEC ID: 1473803119

PERMIT
Under the Environmental Conservation Law (ECL)

IDENTIFICATION INFORMATION

Permit Type: Title IV (Phase II Acid Rain)

Permit ID: 1-4738-03119/00002

Effective Date:

Expiration Date:

Permit Type: Air Title V Facility

Permit ID: 1-4738-03119/00004

Effective Date:

Expiration Date:

Permit Issued To: HAWKEYE ENERGY GREENPORT LLC
336 S SERVICE RD
MELVILLE, NY 11747

Contact: JOHN REYNOLDS
HAWKEYE ENERGY GREENPORT LLC
336 S Service Rd
Melville, NY 11747-3232
(516) 336-6720

Facility: HAWKEYE ENERGY GREENPORT
1885 MOORES LN|SCTM # 1001-40-4-1.1
GREENPORT, NY 11944

Contact: ROBERT ZORCIK
HAWKEYE ENERGY GREENPORT
1885 MOORES LN
GREENPORT, NY 11944
(516) 369-0969

Description:

This is a renewal of Air Title IV and Title V permit for Hawkeye Energy Greenport power generating facility. The facility operates as a peaking unit and receives dispatch instructions on a day-ahead basis from New York ISO. The facility has one emission unit which consists of two 27 MW Pratt & Whitney FT8 simple cycle combustion turbines. The turbines are fired only on low-sulfur (.0015%) distillate fuel. Distillate oil is stored in two, 150,000 gallon storage tanks. The facility is capping NOx emissions to stay below 22.5 tons per year on an annual average basis rolled daily. The facility emissions are controlled by carbon monoxide catalysts and a selective catalytic reactor (SCR). Renewal 3 does not include changes to facility equipment and processes.

Facility DEC ID: 1473803119

By acceptance of this permit, the permittee agrees that the permit is contingent upon strict compliance with the ECL, all applicable regulations, the General Conditions specified and any Special Conditions included as part of this permit.

Permit Administrator: KEVIN A KISPERT
 SUNY @ STONY BROOK
 50 CIRCLE RD
 STONY BROOK, NY 11790

Authorized Signature: _____ Date: ___ / ___ / ___

Facility DEC ID: 1473803119

Notification of Other State Permittee Obligations

Item A: Permittee Accepts Legal Responsibility and Agrees to Indemnification

The permittee expressly agrees to indemnify and hold harmless the Department of Environmental Conservation of the State of New York, its representatives, employees and agents ("DEC") for all claims, suits, actions, and damages, to the extent attributable to the permittee's acts or omissions in connection with the compliance permittee's undertaking of activities in connection with, or operation and maintenance of, the facility or facilities authorized by the permit whether in compliance or not in any compliance with the terms and conditions of the permit. This indemnification does not extend to any claims, suits, actions, or damages to the extent attributable to DEC's own negligent or intentional acts or omissions, or to any claims, suits, or actions naming the DEC and arising under article 78 of the New York Civil Practice Laws and Rules or any citizen suit or civil rights provision under federal or state laws.

Item B: Permittee's Contractors to Comply with Permit

The permittee is responsible for informing its independent contractors, employees, agents and assigns of their responsibility to comply with this permit, including all special conditions while acting as the permittee's agent with respect to the permitted activities, and such persons shall be subject to the same sanctions for violations of the Environmental Conservation Law as those prescribed for the permittee.

Item C: Permittee Responsible for Obtaining Other Required Permits

The permittee is responsible for obtaining any other permits, approvals, lands, easements and rights-of-way that may be required to carry out the activities that are authorized by this permit.

Item D: No Right to Trespass or Interfere with Riparian Rights

This permit does not convey to the permittee any right to trespass upon the lands or interfere with the riparian rights of others in order to perform the permitted work nor does it authorize the impairment of any rights, title, or interest in real or personal property held or vested in a person not a party to the permit.

Facility DEC ID: 1473803119

PAGE LOCATION OF CONDITIONS

PAGE

DEC GENERAL CONDITIONS

General Provisions

- 5 1 Facility Inspection by the Department
- 5 2 Relationship of this Permit to Other Department Orders and Determinations
- 5 3 Applications for permit renewals, modifications and transfers
- 6 4 Permit modifications, suspensions or revocations by the Department

Facility Level

- 6 5 Submission of application for permit modification or renewal - REGION 1 HEADQUARTERS

Facility DEC ID: 1473803119

DEC GENERAL CONDITIONS

**** General Provisions ****

For the purpose of your Title V permit, the following section contains state-only enforceable terms and conditions.

GENERAL CONDITIONS - Apply to ALL Authorized Permits.

Condition 1: Facility Inspection by the Department

Applicable State Requirement: ECL 19-0305

Item 1.1:

The permitted site or facility, including relevant records, is subject to inspection at reasonable hours and intervals by an authorized representative of the Department of Environmental Conservation (the Department) to determine whether the permittee is complying with this permit and the ECL. Such representative may order the work suspended pursuant to ECL 71-0301 and SAPA 401(3).

Item 1.2:

The permittee shall provide a person to accompany the Department's representative during an inspection to the permit area when requested by the Department.

Item 1.3:

A copy of this permit, including all referenced maps, drawings and special conditions, must be available for inspection by the Department at all times at the project site or facility. Failure to produce a copy of the permit upon request by a Department representative is a violation of this permit.

Condition 2: Relationship of this Permit to Other Department Orders and Determinations

Applicable State Requirement: ECL 3-0301 (2) (m)

Item 2.1:

Unless expressly provided for by the Department, issuance of this permit does not modify, supersede or rescind any order or determination previously issued by the Department or any of the terms, conditions or requirements contained in such order or determination.

Condition 3: Applications for permit renewals, modifications and transfers

Applicable State Requirement: 6 NYCRR 621.11

Item 3.1:

The permittee must submit a separate written application to the Department for renewal, modification or transfer of this permit. Such application must include any forms or supplemental information the Department requires. Any renewal, modification or transfer granted by the Department must be in writing.

Item 3.2:

The permittee must submit a renewal application at least 180 days before the expiration of permits for Title V and State Facility Permits.

Item 3.3

Permits are transferrable with the approval of the department unless specifically prohibited by the statute, regulation or another permit condition. Applications for permit transfer should be

Facility DEC ID: 1473803119

submitted prior to actual transfer of ownership.

Condition 4: Permit modifications, suspensions or revocations by the Department
Applicable State Requirement: 6 NYCRR 621.13

Item 4.1:

The Department reserves the right to exercise all available authority to modify, suspend, or revoke this permit in accordance with 6NYCRR Part 621. The grounds for modification, suspension or revocation include:

- a) materially false or inaccurate statements in the permit application or supporting papers;
- b) failure by the permittee to comply with any terms or conditions of the permit;
- c) exceeding the scope of the project as described in the permit application;
- d) newly discovered material information or a material change in environmental conditions, relevant technology or applicable law or regulations since the issuance of the existing permit;
- e) noncompliance with previously issued permit conditions, orders of the commissioner, any provisions of the Environmental Conservation Law or regulations of the Department related to the permitted activity.

****** Facility Level ******

Condition 5: Submission of application for permit modification or renewal - REGION 1 HEADQUARTERS
Applicable State Requirement: 6 NYCRR 621.6 (a)

Item 5.1:

Applications for permit modification or renewal are to be submitted to:
NYSDEC Regional Permit Administrator
Region 1 Headquarters
Division of Environmental Permits
Stony Brook University
50 Circle Road
Stony Brook, NY 11790-3409
(631) 444-0365

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

Permit Under the Environmental Conservation Law (ECL)

ARTICLE 19: AIR POLLUTION CONTROL - TITLE V PERMIT

IDENTIFICATION INFORMATION

Permit Issued To: HAWKEYE ENERGY GREENPORT LLC
336 S SERVICE RD
MELVILLE, NY 11747

Facility: HAWKEYE ENERGY GREENPORT
1885 MOORES LN|SCTM # 1001-40-4-1.1
GREENPORT, NY 11944

Authorized Activity By Standard Industrial Classification Code:
4911 - ELECTRIC SERVICES

Permit Effective Date:

Permit Expiration Date:

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

PAGE LOCATION OF CONDITIONS

PAGE

FEDERALLY ENFORCEABLE CONDITIONS

Facility Level

- 7 1 6 NYCRR 200.6: Acceptable Ambient Air Quality
- 8 2 6 NYCRR 201-6.4 (a) (7): Fees
- 8 3 6 NYCRR 201-6.4 (c): Recordkeeping and Reporting of
Compliance Monitoring
- 8 4 6 NYCRR 201-6.4 (c) (2): Compliance Certification
- 9 5 6 NYCRR 201-6.4 (c) (3) (ii): Compliance Certification
- 11 6 6 NYCRR 201-6.4 (e): Compliance Certification
- 13 7 6 NYCRR 202-2.5: Recordkeeping requirements
- 13 8 6 NYCRR 215.2: Open Fires - Prohibitions
- 14 9 6 NYCRR 200.7: Maintenance of Equipment
- 15 10 6 NYCRR 201-1.7: Recycling and Salvage
- 15 11 6 NYCRR 201-1.8: Prohibition of Reintroduction of
Collected Contaminants to the air
- 15 12 6 NYCRR 201-3.2 (a): Exempt Sources - Proof of Eligibility
- 15 13 6 NYCRR 201-3.3 (a): Trivial Sources - Proof of Eligibility
- 15 14 6 NYCRR 201-6.4 (a) (4): Requirement to Provide Information
- 16 15 6 NYCRR 201-6.4 (a) (8): Right to Inspect
- 16 16 6 NYCRR 202-1.1: Required Emissions Tests
- 17 17 40 CFR Part 68: Accidental release provisions.
- 17 18 40CFR 82, Subpart F: Recycling and Emissions Reduction
- 17 19 6 NYCRR Subpart 201-6: Emission Unit Definition
- 18 20 6 NYCRR 201-6.4 (d) (4): Progress Reports Due Semiannually
- 18 21 6 NYCRR 201-6.4 (f): Operational Flexibility
- 18 22 6 NYCRR Subpart 201-7: Facility Permissible Emissions
- 19 *23 6 NYCRR Subpart 201-7: Capping Monitoring Condition
- 20 24 6 NYCRR 202-2.1 (c): Compliance Certification
- 21 25 6 NYCRR 202-2.4 (a) (3): Statement dates for emissions statements.
- 21 26 6 NYCRR 211.2: Visible Emissions Limited
- 21 27 6 NYCRR 225-1.2 (d): Compliance Certification
- 22 28 6 NYCRR 227-1.4 (a): Compliance Certification
- 23 29 40CFR 60.4, NSPS Subpart A: EPA Region 2 address.
- 23 30 40CFR 60.7(a), NSPS Subpart A: Modification Notification
- 23 31 40CFR 60.7(b), NSPS Subpart A: Recordkeeping requirements.
- 24 32 40CFR 60.7(c), NSPS Subpart A: Compliance Certification
- 25 33 40CFR 60.7(f), NSPS Subpart A: Facility files for subject sources.
- 25 34 40CFR 60.12, NSPS Subpart A: Circumvention.
- 25 35 40CFR 60.13, NSPS Subpart A: Monitoring requirements.
- 25 36 40CFR 60.14, NSPS Subpart A: Modifications.
- 25 37 40CFR 60.15, NSPS Subpart A: Reconstruction
- 26 38 40CFR 60.334(b), NSPS Subpart GG: CEMS
- 26 39 40 CFR Part 72: Facility Subject to Title IV Acid
Rain Regulations and Permitting
- 27 40 40 CFR Part 97: Federal Cross-State Air Pollution Regulation (CSAPR)
- 27 41 40CFR 97.406, Subpart AAAAA: Compliance Certification
- 28 42 40CFR 97.606, Subpart CCCCC: Compliance Certification

Emission Unit Level

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

29 43 6 NYCRR Subpart 201-6: Emission Point Definition By Emission Unit

EU=U-00001

- 30 44 6 NYCRR Subpart 201-6: Compliance Certification
- 30 45 6 NYCRR Subpart 201-6: Compliance Certification
- 31 46 6 NYCRR 202-1.1: Required emission tests
- 31 47 40CFR 60.334(a), NSPS Subpart GG: Compliance Certification

EU=U-00001,EP=EP001,Proc=DFO

- 32 48 6 NYCRR Subpart 201-6: Compliance Certification
- 32 49 6 NYCRR Subpart 201-6: Compliance Certification
- 33 50 6 NYCRR Subpart 201-6: Compliance Certification
- 34 51 6 NYCRR Subpart 201-6: Compliance Certification
- 35 52 6 NYCRR Subpart 201-6: Compliance Certification
- 36 53 6 NYCRR Subpart 201-6: Compliance Certification

STATE ONLY ENFORCEABLE CONDITIONS

Facility Level

- 39 54 ECL 19-0301: Contaminant List
- 39 55 6 NYCRR 201-1.4: Malfunctions and Start-up/Shutdown Activities
- 40 56 6 NYCRR 201-6.5 (a): CLCPA Applicability
- 41 57 6 NYCRR 211.1: Air pollution prohibited
- 41 58 6 NYCRR 242-1.5: CO2 Budget Trading Program - Excess emission requirements
- 41 59 6 NYCRR 242-1.5: Compliance Demonstration
- 43 60 6 NYCRR 242-1.5: Compliance Demonstration
- 44 61 6 NYCRR Subpart 242-4: Compliance Demonstration
- 45 62 6 NYCRR 242-8.5: Compliance Demonstration
- 47 63 6 NYCRR 251.6 (f): Compliance Demonstration
- 48 64 6 NYCRR 253-1.4: Compliance Demonstration
- 49 65 6 NYCRR 253-1.7: Compliance Demonstration

Emission Unit Level

EU=U-00001

- 51 66 6 NYCRR Subpart 201-5: General Provisions
- 51 67 6 NYCRR 251.3 (b): Compliance Demonstration

NOTE: * preceding the condition number indicates capping.

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

FEDERALLY ENFORCEABLE CONDITIONS

Renewal 3/DRAFT

**** Facility Level ****

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

The items listed below are not subject to the annual compliance certification requirements under Title V. Permittees may also have other obligations under regulations of general applicability.

Item A: Public Access to Recordkeeping for Title V Facilities - 6 NYCRR 201-1.10 (b)

The Department will make available to the public any permit application, compliance plan, permit, and monitoring and compliance certification report pursuant to Section 503(e) of the Act, except for information entitled to confidential treatment pursuant to 6 NYCRR Part 616 - Public Access to records and Section 114(c) of the Act.

Item B: Timely Application for the Renewal of Title V Permits - 6 NYCRR 201-6.2 (a) (4)

Owners and/or operators of facilities having an issued Title V permit shall submit a complete application at least 180 days, but not more than eighteen months, prior to the date of permit expiration for permit renewal purposes.

Item C: Certification by a Responsible Official - 6 NYCRR 201-6.2 (d) (12)

Any application, form, report or compliance certification required to be submitted pursuant to the federally enforceable portions of this permit shall contain a certification of truth, accuracy and completeness by a responsible official. This certification shall state that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

Item D: Requirement to Comply With All Conditions - 6 NYCRR 201-6.4 (a) (2)

The permittee must comply with all conditions of the Title V facility permit. Any permit non-compliance constitutes a violation of the Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

Item E: Permit Revocation, Modification, Reopening, Reissuance or Termination, and Associated Information Submission Requirements - 6 NYCRR 201-6.4 (a) (3)

This permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.

Item F: Cessation or Reduction of Permitted Activity Not a Defense - 6 NYCRR 201-6.4 (a) (5)

It shall not be a defense for a permittee in an enforcement action to claim that a cessation or reduction in the permitted activity would have been necessary in order to maintain compliance with the conditions of this permit.

Item G: Property Rights - 6 NYCRR 201-6.4 (a) (6)

This permit does not convey any property rights of any sort or any exclusive privilege.

Item H: Severability - 6 NYCRR 201-6.4 (a) (9)

If any provisions, parts or conditions of this permit are found to be invalid or are the subject of a challenge, the remainder of this permit shall continue to be valid.

Item I: Permit Shield - 6 NYCRR 201-6.4 (g)

All permittees granted a Title V facility permit shall be covered under the protection of a permit shield, except as provided under 6 NYCRR Subpart 201-6. Compliance with the conditions of the permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that such applicable requirements are included and are specifically identified in the permit, or the Department, in acting on the permit application or revision, determines in writing that other requirements specifically identified are not applicable to the major stationary source, and the permit includes the determination or a concise summary thereof. Nothing herein shall preclude the Department from revising or revoking the permit pursuant to 6 NYCRR Part 621 or from exercising its summary abatement authority. Nothing in this permit shall alter or affect the following:

- i. The ability of the Department to seek to bring suit on behalf of the State of New York, or the Administrator to seek to bring suit on behalf of the United States, to immediately restrain any person causing or contributing to pollution presenting an imminent and substantial endangerment to public health, welfare or the environment to stop the emission of air pollutants causing or contributing to such pollution;
- ii. The liability of a permittee of the Title V

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

facility for any violation of applicable requirements prior to or at the time of permit issuance;

iii. The applicable requirements of Title IV of the Act;

iv. The ability of the Department or the Administrator to obtain information from the permittee concerning the ability to enter, inspect and monitor the facility.

Item J: Reopening for Cause - 6 NYCRR 201-6.4 (i)

This Title V permit shall be reopened and revised under any of the following circumstances:

i. When additional applicable requirements under the act become applicable to a title V facility with a remaining permit term of three or more years, a reopening shall be completed not later than 18 months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which the permit is due to expire, unless the original permit or any of its terms and conditions has been extended by the department pursuant to the provisions of section 201- 6.6 of this Subpart.

ii. The Department or the Administrator determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.

iii. The Department or the Administrator determines that the Title V permit must be revised or reopened to assure compliance with applicable requirements.

iv. If the permitted facility is an "affected source" subject to the requirements of Title IV of the Act, and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.

Proceedings to reopen and issue Title V facility permits shall follow the same procedures as apply to initial permit issuance but shall affect only those parts of the permit for which cause to reopen exists.

Reopenings shall not be initiated before a notice of such intent is provided to the facility by the Department at least thirty days in advance of the date that the permit

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

is to be reopened, except that the Department may provide a shorter time period in the case of an emergency.

Item K: Permit Exclusion - ECL 19-0305

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York (NYCRR). The issuance of this permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.

Item L: Federally Enforceable Requirements - 40 CFR 70.6 (b)

All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

**MANDATORY FEDERALLY ENFORCEABLE PERMIT CONDITIONS
SUBJECT TO ANNUAL CERTIFICATIONS AT ALL TIMES**

The following federally enforceable permit conditions are mandatory for all Title V permits and are subject to annual compliance certification requirements at all times.

**Condition 1: Acceptable Ambient Air Quality
Effective for entire length of Permit****Applicable Federal Requirement: 6 NYCRR 200.6****Item 1.1:**

Notwithstanding the provisions of 6 NYCRR Chapter III, Subchapter A, no person shall allow or permit any air contamination source to emit air contaminants in quantities which alone or in combination with emissions from other air contamination sources would contravene any applicable ambient air quality standard and/or cause air pollution. In such cases where

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

contravention occurs or may occur, the Commissioner shall specify the degree and/or method of emission control required.

Condition 2: Fees
Effective for entire length of Permit

Applicable Federal Requirement:6 NYCRR 201-6.4 (a) (7)

Item 2.1:

The owner and/or operator of a stationary source shall pay fees to the Department consistent with the fee schedule authorized by ECL 72-0303.

Condition 3: Recordkeeping and Reporting of Compliance Monitoring
Effective for entire length of Permit

Applicable Federal Requirement:6 NYCRR 201-6.4 (c)

Item 3.1:

The following information must be included in any required compliance monitoring records and reports:

- (i) The date, place, and time of sampling or measurements;
- (ii) The date(s) analyses were performed;
- (iii)The company or entity that performed the analyses;
- (iv) The analytical techniques or methods used including quality assurance and quality control procedures if required;
- (v) The results of such analyses including quality assurance data where required; and
- (vi) The operating conditions as existing at the time of sampling or measurement.

Any deviation from permit requirements must be clearly identified in all records and reports. Reports must be certified by a responsible official, consistent with Section 201-6.2 of Part 201.

Condition 4: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement:6 NYCRR 201-6.4 (c) (2)

Item 4.1:

The Compliance Certification activity will be performed for the Facility.

Item 4.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

The owner or operator of a Title V facility must keep all records used to determine compliance with any applicable limit(s) and/or monitoring requirement(s) at the facility (or other Department approved location) for a minimum of five years.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

**Condition 5: Compliance Certification
Effective for entire length of Permit**

Applicable Federal Requirement: 6 NYCRR 201-6.4 (c) (3) (ii)

Item 5.1:

The Compliance Certification activity will be performed for the Facility.

Item 5.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

To meet the requirements of this facility permit with respect to reporting, the permittee must:

Submit reports of any required monitoring at a minimum frequency of every 6 months, based on a calendar year reporting schedule. These reports shall be submitted to the Department within 60 days after the end of a reporting period. All instances of deviations from permit requirements must be clearly identified in such reports. All required reports must be certified by the responsible official for this facility.

Notify the Department and report permit deviations and incidences of noncompliance stating the probable cause of such deviations, and any corrective actions or preventive measures taken. Where the underlying applicable requirement contains a definition of prompt or otherwise specifies a time frame for reporting deviations, that definition or time frame shall govern. Where the underlying applicable requirement fails to address the time frame for reporting deviations, reports of deviations shall be submitted to the permitting authority based on the following schedule:

- (1) For emissions of a hazardous air pollutant (as identified in an applicable regulation) that continue for more than an hour in excess of permit requirements, the report must be made within 24 hours of the occurrence.

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

(2) For emissions of any regulated air pollutant, excluding those listed in paragraph (1) of this section, that continue for more than two hours in excess of permit requirements, the report must be made within 48 hours.

(3) For all other deviations from permit requirements, the report shall be contained in the 6 month monitoring report required above.

(4) This permit may contain a more stringent reporting requirement than required by paragraphs (1), (2) or (3) above. If more stringent reporting requirements have been placed in this permit or exist in applicable requirements that apply to this facility, the more stringent reporting requirement shall apply.

If above paragraphs (1) or (2) are met, the source must notify the permitting authority by telephone during normal business hours at the Regional Office of jurisdiction for this permit, attention Regional Air Pollution Control Engineer (RAPCE) according to the timetable listed in paragraphs (1) and (2) of this section. For deviations and incidences that must be reported outside of normal business hours, on weekends, or holidays, the DEC Spill Hotline phone number at 1-800-457-7362 shall be used. A written notice, certified by a responsible official consistent with 6 NYCRR Part 201-6.2(d)(12), must be submitted within 10 working days of an occurrence for deviations reported under (1) and (2). All deviations reported under paragraphs (1) and (2) of this section must also be identified in the 6 month monitoring report required above.

The provisions of 6 NYCRR 201-1.4 shall apply if the permittee seeks to have a violation excused unless otherwise limited by regulation. In order to have a violation of a federal regulation (such as a new source performance standard or national emissions standard for hazardous air pollutants) excused, the specific federal regulation must provide for an affirmative defense during start-up, shutdowns, malfunctions or upsets. Notwithstanding any recordkeeping and reporting requirements in 6 NYCRR 201-1.4, reports of any deviations shall not be on a less frequent basis than the reporting periods described in paragraphs (1) and (4) above.

In the case of any condition contained in this permit with a reporting requirement of "Upon request by regulatory agency" the permittee shall include in the semiannual report, a statement for each such condition that the

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

monitoring or recordkeeping was performed as required or requested and a listing of all instances of deviations from these requirements.

In the case of any emission testing performed during the previous six month reporting period, either due to a request by the Department, EPA, or a regulatory requirement, the permittee shall include in the semiannual report a summary of the testing results and shall indicate whether or not the Department or EPA has approved the results.

All semiannual reports may be submitted electronically or physically. Electronic reports shall be submitted using the Department's Air Compliance and Emissions Electronic-Reporting system (ACE). If the facility owner or operator elects to send physical copies instead, two copies shall be sent to the Department (one copy to the regional air pollution control engineer (RAPCE) in the regional office and one copy to the Bureau of Quality Assurance (BQA) in the DEC central office) and one copy shall be sent to the Administrator (or his or her representative). Mailing addresses for the above referenced persons are contained in the monitoring condition for 6 NYCRR Part 201-6.4(e), contained elsewhere in this permit.

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)
Reports due 60 days after the reporting period.
Subsequent reports are due every 6 calendar month(s).

Condition 6: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement: 6 NYCRR 201-6.4 (e)

Item 6.1:

The Compliance Certification activity will be performed for the Facility.

Item 6.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Requirements for compliance certifications with terms and conditions contained in this facility permit include the following:

- i. Compliance certifications shall contain:
 - the identification of each term or condition of the permit that is the basis of the certification;
 - the compliance status;

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

- whether compliance was continuous or intermittent;
- the method(s) used for determining the compliance status of the facility, currently and over the reporting period consistent with the monitoring and related recordkeeping and reporting requirements of this permit;
- such other facts as the Department may require to determine the compliance status of the facility as specified in any special permit terms or conditions;
- and
- such additional requirements as may be specified elsewhere in this permit related to compliance certification.

ii. The responsible official must include in the annual certification report all terms and conditions contained in this permit which are identified as being subject to certification, including emission limitations, standards, or work practices. That is, the provisions labeled herein as "Compliance Certification" are not the only provisions of this permit for which an annual certification is required.

iii. Compliance certifications shall be submitted annually. Certification reports are due 60 days after the anniversary date of four consecutive calendar quarters. The first report is due 60 days after the calendar quarter that occurs just prior to the permit anniversary date, unless another quarter has been acceptable by the Department.

iv. All annual compliance certifications may be submitted electronically or physically. Electronic reports shall be submitted using the Department's Air Compliance and Emissions Electronic-Reporting system (ACE). If the facility owner or operator elects to send physical copies instead, two copies shall be sent to the Department (one copy to the regional air pollution control engineer (RAPCE) in the regional office and one copy to the Bureau of Quality Assurance (BQA) in the DEC central office) and one copy shall be sent to the Administrator (or his or her representative). The mailing addresses for the above referenced persons are:

Chief – Air Compliance Branch
USEPA Region 2 DECA/ACB
290 Broadway, 21st Floor
New York, NY 10007

The address for the RAPCE is as follows:

Regional Air Pollution Control Engineer
NYSDEC- Region 1 Headquarters

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

Stony Brook University
50 Circle Road
Stony Brook, NY 11790-3409

The address for the BQA is as follows:

NYSDEC
Bureau of Quality Assurance
625 Broadway
Albany, NY 12233-3258

Monitoring Frequency: ANNUALLY
Reporting Requirements: ANNUALLY (CALENDAR)
Reports due 60 days after the reporting period.
The initial report is due 3/1/2027.
Subsequent reports are due on the same day each year

Condition 7: Recordkeeping requirements
Effective for entire length of Permit

Applicable Federal Requirement:6 NYCRR 202-2.5

Item 7.1:

(a) The following records shall be maintained for at least five years:

(1) a copy of each emission statement submitted to the department; and

(2) records indicating how the information submitted in the emission statement was determined, including any calculations, data, measurements, and estimates used.

(b) These records shall be made available at the facility to the representatives of the department upon request during normal business hours.

Condition 8: Open Fires - Prohibitions
Effective for entire length of Permit

Applicable Federal Requirement:6 NYCRR 215.2

Item 8.1:

Except as allowed by Title 6 NYCRR Section 215.3, no person shall burn, cause, suffer, allow or permit the burning of any materials in an open fire.

Item 8.2

Per Section 215.3, burning in an open fire, provided it is not contrary to other law or regulation, will be allowed as follows:

(a) On-site burning in any town with a total population less than 20,000 of downed limbs and branches (including branches with attached leaves or needles) less than six inches in diameter and eight feet in length between May 15th and the following March 15th. For the purposes of this subdivision, the total population of a town shall include the population of any village or portion thereof located within the town. However, this subdivision shall not be construed to allow burning within any village.

(b) Barbecue grills, maple sugar arches and similar outdoor cooking devices when actually used

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

for cooking or processing food.

(c) Small fires used for cooking and camp fires provided that only charcoal or untreated wood is used as fuel and the fire is not left unattended until extinguished.

(d) On-site burning of agricultural wastes as part of a valid agricultural operation on contiguous agricultural lands larger than five acres actively devoted to agricultural or horticultural use, provided such waste is actually grown or generated on those lands and such waste is capable of being fully burned within a 24-hour period.

(e) The use of liquid petroleum fueled smudge pots to prevent frost damage to crops.

(f) Ceremonial or celebratory bonfires where not otherwise prohibited by law, provided that only untreated wood or other agricultural products are used as fuel and the fire is not left unattended until extinguished.

(g) Small fires that are used to dispose of a flag or religious item, and small fires or other smoke producing process where not otherwise prohibited by law that are used in connection with a religious ceremony.

(h) Burning on an emergency basis of explosive or other dangerous or contraband materials by police or other public safety organization.

(i) Prescribed burns performed according to Part 194 of this Title.

(j) Fire training, including firefighting, fire rescue, and fire/arson investigation training, performed under applicable rules and guidelines of the New York State Department of State's Office of Fire Prevention and Control. For fire training performed on acquired structures, the structures must be emptied and stripped of any material that is toxic, hazardous or likely to emit toxic smoke (such as asbestos, asphalt shingles and vinyl siding or other vinyl products) prior to burning and must be at least 300 feet from other occupied structures. No more than one structure per lot or within a 300 foot radius (whichever is bigger) may be burned in a training exercise.

(k) Individual open fires as approved by the Director of the Division of Air Resources as may be required in response to an outbreak of a plant or animal disease upon request by the commissioner of the Department of Agriculture and Markets, or for the destruction of invasive plant and insect species.

(l) Individual open fires that are otherwise authorized under the environmental conservation law, or by rule or regulation of the Department.

**MANDATORY FEDERALLY ENFORCEABLE PERMIT CONDITIONS
SUBJECT TO ANNUAL CERTIFICATIONS ONLY IF APPLICABLE**

The following federally enforceable permit conditions are mandatory for all Title V permits and are subject to annual compliance certification requirements only if effectuated during the reporting period.

[NOTE: The corresponding annual compliance certification for those conditions not effectuated during the reporting period shall be specified as "not applicable".]

**Condition 9: Maintenance of Equipment
Effective for entire length of Permit**

Applicable Federal Requirement: 6 NYCRR 200.7

Item 9.1:

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

Any person who owns or operates an air contamination source which is equipped with an emission control device shall operate such device and keep it in a satisfactory state of maintenance and repair in accordance with ordinary and necessary practices, standards and procedures, inclusive of manufacturer's specifications, required to operate such device effectively.

Condition 10: Recycling and Salvage
Effective for entire length of Permit

Applicable Federal Requirement:6 NYCRR 201-1.7

Item 10.1:

Where practical, the owner or operator of an air contamination source shall recycle or salvage air contaminants collected in an air cleaning device according to the requirements of the ECL.

Condition 11: Prohibition of Reintroduction of Collected Contaminants to the air
Effective for entire length of Permit

Applicable Federal Requirement:6 NYCRR 201-1.8

Item 11.1:

No person shall unnecessarily remove, handle or cause to be handled, collected air contaminants from an air cleaning device for recycling, salvage or disposal in a manner that would reintroduce them to the outdoor atmosphere.

Condition 12: Exempt Sources - Proof of Eligibility
Effective for entire length of Permit

Applicable Federal Requirement:6 NYCRR 201-3.2 (a)

Item 12.1:

The owner or operator of an emission source or activity that is listed as being exempt may be required to certify that it is operated within the specific criteria described in this Subpart. The owner or operator of any such emission source or activity must maintain all records necessary for demonstrating compliance with this Subpart on-site for a period of five years, and make them available to representatives of the department upon request.

Condition 13: Trivial Sources - Proof of Eligibility
Effective for entire length of Permit

Applicable Federal Requirement:6 NYCRR 201-3.3 (a)

Item 13.1:

The owner or operator of an emission source or activity that is listed as being trivial in this Section may be required to certify that it is operated within the specific criteria described in this Subpart. The owner or operator of any such emission source or activity must maintain all required records on-site for a period of five years and make them available to representatives of the department upon request.

Condition 14: Requirement to Provide Information
Effective for entire length of Permit

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

Applicable Federal Requirement:6 NYCRR 201-6.4 (a) (4)

Item 14.1:

The owner and/or operator shall furnish to the department, within a reasonable time, any information that the department may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the department copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to the administrator along with a claim of confidentiality, if the administrator initiated the request for information or otherwise has need of it.

**Condition 15: Right to Inspect
Effective for entire length of Permit**

Applicable Federal Requirement:6 NYCRR 201-6.4 (a) (8)

Item 15.1:

The department or an authorized representative shall be allowed upon presentation of credentials and other documents as may be required by law to:

- (i) enter upon the permittee's premises where a facility subject to the permitting requirements of this Subpart is located or emissions-related activity is conducted, or where records must be kept under the conditions of the permit;
- (ii) have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;
- (iii) inspect at reasonable times any emission sources, equipment (including monitoring and air pollution control equipment), practices, and operations regulated or required under the permit; and
- (iv) sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the permit or applicable requirements.

**Condition 16: Required Emissions Tests
Effective for entire length of Permit**

Applicable Federal Requirement:6 NYCRR 202-1.1

Item 16.1:

For the purpose of ascertaining compliance or non-compliance with any air pollution control code, rule or regulation, the Department may require the person who owns such air contamination source to submit an acceptable report of measured emissions within a stated time.

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

**Condition 17: Accidental release provisions.
Effective for entire length of Permit**

Applicable Federal Requirement:40 CFR Part 68

Item 17.1:

If a chemical is listed in Tables 1,2,3 or 4 of 40 CFR §68.130 is present in a process in quantities greater than the threshold quantity listed in Tables 1,2,3 or 4, the following requirements will apply:

- a) The owner or operator shall comply with the provisions of 40 CFR Part 68 and;
- b) The owner or operator shall submit at the time of permit issuance (if not previously submitted) one of the following, if such quantities are present:
 - 1) A compliance schedule for meeting the requirements of 40 CFR Part 68 by the date provided in 40 CFR §68.10(a) or,
 - 2) A certification statement that the source is in compliance with all requirements of 40 CFR Part 68, including the registration and submission of the Risk Management Plan. Information should be submitted to:

Risk Management Plan Reporting Center
C/O CSC
8400 Corporate Dr
Carrollton, Md. 20785

**Condition 18: Recycling and Emissions Reduction
Effective for entire length of Permit**

Applicable Federal Requirement:40CFR 82, Subpart F

Item 18.1:

The permittee shall comply with all applicable provisions of 40 CFR Part 82.

The following conditions are subject to annual compliance certification requirements for Title V permits only.

**Condition 19: Emission Unit Definition
Effective for entire length of Permit**

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 19.1:

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: U-00001

Emission Unit Description:

This emission unit contains two 27 MW Pratt & Whitney FT8

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

simple cycle combustion turbines, each capable of firing distillate fuel oil only. Emissions are controlled by a carbon monoxide catalyst and by a SCR. Emissions are continuously monitored by a CEM unit.

Building(s): MAIN
SCR

**Condition 20: Progress Reports Due Semiannually
Effective for entire length of Permit**

Applicable Federal Requirement:6 NYCRR 201-6.4 (d) (4)

Item 20.1:

Progress reports consistent with an applicable schedule of compliance are to be submitted at least semiannually, or at a more frequent period if specified in the applicable requirement or by the department. Such progress reports shall contain the following:

- (i) dates for achieving the activities, milestones, or compliance required in the schedule of compliance, and dates when such activities, milestones or compliance were achieved; and
- (ii) an explanation of why any dates in the schedule of compliance were not or will not be met, and any preventive or corrective measures adopted.

**Condition 21: Operational Flexibility
Effective for entire length of Permit**

Applicable Federal Requirement:6 NYCRR 201-6.4 (f)

Item 21.1:

A permit modification is not required for changes that are provided for in the permit. Such changes include approved alternate operating scenarios and changes that have been submitted and approved pursuant to an established operational flexibility protocol and the requirements of this section. Each such change cannot be a modification under any provision of Title I of the Clean Air Act or exceed, or cause the facility to exceed, an emissions cap or limitation in the permit. The facility owner or operator must incorporate all changes into any compliance certifications, record keeping, and/or reporting required by the permit.

**Condition 22: Facility Permissible Emissions
Effective for entire length of Permit**

Applicable Federal Requirement:6 NYCRR Subpart 201-7

Item 22.1:

The sum of emissions from the emission units specified in this permit shall not equal or exceed the following
Potential To Emit (PTE) rate for each regulated contaminant:

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

CAS No: 0NY210-00-0

PTE: 45,000 pounds per year

Name: OXIDES OF NITROGEN

**Condition 23: Capping Monitoring Condition
Effective for entire length of Permit****Applicable Federal Requirement:6 NYCRR Subpart 201-7****Item 23.1:**

Under the authority of 6 NYCRR Part 201-7, this condition contains an emission cap for the purpose of limiting emissions from the facility, emission unit or process to avoid being subject to the following applicable requirement(s) that the facility, emission unit or process would otherwise be subject to:

6 NYCRR Subpart 227-2

6 NYCRR Subpart 231-2

Item 23.2:

Operation of this facility shall take place in accordance with the approved criteria, emission limits, terms, conditions and standards in this permit.

Item 23.3:

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

Item 23.4:

On an annual basis, unless otherwise specified below, beginning one year after the granting of an emissions cap, the responsible official shall provide a certification to the Department that the facility has operated all emission units within the limits imposed by the emission cap. This certification shall include a brief summary of the emissions subject to the cap for that time period and a comparison to the threshold levels that would require compliance with an applicable requirement.

Item 23.5:

The emission of pollutants that exceed the applicability thresholds for an applicable requirement, for which the facility has obtained an emissions cap, constitutes a violation of Part 201 and of the Act.

Item 23.6:

The Compliance Certification activity will be performed for the facility:
The Compliance Certification applies to:

Emission Unit: U-00001

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 23.7:

Compliance Certification shall include the following monitoring:

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

Capping: Yes

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

The owner or operator of the facility shall calibrate, maintain and operate a continuous emissions monitor for oxides of nitrogen. The limit shall apply at all loads of operation and during start up and shutdown.

The permittee shall monitor emissions while firing low sulfur distillate fuel oil to keep NOx emissions from this facility below 22.5 tons per year on an annual average basis, rolled daily.

The permittee shall use data produced from the CEMS to ensure that the NOx cap is not exceeded on an annual average, rolled daily basis.

All reports shall be maintained by the applicant at their facility for a minimum of five years.

Manufacturer Name/Model Number: NOx Analyzer

Parameter Monitored: OXIDES OF NITROGEN

Upper Permit Limit: 22.5 tons per year

Reference Test Method: 40 CFR 75- App. B

Monitoring Frequency: CONTINUOUS

Averaging Method: ANNUAL TOTAL ROLLED DAILY

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 6 calendar month(s).

**Condition 24: Compliance Certification
Effective for entire length of Permit**

Applicable Federal Requirement: 6 NYCRR 202-2.1 (c)

Item 24.1:

The Compliance Certification activity will be performed for the Facility.

Item 24.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Electronic submittal of emission statements will become mandatory and will be included as an enforceable condition in new or renewed Title V permits issued after January 1, 2021. The first reporting year under this provision will be the reporting year in which the permit was issued or reporting year 2025 (emission statements due in 2026), whichever is earlier.

Monitoring Frequency: ANNUALLY

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

Reporting Requirements: ANNUALLY (CALENDAR)
Reports due 60 days after the reporting period.
Subsequent reports are due every 12 calendar month(s).

**Condition 25: Statement dates for emissions statements.
Effective for entire length of Permit**

Applicable Federal Requirement:6 NYCRR 202-2.4 (a) (3)

Item 25.1:

This facility is required to submit an annual emission statement electronically and these emissions statements must be submitted to the department as per the following schedule:

- (i) March 15th of each year for facilities with three or fewer processes listed in their Title V permit:
- (ii) March 31st of each year for facilities with four to six processes listed in their Title V permit:
- (iii) April 15th of each year for facilities with 7 to 12 processes listed in their Title V permit:
- (iv) April 30th of each year for facilities with 13 or more processes listed in their Title V permit.

**Condition 26: Visible Emissions Limited
Effective for entire length of Permit**

Applicable Federal Requirement:6 NYCRR 211.2

Item 26.1:

Except as permitted by a specific part of this Subchapter and for open fires for which a restricted burning permit has been issued, no person shall cause or allow any air contamination source to emit any material having an opacity equal to or greater than 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent opacity.

**Condition 27: Compliance Certification
Effective for entire length of Permit**

Applicable Federal Requirement:6 NYCRR 225-1.2 (d)

Item 27.1:

The Compliance Certification activity will be performed for the Facility.

Item 27.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC
OPERATIONS

Monitoring Description:

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

Owners or operators of emission sources that fire distillate oil are limited to a 0.0015 percent sulfur content by weight of the fuel. Compliance with the sulfur-in-fuel limitation is based on fuel vendor receipts. All fuel vendor receipts must be maintained on site or at a Department approved alternative location for a minimum of five years.

Note - Process sources and incinerators must comply with the above requirements on or after July 1, 2023.

Work Practice Type: PARAMETER OF PROCESS MATERIAL
Process Material: DISTILLATES - NUMBER 1 AND NUMBER 2 OIL
Parameter Monitored: SULFUR CONTENT
Upper Permit Limit: 0.0015 percent by weight
Monitoring Frequency: PER DELIVERY
Averaging Method: MAXIMUM - NOT TO BE EXCEEDED AT ANY TIME (INSTANTANEOUS/DISCRETE OR GRAB)
Reporting Requirements: SEMI-ANNUALLY (CALENDAR)
Reports due 60 days after the reporting period.
Subsequent reports are due every 6 calendar month(s).

Condition 28: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement: 6 NYCRR 227-1.4 (a)

Item 28.1:

The Compliance Certification activity will be performed for the Facility.

Item 28.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

No owner or operator of a stationary combustion installation subject to this subpart shall operate an emission source which exhibits greater than 20 percent opacity (based on a six minute average), except for one 6 minute period per hour of not more than 27 percent opacity. The owner or operator will conduct a Method 9 test annually. A report of the results of the test will be submitted to the department semiannually (calendar), 60 days after the annual reporting period. All records generated by the permittee must be maintained at the facility or at an alternate location approved by the department for a minimum of five years.

Parameter Monitored: OPACITY

Upper Permit Limit: 20 percent

Reference Test Method: 40 CFR 60, Appendix A, Method 9

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

Monitoring Frequency: ANNUALLY
Averaging Method: 6-MINUTE AVERAGE (METHOD 9)
Reporting Requirements: ANNUALLY (CALENDAR)
Reports due 60 days after the reporting period.
Subsequent reports are due every 12 calendar month(s).

**Condition 29: EPA Region 2 address.
Effective for entire length of Permit**

Applicable Federal Requirement:40CFR 60.4, NSPS Subpart A

Item 29.1:

All requests, reports, applications, submittals, and other communications to the Administrator pursuant to this part shall be submitted in duplicate to the following address:

Director, Division of Enforcement and Compliance Assistance
USEPA Region 2
290 Broadway, 21st Floor
New York, NY 10007-1886

Copies of all correspondence to the administrator pursuant to this part shall also be submitted to the NYSDEC Regional Office issuing this permit (see address at the beginning of this permit) and to the following address:

NYSDEC
Bureau of Quality Assurance
625 Broadway
Albany, NY 12233-3258

**Condition 30: Modification Notification
Effective for entire length of Permit**

Applicable Federal Requirement:40CFR 60.7(a), NSPS Subpart A

Item 30.1:

Any owner or operator subject to 40 CFR Part 60 shall furnish the Administrator and this office with the following information:

- a notification of any physical or operational change to an existing facility which may increase the emission rate of any air pollutant to which a standard applies, unless the change is specifically exempted under 40 CFR Part 60. The notice shall be post marked 60 days or as soon as practicable before the change is commenced and shall include information describing the precise nature of the change, present and proposed emission control systems, productivity capability of the facility before and after the change, and the expected completion date of the change. The Administrator and/or this Department may request additional information regarding the change.

**Condition 31: Recordkeeping requirements.
Effective for entire length of Permit**

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

Applicable Federal Requirement: 40CFR 60.7(b), NSPS Subpart A

Item 31.1:

Affected owners or operators shall maintain records of occurrence and duration of any startup, shutdown, or malfunction in the operation of an affected facility; any malfunction of the air pollution control equipment; or any periods during which a continuous monitoring system or monitoring device is inoperative.

**Condition 32: Compliance Certification
Effective for entire length of Permit**

Applicable Federal Requirement: 40CFR 60.7(c), NSPS Subpart A

Item 32.1:

The Compliance Certification activity will be performed for the Facility.

Item 32.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Affected owners or operators shall submit an excess emissions report and/or a summary report form (as defined in 40 CFR 60.7(d)) semi-annually (or more frequently as required by the applicable Subpart or the Administrator), to the Administrator. These reports shall be post marked no later than 30 days after each six (6) month period (or as appropriate), and shall contain the following information:

- 1) the magnitude of excess emissions computed, any conversion factors used, the date and time of each occurrence, and the process operating time during the reporting period;
- 2) specific identification of each period of excess emissions that occur during startup, shutdown, or malfunction, where the nature, cause, and corrective action are provided for a malfunction;
- 3) the date and time identifying each period during which the continuous monitoring system was inoperative except for zero and span checks and the nature of the system repairs or adjustments; and
- 4) when no excess emissions have occurred or when the continuous monitoring system(s) have not been inoperative, repaired, or adjusted, such information shall be provided in the report.

Monitoring Frequency: CONTINUOUS

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

Reports due 60 days after the reporting period.
 Subsequent reports are due every 6 calendar month(s).

**Condition 33: Facility files for subject sources.
 Effective for entire length of Permit**

Applicable Federal Requirement:40CFR 60.7(f), NSPS Subpart A

Item 33.1:

The following files shall be maintained at the facility for all affected sources: all measurements, including continuous monitoring systems, monitoring device, and performance testing measurements; all continuous monitoring system performance evaluations; all continuous monitoring device calibration checks; adjustments and maintenance performed on these systems or devices; and all other information required by this part, recorded in permanent form suitable for inspections. The file shall be maintained for at least two years following the date of such measurements, reports, and records.

**Condition 34: Circumvention.
 Effective for entire length of Permit**

Applicable Federal Requirement:40CFR 60.12, NSPS Subpart A

Item 34.1:

No owner or operator subject to the provisions of this part shall build, erect, install, or use any article, machine, equipment or process, the use of which conceals an emission which would otherwise constitute a violation of an applicable standard. Such concealment includes, but is not limited to, the use of gaseous diluents to achieve compliance with an opacity standard or with a standard which is based on the concentration of a pollutant in the gases discharged to the atmosphere.

**Condition 35: Monitoring requirements.
 Effective for entire length of Permit**

Applicable Federal Requirement:40CFR 60.13, NSPS Subpart A

Item 35.1:

All continuous monitoring systems and devices shall be installed, calibrated, maintained, and operated in accordance with the requirements of section 60.13.

**Condition 36: Modifications.
 Effective for entire length of Permit**

Applicable Federal Requirement:40CFR 60.14, NSPS Subpart A

Item 36.1:

Within 180 days of the completion of any physical or operational change (as defined in section 60.14), compliance with the applicable standards must be achieved.

**Condition 37: Reconstruction
 Effective for entire length of Permit**

Applicable Federal Requirement:40CFR 60.15, NSPS Subpart A

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

Item 37.1:

The following shall be submitted to the Administrator prior to reconstruction (as defined in section 60.15):

- 1) a notice of intent to reconstruct 60 days (or as soon as practicable) prior to the action;
- 2) name and address of the owner or operator;
- 3) the location of the existing facility;
- 4) a brief description of the existing facility and the components to be replaced;
- 5) a description of the existing air pollution control equipment and the proposed air pollution control equipment;
- 6) an estimate of the fixed capital cost of the replacements and of constructing a comparable entirely new facility;
- 7) the estimated life of the facility after the replacements; and
- 8) a discussion of any economic or technical limitations the facility may have in complying with the applicable standards of performance after the proposed replacements.

**Condition 38: CEMS
Effective for entire length of Permit**

Applicable Federal Requirement: 40 CFR 60.334(b), NSPS Subpart GG

Item 38.1:

The owner or operator of any stationary gas turbine that commenced construction, reconstruction or modification after October 3, 1977, but before July 8, 2004, and which uses water or steam injection to control NOX emissions may, as an alternative to operating the continuous monitoring system described in paragraph (a) of this section, install, certify, maintain, operate, and quality-assure a continuous emission monitoring system (CEMS) consisting of NOX and O2 monitors. As an alternative, a CO2 monitor may be used to adjust the measured NOX concentrations to 15 percent O2 by either converting the CO2 hourly averages to equivalent O2 concentrations using Equation F-14a or F-14b in appendix F to 40 CFR Part 75 and making the adjustments to 15 percent O2, or by using the CO2 readings directly to make the adjustments, as described in Method 20. If the option to use a CEMS is chosen, the CEMS shall be installed, certified, maintained and operated as specified in 40 CFR 60.334(b)(1), (2) and (3).

**Condition 39: Facility Subject to Title IV Acid Rain Regulations and Permitting
Effective for entire length of Permit**

Applicable Federal Requirement: 40 CFR Part 72

Item 39.1: This facility is subject to the Title IV Acid Rain Program regulations found in

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

40 CFR Parts 72, 73, 75, 76, 77, and 78. In accordance with those requirements, a separate Title IV Acid Rain permit has been issued to the facility. The facility owner or operator shall maintain a copy of the Title IV Acid Rain permit together with this Title V permit in the facility’s files.

**Condition 40: Federal Cross-State Air Pollution Regulation (CSAPR)
Effective for entire length of Permit**

Applicable Federal Requirement:40 CFR Part 97

Item 40.1: This facility is subject to the CSAPR requirements found in 40 CFR Part 97.

**Condition 41: Compliance Certification
Effective for entire length of Permit**

Applicable Federal Requirement:40CFR 97.406, Subpart AAAAA

Item 41.1:
The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):
CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 41.2:
Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES
Monitoring Description:

- (1) The facility shall comply with the requirement to have a designated representative, and may have an alternate designated representative, in accordance with §§97.413 through 97.418 of Subpart AAAAA. The facility shall notify the Department of this representative (and alternative) with contact information upon issuance of this permit and when any changes are made to the representative (or alternative) or their contact information.
- (2) The facility, and the designated representative, of each TR NOX Annual source (facility) and each TR NOx Annual Unit at the facility shall comply with the monitoring, reporting, and recordkeeping requirements of §§97.430 through 97.435 of Subpart AAAAA and subpart H of part 75 of this chapter. This includes but is not limited to: requirements for installation, certification, and data accounting for all required monitoring systems; requirements for recording, reporting, and

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

quality-assurance of the data; and certification of compliance of such data. Data from continuous emission monitoring equipment are submitted quarterly (calendar year). These reports are generally due 30 days after the end of a calendar quarter. All other monitoring data are submitted to the DEC semiannually (calendar year). These reports are due on January 30th and July 30th of each year.

(3) The emissions data determined shall be used to calculate allocations of TR NO_x Annual allowances and to determine compliance with the TR NO_x Annual emissions limitation and assurance provisions. As of the allowance transfer deadline for a control period in a given year, the owners and operators of each TR NO_x Annual facility and each TR NO_x Annual Unit at the facility shall hold, in the facilities compliance account, TR NO_x Annual allowances available for deduction for such control period under §97.424(a) in an amount not less than the tons of total NO_x emissions for such control period from all TR NO_x Annual Units at the facility.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 42: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement:40CFR 97.606, Subpart CCCCC

Item 42.1:

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 007446-09-5 SULFUR DIOXIDE

Item 42.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

(1) The facility shall comply with the requirement to have a designated representative, and may have an alternate designated representative, in accordance with §§97.613 through 97.618 of Subpart CCCCC. The facility shall notify the Department of this representative (and alternative) with contact information upon issuance of this permit and when any changes are made to the representative (or alternative) or their contact

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

information.

(2) The facility, and the designated representative, of each TR SO2 Group 1 source (facility) and each TR SO2 Group 1 Unit at the facility shall comply with the monitoring, reporting, and recordkeeping requirements of §§97.630 through 97.635 of Subpart CCCC and subpart H of part 75 of this chapter. This includes but is not limited to: requirements for installation, certification, and data accounting for all required monitoring systems; requirements for recording, reporting, and quality-assurance of the data; and certification of compliance of such data. Data from continuous emission monitoring equipment are submitted quarterly (calendar year). These reports are generally due 30 days after the end of a calendar quarter. All other monitoring data are submitted to the DEC semiannually (calendar year). These reports are due on January 30th and July 30th of each year.

(3) The emissions data determined shall be used to calculate allocations of TR SO2 Group 1 allowances and to determine compliance with the TR SO2 Group 1 emissions limitation and assurance provisions. As of the allowance transfer deadline for a control period in a given year, the owners and operators of each TR SO2 Group 1 facility and each TR SO2 Group 1 Unit at the facility shall hold, in the facilities compliance account, TR SO2 Group 1 allowances available for deduction for such control period under §97.624(a) in an amount not less than the tons of total SO2 emissions for such control period from all TR SO2 Group 1 Units at the facility.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

****** Emission Unit Level ******

**Condition 43: Emission Point Definition By Emission Unit
Effective for entire length of Permit**

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 43.1:

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: U-00001

Emission Point: EP001

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

Height (ft.): 65 Diameter (in.): 120
NYTMN (km.): 4553.849 NYTME (km.): 720.33 Building: SCR

Condition 44: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 44.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Item 44.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

A shutdown shall not exceed 20 minutes per occurrence. The owner or operator shall record each period of shutdown and its duration. A report consisting of the recorded information shall be submitted to the Department quarterly with the facility's required excess emissions report. All records shall be maintained at the facility for a minimum of five years.

Parameter Monitored: DURATION OF SHUTDOWN

Upper Permit Limit: 20 minutes

Monitoring Frequency: CONTINUOUS

Averaging Method: MAXIMUM - NOT TO BE EXCEEDED PER
OCCURRENCE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 60 days after the reporting period.

Subsequent reports are due every 3 calendar month(s).

Condition 45: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 45.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Item 45.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The owner and/or operator of this facility shall operate

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

the combustion turbines at base load (maximum load), either individually or simultaneously, at all times except during periods of start-up, shutdown and malfunction. the permittee shall maintain a log, at the facility, which records all periods of non-base load operation and the reason for such operation. These records shall be maintained, at the facility, for a period of no less than five years.

Monitoring Frequency: CONTINUOUS
 Reporting Requirements: QUARTERLY (CALENDAR)
 Reports due 60 days after the reporting period.
 Subsequent reports are due every 3 calendar month(s).

Condition 46: Required emission tests
Effective for entire length of Permit

Applicable Federal Requirement:6 NYCRR 202-1.1

Item 46.1:
 This Condition applies to Emission Unit: U-00001

Item 46.2:
 An acceptable report of measured emissions shall be submitted, if requested by the commissioner, to ascertain compliance or noncompliance with any air pollution code, rule, or regulation.

Condition 47: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement:40CFR 60.334(a), NSPS Subpart GG

Item 47.1:
 The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Item 47.2:
 Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES
 Monitoring Description:

The owner or operator of any stationary gas turbine subject to the provisions of 40 CFR 60 Subpart GG, that is using water injection to control NOx emissions, shall install and operate a continuous monitoring system to monitor and record fuel consumption and the ratio of water to fuel fired in the turbine. This system shall be accurate to within +/- 5.0 percent and shall be approved by the Administrator.

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

Monitoring Frequency: CONTINUOUS
 Reporting Requirements: SEMI-ANNUALLY (CALENDAR)
 Reports due 60 days after the reporting period.
 Subsequent reports are due every 6 calendar month(s).

Condition 48: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 48.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001 Emission Point: EP001
 Process: DFO

Regulated Contaminant(s):
 CAS No: 000630-08-0 CARBON MONOXIDE

Item 48.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

The owner or operator shall continuously monitor emissions of carbon monoxide during periods of operation between 50% and 100% load (this includes load shifting between 50% and 100%). Emissions in excess of this limit shall be reported quarterly in the facility's excess emission report.

Manufacturer Name/Model Number: CO CEMs
 Parameter Monitored: CARBON MONOXIDE
 Upper Permit Limit: 5 parts per million by volume (dry, corrected to 15% O2)
 Reference Test Method: Method 10
 Monitoring Frequency: CONTINUOUS
 Averaging Method: 1-HOUR AVERAGE
 Reporting Requirements: QUARTERLY (CALENDAR)
 Reports due 60 days after the reporting period.
 Subsequent reports are due every 3 calendar month(s).

Condition 49: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 49.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001 Emission Point: EP001

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

Process: DFO

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 49.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

This facility shall install, calibrate, maintain and operate a continuous emissions monitor for oxides of nitrogen. This limit shall apply only during periods of start-up, not to exceed 30 minutes per occurrence. Emissions in excess of this limit shall be reported quarterly through the facility's excess emissions report.

Manufacturer Name/Model Number: NO_x Analyzer

Parameter Monitored: OXIDES OF NITROGEN

Upper Permit Limit: 40 pounds

Reference Test Method: 40 CFR 60

Monitoring Frequency: CONTINUOUS

Averaging Method: MAXIMUM - NOT TO BE EXCEEDED PER OCCURRENCE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 60 days after the reporting period.

Subsequent reports are due every 3 calendar month(s).

**Condition 50: Compliance Certification
Effective for entire length of Permit**

Applicable Federal Requirement: 6 NYCRR Subpart 201-6

Item 50.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Emission Point: EP001

Process: DFO

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 50.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

The facility shall install, calibrate, maintain, and operate a continuous emission monitor for oxides of nitrogen. The 13.99 pounds per hour shall apply during steady state operations where the

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

turbines operate for the full 60 minutes of the hour. The following shall apply during steady state partial hours (less than the full 60 minutes) of operation:

Time period (minutes)
NOx Mass limit (pounds)

1-15	
	7.00
16-30	
	9.33
31-45	
	11.66
46-59	
	13.99

Emissions in excess of the steady state limits for full 60 minute hours and steady state partial hours shall be reported quarterly through the facility's excess emissions report.

Manufacturer Name/Model Number: NOx Analyzer
 Parameter Monitored: OXIDES OF NITROGEN
 Upper Permit Limit: 13.99 pounds per hour
 Reference Test Method: 40 CFR 60
 Monitoring Frequency: CONTINUOUS
 Averaging Method: 1-HOUR AVERAGE
 Reporting Requirements: QUARTERLY (CALENDAR)
 Reports due 60 days after the reporting period.
 Subsequent reports are due every 3 calendar month(s).

Condition 51: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement: 6 NYCRR Subpart 201-6

Item 51.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001 Emission Point: EP001
 Process: DFO

Regulated Contaminant(s):
 CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 51.2:

Compliance Certification shall include the following monitoring:

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

The facility shall install, calibrate, maintain, and operate a continuous 40 CFR Part 75 emissions monitor for measuring and recording oxides of nitrogen. The facility shall also install either a continuous monitor for oxygen or carbon dioxide. All records shall be maintained by the applicant at their facility for a minimum of five years.

The 6.0 ppmvd limit shall be applicable during periods of steady state operation where the facility operates 16 or more minutes connectively in one clock hour. When a facility operates in steady state less than 16 minutes (consecutively in one clock hour, and excluding start-up and shutdown) the 6.0 ppmvd limit does not apply, but a mass emission limit of 7.0 pounds applies. Emissions in excess of either the concentration or mass emission limits shall be reported quarterly through the facility's excess emission report.

Manufacturer Name/Model Number: NOx Analyzer

Parameter Monitored: OXIDES OF NITROGEN

Upper Permit Limit: 6 parts per million by volume (dry, corrected to 15% O2)

Reference Test Method: 40 CFR 60

Monitoring Frequency: CONTINUOUS

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 60 days after the reporting period.

Subsequent reports are due every 3 calendar month(s).

**Condition 52: Compliance Certification
Effective for entire length of Permit**

Applicable Federal Requirement: 6 NYCRR Subpart 201-6

Item 52.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Emission Point: EP001

Process: DFO

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 52.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

The facility shall install, calibrate, maintain and

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

operate a continuous emissions monitor for oxides of nitrogen. This limit shall apply only during periods of shutdown, not to exceed 20 minutes per occurrence. Emissions in excess of this limit shall be reported quarterly through the facility's excess emissions report. All records shall be maintained by the applicant at their facility for a minimum of five years.

Manufacturer Name/Model Number: NOx Analyzer
 Parameter Monitored: OXIDES OF NITROGEN
 Upper Permit Limit: 2 pounds
 Reference Test Method: 40 CFR 60
 Monitoring Frequency: CONTINUOUS
 Averaging Method: MAXIMUM - NOT TO BE EXCEEDED PER OCCURRENCE
 Reporting Requirements: QUARTERLY (CALENDAR)
 Reports due 60 days after the reporting period.
 Subsequent reports are due every 3 calendar month(s).

**Condition 53: Compliance Certification
 Effective for entire length of Permit**

Applicable Federal Requirement: 6 NYCRR Subpart 201-6

Item 53.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001 Emission Point: EP001
 Process: DFO

Regulated Contaminant(s):
 CAS No: 007664-41-7 AMMONIA

Item 53.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

The facility shall install, calibrate, maintain and operate a continuous emissions monitor for ammonia slip, in accordance with the manufacturer's specifications. The facility must submit a compliance test protocol, for an initial ammonia slip compliance test using USEPA conditional test method 27, for Department approval. Within 180 days of the initial operation of the SCR, the facility must perform a compliance test and submit the results for Department approval.

Manufacturer Name/Model Number: Ammonia Analyzer
 Parameter Monitored: AMMONIA
 Upper Permit Limit: 10 parts per million by volume (dry, corrected to 15% O₂)

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

Reference Test Method: 40 CFR 60
Monitoring Frequency: CONTINUOUS
Averaging Method: 1-HOUR AVERAGE
Reporting Requirements: QUARTERLY (CALENDAR)
Reports due 60 days after the reporting period.
Subsequent reports are due every 3 calendar month(s).

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

STATE ONLY ENFORCEABLE CONDITIONS****** Facility Level ********NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS**

This section contains terms and conditions which are not federally enforceable. Permittees may also have other obligations under regulations of general applicability

Item A: Emergency Defense - 6 NYCRR 201-1.5

An emergency, as defined in 6 NYCRR subpart 201-2, constitutes an affirmative defense to penalties sought in an enforcement action brought by the department for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

(a) The affirmative defense of emergency shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:

(1) an emergency occurred and that the facility owner or operator can identify the cause(s) of the emergency;

(2) the equipment at the facility was being properly operated and maintained;

(3) during the period of the emergency the facility owner or operator took all reasonable steps to minimize the levels of emissions that exceeded the emission standards, or other requirements in the permit; and

(4) the facility owner or operator notified the department within two working days after the event occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and any corrective actions taken.

(b) In any enforcement proceeding, the facility owner or operator seeking to establish the occurrence of an emergency has the burden of proof.

(c) This provision is in addition to any emergency or malfunction provision contained in any applicable requirement.

Item B: General Provisions for State Enforceable Permit Terms and Condition - 6 NYCRR Part 201-5

Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

criteria, emission limits, terms, conditions, and standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

STATE ONLY APPLICABLE REQUIREMENTS

The following conditions are state applicable requirements and are not subject to compliance certification requirements unless otherwise noted or required under 6 NYCRR Part 201.

Condition 54: Contaminant List
Effective for entire length of Permit

Applicable State Requirement: ECL 19-0301

Item 54.1:

Emissions of the following contaminants are subject to contaminant specific requirements in this permit (emission limits, control requirements or compliance monitoring conditions).

CAS No: 000124-38-9
Name: CARBON DIOXIDE

CAS No: 000630-08-0
Name: CARBON MONOXIDE

CAS No: 007446-09-5
Name: SULFUR DIOXIDE

CAS No: 007664-41-7
Name: AMMONIA

CAS No: 0NY210-00-0
Name: OXIDES OF NITROGEN

Condition 55: Malfunctions and Start-up/Shutdown Activities
Effective for entire length of Permit

Applicable State Requirement: 6 NYCRR 201-1.4

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

Item 55.1:

(a) The facility owner or operator shall take all necessary and appropriate actions to prevent the emission of air pollutants that result in contravention of any applicable emission standard during periods of start-up, shutdown, or malfunction.

(b) The facility owner or operator shall compile and maintain records of all equipment maintenance and start-up/shutdown activities when they are expected to result in an exceedance of any applicable emission standard, and shall submit a report of such activities to the department when required by a permit condition or upon request by the department. Such reports shall state whether an exceedance occurred and if it was unavoidable, include the time, frequency and duration of the exceedance, and an estimate of the emission rates of any air contaminants released. Such records shall be maintained for a period of at least five years and made available for review to department representatives upon request. Facility owners or operators subject to continuous monitoring and quarterly reporting requirements need not submit additional reports of exceedances to the department.

(c) In the event that air contaminant emissions exceed any applicable emission standard due to a malfunction, the facility owner or operator shall notify the department as soon as possible during normal working hours, but not later than two working days after becoming aware that the malfunction occurred. In addition, the facility owner or operator shall compile and maintain a record of all malfunctions. Such records shall be maintained at the facility for a period of at least five years and must be made available to the department upon request. When requested by the department, the facility owner or operator shall submit a written report to the department describing the malfunction, the corrective action taken, the air contaminants emitted, and the resulting emission rates and/or opacity.

(d) The department may also require the facility owner or operator to include, in reports described under Subdivisions (b) and (c) of this Section, an estimate of the maximum ground level concentration of each air contaminant emitted and the effect of such emissions.

(e) A violation of any applicable emission standard resulting from start-up, shutdown, or malfunction conditions at a permitted or registered facility may not be subject to an enforcement action by the department and/or penalty if the department determines, in its sole discretion, that such a violation was unavoidable. The actions and recordkeeping and reporting requirements listed above must be adhered to in such circumstances.

Condition 56: CLCPA Applicability
Effective for entire length of Permit

Applicable State Requirement: 6 NYCRR 201-6.5 (a)

Item 56.1:

Pursuant to The New York State Climate Leadership and Community Protection Act (CLCPA) and Article 75 of the Environmental Conservation Law, emission sources shall comply with regulations to be promulgated by the Department to ensure that by 2030 statewide greenhouse

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

gas emissions are reduced by 40% of 1990 levels, and by 2050 statewide greenhouse gas emissions are reduced by 85% of 1990 levels.

**Condition 57: Air pollution prohibited
Effective for entire length of Permit**

Applicable State Requirement:6 NYCRR 211.1

Item 57.1:

No person shall cause or allow emissions of air contaminants to the outdoor atmosphere of such quantity, characteristic or duration which are injurious to human, plant or animal life or to property, or which unreasonably interfere with the comfortable enjoyment of life or property. Notwithstanding the existence of specific air quality standards or emission limits, this prohibition applies, but is not limited to, any particulate, fume, gas, mist, odor, smoke, vapor, pollen, toxic or deleterious emission, either alone or in combination with others.

**Condition 58: CO2 Budget Trading Program - Excess emission requirements
Effective for entire length of Permit**

Applicable State Requirement:6 NYCRR 242-1.5

Item 58.1:

The owners and operators of a CO2 budget source that has excess emissions in any control period shall:
 (1) forfeit the CO2 allowances required for deduction under 6 NYCRR Part 242-6.5(d)(1), provided CO2 offset allowances may not be used to cover any part of such excess emissions; and
 (2) pay any fine, penalty, or assessment or comply with any other remedy imposed under 6 NYCRR Part 242-6.5(d)(2).

**Condition 59: Compliance Demonstration
Effective for entire length of Permit**

Applicable State Requirement:6 NYCRR 242-1.5

Item 59.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 59.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The owners and operators and, to the extent applicable, the CO2 authorized account representative of each CO2 budget source and each CO2 budget unit at the source shall comply with the monitoring requirements of Subpart 242-8. The emissions measurements recorded and reported in accordance with Subpart 242-8 of this Part shall be used

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

to determine compliance by the unit with the following CO₂ requirements:

- (1) The owners and operators of each CO₂ budget source and each CO₂ budget unit at the source shall hold CO₂ allowances available for compliance deductions under Section 242-6.5, as of the CO₂ allowance transfer deadline, in the source's compliance account in an amount not less than the total CO₂ emissions for the control period from all CO₂ budget units at the source, as determined in accordance with Subparts 242-6 and 242-8.
- (2) Each ton of CO₂ emitted in excess of the CO₂ budget emissions limitation shall constitute a separate violation of this Part and applicable state law.
- (3) A CO₂ budget unit shall be subject to the requirements specified in item 1 starting on the later, of January 1, 2009 or the date on which the unit commences operation.
- (4) CO₂ allowances shall be held in, deducted from, or transferred among CO₂ Allowance Tracking System accounts in accordance with Subparts 242-5, 242-6, and 242-7, and Section 242-10.7.
- (5) A CO₂ allowance shall not be deducted, in order to comply with the requirements specified in item 1, for a control period that ends prior to the allocation year for which the CO₂ allowance was allocated. A CO₂ offset allowance shall not be deducted, in order to comply with the requirements under item 1, beyond the applicable percent limitations set out in 6NYCRR Part 242-6.5(a)(3).
- (6) A CO₂ allowance under the CO₂ Budget Trading Program is a limited authorization by the Department or a participating state to emit one ton of CO₂ in accordance with the CO₂ Budget Trading Program. No provision of the CO₂ Budget Trading Program, the CO₂ budget permit application, or the CO₂ budget permit or any provision of law shall be construed to limit the authority of the Department or a participating state to terminate or limit such authorization.
- (7) A CO₂ allowance under the CO₂ Budget Trading Program does not constitute a property right.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

Reports due 60 days after the reporting period.
Subsequent reports are due every 6 calendar month(s).

Condition 60: Compliance Demonstration
Effective for entire length of Permit

Applicable State Requirement: 6 NYCRR 242-1.5

Item 60.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 60.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The owners and operators of the CO₂ budget source and each CO₂ budget unit at the source shall keep on site at the source each of the following documents for a period of 10 years from the date the document is created. This period may be extended for cause, at any time prior to the end of 10 years, in writing by the department.

(i) The account certificate of representation for the CO₂ authorized account representative for the source and each CO₂ budget unit at the source and all documents that demonstrate the truth of the statements in the account certificate of representation, in accordance with 6 NYCRR Part 242-2.4, provided that the certificate and documents shall be retained on site at the source beyond such 10-year period until such documents are superseded because of the submission of a new account certificate of representation.

(ii) All emissions monitoring information, in accordance with Subpart 242-8 and 40 CFR 75.57.

(iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CO₂ Budget Trading Program.

(iv) Copies of all documents used to complete a CO₂ budget permit application and any other submission under the CO₂ Budget Trading Program or to demonstrate compliance with the requirements of the CO₂ Budget Trading Program.

The CO₂ authorized account representative of a CO₂ budget source and each CO₂ budget unit at the source shall submit the reports and compliance certifications required under the CO₂ Budget Trading Program, including those under Subpart 242-4.

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 60 days after the reporting period.

Subsequent reports are due every 6 calendar month(s).

**Condition 61: Compliance Demonstration
Effective for entire length of Permit**

Applicable State Requirement:6 NYCRR Subpart 242-4

Item 61.1:

The Compliance Demonstration activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 000124-38-9 CARBON DIOXIDE

Item 61.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Annual Compliance Certification Report:

(a) For each control period in which a CO2 budget source is subject to the CO2 requirements of subdivision 242-1.5(c) of this Part, CO2 authorized account representative of the source shall submit to the department by March 1st following the relevant control period, a compliance certification report. The control period is a three-calendar-year time period.

(b) The compliance certification report shall include the following elements:

(1) identification of the source and each CO2 budget unit at the source;

(2) as an option, the serial numbers of the CO2 allowances that are to be deducted from the source's compliance account under section 242-6.5 of this Part for the control period, including the serial numbers of any CO2 offset allowances that are to be deducted subject to the limitations of section 242-6.5(a)(3) of this Part; and

(3) the compliance certification under subdivision (c) of this section (below).

(c) In the compliance certification report the CO2 authorized account representative shall certify, based on reasonable inquiry of those persons with primary

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

responsibility for operating the source and the CO2 budget units at the source in compliance with the CO2 Budget Trading Program, whether the source and each CO2 budget unit at the source for which the compliance certification is submitted was operated during the calendar years covered by the report in compliance with the requirements of the CO2 Budget Trading Program, including:

(1) whether the source was operated in compliance with the CO2 requirements of section 242-1.5(c) of this Part;

(2) whether the monitoring plan applicable to each unit at the source has been maintained to reflect the actual operation and monitoring of the unit, and contains all information necessary to attribute CO2 emissions to the unit, in accordance with Subpart 242-8 of this Part;

(3) whether all the CO2 emissions from the units at the source were monitored or accounted for through the missing data procedures and reported in the quarterly monitoring reports, including whether conditional data were reported in the quarterly reports in accordance with Subpart 242-8 of this Part. If conditional data were reported, the owner or operator shall indicate whether the status of all conditional data has been resolved and all necessary quarterly report resubmissions have been made;

(4) whether the facts that form the basis for certification under Subpart 242-8 of each monitor at each unit at the source, or for using an excepted monitoring method or alternative monitoring method approved under Subpart 242-8 of this Part, if any, have changed; and

(5) if a change is required to be reported under paragraph (c)(4) above, specify the nature of the change, the reason for the change, when the change occurred, and how the unit's compliance status was determined subsequent to the change, including what method was used to determine emissions when a change mandated the need for monitor recertification.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

**Condition 62: Compliance Demonstration
Effective for entire length of Permit**

Applicable State Requirement: 6 NYCRR 242-8.5

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

Item 62.1:

The Compliance Demonstration activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 000124-38-9 CARBON DIOXIDE

Item 62.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Recordkeeping and Reporting (6NYCRR Part 242-8.5)

(a) General provisions. The CO₂ authorized account representative shall comply with all recordkeeping and reporting requirements in this section, the applicable record keeping and reporting requirements under 40 CFR 75.73 and with the requirements of section 242-2.1(e) of this Part.

(b) Monitoring plans. The owner or operator of a CO₂ budget unit shall submit a monitoring plan in the manner prescribed in 40 CFR 75.62.

(c) Certification applications. The CO₂ authorized account representative shall submit an application to the department within 45 days after completing all CO₂ monitoring system initial certification or recertification tests required under section 242-8.2 of this Subpart including the information required under 40 CFR 75.63 and 40 CFR 75.53(e) and (f).

(d) Quarterly reports. The CO₂ authorized account representative shall submit quarterly reports, as follows:

(1) The CO₂ authorized account representative shall report the CO₂ mass emissions data and heat input data for the CO₂ budget unit, in an electronic format prescribed by the administrator unless otherwise prescribed by the department for each calendar quarter.

(2) The CO₂ authorized account representative shall submit each quarterly report to the department or its agent within 30 days following the end of the calendar quarter covered by the report. Quarterly reports shall be submitted in the manner specified in subpart H of 40 CFR part 75 and 40 CFR 75.64. Quarterly reports shall be submitted for each CO₂ budget unit (or group of units using a common stack), and shall include all of the data and information required in subpart G of 40 CFR part 75, except for opacity, NO_x, and SO₂ provisions.

(3) The CO₂ authorized account representative shall

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

submit to the department or its agent a compliance certification in support of each quarterly report based on reasonable inquiry of those persons with primary responsibility for ensuring that all of the unit's emissions are correctly and fully monitored. The certification shall state that:

- (i) the monitoring data submitted were recorded in accordance with the applicable requirements of this Subpart and 40 CFR part 75, including the quality assurance procedures and specifications;
- (ii) for a unit with add-on CO₂ emissions controls and for all hours where data are substituted in accordance with 40 CFR 75.34(a)(1), the add-on emissions controls were operating within the range of parameters listed in the quality assurance/quality control program under appendix B of 40 CFR part 75 and the substitute values do not systematically underestimate CO₂ emissions; and
- (iii) the CO₂ concentration values substituted for missing data under Subpart D of 40 CFR part 75 do not systematically underestimate CO₂ emissions.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 60 days after the reporting period.

Subsequent reports are due every 3 calendar month(s).

**Condition 63: Compliance Demonstration
Effective for entire length of Permit**

Applicable State Requirement: 6 NYCRR 251.6 (f)

Item 63.1:

The Compliance Demonstration activity will be performed for the Facility.

Regulated Contaminant(s):
CAS No: 000124-38-9 CARBON DIOXIDE

Item 63.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Owners or operators that choose not to demonstrate compliance with the provisions in subdivision 251.3(b) of this Part through the use of a CEM may utilize an alternative monitoring plan as approved by the Department. The owners or operators may submit their annual reports under one of the following provisions:

- (1) Sources subject to the reporting requirements of 6 NYCRR Subpart 202-2 of this Title may use their annual

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

emission statement to satisfy the requirements of this subdivision, or

(2) Sources subject to the reporting requirements of 40 CFR Part 98 (see Table 1, section 200.9 of this Title) may use their annual submission to EPA to satisfy the requirements of this subdivision, or

(3) Sources that are not subject to the reporting requirements of 6 NYCRR Subpart 202-2 of this Title or 40 CFR Part 98 (see Table 1, section 200.9 of this Title) must submit an annual report, in a format prescribed by the Department, by the April 15th immediately following the end of the calendar year for which the annual report is required. At a minimum, the annual report should include:

- (i) Fuel type combusted in each unit subject to this Part;
- (ii) Quantity of fuel combusted in each unit subject to this Part; and
- (iii) Heat content of each fuel combusted.

The approved alternative monitoring shall be cited in a facility specific condition under subdivision 251.3(b) of this Part. and shall at a minimum include the prescribed CO2 emission limit and type of monitoring used to show compliance with said emission limit.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

**Condition 64: Compliance Demonstration
Effective for entire length of Permit**

Applicable State Requirement: 6 NYCRR 253-1.4

Item 64.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 64.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Owners or operators of facilities that contain emission sources specified in Section 253-1.2 of this Part must monitor emissions and submit emissions data reports to the Department, except as otherwise provided in Part 253, following the requirements specified in 40 CFR Sections 98.3 through 98.4 (Amended November 18, 2024) (see Table

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

1, section 200.9 of this Title).

Owners or operators shall submit emissions data reports and any revisions to the reports through the NYS e-GGRT platform, or any other reporting tool approved by the Department that will guarantee transmittal and receipt of data and information required by Part 253. Each owner or operator must submit an emissions data report for the previous calendar year no later than June 1st of the current calendar year.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

**Condition 65: Compliance Demonstration
Effective for entire length of Permit**

Applicable State Requirement:6 NYCRR 253-1.7

Item 65.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 65.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The owner or operator of each emission source that is required to report greenhouse gases under this Part, which emits a minimum of 10,000 metric tons (MT) of CO₂e but less than 25,000 MT of CO₂e, must keep records as required by 40 CFR Sections 98.3(g) through (h) (Amended November 18, 2024) (see Table 1, Section 200.9 of this Title) and as specified in this Subpart or as prescribed in the relevant Section(s) of Subpart 2 of this Part.

The following emission sources must maintain records on-site or at an alternative location approved by the Department for a period of five years from the date of emissions data report certification:

Emission sources that do not meet the threshold requirements pursuant to paragraph 253-1.2(f) of this Part or are not required to verify their emissions pursuant to Subpart 253-4 of this Part during any reporting year, must maintain required records for a period of five years from the date of certification.

Copies of any records or other materials maintained under the requirements of 40 CFR Part 98 (Amended November 18, 2024) (see Table 1, section 200.9 of this Title) or this

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

Part must be made available to the Department upon request within 14 days of receipt of such request by the designated representative of the reporting entity, unless a different schedule is agreed to by the Department.

Emission sources must maintain the following records, including but not limited to:

- (1) Information used to quantify or report emissions and product data in the emissions data report, underlying monitoring and metering data, invoices of receipts or deliveries, sales transaction data, calculation methods, protocols used, analysis results, calibration records, electricity transaction data, and other relevant information.
- (2) A list of units, operations, processes, and activities for which GHG emissions were calculated.
- (3) The data used to calculate the GHG emissions for each unit, operation, process and activity categorized by fuel or material type. These data include but are not limited to:
 - (i) the GHG emissions calculations and methods used;
 - (ii) analytical results for the development of site-specific emission factors;
 - (iii) the results of all required analyses for high heat value, carbon content, and other required fuel or feed stock parameters;
 - (iv) emissions data and input data, industrial product data and associated inputs; data associated with thermal energy provided, sold, purchased, or acquired; and data associated with electricity provided, sold, purchased, or acquired must be sufficient to allow for verification of each emissions data report; and
 - (v) any facility operating data or process information used for the GHG calculations.
- (4) The annual GHG emissions data reports.
- (5) Missing data computations for each missing data event, the cause of each event and the corrective actions taken to restore malfunctioning monitoring equipment.
- (6) Continuous monitoring system records. The results of all required certification and quality assurance tests for continuous monitoring systems, fuel flow meters, and other instrumentation used to provide data for the GHG emissions reported under this Part.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: UPON REQUEST BY REGULATORY AGENCY

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

****** Emission Unit Level ******

**Condition 66: General Provisions
Effective for entire length of Permit**

Applicable State Requirement:6 NYCRR Subpart 201-5

Item 66.1:

This Condition applies to Emission Unit: U-00001

Item 66.2:

This section of the permit contains terms and conditions that are not federally enforceable and are not required under the Act or under any of its applicable requirements. Terms and conditions so designated are not subject to the requirements of Section 201-6.4 of Part 201.

Item 66.3:

Any person who owns and/or operates emission sources subject to this permit shall operate and maintain all emission sources and required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate in accordance with all criteria, emission limits, terms, conditions, and standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such control devices may be sufficient reason for the Department to revoke or deny a permit.

Item 66.4:

The owner or operator of the emission sources subject to this permit must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access during normal operating hours, for the purpose of determining compliance with this and any other state or federal air pollution control requirements, regulations or law.

**Condition 67: Compliance Demonstration
Effective for entire length of Permit**

Applicable State Requirement:6 NYCRR 251.3 (b)

Item 67.1:

The Compliance Demonstration activity will be performed for:

Emission Unit: U-00001

Regulated Contaminant(s):

CAS No: 000124-38-9 CARBON DIOXIDE

Item 67.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119

Monitoring Description:

On or after December 31, 2020, owners or operators of non-modified existing sources shall not fire any single fossil fuel, alone or in combination with any other fuel, where each fossil fuel is required to meet an emission rate of 180 pounds of CO₂ per million Btu of input (input-based limit). These emission limits are measured on an annual basis, calculated by dividing the annual total of CO₂ emissions for the calendar year by the annual total Btus (input -based limit) fired for each separate fossil fuel fired. The owner or operator must maintain all records associated with these requirements on site or at a location acceptable to the department for a minimum of five years.

Manufacturer Name/Model Number: CO₂ continuous Monitor

Parameter Monitored: CARBON DIOXIDE

Upper Permit Limit: 180 pounds per million Btus

Reference Test Method: 40 CFR

Monitoring Frequency: CONTINUOUS

Averaging Method: CALENDAR YEAR AVERAGE

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 60 days after the reporting period.

Subsequent reports are due every 12 calendar month(s).

Permit ID: 1-4738-03119/00004

Facility DEC ID: 1473803119