

Facility DEC ID: 3330900040

PERMIT
Under the Environmental Conservation Law (ECL)

IDENTIFICATION INFORMATION

Permit Type: Air State Facility
Permit ID: 3-3309-00040/00005
Effective Date: 08/02/2023 Expiration Date: 08/01/2033

Permit Issued To: ALLIANCE NYGT LLC
110 E SENECA ST
SHERRILL, NY 13461

Contact: GREG SHARLAND
ALLIANCE NYGT LLC
110 E SENECA ST
SHERRILL, NY 13461
(845) 856-3920

Facility: ALLIANCE ENERGY - SHOEMAKER GAS TURBINE FACILITY
71 DOLSON AVE
MIDDLETOWN, NY 10940

Description:
The Shoemaker Gas Turbine Facility is a peaking station which consists of one Worthington P/WGG4-7 D/F Gas Turbine Twin Pac. The Twin Pac consists of two jet engines to turn a simple-cycle gas turbine rated at 512 mmBtu/hr (40 MW). The other sources on-site include a natural gas-fired (560 kW) internal combustion engine and one natural gas-fired (45 kW) emergency generator.

By acceptance of this permit, the permittee agrees that the permit is contingent upon strict compliance with the ECL, all applicable regulations, the General Conditions specified and any Special Conditions included as part of this permit.

Permit Administrator: REBECCA S CRIST
21 S PUTT CORNERS RD
NEW PALTZ, NY 12561

Authorized Signature: _____ Date: ___ / ___ / _____

Facility DEC ID: 3330900040

Notification of Other State Permittee Obligations

Item A: Permittee Accepts Legal Responsibility and Agrees to Indemnification

The permittee expressly agrees to indemnify and hold harmless the Department of Environmental Conservation of the State of New York, its representatives, employees and agents ("DEC") for all claims, suits, actions, and damages, to the extent attributable to the permittee's acts or omissions in connection with the compliance permittee's undertaking of activities in connection with, or operation and maintenance of, the facility or facilities authorized by the permit whether in compliance or not in any compliance with the terms and conditions of the permit. This indemnification does not extend to any claims, suits, actions, or damages to the extent attributable to DEC's own negligent or intentional acts or omissions, or to any claims, suits, or actions naming the DEC and arising under article 78 of the New York Civil Practice Laws and Rules or any citizen suit or civil rights provision under federal or state laws.

Item B: Permittee's Contractors to Comply with Permit

The permittee is responsible for informing its independent contractors, employees, agents and assigns of their responsibility to comply with this permit, including all special conditions while acting as the permittee's agent with respect to the permitted activities, and such persons shall be subject to the same sanctions for violations of the Environmental Conservation Law as those prescribed for the permittee.

Item C: Permittee Responsible for Obtaining Other Required Permits

The permittee is responsible for obtaining any other permits, approvals, lands, easements and rights-of-way that may be required to carry out the activities that are authorized by this permit.

Item D: No Right to Trespass or Interfere with Riparian Rights

This permit does not convey to the permittee any right to trespass upon the lands or interfere with the riparian rights of others in order to perform the permitted work nor does it authorize the impairment of any rights, title, or interest in real or personal property held or vested in a person not a party to the permit.

Facility DEC ID: 3330900040

PAGE LOCATION OF CONDITIONS

PAGE

DEC GENERAL CONDITIONS

General Provisions

- 4 1 Facility Inspection by the Department
- 4 2 Relationship of this Permit to Other Department Orders and Determinations
- 4 3 Applications for permit renewals, modifications and transfers
- 5 4 Permit modifications, suspensions or revocations by the Department

Facility Level

- 5 5 Submission of application for permit modification or renewal
-REGION 3 HEADQUARTERS

Facility DEC ID: 3330900040

DEC GENERAL CONDITIONS
****** General Provisions ******
GENERAL CONDITIONS - Apply to ALL Authorized Permits.

Condition 1: Facility Inspection by the Department
Applicable State Requirement: ECL 19-0305

Item 1.1:

The permitted site or facility, including relevant records, is subject to inspection at reasonable hours and intervals by an authorized representative of the Department of Environmental Conservation (the Department) to determine whether the permittee is complying with this permit and the ECL. Such representative may order the work suspended pursuant to ECL 71-0301 and SAPA 401(3).

Item 1.2:

The permittee shall provide a person to accompany the Department's representative during an inspection to the permit area when requested by the Department.

Item 1.3:

A copy of this permit, including all referenced maps, drawings and special conditions, must be available for inspection by the Department at all times at the project site or facility. Failure to produce a copy of the permit upon request by a Department representative is a violation of this permit.

Condition 2: Relationship of this Permit to Other Department Orders and Determinations
Applicable State Requirement: ECL 3-0301 (2) (m)

Item 2.1:

Unless expressly provided for by the Department, issuance of this permit does not modify, supersede or rescind any order or determination previously issued by the Department or any of the terms, conditions or requirements contained in such order or determination.

Condition 3: Applications for permit renewals, modifications and transfers
Applicable State Requirement: 6 NYCRR 621.11

Item 3.1:

The permittee must submit a separate written application to the Department for renewal, modification or transfer of this permit. Such application must include any forms or supplemental information the Department requires. Any renewal, modification or transfer granted by the Department must be in writing.

Item 3.2:

The permittee must submit a renewal application at least 180 days before the expiration of permits for Title V and State Facility Permits.

Item 3.3

Permits are transferrable with the approval of the department unless specifically prohibited by the statute, regulation or another permit condition. Applications for permit transfer should be submitted prior to actual transfer of ownership.

Facility DEC ID: 3330900040

Condition 4: Permit modifications, suspensions or revocations by the Department
Applicable State Requirement: 6 NYCRR 621.13

Item 4.1:

The Department reserves the right to exercise all available authority to modify, suspend, or revoke this permit in accordance with 6NYCRR Part 621. The grounds for modification, suspension or revocation include:

- a) materially false or inaccurate statements in the permit application or supporting papers;
- b) failure by the permittee to comply with any terms or conditions of the permit;
- c) exceeding the scope of the project as described in the permit application;
- d) newly discovered material information or a material change in environmental conditions, relevant technology or applicable law or regulations since the issuance of the existing permit;
- e) noncompliance with previously issued permit conditions, orders of the commissioner, any provisions of the Environmental Conservation Law or regulations of the Department related to the permitted activity.

****** Facility Level ******

Condition 5: Submission of application for permit modification or renewal -REGION 3 HEADQUARTERS
Applicable State Requirement: 6 NYCRR 621.6 (a)

Item 5.1:

Submission of applications for permit modification or renewal are to be submitted to:
NYSDEC Regional Permit Administrator
Region 3 Headquarters
Division of Environmental Permits
21 South Putt Corners Road
New Paltz, NY 12561-1696
(845) 256-3054

Permit ID: 3-3309-00040/00005

Facility DEC ID: 3330900040

Permit Under the Environmental Conservation Law (ECL)

ARTICLE 19: AIR POLLUTION CONTROL - AIR STATE FACILITY PERMIT

IDENTIFICATION INFORMATION

Permit Issued To: ALLIANCE NYGT LLC
110 E SENECA ST
SHERRILL, NY 13461

Facility: ALLIANCE ENERGY - SHOEMAKER GAS TURBINE FACILITY
71 DOLSON AVE
MIDDLETOWN, NY 10940

Authorized Activity By Standard Industrial Classification Code:
4911 - ELECTRIC SERVICES

Permit Effective Date: 08/02/2023

Permit Expiration Date: 08/01/2033

PAGE LOCATION OF CONDITIONS

PAGE

FEDERALLY ENFORCEABLE CONDITIONS

Facility Level

6	1	6 NYCRR Subpart 201-7: Facility Permissible Emissions
6	*2	6 NYCRR Subpart 201-7: Capping Monitoring Condition
7	3	6 NYCRR 211.2: Visible Emissions Limited
8	4	6 NYCRR 225-1.2 (d): Compliance Demonstration
8	5	6 NYCRR 227-1.3 (c): Compliance Demonstration
9	6	6 NYCRR 227-1.4 (a): Compliance Demonstration
10	7	6 NYCRR 227-3.4 (a) (1): Compliance Demonstration
10	8	6 NYCRR 227-3.4 (a) (2): Compliance Demonstration
11	9	6 NYCRR 227-3.4 (a) (3): Compliance Demonstration
12	10	40CFR 63, Subpart ZZZZ: Applicability
12	11	40CFR 97.406, Subpart AAAAA: Compliance Demonstration
13	12	40CFR 97.1006, Subpart GGGG: Compliance Demonstration

STATE ONLY ENFORCEABLE CONDITIONS

Facility Level

16	13	ECL 19-0301: Contaminant List
17	14	6 NYCRR 201-1.4: Malfunctions and Start-up/Shutdown Activities
17	15	6 NYCRR Subpart 201-5: Emission Unit Definition
18	16	6 NYCRR 201-5.2 (c): Renewal deadlines for state facility permits
18	17	6 NYCRR 201-5.3 (c): Compliance Demonstration
19	18	6 NYCRR 211.1: Air pollution prohibited

Emission Unit Level

19	19	6 NYCRR Subpart 201-5: Emission Point Definition By Emission Unit
19	20	6 NYCRR Subpart 201-5: Process Definition By Emission Unit

EU=1-00001

20	21	6 NYCRR 251.3 (b): Compliance Demonstration
----	----	---

NOTE: * preceding the condition number indicates capping.

Permit ID: 3-3309-00040/00005

Facility DEC ID: 3330900040

FEDERALLY ENFORCEABLE CONDITIONS

FINAL

**** Facility Level ****

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

This section contains terms and conditions which are federally enforceable. Permittees may also have other obligations under regulations of general applicability

Item A: Sealing - 6 NYCRR 200.5

The Commissioner may seal an air contamination source to prevent its operation if compliance with 6 NYCRR Chapter III is not met within the time provided by an order of the Commissioner issued in the case of the violation. Sealing means labeling or tagging a source to notify any person that operation of the source is prohibited, and also includes physical means of preventing the operation of an air contamination source without resulting in destruction of any equipment associated with such source, and includes, but is not limited to, bolting, chaining or wiring shut control panels, apertures or conduits associated with such source.

No person shall operate any air contamination source sealed by the Commissioner in accordance with this section unless a modification has been made which enables such source to comply with all requirements applicable to such modification.

Unless authorized by the Commissioner, no person shall remove or alter any seal affixed to any contamination source in accordance with this section.

Item B: Acceptable Ambient Air Quality - 6 NYCRR 200.6

Notwithstanding the provisions of 6 NYCRR Chapter III, Subchapter A, no person shall allow or permit any air contamination source to emit air contaminants in quantities which alone or in combination with emissions from other air contamination sources would contravene any applicable ambient air quality standard and/or cause air pollution. In such cases where contravention occurs or may occur, the Commissioner shall specify the degree and/or method of emission control required.

Item C: Maintenance of Equipment - 6 NYCRR 200.7

Any person who owns or operates an air contamination source which is equipped with an emission control device shall operate such device and keep it in a satisfactory state of maintenance and repair in accordance with ordinary and necessary practices, standards and procedures, inclusive of manufacturer's specifications,

Permit ID: 3-3309-00040/00005

Facility DEC ID: 3330900040

required to operate such device effectively.

Item D: Unpermitted Emission Sources - 6 NYCRR 201-1.2

(a) Except as otherwise provided by this Part, construction or operation of a new, modified or existing air contamination source without a registration or permit issued pursuant to this Part is prohibited.

(b) If an existing facility or emission source was subject to the permitting requirements of this Part at the time of construction or modification, and the owner or operator failed to apply for a permit or registration as described in this Part, the owner or operator must apply for a permit or registration in accordance with the provisions of this Part. The facility or emission source is subject to all regulations that were applicable to it at the time of construction or modification and any subsequent requirements applicable to existing emission sources.

Item E: Recycling and Salvage - 6 NYCRR 201-1.7

Where practical, any person who owns or operates an air contamination source shall recycle or salvage air contaminants collected in an air cleaning device according to the requirements of 6 NYCRR.

Item F: Prohibition of Reintroduction of Collected Contaminants to the Air - 6 NYCRR 201-1.8

No person shall unnecessarily remove, handle, or cause to be handled, collected air contaminants from an air cleaning device for recycling, salvage or disposal in a manner that would reintroduce them to the outdoor atmosphere.

Item G: Proof of Eligibility for Sources Defined as Exempt Activities - 6 NYCRR 201-3.2 (a)

The owner and/or operator of an emission source or unit that is eligible to be exempt, may be required to certify that it operates within the specific criteria described in 6 NYCRR Subpart 201-3. The owner or operator of any such emission source must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request.

Department representatives must be granted access to any facility which contains emission sources or units subject to 6 NYCRR Subpart 201-3, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

Item H: Proof of Eligibility for Sources Defined as Trivial

Permit ID: 3-3309-00040/00005

Facility DEC ID: 3330900040

Activities - 6 NYCRR 201-3.3 (a)

The owner and/or operator of an emission source or unit that is listed as being trivial in 6 NYCRR Part 201 may be required to certify that it operates within the specific criteria described in 6 NYCRR Subpart 201-3. The owner or operator of any such emission source must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility which contains emission sources or units subject to 6 NYCRR Subpart 201-3, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

Item I: Required Emission Tests - 6 NYCRR 202-1.1

An acceptable report of measured emissions shall be submitted, as may be required by the Commissioner, to ascertain compliance or noncompliance with any air pollution code, rule, or regulation. Failure to submit a report acceptable to the Commissioner within the time stated shall be sufficient reason for the Commissioner to suspend or deny an operating permit. Notification and acceptable procedures are specified in 6 NYCRR Subpart 202-1.

Item J: Open Fires Prohibitions - 6 NYCRR 215.2

Except as allowed by section 215.3 of 6 NYCRR Part 215, no person shall burn, cause, suffer, allow or permit the burning of any materials in an open fire.

Item K: Permit Exclusion - ECL 19-0305

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York (NYCRR). The issuance of this permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.

Item L: Federally Enforceable Requirements - 40 CFR 70.6 (b)

Permit ID: 3-3309-00040/00005

Facility DEC ID: 3330900040

All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

FEDERAL APPLICABLE REQUIREMENTS
The following conditions are federally enforceable.

Condition 1: Facility Permissible Emissions
Effective between the dates of 08/02/2023 and 08/01/2033

Applicable Federal Requirement:6 NYCRR Subpart 201-7

Item 1.1:

The sum of emissions from the emission units specified in this permit shall not equal or exceed the following

Potential To Emit (PTE) rate for each regulated contaminant:

CAS No: 000630-08-0	PTE: 199,000 pounds per year
Name: CARBON MONOXIDE	

Condition 2: Capping Monitoring Condition
Effective between the dates of 08/02/2023 and 08/01/2033

Applicable Federal Requirement:6 NYCRR Subpart 201-7

Item 2.1:

Under the authority of 6 NYCRR Part 201-7, this condition contains an emission cap for the purpose of limiting emissions from the facility, emission unit or process to avoid being subject to the following applicable requirement(s) that the facility, emission unit or process would otherwise be subject to:

6 NYCRR Subpart 201-6

Item 2.2:

Operation of this facility shall take place in accordance with the approved criteria, emission limits, terms, conditions and standards in this permit.

Item 2.3:

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any

Permit ID: 3-3309-00040/00005

Facility DEC ID: 3330900040

other state and federal air pollution control requirements, regulations or law.

Item 2.4:

On an annual basis, unless otherwise specified below, beginning one year after the granting of an emissions cap, the responsible official shall provide a certification to the Department that the facility has operated all emission units within the limits imposed by the emission cap. This certification shall include a brief summary of the emissions subject to the cap for that time period and a comparison to the threshold levels that would require compliance with an applicable requirement.

Item 2.5:

The emission of pollutants that exceed the applicability thresholds for an applicable requirement, for which the facility has obtained an emissions cap, constitutes a violation of Part 201 and of the Act.

Item 2.6:

The Compliance Demonstration activity will be performed for the Facility.

Regulated Contaminant(s):
 CAS No: 000630-08-0 CARBON MONOXIDE

Item 2.7:

Compliance Demonstration shall include the following monitoring:

Capping: Yes

Monitoring Type: MONITORING OF PROCESS OR CONTROL
 DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

The facility will cap carbon monoxide (CO) emissions below 199,000 pounds/year (99.5 tons/year) per rolling 12-month period. By taking this cap, the facility will avoid Air Title V permitting. The facility will only operate on natural gas during the ozone season. To achieve compliance with this emission limit, the facility plans to limit total operating hours.

CO emissions will be calculated monthly based on fuel usage and agreed upon emission factors. Records shall be kept for a minimum of (5) years and be made available to the Department upon request.

Parameter Monitored: CARBON MONOXIDE
 Upper Permit Limit: 199000 pounds per year
 Monitoring Frequency: MONTHLY
 Averaging Method: 12 MONTH AVERAGE - ROLLED MONTHLY
 Reporting Requirements: ANNUALLY (CALENDAR)
 Reports due 30 days after the reporting period.
 The initial report is due 1/30/2024.
 Subsequent reports are due every 12 calendar month(s).

Condition 3: Visible Emissions Limited
Effective between the dates of 08/02/2023 and 08/01/2033

Permit ID: 3-3309-00040/00005

Facility DEC ID: 3330900040

Applicable Federal Requirement:6 NYCRR 211.2

Item 3.1:

Except as permitted by a specific part of this Subchapter and for open fires for which a restricted burning permit has been issued, no person shall cause or allow any air contamination source to emit any material having an opacity equal to or greater than 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent opacity.

Condition 4: Compliance Demonstration
Effective between the dates of 08/02/2023 and 08/01/2033

Applicable Federal Requirement:6 NYCRR 225-1.2 (d)

Item 4.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 4.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS

Monitoring Description:

Owners or operators of emission sources that fire distillate oil are limited to a 0.0015 percent sulfur content by weight of the fuel. Compliance with the sulfur-in-fuel limitation is based on fuel vendor receipts. All fuel vendor receipts must be maintained on site or at a Department approved alternative location for a minimum of five years.

Note - Process sources and incinerators must comply with the above requirements on or after July 1, 2023.

Work Practice Type: PARAMETER OF PROCESS MATERIAL

Process Material: DISTILLATES - NUMBER 1 AND NUMBER 2 OIL

Parameter Monitored: SULFUR CONTENT

Upper Permit Limit: 0.0015 percent by weight

Monitoring Frequency: PER DELIVERY

Averaging Method: MAXIMUM - NOT TO BE EXCEEDED AT ANY TIME (INSTANTANEOUS/DISCRETE OR GRAB)

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2024.

Subsequent reports are due every 12 calendar month(s).

Condition 5: Compliance Demonstration
Effective between the dates of 08/02/2023 and 08/01/2033

Applicable Federal Requirement:6 NYCRR 227-1.3 (c)

Permit ID: 3-3309-00040/00005

Facility DEC ID: 3330900040

Item 5.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 5.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The owner or operator of a stationary combustion installation must perform an annual tune-up on each emission source subject to 6 NYCRR Subpart 227-1. Records of the tune-up shall be maintained at the facility or at a Department approved alternative location for a minimum of five years. The records shall, at a minimum, include the date the tune-up(s) occurred and the details of the tune-up procedures for each emission source.

Monitoring Frequency: ANNUALLY

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2024.

Subsequent reports are due every 12 calendar month(s).

Condition 6: Compliance Demonstration
Effective between the dates of 08/02/2023 and 08/01/2033

Applicable Federal Requirement: 6 NYCRR 227-1.4 (a)

Item 6.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 6.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

No owner or operator of a stationary combustion installation subject to this Subpart shall operate an emission source which exhibits greater than 20 percent opacity (based on a six minute average), except for one 6 minute period per hour of not more than 27 percent opacity. The owner or operator will conduct a Method 9 test annually. A report of the results of the test will be submitted to the Department within 30 days of the completion of the Method 9 test. All records generated by the permittee must be maintained at the facility or at an alternative location approved by the Department for a minimum of five years.

Parameter Monitored: OPACITY

Upper Permit Limit: 20 percent

Permit ID: 3-3309-00040/00005

Facility DEC ID: 3330900040

Reference Test Method: 40 CFR 60, Appendix A, Method 9
 Monitoring Frequency: ANNUALLY
 Averaging Method: 6-MINUTE AVERAGE (METHOD 9)
 Reporting Requirements: ANNUALLY (CALENDAR)
 Reports due 30 days after the reporting period.
 The initial report is due 1/30/2024.
 Subsequent reports are due every 12 calendar month(s).

Condition 7: Compliance Demonstration
Effective between the dates of 08/02/2023 and 08/01/2033

Applicable Federal Requirement:6 NYCRR 227-3.4 (a) (1)

Item 7.1:

The Compliance Demonstration activity will be performed for the Facility.

Regulated Contaminant(s):
 CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 7.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

By May 1, 2023, the owner or operator of an affected source must submit to the Department a compliance test protocol for Department approval at least 30 days prior to conducting the test. The owner or operator must submit a compliance test report containing the results of the emission test to the Department for approval no later than 60 days after completion of the emission test. The owner or operator must maintain a copy of the test report until a new test report has been approved by the Department. The approved test results will be used to calculate compliance with the applicable NOx emission limit.

Parameter Monitored: OXIDES OF NITROGEN
 Upper Permit Limit: 100 parts per million by volume
 (dry, corrected to 15% O2)
 Reference Test Method: Method 20
 Monitoring Frequency: Once every five years
 Averaging Method: 1-HOUR AVERAGE
 Reporting Requirements: ANNUALLY (CALENDAR)
 Reports due 30 days after the reporting period.
 The initial report is due 1/30/2024.
 Subsequent reports are due every 12 calendar month(s).

Condition 8: Compliance Demonstration
Effective between the dates of 08/02/2023 and 08/01/2033

Applicable Federal Requirement:6 NYCRR 227-3.4 (a) (2)

Permit ID: 3-3309-00040/00005

Facility DEC ID: 3330900040

Item 8.1:

The Compliance Demonstration activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 8.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

By May 1, 2025, the owner or operator of an affected source must submit to the Department a compliance test protocol for Department approval at least 30 days prior to conducting the test. The owner or operator must submit a compliance test report containing the results of the emission test to the Department for approval no later than 60 days after completion of the emission test. The owner or operator must maintain a copy of the test report until a new test report has been approved by the Department. The approved test results will be used to calculate compliance with the applicable NOx emission limit.

Parameter Monitored: OXIDES OF NITROGEN

Upper Permit Limit: 25 parts per million by volume (dry, corrected to 15% O2)

Reference Test Method: Method 20

Monitoring Frequency: Once every five years

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2024.

Subsequent reports are due every 12 calendar month(s).

Condition 9: Compliance Demonstration
Effective between the dates of 08/02/2023 and 08/01/2033

Applicable Federal Requirement: 6 NYCRR 227-3.4 (a) (3)

Item 9.1:

The Compliance Demonstration activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 9.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The facility will utilize water injection in order to meet the NOx emission limit under 6 NYCRR 227-3.4 when

Permit ID: 3-3309-00040/00005

Facility DEC ID: 3330900040

operating on natural gas during the ozone season. In addition, the facility will only operate on natural gas during the ozone season (May 1 -September 30). Compliance will be documented through stack testing.

Reference Test Method: USEPA Method 20

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 10: Applicability
Effective between the dates of 08/02/2023 and 08/01/2033

Applicable Federal Requirement:40CFR 63, Subpart ZZZZ

Item 10.1:

Facilities that have reciprocating internal combustion engines must comply with applicable portions of 40 CFR 63 Subpart ZZZZ.

Condition 11: Compliance Demonstration
Effective between the dates of 08/02/2023 and 08/01/2033

Applicable Federal Requirement:40CFR 97.406, Subpart AAAAA

Item 11.1:

The Compliance Demonstration activity will be performed for the Facility.

Regulated Contaminant(s):
 CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 11.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

- (1) The facility shall comply with the requirement to have a designated representative, and may have an alternate designated representative, in accordance with §§97.413 through 97.418 of Subpart AAAAA. The facility shall notify the Department of this representative (and alternative) with contact information upon issuance of this permit and when any changes are made to the representative (or alternative) or their contact information.
- (2) The facility, and the designated representative, of each TR NOX Annual source (facility) and each TR NOX Annual Unit at the facility shall comply with the monitoring, reporting, and recordkeeping requirements of §§97.430 through 97.435 of Subpart AAAAA and subpart H of part 75 of this chapter. This includes but is not limited

Permit ID: 3-3309-00040/00005

Facility DEC ID: 3330900040

to: requirements for installation, certification, and data accounting for all required monitoring systems; requirements for recording, reporting, and quality-assurance of the data; and certification of compliance of such data. Data from continuous emission monitoring equipment are submitted quarterly (calendar year). These reports are generally due 30 days after the end of a calendar quarter. All other monitoring data are submitted to the DEC semiannually (calendar year). These reports are due on January 30th and July 30th of each year.

(3) The emissions data determined shall be used to calculate allocations of TR NOx Annual allowances and to determine compliance with the TR NOx Annual emissions limitation and assurance provisions. As of the allowance transfer deadline for a control period in a given year, the owners and operators of each TR NOx Annual facility and each TR NOx Annual Unit at the facility shall hold, in the facilities compliance account, TR NOx Annual allowances available for deduction for such control period under §97.424(a) in an amount not less than the tons of total NOx emissions for such control period from all TR NOx Annual Units at the facility.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 12: Compliance Demonstration
Effective between the dates of 08/02/2023 and 08/01/2033

Applicable Federal Requirement: 40CFR 97.1006, Subpart GGGGG

Item 12.1:

The Compliance Demonstration activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 12.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

(1) The facility shall comply with the requirement to have a designated representative, and may have an alternate designated representative, in accordance with §§97.1013 through 97.1018 of Subpart GGGGG. The facility shall notify the Department of this representative (and

Permit ID: 3-3309-00040/00005

Facility DEC ID: 3330900040

alternate) with contact information upon issuance of this permit and when any changes are made to the representative (or alternate) or their contact information.

(2) The facility, and the designated representative, of each CSAPR NOx Ozone Season Group 3 source (facility) and each CSAPR NOx Ozone Season Group unit at the facility must comply with the monitoring, reporting, and recordkeeping requirements of §§97.1030 through 97.1035 of Subpart GGGGG and subpart H of part 75 of this chapter. This includes but is not limited to: requirements for installation, certification, and data accounting for all required monitoring systems; requirements for recording, reporting, and quality assurance of the data; and certification of compliance of such data. Data from continuous emission monitoring equipment are to be submitted quarterly (calendar year). These reports are generally due 30 days after the end of a calendar quarter. All other monitoring data are to be submitted to the DEC semiannually (calendar year). These reports are due on January 30th and July 30th of each year.

(3) The emissions data determined shall be used to calculate allocations of CSAPR NOx Ozone Season allowances and to determine compliance with the CSAPR NOx Ozone Season emissions limitation and assurance provisions. As of the allowance transfer deadline for a control period in a given year, the owners and operators of each CSAPR NOx Ozone Season facility and each CSAPR NOx Ozone Season Unit at the facility shall hold, in the facilities compliance account, CSAPR NOx Ozone Season allowances available for deduction for such control period under §97.1024(a) in an amount not less than the tons of total NOx emissions for such control period from all CSAPR NOx Ozone Season Group 3 units at the facility.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Permit ID: 3-3309-00040/00005

Facility DEC ID: 3330900040

STATE ONLY ENFORCEABLE CONDITIONS

****** Facility Level ******

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

This section contains terms and conditions which are not federally enforceable. Permittees may also have other obligations under regulations of general applicability

Item A: Emergency Defense - 6 NYCRR 201-1.5

An emergency, as defined in 6 NYCRR subpart 201-2, constitutes an affirmative defense to penalties sought in an enforcement action brought by the department for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

(a) The affirmative defense of emergency shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:

(1) an emergency occurred and that the facility owner or operator can identify the cause(s) of the emergency;

(2) the equipment at the facility was being properly operated and maintained;

(3) during the period of the emergency the facility owner or operator took all reasonable steps to minimize the levels of emissions that exceeded the emission standards, or other requirements in the permit; and

(4) the facility owner or operator notified the department within two working days after the event occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and any corrective actions taken.

(b) In any enforcement proceeding, the facility owner or operator seeking to establish the occurrence of an emergency has the burden of proof.

(c) This provision is in addition to any emergency or malfunction provision contained in any applicable requirement.

Item B: Public Access to Recordkeeping for Facilities With State Facility Permits - 6 NYCRR 201-1.10 (a)

Where facility owners and/or operators keep records pursuant to compliance with the requirements of 6 NYCRR Subpart 201-5.4, and/or the emission capping requirements of 6 NYCRR Subpart 201-7, the Department will make such records available to the public upon request in accordance

Permit ID: 3-3309-00040/00005

Facility DEC ID: 3330900040

with 6 NYCRR Part 616 - Public Access to Records.
Facility owners and/or operators must submit the records
required to comply with the request within sixty working
days of written notification by the Department.

Item C: **General Provisions for State Enforceable Permit Terms and
Condition - 6 NYCRR Part 201-5**

Any person who owns and/or operates stationary sources
shall operate and maintain all emission units and any
required emission control devices in compliance with all
applicable Parts of this Chapter and existing laws, and
shall operate the facility in accordance with all
criteria, emission limits, terms, conditions, and
standards in this permit. Failure of such person to
properly operate and maintain the effectiveness of such
emission units and emission control devices may be
sufficient reason for the Department to revoke or deny a
permit.

The owner or operator of the permitted facility must
maintain all required records on-site for a period of five
years and make them available to representatives of the
Department upon request. Department representatives must
be granted access to any facility regulated by this
Subpart, during normal operating hours, for the purpose of
determining compliance with this and any other state and
federal air pollution control requirements, regulations or
law.

STATE ONLY APPLICABLE REQUIREMENTS

The following conditions are state only enforceable.

Condition 13: Contaminant List

Effective between the dates of 08/02/2023 and 08/01/2033

Applicable State Requirement: ECL 19-0301

Item 13.1:

Emissions of the following contaminants are subject to contaminant specific requirements in
this permit (emission limits, control requirements or compliance monitoring conditions).

CAS No: 000124-38-9
Name: CARBON DIOXIDE

CAS No: 000630-08-0
Name: CARBON MONOXIDE

CAS No: 0NY210-00-0
Name: OXIDES OF NITROGEN

Permit ID: 3-3309-00040/00005

Facility DEC ID: 3330900040

Condition 14: Malfunctions and Start-up/Shutdown Activities
Effective between the dates of 08/02/2023 and 08/01/2033

Applicable State Requirement:6 NYCRR 201-1.4

Item 14.1:

(a) The facility owner or operator shall take all necessary and appropriate actions to prevent the emission of air pollutants that result in contravention of any applicable emission standard during periods of start-up, shutdown, or malfunction.

(b) The facility owner or operator shall compile and maintain records of all equipment maintenance and start-up/shutdown activities when they are expected to result in an exceedance of any applicable emission standard, and shall submit a report of such activities to the department when required by a permit condition or upon request by the department. Such reports shall state whether an exceedance occurred and if it was unavoidable, include the time, frequency and duration of the exceedance, and an estimate of the emission rates of any air contaminants released. Such records shall be maintained for a period of at least five years and made available for review to department representatives upon request. Facility owners or operators subject to continuous monitoring and quarterly reporting requirements need not submit additional reports of exceedances to the department.

(c) In the event that air contaminant emissions exceed any applicable emission standard due to a malfunction, the facility owner or operator shall notify the department as soon as possible during normal working hours, but not later than two working days after becoming aware that the malfunction occurred. In addition, the facility owner or operator shall compile and maintain a record of all malfunctions. Such records shall be maintained at the facility for a period of at least five years and must be made available to the department upon request. When requested by the department, the facility owner or operator shall submit a written report to the department describing the malfunction, the corrective action taken, the air contaminants emitted, and the resulting emission rates and/or opacity.

(d) The department may also require the facility owner or operator to include, in reports described under Subdivisions (b) and (c) of this Section, an estimate of the maximum ground level concentration of each air contaminant emitted and the effect of such emissions.

(e) A violation of any applicable emission standard resulting from start-up, shutdown, or malfunction conditions at a permitted or registered facility may not be subject to an enforcement action by the department and/or penalty if the department determines, in its sole discretion, that such a violation was unavoidable. The actions and recordkeeping and reporting requirements listed above must be adhered to in such circumstances.

Condition 15: Emission Unit Definition
Effective between the dates of 08/02/2023 and 08/01/2033

Applicable State Requirement:6 NYCRR Subpart 201-5

Item 15.1:

Permit ID: 3-3309-00040/00005

Facility DEC ID: 3330900040

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: 1-00001

Emission Unit Description:

Natural gas/jet fuel A/distillate/biodiesel-fired twin pac turbine consisting of two engines used to turn a simple cycle gas turbine rated at 512 mmBtu/hr (40 MW).

Building(s): GTBLDG

Item 15.2:

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: 1-00002

Emission Unit Description:

Natural gas-fired reciprocating internal combustion engine used to boost the pressure of the natural gas supplied to the gas turbine. Engine rated at 560 kW.

Building(s): ICBLDG

Condition 16: Renewal deadlines for state facility permits
Effective between the dates of 08/02/2023 and 08/01/2033

Applicable State Requirement:6 NYCRR 201-5.2 (c)

Item 16.1:

The owner or operator of a facility having an issued state facility permit shall submit a complete application at least 180 days, but not more than eighteen months, prior to the date of permit expiration for permit renewal purposes.

Condition 17: Compliance Demonstration
Effective between the dates of 08/02/2023 and 08/01/2033

Applicable State Requirement:6 NYCRR 201-5.3 (c)

Item 17.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 17.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Any reports or submissions required by this permit shall be submitted to the Regional Air Pollution Control Engineer (RAPCE) at the following address:

Division of Air Resources
NYS Dept. of Environmental Conservation
Region 3
21 South Putt Corners Rd.
New Paltz, NY 12561

Permit ID: 3-3309-00040/00005

Facility DEC ID: 3330900040

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING

DESCRIPTION

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2024.

Subsequent reports are due every 12 calendar month(s).

Condition 18: Air pollution prohibited
Effective between the dates of 08/02/2023 and 08/01/2033

Applicable State Requirement:6 NYCRR 211.1

Item 18.1:

No person shall cause or allow emissions of air contaminants to the outdoor atmosphere of such quantity, characteristic or duration which are injurious to human, plant or animal life or to property, or which unreasonably interfere with the comfortable enjoyment of life or property. Notwithstanding the existence of specific air quality standards or emission limits, this prohibition applies, but is not limited to, any particulate, fume, gas, mist, odor, smoke, vapor, pollen, toxic or deleterious emission, either alone or in combination with others.

****** Emission Unit Level ******

Condition 19: Emission Point Definition By Emission Unit
Effective between the dates of 08/02/2023 and 08/01/2033

Applicable State Requirement:6 NYCRR Subpart 201-5

Item 19.1:

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: 1-00001

Emission Point: 00001

Height (ft.): 45 Length (in.): 21 Width (in.): 15

NYTMN (km.): 4587.034 NYTME (km.): 548.249 Building: GTBLDG

Item 19.2:

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: 1-00002

Emission Point: 00002

Height (ft.): 13 Diameter (in.): 8

NYTMN (km.): 4587.023 NYTME (km.): 548.251 Building: ICBLDG

Condition 20: Process Definition By Emission Unit
Effective between the dates of 08/02/2023 and 08/01/2033

Permit ID: 3-3309-00040/00005

Facility DEC ID: 3330900040

Applicable State Requirement:6 NYCRR Subpart 201-5

Item 20.1:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: 1-00001
 Process: 1GS Source Classification Code: 2-01-002-01
 Process Description:
 Stationary jet engines operating on natural gas driving a
 SCGT rated at 40 MW generating electricity for sale.
 Emission Source/Control: 0GT01 - Combustion
 Design Capacity: 512 million Btu per hour

Item 20.2:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: 1-00001
 Process: 1OL Source Classification Code: 2-01-009-01
 Process Description:
 Stationary jet engines operating on fuel oil driving a
 SCGT rated at 40 MW generating electricity for sale. The
 facility will only operate on fuel oil during the
 non-ozone season.
 Emission Source/Control: 0GT01 - Combustion
 Design Capacity: 512 million Btu per hour

Item 20.3:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: 1-00002
 Process: 2GS Source Classification Code: 2-02-002-02
 Process Description:
 Natural gas-fired reciprocating internal combustion
 engine used to boost the pressure of the natural gas
 supplied to the gas turbine.
 Emission Source/Control: 0IC01 - Combustion
 Design Capacity: 560 kilowatts

Condition 21: Compliance Demonstration
Effective between the dates of 08/02/2023 and 08/01/2033

Applicable State Requirement:6 NYCRR 251.3 (b)

Item 21.1:

The Compliance Demonstration activity will be performed for:

Emission Unit: 1-00001

Permit ID: 3-3309-00040/00005

Facility DEC ID: 3330900040

Regulated Contaminant(s):

CAS No: 000124-38-9 CARBON DIOXIDE

Item 21.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

On or after December 31, 2020, owners or operators of non-modified existing sources shall not fire any single fossil fuel, alone or in combination with any other fuel, where each fossil fuel is required to meet an emission rate of 1800 pounds of CO₂ per MW hour gross electrical output (output-based limit). These emission limits are measured on an annual basis, calculated by dividing the annual total of CO₂ emissions for the calendar year by the annual total MW hour gross electrical output (output-based limit) for each separate fossil fuel fired.

The owner or operator must maintain all records associated with these requirements on site or at a location acceptable to the Department for a minimum of five years.

Manufacturer Name/Model Number: CO₂ Continuous Monitor

Parameter Monitored: CARBON DIOXIDE

Upper Permit Limit: 1800 pounds per megawatt hour

Monitoring Frequency: CONTINUOUS

Averaging Method: CALENDAR YEAR AVERAGE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 10/30/2023.

Subsequent reports are due every 3 calendar month(s).

Permit ID: 3-3309-00040/00005

Facility DEC ID: 3330900040