

Facility DEC ID: 3552200062

PERMIT
Under the Environmental Conservation Law (ECL)

IDENTIFICATION INFORMATION

Permit Type: Air State Facility
Permit ID: 3-5522-00062/00005
Effective Date:

Expiration Date:

Permit Issued To: US DEPT OF VETERANS AFFAIRS
c/o DR SHEREEF ELNAHAL
810 VERMONT AVE NW
WASHINGTON, DC 20420

Contact: JOE DILOSSI
VA HUDSON VALLEY HEALTH CARE SYSTEM
2094 ALBANY POST RD
MONTROSE, NY 10548
(914) 755-0524

Facility: VA HUDSON VALLEY HEALTH CARE SYSTEM
2094 ALBANY POST RD & ST RTE 9A
Montrose, NY 10548

Description:
The VA Hudson Valley Health Care system, Montrose campus provides general medical and surgical services. It consists primarily of a hospital building, which supports general medical facilities, laboratories and office space. The hospital currently operates four natural gas/No. 2 fuel-fired boilers (32.58 mmBtu/hr) and thirteen diesel/No. 2 fuel oil-fired emergency generators.

By acceptance of this permit, the permittee agrees that the permit is contingent upon strict compliance with the ECL, all applicable regulations, the General Conditions specified and any Special Conditions included as part of this permit.

Permit Administrator: ELLEN M HART
NYSDEC - REGION 3
21 S PUTT CORNERS RD
NEW PALTZ, NY 12561

Authorized Signature: _____ Date: ____ / ____ / ____

Facility DEC ID: 3552200062

Notification of Other State Permittee Obligations**Item A: Permittee Accepts Legal Responsibility and Agrees to Indemnification**

The permittee expressly agrees to indemnify and hold harmless the Department of Environmental Conservation of the State of New York, its representatives, employees and agents ("DEC") for all claims, suits, actions, and damages, to the extent attributable to the permittee's acts or omissions in connection with the compliance permittee's undertaking of activities in connection with, or operation and maintenance of, the facility or facilities authorized by the permit whether in compliance or not in any compliance with the terms and conditions of the permit. This indemnification does not extend to any claims, suits, actions, or damages to the extent attributable to DEC's own negligent or intentional acts or omissions, or to any claims, suits, or actions naming the DEC and arising under article 78 of the New York Civil Practice Laws and Rules or any citizen suit or civil rights provision under federal or state laws.

Item B: Permittee's Contractors to Comply with Permit

The permittee is responsible for informing its independent contractors, employees, agents and assigns of their responsibility to comply with this permit, including all special conditions while acting as the permittee's agent with respect to the permitted activities, and such persons shall be subject to the same sanctions for violations of the Environmental Conservation Law as those prescribed for the permittee.

Item C: Permittee Responsible for Obtaining Other Required Permits

The permittee is responsible for obtaining any other permits, approvals, lands, easements and rights-of-way that may be required to carry out the activities that are authorized by this permit.

Item D: No Right to Trespass or Interfere with Riparian Rights

This permit does not convey to the permittee any right to trespass upon the lands or interfere with the riparian rights of others in order to perform the permitted work nor does it authorize the impairment of any rights, title, or interest in real or personal property held or vested in a person not a party to the permit.

Facility DEC ID: 3552200062

PAGE LOCATION OF CONDITIONS

PAGE

DEC GENERAL CONDITIONS

General Provisions

- | | | |
|---|---|---|
| 4 | 1 | Facility Inspection by the Department |
| 4 | 2 | Relationship of this Permit to Other Department Orders and Determinations |
| 4 | 3 | Applications for permit renewals, modifications and transfers |
| 5 | 4 | Permit modifications, suspensions or revocations by the Department |

Facility Level

- | | | |
|---|---|--|
| 5 | 5 | Submission of application for permit modification or renewal
-REGION 3 HEADQUARTERS |
|---|---|--|

Facility DEC ID: 3552200062

DEC GENERAL CONDITIONS

**** General Provisions ****

GENERAL CONDITIONS - Apply to ALL Authorized Permits.**Condition 1: Facility Inspection by the Department****Applicable State Requirement: ECL 19-0305****Item 1.1:**

The permitted site or facility, including relevant records, is subject to inspection at reasonable hours and intervals by an authorized representative of the Department of Environmental Conservation (the Department) to determine whether the permittee is complying with this permit and the ECL. Such representative may order the work suspended pursuant to ECL 71-0301 and SAPA 401(3).

Item 1.2:

The permittee shall provide a person to accompany the Department's representative during an inspection to the permit area when requested by the Department.

Item 1.3:

A copy of this permit, including all referenced maps, drawings and special conditions, must be available for inspection by the Department at all times at the project site or facility. Failure to produce a copy of the permit upon request by a Department representative is a violation of this permit.

Condition 2: Relationship of this Permit to Other Department Orders and Determinations**Applicable State Requirement: ECL 3-0301 (2) (m)****Item 2.1:**

Unless expressly provided for by the Department, issuance of this permit does not modify, supersede or rescind any order or determination previously issued by the Department or any of the terms, conditions or requirements contained in such order or determination.

Condition 3: Applications for permit renewals, modifications and transfers**Applicable State Requirement: 6 NYCRR 621.11****Item 3.1:**

The permittee must submit a separate written application to the Department for renewal, modification or transfer of this permit. Such application must include any forms or supplemental information the Department requires. Any renewal, modification or transfer granted by the Department must be in writing.

Item 3.2:

The permittee must submit a renewal application at least 180 days before the expiration of permits for Title V and State Facility Permits.

Item 3.3

Permits are transferrable with the approval of the department unless specifically prohibited by the statute, regulation or another permit condition. Applications for permit transfer should be submitted prior to actual transfer of ownership.

Facility DEC ID: 3552200062

Condition 4: Permit modifications, suspensions or revocations by the Department
Applicable State Requirement: 6 NYCRR 621.13

Item 4.1:

The Department reserves the right to exercise all available authority to modify, suspend, or revoke this permit in accordance with 6NYCRR Part 621. The grounds for modification, suspension or revocation include:

- a) materially false or inaccurate statements in the permit application or supporting papers;
- b) failure by the permittee to comply with any terms or conditions of the permit;
- c) exceeding the scope of the project as described in the permit application;
- d) newly discovered material information or a material change in environmental conditions, relevant technology or applicable law or regulations since the issuance of the existing permit;
- e) noncompliance with previously issued permit conditions, orders of the commissioner, any provisions of the Environmental Conservation Law or regulations of the Department related to the permitted activity.

****** Facility Level ******

Condition 5: Submission of application for permit modification or renewal -REGION 3 HEADQUARTERS
Applicable State Requirement: 6 NYCRR 621.6 (a)

Item 5.1:

Submission of applications for permit modification or renewal are to be submitted to:
NYSDEC Regional Permit Administrator
Region 3 Headquarters
Division of Environmental Permits
21 South Putt Corners Road
New Paltz, NY 12561-1696
(845) 256-3054

Permit ID: 3-5522-00062/00005

Facility DEC ID: 3552200062

Permit Under the Environmental Conservation Law (ECL)

ARTICLE 19: AIR POLLUTION CONTROL - AIR STATE FACILITY PERMIT

IDENTIFICATION INFORMATION

Permit Issued To: US DEPT OF VETERANS AFFAIRS
c/o DR SHEREEF ELNAHAL
810 VERMONT AVE NW
WASHINGTON, DC 20420

Facility: VA HUDSON VALLEY HEALTH CARE SYSTEM
2094 ALBANY POST RD & ST RTE 9A
Montrose, NY 10548

Authorized Activity By Standard Industrial Classification Code:
4961 - STEAM SUPPLY
8062 - GENERAL MEDICAL & SURGICAL HOSPITALS
8999 - SERVICES, NEC

Permit Effective Date:

Permit Expiration Date:

Permit ID: 3-5522-00062/00005

Facility DEC ID: 3552200062

PAGE LOCATION OF CONDITIONS

PAGE

FEDERALLY ENFORCEABLE CONDITIONS

Facility Level

- | | |
|----|---|
| 6 | 1 40 CFR Part 68: Accidental release provisions. |
| 6 | 2 40CFR 82, Subpart F: Recycling and Emissions Reduction |
| 7 | 3 6 NYCRR 200.1 (cq): Definition for Emergency Generators |
| 7 | 4 6 NYCRR Subpart 201-7: Facility Permissible Emissions |
| 7 | *5 6 NYCRR Subpart 201-7: Capping Monitoring Condition |
| 9 | 6 6 NYCRR 211.2: Visible Emissions Limited |
| 9 | 7 6 NYCRR 225-1.2 (d): Compliance Demonstration |
| 10 | 8 6 NYCRR 227-1.4 (a): Compliance Demonstration |
| 11 | 9 40CFR 60, NSPS Subpart IIII: Applicability |
| 11 | 10 40CFR 63, Subpart JJJJJ: Applicability |

Emission Unit Level

- | | |
|----|---|
| 11 | 11 6 NYCRR Subpart 201-7: Process Permissible Emissions |
|----|---|

STATE ONLY ENFORCEABLE CONDITIONS

Facility Level

- | | |
|----|--|
| 14 | 12 ECL 19-0301: Contaminant List |
| 14 | 13 6 NYCRR 201-1.4: Malfunctions and Start-up/Shutdown Activities |
| 15 | 14 6 NYCRR Subpart 201-5: Emission Unit Definition |
| 16 | 15 6 NYCRR 201-5.2 (c): Renewal deadlines for state facility permits |
| 16 | 16 6 NYCRR 201-5.3 (c): Compliance Demonstration |
| 17 | 17 6 NYCRR 211.1: Air pollution prohibited |

Emission Unit Level

- | | |
|----|--|
| 17 | 18 6 NYCRR Subpart 201-5: Emission Point Definition By Emission Unit |
| 19 | 19 6 NYCRR Subpart 201-5: Process Definition By Emission Unit |

NOTE: * preceding the condition number indicates capping.

Permit ID: 3-5522-00062/00005

Facility DEC ID: 3552200062

FEDERALLY ENFORCEABLE CONDITIONS

Renewal 2/DRAFT

**** Facility Level ****

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

This section contains terms and conditions which are federally enforceable. Permittees may also have other obligations under regulations of general applicability

Item A: Sealing - 6 NYCRR 200.5

The Commissioner may seal an air contamination source to prevent its operation if compliance with 6 NYCRR Chapter III is not met within the time provided by an order of the Commissioner issued in the case of the violation. Sealing means labeling or tagging a source to notify any person that operation of the source is prohibited, and also includes physical means of preventing the operation of an air contamination source without resulting in destruction of any equipment associated with such source, and includes, but is not limited to, bolting, chaining or wiring shut control panels, apertures or conduits associated with such source.

No person shall operate any air contamination source sealed by the Commissioner in accordance with this section unless a modification has been made which enables such source to comply with all requirements applicable to such modification.

Unless authorized by the Commissioner, no person shall remove or alter any seal affixed to any contamination source in accordance with this section.

Item B: Acceptable Ambient Air Quality - 6 NYCRR 200.6

Notwithstanding the provisions of 6 NYCRR Chapter III, Subchapter A, no person shall allow or permit any air contamination source to emit air contaminants in quantities which alone or in combination with emissions from other air contamination sources would contravene any applicable ambient air quality standard and/or cause air pollution. In such cases where contravention occurs or may occur, the Commissioner shall specify the degree and/or method of emission control required.

Item C: Maintenance of Equipment - 6 NYCRR 200.7

Any person who owns or operates an air contamination source which is equipped with an emission control device shall operate such device and keep it in a satisfactory state of maintenance and repair in accordance with ordinary and necessary practices, standards and procedures, inclusive of manufacturer's specifications,

Permit ID: 3-5522-00062/00005

Facility DEC ID: 3552200062

required to operate such device effectively.

Item D: Unpermitted Emission Sources - 6 NYCRR 201-1.2

(a) Except as otherwise provided by this Part, construction or operation of a new, modified or existing air contamination source without a registration or permit issued pursuant to this Part is prohibited.

(b) If an existing facility or emission source was subject to the permitting requirements of this Part at the time of construction or modification, and the owner or operator failed to apply for a permit or registration as described in this Part, the owner or operator must apply for a permit or registration in accordance with the provisions of this Part. The facility or emission source is subject to all regulations that were applicable to it at the time of construction or modification and any subsequent requirements applicable to existing emission sources.

Item E: Recycling and Salvage - 6 NYCRR 201-1.7

Where practical, any person who owns or operates an air contamination source shall recycle or salvage air contaminants collected in an air cleaning device according to the requirements of 6 NYCRR.

Item F: Prohibition of Reintroduction of Collected Contaminants to the Air - 6 NYCRR 201-1.8

No person shall unnecessarily remove, handle, or cause to be handled, collected air contaminants from an air cleaning device for recycling, salvage or disposal in a manner that would reintroduce them to the outdoor atmosphere.

Item G: Proof of Eligibility for Sources Defined as Exempt Activities - 6 NYCRR 201-3.2 (a)

The owner and/or operator of an emission source or unit that is eligible to be exempt, may be required to certify that it operates within the specific criteria described in 6 NYCRR Subpart 201-3. The owner or operator of any such emission source must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request.

Department representatives must be granted access to any facility which contains emission sources or units subject to 6 NYCRR Subpart 201-3, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

Item H: Proof of Eligibility for Sources Defined as Trivial

Permit ID: 3-5522-00062/00005

Facility DEC ID: 3552200062

Activities - 6 NYCRR 201-3.3 (a)

The owner and/or operator of an emission source or unit that is listed as being trivial in 6 NYCRR Part 201 may be required to certify that it operates within the specific criteria described in 6 NYCRR Subpart 201-3. The owner or operator of any such emission source must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility which contains emission sources or units subject to 6 NYCRR Subpart 201-3, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

Item I: Required Emission Tests - 6 NYCRR 202-1.1

An acceptable report of measured emissions shall be submitted, as may be required by the Commissioner, to ascertain compliance or noncompliance with any air pollution code, rule, or regulation. Failure to submit a report acceptable to the Commissioner within the time stated shall be sufficient reason for the Commissioner to suspend or deny an operating permit. Notification and acceptable procedures are specified in 6 NYCRR Subpart 202-1.

Item J: Open Fires Prohibitions - 6 NYCRR 215.2

Except as allowed by section 215.3 of 6 NYCRR Part 215, no person shall burn, cause, suffer, allow or permit the burning of any materials in an open fire.

Item K: Permit Exclusion - ECL 19-0305

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York (NYCRR). The issuance of this permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.

Item L: Federally Enforceable Requirements - 40 CFR 70.6 (b)

Permit ID: 3-5522-00062/00005

Facility DEC ID: 3552200062

All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

FEDERAL APPLICABLE REQUIREMENTS**The following conditions are federally enforceable.****Condition 1: Accidental release provisions.
Effective for entire length of Permit****Applicable Federal Requirement: 40 CFR Part 68****Item 1.1:**

If a chemical is listed in Tables 1,2,3 or 4 of 40 CFR §68.130 is present in a process in quantities greater than the threshold quantity listed in Tables 1,2,3 or 4, the following requirements will apply:

- a) The owner or operator shall comply with the provisions of 40 CFR Part 68 and;
- b) The owner or operator shall submit at the time of permit issuance (if not previously submitted) one of the following, if such quantities are present:
 - 1) A compliance schedule for meeting the requirements of 40 CFR Part 68 by the date provided in 40 CFR §68.10(a) or,
 - 2) A certification statement that the source is in compliance with all requirements of 40 CFR Part 68, including the registration and submission of the Risk Management Plan. Information should be submitted to:

Risk Management Plan Reporting Center
C/O CSC
8400 Corporate Dr
Carrollton, Md. 20785

**Condition 2: Recycling and Emissions Reduction
Effective for entire length of Permit****Applicable Federal Requirement: 40 CFR 82, Subpart F****Item 2.1:**

The permittee shall comply with all applicable provisions of 40 CFR Part 82.

Condition 3: Definition for Emergency Generators

Permit ID: 3-5522-00062/00005

Facility DEC ID: 3552200062

Effective for entire length of Permit**Applicable Federal Requirement: 6 NYCRR 200.1 (cq)**

Item 3.1: Emergency power generating stationary internal combustion engine is defined as a stationary internal combustion engine that operates as a mechanical or electrical power source only when the usual supply of power is unavailable, and operates for no more than 500 hours per year. The 500 hours of annual operation for the engine includes operation during the emergency situations, routine maintenance and routine exercising (for example, test firing the engine for one hour a week to ensure reliability). A stationary internal combustion engine used for peak shaving generation is not an emergency power generating stationary internal combustion engine.

Condition 4: Facility Permissible Emissions
Effective for entire length of Permit

Applicable Federal Requirement: 6 NYCRR Subpart 201-7**Item 4.1:**

The sum of emissions from the emission units specified in this permit shall not equal or exceed the following

Potential To Emit (PTE) rate for each regulated contaminant:

CAS No: 0NY210-00-0

PTE: 45,000 pounds per year

Name: OXIDES OF NITROGEN

Condition 5: Capping Monitoring Condition
Effective for entire length of Permit

Applicable Federal Requirement: 6 NYCRR Subpart 201-7**Item 5.1:**

Under the authority of 6 NYCRR Part 201-7, this condition contains an emission cap for the purpose of limiting emissions from the facility, emission unit or process to avoid being subject to the following applicable requirement(s) that the facility, emission unit or process would otherwise be subject to:

6 NYCRR Subpart 201-6

Item 5.2:

Operation of this facility shall take place in accordance with the approved criteria, emission limits, terms, conditions and standards in this permit.

Item 5.3:

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any

Permit ID: 3-5522-00062/00005

Facility DEC ID: 3552200062

other state and federal air pollution control requirements, regulations or law.

Item 5.4:

On an annual basis, unless otherwise specified below, beginning one year after the granting of an emissions cap, the responsible official shall provide a certification to the Department that the facility has operated all emission units within the limits imposed by the emission cap. This certification shall include a brief summary of the emissions subject to the cap for that time period and a comparison to the threshold levels that would require compliance with an applicable requirement.

Item 5.5:

The emission of pollutants that exceed the applicability thresholds for an applicable requirement, for which the facility has obtained an emissions cap, constitutes a violation of Part 201 and of the Act.

Item 5.6:

The Compliance Demonstration activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 5.7:

Compliance Demonstration shall include the following monitoring:

Capping: Yes

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

The total NO_x emissions cannot exceed 45,000 pounds per year.

The facility will use the following formula to verify that the Facility complies with the herein stated limit.

$$A * EF1 + B * EF2 + C * EF3 = 45,000$$

lbs/year

where:

A: Quantity of No. 2 oil burned by the boilers in thousand gallons. This quantity will be calculated using a 12 month average, rolled monthly.

EF1: emission factor = 20 lbs of NO_x emitted per thousand gallons of No. 2 oil burned.

B: Quantity of natural gas burned by the boilers in million cubic feet. This quantity will be calculated using a 12 month average, rolled monthly.

EF2: emission factor = 50 lbs of NO_x emitted per million standard cubic feet of natural gas burned.

Permit ID: 3-5522-00062/00005

Facility DEC ID: 3552200062

C: Quantity of No. 2 oil and diesel fuel burned by the emergency generators. This quantity will be calculated using a 12 month average, rolled monthly.

EF3: Emissions factor for engines (generators) per gallon of No. 2 oil or diesel fuel used. This factor is given as the product of 4.41 lbs/mmBtu and the heating value of No. 2 oil/diesel fuel is considered to be 135,000 BTU/gallon. Thus, $EF3 = 0.595$ lbs of NO_x per gallon of No. 2 oil/diesel fuel.

Emission factors are referenced on Table 1.3-1, Table 1.4-1 and Table 3.3-1 of AP-42.

The facility shall submit annual reports indicating annual NO_x emissions (based on fuel use), which will be calculated on a monthly basis (12-month rolling average).

Parameter Monitored: OXIDES OF NITROGEN

Upper Permit Limit: 45,000 pounds per year

Reference Test Method: N/A

Monitoring Frequency: MONTHLY

Averaging Method: 12 MONTH AVERAGE - ROLLED MONTHLY

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 12 calendar month(s).

Condition 6: Visible Emissions Limited
Effective for entire length of Permit

Applicable Federal Requirement: 6 NYCRR 211.2

Item 6.1:

Except as permitted by a specific part of this Subchapter and for open fires for which a restricted burning permit has been issued, no person shall cause or allow any air contamination source to emit any material having an opacity equal to or greater than 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent opacity.

Condition 7: Compliance Demonstration
Effective for entire length of Permit

Applicable Federal Requirement: 6 NYCRR 225-1.2 (d)

Item 7.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 7.2:

Permit ID: 3-5522-00062/00005

Facility DEC ID: 3552200062

Compliance Demonstration shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS

Monitoring Description:

Owners or operators of emission sources that fire distillate oil are limited to a 0.0015 percent sulfur content by weight of the fuel. Compliance with the sulfur-in-fuel limitation is based on fuel vendor receipts. All fuel vendor receipts must be maintained on site or at a Department approved alternative location for a minimum of five years.

Note - Process sources and incinerators must comply with the above requirements on or after July 1, 2023.

Work Practice Type: PARAMETER OF PROCESS MATERIAL

Process Material: DISTILLATES - NUMBER 1 AND NUMBER 2 OIL

Parameter Monitored: SULFUR CONTENT

Upper Permit Limit: 0.0015 percent by weight

Monitoring Frequency: PER DELIVERY

Averaging Method: MAXIMUM - NOT TO BE EXCEEDED AT ANY TIME (INSTANTANEOUS/DISCRETE OR GRAB)

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 12 calendar month(s).

Condition 8: Compliance Demonstration
Effective for entire length of Permit

Applicable Federal Requirement: 6 NYCRR 227-1.4 (a)

Item 8.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 8.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

No owner or operator of a stationary combustion installation subject to this Subpart shall operate an emission source which exhibits greater than 20 percent opacity (based on a six minute average), except for one 6 minute period per hour of not more than 27 percent opacity. The owner or operator will conduct a Method 9 test annually. A report of the results of the test will be submitted to the Department within 30 days of the completion of the Method 9 test. All records generated by the permittee must be maintained at the facility or at an alternative location approved by the Department for a

Permit ID: 3-5522-00062/00005

Facility DEC ID: 3552200062

minimum of five years.

Parameter Monitored: OPACITY
 Upper Permit Limit: 20 percent
 Reference Test Method: 40 CFR 60, Appendix A, Method 9
 Monitoring Frequency: ANNUALLY
 Averaging Method: 6-MINUTE AVERAGE (METHOD 9)
 Reporting Requirements: ANNUALLY (CALENDAR)
 Reports due 30 days after the reporting period.
 Subsequent reports are due every 12 calendar month(s).

Condition 9: Applicability
Effective for entire length of Permit

Applicable Federal Requirement: 40 CFR 60, NSPS Subpart IIII

Item 9.1:

Facilities that have stationary compression ignition internal combustion engines must comply with applicable portions of 40 CFR 60 Subpart IIII.

Condition 10: Applicability
Effective for entire length of Permit

Applicable Federal Requirement: 40 CFR 63, Subpart JJJJJ

Item 10.1:

Facilities that are area sources of HAP with industrial, commercial, or institutional boilers must comply with applicable portions of 40 CFR 63 JJJJJ.

****** Emission Unit Level ******

Condition 11: Process Permissible Emissions
Effective for entire length of Permit

Applicable Federal Requirement: 6 NYCRR Subpart 201-7

Item 11.1:

The sum of emissions from the regulated process cited shall not exceed the following Potential to Emit (PTE) rates for each regulated contaminant:

Emission Unit:	1-00001	Process:	A01
CAS No: 0NY210-00-0			
Name: OXIDES OF NITROGEN			
PTE(s):	0.07 pounds per hour		
			613.2 pounds per year

Permit ID: 3-5522-00062/00005

Facility DEC ID: 3552200062

Emission Unit: 1-00001

Process: B01

CAS No: 0NY210-00-0

Name: OXIDES OF NITROGEN

PTE(s): 3.8 pounds per hour

33,288 pounds per year

Emission Unit: 1-00003

Process: A03

CAS No: 0NY210-00-0

Name: OXIDES OF NITROGEN

PTE(s): 1.25 pounds per hour

10,950 pounds per year

Permit ID: 3-5522-00062/00005

Facility DEC ID: 3552200062

STATE ONLY ENFORCEABLE CONDITIONS****** Facility Level ********NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS**

This section contains terms and conditions which are not federally enforceable. Permittees may also have other obligations under regulations of general applicability

Item A: Emergency Defense - 6 NYCRR 201-1.5

An emergency, as defined in 6 NYCRR subpart 201-2, constitutes an affirmative defense to penalties sought in an enforcement action brought by the department for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

(a) The affirmative defense of emergency shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:

(1) an emergency occurred and that the facility owner or operator can identify the cause(s) of the emergency;

(2) the equipment at the facility was being properly operated and maintained;

(3) during the period of the emergency the facility owner or operator took all reasonable steps to minimize the levels of emissions that exceeded the emission standards, or other requirements in the permit; and

(4) the facility owner or operator notified the department within two working days after the event occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and any corrective actions taken.

(b) In any enforcement proceeding, the facility owner or operator seeking to establish the occurrence of an emergency has the burden of proof.

(c) This provision is in addition to any emergency or malfunction provision contained in any applicable requirement.

Item B: Public Access to Recordkeeping for Facilities With State Facility Permits - 6 NYCRR 201-1.10 (a)

Where facility owners and/or operators keep records pursuant to compliance with the requirements of 6 NYCRR Subpart 201-5.4, and/or the emission capping requirements of 6 NYCRR Subpart 201-7, the Department will make such records available to the public upon request in accordance

Permit ID: 3-5522-00062/00005

Facility DEC ID: 3552200062

with 6 NYCRR Part 616 - Public Access to Records.
Facility owners and/or operators must submit the records
required to comply with the request within sixty working
days of written notification by the Department.

Item C: **General Provisions for State Enforceable Permit Terms and
Condition - 6 NYCRR Part 201-5**

Any person who owns and/or operates stationary sources
shall operate and maintain all emission units and any
required emission control devices in compliance with all
applicable Parts of this Chapter and existing laws, and
shall operate the facility in accordance with all
criteria, emission limits, terms, conditions, and
standards in this permit. Failure of such person to
properly operate and maintain the effectiveness of such
emission units and emission control devices may be
sufficient reason for the Department to revoke or deny a
permit.

The owner or operator of the permitted facility must
maintain all required records on-site for a period of five
years and make them available to representatives of the
Department upon request. Department representatives must
be granted access to any facility regulated by this
Subpart, during normal operating hours, for the purpose of
determining compliance with this and any other state and
federal air pollution control requirements, regulations or
law.

STATE ONLY APPLICABLE REQUIREMENTS

The following conditions are state only enforceable.

Condition 12: Contaminant List
Effective for entire length of Permit

Applicable State Requirement:ECL 19-0301

Item 12.1:

Emissions of the following contaminants are subject to contaminant specific requirements in
this permit(emission limits, control requirements or compliance monitoring conditions).

CAS No: 0NY210-00-0

Name: OXIDES OF NITROGEN

Condition 13: Malfunctions and Start-up/Shutdown Activities
Effective for entire length of Permit

Applicable State Requirement:6 NYCRR 201-1.4

Permit ID: 3-5522-00062/00005

Facility DEC ID: 3552200062

Item 13.1:

(a) The facility owner or operator shall take all necessary and appropriate actions to prevent the emission of air pollutants that result in contravention of any applicable emission standard during periods of start-up, shutdown, or malfunction.

(b) The facility owner or operator shall compile and maintain records of all equipment maintenance and start-up/shutdown activities when they are expected to result in an exceedance of any applicable emission standard, and shall submit a report of such activities to the department when required by a permit condition or upon request by the department. Such reports shall state whether an exceedance occurred and if it was unavoidable, include the time, frequency and duration of the exceedance, and an estimate of the emission rates of any air contaminants released. Such records shall be maintained for a period of at least five years and made available for review to department representatives upon request. Facility owners or operators subject to continuous monitoring and quarterly reporting requirements need not submit additional reports of exceedances to the department.

(c) In the event that air contaminant emissions exceed any applicable emission standard due to a malfunction, the facility owner or operator shall notify the department as soon as possible during normal working hours, but not later than two working days after becoming aware that the malfunction occurred. In addition, the facility owner or operator shall compile and maintain a record of all malfunctions. Such records shall be maintained at the facility for a period of at least five years and must be made available to the department upon request. When requested by the department, the facility owner or operator shall submit a written report to the department describing the malfunction, the corrective action taken, the air contaminants emitted, and the resulting emission rates and/or opacity.

(d) The department may also require the facility owner or operator to include, in reports described under Subdivisions (b) and (c) of this Section, an estimate of the maximum ground level concentration of each air contaminant emitted and the effect of such emissions.

(e) A violation of any applicable emission standard resulting from start-up, shutdown, or malfunction conditions at a permitted or registered facility may not be subject to an enforcement action by the department and/or penalty if the department determines, in its sole discretion, that such a violation was unavoidable. The actions and recordkeeping and reporting requirements listed above must be adhered to in such circumstances.

Condition 14: Emission Unit Definition
Effective for entire length of Permit

Applicable State Requirement: 6 NYCRR Subpart 201-5

Item 14.1:

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: 1-00001

Emission Unit Description:

This emission unit is comprised of four (4) boilers, three (3) rated at 34.7 mmBtu/hr and one (1) exempt summer boiler rated at 6.7 mmbtu/hr. These new boilers are part

Permit ID: 3-5522-00062/00005

Facility DEC ID: 3552200062

of a permit modification that was approved in 2011. The boilers (dual fuel-fired) can burn both natural gas (primary) and No. 2 fuel oil (back-up) and are located at the hospital's boiler plant, Building No. 20. The boilers utilize low NOx burner control technology. All four boilers are connected to a single stack and serve the heating and steam needs for the entire hospital complex. These boilers are going to replace the four (4) current boilers (listed as Emission Unit 1-00002). The permittee will notify the Department when these boilers are installed.

Building(s): 20

Item 14.2:

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: 1-00003

Emission Unit Description:

This emission unit is comprised of thirteen (13) diesel/No. 2 fuel oil-fired emergency generators. These generators provide power to various buildings at the hospital when necessary. The building numbers where each generator is located are: 12, 15, 20, 29, 3, 30, 36, 5, 52, 7, 4 and two are mobile generators. Each generator vents to its own stack.

Building(s): 12
15
20
29
3
30
36
4
5
52
7

Condition 15: Renewal deadlines for state facility permits
Effective for entire length of Permit

Applicable State Requirement: 6 NYCRR 201-5.2 (c)

Item 15.1:

The owner or operator of a facility having an issued state facility permit shall submit a complete application at least 180 days, but not more than eighteen months, prior to the date of permit expiration for permit renewal purposes.

Condition 16: Compliance Demonstration
Effective for entire length of Permit

Permit ID: 3-5522-00062/00005

Facility DEC ID: 3552200062

Applicable State Requirement:6 NYCRR 201-5.3 (c)

Item 16.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 16.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Any reports or submissions required by this permit shall
be submitted to the Regional Air Pollution Control
Engineer (RAPCE) at the following address:

Division of Air Resources
NYS Dept. of Environmental Conservation
Region 3
21 South Putt Corners Rd.
New Paltz, NY 12561

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 12 calendar month(s).

Condition 17: Air pollution prohibited
Effective for entire length of Permit

Applicable State Requirement:6 NYCRR 211.1

Item 17.1:

No person shall cause or allow emissions of air contaminants to the outdoor atmosphere of such quantity, characteristic or duration which are injurious to human, plant or animal life or to property, or which unreasonably interfere with the comfortable enjoyment of life or property. Notwithstanding the existence of specific air quality standards or emission limits, this prohibition applies, but is not limited to, any particulate, fume, gas, mist, odor, smoke, vapor, pollen, toxic or deleterious emission, either alone or in combination with others.

****** Emission Unit Level ******

Condition 18: Emission Point Definition By Emission Unit
Effective for entire length of Permit

Applicable State Requirement:6 NYCRR Subpart 201-5

Item 18.1:

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: 1-00001

Permit ID: 3-5522-00062/00005

Facility DEC ID: 3552200062

Emission Point: 00001
 Height (ft.): 177 Diameter (in.): 96
 NYTMN (km.): 4559. NYTME (km.): 596. Building: 20

Item 18.2:

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: 1-00003

Emission Point: A0003
 Height (ft.): 10 Diameter (in.): 4
 NYTMN (km.): 4559. NYTME (km.): 596. Building: 3

Emission Point: B0003
 Height (ft.): 11 Diameter (in.): 4
 NYTMN (km.): 4559. NYTME (km.): 596. Building: 5

Emission Point: C0003
 Height (ft.): 15 Diameter (in.): 9
 NYTMN (km.): 4559. NYTME (km.): 596. Building: 7

Emission Point: D0003
 Height (ft.): 10 Diameter (in.): 4
 NYTMN (km.): 4559. NYTME (km.): 596. Building: 4

Emission Point: E0003
 Height (ft.): 10 Diameter (in.): 4
 NYTMN (km.): 4559. NYTME (km.): 596. Building: 12

Emission Point: F0003
 Height (ft.): 22 Diameter (in.): 9
 NYTMN (km.): 4559. NYTME (km.): 596. Building: 15

Emission Point: G0003
 Height (ft.): 26 Diameter (in.): 9
 NYTMN (km.): 4559. NYTME (km.): 596. Building: 20

Emission Point: H0003
 Height (ft.): 9 Diameter (in.): 4
 NYTMN (km.): 4559. NYTME (km.): 596. Building: 29

Emission Point: I0003
 Height (ft.): 68 Diameter (in.): 6
 NYTMN (km.): 4559. NYTME (km.): 596. Building: 30

Emission Point: J0003
 Height (ft.): 10 Diameter (in.): 3
 NYTMN (km.): 4559. NYTME (km.): 596. Building: 36

Emission Point: K0003
 Height (ft.): 5 Diameter (in.): 4

Permit ID: 3-5522-00062/00005

Facility DEC ID: 3552200062

NYTMN (km.): 4559.

NYTME (km.): 596.

Building: 52

**Condition 19: Process Definition By Emission Unit
Effective for entire length of Permit**

Applicable State Requirement: 6 NYCRR Subpart 201-5

Item 19.1:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: 1-00001

Process: A01

Source Classification Code: 1-02-005-01

Process Description:

Combustion of No. 2 fuel oil by the four (4) new boilers; three rated at 34.7 mmBtu/hr and one exempt boiler rated at 6.7 mmBtu/hr. No. 2 oil is the backup fuel. The three (3) 34.7 mmBtu/hr boilers utilize low NOx burners- Webster Model HDSXC-1015C-9V-750-YB110-M. The 6.7 mmBtu/hr boiler utilizes low NOx burner - Webster Model HDSX-7. The four (4) boilers vent to a single stack located at the Boiler Plant- Building No. 20.

Emission Source/Control: A0002 - Combustion

Design Capacity: 34.7 million Btu per hour

Emission Source/Control: B0002 - Combustion

Design Capacity: 34.7 million Btu per hour

Emission Source/Control: C0002 - Combustion

Design Capacity: 34.7 million Btu per hour

Emission Source/Control: D0002 - Combustion

Design Capacity: 6.7 million Btu per hour

Item 19.2:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: 1-00001

Process: B01

Source Classification Code: 1-02-006-03

Process Description:

Combustion of natural gas by the four (4) new boilers; three rated at 34.7 mmBtu/hr and one exempt boiler rated at 6.7 mmBtu/hr. Natural gas is the primary fuel. The three (3) 34.7 mmBtu/hr boilers utilize low NOx burners- Webster Model HDSXC-1015C-9V-750-YB110-M. The 6.7 mmBtu/hr boiler utilizes low NOx burner - Webster Model HDSX-7. The four (4) boilers vent to a single stack located at the Boiler Plant- Building No. 20.

Emission Source/Control: A0002 - Combustion

Design Capacity: 34.7 million Btu per hour

Permit ID: 3-5522-00062/00005

Facility DEC ID: 3552200062

Emission Source/Control: B0002 - Combustion
Design Capacity: 34.7 million Btu per hour

Emission Source/Control: C0002 - Combustion
Design Capacity: 34.7 million Btu per hour

Emission Source/Control: D0002 - Combustion
Design Capacity: 6.7 million Btu per hour

Item 19.3:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: 1-00003

Process: A03

Source Classification Code: 2-02-001-02

Process Description:

Combustion of diesel/No. 2 fuel oil in the thirteen (13)
emergency generators.

Emission Source/Control: A0003 - Combustion
Design Capacity: 300 kilowatts

Emission Source/Control: B0003 - Combustion
Design Capacity: 450 kilowatts

Emission Source/Control: C0003 - Combustion
Design Capacity: 600 kilowatts

Emission Source/Control: D0003 - Combustion
Design Capacity: 300 kilowatts

Emission Source/Control: E0003 - Combustion
Design Capacity: 300 kilowatts

Emission Source/Control: F0003 - Combustion
Design Capacity: 440 kilowatts

Emission Source/Control: G0003 - Combustion
Design Capacity: 350 kilowatts

Emission Source/Control: H0003 - Combustion
Design Capacity: 125 kilowatts

Emission Source/Control: I0003 - Combustion
Design Capacity: 150 kilowatts

Emission Source/Control: J0003 - Combustion
Design Capacity: 80 kilowatts

Emission Source/Control: K0003 - Combustion
Design Capacity: 300 kilowatts

Emission Source/Control: L0003 - Combustion

Permit ID: 3-5522-00062/00005

Facility DEC ID: 3552200062

Design Capacity: 300 kilowatts

Emission Source/Control: M0003 - Combustion

Design Capacity: 570 kilowatts

Permit ID: 3-5522-00062/00005

Facility DEC ID: 3552200062