

Facility DEC ID: 3553400286

PERMIT
Under the Environmental Conservation Law (ECL)

IDENTIFICATION INFORMATION

Permit Type: Air State Facility
Permit ID: 3-5534-00286/00002
Mod 0 Effective Date: 01/24/2018 Expiration Date: 01/23/2028
Mod 1 Effective Date: 10/05/2021 Expiration Date: 01/23/2028
Mod 2 Effective Date: 02/19/2025 Expiration Date: 01/23/2028

Permit Issued To: BLYTHEDALE CHILDRENS HOSPITAL
95 BRADHURST AVE
VALHALLA, NY 10595

Contact: Carlo A Dattilo
Blythedale Children's Hospital
95 Bradhurst Ave
Valhalla, NY 10595

Facility: BLYTHEDALE CHILDRENS HOSPITAL
95 BRADHURST AVE
VALHALLA, NY 10595

Description:

Blythedale Children's hospital currently operates four (4) chillers and three (3) 12 mmBTU/hr boilers. This application for a permit modification involves replacement of all three boilers with three (3) new Cleaver Brooks Boilers, rated at 5.1 million BTU/hr, each). During the replacement work, the hospital will use two temporary AL Eastmont Sons INC boilers, rated at 10.5 mmBTU/hr, each, which will be removed upon installation and operation of the new boilers. The replacement will result in reduction of NOx emissions. The hospital will maintain fuel consumption records to ensure that NOx emissions, generated from the operation of all combustion sources, will remain under the allowable cap.

This application was accompanied by a CLCPA analysis to comply with EJ (section 7(2)) and DAC Section 7(3) requirements.

Facility DEC ID: 3553400286

By acceptance of this permit, the permittee agrees that the permit is contingent upon strict compliance with the ECL, all applicable regulations, the General Conditions specified and any Special Conditions included as part of this permit.

Permit Administrator: ELLEN M HART
NYSDEC - REGION 3
21 S PUTT CORNERS RD
NEW PALTZ, NY 12561

Authorized Signature: _____ Date: ___ / ___ / ___

Facility DEC ID: 3553400286

Notification of Other State Permittee Obligations

Item A: Permittee Accepts Legal Responsibility and Agrees to Indemnification

The permittee expressly agrees to indemnify and hold harmless the Department of Environmental Conservation of the State of New York, its representatives, employees and agents ("DEC") for all claims, suits, actions, and damages, to the extent attributable to the permittee's acts or omissions in connection with the compliance permittee's undertaking of activities in connection with, or operation and maintenance of, the facility or facilities authorized by the permit whether in compliance or not in any compliance with the terms and conditions of the permit. This indemnification does not extend to any claims, suits, actions, or damages to the extent attributable to DEC's own negligent or intentional acts or omissions, or to any claims, suits, or actions naming the DEC and arising under article 78 of the New York Civil Practice Laws and Rules or any citizen suit or civil rights provision under federal or state laws.

Item B: Permittee's Contractors to Comply with Permit

The permittee is responsible for informing its independent contractors, employees, agents and assigns of their responsibility to comply with this permit, including all special conditions while acting as the permittee's agent with respect to the permitted activities, and such persons shall be subject to the same sanctions for violations of the Environmental Conservation Law as those prescribed for the permittee.

Item C: Permittee Responsible for Obtaining Other Required Permits

The permittee is responsible for obtaining any other permits, approvals, lands, easements and rights-of-way that may be required to carry out the activities that are authorized by this permit.

Item D: No Right to Trespass or Interfere with Riparian Rights

This permit does not convey to the permittee any right to trespass upon the lands or interfere with the riparian rights of others in order to perform the permitted work nor does it authorize the impairment of any rights, title, or interest in real or personal property held or vested in a person not a party to the permit.

Facility DEC ID: 3553400286

PAGE LOCATION OF CONDITIONS

PAGE

DEC GENERAL CONDITIONS

General Provisions

- 5 1 Facility Inspection by the Department
- 5 2 Relationship of this Permit to Other Department Orders and Determinations
- 5 3 Applications for permit renewals, modifications and transfers
- 6 4 Permit modifications, suspensions or revocations by the Department

Facility Level

- 6 5 Submission of application for permit modification or renewal
-REGION 3 HEADQUARTERS

Facility DEC ID: 3553400286

DEC GENERAL CONDITIONS
****** General Provisions ******
GENERAL CONDITIONS - Apply to ALL Authorized Permits.

Condition 1: Facility Inspection by the Department
Applicable State Requirement: ECL 19-0305

Item 1.1:

The permitted site or facility, including relevant records, is subject to inspection at reasonable hours and intervals by an authorized representative of the Department of Environmental Conservation (the Department) to determine whether the permittee is complying with this permit and the ECL. Such representative may order the work suspended pursuant to ECL 71-0301 and SAPA 401(3).

Item 1.2:

The permittee shall provide a person to accompany the Department's representative during an inspection to the permit area when requested by the Department.

Item 1.3:

A copy of this permit, including all referenced maps, drawings and special conditions, must be available for inspection by the Department at all times at the project site or facility. Failure to produce a copy of the permit upon request by a Department representative is a violation of this permit.

Condition 2: Relationship of this Permit to Other Department Orders and Determinations
Applicable State Requirement: ECL 3-0301 (2) (m)

Item 2.1:

Unless expressly provided for by the Department, issuance of this permit does not modify, supersede or rescind any order or determination previously issued by the Department or any of the terms, conditions or requirements contained in such order or determination.

Condition 3: Applications for permit renewals, modifications and transfers
Applicable State Requirement: 6 NYCRR 621.11

Item 3.1:

The permittee must submit a separate written application to the Department for renewal, modification or transfer of this permit. Such application must include any forms or supplemental information the Department requires. Any renewal, modification or transfer granted by the Department must be in writing.

Item 3.2:

The permittee must submit a renewal application at least 180 days before the expiration of permits for Title V and State Facility Permits.

Item 3.3

Permits are transferrable with the approval of the department unless specifically prohibited by the statute, regulation or another permit condition. Applications for permit transfer should be submitted prior to actual transfer of ownership.

Facility DEC ID: 3553400286

Condition 5: Permit modifications, suspensions or revocations by the Department
Applicable State Requirement: 6 NYCRR 621.13

Item 5.1:

The Department reserves the right to exercise all available authority to modify, suspend, or revoke this permit in accordance with 6NYCRR Part 621. The grounds for modification, suspension or revocation include:

- a) materially false or inaccurate statements in the permit application or supporting papers;
- b) failure by the permittee to comply with any terms or conditions of the permit;
- c) exceeding the scope of the project as described in the permit application;
- d) newly discovered material information or a material change in environmental conditions, relevant technology or applicable law or regulations since the issuance of the existing permit;
- e) noncompliance with previously issued permit conditions, orders of the commissioner, any provisions of the Environmental Conservation Law or regulations of the Department related to the permitted activity.

****** Facility Level ******

Condition 2-1: Submission of application for permit modification or renewal
-REGION 3

HEADQUARTERS

Applicable State Requirement: 6 NYCRR 621.6 (a)

Item 2-1.1:

Submission of applications for permit modification or renewal are to be submitted to:

NYSDEC Regional Permit Administrator
Region 3 Headquarters
Division of Environmental Permits
21 South Putt Corners Road
New Paltz, NY 12561-1696
(845) 256-3054

Permit ID: 3-5534-00286/00002

Facility DEC ID: 3553400286

Permit Under the Environmental Conservation Law (ECL)

ARTICLE 19: AIR POLLUTION CONTROL - AIR STATE FACILITY PERMIT

IDENTIFICATION INFORMATION

Permit Issued To: BLYTHEDALE CHILDRENS HOSPITAL
95 BRADHURST AVE
VALHALLA, NY 10595

Facility: BLYTHEDALE CHILDRENS HOSPITAL
95 BRADHURST AVE
VALHALLA, NY 10595

Authorized Activity By Standard Industrial Classification Code:
8062 - GENERAL MEDICAL & SURGICAL HOSPITALS

Mod 0 Permit Effective Date: 01/24/2018

Permit Expiration Date: 01/23/2028

Mod 1 Permit Effective Date: 10/05/2021

Permit Expiration Date: 01/23/2028

Mod 2 Permit Effective Date: 02/19/2025

Permit Expiration Date: 01/23/2028

PAGE LOCATION OF CONDITIONS

PAGE

FEDERALLY ENFORCEABLE CONDITIONS

Facility Level

- 6 2-1 6 NYCRR 201-3.2 (a): Exempt Sources - Proof of Eligibility
- 6 2-2 6 NYCRR 201-3.2 (a): Compliance Demonstration
- 7 2-3 6 NYCRR 200.1 (cq): Definition for Emergency Generators
- 7 2-4 6 NYCRR 201-3.2 (b): Exempt Activities - Operation and Maintenance
- 7 1 6 NYCRR 201-7.1: Facility Permissible Emissions
- 7 *2 6 NYCRR 201-7.1: Capping Monitoring Condition
- 9 20 6 NYCRR 211.2: Visible Emissions Limited
- 9 2-5 6 NYCRR 211.2: Compliance Demonstration
- 11 2-6 6 NYCRR 225-1.2 (d): Compliance Demonstration
- 11 2-7 6 NYCRR 227-1.3 (c): Compliance Demonstration
- 12 2-8 6 NYCRR 227-1.4 (a): Compliance Demonstration
- 13 2-9 40CFR 60, NSPS Subpart A: Applicability of Subpart A General Provisions
- 13 7 40CFR 60, NSPS Subpart JJJJ: Applicability
- 13 2-10 40CFR 63, Subpart A: General Provisions
- 13 10 40CFR 63, Subpart JJJJJ: Compliance and Enforcement
- 14 11 40CFR 63, Subpart ZZZZ: Applicability

Emission Unit Level

- 14 1-3 6 NYCRR 201-7.1: Emission Unit Permissible Emissions

EU=U-00001

- 14 13 40CFR 60.4, NSPS Subpart A: EPA Region 2 address.

EU=U-00004,EP=00006

- 15 1-5 40CFR 60.4230(a)(4)(i), NSPS Subpart JJJJ:
Applicability of facilities subject to Subpart JJJJ

STATE ONLY ENFORCEABLE CONDITIONS

Facility Level

- 17 15 ECL 19-0301: Contaminant List
- 17 2-11 6 NYCRR 201-1.4: Malfunctions and Start-up/Shutdown Activities
- 18 17 6 NYCRR Subpart 201-5: Emission Unit Definition
- 19 18 6 NYCRR 201-5.2 (c): Renewal deadlines for state facility permits
- 19 2-12 6 NYCRR 201-5.3 (c): Compliance Demonstration
- 20 3 6 NYCRR 211.1: Air pollution prohibited

Emission Unit Level

- 20 21 6 NYCRR Subpart 201-5: Emission Point Definition By Emission Unit
- 21 22 6 NYCRR Subpart 201-5: Process Definition By Emission Unit

NOTE: * preceding the condition number indicates capping.

Permit ID: 3-5534-00286/00002

Facility DEC ID: 3553400286

FEDERALLY ENFORCEABLE CONDITIONS

Mod 2/FINAL

**** Facility Level ****

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

This section contains terms and conditions which are federally enforceable. Permittees may also have other obligations under regulations of general applicability

Item A: Sealing - 6 NYCRR 200.5

The Commissioner may seal an air contamination source to prevent its operation if compliance with 6 NYCRR Chapter III is not met within the time provided by an order of the Commissioner issued in the case of the violation. Sealing means labeling or tagging a source to notify any person that operation of the source is prohibited, and also includes physical means of preventing the operation of an air contamination source without resulting in destruction of any equipment associated with such source, and includes, but is not limited to, bolting, chaining or wiring shut control panels, apertures or conduits associated with such source.

No person shall operate any air contamination source sealed by the Commissioner in accordance with this section unless a modification has been made which enables such source to comply with all requirements applicable to such modification.

Unless authorized by the Commissioner, no person shall remove or alter any seal affixed to any contamination source in accordance with this section.

Item B: Acceptable Ambient Air Quality - 6 NYCRR 200.6

Notwithstanding the provisions of 6 NYCRR Chapter III, Subchapter A, no person shall allow or permit any air contamination source to emit air contaminants in quantities which alone or in combination with emissions from other air contamination sources would contravene any applicable ambient air quality standard and/or cause air pollution. In such cases where contravention occurs or may occur, the Commissioner shall specify the degree and/or method of emission control required.

Item C: Maintenance of Equipment - 6 NYCRR 200.7

Any person who owns or operates an air contamination source which is equipped with an emission control device shall operate such device and keep it in a satisfactory state of maintenance and repair in accordance with ordinary and necessary practices, standards and procedures, inclusive of manufacturer's specifications,

Permit ID: 3-5534-00286/00002

Facility DEC ID: 3553400286

required to operate such device effectively.

Item D: Unpermitted Emission Sources - 6 NYCRR 201-1.2

(a) Except as otherwise provided by this Part, construction or operation of a new, modified or existing air contamination source without a registration or permit issued pursuant to this Part is prohibited.

(b) If an existing facility or emission source was subject to the permitting requirements of this Part at the time of construction or modification, and the owner or operator failed to apply for a permit or registration as described in this Part, the owner or operator must apply for a permit or registration in accordance with the provisions of this Part. The facility or emission source is subject to all regulations that were applicable to it at the time of construction or modification and any subsequent requirements applicable to existing emission sources.

Item E: Recycling and Salvage - 6 NYCRR 201-1.7

Where practical, any person who owns or operates an air contamination source shall recycle or salvage air contaminants collected in an air cleaning device according to the requirements of 6 NYCRR.

Item F: Prohibition of Reintroduction of Collected Contaminants to the Air - 6 NYCRR 201-1.8

No person shall unnecessarily remove, handle, or cause to be handled, collected air contaminants from an air cleaning device for recycling, salvage or disposal in a manner that would reintroduce them to the outdoor atmosphere.

Item G: Proof of Eligibility for Sources Defined as Exempt Activities - 6 NYCRR 201-3.2 (a)

The owner and/or operator of an emission source or unit that is eligible to be exempt, may be required to certify that it operates within the specific criteria described in 6 NYCRR Subpart 201-3. The owner or operator of any such emission source must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request.

Department representatives must be granted access to any facility which contains emission sources or units subject to 6 NYCRR Subpart 201-3, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

Item H: Proof of Eligibility for Sources Defined as Trivial

Permit ID: 3-5534-00286/00002

Facility DEC ID: 3553400286

Activities - 6 NYCRR 201-3.3 (a)

The owner and/or operator of an emission source or unit that is listed as being trivial in 6 NYCRR Part 201 may be required to certify that it operates within the specific criteria described in 6 NYCRR Subpart 201-3. The owner or operator of any such emission source must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility which contains emission sources or units subject to 6 NYCRR Subpart 201-3, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

Item I: Required Emission Tests - 6 NYCRR 202-1.1

An acceptable report of measured emissions shall be submitted, as may be required by the Commissioner, to ascertain compliance or noncompliance with any air pollution code, rule, or regulation. Failure to submit a report acceptable to the Commissioner within the time stated shall be sufficient reason for the Commissioner to suspend or deny an operating permit. Notification and acceptable procedures are specified in 6 NYCRR Subpart 202-1.

Item J: Open Fires Prohibitions - 6 NYCRR 215.2

Except as allowed by section 215.3 of 6 NYCRR Part 215, no person shall burn, cause, suffer, allow or permit the burning of any materials in an open fire.

Item K: Permit Exclusion - ECL 19-0305

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York (NYCRR). The issuance of this permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.

Item L: Federally Enforceable Requirements - 40 CFR 70.6 (b)

Permit ID: 3-5534-00286/00002

Facility DEC ID: 3553400286

All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

FEDERAL APPLICABLE REQUIREMENTS
The following conditions are federally enforceable.

Condition 2-1: Exempt Sources - Proof of Eligibility
Effective between the dates of 02/19/2025 and 01/23/2028

Applicable Federal Requirement:6 NYCRR 201-3.2 (a)

Item 2-1.1:

The owner or operator of an emission source or activity that is listed as being exempt may be required to certify that it is operated within the specific criteria described in this Subpart. The owner or operator of any such emission source or activity must maintain all records necessary for demonstrating compliance with this Subpart on-site for a period of five years, and make them available to representatives of the department upon request.

Condition 2-2: Compliance Demonstration
Effective between the dates of 02/19/2025 and 01/23/2028

Applicable Federal Requirement:6 NYCRR 201-3.2 (a)

Item 2-2.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 2-2.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS

Monitoring Description:

As proof of exempt eligibility for the emergency generators, the facility must maintain monthly records which demonstrate that each engine is operated less than 500 hours per year, on a 12-month rolling total basis.

Work Practice Type: HOURS PER YEAR OPERATION

Upper Permit Limit: 500.0 hours

Monitoring Frequency: MONTHLY

Averaging Method: ANNUAL MAXIMUM ROLLED MONTHLY

Reporting Requirements: UPON REQUEST BY REGULATORY AGENCY

Permit ID: 3-5534-00286/00002

Facility DEC ID: 3553400286

Condition 2-3: Definition for Emergency Generators
Effective between the dates of 02/19/2025 and 01/23/2028

Applicable Federal Requirement:6 NYCRR 200.1 (cq)

Item 2-3.1: Emergency power generating stationary internal combustion engine is defined as a stationary internal combustion engine that operates as a mechanical or electrical power source only when the usual supply of power is unavailable, and operates for no more than 500 hours per year. The 500 hours of annual operation for the engine includes operation during the emergency situations, routine maintenance and routine exercising (for example, test firing the engine for one hour a week to ensure reliability). A stationary internal combustion engine used for peak shaving generation is not an emergency power generating stationary internal combustion engine.

Condition 2-4: Exempt Activities - Operation and Maintenance
Effective between the dates of 02/19/2025 and 01/23/2028

Applicable Federal Requirement:6 NYCRR 201-3.2 (b)

Item 2-4.1:

The owner or operator of any emission source or activity that is listed as being exempt in 6 NYCRR Subdivision 201-3.2(b) shall operate and maintain the emission source and any associated emissions controls in a manner consistent with manufacturer’s specifications and good engineering practices. Failure to do so constitutes a violation of 6 NYCRR Part 201.

Condition 1: Facility Permissible Emissions
Effective between the dates of 01/24/2018 and 01/23/2028

Applicable Federal Requirement:6 NYCRR 201-7.1

Item 1.1:

The sum of emissions from the emission units specified in this permit shall not equal or exceed the following

Potential To Emit (PTE) rate for each regulated contaminant:

per year	CAS No: 0NY210-00-0 (From Mod 2)	PTE: 49,800 pounds
	Name: OXIDES OF NITROGEN	

Condition 2: Capping Monitoring Condition
Effective between the dates of 01/24/2018 and 01/23/2028

Applicable Federal Requirement:6 NYCRR 201-7.1

Item 2.1:

Under the authority of 6 NYCRR Part 201-7, this condition contains an emission cap for the

Permit ID: 3-5534-00286/00002

Facility DEC ID: 3553400286

purpose of limiting emissions from the facility, emission unit or process to avoid being subject to the following applicable requirement(s) that the facility, emission unit or process would otherwise be subject to:

6 NYCRR Subpart 201-6
6 NYCRR Subpart 227-2

Item 2.2:

Operation of this facility shall take place in accordance with the approved criteria, emission limits, terms, conditions and standards in this permit.

Item 2.3:

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

Item 2.4:

On an annual basis, unless otherwise specified below, beginning one year after the granting of an emissions cap, the responsible official shall provide a certification to the Department that the facility has operated all emission units within the limits imposed by the emission cap. This certification shall include a brief summary of the emissions subject to the cap for that time period and a comparison to the threshold levels that would require compliance with an applicable requirement.

Item 2.5:

The emission of pollutants that exceed the applicability thresholds for an applicable requirement, for which the facility has obtained an emissions cap, constitutes a violation of Part 201 and of the Act.

Item 2.6:

The Compliance Demonstration activity will be performed for the Facility.

Regulated Contaminant(s):
CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 2.7:

Compliance Demonstration shall include the following monitoring:

Capping: Yes

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

The owner or operator of the facility, must monitor on a monthly basis the amount of fuel fired at the facility. Using the following equation, the facility will determine compliance with the 24.9 tons per year NOx cap:

$$(BG \times 100 \text{ lb/million cf}) + (BO \times 20 \text{ lb/1000 gal}) + (C \times 0.8470 \text{ lb/MMBtu}) + (EG \times 3.2 \text{ lb/MMBtu}) \leq 49,800 \text{ lbs/yr NOx}$$

Permit ID: 3-5534-00286/00002

Facility DEC ID: 3553400286

Where:

BG = Amount of natural gas fired in the boilers in million
cf

BO = Amount of distillate oil fired in the boilers in 1000
gal

C = Amount of natural gas fired in the chillers MMBtu

EG = Amount of distillate oil fired in the emergency
generator MMBtu

These records must be kept on site for a period of no less
than 5 years.

Work Practice Type: PROCESS MATERIAL THRUPUT

Process Material: FUEL

Upper Permit Limit: 24.9 tons per year

Monitoring Frequency: MONTHLY

Averaging Method: 12 MONTH AVERAGE - ROLLED MONTHLY

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2018.

Subsequent reports are due every 12 calendar month(s).

Condition 20: Visible Emissions Limited
Effective between the dates of 01/24/2018 and 01/23/2028

Applicable Federal Requirement:6 NYCRR 211.2

Item 20.1:

Except as permitted by a specific part of this Subchapter and for open fires for which a restricted burning permit has been issued, no person shall cause or allow any air contamination source to emit any material having an opacity equal to or greater than 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent opacity.

Condition 2-5: Compliance Demonstration
Effective between the dates of 02/19/2025 and 01/23/2028

Applicable Federal Requirement:6 NYCRR 211.2

Item 2-5.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 2-5.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

Except as permitted by a specific part of Title 6 of the
NYCRR, no person shall cause or allow any air

Permit ID: 3-5534-00286/00002

Facility DEC ID: 3553400286

contamination source to emit any material having an opacity equal to or greater than 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent opacity.

Operators of air contamination sources that are not exempt from permitting and where a continuous opacity monitor is not utilized for measuring smoke emissions, shall be required to perform the following:

- 1) Observe the stack(s) or vent(s) once per day for visible emissions. This observation(s) must be conducted during daylight hours except during adverse weather conditions (fog, rain, or snow).
- 2) The results of each observation must be recorded in a bound logbook or other format acceptable to the Department. The following data must be recorded for each stack:
 - weather condition
 - was a plume observed?

This logbook must be retained at the facility for five (5) years after the date of the last entry.

3) If the operator observes any visible emissions (other than steam - see below) two consecutive days, then a Method 9 analysis (based upon a 6-minute mean) of the affected emission point(s) must be conducted within two (2) business days of such occurrence. The results of the Method 9 analysis must be recorded in the logbook. The operator must contact the Regional Air Pollution Control Engineer within one (1) business day of performing the Method 9 analysis if the opacity standard is contravened. Upon notification, any corrective actions or future compliance schedules shall be presented to the Department for acceptance.

**** NOTE **** Steam plumes generally form after leaving the top of the stack (this is known as a detached plume). The distance between the stack and the beginning of the detached plume may vary, however, there is (normally) a distinctive distance between the plume and stack. Steam plumes are white in color and have a billowy consistency. Steam plumes dissipate within a short distance of the stack (the colder the air the longer the steam plume will last) and leave no dispersion trail downwind of the stack.

Parameter Monitored: OPACITY
Upper Permit Limit: 20 percent

Permit ID: 3-5534-00286/00002

Facility DEC ID: 3553400286

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING
DESCRIPTION

Averaging Method: 6 MINUTE AVERAGE

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2026.

Subsequent reports are due every 12 calendar month(s).

Condition 2-6: Compliance Demonstration
Effective between the dates of 02/19/2025 and 01/23/2028

Applicable Federal Requirement:6 NYCRR 225-1.2 (d)

Replaces Condition(s) 1-1

Item 2-6.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 2-6.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC
OPERATIONS

Monitoring Description:

Owners or operators of emission sources that fire distillate oil are limited to a 0.0015 percent sulfur content by weight of the fuel. Compliance with the sulfur-in-fuel limitation is based on fuel vendor receipts. All fuel vendor receipts must be maintained on site or at a Department approved alternative location for a minimum of five years.

Note - Process sources and incinerators must comply with the above requirements on or after July 1, 2023.

Work Practice Type: PARAMETER OF PROCESS MATERIAL

Process Material: DISTILLATES - NUMBER 1 AND NUMBER 2 OIL

Parameter Monitored: SULFUR CONTENT

Upper Permit Limit: 0.0015 percent by weight

Monitoring Frequency: PER DELIVERY

Averaging Method: MAXIMUM - NOT TO BE EXCEEDED AT ANY
TIME (INSTANTANEOUS/DISCRETE OR GRAB)

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2026.

Subsequent reports are due every 12 calendar month(s).

Condition 2-7: Compliance Demonstration
Effective between the dates of 02/19/2025 and 01/23/2028

Applicable Federal Requirement:6 NYCRR 227-1.3 (c)

Item 2-7.1:

Permit ID: 3-5534-00286/00002

Facility DEC ID: 3553400286

The Compliance Demonstration activity will be performed for the Facility.

Item 2-7.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The owner or operator of a stationary combustion installation must perform an annual tune-up on each emission source subject to 6 NYCRR Subpart 227-1. Records of the tune-up shall be maintained at the facility or at a Department approved alternative location for a minimum of five years. The records shall, at a minimum, include the date the tune-up(s) occurred and the details of the tune-up procedures for each emission source.

Monitoring Frequency: ANNUALLY

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2026.

Subsequent reports are due every 12 calendar month(s).

Condition 2-8: Compliance Demonstration
Effective between the dates of 02/19/2025 and 01/23/2028

Applicable Federal Requirement:6 NYCRR 227-1.4 (a)

Item 2-8.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 2-8.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

No owner or operator of a stationary combustion installation subject to this Subpart shall operate an emission source which exhibits greater than 20 percent opacity (based on a six minute average), except for one 6 minute period per hour of not more than 27 percent opacity. The owner or operator will conduct a Method 9 test annually. A report of the results of the test will be submitted to the Department within 30 days of the completion of the Method 9 test. All records generated by the permittee must be maintained at the facility or at an alternative location approved by the Department for a minimum of five years.

Parameter Monitored: OPACITY

Upper Permit Limit: 20 percent

Reference Test Method: 40 CFR 60, Appendix A, Method 9

Permit ID: 3-5534-00286/00002

Facility DEC ID: 3553400286

Monitoring Frequency: ANNUALLY
 Averaging Method: 6-MINUTE AVERAGE (METHOD 9)
 Reporting Requirements: ANNUALLY (CALENDAR)
 Reports due 30 days after the reporting period.
 The initial report is due 1/30/2026.
 Subsequent reports are due every 12 calendar month(s).

Condition 2-9: Applicability of Subpart A General Provisions
Effective between the dates of 02/19/2025 and 01/23/2028

Applicable Federal Requirement:40CFR 60, NSPS Subpart A

Item 2-9.1:

This emission source is subject to the applicable general provisions of 40 CFR 60. The facility owner is responsible for complying with all applicable technical, administrative and reporting requirements.

Condition 7: Applicability
Effective between the dates of 01/24/2018 and 01/23/2028

Applicable Federal Requirement:40CFR 60, NSPS Subpart JJJJ

Item 7.1:

Facilities that have stationary spark ignition internal combustion engines must comply with applicable portions of 40 CFR 60 subpart JJJJ.

Condition 2-10: General Provisions
Effective between the dates of 02/19/2025 and 01/23/2028

Applicable Federal Requirement:40CFR 63, Subpart A

Item 2-10.1:

This emission source is subject to the applicable provisions of 40 CFR 63 Subpart A. The facility owner is responsible for complying with all applicable technical, administrative and reporting requirements.

Condition 10: Compliance and Enforcement
Effective between the dates of 01/24/2018 and 01/23/2028

Applicable Federal Requirement:40CFR 63, Subpart JJJJJJ

Item 10.1:

The Department has not accepted delegation of 40 CFR Part 63 Subpart JJJJJJ, National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers Area Sources. Any questions concerning compliance and/or enforcement of this regulation should be referred to USEPA Region 2, 290 Broadway, 21st Floor, New York, NY 10007-1866; (212) 637-4080. Should the Department decide to accept delegation of 40 CFR Part 63 Subpart JJJJJJ during the term of this permit, enforcement of this regulation will revert to the Department as of the effective date of delegation.

Permit ID: 3-5534-00286/00002

Facility DEC ID: 3553400286

Condition 11: Applicability
Effective between the dates of 01/24/2018 and 01/23/2028

Applicable Federal Requirement:40CFR 63, Subpart ZZZZ

Item 11.1:

Facilities that have reciprocating internal combustion engines must comply with applicable portions of 40 CFR 63 subpart ZZZZ.

****** Emission Unit Level ******

Condition 1-3: Emission Unit Permissible Emissions
Effective between the dates of 10/05/2021 and 01/23/2028

Applicable Federal Requirement:6 NYCRR 201-7.1

Item 1-3.1:

The sum of emissions from all regulated processes specified in this permit for the emission unit cited shall not exceed the following Potential to Emit (PTE) rates for each regulated contaminant:

Emission Unit: U-00004

CAS No: 0NY210000 (From Mod 1)

Name: OXIDES OF NITROGEN

PTE(s): 6,841.73 pounds per year

0.781 pounds per hour

Condition 13: EPA Region 2 address.
Effective between the dates of 01/24/2018 and 01/23/2028

Applicable Federal Requirement:40CFR 60.4, NSPS Subpart A

Item 13.1:

This Condition applies to Emission Unit: U-00001

Item 13.2:

All requests, reports, applications, submittals, and other communications to the Administrator pursuant to this part shall be submitted in duplicate to the following address:

Director, Division of Enforcement and Compliance Assistance
USEPA Region 2

Permit ID: 3-5534-00286/00002

Facility DEC ID: 3553400286

290 Broadway, 21st Floor
New York, NY 10007-1886

Copies of all correspondence to the administrator pursuant to this part shall also be submitted to the NYSDEC Regional Office issuing this permit (see address at the beginning of this permit) and to the following address:

NYSDEC
Bureau of Quality Assurance
625 Broadway
Albany, NY 12233-3258

**Condition 1-5: Applicability of facilities subject to Subpart JJJJ
Effective between the dates of 10/05/2021 and 01/23/2028**

Applicable Federal Requirement: 40CFR 60.4230(a)(4)(i), NSPS Subpart JJJJ

Item 1-5.1:

This Condition applies to Emission Unit: U-00004 Emission Point: 00006

Item 1-5.2: The provisions of 40 CFR 60 Subpart JJJJ are applicable to manufacturers, owners, and operators of stationary spark ignition (SI) internal combustion engines (ICE) that commence construction after June 12, 2006, and where the stationary SI ICE are manufactured on or after July 1, 2007, for engines with a maximum engine power greater than or equal to 500 HP (except lean burn engines with a maximum engine power greater than or equal to 500 HP and less than 1,350 HP). For the purposes of this subpart, the date that construction commences is the date the engine is ordered by the owner or operator.

Permit ID: 3-5534-00286/00002

Facility DEC ID: 3553400286

STATE ONLY ENFORCEABLE CONDITIONS****** Facility Level ********NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS**

This section contains terms and conditions which are not federally enforceable. Permittees may also have other obligations under regulations of general applicability

Item A: Emergency Defense - 6 NYCRR 201-1.5

An emergency, as defined in 6 NYCRR subpart 201-2, constitutes an affirmative defense to penalties sought in an enforcement action brought by the department for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

(a) The affirmative defense of emergency shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:

(1) an emergency occurred and that the facility owner or operator can identify the cause(s) of the emergency;

(2) the equipment at the facility was being properly operated and maintained;

(3) during the period of the emergency the facility owner or operator took all reasonable steps to minimize the levels of emissions that exceeded the emission standards, or other requirements in the permit; and

(4) the facility owner or operator notified the department within two working days after the event occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and any corrective actions taken.

(b) In any enforcement proceeding, the facility owner or operator seeking to establish the occurrence of an emergency has the burden of proof.

(c) This provision is in addition to any emergency or malfunction provision contained in any applicable requirement.

Item B: Public Access to Recordkeeping for Facilities With State Facility Permits - 6 NYCRR 201-1.10 (a)

Where facility owners and/or operators keep records pursuant to compliance with the requirements of 6 NYCRR Subpart 201-5.4, and/or the emission capping requirements of 6 NYCRR Subpart 201-7, the Department will make such records available to the public upon request in accordance

Permit ID: 3-5534-00286/00002

Facility DEC ID: 3553400286

with 6 NYCRR Part 616 - Public Access to Records.
Facility owners and/or operators must submit the records required to comply with the request within sixty working days of written notification by the Department.

Item C: **General Provisions for State Enforceable Permit Terms and Condition - 6 NYCRR Part 201-5**

Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all criteria, emission limits, terms, conditions, and standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

STATE ONLY APPLICABLE REQUIREMENTS

The following conditions are state only enforceable.

Condition 15: Contaminant List

Effective between the dates of 01/24/2018 and 01/23/2028

Applicable State Requirement:ECL 19-0301

Item 15.1:

Emissions of the following contaminants are subject to contaminant specific requirements in this permit(emission limits, control requirements or compliance monitoring conditions).

CAS No: 0NY210-00-0

Name: OXIDES OF NITROGEN

Condition 2-11: Malfunctions and Start-up/Shutdown Activities

Effective between the dates of 02/19/2025 and 01/23/2028

Applicable State Requirement:6 NYCRR 201-1.4

Replaces Condition(s) 1-6, 16

Permit ID: 3-5534-00286/00002

Facility DEC ID: 3553400286

Item 2-11.1:

(a) The facility owner or operator shall take all necessary and appropriate actions to prevent the emission of air pollutants that result in contravention of any applicable emission standard during periods of start-up, shutdown, or malfunction.

(b) The facility owner or operator shall compile and maintain records of all equipment maintenance and start-up/shutdown activities when they are expected to result in an exceedance of any applicable emission standard, and shall submit a report of such activities to the department when required by a permit condition or upon request by the department. Such reports shall state whether an exceedance occurred and if it was unavoidable, include the time, frequency and duration of the exceedance, and an estimate of the emission rates of any air contaminants released. Such records shall be maintained for a period of at least five years and made available for review to department representatives upon request. Facility owners or operators subject to continuous monitoring and quarterly reporting requirements need not submit additional reports of exceedances to the department.

(c) In the event that air contaminant emissions exceed any applicable emission standard due to a malfunction, the facility owner or operator shall notify the department as soon as possible during normal working hours, but not later than two working days after becoming aware that the malfunction occurred. In addition, the facility owner or operator shall compile and maintain a record of all malfunctions. Such records shall be maintained at the facility for a period of at least five years and must be made available to the department upon request. When requested by the department, the facility owner or operator shall submit a written report to the department describing the malfunction, the corrective action taken, the air contaminants emitted, and the resulting emission rates and/or opacity.

(d) The department may also require the facility owner or operator to include, in reports described under Subdivisions (b) and (c) of this Section, an estimate of the maximum ground level concentration of each air contaminant emitted and the effect of such emissions.

(e) A violation of any applicable emission standard resulting from start-up, shutdown, or malfunction conditions at a permitted or registered facility may not be subject to an enforcement action by the department and/or penalty if the department determines, in its sole discretion, that such a violation was unavoidable. The actions and recordkeeping and reporting requirements listed above must be adhered to in such circumstances.

Condition 17: Emission Unit Definition**Effective between the dates of 01/24/2018 and 01/23/2028****Applicable State Requirement: 6 NYCRR Subpart 201-5****Item 17.1(From Mod 2):**

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: U-00001

Emission Unit Description:

This unit consists of three (3) boilers each rated at 5.1 mBTU/hr. The boilers are capable of firing either natural

Permit ID: 3-5534-00286/00002

Facility DEC ID: 3553400286

gas or No.2 oil. Each boiler vents through its own dedicated stack.
 These boilers are replacing the three (3) 12 mmBTU/hr (each) boilers which were removed. The old boilers were venting through a common stack which was also removed.

Building(s): North Bldg

Item 17.2(From Mod 1):

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: U-00004

Emission Unit Description:

This unit replaces unit U-00002 and all its sources. This unit comprises three new identical Tecochill CH-200X (~600 HP) gas fired chillers and one Tecochill CH-300X (~820 HP) gas fired chiller. The vents of each one of the four sources manifold inside the building and exhaust via a common stack. The chillers are internal combustion engines equipped with catalytic converters which offer 0.15 gm/hp-hr emissions of NOx as guaranteed by the manufacturer.

Building(s): North Bldg

Condition 18: Renewal deadlines for state facility permits
Effective between the dates of 01/24/2018 and 01/23/2028

Applicable State Requirement: 6 NYCRR 201-5.2 (c)

Item 18.1:

The owner or operator of a facility having an issued state facility permit shall submit a complete application at least 180 days, but not more than eighteen months, prior to the date of permit expiration for permit renewal purposes.

Condition 2-12: Compliance Demonstration
Effective between the dates of 02/19/2025 and 01/23/2028

Applicable State Requirement: 6 NYCRR 201-5.3 (c)

Replaces Condition(s) 19

Item 2-12.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 2-12.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Any reports or submissions required by this permit shall

Permit ID: 3-5534-00286/00002

Facility DEC ID: 3553400286

be submitted to the Regional Air Pollution Control Engineer (RAPCE) at the following address:

Division of Air Resources
NYS Dept. of Environmental Conservation
Region 3
21 South Putt Corners Rd.
New Paltz, NY 12561

Reporting Requirements: ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 1/30/2026.
Subsequent reports are due every 12 calendar month(s).

Condition 3: Air pollution prohibited
Effective between the dates of 01/24/2018 and 01/23/2028

Applicable State Requirement:6 NYCRR 211.1

Item 3.1:

No person shall cause or allow emissions of air contaminants to the outdoor atmosphere of such quantity, characteristic or duration which are injurious to human, plant or animal life or to property, or which unreasonably interfere with the comfortable enjoyment of life or property. Notwithstanding the existence of specific air quality standards or emission limits, this prohibition applies, but is not limited to, any particulate, fume, gas, mist, odor, smoke, vapor, pollen, toxic or deleterious emission, either alone or in combination with others.

****** Emission Unit Level ******

Condition 21: Emission Point Definition By Emission Unit
Effective between the dates of 01/24/2018 and 01/23/2028

Applicable State Requirement:6 NYCRR Subpart 201-5

Item 21.1(From Mod 2):

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: U-00001

Emission Point: 0001A

Height (ft.): 26 Diameter (in.): 20
NYTMN (km.): 4547.7 NYTME (km.): 600.3 Building: North Bldg

Emission Point: 0002A

Height (ft.): 26 Diameter (in.): 20
NYTMN (km.): 4547.7 NYTME (km.): 600.3 Building: North Bldg

Emission Point: 0003A

Permit ID: 3-5534-00286/00002

Facility DEC ID: 3553400286

Height (ft.): 20 Diameter (in.): 18
 NYTMN (km.): 4547.7 NYTME (km.): 600.3 Building: North Bldg

Item 21.2(From Mod 1):

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: U-00004

Emission Point: 00006
 Height (ft.): 25 Diameter (in.): 12
 NYTMN (km.): 4547.7 NYTME (km.): 600.3 Building: North Bldg

**Condition 22: Process Definition By Emission Unit
 Effective between the dates of 01/24/2018 and 01/23/2028**

Applicable State Requirement:6 NYCRR Subpart 201-5

Item 22.1(From Mod 2):

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-00001
 Process: BNG Source Classification Code: 1-02-006-02

Emission Source/Control: S001A - Combustion
 Design Capacity: 5.1 million Btu per hour

Emission Source/Control: S002A - Combustion
 Design Capacity: 5.1 million Btu per hour

Emission Source/Control: S003A - Combustion
 Design Capacity: 5.1 million Btu per hour

Item 22.2(From Mod 2):

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-00001
 Process: OIL Source Classification Code: 1-03-005-02

Emission Source/Control: S001A - Combustion
 Design Capacity: 5.1 million Btu per hour

Emission Source/Control: S002A - Combustion
 Design Capacity: 5.1 million Btu per hour

Emission Source/Control: S003A - Combustion
 Design Capacity: 5.1 million Btu per hour

Item 22.3(From Mod 1):

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-00004
 Process: NG1 Source Classification Code: 2-01-002-02

Permit ID: 3-5534-00286/00002

Facility DEC ID: 3553400286

Process Description:

Four chillers firing natural gas and exhausting via a common stack.

The chillers operate for 12 hours per day, 150 days per year. The quantity of natural gas expected to be burned by the chillers under these operating conditions is 32,774,510 cubic feet per year or 6,555 cf/hr.

Emission Source/Control: S0008 - Combustion
Design Capacity: 1.53 million Btu per hour

Emission Source/Control: S0009 - Combustion
Design Capacity: 1.53 million Btu per hour

Emission Source/Control: S0010 - Combustion
Design Capacity: 1.53 million Btu per hour

Emission Source/Control: S0011 - Combustion
Design Capacity: 2.09 million Btu per hour

Emission Source/Control: C0008 - Control
Control Type: CATALYTIC REDUCTION

Emission Source/Control: C0009 - Control
Control Type: CATALYTIC REDUCTION

Emission Source/Control: C0010 - Control
Control Type: CATALYTIC REDUCTION

Emission Source/Control: C0011 - Control
Control Type: CATALYTIC REDUCTION

Permit ID: 3-5534-00286/00002

Facility DEC ID: 3553400286