

PERMIT Under the Environmental Conservation Law (ECL)

IDENTIFICATION INFORMATION

Permit Type: Air Title V Facility Permit ID: 4-0101-00122/00009

Effective Date: 08/24/2017 Expiration Date: 08/23/2022

Permit Issued To:NYS OFFICE OF GENERAL SERVICES

MAYOR ERASTUS CORNING TOWER FL 34

EMPIRE STATE PLZ ALBANY, NY 12242

Contact: Edward Burkhart

NYS OGS Sheridan Steam Plant

79 Sheridan Ave Albany, NY 12210 (518) 408-1314

Facility: NYS OGS SHERIDAN STEAM PLANT

79 SHERIDAN AVE ALBANY, NY 12210

Description:

The New York State Office of General Services Empire State Plaza heating needs are met by the operation of six 106 million Btu/hr boilers. All of the boilers burn natural gas and are capable of using No.2 fuel oil as a back-up. Other sources of emissions include two diesel and one No.2 exempt emergency generators. The existing 125.6 MM Btu/hr boiler is being removed from the Title V permit.

By acceptance of this permit, the permittee agrees that the permit is contingent upon strict compliance with the ECL, all applicable regulations, the General Conditions specified and any Special Conditions included as part of this permit.

Permit Administrator:	ANGELO A MARCUCCIO

NYSDEC - REGION 4 1130 N WESTCOTT RD

SCHENECTADY, NY 12306-2014

Authorized Signature:	Date:	′ /	/



Notification of Other State Permittee Obligations

Item A: Permittee Accepts Legal Responsibility and Agrees to Indemnification

The permittee expressly agrees to indemnify and hold harmless the Department of Environmental Conservation of the State of New York, its representatives, employees and agents ("DEC") for all claims, suits, actions, and damages, to the extent attributable to the permittee's acts or omissions in connection with the compliance permittee's undertaking of activities in connection with, or operation and maintenance of, the facility or facilities authorized by the permit whether in compliance or not in any compliance with the terms and conditions of the permit. This indemnification does not extend to any claims, suits, actions, or damages to the extent attributable to DEC's own negligent or intentional acts or omissions, or to any claims, suits, or actions naming the DEC and arising under article 78 of the New York Civil Practice Laws and Rules or any citizen suit or civil rights provision under federal or state laws.

Item B: Permittee's Contractors to Comply with Permit

The permittee is responsible for informing its independent contractors, employees, agents and assigns of their responsibility to comply with this permit, including all special conditions while acting as the permittee's agent with respect to the permitted activities, and such persons shall be subject to the same sanctions for violations of the Environmental Conservation Law as those prescribed for the permittee.

Item C: Permittee Responsible for Obtaining Other Required Permits

The permittee is responsible for obtaining any other permits, approvals, lands, easements and rights-of-way that may be required to carry out the activities that are authorized by this permit.

Item D: No Right to Trespass or Interfere with Riparian Rights

This permit does not convey to the permittee any right to trespass upon the lands or interfere with the riparian rights of others in order to perform the permitted work nor does it authorize the impairment of any rights, title, or interest in real or personal property held or vested in a person not a party to the permit.



LIST OF CONDITIONS

DEC GENERAL CONDITIONS

General Provisions

Facility Inspection by the Department Relationship of this Permit to Other Department Orders and Determinations

Applications for permit renewals, modifications and transfers
Permit modifications, suspensions or revocations by the Department
Facility Level

Submission of application for permit modification or renewal-REGION 4 HEADQUARTERS



DEC GENERAL CONDITIONS

**** General Provisions ****

For the purpose of your Title V permit, the following section contains state-only enforceable terms and conditions.

GENERAL CONDITIONS - Apply to ALL Authorized Permits.

Condition 1: Facility Inspection by the Department
Applicable State Requirement: ECL 19-0305

Item 1.1:

The permitted site or facility, including relevant records, is subject to inspection at reasonable hours and intervals by an authorized representative of the Department of Environmental Conservation (the Department) to determine whether the permittee is complying with this permit and the ECL. Such representative may order the work suspended pursuant to ECL 71-0301 and SAPA 401(3).

Item 1.2:

The permittee shall provide a person to accompany the Department's representative during an inspection to the permit area when requested by the Department.

Item 1.3:

A copy of this permit, including all referenced maps, drawings and special conditions, must be available for inspection by the Department at all times at the project site or facility. Failure to produce a copy of the permit upon request by a Department representative is a violation of this permit.

Condition 2: Relationship of this Permit to Other Department Orders and Determinations Applicable State Requirement: ECL 3-0301 (2) (m)

Item 2.1:

Unless expressly provided for by the Department, issuance of this permit does not modify, supersede or rescind any order or determination previously issued by the Department or any of the terms, conditions or requirements contained in such order or determination.

Condition 3: Applications for permit renewals, modifications and transfers Applicable State Requirement: 6 NYCRR 621.11

Item 3.1:

The permittee must submit a separate written application to the Department for renewal, modification or transfer of this permit. Such application must include any forms or supplemental information the Department requires. Any renewal, modification or transfer granted by the Department must be in writing.

Item3.2:

The permittee must submit a renewal application at least 180 days before the expiration of permits for Title V and State Facility Permits.

Item 3.3

Permits are transferrable with the approval of the department unless specifically prohibited by

the statute, regulation or another permit condition. Applications for permit transfer should be submitted prior to actual transfer of ownership.

Condition 4: Permit modifications, suspensions or revocations by the Department Applicable State Requirement: 6 NYCRR 621.13

Item 4.1:

The Department reserves the right to exercise all available authority to modify, suspend, or revoke this permit in accordance with 6NYCRR Part 621. The grounds for modification, suspension or revocation include:

- a) materially false or inaccurate statements in the permit application or supporting papers;
- b) failure by the permittee to comply with any terms or conditions of the permit;
- c) exceeding the scope of the project as described in the permit application;
- d) newly discovered material information or a material change in environmental conditions, relevant technology or applicable law or regulations since the issuance of the existing permit;
- e) noncompliance with previously issued permit conditions, orders of the commissioner, any provisions of the Environmental Conservation Law or regulations of the Department related to the permitted activity.

**** Facility Level ****

Condition 5: Submission of application for permit modification or renewal-REGION 4
HEADQUARTERS
Applicable State Requirement: 6 NYCRR 621.6 (a)

Item 5.1:

Submission of applications for permit modification or renewal are to be submitted to:

NYSDEC Regional Permit Administrator Region 4 Headquarters Division of Environmental Permits 1130 North Westcott Rd. Schenectady, NY 12306-2014 (518) 357-2069



Permit ID: 4-0101-00122/00009 Facility DEC ID: 4010100122

Permit Under the Environmental Conservation Law (ECL)

ARTICLE 19: AIR POLLUTION CONTROL - TITLE V PERMIT

IDENTIFICATION INFORMATION

Permit Issued To:NYS OFFICE OF GENERAL SERVICES

MAYOR ERASTUS CORNING TOWER FL 34

EMPIRE STATE PLZ ALBANY, NY 12242

Facility: NYS OGS SHERIDAN STEAM PLANT

79 SHERIDAN AVE ALBANY, NY 12210

Authorized Activity By Standard Industrial Classification Code:

4961 - STEAM SUPPLY

Permit Effective Date: 08/24/2017 Permit Expiration Date: 08/23/2022



Permit ID: 4-0101-00122/00009 Facility DEC ID: 4010100122

LIST OF CONDITIONS

FEDERALLY ENFORCEABLE CONDITIONS Facility Level

- 1 6 NYCRR 200.6: Acceptable Ambient Air Quality
- 2 6 NYCRR 201-6.4 (a) (7): Fees
- 3 6 NYCRR 201-6.4 (c): Recordkeeping and Reporting of Compliance Monitoring
- 4 6 NYCRR 201-6.4 (c) (2): Records of Monitoring, Sampling, and Measurement
- 5 6 NYCRR 201-6.4 (c) (3) (ii): Compliance Certification
- 6 6 NYCRR 201-6.4 (e): Compliance Certification
- 7 6 NYCRR 202-2.1: Compliance Certification
- 8 6 NYCRR 202-2.5: Recordkeeping requirements
- 9 6 NYCRR 215.2: Open Fires Prohibitions
- 10 6 NYCRR 200.7: Maintenance of Equipment
- 11 6 NYCRR 201-1.7: Recycling and Salvage
- 12 6 NYCRR 201-1.8: Prohibition of Reintroduction of Collected Contaminants to the air
- 13 6 NYCRR 201-3.2 (a): Exempt Sources Proof of Eligibility
- 14 6 NYCRR 201-3.3 (a): Trivial Sources Proof of Eligibility
- 15 6 NYCRR 201-6.4 (a) (4): Requirement to Provide Information
- 16 6 NYCRR 201-6.4 (a) (8): Right to Inspect
- 17 6 NYCRR 201-6.4 (f) (6): Off Permit Changes
- 18 6 NYCRR 202-1.1: Required Emissions Tests
- 19 40 CFR Part 68: Accidental release provisions.
- 20 40CFR 82, Subpart F: Recycling and Emissions Reduction
- 21 6 NYCRR Subpart 201-6: Emission Unit Definition
- 22 6 NYCRR 201-6.4 (d) (4): Progress Reports Due Semiannually
- 23 6 NYCRR 202-1.2: Notification
- 24 6 NYCRR 202-1.3: Acceptable procedures Stack test report submittal
- 25 6 NYCRR 211.1: Air pollution prohibited
- 26 6 NYCRR 225-1.2 (h): Compliance Certification
- 27 6 NYCRR 225-1.5 (c): Compliance Certification
- 28 6 NYCRR 227-1.2 (a) (1): Compliance Certification
- 29 6 NYCRR 227-1.2 (b): Multiple combustion sources
- 30 6 NYCRR 227-1.3 (a): Compliance Certification
- 31 6 NYCRR 227-1.4 (b): Compliance Certification
- 32 6 NYCRR 227-1.4 (c): Stack Monitoring
- 33 40CFR 63, Subpart JJJJJJ: Compliance Certification
- 34 40CFR 63, Subpart ZZZZ: Compliance Certification

Emission Unit Level

- 35 6 NYCRR Subpart 201-6: Emission Point Definition By Emission Unit
- 36 6 NYCRR Subpart 201-6: Process Definition By Emission Unit

EU=0-0MAIN

- 37 6 NYCRR 227-1.7: General Provisions
- 38 6 NYCRR 227-2.4 (b) (1) (ii): Compliance Certification

STATE ONLY ENFORCEABLE CONDITIONS



Facility Level

39 ECL 19-0301: Contaminant List

40 6 NYCRR 201-1.4: Malfunctions and start-up/shutdown activities

41 6 NYCRR 227-1.4 (a): Compliance Demonstration



Permit ID: 4-0101-00122/00009 Facility DEC ID: 4010100122

FEDERALLY ENFORCEABLE CONDITIONS **** Facility Level ****

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

The items listed below are not subject to the annual compliance certification requirements under Title V. Permittees may also have other obligations under regulations of general applicability.

Item A: Public Access to Recordkeeping for Title V Facilities - 6 NYCRR 201-1.10 (b)

The Department will make available to the public any permit application, compliance plan, permit, and monitoring and compliance certification report pursuant to Section 503(e) of the Act, except for information entitled to confidential treatment pursuant to 6 NYCRR Part 616 - Public Access to records and Section 114(c) of the Act.

Item B: Timely Application for the Renewal of Title V Permits - 6 NYCRR 201-6.2 (a) (4)

Owners and/or operators of facilities having an issued Title V permit shall submit a complete application at least 180 days, but not more than eighteen months, prior to the date of permit expiration for permit renewal purposes.

Item C: Certification by a Responsible Official - 6 NYCRR 201-6.2 (d) (12)

Any application, form, report or compliance certification required to be submitted pursuant to the federally enforceable portions of this permit shall contain a certification of truth, accuracy and completeness by a responsible official. This certification shall state that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

Item D: Requirement to Comply With All Conditions - 6 NYCRR 201-6.4 (a) (2)

The permittee must comply with all conditions of the Title V facility permit. Any permit non-compliance constitutes a violation of the Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

Item E: Permit Revocation, Modification, Reopening, Reissuance or Termination, and Associated Information Submission Requirements - 6 NYCRR 201-6.4 (a) (3)

This permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and

Air Pollution Control Permit Conditions Renewal 3 Page 4 FINAL



Permit ID: 4-0101-00122/00009 Facility DEC ID: 4010100122

reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.

Item F: Cessation or Reduction of Permitted Activity Not a Defense - 6 NYCRR 201-6.4 (a) (5)

It shall not be a defense for a permittee in an enforcement action to claim that a cessation or reduction in the permitted activity would have been necessary in order to maintain compliance with the conditions of this permit.

Item G: Property Rights - 6 NYCRR 201-6.4 (a) (6)

This permit does not convey any property rights of any sort or any exclusive privilege.

Item H: Severability - 6 NYCRR 201-6.4 (a) (9)

If any provisions, parts or conditions of this permit are found to be invalid or are the subject of a challenge, the remainder of this permit shall continue to be valid.

Item I: Permit Shield - 6 NYCRR 201-6.4 (g)

All permittees granted a Title V facility permit shall be covered under the protection of a permit shield, except as provided under 6 NYCRR Subpart 201-6. Compliance with the conditions of the permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that such applicable requirements are included and are specifically identified in the permit, or the Department, in acting on the permit application or revision, determines in writing that other requirements specifically identified are not applicable to the major stationary source, and the permit includes the determination or a concise summary thereof. Nothing herein shall preclude the Department from revising or revoking the permit pursuant to 6 NYCRR Part 621 or from exercising its summary abatement authority. Nothing in this permit shall alter or affect the following:

- i. The ability of the Department to seek to bring suit on behalf of the State of New York, or the Administrator to seek to bring suit on behalf of the United States, to immediately restrain any person causing or contributing to pollution presenting an imminent and substantial endangerment to public health, welfare or the environment to stop the emission of air pollutants causing or contributing to such pollution;
- ii. The liability of a permittee of the Title V



facility for any violation of applicable requirements prior to or at the time of permit issuance;

- iii. The applicable requirements of Title IV of the Act;
- iv. The ability of the Department or the Administrator to obtain information from the permittee concerning the ability to enter, inspect and monitor the facility.

Item J: Reopening for Cause - 6 NYCRR 201-6.4 (i)

This Title V permit shall be reopened and revised under any of the following circumstances:

- i. When additional applicable requirements under the act become applicable to a title V facility with a remaining permit term of three or more years, a reopening shall be completed not later than 18 months after promulgation of the applicable requirement. No such reopening is required if the effective date of therequirement is later than the date on which the permit is due to expire, unless the original permit or any ofits terms and conditions has been extended by the department pursuant to the provisions of section 201- 6.6 of this Subpart.
- ii. The Department or the Administrator determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.
- iii. The Department or the Administrator determines that the Title V permit must be revised or reopened to assure compliance with applicable requirements.
- iv. If the permitted facility is an "affected source" subject to the requirements of Title IV of the Act, and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.

Proceedings to reopen and issue Title V facility permits shall follow the same procedures as apply to initial permit issuance but shall affect only those parts of the permit for which cause to reopen exists.

Reopenings shall not be initiated before a notice of such intent is provided to the facility by the Department at least thirty days in advance of the date that the permit



Permit ID: 4-0101-00122/00009 Facility DEC ID: 4010100122

is to be reopened, except that the Department may provide a shorter time period in the case of an emergency.

Item K: Permit Exclusion - ECL 19-0305

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York (NYCRR). The issuance of this permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.

Item L: Federally Enforceable Requirements - 40 CFR 70.6 (b)

All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

MANDATORY FEDERALLY ENFORCEABLE PERMIT CONDITIONS SUBJECT TO ANNUAL CERTIFICATIONS AT ALL TIMES

The following federally enforceable permit conditions are mandatory for all Title V permits and are subject to annual compliance certification requirements at all times.

Condition 1: Acceptable Ambient Air Quality

Effective between the dates of 08/24/2017 and 08/23/2022

Applicable Federal Requirement: 6 NYCRR 200.6

Item 1.1:

Notwithstanding the provisions of 6 NYCRR Chapter III, Subchapter A, no person shall allow or permit any air contamination source to emit air contaminants in quantities which alone or in combination with emissions from other air contamination sources would contravene any applicable ambient air quality standard and/or cause air pollution. In such cases where



Permit ID: 4-0101-00122/00009 Facility DEC ID: 4010100122

contravention occurs or may occur, the Commissioner shall specify the degree and/or method of emission control required.

Condition 2: Fees

Effective between the dates of 08/24/2017 and 08/23/2022

Applicable Federal Requirement: 6 NYCRR 201-6.4 (a) (7)

Item 2.1:

The owner and/or operator of a stationary source shall pay fees to the Department consistent with the fee schedule authorized by ECL 72-0303.

Condition 3: Recordkeeping and Reporting of Compliance Monitoring

Effective between the dates of 08/24/2017 and 08/23/2022

Applicable Federal Requirement: 6 NYCRR 201-6.4 (c)

Item 3.1:

The following information must be included in any required compliance monitoring records and reports:

- (i) The date, place, and time of sampling or measurements;
- (ii) The date(s) analyses were performed;
- (iii)The company or entity that performed the analyses;
- (iv) The analytical techniques or methods used including quality assurance and quality control procedures if required;
- (v) The results of such analyses including quality assurance data where required; and
- (vi) The operating conditions as existing at the time of sampling or measurement.

Any deviation from permit requirements must be clearly identified in all records and reports. Reports must be certified by a responsible official, consistent with Section 201-6.2 of Part 201.

Condition 4: Records of Monitoring, Sampling, and Measurement

Effective between the dates of 08/24/2017 and 08/23/2022

Applicable Federal Requirement:6 NYCRR 201-6.4 (c) (2)

Item 4.1:

Compliance monitoring and recordkeeping shall be conducted according to the terms and conditions contained in this permit and shall follow all quality assurance requirements found in applicable regulations. Records of all monitoring data and support information must be retained for a period of at least 5 years from the date of the monitoring, sampling, measurement, report, or application. Support information includes all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all



Permit ID: 4-0101-00122/00009 Facility DEC ID: 4010100122

reports required by the permit.

Condition 5: Compliance Certification

Effective between the dates of 08/24/2017 and 08/23/2022

Applicable Federal Requirement:6 NYCRR 201-6.4 (c) (3) (ii)

Item 5.1:

The Compliance Certification activity will be performed for the Facility.

Item 5.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES Monitoring Description:

> To meet the requirements of this facility permit with respect to reporting, the permittee must:

Submit reports of any required monitoring at a minimum frequency of every 6 months, based on a calendar year reporting schedule. These reports shall be submitted to the Department within 30 days after the end of a reporting period. All instances of deviations from permit requirements must be clearly identified in such reports. All required reports must be certified by the responsible official for this facility.

Notify the Department and report permit deviations and incidences of noncompliance stating the probable cause of such deviations, and any corrective actions or preventive measures taken. Where the underlying applicable requirement contains a definition of prompt or otherwise specifies a time frame for reporting deviations, that definition or time frame shall govern. Where the underlying applicable requirement fails to address the time frame for reporting deviations, reports of deviations shall be submitted to the permitting authority based on the following schedule:

- (1) For emissions of a hazardous air pollutant (as identified in an applicable regulation) that continue for more than an hour in excess of permit requirements, the report must be made within 24 hours of the occurrence.
- (2) For emissions of any regulated air pollutant, excluding those listed in paragraph (1) of this section, that continue for more than two hours in excess of permit requirements, the report must be made within 48 hours.
- (3) For all other deviations from permit requirements,



the report shall be contained in the 6 month monitoring report required above.

(4) This permit may contain a more stringent reporting requirement than required by paragraphs (1), (2) or (3) above. If more stringent reporting requirements have been placed in this permit or exist in applicable requirements that apply to this facility, the more stringent reporting requirement shall apply.

If above paragraphs (1) or (2) are met, the source must notify the permitting authority by telephone during normal business hours at the Regional Office of jurisdiction for this permit, attention Regional Air Pollution Control Engineer (RAPCE) according to the timetable listed in paragraphs (1) and (2) of this section. For deviations and incidences that must be reported outside of normal business hours, on weekends, or holidays, the DEC Spill Hotline phone number at 1-800-457-7362 shall be used. A written notice, certified by a responsible official consistent with 6 NYCRR Part 201-6.2(d)(12), must be submitted within 10 working days of an occurrence for deviations reported under (1) and (2). All deviations reported under paragraphs (1) and (2) of this section must also be identified in the 6 month monitoring report required above.

The provisions of 6 NYCRR 201-1.4 shall apply if the permittee seeks to have a violation excused unless otherwise limited by regulation. In order to have a violation of a federal regulation (such as a new source performance standard or national emissions standard for hazardous air pollutants) excused, the specific federal regulation must provide for an affirmative defense during start-up, shutdowns, malfunctions or upsets.

Notwithstanding any recordkeeping and reporting requirements in 6 NYCRR 201-1.4, reports of any deviations shall not be on a less frequent basis than the reporting periods described in paragraphs (1) and (4) above.

In the case of any condition contained in this permit with a reporting requirement of "Upon request by regulatory agency" the permittee shall include in the semiannual report, a statement for each such condition that the monitoring or recordkeeping was performed as required or requested and a listing of all instances of deviations from these requirements.

In the case of any emission testing performed during the previous six month reporting period, either due to a request by the Department, EPA, or a regulatory requirement, the permittee shall include in the semiannual



report a summary of the testing results and shall indicate whether or not the Department or EPA has approved the results.

All semiannual reports may be submitted electronically or physically. Electronic reports shall be submitted using the Department's Air Compliance and Emissions Electronic-Reporting system (ACE). If the facility owner or operator elects to send physical copies instead, two copies shall be sent to the Department (one copy to the regional air pollution control engineer (RAPCE) in the regional office and one copy to the Bureau of Quality Assurance (BQA) in the DEC central office) and one copy shall be sent to the Administrator (or his or her representative). Mailing addresses for the above referenced persons are contained in the monitoring condition for 6 NYCRR Part 201-6.4(e), contained elsewhere in this permit.

Reporting Requirements: SEMI-ANNUALLY (CALENDAR) Reports due 30 days after the reporting period. The initial report is due 1/30/2018. Subsequent reports are due every 6 calendar month(s).

Condition 6: Compliance Certification

Effective between the dates of 08/24/2017 and 08/23/2022

Applicable Federal Requirement: 6 NYCRR 201-6.4 (e)

Item 6.1:

The Compliance Certification activity will be performed for the Facility.

Item 6.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES Monitoring Description:

Requirements for compliance certifications with terms and conditions contained in this facility permit include the following:

- i. Compliance certifications shall contain:
- the identification of each term or condition of the permit that is the basis of the certification;
- the compliance status;
- whether compliance was continuous or intermittent;
- the method(s) used for determining the compliance status of the facility, currently and over the reporting period consistent with the monitoring and related recordkeeping and reporting requirements of this permit;
- such other facts as the Department may require to determine the compliance status of the facility as



specified in any special permit terms or conditions; and

- such additional requirements as may be specified elsewhere in this permit related to compliance certification.
- ii. The responsible official must include in the annual certification report all terms and conditions contained in this permit which are identified as being subject to certification, including emission limitations, standards, or work practices. That is, the provisions labeled herein as "Compliance Certification" are not the only provisions of this permit for which an annual certification is required.
- iii. Compliance certifications shall be submitted annually. Certification reports are due 30 days after the anniversary date of four consecutive calendar quarters. The first report is due 30 days after the calendar quarter that occurs just prior to the permit anniversary date, unless another quarter has been acceptable by the Department.
- iv. All annual compliance certifications may be submitted electronically or physically. Electronic reports shall be submitted using the Department's Air Compliance and Emissions Electronic-Reporting system (ACE). If the facility owner or operator elects to send physical copies instead, two copies shall be sent to the Department (one copy to the regional air pollution control engineer (RAPCE) in the regional office and one copy to the Bureau of Quality Assurance (BQA) in the DEC central office) and one copy shall be sent to the Administrator (or his or her representative). The mailing addresses for the above referenced persons are:

Chief – Stationary Source Compliance Section USEPA Region 2 Air Compliance Branch 290 Broadway New York, NY 10007-1866

The address for the RAPCE is as follows:

Regional Air Pollution Control Engineer NYSDEC Region 4 Headquarters 1130 North Westcott Road Schenectady, NY 12306-2014

The address for the BQA is as follows:

NYSDEC



Permit ID: 4-0101-00122/00009 Facility DEC ID: 4010100122

> Bureau of Quality Assurance 625 Broadway Albany, NY 12233-3258

Monitoring Frequency: ANNUALLY

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2018.

Subsequent reports are due on the same day each year

Condition 7: Compliance Certification

Effective between the dates of 08/24/2017 and 08/23/2022

Applicable Federal Requirement:6 NYCRR 202-2.1

Item 7.1:

The Compliance Certification activity will be performed for the Facility.

Item 7.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Emission statements shall be submitted on or before April 15th each year for emissions of the previous calendar year. Statements are to be mailed to: New York State Department of Environmental Conservation, Division of Air Resources, Bureau of Air Quality Planning, 625 Broadway, Albany NY 12233-3251

Monitoring Frequency: ANNUALLY

Reporting Requirements: ANNUALLY (CALENDAR) Reports due by April 15th for previous calendar year

Condition 8: Recordkeeping requirements

Effective between the dates of 08/24/2017 and 08/23/2022

Applicable Federal Requirement: 6 NYCRR 202-2.5

Item 8.1:

- (a) The following records shall be maintained for at least five years:
 - (1) a copy of each emission statement submitted to the department; and
- records indicating how the information submitted in the emission statement was determined, including any calculations, data, measurements, and estimates used.
- These records shall be made available at the facility to the representatives of the department upon request during normal business hours.

Condition 9: Open Fires - Prohibitions

Effective between the dates of 08/24/2017 and 08/23/2022



Applicable Federal Requirement: 6 NYCRR 215.2

Item 9.1:

Except as allowed by Title 6 NYCRR Section 215.3, no person shall burn, cause, suffer, allow or permit the burning of any materials in an open fire.

Item 9.2

Per Section 215.3, burning in an open fire, provided it is not contrary to other law or regulation, will be allowed as follows:

- (a) On-site burning in any town with a total population less than 20,000 of downed limbs and branches (including branches with attached leaves or needles) less than six inches in diameter and eight feet in length between May 15th and the following March 15th. For the purposes of this subdivision, the total population of a town shall include the population of any village or portion thereof located within the town. However, this subdivision shall not be construed to allow burning within any village.
- (b) Barbecue grills, maple sugar arches and similar outdoor cooking devices when actually used for cooking or processing food.
- (c) Small fires used for cooking and camp fires provided that only charcoal or untreated wood is used as fuel and the fire is not left unattended until extinguished.
- (d) On-site burning of agricultural wastes as part of a valid agricultural operation on contiguous agricultural lands larger than five acres actively devoted to agricultural or horticultural use, provided such waste is actually grown or generated on those lands and such waste is capable of being fully burned within a 24-hour period.
- (e) The use of liquid petroleum fueled smudge pots to prevent frost damage to crops.
- (f) Ceremonial or celebratory bonfires where not otherwise prohibited by law, provided that only untreated wood or other agricultural products are used as fuel and the fire is not left unattended until extinguished.
- (g) Small fires that are used to dispose of a flag or religious item, and small fires or other smoke producing process where not otherwise prohibited by law that are used in connection with a religious ceremony.
- (h) Burning on an emergency basis of explosive or other dangerous or contraband materials by police or other public safety organization.
- (i) Prescribed burns performed according to Part 194 of this Title.
- (j) Fire training, including firefighting, fire rescue, and fire/arson investigation training, performed under applicable rules and guidelines of the New York State Department of State's Office of Fire Prevention and Control. For fire training performed on acquired structures, the structures must be emptied and stripped of any material that is toxic, hazardous or likely to emit toxic smoke (such as asbestos, asphalt shingles and vinyl siding or other vinyl products) prior to burning and must be at least 300 feet from other occupied structures. No more than one structure per lot or within a 300 foot radius (whichever is bigger) may be burned in a training exercise.
- (k) Individual open fires as approved by the Director of the Division of Air Resources as may be required in response to an outbreak of a plant or animal disease upon request by the commissioner of the Department of Agriculture and Markets, or for the destruction of invasive plant and insect species.
- (1) Individual open fires that are otherwise authorized under the environmental conservation law, or by rule or regulation of the Department.

MANDATORY FEDERALLY ENFORCEABLE PERMIT CONDITIONS



Permit ID: 4-0101-00122/00009 Facility DEC ID: 4010100122

SUBJECT TO ANNUAL CERTIFICATIONS ONLY IF APPLICABLE

The following federally enforceable permit conditions are mandatory for all Title V permits and are subject to annual compliance certification requirements only if effectuated during the reporting period.

[NOTE: The corresponding annual compliance certification for those conditions not effectuated during the reporting period shall be specified as "not applicable".]

Condition 10: Maintenance of Equipment

Effective between the dates of 08/24/2017 and 08/23/2022

Applicable Federal Requirement: 6 NYCRR 200.7

Item 10.1:

Any person who owns or operates an air contamination source which is equipped with an emission control device shall operate such device and keep it in a satisfactory state of maintenance and repair in accordance with ordinary and necessary practices, standards and procedures, inclusive of manufacturer's specifications, required to operate such device effectively.

Condition 11: Recycling and Salvage

Effective between the dates of 08/24/2017 and 08/23/2022

Applicable Federal Requirement: 6 NYCRR 201-1.7

Item 11.1:

Where practical, the owner or operator of an air contamination source shall recycle or salvage air contaminants collected in an air cleaning device according to the requirements of the ECL.

Condition 12: Prohibition of Reintroduction of Collected Contaminants to the air

Effective between the dates of 08/24/2017 and 08/23/2022

Applicable Federal Requirement: 6 NYCRR 201-1.8

Item 12.1:

No person shall unnecessarily remove, handle or cause to be handled, collected air contaminants from an air cleaning device for recycling, salvage or disposal in a manner that would reintroduce them to the outdoor atmosphere.

Condition 13: Exempt Sources - Proof of Eligibility

Effective between the dates of 08/24/2017 and 08/23/2022

Applicable Federal Requirement: 6 NYCRR 201-3.2 (a)

Item 13.1:

The owner or operator of an emission source or activity that is listed as being exempt may be required to certify that it is operated within the specific criteria described in this Subpart. The owner or operator of any such emission source or activity must maintain all records necessary for demonstrating compliance with this Subpart on-site for a period of five years, and make them available to representatives of the department upon request.



Permit ID: 4-0101-00122/00009 Facility DEC ID: 4010100122

Condition 14: Trivial Sources - Proof of Eligibility

Effective between the dates of 08/24/2017 and 08/23/2022

Applicable Federal Requirement: 6 NYCRR 201-3.3 (a)

Item 14.1:

The owner or operator of an emission source or activity that is listed as being trivial in this Section may be required to certify that it is operated within the specific criteria described in this Subpart. The owner or operator of any such emission source or activity must maintain all required records on-site for a period of five years and make them available to representatives of the department upon request.

Condition 15: Requirement to Provide Information

Effective between the dates of 08/24/2017 and 08/23/2022

Applicable Federal Requirement: 6 NYCRR 201-6.4 (a) (4)

Item 15.1:

The owner and/or operator shall furnish to the department, within a reasonable time, any information that the department may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the department copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to the administrator along with a claim of confidentiality, if the administrator initiated the request for information or otherwise has need of it.

Condition 16: Right to Inspect

Effective between the dates of 08/24/2017 and 08/23/2022

Applicable Federal Requirement: 6 NYCRR 201-6.4 (a) (8)

Item 16.1:

The department or an authorized representative shall be allowed upon presentation of credentials and other documents as may be required by law to:

- (i) enter upon the permittee's premises where a facility subject to the permitting requirements of this Subpart is located or emissions-related activity is conducted, or where records must be kept under the conditions of the permit;
- (ii) have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;
- (iii) inspect at reasonable times any emission sources, equipment (including monitoring and air pollution control equipment), practices, and operations regulated or required under the permit; and
- (iv) sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the permit or applicable requirements.



Permit ID: 4-0101-00122/00009 Facility DEC ID: 4010100122

Condition 17: Off Permit Changes

Effective between the dates of 08/24/2017 and 08/23/2022

Applicable Federal Requirement:6 NYCRR 201-6.4 (f) (6)

Item 17.1:

No permit revision will be required for operating changes that contravene an express permit term, provided that such changes would not violate applicable requirements as defined under this Part or contravene federally enforceable monitoring (including test methods), recordkeeping, reporting, or compliance certification permit terms and conditions. Such changes may be made without requiring a permit revision, if the changes are not modifications under any provision of title I of the act and the changes do not exceed the emissions allowable under the permit (whether expressed therein as a rate of emissions or in terms of total emissions) provided that the facility provides the administrator and the department with written notification as required below in advance of the proposed changes within a minimum of seven days. The facility owner or operator, and the department shall attach each such notice to their copy of the relevant permit.

- (i) For each such change, the written notification required above shall include a brief description of the change within the permitted facility, the date on which the change will occur, any change in emissions, and any permit term or condition that is no longer applicable as a result of the change.
- (ii) The permit shield described in section 6 NYCRR 201-6.4 shall not apply to any change made pursuant to this paragraph.

Condition 18: Required Emissions Tests

Effective between the dates of 08/24/2017 and 08/23/2022

Applicable Federal Requirement:6 NYCRR 202-1.1

Item 18.1:

For the purpose of ascertaining compliance or non-compliance with any air pollution control code, rule or regulation, the commissioner may require the person who owns such air contamination source to submit an acceptable report of measured emissions within a stated time.

Condition 19: Accidental release provisions.

Effective between the dates of 08/24/2017 and 08/23/2022

Applicable Federal Requirement: 40 CFR Part 68

Item 19.1:

If a chemical is listed in Tables 1,2,3 or 4 of 40 CFR §68.130 is present in a process in quantities greater than the threshold quantity listed in Tables 1,2,3 or 4, the following requirements will apply:

a) The owner or operator shall comply with the provisions of 40 CFR Part 68 and;



b) The owner or operator shall submit at the time of permit issuance (if not previously submitted) one of the following, if such quantities are present:

- 1) A compliance schedule for meeting the requirements of 40 CFR Part 68 by the date provided in 40 CFR §68.10(a) or,
- 2) A certification statement that the source is in compliance with all requirements of 40 CFR Part 68, including the registration and submission of the Risk Management Plan. Information should be submitted to:

Risk Management Plan Reporting Center C/O CSC 8400 Corporate Dr Carrollton, Md. 20785

Condition 20: Recycling and Emissions Reduction

Effective between the dates of 08/24/2017 and 08/23/2022

Applicable Federal Requirement: 40CFR 82, Subpart F

Item 20.1:

The permittee shall comply with all applicable provisions of 40 CFR Part 82.

The following conditions are subject to annual compliance certification requirements for Title V permits only.

Condition 21: Emission Unit Definition

Effective between the dates of 08/24/2017 and 08/23/2022

Applicable Federal Requirement: 6 NYCRR Subpart 201-6

Item 21.1:

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: 0-0MAIN Emission Unit Description:

Six 106 mmbtu/hr boilers capable of firing natural gas or No. 2 fuel oil. All boilers have been retrofitted with low-NOx burners. Boilers 1-3 vent to a common stack. Boilers 4-6 vent to a common stack.

Building(s): EAST

Condition 22: Progress Reports Due Semiannually

Effective between the dates of 08/24/2017 and 08/23/2022

Applicable Federal Requirement: 6 NYCRR 201-6.4 (d) (4)



Permit ID: 4-0101-00122/00009 Facility DEC ID: 4010100122

Item 22.1:

Progress reports consistent with an applicable schedule of compliance are to be submitted at least semiannually, or at a more frequent period if specified in the applicable requirement or by the department. Such progress reports shall contain the following:

- (i) dates for achieving the activities, milestones, or compliance required in the schedule of compliance, and dates when such activities, milestones or compliance were achieved; and
- (ii) an explanation of why any dates in the schedule of compliance were not or will not be met, and any preventive or corrective measures adopted.

Condition 23: Notification

Effective between the dates of 08/24/2017 and 08/23/2022

Applicable Federal Requirement: 6 NYCRR 202-1.2

Item 23.1:

A person who is required by the commissioner to submit a stack test report shall notify the commissioner, in writing, not less than 30 days prior to the test, of the time and date of the test. Such notification shall also include the acceptable procedures to be used to stack test including sampling and analytical procedures. Such person shall allow the commissioner, or his representative, free access to observe stack testing being conducted by such person.

Condition 24: Acceptable procedures - Stack test report submittal

Effective between the dates of 08/24/2017 and 08/23/2022

Applicable Federal Requirement: 6 NYCRR 202-1.3

Item 24.1:

Emission test reports must be submitted in triplicate to the commissioner within 60 days after the completion of the tests, unless additional time is requested in writing.

Condition 25: Air pollution prohibited

Effective between the dates of 08/24/2017 and 08/23/2022

Applicable Federal Requirement: 6 NYCRR 211.1

Item 25.1:

No person shall cause or allow emissions of air contaminants to the outdoor atmosphere of such quantity, characteristic or duration which are injurious to human, plant or animal life or to property, or which unreasonably interfere with the comfortable enjoyment of life or property. Notwithstanding the existence of specific air quality standards or emission limits, this prohibition applies, but is not limited to, any particulate, fume, gas, mist, odor, smoke, vapor, pollen, toxic or deleterious emission, either alone or in combination with others.

Condition 26: Compliance Certification

Effective between the dates of 08/24/2017 and 08/23/2022

Applicable Federal Requirement: 6 NYCRR 225-1.2 (h)



Permit ID: 4-0101-00122/00009 Facility DEC ID: 4010100122

Item 26.1:

The Compliance Certification activity will be performed for the facility: The Compliance Certification applies to:

Emission Unit: 0-0MAIN

Process: OIL

Item 26.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS

Monitoring Description:

Owners and/or operators of a stationary combustion installations that fire distillate oil are limited to the firing of distillate oil with 0.0015 percent sulfur by weight or less on or after July 1, 2016. Compliance with this limit will be based on vendor certifications.

Data collected pursuant to this Subpart must be tabulated and summarized in a form acceptable to the Department, and must be retained for at least five years. The owner of a Title V facility must furnish to the Department such records and summaries, on a semiannual calendar basis, within 30 days after the end of the semiannual period. All other facility owners or distributors must submit these records and summaries upon request of the Department.

Work Practice Type: PARAMETER OF PROCESS MATERIAL Process Material: DISTILLATES - NUMBER 1 AND NUMBER 2 OIL

Parameter Monitored: SULFUR CONTENT Upper Permit Limit: 0.0015 percent by weight Monitoring Frequency: PER DELIVERY

Averaging Method: MAXIMUM - NOT TO BE EXCEEDED AT ANY

TIME (INSTANTANEOUS/DISCRETE OR GRAB)

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 27: Compliance Certification

Effective between the dates of 08/24/2017 and 08/23/2022

Applicable Federal Requirement: 6 NYCRR 225-1.5 (c)

Item 27.1:

The Compliance Certification activity will be performed for the Facility.

Item 27.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES Monitoring Description:

Measurements must be made daily of the rate of each fuel



Permit ID: 4-0101-00122/00009 Facility DEC ID: 4010100122

fired. The gross heat content and ash content of each fuel fired must be determined at least once each week. In the case of stationary combustion installations producing electricity for sale, the average electrical output and the hourly generation rate must also be measured.

Data collected pursuant to this Subpart must be tabulated and summarized in a form acceptable to the Department, and must be retained for at least five years. The owner of a Title V facility must furnish to the Department such records and summaries, on a semiannual calendar basis, within 30 days after the end of the semiannual period. All other facility owners or distributors must submit these records and summaries upon request of the Department.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 28: Compliance Certification

Effective between the dates of 08/24/2017 and 08/23/2022

Applicable Federal Requirement: 6 NYCRR 227-1.2 (a) (1)

Item 28.1:

The Compliance Certification activity will be performed for the facility: The Compliance Certification applies to:

Emission Unit: 0-0MAIN Emission Point: 00001

Process: OIL

Emission Unit: 0-0MAIN Emission Point: 00002

Process: OIL

Regulated Contaminant(s):

CAS No: 0NY075-00-0 PARTICULATES

Item 28.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

Particulate emission limit for singular boilers or multiple boilers ducted through a common stack, which fire liquid fuels, and that have a heat capacity exceeding 250 mmBtu/hr.

Parameter Monitored: PARTICULATES

Upper Permit Limit: 0.10 pounds per million Btus



Permit ID: 4-0101-00122/00009 Facility DEC ID: 4010100122

Reference Test Method: USEPA Reference Method 5

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2018.

Subsequent reports are due every 6 calendar month(s).

Condition 29: Multiple combustion sources

Effective between the dates of 08/24/2017 and 08/23/2022

Applicable Federal Requirement: 6 NYCRR 227-1.2 (b)

Item 29.1:

The total heat input of all furnaces connected to the same stack or pollution control device shall be used to calculate the permissible particulate emission rate.

Condition 30: Compliance Certification

Effective between the dates of 08/24/2017 and 08/23/2022

Applicable Federal Requirement: 6 NYCRR 227-1.3 (a)

Item 30.1:

The Compliance Certification activity will be performed for the facility: The Compliance Certification applies to:

Emission Unit: 0-0MAIN Emission Point: 00001

Emission Unit: 0-0MAIN Emission Point: 00002

Item 30.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

No owner or operator of a combustion installation shall emit greater than 20 percent opacity except for one six minute period per hour, not to exceed 27 percent, based upon the six minute average utilizing a continuous opacity

monitor (COM).

Parameter Monitored: OPACITY Upper Permit Limit: 20 percent Monitoring Frequency: CONTINUOUS Averaging Method: 6 MINUTE AVERAGE



Permit ID: 4-0101-00122/00009 Facility DEC ID: 4010100122

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 10/30/2017.

Subsequent reports are due every 3 calendar month(s).

Condition 31: Compliance Certification

Effective between the dates of 08/24/2017 and 08/23/2022

Applicable Federal Requirement:6 NYCRR 227-1.4 (b)

Item 31.1:

The Compliance Certification activity will be performed for the facility: The Compliance Certification applies to:

Emission Unit: 0-0MAIN Emission Point: 00001

Emission Unit: 0-0MAIN Emission Point: 00002

Item 31.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES Monitoring Description:

The owner or operator of a stationary combustion installation which utilizes a continuous opacity monitoring system (COMS) shall include the following in their quarterly excess emission reports:

- 1) Magnitude, date, and time of each exceedence;
- 2) For each period of excess emissions, specific identification of the cause and corrective action taken:
- 3) Date, time, and duration of each period of COMS downtime, and the corrective action for each period of downtime:
- 4) Total time the COMS is required to record data during the reporting period;
- 5) The total number of exceedences and the duration of exceedences expressed as a percentage of the total time in which the COMS are required to record data; and
- 6) Such other requirements as the Department may deem necessary in order to enforce Article 19 of the Environmental Conservation Law (ECL).

Monitoring Frequency: QUARTERLY

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 60 days after the reporting period.



Permit ID: 4-0101-00122/00009 Facility DEC ID: 4010100122

The initial report is due 11/29/2017. Subsequent reports are due every 3 calendar month(s).

Condition 32: Stack Monitoring

Effective between the dates of 08/24/2017 and 08/23/2022

Applicable Federal Requirement: 6 NYCRR 227-1.4 (c)

Item 32.1: If the sum of the maximum heat input capacity of all furnaces, which are operated simultaneously and are connected to a common air cleaning device and/or a common stack exceeds 250 million Btu per hour maximum heat input capacity, stack monitoring shall be required for such combustion installation in accordance with this section. The continuous stack monitoring and reporting requirements of this section as they may pertain to existing stationary combustion installations shall apply within one year after the effective date of this section, or by such later date as determined by an order of the commissioner.

Condition 33: Compliance Certification

Effective between the dates of 08/24/2017 and 08/23/2022

Applicable Federal Requirement: 40CFR 63, Subpart JJJJJJ

Item 33.1:

The Compliance Certification activity will be performed for the Facility.

Item 33.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES Monitoring Description:

Sheridan Plant ("Permittee") is subject to the requirements of NESHAP 6J. Notwithstanding conditions in this permit, the Permittee shall comply with all applicable requirements of NESHAP 6J. NESHAP 6J applies to the following six existing boilers or existing affected sources at Sheridan Plant:

Six existing identical boilers of Emission Unit: 0-0MAIN each with a design heat input capacity of 106 MMBTU/hr. The boilers are natural gas and No.2 fuel oil - fired.

I. General Compliance Requirement

The owner or operator (the Permittee) shall comply with all applicable provisions, including the notification, testing, and monitoring requirements as promulgated in 40 CFR 63, Subpart JJJJJJ, "National Emission Standards for Hazardous Air Pollutants for Area Sources: Industrial.



Commercial, and Institutional Boilers," including Subpart A "General Provisions."

II. Compliance Date

1. The Permittee of an existing source, with a heat input capacity of 10 MMBTU/hr or greater, is required to comply with the tune-up and the energy assessment requirements no later than March 21, 2014. [40 CFR 63.11196]

III. Compliance Requirements

- 1. At all times the Permittee shall operate and maintain any affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. [(40 CFR 63.11205(a)].
- 2. Boiler Tune-up
- a. Initial tune-up
- i. An initial boiler tune-up is required by March 21, 2014. If the unit is not operating on the required date for a tune-up, the tune-up must be conducted within thirty days of startup. [40 CFR 63.11223]
- b. Periodic tune-ups
- i. A biennial tune-up is required and shall be conducted no more than 25 months after the previous tune-up. [40 CFR 63.11223(b)]
- ii. The Permittee shall comply with the following with respect to the tune-up:
- The permittee shall conduct the tune-up while burning the type of fuel (or fuels in thecase of boilers that routinely burn two types of fuels at the same time) that provided the majority of the heat input to the boiler over the 12 months prior to the tune-up. [40 CFR 63.11223(a)]
- As applicable, inspect the burner, and clean or replace any components of the burner as necessary. The Permittee may delay the burner inspection until the next scheduled unit shutdown, but must inspect each burner at least once every 36 months (72 months for 5-year tune-ups). [40 CFR 63.11223(b)]
- Inspect the flame pattern, as applicable, and adjust the burner as necessary to optimize the flame pattern. The adjustment should be consistent with the manufacturer's specifications, if available. [40 CFR 63.11223(b)]
- Inspect the system controlling the air-to-fuel ratio, as applicable, and ensure that it is correctly calibrated and functioning properly. The Permittee may delay the air to fuel ratio inspection until the next scheduled unit



shutdown, but must conduct the inspection at least once every 36 months (72 months for 5-year tune-ups). [40 CFR 63.11223(b)]

- Optimize total emissions of carbon monoxide. This optimization should be consistent with the manufacturer's specifications, if available, and with any nitrogen oxide requirement to which the unit is subject. [40 CFR 63.11223(b)]
- Measure the concentrations in the effluent stream of carbon monoxide in parts per million, by volume, and oxygen in volume percent, before and after the adjustments are made (measurements may be either on a dry or wet basis, as long as it is the same basis before and after the adjustments are made). Measurements may be taken with a portable CO analyzer. [40 CFR 63.11223(b)]
- 3. Energy Assessment: A one-time initial energy assessment is required by March 21, 2014.

The energy assessment must be performed by a qualified energy assessor. An energy assessment completed on or after January 1, 2008, that meets, or is amended to meet, the energy assessment requirements in this section satisfies the energy assessment requirement.

This energy assessment requirement does not apply to limited use boilers as defined in 40 CFR 63.11237. A facility that operates under an energy management program compatible with ISO 50001 that includes the affected units satisfies the energy assessment requirement. The energy assessment must include:

- a. A visual inspection of the boiler system.
- b. An evaluation of operating characteristics of the facility, specifications of energy using systems, operating and maintenance procedures, and unusual operating constraints.
- c. Inventory of major systems consuming energy from affected boilers and which are under control of the boiler owner or operator.
- d. A review of available architectural and engineering plans, facility operation and maintenance procedures and logs, and fuel usage.
- e. A list of major energy conservation measures that are within the facility's control.
- f. A list of the energy savings potential of the energy conservation measures identified.
- g. A comprehensive report detailing the ways to improve efficiency, the cost of specific improvements, benefits, and the time frame for recouping those investments. [40 CFR 63.11214(c)]
- IV. Notification and Reporting Requirements



1. An Initial Notification is required by January 20, 2014. [40 CFR 63.9(b) and 40 CFR 63.11225(a) (2)] 2. The Notification of Compliance Status is required by no later than 120 days after the applicable compliance dates specified in 40 CFR 63.11196 and elsewhere in this permit. [40 CFR 63.11225(a) (4)]

3. An annual compliance certification report, must be prepared by March 1 of every year, for the previous calendar year, containing the information specified in paragraphs 40 CFR 63.11225 (b) (1) through (b)(4), and must be submitted upon request. If the source experiences any deviations from the applicable requirements, then the report must be submitted by March 15. The report must meet the requirements of 40 CFR 63.11225(b) (1-4). [40 CFR 63.11225(b) (1-4)]

V. Recordkeeping Requirements

The following records, as defined under 40 CFR 63.11225(c), shall be maintained by the Permittee:

- 1. Copies of all required notifications. [40 CFR 63.11225(c) (1)]
- 2. Tune-up records must identify each boiler, the date of tune-up, the procedures followed for tune-up, the manufacturer's specifications to which the boiler was tuned, and the following:
- a. The concentrations of CO in the effluent stream in parts per million, by volume, and oxygen in volume percent, measured at high fire or typical operating load, before and after the tune-up of the boiler. [40 CFR 63.11223(b) (6) (i)]
- b. A description of any corrective actions taken as a part of the tune-up of the boiler. [40 CFR 63.11223 (b) (6)
- c. The type and amount of fuel used over the 12 months prior to the tune-up of the boiler but only if the unit was physically and legally capable of using more than one type of fuel during that period. Units sharing a fuel meter may estimate the fuel use by each unit. [40 CFR 63.11223 (b) (6) (iii)]
- 3. A copy of the Energy Assessment Report required by 40 CFR 63.11214(c). [40 CFR 63.11214(c)]
- 4. Records of non-waste determinations per 40 CFR 63.11225(c) (2) (ii). [40 CFR 63.11225(c) (2) (ii)]
- 5. Records of the occurrence and duration of each malfunction of the boiler, or of the associated air pollution control and monitoring equipment. Records of actions taken during periods of malfunction to minimize emissions in accordance with the general duty to minimize emissions in 40 CFR 63.11205(a), including corrective actions to restore the malfunctioning boiler, air

Renewal 3



Permit ID: 4-0101-00122/00009 Facility DEC ID: 4010100122

pollution control, or monitoring equipment to its normal or usual manner of operation. [40 CFR 63.11225(c) (4) (iv)]

6. Keep each record for 5 years following the date of each recorded action. [40 CFR 63.11225(d)]

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 34: Compliance Certification

Effective between the dates of 08/24/2017 and 08/23/2022

Applicable Federal Requirement: 40CFR 63, Subpart ZZZZ

Item 34.1:

The Compliance Certification activity will be performed for the Facility.

Item 34.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES Monitoring Description:

Sheridan Plant ("Permittee") is subject to the requirements of NESHAP 4Z for area sources. Notwithstanding conditions in this permit, the Permittee shall comply with all applicable requirements of NESHAP 4Z. NESHAP 4Z applies to the following three existing RICE emergency generators at Sheridan Plant:

- Two identical existing RICE emergency generators which comprise of compression ignition (CI) engines each rated at 4,500 BHP and fired by diesel or No.2 fuel oil;
- One existing RICE emergency generator which comprise of a compression ignition (CI) engines rated at 90 BHP and fired by diesel or No.2 fuel oil;

The Permittee shall comply with the definition of emergency stationary RICE in 40 CFR 63.6675 and the following provisions:

I. Compliance Date:

The compliance date for the 3 existing EG CI engines: May 3, 2013. [40 CFR 63.6595 (a)]

- II. General Requirements for Complying with Subpart ZZZZ
- 1. The Permittee must be in compliance with the emission limitations, operating limitations and other applicable requirements of Subpart ZZZZ at all times. [40 CFR 63.6605



(a)]

2. At all times, the Permittee must operate and maintain any affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. The general duty to minimize emissions does not require you to make any further efforts to reduce emissions if levels required by this standard have been achieved. Determination of whether such operation and maintenance procedures are being used will be based on information available to the EPA which may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source. [40 CFR 63.6605 (b)]

III. Emission Limitations, Management Practices and Other Requirements:

- 1. The Permittee shall comply with the following requirements of 40 CFR 63.6603 and Table 2d, Section 4 of Subpart ZZZZ: The requirements a through c must be met at all times, except during periods of startup.
- a. Change the oil and filter every 500 hours of operation or annually, whichever comes first. The Permittee has the option to utilize an oil analysis program as described in 63.6625(i) in order to extend the specified oil change requirements.
- b. Inspect the air cleaner every 1,000 hours of operation or annually, whichever comes first, and replace as necessary.
- c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.
- d. The Permittee must minimize the engine's time spent at idle during startup and minimize the engine's startup time at startup to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes after which time the emission standards applicable to all times other than startup apply. [40 CFR 63.6625(h)]
- e. If the emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the management practice requirements on the schedules required in Table 2d of Subpart ZZZZ, or if performing the management practice on the required schedules would otherwise pose an unacceptable risk under federal, state or local law, the management practices can be delayed until the emergency is over or the unacceptable risk under federal, state, or local law has abated. The management practice shall be performed as soon as possible after the emergency has ended or the unacceptable risk has abated. The Permittee shall report any failure to perform



the management practice on the schedule required and the federal, state, or local law under which the risk was deemed unacceptable. [Table 2d of Subpart ZZZZ]

- 2. Operate and maintain the engines and after-treatment control device (if any) according to the manufacturer's emission-related operation and maintenance instructions; or develop and follow your its own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good pollution control practices for minimizing emissions. [40 CFR 63.6625 (e)]
- 3. Install a non-resettable hour meter if one is not already installed. [40 CFR 63.6625 (f)]
- 4. The Permittee may utilize an oil analysis program in order to extend the oil change requirements specified in 63.602 (a) and Table 2d. The oil analysis must be performed as specified in 63.6625 (i).
- 5. The Permittee must demonstrate continuous compliance with each applicable operating limitation in Table 2d in accordance to methods specified in Table 6. [40 CFR 63.6640 (a)]
- 6. If the Permittee does not operate the engine according to the requirements in 63.6640(f) (1) through (f) (4), then the engine will not be considered an emergency engine under Subpart ZZZZ and must meet all requirements for non-emergency engines. [40 CFR 63.6640 (f)]
 a. There is no time limit on the use in emergency situations. [40 CFR 63.6640 (f) (1)] NOTE: Part 201-3 requires that the total number of hours (which includes emergency and non-emergency operation) that an emergency generator could be operated in a calendar year to be limited to 500 hr. However, there are no requirements in the permit that the facility should monitor and record the number of operating hours.
- b. The Permittee may operate the engine for the purposes specified in paragraph (f) (2) (i) for a maximum of 100 hours per calendar year. Any operation for non-emergency situation as allowed by paragraph (f) (4) counts as part of the 100 hours per calendar year as allowed by paragraph (f) (2). [40 CFR 63.6640 (f) (2)]
- The engine may be operated for maintenance checks and readiness testing, provided that the tests are recommended by federal, state or local government, the manufacturer, the vendor, the regional transmission authority or equivalent balancing authority and transmission operator, or the insurance company associated with the engine. The Permittee may petition the Administrator for approval of



additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the Permittee maintains records indicating that federal, state, or local standards require maintenance and testing of the engine beyond 100 hours per calendar year. [40 CFR 63.6640 (f) (2) (i)]

7. Pursuant to 40 CFR 63.6640(f) (3), the engine may be operated for up to 50 hours per calendar year in non-emergency situations. The 50 hours of operation in non-emergency situations are counted as part of the 100 hours per calendar year for maintenance and testing and emergency demand response provided in 63.6640(f) (2). The 50 hours per year for non-emergency situations cannot be used for peak shaving or non-emergency demand response, or to generate income for the facility to supply power to an electric grid or otherwise supply power as part of a financial arrangement with another entity.[40 CFR 63.6640 (f) (3)]

IV. Fuel Requirements

Pursuant to 40 CFR 63.6604(b) the following the Permittee shall comply with the following fuel requirements:

Beginning January 1, 2015, emergency engines that meet all the following conditions must use diesel fuel that meets the requirements in 40 CFR 80.510(b) for nonroad diesel fuel, except that any existing diesel fuel purchased prior to January 1, 2015 may be used until depleted.

- Greater than 100 brake HP;
- Displacement of less than 30 liters per cylinder;
- Operates for the purposes specified in 63.6640 (f)(4)(ii)

The diesel fuel requirements of 40 CFR 80.510(b) are as follows: (1) Sulfur content of 15 ppm maximum; and (2) A minimum cetane index of 40, or a maximum aromatic content of 35 volume percent. NOTE: Starting July 1, 2016 6 NYCRR Part 225 has limited the sulfur content in diesel and No.2 fuel oil to 15 ppm.

V. Recordkeeping Requirements

The Permittee shall keep records showing:

1. The Permittee must keep the records required in Table 6 of Subpart ZZZZ to show continuous compliance with each applicable emission or operating limitation in 40 CFR Part 63, Subpart ZZZZ. [40 CFR 63.6655 (a) and (d)]



- 2. If applicable, the parameters that are analyzed as part of the oil analysis program, the results of the analysis, and the oil changes for the engine.[40CFR 63.6655 (e)]
- 3. The hours of operation of the engine that is recorded through the non-resettable hour meter. The Permittee must document how many hours are spent for emergency operation; including what classified the operation as emergency and how many hours are spent for non-emergency operation. The Permittee must keep records of the notification of the emergency situation, and the date, start time and end time of the engine operation for these purposes. [40 CFR 63.6655 (f)]
- 4. The records must be in a form suitable and readily available for expeditious review. [40 CFR 63.6660 (a) and 40 CFR 63.10 (b) (1)]
- 5. The Permittee must keep each record for 5 years following the date of each occurrence, measurement, maintenance, corrective action, report, or record. [40 CFR 63.6660 (b) and 40 CFR 63.10 (b) (1)]
- 6. The Permittee must keep each record readily accessible in hard copy or electronic form on site at the source for 5 years after the date of each occurrence, measurement, maintenance, corrective action, report, or record, according to 63.10 (b)(1). [40 CFR63.6660 (c) and 40 CFR 63.10 (b) (1)]

VI. Reporting Requirements

The Permittee must report each instance in which it did not meet each applicable emission limitation or operating limitation in Table 2c. These instances are deviations from the emission and operating limitations in this subpart. These deviations must be reported according to the requirements in 63.6650. [40 CFR 63.6640 (b)]

40 CFR 63 Subpart A-General Provisions

The Permittee shall comply with all applicable provisions of 40 CFR Subpart A as outlined in Table 8 of 40 CFR 63 Subpart ZZZZ.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION



Permit ID: 4-0101-00122/00009 Facility DEC ID: 4010100122

**** Emission Unit Level ****

Condition 35: Emission Point Definition By Emission Unit

Effective between the dates of 08/24/2017 and 08/23/2022

Applicable Federal Requirement: 6 NYCRR Subpart 201-6

Item 35.1:

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: 0-0MAIN

Emission Point: 00001

Height (ft.): 160 Diameter (in.): 96

NYTMN (km.): 4723.333 NYTME (km.): 602.081 Building: EAST

Emission Point: 00002

Height (ft.): 160 Diameter (in.): 96

NYTMN (km.): 4723.289 NYTME (km.): 602.112 Building: EAST

Condition 36: Process Definition By Emission Unit

Effective between the dates of 08/24/2017 and 08/23/2022

Applicable Federal Requirement: 6 NYCRR Subpart 201-6

Item 36.1:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: 0-0MAIN

Process: GAS Source Classification Code: 1-02-006-01

Process Description: The six boilers burn natural gas.

Emission Source/Control: 00B01 - Combustion Design Capacity: 106 million Btu per hour

Emission Source/Control: 00B02 - Combustion Design Capacity: 106 million Btu per hour

Emission Source/Control: 00B03 - Combustion Design Capacity: 106 million Btu per hour

Emission Source/Control: 00B04 - Combustion Design Capacity: 106 million Btu per hour

Emission Source/Control: 00B05 - Combustion Design Capacity: 106 million Btu per hour

Emission Source/Control: 00B06 - Combustion Design Capacity: 106 million Btu per hour

Item 36.2:

This permit authorizes the following regulated processes for the cited Emission Unit:



Emission Unit: 0-0MAIN

Process: OIL Source Classification Code: 1-02-005-01

Process Description: The six boilers burn No. 2 fuel oil.

Emission Source/Control: 00B01 - Combustion Design Capacity: 106 million Btu per hour

Emission Source/Control: 00B02 - Combustion Design Capacity: 106 million Btu per hour

Emission Source/Control: 00B03 - Combustion Design Capacity: 106 million Btu per hour

Emission Source/Control: 00B04 - Combustion Design Capacity: 106 million Btu per hour

Emission Source/Control: 00B05 - Combustion Design Capacity: 106 million Btu per hour

Emission Source/Control: 00B06 - Combustion Design Capacity: 106 million Btu per hour

Condition 37: General Provisions

Effective between the dates of 08/24/2017 and 08/23/2022

Applicable Federal Requirement: 6 NYCRR 227-1.7

Item 37.1:

This Condition applies to Emission Unit: 0-0MAIN

Item 37.2:

- (a) Emission data. Any person who owns or operates a stationary combustion installation described in 6 NYCRR Part 227-1 shall provide pertinent data concerning emissions when so requested by the commissioner.
- (b) Test methods. Sampling, compositing and analysis of fuel samples shall be carried out in accordance with the most recent ASTM standard methods or equivalent methods acceptable to the commissioner.

Condition 38: Compliance Certification

Effective between the dates of 08/24/2017 and 08/23/2022

Applicable Federal Requirement: 6 NYCRR 227-2.4 (b) (1) (ii)

Item 38.1:

The Compliance Certification activity will be performed for:

Emission Unit: 0-0MAIN

Regulated Contaminant(s):



CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 38.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING Monitoring Description:

This condition applies to natural gas/oil fired large boilers. The owner or operator shall submit a testing protocol to the Department for approval a minimum of 30 days prior to any stack testing.

The owner or operator will maintain records on-site for a minimum of five years.

The compliance deadline, with the emission limitation listed in this condition, is July, 1 2014. Compliance with the monitoring, record keeping, or reporting requirements listed in this condition begins on July, 1 2014.

Parameter Monitored: OXIDES OF NITROGEN Upper Permit Limit: 0.15 pounds per million Btus

Reference Test Method: 40 CFR 60 Appendix A - Method 7, 7E, or 19 Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2018.

Subsequent reports are due every 6 calendar month(s).



Permit ID: 4-0101-00122/00009 Facility DEC ID: 4010100122

STATE ONLY ENFORCEABLE CONDITIONS **** Facility Level ****

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

This section contains terms and conditions which are not federally enforceable. Permittees may also have other obligations under regulations of general applicability

Item A: Emergency Defense - 6 NYCRR 201-1.5

An emergency, as defined by subpart 201-2, constitutes an affirmative defense to penalties sought in an enforcement action brought by the Department for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

- (a) The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:
- (1) An emergency occurred and that the facility owner or operator can identify the cause(s) of the emergency;
- (2) The equipment at the permitted facility causing the emergency was at the time being properly operated and maintained;
- (3) During the period of the emergency the facility owner or operator took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and
- (4) The facility owner or operator notified the Department within two working days after the event occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.
- (b) In any enforcement proceeding, the facility owner or operator seeking to establish the occurrence of an emergency has the burden of proof.
- (c) This provision is in addition to any emergency or upset provision contained in any applicable requirement.

Item B: General Provisions for State Enforceable Permit Terms and Condition - 6 NYCRR Part 201-5

Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all criteria, emission limits, terms, conditions, and



Permit ID: 4-0101-00122/00009 Facility DEC ID: 4010100122

standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

STATE ONLY APPLICABLE REQUIREMENTS

The following conditions are state applicable requirements and are not subject to compliance certification requirements unless otherwise noted or required under 6 NYCRR Part 201.

Condition 39: Contaminant List

Effective between the dates of 08/24/2017 and 08/23/2022

Applicable State Requirement: ECL 19-0301

Item 39.1:

Emissions of the following contaminants are subject to contaminant specific requirements in this permit(emission limits, control requirements or compliance monitoring conditions).

CAS No: 0NY075-00-0 Name: PARTICULATES

CAS No: 0NY210-00-0

Name: OXIDES OF NITROGEN

Condition 40: Malfunctions and start-up/shutdown activities

Effective between the dates of 08/24/2017 and 08/23/2022

Applicable State Requirement: 6 NYCRR 201-1.4

Item 40.1:

- (a) The facility owner or operator shall take all necessary and appropriate actions to prevent the emission of air pollutants that result in contravention of any applicable emission standard during periods of start-up, shutdown, or malfunction.
- (b) The facility owner or operator shall compile and maintain records of all equipment malfunctions, maintenance, or start-up/shutdown activities when they can be expected to result in an exceedance of any applicable emission standard, and shall submit a report of such activities to

Air Pollution Control Permit Conditions
Renewal 3 Page 37 FINAL



the department when requested to do so, or when so required by a condition of a permit issued for the corresponding air contamination source. Such reports shall state whether any violations occurred and, if so, whether they were unavoidable, include the time, frequency and duration of the maintenance and/or start-up/shutdown activities, and an estimate of the emission rates of any air contaminants released. Such records shall be maintained for a period of at least five years and made available for review to department representatives upon request. Facility owners or operators subject to continuous stack monitoring and quarterly reporting requirements need not submit additional reports for equipment maintenance or start-up/shutdown activities for the facility to the department.

- (c) In the event that emissions of air contaminants in excess of any emission standard in this Subchapter occur due to a malfunction, the facility owner or operator shall compile and maintain records of the malfunction and notify the department as soon as possible during normal working hours, but not later than two working days after becoming aware that the malfunction occurred. When requested by the department, the facility owner or operator shall submit a written report to the department describing the malfunction, the corrective action taken, identification of air contaminants, and an estimate of the emission rates.
- (d) The department may also require the owner or operator to include, in reports described under Subdivisions (b) and (c) of this Section, an estimate of the maximum ground level concentration of each air contaminant emitted and the effect of such emissions.
- (e) A violation of any applicable emission standard resulting from start-up, shutdown, or malfunction conditions at a permitted or registered facility may not be subject to an enforcement action by the department and/or penalty if the department determines, in its sole discretion, that such a violation was unavoidable. The actions and recordkeeping and reporting requirements listed above must be adhered to in such circumstances.

Condition 41: Compliance Demonstration

Effective between the dates of 08/24/2017 and 08/23/2022

Applicable State Requirement: 6 NYCRR 227-1.4 (a)

Item 41.1:

The Compliance Demonstration activity will be performed for the facility: The Compliance Demonstration applies to:

Emission Unit: 0-0MAIN Emission Point: 00001

Emission Unit: 0-0MAIN Emission Point: 00002

Item 41.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

Any person who owns a stationary combustion installation (excluding gas turbines), with a total maximum heat input capacity exceeding 250 million Btu per hour shall install, operate in accordance with manufacturer's instructions,

Air Pollution Control Permit Conditions Renewal 3 Page 38 FINAL



and properly maintain, accurate instruments satisfying the criteria in appendix B of title 40, part 60 of the Code of Federal Regulations, or approved by the commissioner on an individual case basis, for continuously monitoring and recording opacity, and when sulfur dioxide continuous monitoring is required by Part 225 of this Title, for continuously monitoring and recording either the percent oxygen or carbon dioxide in the flue gases from such installations at all times that the combustion installation is in service. Where gas is the only fuel burned, monitoring and recording of opacity is not required.

Parameter Monitored: OPACITY Upper Permit Limit: 20 percent

Reference Test Method: 40CFR60 Appendix B Monitoring Frequency: CONTINUOUS Averaging Method: 6 MINUTE AVERAGE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 10/30/2017.

Subsequent reports are due every 3 calendar month(s).

