Facility DEC ID: 5412000266

PERMIT
Under the Environmental Conservation Law (ECL)

IDENTIFICATION INFORMATION

Permit Type: Air State Facility
Permit ID: 5-4120-00266/00001
Effective Date: 10/21/2026 Expiration Date: 10/20/2036

Permit Issued To:DOLOMITE PRODUCTS COMPANY INC.
The Dolomite Group A CRH Company
800 Parker Hill Dr Ste 400
ROCHESTER, NY 14625

Contact: Evan Onuskanych
PO Box 15097
Albany, NY 12212-5097
(518) 374-2222

Facility: DOLOMITE HOT MIX ASPHALT PLANT
CURTIS PARK RD
Ballston, NY 12020

Description:
The facility is an existing 200 ton per hour drum mix asphalt plant firing on natural gases the sole fuel source. A fabric filter baghouse controls particulate emissions, and an activated carbon drum filter controls fugitive VOC emissions from the liquid asphalt storage tank. The plant is powered by utility electric. Trivial emissions from aggregate stockpiles, and fugitive emissions from ancillary equipment have been accounted for in the facility emission potential.

By acceptance of this permit, the permittee agrees that the permit is contingent upon strict compliance with the ECL, all applicable regulations, the General Conditions specified and any Special Conditions included as part of this permit.

Permit Administrator: BETH A MAGEE
NYSDEC - WARRENSBURG SUBOFFICE
232 GOLF COURSE RD
WARRENSBURG, NY 12885-1172

Authorized Signature: _____ Date: ___ / ___ / _____

Notification of Other State Permittee Obligations

Item A: Permittee Accepts Legal Responsibility and Agrees to Indemnification

The permittee expressly agrees to indemnify and hold harmless the Department of Environmental Conservation of the State of New York, its representatives, employees and agents ("DEC") for all claims, suits, actions, and damages, to the extent attributable to the permittee's acts or omissions in connection with the compliance permittee's undertaking of activities in connection with, or operation and maintenance of, the facility or facilities authorized by the permit whether in compliance or not in any compliance with the terms and conditions of the permit. This indemnification does not extend to any claims, suits, actions, or damages to the extent attributable to DEC's own negligent or intentional acts or omissions, or to any claims, suits, or actions naming the DEC and arising under article 78 of the New York Civil Practice Laws and Rules or any citizen suit or civil rights provision under federal or state laws.

Item B: Permittee's Contractors to Comply with Permit

The permittee is responsible for informing its independent contractors, employees, agents and assigns of their responsibility to comply with this permit, including all special conditions while acting as the permittee's agent with respect to the permitted activities, and such persons shall be subject to the same sanctions for violations of the Environmental Conservation Law as those prescribed for the permittee.

Item C: Permittee Responsible for Obtaining Other Required Permits

The permittee is responsible for obtaining any other permits, approvals, lands, easements and rights-of-way that may be required to carry out the activities that are authorized by this permit.

Item D: No Right to Trespass or Interfere with Riparian Rights

This permit does not convey to the permittee any right to trespass upon the lands or interfere with the riparian rights of others in order to perform the permitted work nor does it authorize the impairment of any rights, title, or interest in real or personal property held or vested in a person not a party to the permit.

PAGE LOCATION OF CONDITIONS

PAGE

DEC GENERAL CONDITIONS

General Provisions

4 1 Facility Inspection by the Department

4 2 Relationship of this Permit to Other Department Orders and Determinations

4 3 Applications for permit renewals, modifications and transfers

5 4 Permit modifications, suspensions or revocations by the Department

Facility Level

5 5 Submission of application for permit modification or renewal-REGION 5 SUBOFFICE - WARRENSBURG

DEC GENERAL CONDITIONS
**** General Provisions ****
GENERAL CONDITIONS - Apply to ALL Authorized Permits.

Condition 1: Facility Inspection by the Department
Applicable State Requirement: ECL 19-0305

Item 1.1:
The permitted site or facility, including relevant records, is subject to inspection at reasonable hours and intervals by an authorized representative of the Department of Environmental Conservation (the Department) to determine whether the permittee is complying with this permit and the ECL. Such representative may order the work suspended pursuant to ECL 71-0301 and SAPA 401(3).

Item 1.2:
The permittee shall provide a person to accompany the Department's representative during an inspection to the permit area when requested by the Department.

Item 1.3:
A copy of this permit, including all referenced maps, drawings and special conditions, must be available for inspection by the Department at all times at the project site or facility. Failure to produce a copy of the permit upon request by a Department representative is a violation of this permit.

Condition 2: Relationship of this Permit to Other Department Orders and Determinations
Applicable State Requirement: ECL 3-0301 (2) (m)

Item 2.1:
Unless expressly provided for by the Department, issuance of this permit does not modify, supersede or rescind any order or determination previously issued by the Department or any of the terms, conditions or requirements contained in such order or determination.

Condition 3: Applications for permit renewals, modifications and transfers
Applicable State Requirement: 6 NYCRR 621.11

Item 3.1:
The permittee must submit a separate written application to the Department for renewal, modification or transfer of this permit. Such application must include any forms or supplemental information the Department requires. Any renewal, modification or transfer granted by the Department must be in writing.

Item 3.2:
The permittee must submit a renewal application at least 180 days before the expiration of permits for Title V and State Facility Permits.

Item 3.3
Permits are transferrable with the approval of the department unless specifically prohibited by the statute, regulation or another permit condition. Applications for permit transfer should be submitted prior to actual transfer of ownership.

Facility DEC ID: 5412000266

Condition 4: Permit modifications, suspensions or revocations by the Department
Applicable State Requirement: 6 NYCRR 621.13

Item 4.1:
The Department reserves the right to exercise all available authority to modify, suspend, or revoke this permit in accordance with 6NYCRR Part 621. The grounds for modification, suspension or revocation include:

a) materially false or inaccurate statements in the permit application or supporting papers;
b) failure by the permittee to comply with any terms or conditions of the permit;
c) exceeding the scope of the project as described in the permit application;
d) newly discovered material information or a material change in environmental conditions, relevant technology or applicable law or regulations since the issuance of the existing permit;
e) noncompliance with previously issued permit conditions, orders of the commissioner, any provisions of the Environmental Conservation Law or regulations of the Department related to the permitted activity.

****** Facility Level ******

Condition 5: Submission of application for permit modification or renewal-REGION 5 SUBOFFICE - WARRENSBURG
Applicable State Requirement: 6 NYCRR 621.6 (a)

Item 5.1:
Submission of applications for permit modification or renewal are to be submitted to:

NYSDEC Regional Permit Administrator
Region 5 Sub-office
Division of Environmental Permits
232 Golf Course Road
Warrensburg, NY 12885-1172
(518) 623-1281

Permit ID: 5-4120-00266/00001 **Facility DEC ID: 5412000266**

Permit Under the Environmental Conservation Law (ECL)

ARTICLE 19: AIR POLLUTION CONTROL - AIR STATE FACILITY PERMIT

IDENTIFICATION INFORMATION

Permit Issued To: DOLOMITE PRODUCTS COMPANY INC.
The Dolomite Group A CRH Company
800 Parker Hill Dr Ste 400
ROCHESTER, NY 14625

Facility: DOLOMITE HOT MIX ASPHALT PLANT
CURTIS PARK RD
Ballston, NY 12020

Authorized Activity By Standard Industrial Classification Code:
2951 - PAVING MIXTURES AND BLOCKS

Permit Effective Date: 10/21/2026 Permit Expiration Date: 10/20/2036

PAGE LOCATION OF CONDITIONS

PAGE

FEDERALLY ENFORCEABLE CONDITIONS
Facility Level

6 19 6 NYCRR 201-1.4: Malfunctions and Start-up/Shutdown Activities
7 1 6 NYCRR Subpart 201-7: Facility Permissible Emissions
7 *2 6 NYCRR Subpart 201-7: Capping Monitoring Condition
9 3 6 NYCRR 211.2: Visible Emissions Limited
9 4 6 NYCRR 220-3.3 (a): Compliance Demonstration
10 5 6 NYCRR 220-3.3 (b): Compliance Demonstration
10 6 6 NYCRR 220-3.3 (b): Compliance Demonstration
11 7 6 NYCRR 220-3.3 (b): Compliance Demonstration
12 8 6 NYCRR 220-3.4: Filling of Asphalt Cement Storage Tanks.
12 9 6 NYCRR 220-3.5 (b): Compliance Demonstration
13 10 6 NYCRR 220-3.5 (b): Compliance Demonstration
14 11 6 NYCRR 220-3.6 (a): Compliance Demonstration
15 12 6 NYCRR 220-3.7 (a): Compliance Demonstration
16 13 6 NYCRR 220-3.8: Compliance Demonstration
16 14 6 NYCRR 220-3.9 (c): Compliance Demonstration
17 15 6 NYCRR 220-3.10: Minimization of Fugitive Dust Emissions.

Emission Unit Level

EU=1-ASPHP,EP=00001

18 16 40CFR 60.92(a)(1), NSPS Subpart I: Compliance Demonstration
18 17 40CFR 60.92(a)(2), NSPS Subpart I: Compliance Demonstration

STATE ONLY ENFORCEABLE CONDITIONS
Facility Level

21 18 ECL 19-0301: Contaminant List
22 20 6 NYCRR Subpart 201-5: Emission Unit Definition
22 21 6 NYCRR 201-5.2 (c): Renewal deadlines for state facility permits
22 22 6 NYCRR 201-5.3 (c): Compliance Demonstration
23 23 6 NYCRR 211.1: Air pollution prohibited

Emission Unit Level

23 24 6 NYCRR Subpart 201-5: Emission Point Definition By Emission Unit
23 25 6 NYCRR Subpart 201-5: Process Definition By Emission Unit

NOTE: * preceding the condition number indicates capping.

FEDERALLY ENFORCEABLE CONDITIONS

Renewal 1/FINAL ****** Facility Level ******

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

This section contains terms and conditions which are federally enforceable. Permittees may also have other obligations under regulations of general applicability

Item A: Sealing - 6 NYCRR 200.5

The Commissioner may seal an air contamination source to prevent its operation if compliance with 6 NYCRR Chapter III is not met within the time provided by an order of the Commissioner issued in the case of the violation. Sealing means labeling or tagging a source to notify any person that operation of the source is prohibited, and also includes physical means of preventing the operation of an air contamination source without resulting in destruction of any equipment associated with such source, and includes, but is not limited to, bolting, chaining or wiring shut control panels, apertures or conduits associated with such source.

No person shall operate any air contamination source sealed by the Commissioner in accordance with this section unless a modification has been made which enables such source to comply with all requirements applicable to such modification.

Unless authorized by the Commissioner, no person shall remove or alter any seal affixed to any contamination source in accordance with this section.

Item B: Acceptable Ambient Air Quality - 6 NYCRR 200.6

Notwithstanding the provisions of 6 NYCRR Chapter III, Subchapter A, no person shall allow or permit any air contamination source to emit air contaminants in quantities which alone or in combination with emissions from other air contamination sources would contravene any applicable ambient air quality standard and/or cause air pollution. In such cases where contravention occurs or may occur, the Commissioner shall specify the degree and/or method of emission control required.

Item C: Maintenance of Equipment - 6 NYCRR 200.7

Any person who owns or operates an air contamination source which is equipped with an emission control device shall operate such device and keep it in a satisfactory state of maintenance and repair in accordance with ordinary and necessary practices, standards and procedures, inclusive of manufacturer's specifications,

required to operate such device effectively.

Item D: Unpermitted Emission Sources - 6 NYCRR 201-1.2

(a) Except as otherwise provided by this Part, construction or operation of a new, modified or existing air contamination source without a registration or permit issued pursuant to this Part is prohibited.

(b) If an existing facility or emission source was subject to the permitting requirements of this Part at the time of construction or modification, and the owner or operator failed to apply for a permit or registration as described in this Part, the owner or operator must apply for a permit or registration in accordance with the provisions of this Part. The facility or emission source is subject to all regulations that were applicable to it at the time of construction or modification and any subsequent requirements applicable to existing emission sources.

Item E: Recycling and Salvage - 6 NYCRR 201-1.7

Where practical, any person who owns or operates an air contamination source shall recycle or salvage air contaminants collected in an air cleaning device according to the requirements of 6 NYCRR.

Item F: Prohibition of Reintroduction of Collected Contaminants to the Air - 6 NYCRR 201-1.8

No person shall unnecessarily remove, handle, or cause to be handled, collected air contaminants from an air cleaning device for recycling, salvage or disposal in a manner that would reintroduce them to the outdoor atmosphere.

Item G: Proof of Eligibility for Sources Defined as Exempt Activities - 6 NYCRR 201-3.2 (a)

The owner and/or operator of an emission source or unit that is eligible to be exempt, may be required to certify that it operates within the specific criteria described in 6 NYCRR Subpart 201-3. The owner or operator of any such emission source must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility which contains emission sources or units subject to 6 NYCRR Subpart 201-3, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

Item H: Proof of Eligibility for Sources Defined as Trivial

Activities - 6 NYCRR 201-3.3 (a)
The owner and/or operator of an emission source or unit that is listed as being trivial in 6 NYCRR Part 201 may be required to certify that it operates within the specific criteria described in 6 NYCRR Subpart 201-3. The owner or operator of any such emission source must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility which contains emission sources or units subject to 6 NYCRR Subpart 201-3, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

Item I: Required Emission Tests - 6 NYCRR 202-1.1

An acceptable report of measured emissions shall be submitted, as may be required by the Commissioner, to ascertain compliance or noncompliance with any air pollution code, rule, or regulation. Failure to submit a report acceptable to the Commissioner within the time stated shall be sufficient reason for the Commissioner to suspend or deny an operating permit. Notification and acceptable procedures are specified in 6 NYCRR Subpart 202-1.

Item J: Open Fires Prohibitions - 6 NYCRR 215.2
Except as allowed by section 215.3 of 6 NYCRR Part 215, no person shall burn, cause, suffer, allow or permit the burning of any materials in an open fire.

Item K: Permit Exclusion - ECL 19-0305
The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York (NYCRR). The issuance of this permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.

Item L: Federally Enforceable Requirements - 40 CFR 70.6 (b)

All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

FEDERAL APPLICABLE REQUIREMENTS
The following conditions are federally enforceable.

Condition 19: Malfunctions and Start-up/Shutdown Activities
Effective between the dates of 10/21/2026 and 10/20/2036

Applicable Federal Requirement:6 NYCRR 201-1.4

Item 19.1:
(a) The facility owner or operator shall take all necessary and appropriate actions to prevent the emission of air pollutants that result in contravention of any applicable emission standard during periods of start-up, shutdown, or malfunction.

(b) The facility owner or operator shall compile and maintain records of all equipment maintenance and start-up/shutdown activities when they are expected to result in an exceedance of any applicable emission standard, and shall submit a report of such activities to the department when required by a permit condition or upon request by the department. Such reports shall state whether an exceedance occurred and if it was unavoidable, include the time, frequency and duration of the exceedance, and an estimate of the emission rates of any air contaminants released. Such records shall be maintained for a period of at least five years and made available for review to department representatives upon request. Facility owners or operators subject to continuous monitoring and quarterly reporting requirements need not submit additional reports of exceedances to the department.

(c) In the event that air contaminant emissions exceed any applicable emission standard due to a malfunction, the facility owner or operator shall notify the department as soon as possible during normal working hours, but not later than two working days after becoming aware that the malfunction occurred. In addition, the facility owner or operator shall compile and maintain a record of all malfunctions. Such records shall be maintained at the facility for a period of at least five years and must be made available to the department upon request. When requested by the department, the facility owner or operator shall submit a written report to the department describing the malfunction, the corrective action taken, the air contaminants emitted, and the resulting emission rates and/or opacity.

(d) The department may also require the facility owner or operator to include, in reports described under Subdivisions (b) and (c) of this Section, an estimate of the maximum ground level concentration of each air contaminant emitted and the effect of such emissions.

(e) A violation of any applicable emission standard resulting from start-up, shutdown, or malfunction conditions at a permitted or registered facility may not be subject to an enforcement action by the department and/or penalty if the department determines, in its sole discretion, that such a violation was unavoidable. The actions and recordkeeping and reporting requirements listed above must be adhered to in such circumstances.

Condition 1: Facility Permissible Emissions
Effective between the dates of 10/21/2026 and 10/20/2036

Applicable Federal Requirement:6 NYCRR Subpart 201-7

Item 1.1:
The sum of emissions from the emission units specified in this permit shall not equal or exceed the following
Potential To Emit (PTE) rate for each regulated contaminant:

CAS No: 000630-08-0 PTE: 27,575 pounds per year
Name: CARBON MONOXIDE

Condition 2: Capping Monitoring Condition
Effective between the dates of 10/21/2026 and 10/20/2036

Applicable Federal Requirement:6 NYCRR Subpart 201-7

Item 2.1:
Under the authority of 6 NYCRR Part 201-7, this condition contains an emission cap for the purpose of limiting emissions from the facility, emission unit or process to avoid being subject to the following applicable requirement(s) that the facility, emission unit or process would otherwise be subject to:

6 NYCRR 201-6.1 (a)

Item 2.2:
Operation of this facility shall take place in accordance with the approved criteria, emission limits, terms, conditions and standards in this permit.

Item 2.3:
The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

Item 2.4:
On an annual basis, unless otherwise specified below, beginning one year after the granting of an emissions cap, the responsible official shall provide a certification to the Department that the facility has operated all emission units within the limits imposed by the emission cap. This

certification shall include a brief summary of the emissions subject to the cap for that time period and a comparison to the threshold levels that would require compliance with an applicable requirement.

Item 2.5:
The emission of pollutants that exceed the applicability thresholds for an applicable requirement, for which the facility has obtained an emissions cap, constitutes a violation of Part 201 and of the Act.

Item 2.6:
The Compliance Demonstration activity will be performed for the Facility.

Regulated Contaminant(s):
CAS No: 000630-08-0 CARBON MONOXIDE

Item 2.7:
Compliance Demonstration shall include the following monitoring:

Capping: Yes
Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS
Monitoring Description:
Facility-wide emissions of CO will be capped below the major source threshold by limiting asphalt production to 200,000 tons per consecutive twelve (12) month period, rolled monthly. The facility's CO emissions shall be summed up each month for every 12-month rolling period and shall not exceed 27,575 pounds per year. The potential to emit (PTE) CO from exempt, trivial, and insignificant sources shall be included, along with the actual CO emissions from permitted sources, in these emissions.

The source owner or operator shall use the most accurate emission factors available (e.g., latest published AP-42 factor, manufacturer's guarantee, stack test data, etc.), for each emission source, to determine compliance with the emission cap.

Should the Department determine that the permittee's emission factor(s) is inadequate to demonstrate compliance with this condition, it shall provide written notice to the permittee stating the inadequacies, and permittee shall have 30 days to revise its respective records and emission factor(s) in a manner acceptable to the Department.

On an annual basis, the responsible official shall provide a certification to the Department that the facility has operated within the limit imposed by the facility's asphalt production cap and that their actual CO emissions do not exceed the specified amount. This compliance

activity caps the facility out of the Title V permitting requirements contained in 6 NYCRR Subpart 201-6. All of the records required to document compliance with the facility-wide emission cap above shall be maintained on-site for a period of at least five (5) years.

Work Practice Type: PROCESS MATERIAL THRUPUT
Process Material: ASPHALTIC CONCRETE
Upper Permit Limit: 200,000 tons per year
Monitoring Frequency: MONTHLY
Averaging Method: 12-MONTH TOTAL, ROLLED MONTHLY
Reporting Requirements: ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 1/30/2027.
Subsequent reports are due every 12 calendar month(s).

Condition 3: Visible Emissions Limited
Effective between the dates of 10/21/2026 and 10/20/2036

Applicable Federal Requirement:6 NYCRR 211.2

Item 3.1:
Except as permitted by a specific part of this Subchapter and for open fires for which a restricted burning permit has been issued, no person shall cause or allow any air contamination source to emit any material having an opacity equal to or greater than 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent opacity.

Condition 4: Compliance Demonstration
Effective between the dates of 10/21/2026 and 10/20/2036

Applicable Federal Requirement:6 NYCRR 220-3.3 (a)

Item 4.1:
The Compliance Demonstration activity will be performed for the Facility.

Item 4.2:
Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES
Monitoring Description:
Owners or operators of an Asphalt Mixture Manufacturing Plant shall record the following information once daily, as applicable, for each Asphalt Mixture Processing Unit during operation in a calendar year:

(1) Tons produced of asphalt mixture;
(2) RAP used in tons of material;
(3) Recorded hours of burner operation;
(4) Baghouse differential pressure;
(5) Warm mix tons produced;
(6) Amount of fuel consumed;

(7) Type of fuel consumed;
(8) Instantaneous visual stack opacity reading by a trained employee that fulfills the requirements of 40 CFR Part 60, Appendix A-4, Method 9;
(9) Typical stack temperature during operations;
(10) RAP moisture content; and
(11) Maintain annual records of Visible Emissions (Opacity) Training.

These records shall be maintained on site for at least two years after issuance of the permit and may be stored offsite (including electronic storage) afterwards for the life of the permit. Access to such offsite records must be made available in a timely manner if requested by the Department.

Monitoring Frequency: DAILY
Reporting Requirements: UPON REQUEST BY REGULATORY AGENCY

Condition 5: Compliance Demonstration
Effective between the dates of 10/21/2026 and 10/20/2036

Applicable Federal Requirement:6 NYCRR 220-3.3 (b)

Item 5.1:
The Compliance Demonstration activity will be performed for the Facility.

Item 5.2:
Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES
Monitoring Description:

As of the effective date of this Subpart, an annual service must be performed by a qualified employee or vendor on the dryer burner of any Asphalt Mixture Processing Unit that is in operation during that calendar year.

All annual service records shall be maintained on site for at least two years after issuance of the permit and may be stored offsite (including electronic storage) afterwards for the life of the permit. Access to such offsite records must be made available in a timely manner if requested by the Department.

Monitoring Frequency: ANNUALLY
Reporting Requirements: UPON REQUEST BY REGULATORY AGENCY

Condition 6: Compliance Demonstration
Effective between the dates of 10/21/2026 and 10/20/2036

Applicable Federal Requirement:6 NYCRR 220-3.3 (b)

Item 6.1:
The Compliance Demonstration activity will be performed for the Facility.

Item 6.2:
Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES
Monitoring Description:

The owner or operator shall:

(i) perform an annual visual inspection of baghouse tubesheet and internal structure. Record findings and any corrective actions.

(ii) replacement bags for the baghouse shall be kept on site with the minimum capability of at least a 20% bag change out. Record changed bag locations on baghouse tube map.

The owner or operator shall inspect all ductwork for leaks and perform needed maintenance prior to operating during the asphalt production season.

The owner or operator shall maintain annual records of baghouse and ductwork inspections.

All of these records shall be maintained on site for at least two years after issuance of the permit and may be stored offsite (including electronic storage) afterwards for the life of the permit. Access to such offsite records must be made available in a timely manner if requested by the Department.

Monitoring Frequency: ANNUALLY
Reporting Requirements: UPON REQUEST BY REGULATORY AGENCY

Condition 7: Compliance Demonstration
Effective between the dates of 10/21/2026 and 10/20/2036

Applicable Federal Requirement:6 NYCRR 220-3.3 (b)

Item 7.1:
The Compliance Demonstration activity will be performed for the Facility.

Item 7.2:
Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES
Monitoring Description:

As of the effective date of this Subpart, an annual tune-up must be performed by a qualified employee or

vendor on the hot oil heater located at any Asphalt Manufacturing Plant that is in operation during that calendar year.

All annual tune-up records shall be maintained on site for at least two years after issuance of the permit and may be stored offsite (including electronic storage) afterwards for the life of the permit. Access to such offsite records must be made available in a timely manner if requested by the Department.

Monitoring Frequency: ANNUALLY
Reporting Requirements: UPON REQUEST BY REGULATORY AGENCY

Condition 8: Filling of Asphalt Cement Storage Tanks.
Effective between the dates of 10/21/2026 and 10/20/2036

Applicable Federal Requirement:6 NYCRR 220-3.4

Item 8.1: The filling of asphalt cement storage tanks should be observed to prevent or mitigate potential spills by the delivery company and/or asphalt mixture manufacturing plant personnel.

Condition 9: Compliance Demonstration
Effective between the dates of 10/21/2026 and 10/20/2036

Applicable Federal Requirement:6 NYCRR 220-3.5 (b)

Item 9.1:
The Compliance Demonstration activity will be performed for the Facility.

Regulated Contaminant(s):
CAS No: 0NY075-00-0 PARTICULATES

Item 9.2:
Compliance Demonstration shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING
Monitoring Description:
The owner or operator of any existing aggregate dryer must submit, at least thirty (30) calendar days prior to commencing an emission test, a test protocol to the department for review and approval. The owner or operator must submit a complete test report to the department no later than sixty (60) calendar days after completion of the on-site testing.

Monitoring records stating the following information shall be maintained on site for at least two years after issuance of the permit and may be stored offsite

(including electronic storage) afterwards for the life of the permit. Access to such offsite records must be made available in a timely manner if requested by the department.

Parameter Monitored: PARTICULATES
Upper Permit Limit: 0.030 grains per dscf
Reference Test Method: Method 5 and Method 202
Monitoring Frequency: ONCE EVERY TEN YEARS
Averaging Method: 1-HOUR AVERAGE
Reporting Requirements: ONCE / BATCH OR MONITORING OCCURRENCE

Condition 10: Compliance Demonstration
Effective between the dates of 10/21/2026 and 10/20/2036

Applicable Federal Requirement:6 NYCRR 220-3.5 (b)

Item 10.1:
The Compliance Demonstration activity will be performed for the Facility.

Regulated Contaminant(s):
CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 10.2:
Compliance Demonstration shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING
Monitoring Description:
The owner or operator of any existing natural gas/propane fired aggregate dryer must submit, at least thirty (30) calendar days prior to commencing an emission test, a test protocol to the department for review and approval. The owner or operator must submit a complete test report to the department no later than sixty (60) calendar days after completion of the on-site testing.

Monitoring records stating the following information shall be maintained on site for at least two years after issuance of the permit and may be stored offsite (including electronic storage) afterwards for the life of the permit. Access to such offsite records must be made available in a timely manner if requested by the department.

Parameter Monitored: OXIDES OF NITROGEN
Upper Permit Limit: 0.096 pounds per million Btus
Reference Test Method: Method 7
Monitoring Frequency: ONCE EVERY TEN YEARS
Averaging Method: 1-HOUR AVERAGE
Reporting Requirements: ONCE / BATCH OR MONITORING OCCURRENCE

Condition 11: Compliance Demonstration

Effective between the dates of 10/21/2026 and 10/20/2036

Applicable Federal Requirement:6 NYCRR 220-3.6 (a)

Item 11.1:
The Compliance Demonstration activity will be performed for the Facility.

Item 11.2:
Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES
Monitoring Description:

The owner or operator of an existing Asphalt Mixture Processing Unit shall control emissions associated with the drag conveyor, and/or hot screens, pug mill, and asphalt storage silo filling operations. Emissions from these sources must be captured and can either be returned to the drum mixer, controlled with coalescing filters, or controlled with any other method acceptable and approved by the Department. Controls must be installed based on the production level of the Asphalt Mixture Processing Unit according to the following schedule:

(1) Calculated annual production level equal to or greater than 500,000 tpy of asphalt mixture, must comply by September 5, 2025.

(2) Calculated annual production level equal to or greater than 250,000 tpy but less than 500,000 tpy of asphalt mixture, must comply by September 5, 2027.

(3) Calculated annual production level equal to or greater than 75,000 tpy but less than 250,000 tpy of asphalt mixture, must comply by September 5, 2029.

Within 90 days of control installation, the owner or operator of the Asphalt Mixture Processing Unit shall submit a report to the Department stating the date of completed control installation.

The owner or operator of an existing Asphalt Mixture Processing Unit shall maintain and operate the control equipment based on manufacturer's specifications and retain records at the facility or at an alternative Department approved location, of control equipment maintenance. These records shall include, but are not limited to, the date and type of maintenance performed on the control equipment. These records shall be made available to the Department upon request.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 12: Compliance Demonstration
Effective between the dates of 10/21/2026 and 10/20/2036

Applicable Federal Requirement:6 NYCRR 220-3.7 (a)

Item 12.1:
The Compliance Demonstration activity will be performed for the Facility.

Item 12.2:
Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES
Monitoring Description:

The owner or operator of an existing Asphalt Mixture Processing Unit shall control emissions associated with the load-out process operations. Blue smoke emissions from these operations must be directed to a dedicated control device or controlled with any other method acceptable and approved by the Department. Controls must be installed based on the production level of the Asphalt Mixture Processing Unit according to the following schedule:

(1) Calculated annual production level equal to or greater than 500,000 tpy of asphalt mixture, must comply by September 5, 2025.

(2) Calculated annual production level equal to or greater than 250,000 tpy but less than 500,000 tpy of asphalt mixture, must comply by September 5, 2027.

(3) Calculated annual production level equal to or greater than 75,000 tpy but less than 250,000 tpy of asphalt mixture, must comply by September 5, 2029.

Within 90 days of control installation, the owner or operator of the Asphalt Mixture Processing Unit shall submit a report to the Department stating the date of completed control installation.

The owner or operator of an existing Asphalt Mixture Processing Unit shall maintain and operate the control equipment based on manufacturer's specifications and retain records at the facility or at an alternative Department approved location, of control equipment maintenance. These records shall include, but are not limited to, the date and type of maintenance performed on the control equipment. These records shall be made available to the Department upon request.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION
Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 13: Compliance Demonstration
Effective between the dates of 10/21/2026 and 10/20/2036

Applicable Federal Requirement:6 NYCRR 220-3.8

Item 13.1:
The Compliance Demonstration activity will be performed for the Facility.

Item 13.2:
Compliance Demonstration shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL DEVICE PARAMETERS AS SURROGATE
Monitoring Description:
No facility owner or operator shall cause or allow emissions to exceed an average opacity of 20 percent or greater during any six consecutive minutes from any process emission source or emission point.

Parameter Monitored: OPACITY
Upper Permit Limit: 20 percent
Reference Test Method: Method 9
Monitoring Frequency: ANNUALLY
Averaging Method: 6-MINUTE AVERAGE (METHOD 9)
Reporting Requirements: UPON REQUEST BY REGULATORY AGENCY

Condition 14: Compliance Demonstration
Effective between the dates of 10/21/2026 and 10/20/2036

Applicable Federal Requirement:6 NYCRR 220-3.9 (c)

Item 14.1:
The Compliance Demonstration activity will be performed for the Facility.

Item 14.2:
Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES
Monitoring Description:
The owner or operator shall conduct a burner tuning procedure in accordance with the manufacturer's specifications to minimize NOx and carbon monoxide (CO) emissions each calendar year.

The following information shall be monitored and recorded:

(i) the date of the tuning procedure;

(ii) the name of the servicing company/qualified internal staff/technician;
(iii) the production rate (tons/hr) or load before and after tuning;
(iv) the NOx and CO concentrations (ppmvd @ 3% O2) before and after tuning; and
(v) the percent O2 before and after tuning.

Records of this information shall be maintained on site for at least two years after issuance of the permit and may be stored offsite (including electronic storage) afterwards for the life of the permit. Access to such offsite records must be made available in a timely manner if requested by the Department.

Monitoring Frequency: ANNUALLY
Reporting Requirements: UPON REQUEST BY REGULATORY AGENCY

Condition 15: Minimization of Fugitive Dust Emissions.
Effective between the dates of 10/21/2026 and 10/20/2036

Applicable Federal Requirement:6 NYCRR 220-3.10

Item 15.1:

(a) Site Roadways and Plant Property:

(1) Dust on the site roadways and plant property shall be controlled by applications of water, calcium chloride or other acceptable and approved fugitive dust control compound. Application of dust suppressants shall be completed often enough to prevent dust emissions from leaving the plant property.
(2) All paved areas shall be swept and treated with water, as needed, to reduce dust.
(3) Any aggregate, RAP, or other materials used to manufacture asphalt mixture that is spilled on site roads shall be cleaned up to avoid tracking onto public roadways.
(4) The potential for dust to be tracked out to public roadways shall be minimized by implementing the procedures cited in paragraph (1) of this subdivision, along with any other reasonable procedure(s).

(b) Asphalt Mixture Processing Units:

(1) The drop distance at each location where asphalt is exposed to the air must be reduced to the minimum that the equipment can achieve and allow for proper operation to comply with the opacity requirements in section 220-3.8 of this Subpart.
(2) The transfer point where the belt feeder transfers aggregate or RAP from its bin onto a belt conveyor to the aggregate dryer shall be equipped, where it does not unreasonably interfere with production, with an enclosed chute, within 1 year of the effective date of this Subpart.

(c) Storage Piles. Stockpiling of all nonmetallic minerals shall be performed to minimize drop distance and control potential dust problems.

(d) Vehicles:

(1) Vehicles shall be loaded to prevent their contents from dropping, leaking, blowing or otherwise escaping.
(2) Trucks shall always be tarped unless loading and unloading.
(3) A speed limit sign of 15 miles-per-hour or lower shall apply to onsite traffic and be posted so that it is visible to truck operators.

(e) Fugitive Dust Corrective Actions. When corrective action needs to be taken, the permittee shall consider and use one or more of the following options: adjust the watering and/or sweeping frequencies, reduce drop distances, increase coverings, and/or take other appropriate actions to reduce fugitive dust emissions.

****** Emission Unit Level ******

Condition 16: Compliance Demonstration
Effective between the dates of 10/21/2026 and 10/20/2036

Applicable Federal Requirement:40CFR 60.92(a)(1), NSPS Subpart I

Item 16.1:
The Compliance Demonstration activity will be performed for:

Emission Unit: 1-ASPHP Emission Point: 00001

Regulated Contaminant(s):
CAS No: 0NY075-00-0 PARTICULATES

Item 16.2:
Compliance Demonstration shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING
Monitoring Description:
Emissions of solid particulates are limited to less than 0.04 (90 mg/dscm) grains of particulates per cubic foot of exhaust gas, expressed at standard conditions on a dry gas basis.

Parameter Monitored: PARTICULATES
Upper Permit Limit: 0.04 grains per dscf
Reference Test Method: EPA Method 5
Monitoring Frequency: SINGLE OCCURRENCE
Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST METHOD INDICATED
Reporting Requirements: ONCE / BATCH OR MONITORING OCCURRENCE

Condition 17: Compliance Demonstration
Effective between the dates of 10/21/2026 and 10/20/2036

Applicable Federal Requirement:40CFR 60.92(a)(2), NSPS Subpart I

Item 17.1:
The Compliance Demonstration activity will be performed for:

Emission Unit: 1-ASPHP Emission Point: 00001

Regulated Contaminant(s):
CAS No: 0NY075-00-0 PARTICULATES

Item 17.2:
Compliance Demonstration shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL DEVICE PARAMETERS AS SURROGATE
Monitoring Description:
No person shall cause or allow emissions having an average opacity during any six consecutive minutes of 20 percent or greater. The Department reserves the right to perform or require the performance of a Method 9 opacity evaluation

Parameter Monitored: OPACITY
Upper Permit Limit: 20 percent
Reference Test Method: EPA Method 9
Averaging Method: 6-MINUTE AVERAGE (METHOD 9)
Reporting Requirements: UPON REQUEST BY REGULATORY AGENCY

STATE ONLY ENFORCEABLE CONDITIONS
****** Facility Level ******

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS
This section contains terms and conditions which are not federally enforceable. Permittees may also have other obligations under regulations of general applicability

Item A: Emergency Defense - 6 NYCRR 201-1.5

An emergency, as defined in 6 NYCRR subpart 201-2, constitutes an affirmative defense to penalties sought in an enforcement action brought by the department for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

(a) The affirmative defense of emergency shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:

(1) an emergency occurred and that the facility owner or operator can identify the cause(s) of the emergency;
(2) the equipment at the facility was being properly operated and maintained;
(3) during the period of the emergency the facility owner or operator took all reasonable steps to minimize the levels of emissions that exceeded the emission standards, or other requirements in the permit; and
(4) the facility owner or operator notified the department within two working days after the event occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and any corrective actions taken.

(b) In any enforcement proceeding, the facility owner or operator seeking to establish the occurrence of an emergency has the burden of proof.

(c) This provision is in addition to any emergency or malfunction provision contained in any applicable requirement.

Item B: **Public Access to Recordkeeping for Facilities With State Facility Permits - 6 NYCRR 201-1.10 (a)**
Where facility owners and/or operators keep records pursuant to compliance with the requirements of 6 NYCRR Subpart 201-5.4, and/or the emission capping requirements of 6 NYCRR Subpart 201-7, the Department will make such records available to the public upon request in accordance

with 6 NYCRR Part 616 - Public Access to Records. Facility owners and/or operators must submit the records required to comply with the request within sixty working days of written notification by the Department.

Item C: **General Provisions for State Enforceable Permit Terms and Condition - 6 NYCRR Part 201-5**
Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all criteria, emission limits, terms, conditions, and standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

STATE ONLY APPLICABLE REQUIREMENTS
The following conditions are state only enforceable.

Condition 18: Contaminant List
Effective between the dates of 10/21/2026 and 10/20/2036

Applicable State Requirement:ECL 19-0301

Item 18.1:
Emissions of the following contaminants are subject to contaminant specific requirements in this permit(emission limits, control requirements or compliance monitoring conditions).

CAS No: 000630-08-0
Name: CARBON MONOXIDE

CAS No: 0NY075-00-0
Name: PARTICULATES

CAS No: 0NY210-00-0
Name: OXIDES OF NITROGEN

Condition 20: Emission Unit Definition
Effective between the dates of 10/21/2026 and 10/20/2036

Applicable State Requirement:6 NYCRR Subpart 201-5

Item 20.1:
The facility is authorized to perform regulated processes under this permit for:
Emission Unit: 1-ASPHP
Emission Unit Description:
200 TPH Hot mix asphalt plant with natural gas fired
rotary drum dryer.

Condition 21: Renewal deadlines for state facility permits
Effective between the dates of 10/21/2026 and 10/20/2036

Applicable State Requirement:6 NYCRR 201-5.2 (c)

Item 21.1:
The owner or operator of a facility having an issued state facility permit shall submit a complete application at least 180 days, but not more than eighteen months, prior to the date of permit expiration for permit renewal purposes.

Condition 22: Compliance Demonstration
Effective between the dates of 10/21/2026 and 10/20/2036

Applicable State Requirement:6 NYCRR 201-5.3 (c)

Item 22.1:
The Compliance Demonstration activity will be performed for the Facility.

Item 22.2:
Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES
Monitoring Description:
Any reports or submissions required by this permit shall
be submitted to the Regional Air Pollution Control
Engineer (RAPCE) at the following address:

Division of Air Resources
NYS Dept. of Environmental Conservation
Region 5
232 Golf Course Rd.
Warrensburg, NY 12885

Reporting Requirements: ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 1/30/2027.
Subsequent reports are due every 12 calendar month(s).

Condition 23: Air pollution prohibited

Effective between the dates of 10/21/2026 and 10/20/2036

Applicable State Requirement:6 NYCRR 211.1

Item 23.1:
No person shall cause or allow emissions of air contaminants to the outdoor atmosphere of such quantity, characteristic or duration which are injurious to human, plant or animal life or to property, or which unreasonably interfere with the comfortable enjoyment of life or property. Notwithstanding the existence of specific air quality standards or emission limits, this prohibition applies, but is not limited to, any particulate, fume, gas, mist, odor, smoke, vapor, pollen, toxic or deleterious emission, either alone or in combination with others.

****** Emission Unit Level ******

Condition 24: Emission Point Definition By Emission Unit
Effective between the dates of 10/21/2026 and 10/20/2036

Applicable State Requirement:6 NYCRR Subpart 201-5

Item 24.1:
The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: 1-ASPHP

Emission Point: 00001
Height (ft.): 21 Length (in.): 29 Width (in.): 38
NYTMN (km.): 4758.647 NYTME (km.): 594.123

Condition 25: Process Definition By Emission Unit
Effective between the dates of 10/21/2026 and 10/20/2036

Applicable State Requirement:6 NYCRR Subpart 201-5

Item 25.1:
This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: 1-ASPHP
Process: BTC Source Classification Code: 3-05-002-51
Process Description:
Hot mix asphalt plant exhausting to a fabric filter bafhouse. The rotary drum dryer utilizes natural gas as the sole fuel source.

Emission Source/Control: BAG01 - Control
Control Type: FABRIC FILTER

Emission Source/Control: BRN01 - Control
Control Type: LOW NOx BURNER

Emission Source/Control: DRM01 - Process