

## Division of Air Resources Permit Review Report

Permit ID: 2-6201-00005/00007

Renewal Number: 4

01/16/2026

### Facility Identification Data

Name: NEW YORK PRESBYTERIAN HOSPITAL

Address: 622 W 168TH ST

NEW YORK, NY 10032-3702

### Owner/Firm

Name: THE NEW YORK AND PRESBYTERIAN HOSPITAL

Address: 525 E 68TH ST

NEW YORK, NY 10065-4885, USA

Owner Classification: Corporation/Partnership

### Permit Contacts

Division of Environmental Permits:

Name: DENISE L GRATTAN

Address: 1 HUNTERS POINT PLAZA

47-40 21ST ST

LONG ISLAND CITY, NY 11101

Phone: 7184824997

Division of Air Resources:

Name: JUSTIN NG

Address: NYSDEC - REGION 2

47-40 21ST ST

LONG ISLAND CITY, NY 11101

Phone: 7184826428

Air Permitting Contact:

Name: EDO VOLARIC

Address: NEW YORK PRESBYTERIAN HOSPITAL

622 W 168TH ST

NEW YORK, NY 10032

Phone: 3052125606

### Permit Description Introduction

The Title V operating air permit is intended to be a document containing only enforceable terms and conditions as well as any additional information, such as the identification of emission units, emission points, emission sources and processes, that makes the terms meaningful. 40 CFR Part 70.7(a)(5) requires that each Title V permit have an accompanying "...statement that sets forth the legal and factual basis for the draft permit conditions". The purpose for this permit review report is to satisfy the above requirement by providing pertinent details regarding the permit/application data and permit conditions in a more easily understandable format. This report will also include background narrative and explanations of regulatory decisions made by the reviewer. It should be emphasized that this permit review report, while based on information contained in the permit, is a separate document and is not itself an enforceable term and condition of the permit.

### Summary Description of Proposed Project

Renewal of Air Title V permit. There are no changes proposed in this permit renewal.

Division of Air Resources  
 Permit Review Report

Permit ID: 2-6201-00005/00007

Renewal Number: 4

01/16/2026

The capping condition of 6 NYCRR 201-7.1 for SO<sub>2</sub> for 140.66 tpy has been removed from the permit since the facility's PTE emissions of SO<sub>2</sub> is only 3.83 tpy (7,660 lbs/yr) as result of the facility using #2 fuel oil (effective July 1, 2014) containing a maximum sulfur content of 15 ppm.

**Attainment Status**

NEW YORK PRESBYTERIAN HOSPITAL is located in the town of MANHATTAN in the county of NEW YORK.

The attainment status for this location is provided below. (Areas classified as attainment are those that meet all ambient air quality standards for a designated criteria air pollutant.)

Criteria Pollutant	Attainment Status
<hr/>	
Particulate Matter (PM)	ATTAINMENT
Particulate Matter< 10 $\mu$ in diameter (PM10)	MODERATE NON-ATTAINMENT
Sulfur Dioxide (SO <sub>2</sub> )	ATTAINMENT
Ozone*	SEVERE NON-ATTAINMENT
Oxides of Nitrogen (NO <sub>x</sub> )**	ATTAINMENT
Carbon Monoxide (CO)	ATTAINMENT

---

\* Ozone is regulated in terms of the emissions of volatile organic compounds (VOC) and/or oxides of nitrogen (NO<sub>x</sub>) which are ozone precursors.

\*\* NO<sub>x</sub> has a separate ambient air quality standard in addition to being an ozone precursor.

**Facility Description:**

New York Presbyterian Hospital (NYPH), located at 622 West 168th Street, New York, NY (Uptown Campus), operates a few emission sources that include four large size dual fuel boilers which burn natural gas and #2 distillate oil. Two of these four boilers are 150 MM Btu/hr Combustion Engineering installed on 1/1/1975, and the other two are 137.8 MM Btu/hr Babcock & Wilcox installed on 5/1/2005. This application is a renewal.

The NO<sub>x</sub> RACT limit for large boilers operating on gas/oil is 0.15 lb/MM Btus effective July 1, 2014. Each of the two 137.8 MM Btu/hr Babcock & Wilcox heat capacity boilers is low heat release rate. The two (2) 137.8mmbtu/hr boilers are subjected to 40 CFR 60 Subpart Db NO<sub>x</sub> Limit of 0.1 lb/mmbtu. The continuous monitoring of the NO<sub>x</sub> and opacity emission will continue to be monitored by CEMS.

In addition to the four boilers mentioned above, the facility also operates eight (8) diesel fired emergency generators, eighteen (18) water cooling towers, thirteen (13) fuel oil storage tanks and



**Division of Air Resources  
Permit Review Report**

**Permit ID: 2-6201-00005/00007**

**Renewal Number: 4**

**01/16/2026**

several fume hoods. Also, the Ethylene Oxide sterilizers and associated abator (Emission Unit U-00002) were removed on April 30, 2011.

The two emergency Caterpillar generators installed in 2008 are subjected to 40CFR60 Subpart III.

Capacities and Fuel Consumption from the Emergency Generators:

#	Equipment	Year Installed	Rating (KW)	Actual Usage (GPY)	Location
1	CAT 3516 Hosp Bldg	2000	1400	5,163	Basement, Milstein SN: 25Z00715
2	CAT 3516 Hosp Bldg	2000	1400	5,163	Basement, Milstein SN: 25Z00714
3	CAT 3516B Hosp Bldg	2000	2000	7,376	Basement, Milstein SN: B6HN00425
4	CAT 3156B	2003	2000	7,376	CHONY North SN: 1HZ02099
5	CAT 3156B	2003	2000	7,376	CHONY North SN: 1HZ02101
6	CAT 3512	2000	125	461	166th St. Garage

Division of Air Resources  
Permit Review Report

Permit ID: 2-6201-00005/00007

Renewal Number: 4

01/16/2026

SN: 83Z12599

7	CAT 3512	2008	1500	5,532	Roof, Milstein Hosp
	Bldg				

SN: EBG00278

8	CAT 3512	2008	1500	5,532	Roof, Milstein Hosp
	Bldg				

SN: EBG00279

**Permit Structure and Description of Operations**

The Title V permit for NEW YORK PRESBYTERIAN HOSPITAL

is structured in terms of the following hierarchy: facility, emission unit, emission point, emission source and process. A facility is defined as all emission sources located at one or more adjacent or contiguous properties owned or operated by the same person or persons under common control. The facility is subdivided into one or more emission units (EU). Emission units are defined as any part or activity of a stationary facility that emits or has the potential to emit any federal or state regulated air pollutant. An emission unit is represented as a grouping of processes (defined as any activity involving one or more emission sources (ES) that emits or has the potential to emit any federal or state regulated air pollutant). An emission source is defined as any apparatus, contrivance or machine capable of causing emissions of any air contaminant to the outdoor atmosphere, including any appurtenant exhaust system or air cleaning device. [NOTE: Indirect sources of air contamination as defined in 6 NYCRR Part 203 (i.e. parking lots) are excluded from this definition]. The applicant is required to identify the principal piece of equipment (i.e., emission source) that directly results in or controls the emission of federal or state regulated air pollutants from an activity (i.e., process). Emission sources are categorized by the following types:  
combustion - devices which burn fuel to generate heat, steam or power  
incinerator - devices which burn waste material for disposal  
control - emission control devices  
process - any device or contrivance which may emit air contaminants  
that is not included in the above categories.

NEW YORK PRESBYTERIAN HOSPITAL is defined by the following emission unit(s):



## Division of Air Resources Permit Review Report

Permit ID: 2-6201-00005/00007

Renewal Number: 4

01/16/2026

Emission unit U00001 - Emission Unit U-00001 consists of four large boilers. The two boilers are 150 MM Btu/hr (each) Combustion Engineering/VP-12W (Emission Sources 00004 & 00005) and the other two boilers are 137.8 MM Btu/hr (each) Babcock & Wilcox/FM-2566 (Emission Sources 00008 & S0009). Each of the two 137.8 MM Btu/hr Babcock & Wilcox boilers is a low heat release rate. All four boilers operate on natural gas (Process 001) and #2 fuel oil (Process 003).

The exhaust gases are discharged to the atmosphere via a common stack connected to the existing boilers, identified as Emission Point 00001.

All boilers are subjected to NOx RACT. Additionally, ES00008 and ES0009 are also subject to 40CFR60 Subpart Db.

Facility has CEMS units for ES 00008 and ES00009, which are connected to the duct before the common stack. Each emission source is monitored individually.

Emission unit U00001 is associated with the following emission points (EP):  
00001

Process: 001 is located at BASEMENT, Building HOSPITAL - Process 001 is the firing of natural gas in Boilers 004, 005, 008 & 009 (Emission Sources 00004, 00005, 00008 & S0009) in Emission Unit U-00001. The exhaust gases are discharged to the atmosphere via a common stack connected to the existing boilers, identified as Emission Point 00001.

Process: 003 is located at BASEMENT, Building HOSPITAL - Process 003 is when one or more of the four Boilers 004, 005, 008 & 009 (Emission Sources 00004, 00005, 00008 & S0009) in Emission Unit U-00001 fire #2 fuel oil that began on July 1st, 2014 (when the #6 fuel oil -Process 002 usage terminated) to generate steam for heating the hospital buildings. The exhaust gases are discharged to the atmosphere via a common stack connected to the existing boilers, identified as Emission Point 00001.

### Title V/Major Source Status

NEW YORK PRESBYTERIAN HOSPITAL is subject to Title V requirements. This determination is based on the following information:

New York Presbyterian Hospital is a major facility because the potential emissions of carbon monoxide

Division of Air Resources  
 Permit Review Report

Permit ID: 2-6201-00005/00007

Renewal Number: 4

01/16/2026

and nitrogen oxides are greater than the major source thresholds (100 tons/year for carbon monoxide and 25 tons per year for nitrogen oxides).

**Program Applicability**

The following chart summarizes the applicability of NEW YORK PRESBYTERIAN HOSPITAL with regards to the principal air pollution regulatory programs:

Regulatory Program	Applicability
PSD	NO
NSR (non-attainment)	NO
NESHAP (40 CFR Part 61)	NO
NESHAP (MACT - 40 CFR Part 63)	YES
NSPS	YES
TITLE IV	NO
TITLE V	YES
TITLE VI	NO
RACT	YES
SIP	YES

**NOTES:**

PSD Prevention of Significant Deterioration (40 CFR 52.21, 6 NYCRR 231-7, 231-8) - requirements which pertain to major stationary sources located in areas which are in attainment of National Ambient Air Quality Standards (NAAQS) for specified pollutants.

NSR New Source Review (6 NYCRR 231-5, 231-6) - requirements which pertain to major stationary sources located in areas which are in non-attainment of National Ambient Air Quality Standards (NAAQS) for specified pollutants.

NESHAP National Emission Standards for Hazardous Air Pollutants (40 CFR 61, 6 NYCRR 200.10) - contaminant and source specific emission standards established prior to the Clean Air Act Amendments of 1990 (CAA) which were developed for 9 air contaminants (inorganic arsenic, radon, benzene, vinyl chloride, asbestos, mercury, beryllium, radionuclides, and volatile HAP's).



## Division of Air Resources Permit Review Report

Permit ID: 2-6201-00005/00007

Renewal Number: 4

01/16/2026

**MACT** Maximum Achievable Control Technology (40 CFR 63, 6 NYCRR 200.10) - contaminant and source specific emission standards established by the 1990 CAAA. Under Section 112 of the CAAA, the US EPA is required to develop and promulgate emissions standards for new and existing sources. The standards are to be based on the best demonstrated control technology and practices in the regulated industry, otherwise known as MACT. The corresponding regulations apply to specific source types and contaminants.

**NSPS** New Source Performance Standards (40 CFR 60, 6 NYCRR 200.10) - standards of performance for specific stationary source categories developed by the US EPA under Section 111 of the CAAA. The standards apply only to those stationary sources which have been constructed or modified after the regulations have been proposed by publication in the Federal Register and only to the specific contaminant(s) listed in the regulation.

**Title IV Acid Rain Control Program** (40 CFR 72 thru 78, 6 NYCRR 201-6) - regulations which mandate the implementation of the acid rain control program for large stationary combustion facilities.

**Title VI Stratospheric Ozone Protection** (40 CFR 82, Subpart A thru G, 6 NYCRR 200.10) - federal requirements that apply to sources which use a minimum quantity of CFC's (chlorofluorocarbons), HCFC's (hydrofluorocarbons) or other ozone depleting substances or regulated substitute substances in equipment such as air conditioners, refrigeration equipment or motor vehicle air conditioners or appliances.

**RACT** Reasonably Available Control Technology (6 NYCRR Parts 212-3, 220-1.6, 220-1.7, 220-2.3, 220-2.4, 226, 227-2, 228, 229, 230, 233, 234, 235, 236) - the lowest emission limit that a specific source is capable of meeting by application of control technology that is reasonably available, considering technological and economic feasibility. RACT is a control strategy used to limit emissions of VOC's and NOx for the purpose of attaining the air quality standard for ozone. The term as it is used in the above table refers to those state air pollution control regulations which specifically regulate VOC and NOx emissions.

**SIP** State Implementation Plan (40 CFR 52, Subpart HH, 6 NYCRR 200.10) - as per the CAAA, all states are empowered and required to devise the specific combination of controls that, when implemented, will bring about attainment of ambient air quality standards established by the federal government and the individual state. This specific combination of measures is referred to as the SIP. The term here refers to those state regulations that are approved to be included in the SIP and thus are considered federally enforceable.

### Compliance Status

Facility is in compliance with all requirements.

### SIC Codes

SIC or Standard Industrial Classification code is an industrial code developed by the federal Office of Management and Budget for use, among other things, in the classification of establishments by the type of activity in which they are engaged. Each operating establishment is assigned an industry code on the basis of its primary activity, which is determined by its principal product or group of products produced or distributed, or services rendered. Larger facilities typically have more than one SIC code.

#### SIC Code

8062

#### Description

GENERAL MEDICAL & SURGICAL HOSPITALS



## Division of Air Resources Permit Review Report

Permit ID: 2-6201-00005/00007

Renewal Number: 4

01/16/2026

9999

NONCLASSIFIABLE ESTABLISHMENTS

### SCC Codes

SCC or Source Classification Code is a code developed and used" by the USEPA to categorize processes which result in air emissions for the purpose of assessing emission factor information. Each SCC represents a unique process or function within a source category logically associated with a point of air pollution emissions. Any operation that causes air pollution can be represented by one or more SCC's.

SCC Code	Description
1-02-005-01	EXTERNAL COMBUSTION BOILERS - INDUSTRIAL INDUSTRIAL BOILER - DISTILLATE OIL Grades 1 and 2 Oil
1-02-006-01	EXTERNAL COMBUSTION BOILERS - INDUSTRIAL INDUSTRIAL BOILER - NATURAL GAS Over 100 MBtu/Hr

### Facility Emissions Summary

In the following table, the CAS No. or Chemical Abstract Service code is an identifier assigned to every chemical compound. [NOTE: Certain CAS No.'s contain a 'NY' designation within them. These are not true CAS No.'s but rather an identification which has been developed by the department to identify groups of contaminants which ordinary CAS No.'s do not do. As an example, volatile organic compounds or VOC's are identified collectively by the NY CAS No. 0NY998-00-0.] The PTE refers to the Potential to Emit. This is defined as the maximum capacity of a facility or air contaminant source to emit any air contaminant under its physical and operational design. Any physical or operational limitation on the capacity of the facility or air contamination source to emit any air contaminant, including air pollution control equipment and/or restrictions on the hours of operation, or on the type or amount or material combusted, stored, or processed, shall be treated as part of the design only if the limitation is contained in federally enforceable permit conditions. The PTE for each contaminant that is displayed represents the facility-wide PTE in tons per year (tpy) or pounds per year (lbs/yr). In some instances the PTE represents a federally enforceable emissions cap or limitation for that contaminant. The term 'HAP' refers to any of the hazardous air pollutants listed in section 112(b) of the Clean Air Act Amendments of 1990. Total emissions of all hazardous air pollutants are listed under the special NY CAS No. 0NY100-00-0. In addition, each individual hazardous air pollutant is also listed under its own specific CAS No. and is identified in the list below by the (HAP) designation.

Cas No.	Contaminant	PTE lbs/yr	PTE tons/yr	Actual lbs/yr	Actual tons/yr
0NY750-00-0	CARBON	2246770000000		42981240000	
	DIOXIDE	00			
	EQUIVALENTS				
000630-08-0	CARBON	432400		212980	
	MONOXIDE				
007439-92-1	LEAD	60		3.2	
0NY210-00-0	OXIDES OF	346740		281200	
	NITROGEN				
0NY075-00-0	PARTICULATES	37000		10650	
0NY075-00-5	PM-10	37000		10650	
0NY075-02-5	PM-2.5	37000		10650	
007446-09-5	SULFUR	7700		1720	
	DIOXIDE				
0NY100-00-0	TOTAL HAP	3380		141.4	
0NY998-00-0	VOC	29000		13800	

Division of Air Resources  
Permit Review Report

Permit ID: 2-6201-00005/00007

Renewal Number: 4

01/16/2026

**NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS**

**Item A: Public Access to Recordkeeping for Title V Facilities - 6 NYCRR 201-1.10(b)**

The Department will make available to the public any permit application, compliance plan, permit, and monitoring and compliance certification report pursuant to Section 503(e) of the Act, except for information entitled to confidential treatment pursuant to 6 NYCRR Part 616 - Public Access to records and Section 114(c) of the Act.

**Item B: Timely Application for the Renewal of Title V Permits - 6 NYCRR Part 201-6.2(a)(4)**

Owners and/or operators of facilities having an issued Title V permit shall submit a complete application at least 180 days, but not more than eighteen months, prior to the date of permit expiration for permit renewal purposes.

**Item C: Certification by a Responsible Official - 6 NYCRR Part 201-6.2(d)(12)**

Any application, form, report or compliance certification required to be submitted pursuant to the federally enforceable portions of this permit shall contain a certification of truth, accuracy and completeness by a responsible official. This certification shall state that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

**Item D: Requirement to Comply With All Conditions - 6 NYCRR Part 201-6.4(a)(2)**

The permittee must comply with all conditions of the Title V facility permit. Any permit non-compliance constitutes a violation of the Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

**Item E: Permit Revocation, Modification, Reopening, Reissuance or Termination, and Associated Information Submission Requirements - 6 NYCRR Part 201-6.4(a)(3)**

This permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.

**Item F: Cessation or Reduction of Permitted Activity Not a Defense - 6 NYCRR 201-6.4(a)(5)**

It shall not be a defense for a permittee in an enforcement action to claim that a cessation or reduction in the permitted activity would have been necessary in order to maintain compliance with the conditions of this permit.

**Item G: Property Rights - 6 NYCRR 201-6.4(a)(6)**

This permit does not convey any property rights of any sort or any exclusive privilege.

**Item H: Severability - 6 NYCRR Part 201-6.4(a)(9)**

**Division of Air Resources**  
**Permit Review Report**

**Permit ID: 2-6201-00005/00007**

**Renewal Number: 4**

**01/16/2026**

If any provisions, parts or conditions of this permit are found to be invalid or are the subject of a challenge, the remainder of this permit shall continue to be valid.

**Item I: Permit Shield - 6 NYCRR Part 201-6.4(g)**

All permittees granted a Title V facility permit shall be covered under the protection of a permit shield, except as provided under 6 NYCRR Subpart 201-6. Compliance with the conditions of the permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that such applicable requirements are included and are specifically identified in the permit, or the Department, in acting on the permit application or revision, determines in writing that other requirements specifically identified are not applicable to the major stationary source, and the permit includes the determination or a concise summary thereof. Nothing herein shall preclude the Department from revising or revoking the permit pursuant to 6 NYCRR Part 621 or from exercising its summary abatement authority. Nothing in this permit shall alter or affect the following:

- i. The ability of the Department to seek to bring suit on behalf of the State of New York, or the Administrator to seek to bring suit on behalf of the United States, to immediately restrain any person causing or contributing to pollution presenting an imminent and substantial endangerment to public health, welfare or the environment to stop the emission of air pollutants causing or contributing to such pollution;
- ii. The liability of a permittee of the Title V facility for any violation of applicable requirements prior to or at the time of permit issuance;
- iii. The applicable requirements of Title IV of the Act;
- iv. The ability of the Department or the Administrator to obtain information from the permittee concerning the ability to enter, inspect and monitor the facility.

**Item J: Reopening for Cause - 6 NYCRR Part 201-6.4(i)**

This Title V permit shall be reopened and revised under any of the following circumstances:

- i. If additional applicable requirements under the Act become applicable where this permit's remaining term is three or more years, a reopening shall be completed not later than 18 months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which this permit is due to expire, unless the original permit or any of its terms and conditions has been extended by the Department pursuant to the provisions of Part 201-6.7 and Part 621.
- ii. The Department or the Administrator determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.
- iii. The Department or the Administrator determines that the Title V permit must be revised or reopened to assure compliance with applicable requirements.
- iv. If the permitted facility is an "affected source" subject to the requirements of Title IV of the Act, and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess

**Division of Air Resources  
Permit Review Report**

Permit ID: 2-6201-00005/00007

Renewal Number: 4

01/16/2026

emissions offset plans shall be deemed to be incorporated into the permit.

Proceedings to reopen and issue Title V facility permits shall follow the same procedures as apply to initial permit issuance but shall affect only those parts of the permit for which cause to reopen exists.

Reopenings shall not be initiated before a notice of such intent is provided to the facility by the Department at least thirty days in advance of the date that the permit is to be reopened, except that the Department may provide a shorter time period in the case of an emergency.

**Item K: Permit Exclusion - ECL 19-0305**

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York (NYCRR). The issuance of this permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.

**Item L: Federally Enforceable Requirements - 40 CFR 70.6(b)**

All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

**NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS**

**Item A: Emergency Defense - 6 NYCRR 201-1.5**

An emergency, as defined by subpart 201-2, constitutes an affirmative defense to penalties sought in an enforcement action brought by the Department for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

(a) The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:

- (1) An emergency occurred and that the facility owner or operator can identify the cause(s) of the emergency;
- (2) The equipment at the permitted facility causing the emergency was at the time being properly operated and maintained;
- (3) During the period of the emergency the facility owner or

**Division of Air Resources  
Permit Review Report**

**Permit ID: 2-6201-00005/00007**

**Renewal Number: 4**

**01/16/2026**

operator took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and

(4) The facility owner or operator notified the Department within two working days after the event occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

(b) In any enforcement proceeding, the facility owner or operator seeking to establish the occurrence of an emergency has the burden of proof.

(c) This provision is in addition to any emergency or upset provision contained in any applicable requirement. item\_02

**Item B: General Provisions for State Enforceable Permit Terms and Condition - 6  
NYCRR Part 201-5**

Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all criteria, emission limits, terms, conditions, and standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

**Regulatory Analysis**

<b>Location Facility/EU/EP/Process/ES</b>	<b>Regulation</b>	<b>Condition</b>	<b>Short Description</b>
-- FACILITY	ECL 19-0301	64	Powers and Duties of the Department with respect to air pollution control
U- 00001/00001/001/00008	40CFR 60-A	52	General provisions
U- 00001/00001/001/00008	40CFR 60-A.13	56	General provisions - Monitoring requirements
FACILITY	40CFR 60-A.13 (c)	37	General provisions - Monitoring requirements
FACILITY	40CFR 60-A.4	33	General provisions - Address
U- 00001/00001/001/00008	40CFR 60-A.7 (b)	53	Notification and Recordkeeping
U- 00001/00001/001/00008	40CFR 60-A.7 (d)	54	Notification and Recordkeeping

Division of Air Resources  
 Permit Review Report

Permit ID: 2-6201-00005/00007

Renewal Number: 4

01/16/2026

U-00001/00001/001/00008	40CFR 60-A.7(f)	55	Notification and Recordkeeping
FACILITY	40CFR 60-A.8(d)	34	Performance Tests
FACILITY	40CFR 60-A.8(e)	35	Performance Tests
FACILITY	40CFR 60-A.8(f)	36	Performance Tests
FACILITY	40CFR 60-Db.43b(f)	38	Standard for Particulate Matter Opacity.
U-00001/00001/003/00008	40CFR 60-Db.43b(g)	62	Standard for Particulate Matter Exemption.
U-00001	40CFR 60-Db.43b(h) (1)	47	Standard for particulates for facilities built after 2/28/05
U-00001	40CFR 60-Db.44b(a) (1)	48	Standard for Nitrogen Oxides Firing Natural Gas and Distillate Oil. (see narrative)
U-00001/00001/001/00008	40CFR 60-Db.44b(h)	57	Standards for Nitrogen Oxides Provisions.
U-00001/00001	40CFR 60-Db.44b(i)	51	Averaging Period.
U-00001	40CFR 60-Db.45b(j)	49	Compliance and Performance Test Methods and Procedures for Sulfur Dioxide.
FACILITY	40CFR 60-Db.48b(a)	39	Emissions Monitoring for Particulate Matter and Nitrogen Oxides.
U-00001/00001/001/S0009	40CFR 60-Db.48b(f)	61	Emission Monitoring for Particulate Matter and Nitrogen Oxides.
U-00001/00001/001/00008	40CFR 60-Db.49b(g)	58	Reporting and Recordkeeping Requirements.
U-00001/00001/001/00008	40CFR 60-Db.49b(h)	59	Reporting and Recordkeeping Requirements.
U-00001/00001/001/00008	40CFR 60-Db.49b(i)	60	Reporting and Recordkeeping Requirements.
U-00001/00001/003/00008	40CFR 60-Db.49b(r)	63	Reporting and Recordkeeping Requirements.
FACILITY	40CFR 60-III	40	Standards of Performance for Stationary Compression Ignition Internal Combustion Engines
FACILITY	40CFR 63-JJJJJ	41	National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers Area Sources
FACILITY	40CFR 63-ZZZZ	42, 43	Reciprocating Internal Combustion Engine (RICE) NESHAP

Division of Air Resources  
 Permit Review Report

Permit ID: 2-6201-00005/00007

Renewal Number: 4

01/16/2026

FACILITY	40CFR 68	18	Chemical accident prevention provisions
FACILITY	40CFR 82-F	19	Protection of Stratospheric Ozone - recycling and emissions reduction
FACILITY	6NYCRR 200.6	1	Acceptable ambient air quality.
FACILITY	6NYCRR 200.7	9	Maintenance of equipment.
FACILITY	6NYCRR 201-1.4	65	Unavoidable noncompliance and violations
FACILITY	6NYCRR 201-1.7	10	Recycling and Salvage
FACILITY	6NYCRR 201-1.8	11	Prohibition of reintroduction of collected contaminants to the air
FACILITY	6NYCRR 201-3.2(a)	12	Exempt Activities - Proof of eligibility
FACILITY	6NYCRR 201-3.3(a)	13	Trivial Activities - proof of eligibility
FACILITY	6NYCRR 201-6	20, 44, 45	Title V Permits and the Associated Permit Conditions
FACILITY	6NYCRR 201-6.4(a) (4)	14	General Conditions - Requirement to Provide Information
FACILITY	6NYCRR 201-6.4(a) (7)	2	General Conditions - Fees
FACILITY	6NYCRR 201-6.4(a) (8)	15	General Conditions - Right to Inspect
FACILITY	6NYCRR 201-6.4(c)	3	Recordkeeping and Reporting of
FACILITY	6NYCRR 201-6.4(c) (2)	4	Compliance Monitoring
FACILITY	6NYCRR 201-6.4- 6.4(c) (3) (ii)	5	Records of Monitoring, Sampling and Measurement
FACILITY	6NYCRR 201-6.4(d) (4)	21	Reporting Requirements - Deviations and Noncompliance
FACILITY	6NYCRR 201-6.4(e)	6	Compliance Schedules - Progress Reports
FACILITY	6NYCRR 201-6.4(f)	22	Compliance Certification
FACILITY	6NYCRR 201-7.1	23	Operational Flexibility
FACILITY	6NYCRR 202-1.1	16, 17	Emission Capping in Facility Permits
FACILITY	6NYCRR 202-2.4(a) (3)	25	Required emissions tests.
FACILITY	6NYCRR 202-2.5	7	Emission statement methods and procedures
FACILITY	6NYCRR 211.1	66	Emission Statements - record keeping requirements.
FACILITY	6NYCRR 211.2	26	General Prohibitions - air pollution prohibited
			General Prohibitions - visible emissions limited.

**Division of Air Resources  
Permit Review Report**

**Permit ID: 2-6201-00005/00007**

**Renewal Number: 4**

**01/16/2026**

FACILITY	6NYCRR 215.2	8	Open Fires - Prohibitions
FACILITY	6NYCRR 225-1.2 (d)	27	Sulfur-in-Fuel Limitation - Distillate Oil
FACILITY	6NYCRR 225-1.6 (f)	28	Excess Emission Reports
FACILITY	6NYCRR 227-1.3 (a)	29	Particulate Emission Standards
FACILITY	6NYCRR 227-1.3 (c)	30	Annual Tune-up Requirement
U-00001/00001	6NYCRR 227-1.4 (a)	50	Opacity Standard
FACILITY	6NYCRR 227-1.5 (b) (2)	31	Excess Emissions & Monitoring System Reports
U-00001	6NYCRR 227-2.4 (b) (1)	46	Emission limits.
FACILITY	6NYCRR 227-2.6 (b)	32	CEMS requirements

**Applicability Discussion:**

Mandatory Requirements: The following facility-wide regulations are included in all Title V permits:

**ECL 19-0301**

This section of the Environmental Conservation Law establishes the powers and duties assigned to the Department with regard to administering the air pollution control program for New York State.

**6 NYCRR 200.6**

Acceptable ambient air quality - prohibits contravention of ambient air quality standards without mitigating measures

**6 NYCRR 200.7**

Anyone owning or operating an air contamination source which is equipped with an emission control device must operate the control consistent with ordinary and necessary practices, standards and procedures, as per manufacturer's specifications and keep it in a satisfactory state of maintenance and repair so that it operates effectively

**6 NYCRR 201-1.4**

This regulation specifies the actions and recordkeeping and reporting requirements for any violation of an applicable state enforceable emission standard that results from a necessary scheduled equipment maintenance, start-up, shutdown, malfunction or upset in the event that these are unavoidable.

**6 NYCRR 201-1.7**

Requires the recycle and salvage of collected air contaminants where practical

**6 NYCRR 201-1.8**

Prohibits the reintroduction of collected air contaminants to the outside air

**6 NYCRR 201-3.2 (a)**

An owner and/or operator of an exempt emission source or unit may be required to certify that it operates within the specific criteria described in this Subpart. All required records must be maintained on-site for a period of 5 years and made available to department representatives upon request. In addition, department representatives must be granted access to any facility which contains exempt emission sources or units, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

Division of Air Resources  
Permit Review Report

Permit ID: 2-6201-00005/00007

Renewal Number: 4

01/16/2026

6 NYCRR 201-3.3 (a)

The owner and/or operator of a trivial emission source or unit may be required to certify that it operates within the specific criteria described in this Subpart. All required records must be maintained on-site for a period of 5 years and made available to department representatives upon request. In addition, department representatives must be granted access to any facility which contains trivial emission sources or units subject to this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

6 NYCRR Subpart 201-6

This regulation applies to those terms and conditions which are subject to Title V permitting. It establishes the applicability criteria for Title V permits, the information to be included in all Title V permit applications as well as the permit content and terms of permit issuance. This rule also specifies the compliance, monitoring, recordkeeping, reporting, fee, and procedural requirements that need to be met to obtain a Title V permit, modify the permit and demonstrate conformity with applicable requirements as listed in the Title V permit. For permitting purposes, this rule specifies the need to identify and describe all emission units, processes and products in the permit application as well as providing the Department the authority to include this and any other information that it deems necessary to determine the compliance status of the facility.

6 NYCRR 201-6.4 (a) (4)

This mandatory requirement applies to all Title V facilities. It requires the permittee to provide information that the Department may request in writing, within a reasonable time, in order to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. The request may include copies of records required to be kept by the permit.

6 NYCRR 201-6.4 (a) (7)

This is a mandatory condition that requires the owner or operator of a facility subject to Title V requirements to pay all applicable fees associated with the emissions from their facility.

6 NYCRR 201-6.4 (a) (8)

This is a mandatory condition for all facilities subject to Title V requirements. It allows the Department to inspect the facility to determine compliance with this permit, including copying records, sampling and monitoring, as necessary.

6 NYCRR 201-6.4 (c)

This requirement specifies, in general terms, what information must be contained in any required compliance monitoring records and reports. This includes the date, time and place of any sampling, measurements and analyses; who performed the analyses; analytical techniques and methods used as well as any required QA/QC procedures; results of the analyses; the operating conditions at the time of sampling or measurement and the identification of any permit deviations. All such reports must also be certified by the designated responsible official of the facility.

6 NYCRR 201-6.4 (c) (2)

This requirement specifies that all compliance monitoring and recordkeeping is to be conducted according to the terms and conditions of the permit and follow all QA requirements found in applicable regulations. It also requires monitoring records and supporting information to be retained for at least 5 years from the time of sampling, measurement, report or application. Support information is defined as including all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit.

6 NYCRR 201-6.4 (c) (3) (ii)

## Division of Air Resources Permit Review Report

Permit ID: 2-6201-00005/00007

Renewal Number: 4

01/16/2026

This regulation specifies any reporting requirements incorporated into the permit must include provisions regarding the notification and reporting of permit deviations and incidences of noncompliance stating the probable cause of such deviations, and any corrective actions or preventive measures taken.

### 6 NYCRR 201-6.4 (d) (4)

This condition applies to every Title V facility subject to a compliance schedule. It requires that reports, detailing the status of progress on achieving compliance with emission standards, be submitted semiannually.

### 6 NYCRR 201-6.4 (e)

Sets forth the general requirements for compliance certification content; specifies an annual submittal frequency; and identifies the EPA and appropriate regional office address where the reports are to be sent.

### 6 NYCRR 202-1.1

This regulation allows the department the discretion to require an emission test for the purpose of determining compliance. Furthermore, the cost of the test, including the preparation of the report are to be borne by the owner/operator of the source.

### 6 NYCRR 202-2.5

This rule specifies that each facility required to submit an emission statement must retain a copy of the statement and supporting documentation for at least 5 years and must make the information available to department representatives.

### 6 NYCRR 211.2

This regulation limits opacity from sources to less than or equal to 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent opacity.

### 6 NYCRR 215.2

Except as allowed by section 215.3 of 6 NYCRR Part 215, no person shall burn, cause, suffer, allow or permit the burning of any materials in an open fire.

### 40 CFR Part 68

This Part lists the regulated substances and their applicability thresholds and sets the requirements for stationary sources concerning the prevention of accidental releases of these substances.

### 40 CFR Part 82, Subpart F

Subpart F requires the reduction of emissions of class I and class II refrigerants to the lowest achievable level during the service, maintenance, repair, and disposal of appliances in accordance with section 608 of the Clean Air Act Amendments of 1990. This subpart applies to any person servicing, maintaining, or repairing appliances except for motor vehicle air conditioners. It also applies to persons disposing of appliances, including motor vehicle air conditioners, refrigerant reclaimers, appliance owners, and manufacturers of appliances and recycling and recovery equipment. Those individuals, operations, or activities affected by this rule, may be required to comply with specified disposal, recycling, or recovery practices, leak repair practices, recordkeeping and/or technician certification requirements.

### **Facility Specific Requirements**

In addition to Title V, NEW YORK PRESBYTERIAN HOSPITAL has been determined to be subject to the following regulations:

40 CFR 60.13

**Division of Air Resources  
Permit Review Report**

**Permit ID: 2-6201-00005/00007**

**Renewal Number: 4**

**01/16/2026**

This regulation specifies how monitoring shall be performed and which methods and appendices are used to determine if the monitoring is adequate and in compliance with the regulated standards.

**40 CFR 60.13 (c)**

This regulation specifies how monitoring shall be performed and which methods and appendices are used to determine if the monitoring is adequate and in compliance with the regulated standards.

**40 CFR 60.4**

This condition lists the USEPA Region 2 address for the submittal of all communications to the "Administrator". In addition, all such communications must be copied to NYSDEC Bureau of Quality Assurance (BQA).

**40 CFR 60.43b (f)**

This regulation specifies maximum allowable opacity for affected affected sources. The opacity of the emission may not exceed 20%, except for one six minute period when the maximum opacity may not exceed 27%.

**40 CFR 60.43b (g)**

This regulation specifies that the particulate matter and opacity standards apply at all times, except during periods of startup, shutdown or malfunction.

**40 CFR 60.43b (h) (1)**

The regulation requires that facilities built after February 28, 2005 limit the emissions of particulates to less than 0.030 pounds of particulates per million BTU heat input.

**40 CFR 60.44b (a) (1)**

These standards apply to all boilers firing natural gas and/or distillate oil except as provided in 40 CFR 60.44b(a)(4) Duct Burners Used in a Comdined Cycle System.

**40 CFR 60.44b (h)**

This regulation specifies that the NSPS nitrogen oxide standards apply at all time including periods of startup, shutdown, or malfunction.

**40 CFR 60.44b (i)**

This subdivision requires that the facility use a 30 day rolling average to determine compliance with any applicable standards in this Subpart.

**40 CFR 60.45b (j)**

This regulation specifies that owner or operators that combust very low sulfur oil are not subject to compliance and performance testing requirements for Sulfur Dioxide if they obtain fuel receipts as described in 40 CFR 60.49b(r)

**Division of Air Resources**  
**Permit Review Report**

**Permit ID: 2-6201-00005/00007**

**Renewal Number: 4**

**01/16/2026**

**40 CFR 60.48b (a)**

This subdivision requires the installation of a continuous opacity monitor.

**40 CFR 60.48b (f)**

This regulation requires that standby methods of obtaining minimum emissions data for oxides of nitrogen be specified by the source owner or operator.

**40 CFR 60.49b (g)**

This subdivision requires reporting and recordkeeping for affected steam generating units - specific oxides of nitrogen requirements.

**40 CFR 60.49b (h)**

This subdivision specifies that the facility must submit excess emission reports.

**40 CFR 60.49b (i)**

This subdivision specifies that the facility submit reports on oxides of nitrogen emissions in accordance with the required recordkeeping provisions of 40 CFR 60.49b(g).

**40 CFR 60.49b (r)**

This regulation specifies that owner or operators that combust very low sulfur oil are required to obtain fuel receipts. The oil need not meet the fuel nitrogen content specification in the definition of distillate oil. Reports shall be submitted to the Administrator certifying that only very low sulfur oil meeting this definition was combusted

**40 CFR 60.7 (b)**

This regulation requires the owner or operator to maintain records of the occurrence and duration of any startup, shutdown, or malfunction of the source or control equipment or continuous monitoring system.

**40 CFR 60.7 (d)**

This condition specifies the required information and format for a summary report form and details when either a summary form and/or excess emissions reports are required.

**40 CFR 60.7 (f)**

This condition specifies requirements for maintenance of files of all measurements, including continuous monitoring system (CMS), monitoring device, and performance testing measurements; all CMS performance evaluations; all CMS or monitoring device calibration checks; adjustments and maintenance performed on these systems or devices for at least two years.

**40 CFR 60.8 (d)**

This regulation contains the requirements for advance notification of Performance (stack) testing.

## Division of Air Resources Permit Review Report

Permit ID: 2-6201-00005/00007

Renewal Number: 4

01/16/2026

### 40 CFR 60.8 (e)

This regulation requires the facility to provide appropriate sampling ports, safe platforms and utilities as necessary for Performance (stack) testing.

### 40 CFR 60.8 (f)

This regulation requires that Performance (stack) tests consist of three runs unless otherwise specified. The rule also designates the allowable averaging methods for the analysis of the results.

### 40 CFR Part 60, Subpart A

This regulation contains the General Provisions of 40 CFR 60. The facility owner is responsible for reviewing these general provisions in detail and complying with all applicable technical, administrative and reporting requirements

### 40 CFR Part 60, Subpart III

Subpart III applies to new and reconstructed compression ignition reciprocating internal combustion engines. Sources subject to Subpart III must comply with emission standards for hydrocarbons, nitrogen oxides, carbon monoxide, and particulate matter.

### 40 CFR Part 63, Subpart JJJJJ

This regulation covers facilities that own or operate an industrial, commercial, or institutional boiler as defined in §63.11237 that is located at, or is part of, an area source of hazardous air pollutants (HAP), as defined in §63.2, except as specified in §63.11195.

### 40 CFR Part 63, Subpart ZZZZ

Subpart ZZZZ applies to reciprocating internal combustion engines. Sources subject to Subpart ZZZZ must limit emissions of carbon monoxide and formaldehyde. Sources must also comply with work practice standards and operating limits.

### 6 NYCRR 201-6.4 (f)

This section describes the potential for certain operational changes to be made by the facility owner or operator without first obtaining a permit modification. Changes made pursuant to this provision must meet all of the criteria described in this section to qualify for consideration as operational flexibility. The Department reserves the right to require the facility owner or operator to obtain a permit modification prior to making any changes at the facility pursuant to this section.

### 6 NYCRR 201-7.1

This section of Part 201-7 specifies the criteria that need to be met in order to restrict emissions to avoid Title V or other applicable requirements using federally enforceable permit conditions permit.

**Division of Air Resources**  
**Permit Review Report**

**Permit ID: 2-6201-00005/00007**

**Renewal Number: 4**

**01/16/2026**

**6 NYCRR 202-2.4 (a) (3)**

Once a facility is required to submit annual emission statements electronically, emission statements must be submitted to the department per the specified schedule, in this regulation beginning the reporting year that a Title V permit containing a condition mandating electronic submittal is issued.

**6 NYCRR 211.1**

This regulation requires that no person shall cause or allow emissions of air contaminants to the outdoor atmosphere of such quantity, characteristic or duration which are injurious to human, plant or animal life or to property, or which unreasonably interfere with the comfortable enjoyment of life or property.

**6 NYCRR 225-1.2 (d)**

This subdivision sets the sulfur-in-fuel limitation for distillate oil fired emission sources throughout the State.

**6 NYCRR 225-1.6 (f)**

This subdivision requires the submission of excess emission reports when the sulfur-in-fuel limitation, equivalent emission rate, or measured emissions exceeds the allowable standard.

**6 NYCRR 227-1.3 (a)**

This subdivision sets the particulate matter emission standards for subject stationary combustion installations.

**6 NYCRR 227-1.3 (c)**

This subdivision requires that all stationary combustion installations subject to this subpart perform an annual tune-up.

**6 NYCRR 227-1.4 (a)**

This subdivision sets the opacity standard for subject stationary combustion installations.

**6 NYCRR 227-1.5 (b) (2)**

This paragraph contains the excess emissions and monitoring system reporting requirements for emission sources required to utilize a continuous opacity monitor.

Division of Air Resources  
 Permit Review Report

Permit ID: 2-6201-00005/00007

Renewal Number: 4

01/16/2026

6 NYCRR 227-2.4 (b) (1)

NOx emission limits for large boilers.

6 NYCRR 227-2.6 (b)

Any owner or operator of a combustion source subject to reasonably available control technology (RACT) requirements, under this subdivision, for NOx and either is required or opts to employ a continuous emissions monitoring system (CEMS) must:

- 1) Submit a CEMS monitoring plan for approval by the Department,
- 2) Submit a CEMS certification protocol,
- 3) Meet CEMS monitoring requirements as detailed in this paragraph of this subdivision, and
- 4) Meet CEMS recordkeeping and reporting requirements as detailed in this paragraph of this subdivision.

**Compliance Certification**
**Summary of monitoring activities at NEW YORK PRESBYTERIAN HOSPITAL:**

Location Facility/EU/EP/Process/ES	Cond No.	Type of Monitoring
FACILITY	37	record keeping/maintenance procedures
FACILITY	38	monitoring of process or control device parameters as surrogate
U-00001	47	intermittent emission testing
U-00001	48	continuous emission monitoring (cem)
U-00001	49	record keeping/maintenance procedures
FACILITY	39	monitoring of process or control device parameters as surrogate
U-00001/00001/001/00008	58	record keeping/maintenance procedures
U-00001/00001/001/00008	59	record keeping/maintenance procedures
U-00001/00001/001/00008	60	record keeping/maintenance procedures
U-00001/00001/003/00008	63	record keeping/maintenance procedures
FACILITY	4	record keeping/maintenance procedures
FACILITY	5	record keeping/maintenance procedures
FACILITY	6	record keeping/maintenance procedures
FACILITY	24	work practice involving specific operations
FACILITY	27	work practice involving specific operations
FACILITY	28	record keeping/maintenance procedures
FACILITY	29	record keeping/maintenance procedures
FACILITY	30	record keeping/maintenance procedures
U-00001/00001	50	monitoring of process or control device parameters as surrogate
FACILITY	31	record keeping/maintenance procedures
U-00001	46	intermittent emission testing
FACILITY	32	record keeping/maintenance procedures

**Division of Air Resources  
Permit Review Report**

**Permit ID: 2-6201-00005/00007**

**Renewal Number: 4**

**01/16/2026**

**Basis for Monitoring**

6 NYCRR 201-7, This is a facility-wide condition. This condition limits the NOx emissions to 174.64 tpy for all emission sources at the facility in order not to trigger NSR (New Source Review). The facility will use the emission factors from their most recent stack test results or the latest stack testing for ES0004 & ES00005. For ES 0008 & ES 0009, the facility will use CEMS.

NOx RACT limit is set to 0.15 lbs/MM Btus as per 6 NYCRR 227-2.4 for all four large boilers, but for Emission Sources 00008 & S0009, the more stringent 40 CFR 60 Subpart Db NOx emission limit of 0.1 lb/mmbtu are applicable. All boilers emit to one emission point and ES 0008 & ES 0009 have continuous monitoring of the NOx emission by CEMS.

6NYCRR 225-1.2 (d) 0.0015% by weight of sulfur content limit is verified through fuel vendor receipts for each delivery.

6NYCRR Part 227-1.3(a); Particulate limit is 0.1 lb/mmbtu is also verified through fuel vendor receipts. These limits are applicable for all four boilers except for the two large boilers after 2005, where 40CFR60 Subpart Db Particulates limit is set at 0.03 lb/mmbtu. (Emission Sources 00008 & S0009). Stack test to be performed once every 5 years.

6NYCRR Part 227-1.4, all boilers emit to emission point 00001 and opacity is monitored by using a continuous opacity monitoring system(COMS).

SO2 capping condition of 140.66 tpy are removed from this permit since the facility's SO2 PTE is only 3.85 tpy (7,700 lbs/yr) since the facility switched from # 6 fuel oil to # 2 fuel oil (effective July 1, 2014) with the maximum sulfur content in the ULSD of 15 ppm.

NYCRR Part 201-6.5(a): Pursuant to the requirements of Section 7(2) and 7(3) of the Climate Leadership and Community Protection Act (CLCPA), the Department has requested and received information regarding the Project's emissions with CLCPA analysis.

40 CFR Part 60 Subpart IIII: The two 1500 KW caterpillar emergency engines installed 2008 are subject to this regulation. The facility has submitted a US EPA issued Certificate of Conformity

40 CFR Part 63 Subpart ZZZZ: The emergency engines are subject to this regulation. The two 1500 KW Caterpillar emergency engines are applicable to the requirements of 40 CFR 60 Subpart IIII and thus satisfies the requirements of Subpart ZZZZ.