

**Division of Air Resources
Permit Review Report**

Permit ID: 2-6307-00290/00001
Renewal Number: 4
03/27/2025

Facility Identification Data

Name: LONG ISLAND JEWISH MEDICAL CENTER
Address: 270-05 76TH AVE
NEW HYDE PARK, NY 11040

Owner/Firm

Name: LONG ISLAND JEWISH MEDICAL CENTER
Address: 270-05 76th Ave
NEW HYDE PARK, NY 11040-1433, USA
Owner Classification: Corporation/Partnership

Permit Contacts

Division of Environmental Permits:
Name: LISA E HORWITZ
Address: NYSDEC - Region 2
47-40 21st St
Long Island City, NY 11101-5401
Phone: 7184824997

Division of Air Resources:
Name: PARESH SHAH
Address: NYSDEC - REGION 2
47-40 21ST ST
LONG ISLAND CITY, NY 11101

Air Permitting Facility Owner Contact:
Name: Manuel Sanchez
Address: Long Island Jewish Medical Center
270-05 76th Ave
New Hyde Park, NY 11040
Phone: 7184707484

**Permit Description
Introduction**

The Title V operating air permit is intended to be a document containing only enforceable terms and conditions as well as any additional information, such as the identification of emission units, emission points, emission sources and processes, that makes the terms meaningful. 40 CFR Part 70.7(a)(5) requires that each Title V permit have an accompanying "...statement that sets forth the legal and factual basis for the draft permit conditions". The purpose for this permit review report is to satisfy the above requirement by providing pertinent details regarding the permit/application data and permit conditions in a more easily understandable format. This report will also include background narrative and explanations of regulatory decisions made by the reviewer. It should be emphasized that this permit review report, while based on information contained in the permit, is a separate document and is not itself an enforceable term and condition of the permit.

Summary Description of Proposed Project

Application for renewal of Air Title V Facility.

Attainment Status

LONG ISLAND JEWISH MEDICAL CENTER is located in the town of QUEENS in the county of

**Division of Air Resources
Permit Review Report**

Permit ID: 2-6307-00290/00001
Renewal Number: 4
03/27/2025

QUEENS.

The attainment status for this location is provided below. (Areas classified as attainment are those that meet all ambient air quality standards for a designated criteria air pollutant.)

Criteria Pollutant	Attainment Status
Particulate Matter (PM)	ATTAINMENT
Particulate Matter < 10µ in diameter (PM10)	ATTAINMENT
Sulfur Dioxide (SO2)	ATTAINMENT
Ozone*	SEVERE NON-ATTAINMENT
Oxides of Nitrogen (NOx)**	ATTAINMENT
Carbon Monoxide (CO)	ATTAINMENT

* Ozone is regulated in terms of the emissions of volatile organic compounds (VOC) and/or oxides of nitrogen (NOx) which are ozone precursors.

** NOx has a separate ambient air quality standard in addition to being an ozone precursor.

Facility Description:

The facility is a hospital associated with the Northwell Health System - LIJ. The hospital operates three (3) dual fired boilers each rated at 63 mmBTU/hr, burning #2 fuel oil and natural gas, two cogen units rated at 12.219 mmbtu/hr (1.4 MW) burning natural gas, a dual use generator (emergency power back up engine) and seven (7) emergency generators burning fuel oil and Nine (9) exempt boilers and a water heater. Note: Exempt boilers are located within the Main Staff, Lowenstein, Littauer, Conference Center, Health & Speech, Sloman & Generator Bldgs. Littauer (Zucker Hillside) has three exempt boilers and 1 water heater.

Permit Structure and Description of Operations

The Title V permit for LONG ISLAND JEWISH MEDICAL CENTER is structured in terms of the following hierarchy: facility, emission unit, emission point, emission source and process. A facility is defined as all emission sources located at one or more adjacent or contiguous properties owned or operated by the same person or persons under common control. The facility is subdivided into one or more emission units (EU). Emission units are defined as any part or activity of a stationary facility that emits or has the potential to emit any federal or state regulated air pollutant. An emission unit is represented as a grouping of processes (defined as any activity involving one or more emission sources (ES) that emits or has the potential to emit any federal or state regulated air pollutant). An emission source is defined as any apparatus, contrivance or machine capable of causing emissions of any air contaminant to the outdoor atmosphere, including any appurtenant exhaust system or air cleaning device. [NOTE: Indirect sources of air contamination as defined in 6 NYCRR Part 203 (i.e. parking lots) are excluded from this definition]. The applicant is required to identify the principal piece of equipment (i.e., emission source) that directly results in or controls the emission of federal or state regulated air pollutants from an activity (i.e., process). Emission sources are categorized by the following types:

- combustion - devices which burn fuel to generate heat, steam or power
- incinerator - devices which burn waste material for disposal
- control - emission control devices
- process - any device or contrivance which may emit air contaminants that is not included in the above categories.

**Division of Air Resources
Permit Review Report**

Permit ID: 2-6307-00290/00001

Renewal Number: 4

03/27/2025

LONG ISLAND JEWISH MEDICAL CENTER is defined by the following emission unit(s):

Emission unit EMRGEN - Six emergency generators not included in any other emission unit.

Process: EMG Diesel #2 oil

Emission unit U000CP - Three (3) boilers with emission sources 00CP1, 00CP2, 00CP3 combined to one (1) stack, emission point 000CP.

Two cogeneration systems; sources 00CG1 and 00CG2 exhausting through the existing stack, emission point 000CP. Each of these sources is equipped with catalytic oxidation controls, designated as 01CG1, 02CG2 respectively.

Emission unit U000CP is associated with the following emission points (EP):
000CP

Process: 1CF is located at CENTRAL PLANT, Building CENTRAL - FIRING NUMBER 2 FUEL OIL.

Process: 1CG is located at CENTRAL PLANT, Building CENTRAL - FIRING NATURAL GAS.

Process: 2CF is located at CENTRAL PLANT, Building CENTRAL - FIRING NUMBER 2 FUEL OIL.

Process: 2CG is located at CENTRAL PLANT, Building CENTRAL - FIRING NATURAL GAS.

Process: 3CF is located at CENTRAL PLANT, Building CENTRAL - FIRING NUMBER 2 FUEL OIL.

Process: 3CG is located at CENTRAL PLANT, Building CENTRAL - FIRING NATURAL GAS.

Emission unit UGENCP - This emission unit includes one dual-use generator (emergency and assist for the cogen units); designated as 0GEN1, exhausting to emission point 000G1.

Emission unit UGENCP is associated with the following emission points (EP):
000G1

Process: CF3 is located at Building CENTRAL - Firing No. 2 oil.

Emission unit UOEGCP - This emission unit is for the existing emergency generator (source EGEN1) installed in the central plant that was part of the central plant boiler installation. This emergency generator has a dedicated exhaust stack (emission point 00EG1).

Emission unit UOEGCP is associated with the following emission points (EP):
00EG1

**Division of Air Resources
Permit Review Report**

Permit ID: 2-6307-00290/00001
Renewal Number: 4
03/27/2025

Process: ECF Firing no. 2 fuel oil.

Title V/Major Source Status

LONG ISLAND JEWISH MEDICAL CENTER is subject to Title V requirements. This determination is based on the following information:
 Facility is in major category for its NOx PTE emissions.

Program Applicability

The following chart summarizes the applicability of LONG ISLAND JEWISH MEDICAL CENTER with regards to the principal air pollution regulatory programs:

Regulatory Program	Applicability
PSD	NO
NSR (non-attainment)	NO
NESHAP (40 CFR Part 61)	NO
NESHAP (MACT - 40 CFR Part 63)	YES
NSPS	YES
TITLE IV	NO
TITLE V	YES
TITLE VI	NO
RACT	YES
SIP	YES

NOTES:

PSD Prevention of Significant Deterioration (40 CFR 52.21, 6 NYCRR 231-7, 231-8) - requirements which pertain to major stationary sources located in areas which are in attainment of National Ambient Air Quality Standards (NAAQS) for specified pollutants.

NSR New Source Review (6 NYCRR 231-5, 231-6) - requirements which pertain to major stationary sources located in areas which are in non-attainment of National Ambient Air Quality Standards (NAAQS) for specified pollutants.

NESHAP National Emission Standards for Hazardous Air Pollutants (40 CFR 61, 6 NYCRR 200.10) - contaminant and source specific emission standards established prior to the Clean Air Act Amendments of 1990 (CAAA) which were developed for 9 air contaminants (inorganic arsenic, radon, benzene, vinyl chloride, asbestos, mercury, beryllium, radionuclides, and volatile HAP's).

MACT Maximum Achievable Control Technology (40 CFR 63, 6 NYCRR 200.10) - contaminant and source specific emission standards established by the 1990 CAAA. Under Section 112 of the CAAA, the US EPA is required to develop and promulgate emissions standards for new and existing sources. The standards are to be based on the best demonstrated control technology and practices in the regulated

**Division of Air Resources
Permit Review Report**

Permit ID: 2-6307-00290/00001
Renewal Number: 4
03/27/2025

industry, otherwise known as MACT. The corresponding regulations apply to specific source types and contaminants.

NSPS New Source Performance Standards (40 CFR 60, 6 NYCRR 200.10) - standards of performance for specific stationary source categories developed by the US EPA under Section 111 of the CAAA. The standards apply only to those stationary sources which have been constructed or modified after the regulations have been proposed by publication in the Federal Register and only to the specific contaminant(s) listed in the regulation.

Title IV Acid Rain Control Program (40 CFR 72 thru 78, 6 NYCRR 201-6) - regulations which mandate the implementation of the acid rain control program for large stationary combustion facilities.

Title VI Stratospheric Ozone Protection (40 CFR 82, Subpart A thru G, 6 NYCRR 200.10) - federal requirements that apply to sources which use a minimum quantity of CFC's (chlorofluorocarbons), HCFC's (hydrofluorocarbons) or other ozone depleting substances or regulated substitute substances in equipment such as air conditioners, refrigeration equipment or motor vehicle air conditioners or appliances.

RACT Reasonably Available Control Technology (6 NYCRR Parts 212-3, 220-1.6, 220-1.7, 220-2.3, 220-2.4, 226, 227-2, 228, 229, 230, 233, 234, 235, 236) - the lowest emission limit that a specific source is capable of meeting by application of control technology that is reasonably available, considering technological and economic feasibility. RACT is a control strategy used to limit emissions of VOC's and NOx for the purpose of attaining the air quality standard for ozone. The term as it is used in the above table refers to those state air pollution control regulations which specifically regulate VOC and NOx emissions.

SIP State Implementation Plan (40 CFR 52, Subpart HH, 6 NYCRR 200.10) - as per the CAAA, all states are empowered and required to devise the specific combination of controls that, when implemented, will bring about attainment of ambient air quality standards established by the federal government and the individual state. This specific combination of measures is referred to as the SIP. The term here refers to those state regulations that are approved to be included in the SIP and thus are considered federally enforceable.

Compliance Status

Facility is in compliance with all requirements.

SIC Codes

SIC or Standard Industrial Classification code is an industrial code developed by the federal Office of Management and Budget for use, among other things, in the classification of establishments by the type of activity in which they are engaged. Each operating establishment is assigned an industry code on the basis of its primary activity, which is determined by its principal product or group of products produced or distributed, or services rendered. Larger facilities typically have more than one SIC code.

SIC Code

Description

8062

GENERAL MEDICAL & SURGICAL HOSPITALS

SCC Codes

SCC or Source Classification Code is a code developed and used" by the USEPA to categorize processes which result in air emissions for the purpose of assessing emission factor information.Each SCC represents

**Division of Air Resources
Permit Review Report**

Permit ID: 2-6307-00290/00001
Renewal Number: 4
03/27/2025

a unique process or function within a source category logically associated with a point of air pollution emissions. Any operation that causes air pollution can be represented by one or more SCC's.

SCC Code	Description
1-03-005-02	EXTERNAL COMBUSTION BOILERS - COMMERCIAL/INDUSTRIAL COMMERCIAL/INSTITUTIONAL BOILER - DISTILLATE OIL 10-100MMBTU/HR **
1-03-006-02	EXTERNAL COMBUSTION BOILERS - COMMERCIAL/INDUSTRIAL COMMERCIAL/INSTITUTIONAL BOILER - NATURAL GAS 10-100 MMBtu/Hr
2-03-001-01	INTERNAL COMBUSTION ENGINES - COMMERCIAL/INSTITUTIONAL COMMERCIAL/INSTITUTIONAL IC ENGINE - DISTILLATE OIL (DIESEL) Reciprocating
2-03-002-04	INTERNAL COMBUSTION ENGINES - COMMERCIAL/INSTITUTIONAL COMMERCIAL/INSTITUTIONAL IC ENGINE - NATURAL GAS COGENERATION

Facility Emissions Summary

In the following table, the CAS No. or Chemical Abstract Service code is an identifier assigned to every chemical compound. [NOTE: Certain CAS No.'s contain a 'NY' designation within them. These are not true CAS No.'s but rather an identification which has been developed by the department to identify groups of contaminants which ordinary CAS No.'s do not do. As an example, volatile organic compounds or VOC's are identified collectively by the NY CAS No. 0NY998-00-0.] The PTE refers to the Potential to Emit. This is defined as the maximum capacity of a facility or air contaminant source to emit any air contaminant under its physical and operational design. Any physical or operational limitation on the capacity of the facility or air contamination source to emit any air contaminant, including air pollution control equipment and/or restrictions on the hours of operation, or on the type or amount or material combusted, stored, or processed, shall be treated as part of the design only if the limitation is contained in federally enforceable permit conditions. The PTE for each contaminant that is displayed represents the facility-wide PTE in tons per year (tpy) or pounds per year (lbs/yr). In some instances the PTE represents a federally enforceable emissions cap or limitation for that contaminant. The term 'HAP' refers to any of the hazardous air pollutants listed in section 112(b) of the Clean Air Act Amendments of 1990. Total emissions of all hazardous air pollutants are listed under the special NY CAS No. 0NY100-00-0. In addition, each individual hazardous air pollutant is also listed under its own specific CAS No. and is identified in the list below by the (HAP) designation.

Cas No.	Contaminant	PTE lbs/yr	PTE tons/yr	Actual lbs/yr	Actual tons/yr
0NY508-00-1	40 CFR 60 SUBPART IIII -	26015			
000630-08-0	HYDROCARBONS CARBON MONOXIDE	126774			
007439-92-1	LEAD	3.5			
0NY210-00-0	OXIDES OF NITROGEN	87840			
0NY075-00-0	PARTICULATES	8447			

**Division of Air Resources
Permit Review Report**

Permit ID: 2-6307-00290/00001

Renewal Number: 4

03/27/2025

ONY075-00-5	PM-10	8447
007446-09-5	SULFUR DIOXIDE	1395
ONY100-00-0	TOTAL HAP	16000
ONY998-00-0	VOC	26015

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

Item A: Public Access to Recordkeeping for Title V Facilities - 6 NYCRR 201-1.10(b)

The Department will make available to the public any permit application, compliance plan, permit, and monitoring and compliance certification report pursuant to Section 503(e) of the Act, except for information entitled to confidential treatment pursuant to 6 NYCRR Part 616 - Public Access to records and Section 114(c) of the Act.

Item B: Timely Application for the Renewal of Title V Permits -6 NYCRR Part 201-6.2(a)(4)

Owners and/or operators of facilities having an issued Title V permit shall submit a complete application at least 180 days, but not more than eighteen months, prior to the date of permit expiration for permit renewal purposes.

Item C: Certification by a Responsible Official - 6 NYCRR Part 201-6.2(d)(12)

Any application, form, report or compliance certification required to be submitted pursuant to the federally enforceable portions of this permit shall contain a certification of truth, accuracy and completeness by a responsible official. This certification shall state that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

Item D: Requirement to Comply With All Conditions - 6 NYCRR Part 201-6.4(a)(2)

The permittee must comply with all conditions of the Title V facility permit. Any permit non-compliance constitutes a violation of the Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

Item E: Permit Revocation, Modification, Reopening, Reissuance or Termination, and Associated Information Submission Requirements - 6 NYCRR Part 201-6.4(a)(3)

This permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.

Item F: Cessation or Reduction of Permitted Activity Not a Defense - 6 NYCRR 201-6.4(a)(5)

It shall not be a defense for a permittee in an enforcement action to claim that a cessation or reduction in the permitted activity would have been necessary in order to maintain compliance with the conditions of this permit.

Division of Air Resources
Permit Review Report

Permit ID: 2-6307-00290/00001

Renewal Number: 4

03/27/2025

Item G: Property Rights - 6 NYCRR 201-6.4(a)(6)

This permit does not convey any property rights of any sort or any exclusive privilege.

Item H: Severability - 6 NYCRR Part 201-6.4(a)(9)

If any provisions, parts or conditions of this permit are found to be invalid or are the subject of a challenge, the remainder of this permit shall continue to be valid.

Item I: Permit Shield - 6 NYCRR Part 201-6.4(g)

All permittees granted a Title V facility permit shall be covered under the protection of a permit shield, except as provided under 6 NYCRR Subpart 201-6. Compliance with the conditions of the permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that such applicable requirements are included and are specifically identified in the permit, or the Department, in acting on the permit application or revision, determines in writing that other requirements specifically identified are not applicable to the major stationary source, and the permit includes the determination or a concise summary thereof. Nothing herein shall preclude the Department from revising or revoking the permit pursuant to 6 NYCRR Part 621 or from exercising its summary abatement authority. Nothing in this permit shall alter or affect the following:

- i. The ability of the Department to seek to bring suit on behalf of the State of New York, or the Administrator to seek to bring suit on behalf of the United States, to immediately restrain any person causing or contributing to pollution presenting an imminent and substantial endangerment to public health, welfare or the environment to stop the emission of air pollutants causing or contributing to such pollution;
- ii. The liability of a permittee of the Title V facility for any violation of applicable requirements prior to or at the time of permit issuance;
- iii. The applicable requirements of Title IV of the Act;
- iv. The ability of the Department or the Administrator to obtain information from the permittee concerning the ability to enter, inspect and monitor the facility.

Item J: Reopening for Cause - 6 NYCRR Part 201-6.4(i)

This Title V permit shall be reopened and revised under any of the following circumstances:

- i. If additional applicable requirements under the Act become applicable where this permit's remaining term is three or more years, a reopening shall be completed not later than 18 months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which this permit is due to expire, unless the original permit or any of its terms and conditions has been extended by the Department pursuant to the provisions of Part 201-6.7 and Part 621.
- ii. The Department or the Administrator determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.
- iii. The Department or the Administrator determines that the Title V permit

**Division of Air Resources
Permit Review Report**

Permit ID: 2-6307-00290/00001

Renewal Number: 4

03/27/2025

must be revised or reopened to assure compliance with applicable requirements.

iv. If the permitted facility is an "affected source" subject to the requirements of Title IV of the Act, and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.

Proceedings to reopen and issue Title V facility permits shall follow the same procedures as apply to initial permit issuance but shall affect only those parts of the permit for which cause to reopen exists.

Reopenings shall not be initiated before a notice of such intent is provided to the facility by the Department at least thirty days in advance of the date that the permit is to be reopened, except that the Department may provide a shorter time period in the case of an emergency.

Item K: Permit Exclusion - ECL 19-0305

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York (NYCRR). The issuance of this permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.

Item L: Federally Enforceable Requirements - 40 CFR 70.6(b)

All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

Item A: Emergency Defense - 6 NYCRR 201-1.5

An emergency, as defined by subpart 201-2, constitutes an affirmative defense to penalties sought in an enforcement action brought by the Department for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

(a) The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:

**Division of Air Resources
Permit Review Report**

Permit ID: 2-6307-00290/00001
Renewal Number: 4
03/27/2025

- (1) An emergency occurred and that the facility owner or operator can identify the cause(s) of the emergency;
- (2) The equipment at the permitted facility causing the emergency was at the time being properly operated and maintained;
- (3) During the period of the emergency the facility owner or operator took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and
- (4) The facility owner or operator notified the Department within two working days after the event occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

(b) In any enforcement proceeding, the facility owner or operator seeking to establish the occurrence of an emergency has the burden of proof.

(c) This provision is in addition to any emergency or upset provision contained in any applicable requirement. item_02

**Item B: General Provisions for State Enforceable Permit Terms and Condition - 6
NYCRR Part 201-5**

Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all criteria, emission limits, terms, conditions, and standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

Regulatory Analysis

Location Facility/EU/EP/Process/ES	Regulation	Condition	Short Description
-- FACILITY	ECL 19-0301	47	Powers and Duties of the Department with respect to air pollution control
U-000CP	40CFR 60-Dc.48c (i)	44	Reporting and Recordkeeping Requirements.
FACILITY	40CFR 60-IIII	36	Standards of Performance for Stationary Compression Ignition

**Division of Air Resources
Permit Review Report**

**Permit ID: 2-6307-00290/00001
Renewal Number: 4
03/27/2025**

FACILITY	40CFR 60-JJJJ	37	Internal Combustion Engines
FACILITY	40CFR 63-JJJJJJ	38	Standards of Performance for Stationary Spark Ignition Internal Combustion Engines
FACILITY	40CFR 63-ZZZZ	39, 40	National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers Area Sources
FACILITY	40CFR 68	18	Reciprocating Internal Combustion Engine (RICE) NESHAP
FACILITY	40CFR 82-F	19	Chemical accident prevention provisions
FACILITY	6NYCRR 200.6	1	Protection of Stratospheric Ozone - recycling and emissions reduction
FACILITY	6NYCRR 200.7	10	Acceptable ambient air quality.
FACILITY	6NYCRR 201-1.4	48	Maintenance of equipment.
FACILITY	6NYCRR 201-1.7	11	Unavoidable noncompliance and violations
FACILITY	6NYCRR 201-1.8	12	Recycling and Salvage
FACILITY	6NYCRR 201-3.2 (a)	13	Prohibition of reintroduction of collected contaminants to the air
FACILITY	6NYCRR 201-3.3 (a)	14	Exempt Activities - Proof of eligibility
FACILITY	6NYCRR 201-6	20, 41, 42	Trivial Activities - proof of eligibility
FACILITY	6NYCRR 201-6.4 (a) (4)	15	Title V Permits and the Associated Permit Conditions
FACILITY	6NYCRR 201-6.4 (a) (7)	2	General Conditions - Requirement to Provide Information
FACILITY	6NYCRR 201-6.4 (a) (8)	16	General Conditions - Fees
FACILITY	6NYCRR 201-6.4 (c)	3	General Conditions - Right to Inspect
FACILITY	6NYCRR 201-6.4 (c) (2)	4	Recordkeeping and Reporting of Compliance Monitoring
FACILITY	6NYCRR 201-6.4 (c) (3) (ii)	5	Records of Monitoring, Sampling and Measurement
FACILITY	6NYCRR 201-6.4 (d) (4)	21	Reporting Requirements - Deviations and Noncompliance
FACILITY	6NYCRR 201-6.4 (e)	6	Compliance Schedules - Progress Reports
			Compliance Certification

**Division of Air Resources
Permit Review Report**

Permit ID: 2-6307-00290/00001

Renewal Number: 4

03/27/2025

FACILITY	6NYCRR 201-6.4 (f)	22	Operational Flexibility
FACILITY	6NYCRR 201-6.5 (a)	49	State Enforceable Requirements
FACILITY	6NYCRR 201-7	23	Federally Enforceable Emissions Caps
FACILITY	6NYCRR 202-1.1	17	Required emissions tests.
FACILITY	6NYCRR 202-2.1	7	Emission Statements - Applicability
FACILITY	6NYCRR 202-2.4 (a) (3)	25	Emission statement methods and procedures
FACILITY	6NYCRR 202-2.5	8	Emission Statements - record keeping requirements.
FACILITY	6NYCRR 211.1	50	General Prohibitions - air pollution prohibited
FACILITY	6NYCRR 211.2	26	General Prohibitions - visible emissions limited.
FACILITY	6NYCRR 215.2	9	Open Fires - Prohibitions
FACILITY	6NYCRR 225-1.2 (d)	27	Sulfur-in-Fuel Limitation - Distillate Oil
FACILITY	6NYCRR 225-1.6 (f)	28	Excess Emission Reports
FACILITY	6NYCRR 227-1.3 (a)	29	Particulate Emission Standards
FACILITY	6NYCRR 227-1.3 (c)	30	Annual Tune-up Requirement
FACILITY	6NYCRR 227-1.4 (a)	31, 32	Opacity Standard
FACILITY	6NYCRR 227-2.4 (d)	33	Small boilers, small combustion turbines, and small stationary internal combustion engines.
U-000CP	6NYCRR 227-2.4 (f) (1)	43	Emission limit for natural gas fired engines.
FACILITY	6NYCRR 227-2.5 (a)	34	Fuel switching option.
U-GENCP/000G1/CF3/0GEN1	6NYCRR 227-2.5 (c)	45, 46	Alternative RACT option.
FACILITY	6NYCRR 231-2.7	35	Netting

Applicability Discussion:

Mandatory Requirements: The following facility-wide regulations are included in all Title V permits:

ECL 19-0301

This section of the Environmental Conservation Law establishes the powers and duties assigned to the Department with regard to administering the air pollution control program for New York State.

6 NYCRR 200.6

Acceptable ambient air quality - prohibits contravention of ambient air quality standards without mitigating measures

6 NYCRR 200.7

Anyone owning or operating an air contamination source which is equipped with an emission control

**Division of Air Resources
Permit Review Report**

Permit ID: 2-6307-00290/00001

Renewal Number: 4

03/27/2025

device must operate the control consistent with ordinary and necessary practices, standards and procedures, as per manufacturer's specifications and keep it in a satisfactory state of maintenance and repair so that it operates effectively

6 NYCRR 201-1.4

This regulation specifies the actions and recordkeeping and reporting requirements for any violation of an applicable state enforceable emission standard that results from a necessary scheduled equipment maintenance, start-up, shutdown, malfunction or upset in the event that these are unavoidable.

6 NYCRR 201-1.7

Requires the recycle and salvage of collected air contaminants where practical

6 NYCRR 201-1.8

Prohibits the reintroduction of collected air contaminants to the outside air

6 NYCRR 201-3.2 (a)

An owner and/or operator of an exempt emission source or unit may be required to certify that it operates within the specific criteria described in this Subpart. All required records must be maintained on-site for a period of 5 years and made available to department representatives upon request. In addition, department representatives must be granted access to any facility which contains exempt emission sources or units, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

6 NYCRR 201-3.3 (a)

The owner and/or operator of a trivial emission source or unit may be required to certify that it operates within the specific criteria described in this Subpart. All required records must be maintained on-site for a period of 5 years and made available to department representatives upon request. In addition, department representatives must be granted access to any facility which contains trivial emission sources or units subject to this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

6 NYCRR Subpart 201-6

This regulation applies to those terms and conditions which are subject to Title V permitting. It establishes the applicability criteria for Title V permits, the information to be included in all Title V permit applications as well as the permit content and terms of permit issuance. This rule also specifies the compliance, monitoring, recordkeeping, reporting, fee, and procedural requirements that need to be met to obtain a Title V permit, modify the permit and demonstrate conformity with applicable requirements as listed in the Title V permit. For permitting purposes, this rule specifies the need to identify and describe all emission units, processes and products in the permit application as well as providing the Department the authority to include this and any other information that it deems necessary to determine the compliance status of the facility.

6 NYCRR 201-6.4 (a) (4)

This mandatory requirement applies to all Title V facilities. It requires the permittee to provide information that the Department may request in writing, within a reasonable time, in order to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. The request may include copies of records required to be kept by the permit.

6 NYCRR 201-6.4 (a) (7)

This is a mandatory condition that requires the owner or operator of a facility subject to Title V requirements to pay all applicable fees associated with the emissions from their facility.

Division of Air Resources
Permit Review Report

Permit ID: 2-6307-00290/00001

Renewal Number: 4

03/27/2025

6 NYCRR 201-6.4 (a) (8)

This is a mandatory condition for all facilities subject to Title V requirements. It allows the Department to inspect the facility to determine compliance with this permit, including copying records, sampling and monitoring, as necessary.

6 NYCRR 201-6.4 (c)

This requirement specifies, in general terms, what information must be contained in any required compliance monitoring records and reports. This includes the date, time and place of any sampling, measurements and analyses; who performed the analyses; analytical techniques and methods used as well as any required QA/QC procedures; results of the analyses; the operating conditions at the time of sampling or measurement and the identification of any permit deviations. All such reports must also be certified by the designated responsible official of the facility.

6 NYCRR 201-6.4 (c) (2)

This requirement specifies that all compliance monitoring and recordkeeping is to be conducted according to the terms and conditions of the permit and follow all QA requirements found in applicable regulations. It also requires monitoring records and supporting information to be retained for at least 5 years from the time of sampling, measurement, report or application. Support information is defined as including all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit.

6 NYCRR 201-6.4 (c) (3) (ii)

This regulation specifies any reporting requirements incorporated into the permit must include provisions regarding the notification and reporting of permit deviations and incidences of noncompliance stating the probable cause of such deviations, and any corrective actions or preventive measures taken.

6 NYCRR 201-6.4 (d) (4)

This condition applies to every Title V facility subject to a compliance schedule. It requires that reports, detailing the status of progress on achieving compliance with emission standards, be submitted semiannually.

6 NYCRR 201-6.4 (e)

Sets forth the general requirements for compliance certification content; specifies an annual submittal frequency; and identifies the EPA and appropriate regional office address where the reports are to be sent.

6 NYCRR 202-1.1

This regulation allows the department the discretion to require an emission test for the purpose of determining compliance. Furthermore, the cost of the test, including the preparation of the report are to be borne by the owner/operator of the source.

6 NYCRR 202-2.5

This rule specifies that each facility required to submit an emission statement must retain a copy of the statement and supporting documentation for at least 5 years and must make the information available to department representatives.

6 NYCRR 211.2

This regulation limits opacity from sources to less than or equal to 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent opacity.

**Division of Air Resources
Permit Review Report**

Permit ID: 2-6307-00290/00001

Renewal Number: 4

03/27/2025

6 NYCRR 215.2

Except as allowed by section 215.3 of 6 NYCRR Part 215, no person shall burn, cause, suffer, allow or permit the burning of any materials in an open fire.

40 CFR Part 68

This Part lists the regulated substances and their applicability thresholds and sets the requirements for stationary sources concerning the prevention of accidental releases of these substances.

40 CFR Part 82, Subpart F

Subpart F requires the reduction of emissions of class I and class II refrigerants to the lowest achievable level during the service, maintenance, repair, and disposal of appliances in accordance with section 608 of the Clean Air Act Amendments of 1990. This subpart applies to any person servicing, maintaining, or repairing appliances except for motor vehicle air conditioners. It also applies to persons disposing of appliances, including motor vehicle air conditioners, refrigerant reclaimers, appliance owners, and manufacturers of appliances and recycling and recovery equipment. Those individuals, operations, or activities affected by this rule, may be required to comply with specified disposal, recycling, or recovery practices, leak repair practices, recordkeeping and/or technician certification requirements.

Facility Specific Requirements

In addition to Title V, LONG ISLAND JEWISH MEDICAL CENTER has been determined to be subject to the following regulations:

40 CFR 60.48c (i)

This regulation requires the source owner or operator to retain all records for a minimum of two years for compliance with the NSPS. This does not supercede any requirement that is more stringent, including the Title V requirement to maintain records for for a minimum of 5 years.

40 CFR Part 60, Subpart IIII

Subpart IIII applies to new and reconstructed compression ignition reciprocating internal combustion engines. Sources subject to Subpart IIII must comply with emission standards for hydrocarbons, nitrogen oxides, carbon monoxide, and particulate matter.

40 CFR Part 60, Subpart JJJJ

Subpart JJJJ applies to manufacturers, owners, and operators of stationary spark ignition (SI) internal combustion engines (ICE) as specified in §60.4230, paragraphs (a)(1) through (6). Sources subject to Subpart JJJJ must comply with emission standards for nitrogen oxides, carbon monoxide, and volatile organic compounds.

40 CFR Part 63, Subpart JJJJJ

This regulation covers facilities that own or operate an industrial, commercial, or institutional boiler as defined in §63.11237 that is located at, or is part of, an area source of hazardous air pollutants (HAP), as defined in §63.2, except as specified in §63.11195.

**Division of Air Resources
Permit Review Report**

Permit ID: 2-6307-00290/00001

Renewal Number: 4

03/27/2025

40 CFR Part 63, Subpart ZZZZ

Subpart ZZZZ applies to reciprocating internal combustion engines. Sources subject to Subpart ZZZZ must limit emissions of carbon monoxide and formaldehyde. Sources must also comply with work practice standards and operating limits.

6 NYCRR 201-6.4 (f)

This section describes the potential for certain operational changes to be made by the facility owner or operator without first obtaining a permit modification. Changes made pursuant to this provision must meet all of the criteria described in this section to qualify for consideration as operational flexibility. The Department reserves the right to require the facility owner or operator to obtain a permit modification prior to making any changes at the facility pursuant to this section.

6 NYCRR 201-6.5 (a)

This subdivision states that the Department shall include state enforceable conditions in Title V permits. State enforceable conditions related to regulations developed pursuant to the Climate Leadership and Community Protection Act (CLCPA) and Article 75 of New York State Environmental Conservation Law may be included in future versions of this permit, as applicable.

6 NYCRR 202-2.4 (a) (3)

Once a facility is required to submit annual emission statements electronically, emission statements must be submitted to the department per the specified schedule, in this regulation beginning the reporting year that a Title V permit containing a condition mandating electronic submittal is issued.

6 NYCRR 211.1

This regulation requires that no person shall cause or allow emissions of air contaminants to the outdoor atmosphere of such quantity, characteristic or duration which are injurious to human, plant or animal life or to property, or which unreasonably interfere with the comfortable enjoyment of life or property.

6 NYCRR 225-1.2 (d)

This subdivision sets the sulfur-in-fuel limitation for distillate oil fired emission sources throughout the State.

6 NYCRR 225-1.6 (f)

This subdivision requires the submission of excess emission reports when the the sulfur-in-fuel limitation, equivalent emission rate, or measured emissions exceeds the allowable standard.

**Division of Air Resources
Permit Review Report**

Permit ID: 2-6307-00290/00001

Renewal Number: 4

03/27/2025

6 NYCRR 227-1.3 (a)

This subdivision sets the particulate matter emission standards for subject stationary combustion installations.

6 NYCRR 227-1.3 (c)

This subdivision requires that all stationary combustion installations subject to this subpart perform an annual tune-up.

6 NYCRR 227-1.4 (a)

This subdivisions sets the opacity standard for subject stationary combustion installations.

6 NYCRR 227-2.4 (d)

This section includes NO_x RACT requirements for small boilers, small combustion turbines, and small stationary internal combustion engines.

6 NYCRR 227-2.4 (f) (1)

Presumptive NO_x RACT emission limit for natural gas fired stationary internal combustion engines.

6 NYCRR 227-2.5 (a)

Fuel switching NO_x RACT compliance option.

6 NYCRR 227-2.5 (c)

This provision allows the owner or operator to demonstrate that the applicable presumptive RACT emission limit in section 227-2.4 of this Subpart is not economically or technically feasible. Based on this determination the Department is allowed to set a higher emission source specific emission limit.

**Division of Air Resources
Permit Review Report**

Permit ID: 2-6307-00290/00001
Renewal Number: 4
03/27/2025

6 NYCRR 231-2.7

The provisions of Subpart 231-2 apply to new or modified major facilities. The contaminants of concern state-wide are nitrogen oxides and volatile organic compounds since New York State is located in the ozone transport region and because there are ozone non-attainment areas within the state. In the New York City metropolitan area, carbon monoxide is also a non-attainment contaminant. In addition, particulate matter less than 10 microns in size (PM-10) is a non-attainment contaminant in Manhattan County.

Pursuant to section 231-2.7, existing major facilities may avoid the requirements of Subpart 231-2 by conducting a netting analysis. This is done by utilizing the following equation:

$$NEI = PEP + CEI - ERCs$$

where:

- NEI = net emission increase
- PEP = project emission potential for the proposed source project
- CEI = creditable emission increases
- ERCs = emission reduction credits

All of the creditable emission increases and emission reduction credits must have occurred at the facility for which the netting analysis is being conducted and must have occurred during the contemporaneous period for the proposed project. If the net emission increase is less than the threshold values incorporated into sections 231-2.12 and 231-2.13, then the the proposed source project is not subject to the requirements of Subpart 231-2.

6 NYCRR Subpart 201-7

This regulation sets forth an emission cap that cannot be exceeded by the facility. In this permit that cap is

Compliance Certification

Summary of monitoring activities at LONG ISLAND JEWISH MEDICAL CENTER:

Location Facility/EU/EP/Process/ES	Cond No.	Type of Monitoring

U-000CP	44	record keeping/maintenance procedures
FACILITY	38	record keeping/maintenance procedures
FACILITY	5	record keeping/maintenance procedures
FACILITY	6	record keeping/maintenance procedures
FACILITY	24	monitoring of process or control device parameters as surrogate
FACILITY	7	record keeping/maintenance procedures
FACILITY	27	work practice involving specific operations
FACILITY	28	record keeping/maintenance procedures

**Division of Air Resources
Permit Review Report**

Permit ID: 2-6307-00290/00001

Renewal Number: 4

03/27/2025

FACILITY	29	record keeping/maintenance procedures
FACILITY	30	record keeping/maintenance procedures
FACILITY	31	monitoring of process or control device parameters as surrogate
FACILITY	32	record keeping/maintenance procedures
FACILITY	33	record keeping/maintenance procedures
U-000CP	43	intermittent emission testing
FACILITY	34	intermittent emission testing
U-GENCP/000G1/CF3/0GEN1	45	intermittent emission testing
U-GENCP/000G1/CF3/0GEN1	46	monitoring of process or control device parameters as surrogate
FACILITY	35	monitoring of process or control device parameters as surrogate

Basis for Monitoring

6 NYCRR 201-7: This permit condition caps NOx emissions at 21.4 tpy, for the emissions from the three boilers (started operating in year 2003), to avoid 231-2 NSR requirements. The permit condition also requires the facility to perform stack test once every 5 years to verify the compliance with this condition.

6 NYCRR 231-2.7: This is a netting condition for NOx emissions, limiting at 22.5 tpy, for the emissions from the two Cogen engines (started operating in year 2008), one assist engine (started operating in year 2008), and the existing emergency generator, to avoid 231-2.7 NSR requirements. The permit condition also requires the facility to do stack test the engines once every 5 years to verify compliance with this condition.

6 NYCRR 225: The facility is required to comply with sulfur in fuel 0.0015 % by weight, by maintaining vendor delivery receipts at the site, which contains supplier's certification showing the sulfur content in fuel. The facility is required to keep the receipts for a minimum of five years after the date of the last entry.

6 NYCRR 227-1: The facility is required to monitor the opacity by conducting daily observations for oil processes and take corrective measures if there are any exceedances to Opacity standard of 20%. Once a year, Opacity testing by method 9 is required.

6 NYCRR 227-2.5 (c):

The dual use generator (emergency and assist cogen engine), is a 2008 engine and can't meet the presumptive NOx limit of 2.3 g/hp-hr. A source specific NOx RACT plan was submitted in October 2022, and an alternative NOx RACT limit of 6.5 gm/bhp was requested due to economic and technical reasons, and was accepted by the department. Process-specific Reasonably Available Control Technology (RACT) determinations that are included in this permit action will be submitted to the United States Environmental Protection Agency for approval as a revision to the State Implementation Plan (SIP). The facility is required to conduct a stack test once every five years to verify the alternative NOx RACT limit.

There is also a condition in the permit that this unit will operate no more than 500 hrs.yr.

6 NYCRR 227-2.5 (a): The facility is required to comply with NOx limit of 0.08 lb/mmbtu for its mid-size boilers, by averaging fuel oil usage (no more than 20%) with gas usage. The facility is required to conduct the stack test once every five years.

6 NYCRR 227-2.4 (f) (1): The facility's cogen engines (OOCG1 and OOCG2) are required to comply with NOx limit of 1.5 gms/bhp-hr, and to verify compliance with this condition by conducting stack test once every five years.

**Division of Air Resources
Permit Review Report**

Permit ID: 2-6307-00290/00001

Renewal Number: 4

03/27/2025

40 CFR 60, Subpart Dc: Three (3) boilers in emission unit 000CP (00CP1, 00CP2, 00CP3) are subject to Federal regulations for Sulfur in fuel and Opacity requirements (40 CFR 60- subpart DC, 40 CFR 60.42c (d), 40 CFR 60.44c (h), 40 cfr 43c (c)), however they are not added here as more stringent NYS regulations 6 NYCRR Part 225 and 227 requirements are included in the permit.

40 CFR 63, Subpart JJJJJJ:

The Permittee is avoiding applicability of 40 CFR 63 Subpart JJJJJJ "Industrial, Commercial, and Institutional Boilers Area Sources." (Subpart 6J). The Permittee is permitted to operate the above listed boilers on natural gas/No.2 fuel oil. Per 40 CFR63.11195(e), these existing and new boilers are exempt from Subpart 6J because they are defined as gas-fired boiler(s) in 40 CFR 63.11237. In order to maintain this exemption, the Permittee is allowed to fire liquid fuel only during periods of gas curtailment, gas supply interruptions, startups, or for periodic testing on liquid fuel (periodic testing not to exceed a combined total of 48 hours during any calendar year).

40CFR 60, NSPS Subpart IIII: Facilities that have stationary compression ignition internal combustion engines (Emission Unit: EMRGEN, Emission Unit: UGENCP), must comply with applicable portions of 40 CFR 60 Subpart IIII.

40CFR 60, NSPS Subpart JJJJ: Facilities that have stationary spark ignition internal combustion engines (Emission Unit: OOOCP), must comply with applicable portions of 40 CFR 60 Subpart JJJJ.

40 CFR 64 Compliance Assurance Monitoring (CAM): The emissions from the 3 nebraska boilers are limited to 22.5 tpy NOx and are therefore exempt from CAM as described at 40 CFR 64.2(b)1(v). Emissions from two cogeneration IC engines (emission sources 00CG1 and 00CG2), the assist engine (emission source 0GEN1) as emergency and assist, the existing emergency generator (emission source EGEN1), are also capped under 231-2.7, and are exempt from the requirements of Part 64, as described in 40 CFR 64.2(b)1(v).

Also, the six emergency generators of the emission unit E-MRGEN are not equipped with a control device as defined in 40 CFR 64.1 and therefore do not meet the applicability criteria described at 40 CFR 64.2(a)(2).