

New York State Department of Environmental Conservation – Petroleum Bulk Storage (PBS) Inspection Form

DATE: _____ DEC INSPECTOR: _____

PBS #: _____ or Unregistered FACILITY REP. NAME & TITLE: _____

FACILITY NAME: _____ FACILITY ADDRESS: _____

FACILITY PHONE: _____

Facility-Level Information

1. Is the inspection announced or unannounced?	<input type="checkbox"/> Announced <input type="checkbox"/> Unannounced
2. Is the registration certificate posted at a conspicuous location at the facility?	<input type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> 1 (not signed)
3. Is the registration information current and accurate?	<input type="checkbox"/> Y <input type="checkbox"/> N (inaccurate information) <input type="checkbox"/> 1 (expired registration) <input type="checkbox"/> 2 (unregistered facility) <input type="checkbox"/> 3 (unregistered tank)
4. Does the facility have an as-built diagram?	<input type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> X (not required) <input type="checkbox"/> 1 (incomplete)

Tank-Specific Information

Tank Registration #

Applicable Subpart: 2 / 3 / 4					
Product Stored/Tank Volume					
Date Installed					
5. Are monitoring/observation wells marked and secured? Y / X (no wells) / 1 (not marked) / 2 (improperly marked) / 3 (not secured)					
6. Is the dispenser sump present when required and in good working order? Y / N (not present when required) / X (no sump; not required) / 1 (lacks integrity) / 2 (contains water/debris) / 3 (no access)					
7. For motor fuel tank systems with pressurized piping, are shear valves properly installed and operable? Y / N (no shear valve) / X (not pressurized piping; not motor fuel) / 1 (valve inoperable) / 2 (improperly installed) / 3 (no access)					
8. Was the tank properly closed, or service changed, with pre-notification? Y / X (active or out-of-service tank) / 1 (improper closure method) / 2 (no site assessment performed for Subpart 2 tank at time of closure/change-in-service) 3 (no closure report; not maintained for 3 years) / 4 (closure report not submitted) / 5 (tank closed without pre-work notification)					
9. If the tank system is out-of-service (OOS), is it following all OOS requirements? ASTs may remain OOS for longer than 12 months if another active tank is at the facility. Y / X (active/closed tank) / 1 (piping not capped/secured) / 2 (vent lines not left open) / 3 (not closed after 12 months)					
10. Is the facility free of observable spills and have reportable spills been reported? Mark all that apply and describe as needed in the notes/comments section. Y / 1 (petroleum in spill bucket) / 2 (petroleum in sump) / 3 (petroleum in dispenser sump) / 4 (petroleum in tank secondary containment) / 5 (petroleum in the environment) / 6 (suspected spill not investigated) / 7 (suspected spill not reported) / 8 (spill not reported) / 9 (release not reported) / 10 (failed spill bucket test not reported) / 11 (failed sump test not reported)					
11. Is the fill port/tank color coded/marked to identify the product in the tank system? Y / N (not color coded/marked) / X (day tank) / 1 (incorrectly color coded/marked)					

Leak Detection (equipment)	Tank Registration #				
12. Does the system have the <u>required equipment</u> installed to perform leak detection? Y (see applicable questions below) / N / X (leak detection not required; tank is out-of-service and empty [≤ 1 inch]; exempt tank/piping; uses tightness testing or SIR [see applicable questions below])					

Leak Detection (standards and performance): Fill out ONLY the applicable leak detection methods below for each system

Automatic Tank Gauging (ATG)					
13. Does the ATG meet leak detection standards (a NWGLDE-listed device meets standards)? Y / N / 1 (inoperable)					
14. Is the ATG set up properly to conduct leak tests? Y / X (unable to confirm) / 1 (tests not being performed; not performed at least weekly) / 2 (not set up properly to conduct leak tests [e.g., configuration, timing]) / 3 (measurements do not include portions of tank that routinely contains petroleum) / 4 (no weekly records; not maintained for 3 years) / 5 (no monthly operability records for electronic LD; not maintained for 3 years) / 6 (inappropriate method for Subpart/Category and no other compliant method used)					
15. Is the ATG tested annually for proper operation? Y / N / X (Subpart 3 tank system) / 1 (alarm not tested) / 2 (leak rate/tank size configuration not verified) / 3 (battery backup not tested) / 4 (float not tested) / 5 (communication with console not tested) / 6 (no records; not maintained for 3 year)					
Manual Tank Gauging (MTG)					
16. Is manual tank gauging being performed properly? Y / 1 (tests not being performed; not performed at least weekly) / 2 (tank size not appropriate [>1000 gal.]) / 3 (equipment not capable of 1/8" measurement) / 4 (no records; not maintained for 3 years) / 5 (inappropriate method for Subpart/Category and no other compliant method used)					
Tank Testing					
17. Is tank testing conducted within the required time frame? Y / 1 (test not conducted annually) / 2 (test report not submitted) / 3 (no test report; not maintained until date of next test) / 4 (inappropriate method for Subpart/Category and no other compliant method used)					
Line Testing					
18. Is line testing conducted within the required time frame? Y / 1 (pressurized piping not tested annually) / 2 (non-exempt suction piping not tested within required time frame) / 3 (test report not submitted) / 4 (no test report; not maintained until date of next test) / 5 (inappropriate method for Subpart/Category and no other compliant method used)					
Inventory Monitoring					
19. Does the facility have adequate inventory records for metered tanks storing motor fuel/kerosene that will be sold as part of a commercial transaction? Y / 1 (no records; not maintained for 3 years) / 2 (no tank bottom water measurements) / 3 (equipment not capable of 1/8" measurement) / 4 (meter not calibrated) / 5 (no reconciliation of records) / 6 (improper reconciliation)					

Leak Detection (continued)

Groundwater/Vapor Monitoring				
20. Is there a site assessment report indicating location and number of groundwater/vapor monitoring wells? Y / N (no report) / 1 (wells not properly designed/positioned to detect leaks) / 2 (GW not always detectable in GW well [GW is more than 20' from surface]) / 3 (vapor well affected by GW)		TANK		
21. Is leak detection being performed? Note that continuous electronic monitoring satisfies weekly requirements (weekly records are not required). Y / 1 (not performed; not performed at least weekly) / 2 (no weekly records; not maintained for 3 years) / 3 (no monthly operability records for electronic LD; not maintained for 3 years) / 4 (inappropriate method for Subpart/Category and no other compliant method used)		TANK		
22. Is handheld electronic sampling equipment being tested annually for operability? Y / X (electronic sampling equipment not used; Subpart 3 tank system) / 1 (not tested annually) / 2 (no records; not maintained for 3 years)				
Interstitial Monitoring (IM)				
23. Is the secondary containment in good working order (i.e., double-walled tank, double walled-piping, and <u>any</u> sump used for leak detection)? Y / N (not tight) / 1 (sump contains water/debris) / 2 (sump lacks integrity) / 3 (no access)		TANK		
24. Is the sensor operational and, for piping, properly positioned in the sump? Y / X (manual monitoring; no access) / 1 (inoperable) / 2 (sensor not properly positioned in sump)		TANK		
25. Is leak detection being performed? Note that continuous electronic monitoring satisfies weekly requirements (weekly records are not required). Y / 1 (not performed; not performed at least weekly) / 2 (no weekly records; not maintained for 3 years) / 3 (no monthly operability records for electronic LD; not maintained for 3 years)		TANK		
26. Are the probes and sensors inspected annually? Y / N / X (manual monitoring; Subpart 3 tank system) / 1 (not inspected for residual buildup) / 2 (float not tested) / 3 (visually accessible cable not inspected for kinks/breaks) / 4 (alarm operability not tested) / 5 (communication with console not tested) / 6 (no records; not maintained for 3 years)		TANK		
27. Are the sump(s) (tank-top, UDC, transition), <u>used for IM</u> , tested triennially for tightness? Alternatively, double-walled sumps can instead monitor the integrity of both walls annually. The interstitial space of these double-walled sumps must be held under pressure, vacuum, or be liquid-filled and equipped with an indicator/gauge to use this alternative method. Piping installed before 4/13/16 can perform a line test in lieu of IM <u>for EPA</u> and is therefore not required to perform a sump test. Y / X (IM not used for piping; Subpart 3 tank system) / 1 (not tested triennially) / 2 (improper annual monitoring) / 3 (no test records; not maintained for 3 years)				
Automatic Line Leak Detector (ALLD)				
28. Is the ALLD present and does it appear to be operational? Y / N (not present) / 1 (not operational) / 2 (no access)				
29. For Subpart 2 facilities, has the annual functionality test of the ALLD been conducted, and are records available? Y / N (not tested annually) / X (Subpart 3 tank system) / 1 (no records; not maintained for 3 years)				
Statistical Inventory Reconciliation (SIR)				
30. Is SIR being performed properly? Y / 1 (SIR method does not meet standards [NWGLDE-listed meets standards]) / 2 (not performed; not performed at least weekly) / 3 (no records; not maintained for 3 years) / 4 (inappropriate method for Subpart/Category and no other compliant method used)		TANK		
Weep Holes				
31. Are all weep holes visible and are they free of obstructions? Y / 1 (not visible) / 2 (obstructed)				
32. Is leak detection being performed? Y / 1 (not performed; not performed at least weekly) / 2 (no records; not maintained for 3 years) / 3 (inappropriate method for Subpart/Category and no other compliant method used)				

Subpart 2 UST Systems

Tank Registration #

33. Does the Category 2/3 tank have a fill port label? Y / N / X (Cat.1 tank) / 1 (incomplete label)				
34. Is the spill bucket present and functional? Y / N (not present when required) / X (tank receives ≤ 25 gal. at a time) 1 (contains water/debris) / 2 (lacks integrity) / 3 (no access)				
35. Is the spill bucket tested triennially for tightness? Alternatively, double-walled spill buckets can instead be monitored for the integrity of both walls every 30 days. The interstitial space of these double-walled spill buckets must be held under pressure, vacuum, or be liquid-filled and be equipped with an indicator/gauge to use this alternative method. Y / X (no spill bucket) / 1 (not tested triennially) / 2 (improper 30-day monitoring) / 3 (no test/monitoring records; not maintained for 3 years)				
36. Is the overfill prevention device (i.e., automatic shut-off, high-level alarm, ball float valve) present and functional? Y / N (not present) / X (tank receives ≤ 25 gal. at one time) / 1 (cannot verify) If automatic shutoff or high-level alarm is not functional: 2 (not set at appropriate level) / 3 (alarm not audible/visible to driver) / 4 (inoperable) If ball float valve is not functional: 5 (Stage I coaxial vapor recovery is present) / 6 (piping system is suction) / 7 (spill bucket drain valve broken/impaired by debris)				
37. Is the overfill prevention device inspected triennially and are records being maintained? Y / N (not inspected) / X (not present) / 1 (not inspected for being set at appropriate level) / 2 (not inspected for activating at appropriate level) / 3 (no records; not maintained for 3 years)				
38. Does the Cat. 2/3 tank and Cat. 3 piping have secondary containment installed? Tank and piping secondary containment, if installed, must be maintained tight. This includes any sump used as part of the piping secondary containment system. Y / N (no appropriate secondary containment) / X (Cat. 1 tank; Cat. 1/2 piping) / 1 (not tight) / 2 (sump lacks integrity) / 3 (no access)		TANK		
39. Was the metal tank system, in contact with soil, installed with a cathodic protection system? Category 1 tanks must have installed a cathodic protection system or lining by 12/22/98. Y / X (inherently corrosion-resistant) / 1 (does not have CP installed or Cat. 1 tank has no CP or lining) / 2 (portion of piping [including fittings, connectors, etc.] not protected from corrosion)		TANK		
40. Is the cathodic protection system tested annually and is it providing continuous protection? Y / X (no CP system installed) / 1 (system not tested annually) / 2 (inadequate monitoring – not enough readings) / 3 (minimum protection not provided as indicated on test) / 4 (no records; not maintained for 3 years)		TANK		
41. If an impressed current system is in use, has the system been operated continuously? Y / X (no impressed current system) / 1 (rectifier is not operational) / 2 (rectifier does not have electrical power 24/7) / 3 (clock shows that power has been turned off) / 4 (not inspected every 60 days) / 5 (no records; not maintained for 3 years)		PIPING		
42. For lined Cat. 1 USTs, is the internal lining being inspected periodically (i.e., within 10 years after installation and every 5 years thereafter)? Y / N (no inspection) / X (UST not lined; Cat. 2/3 UST; lining installed w/ CP) / 1 (operating with failed lining) / 2 (inspection procedure not acceptable) / 3 (no report; not maintained for 5 years)		PIPING		
43. If a cathodically protected tank or piping was structurally repaired, were CP systems tested/inspected within 6 months after repair? Y / N / X (no CP system/structural repair)				
44. Were structurally repaired tank and piping tested for tightness within 30 days after repair completion? A tightness test is not required when an internal inspection is conducted after a repair or if a weekly leak detection method is in use. Y / N / X (no structural repair; internal inspection performed; weekly LD used)				

Subpart 2 UST Systems (continued)	Tank Registration #				
45. Is there a designated Class A Operator and is that person properly authorized? Y / N (no authorized Operator) / 1 (current authorized Class A Operator is not designated) / 2 (no records)					
46. Is there a designated Class B Operator and is that person properly authorized? Y / N (no authorized Operator) / 1 (current authorized Class B Operator is not designated) / 2 (no records)					
47. Is there a designated Class C Operator and is that person properly trained? Y / N (no trained Operator) / 1 (no records; not designated)					
48. Does the Category 3 tank system have an installer certification and manufacturer's checklist (only applies to tank and piping)? Y / X (Category 1 or 2 system) / 1 (no installer certification) / 2 (no manufacturer's checklist or PE inspection & certification)					
49. Did the facility conduct 30-day and annual walkthrough inspections? If a code of practice is followed, it must be followed in its entirety (e.g., daily inspections). Y / 1 (30-day walkthrough not performed or inadequate) / 2 (annual walkthrough not performed or inadequate) / 3 (code of practice not followed) 4 (no 30-day walkthrough records; not maintained for 1 year) / 5 (no annual walkthrough records; not maintained for 1 year)					
50. Is the facility complying with financial responsibility? Y / N					

Subpart 3 UST Systems	Tank Registration #				
51. Does the Category 2/3 tank have a fill port label? Y / N / X (Cat. 1 tank) / 1 (incomplete label)					
52. Does the Category 2/3 tank have an overfill prevention device (i.e., automatic shut-off, high-level alarm, ball float valve) and is it functional? Y / N (not present) / X (tank receives ≤ 25 gal. at one time) / 1 (cannot verify) If automatic shutoff or high-level alarm is not functional: 2 (not set at appropriate level) / 3 (alarm not audible/visible to driver) / 4 (inoperable) If ball float valve is not functional: 5 (piping system is suction) / 6 (spill bucket drain valve broken/impaired by debris)					
53. Does the Cat. 2/3 tank have secondary containment installed and is it tight? Y / N (no appropriate secondary containment) / X (Cat. 1 tank) / 1 (not tight)					
54. Was the metal tank system, in contact with soil, installed with a cathodic protection system? Y / X (inherently corrosion-resistant; Cat. 1 tank/piping; not in contact with soil) 1 (does not have CP installed) / 2 (portion of piping [including fittings, connectors, etc.] not protected from corrosion)					
55. Is the cathodic protection system tested annually and is it providing continuous protection? Y / X (no CP system installed) / 1 (system not tested annually) / 2 (inadequate monitoring – not enough readings) / 3 (minimum protection not provided as indicated on test) / 4 (no records; not maintained for 3 years)					

Subpart 4 AST Systems	Tank Registration #					
56. For Cat. 2 and 3 ASTs, does the AST meet standards? Y / X (Cat. 1 AST) / 1 (tank does not meet construction standards) / 2 (no surface coating) / 3 (tank on grade w/o impermeable barrier) / 4 (no leak detection between tank & barrier)						
57. Was the metal tank system, in contact with soil, installed with a cathodic protection system? Y / X (inherently corrosion-resistant; Cat. 1 tank/piping; not in contact with soil) / 1 (does not have CP installed) / 2 (portion of piping [including fittings, connectors, etc.] not protected from corrosion)						
58. Is the cathodic protection system tested within the required time frame and is it providing continuous protection? Y / X (no CP system installed) / 1 (system not tested annually) / 2 (inadequate monitoring – not enough readings) / 3 (minimum protection not provided as indicated on test) / 4 (no records; not maintained for 3 years)						
59. If an impressed current system is in use, has the system been operated continuously? Y / X (no impressed current system) / 1 (rectifier is not operational) / 2 (rectifier does not have electrical power 24/7) / 3 (clock shows that power has been turned off) / 4 (not inspected every 60 days) 5 (no records; not maintained for 3 years)						
60. For ASTs ≥10,000 gallons, is the secondary containment adequately designed and in good condition? Y / N (no secondary containment) / X (<10,000 gallons; refer to question 61) / 1 (secondary containment lacks integrity) / 2 (contains water/debris) / 3 (inadequate design)						
61. For ASTs <10,000 gallons that are within 500 feet of a sensitive receptor, is the secondary containment adequately designed or is the tank using alternatives which address DER-25 issues? Y / N (no secondary containment/alternative equipment) / X (not required/applicable) / 1 (secondary containment lacks integrity/equipment not maintained) / 2 (contains water/debris) / 3 (inadequate design/DER-25 issues not addressed)						
62. Are dike drain valves locked in a closed position? Y / N (unlocked) / X (no dike/discharge pipe) / 1 (no valve on discharge pipe)						
63. Does the AST have a gauge, high-level alarm, high-level liquid pump cut-off controller, or an equivalent device? Y / N / 1 (inoperable)						
64. Is the tank marked with design & working capacities and tank ID number? Y / N / 1 (incomplete label)						
65. Is a solenoid or equivalent valve in place for gravity-fed motor fuel dispensers? Y / N / X (AST system not storing motor fuel OR dispensers not gravity-fed) / 1 (inoperable) / 2 (not adjacent to and downstream from the operating valve)						
66. Is a check valve in place for pump-filled ASTs with remote fills? Y / N / X (no remote fill) / 1 (inoperable)						
67. Is an operating valve in place on every line with gravity head? Y / N / X (no gravity head on line) / 1 (inoperable)						
68. Are monthly inspections being performed? Y / N / 1 (inadequate inspection) / 2 (no records; not maintained for 3 years)						
69. Are ten-year inspections (internal inspections or tightness tests) for Cat. 1 systems being conducted? Y / N / X (not required per Part 613-4.3(a)(1)(iii) OR Cat. 2/3 AST system) / 1 (inadequate inspection) / 2 (test report not submitted) / 3 (no records; not maintained for 10 years)						
70. Does the facility conduct tightness testing at ten-year intervals for underground piping installed before 12/27/86? Y / N / X (piping installed on or after 12/27/86; not underground) / 1 (no records; not maintained for 10 years)						

Notes/Comments:

Include additional information to be appended onto the record of inspection or notice of violation such as spill descriptions, follow-ups, and contact information.
