

# **BATAVIA IRON & METAL CO, INC. REMEDIAL ACTION**

**301 Bank Street, Batavia, New York  
Site Number 819018**

**August 2022**

**ADDENDUM NUMBER 2  
TO CONTRACT D011945**



**Prepared by:**

**MACTEC Engineering and Geology P.C.  
and  
New York State Department of Environmental Conservation  
Division of Environmental Remediation**

**ADDENDUM NUMBER 2  
TO THE JULY 2022 CONTRACT DOCUMENTS  
BATAVIA IRON & METAL CO. INC.  
REMEDIAL ACTION  
301 BANK STREET, BATAVIA,  
GENESEE COUNTY, NEW YORK  
CONTRACT NO. D011945  
August 4, 2022**

**TO ALL HOLDERS OF THE CONTRACT DOCUMENTS:**

Section III, Article 3 of the Contract Documents requires bidders to acknowledge receipt of all addenda on Form V-5.

**Table of Contents**

<b>Section A</b>	<b>Announcements</b>
<b>Section B</b>	<b>Clarifications</b>

---

**Batavia - Remedial Action**  
Contract No. D011945

## **Section A:       Announcements**

The Bid Opening Call will be held on Tuesday, August 9, 2022, at 1PM Eastern.

To join on Microsoft Teams:

Meeting ID: 217 671 462 849

Passcode: fxL2Ni

To call in (audio only):

Phone Number: 1-518-801-9699

Conference ID: 894 478 29#

## **Section B:       Questions, Answers, Clarification**

The following provides clarifications on two items the Department has deemed impactful to bid preparation. Bidders are reminded to thoroughly review the bidding documents and bid as specified.

### Clarifications

1. Permanent fence shall be installed to replace any existing chain link fence that is impacted during construction activities. Please refer to existing condition Drawings C-101 to C-104.
2. The minimum depth of topsoil for restoration in the upland areas is 4 inches, and a minimum of 12 inches in the wetland areas as indicated on Drawing C-504 and in Specification 32 92 26.