

2004.04.12 HW
minor mod
File

New York State Department of Environmental Conservation

Division of Environmental Permits, Region 4

1150 North Westcott Road, Schenectady, New York 12306-2014

Phone: (518) 357-2069 • FAX: (518) 357-2460

Website: www.dec.state.ny.us



Erin M. Crotty
Commissioner

April 12, 2004

Thomas J. Sullivan
Environmental Manager
Norlite Corporation
628 S. Saratoga Street
P.O. Box 694
Cohoes, NY 12047

RE: Permit Application #4-0103-16/16-0
Norlite Corporation
Part 373 minor permit modification
Cohoes (C), Albany County

Dear Mr. Sullivan:

This letter serves as a minor modification to the above-referenced permit. This modification shall be carried out in accordance with plans and specifications submitted on March 23, 2004 and modified by 4/6/03 letter and a 4/7/04 email. This project involves installing a pipe from the utility room to the trench in the Low Grade Fuel storage building and modifying the secondary containment in this building by allowing material pumped through this pipe to enter the secondary containment catchment area.

In accordance with 6 NYCRR 373-1.7 (c)(2)(v)(b), the installation of the pipe and modification of the hazardous-waste storage tanks' secondary containment are hereby incorporated into Norlite's Part 373 permit as a minor modification to the permit referenced above.

Feel free to contact me if you have any questions pertaining to this permit.

Sincerely,

William J. Clarke
Regional Permit Administrator
Region 4

373sumpapproval001.wpd

cc: P. Amin
H. Brezner
S. Chetty
P. Counterman
E. Dassatti
C. Van Guilder

New York State Department of Environmental Conservation

Division of Environmental Permits, Region 4

1150 North Westcott Road, Schenectady, New York 12306-2014

Phone: (518) 357-2069 • FAX: (518) 357-2460

Website: www.dec.state.ny.us



April 7, 2004

Thomas J. Sullivan
Environmental Manager
Norlite Corporation
628 S. Saratoga Street
P.O. Box 694
Cohoes, NY 12047

RE: Permit Application #4-0103-16/16-0
Norlite Corporation
Part 373 minor permit modification
Cohoes (C), Albany County

Dear Mr. Sullivan:

This letter serves as a minor modification to the above-referenced permit. This modification submitted on March 23, 2004 and modified by 4/6/03 letter and a 4/7/04 email involves installing a pipe from the utility room to the trench in the Low Grade Fuel storage building and modifying the secondary containment in this building by allowing material pump through this pipe to enter the secondary containment.

In accordance with 6 NYCRR 373-1.7 (c)(2)(v)(b), the installation of the pipe and modification of the hazardous-waste storage tanks' secondary containment are hereby incorporated into Norlite's Part 373 permit as a minor modification to the permit referenced above.


Feel free to contact me if you have any questions pertaining to this permit.

Sincerely,

William J. Clarke
Regional Permit Administrator

cc: P. Amin
H. Brezner
S. Chetty
P. Counterman
E. Dassatti
C. Van Guilder

Norlite Corporation



628 SO. SARATOGA ST.
P.O. BOX 694
COHOES, NY 12047
PHONE (518) 235-0401
FAX (518) 235-0233

April 6, 2004

Mr. William J. Clarke
Regional Permit Administrator
New York State Department of Environmental Conservation
Region 4
1150 North Wescott Road
Schenectady, NY 12306-2014

VIA CERTIFIED MAIL: 70031010000526537493
RETURN RECEIPT REQUESTED

Re: Utility Room Sump Project

VIA FACSIMILE @: (518) 357-2398

Dear Mr. Clarke:

As discussed with NYSDEC personnel on April 6, 2004, Norlite requests the utility room sump project be processed as a minor permit modification to its current Part 373 Permit.

There was also concern of how the piping will be located in the LGF Building. After the pipe from the utility room comes through the side of the LGF Building, above the concrete containment, the pipe will have a 90° elbow that will direct it to the trench of the LGF Building. There will be piping installed all the way from the 90° elbow directly into the floor trench.


Should you have any questions regarding this letter or should the Department require any additional information to process this minor permit modification, please contact me at (518) 235-0401.

Sincerely,

A handwritten signature in black ink, appearing to read "Thomas J. Sullivan".

Thomas J. Sullivan
Environmental Manager

Cc: Howard Brezner, NYSDEC-Region 4
Parag Amin, NYSDEC-Central Office



Norlite Corporation



628 SO. SARATOGA ST.
P.O. BOX 694
COHOES, NY 12047
PHONE (518) 235-0401
FAX (518) 235-0233

March 26, 2004

Mr. William J. Clarke
Regional Permit Administrator
New York State Department of Environmental Conservation
Region 4
1150 North Wescott Road
Schenectady, NY 12306-2014

VIA CERTIFIED MAIL: 70031010000526537431
RETURN RECEIPT REQUESTED

Re: Utility Room Sump Project

VIA FACSIMILE @: (518) 357-2398

Dear Mr. Clarke:

This letter is being sent to answer questions brought up during telephone conversations with Mr. Cliff VanGuilder of NYSDEC Region 4 on March 26, 2004.

This project is being put forth to make the operation safer and more efficient. The sump represents a permanent solution to the safety situation and also eliminates the need to manually remove the water. The object of the sump is to make sure the floor remains dry and to avoid the accumulation of water, which is a safety issue.

On an average weekly basis, approximately 20 to 50 gallons of water could be pumped out of the room. The water may be removed over the weekly period or all at once. Once the sump has been installed, this situation will be eliminated.


Should you have any questions regarding this letter please contact me at (518) 235-0401.

Sincerely,

A handwritten signature in black ink, appearing to read "Thomas J. Sullivan". The signature is written over a horizontal line.

Thomas J. Sullivan
Environmental Manager

Cc: Cliff VanGuilder, NYSDEC-Region 4
Howard Brezner, NYSDEC-Region 4
Sev Chetty, NYSDEC-Central Office





628 SO. SARATOGA ST.
P.O. BOX 694
COHOES, NY 12047
PHONE (518) 235-0401
FAX (518) 235-0233

March 23, 2004

Mr. William J. Clarke
Regional Permit Administrator
New York State Department of Environmental Conservation
Region 4
1150 North Wescott Road
Schenectady, NY 12306-2014

VIA CERTIFIED MAIL: 70031010000526537394
RETURN RECEIPT REQUESTED

Re: Utility Room Sump Project

Dear Mr. Clarke:

Attached is a letter and drawing that was sent to Mr. Parag Amin for an improvement project in the hazardous waste facility of the Norlite Corporation (Norlite). Norlite is under the impression a permit modification will not be needed for this project. Due to Mr. Amin's absence, Norlite would like to ensure a permit modification is not needed and gain approval of the project from the NYSDEC at Region 4.

The project will involve liquid being pumped from the sump that will be constructed in the LGF Utility Room to the LGF building trench. As shown in the drawing, the piping will be aboveground and will enter the LGF building above the concrete wall, therefore avoiding a breach of the concrete containment structure. Norlite is prepared to implement the project upon approval by the NYSDEC.


Should you have any questions regarding this letter please contact me at (518) 235-0401.




Sincerely,

Thomas J. Sullivan
Environmental Manager

Attachments (letter and Utility Bldg Dwg)

Cc: Anthony Kokocki, NYSDEC-Region 4 w/ attachments
Cliff VanGuilder, NYSDEC-Region 4 w/ attachments
Howard Brezner, NYSDEC-Region 4 w/ attachments





INFORMATION PRESENTED ON THIS DRAWING HAS BEEN COMPILED FROM CURRENT FIELD DATA AND INFORMATION PROVIDED BY NORLITE CORPORATION.

REV.		DESCRIPTION		DRWN.	ENG.	CHK.	DATE	DRAWN BY: T.V.B.		DATE: 02/08/2004	DRAWING/FILE REF:	
<small>This drawing is property of HMK P.E., including all patented and patentable features, and / or confidential information and is loaned to the user's agreement not to reproduce the drawing, in whole or part, nor the material described therein, nor the use of the drawing for any purpose other than specifically permitted in writing by HMK P.E.</small>								ENGINEER: H.M.K.		FILE NAME: UTILITY BLDG.DWG	DRAWING NO. X	

CLIENT APPROVAL: _____ DATE: _____

HARVEY M. KING, P.E.
ENVIRONMENTAL ENGINEERS & SCIENTISTS
4 STONY BROOK DRIVE, REXFORD, NEW YORK 12148-1608

NORLITE CORPORATION - COHOES, NY
UTILITY BUILDING
VACUUM PUMP ROOM
SUMP INSTALLATION

FOR PERMIT PURPOSES ONLY

