

NEW YORK STATE DEPARTMENT OF ENVIRONMENTAL CONSERVATION

Division of Water, Bureau of Water Permits
625 Broadway, Albany, New York 12233-3505
P: (518) 402-8111 | F: (518) 402-9029
www.dec.ny.gov

August 7, 2017

SENT VIA EMAIL

Prince Knight
Environmental & Compliance Manager
Tradebe Environmental Services, LLC
Prince.Knight@tradebe.com

Dear Mr. Knight,

On July 3, 2017, the New York State Department of Environmental Conservation (“the Department”) received Tradebe Environmental Services’, LLC (“Tradebe”) response to Department comments. These responses are considered acceptable.

Norlite may proceed with the interim study as requested in the March 29, 2017 letter. The study, as outlined in the letter, will use 50% hydrogen peroxide and will be conducted for a period of 30 days. At the end of the study period, Norlite will return to normal wastewater treatment plant operation using sodium hypochlorite. Norlite will submit a final report with the results of the study. This report will be submitted 30 days after the conclusion of the study.

After reviewing prior submissions, it was noted that Norlite has not yet submitted a Water Treatment Chemical (“WTC”) Notification Form for hydrogen peroxide. Prior to commencing the interim study, please submit a WTC form to the Department for review and authorization to proceed.

Should you have any questions regarding this letter, contact me at (518) 402-8278.

Sincerely,



Carrie Smith, P.E.
Assistant Engineer (Environmental)
Division of Water

Cc: James Malcolm, DEC
Kate Kornak, DEC
Dave Maguffin, Tradebe