



# State Pollutant Discharge Elimination System (SPDES) DISCHARGE PERMIT

SIC Code:	<b>4952</b>	NAICS Code:	<b>221320</b>	SPDES Number:	<b>NY 002 8851</b>
Discharge Class (CL):	<b>05</b>	DEC Number:	<b>3-3928-00026/00002</b>		
Toxic Class (TX):	<b>T</b>	Effective Date (EDP):	<b>TBD</b>		
Major-Sub Drainage Basin:	<b>13 - 01</b>	Expiration Date (ExDP):	<b>TBD</b>		
Water Index Number:	<b>H portion</b>	Item No.:	<b>864 - 2</b>	Modification Dates (EDPM):	
Compact Area:	<b>IEC</b>				

This SPDES permit is issued in compliance with Title 8 of Article 17 of the Environmental Conservation Law of New York State and in compliance with the Clean Water Act, as amended, (33 U.S.C. '1251 et.seq.)

PERMITTEE NAME AND ADDRESS						
Name:	<b>Town of Stony Point</b>			Attention:	<b>Supervisor and Town Board</b>	
Street:	<b>74 East Main Street</b>					
City:	<b>Stony Point</b>			State:	<b>NY</b>	Zip Code: <b>10980</b>
Email:	<b>supervisor@townofstonypoint.org</b>			Phone:	<b>(845) 786-2716</b>	

is authorized to discharge from the facility described below:

FACILITY NAME, ADDRESS, AND PRIMARY OUTFALL										
Name:	<b>Town of Stony Point Sewage Treatment Plant</b>									
Address / Location:	<b>24 North Street</b>						County:	<b>Rockland</b>		
City:	<b>Stony Point</b>				State:	<b>NY</b>	Zip Code:	<b>10980</b>		
Facility Location:	Latitude:	<b>41</b> °	<b>13</b> '	<b>21</b> " N	& Longitude:	<b>73</b> °	<b>57</b> '	<b>56</b> " W		
Primary Outfall No.:	<b>001</b>	Latitude:	<b>41</b> °	<b>13</b> '	<b>20</b> " N	& Longitude:	<b>73</b> °	<b>57</b> '	<b>35</b> " W	
Outfall Description:	<b>Treated Sanitary</b>	Receiving Water:	<b>Hudson River</b>			Class:	<b>SB</b>	Standard:	<b>-</b>	

in accordance with: effluent limitations; monitoring and reporting requirements; other provisions and conditions set forth in this permit; and 6 NYCRR Part 750-1 and 750-2.

This permit and the authorization to discharge shall expire on midnight of the expiration date shown above and the permittee shall not discharge after the expiration date unless this permit has been renewed or extended pursuant to law. To be authorized to discharge beyond the expiration date, the permittee shall apply for permit renewal not less than 180 days prior to the expiration date shown above.

DISTRIBUTION:

Permit Administrator:	
Address:	<b>21 South Putt Corners Road New Paltz, NY 12477</b>
Signature	Date

## Contents

DEFINITIONS	3
PERMIT LIMITS, LEVELS AND MONITORING (During Construction)	4
PERMIT LIMITS, LEVELS AND MONITORING (Post Construction)	6
STORMWATER POLLUTION PREVENTION REQUIREMENTS	9
MERCURY MINIMIZATION PROGRAM (MMP) - Type I	10
MERCURY MINIMIZATION PROGRAM (MMP) - Type I (Continued)	11
DISCHARGE NOTIFICATION REQUIREMENTS	13
SCHEDULE OF COMPLIANCE	14
MONITORING LOCATIONS	15
GENERAL REQUIREMENTS	16
RECORDING, REPORTING AND ADDITIONAL MONITORING REQUIREMENTS	18
E. Schedule of Additional Submittals:	18

## DEFINITIONS

TERM	DEFINITION
7-Day Geo Mean	The highest allowable geometric mean of daily discharges over a calendar week.
7-Day Average	The average of all daily discharges for each 7-days in the monitoring period. The sample measurement is the highest of the 7-day averages calculated for the monitoring period.
12-Month Rolling Average (12 MRA)	The current monthly value of a parameter, plus the sum of the monthly values over the previous 11 months for that parameter, divided by the number of months for which samples were collected in the 12-month period.
30-Day Geometric Mean	The highest allowable geometric mean of daily discharges over a calendar month, calculated as the antilog of: the sum of the log of each of the daily discharges measured during a calendar month divided by the number of daily discharges measured during that month.
Action Level	Action level means a monitoring requirement characterized by a numerical value that, when exceeded, triggers additional permittee actions and department review to determine if numerical effluent limitations should be imposed.
Compliance Level / Minimum Level	A compliance level is an effluent limitation. A compliance level is given when the water quality evaluation specifies a Water Quality Based Effluent Limit (WQBEL) below the Minimum Level. The compliance level shall be set at the Minimum Level (ML) for the most sensitive analytical method as given in 40 CFR Part 136, or otherwise accepted by the Department.
Daily Discharge	The discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for the purposes of sampling. For pollutants expressed in units of mass, the 'daily discharge' is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurement, the 'daily discharge' is calculated as the average measurement of the pollutant over the day.
Daily Maximum	The highest allowable Daily Discharge.
Daily Minimum	The lowest allowable Daily Discharge.
Effective Date of Permit (EDP or EDPM)	The date this permit is in effect.
Effluent Limitations	Effluent limitation means any restriction on quantities, quality, rates and concentrations of chemical, physical, biological, and other constituents of effluents that are discharged into waters of the state.
Expiration Date of Permit (ExDP)	The date this permit is no longer in effect.
Instantaneous Maximum	The maximum level that may not be exceeded at any instant in time.
Instantaneous Minimum	The minimum level that must be maintained at all instants in time.
Monthly Average	The highest allowable average of daily discharges over a calendar month, calculated as the sum of each of the daily discharges measured during a calendar month divided by the number of daily discharges measured during that month.
Outfall	The terminus of a sewer system, or the point of emergence of any waterborne sewage, industrial waste or other wastes or the effluent therefrom, into the waters of the State.
Range	The minimum and maximum instantaneous measurements for the reporting period must remain between the two values shown.
Receiving Water	The classified waters of the state to which the listed outfall discharges.
Sample Frequency / Sample Type / Units	See NYSDEC's "DMR Manual for Completing the Discharge Monitoring Report for the SPDES" for information on sample frequency, type and units.

## PERMIT LIMITS, LEVELS AND MONITORING (During Construction)

OUTFALL	LIMITATIONS APPLY	RECEIVING WATER	EFFECTIVE	EXPIRING
001	All year unless noted otherwise	Hudson River	EDP	Construction completion

PARAMETER	EFFLUENT LIMITATION					MONITORING REQUIREMENTS				FN
	Type	Limit	Units	Limit	Units	Sample Frequency	Sample Type	Location		
								Inf.	Eff.	
Flow	Monthly Average	1.0	MGD			Continuous	Recorder	X		
BOD <sub>5</sub>	Monthly Average	30	mg/L	250	lbs/d	1/week	24-hr. Comp.	X	X	1
	7-Day Average	45	mg/L	375	lbs/d				X	
	6-Consecutive Hour Average	50	mg/L							3
Total Suspended Solids (TSS)	Monthly Average	30	mg/L	250	lbs/d	1/week	24-hr. Comp.	X	X	1
	7-Day Average	45	mg/L	375	lbs/d				X	
	6-Consecutive Hour Average	50	mg/L							3
Settleable Solids	Daily Maximum	0.3	mL/L			2/day	Grab		X	
pH	Daily Minimum	6.0	SU			2/day	Grab		X	
	Daily Maximum	9.0	SU							
Temperature	Daily Maximum	Monitor	°F			2/day	Grab		X	
Ammonia (as N)	Monthly Average	Monitor	mg/L			1/quarter	24-hr. Comp.		X	5
Total Kjeldahl Nitrogen (TKN) (as N)	Monthly Average	Monitor	mg/L			1/quarter	24-hr. Comp.		X	5
Nitrite (as N)	Monthly Average	Monitor	mg/L			1/quarter	24-hr. Comp.		X	5
Nitrate (as N)	Monthly Average	Monitor	mg/L			1/quarter	24-hr. Comp.		X	5

EFFLUENT DISINFECTION		Limit	Units	Limit	Units	Sample Frequency	Sample Type	Inf.	Eff.	FN
Required Seasonal from May 1st - October 31st										
Coliform, Fecal	30-Day Geometric Mean	200	No./100 mL			1/week	Grab		X	2
Coliform, Fecal	7-Day Geometric Mean	400	No./100 mL			1/week	Grab		X	2
Coliform, Fecal	6-Hour Geometric Mean	800	No./100 mL							2,3
Coliform, Fecal	Individual Sample	2400	No./100 mL							2,3
Chlorine, Total Residual	Daily Maximum	1.0	mg/L			2/day	Grab		X	2,4

**FOOTNOTES:**

- And effluent shall not exceed 15% and 15% of influent concentration values for BOD<sub>5</sub> & TSS respectively.

2. Monitoring of these parameters is only required during the period when disinfection is required.
3. This is an Interstate Environmental Commission (IEC) requirement. The permittee is not required to perform this sampling but shall be required to meet the permit limit at all times. EPA, DEC, or IEC may perform the sampling.
4. Sampling and reporting for total residual chlorine are only necessary if chlorine is used for disinfection, elsewhere in the treatment process, or the facility otherwise has reasonable potential to discharge chlorine. Otherwise, the permittee shall report NODI-9 on the DMR.
5. Quarterly samples shall be collected in calendar quarters (Q1 – January 1<sup>st</sup> to March 31<sup>st</sup>; Q2 – April 1<sup>st</sup> to June 30<sup>th</sup>; Q3 – July 1<sup>st</sup> to September 30<sup>th</sup>; Q4 – October 1<sup>st</sup> to December 31<sup>st</sup>).

## PERMIT LIMITS, LEVELS AND MONITORING (Post Construction)

OUTFALL	LIMITATIONS APPLY	RECEIVING WATER	EFFECTIVE	EXPIRING
001	All year unless noted otherwise	Hudson River	Construction completion	ExDP

PARAMETER	EFFLUENT LIMITATION					MONITORING REQUIREMENTS				FN
	Type	Limit	Units	Limit	Units	Sample Frequency	Sample Type	Location		
								Inf.	Eff.	
Flow	Monthly Average	1.8	MGD			Continuous	Recorder	X		
pH	Daily Minimum	6.0	SU			2/day	Grab		X	
	Daily Maximum	9.0	SU							
Temperature	Daily Maximum	Monitor	°F			2/day	Grab		X	
BOD <sub>5</sub>	Monthly Average	30	mg/L	450	lbs/d	1/week	24-hr. Comp.	X	X	1
	7-Day Average	45	mg/L	680	lbs/d				X	
	6-Consecutive Hour Average	50	mg/L							5
Total Suspended Solids (TSS)	Monthly Average	30	mg/L	450	lbs/d	1/week	24-hr. Comp.	X	X	1
	7-Day Average	45	mg/L	680	lbs/d				X	
	6-Consecutive Hour Average	50	mg/L							5
Settleable Solids	Daily Maximum	0.3	mL/L			2/day	Grab		X	
Ammonia (as N)	Monthly Average	Monitor	mg/L			1/quarter	24-hr. Comp.		X	4
Total Kjeldahl Nitrogen (TKN) (as N)	Monthly Average	Monitor	mg/L			1/quarter	24-hr. Comp.		X	4
Nitrite (as N)	Monthly Average	Monitor	mg/L			1/quarter	24-hr. Comp.		X	4
Nitrate (as N)	Monthly Average	Monitor	mg/L			1/quarter	24-hr. Comp.		X	4
Total Mercury	Daily Maximum	50	ng/L			1/month	Grab	X	X	
Biennial Pollutant Scan						1/Two Years	-		X	2

EFFLUENT DISINFECTION		Limit	Units	Limit	Units	Sample Frequency	Sample Type	Inf.	Eff.	FN
Required Seasonal from May 1st - October 31st										
Coliform, Fecal	30-Day Geometric Mean	200	No./100 mL			1/week	Grab		X	
Coliform, Fecal	7-Day Geometric Mean	400	No./100 mL			1/week	Grab		X	
Coliform, Fecal	6-Hour Geometric Mean	800	No./100 mL							5
Coliform, Fecal	Individual Sample	2400	No./100 mL							5
Chlorine, Total Residual	Daily Maximum	0.75	mg/L			2/day	Grab		X	3

WHOLE EFFLUENT TOXICITY (WET) TESTING		Limit	Units	Action Level	Units	Sample Frequency	Sample Type	Inf.	Eff.	FN
WET - Acute Invertebrate	See footnote			6.3	TUa	1/quarter	See footnote		X	4,6
WET - Acute Vertebrate	See footnote			6.3	TUa	1/quarter	See footnote		X	4,6
WET - Chronic Invertebrate	See footnote			100	TUc	1/quarter	See footnote		X	4,6
WET - Chronic Vertebrate	See footnote			100	TUc	1/quarter	See footnote		X	4,6

**FOOTNOTES:**

1. Effluent shall not exceed 15% of influent concentration values for BOD<sub>5</sub> & TSS.
2. Biennial Pollutant Scan: The permittee shall perform effluent sampling every two (2) years for all applicable pollutants identified in the NY-2A Application, Tables A - D. Sampling data shall be collected according to the guidance in the NY-2A application and maintained by the permittee. Monitoring results shall not be submitted on the DMR. Data shall be submitted with the next submission of the NY-2A form.
3. Sampling and reporting for total residual chlorine are only necessary if chlorine is used for disinfection, elsewhere in the treatment process, or the facility otherwise has reasonable potential to discharge chlorine. Otherwise, the permittee shall report NODI-9 on the DMR.
4. Quarterly samples shall be collected in calendar quarters (Q1 – January 1<sup>st</sup> to March 31<sup>st</sup>; Q2 – April 1<sup>st</sup> to June 30<sup>th</sup>; Q3 – July 1<sup>st</sup> to September 30<sup>th</sup>; Q4 – October 1<sup>st</sup> to December 31<sup>st</sup>).
5. This is an Interstate Environmental Commission (IEC) requirement. The permittee is not required to perform this sampling but shall be required to meet the permit limit at all times. EPA, DEC, or IEC may perform the sampling.
6. **Whole Effluent Toxicity (WET) Testing:**  
Testing Requirements – Acute and if directed Chronic WET testing is required. Testing shall be performed in accordance with 40 CFR Part 136 and TOGS 1.3.2 unless prior written approval has been obtained from the Department. The test species shall be *Mysidopsis bahia* (mysid shrimp - invertebrate) and *Cyprinodon variegatus* (sheepshead minnow - vertebrate). Artificial salt water should be used for dilution. All tests conducted should be static-renewal (two 24-hr composite samples with one renewal for Acute tests and three 24-hr composite samples with two renewals for Chronic tests). The appropriate dilution series should be used to generate a definitive test endpoint, otherwise an immediate rerun of the test may be required. WET testing shall be coordinated with the monitoring of chemical and physical parameters limited by this permit so that the resulting analyses are also representative of the sample used for WET testing. The ratio of critical receiving water flow to discharge flow (i.e. dilution ratio) is 21.1:1 for acute, and 100:1 for chronic.

Monitoring Period - WET testing shall be performed quarterly (calendar quarters) during calendar years ending in 0 and 5.

Reporting - Toxicity Units shall be calculated and reported on the DMR as follows: TUa = (100)/(48-hr LC50) [note that Acute data is generated by both Acute and Chronic testing] and TUc = (100)/(7-day NOEC) or (100)/(7-day IC25) when Chronic testing has been performed or TUc = (TUa) x (10) when only Acute testing has been performed and is used to predict Chronic test results, where the 48-hr LC50, 7-day NOEC and/or IC25 are all expressed in % effluent. This must be done, including the Chronic prediction from the Acute data, for both species unless otherwise directed. For Chronic results, report the most sensitive endpoint (i.e. survival, growth and/or reproduction) corresponding to the lowest 7-day NOEC or IC25 and resulting highest TUc. For Acute results, report a TUa of 0.3 if there is no statistically significant mortality in 100% effluent as compared to the control. Report a TUa of 1.0 if there is statistically significant mortality in 100% effluent as compared to the control, but insufficient mortality to generate a 48-hr LC50. Also, in the absence of a 48-hr LC50, use 1.0 TUa for the Chronic prediction from the Acute data, and report a TUc of 10.0.

The complete test report including all bench sheets, statistical analyses, reference toxicity data, daily average flow at the time of sampling and other appropriate supporting documentation, shall be submitted within 60 days following the end of each test period with your WET DMR and to the [WET@dec.ny.gov](mailto:WET@dec.ny.gov) email address. A summary page of

the test results for the invertebrate and vertebrate species indicating TUa, 48-hr LC50 for Acute tests and/or TUC, NOEC, IC25, and most sensitive endpoints for Chronic tests, should also be included at the beginning of the test report.

WET Testing Action Level Exceedances - If an action level is exceeded then the Department may require the permittee to conduct additional WET testing including Acute and/or Chronic tests. Additionally, the permittee may be required to perform a Toxicity Identification/Reduction Evaluation (TI/RE) in accordance with Department guidance. Enforceable WET limits may also apply. The permittee shall be notified in writing by their Regional DEC office of additional requirements. The written notification shall include the reason(s) why such testing, TI/RE and/or limits are required.



## STORMWATER POLLUTION PREVENTION REQUIREMENTS

### **NO EXPOSURE CERTIFICATION**

The permittee submitted a Conditional Exclusion for No Exposure Form on 6/12/2023, certifying that all industrial activities and materials are completely sheltered from exposure to rain, snow, snowmelt, and/or stormwater runoff. The permittee must maintain a condition of no exposure for the exclusion to remain applicable. If conditions change resulting in the exposure of materials and activities to stormwater, the permittee must notify the Regional Water Engineer. The permittee must recertify a condition of no exposure every five years by completing the "No Exposure Certification Form" found on the NYSDEC website.

## MERCURY MINIMIZATION PROGRAM (MMP) - Type I

1. General - The permittee must develop, implement, and maintain a mercury minimization program (MMP), containing the elements set forth below, to reduce mercury effluent levels with the goal of achieving the WQBEL of 0.7 ng/L.
2. MMP Elements - The MMP must be a written document and must include any necessary drawings or maps of the facility and/or collection system. Other related documents already prepared for the facility may be used as part of the MMP and may be incorporated by reference. At a minimum, the MMP must include the following elements as described in detail below:
  - a. Monitoring - Monitoring at Outfall 001, influent and other locations tributary to compliance points shall be performed using either USEPA Method 1631 or another sufficiently sensitive method, as approved under 40 CFR Part 136<sup>1</sup>. Monitoring of raw materials, equipment, treatment residuals, and other non-wastewater/non-stormwater substances may be performed using other methods as appropriate. Monitoring must be coordinated so that the results can be effectively compared between locations.

Minimum required monitoring is as follows:

- i. Sewage Treatment Plant Influent and/or Effluent – The permittee must collect samples at the location(s) and frequency as specified in the SPDES permit limitations table.
  - ii. Key Locations and Potential Mercury Sources – The permittee must sample *key locations*, chosen to identify *potential mercury sources*, at least semi-annually. Sampling of discharges from dental facilities in compliance with 6 NYCRR 374.4 is not required.
  - iii. Hauled Wastes – The permittee must establish procedures for the acceptance of hauled waste to ensure the hauled waste is not a potential mercury source. Loads which may exceed 500 ng/L,<sup>2</sup> must receive approval from the Department prior to acceptance.
  - iv. Decreased Monitoring Requirements - Facilities with EEQ at or below 12 ng/L are eligible for the following:
    - 1) Reduced requirements, through a permittee-initiated permit modification
      - a) Conduct influent monitoring, sampling quarterly, in lieu of monitoring within the collection system, such as at *key locations*; and
      - b) Conduct effluent compliance sampling quarterly.
    - 2) If a facility with reduced requirements reports discharges above 12 ng/L for two of four consecutive effluent samples, the Department may undertake a Department-initiated modification to remove the allowance of reduced requirements.
    - 3) Under the decreased permit requirements, the facility must continue to conduct a status report, as applicable in accordance with 2.c of this MMP, to determine if any waste streams have changed.
  - v. Additional monitoring must be completed as required elsewhere in this permit (e.g., locations tributary to compliance points).
- b. Control Strategy - The control strategy must contain the following minimum elements:
    - i. Pretreatment/Sewer Use Law - The permittee must review pretreatment program requirements and the Sewer Use Law (SUL) to ensure it is up-to-date and enforceable with applicable permit requirements and will support efforts to achieve a dissolved mercury concentration of 0.70 ng/L in the effluent.
    - ii. Monitoring and Inventory/Inspections for Outfall 001 -
      - 1) Monitoring shall be performed as described in 2.a above. As mercury sources are found, the permittee must enforce its sewer use law to track down and minimize these sources.
      - 2) The permittee must inventory and/or inspect users of its system as necessary to support the MMP.
        - a) Dental Facilities
          1. The permittee must maintain an inventory of each dental facility.

<sup>1</sup> Outfall monitoring must be conducted using the methods specified in Table 8 of *DOW 1.3.10*.

<sup>2</sup>A level of 0.2 mg/L (200,000 ng/L) or more is considered hazardous per 40 CFR Part 261.11. 500 ng/L is used here to alert the permittee that there is an unusual concentration of mercury and that it will need to be managed appropriately.

## MERCURY MINIMIZATION PROGRAM (MMP) - Type I (Continued)

2. The permittee must inspect each dental facility at least once every five years to verify compliance with the wastewater treatment operation, maintenance, and notification elements of 6 NYCRR 374.4. Alternatively, the permittee may develop and implement an outreach program,<sup>3</sup> which informs users of their responsibilities, and collect the “Amalgam Waste Compliance Report for Dental Dischargers”<sup>4</sup> form, as needed, to satisfy the inspection requirements. The permittee must conduct the outreach program at least once every five years and ensure the “Amalgam Waste Compliance Report for Dental Dischargers” are submitted by new users, as necessary. The outreach program could be supported by a subset of site inspections.
  3. A file shall be maintained containing documentation demonstrating compliance with 2.b.ii.2)a) above. This file shall be available for review by the Department representatives and copies shall be provided upon request.
- b) *Other potential mercury sources*
1. The permittee must maintain an inventory of other *potential mercury sources*.
  2. The permittee must inspect other *potential mercury sources* once every five years. Alternatively, the permittee may develop and implement an outreach program which informs users of their responsibilities as *potential mercury sources*. The permittee must conduct the outreach program at least once every five years. The outreach program should be supported by a subset of site inspections.
  3. A file shall be maintained containing documentation demonstrating compliance with 2.b.ii.2)b) above. This file shall be available for review by the Department representatives and copies shall be provided upon request.
- iii. Systems with CSO & Type II SSO Outfalls – Permittees must prioritize *potential mercury sources* upstream of CSOs and Type II SSOs for mercury reduction activities and/or controlled-release discharge.
- iv. Equipment and Materials – Equipment and materials (e.g., thermometers, thermostats) used by the permittee, which may contain mercury, must be evaluated by the permittee. As equipment and materials containing mercury are updated/replaced, the permittee must use mercury-free alternatives, if possible.
- v. Bulk Chemical Evaluation – For chemicals, used at a rate which exceeds 1,000 gallons/year or 10,000 pounds/year, the permittee must obtain a manufacturer’s certificate of analysis, a chemical analysis performed by a certified laboratory, and/or a notarized affidavit which describes the substances’ mercury concentration and the detection limit achieved. If possible, the permittee must only use bulk chemicals utilized in the wastewater treatment process which contain <10 ppb mercury.
- c. **Status Report - An annual** status report must be developed and maintained on site, in accordance with the [Schedule of Additional Submittals](#), summarizing:
- i. All MMP monitoring results for Outfall 001 for the previous reporting period;
  - ii. A list of known and *potential mercury sources* for Outfall 001
    - 1) If the permittee meets the criteria for MMP Type IV, the permittee must notify the Department for a permittee-initiated modification;
  - iii. All actions undertaken, pursuant to the control strategy, during the previous reporting period;
  - iv. Actions planned, pursuant to the control strategy, for the upcoming reporting period; and
  - v. Progress towards achieving a dissolved mercury concentration of 0.70 ng/L in the effluent (e.g., summarizing reductions in effluent concentrations as a result of the control strategy implementation and/or installation/modification of a treatment system).
- The permittee must maintain a file with all MMP documentation. The file must be available for review by Department representatives and copies must be provided upon request in accordance with 6 NYCRR 750-2.1(i) and 750-2.5(c)(4).

<sup>3</sup> For example, the outreach program could include education about sources of mercury and what to do if a mercury source is found.

<sup>4</sup> The form, “Amalgam Waste Compliance Report for Dental Dischargers,” can be found here:  
[https://www.dec.ny.gov/docs/water\\_pdf/dentalform.pdf](https://www.dec.ny.gov/docs/water_pdf/dentalform.pdf)

3. MMP Modification - The MMP must be modified whenever:
  - a. Changes at the facility, or within the collection system, increase the potential for mercury discharges;
  - b. Effluent discharges exceed the current permit limitation(s); or
  - c. A letter from the Department identifies inadequacies in the MMP.

The Department may use information in the status reports, as applicable in accordance with 2.c of this MMP, to determine if the permit limitations and MMP Type is appropriate for the facility.

**DEFINITIONS:**

**Key location** – a location within the collection/wastewater system (e.g. including but not limited to a specific manhole/access point, tributary sewer/wastewater connection, or user discharge point) identified by the permittee as a potential mercury source. The permittee may adjust key locations based upon sampling and/or best professional judgement.

**Potential mercury source** – a source identified by the permittee that may reasonably be expected to have total mercury contained in the discharge. Some potential mercury sources include switches, fluorescent lightbulbs, cleaners, degreasers, thermometers, batteries, hauled wastes, universities, hospitals, laboratories, landfills, Brownfield sites, or raw material storage.

## DISCHARGE NOTIFICATION REQUIREMENTS

- (a) The permittee shall install and maintain identification signs at all outfalls to surface waters listed in this permit, unless the Permittee has obtained a waiver in accordance with the Discharge Notification Act (DNA). Such signs shall be installed before initiation of any new discharge location.
- (b) Subsequent modifications to or renewal of this permit does not reset or revise the deadline set forth in (a) above, unless a new deadline is set explicitly by such permit modification or renewal.
- (c) The Discharge Notification Requirements described herein do not apply to outfalls from which the discharge is composed exclusively of storm water, or discharges to ground water.
- (d) The sign(s) shall be conspicuous, legible and in as close proximity to the point of discharge as is reasonably possible while ensuring the maximum visibility from the surface water and shore. The signs shall be installed in such a manner to pose minimal hazard to navigation, bathing or other water related activities. If the public has access to the water from the land in the vicinity of the outfall, an identical sign shall be posted to be visible from the direction approaching the surface water.

The signs shall have **minimum** dimensions of eighteen inches by twenty-four inches (18" x 24") and shall have white letters on a green background and contain the following information:

<p><b>N.Y.S. PERMITTED DISCHARGE POINT</b></p> <p><b>SPDES PERMIT No.: NY_____</b></p> <p><b>OUTFALL No. : _____</b></p> <p>For information about this permitted discharge contact:</p> <p>Permittee Name: _____</p> <p>Permittee Contact: _____</p> <p>Permittee Phone: ( ) - ### - #####</p> <p>OR:</p> <p>NYSDEC Division of Water Regional Office Address:</p> <p>NYSDEC Division of Water Regional Phone: ( ) - ### - #####</p>
--

- (e) Upon request, the permittee shall make available electronic or hard copies of the sampling data to the public. In accordance with the RECORDING, REPORTING AND ADDITIONAL MONITORING REQUIREMENTS page of your permit, each DMR shall be maintained (either electronically or as a hard copy) on record for a period of five years.
- (f) The permittee shall periodically inspect the outfall identification sign(s) in order to ensure they are maintained, are still visible, and contain information that is current and factually correct. Signs that are damaged or incorrect shall be replaced within 3 months of inspection.

## SCHEDULE OF COMPLIANCE

a) The permittee shall comply with the following schedule:

Outfall(s)	Compliance Action	Compliance Date <sup>5</sup>
	<p><b>COMPLETE CONSTRUCTION</b>                      The permittee shall provide a Certificate of Completion<sup>6</sup> to the Department that the disposal system has been fully completed in accordance with the approved Design Documents.</p>	<p>Per Design Documents</p>
	<p><b>COMMENCE OPERATION</b>                      Following receipt of Department acceptance of Certificate of Completion, the permittee shall comply with the final effluent limitation(s) described in this permit.</p>	<p>Upon Department Acceptance</p>
<p><b>Unless noted otherwise, the above actions are one-time requirements.</b></p>		

- b) The permittee shall submit a notice of non-compliance with each of the above schedule dates no later than 14 days following each elapsed date, unless conditions require more immediate notice as prescribed in 6 NYCRR Part 750-1.2(a) and 750-2. All notifications shall be sent to the locations listed under the section of this permit entitled RECORDING, REPORTING AND ADDITIONAL MONITORING REQUIREMENTS. Each notice of non-compliance shall include the following information:
1. A short description of the non-compliance;
  2. A description of any actions taken or proposed by the permittee to comply with the elapsed schedule requirements without further delay and to limit environmental impact associated with the non-compliance;
  3. Any details which tend to explain or mitigate an instance of non-compliance; and
  4. An estimate of the date the permittee will comply with the elapsed schedule requirement and an assessment of the probability that the permittee will meet the next scheduled requirement on time.
- c) The permittee shall submit copies of any document required by the above schedule of compliance to the NYSDEC Regional Water Engineer and to the Bureau of Water Permits.

<sup>5</sup> 6 NYCRR 750-1.14 (a)


<sup>6</sup> 6 NYCRR 750-2.10 (c)

## MONITORING LOCATIONS

The permittee shall take samples and measurements, to comply with the monitoring requirements specified in this permit, at the locations(s) specified below:

Influent: Headworks

Effluent: After UV Disinfection



## GENERAL REQUIREMENTS

A. The regulations in 6 NYCRR Part 750 are hereby incorporated by reference and the conditions are enforceable requirements under this permit. The permittee shall comply with all requirements set forth in this permit and with all the applicable requirements of 6 NYCRR Part 750 incorporated into this permit by reference, including but not limited to the regulations in paragraphs B through I as follows:

### B. General Conditions

- |  |   |
|--|---|
| 1. Duty to comply                                | 6 NYCRR 750-2.1(e) & 2.4                |
| 2. Duty to reapply                               | 6 NYCRR 750-1.16(a)                     |
| 3. Need to halt or reduce activity not a defense | 6 NYCRR 750-2.1(g)                      |
| 4. Duty to mitigate                              | 6 NYCRR 750-2.7(f)                      |
| 5. Permit actions                                | 6 NYCRR 750-1.1(c), 1.18, 1.20 & 2.1(h) |
| 6. Property rights                               | 6 NYCRR 750-2.2(b)                      |
| 7. Duty to provide information                   | 6 NYCRR 750-2.1(i)                      |
| 8. Inspection and entry                          | 6 NYCRR 750-2.1(a) & 2.3                |

### C. Operation and Maintenance

- |                                   |                                      |
|-----------------------------------|--------------------------------------|
| 1. Proper Operation & Maintenance | 6 NYCRR 750-2.8                      |
| 2. Bypass                         | 6 NYCRR 750-1.2(a)(17), 2.8(b) & 2.7 |
| 3. Upset                          | 6 NYCRR 750-1.2(a)(94) & 2.8(c)      |

### D. Monitoring and Records

- |                           |  |
|---------------------------|--|
| 1. Monitoring and records | 6 NYCRR 750-2.5(a)(2), 2.5(a)(6), 2.5(c)(1), 2.5(c)(2), & 2.5(d) |
| 2. Signatory requirements | 6 NYCRR 750-1.8 & 2.5(b)   |

### E. Reporting Requirements

- |   |                             |
|---|-----------------------------|
| 1. Reporting requirements                     | 6 NYCRR 750-2.5, 2.7 & 1.17 |
| 2. Anticipated noncompliance                  | 6 NYCRR 750-2.7(a)          |
| 3. Transfers                                  | 6 NYCRR 750-1.17            |
| 4. Monitoring reports                         | 6 NYCRR 750-2.5(e)          |
| 5. Compliance schedules                       | 6 NYCRR 750-1.14(d)         |
| 6. 24-hour reporting                          | 6 NYCRR 750-2.7(c) & (d)    |
| 7. Other noncompliance                        | 6 NYCRR 750-2.7(e)          |
| 8. Other information                          | 6 NYCRR 750-2.1(f)          |
| 9. Additional conditions applicable to a POTW | 6 NYCRR 750-2.9             |

### F. Planned Changes

1. The permittee shall give notice to the Department as soon as possible of planned physical alterations or additions to the permitted facility when:
  - a. The alteration or addition to the permitted facility may meet any of the criteria for determining whether facility is a new source in 40 CFR §122.29(b); or
  - b. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants which are subject either to effluent limitations in the permit, or to notification requirements under 40 CFR §122.42(a)(1); or
  - c. The alteration or addition results in a significant change in the permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan.

In addition to the Department, the permittee shall submit a copy of this notice to the United States Environmental Protection Agency at the following address: U.S. EPA Region 2, Clean Water Regulatory Branch, 290 Broadway, 24th Floor, New York, NY 10007-1866.



## GENERAL REQUIREMENTS (continued)

### 2. Notification Requirement for POTWs

All POTWs shall provide adequate notice to the Department and the USEPA of the following:

- a. Any new introduction of pollutants into the POTW from an indirect discharger which would be subject to section 301 or 306 of CWA if it were directly discharging those pollutants; or
- b. Any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of issuance of the permit.
- c. For the purposes of this paragraph, adequate notice shall include information on:
  - i. the quality and quantity of effluent introduced into the POTW, and
  - ii. any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW.

POTWs shall submit a copy of this notice to the United States Environmental Protection Agency, at the following address:

U.S. EPA Region 2, Clean Water Regulatory Branch, 290 Broadway, 24th Floor, New York, NY 10007-1866

### G. Sludge Management

The permittee shall comply with all applicable requirements of 6 NYCRR Part 360.

### H. SPDES Permit Program Fee

The permittee shall pay to the Department an annual SPDES permit program fee within 30 days of the date of the first invoice, unless otherwise directed by the Department, and shall comply with all applicable requirements of ECL 72-0602 and 6 NYCRR Parts 480, 481 and 485. Note that if there is inconsistency between the fees specified in ECL 72-0602 and 6 NYCRR Part 485, the ECL 72-0602 fees govern.

### I. Water Treatment Chemicals (WTCs)

New or increased use and discharge of a WTC requires prior Department review and authorization. At a minimum, the permittee must notify the Department in writing of its intent to change WTC use by submitting a completed *WTC Notification Form* for each proposed WTC. The Department will review that submittal and determine if a SPDES permit modification is necessary or whether WTC review and authorization may proceed outside of the formal permit administrative process. The majority of WTC authorizations do not require SPDES permit modification. In any event, use and discharge of a WTC shall not proceed without prior authorization from the Department. Examples of WTCs include biocides, coagulants, conditioners, corrosion inhibitors, defoamers, deposit control agents, flocculants, scale inhibitors, sequestrants, and settling aids.

1. WTC use shall not exceed the rate explicitly authorized by this permit or otherwise authorized in writing by the Department.
2. The permittee shall maintain a logbook of all WTC use, noting for each WTC the date, time, exact location, and amount of each dosage, and, the name of the individual applying or measuring the chemical. The logbook must also document that adequate process controls are in place to ensure that excessive levels of WTCs are not used.
3. The permittee shall submit a completed WTC Annual Report Form each year that they use and discharge WTCs. This form shall be submitted in electronic format and attached to either the December DMR or the annual monitoring report required below. The *WTC Notification Form* and *WTC Annual Report Form* are available from the Department's website at: <http://www.dec.ny.gov/permits/93245.html>

## RECORDING, REPORTING AND ADDITIONAL MONITORING REQUIREMENTS

A. The monitoring information required by this permit shall be retained for a period of at least five years from the date of the sampling for subsequent inspection by the Department or its designated agent.

B. Discharge Monitoring Reports (DMRs): Completed DMR forms shall be submitted for each one (1) month reporting period in accordance with the DMR Manual available on Department's website.

DMRs must be submitted electronically using the electronic reporting tool (NetDMR) specified by NYSDEC. Instructions on the use of NetDMR can be found at <https://www.dec.ny.gov/chemical/8461.html>. **Hardcopy paper DMRs will only be accepted if a waiver from the electronic submittal requirements has been granted by DEC to the facility.**

Attach the monthly "Wastewater Facility Operation Report" (form 92-15-7) and any required DMR attachments electronically to the DMR or with the hardcopy submittal.

The first monitoring period begins on the effective date of this permit, and, unless otherwise required, the reports are due no later than the 28th day of the month following the end of each monitoring period.

C. Additional information required to be submitted by this permit shall be summarized and reported to the Regional Water Engineer and Bureau of Water Permits at the following addresses:

Department of Environmental Conservation  
Division of Water, Bureau of Water Permits  
625 Broadway, Albany, New York 12233-3505

Phone: (518) 402-8111

Department of Environmental Conservation  
Regional Water Engineer, Region 3  
220 White Plains Road, Suite 110, Tarrytown, New York, 10591

Phone: (914) 803-8157

D. Bypass and Sewage Pollutant Right to Know Reporting: In accordance with the Sewage Pollutant Right to Know Act (ECL § 17-0826-a), Publicly Owned Treatment Works (POTWs) are required to notify DEC and Department of Health within two hours of discovery of an untreated or partially treated sewage discharge and to notify the public and adjoining municipalities within four hours of discovery. Information regarding reporting and other requirements of this program may be found on the Department's website. In addition, POTWs are required to provide a five-day incident report and supplemental information to the DEC in accordance with Part 750-2.7(d) by utilizing the Division of Water Report of Noncompliance Event form unless waived by DEC on a case-by-case basis.

E. Schedule of Additional Submittals:

The permittee shall submit the following information to the Regional Water Engineer and to the Bureau of Water Permits, unless otherwise instructed:

<b>SCHEDULE OF ADDITIONAL SUBMITTALS</b>		
<b>Outfall(s)</b>	<b>Required Action</b>	<b>Due Date</b>
	<p><b><u>EMERGING CONTAMINANT SHORT-TERM MONITORING PROGRAM</u></b> The permittee shall collect grab samples of both the influent and effluent from the facility's treatment system(s) associated with the identified outfall for Per-and Polyfluoroalkyl Substances (PFAS) and 1,4-Dioxane (1,4-D), unless permittee receives written notification from the Department during this time that sampling can be discontinued. Samples must be analyzed utilizing EPA draft analytical method 1633 and EPA Method 8270D SIM or 8270E SIM, respectively. The samples must represent normal discharge conditions and treatment operations and shall be obtained on a quarterly basis for at least 4 consecutive quarters, unless written notification from the Department indicates otherwise. The results shall be reported through the "Emerging Contaminants Survey for POTWs" found at: <a href="https://www.dec.ny.gov/chemical/127939.html">https://www.dec.ny.gov/chemical/127939.html</a>.</p>	EDPM + 14 months
	<p>The permittee shall initiate track down of potential sources by completing the "Emerging Contaminants Investigation Checklist for POTWs" available at the above link. The Department may periodically request updates and/or additional monitoring to check progress on track down investigations. Elements of the checklist may be used as permit conditions in future permit modifications.</p>	Within 90 days of DEC written notification
	<p><b><u>ANNUAL FLOW CERTIFICATION</u></b> The permittee shall submit an Annual Flow Certification form each year in accordance with 750-2.9(C)(4). The form shall be attached to the February DMR or submitted through nForm.</p>	February DMR (March 28 <sup>th</sup> )
	<p><b><u>BIENNIAL POLLUTANT SCAN</u></b> The permittee shall implement an ongoing monitoring program and perform effluent sampling every two years as specified in footnote of the permit limits table.</p>	Retain and submit with next NY-2A Application
	<p><b><u>WHOLE EFFLUENT TOXICITY (WET) TESTING</u></b> WET testing shall be performed as required in the footnote of the permit limits table. The toxicity test report including all information requested of this permit shall be attached to your WET DMRs and sent to the <a href="mailto:WET@dec.ny.gov">WET@dec.ny.gov</a> email address.</p>	Within 60 days following the end of each monitoring period
	<p><b><u>STORMWATER NO EXPOSURE CERTIFICATION</u></b> Permittee must recertify every five years a condition of no exposure to stormwater in order to continue to qualify for the no exposure exclusion. The No Exposure Certification Form can be found on the NYSDEC website.</p>	June 12, 2028, and every 5 years thereafter
	<p><b><u>MERCURY MINIMIZATION PLAN</u></b> The permittee must complete and maintain onsite an annual mercury minimization status report in accordance with the requirements of this permit.</p>	<b>Maintained Onsite</b> EDP + 12 months, annually thereafter

**Unless noted otherwise, the above actions are one-time requirements.**

- F. Monitoring and analysis shall be conducted using sufficiently sensitive test procedures approved under 40 CFR Part 136, unless other test procedures have been specified in this permit.

- G. More frequent monitoring of the discharge(s), monitoring point(s), or waters of the State than required by the permit, where analysis is performed by a certified laboratory or where such analysis is not required to be performed by a certified laboratory, shall be included in the calculations and recording of the data on the corresponding DMRs.
- H. Calculations which require averaging of measurements shall utilize an arithmetic mean unless otherwise specified in this permit.
- I. Unless otherwise specified, all information recorded on the DMRs shall be based upon measurements and sampling carried out during the most recently completed reporting period.
- J. Any laboratory test or sample analysis required by this permit for which the State Commissioner of Health issues certificates of approval pursuant to section 502 of the Public Health Law shall be conducted by a laboratory which has been issued a certificate of approval. Inquiries regarding laboratory certification should be directed to the New York State Department of Health, Environmental Laboratory Accreditation Program.

Permittee: Town of Stony Point  
Facility: Town of Stony Point Sewage Treatment Plant  
SPDES Number: NY0028851  
USEPA Major/Class 05 Municipal

Date: **Date** v.1.19  
Permit Writer: Kirsten Jedd-Barry  
Water Quality Reviewer: Kirsten Jedd-Barry  
Full Technical Review

# **SPDES Permit Fact Sheet Town of Stony Point Town of Stony Point Sewage Treatment Plant NY0028851**



**Department of  
Environmental  
Conservation**

## Contents

Summary of Permit Changes .....	3
Administrative History .....	3
Facility Information .....	4
Site Overview .....	5
Enforcement History .....	6
Existing Effluent Quality.....	6
Interstate Water Pollution Control Agencies .....	6
Receiving Water Information .....	6
Impaired Waterbody Information .....	7
Critical Receiving Water Data & Mixing Zone.....	7
Permit Requirements .....	7
Whole Effluent Toxicity (WET) Testing .....	7
Anti-backsliding .....	8
Antidegradation .....	8
Discharge Notification Act Requirements .....	8
Stormwater Pollution Prevention Requirements .....	8
Mercury .....	8
Biennial Pollutant Scan.....	9
Schedule(s) of Compliance .....	9
Emerging Contaminant Monitoring .....	9
Schedule(s) of Additional Submittals .....	9
OUTFALL AND RECEIVING WATER SUMMARY TABLE .....	10
POLLUTANT SUMMARY TABLE .....	10
Outfall 001 .....	10
Appendix A: Regulatory and Technical Basis of Permit Authorizations.....	16
Regulatory References.....	16
Outfall and Receiving Water Information .....	16
Interstate Water Pollution Control Agencies .....	17
Existing Effluent Quality.....	17
Permit Requirements.....	17
Appendix B CORMIX Model.....	22
Low Flow Conditions .....	22
Description of Outfall .....	22
Model Design .....	22
Results of Mixing Analysis.....	22

## Summary of Permit Changes

A State Pollutant Discharge Elimination System (SPDES) EBPS permit renewal with changes requested by the permittee has been drafted for the Town of Stony Point Sewage Treatment Plant. The changes to the permit are summarized below:

- Updated permit format, definitions, and general conditions
- Updated the Permit Limits, Levels and Monitoring table to reflect effluent limits during construction
- Added a new Permit Limits, Levels and Monitoring table with effluent limits effective post construction
  - Changed limit for flow from 1.0 MGD to 1.8 MGD
  - Updated the monthly average and daily maximum BOD<sub>5</sub> loading limit
  - Updated the monthly average and daily maximum TSS loading limit
  - Added daily maximum effluent limitation for total mercury of 50 ng/L
  - Added Biennial Pollutant Scan
  - Changed limit for total residual chlorine (TRC) from 1.0 mg/L to 0.75 mg/L
  - Added Whole Effluent Toxicity (WET) action level of 6.3 TU<sub>a</sub> for acute invertebrate and vertebrate testing
  - Added WET action level of 100 TU<sub>c</sub> for chronic invertebrate and vertebrate testing
- Updated the Stormwater Pollution Prevention Requirements
- Updated the Mercury Minimization Program requirements
- Removed the Inflow and Infiltration Management Program
- Updated the Schedule of Compliance
- Updated the Monitoring Locations and site schematic
- Added a Schedule of Additional Submittals

**This fact sheet summarizes the information used to determine the effluent limitations (limits) and other conditions contained in the permit. General background information including the regulatory basis for the effluent limitations and other conditions are in the [Appendix](#) linked throughout this fact sheet.**

## Administrative History

- 3/25/2009 The last full technical review was performed and the SPDES permit was modified to update permit format, definitions, and general conditions, add mercury minimization requirements, add inflow and infiltration monitoring, reduce the total residual chlorine limit, update the disinfection season, and update the monitoring frequency for ammonia, nitrate, nitrite, and total Kjeldahl nitrogen (TKN). The 2009 permit has formed the basis of this permit.
- The permit was administratively renewed in 2010 and again in 2015. The current permit administrative renewal was effective until 3/31/2020.
- 3/31/2020 The current permit was allowed to stay in effect pursuant to SAPA<sup>1</sup>.
- 9/7/2021 The Town of Stony Point submitted a request to modify the permit to expand the design flow from 1.0 MGD to 1.8 MGD.
- 8/14/2023 The Town of Stony Point submitted a NY-2A permit application.

---

<sup>1</sup> State Administrative Procedures Act Section 401(2) and 6 NYCRR 621.11(f)

The Notice of Complete Application, published in the [Environmental Notice Bulletin](#) and newspapers, contains information on the public notice process.

## Facility Information

This facility is a publicly owned treatment works constructed in 1969 that receives flow from domestic users, with effluent consisting of treated sanitary waste. The facility was upgraded in 1985 with the installation of a belt filter press and aerobic sludge holding tanks for sludge processing. The Cedar Pond Brook Sewage Pump Station was also constructed during this time to allow for the diversion of sewage to the Haverstraw Joint Regional Sewerage Board (HJRSB) under an intermunicipal agreement that ends in July 2025. The collection system consists of separate sewers. The facility does not have any significant industrial users (SIUs).

The current 1.0 MGD treatment plant consists of:

- Preliminary Treatment: Screening and grit removal
- Secondary Treatment: Activated sludge with secondary settling tanks
- Disinfection: Chlorine with dechlorination

Sludge is aerobically digested and dewatered with a centrifuge and is disposed of offsite.

The primary outfall (Outfall 001) is a 21" diameter submerged corrugated metal pipe. The outfall is not diffused and terminates approximately 25 feet from the shoreline.

Flow Diversion to Haverstraw Joint Regional Sewer Board (HJRSB): The Town of Stony Point had entered into an Inter-Municipal Agreement (IMA) with the Haverstraw Joint Regional Sewer Board to treat up to 0.7 MGD (average daily flow) of the Town of Stony Point's wastewater.

Currently, the Town of Stony Point diverts an average of 0.04 MGD (maximum of 0.17 MGD) to the HJRSB treatment plant (SPDES # NY0028533) via the Cedar Pond Brook Pump Station.

This IMA is set to expire on July 5, 2025 and is the main driver for the facility's flow expansion proposal described below.

The facility is planning the following upgrades/improvements:

- Expansion of treatment plant capacity from 1.0 MGD to 1.8 MGD (*in progress*)
- New raw sewage pumping capacities
- Expanded raw sewage force main (*in progress*)
- New headworks facility (*in progress*)
- New automatic screening with bypass channel
- Additional air pumping capacity for aeration basins (*completed*)
- New circular clarifiers to replace existing clarifiers (*in progress*)
- Additional return activated sludge (RAS) pumping capacities
- Upgrading seasonal chlorination to seasonal UV disinfection (*completed*)
- Additional air pumping capacity for aerobic digesters (*completed*)

The facility accepts wastewater from the following municipalities:


Municipality	POSS # or SPDES #	Collection System
Town of Stony Point	NY0028851	Separate




Permittee: Town of Stony Point  
Facility: Town of Stony Point Sewage Treatment Plant  
SPDES Number: NY0028851  
USEPA Major/Class 05 Municipal

Date: **Date** v.1.19  
Permit Writer: Kirsten Jedd-Barry  
Water Quality Reviewer: Kirsten Jedd-Barry  
Full Technical Review

### Site Overview





### Enforcement History

Compliance and enforcement information can be found on the EPA's [Enforcement and Compliance History Online \(ECHO\)](#) website.

### Existing Effluent Quality

The [Pollutant Summary Table](#) presents the existing effluent quality and effluent limitations. The existing effluent quality was determined from Discharge Monitoring Reports and the application submitted by the permittee for the period 8/1/2018 to 7/31/2023. [Appendix Link](#)

### Interstate Water Pollution Control Agencies

Outfall(s) 001 is located within the Interstate Environmental Commission (IEC) compact area which places additional requirements in the SPDES permit. [Appendix Link](#)

### Receiving Water Information

The facility discharges via the following outfalls:

Outfall No.	SIC Code	Wastewater Type	Receiving Water
001	4952	Treated Sanitary Sewage	Hudson River, Class SB

**Reach Description:** The segment of the Hudson River at the point of discharge is classified as SB (6NYCRR 864.6 – Table I – Item 2).

See the [Outfall and Receiving Water Summary Table](#) and [Appendix](#) for additional information.

### Impaired Waterbody Information

The Hudson River segment (PWL No. 1301-0094) was first listed on the 1998 [New York State Section 303\(d\) List](#) of Impaired/TMDL Waters as impaired due to PCBs and other toxics from contaminated sediment. The segment continues to be listed as of the 2018 NYS Section 303(d) List. A TMDL has not been developed to address the impairment and, therefore, there are no applicable wasteload allocations (WLAs) for this facility.

### Critical Receiving Water Data & Mixing Zone

Consistent with TOGS 1.3.1, the outfall information submitted in the application and detailed mixing zone form was used to develop a mixing zone model to establish dilution ratios for the water quality analysis. The model showed that mixing is driven by positive buoyancy of the effluent.

Outfall No.	Acute Dilution Ratio A(A)	Chronic Dilution Ratio A(C)	Human, Aesthetic, Wildlife Dilution Ratio (HEW)	Basis
001	21.1:1	100:1	100:1	CORMIX

Critical receiving water data are listed in the [Pollutant Summary Table](#) at the end of this fact sheet. [Appendix Link](#)

Model inputs and description can be found in [Appendix B](#).

## Permit Requirements

The technology based effluent limitations ([TBELs](#)), water quality-based effluent limitations ([WQBELs](#)), [Existing Effluent Quality](#) and a discussion of the selected effluent limitation for each pollutant present in the discharge are provided in the [Pollutant Summary Table](#).

### Whole Effluent Toxicity (WET) Testing

An evaluation of the discharge indicates the potential for toxicity based on the following criteria: [Appendix Link](#)

- Treatment plants which equal or exceed a discharge of 1MGD. (#7)

The requirement for WET testing is new. No previous WET data was available to perform a reasonable potential analysis. Consistent with TOGS 1.3.2, given the dilution available and location outside of the Great Lakes basin, the permit requires acute and if directed chronic WET testing. WET testing action levels of 6.3 TUA and 100 TUC have been included in the permit for each species. The acute action level for each species represent the acute dilution ratio times a factor of 0.3. Samples will be collected quarterly once every five years.

### Anti-backsliding

The limitations contained in the permit are at least as stringent as the previous permit limits and there are no instances of backsliding. [Appendix Link](#)

### Antidegradation

The permit contains effluent limitations which ensure that the best usages of the receiving waters will be maintained. The Notice of Complete Application published in the Environmental Notice Bulletin contains information on the State Environmental Quality Review (SEQR)<sup>2</sup> determination. [Appendix Link](#)

### Discharge Notification Act Requirements

In accordance with the Discharge Notification Act (ECL 17-0815-a), the permittee is required to post a sign at each point of wastewater discharge to surface waters, unless a waiver is obtained. This requirement is being continued from the previous permit.

Additionally, the permit contains a requirement to make the DMR sampling data available to the public upon request. This requirement is being continued from the previous permit.

### Stormwater Pollution Prevention Requirements

The facility is a publicly owned treatment works  $\geq 1$  MGD that requires SPDES permit coverage under 40 CFR 122.26 (b)(14)(ix).

On 6/12/2023, the permittee submitted a Conditional Exclusion for No Exposure Form, certifying that all industrial activities and materials are completely sheltered from exposure. This condition must be maintained for the exclusion to remain applicable. The schedule of submittals also includes a due date for re-certification every five years as required by 40 CFR 122.26(g)(iii). This requirement is new.

### Mercury<sup>3</sup>

The multiple discharge variance (MDV) for mercury provides the framework for NYSDEC to require mercury monitoring and mercury minimization programs (MMPs), through SPDES permitting. [Appendix Link](#)

The facility is an EPA Major, Class 05, POTW and the permit includes requirements for the implementation of MMP Type I.

Based on three data point(s), with a maximum value of 0.9 ng/L, collected as part of the application the facility is expected to meet the new daily max permit limit of 50 ng/L (with monthly sampling frequency). The limit represents the general level currently achievable (GLCA). The data collected will be used to establish an additional 12-month rolling average effluent limit during the next permit review.

A mercury minimization program consisting of the following is also required:

- Additional monitoring of key locations, as defined in the MMP
- Control strategy for implementation of the MMP
- Annual status report (maintained onsite)

---

<sup>2</sup> As prescribed by 6 NYCRR Part 617

<sup>3</sup> In accordance with DOW 1.3.10 Mercury – SPDES Permitting & Multiple Discharge Variance (MDV), December 30, 2020.

### Biennial Pollutant Scan

Three effluent samples for applicable parameters must be submitted with an NY-2A Application<sup>4</sup>. The permit includes a requirement to perform biennial sampling (once every two years) of the WWTP effluent for the parameters in the NY-2A Application, Tables A – D. This requirement ensures the data is representative of effluent conditions over the permit term and will be available for the next application submittal and permit review. This requirement is new.

### Schedule(s) of Compliance

A Schedule of Compliance is being included<sup>5</sup> for the following items ([Appendix Link](#)):

- Submittal of Certificate of Completion to the Department to certify completion of construction

### Emerging Contaminant Monitoring

Emerging Contaminants, such as Perfluorooctanoic acid (PFOA), Perfluorooctanesulfonic acid (PFOS), and 1,4-Dioxane (1,4-D), have been used in a wide variety of consumer and industrial product as well as in manufacturing processes for decades. These contaminants do not break down easily, therefore their presence in wastewater can remain a concern for years following their discontinued use. As the science surrounding these contaminants is still evolving, additional monitoring is needed to better understand potential sources and background levels. For more information on emerging contaminants, please see the NYSDEC Division of Water web page: <https://www.dec.ny.gov/chemical/127939.html>.

Pursuant to 6 NYCRR Part 750-1.13(b), the permit includes a short-term monitoring program listed in the Schedule of Additional Submittals to evaluate the influent and effluent discharge levels of Per- and Polyfluoroalkyl Substances (PFAS) and 1,4-Dioxane. This monitoring program is consistent with PFAS guidance released in EPA guidance memos dated April 28, 2022, and December 5, 2022.

The Department will review the monitoring results and, pursuant to 6 NYCRR 750-2.1(i), may notify the permittee of the need for further monitoring to identify potential sources as specified in the Emerging Contaminants Investigation Checklist for POTWs to determine whether cause exists to modify the permit to incorporate a pollutant minimization program per 6 NYCRR 750-1.14(f).

The Department will consider this information and progress made to track down and reduce or eliminate the source of the identified pollutants in determining if a permit modification is needed.

### Schedule(s) of Additional Submittals

A schedule of additional submittals has been included for the following ([Appendix Link](#)):

- Emerging Contaminant Short-Term Monitoring Program
- Annual Flow Certification
- Biennial Pollutant Scan
- WET Testing
- Stormwater No Exposure Certification
- Mercury Minimization Plan Annual Report (maintained onsite)

---

<sup>4</sup> Pursuant to 40 CFR 122.21(j)(4)(vi).

<sup>5</sup> Pursuant to 6 NYCRR 750-1.14

Permittee: Town of Stony Point  
 Facility: Town of Stony Point Sewage Treatment Plant  
 SPDES Number: NY0028851  
 USEPA Major/Class 05 Municipal

Date: **Date** v.1.19  
 Permit Writer: Kirsten Jedd-Barry  
 Water Quality Reviewer: Kirsten Jedd-Barry  
 Full Technical Review

## OUTFALL AND RECEIVING WATER SUMMARY TABLE

Outfall	Latitude	Longitude	Receiving Water Name	Water Class	Water Index No. / Priority Waterbody Listing (PWL) No.	Major / Sub Basin	Hardness (mg/l)	1Q10 (cfs)	7Q10 (cfs)	30Q10 (cfs)	Critical Effluent Flow (MGD)	Dilution Ratio		
												A(A)	A(C)	HEW
001	41° 13' 20" N	73° 57' 35" W	Hudson River	SB	H PWL: 1301-0094	13 / 01	6,800 <sup>6</sup>	3,000	6,000	7,200	1.8	21.1 :1	100:1	100:1

## POLLUTANT SUMMARY TABLE

### Outfall 001

Outfall #	Description of Wastewater: Treated Sanitary Sewage														
	Type of Treatment: Screening and grit removal, activated sludge with final clarification, and UV disinfection.														
Effluent Parameter	Units	Averaging Period	Existing Discharge Data			TBELs		Water Quality Data & WQBELs						ML	Basis for Permit Requirement
			Permit Limit	Existing Effluent Quality <sup>7</sup>	# of Data Points Detects / Non-Detects	Limit	Basis	Ambient Bkgd. Conc.	Projected Instream Conc.	WQ Std. or GV	WQ Type	Calc. WQBEL	Basis for WQBEL		
<b>General Notes:</b> Existing discharge data from August 2018 to July 2023 was obtained from Discharge Monitoring Reports provided by the permittee. All applicable water quality standards were reviewed for development of the WQBELs. The standard and WQBEL shown below represent the most stringent.															
Flow Rate	MGD	Monthly Avg	1.0	0.77 Actual Average	60 / 0	1.8	Design Flow	Narrative: No alterations that will impair the waters for their best usages.				703.2	-	TBEL	
		Consistent with TOGS 1.3.3, a monthly average flow limitation equal to the average daily design capacity of the treatment plant is specified.													
pH	SU	Minimum	6.0	4.9 Actual Min	60 / 0	6.0	TOGS 1.3.3	7.62 <sup>8</sup>	-	6.5 – 8.5	Range	-	703.3	-	TBEL
		Maximum	9.0	11 Actual Max	60 / 0	9.0									
Consistent with TOGS 1.3.3 for POTWs, TBELs reflect secondary treatment standards. Given the available dilution, an effluent limitation equal to the TBEL is protective of the WQS.															
Temperature	°F	Daily Max	Monitor	78.5 Actual Max	60 / 0	Monitor	750-1.13 Monitor	13.3	Narrative (Non-Trout): The water temperature at the surface of a stream shall not be raised to more than 90F at any point and... shall not be raised or lowered to more than 5F over the temperature that existed before the addition				703.2	-	TBEL

<sup>6</sup> Ambient hardness data obtained from HRECOS.

<sup>7</sup> Existing Effluent Quality: Daily Max = 99% lognormal; Monthly Avg = 95% lognormal (for datasets with ≤3 nondetects); Daily Max = 99% delta-lognormal; Monthly Avg = 95% delta-lognormal (for datasets with >3 nondetects)

<sup>8</sup> Ambient pH obtained from HRECOS.

Permittee: Town of Stony Point  
 Facility: Town of Stony Point Sewage Treatment Plant  
 SPDES Number: NY0028851  
 USEPA Major/Class 05 Municipal

Date: **Date** v.1.19  
 Permit Writer: Kirsten Jedd-Barry  
 Water Quality Reviewer: Kirsten Jedd-Barry  
 Full Technical Review

Outfall #	001	Description of Wastewater: Treated Sanitary Sewage													
		Type of Treatment: Screening and grit removal, activated sludge with final clarification, and UV disinfection.													
Effluent Parameter	Units	Averaging Period	Existing Discharge Data			TBELs		Water Quality Data & WQBELs						ML	Basis for Permit Requirement
			Permit Limit	Existing Effluent Quality <sup>7</sup>	# of Data Points Detects / Non-Detects	Limit	Basis	Ambient Bkgd. Conc.	Projected Instream Conc.	WQ Std. or GV	WQ Type	Calc. WQBEL	Basis for WQBEL		
Consistent with 6 NYCRR 750-1.13(a), monitoring is required and may be used to inform future permitting decisions. This requirement is continued from the previous permit.															
Dissolved Oxygen (DO)	mg/L	Daily Min	-	-	-	-	-	-	6.05 Critical Point	5	Narrative	No Reasonable Potential	-	-	No Limitation
	The downstream DO concentration was modeled using the Streeter-Phelps equations and the following assumptions: Effluent DO = 2.0 mg/l (TOGS 1.3.1D), Effluent BOD5 = 45 mg/L (daily maximum permit limit), Effluent NOD = 30.5 mg/L (maximum effluent ammonia concentration reported on DMRs, converted to NOD). Reach Description: The model included the Town of Stony Point STP. There are no significant features upstream or downstream, so the model ended three miles downstream of Stony Point STP. The model showed that DO standards are maintained and consequently WQBELs for DO are unnecessary and no permit limit is needed.														
5-day Biochemical Oxygen Demand (BOD <sub>5</sub> )	mg/L	Monthly Avg	30	11.5	60 / 0	<b>30</b>	TOGS 1.3.3	-	See Dissolved Oxygen	-	No Reasonable Potential	703.3	-	TBEL	
		7 Day Avg	45	58.3	60 / 0	<b>45</b>	TOGS 1.3.3								
	lbs/d	Monthly Avg	250	80.7	60 / 0	<b>450</b>	TOGS 1.3.3								
		7 Day Avg	375	494	60 / 0	<b>680</b>	TOGS 1.3.3								
	% Rem	Minimum	85	84 Actual Min	60 / 0	<b>85</b>	TOGS 1.3.3								
mg/L	6-Consecutive Hr. Avg	50	-	-	<b>50</b>	550.2(e)(3)	IEC								
Consistent with TOGS 1.3.3 for POTWs, TBELs reflect secondary treatment standards.															
The 6-Consecutive Hour Average is an Interstate Environmental Commission (IEC) requirement. The permittee is not required to perform this sampling but shall be required to meet the permit limit at all times. EPA, DEC or IEC may perform the sampling.															
Total Suspended Solids (TSS)	mg/L	Monthly Avg	30	16.6	60 / 0	<b>30</b>	TOGS 1.3.3	-	Narrative: None from sewage, industrial wastes or other wastes that will cause deposition or impair the waters for their best usages.	-	703.2	-	TBEL		
		7 Day Avg	45	103	60 / 0	<b>45</b>	TOGS 1.3.3								
	lbs/d	Monthly Avg	250	107	60 / 0	<b>450</b>	TOGS 1.3.3								
		7 Day Avg	375	756	60 / 0	<b>680</b>	TOGS 1.3.3								
	% Rem	Minimum	85	69 Actual Min	60 / 0	<b>85</b>	TOGS 1.3.3								
mg/L	6-Consecutive Hr. Avg	50	-	-	<b>50</b>	550.2(e)(3)	IEC								

Permittee: Town of Stony Point  
 Facility: Town of Stony Point Sewage Treatment Plant  
 SPDES Number: NY0028851  
 USEPA Major/Class 05 Municipal

Date: **Date** v.1.19  
 Permit Writer: Kirsten Jedd-Barry  
 Water Quality Reviewer: Kirsten Jedd-Barry  
 Full Technical Review

Outfall #	Description of Wastewater: Treated Sanitary Sewage														
	Type of Treatment: Screening and grit removal, activated sludge with final clarification, and UV disinfection.														
Effluent Parameter	Units	Averaging Period	Existing Discharge Data			TBELs		Water Quality Data & WQBELs						ML	Basis for Permit Requirement
			Permit Limit	Existing Effluent Quality <sup>7</sup>	# of Data Points Detects / Non-Detects	Limit	Basis	Ambient Bkgd. Conc.	Projected Instream Conc.	WQ Std. or GV	WQ Type	Calc. WQBEL	Basis for WQBEL		
<p>Consistent with TOGS 1.3.3 for POTWs, TBELs reflect secondary treatment standards. Given the available dilution, an effluent limitation equal to the TBEL, and consistent with TOGS 1.3.3, is protective of water quality standards.</p> <p>The 6-Consecutive Hour Average is an Interstate Environmental Commission (IEC) requirement. The permittee is not required to perform this sampling but shall be required to meet the permit limit at all times. EPA, DEC or IEC may perform the sampling.</p>															
Settleable Solids	mL/L	Daily Max	0.3	8.44	23 / 34	<b>0.3</b>	TOGS 1.3.3	-	Narrative: None from sewage, industrial wastes or other wastes that will cause deposition or impair the waters for their best usages				703.2	-	TBEL
	Consistent with TOGS 1.3.3, the effluent limitation is equal to the TBEL of 0.3 mL/L for POTWs providing secondary treatment without filtration. Given that adequate dilution is available the TBEL is protective of WQS.														
Nitrogen, Ammonia (as N)	mg/L	Monthly Avg	Monitor	75.8	18 / 2	<b>Monitor</b>	TOGS 1.3.3	-	-	3.6	A(C)	No Reasonable Potential	703.4	-	TBEL
	<p>The WQS for Ammonia was determined from TOGS 1.1.1 from an average pH of 7.62 (calculated from data collected from HRECOS gage at Bear Mountain), an average temperature of 13.3 (calculated from data collected from HRECOS gage at Bear Mountain), and an average salinity of 1.64 g/kg (calculated from data collected from HRECOS gage at Bear Mountain). The projected instream concentration was calculated using the maximum reported effluent concentration of 37 mg/L and an assumed ambient upstream concentration of 0.08 mg/L. A multiplier<sup>9</sup> of 1.90 was applied to the maximum effluent concentration to account for the number of samples. The marine chronic dilution ratio was applied to calculate the projected instream concentration. A comparison of the projected instream concentration to the WQS indicates no reasonable potential to cause or contribute to a WQS violation. Therefore, no limitation is specified and the monitor only sampling requirement will remain in the permit.</p> <p>Reporting for Ammonia has been changed from (as NH<sub>3</sub>) to (as N) for simpler data reporting, as this is consistent with the laboratory reporting units. Values can be converted using the equation: Ammonia (as N) = Ammonia (as NH<sub>3</sub>) x 0.8224.</p>														
Total Kjeldahl Nitrogen (TKN) (as N)	mg/L	Monthly Avg	Monitor	45.9	18 / 2	<b>Monitor</b>	TOGS 1.3.3	-	-	-	-	No Reasonable Potential	703.4	-	TBEL
	Monitoring for TKN is being continued from the previous permit review to provide information regarding nitrogen discharges from the facility.														
Nitrite (as N)	mg/L	Monthly Avg	Monitor	0.53	19 / 1	<b>Monitor</b>	TOGS 1.3.3	-	-	-	-	No Reasonable Potential	703.4	-	TBEL
	Monitoring for Nitrite is being continued from the previous permit review to provide information regarding nitrogen discharges from the facility.														
Nitrate (as N)	mg/L	Monthly Avg	Monitor	76.5	19 / 1	<b>Monitor</b>	TOGS 1.3.3	-	-	-	-	No Reasonable Potential	703.4	-	TBEL

<sup>9</sup> As recommended from EPA's Technical Support Document, Chapter 3.3



Permittee: Town of Stony Point  
 Facility: Town of Stony Point Sewage Treatment Plant  
 SPDES Number: NY0028851  
 USEPA Major/Class 05 Municipal

Date: **Date** v.1.19  
 Permit Writer: Kirsten Jedd-Barry  
 Water Quality Reviewer: Kirsten Jedd-Barry  
 Full Technical Review

Outfall #	001	Description of Wastewater: Treated Sanitary Sewage													
		Type of Treatment: Screening and grit removal, activated sludge with final clarification, and UV disinfection.													
Effluent Parameter	Units	Averaging Period	Existing Discharge Data			TBELs		Water Quality Data & WQBELs						ML	Basis for Permit Requirement
			Permit Limit	Existing Effluent Quality <sup>7</sup>	# of Data Points Detects / Non-Detects	Limit	Basis	Ambient Bkgd. Conc.	Projected Instream Conc.	WQ Std. or GV	WQ Type	Calc. WQBEL	Basis for WQBEL		
Monitoring for Nitrate is being continued from the previous permit review to provide information regarding nitrogen discharges from the facility.															
Total Mercury	ng/L	Daily Max	-	0.9 NY-2A	1 / 2	-	-	-	-	0.7	H(FC)	50	GLCA	-	DOW 1.3.10
See <a href="#">Mercury section of this fact sheet.</a>															
Coliform, Fecal	#/100 ml	30d Geo Mean	200	1,394	23 / 7	200	TOGS 1.3.3	-	Narrative: The monthly geometric mean, from a minimum of five examinations, shall not exceed 200.				703.4	-	TBEL
		7d Geo Mean	400	12,812	26 / 1	400	TOGS 1.3.3	-							IEC
		6-Hour Geo Mean	800	-	-	800	550.2(e)(3)	-							
		Individual Sample	2,400	-	-	2,400	550.2(e)(3)	-							
Consistent with TOGS 1.3.3, effluent disinfection is required seasonally from May 1st - October 31st, due to the class of the receiving waterbody. Fecal coliform limits equal to the TBEL are specified.															
The 6-Hour Geometric Mean and Individual Sample limits are an Interstate Environmental Commission (IEC) requirement. The permittee is not required to perform this sampling but shall be required to meet the permit limit at all times. EPA, DEC or IEC may perform the sampling.															
Total Residual Chlorine (TRC)	mg/L	Daily Max	1.0	2.93	26 / 0	2.0	TOGS 1.3.3	-	0.025	0.0075	A(C)	0.75	703.4	-	WQBEL
Effluent disinfection is currently required seasonally and will remain a permit requirement. The WQBEL was calculated by multiplying the WQS by the chronic dilution ratio. Due to the low dilution, the calculated WQBEL is less than the TBEL and an effluent limitation equal to the WQBEL is appropriate.															
Additional Pollutants Detected															
Total Lead	µg/L	Daily Max	-	5.5 NY-2A	1 / 0	-	-	-	0.14	8.0	A(C)	No Reasonable Potential	703.4	-	No Limitation
	Lead was detected in the effluent as reported in the NY-2A application. The projected instream concentration was calculated using the maximum (reported or measured) effluent concentration of 5.5 µg/L and a negligent ambient upstream concentration. A multiplier, as recommended in EPA's Technical Support Document Chapter 3.3, of 6.2 was applied to the projected effluent to account for the number of samples. A metals translator of 2.5 was applied to convert between the total and dissolved form in accordance with the TriBasin RIBS calculation. A comparison of the projected instream concentration to the WQS indicates no reasonable potential to cause or contribute to a WQS violation. Therefore, no WQBEL is specified.														
Total Zinc	µg/L	Daily Max	-	24 NY-2A	1 / 0	-	-	-	0.74	66	A(C)	No Reasonable Potential	703.4	-	No Limitation

Permittee: Town of Stony Point  
 Facility: Town of Stony Point Sewage Treatment Plant  
 SPDES Number: NY0028851  
 USEPA Major/Class 05 Municipal

Date: **Date** v.1.19  
 Permit Writer: Kirsten Jedd-Barry  
 Water Quality Reviewer: Kirsten Jedd-Barry  
 Full Technical Review

Outfall #	Description of Wastewater: Treated Sanitary Sewage																
	Type of Treatment: Screening and grit removal, activated sludge with final clarification, and UV disinfection.																
Effluent Parameter	Units	Averaging Period	Existing Discharge Data			TBELs		Water Quality Data & WQBELs						ML	Basis for Permit Requirement		
			Permit Limit	Existing Effluent Quality <sup>7</sup>	# of Data Points Detects / Non-Detects	Limit	Basis	Ambient Bkgd. Conc.	Projected Instream Conc.	WQ Std. or GV	WQ Type	Calc. WQBEL	Basis for WQBEL				
			Zinc was detected in the effluent as reported in the NY-2A application. The projected instream concentration was calculated using the maximum (reported or measured) effluent concentration of 24 µg/L and a negligent ambient upstream concentration. A multiplier, as recommended in EPA's Technical Support Document Chapter 3.3, of 6.2 was applied to the projected effluent to account for the number of samples. A metals translator of 2.0 was applied to convert between the total and dissolved form in accordance with the TriBasin RIBS calculation. A comparison of the projected instream concentration to the WQS indicates no reasonable potential to cause or contribute to a WQS violation. Therefore, no WQBEL is specified.														
Total Dissolved Solids (TDS)	mg/L	Daily Max	-	610 NY-2A	1 / 0	-	-	-	-	-	-	No Reasonable Potential	703.4	-	No Limitation		
	TDS was detected in the effluent as reported in the NY-2A application. The projected instream concentration was calculated using the maximum (reported or measured) effluent concentration of 610 mg/L and a negligent ambient upstream concentration. A multiplier, as recommended in EPA's Technical Support Document Chapter 3.3, of 6.2 was applied to the projected effluent to account for the number of samples. A numeric water quality standard for TDS does not exist for Class SB waterbodies. Therefore, no WQBEL is specified.																
Antimony	µg/L	Daily Max	-	60 NY-2A	1 / 0	-	-	-	-	-	-	No Reasonable Potential	703.4	-	No Limitation		
	Antimony was detected in the effluent as reported in the NY-2A application. The projected instream concentration was calculated using the maximum (reported or measured) effluent concentration of 60 µg/L and a negligent ambient upstream concentration. A multiplier, as recommended in EPA's Technical Support Document Chapter 3.3, of 6.2 was applied to the projected effluent to account for the number of samples. A numeric water quality standard for Antimony does not exist for Class SB waterbodies. Therefore, no WQBEL is specified.																
Cyanide	µg/L	Daily Max	-	6 NY-2A	1 / 0	-	-	-	0.37	1.0	A(C)	No Reasonable Potential	703.4	-	No Limitation		
	Cyanide was detected in the effluent as reported in the NY-2A application. The projected instream concentration was calculated using the maximum (reported or measured) effluent concentration of 6 µg/L and a negligent ambient upstream concentration. A multiplier, as recommended in EPA's Technical Support Document Chapter 3.3, of 6.2 was applied to the projected effluent to account for the number of samples. A comparison of the projected instream concentration to the WQS indicates no reasonable potential to cause or contribute to a WQS violation. Therefore, no WQBEL is specified.																
Total Phenolic Compounds	µg/L	Daily Max	-	100 NY-2A	1 / 0	-	-	-	-	-	-	No Reasonable Potential	703.4	-	No Limitation		
	Total Phenolic Compounds were detected in the effluent as reported in the NY-2A application. The projected instream concentration was calculated using the maximum (reported or measured) effluent concentration of 100 µg/L and a negligent ambient upstream concentration. A multiplier, as recommended in EPA's Technical Support Document Chapter 3.3, of 6.2 was applied to the projected effluent to account for the number of samples. A numeric water quality standard for Antimony does not exist for Class SB waterbodies. Therefore, no WQBEL is specified.																
Acetone	µg/L	Daily Max	-	14 NY-2A	1 / 0	-	-	-	-	-	-	No Reasonable Potential	703.4	-	No Limitation		

Permittee: Town of Stony Point

Date: Date v.1.19

Facility: Town of Stony Point Sewage Treatment Plant Permit Writer: Kirsten Jedd-Barry

SPDES Number: NY0028851

Water Quality Reviewer: Kirsten Jedd-Barry

USEPA Major/Class 05 Municipal

Full Technical Review

<b>Outfall #</b>	001	<b>Description of Wastewater:</b> Treated Sanitary Sewage													
		<b>Type of Treatment:</b> Screening and grit removal, activated sludge with final clarification, and UV disinfection.													
Effluent Parameter	Units	Averaging Period	Existing Discharge Data			TBELs		Water Quality Data & QBELs						ML	Basis for Permit Requirement
			Permit Limit	Existing Effluent Quality <sup>7</sup>	# of Data Points Detects / Non-Detects	Limit	Basis	Ambient Bkgd. Conc.	Projected Instream Conc.	WQ Std. or GV	WQ Type	Calc. QBEL	Basis for QBEL		
			Acetone was detected in the effluent as reported in the NY-2A application. The projected instream concentration was calculated using the maximum (reported or measured) effluent concentration of 14 µg/L and a negligent ambient upstream concentration. A multiplier, as recommended in EPA's Technical Support Document Chapter 3.3, of 6.2 was applied to the projected effluent to account for the number of samples. A numeric water quality standard for Antimony does not exist for Class SB waterbodies. Therefore, no QBEL is specified.												

## Appendix A: Regulatory and Technical Basis of Permit Authorizations

The Appendix is meant to supplement the fact sheet for multiple types of SPDES permits. Portions of this Appendix may not be applicable to this specific permit.

### Regulatory References

The provisions of the permit are based largely upon 40 CFR 122 subpart C and 6 NYCRR Part 750 and include monitoring, recording, reporting, and compliance requirements, as well as general conditions applicable to all SPDES permits. Below are the most common citations for the requirements included in SPDES permits:

- Clean Water Act (CWA) 33 section USC 1251 to 1387
- Environmental Conservation Law (ECL) Articles 17 and 70
- Federal Regulations
  - 40 CFR, Chapter I, subchapters D, N, and O
- State environmental regulations
  - 6 NYCRR Part 621
  - 6 NYCRR Part 750
  - 6 NYCRR Parts 700 - 704 – Best use and other requirements applicable to water classes
  - 6 NYCRR Parts 800 – 941 - Classification of individual surface waters
- NYSDEC water program policy, referred to as Technical and Operational Guidance Series (TOGS)
- USEPA Office of Water Technical Support Document for Water Quality-based Toxics Control, March 1991, Appendix E

The following is a quick guide to the references used within the fact sheet:

SPDES Permit Requirements	Regulatory Reference
Anti-backsliding	6 NYCRR 750-1.10(c)
Best Management Practices (BMPS) for CSOs	6 NYCRR 750-2.8(a)(2)
Environmental Benefits Permit Strategy (EBPS)	6 NYCRR 750-1.18, NYS ECL 17-0817(4), TOGS 1.2.2 (revised January 25,2012)
Exceptions for Type I SSO Outfalls (bypass)	6 NYCRR 750-2.8(b)(2), 40 CFR 122.41
Mercury Multiple Discharge Variance	Division of Water Program Policy 1.3.10 (DOW 1.3.10)
Mixing Zone and Critical Water Information	TOGS 1.3.1 & Amendments
PCB Minimization Program	40 CFR Part 132 Appendix F Procedure 8, 6 NYCRR 750-1.13(a) and 750-1.14(f), and TOGS 1.2.1
Pollutant Minimization Program (PMP)	6 NYCRR 750-1.13(a), 750-1.14(f), TOGS 1.2.1
Schedules of Compliance	6 NYCRR 750-1.14
Sewage Pollution Right to Know (SPRTK)	NYS ECL 17-0826-a, 6 NYCRR 750-2.7
State Administrative Procedure Act (SAPA)	State Administrative Procedure Act Section 401(2), 6 NYCRR 621.11(l)
State Environmental Quality Review (SEQR)	6 NYCRR Part 617
USEPA Effluent Limitation Guidelines (ELGs)	40 CFR Parts 405-471
USEPA National CSO Policy	33 USC Section 1342(q)
Whole Effluent Toxicity (WET) Testing	TOGS 1.3.2
General Provisions of a SPDES Permit Department Request for Additional Information	NYCRR 750-2.1(i)

### Outfall and Receiving Water Information

#### Impaired Waters

The [NYS 303\(d\) List of Impaired/TMDL Waters](#) identifies waters where specific best usages are not fully supported. The state must consider the development of a Total Maximum Daily Load (TMDL) or other strategy to reduce the input of the specific pollutant(s) that restrict waterbody uses, in order to restore and protect such uses. SPDES permits must include effluent limitations necessary to implement a WLA of an EPA-approved TMDL (6 NYCRR 750-1.11(a)(5)(ii)), if applicable. In accordance with 6 NYCRR 750-1.13(a), permittees discharging to waters which are on the list but do not yet have a TMDL developed may be required to perform additional monitoring for the parameters causing the impairment. Accurate monitoring data is needed to

Permittee: Town of Stony Point

Date: **Date** v.1.19

Facility: Town of Stony Point Sewage Treatment Plant Permit Writer: Kirsten Jedd-Barry

SPDES Number: NY0028851

Water Quality Reviewer: Kirsten Jedd-Barry

USEPA Major/Class 05 Municipal

Full Technical Review

determine the existing capabilities of the wastewater treatment plants and to assure that wasteload allocations (WLAs) are allocated equitably.

### Interstate Water Pollution Control Agencies

Some POTWs may be subject to regulations of interstate basin/compact agencies including: Interstate Sanitation Commission (ISC), International Joint Commission (IJC), Delaware River Basin Commission (DRBC), Ohio River Valley Water Sanitation Commission (ORSANCO), and the Susquehanna River Basin Commission (SRBC). Generally, basin commission requirements focus principally on water quality and not treatment technology. However, interstate/compact agency regulations for the ISC, IJC, DRBC and NYC Watershed contain explicit effluent limits which must be addressed during permit drafting. 6 NYCRR 750-2.1(d) requires SPDES permits for discharges that originate within the jurisdiction of an interstate water pollution control agency, to include any applicable effluent standards or water quality standards (WQS) promulgated by that interstate agency.

### Existing Effluent Quality

The existing effluent quality is determined from a statistical evaluation of effluent data in accordance with TOGS 1.2.1 and the USEPA Office of Water, Technical Support Document for Water Quality-based Toxics Control, March 1991, Appendix E (TSD). The existing effluent quality is equal to the 95<sup>th</sup> (monthly average) and 99<sup>th</sup> (daily maximum) percentiles of the lognormal distribution of existing effluent data. When there are greater than three non-detects, a delta-lognormal distribution is assumed, and delta-lognormal calculations are used to determine the monthly average and daily maximum pollutant concentrations. Statistical calculations are not performed for parameters where there are less than ten data points. If additional data is needed, a monitoring requirement may be specified either through routine monitoring or a short-term high intensity monitoring program. The [Pollutant Summary Table](#) identifies the number of sample data points available.

### Permit Requirements

#### Basis for Effluent Limitations

Sections 101, 301, 304, 308, 401, 402, and 405 of the CWA and Titles 5, 7, and 8 of Article 17 ECL, as well as their implementing federal and state regulations, and related guidance, provide the basis for the effluent limitations and other conditions in the permit.

When conducting a full technical review of an existing permit, the previous effluent limitations form the basis for the next permit. Existing effluent quality is evaluated against the existing effluent limitations to determine if these should be continued, revised, or deleted. Generally, existing limitations are continued unless there are changed conditions at the facility, the facility demonstrates an ability to meet more stringent limitations, and/or in response to updated regulatory requirements. Pollutant monitoring data is also reviewed to determine the presence of additional contaminants that should be included in the permit based on a reasonable potential analysis to cause or contribute to a water quality standards violation.

#### Anti-backsliding

Anti-backsliding requirements are specified in the CWA sections 402(o) and 303(d)(4), ECL 17-0809, and regulations at 40 CFR 122.44(l) and 6 NYCRR 750-1.10(c) and (d). Generally, the relaxation of effluent limitations in permits is prohibited unless one of the specified exceptions applies, which will be cited on a case-by-case basis in this fact sheet. Consistent with current case law<sup>10</sup> and USEPA interpretation<sup>11</sup> anti-backsliding requirements do not apply should a revision to the final effluent limitation take effect before the scheduled date of compliance for that final effluent limitation.

---

<sup>10</sup> American Iron and Steel Institute v. Environmental Protection Agency, 115 F.3d 979, 993 n.6 (D.C. Cir. 1997)

<sup>11</sup> U.S. EPA, Water Quality Standards; Establishment of Numeric Criteria for Priority Toxic Pollutants for the State of California; 65 Fed. Reg. 31682, 31704 (May 18, 2000); Proposed Water Quality Guidance for the Great Lakes System, 58 Fed. Reg. 20802, 20837 & 20981 (April 16, 1993)

## Antidegradation Policy

New York State implements the antidegradation portion of the CWA based upon two documents: (1) Organization and Delegation Memorandum #85-40, "Water Quality Antidegradation Policy" (September 9, 1985); and, (2) TOGS 1.3.9, "Implementation of the NYSDEC Antidegradation Policy – Great Lakes Basin (Supplement to Antidegradation Policy dated September 9, 1985) (undated)." The permit for the facility contains effluent limitations which ensure that the existing best usage of the receiving waters will be maintained. To further support the antidegradation policy, SPDES applications have been reviewed in accordance with the State Environmental Quality Review Act (SEQR) as prescribed by 6 NYCRR Part 617.

## Effluent Limitations

In developing a permit, the Department determines the technology-based effluent limitations (TBELs) and then evaluates the water quality expected to result from technology controls to determine if any exceedances of water quality criteria in the receiving water might result. If there is a reasonable potential for exceedances of water quality criteria to occur, water quality-based effluent limitations (WQBELs) are developed. A WQBEL is designed to ensure that the water quality standards of receiving waters are met. In general, the CWA requires that the effluent limitations for a particular pollutant are the more stringent of either the TBEL or WQBEL.

### *Technology-based Effluent Limitations (TBELs)*

CWA sections 301(b)(1)(B) and 304(d)(1), 40 CFR 133.102, ECL section 17-0509, and 6 NYCRR 750-1.11 require technology-based controls, known as secondary treatment. These and other requirements are summarized in TOGS 1.3.3. Where the TBEL is more stringent than the WQBEL, the TBEL is applied as a limit in accordance with TOGS 1.3.3. Equivalent secondary treatment, as defined in 40 CFR 133.105, allow for effluent limitations of the more stringent of the consistently achievable concentrations or monthly/weekly averages of 45/65 mg/l, and the minimum monthly average of at least 65% removal. Consistently achievable concentrations are defined in 40 CFR 133.101(f) as the 95th percentile value for the 30-day (monthly) average effluent quality achieved by the facility in a period of two years. The achievable 7-day (weekly) average value is equal to 1.5 times the 30-day average value calculated above. Equivalent secondary treatment applies to those facilities where the principal treatment process is either a trickling filter or a waste stabilization pond; the treatment works provides significant biological treatment of municipal wastewater; and, the effluent concentrations consistently achievable through proper operation and maintenance of the facility cannot meet traditional secondary treatment requirements. There are no federal technology-based standards for toxic pollutants from POTWs. A statistical analysis of existing effluent data, as described in TOGS 1.2.1, may be used to establish other performance-based TBELs.

### *Water Quality-Based Effluent Limitations (WQBELs)*

In addition to the TBELs, permits must include additional or more stringent effluent limitations and conditions, including those necessary to protect water quality. CWA sections 101 and 301(b)(1)(C), 40 CFR 122.44(d)(1), and 6 NYCRR Parts 750-1.11 require that permits include limitations for all pollutants or parameters which are or may be discharged at a level which may cause or contribute to an exceedance of any State water quality standard adopted pursuant to NYS ECL 17-0301. Additionally, 6 NYCRR Part 701.1 prohibits the discharge of pollutants that will cause impairment of the best usages of the receiving water as specified by the water classifications at the location of discharge and at other locations that may be affected by such discharge. Water quality standards can be found under 6 NYCRR Parts 700-704. The limitations must be stringent enough to ensure that water quality standards are met at the point of discharge and in downstream waters and must be consistent with any applicable WLA which may be in effect through a TMDL for the receiving water. These and other requirements are summarized in TOGS 1.1.1, 1.3.1, 1.3.2, 1.3.5 and 1.3.6. The Department considers a mixing zone analysis, critical flows, and reasonable potential analysis when developing a WQBEL.

### *Mixing Zone Analyses*

In accordance with TOGS 1.3.1., the Department may perform additional analysis of the mixing condition between the effluent and the receiving waterbody. Mixing zone analyses using plume dispersion modeling are conducted in accordance with the following:

“EPA Technical Support Document for Water Quality-Based Toxics Control” (March 1991); EPA Region VIII’s “Mixing Zones and Dilution Policy” (December 1994); NYSDEC TOGS 1.3.1, “Total Maximum Daily Loads and Water Quality-Based Effluent Limitations” (July 1996); “CORMIX v11.0” (2019).

#### Critical Flows

In accordance with TOGS 1.2.1 and 1.3.1, WQBELs are developed using dilution ratios that relate the critical low flow condition of the receiving waterbody to the critical effluent flow. The critical low flow condition used in the dilution ratio will be different depending on whether the limitations are for aquatic or human health protection. For chronic aquatic protection, the critical low flow condition of the waterbody is typically represented by the 7Q10 flow and is calculated as the lowest average flow over a 7-day consecutive period within 10 years. For acute aquatic protection, the critical low flow condition is typically represented by the 1Q10 and is calculated as the lowest 1-day flow within 10 years. However, NYSDEC considers using 50% of the 7Q10 to be equivalent to the 1Q10 flow. For the protection of human health, the critical low flow condition is typically represented by the 30Q10 flow and is calculated as the lowest average flow over a 30-day consecutive period within 10 years. However, NYSDEC considers using 1.2 x 7Q10 to be equivalent to the 30Q10. The 7Q10 or 30Q10 flow is used with the critical effluent flow to calculate the dilution ratio. The critical effluent flow can be the maximum daily flow reported on the permit application, the maximum of the monthly average flows from discharge monitoring reports for the past three years, or the facility design flow. When more than one applicable standard exists for aquatic or human health protection for a specific pollutant, a reasonable potential analysis is conducted for each applicable standard and corresponding critical flow to ensure effluent limitations are sufficiently stringent to ensure all applicable water quality standards are met as required by 40 CFR 122.44(d)(1)(i). For brevity, the pollutant summary table reports the results of the most conservative scenario.

#### Reasonable Potential Analysis (RPA)

The Reasonable Potential Analysis (RPA) is a statistical estimation process, outlined in the 1991 USEPA Technical Support Document for Water Quality-based Toxics Control (TSD), Appendix E. This process uses existing effluent quality data and statistical variation methodology to project the maximum amounts of pollutants that could be discharged by the facility. This projected instream concentration (PIC) is calculated using the appropriate ratio and compared to the water quality standard (WQS). When the RPA process determines the WQS may be exceeded, a WQBEL is required. The procedure for developing WQBELs includes the following steps:

- 1) identify the pollutants present in the discharge(s) based upon existing data, sampling data collected by the permittee as part of the permit application or a short-term high intensity monitoring program, or data gathered by the Department;
- 2) identify water quality criteria applicable to these pollutants;
- 3) determine if WQBELs are necessary (i.e. reasonable potential analysis (RPA)). The RPA will utilize the procedure outlined in Chapter 3.3.2 of EPA’s Technical Support Document (TSD). As outlined in the TSD, for parameters with limited effluent data the RPA may include multipliers to account for effluent variability; and,
- 4) calculate WQBELs (if necessary). Factors considered in calculating WQBELs include available dilution of effluent in the receiving water, receiving water chemistry, and other pollutant sources.

The Department uses modeling tools to estimate the expected concentrations of the pollutant in the receiving water and develop WQBELs. These tools were developed in part using the methodology referenced above. If the estimated concentration of the pollutant in the receiving water is expected to exceed the ambient water quality standard or guidance value (i.e. numeric interpretation of a narrative water quality standard), then there is a reasonable potential that the discharge may cause or contribute to an exceedance of any State water quality standard adopted

pursuant to NYS ECL 17-0301. If a TMDL is in place, the facility's WLA for that pollutant is applied as the WQBEL.

For carbonaceous and nitrogenous oxygen demanding pollutants, the Department uses a model which incorporates the Streeter-Phelps equation. The equation relates the decomposition of inorganic and organic materials along with oxygen reaeration rates to compute the downstream dissolved oxygen concentration for comparison to water quality standards.

The Division of Water has been using the TMDL approach in permit limit development for the control of toxic substances. Since the early 1980's, the loading capacity for specific pollutants has been determined for each drainage basin. Water quality-limiting segments and pollutants have been identified, TMDLs, wasteload allocations and load allocations have been developed, and permits with water quality-based effluent limits have been issued. In accordance with TOGS 1.3.1, the Division of Water implements a Toxics Reduction Strategy which is committed to the application of the TMDL process using numeric, pollutant-specific water quality standards through the Watershed Approach. The Watershed Approach accounts for the cumulative effect of multiple discharges of conservative toxic pollutants to ensure water quality standards are met in downstream segments.

A Watershed Maximum Daily Load (WMDL) may be developed by the Department to account for the cumulative effect of multiple discharges of conservative toxic pollutants to ensure water quality standards are met in downstream segments. The WMDL uses a simple dilution model, assuming full mix in the receiving stream, to calculate the maximum allowable pollutant load that can be discharged and still meet water quality standards during critical low flow in downstream segments such as those with sensitive receptors (e.g. public water supply) or higher water classification. WQBELs are established to ensure that the cumulative mass load from point source discharges does not exceed the maximum allowable load to ensure permit limits are protective of water quality.

#### *Whole Effluent Toxicity (WET) Testing:*

WET tests use small vertebrate and invertebrate species to measure the aggregate toxicity of an effluent. There are two different durations of toxicity tests: acute and chronic. Acute toxicity tests measure survival over a 96-hour test exposure period. Chronic toxicity tests measure reductions in survival, growth, and reproduction over a 7-day exposure. TOGS 1.3.1 includes guidance for determining when aquatic toxicity testing should be included in SPDES permits. The authority to require toxicity testing is in 6NYCRR 702.9. TOGS 1.3.2 describes the procedures which should be followed when determining whether to include toxicity testing in a SPDES permit and how to implement a toxicity testing program. Per TOGS 1.3.2, WET testing may be required when any one of the following seven criteria are applicable:

1. There is the presence of substances in the effluent for which ambient water quality criteria do not exist.
2. There are uncertainties in the development of TMDLs, WLAs, and WQBELs, caused by inadequate ambient and/or discharge data, high natural background concentrations of pollutants, available treatment technology, and other such factors.
3. There is the presence of substances for which WQBELs are below analytical detectability.
4. There is the possibility of complex synergistic or additive effects of chemicals, typically when the number of metals or organic compounds discharged by the permittee equals or exceeds five.
5. There are observed detrimental effects on the receiving water biota.
6. Previous WET testing indicated a problem.
7. POTWs which exceed a discharge of 1 MGD. Facilities of less than 1 MGD may be required to test, e.g., POTWs <1 MGD which are managing industrial pretreatment programs.

#### *Minimum Level of Detection*

Pursuant to 40 CFR 122.44(i)(1)(iv) and 6 NYCRR 750-2.5(d), SPDES permits must contain monitoring requirements using sufficiently sensitive test procedures approved under 40 CFR Part 136. A method is "sufficiently sensitive" when the method's minimum level (ML) is at or below the level of the effluent limitation



Permittee: Town of Stony Point

Date: **Date** v.1.19

Facility: Town of Stony Point Sewage Treatment Plant Permit Writer: Kirsten Jedd-Barry

SPDES Number: NY0028851

Water Quality Reviewer: Kirsten Jedd-Barry

USEPA Major/Class 05 Municipal

Full Technical Review

established in the permit for the measured pollutant parameter; or the lowest ML of the analytical methods approved under 40 CFR Part 136. The ML represents the lowest level that can be measured within specified limitations of precision and accuracy during routine laboratory operations on most effluent matrices. When establishing effluent limitations for a specific parameter (based on technology or water quality requirements), it is possible that the calculated limitation will fall below the ML established by the approved analytical method(s). In these instances, the calculated limitation is included in the permit with a compliance level set equal to the ML of the most sensitive method.

### Monitoring Requirements

CWA section 308, 40 CFR 122.44(i), 6 NYCRR 750-1.13, and 750-2.5 require that monitoring be included in permits to determine compliance with effluent limitations. Additional effluent monitoring may also be required to gather data to determine if effluent limitations may be required. The permittee is responsible for conducting the monitoring and reporting results on Discharge Monitoring Reports (DMRs). The permit contains the monitoring requirements for the facility. Monitoring frequency is based on the minimum sampling necessary to adequately monitor the facility's performance and characterize the nature of the discharge of the monitored flow or pollutant. Variable effluent flows and pollutant levels may be required to be monitored at more frequent intervals than relatively constant effluent flow and pollutant levels (6 NYCRR 750-1.13). For industrial facilities, sampling frequency is based on guidance provided in TOGS 1.2.1. For municipal facilities, sampling frequency is based on guidance provided in TOGS 1.3.3.

### Other Conditions

#### Mercury

The multiple discharge variance (MDV) for mercury was developed in accordance with 6 NYCRR 702.17(h) "to address widespread standard or guidance value attainment issues including the presence of a ubiquitous pollutant or naturally high levels of a pollutant in a watershed." The first MDV was issued in October 2010, and subsequently revised and reissued in 2015; each subsequent iteration of the MDV is designed to build off the previous version, to make reasonable progress towards the water quality standard (WQS) of 0.7 ng/L dissolved mercury. The MDV is necessary because human-caused conditions or sources of mercury prevent attainment of the WQS and cannot be remedied (i.e., mercury is ubiquitous in New York waters at levels above the WQS and compliance with a water quality based effluent limitation (WQBEL) for mercury cannot be achieved with demonstrated effluent treatment technologies). The Department has determined that the MDV is consistent with the protection of public health, safety, and welfare. During the effective period of this MDV, any increased risks to human health are mitigated by fish consumption advisories issued periodically by the NYSDOH.

All surface water SPDES permittees are eligible for authorization by the MDV provided they meet the requirements specified in DOW 1.3.10.

### Schedules of Compliance

Schedules of compliance are included in accordance with 40 CFR Part 132 Attachment F, Procedure 9, 40 CFR 122.47 and 6 NYCRR 750-1.14. Schedules of compliance are intended to, in the shortest reasonable time, achieve compliance with applicable effluent standards and limitations, water quality standards, and other applicable requirements. Where the time for compliance is more than nine months, the schedule of compliance must include interim requirements and dates for their achievement. If the time necessary to complete the interim milestones is more than nine months, and not readily divisible into stages for completion, progress reports must be required.

### Schedule(s) of Additional Submittals

Schedules of Additional Submittals are used to summarize the deliverables required by the permit not identified in a separate Schedule of Compliance.

## Appendix B CORMIX Model

Consistent with TOGS 1.3.1, outfall information submitted with the NY 2-A application, the mixing zone form, and additional tidal data from NOAA tide gage HUR0503 (Stony Point) was used to establish dilution ratios and dilution models to confirm the appropriateness of the existing permit limits for the water quality analysis.

### Low Flow Conditions

The Hudson River below Troy Dam is a tidal waterbody. Below the Bear Mountain Bridge, the Hudson River is saline. The critical low flow conditions in a tidal waterbody occurs approximately one hour after slack tide. Tidal data from NOAA tide gage HUR0401 for the period of 12/20/2022 – 12/26/2022 was used to obtain the maximum tidal velocity of 1.55 knots and one hour after slack tide velocity of 0.62 knots to be used in the CORMIX model.

### Description of Outfall

The outfall consists of a 21" diameter discharge pipe that runs approximately 25' into the Hudson River. The discharge pipe is single port, horizontal, and pointing toward the centerline of the Hudson River.

The Hudson River at the facility's location is approximately 7,920' wide, has an average depth of 40' and the outfall is located at a depth of 30'.

### Model Design

The CORMIX model used the following data:

- River width: 7,920'
- River average depth: 40'
- Depth at discharge: 30'
- Manning's n: 0.030
- Wind Velocity: 2 m/s
- Unsteady conditions with:
  - Period: 12.4 hr. \*
  - Max Velocity: 1.55 knots \*
  - Tidal Velocity 1-hr after slack tide: 0.62 knots
  - Non-fresh, uniform receiving water density: 1,002.53 (HRECOS data)
- Flow rate: 1.8 MGD
- Effluent density: calculated from effluent temperature 68.5 °F, provided by the permittee in the mixing zone form.
- CORMIX1 Single Port Geometry:
  - Nearest Bank: Right
  - Outfall Length: 25'
  - Port height: 1.505' above bottom
  - Port Diameter: 1.75'
  - Vertical Angle Theta: 0
  - Horizontal Angle Sigma: 90

### Results of Mixing Analysis

The CORMIX model shows that mixing is driven by positive buoyancy of the effluent. The plume may attach to the bottom in the near-field region due to the strong ambient current. The plume comes into contact with the right bank 119m downstream of the outfall and becomes bounded on its right side. The CORMIX model defines the end of the near-field region as the point where the plume reaches the surface and buoyant ambient spreading occurs.

## Dilution

The CORMIX prediction file has the results of the model that provides dilution at intervals across the region of interest. Three methods were used to identify the acute mixing zone length, which is used to obtain the dilution from the CORMIX model prediction file. The length of the chronic mixing zone is calculated as 3-5 times the acute mixing zone length. For this permit, the more conservative factor of 3 was used to take into consideration the tidal reversal in the receiving water.

### 50 \* Distance Length Scale (DLS)

The EPA *Technical Support Document for Water Quality-Based Toxics Control* defines the DLS as the square root of the cross-sectional area of any discharge pipe. For this outfall configuration:

- Acute mixing zone length 23.6m; Dilution 21.1 : 1
- Chronic mixing zone length 70.8m; Dilution 114 : 1

### 5 \* Local Water Depth (LWD)

Local water depth is the average local water depth under design (low flow) conditions. For this outfall configuration:

- Acute mixing zone length: 61m; Dilution 106 : 1
- Chronic mixing zone length 183m; Dilution 205 : 1 (end of model at 182.75m due to tidal reversal)

### End of Near Field Mixing Region


CORMIX defines the near field mixing region as the region where mixing is driven primarily by the energy of the discharge plume, and also identifies the end of this region as the acute mixing zone.

The prediction file calculated the end of the NFR at 61.77m downstream of the outfall.

- Acute mixing zone length 61.77m; Dilution 109 : 1
- Chronic mixing zone length 185m; Dilution 205 : 1 (end of model at 182.75 due to tidal reversal)

The mixing zones and dilution from the most conservative of the three methods was used for the development of this draft permit.

Note: The CORMIX model is a prediction of mixing conditions. Without a site-specific study to determine mixing and dilution at the point of discharge, the most conservative approach according to TOGS 1.3.1 is to limit the chronic dilution to 100:1.



Permittee: Town of Stony Point  
Facility: Town of Stony Point Sewage Treatment Plant  
SPDES Number: NY0028851  
USEPA Major/Class 05 Municipal

Date: Date v.1.19  
Permit Writer: Kirsten Jedd-Barry  
Water Quality Reviewer: Kirsten Jedd-Barry  
Full Technical Review

