



Department of
Environmental
Conservation

State Pollutant Discharge Elimination System (SPDES) DISCHARGE PERMIT

| | | | | | |
|---------------------------|---------|-------------------------|--------------------|----------------------------|-----------|
| SIC Code: | 8999 | NAICS Code: | 531110 | SPDES Number: | NY0218987 |
| Discharge Class (CL): | 09 | DEC Number: | 3-4828-00118/00002 | | |
| Toxic Class (TX): | N | Effective Date (EDP): | | | |
| Major-Sub Drainage Basin: | 14 - 02 | Expiration Date (ExDP): | | | |
| Water Index Number: | D-1 | Item No.: | 815 - 4 | Modification Dates (EDPM): | |
| Compact Area: | DRBC | | | | |

This SPDES permit is issued in compliance with Title 8 of Article 17 of the Environmental Conservation Law of New York State and in compliance with the Clean Water Act, as amended, (33 U.S.C. '1251 et seq.)

| PERMITTEE NAME AND ADDRESS | | | | | |
|----------------------------|--------------------------|------------|--------------------|-----------|-------|
| Name: | Davos Sewer Company Inc. | Attention: | Bob Zhang, Manager | | |
| Street: | PO Box 879 | | | | |
| City: | Monticello | State: | NY | Zip Code: | 12701 |
| Email: | earthstandard@yahoo.com | Phone: | 212-807-8688 | | |

is authorized to discharge from the facility described below:

| FACILITY NAME, ADDRESS, AND PRIMARY OUTFALL | | | | | | | | | |
|---|--------------------|-----------|------------------|------------------------------------|--------------|--------------|-----------|----------|----------------|
| Name: | Davos in the Woods | | | | | | | | |
| Address / Location: | 531 River Road | | | | | County: | Sullivan | | |
| City: | Woodridge | | | | State: | NY | Zip Code: | 12789 | |
| Facility Location: | Latitude: | 41 ° | 41 ' | 32.4 " N | & Longitude: | 74 ° | 35 ' | 20.5 " W | |
| Primary Outfall No.: | 001 | Latitude: | 41 ° | 40 ' | 46 " N | & Longitude: | 74 ° | 35 ' | 48 " W |
| Outfall Description: | Treated Sanitary | | Receiving Water: | Neversink River, Middle, Main Stem | | | Class: | B | Standard: B(T) |

in accordance with: effluent limitations; monitoring and reporting requirements; other provisions and conditions set forth in this permit; and 6 NYCRR Part 750-1 and 750-2. The co-permittees subject to one or more conditions of this permit are listed on page 2.

This permit and the authorization to discharge shall expire on midnight of the expiration date shown above and the permittee shall not discharge after the expiration date unless this permit has been renewed or extended pursuant to law. To be authorized to discharge beyond the expiration date, the permittee shall apply for permit renewal not less than 180 days prior to the expiration date shown above.

DISTRIBUTION:

Town of Fallsburgh, Supervisor
EPA Region II
NYSEFC
NYSDOH
DRBC
CO BWP - Permit Coordinator
Stephen Monteverde, DEC DOW
Manju Cherian, DEC DOW RWE

| | |
|-----------------------|---|
| Permit Administrator: | |
| Address: | 21 South Putt Corners Rd, New Paltz, NY 12561 |
| | |
| Signature | Date |

Contents

| | |
|---|----|
| DEFINITIONS..... | 3 |
| PERMIT LIMITS, LEVELS AND MONITORING..... | 4 |
| ADDITIONAL REQUIREMENTS PROVIDED BY THE DELAWARE RIVER BASIN COMMISSION (DRBC)..... | 6 |
| MERCURY MINIMIZATION PROGRAM (MMP) - Type IV | 7 |
| DISCHARGE NOTIFICATION REQUIREMENTS..... | 9 |
| MONITORING LOCATIONS..... | 10 |
| GENERAL REQUIREMENTS..... | 11 |
| RECORDING, REPORTING AND ADDITIONAL MONITORING REQUIREMENTS..... | 13 |
| D. Schedule of Additional Submittals: | 13 |

DEFINITIONS

| TERM | DEFINITION |
|--|---|
| 7-Day Geo Mean | The highest allowable geometric mean of daily discharges over a calendar week. |
| 7-Day Average | The average of all daily discharges for each 7-days in the monitoring period. The sample measurement is the highest of the 7-day averages calculated for the monitoring period. |
| 12-Month Rolling Average (12 MRA) | The current monthly value of a parameter, plus the sum of the monthly values over the previous 11 months for that parameter, divided by the number of months for which samples were collected in the 12-month period. |
| 30-Day Geometric Mean | The highest allowable geometric mean of daily discharges over a calendar month, calculated as the antilog of: the sum of the log of each of the daily discharges measured during a calendar month divided by the number of daily discharges measured during that month. |
| Action Level | Action level means a monitoring requirement characterized by a numerical value that, when exceeded, triggers additional permittee actions and DEC review to determine if numerical effluent limitations should be imposed. |
| Compliance Level / Minimum Level | A compliance level is an effluent limitation. A compliance level is given when the water quality evaluation specifies a Water Quality Based Effluent Limit (WQBEL) below the Minimum Level. The compliance level shall be set at the Minimum Level (ML) for the most sensitive analytical method as given in 40 CFR Part 136, or otherwise accepted by the DEC. |
| Daily Discharge | The discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for the purposes of sampling. For pollutants expressed in units of mass, the 'daily discharge' is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurement, the 'daily discharge' is calculated as the average measurement of the pollutant over the day. |
| Daily Maximum | The highest allowable Daily Discharge. |
| Daily Minimum | The lowest allowable Daily Discharge. |
| Effective Date of Permit (EDP or EDPM) | The date this permit is in effect. |
| Effluent Limitations | Effluent limitation means any restriction on quantities, quality, rates and concentrations of chemical, physical, biological, and other constituents of effluents that are discharged into waters of the state. |
| Expiration Date of Permit (ExDP) | The date this permit is no longer in effect. |
| Instantaneous Maximum | The maximum level that may not be exceeded at any instant in time. |
| Instantaneous Minimum | The minimum level that must be maintained at all instants in time. |
| Monthly Average | The highest allowable average of daily discharges over a calendar month, calculated as the sum of each of the daily discharges measured during a calendar month divided by the number of daily discharges measured during that month. |
| Outfall | The terminus of a sewer system, or the point of emergence of any waterborne sewage, industrial waste or other wastes or the effluent therefrom, into the waters of the State. |
| Range | The minimum and maximum instantaneous measurements for the reporting period must remain between the two values shown. |
| Receiving Water | The classified waters of the state to which the listed outfall discharges. |
| Sample Frequency / Sample Type / Units | See NYSDEC's "DMR Manual for Completing the Discharge Monitoring Report for the SPDES" for information on sample frequency, type and units. |

PERMIT LIMITS, LEVELS AND MONITORING

| OUTFALL | LIMITATIONS APPLY | RECEIVING WATER | EFFECTIVE | EXPIRING |
|---------|-------------------|------------------------------------|-----------|----------|
| 001 | All Year | Neversink River, Middle, Main Stem | | |

| PARAMETER | EFFLUENT LIMITATION | | | | | MONITORING REQUIREMENTS | | | | FN |
|--|-----------------------|---------|-------------|-------|-------|-------------------------|-------------|----------|------|-------|
| | Type | Limit | Units | Limit | Units | Sample Frequency | Sample Type | Location | | |
| | | | | | | | | Inf. | Eff. | |
| Flow | Monthly Average | 0.10 | MGD | | | Continuous | Recorder | X | X | (4) |
| pH | Daily Minimum | 6.5 | SU | | | Daily | Grab | X | X | |
| | Daily Maximum | 8.5 | SU | | | | | | | |
| Temperature | Daily Maximum | 70 | °F | | | Daily | Grab | | X | |
| BOD ₅ | Daily Maximum | 5.0 | mg/L | 4.17 | lbs/d | 1/Month | 6-hr. Comp. | X | X | (1,3) |
| Total Suspended Solids (TSS) | Daily Maximum | 10.0 | mg/L | 5.34 | lbs/d | 1/Month | 6-hr. Comp. | X | X | (1,3) |
| Settleable Solids | Daily Maximum | 0.1 | mL/L | | | Daily | Grab | | X | |
| Dissolved Oxygen | Daily Minimum | 7.0 | mg/L | | | Daily | Grab | | X | |
| Ammonia (as N) June 1st - October 31st | Monthly Average | 0.90 | mg/L | 1.90 | lbs/d | 1/Month | 6-hr. Comp. | | X | (3) |
| Ammonia (as N) November 1 st – May 31 st | Monthly Average | 1.81 | mg/L | 3.78 | lbs/d | 1/Month | 6-hr. Comp. | | X | (3) |
| Total Phosphorus (as P) | Monthly Average | Monitor | mg/L | | | 1/Month | 6-hr. Comp. | | X | (5) |
| Nitrogen, Nitrate (as N) | Daily Maximum | Monitor | mg/L | | | 1/Month | 6-hr. Comp. | | X | (5) |
| Nitrogen, TKN (as N) | Monthly Average | Monitor | mg/L | | | 1/Month | 6-hr. Comp. | X | X | (5) |
| Total Dissolved Solids | Daily Maximum | Monitor | mg/L | | | 1/Quarter | 6-hr. Comp. | | X | (5) |
| EFFLUENT DISINFECTION | | | | | | | | | | |
| Required Seasonal from June 1 st - October 31 st | | Limit | Units | Limit | Units | Sample Frequency | Sample Type | Inf. | Eff. | FN |
| Coliform, Fecal | 30-Day Geometric Mean | 200 | No./ 100 mL | | | 1/Month | Grab | | X | |
| Coliform, Fecal | 7-Day Geometric Mean | 400 | No./ 100 mL | | | 1/Month | Grab | | X | |
| Chlorine, Total Residual | Daily Maximum | 0.1 | mg/L | | | Daily | Grab | | X | (2) |

FOOTNOTES:

- Effluent shall not exceed 15% and 15% of influent concentration values for BOD₅ & TSS respectively.
- Sampling and reporting for total residual chlorine are only necessary if chlorine is used for disinfection, elsewhere in the treatment process, or the facility otherwise has reasonable potential to discharge chlorine. Otherwise, the permittee shall report NODI-9 on the DMR.
- At least 8 individual manual grab samples must be collected over the course of 6 hours analyzed separately, and the concentrations averaged. Alternatively, grab samples may be collected in the field and composited in the

laboratory and analyzed as a single sample if the results are equivalent to the arithmetic averaging of individual grab samples. Where effluent flows do not vary more than 10 percent over the course of composite sample collection, composite samples may be composed of equal size grab samples taken at equal time intervals. Where effluent flows do vary more than 10 percent over the course of sample collection, composite samples must be flow-proportioned.

4. Monthly average flow may be recorded at either the influent or the effluent.
5. Delaware River Basin Commission (DRBC) monitoring and reporting requirements.

DRAFT

ADDITIONAL REQUIREMENTS PROVIDED BY THE DELAWARE RIVER BASIN COMMISSION (DRBC)

1. Prior to the permittee initiating any substantial alterations or additions to the existing WWTP as defined in Section 3.10.3A2.a.16 of the Delaware River Basin Commission's Water Quality Regulations (18CFR Part 410), a No Measureable Change to Existing Water Quality Analysis must be conducted by the Delaware River Basin Commission. The No Measureable Change to Existing Water Quality Analysis shall be conducted prior to final design to ensure that the Commission can provide the permittee with proposed effluent limitations to be included in a future SPDES permit for Special Protection Waters specific parameters as guidance for treatment design purposes. The permittee is encouraged to contact DRBC staff during the planning stages of any project that meets the definition of substantial alteration or additions, as per DRBC.
2. Except as otherwise authorized by this permit, if the permittee seeks relief from any limitation based upon a Delaware River Basin Commission water quality standard or minimum treatment requirement, the permittee shall apply for approval from the Delaware River Basin Commission Executive Director and NJDEP for a permit revision.
3. Prior to accepting for treatment and discharge 50,000 gallons per day or more (as a daily average) of wastewater that is imported from outside the Delaware River Basin, the permittee shall first apply to and obtain approval from the Delaware River Basin Commission.
4. The permittee may conduct a study to determine if specific conductance may be substituted for TDS in the permit. The study should include effluent specific data to be used to determine a correlation between TDS and specific conductance. Upon review, the Delaware River Basin Commission will determine if the permit may be modified to allow the substitution of specific conductivity for TDS monitoring. The TDS limit would then be supplanted by a specific conductance limit in the permit.
5. The WWTP shall have available standby power facilities unless it can be shown that a proposed discharge can be interrupted for an extended period with no threat to the water quality of Delaware River Basin Commission (DRBC)-designated Special Protection Waters (SPW)." 18 CFR Part 410 Section 3.10.3. A. 2.d.1.
6. In the event that the WWTP is not staffed 24 hours every day, the WWTP shall have a remote alarm that will continuously monitor plant operations whenever the plant is not staffed. The alarm system shall be designed to alert someone available with authority and knowledge to take appropriate action. 18 CFR Part 410 Section 3.10.3. A. 2.d.2.
7. The permittee shall prepare and implement an emergency management plan (EMP) following the guidance provided in the Water Pollution Control Federation's Manual of Practice SM-8, Emergency Planning for Municipal Wastewater Facilities, the U.S. EPA's Design Criteria for Mechanical, Electric and Fluid System and Component Reliability or other suitable manuals. Emergency management plans shall include an emergency notification procedure covering all affected downstream users." 18 CFR Part 410 Section 3.10.3. A. 2.d.4.
8. Based upon the written recommendation of the DRBC staff, when the discharge is operated in accordance with the provisions and conditions established by this permit, then with respect to effluent quality and stream quality objectives, the project does not substantially impair or conflict with the Commission's Comprehensive Plan.

MERCURY MINIMIZATION PROGRAM (MMP) - Type IV

1. General - The permittee must develop, implement, and maintain a mercury minimization program (MMP), containing the elements set forth below.
2. MMP Elements - The MMP must be a written document and must include any necessary drawings or maps of the facility and/or collection system. Other related documents already prepared for the facility may be used as part of the MMP and may be incorporated by reference. At a minimum, the MMP must include the following elements¹ as described in detail below:
 - a. Conditional Exclusion Certification - A certification (Appendix D of *DOW 1.3.10*), signed in accordance with 750-1.8 Signature of SPDES forms, must be submitted once every five (5) years for Outfall(s) 001 to the Regional Water Engineer and to the Bureau of Water Permits certifying that Outfall(s) 001 for the facility is neither a mercury source nor receives flows from a mercury source. Criteria to determine if a facility has a mercury source are as follows:
 - The facility is or receives discharge from 1) individually permitted combined sewer overflow (CSOs)² communities and/or 2) Type II sanitary sewer overflow (SSO)³ facilities;
 - One or more effluent samples which exceed 12 ng/L, including samples taken as a result of the SPDES application process;
 - Internal or tributary waste stream samples exceed the GLCA effluent limitation **AND** the final effluent samples are less than the GLCA due primarily to dilution by uncontaminated or less contaminated waste streams. Both components of this criterion may include samples taken as a result of the SPDES application process;
 - A permit application or other information indicates that mercury is handled on site and could be discharged through outfalls;
 - Outfalls which contain legacy mercury contamination;
 - The facility's collection system receives discharges from a dental and/or categorical industrial user (CIU)⁴ that may discharge mercury;
 - The facility accepts hauled wastes; or,
 - The facility is defined as a categorical industry that may discharge mercury. This may also include dentists, universities, hospitals, or laboratories which have their own SPDES permit.
 - b. Control Strategy - The control strategy must contain the following minimum elements:
 - i. Equipment and Materials – Equipment and materials (e.g., thermometers, thermostats) used by the permittee, which may contain mercury, must be evaluated by the permittee. As equipment and materials containing mercury are updated/replaced, the permittee must use mercury-free alternatives, if possible.
 - ii. Bulk Chemical Evaluation – For chemicals, used at a rate which exceeds 1,000 gallons/year or 10,000 pounds/year, the permittee must obtain a manufacturer's certificate of analysis, a chemical analysis performed by a certified laboratory, and/or a notarized affidavit which describes the substances' mercury concentration and the detection limit achieved. If possible, the permittee must only use bulk chemicals utilized in the wastewater treatment process which contain <10 ppb mercury.

¹Neither monitoring nor outreach is required for facilities meeting the criteria for MMP Type IV, but monitoring and/or outreach can be included in the permittee's control strategy.

²CSO permits are included under the 05 and 07 permit classifications.

³These are overflow retention facilities (ORFs) and are included under the 05 and 07 permit classifications.

⁴CIUs include those listed under Federal Regulation in 40 CFR Part 400.

MERCURY MINIMIZATION PROGRAM (MMP) – Type IV (Continued)

- c. **Status Report** - An **annual** status report must be developed and maintained on site, in accordance with the [Schedule of Additional Submittals](#), summarizing:
- Review of criteria to determine if the facility has a potential mercury source;
 - If the permittee no longer meets the criteria for MMP Type IV, the permittee must notify the DEC for a permittee-initiated permit modification;
 - All actions undertaken, pursuant to the control strategy, during the previous year; and
 - Actions planned, pursuant to the control strategy, for the upcoming year.

The permittee must maintain a file with all MMP documentation. The file must be available for review by DEC representatives and copies must be provided upon request in accordance with 6 NYCRR 750-2.1(i) and 750-2.5(c)(4).

3. **MMP Modification** - The MMP must be modified whenever:
- Changes at the facility, or within the collection system, increase the potential for mercury discharges;
 - A letter from the Department identifies inadequacies in the MMP.

The DEC may use information in the annual status reports, in accordance with 2.c of this MMP, to determine if the permit limitations and MMP Type is appropriate for the facility.

DEFINITIONS:

Potential mercury source – a source identified by the permittee that may reasonably be expected to have total mercury contained in the discharge. Some potential mercury sources include switches, fluorescent lightbulbs, cleaners, degreasers, thermometers, batteries, hauled wastes, universities, hospitals, laboratories, landfills, Brownfield sites, or raw material storage.

DISCHARGE NOTIFICATION REQUIREMENTS

- (a) The permittee shall install and maintain identification signs at all outfalls to surface waters listed in this permit, unless the Permittee has obtained a waiver in accordance with the Discharge Notification Act (DNA). Such signs shall be installed before initiation of any new discharge location.
- (b) Subsequent modifications to or renewal of this permit does not reset or revise the deadline set forth in (a) above, unless a new deadline is set explicitly by such permit modification or renewal.
- (c) The Discharge Notification Requirements described herein do not apply to outfalls from which the discharge is composed exclusively of storm water, or discharges to ground water.
- (d) The sign(s) shall be conspicuous, legible and in as close proximity to the point of discharge as is reasonably possible while ensuring the maximum visibility from the surface water and shore. The signs shall be installed in such a manner to pose minimal hazard to navigation, bathing or other water related activities. If the public has access to the water from the land in the vicinity of the outfall, an identical sign shall be posted to be visible from the direction approaching the surface water.

The signs shall have **minimum** dimensions of eighteen inches by twenty-four inches (18" x 24") and shall have white letters on a green background and contain the following information:

N.Y.S. PERMITTED DISCHARGE POINT

SPDES PERMIT No.: NY _____

OUTFALL No. : _____

For information about this permitted discharge contact:

Permittee Name: _____

Permittee Contact: _____

Permittee Phone: () - ### - #####

OR:

NYSDEC Division of Water Regional Office Address:

NYSDEC Division of Water Regional Phone: () - ### - #####


- (e) Upon request, the permittee shall make available electronic or hard copies of the sampling data to the public. In accordance with the RECORDING, REPORTING AND ADDITIONAL MONITORING REQUIREMENTS page of your permit, each DMR shall be maintained (either electronically or as a hard copy) on record for a period of five years.
- (f) The permittee shall periodically inspect the outfall identification sign(s) in order to ensure they are maintained, are still visible, and contain information that is current and factually correct. Signs that are damaged or incorrect shall be replaced within 3 months of inspection.

MONITORING LOCATIONS

The permittee shall take samples and measurements, to comply with the monitoring requirements specified in this permit, at the locations(s) specified below:

Influent: Bar Screen

Effluent: Cascade Aerator



GENERAL REQUIREMENTS

- A. The regulations in 6 NYCRR Part 750 are hereby incorporated by reference and the conditions are enforceable requirements under this permit. The permittee shall comply with all requirements set forth in this permit and with all the applicable requirements of 6 NYCRR Part 750 incorporated into this permit by reference, including but not limited to the regulations in paragraphs B through I as follows:
- B. General Conditions
1. Duty to comply 6 NYCRR 750-2.1(e) & 2.4
 2. Duty to reapply 6 NYCRR 750-1.16(a)
 3. Need to halt or reduce activity not a defense 6 NYCRR 750-2.1(g)
 4. Duty to mitigate 6 NYCRR 750-2.7(f)
 5. Permit actions 6 NYCRR 750-1.1(c), 1.18, 1.20 & 2.1(h)
 6. Property rights 6 NYCRR 750-2.2(b)
 7. Duty to provide information 6 NYCRR 750-2.1(i)
 8. Inspection and entry 6 NYCRR 750-2.1(a) & 2.3
- C. Operation and Maintenance
1. Proper Operation & Maintenance 6 NYCRR 750-2.8
 2. Bypass 6 NYCRR 750-1.2(a)(17), 2.8(b) & 2.7
 3. Upset 6 NYCRR 750-1.2(a)(94) & 2.8(c)
- D. Monitoring and Records
1. Monitoring and records 6 NYCRR 750-2.5(a)(2), 2.5(a)(6), 2.5(c)(1), 2.5(c)(2), & 2.5(d)
 2. Signatory requirements 6 NYCRR 750-1.8 & 2.5(b)
- E. Reporting Requirements
1. Reporting requirements 6 NYCRR 750-2.5, 2.7 & 1.17
 2. Anticipated noncompliance 6 NYCRR 750-2.7(a)
 3. Transfers 6 NYCRR 750-1.17
 4. Monitoring reports 6 NYCRR 750-2.5(e)
 5. Compliance schedules 6 NYCRR 750-1.14(d)
 6. 24-hour reporting 6 NYCRR 750-2.7(c) & (d)
 7. Other noncompliance 6 NYCRR 750-2.7(e)
 8. Other information 6 NYCRR 750-2.1(f)
- F. Planned Changes
1. The permittee shall give notice to the DEC as soon as possible of planned physical alterations or additions to the permitted facility when:
 - a. The alteration or addition to the permitted facility may meet any of the criteria for determining whether facility is a new source in 40 CFR §122.29(b); or
 - b. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants which are subject either to effluent limitations in the permit, or to notification requirements under 40 CFR §122.42(a)(1); or
 - c. The alteration or addition results in a significant change in the permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan.

In addition to the DEC, the permittee shall submit a copy of this notice to the United States Environmental Protection Agency at the following address: U.S. EPA Region 2, Clean Water Regulatory Branch, 290 Broadway, 24th Floor, New York, NY 10007-1866.

GENERAL REQUIREMENTS (continued)

G. Sludge Management

The permittee shall comply with all applicable requirements of 6 NYCRR Part 360.

H. SPDES Permit Program Fee

The permittee shall pay to the Department an annual SPDES permit program fee within 30 days of the date of the first invoice, unless otherwise directed by the DEC, and shall comply with all applicable requirements of ECL 72-0602 and 6 NYCRR Parts 480, 481 and 485. Note that if there is inconsistency between the fees specified in ECL 72-0602 and 6 NYCRR Part 485, the ECL 72-0602 fees govern.

I. Water Treatment Chemicals (WTCs)

New or increased use and discharge of a WTC requires prior DEC review and authorization. At a minimum, the permittee must notify the DEC in writing of its intent to change WTC use by submitting a completed *WTC Notification Form* for each proposed WTC. The DEC will review that submittal and determine if a SPDES permit modification is necessary or whether WTC review and authorization may proceed outside of the formal permit administrative process. The majority of WTC authorizations do not require SPDES permit modification. In any event, use and discharge of a WTC shall not proceed without prior authorization from the DEC. Examples of WTCs include biocides, coagulants, conditioners, corrosion inhibitors, defoamers, deposit control agents, flocculants, scale inhibitors, sequestrants, and settling aids.

1. WTC use shall not exceed the rate explicitly authorized by this permit or otherwise authorized in writing by the DEC.
2. The permittee shall maintain a logbook of all WTC use, noting for each WTC the date, time, exact location, and amount of each dosage, and, the name of the individual applying or measuring the chemical. The logbook must also document that adequate process controls are in place to ensure that excessive levels of WTCs are not used.
3. The permittee shall submit a completed WTC Annual Report Form each year that they use and discharge WTCs. This form shall be submitted in electronic format and attached to either the December DMR or the annual monitoring report required below. The *WTC Notification Form* and *WTC Annual Report Form* are available from the DEC's website at: <http://www.dec.ny.gov/permits/93245.html>

RECORDING, REPORTING AND ADDITIONAL MONITORING REQUIREMENTS

- A. The monitoring information required by this permit shall be retained for a period of at least five years from the date of the sampling for subsequent inspection by the DEC or its designated agent.
- B. Discharge Monitoring Reports (DMRs): Completed DMR forms shall be submitted for each 1 month reporting period in accordance with the DMR Manual available on DEC's website.

DMRs must be submitted electronically using the electronic reporting tool (NetDMR) specified by DEC. Instructions on the use of NetDMR can be found at <https://www.dec.ny.gov/chemical/8461.html>. **Hardcopy paper DMRs will only be accepted if a waiver from the electronic submittal requirements has been granted by DEC to the facility.**

Attach the monthly "Wastewater Facility Operation Report" (form 92-15-7) and any required DMR attachments electronically to the DMR or with the hardcopy submittal.

The first monitoring period begins on the effective date of this permit, and, unless otherwise required, the reports are due no later than the 28th day of the month following the end of each monitoring period.

- C. Additional information required to be submitted by this permit shall be summarized and reported to the Regional Water Engineer and Bureau of Water Permits at the following addresses:

Department of Environmental Conservation
Division of Water, Bureau of Water Permits
625 Broadway, Albany, New York 12233-3505

Phone: (518) 402-8111

Department of Environmental Conservation
Regional Water Engineer, Region 3
21 South Putt Corners Road, New Paltz, New York, 12561-1620 Phone: (845) 256-3000

- D. Schedule of Additional Submittals:

The permittee shall submit the following information to the Regional Water Engineer and to the Bureau of Water Permits, unless otherwise instructed:

| SCHEDULE OF ADDITIONAL SUBMITTALS | | |
|-----------------------------------|---|--|
| Outfall(s) | Required Action | Due Date |
| 001 | <p>MERCURY - CONDITIONAL EXCLUSION CERTIFICATION</p> <p>Permittee must submit a mercury conditional exclusion certification every five years in order to maintain MMP Type IV status. The permittee shall collect and submit a single representative effluent grab sample and have it analyzed for total mercury using EPA Method 1631. As part of the certification the permittee will be required to sample the effluent and measure <12 ng/L.</p> <p>Upon review of the above results, the Department may reopen the permit to include additional limits for Mercury.</p> | EDP + 6 months, and every 5 years thereafter |

- E. Monitoring and analysis shall be conducted using sufficiently sensitive test procedures approved under 40 CFR Part 136, unless other test procedures have been specified in this permit.
- F. More frequent monitoring of the discharge(s), monitoring point(s), or waters of the State than required by the permit, where analysis is performed by a certified laboratory or where such analysis is not required to be performed by a certified laboratory, shall be included in the calculations and recording of the data on the corresponding DMRs.

- G. Calculations which require averaging of measurements shall utilize an arithmetic mean unless otherwise specified in this permit.
- H. Unless otherwise specified, all information recorded on the DMRs shall be based upon measurements and sampling carried out during the most recently completed reporting period.
- I. Any laboratory test or sample analysis required by this permit for which the State Commissioner of Health issues certificates of approval pursuant to section 502 of the Public Health Law shall be conducted by a laboratory which has been issued a certificate of approval. Inquiries regarding laboratory certification should be directed to the New York State Department of Health, Environmental Laboratory Accreditation Program.

DRAFT

Permittee: Davos Sewer Company Inc.
Facility: Davos in the Woods
SPDES Number: NY0218987
USEPA Non-Major/Class 09 PCI

Date: April 9, 2025 v.1.28
Permit Writer: Stephen Monteverde
Water Quality Reviewer: Aslam Mirza
Full Technical Review

SPDES Permit Fact Sheet

Davos Sewer Company Inc.

Davos in the Woods

NY0218987



**Department of
Environmental
Conservation**

Contents

| | |
|---|----|
| Summary of Permit Changes | 3 |
| Administrative History..... | 3 |
| Facility Information | 4 |
| Site Overview | 4 |
| Enforcement History | 4 |
| Existing Effluent Quality | 4 |
| Interstate Water Pollution Control Agencies..... | 4 |
| Additional Site-Specific Concerns | 4 |
| Receiving Water Information | 5 |
| Impaired Waterbody Information..... | 6 |
| Critical Receiving Water Data & Mixing Zone..... | 7 |
| Permit Requirements..... | 8 |
| Whole Effluent Toxicity (WET) Testing..... | 8 |
| Anti-backsliding | 8 |
| Antidegradation | 8 |
| Discharge Notification Act Requirements | 8 |
| Mercury | 9 |
| OUTFALL AND RECEIVING WATER SUMMARY TABLE | 10 |
| POLLUTANT SUMMARY TABLE - Outfall 001..... | 10 |
| Appendix: Regulatory and Technical Basis of Permit Authorizations | 13 |
| Regulatory References | 13 |
| Outfall and Receiving Water Information..... | 13 |
| Interstate Water Pollution Control Agencies..... | 14 |
| Existing Effluent Quality..... | 14 |
| Permit Requirements | 14 |

Summary of Permit Changes

State Pollutant Discharge Elimination System (SPDES) permit has been drafted for the Davos in the Woods. The changes to the permit are summarized below:

- Updated to include correct and ground verified outfall location.
- BOD₅ effluent of limit 5.0 mg/L has been updated to include the mass flow rate of 4.17 lbs/day.
- Total Suspended Solids effluent limit of 10.0 mg/L has been updated to include the mass flow rate of 5.34 lbs/day.
- The monthly average ammonia effluent limit of 2.0 mg/L has been updated to include season effluent limits of 0.90 mg/L and 1.81 mg/L for June 1st through October 31st and November 1st through May 31st, respectively.
- The seasonal ammonia effluent limits have also been updated to include mass flow rates of 1.90 lbs/day and 3.78 lbs/day for June 1st through October 31st and November 1st through May 31st, respectively.
- Seasonal effluent disinfection dates have been updated from May 15th to October 15th to include June 1st to October 31st.
- Updated to include Delaware River Basin Commission (DRBC) monthly monitoring and reporting requirements for Total Phosphorus, Nitrate (as N), Total Kjeldahl Nitrogen (as N).
- Updated to include Delaware River Basin Commission (DRBC) quarterly monitoring requirement for Total Dissolved Solids (TDS).
- Reporting frequency updated to include an annual report, to be submitted to the Department by February 1st each year. The report shall summarize information for January to December of the previous year and shall be submitted electronically, or in hardcopy format, utilizing the SPDES Annual Report Form available on the Department's website.
- Updated the Individual SPDES Permit class from 02 PCI to 09 PCI.
- Updated to include a Mercury Conditional Exclusion Certification every 5 years in order to maintain MMP Type IV status.
- Updated SPDES annual reporting to monthly Net DMR submissions.

This fact sheet summarizes the information used to determine the effluent limitations (limits) and other conditions contained in the permit. General background information including the regulatory basis for the effluent limitations and other conditions are in the [Appendix](#) linked throughout this fact sheet.

Administrative History

12/1/2006 The last full technical review was performed and the SPDES permit became effective with a new five-year term and expiration date of 11/30/2011. The 2006 permit has formed the basis of this permit.

The permit was administratively renewed in 2011 and again in 2016. The current permit expired on 11/20/2021.

11/20/2021 The SPDES permit for the facility expired.

8/9/2022 The Davos Sewer Company Inc. submitted a PCI form.

2/2/2024 A notice of incomplete application was sent to the permittee.

3/18/2024 The permittee responded to the notice of incomplete application and supplied documentation that supported the formation of a Sewage Disposal Corporation.

The Notice of Complete Application, published in the [Environmental Notice Bulletin](#) and newspapers, contains information on the public notice process.

Facility Information

This facility is a private facility that receives flow from domestic users, with effluent consisting of treated sanitary wastewater. The collection system consists of separate sewers. The facility does not have any significant industrial users (SIUs).

The current 0.1 MGD treatment plant consists of:

- Preliminary Treatment: Bar Screen
- Primary Treatment: Flow Equalization and Primary Settling
- Secondary Treatment: Rotating Biological Contactors
- Tertiary Treatment: Rapid Sand Filtration
- Disinfection: UV disinfection

Sludge is collected through an airlift system and stored in a 26,000-gallon aerobic sludge storage tank for removal and disposal by a licensed commercial sludge hauler.

The primary outfall (Outfall 001) is a surface water discharge. Following open channel cascade aeration, a 12" effluent pipe extends to the Neversink River from the treatment plant. The outfall pipe is approximately 1,250 linear feet.

The facility does not have any planned improvements.

The facility accepts wastewater from the following municipalities:

| Municipality | POSS # or SPDES # | Collection System |
|--------------------------|-------------------|-------------------|
| Davos Sewer Company Inc. | NY0218987 | Separate |

Site Overview

Enforcement History

On April 29, 2022, Davos in the Woods received a notice of violation for several deficiencies related to the grounds and treatment facilities. The facility was directed to submit a corrective action plan and schedule for resolving violations by 6/30/2022. This item has not been completed to date.

Existing Effluent Quality

The [Pollutant Summary Table](#) presents the existing effluent quality and effluent limitations. The existing effluent quality was determined from Discharge Monitoring Reports and the application submitted by the permittee for the period 1/1/2020 to 3/31/2021.

Interstate Water Pollution Control Agencies

Outfall(s) 001 is located within the Delaware River Basin Commission (DRBC) compact area which places additional requirements in the SPDES permit. [Appendix Link](#)

Additional Site-Specific Concerns


The Neversink River contains an endangered mussel species. The facility is located within a watershed with known populations of Brook Floater Mussel, which may place additional requirements in the SPDES permit.

Receiving Water Information


The facility discharges via the following outfalls:

| Outfall No. | SIC Code | Wastewater Type | Receiving Water |
|-------------|----------|-------------------------|------------------------------|
| 001 | 8999 | Treated Sanitary Sewage | Neversink River, Class B(T), |

Reach Description: The Davos in the Woods facility discharges into the Neversink River, Main Stem just upstream of the confluence, where minor tributaries join the larger channel. The main stem of the Neversink River (D – 1 Portion 3) is a tributary of the Delaware River, within the Delaware River Basin. The segment of The Neversink River at the point of discharge is classified as B with B(T) standard classification (6NYCRR 815.6 – Table I - Item 4). The classification remains as B(T) until changing to class B at the Basher Kill Confluence (6NYCRR 815.6 – Table I – Item 45), approximately 23 miles downstream of the discharge. A Tributary of the Codfish Brook (WIN: D-1-42-1, 4), Class B, also runs through the site. There are bald eagle nests and brook floater mussels within the Codfish Brook catchment area and within the Neversink River. No DEC regulated wetlands are located near the facility, but the Fish and Wildlife Service/National Wetlands Inventory lists several wetlands that are in the vicinity of the facility’s process units.



USGS Terrain Map of Neversink River Reach - facility demarcated by red point on Grinne Felder Rd.



Satellite image of Neversink River, Davos in the Woods facility, and facility outfall locations.

See the [Outfall and Receiving Water Summary Table](#) and [Appendix](#) for additional information.

Impaired Waterbody Information

The Neversink River, Main Stem segment (PWL No. 1402 - 0021) is not listed on the 2018 [New York State Section 303\(d\) List](#) of Impaired/TMDL Waters, and therefore, there are no applicable wasteload allocations (WLAs) for this discharge.

Critical Receiving Water Data & Mixing Zone

The low flow of 17.7 cfs for Neversink river was obtained from a water quality model developed by the NYSDEC in 1991. The current 7Q10 flow (17.1 cfs) is close to the one used in model, hence, modeled flow of 17.7 will be used for this permit for summer period. For winter, a flow of 10.3 will be used consistent with past modeling effort. Since, no mixing zone data was provided, hence, WQBELs for toxic pollutants will be determined using “rapid and complete mix” assumption. The flows used in determining the waste load allocations (WLA) are listed below:

Part 671.3 Operation of Neversink Reservoir, Unit = CFS

| Normal Hydrologic Conditions | Constant Minimum Flow | Intervening Flow-7Q10 | Q-Total | Flow Used in the WQ Model |
|------------------------------|-----------------------|-----------------------|---------|---------------------------|
| April 1 – Oct 31 | 45 | 2.2 | 47.2 | No |
| Nov 1 – March 31 | 25 | 5.7 | 30.7 | No |

Part 671.3 Operation of Neversink Reservoir, Unit = CFS

| Drought and Drought Warning Conditions | Constant Minimum Flow | Intervening Flow-7Q10 | Q-Total | Flow Used in the WQ Model | 30Q10 |
|--|-----------------------|-----------------------|---------|---------------------------|---------|
| April 1 – Oct 31 | 15.5 | 2.2 | 17.7 | Yes* | 19.2** |
| Nov 1 – March 31 | 4.6 | 5.7 | 10.3 | Yes* | 14.0*** |

*- 30 % reduction was applied for to the model inputs for computing WLA per NYSDEC policy (Now, TOGS 1.3.1). These flows were calculated upstream of the S. Fallsburg plant.

** - November 1 – April 7

*** - April 8 – October 31

The Neversink flow at the Davos in Woods is sum of upstream discharge flows (S. Fallsburg, Woodridge) and lowest release flow per Part 671.3.

Summer = $5.04 + 1.22 + 17.7 = 23.96$ cfs

Winter = $5.04 + 1.22 + 10.3 = 16.56$ cfs

These flows are used for computing acute, chronic, and human, aesthetic, wildlife (HEW) dilution ratios and are listed below.

Dilution Ratio = (Facility Flow + Low Flow) / Facility Flow

| Outfall No. | Acute Dilution Ratio A(A) | Chronic Dilution Ratio A(C) | Human, Aesthetic, Wildlife Dilution Ratio (HEW) | Basis |
|-------------|---------------------------|-----------------------------|---|-------|
| 001 | 100:1* | 100:1* | 100:1* | BPJ |

*- Due to high dilution, it is capped to 100:1 (BPJ)

Critical receiving water data are listed in the [Pollutant Summary Table](#) at the end of this fact sheet. [Appendix Link](#)

Permit Requirements

The technology based effluent limitations ([TBELs](#)), water quality-based effluent limitations ([WQBELs](#)), [Existing Effluent Quality](#) and a discussion of the selected effluent limitation for each pollutant present in the discharge are provided in the [Pollutant Summary Table](#).

Whole Effluent Toxicity (WET) Testing

None of the seven criteria that are indicative of potential toxicity are applicable to this facility; therefore, WET testing is not included in the permit. [Appendix Link](#)

Anti-backsliding

The limitations contained in the permit are at least as stringent as the previous permit limits and there are no instances of backsliding.

[Appendix Link](#)

Antidegradation

The permit contains effluent limitations which ensure that the best usages of the receiving waters will be maintained. The Notice of Complete Application published in the Environmental Notice Bulletin contains information on the State Environmental Quality Review (SEQR)¹ determination. [Appendix Link](#)

Discharge Notification Act Requirements

In accordance with the Discharge Notification Act (ECL 17-0815-a), the permittee is required to post a sign at each point of wastewater discharge to surface waters, unless a waiver is obtained. This requirement is being continued from the previous permit.

¹ As prescribed by 6 NYCRR Part 617
PAGE 8 OF 18

Permittee: Davos Sewer Company Inc.
Facility: Davos in the Woods
SPDES Number: NY0218987
USEPA Non-Major/Class 09 PCI

Date: April 9, 2025 v.1.28
Permit Writer: Stephen Monteverde
Water Quality Reviewer: Aslam Mirza
Full Technical Review

Mercury

The multiple discharge variance (MDV) for mercury provides the framework for DEC to require mercury monitoring and mercury minimization programs (MMPs), through SPDES permitting. [Appendix Link](#)

The facility is an EPA 09, PCI Significant Minor. By six months from the effective date of the permit, the permittee must submit a Conditional Exclusion Certification, certifying that the facility does not have any of the mercury sources listed in Part III.A.3. of DOW 1.3.10 and the effluent measured <12 ng/L. Therefore, consistent with DOW 1.3.10, the permit includes requirements for the implementation of MMP Type IV and does not include mercury effluent limitations. The [Schedule of Additional Submittals](#) includes a mercury minimization plan annual status report (maintained onsite), and re-certification of the exclusion every five years. As part of the re-certification, the effluent must be sampled and continue to measure <12 ng/L. This requirement is new.

OUTFALL AND RECEIVING WATER SUMMARY TABLE

| Outfall | Latitude | Longitude | Receiving Water Name | Water Class | Water Index No. / Priority Waterbody Listing (PWL) No. | Major / Sub Basin | Hardness (mg/l) | 1Q10 (CFS) | 7Q10 (CFS) | 30Q10 (CFS) | Critical Effluent Flow (MGD) | Dilution Ratio | | |
|---------|---------------|---------------|----------------------|-------------|--|-------------------|-----------------|-----------------|------------|-------------|------------------------------|----------------|------|-----|
| | | | | | | | | | | | | A(A) | A(C) | HEW |
| 001 | 41° 40' 46" N | 74° 35' 48" W | Neversink River | B(T) | D-1 (portion 3) PWL: 1402-0021 | 14 / 02 | 30 | Regulated Flow* | | | 0.10 | 100:1 (Capped) | | |

*- See Critical Receiving Water Data & Mixing Zone Section for detail.

POLLUTANT SUMMARY TABLE - Outfall 001

| Outfall # | 001 | Description of Wastewater: Treated Sanitary Sewage | | | | | | | | | | | | | |
|--|-------|--|-------------------------|--|---|-------|------------------|--|--|-------------------|---------|-------------|-----------------|-------|--|
| | | Type of Treatment: Bar Screen, Flow Equalization, Primary Settling, Rotating Biological Contactor (RBCs), Secondary Clarifier, Sand filtration, UV disinfection, Cascade Aeration. | | | | | | | | | | | | | |
| Effluent Parameter | Units | Averaging Period | Existing Discharge Data | | | TBELs | | Water Quality Data & WQBELs | | | | | | ML | Basis for Permit Requirement |
| | | | Permit Limit | Existing Effluent Quality ² | # of Data Points Detects / Non-Detects | Limit | Basis | Ambient Bkgd. Conc. | Projected Instream Conc. | WQ Std. or GV | WQ Type | Calc. WQBEL | Basis for WQBEL | | |
| General Notes: Existing discharge data from 1/1/2020 to 3/31/2021 was obtained from Discharge Monitoring Reports provided by the permittee. All applicable water quality standards were reviewed for development of the WQBELs. The standard and WQBEL shown below represent the most stringent. | | | | | | | | | | | | | | | |
| Flow Rate | MGD | Monthly Avg | 0.10 | 0.02 Actual Average | 15 | 0.1 | Antibacksliding | Narrative: No alterations that will impair the waters for their best usages. | | | | 703.2 | - | - | |
| | | | | | | | | | | | | | | | The flow limit is set at the design flow of the wastewater treatment facility. |
| pH | SU | Minimum | 6.5 | 7.12 | 15 | 6.5 | Anti-backsliding | - | - | 6.5 – 8.5 (703.3) | Range | - | - | - | TBEL |
| | | Maximum | 8.5 | 9.49 | 15 | 8.5 | | | | | | | | | |
| Consistent with ECL 17-0509, TBELs for facilities treating sanitary sewage are reflective of secondary treatment standards . Given the available dilution an effluent limitation equal to the TBEL is reasonably protective of the WQS. | | | | | | | | | | | | | | | |
| Temperature | °F | Daily Max | 70 | 80.8 | 15 | 70 | Antibacksliding | - | Narrative (Trout): No discharge at a temperature over 70F (21C) shall be permitted at any time to streams classified for trout | | | 704.2 | - | WQBEL | |
| | | | | | | | | | | | | | | | See the Temperature Requirements for Municipal Discharges to Trout Streams section of the factsheet for a full discussion. |
| Dissolved Oxygen, DO | mg/L | Daily Min | 7.0 | 10.45 | 15 | 7.0 | Antibacksliding | - | >5.0 | 5.0 (703.3) | Chronic | 4.0 | 703.3 | - | TBEL |

² Existing Effluent Quality: Daily Max = 99% lognormal; Monthly Avg = 95% lognormal (for datasets with ≤3 nondetects); Daily Max = 99% delta-lognormal; Monthly Avg = 95% delta-lognormal (for datasets with >3 nondetects)

Permittee: Davos Sewer Company Inc.
 Facility: Davos in the Woods
 SPDES Number: NY0218987
 USEPA Non-Major/Class 09 PCI

Date: April 9, 2025 v.1.28
 Permit Writer: Stephen Monteverde
 Water Quality Reviewer: Aslam Mirza
 Full Technical Review

| Outfall # | 001 | Description of Wastewater: Treated Sanitary Sewage | | | | | | | | | | | | | |
|--|--|--|-------------------------|--|---|-------|-----------------|---|--------------------------|---------------|---------|------------------|-----------------|----|------------------------------|
| | | Type of Treatment: Bar Screen, Flow Equalization, Primary Settling, Rotating Biological Contactor (RBCs), Secondary Clarifier, Sand filtration, UV disinfection, Cascade Aeration. | | | | | | | | | | | | | |
| Effluent Parameter | Units | Averaging Period | Existing Discharge Data | | | TBELs | | Water Quality Data & WQBELs | | | | | | ML | Basis for Permit Requirement |
| | | | Permit Limit | Existing Effluent Quality ² | # of Data Points Detects / Non-Detects | Limit | Basis | Ambient Bkgd. Conc. | Projected Instream Conc. | WQ Std. or GV | WQ Type | Calc. WQBEL | Basis for WQBEL | | |
| SUMMER 6/1 – 10/31 | Based upon the model developed by the DEC staff, it is concluded that a effluent limit of 4.0 mg/l is appropriate. The model using developed using site specific data for Kd and Kr values. | | | | | | | | | | | | | | |
| Dissolved Oxygen, DO | mg/L | Daily Min | 7.0 | 10.45 | 15 | 7.0 | Antibacksliding | - | >5.0 | 5.0 (703.3) | Chronic | 4.0 | 703.3 | - | TBEL |
| WINTER 11/1 – 5/31 | Based upon the model developed by the DEC staff in 1987, it is concluded that an effluent limit of 4.0 mg/l is appropriate. The model using developed using site specific data for Kd and Kr values. The model was calibrated using the stream date including BOD, DO, temperature and etc. The current limit is rolled onto this factsheet. | | | | | | | | | | | | | | |
| 5-day Biochemical Oxygen Demand BOD5 | mg/L | Monthly Avg | 5.0 | 4.82 | 15 /0 | 30 | Antibacksliding | Dissolved Oxygen= 5.0 mg/l (Surrogate Standard - 703.3) | | | | 5.0 (Daily Max) | 703.3 | - | WQBEL |
| | | 7 Day Avg | - | - | - | 45 | Antibacksliding | | | | | | | | |
| | lbs/d | Monthly Avg | 4.17 | 0.80 | 15 | 25.04 | TOGS 1.3.3 | | | | | 4.17 | | | |
| | | 7 Day Avg | - | - | - | 37.56 | TOGS 1.3.3 | | | | | - | | | |
| | % Rem | Minimum | - | - | - | 85 | ECL 17-0509 | | | | | | | | |
| See justification for Dissolved Oxygen. Current permit limits are more stringent than the TBEL. | | | | | | | | | | | | | | | |
| Total Suspended Solids (TSS) | mg/L | Monthly Avg | 10.0 | 2.70 | 15 | 30 | Antibacksliding | Narrative: None from sewage, industrial wastes or other wastes that will cause deposition or impair the waters for their best usages. (703.2) | | | | 10.0 (Daily Max) | Togs 1.3.1 | - | ISEL |
| | | 7 Day Avg | - | - | - | 45 | Antibacksliding | | | | | | | | |
| | lbs/d | Monthly Avg | 8.34 | 0.45 | 15 | 25.04 | TOGS 1.3.3 | | | | | 5.34 | | | |
| | | 7 Day Avg | - | - | - | 37.56 | TOGS 1.3.3 | | | | | - | | | |
| | % Rem | Minimum | - | - | - | 85 | ECL 17-0509 | | | | | | | | |
| Consistent with TOGS 1.3.1, intermittent stream effluent limits (ISEL) are applied to effluent discharges to streams where little or no streamflow is available for dilution. These limits represent the highest degree of treatment that can reasonably be achieved by a wastewater treatment facility treating domestic type waste. These limits are more stringent than the secondary treatment standards under 40CFR Part 133.102. | | | | | | | | | | | | | | | |
| Settleable Solids | mL/L | Daily Max | - | - | - /- | 0.1 | TOGS 1.3.3 | Narrative: None from sewage, industrial wastes or other wastes that will cause deposition or impair the waters for their best usages (703.2) | | | | - | - | - | TBEL |
| Consistent with TOGS 1.3.3 the effluent limitation is equal to the TBEL of 0.1 mL/L for POTWs providing secondary treatment and filtration. Given that adequate dilution is available the TBEL is reasonably protective of the WQS. | | | | | | | | | | | | | | | |

Permittee: Davos Sewer Company Inc.
 Facility: Davos in the Woods
 SPDES Number: NY0218987
 USEPA Non-Major/Class 09 PCI

Date: April 9, 2025 v.1.28
 Permit Writer: Stephen Monteverde
 Water Quality Reviewer: Aslam Mirza
 Full Technical Review

| Outfall # | 001 | Description of Wastewater: Treated Sanitary Sewage | | | | | | | | | | | | | |
|---|---|--|-------------------------|--|---|-------|------------------|-----------------------------|---|---------------|---------|---------------------------|-----------------|----|------------------------------|
| | | Type of Treatment: Bar Screen, Flow Equalization, Primary Settling, Rotating Biological Contactor (RBCs), Secondary Clarifier, Sand filtration, UV disinfection, Cascade Aeration. | | | | | | | | | | | | | |
| Effluent Parameter | Units | Averaging Period | Existing Discharge Data | | | TBELs | | Water Quality Data & WQBELs | | | | | | ML | Basis for Permit Requirement |
| | | | Permit Limit | Existing Effluent Quality ² | # of Data Points Detects / Non-Detects | Limit | Basis | Ambient Bkgd. Conc. | Projected Instream Conc. | WQ Std. or GV | WQ Type | Calc. WQBEL | Basis for WQBEL | | |
| Nitrogen, Ammonia (as N) | mg/L | Monthly Avg | - | - | - /- | 0.90 | Antibacksliding | - | <0.98 | 0.98 | A(C) | 0.98 (ISEL in the permit) | 703.5 | - | WQBEL |
| | lb/d | Monthly Avg | - | - | - | 1.90 | Antibacksliding | - | - | - | - | 0.82 | | | |
| June 1 st – Oct. 31 st | The existing permit limit has been updated per Part 703.5 for a temperature of 24°C (for trout stream) and is being updated to the WQBEL to comply with water quality standard. Reporting for ammonia is also changed from (as NH ₃) to (as N) for simpler data reporting, as this is consistent with the laboratory reporting units. | | | | | | | | | | | | | | |
| Nitrogen, Ammonia (as N) | mg/L | Monthly Avg | - | - | - /- | 1.81 | Antibacksliding | - | <1.81 | 1.81 | A(C) | 1.81 (ISEL in the permit) | 703.5 | - | WQBEL |
| | lb/d | Monthly Avg | - | - | - | 3.78 | Antibacksliding | - | - | - | - | 1.51 | | | |
| Nov. 1 st – May 31 st | The current permit limit is consistent with Part 703.5 for a temperature of 10°C (for trout stream) and is being retained. Reporting for ammonia is also changed from total ammonia to ammonia nitrogen for simpler data reporting, as this is consistent with the laboratory reporting units. | | | | | | | | | | | | | | |
| Coliform, Fecal Seasonal | #/100 ml | 30d Geo Mean | - | - | - /- | 200 | TOGS 1.3.3 | - | Narrative: The monthly geometric mean, from a minimum of five examinations, shall not exceed 200. (703.4_ | | | | - | - | TBEL |
| | | 7d Geo Mean | - | - | - /- | 400 | TOGS 1.3.3 | - | | | | | | | |
| May 15 th – October 15 th | Consistent with TOGS 1.3.3, effluent disinfection is required year-round due to the class of the receiving waterbody. Fecal coliform effluent limitations equal to the TBEL are specified. | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | |
| Total Residual Chlorine (TRC) | mg/L | Daily Max | - | - | - /- | 0.1 | Anti-backsliding | 0.38 (computed) | 0.005 | 0.005 | A(C) | 0.49 | 703.5 | - | WLA |
| | The WQBEL was developed by modeling TRC decay for the upstream two facilities (S. Fallsburg and Woodridge) and the Davos in Woods. A TRC decay rate of 9.6/day was used along with the flow used in the 1987 model. This resulted in an effluent of 0.49 mg/l. A “complete mix” scenario was assumed for computed the WQBEL. | | | | | | | | | | | | | | |

Appendix: Regulatory and Technical Basis of Permit Authorizations

The Appendix is meant to supplement the fact sheet for multiple types of SPDES permits. Portions of this Appendix may not be applicable to this specific permit.

Regulatory References

The provisions of the permit are based largely upon 40 CFR 122 subpart C and 6 NYCRR Part 750 and include monitoring, recording, reporting, and compliance requirements, as well as general conditions applicable to all SPDES permits. Below are the most common citations for the requirements included in SPDES permits:

- Clean Water Act (CWA) 33 section USC 1251 to 1387
- Environmental Conservation Law (ECL) Articles 17 and 70
- Federal Regulations
 - 40 CFR, Chapter I, subchapters D, N, and O
- State environmental regulations
 - 6 NYCRR Part 621
 - 6 NYCRR Part 750
 - 6 NYCRR Parts 700 - 704 – Best use and other requirements applicable to water classes
 - 6 NYCRR Parts 800 – 941 - Classification of individual surface waters
- NYSDEC water program policy, referred to as Technical and Operational Guidance Series (TOGS)
- USEPA Office of Water Technical Support Document for Water Quality-based Toxics Control, March 1991, Appendix E

The following is a quick guide to the references used within the fact sheet:

| SPDES Permit Requirements | Regulatory Reference |
|--|---|
| Anti-backsliding | 6 NYCRR 750-1.10(c) |
| Best Management Practices (BMPS) for CSOs | 6 NYCRR 750-2.8(a)(2) |
| Environmental Benefits Permit Strategy (EBPS) | 6 NYCRR 750-1.18, NYS ECL 17-0817(4), TOGS 1.2.2 (revised January 25, 2012) |
| Exceptions for Type I SSO Outfalls (bypass) | 6 NYCRR 750-2.8(b)(2), 40 CFR 122.41 |
| Mercury Multiple Discharge Variance | Division of Water Program Policy 1.3.10 (DOW 1.3.10) |
| Mixing Zone and Critical Water Information | TOGS 1.3.1 & Amendments |
| PCB Minimization Program | 40 CFR Part 132 Appendix F Procedure 8, 6 NYCRR 750-1.13(a) and 750-1.14(f), and TOGS 1.2.1 |
| Pollutant Minimization Program (PMP) | 6 NYCRR 750-1.13(a), 750-1.14(f), TOGS 1.2.1 |
| Schedules of Compliance | 6 NYCRR 750-1.14 |
| Sewage Pollution Right to Know (SPRTK) | NYS ECL 17-0826-a, 6 NYCRR 750-2.7 |
| State Administrative Procedure Act (SAPA) | State Administrative Procedure Act Section 401(2), 6 NYCRR 621.11(l) |
| State Environmental Quality Review (SEQR) | 6 NYCRR Part 617 |
| USEPA Effluent Limitation Guidelines (ELGs) | 40 CFR Parts 405-471 |
| USEPA National CSO Policy | 33 USC Section 1342(q) |
| Whole Effluent Toxicity (WET) Testing | TOGS 1.3.2 |
| General Provisions of a SPDES Permit Department Request for Additional Information | NYCRR 750-2.1(i) |

Outfall and Receiving Water Information

Impaired Waters

The [NYS 303\(d\) List of Impaired/TMDL Waters](#) identifies waters where specific best usages are not fully supported. The state must consider the development of a Total Maximum Daily Load (TMDL) or other strategy to reduce the input of the specific pollutant(s) that restrict waterbody uses, in order to restore and protect such uses. SPDES permits must include effluent limitations necessary to implement a waste load allocation (WLA) of an EPA-approved TMDL (6 NYCRR 750-1.11(a)(5)(ii)), if applicable. In accordance with 6 NYCRR 750-1.13(a), permittees discharging to waters which are on the list but do not yet have a TMDL developed may be required to perform additional monitoring for the parameters causing the impairment. Accurate monitoring data is needed

to determine the existing capabilities of the wastewater treatment plants and to assure that WLAs are allocated equitably.

Interstate Water Pollution Control Agencies

Some POTWs may be subject to regulations of interstate basin/compact agencies including: Interstate Sanitation Commission (ISC), International Joint Commission (IJC), Delaware River Basin Commission (DRBC), Ohio River Valley Water Sanitation Commission (ORSANCO), and the Susquehanna River Basin Commission (SRBC). Generally, basin commission requirements focus principally on water quality and not treatment technology. However, interstate/compact agency regulations for the ISC, IJC, DRBC and NYC Watershed contain explicit effluent limits which must be addressed during permit drafting. 6 NYCRR 750-2.1(d) requires SPDES permits for discharges that originate within the jurisdiction of an interstate water pollution control agency, to include any applicable effluent standards or water quality standards (WQS) promulgated by that interstate agency.

Existing Effluent Quality

The existing effluent quality is determined from a statistical evaluation of effluent data in accordance with TOGS 1.2.1 and the USEPA Office of Water, Technical Support Document for Water Quality-based Toxics Control, March 1991, Appendix E (TSD). The existing effluent quality is equal to the 95th (monthly average) and 99th (daily maximum) percentiles of the lognormal distribution of existing effluent data. When there are greater than three non-detects, a delta-lognormal distribution is assumed, and delta-lognormal calculations are used to determine the monthly average and daily maximum pollutant concentrations. Statistical calculations are not performed for parameters where there are less than ten data points. If additional data is needed, a monitoring requirement may be specified either through routine monitoring or a short-term high intensity monitoring program. The [Pollutant Summary Table](#) identifies the number of sample data points available.

Permit Requirements

Basis for Effluent Limitations

Sections 101, 301, 304, 308, 401, 402, and 405 of the CWA and Titles 5, 7, and 8 of Article 17 ECL, as well as their implementing federal and state regulations, and related guidance, provide the basis for the effluent limitations and other conditions in the permit.

When conducting a full technical review of an existing permit, the previous effluent limitations form the basis for the next permit. Existing effluent quality is evaluated against the existing effluent limitations to determine if these should be continued, revised, or deleted. Generally, existing limitations are continued unless there are changed conditions at the facility, the facility demonstrates an ability to meet more stringent limitations, or in response to updated regulatory requirements. Pollutant monitoring data is also reviewed to determine the presence of additional contaminants that should be included in the permit based on a reasonable potential analysis to cause or contribute to a water quality standards violation.

Anti-backsliding

Anti-backsliding requirements are specified in the CWA sections 402(o) and 303(d)(4), ECL 17-0809, and regulations at 40 CFR 122.44(l) and 6 NYCRR 750-1.10(c) and (d). Generally, the relaxation of effluent limitations in permits is prohibited unless one of the specified exceptions applies, which will be cited on a case-by-case basis in this fact sheet. Consistent with current case law³ and USEPA interpretation⁴ anti-backsliding requirements do not apply should a revision to the final effluent limitation take effect before the scheduled date of compliance for that final effluent limitation.

³ American Iron and Steel Institute v. Environmental Protection Agency, 115 F.3d 979, 993 n.6 (D.C. Cir. 1997)

⁴ U.S. EPA, Water Quality Standards; Establishment of Numeric Criteria for Priority Toxic Pollutants for the State of California; 65 Fed. Reg. 31682, 31704 (May 18, 2000); Proposed Water Quality Guidance for the Great Lakes System, 58 Fed. Reg. 20802, 20837 & 20981 (April 16, 1993)

Antidegradation Policy

New York State implements the antidegradation portion of the CWA based upon two documents: (1) Organization and Delegation Memorandum #85-40, "Water Quality Antidegradation Policy" (September 9, 1985); and, (2) TOGS 1.3.9, "Implementation of the NYSDEC Antidegradation Policy – Great Lakes Basin (Supplement to Antidegradation Policy dated September 9, 1985) (undated)." The permit for the facility contains effluent limitations which ensure that the existing best usage of the receiving waters will be maintained. To further support the antidegradation policy, SPDES applications have been reviewed in accordance with the State Environmental Quality Review Act (SEQR) as prescribed by 6 NYCRR Part 617.

Effluent Limitations

In developing a permit, the Department determines the technology-based effluent limitations (TBELs) and then evaluates the water quality expected to result from technology controls to determine if any exceedances of water quality criteria in the receiving water might result. If there is a reasonable potential for exceedances of water quality criteria to occur, water quality-based effluent limitations (WQBELs) are developed. A WQBEL is designed to ensure that the water quality standards of receiving waters are met. In general, the CWA requires that the effluent limitations for a particular pollutant are the more stringent of either the TBEL or WQBEL.

Technology-based Effluent Limitations (TBELs)

CWA sections 301(b)(1)(B) and 304(d)(1), 40 CFR 133.102, ECL section 17-0509, and 6 NYCRR 750-1.11 require technology-based controls, known as secondary treatment. These and other requirements are summarized in TOGS 1.3.3. Where the TBEL is more stringent than the WQBEL, the TBEL is applied as a limit in accordance with TOGS 1.3.3. Equivalent secondary treatment, as defined in 40 CFR 133.105, allow for effluent limitations of the more stringent of the consistently achievable concentrations or monthly/weekly averages of 45/65 mg/L, and the minimum monthly average of at least 65% removal. Consistently achievable concentrations are defined in 40 CFR 133.101(f) as the 95th percentile value for the 30-day (monthly) average effluent quality achieved by the facility in a period of two years. The achievable 7-day (weekly) average value is equal to 1.5 times the 30-day average value calculated above. Equivalent secondary treatment applies to those facilities where the principal treatment process is either a trickling filter or a waste stabilization pond; the treatment works provides significant biological treatment of municipal wastewater; and, the effluent concentrations consistently achievable through proper operation and maintenance of the facility cannot meet traditional secondary treatment requirements. There are no federal technology-based standards for toxic pollutants from POTWs. A statistical analysis of existing effluent data, as described in TOGS 1.2.1, may be used to establish other performance-based TBELs.

Water Quality-Based Effluent Limitations (WQBELs)

In addition to the TBELs, permits must include additional or more stringent effluent limitations and conditions, including those necessary to protect water quality. CWA sections 101 and 301(b)(1)(C), 40 CFR 122.44(d)(1), and 6 NYCRR Parts 750-1.11 require that permits include limitations for all pollutants or parameters which are or may be discharged at a level which may cause or contribute to an exceedance of any State water quality standard adopted pursuant to NYS ECL 17-0301. Additionally, 6 NYCRR Part 701.1 prohibits the discharge of pollutants that will cause impairment of the best usages of the receiving water as specified by the water classifications at the location of discharge and at other locations that may be affected by such discharge. Water quality standards can be found under 6 NYCRR Parts 700-704. The limitations must be stringent enough to ensure that water quality standards are met at the point of discharge and in downstream waters and must be consistent with any applicable WLA which may be in effect through a TMDL for the receiving water. These and other requirements are summarized in TOGS 1.1.1, 1.3.1, 1.3.2, 1.3.5 and 1.3.6. The DEC considers a mixing zone analysis, critical flows, and reasonable potential analysis when developing a WQBEL.

Mixing Zone Analyses

In accordance with TOGS 1.3.1., the DEC may perform additional analysis of the mixing condition between the effluent and the receiving waterbody. Mixing zone analyses using plume dispersion modeling are conducted in accordance with the following:

"EPA Technical Support Document for Water Quality-Based Toxics Control" (March 1991); EPA Region VIII's "Mixing Zones and Dilution Policy" (December 1994); NYSDEC TOGS 1.3.1, "Total Maximum Daily Loads and Water Quality-Based Effluent Limitations" (July 1996); "CORMIX v11.0" (2019).

Critical Flows

In accordance with TOGS 1.2.1 and 1.3.1, WQBELs are developed using dilution ratios that relate the critical low flow condition of the receiving waterbody to the critical effluent flow. The critical low flow condition used in the dilution ratio will be different depending on whether the limitations are for aquatic or human health protection. For chronic aquatic protection, the critical low flow condition of the waterbody is typically represented by the 7Q10 flow and is calculated as the lowest average flow over a 7-day consecutive period within 10 years. For acute aquatic protection, the critical low flow condition is typically represented by the 1Q10 and is calculated as the lowest 1-day flow within 10 years. However, NYSDEC considers using 50% of the 7Q10 to be equivalent to the 1Q10 flow. For the protection of human health, the critical low flow condition is typically represented by the 30Q10 flow and is calculated as the lowest average flow over a 30-day consecutive period within 10 years. However, NYSDEC considers using $1.2 \times 7Q10$ to be equivalent to the 30Q10. The 7Q10 or 30Q10 flow is used with the critical effluent flow to calculate the dilution ratio. The critical effluent flow can be the maximum daily flow reported on the permit application, the maximum of the monthly average flows from discharge monitoring reports for the past three years, or the facility design flow. When more than one applicable standard exists for aquatic or human health protection for a specific pollutant, a reasonable potential analysis is conducted for each applicable standard and corresponding critical flow to ensure effluent limitations are sufficiently stringent to ensure all applicable water quality standards are met as required by 40 CFR 122.44(d)(1)(i). For brevity, the pollutant summary table reports the results of the most conservative scenario.

Reasonable Potential Analysis (RPA)

The Reasonable Potential Analysis (RPA) is a statistical estimation process, outlined in the 1991 USEPA Technical Support Document for Water Quality-based Toxics Control (TSD), Appendix E. This process uses existing effluent quality data and statistical variation methodology to project the maximum amounts of pollutants that could be discharged by the facility. This projected instream concentration (PIC) is calculated using the appropriate ratio and compared to the water quality standard (WQS). When the RPA process determines the WQS may be exceeded, a WQBEL is required. The procedure for developing WQBELs includes the following steps:

- 1) identify the pollutants present in the discharge(s) based upon existing data, sampling data collected by the permittee as part of the permit application or a short-term high intensity monitoring program, or data gathered by the DEC;
- 2) identify water quality criteria applicable to these pollutants;
- 3) determine if WQBELs are necessary (i.e. reasonable potential analysis (RPA)). The RPA will utilize the procedure outlined in Chapter 3.3.2 of EPA's Technical Support Document (TSD). As outlined in the TSD, for parameters with limited effluent data the RPA may include multipliers to account for effluent variability; and,
- 4) calculate WQBELs (if necessary). Factors considered in calculating WQBELs include available dilution of effluent in the receiving water, receiving water chemistry, and other pollutant sources.

The DEC uses modeling tools to estimate the expected concentrations of the pollutant in the receiving water and develop WQBELs. These tools were developed in part using the methodology referenced above. If the estimated concentration of the pollutant in the receiving water is expected to exceed the ambient water quality standard or guidance value (i.e. numeric interpretation of a narrative water quality standard), then there is a reasonable potential that the discharge may cause or contribute to an exceedance of any State water quality standard adopted pursuant to

NYS ECL 17-0301. If a TMDL is in place, the facility's WLA for that pollutant is applied as the WQBEL.

For carbonaceous and nitrogenous oxygen demanding pollutants, the DEC uses a model which incorporates the Streeter-Phelps equation. The equation relates the decomposition of inorganic and organic materials along with oxygen reaeration rates to compute the downstream dissolved oxygen concentration for comparison to water quality standards.

The Division of Water has been using the TMDL approach in permit limit development for the control of toxic substances. Since the early 1980's, the loading capacity for specific pollutants has been determined for each drainage basin. Water quality-limiting segments and pollutants have been identified, TMDLs, wasteload allocations and load allocations have been developed, and permits with water quality-based effluent limits have been issued. In accordance with TOGS 1.3.1, the Division of Water implements a Toxics Reduction Strategy which is committed to the application of the TMDL process using numeric, pollutant-specific water quality standards through the Watershed Approach. The Watershed Approach accounts for the cumulative effect of multiple discharges of conservative toxic pollutants to ensure water quality standards are met in downstream segments.

Minimum Level of Detection

Pursuant to 40 CFR 122.44(i)(1)(iv) and 6 NYCRR 750-2.5(d), SPDES permits must contain monitoring requirements using sufficiently sensitive test procedures approved under 40 CFR Part 136. A method is "sufficiently sensitive" when the method's minimum level (ML) is at or below the level of the effluent limitation established in the permit for the measured pollutant parameter; or the lowest ML of the analytical methods approved under 40 CFR Part 136. The ML represents the lowest level that can be measured within specified limitations of precision and accuracy during routine laboratory operations on most effluent matrices. When establishing effluent limitations for a specific parameter (based on technology or water quality requirements), it is possible that the calculated limitation will fall below the ML established by the approved analytical method(s). In these instances, the calculated limitation is included in the permit with a compliance level set equal to the ML of the most sensitive method.

Monitoring Requirements

CWA section 308, 40 CFR 122.44(i), 6 NYCRR 750-1.13, and 750-2.5 require that monitoring be included in permits to determine compliance with effluent limitations. Additional effluent monitoring may also be required to gather data to determine if effluent limitations may be required. The permittee is responsible for conducting the monitoring and reporting results on Discharge Monitoring Reports (DMRs). The permit contains the monitoring requirements for the facility. Monitoring frequency is based on the minimum sampling necessary to adequately monitor the facility's performance and characterize the nature of the discharge of the monitored flow or pollutant. Variable effluent flows and pollutant levels may be required to be monitored at more frequent intervals than relatively constant effluent flow and pollutant levels (6 NYCRR 750-1.13). For industrial facilities, sampling frequency is based on guidance provided in TOGS 1.2.1. For municipal facilities, sampling frequency is based on guidance provided in TOGS 1.3.3.

Other Conditions

Mercury

The multiple discharge variance (MDV) for mercury was developed in accordance with 6 NYCRR 702.17(h) "to address widespread standard or guidance value attainment issues including the presence of a ubiquitous pollutant or naturally high levels of a pollutant in a watershed." The first MDV was issued in October 2010, and subsequently revised and reissued in 2015; each subsequent iteration of the MDV is designed to build off the previous version, to make reasonable progress towards the water quality standard (WQS) of 0.7 ng/L dissolved mercury. The MDV is necessary because human-caused conditions or sources of mercury prevent attainment of the WQS and cannot be remedied (i.e., mercury is ubiquitous in New York waters at levels above the WQS and compliance with a water quality based effluent limitation (WQBEL) for mercury cannot be achieved with demonstrated effluent treatment technologies). The DEC has determined that the MDV is consistent with the

Permittee: Davos Sewer Company Inc.
Facility: Davos in the Woods
SPDES Number: NY0218987
USEPA Non-Major/Class 09 PCI

Date: April 9, 2025 v.1.28
Permit Writer: Stephen Monteverde
Water Quality Reviewer: Aslam Mirza
Full Technical Review

protection of public health, safety, and welfare. During the effective period of this MDV, any increased risks to human health are mitigated by fish consumption advisories issued periodically by the NYSDOH.

All surface water SPDES permittees are eligible for authorization by the MDV provided they meet the requirements specified in DOW 1.3.10.

Schedules of Compliance

Schedules of compliance are included in accordance with 40 CFR Part 132 Attachment F, Procedure 9, 40 CFR 122.47 and 6 NYCRR 750-1.14. Schedules of compliance are intended to, in the shortest reasonable time, achieve compliance with applicable effluent standards and limitations, water quality standards, and other applicable requirements. Where the time for compliance is more than nine months, the schedule of compliance must include interim requirements and dates for their achievement. If the time necessary to complete the interim milestones is more than nine months, and not readily divisible into stages for completion, progress reports must be required.

Schedule(s) of Additional Submittals

Schedules of Additional Submittals are used to summarize the deliverables required by the permit not identified in a separate Schedule of Compliance.