



Department of
Environmental
Conservation

State Pollutant Discharge Elimination System (SPDES) DISCHARGE PERMIT

| | | | | | |
|---------------------------|---------|-------------------------|--------------------|----------------------------|-----------|
| SIC Code: | 4952 | NAICS Code: | 221320 | SPDES Number: | NY0260479 |
| Discharge Class (CL): | 07 | DEC Number: | 4-1036-00019/00001 | | |
| Toxic Class (TX): | N | Effective Date (EDP): | EDP | | |
| Major-Sub Drainage Basin: | 13 - 01 | Expiration Date (ExDP): | ExDP | | |
| Water Index Number: | H | Item No.: | 858 - 3 | Modification Dates (EDPM): | |
| Compact Area: | - | | | | |

This SPDES permit is issued in compliance with Title 8 of Article 17 of the Environmental Conservation Law of New York State and in compliance with the Clean Water Act, as amended, (33 U.S.C. '1251 et.seq.)

| PERMITTEE NAME AND ADDRESS | | | | | |
|----------------------------|----------------------------|--|--|------------|-----------------------|
| Name: | Town of Germantown | | | Attention: | Town Clerk |
| Street: | 50 Palatine Park Road | | | | |
| City: | Germantown | | | State: | NY Zip Code: 12526 |
| Email: | townclerk@germantownny.org | | | Phone: | (518) 537-6687 X 1002 |

is authorized to discharge from the facility described below:

| FACILITY NAME, ADDRESS, AND PRIMARY OUTFALL | | | | | | | | | |
|---------------------------------------------|--------------------|-----------|------------------|------------------------------|--------------|--------------|-----------|--------|-------------|
| Name: | Town of Germantown | | | | | | | | |
| Address / Location: | 50 Palatine Road | | | | | County: | Columbia | | |
| City: | Germantown | | | | State: | NY | Zip Code: | 12526 | |
| Facility Location: | Latitude: | 42 ° | 07 ' | 58 " N | & Longitude: | 73 ° | 53 ' | 46 " W | |
| Primary Outfall No.: | 001 | Latitude: | 42 ° | 08 ' | 00 " N | & Longitude: | 73 ° | 54 ' | 00 " W |
| Outfall Description: | Treated Sanitary | | Receiving Water: | Unnamed trib to Hudson River | | | Class: | D | Standard: D |

in accordance with: effluent limitations; monitoring and reporting requirements; other provisions and conditions set forth in this permit; and 6 NYCRR Part 750-1 and 750-2.

This permit and the authorization to discharge shall expire on midnight of the expiration date shown above and the permittee shall not discharge after the expiration date unless this permit has been renewed or extended pursuant to law. To be authorized to discharge beyond the expiration date, the permittee shall apply for permit renewal not less than 180 days prior to the expiration date shown above.

DISTRIBUTION:

BWP Permit Coordinator (permit.coordinator@dec.ny.gov)
BWP Permit Writer
RWE
RPA
EPA Region II (Region2_NPDES@epa.gov)
NYSEFC (sara.tully@efc.ny.gov)

| | | |
|-----------------------|---------------------------------------|------|
| Permit Administrator: | | |
| Address: | 625 Broadway Albany, NY 12233-1750 | |
| | | |
| Signature | | Date |

DEFINITIONS

| TERM | DEFINITION |
|----------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 7-Day Geo Mean | The highest allowable geometric mean of daily discharges over a calendar week. |
| 7-Day Average | The average of all daily discharges for each 7-days in the monitoring period. The sample measurement is the highest of the 7-day averages calculated for the monitoring period. |
| 12-Month Rolling Average (12 MRA) | The current monthly value of a parameter, plus the sum of the monthly values over the previous 11 months for that parameter, divided by the number of months for which samples were collected in the 12-month period. |
| 30-Day Geometric Mean | The highest allowable geometric mean of daily discharges over a calendar month, calculated as the antilog of: the sum of the log of each of the daily discharges measured during a calendar month divided by the number of daily discharges measured during that month. |
| Action Level | Action level means a monitoring requirement characterized by a numerical value that, when exceeded, triggers additional permittee actions and DEC review to determine if numerical effluent limitations should be imposed. |
| Compliance Level / Minimum Level | A compliance level is an effluent limitation. A compliance level is given when the water quality evaluation specifies a Water Quality Based Effluent Limit (WQBEL) below the Minimum Level. The compliance level shall be set at the Minimum Level (ML) for the most sensitive analytical method as given in 40 CFR Part 136, or otherwise accepted by the DEC. |
| Daily Discharge | The discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for the purposes of sampling. For pollutants expressed in units of mass, the 'daily discharge' is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurement, the 'daily discharge' is calculated as the average measurement of the pollutant over the day. |
| Daily Maximum | The highest allowable Daily Discharge. |
| Daily Minimum | The lowest allowable Daily Discharge. |
| Effective Date of Permit (EDP or EDPM) | The date this permit is in effect. |
| Effluent Limitations | Effluent limitation means any restriction on quantities, quality, rates and concentrations of chemical, physical, biological, and other constituents of effluents that are discharged into waters of the state. |
| Expiration Date of Permit (ExDP) | The date this permit is no longer in effect. |
| Instantaneous Maximum | The maximum level that may not be exceeded at any instant in time. |
| Instantaneous Minimum | The minimum level that must be maintained at all instants in time. |
| Monthly Average | The highest allowable average of daily discharges over a calendar month, calculated as the sum of each of the daily discharges measured during a calendar month divided by the number of daily discharges measured during that month. |
| Outfall | The terminus of a sewer system, or the point of emergence of any waterborne sewage, industrial waste or other wastes or the effluent therefrom, into the waters of the State. |
| Range | The minimum and maximum instantaneous measurements for the reporting period must remain between the two values shown. |
| Receiving Water | The classified waters of the state to which the listed outfall discharges. |
| Sample Frequency / Sample Type / Units | See NYSDEC's "DMR Manual for Completing the Discharge Monitoring Report for the SPDES" for information on sample frequency, type and units. |

PERMIT LIMITS, LEVELS AND MONITORING

| OUTFALL | LIMITATIONS APPLY | RECEIVING WATER | EFFECTIVE | EXPIRING |
|---------|-----------------------------------|------------------------------|-----------|----------|
| 001 | Year round unless otherwise noted | Unnamed Trib of Hudson River | EDP | ExDP |

| PARAMETER | EFFLUENT LIMITATION | | | | | MONITORING REQUIREMENTS | | | | FN |
|------------------------------|-----------------------|---------|------------|-------|-------|-------------------------|-------------|----------|------|-----|
| | Type | Limit | Units | Limit | Units | Sample Frequency | Sample Type | Location | | |
| | | | | | | | | Inf. | Eff. | |
| Flow | Monthly Average | 0.1 | MGD | | | Continuous | Meter | | X | |
| | Daily Maximum | Monitor | MGD | | | Continuous | Meter | | X | |
| pH | Daily Minimum | 6.5 | SU | | | 1/Day | Grab | | X | |
| | Daily Maximum | 8.5 | SU | | | | | | X | |
| Temperature | Daily Maximum | Monitor | °F | | | 1/Day | Grab | | X | |
| BOD ₅ | Monthly Average | 30 | mg/L | 25 | lbs/d | 1/Month | 6-hr. Comp. | X | X | 1 |
| | 7-Day Average | 45 | mg/L | 38 | lbs/d | 1/Month | 6-hr. Comp. | | X | |
| Total Suspended Solids (TSS) | Monthly Average | 30 | mg/L | 25 | lbs/d | 1/Month | 6-hr. Comp. | X | X | 1 |
| | 7-Day Average | 45 | mg/L | 38 | lbs/d | 1/Month | 6-hr. Comp. | | X | |
| Settleable Solids | Daily Maximum | 0.1 | mL/L | | | 1/Day | Grab | | X | |
| Dissolved Oxygen | Daily Minimum | 4.0 | mg/L | | | 1/Month | Grab | | X | |
| Ammonia (as N) | Daily Max | Monitor | mg/L | | | 1/Month | 6-hr. Comp. | | X | |
| EFFLUENT DISINFECTION | | | | | | | | | | |
| Required All Year | | Limit | Units | Limit | Units | Sample Frequency | Sample Type | Inf. | Eff. | FN |
| Coliform, Fecal | 30-Day Geometric Mean | 200 | No./100 mL | | | 1/Month | Grab | | X | |
| Coliform, Fecal | 7-Day Geometric Mean | 400 | No./100 mL | | | 1/Month | Grab | | X | |
| Chlorine, Total Residual | Daily Maximum | 0.03 | mg/L | | | 1/Day | Grab | | X | 2,3 |

FOOTNOTES:

- Effluent shall not exceed 15% of influent concentration values for BOD₅ & TSS.
- Sampling and reporting for total residual chlorine are only necessary if chlorine is used for disinfection, elsewhere in the treatment process, or the facility otherwise has reasonable potential to discharge chlorine. Otherwise, the permittee shall report NODI-9 on the DMR.
- This is a compliance level for total residual chlorine. The calculated WQBEL is 0.005 mg/L.

MERCURY MINIMIZATION PROGRAM (MMP) - Type IV

On April 4, 2025, the permittee submitted a Conditional Exclusion Certification, certifying that the facility does not have any of the mercury sources listed in Part III.A.3. of DOW 1.3.10.

1. General - The permittee must develop, implement, and maintain a mercury minimization program (MMP), containing the elements set forth below.
2. MMP Elements - The MMP must be a written document and must include any necessary drawings or maps of the facility and/or collection system. Other related documents already prepared for the facility may be used as part of the MMP and may be incorporated by reference. At a minimum, the MMP must include the following elements¹ as described in detail below:
 - a. Conditional Exclusion Certification - A certification (Appendix D of *DOW 1.3.10*), signed in accordance with 750-1.8 Signature of SPDES forms, must be submitted once every five (5) years for Outfall 001 to the Regional Water Engineer and to the Bureau of Water Permits certifying that Outfall 001 for the facility is neither a mercury source nor receives flows from a mercury source. Criteria to determine if a facility has a mercury source are as follows:
 - The facility is or receives discharge from 1) individually permitted combined sewer overflow (CSOs)² communities and/or 2) Type II sanitary sewer overflow (SSO)³ facilities;
 - One or more effluent samples which exceed 12 ng/L, including samples taken as a result of the SPDES application process;
 - Internal or tributary waste stream samples exceed the GLCA effluent limitation **AND** the final effluent samples are less than the GLCA due primarily to dilution by uncontaminated or less contaminated waste streams. Both components of this criterion may include samples taken as a result of the SPDES application process;
 - A permit application or other information indicates that mercury is handled on site and could be discharged through outfalls;
 - Outfalls which contain legacy mercury contamination;
 - The facility's collection system receives discharges from a dental and/or categorical industrial user (CIU)⁴ that may discharge mercury;
 - The facility accepts hauled wastes; or,
 - The facility is defined as a categorical industry that may discharge mercury. This may also include dentists, universities, hospitals, or laboratories which have their own SPDES permit.
 - b. Control Strategy - The control strategy must contain the following minimum elements:
 - i. Equipment and Materials – Equipment and materials (e.g., thermometers, thermostats) used by the permittee, which may contain mercury, must be evaluated by the permittee. As equipment and materials containing mercury are updated/replaced, the permittee must use mercury-free alternatives, if possible.
 - ii. Bulk Chemical Evaluation – For chemicals, used at a rate which exceeds 1,000 gallons/year or 10,000 pounds/year, the permittee must obtain a manufacturer's certificate of analysis, a chemical analysis performed by a certified laboratory, and/or a notarized affidavit which describes the substances' mercury concentration and the detection limit achieved. If possible, the permittee must only use bulk chemicals utilized in the wastewater treatment process which contain <10 ppb mercury.

¹Neither monitoring nor outreach is required for facilities meeting the criteria for MMP Type IV, but monitoring and/or outreach can be included in the permittee's control strategy.

²CSO permits are included under the 05 and 07 permit classifications.

³These are overflow retention facilities (ORFs) and are included under the 05 and 07 permit classifications.

⁴CIUs include those listed under Federal Regulation in 40 CFR Part 400.

MERCURY MINIMIZATION PROGRAM (MMP) – Type IV (Continued)

- c. **Status Report** - An **annual** status report must be developed and maintained on site, in accordance with the [Schedule of Additional Submittals](#), summarizing:
- Review of criteria to determine if the facility has a potential mercury source;
 - If the permittee no longer meets the criteria for MMP Type IV, the permittee must notify the DEC for a permittee-initiated permit modification;
 - All actions undertaken, pursuant to the control strategy, during the previous year; and
 - Actions planned, pursuant to the control strategy, for the upcoming year.

The permittee must maintain a file with all MMP documentation. The file must be available for review by DEC representatives and copies must be provided upon request in accordance with 6 NYCRR 750-2.1(i) and 750-2.5(c)(4).

3. **MMP Modification** - The MMP must be modified whenever:
- Changes at the facility, or within the collection system, increase the potential for mercury discharges;
 - A letter from the Department identifies inadequacies in the MMP.

The DEC may use information in the annual status reports, in accordance with 2.c of this MMP, to determine if the permit limitations and MMP Type is appropriate for the facility.

DEFINITIONS:

Potential mercury source – a source identified by the permittee that may reasonably be expected to have total mercury contained in the discharge. Some potential mercury sources include switches, fluorescent lightbulbs, cleaners, degreasers, thermometers, batteries, hauled wastes, universities, hospitals, laboratories, landfills, Brownfield sites, or raw material storage.

DISCHARGE NOTIFICATION REQUIREMENTS

- (a) The permittee shall install and maintain identification signs at all outfalls to surface waters listed in this permit, unless the Permittee has obtained a waiver in accordance with the Discharge Notification Act (DNA). Such signs shall be installed before initiation of any new discharge location.
- (b) Subsequent modifications to or renewal of this permit does not reset or revise the deadline set forth in (a) above, unless a new deadline is set explicitly by such permit modification or renewal.
- (c) The Discharge Notification Requirements described herein do not apply to outfalls from which the discharge is composed exclusively of storm water, or discharges to ground water.
- (d) The sign(s) shall be conspicuous, legible and in as close proximity to the point of discharge as is reasonably possible while ensuring the maximum visibility from the surface water and shore. The signs shall be installed in such a manner to pose minimal hazard to navigation, bathing or other water related activities. If the public has access to the water from the land in the vicinity of the outfall, an identical sign shall be posted to be visible from the direction approaching the surface water.

The signs shall have **minimum** dimensions of eighteen inches by twenty-four inches (18" x 24") and shall have white letters on a green background and contain the following information:

N.Y.S. PERMITTED DISCHARGE POINT

SPDES PERMIT No.: NY_____

OUTFALL No. : _____

For information about this permitted discharge contact:

Permittee Name: _____

Permittee Contact: _____

Permittee Phone: () - ### - #####

OR:


NYSDEC Division of Water Regional Office Address:

NYSDEC Division of Water Regional Phone: () - ### - #####

- (e) Upon request, the permittee shall make available electronic or hard copies of the sampling data to the public. In accordance with the RECORDING, REPORTING AND ADDITIONAL MONITORING REQUIREMENTS page of your permit, each DMR shall be maintained (either electronically or as a hard copy) on record for a period of five years.
- (f) The permittee shall periodically inspect the outfall identification sign(s) in order to ensure they are maintained, are still visible, and contain information that is current and factually correct. Signs that are damaged or incorrect shall be replaced within 3 months of inspection.

MONITORING LOCATIONS

The permittee shall take samples and measurements, to comply with the monitoring requirements specified in this permit, at the location(s) specified below:



GENERAL REQUIREMENTS

- A. The regulations in 6 NYCRR Part 750 are hereby incorporated by reference and the conditions are enforceable requirements under this permit. The permittee shall comply with all requirements set forth in this permit and with all the applicable requirements of 6 NYCRR Part 750 incorporated into this permit by reference, including but not limited to the regulations in paragraphs B through I as follows:
- B. General Conditions
- | | |
|--------------------------------------------------|-----------------------------------------|
| 1. Duty to comply | 6 NYCRR 750-2.1(e) & 2.4 |
| 2. Duty to reapply | 6 NYCRR 750-1.16(a) |
| 3. Need to halt or reduce activity not a defense | 6 NYCRR 750-2.1(g) |
| 4. Duty to mitigate | 6 NYCRR 750-2.7(f) |
| 5. Permit actions | 6 NYCRR 750-1.1(c), 1.18, 1.20 & 2.1(h) |
| 6. Property rights | 6 NYCRR 750-2.2(b) |
| 7. Duty to provide information | 6 NYCRR 750-2.1(i) |
| 8. Inspection and entry | 6 NYCRR 750-2.1(a) & 2.3 |
- C. Operation and Maintenance
- | | |
|-----------------------------------|--------------------------------------|
| 1. Proper Operation & Maintenance | 6 NYCRR 750-2.8 |
| 2. Bypass | 6 NYCRR 750-1.2(a)(17), 2.8(b) & 2.7 |
| 3. Upset | 6 NYCRR 750-1.2(a)(94) & 2.8(c) |
- D. Monitoring and Records
- | | |
|---------------------------|------------------------------------------------------------------|
| 1. Monitoring and records | 6 NYCRR 750-2.5(a)(2), 2.5(a)(6), 2.5(c)(1), 2.5(c)(2), & 2.5(d) |
| 2. Signatory requirements | 6 NYCRR 750-1.8 & 2.5(b) |
- E. Reporting Requirements
- | | |
|-----------------------------------------------|-----------------------------|
| 1. Reporting requirements | 6 NYCRR 750-2.5, 2.7 & 1.17 |
| 2. Anticipated noncompliance | 6 NYCRR 750-2.7(a) |
| 3. Transfers | 6 NYCRR 750-1.17 |
| 4. Monitoring reports | 6 NYCRR 750-2.5(e) |
| 5. Compliance schedules | 6 NYCRR 750-1.14(d) |
| 6. 24-hour reporting | 6 NYCRR 750-2.7(c) & (d) |
| 7. Other noncompliance | 6 NYCRR 750-2.7(e) |
| 8. Other information | 6 NYCRR 750-2.1(f) |
| 9. Additional conditions applicable to a POTW | 6 NYCRR 750-2.9 |
- F. Planned Changes
1. The permittee shall give notice to the DEC as soon as possible of planned physical alterations or additions to the permitted facility when:
 - a. The alteration or addition to the permitted facility may meet any of the criteria for determining whether facility is a new source in 40 CFR §122.29(b); or
 - b. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants which are subject either to effluent limitations in the permit, or to notification requirements under 40 CFR §122.42(a)(1); or
 - c. The alteration or addition results in a significant change in the permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan.

In addition to the DEC, the permittee shall submit a copy of this notice to the United States Environmental Protection Agency at the following address: U.S. EPA Region 2, Clean Water Regulatory Branch, 290 Broadway, 24th Floor, New York, NY 10007-1866.

GENERAL REQUIREMENTS (continued)

2. Notification Requirement for POTWs

All POTWs shall provide adequate notice to the Department and the USEPA of the following:

- a. Any new introduction of pollutants into the POTW from an indirect discharger which would be subject to section 301 or 306 of CWA if it were directly discharging those pollutants; or
- b. Any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of issuance of the permit.
- c. For the purposes of this paragraph, adequate notice shall include information on:
 - i. the quality and quantity of effluent introduced into the POTW, and
 - ii. any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW.

POTWs shall submit a copy of this notice to the United States Environmental Protection Agency, at the following address:

U.S. EPA Region 2, Clean Water Regulatory Branch, 290 Broadway, 24th Floor, New York, NY 10007-1866

G. Sludge Management

The permittee shall comply with all applicable requirements of 6 NYCRR Part 360.

H. SPDES Permit Program Fee

The permittee shall pay to the Department an annual SPDES permit program fee within 30 days of the date of the first invoice, unless otherwise directed by the DEC, and shall comply with all applicable requirements of ECL 72-0602 and 6 NYCRR Parts 480, 481 and 485. Note that if there is inconsistency between the fees specified in ECL 72-0602 and 6 NYCRR Part 485, the ECL 72-0602 fees govern.

I. Water Treatment Chemicals (WTCs)

New or increased use and discharge of a WTC requires prior DEC review and authorization. At a minimum, the permittee must notify the DEC in writing of its intent to change WTC use by submitting a completed *WTC Notification Form* for each proposed WTC. The DEC will review that submittal and determine if a SPDES permit modification is necessary or whether WTC review and authorization may proceed outside of the formal permit administrative process. The majority of WTC authorizations do not require SPDES permit modification. In any event, use and discharge of a WTC shall not proceed without prior authorization from the DEC. Examples of WTCs include biocides, coagulants, conditioners, corrosion inhibitors, defoamers, deposit control agents, flocculants, scale inhibitors, sequestrants, and settling aids.

1. WTC use shall not exceed the rate explicitly authorized by this permit or otherwise authorized in writing by the DEC.
2. The permittee shall maintain a logbook of all WTC use, noting for each WTC the date, time, exact location, and amount of each dosage, and, the name of the individual applying or measuring the chemical. The logbook must also document that adequate process controls are in place to ensure that excessive levels of WTCs are not used.
3. The permittee shall submit a completed WTC Annual Report Form each year that they use and discharge WTCs. This form shall be submitted in electronic format and attached to either the December DMR or the annual monitoring report required below. The *WTC Notification Form* and *WTC Annual Report Form* are available from the DEC's website at: <http://www.dec.ny.gov/permits/93245.html>

RECORDING, REPORTING AND ADDITIONAL MONITORING REQUIREMENTS

- A. The monitoring information required by this permit shall be retained for a period of at least five years from the date of the sampling for subsequent inspection by the DEC or its designated agent.

- B. Discharge Monitoring Reports (DMRs): Completed DMR forms shall be submitted for each 1 month reporting period in accordance with the DMR Manual available on DEC's website.

DMRs must be submitted electronically using the electronic reporting tool (NetDMR) specified by DEC. Instructions on the use of NetDMR can be found at <https://www.dec.ny.gov/chemical/8461.html>. **Hardcopy paper DMRs will only be accepted if a waiver from the electronic submittal requirements has been granted by DEC to the facility.**

Attach the monthly "Wastewater Facility Operation Report" (form 92-15-7) and any required DMR attachments electronically to the DMR or with the hardcopy submittal.

The first monitoring period begins on the effective date of this permit, and, unless otherwise required, the reports are due no later than the 28th day of the month following the end of each monitoring period.

- C. Additional information required to be submitted by this permit shall be summarized and reported to the Regional Water Engineer and Bureau of Water Permits at the following addresses:

Department of Environmental Conservation
Division of Water, Bureau of Water Permits
625 Broadway, Albany, New York 12233-3505

Phone: (518) 402-8111

Department of Environmental Conservation
Regional Water Engineer, Region 4
1130 North Westcott Road, Schenectady, New York, 12306-2014 Phone: (518) 357-2045

- D. Bypass and Sewage Pollutant Right to Know Reporting: In accordance with the Sewage Pollutant Right to Know Act (ECL § 17-0826-a), Publicly Owned Treatment Works (POTWs) are required to notify DEC and Department of Health within two hours of discovery of an untreated or partially treated sewage discharge and to notify the public and adjoining municipalities within four hours of discovery. Information regarding reporting and other requirements of this program may be found on the DEC's website. In addition, POTWs are required to provide a five-day incident report and supplemental information to the DEC in accordance with Part 750-2.7(d) by utilizing the Division of Water Report of Noncompliance Event form unless waived by DEC on a case-by-case basis.

- E. Schedule of Additional Submittals:

The permittee shall submit the following information to the Regional Water Engineer and to the Bureau of Water Permits, unless otherwise instructed:

| SCHEDULE OF ADDITIONAL SUBMITTALS | | |
|-----------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------|
| Outfall(s) | Required Action | Due Date |
| | <u>ANNUAL FLOW CERTIFICATION</u> The permittee shall submit an Annual Flow Certification form each year in accordance with 750-2.9(C)(4). The form shall be attached to the February DMR or submitted through nForm. | February DMR (March 28 th) |
| | <u>STORMWATER NO EXPOSURE CERTIFICATION</u> Permittee must recertify every five years a condition of no exposure to stormwater in order to continue to qualify for the no exposure exclusion. The No Exposure Certification Form can be found on the DEC website. | 04/24/2029, and every 5 years thereafter |

| SCHEDULE OF ADDITIONAL SUBMITTALS | | |
|-----------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------|
| Outfall(s) | Required Action | Due Date |
| | <u>MERCURY - CONDITIONAL EXCLUSION CERTIFICATION</u> Permittee must submit a mercury conditional exclusion certification every five years in order to maintain MMP Type IV status. As part of the certification the permittee will be required to sample the effluent and measure <12 ng/L. | 04/04/2030, and every 5 years thereafter |

Unless noted otherwise, the above actions are one-time requirements.

- F. Monitoring and analysis shall be conducted using sufficiently sensitive test procedures approved under 40 CFR Part 136, unless other test procedures have been specified in this permit.
- G. More frequent monitoring of the discharge(s), monitoring point(s), or waters of the State than required by the permit, where analysis is performed by a certified laboratory or where such analysis is not required to be performed by a certified laboratory, shall be included in the calculations and recording of the data on the corresponding DMRs.
- H. Calculations which require averaging of measurements shall utilize an arithmetic mean unless otherwise specified in this permit.
- I. Unless otherwise specified, all information recorded on the DMRs shall be based upon measurements and sampling carried out during the most recently completed reporting period.
- J. Any laboratory test or sample analysis required by this permit for which the State Commissioner of Health issues certificates of approval pursuant to section 502 of the Public Health Law shall be conducted by a laboratory which has been issued a certificate of approval. Inquiries regarding laboratory certification should be directed to the New York State Department of Health, Environmental Laboratory Accreditation Program.

SPDES Permit Fact Sheet

Town of Germantown

Germantown WWTP

NY0260479



Contents

| | |
|-------------------------------------------------------------------------|----|
| Summary of Permit Changes | 3 |
| Administrative History | 3 |
| Facility Information | 3 |
| Site Overview | 4 |
| Enforcement History | 4 |
| Existing Effluent Quality | 4 |
| Receiving Water Information | 5 |
| Impaired Waterbody Information | 5 |
| Critical Receiving Water Data | 5 |
| Permit Requirements | 6 |
| Anti-backsliding | 6 |
| Antidegradation | 6 |
| Discharge Notification Act Requirements | 6 |
| Mercury | 6 |
| Emerging Contaminant Monitoring | 7 |
| Schedule of Additional Submittals | 7 |
| OUTFALL AND RECEIVING WATER SUMMARY TABLE | 8 |
| POLLUTANT SUMMARY TABLE | 8 |
| Outfall 001 | 8 |
| Appendix: Regulatory and Technical Basis of Permit Authorizations | 17 |
| Regulatory References | 17 |
| Outfall and Receiving Water Information | 17 |
| Existing Effluent Quality | 18 |
| Permit Requirements | 18 |

Summary of Permit Changes

A State Pollutant Discharge Elimination System (SPDES) EBPS permit renewal has been drafted for the Germantown WWTP. The changes to the permit are summarized below:

General Updates

- Updated permit format, definitions, and general conditions

Outfall 001 Changes

- Added daily maximum limit for dissolved oxygen of 4.0 mg/L
- Added daily maximum limit for total residual chlorine of 0.03 mg/L
- Minimum and maximum pH limits changed from 6.0 and 9.0 SU, respectfully, to 6.5 and 8.5 SU.

This fact sheet summarizes the information used to determine the effluent limitations (limits) and other conditions contained in the permit. General background information including the regulatory basis for the effluent limitations and other conditions are in the [Appendix](#) linked throughout this fact sheet.

Administrative History

12/01/2007 The last full technical review was performed and the SPDES permit became effective with a new five-year term and expiration date of 11/30/2012. The 2007 permit, along with all subsequent modifications, has formed the basis of this permit.

The permit was administratively renewed in 2012 and again in 2017. The current permit administrative renewal was effective until 11/30/2022.

3/01/2011 Permit was modified to include a short term/high intensity monitoring program for Copper and Zinc, and Discharge Notification Act Requirements.

11/30/2022 The SPDES permit expired.

4/24/2024 The Town of Germantown submitted a new NY-2A permit application to renew the expired permit.

The Notice of Complete Application, published in the [Environmental Notice Bulletin](#) and newspapers, contains information on the public notice process.

Facility Information

This facility is a publicly owned treatment works that receives flow from domestic users, with effluent consisting of treated sanitary. The collection system consists of separate sewers. The facility does not have any significant industrial users (SIUs).

The current 0.1 MGD treatment plant consists of:

- Bar screen, grit chamber
- Primary clarifiers
- Rotating Biological Contactor (RBC), secondary clarifiers
- UV Disinfection

Sludge is aerobically digested and hauled offsite.

The facility does not have any planned improvements.

Compliance and enforcement information can be found on the EPA's [Enforcement and Compliance History Online \(ECHO\)](#) website.

The [Pollutant Summary Table](#) presents the existing effluent quality and effluent limitations. The existing effluent quality was determined from Discharge Monitoring Reports and the application submitted by the permittee for the period 1/1/2020 to 1/1/2025.

Receiving Water Information

The facility discharges via the following outfalls:

| Outfall No. | SIC Code | Wastewater Type | Receiving Water |
|-------------|----------|-------------------------|-----------------------------------------------|
| 001 | 4952 | Treated Sanitary Sewage | Unnamed Tributary to Hudson River, Class D |

Reach Description: Outfall 001 discharges to an unnamed intermittent stream to the east, downstream of the WWTP. Consistent with 6 NYCRR Part 863.4(b), the tributary has been given the stream classification of Class D, also consistent with the previous water quality review. The stream flows through an open channel for about 250 feet and then through an existing culvert for another 250 feet before joining the Hudson River. There exists an elevation drop of 30-40 feet between the culvert start point and the Hudson River.



Impaired Waterbody Information

The unnamed tributary is not listed on the 2020/2022 [New York State Section 303\(d\) List](#) of Impaired/TMDL Waters, and therefore, there are no applicable wasteload allocations (WLAs) for this discharge.

Critical Receiving Water Data

Intermittent stream effluent limits (ISEL) have been applied to select parameters because the Unnamed Tributary to the Hudson River has been stated, by the permittee, to occasionally run dry. Consistent with TOGS 1.3.1, the water quality standards will be applied as end-of-pipe limitations with no mixing or dilution to these parameters. A site-specific water quality analysis was also performed for the evaluation of dissolved oxygen and the specified ISEL limitations in TOGS 1.3.1 were not needed for oxygen demanding parameters to be protective of water quality.

This is consistent with the previous water quality review and is likely due to a change in elevation of 30-40 feet between the effluent discharge and the confluence with the Hudson River, and the overall close proximity of the Hudson River. For more information, see the Pollutant Summary Table of this fact sheet.

Critical receiving water data are listed in the [Pollutant Summary Table](#) at the end of this fact sheet. [Appendix Link](#)

Permit Requirements

The technology based effluent limitations ([TBELs](#)), water quality-based effluent limitations ([WQBELs](#)), [Existing Effluent Quality](#) and a discussion of the selected effluent limitation for each pollutant present in the discharge are provided in the [Pollutant Summary Table](#).

Anti-backsliding

The limitations contained in the permit are at least as stringent as the previous permit limits and there are no instances of backsliding.

[Appendix Link](#)

Antidegradation

The permit contains effluent limitations which ensure that the best usages of the receiving waters will be maintained. The Notice of Complete Application published in the Environmental Notice Bulletin contains information on the State Environmental Quality Review (SEQR)¹ determination.

[Appendix Link](#)

Discharge Notification Act Requirements

In accordance with the Discharge Notification Act (ECL 17-0815-a), the permittee is required to post a sign at each point of wastewater discharge to surface waters, unless a waiver is obtained. This requirement is being continued from the previous permit.

Additionally, the permit contains a requirement to make the DMR sampling data available to the public upon request. This requirement is being continued from the previous permit.

Mercury²

The multiple discharge variance (MDV) for mercury provides the framework for DEC to require mercury monitoring and mercury minimization programs (MMPs), through SPDES permitting.

The facility is not located in the Great Lakes Basin and does not have a mercury source. On April 4, 2025, the permittee submitted a Conditional Exclusion Certification, certifying that the facility does not have any of the mercury sources listed in Part III.A.3. of DOW 1.3.10 and the effluent measured <12 ng/L. Therefore, consistent with DOW 1.3.10, the permit includes requirements for the implementation of MMP Type IV and does not include mercury effluent limitations. The [Schedule of Additional Submittals](#) includes a mercury minimization plan annual status report (maintained onsite), and re-certification of the exclusion every five years. As part of the re-certification, the effluent must be sampled and continue to measure <12 ng/L. This requirement is being continued from the previous permit. [Appendix Link](#)

¹ As prescribed by 6 NYCRR Part 617

² In accordance with DOW 1.3.10 Mercury – SPDES Permitting & Multiple Discharge Variance (MDV), December 30, 2020.

Emerging Contaminant Monitoring

Background: Emerging Contaminants, such as Perfluorooctanoic acid (PFOA), Perfluorooctanesulfonic acid (PFOS), and 1,4-Dioxane (1,4-D), have been used in a wide variety of consumer and industrial products as well as in manufacturing processes for decades. Based on available research, water quality assessments for 1,4-D will follow existing WQBEL development. PFOA and PFOS do not break down easily, therefore their presence in wastewater can remain a concern for years following their discontinued use. As the science surrounding these contaminants is still evolving, additional monitoring is needed to better understand potential sources and background levels. For more information on emerging contaminants, please see the DEC Division of Water web page: [Emerging Contaminants In NY's Waters - NYSDEC](#).

Based on the available data no additional monitoring for PFOA, PFOS, or 1,4-D is required at this time. Please see the [Pollutant Summary Table](#) below for more information.

Schedule of Additional Submittals

A schedule of additional submittals has been included for the following ([Appendix Link](#)):

- Water Treatment Chemical Annual Report Form
- Annual Flow Certification
- Mercury Conditional Exclusion Certification
- Stormwater No Exposure Certification

OUTFALL AND RECEIVING WATER SUMMARY TABLE

| Outfall | Latitude | Longitude | Receiving Water Name | Water Class | Water Index No. / Priority Waterbody Listing (PWL) No. | Major / Sub Basin | Hardness (mg/l) | 1Q10 (MGD) | 7Q10 (MGD) | 30Q10 (MGD) | Critical Effluent Flow (MGD) | Dilution Ratio | | |
|---------|---------------|---------------|----------------------------------|-------------|-----------------------------------------------------------------------------------------------|-------------------|------------------|------------|------------|-------------|------------------------------|----------------|------|-----|
| | | | | | | | | | | | | A(A) | A(C) | HEW |
| 001 | 42° 08' 00" N | 73° 54' 00" W | Unnamed Trib to the Hudson River | D | Unnamed Trib. to Hudson River No PWL Hudson River: H (portion 4b) PWL: 1301-0276 | 13/01 | 138 ³ | - | - | - | 0.1 | - | - | - |

POLLUTANT SUMMARY TABLE

Outfall 001

| Outfall # | 001 | Description of Wastewater: Treated Sanitary Sewage | | | | | | | | | | | | | |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------|-------------------------|----------------------------------------|----------------------------------------|-------|-------------|-------------------------------------------------------------------|--------------------------|---------------|---------|-------------|-------|------------------|------------------------------|
| | | Type of Treatment: Grit Removal, Primary Clarifiers, RBCs, Secondary Clarifiers, UV Disinfection | | | | | | | | | | | | | |
| Effluent Parameter | Units | Averaging Period | Existing Discharge Data | | | TBELs | | Water Quality Data & WQBELs | | | | | | ML | Basis for Permit Requirement |
| | | | Permit Limit | Existing Effluent Quality ⁴ | # of Data Points Detects / Non-Detects | Limit | Basis | Ambient Bkgd. Conc. | Projected Instream Conc. | WQ Std. or GV | WQ Type | Calc. WQBEL | Basis | | |
| General Notes: Existing discharge data from 01/01/2020 to 01/01/2025 was obtained from Discharge Monitoring Reports provided by the permittee. All applicable water quality standards were reviewed for development of the WQBELs. The standard and WQBEL shown below represent the most stringent. | | | | | | | | | | | | | | | |
| Flow Rate | MGD | Monthly Avg | 0.1 | 0.049 Actual Average | 59/0 | 0.1 | Design Flow | No alterations that will impair the waters for their best usages. | | | | 703.2 | - | Design Flow | |
| | | Daily Max | Monitor | 0.12 Actual Average | 59/0 | - | - | | | | | | | Monitor 750-1.13 | |
| | The monthly average flow limit is set at the design flow of the wastewater treatment facility. Daily maximum flow will continue to be monitored for informational purposes and to calculate pollutant loadings. | | | | | | | | | | | | | | |

³ Ambient hardness was established from a 2024 analysis of watershed specific data.

⁴ Existing Effluent Quality: Unless otherwise stated, Daily Max = 99% lognormal; Monthly Avg = 95% lognormal (for datasets with ≤3 nondetects); Daily Max = 99% delta-lognormal; Monthly Avg = 95% delta-lognormal (for datasets with >3 nondetects)

| Outfall # | 001 | Description of Wastewater: Treated Sanitary Sewage | | | | | | | | | | | | | |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------|--------------------------------------------------------------------------------------------------|-------------------------|----------------------------------------|----------------------------------------|-------|----------------|-----------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|---------|-------------|-------|------------------|------------------------------|
| | | Type of Treatment: Grit Removal, Primary Clarifiers, RBCs, Secondary Clarifiers, UV Disinfection | | | | | | | | | | | | | |
| Effluent Parameter | Units | Averaging Period | Existing Discharge Data | | | TBELs | | Water Quality Data & WQBELs | | | | | | ML | Basis for Permit Requirement |
| | | | Permit Limit | Existing Effluent Quality ⁴ | # of Data Points Detects / Non-Detects | Limit | Basis | Ambient Bkgd. Conc. | Projected Instream Conc. | WQ Std. or GV | WQ Type | Calc. WQBEL | Basis | | |
| pH | SU | Minimum | 6.0 | 6.6 Actual Min | 59/0 | 6.0 | 40 CFR 133.102 | 7.6 ⁵ | - | 6.5 – 8.5 | Range | 6.5 - 8.5 | 703.3 | - | ISEL |
| | | Maximum | 9.0 | 8.1 Actual Max | 59/0 | 9.0 | | | | | | | | | |
| The water quality standards have been given as end of pipe limitations. These limits are more stringent than the secondary treatment standards under 40CFR Part 133.102. | | | | | | | | | | | | | | | |
| Temperature | °F | Daily Max | Monitor | 55 Actual Max | 59 | - | - | - | (Non-Trout): The water temperature at the surface of a stream shall not be raised to more than 90F at any point and... shall not be raised or lowered to more than 5F over the temperature that existed before the addition | | | 704.2 | - | Monitor 750-1.13 | |
| | | | | | | | | | | | | | | | |
| Consistent with 6 NYCRR 750-1.13(a), monitoring is required and may be used to inform future permitting decisions. This requirement is continued from the previous permit. | | | | | | | | | | | | | | | |
| Dissolved Oxygen (DO) | mg/L | Daily Min | - | 4.96 minimum | 3 | 7.0 | TOGS 1.3.1. | - | - | (D) 3.0 mg/L | 4.0 | 703.3 | - | WQBEL | |
| | | | | | | | | | | | | | | | |
| Due to a change in elevation of the reach and the proximity of the Hudson River, downstream dissolved oxygen was modeled using the Streeter Phelps equations. The model showed the existing BOD ₅ and new minimum dissolved oxygen limits are protective of downstream dissolved oxygen. | | | | | | | | | | | | | | | |
| 5-day Biochemical Oxygen Demand (BOD ₅) | mg/L | Monthly Avg | 30 | 11 | 59/0 | 30 | 40 CFR 133.102 | - | See Dissolved Oxygen | | | 703.3 | - | TBEL | |
| | | 7 Day Avg | 45 | 11 | 59/0 | 45 | 40 CFR 133.102 | | | | | | | | |
| | | Daily Max | - | - | - | 5.0 | TOGS 1.3.1 | | | | | | | | |
| | lbs/d | Monthly Avg | 25 | 7.4 | 59/0 | 25 | - | | | | | | | | |
| | | 7 Day Avg | 38 | 7.4 | 59/0 | 38 | - | | | | | | | | |
| | | Daily Max | - | - | - | 4.2 | TOGS 1.3.1 | | | | | | | | |
| | % Rem | Minimum | 85 | 98 Actual Average | 59/0 | 85 | 40 CFR 133.102 | | | | | | | | |
| Existing BOD ₅ limits are consistent with secondary treatment standards and protective of dissolved oxygen and will continue. | | | | | | | | | | | | | | | |

⁵ The receiving water is effluent dominated, therefore ambient pH is specified as the 80th percentile of the facility's effluent data.

| Outfall # | 001 | Description of Wastewater: Treated Sanitary Sewage | | | | | | | | | | | | | | |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------|-------------------------|----------------------------------------|----------------------------------------|-------|------------|-----------------------------|---------------------------------------------------------------------------------------------------------------------------|---------------|---------|-------------------------|-------|----|------------------------------|------------------|
| | | Type of Treatment: Grit Removal, Primary Clarifiers, RBCs, Secondary Clarifiers, UV Disinfection | | | | | | | | | | | | | | |
| Effluent Parameter | Units | Averaging Period | Existing Discharge Data | | | TBELs | | Water Quality Data & WQBELs | | | | | | ML | Basis for Permit Requirement | |
| | | | Permit Limit | Existing Effluent Quality ⁴ | # of Data Points Detects / Non-Detects | Limit | Basis | Ambient Bkgd. Conc. | Projected Instream Conc. | WQ Std. or GV | WQ Type | Calc. WQBEL | Basis | | | |
| Settleable Solids | mL/L | Daily Max | 0.3 | 0.1 | 5/54 | 0.1 | TOGS 1.3.3 | - | None from sewage, industrial wastes or other wastes that will cause deposition or impair the waters for their best usages | | | | 703.2 | - | TBEL | |
| | The existing limit is protective of water quality and will remain. | | | | | | | | | | | | | | | |
| Nitrogen, Ammonia (as N) | mg/L | SUMMER 6/1 – 10/31 | - | 3.0 | 3* | - | - | 0.082 | 9.1 | 10.5 | A(A) | No Reasonable Potential | 703.5 | - | Monitor 750-1.13 | |
| | mg/L | Daily Max | - | 3.0 | 3* | - | - | 0.082 | 9.1 | 10.5 | A(A) | No Reasonable Potential | | | | |
| | mg/L | WINTER 11/1 – 5/31 | - | 3.0 | 3* | - | - | 0.082 | 9.1 | 11.2 | A(A) | No Reasonable Potential | 703.5 | - | | Monitor 750-1.13 |
| | mg/L | Daily Max | - | 3.0 | 3* | - | - | 0.082 | 9.1 | 11.2 | A(A) | No Reasonable Potential | | | | |
| <p>* Existing effluent quality represents the maximum of 3 samples reported on the NY-2A application where the number of detections and non-detections were not specified.</p> <p>The WQS for Ammonia was determined from TOGS 1.1.1 from a pH of 7.6 and a summer temperature of 25 °C and winter temperature of 10°C. The temperature of the receiving waterbody was an assumed value and consistent with TOGS 1.3.1E.</p> <p>The projected instream concentration was determined using a value of 3.0 mg/L for summer and winter months and a multiplier of 3.0. The multiplier was recommended in EPA's Technical Support Document Chapter 3.3 to account for the number of samples. The ambient ammonia is an assumed value consistent with TOGS 1.3.1D. A comparison of the projected effluent concentration to the water quality standard indicates no reasonable potential to cause or contribute to a violation of the water quality standard. Year-round monitoring has been added to inform future permitting decisions.</p> | | | | | | | | | | | | | | | | |
| Total Phosphorus | mg/L | Monthly Avg | - | 4 | 3* | - | - | - | None in amounts that will result in growths of algae, weeds and slimes that will impair the waters for their best usages. | | | | 703.2 | - | No Limitation | |
| | * Existing effluent quality represents the maximum of 3 samples reported on the NY-2A application where the number of detections and non-detections were not specified. | | | | | | | | | | | | | | | |
| | The discharge is to the Hudson River and does not have applicable numeric water quality standards. No limitation or monitoring is needed at this time. | | | | | | | | | | | | | | | |
| Total Mercury | ng/L | Daily Max | - | 2.6 Maximum | 3* | - | - | - | - | 0.7 | H(FC) | - | - | - | DOW 1.3.10 | |
| | See Mercury section of this fact sheet . | | | | | | | | | | | | | | | |

Permittee: Town of Germantown
 Facility: Germantown WWTP
 SPDES Number: NY0260479
 USEPA Non-Major/Class 07 Municipal

Date: April 28, 2025 v.1.27
 Permit Writer: James Malcolm
 Water Quality Reviewer: Ethan Sullivan
 Full Technical Review

| Outfall # | 001 | Description of Wastewater: Treated Sanitary Sewage | | | | | | | | | | | | | |
|--------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------|-------------------------|----------------------------------------|-------------------------------------------|-------|------------|-----------------------------|----------------------------------------------------------------------------------------|---------------|---------|-------------|-------|------|------------------------------|
| | | Type of Treatment: Grit Removal, Primary Clarifiers, RBCs, Secondary Clarifiers, UV Disinfection | | | | | | | | | | | | | |
| Effluent Parameter | Units | Averaging Period | Existing Discharge Data | | | TBELs | | Water Quality Data & WQBELs | | | | | | ML | Basis for Permit Requirement |
| | | | Permit Limit | Existing Effluent Quality ⁴ | # of Data Points Detects / Non-Detects | Limit | Basis | Ambient Bkgd. Conc. | Projected Instream Conc. | WQ Std. or GV | WQ Type | Calc. WQBEL | Basis | | |
| Coliform, Fecal | #/ 100 ml | 30d Geo Mean | 200 | 122 | 44/15 | 200 | TOGS 1.3.3 | - | The monthly geometric mean, from a minimum of five examinations, shall not exceed 200. | | | | 703.4 | - | TBEL |
| | | 7d Geo Mean | 400 | 382 | 44/15 | 400 | TOGS 1.3.3 | - | | | | | | | |
| | Consistent with TOGS 1.3.3, effluent disinfection is required year-round due to the class of the downstream receiving waterbody. Fecal coliform effluent limitations equal to the TBEL are specified. | | | | | | | | | | | | | | |
| Total Residual Chlorine (TRC) | mg/L | Daily Max | - | ND | 0/3 | 2.0 | TOGS 1.3.3 | - | - | 0.005 | A(C) | 0.005 | 703.5 | 0.03 | ML |
| | The facility does not utilize chlorine for disinfection, however chlorine is a common water treatment chemical for treatment plants and a limit set at the ML has been included. The permittee is only required to sample and report for TRC if used in the treatment process. | | | | | | | | | | | | | | |
| Additional Pollutants Detected | | | | | | | | | | | | | | | |
| Nitrite (as N) | mg/L | Daily Maximum | - | 0.38 | 3* | - | - | - | - | - | - | - | - | - | No Limitation |
| | * Existing effluent quality represents the maximum of 3 samples reported on the NY-2A application where the number of detections and non-detections were not specified. | | | | | | | | | | | | | | |
| | A water quality standard does not exist for Class D receiving waterbodies. Therefore, no reasonable potential analysis was conducted, and no limitation is specified. | | | | | | | | | | | | | | |
| Nitrate (as N) | mg/L | Daily Maximum | - | 25 | 3* | - | - | - | - | - | - | - | - | - | No Limitation |
| | * Existing effluent quality represents the maximum of 3 samples reported on the NY-2A application where the number of detections and non-detections were not specified. | | | | | | | | | | | | | | |
| | A water quality standard does not exist for Class D receiving waterbodies. Therefore, no reasonable potential analysis was conducted, and no limitation is specified. | | | | | | | | | | | | | | |
| Total Dissolved Solids (TDS) | mg/L | Daily Maximum | - | 1100 | 3* | - | - | - | - | - | - | - | - | - | No Limitation |
| | * Existing effluent quality represents the maximum of 3 samples reported on the NY-2A application where the number of detections and non-detections were not specified. | | | | | | | | | | | | | | |
| | A water quality standard does not exist for Class D receiving waterbodies. Therefore, no reasonable potential analysis was conducted, and no limitation is specified. | | | | | | | | | | | | | | |

| Emerging Contaminants Outfall 001 | | | | | | | | | | | | | | | |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------|------------------|-------------------------|----------------------------------------|----------------------------------------|-------|-------|-----------------------------|--------------------------|---------------|---------|-------------|-------|----|------------------------------|
| Effluent Parameter | Units | Averaging Period | Existing Discharge Data | | | TBELs | | Water Quality Data & WQBELs | | | | | | ML | Basis for Permit Requirement |
| | | | Permit Limit | Existing Effluent Quality ⁶ | # of Data Points Detects / Non-Detects | Limit | Basis | Ambient Bkgd. Conc. | Projected Instream Conc. | WQ Std. or GV | WQ Type | Calc. WQBEL | Basis | | |
| Notes: See Emerging Contaminant Monitoring section above. Effluent samples were analyzed for the 40 PFAS compounds and 1,4-Dioxane. J qualified data was above the method detection limit, but below the reporting level (RL). | | | | | | | | | | | | | | | |
| Perfluoro-butanoic Acid (PFBA) | ng/L | Daily Max | - | 19.1 | 1/0 | - | - | - | - | - | - | - | - | - | No Limitation |
| | Based on available data, no additional monitoring is required at this time. | | | | | | | | | | | | | | |
| Perfluoro-pentanoic Acid (PFPeA) | ng/L | Daily Max | - | 5.46 | 1/0 | - | - | - | - | - | - | - | - | - | No Limitation |
| | Based on available data, no additional monitoring is required at this time. | | | | | | | | | | | | | | |
| Perfluoro-hexanoic Acid (PFHxA) | ng/L | Daily Max | - | 8.03 | 1/0 | - | - | - | - | - | - | - | - | - | No Limitation |
| | Based on available data, no additional monitoring is required at this time. | | | | | | | | | | | | | | |
| Perfluoro-heptanoic Acid (PFHpA) | ng/L | Daily Max | - | 18.3 | 1/0 | - | - | - | - | - | - | - | - | - | No Limitation |
| | Based on available data, no additional monitoring is required at this time. | | | | | | | | | | | | | | |
| Perfluoro-octanoic Acid (PFOA) | ng/L | Daily Max | - | 2.52 Actual Max | 1/0 | - | - | - | - | - | - | - | - | - | No Limitation |
| | Based on available data, no additional monitoring is required at this time. | | | | | | | | | | | | | | |
| Perfluoro-nonanoic Acid (PFNA) | ng/L | Daily Max | - | 1.04 J | 1/0 | - | - | - | - | - | - | - | - | - | No Limitation |
| | Based on available data, no additional monitoring is required at this time. | | | | | | | | | | | | | | |
| Perfluoro-decanoic Acid (PFDA) | ng/L | Daily Max | - | ND | 0/1 | - | - | - | - | - | - | - | - | - | No Limitation |
| | Based on available data, no additional monitoring is required at this time. | | | | | | | | | | | | | | |
| Perfluoro-undecanoic Acid (PFUnA) | ng/L | Daily Max | - | ND | 0/1 | - | - | - | - | - | - | - | - | - | No Limitation |
| | Based on available data, no additional monitoring is required at this time. | | | | | | | | | | | | | | |
| Perfluoro-dodecanoic Acid (PFDoA) | ng/L | Daily Max | - | ND | 0/1 | - | - | - | - | - | - | - | - | - | No Limitation |
| | Based on available data, no additional monitoring is required at this time. | | | | | | | | | | | | | | |
| | ng/L | Daily Max | - | ND | 0/1 | - | - | - | - | - | - | - | - | - | No Limitation |

⁶ Existing Effluent Quality: Unless otherwise stated, Daily Max = 99% lognormal; Monthly Avg = 95% lognormal (for datasets with ≤3 nondetects); Daily Max = 99% delta-lognormal; Monthly Avg = 95% delta-lognormal (for datasets with >3 nondetects)

Permittee: Town of Germantown
 Facility: Germantown WWTP
 SPDES Number: NY0260479
 USEPA Non-Major/Class 07 Municipal

Date: April 28, 2025 v.1.27
 Permit Writer: James Malcolm
 Water Quality Reviewer: Ethan Sullivan
 Full Technical Review

| Emerging Contaminants Outfall 001 | | | | | | | | | | | | | | | |
|------------------------------------------|-----------------------------------------------------------------------------|------------------|-------------------------|----------------------------------------|----------------------------------------|-------|-------|-----------------------------|--------------------------|---------------|---------|-------------------------|------------|----|------------------------------|
| Effluent Parameter | Units | Averaging Period | Existing Discharge Data | | | TBELs | | Water Quality Data & WQBELs | | | | | | ML | Basis for Permit Requirement |
| | | | Permit Limit | Existing Effluent Quality ⁶ | # of Data Points Detects / Non-Detects | Limit | Basis | Ambient Bkgd. Conc. | Projected Instream Conc. | WQ Std. or GV | WQ Type | Calc. WQBEL | Basis | | |
| Perfluoro-tridecanoic Acid (PFTiA) | Based on available data, no additional monitoring is required at this time. | | | | | | | | | | | | | | |
| Perfluoro-tetradecanoic Acid (PFTeA) | ng/L | Daily Max | - | ND | 0/1 | - | - | - | - | - | - | - | - | - | No Limitation |
| | Based on available data, no additional monitoring is required at this time. | | | | | | | | | | | | | | |
| Perfluoro-butanesulfonic Acid (PFBS) | ng/L | Daily Max | - | 0.524 J | 1/0 | - | - | - | - | - | - | - | - | - | No Limitation |
| | Based on available data, no additional monitoring is required at this time. | | | | | | | | | | | | | | |
| Perfluoro-pentanesulfonic Acid (PFPeS) | ng/L | Daily Max | - | ND | 0/1 | - | - | - | - | - | - | - | - | - | No Limitation |
| | Based on available data, no additional monitoring is required at this time. | | | | | | | | | | | | | | |
| Perfluoro-hexanesulfonic Acid (PFHxS) | ng/L | Daily Max | - | ND | 0/1 | - | - | - | - | - | - | - | - | - | No Limitation |
| | Based on available data, no additional monitoring is required at this time. | | | | | | | | | | | | | | |
| Perfluoro-heptanesulfonic Acid (PFHpS) | ng/L | Daily Max | - | ND | 0/1 | - | - | - | - | - | - | - | - | - | No Limitation |
| | Based on available data, no additional monitoring is required at this time. | | | | | | | | | | | | | | |
| Perfluoro-octanesulfonic Acid (PFOS) | ng/L | Daily Max | - | 1.9 Actual Max | 1/0 | - | - | - | - | 710,000 GV | A(A) | No Reasonable Potential | TOGS 1.1.1 | - | No Limitation |
| | Based on available data, no additional monitoring is required at this time. | | | | | | | | | | | | | | |
| Perfluoro-nonanesulfonic Acid (PFNS) | ng/L | Daily Max | - | ND | 0/1 | - | - | - | - | - | - | - | - | - | No Limitation |
| | Based on available data, no additional monitoring is required at this time. | | | | | | | | | | | | | | |
| Perfluoro-decanesulfonic Acid (PFDS) | ng/L | Daily Max | - | ND | 0/1 | - | - | - | - | - | - | - | - | - | No Limitation |
| | Based on available data, no additional monitoring is required at this time. | | | | | | | | | | | | | | |
| Perfluoro-dodecane-sulfonic Acid (PFDoS) | ng/L | Daily Max | - | ND | 0/1 | - | - | - | - | - | - | - | - | - | No Limitation |
| | Based on available data, no additional monitoring is required at this time. | | | | | | | | | | | | | | |
| Perfluoro-octane-sulfonamide (FOSA) | ng/L | Daily Max | - | ND | 0/1 | - | - | - | - | - | - | - | - | - | No Limitation |
| | Based on available data, no additional monitoring is required at this time. | | | | | | | | | | | | | | |

Permittee: Town of Germantown
 Facility: Germantown WWTP
 SPDES Number: NY0260479
 USEPA Non-Major/Class 07 Municipal

Date: April 28, 2025 v.1.27
 Permit Writer: James Malcolm
 Water Quality Reviewer: Ethan Sullivan
 Full Technical Review

| Emerging Contaminants Outfall 001 | | | | | | | | | | | | | | | |
|-------------------------------------------------------------|-----------------------------------------------------------------------------|------------------|-------------------------|----------------------------------------|----------------------------------------|-------|-------|-----------------------------|--------------------------|---------------|---------|-------------|-------|----|------------------------------|
| Effluent Parameter | Units | Averaging Period | Existing Discharge Data | | | TBELs | | Water Quality Data & WQBELs | | | | | | ML | Basis for Permit Requirement |
| | | | Permit Limit | Existing Effluent Quality ⁶ | # of Data Points Detects / Non-Detects | Limit | Basis | Ambient Bkgd. Conc. | Projected Instream Conc. | WQ Std. or GV | WQ Type | Calc. WQBEL | Basis | | |
| N-methyl Perfluoro-octanesulfon-amidoacetic Acid (NMeFOSAA) | ng/L | Daily Max | - | ND | 0/1 | - | - | - | - | - | - | - | - | - | No Limitation |
| | Based on available data, no additional monitoring is required at this time. | | | | | | | | | | | | | | |
| N-ethyl Perfluoro-octanesulfon-amidoacetic Acid (NEtFOSAA) | ng/L | Daily Max | - | ND | 0/1 | - | - | - | - | - | - | - | - | - | No Limitation |
| | Based on available data, no additional monitoring is required at this time. | | | | | | | | | | | | | | |
| 4:2 Fluorotelomer Sulfonic Acid (FTS) | ng/L | Daily Max | - | -* | 0/1 | - | - | - | - | - | - | - | - | - | No Limitation |
| | *No data available for this parameter. | | | | | | | | | | | | | | |
| 6:2 Fluorotelomer Sulfonic Acid (FTS) | ng/L | Daily Max | - | -* | 0/1 | - | - | - | - | - | - | - | - | - | No Limitation |
| | *No data available for this parameter. | | | | | | | | | | | | | | |
| 8:2 Fluorotelomer Sulfonic Acid (FTS) | ng/L | Daily Max | - | -* | 0/1 | - | - | - | - | - | - | - | - | - | No Limitation |
| | *No data available for this parameter. | | | | | | | | | | | | | | |
| N-ethyl Perfluoro-octanesulfon-amide (NEtFOSA) | ng/L | Daily Max | - | ND | 0/1 | - | - | - | - | - | - | - | - | - | No Limitation |
| | Based on available data, no additional monitoring is required at this time. | | | | | | | | | | | | | | |
| N-methyl Perfluoro-octanesulfon-amide (NMeFOSA) | ng/L | Daily Max | - | ND | 0/1 | - | - | - | - | - | - | - | - | - | No Limitation |
| | Based on available data, no additional monitoring is required at this time. | | | | | | | | | | | | | | |
| N-methyl Perfluoro-octanesulfon-amidoethanol (NMeFOSE) | ng/L | Daily Max | - | ND | 0/1 | - | - | - | - | - | - | - | - | - | No Limitation |
| | Based on available data, no additional monitoring is required at this time. | | | | | | | | | | | | | | |

Permittee: Town of Germantown
 Facility: Germantown WWTP
 SPDES Number: NY0260479
 USEPA Non-Major/Class 07 Municipal

Date: April 28, 2025 v.1.27
 Permit Writer: James Malcolm
 Water Quality Reviewer: Ethan Sullivan
 Full Technical Review

| Emerging Contaminants Outfall 001 | | | | | | | | | | | | | | | |
|--------------------------------------------------------------------|-----------------------------------------------------------------------------|------------------|-------------------------|----------------------------------------|----------------------------------------|-------|-------|-----------------------------|--------------------------|---------------|---------|-------------|-------|----|------------------------------|
| Effluent Parameter | Units | Averaging Period | Existing Discharge Data | | | TBELs | | Water Quality Data & WQBELs | | | | | | ML | Basis for Permit Requirement |
| | | | Permit Limit | Existing Effluent Quality ⁶ | # of Data Points Detects / Non-Detects | Limit | Basis | Ambient Bkgd. Conc. | Projected Instream Conc. | WQ Std. or GV | WQ Type | Calc. WQBEL | Basis | | |
| N-ethyl Perfluoro-octanesulfon-amidoethanol (NETFOSE) | ng/L | Daily Max | - | ND | 0/1 | - | - | - | - | - | - | - | - | - | No Limitation |
| | Based on available data, no additional monitoring is required at this time. | | | | | | | | | | | | | | |
| 9-Chlorohexadeca-fluoro-3-oxanonane-1-sulfonic Acid (9Cl-PF3ONS) | ng/L | Daily Max | - | ND | 0/1 | - | - | - | - | - | - | - | - | - | No Limitation |
| | Based on available data, no additional monitoring is required at this time. | | | | | | | | | | | | | | |
| Hexafluoro-propylene Oxide Dimer Acid (HFPO-DA or GenX) | ng/L | Daily Max | - | ND | 0/1 | - | - | - | - | - | - | - | - | - | No Limitation |
| | Based on available data, no additional monitoring is required at this time. | | | | | | | | | | | | | | |
| 11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic Acid (11Cl-PF3OUdS) | ng/L | Daily Max | - | ND | 0/1 | - | - | - | - | - | - | - | - | - | No Limitation |
| | Based on available data, no additional monitoring is required at this time. | | | | | | | | | | | | | | |
| 4,8-Dioxa-3H-perfluorononanoic Acid (ADONA) | ng/L | Daily Max | - | ND | 0/1 | - | - | - | - | - | - | - | - | - | No Limitation |
| | Based on available data, no additional monitoring is required at this time. | | | | | | | | | | | | | | |
| 3-Perfluoropropyl Propanoic Acid (3:3 FTCA) | ng/L | Daily Max | - | ND | 0/1 | - | - | - | - | - | - | - | - | - | No Limitation |
| | Based on available data, no additional monitoring is required at this time. | | | | | | | | | | | | | | |
| 2H,2H,3H,3H-Perfluoro-octanoic Acid (5:3 FTCA) | ng/L | Daily Max | - | ND | 0/1 | - | - | - | - | - | - | - | - | - | No Limitation |
| | Based on available data, no additional monitoring is required at this time. | | | | | | | | | | | | | | |

Permittee: Town of Germantown
 Facility: Germantown WWTP
 SPDES Number: NY0260479
 USEPA Non-Major/Class 07 Municipal

Date: April 28, 2025 v.1.27
 Permit Writer: James Malcolm
 Water Quality Reviewer: Ethan Sullivan
 Full Technical Review

| Emerging Contaminants Outfall 001 | | | | | | | | | | | | | | | |
|--------------------------------------------------|----------------------------------------------------------------------------------|------------------|-------------------------|----------------------------------------|----------------------------------------|-------|-------|-----------------------------|--------------------------|---------------|---------|-------------------------|------------|----|------------------------------|
| Effluent Parameter | Units | Averaging Period | Existing Discharge Data | | | TBELs | | Water Quality Data & WQBELs | | | | | | ML | Basis for Permit Requirement |
| | | | Permit Limit | Existing Effluent Quality ⁶ | # of Data Points Detects / Non-Detects | Limit | Basis | Ambient Bkgd. Conc. | Projected Instream Conc. | WQ Std. or GV | WQ Type | Calc. WQBEL | Basis | | |
| 3-Perfluoroheptyl Propanoic Acid (7:3 FTCA) | ng/L | Daily Max | - | ND | 0/1 | - | - | - | - | - | - | - | - | - | No Limitation |
| | Based on available data, no additional monitoring is required at this time. | | | | | | | | | | | | | | |
| Nonfluoro-3,6-dioxaheptanoic Acid (NFDHA) | ng/L | Daily Max | - | ND | 0/1 | - | - | - | - | - | - | - | - | - | No Limitation |
| | Based on available data, no additional monitoring is required at this time. | | | | | | | | | | | | | | |
| Perfluoro-4-methoxy-butanoic Acid (PFMBA) | ng/L | Daily Max | - | ND | 0/1 | - | - | - | - | - | - | - | - | - | No Limitation |
| | Based on available data, no additional monitoring is required at this time. | | | | | | | | | | | | | | |
| Perfluoro-3-methoxy-propanoic Acid (PFMPA) | ng/L | Daily Max | - | ND | 0/1 | - | - | - | - | - | - | - | - | - | No Limitation |
| | Based on available data, no additional monitoring is required at this time. | | | | | | | | | | | | | | |
| Perfluoro(2-ethoxyethane)sulfonic Acid (PFEEESA) | ng/L | Daily Max | - | ND | 0/1 | - | - | - | - | - | - | - | - | - | No Limitation |
| | Monitoring has been added to support establishment of future standards or TBELs. | | | | | | | | | | | | | | |
| 1,4-Dioxane | µg/L | Daily Max | - | ND | 0/1 | - | - | - | - | 160,000 GV | A(A) | No Reasonable Potential | TOGS 1.1.1 | - | No Limitation |
| | Based on available data, no additional monitoring is required at this time. | | | | | | | | | | | | | | |

Appendix: Regulatory and Technical Basis of Permit Authorizations

The Appendix is meant to supplement the fact sheet for multiple types of SPDES permits. Portions of this Appendix may not be applicable to this specific permit.

Regulatory References

The provisions of the permit are based largely upon 40 CFR 122 subpart C and 6 NYCRR Part 750 and include monitoring, recording, reporting, and compliance requirements, as well as general conditions applicable to all SPDES permits. Below are the most common citations for the requirements included in SPDES permits:

- Clean Water Act (CWA) 33 section USC 1251 to 1387
- Environmental Conservation Law (ECL) Articles 17 and 70
- Federal Regulations
 - 40 CFR, Chapter I, subchapters D, N, and O
- State environmental regulations
 - 6 NYCRR Part 621
 - 6 NYCRR Part 750
 - 6 NYCRR Parts 700 - 704 – Best use and other requirements applicable to water classes
 - 6 NYCRR Parts 800 – 941 - Classification of individual surface waters
- NYSDEC water program policy, referred to as Technical and Operational Guidance Series (TOGS)
- USEPA Office of Water Technical Support Document for Water Quality-based Toxics Control, March 1991, Appendix E

The following is a quick guide to the references used within the fact sheet:

| SPDES Permit Requirements | Regulatory Reference |
|------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------|
| Anti-backsliding | 6 NYCRR 750-1.10(c) |
| Best Management Practices (BMPS) for CSOs | 6 NYCRR 750-2.8(a)(2) |
| Environmental Benefits Permit Strategy (EBPS) | 6 NYCRR 750-1.18, NYS ECL 17-0817(4), TOGS 1.2.2 (revised January 25, 2012) |
| Exceptions for Type I SSO Outfalls (bypass) | 6 NYCRR 750-2.8(b)(2), 40 CFR 122.41 |
| Mercury Multiple Discharge Variance | Division of Water Program Policy 1.3.10 (DOW 1.3.10) |
| Mixing Zone and Critical Water Information | TOGS 1.3.1 & Amendments |
| PCB Minimization Program | 40 CFR Part 132 Appendix F Procedure 8, 6 NYCRR 750-1.13(a) and 750-1.14(f), and TOGS 1.2.1 |
| Pollutant Minimization Program (PMP) | 6 NYCRR 750-1.13(a), 750-1.14(f), TOGS 1.2.1 |
| Schedules of Compliance | 6 NYCRR 750-1.14 |
| Sewage Pollution Right to Know (SPRTK) | NYS ECL 17-0826-a, 6 NYCRR 750-2.7 |
| State Administrative Procedure Act (SAPA) | State Administrative Procedure Act Section 401(2), 6 NYCRR 621.11(l) |
| State Environmental Quality Review (SEQR) | 6 NYCRR Part 617 |
| USEPA Effluent Limitation Guidelines (ELGs) | 40 CFR Parts 405-471 |
| USEPA National CSO Policy | 33 USC Section 1342(q) |
| Whole Effluent Toxicity (WET) Testing | TOGS 1.3.2 |
| General Provisions of a SPDES Permit Department Request for Additional Information | NYCRR 750-2.1(i) |

Outfall and Receiving Water Information

Impaired Waters

The [NYS 303\(d\) List of Impaired/TMDL Waters](#) identifies waters where specific best usages are not fully supported. The state must consider the development of a Total Maximum Daily Load (TMDL) or other strategy to reduce the input of the specific pollutant(s) that restrict waterbody uses, in order to restore and protect such uses. SPDES permits must include effluent limitations necessary to implement a waste load allocation (WLA) of an EPA-approved TMDL (6 NYCRR 750-1.11(a)(5)(ii)), if applicable. In accordance with 6 NYCRR 750-1.13(a), permittees discharging to waters which are on the list but do not yet have a TMDL developed may be required to perform additional monitoring for the parameters causing the impairment. Accurate monitoring data is needed

to determine the existing capabilities of the wastewater treatment plants and to assure that WLAs are allocated equitably.

Existing Effluent Quality

The existing effluent quality is determined from a statistical evaluation of effluent data in accordance with TOGS 1.2.1 and the USEPA Office of Water, Technical Support Document for Water Quality-based Toxics Control, March 1991, Appendix E (TSD). The existing effluent quality is equal to the 95th (monthly average) and 99th (daily maximum) percentiles of the lognormal distribution of existing effluent data. When there are greater than three non-detects, a delta-lognormal distribution is assumed, and delta-lognormal calculations are used to determine the monthly average and daily maximum pollutant concentrations. Statistical calculations are not performed for parameters where there are less than ten data points. If additional data is needed, a monitoring requirement may be specified either through routine monitoring or a short-term high intensity monitoring program. The [Pollutant Summary Table](#) identifies the number of sample data points available.

Permit Requirements

Basis for Effluent Limitations

Sections 101, 301, 304, 308, 401, 402, and 405 of the CWA and Titles 5, 7, and 8 of Article 17 ECL, as well as their implementing federal and state regulations, and related guidance, provide the basis for the effluent limitations and other conditions in the permit.

When conducting a full technical review of an existing permit, the previous effluent limitations form the basis for the next permit. Existing effluent quality is evaluated against the existing effluent limitations to determine if these should be continued, revised, or deleted. Generally, existing limitations are continued unless there are changed conditions at the facility, the facility demonstrates an ability to meet more stringent limitations, or in response to updated regulatory requirements. Pollutant monitoring data is also reviewed to determine the presence of additional contaminants that should be included in the permit based on a reasonable potential analysis to cause or contribute to a water quality standards violation.

Anti-backsliding

Anti-backsliding requirements are specified in the CWA sections 402(o) and 303(d)(4), ECL 17-0809, and regulations at 40 CFR 122.44(l) and 6 NYCRR 750-1.10(c) and (d). Generally, the relaxation of effluent limitations in permits is prohibited unless one of the specified exceptions applies, which will be cited on a case-by-case basis in this fact sheet. Consistent with current case law⁷ and USEPA interpretation⁸ anti-backsliding requirements do not apply should a revision to the final effluent limitation take effect before the scheduled date of compliance for that final effluent limitation.

Antidegradation Policy

New York State implements the antidegradation portion of the CWA based upon two documents: (1) Organization and Delegation Memorandum #85-40, "Water Quality Antidegradation Policy" (September 9, 1985); and, (2) TOGS 1.3.9, "Implementation of the NYSDEC Antidegradation Policy – Great Lakes Basin (Supplement to Antidegradation Policy dated September 9, 1985) (undated)." The permit for the facility contains effluent limitations which ensure that the existing best usage of the receiving waters will be maintained. To further support the antidegradation policy, SPDES applications have been reviewed in accordance with the State Environmental Quality Review Act (SEQR) as prescribed by 6 NYCRR Part 617.

Effluent Limitations

In developing a permit, the Department determines the technology-based effluent limitations (TBELs) and then evaluates the water quality expected to result from technology controls to determine if any exceedances of water quality criteria in the receiving water might result. If there is a reasonable potential for exceedances of water quality criteria to occur, water quality-based effluent limitations (WQBELs) are developed. A WQBEL is designed

⁷ American Iron and Steel Institute v. Environmental Protection Agency, 115 F.3d 979, 993 n.6 (D.C. Cir. 1997)

⁸ U.S. EPA, Water Quality Standards; Establishment of Numeric Criteria for Priority Toxic Pollutants for the State of California; 65 Fed. Reg. 31682, 31704 (May 18, 2000); Proposed Water Quality Guidance for the Great Lakes System, 58 Fed. Reg. 20802, 20837 & 20981 (April 16, 1993)

to ensure that the water quality standards of receiving waters are met. In general, the CWA requires that the effluent limitations for a particular pollutant are the more stringent of either the TBEL or WQBEL.

Technology-based Effluent Limitations (TBELs)

CWA sections 301(b)(1)(B) and 304(d)(1), 40 CFR 133.102, ECL section 17-0509, and 6 NYCRR 750-1.11 require technology-based controls, known as secondary treatment. These and other requirements are summarized in TOGS 1.3.3. Where the TBEL is more stringent than the WQBEL, the TBEL is applied as a limit in accordance with TOGS 1.3.3. Equivalent secondary treatment, as defined in 40 CFR 133.105, allow for effluent limitations of the more stringent of the consistently achievable concentrations or monthly/weekly averages of 45/65 mg/L, and the minimum monthly average of at least 65% removal. Consistently achievable concentrations are defined in 40 CFR 133.101(f) as the 95th percentile value for the 30-day (monthly) average effluent quality achieved by the facility in a period of two years. The achievable 7-day (weekly) average value is equal to 1.5 times the 30-day average value calculated above. Equivalent secondary treatment applies to those facilities where the principal treatment process is either a trickling filter or a waste stabilization pond; the treatment works provides significant biological treatment of municipal wastewater; and, the effluent concentrations consistently achievable through proper operation and maintenance of the facility cannot meet traditional secondary treatment requirements. There are no federal technology-based standards for toxic pollutants from POTWs. A statistical analysis of existing effluent data, as described in TOGS 1.2.1, may be used to establish other performance-based TBELs.

Water Quality-Based Effluent Limitations (WQBELs)

In addition to the TBELs, permits must include additional or more stringent effluent limitations and conditions, including those necessary to protect water quality. CWA sections 101 and 301(b)(1)(C), 40 CFR 122.44(d)(1), and 6 NYCRR Parts 750-1.11 require that permits include limitations for all pollutants or parameters which are or may be discharged at a level which may cause or contribute to an exceedance of any State water quality standard adopted pursuant to NYS ECL 17-0301. Additionally, 6 NYCRR Part 701.1 prohibits the discharge of pollutants that will cause impairment of the best usages of the receiving water as specified by the water classifications at the location of discharge and at other locations that may be affected by such discharge. Water quality standards can be found under 6 NYCRR Parts 700-704. The limitations must be stringent enough to ensure that water quality standards are met at the point of discharge and in downstream waters and must be consistent with any applicable WLA which may be in effect through a TMDL for the receiving water. These and other requirements are summarized in TOGS 1.1.1, 1.3.1, 1.3.2, 1.3.5 and 1.3.6. The DEC considers a mixing zone analysis, critical flows, and reasonable potential analysis when developing a WQBEL.

Reasonable Potential Analysis (RPA)

The Reasonable Potential Analysis (RPA) is a statistical estimation process, outlined in the 1991 USEPA Technical Support Document for Water Quality-based Toxics Control (TSD), Appendix E. This process uses existing effluent quality data and statistical variation methodology to project the maximum amounts of pollutants that could be discharged by the facility. This projected instream concentration (PIC) is calculated using the appropriate ratio and compared to the water quality standard (WQS). When the RPA process determines the WQS may be exceeded, a WQBEL is required. The procedure for developing WQBELs includes the following steps:

- 1) identify the pollutants present in the discharge(s) based upon existing data, sampling data collected by the permittee as part of the permit application or a short-term high intensity monitoring program, or data gathered by the DEC;
- 2) identify water quality criteria applicable to these pollutants;
- 3) determine if WQBELs are necessary (i.e. reasonable potential analysis (RPA)). The RPA will utilize the procedure outlined in Chapter 3.3.2 of EPA's Technical Support Document (TSD). As outlined in the TSD, for parameters with limited effluent data the RPA may include multipliers to account for effluent variability; and,

4) calculate WQBELs (if necessary). Factors considered in calculating WQBELs include available dilution of effluent in the receiving water, receiving water chemistry, and other pollutant sources.

The DEC uses modeling tools to estimate the expected concentrations of the pollutant in the receiving water and develop WQBELs. These tools were developed in part using the methodology referenced above. If the estimated concentration of the pollutant in the receiving water is expected to exceed the ambient water quality standard or guidance value (i.e. numeric interpretation of a narrative water quality standard), then there is a reasonable potential that the discharge may cause or contribute to an exceedance of any State water quality standard adopted pursuant to NYS ECL 17-0301. If a TMDL is in place, the facility's WLA for that pollutant is applied as the WQBEL.

For carbonaceous and nitrogenous oxygen demanding pollutants, the DEC uses a model which incorporates the Streeter-Phelps equation. The equation relates the decomposition of inorganic and organic materials along with oxygen reaeration rates to compute the downstream dissolved oxygen concentration for comparison to water quality standards.

The Division of Water has been using the TMDL approach in permit limit development for the control of toxic substances. Since the early 1980's, the loading capacity for specific pollutants has been determined for each drainage basin. Water quality-limiting segments and pollutants have been identified, TMDLs, wasteload allocations and load allocations have been developed, and permits with water quality-based effluent limits have been issued. In accordance with TOGS 1.3.1, the Division of Water implements a Toxics Reduction Strategy which is committed to the application of the TMDL process using numeric, pollutant-specific water quality standards through the Watershed Approach. The Watershed Approach accounts for the cumulative effect of multiple discharges of conservative toxic pollutants to ensure water quality standards are met in downstream segments.

Minimum Level of Detection

Pursuant to 40 CFR 122.44(i)(1)(iv) and 6 NYCRR 750-2.5(d), SPDES permits must contain monitoring requirements using sufficiently sensitive test procedures approved under 40 CFR Part 136. A method is "sufficiently sensitive" when the method's minimum level (ML) is at or below the level of the effluent limitation established in the permit for the measured pollutant parameter; or the lowest ML of the analytical methods approved under 40 CFR Part 136. The ML represents the lowest level that can be measured within specified limitations of precision and accuracy during routine laboratory operations on most effluent matrices. When establishing effluent limitations for a specific parameter (based on technology or water quality requirements), it is possible that the calculated limitation will fall below the ML established by the approved analytical method(s). In these instances, the calculated limitation is included in the permit with a compliance level set equal to the ML of the most sensitive method.

Monitoring Requirements

CWA section 308, 40 CFR 122.44(i), 6 NYCRR 750-1.13, and 750-2.5 require that monitoring be included in permits to determine compliance with effluent limitations. Additional effluent monitoring may also be required to gather data to determine if effluent limitations may be required. The permittee is responsible for conducting the monitoring and reporting results on Discharge Monitoring Reports (DMRs). The permit contains the monitoring requirements for the facility. Monitoring frequency is based on the minimum sampling necessary to adequately monitor the facility's performance and characterize the nature of the discharge of the monitored flow or pollutant. Variable effluent flows and pollutant levels may be required to be monitored at more frequent intervals than relatively constant effluent flow and pollutant levels (6 NYCRR 750-1.13). For industrial facilities, sampling frequency is based on guidance provided in TOGS 1.2.1. For municipal facilities, sampling frequency is based on guidance provided in TOGS 1.3.3.

Other Conditions

Mercury

Permittee: Town of Germantown
Facility: Germantown WWTP
SPDES Number: NY0260479
USEPA Non-Major/Class 07 Municipal

Date: April 28, 2025 v.1.27
Permit Writer: James Malcolm
Water Quality Reviewer: Ethan Sullivan
Full Technical Review

The multiple discharge variance (MDV) for mercury was developed in accordance with 6 NYCRR 702.17(h) “to address widespread standard or guidance value attainment issues including the presence of a ubiquitous pollutant or naturally high levels of a pollutant in a watershed.” The first MDV was issued in October 2010, and subsequently revised and reissued in 2015; each subsequent iteration of the MDV is designed to build off the previous version, to make reasonable progress towards the water quality standard (WQS) of 0.7 ng/L dissolved mercury. The MDV is necessary because human-caused conditions or sources of mercury prevent attainment of the WQS and cannot be remedied (i.e., mercury is ubiquitous in New York waters at levels above the WQS and compliance with a water quality based effluent limitation (WQBEL) for mercury cannot be achieved with demonstrated effluent treatment technologies). The DEC has determined that the MDV is consistent with the protection of public health, safety, and welfare. During the effective period of this MDV, any increased risks to human health are mitigated by fish consumption advisories issued periodically by the NYSDOH.

All surface water SPDES permittees are eligible for authorization by the MDV provided they meet the requirements specified in DOW 1.3.10.

[Schedule\(s\) of Additional Submittals](#)

Schedules of Additional Submittals are used to summarize the deliverables required by the permit not identified in a separate Schedule of Compliance.