



# State Pollutant Discharge Elimination System (SPDES) DISCHARGE PERMIT

SIC Code:	2514 & 3471	NAICS Code:	337124 332813	SPDES Number:	NY0110485
Discharge Class (CL):	01			DEC Number:	4-1932-00010/00013-0
Toxic Class (TX):	T			Effective Date (EDP):	EDP
Major-Sub Drainage Basin:	13 - 09			Expiration Date (ExDP):	ExDP
Water Index Number:	H-193-19-5a	Item No.:	1309 - 0026	Modification Dates (EDPM):	
Compact Area:	-				

This SPDES permit is issued in compliance with Title 8 of Article 17 of the Environmental Conservation Law of New York State and in compliance with the Clean Water Act, as amended, (33 U.S.C. '1251 et.seq.)

PERMITTEE NAME AND ADDRESS					
Name:	<b>Royal Metal Products Inc.</b>			Attention:	<b>David Johannesen</b>
Street:	<b>463 West Road</b>				
City:	<b>Surprise</b>			State:	<b>NY</b> Zip Code: <b>12176</b>
Email:	<b>royalmetalpro@cs.com</b>			Phone:	<b>(518) 966-4442</b>

is authorized to discharge from the facility described below:

FACILITY NAME, ADDRESS, AND PRIMARY OUTFALL									
Name:	<b>Royal Metal Products Inc.</b>								
Address / Location:	<b>463 West Road</b>						County:	<b>Greene</b>	
City:	<b>Surprise</b>				State:	<b>NY</b>	Zip Code:	<b>12176</b>	
Facility Location:	Latitude:	<b>42</b> °	<b>23</b> '	<b>13</b> " N	& Longitude:	<b>73</b> °	<b>59</b> '	<b>40</b> " W	
Primary Outfall No.:	<b>001</b>	Latitude:	<b>42</b> °	<b>23</b> '	<b>13</b> " N	& Longitude:	<b>73</b> °	<b>59</b> '	<b>40</b> " W
Wastewater Description:	<b>Process Water, Non-contact Cooling Water, and Stormwater</b>		Receiving Water:	<b>Trib. Jan De Bakker Kills</b>		NAICS:	<b>337124 &amp; 332813</b>	Class:	<b>C</b> Standard: <b>C</b>

in accordance with: effluent limitations; monitoring and reporting requirements; other provisions and conditions set forth in this permit; and 6 NYCRR Part 750-1 and 750-2.

This permit and the authorization to discharge shall expire on midnight of the expiration date shown above and the permittee shall not discharge after the expiration date unless this permit has been renewed or extended pursuant to law. To be authorized to discharge beyond the expiration date, the permittee shall apply for permit renewal not less than 180 days prior to the expiration date shown above.

## DISTRIBUTION:

BWP Permit Coordinator  
([permit.coordinator@dec.ny.gov](mailto:permit.coordinator@dec.ny.gov))  
BWP Permit Writer  
RWE  
RPA  
EPA Region II ([Region2\\_NPDES@epa.gov](mailto:Region2_NPDES@epa.gov))

Permit Administrator:		
Address:	625 Broadway Albany, NY 12233-1750	
Signature	Date	

Contents

DEFINITIONS..... 3

PERMIT LIMITS, LEVELS AND MONITORING..... 4

STORMWATER POLLUTION PREVENTION REQUIREMENTS ..... 5

BEST MANAGEMENT PRACTICES (BMPs) FOR INDUSTRIAL FACILITIES ..... 6

MERCURY MINIMIZATION PROGRAM (MMP) - Type IV..... 8

DISCHARGE NOTIFICATION REQUIREMENTS..... 10

SCHEDULE OF COMPLIANCE..... 11

MONITORING LOCATIONS..... 12

GENERAL REQUIREMENTS..... 13

RECORDING, REPORTING AND ADDITIONAL MONITORING REQUIREMENTS..... 14

    E. Schedule of Additional Submittals: ..... 14

## DEFINITIONS

TERM	DEFINITION
7-Day Geo Mean	The highest allowable geometric mean of daily discharges over a calendar week.
7-Day Average	The average of all daily discharges for each 7-days in the monitoring period. The sample measurement is the highest of the 7-day averages calculated for the monitoring period.
12-Month Rolling Average (12 MRA)	The current monthly value of a parameter, plus the sum of the monthly values over the previous 11 months for that parameter, divided by the number of months for which samples were collected in the 12-month period.
30-Day Geometric Mean	The highest allowable geometric mean of daily discharges over a calendar month, calculated as the antilog of: the sum of the log of each of the daily discharges measured during a calendar month divided by the number of daily discharges measured during that month.
Action Level	Action level means a monitoring requirement characterized by a numerical value that, when exceeded, triggers additional permittee actions and department review to determine if numerical effluent limitations should be imposed.
Compliance Level / Minimum Level	A compliance level is an effluent limitation. A compliance level is given when the water quality evaluation specifies a Water Quality Based Effluent Limit (WQBEL) below the Minimum Level. The compliance level shall be set at the Minimum Level (ML) for the most sensitive analytical method as given in 40 CFR Part 136, or otherwise accepted by the DEC.
Daily Discharge	The discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for the purposes of sampling. For pollutants expressed in units of mass, the 'daily discharge' is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurement, the 'daily discharge' is calculated as the average measurement of the pollutant over the day.
Daily Maximum	The highest allowable Daily Discharge.
Daily Minimum	The lowest allowable Daily Discharge.
Effective Date of Permit (EDP or EDPM)	The date this permit is in effect.
Effluent Limitations	Effluent limitation means any restriction on quantities, quality, rates and concentrations of chemical, physical, biological, and other constituents of effluents that are discharged into waters of the state.
Expiration Date of Permit (ExDP)	The date this permit is no longer in effect.
Instantaneous Maximum	The maximum level that may not be exceeded at any instant in time.
Instantaneous Minimum	The minimum level that must be maintained at all instants in time.
Monthly Average	The highest allowable average of daily discharges over a calendar month, calculated as the sum of each of the daily discharges measured during a calendar month divided by the number of daily discharges measured during that month.
Outfall	The terminus of a sewer system, or the point of emergence of any waterborne sewage, industrial waste or other wastes or the effluent therefrom, into the waters of the State.
Range	The minimum and maximum instantaneous measurements for the reporting period must remain between the two values shown.
Receiving Water	The classified waters of the state to which the listed outfall discharges.
Sample Frequency / Sample Type / Units	See DEC's "DMR Manual for Completing the Discharge Monitoring Report for the SPDES" for information on sample frequency, type and units.

## PERMIT LIMITS, LEVELS AND MONITORING

OUTFALL	DESCRIPTION	RECEIVING WATER	EFFECTIVE	EXPIRING
001	Process Water, Non-contact Cooling Water, and Stormwater	Trib. of Jan De Bakkers Kill	EDP	ExDP

PARAMETER	EFFLUENT LIMITATION					MONITORING REQUIREMENTS				FN
	Type	Limit	Units	Limit	Units	Sample Frequency	Sample Type	Location		
								Inf.	Eff.	
Flow	Daily Maximum	Monitor	GPD			Continuous	Recorder		X	
pH	Daily Minimum	6.5	SU			Daily	Grab		X	
	Daily Maximum	8.5	SU							
Total Suspended Solids (TSS)	Daily Maximum	25	mg/L			Daily	Grab		X	
Temperature	Daily Maximum	90	°F			Daily	Grab		X	1
Dissolved Oxygen	Daily Minimum	Monitor	mg/L			Monthly	Grab		X	
Oil & Grease	Daily Maximum	52	mg/L			Monthly	Grab		X	
	Monthly Avg.	26	mg/L			Monthly	Grab		X	
Total Chromium	Daily Maximum	70	ug/L			Monthly	8-hr. Comp.		X	1
Hexavalent Chromium	Daily Maximum	11	ug/L			Monthly	8-hr. Comp.		X	1
Total Copper	Daily Maximum	8.1	ug/L			Monthly	8-hr. Comp.		X	1
Total Cyanide	Daily Maximum	50	ug/L			Monthly	8-hr. Comp.		X	
Free Cyanide	Daily Maximum	Monitor	ug/L			Monthly	8-hr. Comp.		X	
Total Nickel	Daily Maximum	45	ug/L			Monthly	8-hr. Comp.		X	1
Total Zinc	Daily Maximum	72	ug/L			Monthly	8-hr. Comp.		X	1
Total Lead	Daily Maximum	690	ug/L			Quarterly	8-hr. Comp.		X	2
	Monthly Average	430	ug/L			Quarterly	8-hr. Comp.		X	2
Total Cadmium	Daily Maximum	690	ug/L			Quarterly	8-hr. Comp.		X	2
	Monthly Average	260	ug/L			Quarterly	8-hr. Comp.		X	2
Total Toxic Organics	Daily Maximum	2.1	mg/L			Quarterly	8-hr. Comp.		X	2

### FOOTNOTES:

1. This is a final effluent limitation. See [Schedule of Compliance](#) for any applicable interim effluent limitations.
2. Quarterly samples shall be collected in calendar quarters (Q1 – January 1<sup>st</sup> to March 31<sup>st</sup>; Q2 – April 1<sup>st</sup> to June 30<sup>th</sup>; Q3 – July 1<sup>st</sup> to September 30<sup>th</sup>; Q4 – October 1<sup>st</sup> to December 31<sup>st</sup>).

## STORMWATER POLLUTION PREVENTION REQUIREMENTS

### NO EXPOSURE CERTIFICATION

The permittee submitted a Conditional Exclusion for No Exposure Form on 10/10/2024, certifying that all industrial activities and materials are completely sheltered from exposure to rain, snow, snowmelt, and stormwater runoff except as allowed under 40 CFR 122.26(g)(2). The permittee must maintain a condition of no exposure for the exclusion to remain applicable. If conditions change resulting in the exposure of materials and activities to stormwater, the permittee must notify the Regional Water Engineer. The permittee must recertify a condition of no exposure every five years by completing the "No Exposure Certification Form" found on the DEC website.

DRAFT

## BEST MANAGEMENT PRACTICES (BMPs) FOR INDUSTRIAL FACILITIES

Note that for some facilities, especially those with few employees or limited industrial activities, some of the below BMPs may not be applicable. It is acceptable in these cases to indicate "Not Applicable" for the portion(s) of the BMP Plan that do not apply to your facility, along with an explanation.

1. **General** - The permittee shall develop, maintain, and implement a Best Management Practices (BMP) plan to prevent releases of significant amounts of pollutants to the waters of the State through plant site runoff; spillage and leaks; sludge or waste disposal; and stormwater discharges including, but not limited to, drainage from raw material storage. The BMP plan shall be documented in narrative form and shall include the 13 minimum BMPs and any necessary plot plans, drawings, or maps. Other documents already prepared for the facility such as a Safety Manual or a Spill Prevention, Control and Countermeasure (SPCC) plan may be used as part of the plan and may be incorporated by reference. A copy of the current BMP plan shall be submitted to the DEC as required in item (2.) below and a copy must be maintained at the facility and shall be available to authorized DEC representatives upon request.
2. **Compliance Deadlines** – A BMP plan shall be submitted in accordance with the Schedule of Submittals to the Regional Water Engineer. The BMP plan shall be implemented within 6 months of submission, unless a different time frame is approved by the Department. The BMP plan **shall be reviewed annually** and shall be modified whenever (a) changes at the facility materially increase the potential for releases of pollutants; (b) actual releases indicate the plan is inadequate, or (c) a letter from the DEC identifies inadequacies in the plan. The permittee shall certify in writing, as an attachment to the December Discharge Monitoring Report (DMR), that the annual review has been completed. Subsequent modifications to or renewal of this permit does not reset or revise these deadlines unless a new deadline is set explicitly by such permit modification or renewal.
3. **Facility Review** - The permittee shall review all facility components or systems (including but not limited to material storage areas; in-plant transfer, process, and material handling areas; loading and unloading operations; storm water, erosion, and sediment control measures; process emergency control systems; and sludge and waste disposal areas) where materials or pollutants are used, manufactured, stored or handled to evaluate the potential for the release of pollutants to the waters of the State. In performing such an evaluation, the permittee shall consider such factors as the probability of equipment failure or improper operation, cross-contamination of storm water by process materials, settlement of facility air emissions, the effects of natural phenomena such as freezing temperatures and precipitation, fires, and the facility's history of spills and leaks. The relative toxicity of the pollutant shall be considered in determining the significance of potential releases. The review shall address all substances present at the facility that are identified in the SPDES application Form NY-2C (available at [https://www.dec.ny.gov/docs/permits\\_ej\\_operations\\_pdf/form2c.pdf](https://www.dec.ny.gov/docs/permits_ej_operations_pdf/form2c.pdf)).
4. **13 Minimum BMPs:** Whenever the potential for a release of pollutants to State waters is determined to be present, the permittee shall identify BMPs that have been established to prevent or minimize such potential releases. Where BMPs are inadequate or absent, appropriate BMPs shall be established. In selecting appropriate BMPs, the permittee shall consider good industry practices and, where appropriate, structural measures such as secondary containment and erosion/sediment control devices and practices. USEPA guidance for development of stormwater elements of the BMP is available in *Developing Your Stormwater Pollution Prevention Plan A Guide for Industrial Operators*, February 2009, EPA 833-B-09-002. At a minimum, the plan shall include the following BMPs:

- |                                     |                                                       |                                 |
|-------------------------------------|-------------------------------------------------------|---------------------------------|
| 1. BMP Pollution Prevention Team    | 6. Security                                           | 10. Spill Prevention & Response |
| 2. Reporting of BMP Incidents       | 7. Preventive Maintenance                             | 11. Erosion & Sediment Control  |
| 3. Risk Identification & Assessment | 8. Good Housekeeping                                  | 12. Management of Runoff        |
| 4. Employee Training                | 9. Materials/Waste Handling, Storage, & Compatibility | 13. Street Sweeping             |
| 5. Inspections and Records          |                                                       |                                 |

## BMPs FOR INDUSTRIAL FACILITIES (continued)

5. **Stormwater Pollution Prevention Plans (SWPPPs) Required for Discharges of Stormwater from Construction Activity to Surface Waters** - A SWPPP shall be developed prior to commencing any construction activity that will result in soil disturbance of one or more acres of uncontaminated area<sup>1</sup>. (Note: the disturbance threshold is 5000 SF in the New York City East of Hudson Watershed). The SWPPP shall conform to the current version of the SPDES General Permit for Stormwater Discharges from Construction Activity (CGP), including the *New York Standards and Specifications for Erosion and Sediment Control* and *New York State Stormwater Management Design Manual*. The permittee shall submit a copy of the SWPPP and any amendments thereto to the local governing body and any other authorized agency having jurisdiction or regulatory control over the construction activity **at least 30 days prior to soil disturbance**. The SWPPP shall be maintained on-site and submitted to the Department only upon request. When a SWPPP is required, a properly completed *Notice of Intent* (NOI) form shall be submitted (available at [www.dec.ny.gov/chemical/43133.html](http://www.dec.ny.gov/chemical/43133.html)) prior to soil disturbance. Note that submission of the NOI is required for informational purposes; the permittee is not eligible for and will not obtain coverage under any SPDES general permit for stormwater discharges. SWPPPs must be developed for subsequent site disturbances in accordance with the above requirements. The permittee is responsible for ensuring that the provisions of each SWPPP are properly implemented.
6. **Required Sampling For "Hot Spot" Identification** - Development of the BMP plan shall include sampling of waste stream segments for the purpose of pollutant "hot spot" identification. The economic achievability of effluent limits will not be considered until plant site "hot spot" sources have been identified, contained, removed or minimized through the imposition of site specific BMPs or application of internal facility treatment technology. For the purposes of this permit condition a "hot spot" is a segment of an industrial facility (including but not limited to soil, equipment, material storage areas, sewer lines etc.) which contributes elevated levels of problem pollutants to the wastewater or stormwater collection system of that facility. For the purposes of this definition, problem pollutants are substances for which treatment to meet a water quality or technology requirement may, considering the results of waste stream segment sampling, be deemed unreasonable. For the purposes of this definition, an elevated level is a concentration or mass loading of the pollutant in question which is sufficiently higher than the concentration of that same pollutant at the compliance monitoring location so as to allow for an economically justifiable removal, isolation, or B.A.T. treatment of wastewaters emanating from the segment.

---

<sup>1</sup> Uncontaminated area means soils which are free of contamination by any toxic or non-conventional pollutants identified in the tables of SPDES Application Form NY-2C. Disturbance of any size contaminated area(s) and the resulting discharge of contaminated stormwater is not authorized by this permit unless the discharge is under State or Federal oversight as part of a remedial program or after review by the Regional Water Engineer; nor is such discharge authorized by any SPDES general permit for stormwater discharges.



## MERCURY MINIMIZATION PROGRAM (MMP) - Type IV

On 10/10/2024, the permittee submitted a Conditional Exclusion Certification, certifying that the facility does not have any of the mercury sources listed in Part III.A.3. of DOW 1.3.10.

1. General - The permittee must develop, implement, and maintain a mercury minimization program (MMP), containing the elements set forth below.
2. MMP Elements - The MMP must be a written document and must include any necessary drawings or maps of the facility and/or collection system. Other related documents already prepared for the facility may be used as part of the MMP and may be incorporated by reference. At a minimum, the MMP must include the following elements<sup>2</sup> as described in detail below:
  - a. Conditional Exclusion Certification - A certification (Appendix D of *DOW 1.3.10*), signed in accordance with 750-1.8 Signature of SPDES forms, must be submitted once every five (5) years for Outfall 001 to the Regional Water Engineer and to the Bureau of Water Permits certifying that Outfall 001 for the facility is neither a mercury source nor receives flows from a mercury source. Criteria to determine if a facility has a mercury source are as follows:
    - The facility is or receives discharge from 1) individually permitted combined sewer overflow (CSOs)<sup>3</sup> communities and/or 2) Type II sanitary sewer overflow (SSO)<sup>4</sup> facilities;
    - One or more effluent samples which exceed 12 ng/L, including samples taken as a result of the SPDES application process;
    - Internal or tributary waste stream samples exceed the GLCA effluent limitation **AND** the final effluent samples are less than the GLCA due primarily to dilution by uncontaminated or less contaminated waste streams. Both components of this criterion may include samples taken as a result of the SPDES application process;
    - A permit application or other information indicates that mercury is handled on site and could be discharged through outfalls;
    - Outfalls which contain legacy mercury contamination;
    - The facility's collection system receives discharges from a dental and/or categorical industrial user (CIU)<sup>5</sup> that may discharge mercury;
    - The facility accepts hauled wastes; or,
    - The facility is defined as a categorical industry that may discharge mercury. This may also include dentists, universities, hospitals, or laboratories which have their own SPDES permit.
  - b. Control Strategy - The control strategy must contain the following minimum elements:
    - i. Equipment and Materials – Equipment and materials (e.g., thermometers, thermostats) used by the permittee, which may contain mercury, must be evaluated by the permittee. As equipment and materials containing mercury are updated/replaced, the permittee must use mercury-free alternatives, if possible.
    - ii. Bulk Chemical Evaluation – For chemicals, used at a rate which exceeds 1,000 gallons/year or 10,000 pounds/year, the permittee must obtain a manufacturer's certificate of analysis, a chemical analysis performed by a certified laboratory, and/or a notarized affidavit which describes the substances' mercury concentration and the detection limit achieved. If possible, the permittee must only use bulk chemicals utilized in the wastewater treatment process which contain <10 ppb mercury.

<sup>2</sup>Neither monitoring nor outreach is required for facilities meeting the criteria for MMP Type IV, but monitoring and/or outreach can be included in the permittee's control strategy.

<sup>3</sup>CSO permits are included under the 05 and 07 permit classifications.

<sup>4</sup>These are overflow retention facilities (ORFs) and are included under the 05 and 07 permit classifications.

<sup>5</sup>CIUs include those listed under Federal Regulation in 40 CFR Part 400.



## MERCURY MINIMIZATION PROGRAM (MMP) – Type IV (Continued)

- c. **Status Report** - An **annual** status report must be developed and maintained on site, in accordance with the [Schedule of Additional Submittals](#), summarizing:
- Review of criteria to determine if the facility has a potential mercury source;
    - If the permittee no longer meets the criteria for MMP Type IV, the permittee must notify the DEC for a permittee-initiated permit modification;
  - All actions undertaken, pursuant to the control strategy, during the previous year; and
  - Actions planned, pursuant to the control strategy, for the upcoming year.

The permittee must maintain a file with all MMP documentation. The file must be available for review by DEC representatives and copies must be provided upon request in accordance with 6 NYCRR 750-2.1(i) and 750-2.5(c)(4).

3. **MMP Modification** - The MMP must be modified whenever:
- Changes at the facility, or within the collection system, increase the potential for mercury discharges;
  - A letter from the DEC identifies inadequacies in the MMP.

The DEC may use information in the annual status reports, in accordance with 2.c of this MMP, to determine if the permit limitations and MMP Type is appropriate for the facility.

### DEFINITIONS:

Potential mercury source – a source identified by the permittee that may reasonably be expected to have total mercury contained in the discharge. Some potential mercury sources include switches, fluorescent lightbulbs, cleaners, degreasers, thermometers, batteries, hauled wastes, universities, hospitals, laboratories, landfills, Brownfield sites, or raw material storage.

## DISCHARGE NOTIFICATION REQUIREMENTS

- (a) The permittee shall install and maintain identification signs at all outfalls to surface waters listed in this permit, unless the Permittee has obtained a waiver in accordance with the Discharge Notification Act (DNA). Such signs shall be installed before initiation of any new discharge location.
- (b) Subsequent modifications to or renewal of this permit does not reset or revise the deadline set forth in (a) above, unless a new deadline is set explicitly by such permit modification or renewal.
- (c) The Discharge Notification Requirements described herein do not apply to outfalls from which the discharge is composed exclusively of storm water, or discharges to ground water.
- (d) The sign(s) shall be conspicuous, legible and in as close proximity to the point of discharge as is reasonably possible while ensuring the maximum visibility from the surface water and shore. The signs shall be installed in such a manner to pose minimal hazard to navigation, bathing or other water related activities. If the public has access to the water from the land in the vicinity of the outfall, an identical sign shall be posted to be visible from the direction approaching the surface water.

The signs shall have **minimum** dimensions of eighteen inches by twenty-four inches (18" x 24") and shall have white letters on a green background and contain the following information:

### N.Y.S. PERMITTED DISCHARGE POINT

SPDES PERMIT No.: NY\_\_\_\_\_

OUTFALL No. : \_\_\_\_\_

For information about this permitted discharge contact:

Permittee Name: \_\_\_\_\_

Permittee Contact: \_\_\_\_\_

Permittee Phone: ( ) - ### - #####

OR:

NYSDEC Division of Water Regional Office Address:

NYSDEC Division of Water Regional Phone: ( ) - ### - #####

- (e) Upon request, the permittee shall make available electronic or hard copies of the sampling data to the public. In accordance with the RECORDING, REPORTING AND ADDITIONAL MONITORING REQUIREMENTS page of your permit, each DMR shall be maintained (either electronically or as a hard copy) on record for a period of five years.
- (f) The permittee shall periodically inspect the outfall identification sign(s) in order to ensure they are maintained, are still visible, and contain information that is current and factually correct. Signs that are damaged or incorrect shall be replaced within 3 months of inspection.

## SCHEDULE OF COMPLIANCE

a) The permittee shall comply with the following schedule:

OUTFALL	COMPLIANCE ACTION	COMPLIANCE DATE <sup>6</sup>
001	<b>DESIGN DOCUMENTS</b> The permittee shall submit approvable <sup>2</sup> Design Documents including a Basis of Design Report (BODR), Plans, Specifications, and Construction Schedule for the selected alternative that will ensure compliance with final effluent limitations.	EDP + 18 Months
	<b>COMPLETE CONSTRUCTION</b> The permittee shall provide a Construction Completion Certification <sup>7</sup> to the DEC (send to the Regional Water Engineer and NetDMR@dec.ny.gov) that the disposal system has been fully completed in accordance with the approved Design Documents.	EDP + 30 Months
	<b>COMMENCE OPERATION</b> Following receipt of DEC acceptance of the Construction Completion Certification, the permittee shall comply with the final effluent limitations for chromium, hexavalent chromium, copper, nickel, zinc, and temperature.	EDP + 36 Months

OUTFALL	PARAMETER	INTERIM EFFLUENT LIMIT					REQUIREMENTS				Notes
		Type	Limit	Units	Limit	Units	Sample Frequency	Sample Type	Location		
									Inf.	Eff.	
001	Total Chromium	Daily Maximum	2.0	mg/L			Monthly	8-hr. Comp.		X	1
	Chromium Hexavalent	Daily Maximum	0.11	mg/L			Monthly	8-hr. Comp.		X	1
	Total Copper	Daily Maximum	0.12	mg/L			Monthly	8-hr. Comp.		X	1
	Total Nickel	Daily Maximum	1.0	mg/L			Monthly	8-hr. Comp.		X	1
	Total Zinc	Daily Maximum	0.75	mg/L			Monthly	8-hr. Comp.		X	1
	Temperature	Daily Maximum	Monitor	°F			Daily	Grab		X	1
	1. Interim limits expire <b>EDP</b> + 36 months.										

b) The permittee shall submit a [Report of Non-compliance Event](#) form with each of the above schedule dates no later than 14 days following each elapsed date, unless conditions require more immediate notice as prescribed in 6 NYCRR Part 750-1.2(a) and 750-2. All notifications shall be sent to the locations listed under the section of this permit entitled RECORDING, REPORTING AND ADDITIONAL MONITORING REQUIREMENTS. Each notice of non-compliance shall include the following information:

1. A short description of the non-compliance;
2. A description of any actions taken or proposed by the permittee to comply with the elapsed schedule requirements without further delay and to limit environmental impact associated with the non-compliance;
3. Any details which tend to explain or mitigate an instance of non-compliance; and
4. An estimate of the date the permittee will comply with the elapsed schedule requirement and an assessment of the probability that the permittee will meet the next scheduled requirement on time.


c) The permittee shall submit copies of any document required by the above schedule of compliance to the DEC Regional Water Engineer and to the Bureau of Water Permits.

<sup>6</sup> 6 NYCRR 750-1.14 (a)

<sup>7</sup> 6 NYCRR 750-2.10 (c)

## MONITORING LOCATIONS

The permittee shall take samples and measurements, to comply with the monitoring requirements specified in this permit, at the location(s) specified below:  
Effluent shall be sampled after all treatment processes and after the process water, cooling water, and stormwater have combined



## GENERAL REQUIREMENTS

- A. The regulations in 6 NYCRR Part 750 are hereby incorporated by reference and the conditions are enforceable requirements under this permit. The permittee shall comply with all requirements set forth in this permit and with all the applicable requirements of 6 NYCRR Part 750 incorporated into this permit by reference, including but not limited to the regulations in paragraphs B through H as follows:
- B. General Conditions
- |                                                  |                                         |
|--------------------------------------------------|-----------------------------------------|
| 1. Duty to comply                                | 6 NYCRR 750-2.1(e) & 2.4                |
| 2. Duty to reapply                               | 6 NYCRR 750-1.16(a)                     |
| 3. Need to halt or reduce activity not a defense | 6 NYCRR 750-2.1(g)                      |
| 4. Duty to mitigate                              | 6 NYCRR 750-2.7(f)                      |
| 5. Permit actions                                | 6 NYCRR 750-1.1(c), 1.18, 1.20 & 2.1(h) |
| 6. Property rights                               | 6 NYCRR 750-2.2(b)                      |
| 7. Duty to provide information                   | 6 NYCRR 750-2.1(i)                      |
| 8. Inspection and entry                          | 6 NYCRR 750-2.1(a) & 2.3                |
- C. Operation and Maintenance
- |                                   |                                      |
|-----------------------------------|--------------------------------------|
| 1. Proper Operation & Maintenance | 6 NYCRR 750-2.8                      |
| 2. Bypass                         | 6 NYCRR 750-1.2(a)(17), 2.8(b) & 2.7 |
| 3. Upset                          | 6 NYCRR 750-1.2(a)(94) & 2.8(c)      |
- D. Monitoring and Records
- |                           |                                                                  |
|---------------------------|------------------------------------------------------------------|
| 1. Monitoring and records | 6 NYCRR 750-2.5(a)(2), 2.5(a)(6), 2.5(c)(1), 2.5(c)(2), & 2.5(d) |
| 2. Signatory requirements | 6 NYCRR 750-1.8 & 2.5(b)                                         |
- E. Reporting Requirements
- |                                         |                                   |
|-----------------------------------------|-----------------------------------|
| 1. Reporting requirements for non-POTWs | 6 NYCRR 750-2.5, 2.6, 2.7, & 1.17 |
| 2. Anticipated noncompliance            | 6 NYCRR 750-2.7(a)                |
| 3. Transfers                            | 6 NYCRR 750-1.17                  |
| 4. Monitoring reports                   | 6 NYCRR 750-2.5(e)                |
| 5. Compliance schedules                 | 6 NYCRR 750-1.14(d)               |
| 6. 24-hour reporting                    | 6 NYCRR 750-2.7(c) & (d)          |
| 7. Other noncompliance                  | 6 NYCRR 750-2.7(e)                |
| 8. Other information                    | 6 NYCRR 750-2.1(f)                |
- F. Sludge Management
- The permittee shall comply with all applicable requirements of 6 NYCRR Part 360.
- G. SPDES Permit Program Fee
- The permittee shall pay to the DEC an annual SPDES permit program fee within 30 days of the date of the first invoice, unless otherwise directed by the DEC, and shall comply with all applicable requirements of ECL 72-0602 and 6 NYCRR Parts 480, 481 and 485. Note that if there is inconsistency between the fees specified in ECL 72-0602 and 6 NYCRR Part 485, the ECL 72-0602 fees govern.
- H. Water Treatment Chemicals (WTCs)
- New or increased use and discharge of a WTC requires prior DEC review and authorization. At a minimum, the permittee must notify the DEC in writing of its intent to change WTC use by submitting a completed *WTC Notification Form* for each proposed WTC. The DEC will review that submittal and determine if a SPDES permit modification is necessary or whether WTC review and authorization may proceed outside of the formal permit administrative process. The majority of WTC authorizations do not require SPDES permit modification. In any event, use and discharge of a WTC shall not proceed without prior authorization from the DEC. Examples of WTCs include biocides, coagulants, conditioners, corrosion inhibitors, defoamers, deposit control agents, flocculants, scale inhibitors, sequestrants, and settling aids.
1. WTC use shall not exceed the rate explicitly authorized by this permit or otherwise authorized by the DEC.
  2. The permittee shall maintain a logbook of all WTC use, noting for each WTC the date, time, exact location, and amount of each dosage, and the name of the individual applying or measuring the chemical. The logbook must also document that adequate process controls are in place to ensure excessive levels of WTCs are not used.
  3. The permittee shall submit a completed WTC Annual Report Form each year that they use and discharge WTCs. This form shall be submitted in electronic format and attached to either the December DMR or the annual monitoring report required below. The *WTC Notification Form* and *WTC Annual Report Form* are available from the DEC's website at: <http://www.dec.ny.gov/permits/93245.html>

## RECORDING, REPORTING AND ADDITIONAL MONITORING REQUIREMENTS

- A. The monitoring information required by this permit shall be retained for a period of at least five years from the date of the sampling for subsequent inspection by the Department or its designated agent.
- B. Discharge Monitoring Reports (DMRs): Completed DMR forms shall be submitted for each 1 month reporting period in accordance with the DMR Manual available on DEC's website.

DMRs must be submitted electronically using the electronic reporting tool (NetDMR) specified by DEC. Instructions on the use of NetDMR can be found at: [How To Complete And Submit Discharge Monitoring Reports \(DMRs\) - NYSDEC](#). **Hardcopy paper DMRs will only be accepted if a waiver from the electronic submittal requirements has been granted by DEC to the facility.**

The first monitoring period begins on the effective date of this permit, and, unless otherwise required, the reports are due no later than the 28th day of the month following the end of each monitoring period.

- C. Additional information required to be submitted by this permit shall be summarized and reported to the Regional Water Engineer and Bureau of Water Permits at the following addresses:

Department of Environmental Conservation  
Division of Water, Bureau of Water Permits  
625 Broadway, Albany, New York 12233-3505

Phone: (518) 402-8111

Department of Environmental Conservation  
Regional Water Engineer, Region 04

1130 North Westcott Road, Schenectady, New York, 12306-2014 Phone: (518) 357-2045

- D. Annual SPDES Monitoring Reports: An annual report shall be submitted to DEC by February 1<sup>st</sup> each year. The report shall summarize information for January to December of the previous year and shall be submitted electronically, or in hardcopy format, utilizing the SPDES Annual Report Form available on the DEC's website.

Hard copy submission of the Annual Report shall be submitted to the Regional Water Engineer at the address below:

Department of Environmental Conservation  
Regional Water Engineer, Region 04

1130 North Westcott Road, Schenectady, New York, 12306-2014 Phone: (518) 357-2045

- E. Schedule of Additional Submittals:

The permittee shall submit the following information to the Regional Water Engineer and to the Bureau of Water Permits, unless otherwise instructed:

Outfall(s)	SCHEDULE OF ADDITIONAL SUBMITTALS - Required Action	Due Date
001	<p><u>BMP PLAN</u></p> <p>The permittee shall develop and submit a Best Management Practices (BMP) plan.</p> <p>The permittee shall annually review the completed BMP plan, submitted to the DEC on an annual basis. The BMP plan shall be modified whenever: (a) changes at the facility materially increase the potential for releases of pollutants, (b) actual releases indicate the plan is inadequate, or (c) a letter from the DEC identifies inadequacies in the plan. The permittee shall certify in writing, as an attachment to the December Discharge Monitoring Report (DMR), that the annual review has been completed. All BMP plan revisions must be submitted to the Regional Water Engineer within 30 days.</p>	<p><b>EDP + 6 Months</b></p> <p>Annually on January 28<sup>th</sup></p>

Outfall(s)	SCHEDULE OF ADDITIONAL SUBMITTALS - Required Action	Due Date
	<u>WATER TREATMENT CHEMICAL (WTC) ANNUAL REPORT FORM</u> The permittee shall submit a completed WTC Annual Report Form each year that Water Treatment Chemicals are used. The form shall be attached to the December DMR.	Every year with December DMR report
	<u>MERCURY MINIMIZATION PLAN</u> The permittee must complete and maintain onsite an annual mercury minimization status report in accordance with the requirements of this permit.	<b>Maintained Onsite</b>  EDP + 12 months, annually thereafter
	<u>MERCURY - CONDITIONAL EXCLUSION CERTIFICATION</u> Permittee must submit a mercury conditional exclusion certification every five years in order to maintain MMP Type IV status.	Every 5 years from 10/10/2024
	<u>STORMWATER NO EXPOSURE CERTIFICATION</u> Permittee must recertify every five years a condition of no exposure to stormwater in order to continue to qualify for the no exposure exclusion. The No Exposure Certification Form can be found on the DEC website.	Every 5 years from 10/10/2024


**Unless noted otherwise, the above actions are one-time requirements.**

- F. Monitoring and analysis shall be conducted using sufficiently sensitive test procedures approved under 40 CFR Part 136, unless other test procedures have been specified in this permit.
- G. More frequent monitoring of the discharge(s), monitoring point(s), or waters of the State than required by the permit, where analysis is performed by a certified laboratory or where such analysis is not required to be performed by a certified laboratory, shall be included in the calculations and recording of the data on the corresponding DMRs.
- H. Calculations which require averaging of measurements shall utilize an arithmetic mean unless otherwise specified in this permit.
- I. Unless otherwise specified, all information recorded on the DMRs shall be based upon measurements and sampling carried out during the most recently completed reporting period.
- J. Any laboratory test or sample analysis required by this permit for which the State Commissioner of Health issues certificates of approval pursuant to section 502 of the Public Health Law shall be conducted by a laboratory which has been issued a certificate of approval. Inquiries regarding laboratory certification should be directed to the New York State Department of Health, Environmental Laboratory Accreditation Program.



# **SPDES Permit Fact Sheet Royal Metal Products, Inc.**

## **NY0110485**



## Contents

Summary of Permit Changes .....	3
Administrative History .....	4
Facility Information .....	4
Existing Effluent Quality .....	4
Site Overview .....	5
Receiving Water Information .....	6
Impaired Waterbody Information .....	6
Critical Receiving Water Data .....	6
Permit Requirements .....	6
USEPA Effluent Limitation Guidelines (ELGs) Applicable to Facility .....	6
Whole Effluent Toxicity (WET) Testing .....	6
Anti-backsliding .....	6
Antidegradation .....	7
Discharge Notification Act Requirements .....	7
Best Management Practices (BMPs) for Industrial Facilities .....	7
Stormwater Pollution Prevention Requirements .....	7
Mercury .....	7
Emerging Contaminants .....	7
Schedule of Compliance .....	8
Schedule of Additional Submittals .....	8
OUTFALL AND RECEIVING WATER SUMMARY TABLE .....	9
POLLUTANT SUMMARY TABLE .....	9
Outfall 001 .....	9
USEPA EFFLUENT LIMITATION GUIDELINE (ELG) CALCULATIONS .....	14
Appendix: Regulatory and Technical Basis of Permit Authorizations .....	15
Regulatory References .....	15
Outfall and Receiving Water Information .....	15
Existing Effluent Quality .....	16
Permit Requirements .....	16

## Summary of Permit Changes

A State Pollutant Discharge Elimination System (SPDES) EBPS permit renewal and full technical review has been drafted for the Royal Metal Products, Inc. The changes to the permit are summarized below:

### General Changes

- Updated permit format, definitions, and general conditions
- Added requirement to implement a Mercury Minimization Program (MMP) Type IV
- Added requirement to develop and maintain Best Management Practices (BMP) Plan
- Removal of Outfall 002 (~190 GPD sanitary to groundwater)
  - This outfall is below the threshold that requires SPDES permit coverage

### Changes to Outfall 001

- Reduced daily max effluent limitations for the following:
  - pH from 6.0 – 9.0 to 6.5 – 8.5 SU
  - Total Chromium from 2.0 mg/L to 0.07 mg/L (70 ug/L)\*
  - Hexavalent Chromium from 0.11 mg/L to 0.011 mg/L (11 ug/L)\*
  - Copper from 0.12 mg/L to 0.0081 mg/L (8.1 ug/L)\*
  - Nickel from 1.0 mg/L to 0.045 mg/L (45 ug/L)\*
  - Zinc from 0.75 mg/L to 0.072 mg/L (72 ug/L)\*
- Added a new daily max effluent limitation for Temperature of 90°F\*
- Added new Effluent Limitation Guidelines (ELG) daily max and monthly average limitations for Lead of 0.69 mg/L (690 ug/L) and 0.43 mg/L (430 ug/L), respectively
- Added new ELG daily max and monthly average effluent limitations for Cadmium of 0.69 mg/L (690 ug/L) and 0.26 mg/L (260 ug/L), respectively
- Added new ELG daily max for total toxic organics of 2.13 mg/L
- Added new ELG daily max and monthly avg for Oil and Grease.
- Removed action level for tetrachloroethylene and associated action level language

### \*Schedule of Compliance

- Added a compliance schedule to achieve final effluent limitations for Total Chromium, Hexavalent Chromium, Copper, Nickel, Zinc, and Temperature
- Includes interim milestone dates for submittal of design documents

**This fact sheet summarizes the information used to determine the effluent limitations (limits) and other conditions contained in the permit. General background information including the regulatory basis for the effluent limitations and other conditions are in the [Appendix](#) linked throughout this fact sheet.**

## Administrative History

4/1/1994 The SPDES permit became effective with a new five-year term and expiration date of 3/31/1999.

The permit was most recent administratively renewed in 4/1/2024. The current permit administrative renewal is effective until 3/3/2029.

8/12/2024 DEC issued a Request for Information (RFI) to modify and renew the SPDES permit due to the facility's EBPS score<sup>1</sup>. At the time of the RFI, the facility had an EBPS score of 335.

10/10/2024 The Royal Metal Products, Inc. submitted a NY-2C permit application.

The Notice of Complete Application, published in the [Environmental Notice Bulletin](#) and newspapers, contains information on the public notice process.

## Facility Information

This is an industrial facility (SIC codes 2514 and 3471) that produces metal household furniture and includes electroplating, plating, polishing, anodizing, and coloring, and is subject to categorical effluent limitation guidelines (ELGs) (see [ELG summary table](#) at the end of this fact sheet). Effluent consists of plating rinse water, non-contact cooling water, and stormwater. The current treatment system consists of two 785-gallon evaporation tanks, as needed.

Sludge from the evaporation tanks is disposed off-site.

Outfall 001 is a four-inch pipe that discharges to the bank of the Tributary of Jan De Bakkers Kill Creek, Class C. The facility does not have any planned improvements. The facility currently uses groundwater from onsite wells for cooling purposes.

The 1994 permit also lists Outfall 002 (with no monitoring or sampling requirements) for their sanitary discharge of ~190 GPD to groundwater. This flow is below the minimum threshold<sup>2</sup> needed to require a SPDES permit and has been removed from the permit.

## Existing Effluent Quality


The [Pollutant Summary Table](#) presents the existing effluent quality and effluent limitations. The existing effluent quality was determined from Discharge Monitoring Reports and the application submitted by the permittee for the period 10/1/2019 to 11/30/2024.

---


<sup>1</sup> Pursuant to 6 NYCRR 750-1.18 and NYS Environmental Benefit Permit Strategy (EBPS)

<sup>2</sup> Consistent with ECL 17-0701(6) and 6 NYCRR 750-1.5.

## Site Overview



The National Map Advanced Viewer



## Receiving Water Information

The facility discharges via the following outfalls:

Outfall No.	SIC Code	Wastewater Type	Receiving Water
001	2514 3471	Process Water, Cooling Water, and Stormwater	Trib. of Jan De Bakkers Kill, Class C
Note: Approximately 2 miles downstream the receiving water classification changes to C(TS).			

## Impaired Waterbody Information

The Jan De Bakkers Kill segment (PWL No. 1309-0026) is not listed on the 2020/2022 [New York State Section 303\(d\) List](#) of Impaired/Total Maximum Daily Load (TMDL) waters and therefore, there are no applicable wasteload allocations for this discharge.

## Critical Receiving Water Data

Intermittent stream effluent limits (ISEL) have been applied because the facility is located close to the headwaters of the Tributary of Jan De Bakkers Kill (drainage area of 0.42 square miles) and may not have flow during the dry season. Consistent with TOGS 1.3.1, the water quality standards will be applied as end-of-pipe limitations with no mixing or dilution.

Critical receiving water data are listed in the [Pollutant Summary Table](#) at the end of this fact sheet. [Appendix Link](#)

## Permit Requirements

The technology based effluent limitations ([TBELs](#)), water quality-based effluent limitations ([WQBELs](#)), [Existing Effluent Quality](#) and a discussion of the selected effluent limitation for each pollutant present in the discharge are provided in the [Pollutant Summary Table](#).

## USEPA Effluent Limitation Guidelines (ELGs) Applicable to Facility

Best Practicable Control Technology Currently Available (BPT), Best Conventional Pollutant Control Technology (BCT), Best Available Technology Economically Achievable (BAT), and New Source Performance Standards (NSPS) limitations are based on [Effluent Limitation Guidelines](#) developed by USEPA for specific industries<sup>3</sup>. The applicable effluent guidelines and limits are listed at the end of the Pollutant Summary Table in the USEPA ELG Calculation Table. [Appendix Link](#)

## Whole Effluent Toxicity (WET) Testing

None of the seven criteria that are indicative of potential toxicity are applicable to this facility; therefore, WET testing is not included in the permit. [Appendix Link](#)

## Anti-backsliding

The limitations contained in the permit are at least as stringent as the previous permit limits and there are no instances of backsliding. [Appendix Link](#)

<sup>3</sup> As promulgated under 40 CFR Parts 405 - 471



### Antidegradation

The permit contains effluent limitations which ensure that the best usages of the receiving waters will be maintained. The Notice of Complete Application published in the Environmental Notice Bulletin contains information on the State Environmental Quality Review (SEQR)<sup>4</sup> determination.

[Appendix Link](#)

### Discharge Notification Act Requirements

In accordance with the Discharge Notification Act (ECL 17-0815-a), the permittee is required to post a sign at each point of wastewater discharge to surface waters, unless a waiver is obtained. This requirement has been continued from the previous permit.

Additionally, the permit contains a requirement to make the DMR sampling data available to the public upon request. This requirement has been continued from the previous permit.

### Best Management Practices (BMPs) for Industrial Facilities

In accordance with 6 NYCRR 750-1.14(f) and 40 CFR 122.44(k), the permittee is required to develop and implement a BMP plan that prevents, or minimizes the potential for, the release of toxic or hazardous pollutants to state waters. The BMP plan also requires annual review by the permittee. These requirements have been updated from the previous permit.

### Stormwater Pollution Prevention Requirements

On 10/10/2024, the permittee submitted a Conditional Exclusion for No Exposure Form, certifying that all industrial activities and materials are completely sheltered from exposure. This condition must be maintained for the exclusion to remain applicable. The schedule of submittals also includes a due date for re-certification every five years as required by 40 CFR 122.26(g)(iii). This requirement is new.

### Mercury<sup>5</sup>

The multiple discharge variance (MDV) for mercury provides the framework for DEC to require mercury monitoring and mercury minimization programs (MMPs), through SPDES permitting.

On 10/10/2024, the permittee submitted a Conditional Exclusion Certification, certifying that the facility does not have any of the mercury sources listed in Part III.A.3. of DOW 1.3.10 and the effluent measured <12 ng/L. Therefore, consistent with DOW 1.3.10, the permit includes requirements for the implementation of MMP Type IV and does not include mercury effluent limitations. The [Schedule of Additional Submittals](#) includes a mercury minimization plan annual status report (maintained onsite), and re-certification of the exclusion every five years. As part of the re-certification, the effluent must be sampled and continue to measure <12 ng/L. This requirement is new. [Appendix Link](#)

### Emerging Contaminants

Emerging Contaminants, such as Perfluorooctanoic acid (PFOA), Perfluorooctanesulfonic acid (PFOS), and 1,4-Dioxane (1,4-D), have been used in a wide variety of consumer and industrial product as well as in manufacturing processes for decades. These contaminants do not break down easily, therefore their presence in wastewater can remain a concern for years following their discontinued use. As the science surrounding these contaminants is still evolving, additional monitoring is needed to better understand potential sources and background levels. For more

---

<sup>4</sup> As prescribed by 6 NYCRR Part 617

<sup>5</sup> In accordance with DOW 1.3.10 Mercury – SPDES Permitting & Multiple Discharge Variance (MDV), December 30, 2020.



information on emerging contaminants, please see the DEC Division of Water web page: [Emerging Contaminants In NY's Waters - NYSDEC](#).

Based on the data submitted with the application, which measured non-detect for the suite of PFOS compounds, no additional monitoring is required at this time.

### Schedule of Compliance

A Schedule of Compliance has been included<sup>6</sup> for the following items ([Appendix Link](#)):

- Submittal of basis of design report, with the details of the upgrades/construction needed to comply with the final effluent limitations for Temperature, Chromium, Hexavalent Chromium, Copper, Nickel, and Zinc

These are either new limitations or significantly reduced limitations and given there is no existing treatment, it is unknown if the permittee can immediately comply.

### Schedule of Additional Submittals

A schedule of additional submittals has been included for the following ([Appendix Link](#)):

- BMP Plan
- Mercury Minimization Program Annual Status Report
- Mercury no exposure certification
- Stormwater no exposure certification

---

<sup>6</sup> Pursuant to 6 NYCRR 750-1.14

## OUTFALL AND RECEIVING WATER SUMMARY TABLE

Outfall	Latitude	Longitude	Receiving Water Name	Water Class	Water Index No. / Priority Waterbody Listing (PWL) No.	Major / Sub Basin	Hardness (mg/l) <sup>7</sup>	1Q10 (MGD)	7Q10 (MGD)	30Q10 (MGD)	Critical Effluent Flow (MGD)	Dilution Ratio		
												A(A)	A(C)	HEW
001	42° 23' 13" N	73° 59' 40" W	Trib. of Jan De Bakkers Kill	C	H – 193- 19- 5a PWL: 1309-0026	13/09	85	-	-	-	-	1:1	1:1	1:1

## POLLUTANT SUMMARY TABLE

### Outfall 001

Outfall #	001		Description of Wastewater: Process Water, Stormwater, and Non-contact Cooling Water													
			Type of Treatment: Evaporation Tanks (as needed)													
Effluent Parameter	Units	Averaging Period	Existing Discharge Data			TBELs		Water Quality Data & WQBELs						ML	Basis for Permit Requirement	
			Permit Limit	Existing Effluent Quality <sup>8</sup>	# of Data Points Detects / Non-Detects	Limit	Basis	Ambient Bkgd. Conc.	Projected Instream Conc.	WQ Std. or GV	WQ Type	Calc. WQBEL	Basis			
General Notes: Existing discharge data from 10/31/2019 to 11/31/2024 was obtained from Discharge Monitoring Reports provided by the permittee. All applicable water quality standards were reviewed for development of the WQBELs. The standard and WQBEL shown below represent the most stringent.																
Flow Rate	GPD	Daily Max	Monitor	520 Actual Average	60	-	-	No alterations that will impair the waters for their best usages.					703.2	-	Monitor 750-1.13	
	Flow will continue to be monitored for informational purposes and to calculate pollutant loadings.															
Chromium, Total	mg/L	Daily Max	2.0 Total	0.01 Max Total	4 / 46	2.77	40 CFR Part 433, Subpart A	-	-	0.06 Dissolved	A(C)	0.07 Total	703.5	-	WQBEL	
		Monthly Avg	-	-	-	1.71	40 CFR Part 433, Subpart A	-	-	-	-	-	-	-	No Limitation	
The effluent limitation has been reduced to the calculated WQBEL using a metals translator of 1.163, in accordance with EPA document 823-B-96-007. A Schedule of Compliance item has been added. The daily max limitation is protective of the monthly average ELG and monthly average effluent limitations have not been included.																

<sup>7</sup> Ambient hardness was calculated as the average of 10 samples from nearby RIBS station 13-BASC-0.4 in Greenville, NY.

<sup>8</sup> Existing Effluent Quality: Unless otherwise stated, Daily Max = 99% lognormal; Monthly Avg = 95% lognormal (for datasets with ≤3 non-detects); Daily Max = 99% delta-lognormal; Monthly Avg = 95% delta-lognormal (for datasets with >3 nondetects)

Permittee: Royal Metal Products, Inc.  
 Facility: Royal Metal Products, Inc.  
 SPDES Number: NY0110485  
 USEPA Non-Major/Class 01 Industrial

Date: September 19, 2025 v.1.27  
 Permit Writer: Rashid Ahmed, PE  
 Water Quality Reviewer: Rashid Ahmed, PE  
 Full Technical Review

Outfall #	001	Description of Wastewater: Process Water, Stormwater, and Non-contact Cooling Water													
		Type of Treatment: Evaporation Tanks (as needed)													
Effluent Parameter	Units	Averaging Period	Existing Discharge Data			TBELs		Water Quality Data & WQBELs						ML	Basis for Permit Requirement
			Permit Limit	Existing Effluent Quality <sup>8</sup>	# of Data Points Detects / Non-Detects	Limit	Basis	Ambient Bkgd. Conc.	Projected Instream Conc.	WQ Std. or GV	WQ Type	Calc. WQBEL	Basis		
Hexavalent Chromium	mg/L	Daily Max	0.11 Total	< 0.02 Total	0 / 50	-	-	-	-	0.011 Dissolved	A(C)	0.011 Total	703.5	*	WQBEL
	The effluent limitation has been reduced to the calculated WQBEL using a metals translator of 1.040, in accordance with EPA document 823-B-96-007. It is unknown if the permittee will be able to achieve the reduced effluent limitation, as the previous laboratory method was not sensitive enough. Because of this, a Schedule of Compliance item has been added. Please note, a more sensitive laboratory method will need to be used to achieve compliance going forward. *The ML for hexavalent chromium using EPA laboratory method 218.6 is 0.95 ug/L or 0.00095 mg/L.														
Total Copper	mg/L	Daily Max	0.12 Total	0.11 Total Max	50 / 10	3.38	40 CFR Part 433, Subpart A	-	-	0.0078 Dissolved	A(C)	0.0081 Total	703.5	-	WQBEL
		Monthly Avg	-	-	-	2.07	40 CFR Part 433, Subpart A	-	-	-	-	-	-	-	No Limitation
	The effluent limitation has been reduced to the calculated WQBEL using a metals translator of 1.042, in accordance with EPA document 823-B-96-007. Based on existing performance, a Schedule of Compliance item has been added. The daily max limitation is protective of the monthly average ELG and monthly average effluent limitations have not been included.														
Total Cyanide	mg/L	Daily Max	0.05	0.04 Max	9 / 51	1.2	40 CFR Part 433, Subpart A	-	-	-	-	-	-	-	Anti-backsliding
		Monthly Avg	-	-	-	0.65	40 CFR Part 433, Subpart A	-	-	-	-	-	-	-	No Limitation
	The existing effluent limitation will remain due to anti-backsliding. The daily max limitation is more protective than the TBEL limitations. The daily max limitation is protective of the monthly average ELG and monthly average effluent limitations have not been included.														
Free Cyanide	mg/L	Daily Max	-	-	-	-	-	-	-	0.005*	A(C)	0.0052	703.5	-	Monitor 750-1.13
	ELGs exist for Total Cyanide, however, Free Cyanide is the form that has applicable WQS. A monitoring requirement has been added to the permit to provide data for evaluation during the next permit review.														
Total Nickel	mg/L	Daily Max	1.0	0.11 Max	18 / 42	3.98	40 CFR Part 433, Subpart A	-	-	0.045	A(C)	0.045	703.5	-	WQBEL
		Daily Avg	-	-	-	2.38	40 CFR Part 433, Subpart A	-	-	-	-	-	-	-	No Limitation
	The effluent limitation has been reduced to the calculated WQBEL using a metals translator of 1.003, in accordance with EPA document 823-B-96-007. Based on the existing performance, a Schedule of Compliance item has been included. The daily max limitation is protective of the monthly average ELG and monthly average effluent limitations have not been included.														

Permittee: Royal Metal Products, Inc.  
 Facility: Royal Metal Products, Inc.  
 SPDES Number: NY0110485  
 USEPA Non-Major/Class 01 Industrial

Date: September 19, 2025 v.1.27  
 Permit Writer: Rashid Ahmed, PE  
 Water Quality Reviewer: Rashid Ahmed, PE  
 Full Technical Review

Outfall #	001	Description of Wastewater: Process Water, Stormwater, and Non-contact Cooling Water													
		Type of Treatment: Evaporation Tanks (as needed)													
Effluent Parameter	Units	Averaging Period	Existing Discharge Data			TBELs		Water Quality Data & WQBELs						ML	Basis for Permit Requirement
			Permit Limit	Existing Effluent Quality <sup>8</sup>	# of Data Points Detects / Non-Detects	Limit	Basis	Ambient Bkgd. Conc.	Projected Instream Conc.	WQ Std. or GV	WQ Type	Calc. WQBEL	Basis		
Total Zinc	mg/L	Daily Max	0.75	0.06 Max	46 / 14	2.61	<a href="#">40 CFR Part 433, Subpart A</a>	-	-	0.067	A(C)	<b>0.072</b>	<a href="#">703.5</a>	-	WQBEL
		Daily avg	-	-	-	1.48	<a href="#">40 CFR Part 433, Subpart A</a>	-	-	-	-	-	-	-	No Limitation
	The effluent limitation has been reduced to the calculated WQBEL using a metals translator of 1.014, in accordance with EPA document 823-B-96-007. The daily max limitation is protective of the monthly average ELG and monthly average effluent limitations have not been included.														
Total Suspended Solids (TSS)	mg/L	Daily Max	<b>25</b>	4.1 Max	21/33	31 Monthly Avg 60 Daily Max	<a href="#">40 CFR Part 433, Subpart A</a>	-	None from sewage, industrial wastes or other wastes that will cause deposition or impair the waters for their best usages.			<a href="#">703.2</a>	-	Anti-backsliding	
	Consistent with TOGS 1.3.1, intermittent stream effluent limits (ISEL) are applied to effluent discharges to streams where little or no streamflow is available for dilution. A Schedule of Compliance item has been included for this parameter.														
pH	SU	Minimum	6.0	7.1 Actual Min	60	6.0	<a href="#">40 CFR Part 433, Subpart A</a>	7.6 <sup>9</sup>	-	6.5 – 8.5	Range	<b>6.5 - 8.5</b>	<a href="#">703.3</a>	-	WQBEL
		Maximum	9.0	8.1 Actual Max	60	9.0	<a href="#">40 CFR Part 433, Subpart A</a>								
	Consistent with TOGS 1.3.1, intermittent stream effluent limits (ISEL) are applied to effluent discharges to streams where little or no streamflow is available for dilution. As such, the water quality standards will be applied as end-of-pipe limitations with no mixing or dilution. Based on existing performance the permittee is expected to meet the reduced limits.														
Tetrachloroethylene	ug/L	Daily max (Action Level)	10	3.0 (max)	2 / 16	-	-	-	-	-	-	-	<a href="#">703.5</a>	-	Discontinued
	A water quality standard for discharges to Class C surface waterbodies does not exist and the action level has been discontinued.														
Total Toxic Organics (TTO)	mg/L	Daily max	-	NS	NS	<b>2.13</b>	<a href="#">40 CFR Part 433, Subpart A</a>	-	-	-	-	-	<a href="#">703.5</a>	-	TBEL
	A new permit limit for total toxic organics (TTO) is required under 40 CFR 433.14. There is no existing effluent data for this parameter. Please see the <a href="#">ELG section</a> below for more information on the applicability of this parameter.														

<sup>9</sup> Since the receiving stream is effluent dominated, the ambient pH is estimated as the average effluent pH value.

Permittee: Royal Metal Products, Inc.  
 Facility: Royal Metal Products, Inc.  
 SPDES Number: NY0110485  
 USEPA Non-Major/Class 01 Industrial

Date: September 19, 2025 v.1.27  
 Permit Writer: Rashid Ahmed, PE  
 Water Quality Reviewer: Rashid Ahmed, PE  
 Full Technical Review

Outfall #	001	Description of Wastewater: Process Water, Stormwater, and Non-contact Cooling Water													
		Type of Treatment: Evaporation Tanks (as needed)													
Effluent Parameter	Units	Averaging Period	Existing Discharge Data			TBELs		Water Quality Data & WQBELs						ML	Basis for Permit Requirement
			Permit Limit	Existing Effluent Quality <sup>8</sup>	# of Data Points Detects / Non-Detects	Limit	Basis	Ambient Bkgd. Conc.	Projected Instream Conc.	WQ Std. or GV	WQ Type	Calc. WQBEL	Basis		
Additional Pollutants Detected															
Temperature	°F	Daily Max	-	59 Actual Max	2	-	-	-	(Non-Trout): The water temperature at the surface of a stream shall not be raised to more than 90F at any point and... shall not be raised or lowered to more than 5F over the temperature that existed before the addition			90	704.2	-	WQBEL
The discharge is a thermal discharge consisting of non-contact cooling water (NCCW). To achieve standards specified in 6 NYCRR Part 704, an effluent temperature limit of 90 °F is specified. This requirement is new and a Schedule of Compliance items has been included.															
Total Mercury	ng/L	Daily Max	-	<0.5	1	-	-	-	-	0.7	H(FC)	-	-	-	DOW 1.3.10
	See <a href="#">Mercury section of this fact sheet</a> .														
Oil & Grease	mg/L	Daily Max	-	-	-	52	40 CFR Part 433, Subpart A	-	No residue attributable to sewage, industrial wastes or other wastes, nor visible oil film nor globules of grease.			703.2	-	TBEL	
		Monthly Avg	-	-	-	26		-							
	A new permit limit for Oil & Grease is required under 40 CFR 433.13. There is no existing effluent data for this parameter. Please see the <a href="#">ELG section</a> below for more information on the applicability of this parameter.														
Nitrogen, Ammonia (as N)	mg/L	Monthly Avg	-	0.17	1	-	-	0.082	1.1	1.1	A(C)	No reasonable potential	703.5	-	No Limitation or Monitoring
The facility does not have significant source of ammonia. The ammonia water quality standard was calculated from a pH of 7.8 (based off the 80th percentile of effluent pH data) and a temperature of 25 °C, consistent with TOGS 1.3.1E. The projected instream concentration was calculated using the effluent concentration of 0.17 mg/L as reported in the application, a multiplier of 6.2, the HEW dilution ratio, and an upstream ambient concentration consistent with TOGS 1.3.1E. The multiplier was selected from EPA's Technical Support Document Chapter 3.3 to account for the number of samples. A comparison of the projected instream concentration to the WQS indicates no reasonable potential to cause or contribute to a WQS violation. Therefore, no WQBEL is specified.															

Outfall #	001	Description of Wastewater: Process Water, Stormwater, and Non-contact Cooling Water														
		Type of Treatment: Evaporation Tanks (as needed)														
Effluent Parameter	Units	Averaging Period	Existing Discharge Data			TBELs		Water Quality Data & WQBELs						ML	Basis for Permit Requirement	
			Permit Limit	Existing Effluent Quality <sup>8</sup>	# of Data Points Detects / Non-Detects	Limit	Basis	Ambient Bkgd. Conc.	Projected Instream Conc.	WQ Std. or GV	WQ Type	Calc. WQBEL	Basis			
Lead (Pb)	mg/L	Daily Max	-	<0.0005	1	0.69	<a href="#">40 CFR 433 Subpart A</a>	-	-	0.0032	A(C)	No reasonable potential	<a href="#">703.5</a>	-	TBEL	
		Daily Avg	-	-	-	0.43	<a href="#">40 CFR 433 Subpart A</a>	-	-	-	-	-	-	-	TBEL	
	The single data point submitted with the application measured non-detect and there is no reasonable potential to violate the water quality standard. An effluent limitation as specified under the ELGs has been added to the permit. The daily average limit has been included as a monthly average and since the limit is a TBEL only, and based on the single non-detect result, the frequency has been set at quarterly. The TBEL limitations must be achieved at permit issuance and a Schedule of Compliance is not allowable.															
Cadmium (Cd)	mg/L	Daily Max	-	<0.0025	1	0.69	<a href="#">40 CFR 433 Subpart A</a>	-	-	0.0017	A(C)	No reasonable Potential	<a href="#">703.5</a>	-	TBEL	
	mg/L	Daily Avg	-	-	-	0.26	<a href="#">40 CFR 433 Subpart A</a>	-	-	-	-	-	-	-	TBEL	
	The single data point submitted with the application measured non-detect and there is no reasonable potential to violate the water quality standard. An effluent limitation as specified under the ELGs has been added to the permit. The daily average limit has been included as a monthly average and since the limit is a TBEL only, and based on the single non-detect result, the frequency has been set at quarterly. The TBEL limitations must be achieved at permit issuance and a Schedule of Compliance is not allowable.															

## USEPA EFFLUENT LIMITATION GUIDELINE (ELG) CALCULATIONS

### [Appendix Link](#)

For the applicable categorical limitations under 40 CFR Part 433 Subpart A, the following basis was used to determine the TBEL:

<b>Outfall</b>	001
<b>40 CFR Part/Subpart</b>	§433, Subpart A
<b>Subpart Name</b>	METAL FINISHING POINT SOURCE CATEGORY

ELG Pollutant	Daily Max Multiplier	Monthly Avg. Multiplier	Production Rate (Million lbs/d)	Daily Max TBEL (mg/L)	Monthly Avg. TBEL (mg/L)	Applicable Level of Control
40 CFR Part 433.13 & 433.14 Subpart A – ELGs for Best Available Technology Economically Achievable (BAT)						
Cadmium, Total	This ELG is not production based.			0.69	0.26	BPT/BAT
Chromium, Total				2.77	1.71	BPT/BAT
Copper, Total				3.38	2.07	BPT/BAT
Lead, Total				0.69	0.43	BPT/BAT
Nickel, Total				3.98	2.38	BPT/BAT
Silver, Total				0.43	0.24	BPT/BAT
Zinc, Total				2.61	1.48	BPT/BAT
Cyanide, Total				1.20	0.65	BPT/BAT
Total Toxic Organics				2.13	-	BPT/BAT
Oil & Grease				52	26	BPT
Total Suspended Solids				60	31	BPT
pH				Range 6.0 – 9.0		BPT
<b>Note:</b> Information on ELG applicability was obtained through the NY-2C application and discussions with the permittee. The permittee incorrectly identified 40 CFR Part 413 as the applicable effluent limitation guideline in their NY-2C application, however after review of the facility SIC codes of 2514 and 3471, 40 CFR Part 433 for metal finishing is appropriate.						



## Appendix: Regulatory and Technical Basis of Permit Authorizations

The Appendix is meant to supplement the fact sheet for multiple types of SPDES permits. Portions of this Appendix may not be applicable to this specific permit.

### Regulatory References

The provisions of the permit are based largely upon 40 CFR 122 subpart C and 6 NYCRR Part 750 and include monitoring, recording, reporting, and compliance requirements, as well as general conditions applicable to all SPDES permits. Below are the most common citations for the requirements included in SPDES permits:

- Clean Water Act (CWA) 33 section USC 1251 to 1387
- Environmental Conservation Law (ECL) Articles 17 and 70
- Federal Regulations
  - 40 CFR, Chapter I, subchapters D, N, and O
- State environmental regulations
  - 6 NYCRR Part 621
  - 6 NYCRR Part 621
  - 6 NYCRR Parts 700 - 704 – Best use and other requirements applicable to water classes
  - 6 NYCRR Parts 800 – 941 - Classification of individual surface waters
- NYSDEC water program policy, referred to as Technical and Operational Guidance Series (TOGS)
- USEPA Office of Water Technical Support Document for Water Quality-based Toxics Control, March 1991, Appendix E

The following is a quick guide to the references used within the fact sheet:

The following is a quick guide to the references used within the fact sheet:

SPDES Permit Requirements	Regulatory Reference
Anti-backsliding	6 NYCRR 750-1.10(c)
Best Management Practices (BMPs) for CSOs	6 NYCRR 750-2.8(a)(2)
Environmental Benefits Permit Strategy (EBPS)	6 NYCRR 750-1.18, NYS ECL 17-0817(4), TOGS 1.2.2 (revised January 25, 2012)
Exceptions for Type I SSO Outfalls (bypass)	6 NYCRR 750-2.8(b)(2), 40 CFR 122.41
Mercury Multiple Discharge Variance	Division of Water Program Policy 1.3.10 (DOW 1.3.10)
Mixing Zone and Critical Water Information	TOGS 1.3.1 & Amendments
PCB Minimization Program	40 CFR Part 132 Appendix F Procedure 8, 6 NYCRR 750-1.13(a) and 750-1.14(f), and TOGS 1.2.1
Pollutant Minimization Program (PMP)	6 NYCRR 750-1.13(a), 750-1.14(f), TOGS 1.2.1
Schedules of Compliance	6 NYCRR 750-1.14
Sewage Pollution Right to Know (SPRTK)	NYS ECL 17-0826-a, 6 NYCRR 750-2.7
State Administrative Procedure Act (SAPA)	State Administrative Procedure Act Section 401(2), 6 NYCRR 621.11(l)
State Environmental Quality Review (SEQR)	6 NYCRR Part 617
USEPA Effluent Limitation Guidelines (ELGs)	40 CFR Parts 405-471
USEPA National CSO Policy	33 USC Section 1342(q)
Whole Effluent Toxicity (WET) Testing	TOGS 1.3.2
General Provisions of a SPDES Permit Department Request for Additional Information	NYCRR 750-2.1(i)

### Outfall and Receiving Water Information

#### Impaired Waters

The [NYS 303\(d\) List of Impaired/TMDL Waters](#) identifies waters where specific best usages are not fully supported. The state must consider the development of a Total Maximum Daily Load (TMDL) or other strategy to reduce the input of the specific pollutant(s) that restrict waterbody uses, in order to restore and protect such uses. SPDES permits must include effluent limitations necessary to implement a waste load allocation (WLA) of an EPA-approved TMDL (6 NYCRR 750-1.11(a)(5)(ii)), if applicable. In accordance with 6 NYCRR 750-1.13(a), permittees discharging to waters which are on the list but do not yet have a TMDL developed may be required to perform additional monitoring for the parameters causing the impairment. Accurate monitoring data is needed

to determine the existing capabilities of the wastewater treatment plants and to assure that WLAs are allocated equitably.

### Existing Effluent Quality

The existing effluent quality is determined from a statistical evaluation of effluent data in accordance with TOGS 1.2.1 and the USEPA Office of Water, Technical Support Document for Water Quality-based Toxics Control, March 1991, Appendix E (TSD). The existing effluent quality is equal to the 95<sup>th</sup> (monthly average) and 99<sup>th</sup> (daily maximum) percentiles of the lognormal distribution of existing effluent data. When there are greater than three non-detects, a delta-lognormal distribution is assumed, and delta-lognormal calculations are used to determine the monthly average and daily maximum pollutant concentrations. Statistical calculations are not performed for parameters where there are less than ten data points. If additional data is needed, a monitoring requirement may be specified either through routine monitoring or a short-term high intensity monitoring program. The [Pollutant Summary Table](#) identifies the number of sample data points available.

### Permit Requirements

#### Basis for Effluent Limitations

Sections 101, 301, 304, 308, 401, 402, and 405 of the CWA and Titles 5, 7, and 8 of Article 17 ECL, as well as their implementing federal and state regulations, and related guidance, provide the basis for the effluent limitations and other conditions in the permit.

When conducting a full technical review of an existing permit, the previous effluent limitations form the basis for the next permit. Existing effluent quality is evaluated against the existing effluent limitations to determine if these should be continued, revised, or deleted. Generally, existing limitations are continued unless there are changed conditions at the facility, the facility demonstrates an ability to meet more stringent limitations, or in response to updated regulatory requirements. Pollutant monitoring data is also reviewed to determine the presence of additional contaminants that should be included in the permit based on a reasonable potential analysis to cause or contribute to a water quality standards violation.

#### Anti-backsliding

Anti-backsliding requirements are specified in the CWA sections 402(o) and 303(d)(4), ECL 17-0809, and regulations at 40 CFR 122.44(I) and 6 NYCRR 750-1.10(c) and (d). Generally, the relaxation of effluent limitations in permits is prohibited unless one of the specified exceptions applies, which will be cited on a case-by-case basis in this fact sheet. Consistent with current case law<sup>10</sup> and USEPA interpretation<sup>11</sup> anti-backsliding requirements do not apply should a revision to the final effluent limitation take effect before the scheduled date of compliance for that final effluent limitation.

#### Antidegradation Policy

New York State implements the antidegradation portion of the CWA based upon two documents: (1) Organization and Delegation Memorandum #85-40, "Water Quality Antidegradation Policy" (September 9, 1985); and, (2) TOGS 1.3.9, "Implementation of the NYSDEC Antidegradation Policy – Great Lakes Basin (Supplement to Antidegradation Policy dated September 9, 1985) (undated)." The permit for the facility contains effluent limitations which ensure that the existing best usage of the receiving waters will be maintained. To further support the antidegradation policy, SPDES applications have been reviewed in accordance with the State Environmental Quality Review Act (SEQR) as prescribed by 6 NYCRR Part 617.

#### Effluent Limitations

In developing a permit, the Department determines the technology-based effluent limitations (TBELs) and then evaluates the water quality expected to result from technology controls to determine if any exceedances of water quality criteria in the receiving water might result. If there is a reasonable potential for exceedances of water quality criteria to occur, water quality-based effluent limitations (WQBELs) are developed. A WQBEL is designed

<sup>10</sup> American Iron and Steel Institute v. Environmental Protection Agency, 115 F.3d 979, 993 n.6 (D.C. Cir. 1997)

<sup>11</sup> U.S. EPA, Water Quality Standards; Establishment of Numeric Criteria for Priority Toxic Pollutants for the State of California; 65 Fed. Reg. 31682, 31704 (May 18, 2000); Proposed Water Quality Guidance for the Great Lakes System, 58 Fed. Reg. 20802, 20837 & 20981 (April 16, 1993)

to ensure that the water quality standards of receiving waters are met. In general, the CWA requires that the effluent limitations for a particular pollutant are the more stringent of either the TBEL or WQBEL.

### *Technology-based Effluent Limitations (TBELs) for Industrial Facilities*

A TBEL requires a minimum level of treatment for industrial point sources based on currently available treatment technologies or Best Management Practices (BMPs). CWA sections 301(b) and 402, ECL sections 17-0509, 17-0809 and 17-0811, and 6 NYCRR 750-1.11 require technology-based controls on effluents. TBELs are set based upon an evaluation of New Source Performance Standards (NSPS), Best Available Technology Economically Achievable (BAT), Best Conventional Pollutant Control Technology (BCT), Best Practicable Technology Currently Available (BPT), and Best Professional Judgment (BPJ).

### USEPA Effluent Limitation Guidelines (ELGs) Applicable to Facility

In many cases, BPT, BCT, BAT and NSPS limitations are based on effluent guidelines developed by USEPA for specific industries, as promulgated under 40 CFR Parts 405-471. Applicable guidelines, pollutants regulated by these guidelines, and the effluent limitation derivation for facilities subject to these guidelines is in the [USEPA Effluent Limitation Guideline Calculations Table](#).

### Best Professional Judgement (BPJ)

For substances that are not explicitly limited by regulations, the permit writer is authorized to use BPJ in developing TBELs. Consistent with section 402(a)(1) of the CWA, and NYS ECL section 17-0811, the DEC is authorized to issue a permit containing "any further limitations necessary to ensure compliance with water quality standards adopted pursuant to state law". BPJ limitations may be set on a case-by-case basis using any reasonable method that takes into consideration the criteria set forth in 40 CFR 125.3. Applicable state regulations include 6 NYCRR 750-1.11. The BPJ limitation considers the existing technology present at the facility, the statistically calculated existing effluent quality for that parameter, and any unique or site-specific factors relating to the facility. Technology limitations generally achievable for various treatment technologies are included in TOGS 1.2.1, Attachment C. These limitations may be used for the listed parameters when the technology employed at the facility is listed.

### *Water Quality-Based Effluent Limitations (WQBELs)*

In addition to the TBELs, permits must include additional or more stringent effluent limitations and conditions, including those necessary to protect water quality. CWA sections 101 and 301(b)(1)(C), 40 CFR 122.44(d)(1), and 6 NYCRR Parts 750-1.11 require that permits include limitations for all pollutants or parameters which are or may be discharged at a level which may cause or contribute to an exceedance of any State water quality standard adopted pursuant to NYS ECL 17-0301. Additionally, 6 NYCRR Part 701.1 prohibits the discharge of pollutants that will cause impairment of the best usages of the receiving water as specified by the water classifications at the location of discharge and at other locations that may be affected by such discharge. Water quality standards can be found under 6 NYCRR Parts 700-704. The limitations must be stringent enough to ensure that water quality standards are met at the point of discharge and in downstream waters and must be consistent with any applicable WLA which may be in effect through a TMDL for the receiving water. These and other requirements are summarized in TOGS 1.1.1, 1.3.1, 1.3.2, 1.3.5 and 1.3.6. The DEC considers a mixing zone analysis, critical flows, and reasonable potential analysis when developing a WQBEL.

### Critical Flows

In accordance with TOGS 1.2.1 and 1.3.1, WQBELs are developed using dilution ratios that relate the critical low flow condition of the receiving waterbody to the critical effluent flow. The critical low flow condition used in the dilution ratio will be different depending on whether the limitations are for aquatic or human health protection. For chronic aquatic protection, the critical low flow condition of the waterbody is typically represented by the 7Q10 flow and is calculated as the lowest average flow over a 7-day consecutive period within 10 years. For acute aquatic protection, the critical low flow condition is typically represented by the 1Q10 and is calculated as the lowest 1-day flow within 10 years. However, NYSDEC considers using 50% of the 7Q10 to be equivalent

to the 1Q10 flow. For the protection of human health, the critical low flow condition is typically represented by the 30Q10 flow and is calculated as the lowest average flow over a 30-day consecutive period within 10 years. However, NYSDEC considers using  $1.2 \times 7Q10$  to be equivalent to the 30Q10. The 7Q10 or 30Q10 flow is used with the critical effluent flow to calculate the dilution ratio. The critical effluent flow can be the maximum daily flow reported on the permit application, the maximum of the monthly average flows from discharge monitoring reports for the past three years, or the facility design flow. When more than one applicable standard exists for aquatic or human health protection for a specific pollutant, a reasonable potential analysis is conducted for each applicable standard and corresponding critical flow to ensure effluent limitations are sufficiently stringent to ensure all applicable water quality standards are met as required by 40 CFR 122.44(d)(1)(i). For brevity, the pollutant summary table reports the results of the most conservative scenario.

#### Reasonable Potential Analysis (RPA)

The Reasonable Potential Analysis (RPA) is a statistical estimation process, outlined in the 1991 USEPA Technical Support Document for Water Quality-based Toxics Control (TSD), Appendix E. This process uses existing effluent quality data and statistical variation methodology to project the maximum amounts of pollutants that could be discharged by the facility. This projected instream concentration (PIC) is calculated using the appropriate ratio and compared to the water quality standard (WQS). When the RPA process determines the WQS may be exceeded, a WQBEL is required. The procedure for developing WQBELs includes the following steps:

- 1) identify the pollutants present in the discharge(s) based upon existing data, sampling data collected by the permittee as part of the permit application or a short-term high intensity monitoring program, or data gathered by the DEC;
- 2) identify water quality criteria applicable to these pollutants;
- 3) determine if WQBELs are necessary (i.e. reasonable potential analysis (RPA)). The RPA will utilize the procedure outlined in Chapter 3.3.2 of EPA's Technical Support Document (TSD). As outlined in the TSD, for parameters with limited effluent data the RPA may include multipliers to account for effluent variability; and,
- 4) calculate WQBELs (if necessary). Factors considered in calculating WQBELs include available dilution of effluent in the receiving water, receiving water chemistry, and other pollutant sources.

The DEC uses modeling tools to estimate the expected concentrations of the pollutant in the receiving water and develop WQBELs. These tools were developed in part using the methodology referenced above. If the estimated concentration of the pollutant in the receiving water is expected to exceed the ambient water quality standard or guidance value (i.e. numeric interpretation of a narrative water quality standard), then there is a reasonable potential that the discharge may cause or contribute to an exceedance of any State water quality standard adopted pursuant to NYS ECL 17-0301. If a TMDL is in place, the facility's WLA for that pollutant is applied as the WQBEL.

For carbonaceous and nitrogenous oxygen demanding pollutants, the DEC uses a model which incorporates the Streeter-Phelps equation. The equation relates the decomposition of inorganic and organic materials along with oxygen reaeration rates to compute the downstream dissolved oxygen concentration for comparison to water quality standards.

The Division of Water has been using the TMDL approach in permit limit development for the control of toxic substances. Since the early 1980's, the loading capacity for specific pollutants has been determined for each drainage basin. Water quality-limiting segments and pollutants have been identified, TMDLs, wasteload allocations and load allocations have been developed, and permits with water quality-based effluent limits have been issued. In accordance with TOGS 1.3.1, the Division of Water implements a Toxics Reduction Strategy which is committed to the application of the TMDL process using numeric, pollutant-specific water quality standards through



the Watershed Approach. The Watershed Approach accounts for the cumulative effect of multiple discharges of conservative toxic pollutants to ensure water quality standards are met in downstream segments.

#### *Whole Effluent Toxicity (WET) Testing:*

WET tests use small vertebrate and invertebrate species to measure the aggregate toxicity of an effluent. There are two different durations of toxicity tests: acute and chronic. Acute toxicity tests measure survival over a 96-hour test exposure period. Chronic toxicity tests measure reductions in survival, growth, and reproduction over a 7-day exposure. TOGS 1.3.1 includes guidance for determining when aquatic toxicity testing should be included in SPDES permits. The authority to require toxicity testing is in 6NYCRR 702.9. TOGS 1.3.2 describes the procedures which should be followed when determining whether to include toxicity testing in a SPDES permit and how to implement a toxicity testing program. Per TOGS 1.3.2, WET testing may be required when any one of the following seven criteria are applicable:

1. There is the presence of substances in the effluent for which ambient water quality criteria do not exist.
2. There are uncertainties in the development of TMDLs, WLAs, and WQBELs, caused by inadequate ambient and/or discharge data, high natural background concentrations of pollutants, available treatment technology, and other such factors.
3. There is the presence of substances for which WQBELs are below analytical detectability.
4. There is the possibility of complex synergistic or additive effects of chemicals, typically when the number of metals or organic compounds discharged by the permittee equals or exceeds five.
5. There are observed detrimental effects on the receiving water biota.
6. Previous WET testing indicated a problem.
7. POTWs which exceed a discharge of 1 MGD. Facilities of less than 1 MGD may be required to test, e.g., POTWs <1 MGD which are managing industrial pretreatment programs.

#### *Monitoring Requirements*

CWA section 308, 40 CFR 122.44(i), 6 NYCRR 750-1.13, and 750-2.5 require that monitoring be included in permits to determine compliance with effluent limitations. Additional effluent monitoring may also be required to gather data to determine if effluent limitations may be required. The permittee is responsible for conducting the monitoring and reporting results on Discharge Monitoring Reports (DMRs). The permit contains the monitoring requirements for the facility. Monitoring frequency is based on the minimum sampling necessary to adequately monitor the facility's performance and characterize the nature of the discharge of the monitored flow or pollutant. Variable effluent flows and pollutant levels may be required to be monitored at more frequent intervals than relatively constant effluent flow and pollutant levels (6 NYCRR 750-1.13). For industrial facilities, sampling frequency is based on guidance provided in TOGS 1.2.1. For municipal facilities, sampling frequency is based on guidance provided in TOGS 1.3.3.

#### *Other Conditions*

##### *Mercury*

The multiple discharge variance (MDV) for mercury was developed in accordance with 6 NYCRR 702.17(h) "to address widespread standard or guidance value attainment issues including the presence of a ubiquitous pollutant or naturally high levels of a pollutant in a watershed." The first MDV was issued in October 2010, and subsequently revised and reissued in 2015; each subsequent iteration of the MDV is designed to build off the previous version, to make reasonable progress towards the water quality standard (WQS) of 0.7 ng/L dissolved mercury. The MDV is necessary because human-caused conditions or sources of mercury prevent attainment of the WQS and cannot be remedied (i.e., mercury is ubiquitous in New York waters at levels above the WQS and compliance with a water quality based effluent limitation (WQBEL) for mercury cannot be achieved with demonstrated effluent treatment technologies). The DEC has determined that the MDV is consistent with the protection of public health, safety, and welfare. During the effective period of this MDV, any increased risks to human health are mitigated by fish consumption advisories issued periodically by the NYSDOH.

All surface water SPDES permittees are eligible for authorization by the MDV provided they meet the requirements specified in DOW 1.3.10.

### Schedules of Compliance

Schedules of compliance are included in accordance with 40 CFR Part 132 Attachment F, Procedure 9, 40 CFR 122.47 and 6 NYCRR 750-1.14. Schedules of compliance are intended to, in the shortest reasonable time, achieve compliance with applicable effluent standards and limitations, water quality standards, and other applicable requirements. Where the time for compliance is more than nine months, the schedule of compliance must include interim requirements and dates for their achievement. If the time necessary to complete the interim milestones is more than nine months, and not readily divisible into stages for completion, progress reports must be required.

### Schedule(s) of Additional Submittals

Schedules of Additional Submittals are used to summarize the deliverables required by the permit not identified in a separate Schedule of Compliance.

### Best Management Practices (BMP) for Industrial Facilities

BMP plans are authorized for inclusion in NPDES permits pursuant to Sections 304(e) and 402 (a)(1) of the Clean Water Act, and 6 NYCRR 750-1.14(f). The regulations pertaining to BMPs are promulgated under 40 CFR Part 125, Subpart K. These regulations specifically address surface water discharges.