

State Pollutant Discharge Elimination System (SPDES) DISCHARGE PERMIT

SIC Code: 4952	NAICS Code:	221320		SPDES Number:	NY0031089
Discharge Class (CL):	07			DEC Number:	7-4920-00026/00001
Toxic Class (TX):	N			Effective Date (EDP):	
Major-Sub Drainage Basin:	06 - 03			Expiration Date (ExDP):	
Water Index Number:	SR-Pa 1	Item No.:	931 - 1	Madification Dates (EDDM)	
Compact Area:	SRBC			Modification Dates (EDPM):	

This SPDES permit is issued in compliance with Title 8 of Article 17 of the Environmental Conservation Law of New York State and in compliance with the Clean Water Act, as amended, (33 U.S.C. '1251 et.seq.)

PERMITTEE NAME AND ADDRESS							
Name:	Village of Waverly Attention: Village Mayor Betriek Ayree						
Street:	424 Cayuta Avenue		Village Mayor Patrick Ayres				
City:	Waverly	State:	NY	Zip Code:	14892		
Email:	payres@villageofwaverly.com	Phone:	607-56	5-8106			

is authorized to discharge from the facility described below:

FACILITY NAME, ADDRESS, AND PRIMARY OUTFALL																
Name:	Village	illage of Waverly Sewage Treatment Plant														
Address / Location:	424 Ca	4 Cayuta Avenue County: Tioga														
City:	Waver	Waverly State: NY						Zip Code	Zip Code:		14892					
Facility Location:		Latitude:	42	2 °	00	,	06	" N	& Longitude:	76	0		31	,	29	"W
Primary Outfall No.:		Latitude:	42	2 °	00	,	04	" N	& Longitude:	76	0		31	,	22	" W
Outfall Description:	ption: Treated Sanitary Receiving Water: Cayuta Creek						Class:	В	3	St	an	dard:	В			

in accordance with: effluent limitations; monitoring and reporting requirements; other provisions and conditions set forth in this permit; and 6 NYCRR Part 750-1 and 750-2.

This permit and the authorization to discharge shall expire on midnight of the expiration date shown above and the permittee shall not discharge after the expiration date unless this permit has been renewed or extended pursuant to law. To be authorized to discharge beyond the expiration date, the permittee shall apply for permit renewal not less than 180 days prior to the expiration date shown above.

DISTRIBUTION:

BWP Permit Coordinator (permit.coordinator@dec.ny.gov)

BWP Permit Writer

RWE

RPA

EPA Region II (Region2_NPDES@epa.gov)

NYSEFC (Nancy.myers@efc.ny.gov)

Permit Administrator:							
Administrator:							
Address:	625 Broadway Albany, NY 12233-1750						
Signature		Date					

Contents

DEFINITIONS	3
PERMIT LIMITS, LEVELS AND MONITORING	4
MERCURY MINIMIZATION PROGRAM (MMP) - Type II	6
DISCHARGE NOTIFICATION REQUIREMENTS	g
MINI INDUSTRIAL PRETREATMENT PROGRAM	10
SCHEDULE OF COMPLIANCE	11
MONITORING LOCATIONS	12
GENERAL REQUIREMENTS	13
RECORDING, REPORTING AND ADDITIONAL MONITORING REQUIREMENTS	15
E. Schedule of Additional Submittals:	15

SPDES Number: **NY0031089** Page 3 of 16 v.1.25

DEFINITIONS

TERM	DEFINITION
7-Day Geo Mean	The highest allowable geometric mean of daily discharges over a calendar week.
7-Day Average	The average of all daily discharges for each 7-days in the monitoring period. The sample measurement is the highest of the 7-day averages calculated for the monitoring period.
12-Month Rolling Average (12 MRA)	The current monthly value of a parameter, plus the sum of the monthly values over the previous 11 months for that parameter, divided by the number of months for which samples were collected in the 12-month period.
30-Day Geometric Mean	The highest allowable geometric mean of daily discharges over a calendar month, calculated as the antilog of: the sum of the log of each of the daily discharges measured during a calendar month divided by the number of daily discharges measured during that month.
Action Level	Action level means a monitoring requirement characterized by a numerical value that, when exceeded, triggers additional permittee actions and department review to determine if numerical effluent limitations should be imposed.
Compliance Level / Minimum Level	A compliance level is an effluent limitation. A compliance level is given when the water quality evaluation specifies a Water Quality Based Effluent Limit (WQBEL) below the Minimum Level. The compliance level shall be set at the Minimum Level (ML) for the most sensitive analytical method as given in 40 CFR Part 136, or otherwise accepted by the Department.
Daily Discharge	The discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for the purposes of sampling. For pollutants expressed in units of mass, the 'daily discharge' is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurement, the 'daily discharge' is calculated as the average measurement of the pollutant over the day.
Daily Maximum	The highest allowable Daily Discharge.
Daily Minimum	The lowest allowable Daily Discharge.
Effective Date of Permit (EDP or EDPM)	The date this permit is in effect.
Effluent Limitations	Effluent limitation means any restriction on quantities, quality, rates and concentrations of chemical, physical, biological, and other constituents of effluents that are discharged into waters of the state.
Expiration Date of Permit (ExDP)	The date this permit is no longer in effect.
Instantaneous Maximum	The maximum level that may not be exceeded at any instant in time.
Instantaneous Minimum	The minimum level that must be maintained at all instants in time.
Monthly Average	The highest allowable average of daily discharges over a calendar month, calculated as the sum of each of the daily discharges measured during a calendar month divided by the number of daily discharges measured during that month.
Outfall	The terminus of a sewer system, or the point of emergence of any waterborne sewage, industrial waste or other wastes or the effluent therefrom, into the waters of the State.
Range	The minimum and maximum instantaneous measurements for the reporting period must remain between the two values shown.
Receiving Water	The classified waters of the state to which the listed outfall discharges.
Sample Frequency / Sample Type / Units	See NYSDEC's "DMR Manual for Completing the Discharge Monitoring Report for the SPDES" for information on sample frequency, type and units.

PERMIT LIMITS, LEVELS AND MONITORING

OUTFALL	LIMITATIONS APPLY	RECEIVING WATER	EFFECTIVE	EXPIRING
001	Year round unless otherwise noted	Cayuta Creek		

	EFF	LUENT L	IMITATIO	MONITORING REQUIREMENTS						
PARAMETER	Туре	Limit	Units	Limit	Units	Sample Frequency	Sample Type	Loca	etion Eff.	FN
Flow	Monthly Average	0.8	MGD			Continuous	Recorder		Х	
	Daily Minimum	6.0	SU			1/5	0.1		, , , , , , , , , , , , , , , , , , ,	
pΗ	Daily Maximum	9.0	SU			1/Day	Grab		Х	
Temperature	Daily Maximum	Monitor	°F			1/Day	Grab		Х	
BOD ₅	Monthly Average	30	mg/L	200	lbs/d	2/Month	6-hr. Comp.	Х	Х	1
BOD ₅	7-Day Average	45	mg/L	300	lbs/d	2/Month	6-hr. Comp.		X	
Total Suspended Solids (TSS)	Monthly Average	30	mg/L	200	lbs/d	2/Month	6-hr. Comp.	х	Х	1
Total Suspended Solids (TSS)	7-Day Average	45	mg/L	300	lbs/d	2/Month	6-hr. Comp.		Х	
Settleable Solids	Daily Maximum	0.3	mL/L			1/Day	Grab		Х	
Nitrogen, Ammonia (as NH₃)	Monthly Average	4.6	mg/L			2/Month	Grab		Х	
Nitrogen, Nitrate (as N)	Monthly Average	Monitor	mg/L	Monitor	lbs/d	2/Month	6-hr. Comp.	Х	Х	
Nitrogen, Nitrite (as N)	Monthly Average	Monitor	mg/L	Monitor	lbs/d	2/Month	6-hr. Comp.	Х	Х	
Total Nitrogen (as N)	Monthly Average	Monitor	mg/L	Monitor	lbs/d	2/Month	Calculated		Χ	2
Total Nitrogen (as N)	Monthly Total			Monitor	lbs/m	1/Month	Calculated		Х	3
Total Nitrogen (as N)	12-Month Rolling Total			42,000	lbs/yr	1/Month	Calculated		Х	4
Total Phosphorus (as P)	Monthly Average	1.0	mg/L	Monitor	lbs/d	2/Month	6-hr. Comp.	Х	Х	5
Total Phosphorus (as P)	Monthly Total		mg/L	Monitor	lbs/mo	1/Month	Grab		Х	3
Total Phosphorus (as P)	12 Rolling Total			2,050	lbs/yr	1/Month	Calculated		Х	4,5
Total Mercury	Daily Maximum	50	ng/L			2/Year	Grab	Х	Χ	
Total Mercury	12 MRA	12	ng/L			2/Year	Calculated		Х	
EFFLUENT DISINFECTION Required Seasonal from May	1st - October 31st	Limit	Units	Limit	Units	Sample Frequency	Sample Type	Inf.	Eff.	FN
Coliform, Fecal	30-Day Geometric Mean	200	No./ 100 mL			2/Month	Grab		Х	
Coliform, Fecal	7-Day Geometric Mean	400	No./ 100 mL			2/Month	Grab		Х	
Chlorine, Total Residual	Daily Maximum	0.7	mg/L			1/Day	Grab		Х	6

FOOTNOTES ON NEXT PAGE

SPDES Number: NY0031089

Page 5 of 16 v.1.25

FOOTNOTES:

- 1. Effluent shall not exceed 15% and 15% of influent concentration values for BOD₅ & TSS respectively.
- 2. Total Nitrogen (as N) = [Total Kjeldahl Nitrogen (TKN), as N] + [Nitrite (NO₂), as N] + [Nitrate (NO₃), as N].
- 3. Total Nitrogen (as N) and Total Phosphorus (as P), monthly total (lbs/month) is calculated as the monthly average load (lbs/day), multiplied by the number of days in the month.
- 4. Total Nitrogen (as N) and Total Phosphorus (as P), 12-month rolling total (lbs/year), is calculated as the current month load added to the month loads from the previous eleven months.
- 5. This is a final effluent limitation. See Schedule of Compliance for any applicable interim effluent limitations.
- 6. Sampling and reporting for total residual chlorine are only necessary if chlorine is used for disinfection, elsewhere in the treatment process, or the facility otherwise has reasonable potential to discharge chlorine. Otherwise, the permittee shall report NODI-9 on the DMR.



SPDES Number: **NY0031089** Page 6 of 16 v.1.25

MERCURY MINIMIZATION PROGRAM (MMP) - Type II

- 1. <u>General</u> The permittee must develop, implement, and maintain a mercury minimization program (MMP), containing the elements set forth below, to reduce mercury effluent levels with the goal of achieving the WQBEL of 0.7 ng/L.
- 2. MMP Elements The MMP must be a written document and must include any necessary drawings or maps of the facility and/or collection system. Other related documents already prepared for the facility may be used as part of the MMP and may be incorporated by reference. At a minimum, the MMP must include the following elements as described in detail below:
 - a. <u>Monitoring</u> Monitoring at Outfall, influent and other locations tributary to compliance points shall be performed using either USEPA Method 1631 or another sufficiently sensitive method, as approved under 40 CFR Part 136¹. Monitoring of raw materials, equipment, treatment residuals, and other non-wastewater/non-stormwater substances may be performed using other methods as appropriate. Monitoring must be coordinated so that the results can be effectively compared between locations.

Minimum required monitoring is as follows:

- i. <u>Sewage Treatment Plant Influent and/or Effluent</u> The permittee must collect samples at the location(s) and frequency as specified in the SPDES permit limitations table.
- ii. <u>Key Locations and Potential Mercury Sources</u> The permittee must sample *key locations*, chosen to identify *potential mercury sources*, at least semi-annually. Sampling of discharges from dental facilities in compliance with 6 NYCRR 374.4 is not required.
- iii. <u>Hauled Wastes</u> The permittee must establish procedures for the acceptance of hauled waste to ensure the hauled waste is not a potential mercury source. Loads which may exceed 500 ng/L,² must receive approval from the Department prior to acceptance.
- iv. <u>Decreased Monitoring Requirements</u> The permittee has an EEQ at or below 12 ng/L and the permit includes the following requirements:
 - 1) Reduced requirements
 - a) Conduct influent monitoring, sampling semi-annually, in lieu of monitoring within the collection system, such as at *key locations*; and
 - b) Conduct effluent compliance sampling semi-annually.
 - 2) If a facility with reduced requirements reports discharges above 12 ng/L for two of four consecutive effluent samples, the Department may undertake a Department-initiated modification to remove the allowance of reduced requirements.
 - 3) Under the decreased permit requirements, the facility must continue to conduct a status report, as applicable in accordance with 2.c of this MMP, to determine if any waste streams have changed.
- v. Additional monitoring must be completed as required elsewhere in this permit (e.g., locations tributary to compliance points).
- b. Control Strategy The control strategy must contain the following minimum elements:
 - i. <u>Pretreatment/Sewer Use Law</u> The permittee must review pretreatment program requirements and the Sewer Use Law (SUL) to ensure it is up-to-date and enforceable with applicable permit requirements and will support efforts to achieve a dissolved mercury concentration of 0.70 ng/L in the effluent.
 - ii. Monitoring and Inventory/Inspections -
 - 1) Monitoring shall be performed as described in 2.a above. As mercury sources are found, the permittee must enforce its sewer use law to track down and minimize these sources.
 - 2) The permittee must inventory and/or inspect users of its system as necessary to support the MMP.
 - a) Dental Facilities
 - 1. The permittee must maintain an inventory of each dental facility.
 - 2. The permittee must inspect each dental facility at least once every five years to verify compliance with the wastewater treatment operation, maintenance, and notification elements of 6 NYCRR 374.4. Alternatively, the permittee may develop and implement an

¹ Outfall monitoring must be conducted using the methods specified in Table 8 of DOW 1.3.10.

²A level of 0.2 mg/L (200,000 ng/L) or more is considered hazardous per 40 CFR Part 261.11. 500 ng/L is used here to alert the permittee that there is an unusual concentration of mercury and that it will need to be managed appropriately.

SPDES Number: **NY0031089** Page 7 of 16 v.1.25

outreach program,³ which informs users of their responsibilities, and collect the "Amalgam Waste Compliance Report for Dental Dischargers" form, as needed, to satisfy the inspection requirements. The permittee must conduct the outreach program at least once every five years and ensure the "Amalgam Waste Compliance Report for Dental Dischargers" are submitted by new users, as necessary. The outreach program could be supported by a subset of site inspections.

- 3. A file shall be maintained containing documentation demonstrating compliance with 2.b.ii.2)a) above. This file shall be available for review by the Department representatives and copies shall be provided upon request.
- b) Other potential mercury sources
 - 1. The permittee must maintain an inventory of other potential mercury sources.
 - 2. The permittee must inspect other potential mercury sources once every five years. Alternatively, the permittee may develop and implement an outreach program which informs users of their responsibilities as potential mercury sources. The permittee must conduct the outreach program at least once every five years. The outreach program should be supported by a subset of site inspections.
 - 3. A file shall be maintained containing documentation demonstrating compliance with 2.b.ii.2)b) above. This file shall be available for review by the Department representatives and copies shall be provided upon request.
- iii. <u>Systems with CSO & Type II SSO Outfalls</u> Permittees must prioritize *potential mercury sources* upstream of CSOs and Type II SSOs for mercury reduction activities and/or controlled-release discharge.
- iv. <u>Equipment and Materials</u> Equipment and materials (e.g., thermometers, thermostats) used by the permittee, which may contain mercury, must be evaluated by the permittee. As equipment and materials containing mercury are updated/replaced, the permittee must use mercury-free alternatives, if possible.
- v. <u>Bulk Chemical Evaluation</u> For chemicals, used at a rate which exceeds 1,000 gallons/year or 10,000 pounds/year, the permittee must obtain a manufacturer's certificate of analysis, a chemical analysis performed by a certified laboratory, and/or a notarized affidavit which describes the substances' mercury concentration and the detection limit achieved. If possible, the permittee must only use bulk chemicals utilized in the wastewater treatment process which contain <10 ppb mercury.
- c. <u>Status Report</u> An annual status report must be developed and maintained on site, in accordance with the <u>Schedule of Additional Submittals</u>, summarizing:
 - i. All MMP monitoring results for the previous reporting period;
 - ii. A list of known and potential mercury sources
 - 1) If the permittee meets the criteria for MMP Type IV, the permittee must notify the Department for a permittee-initiated modification;
 - iii. All actions undertaken, pursuant to the control strategy, during the previous reporting period;
 - iv. Actions planned, pursuant to the control strategy, for the upcoming reporting period; and
 - v. Progress towards achieving a dissolved mercury concentration of 0.70 ng/L in the effluent (e.g., summarizing reductions in effluent concentrations as a result of the control strategy implementation and/or installation/modification of a treatment system).

The permittee must maintain a file with all MMP documentation. The file must be available for review by Department representatives and copies must be provided upon request in accordance with 6 NYCRR 750-2.1(i) and 750-2.5(c)(4).

- 3. MMP Modification The MMP must be modified whenever:
 - a. Changes at the facility, or within the collection system, increase the potential for mercury discharges;
 - b. Effluent discharges exceed the current permit limitation(s); or
 - c. A letter from the Department identifies inadequacies in the MMP.

³ For example, the outreach program could include education about sources of mercury and what to do if a mercury source is found.

⁴ The form, "Amalgam Waste Compliance Report for Dental Dischargers," can be found here: https://www.dec.ny.gov/docs/water_pdf/dentalform.pdf

SPDES Number: **NY0031089** Page 8 of 16 v.1.25

The Department may use information in the status reports, as applicable in accordance with 2.c of this MMP, to determine if the permit limitations and MMP Type is appropriate for the facility.

DEFINITIONS:

Key location – a location within the collection/wastewater system (e.g. including but not limited to a specific manhole/access point, tributary sewer/wastewater connection, or user discharge point) identified by the permittee as a potential mercury source. The permittee may adjust key locations based upon sampling and/or best professional judgement.

Potential mercury source – a source identified by the permittee that may reasonably be expected to have total mercury contained in the discharge. Some potential mercury sources include switches, fluorescent lightbulbs, cleaners, degreasers, thermometers, batteries, hauled wastes, universities, hospitals, laboratories, landfills, Brownfield sites, or raw material storage.



SPDES Number: **NY0031089** Page 9 of 16 v.1.25

DISCHARGE NOTIFICATION REQUIREMENTS

- (a) The permittee shall install and maintain identification signs at all outfalls to surface waters listed in this permit, unless the Permittee has obtained a waiver in accordance with the Discharge Notification Act (DNA). Such signs shall be installed before initiation of any new discharge location.
- (b) Subsequent modifications to or renewal of this permit does not reset or revise the deadline set forth in (a) above, unless a new deadline is set explicitly by such permit modification or renewal.
- (c) The Discharge Notification Requirements described herein do not apply to outfalls from which the discharge is composed exclusively of storm water, or discharges to ground water.
- (d) The sign(s) shall be conspicuous, legible and in as close proximity to the point of discharge as is reasonably possible while ensuring the maximum visibility from the surface water and shore. The signs shall be installed in such a manner to pose minimal hazard to navigation, bathing or other water related activities. If the public has access to the water from the land in the vicinity of the outfall, an identical sign shall be posted to be visible from the direction approaching the surface water.

The signs shall have **minimum** dimensions of eighteen inches by twenty-four inches (18" x 24") and shall have white letters on a green background and contain the following information:

N.Y.S. PERMITTED DISCHARGE POINT
SPDES PERMIT No.: NY
OUTFALL No. :
For information about this permitted discharge contact:
Permittee Name:
Permittee Contact:
Permittee Phone: () - ### - ####
OR:
NYSDEC Division of Water Regional Office Address:
NYSDEC Division of Water Regional Phone: () - ### - ####

- (e) Upon request, the permittee shall make available electronic or hard copies of the sampling data to the public. In accordance with the RECORDING, REPORTING AND ADDITIONAL MONITORING REQUIREMENTS page of your permit, each DMR shall be maintained (either electronically or as a hard copy) on record for a period of five years.
- (f) The permittee shall periodically inspect the outfall identification sign(s) in order to ensure they are maintained, are still visible, and contain information that is current and factually correct. Signs that are damaged or incorrect shall be replaced within 3 months of inspection.

SPDES Number: **NY0031089** Page 10 of 16 v.1.25

MINI INDUSTRIAL PRETREATMENT PROGRAM

The permittee previously performed the actions described in items 1 through 4 below in order to develop a mini pretreatment program:

1. Industrial Survey

The permittee submitted the results of an industrial survey.

2. <u>Develop Procedures</u>

The permittee submitted documentation of procedures for obtaining and ensuring compliance with applicable standards. Such procedures include requirements and schedules for discharge permits, industrial self-monitoring, compliance monitoring of industries by the permittee, on-going POTW monitoring, and an enforcement program. Such procedures are equivalent to procedures described or referenced in the document entitled Introduction to the National Pretreatment Program, USEPA, June, 2011, (https://www3.epa.gov/npdes/pubs/pretreatment program intro 2011.pdf).

3. Treatment Plant/Industry Monitoring

The permittee submitted the results of industrial and POTW monitoring and a completed Fast Report On Significant Industries forms (FROSIs) for all significant industrial users (SIUs).

4. Local Sewer Use Law

The permittee submitted a draft local sewer use law equivalent to the <u>DEC Model Sewer Use Law, NYSDEC, 1994</u>. Local limits for substance capable of causing SPDES permit violations, endangering municipal employees or limiting sludge disposal options were included in the local law. Such limits were developed in accordance with document entitled <u>Local Limits Development Guidance, US EPA, July 2004, EPA 833-R-04-002A</u> (https://nepis.epa.gov/Exe/ZyPURL.cgi?Dockey=300062Q1.txthttps://www.epa.gov/npdes/pubs/pretreatment_local_limits.pdf). After approval by the Department, dated 02/21/1994, the permittee submitted a copy of the enacted Law accompanied by proof of enactment.

Therefore, the permittee shall continue to implement the procedures developed in accordance with 2. above and approved by the Department. At a minimum, the following activities shall continue to be undertaken by the permittee:

- 1. Issue permits including limitations, monitoring requirements, and reporting requirements to its significant industrial users.
- 2. Enforce the local limits set forth in the POTW local sewer use law.
- 3. Carry out inspections and monitoring of significant industrial users to determine compliance with categorical standards and local limits.
- 4. Undertake enforcement actions in accordance with Department approved procedures.

In accordance with the Schedule of Additional Submittals, the permittee shall submit yearly Fast Report On Significant Industries forms (FROSIs) for each SIU to the Department. Every third year, on the same date, the permittee shall submit Industrial Chemical Survey forms completed by all SIUs to the Department. At the same time the permittee shall notify the Department of any proposed significant changes to its implementing procedures or local sewer use law.

SPDES Number: **NY0031089** Page 11 of 16 v.1.25

SCHEDULE OF COMPLIANCE

a) The permittee shall comply with the following schedule:

Outfall(s)	Compliance Action	Compliance Date
001	Total Phosphorus (as P) 12-Month Rolling Total The permittee shall comply with the final 12-Month Rolling Total limit for total phosphorus of 2,050 lbs/yr. The interim limit is in table below.	01/01/2025
001	Total Phosphorus (as P) Monthly Average The permittee shall comply with the final effluent concentration limit for total phosphorus of 1.0 mg/L. This requirement will be monitor only until the limit takes effect.	12/01/2023

Unless noted otherwise, the above actions are one-time requirements. The permittee shall comply with the above compliance actions to the Department's satisfaction once. When this permit is administratively renewed by NYSDEC letter entitled "SPDES NOTICE/RENEWAL APPLICATION/PERMIT" the permittee is not required to repeat the submission(s) noted above. The above due dates are independent from the effective date of the permit stated in the 'SPDES NOICE/RENEWAL APPLICATION/PERMIT' letter.

	INTERIM EFFLUENT LIMIT				Limits Apply	Notes	Interim Limits Expire		
OUTFALL	PARAMETER	Туре	Limit	Units	Limit	Units	Limits Apply	Notes	Interim Limits Expire
001	Phosphorus	See Note 1	2,640	lbs/yr			Year- Round	1, 2	12/31/2024
001	Total Phosphorus	See Note 1	Monitor	mg/L			Year- Round	1	12/01/2023
1. See permit limits tables for sample type and frequency. Notes: 2. See permit footnote on page 5 of this permit for the calculation. 3. Interim limits expire 01/01/2025.									


- b) The permittee shall submit a written notice of compliance or non-compliance form with each of the above schedule dates no later than 14 days following each elapsed date, unless conditions require more immediate notice as prescribed in 6 NYCRR Part 750-1.2(a) and 750-2. All such compliance or non-compliance notifications shall be sent to the locations listed under the section of this permit entitled RECORDING, REPORTING AND ADDITIONAL MONITORING REQUIREMENTS. Each notice of <u>non-compliance</u> shall include the following information:
 - 1. A short description of the non-compliance;
 - 2. A description of any actions taken or proposed by the permittee to comply with the elapsed schedule requirements without further delay and to limit environmental impact associated with the non-compliance;
 - 3. Any details which tend to explain or mitigate an instance of non-compliance; and
 - 4. An estimate of the date the permittee will comply with the elapsed schedule requirement and an assessment of the probability that the permittee will meet the next scheduled requirement on time.
- c) The permittee shall submit copies of any document required by the above schedule of compliance to the NYSDEC Regional Water Engineer and to the Bureau of Water Permits.

MONITORING LOCATIONS

The permittee shall take samples and measurements, to comply with the monitoring requirements specified in this permit, at the locations(s) specified below:

Influent: Prior to the Equalization Tanks

Effluent: After Effluent Disinfection



SPDES Number: NY0031089 Page 13 of 16 v.1.25

GENERAL REQUIREMENTS

A. The regulations in 6 NYCRR Part 750 are hereby incorporated by reference and the conditions are enforceable requirements under this permit. The permittee shall comply with all requirements set forth in this permit and with all the applicable requirements of 6 NYCRR Part 750 incorporated into this permit by reference, including but not limited to the regulations in paragraphs B through I as follows:

B. General Conditions

1.	Duty to comply	6 NYCRR 750-2.1(e) & 2.4
2.	Duty to reapply	6 NYCRR 750-1.16(a)
3.	Need to halt or reduce activity not a defense	6 NYCRR 750-2.1(g)
4.	Duty to mitigate	6 NYCRR 750-2.7(f)
5.	Permit actions	6 NYCRR 750-1.1(c), 1.18, 1.20 & 2.1(h)
6.	Property rights	6 NYCRR 750-2.2(b)
7.	Duty to provide information	6 NYCRR 750-2.1(i)
8.	Inspection and entry	6 NYCRR 750-2.1(a) & 2.3

Operation and Maintenance

1.	Proper Operation & Maintenance	6 NYCRR 750-2.8	
2.	Bypass	6 NYCRR 750-1.2(a)(17), 2.8(b) & 2.7	
3.	Upset	6 NYCRR 750-1.2(a)(94) & 2.8(c)	

D. Monitoring and Records

1.	Monitoring and records	6 NYCRR 750-2.5(a)(2), 2.5(a)(6), 2.5(c)(1), 2.5(c)(2), & 2.5(d)
2.	Signatory requirements	6 NYCRR 750-1.8 & 2.5(b)

Reporting Requirements

1.	Reporting requirements	6 NYCRR 750-2.5, 2.7 & 1.17
2.	Anticipated noncompliance	6 NYCRR 750-2.7(a)
3.	Transfers	6 NYCRR 750-1.17
4.	Monitoring reports	6 NYCRR 750-2.5(e)
5.	Compliance schedules	6 NYCRR 750-1.14(d)
6.	24-hour reporting	6 NYCRR 750-2.7(c) & (d)
7.	Other noncompliance	6 NYCRR 750-2.7(e)
8.	Other information	6 NYCRR 750-2.1(f)
9.	Additional conditions applicable to a POTW	6 NYCRR 750-2.9

Planned Changes

- The permittee shall give notice to the Department as soon as possible of planned physical alterations or additions to the permitted facility when:
 - The alteration or addition to the permitted facility may meet any of the criteria for determining whether facility a. is a new source in 40 CFR §122.29(b); or
 - The alteration or addition could significantly change the nature or increase the quantity of pollutants b. discharged. This notification applies to pollutants which are subject either to effluent limitations in the permit, or to notification requirements under 40 CFR §122.42(a)(1); or
 - The alteration or addition results in a significant change in the permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan.

In addition to the Department, the permittee shall submit a copy of this notice to the United States Environmental Protection Agency at the following address: U.S. EPA Region 2, Clean Water Regulatory Branch, 290 Broadway, 24th Floor, New York, NY 10007-1866.

SPDES Number: **NY0031089** Page 14 of 16 v.1.25

GENERAL REQUIREMENTS (continued)

2. Notification Requirement for POTWs

All POTWs shall provide adequate notice to the Department and the USEPA of the following:

- Any new introduction of pollutants into the POTW from an indirect discharger which would be subject to section 301 or 306 of CWA if it were directly discharging those pollutants; or
- b. Any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of issuance of the permit.
- c. For the purposes of this paragraph, adequate notice shall include information on:
 - i. the quality and quantity of effluent introduced into the POTW, and
 - ii. any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW.

POTWs shall submit a copy of this notice to the United States Environmental Protection Agency, at the following address:

U.S. EPA Region 2, Clean Water Regulatory Branch, 290 Broadway, 24th Floor, New York, NY 10007-1866

G. Sludge Management

The permittee shall comply with all applicable requirements of 6 NYCRR Part 360.

H. SPDES Permit Program Fee

The permittee shall pay to the Department an annual SPDES permit program fee within 30 days of the date of the first invoice, unless otherwise directed by the Department, and shall comply with all applicable requirements of ECL 72-0602 and 6 NYCRR Parts 480, 481 and 485. Note that if there is inconsistency between the fees specified in ECL 72-0602 and 6 NYCRR Part 485, the ECL 72-0602 fees govern.

I. Water Treatment Chemicals (WTCs)

New or increased use and discharge of a WTC requires prior Department review and authorization. At a minimum, the permittee must notify the Department in writing of its intent to change WTC use by submitting a completed *WTC Notification Form* for each proposed WTC. The Department will review that submittal and determine if a SPDES permit modification is necessary or whether WTC review and authorization may proceed outside of the formal permit administrative process. The majority of WTC authorizations do not require SPDES permit modification. In any event, use and discharge of a WTC shall not proceed without prior authorization from the Department. Examples of WTCs include biocides, coagulants, conditioners, corrosion inhibitors, defoamers, deposit control agents, flocculants, scale inhibitors, sequestrants, and settling aids.

- 1. WTC use shall not exceed the rate explicitly authorized by this permit or otherwise authorized in writing by the Department.
- 2. The permittee shall maintain a logbook of all WTC use, noting for each WTC the date, time, exact location, and amount of each dosage, and, the name of the individual applying or measuring the chemical. The logbook must also document that adequate process controls are in place to ensure that excessive levels of WTCs are not used.
- 3. The permittee shall submit a completed WTC Annual Report Form each year that they use and discharge WTCs. This form shall be submitted in electronic format and attached to either the December DMR or the annual monitoring report required below. The WTC Notification Form and WTC Annual Report Form are available from the Department's website at: http://www.dec.ny.gov/permits/93245.html

SPDES Number: **NY0031089** Page 15 of 16 v.1.25

RECORDING, REPORTING AND ADDITIONAL MONITORING REQUIREMENTS

- A. The monitoring information required by this permit shall be retained for a period of at least five years from the date of the sampling for subsequent inspection by the Department or its designated agent.
- B. <u>Discharge Monitoring Reports (DMRs)</u>: Completed DMR forms shall be submitted for each 1 month reporting period in accordance with the DMR Manual available on Department's website.

DMRs must be submitted electronically using the electronic reporting tool (NetDMR) specified by NYSDEC. Instructions on the use of NetDMR can be found at https://www.dec.ny.gov/chemical/8461.html. Hardcopy paper DMRs will only be accepted if a waiver from the electronic submittal requirements has been granted by DEC to the facility.

Attach the monthly "Wastewater Facility Operation Report" (form 92-15-7) and any required DMR attachments electronically to the DMR or with the hardcopy submittal.

The first monitoring period begins on the effective date of this permit, and, unless otherwise required, the reports are due no later than the 28th day of the month following the end of each monitoring period.

Phone: (518) 402-8111

C. Additional information required to be submitted by this permit shall be summarized and reported to the Regional Water Engineer and Bureau of Water Permits at the following addresses:

Department of Environmental Conservation Division of Water, Bureau of Water Permits 625 Broadway, Albany, New York 12233-3505

Department of Environmental Conservation Regional Water Engineer, Region 7

5786 Widewaters Parkway, Syracuse, NY 13214-1867 Phone: (315) 426-7500

D. Bypass and Sewage Pollutant Right to Know Reporting: In accordance with the Sewage Pollutant Right to Know Act (ECL § 17-0826-a), Publicly Owned Treatment Works (POTWs) are required to notify DEC and Department of Health within two hours of discovery of an untreated or partially treated sewage discharge and to notify the public and adjoining municipalities within four hours of discovery. Information regarding reporting and other requirements of this program may be found on the Department's website. In addition, POTWs are required to provide a five-day incident report and supplemental information to the DEC in accordance with Part 750-2.7(d) by utilizing the Division of Water Report of Noncompliance Event form unless waived by DEC on a case-by-case basis.

E. Schedule of Additional Submittals:

The permittee shall submit as a hardcopy the following information to the Regional Water Engineer and to the Bureau of Water Permits, unless otherwise instructed:

	SCHEDULE OF ADDITIONAL SUBMITTALS			
Outfall(s)	Required Action	Due Date		
001	WATER TREATMENT CHEMICAL (WTC) ANNUAL REPORT FORM The permittee shall submit a completed WTC Annual Report Form each year that Water Treatment Chemicals are used. The form shall be attached to the December DMR.	January 28 th of each year		
001	ANNUAL FLOW CERTIFICATION The permittee shall submit an Annual Flow Certification form each year in accordance with 750-2.9(C)(4). The form shall be attached to the February DMR or submitted through nForm.	February DMR (March 28 th)		

SPDES Number: **NY0031089** Page 16 of 16 v.1.25

SCHEDULE OF ADDITIONAL SUBMITTALS			
Outfall(s)	Required Action	Due Date	
001	MERCURY MINIMIZATION PLAN The permittee must complete and maintain onsite an annual mercury minimization status report in accordance with the requirements of this permit.	Maintained Onsite 12/01/2022 annually thereafter	
001	MINI PRETREATMENT PROGRAM - FROSI Submit completed Fast Report On Significant Industries forms (FROSIs) for each SIU to the Department, or notification letter that no new significant industrial users have been added.	October 28 th of each year	
001	MINI PRETREATMENT PROGRAM – Industrial Chemical Survey (ICS) Forms Submit Industrial Chemical Survey forms completed by all SIUs to the Department. Notify the Department of any proposed significant changes to its implementing procedures or local sewer use law.	October 28 th 2023 and every three years thereafter	

Unless noted otherwise, the above actions are one-time requirements. The permittee shall submit the results of the above actions to the satisfaction of the Department. When this permit is administratively renewed by NYSDEC letter entitled "SPDES NOTICE/RENEWAL APPICATION/PERMIT", the permittee is not required to repeat the above submittals, unless noted otherwise. The above due dates are independent from the effective date of the permit stated in the letter of "SPDES NOTICE/RENEWAL APPLICATION/PERMIT".

- F. Monitoring and analysis shall be conducted using sufficiently sensitive test procedures approved under 40 CFR Part 136, unless other test procedures have been specified in this permit.
- G. More frequent monitoring of the discharge(s), monitoring point(s), or waters of the State than required by the permit, where analysis is performed by a certified laboratory or where such analysis is not required to be performed by a certified laboratory, shall be included in the calculations and recording of the data on the corresponding DMRs.
- H. Calculations which require averaging of measurements shall utilize an arithmetic mean unless otherwise specified in this permit.
- I. Unless otherwise specified, all information recorded on the DMRs shall be based upon measurements and sampling carried out during the most recently completed reporting period.
- J. Any laboratory test or sample analysis required by this permit for which the State Commissioner of Health issues certificates of approval pursuant to section 502 of the Public Health Law shall be conducted by a laboratory which has been issued a certificate of approval. Inquiries regarding laboratory certification should be directed to the New York State Department of Health, Environmental Laboratory Accreditation Program.

Facility: Village of Waverly Sewage Treatment Plant

SPDES Number: NY0031089

USEPA Non-Major/Class 07 Municipal

Date: May 1, 2024 v.1.23 Permit Writer: T.V. Murakami Water Quality Reviewer:

SPDES Permit Fact Sheet Village of Waverly Village of Waverly Sewage Treatment Plant NY0031089



Facility: Village of Waverly Sewage Treatment Plant Permit Writer: T.V. Murakami

SPDES Number: NY0031089

USEPA Non-Major/Class 07 Municipal

Date: May 1, 2024 v.1.23 Permit Writer: T.V. Murakami Water Quality Reviewer:

Summary of Permit Changes

A State Pollutant Discharge Elimination System (SPDES) permittee-initiated permit modification has been drafted for the Village of Waverly Sewage Treatment Plant. The changes to the permit are summarized below:

- Reduced mercury sampling frequency from monthly to semi-annually.
- Added 12-month rolling average limit of 12 ng/L for total mercury.
- Updated Mercury Minimization Program (MMP) Type II for decreased monitoring requirements.

This fact sheet summarizes the information used to determine the effluent limitations (limits) and other conditions contained in the permit. General background information including the regulatory basis for the effluent limitations and other conditions are in the Appendix linked throughout this fact sheet.

Administrative History

7/1/2021

The last full technical review was performed and the SPDES permit became effective with a new five-year term and expiration date of 6/30/2026. The 2021 permit, along with all subsequent modifications, has formed the basis of this permit.

4/9/2024

The Village of Waverly submitted a request to modify the permit to for reduced mercury monitoring requirements. (PIPM)

The Notice of Complete Application, published in the <u>Environmental Notice Bulletin</u> and newspapers, contains information on the public notice process.

Facility Information

This facility is a publicly owned treatment works that receives flow from domestic and industrial users, with effluent consisting of treated sanitary wastewater and process waters. The collection system consists of separate sewers. The facility accepts flow from significant industrial users (SIUs). For more history and information regarding this facility, refer to the previous permit fact sheet.

Existing Effluent Quality

The existing effluent quality was determined from Discharge Monitoring Reports submitted by the permittee for the period 6/30/2020 to 5/31/2021. <u>Appendix Link</u>

Receiving Water Information

The facility discharges via the following outfall:

Outfall No.	SIC Code	Wastewater Type	Receiving Water
001	4952	Treated Sanitary sewage and Process Waters	Cayuta Creek, Class B

Facility: Village of Waverly Sewage Treatment Plant

SPDES Number: NY0031089

USEPA Non-Major/Class 07 Municipal

Permit Requirements

Mercury¹

The multiple discharge variance (MDV) for mercury provides the framework for NYSDEC to require mercury monitoring and mercury minimization programs (MMPs), through SPDES permitting.

Date: May 1, 2024 v.1.23

Water Quality Reviewer:

Permit Writer: T.V. Murakami

The facility is a Class 07 state significant municipal facility located outside the Great Lakes Basin and was previously given permit requirements for the implementation of MMP Type II.

The permit will continue to include a daily max total mercury effluent limitation of 50 ng/L. The existing effluent quality (EEQ) of 0.66 ng/L was calculated from the lognormal 95th percentile of 24 mercury effluent samples collected from 12/31/2021 to 12/31/2023. The maximum reported value was 0.81 ng/L in May 2023.

Consistent with DOW 1.3.10, the permit is being modified to reduce the sampling frequency from monthly to semi-annually. A new 12-month rolling average total mercury effluent limitation equal to 12 ng/L has also been added. The permit language reflects additional reductions in the MMP requirements. <u>Appendix Link</u>

Antidegradation

The permit contains effluent limitations which ensure that the best usages of the receiving waters will be maintained. The Notice of Complete Application published in the Environmental Notice Bulletin contains information on the State Environmental Quality Review (SEQR)² determination. <u>Appendix Link</u>

¹ In accordance with DOW 1.3.10 Mercury – SPDES Permitting & Multiple Discharge Variance (MDV), December 30, 2020.

² As prescribed by 6 NYCRR Part 617

Facility: Village of Waverly Sewage Treatment Plant

SPDES Number: NY0031089

USEPA Non-Major/Class 07 Municipal

Date: May 1, 2024 v.1.23 Permit Writer: T.V. Murakami Water Quality Reviewer:

Appendix: Regulatory and Technical Basis of Permit Authorizations

The Appendix is meant to supplement the fact sheet for multiple types of SPDES permits. Portions of this Appendix may not be applicable to this specific permit.

Regulatory References

The provisions of the permit are based largely upon 40 CFR 122 subpart C and 6 NYCRR Part 750 and include monitoring, recording, reporting, and compliance requirements, as well as general conditions applicable to all SPDES permits. Below are the most common citations for the requirements included in SPDES permits:

- Clean Water Act (CWA) 33 section USC 1251 to 1387
- Environmental Conservation Law (ECL) Articles 17 and 70
- Federal Regulations
 - o 40 CFR, Chapter I, subchapters D, N, and O
- State environmental regulations
 - o 6 NYCRR Part 621
 - o 6 NYCRR Part 750
 - o 6 NYCRR Parts 700 704 Best use and other requirements applicable to water classes
 - o 6 NYCRR Parts 800 941 Classification of individual surface waters
- NYSDEC water program policy, referred to as Technical and Operational Guidance Series (TOGS)
- USEPA Office of Water Technical Support Document for Water Quality-based Toxics Control, March 1991, Appendix E

The following is a quick guide to the references used within the fact sheet:

SPDES Permit Requirements	Regulatory Reference
Anti-backsliding	6 NYCRR 750-1.10(c)
Best Management Practices (BMPS) for CSOs	6 NYCRR 750-2.8(a)(2)
Environmental Benefits Permit Strategy (EBPS)	6 NYCRR 750-1.18, NYS ECL 17-0817(4), TOGS 1.2.2 (revised January 25,2012)
Exceptions for Type I SSO Outfalls (bypass)	6 NYCRR 750-2.8(b)(2), 40 CFR 122.41
Mercury Multiple Discharge Variance	Division of Water Program Policy 1.3.10 (DOW 1.3.10)
Mixing Zone and Critical Water Information	TOGS 1.3.1 & Amendments
PCB Minimization Program	40 CFR Part 132 Appendix F Procedure 8, 6 NYCRR 750-1.13(a) and 750-1.14(f), and TOGS 1.2.1
Pollutant Minimization Program (PMP)	6 NYCRR 750-1.13(a), 750-1.14(f), TOGS 1.2.1
Schedules of Compliance	6 NYCRR 750-1.14
Sewage Pollution Right to Know (SPRTK)	NYS ECL 17-0826-a, 6 NYCRR 750-2.7
State Administrative Procedure Act (SAPA)	State Administrative Procedure Act Section 401(2), 6 NYCRR 621.11(I)
State Environmental Quality Review (SEQR)	6 NYCRR Part 617
USEPA Effluent Limitation Guidelines (ELGs)	40 CFR Parts 405-471
USEPA National CSO Policy	33 USC Section 1342(q)
Whole Effluent Toxicity (WET) Testing	TOGS 1.3.2
General Provisions of a SPDES Permit Department Request for Additional Information	NYCRR 750-2.1(i)

Outfall and Receiving Water Information Existing Effluent Quality

The existing effluent quality is determined from a statistical evaluation of effluent data in accordance with TOGS 1.2.1 and the USEPA Office of Water, <u>Technical Support Document for Water Quality-based Toxics Control</u>, March 1991, Appendix E (TSD). The existing effluent quality is equal to the 95th (monthly average) and 99th (daily maximum) percentiles of the lognormal distribution of existing effluent data. When there are greater than three non-detects, a delta-lognormal distribution is assumed, and delta-lognormal calculations are used to determine the monthly average and daily maximum pollutant concentrations. Statistical calculations are not performed for parameters where there are less than ten data points. If additional data is needed, a monitoring requirement may be specified either through routine monitoring or a short-term high intensity monitoring program.

Facility: Village of Waverly Sewage Treatment Plant

SPDES Number: NY0031089

USEPA Non-Major/Class 07 Municipal

Date: May 1, 2024 v.1.23 Permit Writer: T.V. Murakami Water Quality Reviewer:

Permit Requirements

Basis for Effluent Limitations

Sections 101, 301, 304, 308, 401, 402, and 405 of the CWA and Titles 5, 7, and 8 of Article 17 ECL, as well as their implementing federal and state regulations, and related guidance, provide the basis for the effluent limitations and other conditions in the permit.

Antidegradation Policy

New York State implements the antidegradation portion of the CWA based upon two documents: (1) Organization and Delegation Memorandum #85-40, "Water Quality Antidegradation Policy" (September 9, 1985); and, (2) TOGS 1.3.9, "Implementation of the NYSDEC Antidegradation Policy – Great Lakes Basin (Supplement to Antidegradation Policy dated September 9, 1985) (undated)." The permit for the facility contains effluent limitations which ensure that the existing best usage of the receiving waters will be maintained. To further support the antidegradation policy, SPDES applications have been reviewed in accordance with the State Environmental Quality Review Act (SEQR) as prescribed by 6 NYCRR Part 617.

Mercury

The multiple discharge variance (MDV) for mercury was developed in accordance with 6 NYCRR 702.17(h) "to address widespread standard or guidance value attainment issues including the presence of a ubiquitous pollutant or naturally high levels of a pollutant in a watershed." The first MDV was issued in October 2010, and subsequently revised and reissued in 2015; each subsequent iteration of the MDV is designed to build off the previous version, to make reasonable progress towards the water quality standard (WQS) of 0.7 ng/L dissolved mercury. The MDV is necessary because human-caused conditions or sources of mercury prevent attainment of the WQS and cannot be remedied (i.e., mercury is ubiquitous in New York waters at levels above the WQS and compliance with a water quality based effluent limitation (WQBEL) for mercury cannot be achieved with demonstrated effluent treatment technologies). The Department has determined that the MDV is consistent with the protection of public health, safety, and welfare. During the effective period of this MDV, any increased risks to human health are mitigated by fish consumption advisories issued periodically by the NYSDOH.

All surface water SPDES permittees are eligible for authorization by the MDV provided they meet the requirements specified in DOW 1.3.10.

There have been a number of changes to DOW 1.3.10, December 2020 (e.g., the criteria for mercury sources, the MMP Decision tree, and the MMPs themselves) which could result in less stringent effluent limitations. There are now criteria to determine if a facility has sources of mercury. Additionally, the types of MMPs have been restructured. MMP Type IV is appropriate for facilities that are not sources of mercury. A similar MMP type was not included in the 2010 or 2015 versions of DOW 1.3.10. DOW 1.3.10, Figure 1, is a decision tree, which includes the criteria used to determine if a facility has source of mercury and which MMP is appropriate for a facility.