



Displaying title 40, up to date as of 10/12/2021. Title 40 was last amended 10/12/2021.

## ENHANCED CONTENT - TABLE OF CONTENTS

<b>Part 408</b>	Canned and Preserved Seafood Processing Point Source Category	408.10 – 408.337
<b>Subpart A</b>	Farm-Raised Catfish Processing Subcategory	408.10 – 408.17
§ 408.10	Applicability; description of the farm-raised catfish processing subcategory.	
§ 408.11	Specialized definitions.	
§ 408.12	Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.	
§ 408.13	[Reserved]	
§ 408.14	Pretreatment standards for existing sources.	
§ 408.15	Standards of performance for new sources.	
§ 408.16	Pretreatment standards for new sources.	
§ 408.17	Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).	
<b>Subpart B</b>	Conventional Blue Crab Processing Subcategory	408.20 – 408.27
§ 408.20	Applicability; description of the conventional blue crab processing subcategory.	
§ 408.21	Specialized definitions.	
§ 408.22	Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.	
§ 408.23	[Reserved]	
§ 408.24	Pretreatment standards for existing sources.	
§ 408.25	Standards of performance for new sources.	
§ 408.26	Pretreatment standards for new sources.	
§ 408.27	Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).	
<b>Subpart C</b>	Mechanized Blue Crab Processing Subcategory	408.30 – 408.37
§ 408.30	Applicability; description of the mechanized blue crab processing subcategory.	
§ 408.31	Specialized definitions.	
§ 408.32	Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.	
§ 408.33	[Reserved]	
§ 408.34	Pretreatment standards for existing sources.	
§ 408.35	Standards of performance for new sources.	
§ 408.36	Pretreatment standards for new sources.	
§ 408.37	Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).	
<b>Subpart D</b>	Non-Remote Alaskan Crab Meat Processing Subcategory	408.40 – 408.47
§ 408.40	Applicability; description of the non-remote Alaskan crab meat processing subcategory.	
§ 408.41	Specialized definitions.	
§ 408.42	Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.	
§ 408.43	[Reserved]	
§ 408.44	Pretreatment standards for existing sources.	
§ 408.45	Standards of performance for new sources.	
§ 408.46	Pretreatment standards for new sources.	
§ 408.47	Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).	
<b>Subpart E</b>	Remote Alaskan Crab Meat Processing Subcategory	408.50 – 408.57

**§ 408.50** Applicability; description of the remote Alaskan crab meat processing subcategory.

**§ 408.51** Specialized definitions.

**§ 408.52** Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

*§ 408.53 [Reserved]*

**§ 408.54** Pretreatment standards for existing sources.

**§ 408.55** Standards of performance for new sources.

**§ 408.56** Pretreatment standards for new sources.

**§ 408.57** Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).

**Subpart F** Non-Remote Alaskan Whole Crab and Crab Section Processing Subcategory 408.60 – 408.67

**§ 408.60** Applicability; description of the non-remote Alaskan whole crab and crab section processing subcategory.

**§ 408.61** Specialized definitions.

**§ 408.62** Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

*§ 408.63 [Reserved]*

**§ 408.64** Pretreatment standards for existing sources.

**§ 408.65** Standards of performance for new sources.

**§ 408.66** Pretreatment standards for new sources.

**§ 408.67** Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).

**Subpart G** Remote Alaskan Whole Crab and Crab Section Processing Subcategory 408.70 – 408.77

**§ 408.70** Applicability; description of the remote Alaskan whole crab and crab section processing subcategory.

**§ 408.71** Specialized definitions.

**§ 408.72** Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

*§ 408.73 [Reserved]*

**§ 408.74** Pretreatment standards for existing sources.

**§ 408.75** Standards of performance for new sources.

**§ 408.76** Pretreatment standards for new sources.

**§ 408.77** Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).

**Subpart H** Dungeness and Tanner Crab Processing in the Contiguous States Subcategory 408.80 – 408.87

**§ 408.80** Applicability; description of the dungeness and tanner crab processing in the contiguous States subcategory.

**§ 408.81** Specialized definitions.

**§ 408.82** Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

*§ 408.83 [Reserved]*

**§ 408.84** Pretreatment standards for existing sources.

**§ 408.85** Standards of performance for new sources.

**§ 408.86** Pretreatment standards for new sources.

**§ 408.87** Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).

**Subpart I** Non-Remote Alaskan Shrimp Processing Subcategory 408.90 – 408.97

§ 408.90 Applicability; description of the non-remote Alaskan shrimp processing subcategory.

§ 408.91 Specialized definitions.

§ 408.92 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

§ 408.93 [Reserved]

§ 408.94 Pretreatment standards for existing sources.

§ 408.95 Standards of performance for new sources.

§ 408.96 Pretreatment standards for new sources.

§ 408.97 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).

**Subpart J** Remote Alaskan Shrimp Processing Subcategory 408.100 – 408.107

§ 408.100 Applicability; description of the remote Alaskan shrimp processing subcategory.

§ 408.101 Specialized definitions.

§ 408.102 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

§ 408.103 [Reserved]

§ 408.104 Pretreatment standards for existing sources.

§ 408.105 Standards of performance for new sources.

§ 408.106 Pretreatment standards for new sources.

§ 408.107 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).

**Subpart K** Northern Shrimp Processing in the Contiguous States Subcategory 408.110 – 408.117

§ 408.110 Applicability; description of the Northern shrimp processing in the contiguous States subcategory.

§ 408.111 Specialized definitions.

§ 408.112 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

§ 408.113 [Reserved]

§ 408.114 Pretreatment standards for existing sources.

§ 408.115 Standards of performance for new sources.

§ 408.116 Pretreatment standards for new sources.

§ 408.117 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).

**Subpart L** Southern Non-Breaded Shrimp Processing in the Contiguous States Subcategory 408.120 – 408.127

§ 408.120 Applicability; description of the Southern non-breaded shrimp processing in the contiguous States subcategory.

§ 408.121 Specialized definitions.

§ 408.122 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

§ 408.123 [Reserved]

§ 408.124 Pretreatment standards for existing sources.

§ 408.125 Standards of performance for new sources.

§ 408.126 Pretreatment standards for new sources.

§ 408.127 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).

**Subpart M** Breaded Shrimp Processing in the Contiguous States Subcategory 408.130 – 408.137

**§ 408.130** Applicability; description of the breaded shrimp processing in the contiguous States subcategory.

**§ 408.131** Specialized definitions.

**§ 408.132** Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

*§ 408.133 [Reserved]*

**§ 408.134** Pretreatment standards for existing sources.

**§ 408.135** Standards of performance for new sources.

**§ 408.136** Pretreatment standards for new sources.

**§ 408.137** Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).

**Subpart N** Tuna Processing Subcategory

408.140 – 408.147

**§ 408.140** Applicability; description of the tuna processing subcategory.

**§ 408.141** Specialized definitions.

**§ 408.142** Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

*§ 408.143 [Reserved]*

**§ 408.144** Pretreatment standards for existing sources.

**§ 408.145** Standards of performance for new sources.

**§ 408.146** Pretreatment standards for new sources.

**§ 408.147** Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).

**Subpart O** Fish Meal Processing Subcategory

408.150 – 408.157

**§ 408.150** Applicability; description of the fish meal processing subcategory.

**§ 408.151** Specialized definitions.

**§ 408.152** Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

*§ 408.153 [Reserved]*

**§ 408.154** Pretreatment standards for existing sources.

**§ 408.155** Standards of performance for new sources.

**§ 408.156** Pretreatment standards for new sources.

**§ 408.157** Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).

**Subpart P** Alaskan Hand-Butchered Salmon Processing Subcategory

408.160 – 408.167

**§ 408.160** Applicability; description of the Alaskan hand-butchered salmon processing subcategory.

**§ 408.161** Specialized definitions.

**§ 408.162** Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

*§ 408.163 [Reserved]*

**§ 408.164** Pretreatment standards for existing sources.

**§ 408.165** Standards of performance for new sources.

**§ 408.166** Pretreatment standards for new sources.

**§ 408.167** Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology.

**Subpart Q** Alaskan Mechanized Salmon Processing Subcategory

408.170 – 408.177

§ 408.170 Applicability; description of the Alaskan mechanized salmon processing subcategory.

§ 408.171 Specialized definitions.

§ 408.172 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

§ 408.173 *[Reserved]*

§ 408.174 Pretreatment standards for existing sources.

§ 408.175 Standards of performance for new sources.

§ 408.176 Pretreatment standards for new sources.

§ 408.177 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).

**Subpart R** West Coast Hand-Butchered Salmon Processing Subcategory 408.180 – 408.187

§ 408.180 Applicability; description of the West Coast hand-butchered salmon processing subcategory.

§ 408.181 Specialized definitions.

§ 408.182 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

§ 408.183 *[Reserved]*

§ 408.184 Pretreatment standards for existing sources.

§ 408.185 Standards of performance for new sources.

§ 408.186 Pretreatment standards for new sources.

§ 408.187 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).

**Subpart S** West Coast Mechanized Salmon Processing Subcategory 408.190 – 408.197

§ 408.190 Applicability; description of the West Coast mechanized salmon processing subcategory.

§ 408.191 Specialized definitions.

§ 408.192 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

§ 408.193 *[Reserved]*

§ 408.194 Pretreatment standards for existing sources.

§ 408.195 Standards of performance for new sources.

§ 408.196 Pretreatment standards for new sources.

§ 408.197 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).

**Subpart T** Alaskan Bottom Fish Processing Subcategory 408.200 – 408.207

§ 408.200 Applicability; description of the Alaskan bottom fish processing subcategory.

§ 408.201 Specialized definitions.

§ 408.202 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

§ 408.203 *[Reserved]*

§ 408.204 Pretreatment standards for existing sources.

§ 408.205 Standards of performance for new sources.

§ 408.206 Pretreatment standards for new sources.

§ 408.207 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology.

**Subpart U** Non-Alaskan Conventional Bottom Fish Processing Subcategory 408.210 – 408.217

§ 408.210 Applicability; description of the non-Alaskan conventional bottom fish processing subcategory.

§ 408.211 Specialized definitions.

§ 408.212 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

§ 408.213 *[Reserved]*

§ 408.214 Pretreatment standards for existing sources.

§ 408.215 Standards of performance for new sources.

§ 408.216 Pretreatment standards for new sources.

§ 408.217 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).

**Subpart V** Non-Alaskan Mechanized Bottom Fish Processing Subcategory 408.220 – 408.227

§ 408.220 Applicability; description of the non-Alaskan mechanized bottom fish processing subcategory.

§ 408.221 Specialized definitions.

§ 408.222 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

§ 408.223 *[Reserved]*

§ 408.224 Pretreatment standards for existing sources.

§ 408.225 Standards of performance for new sources.

§ 408.226 Pretreatment standards for new sources.

§ 408.227 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).

**Subpart W** Hand-Shucked Clam Processing Subcategory 408.230 – 408.237

§ 408.230 Applicability; description of the hand-shucked clam processing subcategory.

§ 408.231 Specialized definitions.

§ 408.232 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

§ 408.233 *[Reserved]*

§ 408.234 Pretreatment standards for existing sources.

§ 408.235 Standards of performance for new sources.

§ 408.236 Pretreatment standards for new sources.

§ 408.237 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).

**Subpart X** Mechanized Clam Processing Subcategory 408.240 – 408.247

§ 408.240 Applicability; description of the mechanized clam processing subcategory.

§ 408.241 Specialized definitions.

§ 408.242 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

§ 408.243 *[Reserved]*

§ 408.244 Pretreatment standards for existing sources.

§ 408.245 Standards of performance for new sources.

§ 408.246 Pretreatment standards for new sources.

§ 408.247 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).

**Subpart Y** Pacific Coast Hand-Shucked Oyster Processing Subcategory 408.250 – 408.257

**§ 408.250** Applicability; description of the Pacific Coast hand-shucked oyster processing subcategory.

**§ 408.251** Specialized definitions.

**§ 408.252** Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

*§ 408.253 [Reserved]*

**§ 408.254** Pretreatment standards for existing sources.

**§ 408.255** Standards of performance for new sources.

**§ 408.256** Pretreatment standards for new sources.

**§ 408.257** Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology.

**Subpart Z** Atlantic and Gulf Coast Hand-Shucked Oyster Processing Subcategory 408.260 – 408.267

**§ 408.260** Applicability; description of the Atlantic and Gulf Coast hand-shucked oyster processing subcategory.

**§ 408.261** Specialized definitions.

**§ 408.262** Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

*§ 408.263 [Reserved]*

**§ 408.264** Pretreatment standards for existing sources.

**§ 408.265** Standards of performance for new sources.

**§ 408.266** Pretreatment standards for new sources.

**§ 408.267** Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology.

**Subpart AA** Steamed and Canned Oyster Processing Subcategory 408.270 – 408.277

**§ 408.270** Applicability; description of the steamed and canned oyster processing subcategory.

**§ 408.271** Specialized definitions.

**§ 408.272** Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

*§ 408.273 [Reserved]*

**§ 408.274** Pretreatment standards for existing sources.

**§ 408.275** Standards of performance for new sources.

**§ 408.276** Pretreatment standards for new sources.

**§ 408.277** Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).

**Subpart AB** Sardine Processing Subcategory 408.280 – 408.287

**§ 408.280** Applicability; description of the sardine processing subcategory.

**§ 408.281** Specialized definitions.

**§ 408.282** Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

*§ 408.283 [Reserved]*

**§ 408.284** Pretreatment standards for existing sources.

**§ 408.285** Standards of performance for new sources.

**§ 408.286** Pretreatment standards for new sources.

**§ 408.287** Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).

**Subpart AC** Alaskan Scallop Processing Subcategory 408.290 – 408.297

§ 408.290 Applicability; description of the Alaskan scallop processing subcategory.

§ 408.291 Specialized definitions.

§ 408.292 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

§ 408.293 *[Reserved]*

§ 408.294 Pretreatment standards for existing sources.

§ 408.295 Standards of performance for new sources.

§ 408.296 Pretreatment standards for new sources.

§ 408.297 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology.

**Subpart AD** Non-Alaskan Scallop Processing Subcategory 408.300 – 408.307

§ 408.300 Applicability; description of the non-Alaskan scallop processing subcategory.

§ 408.301 Specialized definitions.

§ 408.302 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

§ 408.303 *[Reserved]*

§ 408.304 Pretreatment standards for existing sources.

§ 408.305 Standards of performance for new sources.

§ 408.306 Pretreatment standards for new sources.

§ 408.307 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology.

**Subpart AE** Alaskan Herring Fillet Processing Subcategory 408.310 – 408.317

§ 408.310 Applicability; description of the Alaskan herring fillet processing subcategory.

§ 408.311 Specialized definitions.

§ 408.312 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

§ 408.313 *[Reserved]*

§ 408.314 Pretreatment standards for existing sources.

§ 408.315 Standards of performance for new sources.

§ 408.316 Pretreatment standards for new sources.

§ 408.317 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).

**Subpart AF** Non-Alaskan Herring Fillet Processing Subcategory 408.320 – 408.327

§ 408.320 Applicability; description of the non-Alaskan herring fillet processing subcategory.

§ 408.321 Specialized definitions.

§ 408.322 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

§ 408.323 *[Reserved]*

§ 408.324 Pretreatment standards for existing sources.

§ 408.325 Standards of performance for new sources.

§ 408.326 Pretreatment standards for new sources.

§ 408.327 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).

**Subpart AG** Abalone Processing Subcategory 408.330 – 408.337



- § 408.330 Applicability; description of the abalone processing subcategory.
- § 408.331 Specialized definitions.
- § 408.332 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.
- § 408.333 [Reserved]
- § 408.334 Pretreatment standards for existing sources.
- § 408.335 Standards of performance for new sources.
- § 408.336 Pretreatment standards for new sources.
- § 408.337 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology.

# Title 40

## PART 408 - CANNED AND PRESERVED SEAFOOD PROCESSING POINT SOURCE CATEGORY

**Authority:** Secs. 301, 304 (b) and (c), 306 (b) and (c), 307(c), of the Federal Water Pollution Control Act, as amended; 33 U.S.C. 1251, 1311, 1314 (b) and (c), 1316 (b) and (c), 1317(c); 86 Stat. 816 *et seq.*, Pub. L. 92-500; 91 Stat. 1567, Pub. L. 95-217.

**Source:** 39 FR 23140, June 26, 1974, unless otherwise noted.

### Subpart A - Farm-Raised Catfish Processing Subcategory

**§ 408.10 Applicability; description of the farm-raised catfish processing subcategory.**

The provisions of this subpart are applicable to discharges resulting from the processing of farm-raised catfish by existing facilities which process more than 1362 kg (3000 lbs) of raw material per day on any day during a calendar year and all new sources.

[40 FR 55780, Dec. 1, 1975]

**§ 408.11 Specialized definitions.**

For the purpose of this subpart:

- (a) Except as provided below, the general definitions, abbreviations and methods of analysis set forth in 40 CFR part 401 shall apply to this subpart.
- (b) The term *oil and grease* shall mean those components of a waste water amenable to measurement by the method described in Methods for Chemical Analysis of Water and Wastes, 1971, Environmental Protection Agency, Analytical Quality Control Laboratory, page 217.
- (c) The term *seafood* shall mean the raw material, including freshwater and saltwater fish and shellfish, to be processed, in the form in which it is received at the processing plant.

**§ 408.12 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.**

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):

Effluent characteristic	Effluent limitations

Effluent characteristic	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kg/kg of seafood)	
TSS	28	9.2
Oil and grease	10	3.4
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (lb/1,000 lb of seafood)	
TSS	28	9.2
Oil and grease	10	3.4
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

[39 FR 23140, June 26, 1974, as amended at 60 FR 33940, June 29, 1995]

#### § 408.13 [Reserved]

#### § 408.14 Pretreatment standards for existing sources.

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a point source subject to the provisions of this subpart.

Pollutant or pollutant property	Pretreatment standard
pH	No limitation.
Oil and grease	Do.
TSS	Do.

[40 FR 6437, Feb. 11, 1975, as amended at 60 FR 33940, June 29, 1995]

#### § 408.15 Standards of performance for new sources.

The following standards of performance establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a new source subject to the provisions of this subpart:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kg/kkg of seafood)	
BOD5	4.6	2.3
TSS	11	5.7
Oil and grease	0.90	0.45
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (lb/1,000 lb of seafood)	
BOD5	4.6	2.3
TSS	11	5.7
Oil and grease	0.90	0.45
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

#### § 408.16 Pretreatment standards for new sources.

Any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403.

[60 FR 33940, June 29, 1995]

#### § 408.17 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT): The limitations shall be the same as those specified for conventional pollutants (which are defined in § 401.16) in § 408.12 of this subpart for the best practicable control technology currently available (BPT).

[51 FR 24997, July 9, 1986]

### Subpart B - Conventional Blue Crab Processing Subcategory

#### § 408.20 Applicability; description of the conventional blue crab processing subcategory.

The provisions of this subpart are applicable to discharges resulting from the processing of blue crab in which manual picking or separation of crab meat from the shell is utilized. The effluent limitations contained in this subpart B are applicable to existing facilities processing more than 1362 kg (3000 lbs) of raw material per day on any day during a calendar year and all new sources.

[40 FR 55780, Dec. 1, 1975]

#### § 408.21 Specialized definitions.

For the purpose of this subpart:

- (a) Except as provided below, the general definitions, abbreviations and methods of analysis set forth in 40 CFR part 401 shall apply to this subpart.
- (b) The term *oil and grease* shall mean those components of a waste water amenable to measurement by the method described in Methods for Chemical Analysis of Water and Wastes, 1971, Environmental Protection Agency, Analytical Quality Control Laboratory, page 217.
- (c) The term *seafood* shall mean the raw material, including freshwater and saltwater fish and shellfish, to be processed, in the form in which it is received at the processing plant.

**§ 408.22 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.**

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kg/kkg of seafood)	
TSS	2.2	0.74
Oil and grease	0.60	0.20
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (lb/1,000 lb of seafood)	
TSS	2.2	0.74
Oil and grease	0.60	0.20
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

[39 FR 23140, June 26, 1974, as amended at 60 FR 33940, June 29, 1995]

**§ 408.23 [Reserved]**

**§ 408.24 Pretreatment standards for existing sources.**

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a point source subject to the provisions of this subpart.

Pollutant or pollutant property	Pretreatment standard
pH	No limitation.
Oil and grease	Do.

Pollutant or pollutant property	Pretreatment standard
TSS	Do.

[40 FR 6438, Feb. 11, 1975, as amended at 60 FR 33940, June 29, 1995]

### § 408.25 Standards of performance for new sources.

The following standards of performance establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a new source subject to the provisions of this subpart:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kg/kkg of seafood)	
BOD5	0.30	0.15
TSS	0.90	0.45
Oil and grease	0.13	0.065
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (lb/1,000 lb of seafood)	
BOD5	0.30	0.15
TSS	0.90	0.45
Oil and grease	0.13	0.065
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

### § 408.26 Pretreatment standards for new sources.

Any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403.

[60 FR 33940, June 29, 1995]

### § 408.27 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT): The limitations shall be the same as those specified for conventional pollutants (which are defined in § 401.16) in § 408.22 of this subpart for the best practicable control technology currently available (BPT).

[51 FR 24997, July 9, 1986]

## Subpart C - Mechanized Blue Crab Processing Subcategory

**§ 408.30 Applicability; description of the mechanized blue crab processing subcategory.**

The provisions of this subpart are applicable to discharges resulting from the processing of blue crab in which mechanical picking or separation of crab meat from the shell is utilized.

[40 FR 55780, Dec. 1, 1975]

**§ 408.31 Specialized definitions.**

For the purpose of this subpart:

- (a) Except as provided below, the general definitions, abbreviations and methods of analysis set forth in 40 CFR part 401 shall apply to this subpart.
- (b) The term *oil and grease* shall mean those components of a waste water amenable to measurement by the method described in Methods for Chemical Analysis of Water and Wastes, 1971, Environmental Protection Agency, Analytical Quality Control Laboratory, page 217.
- (c) The term *seafood* shall mean the raw material, including freshwater and saltwater fish and shellfish, to be processed, in the form in which it is received at the processing plant.

**§ 408.32 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.**

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kg/kkg of seafood)	
TSS	36	12.0
Oil and grease	13	4.2
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (lb/1,000 lb of seafood)	
TSS	36	12.0
Oil and grease	13	4.2
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

[39 FR 23140, June 26, 1974, as amended at 60 FR 33941, June 29, 1995]

**§ 408.33 [Reserved]****§ 408.34 Pretreatment standards for existing sources.**

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a point source subject to the provisions of this subpart.

Pollutant or pollutant property	Pretreatment standard
pH	No limitation.
Oil and grease	Do.
TSS	Do.

[40 FR 6438, Feb. 11, 1975, as amended at 60 FR 33941, June 29, 1995]

#### § 408.35 Standards of performance for new sources.

The following standards of performance establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a new source subject to the provisions of this subpart:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kg/kg of seafood)	
BOD <sub>5</sub>	5.0	2.5
TSS	13	6.3
Oil and grease	2.6	1.3
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (lb/1,000 lb of seafood)	
BOD <sub>5</sub>	5.0	2.5
TSS	13	6.3
Oil and grease	2.6	1.3
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

#### § 408.36 Pretreatment standards for new sources.

Any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403.

[60 FR 33941, June 29, 1995]

#### § 408.37 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT): The limitations shall be the same as those specified for conventional pollutants (which are defined in § 401.16) in § 408.32 of this subpart for the best practicable control technology currently available (BPT).

[51 FR 24997, July 9, 1986]

## Subpart D - Non-Remote Alaskan Crab Meat Processing Subcategory

### § 408.40 Applicability; description of the non-remote Alaskan crab meat processing subcategory.

The provisions of this subpart are applicable to discharges resulting from the processing, in non-remote Alaska, of dungeness, tanner, and king crab meat. The effluent limitations contained in this subpart D are applicable to facilities located in population or processing centers including but not limited to Anchorage, Cordova, Juneau, Ketchikan, Kodiak, and Petersburg.

[40 FR 55780, Dec. 1, 1975]

### § 408.41 Specialized definitions.

For the purpose of this subpart:

- (a) Except as provided below, the general definitions, abbreviations and methods of analysis set forth in 40 CFR part 401 shall apply to this subpart.
- (b) The term *oil and grease* shall mean those components of a waste water amenable to measurement by the method described in Methods for Chemical Analysis of Water and Wastes, 1971, Environmental Protection Agency, Analytical Quality Control Laboratory, page 217.
- (c) The term *seafood* shall mean the raw material, including freshwater and saltwater fish and shellfish, to be processed, in the form in which it is received at the processing plant.

### § 408.42 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kg/kg of seafood)	
TSS	19	6.2
Oil and grease	1.8	0.61
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (lb/1,000 lb of seafood)	
TSS	19	6.2
Oil and grease	1.8	0.61
pH	( <sup>1</sup> )	( <sup>1</sup> )



<sup>1</sup> Within the range 6.0 to 9.0.

[39 FR 23140, June 26, 1974, as amended at 60 FR 33941, June 29, 1995]

### § 408.43 [Reserved]

### § 408.44 Pretreatment standards for existing sources.

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a point source subject to the provisions of this subpart.

Pollutant or pollutant property	Pretreatment standard
pH	No limitation.
Oil and grease	Do.
TSS	Do.

[40 FR 6438, Feb. 11, 1975, as amended at 60 FR 33941, June 29, 1995]

### § 408.45 Standards of performance for new sources.

The following standards of performance establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a new source subject to the provisions of this subpart:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kg/kkg of seafood)	
TSS	16	5.3
Oil and grease	1.6	0.52
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (lb/1,000 lb of seafood)	
TSS	16	5.3
Oil and grease	1.6	0.52
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

### § 408.46 Pretreatment standards for new sources.

Any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403.

[60 FR 33941, June 29, 1995]

### **§ 408.47 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).**

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT): The limitations shall be the same as those specified for conventional pollutants (which are defined in § 401.16) in § 408.42 of this subpart for the best practicable control technology currently available (BPT).

[51 FR 24997, July 9, 1986]

## **Subpart E - Remote Alaskan Crab Meat Processing Subcategory**

### **§ 408.50 Applicability; description of the remote Alaskan crab meat processing subcategory.**

The provisions of this subpart are applicable to discharges resulting from the processing, in remote Alaska, of dungeness, tanner, and king crab meat. The effluent limitations contained in subpart E are applicable to facilities not covered under subpart D.

[40 FR 55780, Dec. 1, 1975]

### **§ 408.51 Specialized definitions.**

For the purpose of this subpart:

- (a) Except as provided below, the general definitions, abbreviations and methods of analysis set forth in 40 CFR part 401 shall apply to this subpart.
- (b) The term *oil and grease* shall mean those components of a waste water amenable to measurement by the method described in Methods for Chemical Analysis of Water and Wastes, 1971, Environmental Protection Agency, Analytical Quality Control Laboratory, page 217.
- (c) The term *seafood* shall mean the raw material, including freshwater and saltwater fish and shellfish, to be processed, in the form in which it is received at the processing plant.

### **§ 408.52 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.**

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT): No pollutants may be discharged which exceed 1.27 cm (0.5 inch) in any dimension.

[60 FR 33941, June 29, 1995]

### **§ 408.53 [Reserved]**

### **§ 408.54 Pretreatment standards for existing sources.**

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a point source subject to the provisions of this subpart.

Pollutant or pollutant property	Pretreatment standard
pH	No limitation.

Pollutant or pollutant property	Pretreatment standard
Oil and grease	Do.
TSS	Do.

[40 FR 6438, Feb. 11, 1975, as amended at 60 FR 33941, June 29, 1995]

#### **§ 408.55 Standards of performance for new sources.**

The following standards of performance establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a new source subject to the provisions of this subpart: No pollutants may be discharged which exceed 1.27 cm (0.5 inch) in any dimension.

[40 FR 55780, Dec. 1, 1975]

#### **§ 408.56 Pretreatment standards for new sources.**

Any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403.

[60 FR 33941, June 29, 1995]

#### **§ 408.57 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).**

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT): The limitations shall be the same as those specified for conventional pollutants (which are defined in § 401.16) in § 408.52 of this subpart for the best practicable control technology currently available (BPT).

[51 FR 24997, July 9, 1986]

### **Subpart F - Non-Remote Alaskan Whole Crab and Crab Section Processing Subcategory**

#### **§ 408.60 Applicability; description of the non-remote Alaskan whole crab and crab section processing subcategory.**

The provisions of this subpart are applicable to discharges resulting from the processing, in non-remote Alaska, of dungeness, tanner and king whole crab and crab sections. The effluent limitations contained in this subpart F are applicable to facilities located in population or processing centers including but not limited to Anchorage, Cordova, Juneau, Ketchikan, Kodiak, and Petersburg.

[40 FR 55780, Dec. 1, 1975]

#### **§ 408.61 Specialized definitions.**

For the purpose of this subpart:

- (a) Except as provided below, the general definitions, abbreviations and methods of analysis set forth in 40 CFR part 401 shall apply to this subpart.
- (b) The term *oil and grease* shall mean those components of a waste water amenable to measurement by the method described in Methods for Chemical Analysis of Water and Wastes, 1971, Environmental Protection Agency, Analytical Quality Control Laboratory, page 217.

- (c) The term *seafood* shall mean the raw material, including freshwater and saltwater fish and shellfish, to be processed, in the form in which it is received at the processing plant.

**§ 408.62 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.**

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
Metric units (kg/kg of seafood)		
TSS	12	12
Oil and grease	1.3	0.42
pH	( <sup>1</sup> )	( <sup>1</sup> )
English units (lb/1,000 lb of seafood)		
TSS	12	3.9
Oil and grease	1.3	0.42
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

[39 FR 23140, June 26, 1974, as amended at 60 FR 33941, June 29, 1995]

**§ 408.63 [Reserved]**

**§ 408.64 Pretreatment standards for existing sources.**

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a point source subject to the provisions of this subpart.

Pollutant or pollutant property	Pretreatment standard
pH	No limitation.
Oil and grease	Do.
TSS	Do.

[40 FR 6438, Feb. 11, 1975, as amended at 60 FR 33941, June 29, 1995]

**§ 408.65 Standards of performance for new sources.**

The following standards of performance establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a new source subject to the provisions of this subpart:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kg/kg of seafood -	
TSS	9.9	3.3
Oil and grease	1.1	0.36
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (lb/1,000 lb of seafood)	
TSS	9.9	3.3
Oil and grease	1.1	0.36
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

#### § 408.66 Pretreatment standards for new sources.

Any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403.

[60 FR 33941, June 29, 1995]

#### § 408.67 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT): The limitations shall be the same as those specified for conventional pollutants (which are defined in § 401.16) in § 408.62 of this subpart for the best practicable control technology currently available (BPT).

[51 FR 24997, July 9, 1986]

### Subpart G - Remote Alaskan Whole Crab and Crab Section Processing Subcategory

#### § 408.70 Applicability; description of the remote Alaskan whole crab and crab section processing subcategory.

The provisions of this subpart are applicable to discharges resulting from the processing, in remote Alaska, of dungeness, tanner, and king whole crab and crab sections. The effluent limitations contained in this subpart G are applicable to facilities not covered under subpart F of this part.

[40 FR 55780, Dec. 1, 1975]

#### § 408.71 Specialized definitions.

For the purpose of this subpart:

- (a) Except as provided below, the general definitions, abbreviations and methods of analysis set forth in 40 CFR part 401 shall apply to this subpart.
- (b) The term *oil and grease* shall mean those components of a waste water amenable to measurement by the method described in Methods for Chemical Analysis of Water and Wastes, 1971, Environmental Protection Agency, Analytical Quality Control Laboratory, page 217.
- (c) The term *seafood* shall mean the raw material, including freshwater and saltwater fish and shellfish, to be processed, in the form in which it is received at the processing plant.

**§ 408.72 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.**

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT): No pollutants may be discharged which exceed 1.27 cm (0.5 inch) in any dimension.

[60 FR 33941, June 29, 1995]

**§ 408.73 [Reserved]**

**§ 408.74 Pretreatment standards for existing sources.**

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a point source subject to the provisions of this subpart.

Pollutant or pollutant property	Pretreatment standard
pH	No limitation.
Oil and grease	Do.
TSS	Do.

[40 FR 6438, Feb. 11, 1975, as amended at 60 FR 33942, June 29, 1995]

**§ 408.75 Standards of performance for new sources.**

The following standards of performance establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a new source subject to the provisions of this subpart: No pollutants may be discharged which exceed 1.27 cm (0.5 inch) in any dimension.

[40 FR 55780, Dec. 1, 1975]

**§ 408.76 Pretreatment standards for new sources.**

Any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403.

[60 FR 33942, June 29, 1995]

**§ 408.77 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).**

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT): The limitations shall be the same as those specified for conventional pollutants (which are defined in § 401.16) in § 408.72 of this subpart for the best practicable control technology currently available (BPT).

[51 FR 24997, July 9, 1986]

## Subpart H - Dungeness and Tanner Crab Processing in the Contiguous States Subcategory

### § 408.80 Applicability; description of the dungeness and tanner crab processing in the contiguous States subcategory.

The provisions of this subpart are applicable to discharges resulting from the processing of dungeness and tanner crab in the contiguous States.

[40 FR 55780, Dec. 1, 1975]

### § 408.81 Specialized definitions.

For the purpose of this subpart:

- (a) Except as provided below, the general definitions, abbreviations and methods of analysis set forth in 40 CFR part 401 shall apply to this subpart.
- (b) The term *oil and grease* shall mean those components of a waste water amenable to measurement by the method described in Methods for Chemical Analysis of Water and Wastes, 1971, Environmental Protection Agency, Analytical Quality Control Laboratory, page 217.
- (c) The term *seafood* shall mean the raw material, including freshwater and saltwater fish and shellfish, to be processed, in the form in which it is received at the processing plant.

### § 408.82 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kg/kg of seafood)	
TSS	8.1	2.7
Oil and grease	1.8	0.61
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (lb/1,000 lb of seafood)	
TSS	8.1	2.7
Oil and grease	1.8	0.61

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

[39 FR 23140, June 26, 1974, as amended at 60 FR 33942, June 29, 1995]

### § 408.83 [Reserved]

### § 408.84 Pretreatment standards for existing sources.

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a point source subject to the provisions of this subpart.

Pollutant or pollutant property	Pretreatment standard
pH	No limitation.
Oil and grease	Do.
TSS	Do.

[40 FR 6438, Feb. 11, 1975, as amended at 60 FR 33942, June 29, 1995]

### § 408.85 Standards of performance for new sources.

The following standards of performance establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a new source subject to the provisions of this subpart:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kg/kg of seafood)	
BOD5	10	4.1
TSS	1.7	0.69
Oil and grease	0.25	0.10
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (lb/1,000 lb of seafood)	
BOD5	10	4.1
TSS	1.7	0.69



Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
Oil and grease	0.25	0.10
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

#### **§ 408.86 Pretreatment standards for new sources.**

Any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403.

[60 FR 33942, June 29, 1995]

#### **§ 408.87 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).**

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT): The limitations shall be the same as those specified for conventional pollutants (which are defined in § 401.16) in § 408.82 of this subpart for the best practicable control technology currently available (BPT).

[51 FR 24997, July 9, 1986]

### **Subpart I - Non-Remote Alaskan Shrimp Processing Subcategory**

#### **§ 408.90 Applicability; description of the non-remote Alaskan shrimp processing subcategory.**

The provisions of this subpart are applicable to discharges resulting from the processing of shrimp in non-remote Alaska. The effluent limitations contained in this subpart I are applicable to facilities located in population or processing centers including but not limited to Anchorage, Cordova, Juneau, Ketchikan, Kodiak, and Petersburg.

[40 FR 55780, Dec. 1, 1975]

#### **§ 408.91 Specialized definitions.**

For the purpose of this subpart:

- (a) Except as provided below, the general definitions, abbreviations and methods of analysis set forth in 40 CFR part 401 shall apply to this subpart.
- (b) The term *oil and grease* shall mean those components of a waste water amenable to measurement by the method described in Methods for Chemical Analysis of Water and Wastes, 1971, Environmental Protection Agency, Analytical Quality Control Laboratory, page 217.
- (c) The term *seafood* shall mean the raw material, including freshwater and saltwater fish and shellfish, to be processed, in the form in which it is received at the processing plant.

#### **§ 408.92 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.**

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kg/kkg of seafood)	
TSS	320	210
Oil and grease	51	17
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (lb/1,000 lb of seafood)	
TSS	320	210
Oil and grease	51	17
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

[39 FR 23140, June 26, 1974, as amended at 60 FR 33942, June 29, 1995]

#### § 408.93 [Reserved]

#### § 408.94 Pretreatment standards for existing sources.

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a point source subject to the provisions of this subpart.

Pollutant or pollutant property	Pretreatment standard
pH	No limitation.
Oil and grease	Do.
TSS	Do.

[40 FR 6438, Feb. 11, 1975, as amended at 60 FR 33942, June 29, 1995]

#### § 408.95 Standards of performance for new sources.

The following standards of performance establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a new source subject to the provisions of this subpart:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kg/kkg of seafood)	

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
TSS	270	180
Oil and grease	45	15
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (lb/1,000 lb of seafood)	
TSS	270	180
Oil and grease	45	15
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

#### § 408.96 Pretreatment standards for new sources.

Any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403.

[60 FR 33942, June 29, 1995]

#### § 408.97 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT): The limitations shall be the same as those specified for conventional pollutants (which are defined in § 401.16) in § 408.92 of this subpart for the best practicable control technology currently available (BPT).

[51 FR 24997, July 9, 1986]

### Subpart J - Remote Alaskan Shrimp Processing Subcategory

#### § 408.100 Applicability; description of the remote Alaskan shrimp processing subcategory.

The provisions of this subpart are applicable to discharges resulting from the processing of shrimp in remote Alaska. The effluent limitations contained in this subpart J are applicable to facilities not covered under subpart I of this part.

[40 FR 55781, Dec. 1, 1975]

#### § 408.101 Specialized definitions.

For the purpose of this subpart:

- Except as provided below, the general definitions, abbreviations and methods of analysis set forth in 40 CFR part 401 shall apply to this subpart.
- The term *oil and grease* shall mean those components of a waste water amenable to measurement by the method described in Methods for Chemical Analysis of Water and Wastes, 1971, Environmental Protection Agency, Analytical Quality Control Laboratory, page 217.

- (c) The term *seafood* shall mean the raw material, including freshwater and saltwater fish and shellfish, to be processed, in the form in which it is received at the processing plant.

**§ 408.102 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.**

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT): No pollutants may be discharged which exceed 1.27 cm (0.5 inch) in any dimension.

[60 FR 33942, June 29, 1995]

**§ 408.103 [Reserved]**

**§ 408.104 Pretreatment standards for existing sources.**

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a point source subject to the provisions of this subpart.

Pollutant or pollutant property	Pretreatment standard
pH	No limitation.
Oil and grease	Do.
TSS	Do.

[40 FR 6439, Feb. 11, 1975, as amended at 60 FR 33942, June 29, 1995]

**§ 408.105 Standards of performance for new sources.**

The following standards of performance establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a new source subject to the provisions of this subpart: No pollutants may be discharged which exceed 1.27 cm (0.5 inch) in any dimension.

[40 FR 55781, Dec. 1, 1975]

**§ 408.106 Pretreatment standards for new sources.**

Any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403.

[60 FR 33942, June 29, 1995]

**§ 408.107 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).**

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT): The limitations shall be the same as those specified for conventional pollutants (which are defined in § 401.16) in § 408.102 of this subpart for the best practicable control technology currently available (BPT).

[51 FR 24997, July 9, 1986]

## Subpart K - Northern Shrimp Processing in the Contiguous States Subcategory

### § 408.110 Applicability; description of the Northern shrimp processing in the contiguous States subcategory.

The provisions of this subpart are applicable to discharges resulting from the processing of shrimp in the Northern contiguous States, including Washington, Oregon, California, Maine, New Hampshire, and Massachusetts. The effluent limitations contained in this subpart K are applicable to existing facilities processing more than 908 kg (2000 lbs) of raw material per day on any day during a calendar year and all new sources.

[40 FR 55781, Dec. 1, 1975]

### § 408.111 Specialized definitions.

For the purpose of this subpart:

- (a) Except as provided below, the general definitions, abbreviations and methods of analysis set forth in 40 CFR part 401 shall apply to this subpart.
- (b) The term *oil and grease* shall mean those components of a waste water amenable to measurement by the method described in Methods for Chemical Analysis of Water and Wastes, 1971, Environmental Protection Agency, Analytical Quality Control Laboratory, page 217.
- (c) The term *seafood* shall mean the raw material, including freshwater and saltwater fish and shellfish, to be processed, in the form in which it is received at the processing plant.

### § 408.112 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kg/kkg of seafood)	
TSS	160	54
Oil and grease	126	42
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (lb/1,000 lb of seafood)	
TSS	160	54
Oil and grease	126	42
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

[39 FR 23140, June 26, 1974, as amended at 60 FR 33942, June 29, 1995]

### § 408.113 [Reserved]

**§ 408.114 Pretreatment standards for existing sources.**

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a point source subject to the provisions of this subpart.

Pollutant or pollutant property	Pretreatment standard
pH	No limitation.
Oil and grease	Do.
TSS	Do.

[40 FR 6439, Feb. 11, 1975, as amended at 60 FR 33942, June 29, 1995]

**§ 408.115 Standards of performance for new sources.**

The following standards of performance establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a new source subject to the provisions of this subpart:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kg/kkg of seafood)	
BOD5	155	62
TSS	38	15
Oil and grease	14	5.7
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (lb/1,000 lb of seafood)	
BOD5	155	62
TSS	38	15
Oil and grease	14	5.7
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

**§ 408.116 Pretreatment standards for new sources.**

Any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403.

[60 FR 33943, June 29, 1995]

**§ 408.117 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).**

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT): The limitations shall be the same as those specified for conventional pollutants (which are defined in § 401.16) in § 408.112 of this subpart for the best practicable control technology currently available (BPT).

[51 FR 24997, July 9, 1986]

**Subpart L - Southern Non-Breaded Shrimp Processing in the Contiguous States**  
**Subcategory**

**§ 408.120 Applicability; description of the Southern non-breaded shrimp processing in the contiguous States subcategory.**

The provisions of this subpart are applicable to discharges resulting from the processing of non-breaded shrimp in the Southern contiguous States, including North and South Carolina, Georgia, Florida, Alabama, Mississippi, Louisiana, and Texas. The effluent limitations contained in this subpart L are applicable to existing facilities processing more than 908 kg (2000 lbs) of raw material per day on any day during a calendar year and all new sources.

[40 FR 55781, Dec. 1, 1975]

**§ 408.121 Specialized definitions.**

For the purpose of this subpart:

- (a) Except as provided below, the general definitions, abbreviations and methods of analysis set forth in 40 CFR part 401 shall apply to this subpart.
- (b) The term *oil and grease* shall mean those components of a waste water amenable to measurement by the method described in Methods for Chemical Analysis of Water and Wastes, 1971, Environmental Protection Agency, Analytical Quality Control Laboratory, page 217.
- (c) The term *seafood* shall mean the raw material, including freshwater and saltwater fish and shellfish, to be processed, in the form in which it is received at the processing plant.

**§ 408.122 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.**

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kg/kkg of seafood)	
TSS	110	38
Oil and grease	36	12
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (lb/1,000 lb of seafood)	

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
TSS	110	38
Oil and grease	36	12
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

[39 FR 23140, June 26, 1974, as amended at 60 FR 33943, June 29, 1995]

### § 408.123 [Reserved]

### § 408.124 Pretreatment standards for existing sources.

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a point source subject to the provisions of this subpart.

Pollutant or pollutant property	Pretreatment standard
pH	No limitation.
Oil and grease	Do.
TSS	Do.

[40 FR 6439, Feb. 11, 1975, as amended at 60 FR 33943, June 29, 1995]

### § 408.125 Standards of performance for new sources.

The following standards of performance establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a new source subject to the provisions of this subpart:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kg/kkg of seafood)	
BOD5	63	25
TSS	25	10
Oil and grease	4.0	1.6
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (lb/1,000 lb of seafood)	



Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
BOD5	63	25
TSS	25	10
Oil and grease	4.0	1.6
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

#### **§ 408.126 Pretreatment standards for new sources.**

Any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403.

[60 FR 33943, June 29, 1995]

#### **§ 408.127 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).**

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT): The limitations shall be the same as those specified for conventional pollutants (which are defined in § 401.16) in § 408.122 of this subpart for the best practicable control technology currently available (BPT).

[51 FR 24997, July 9, 1986]

### **Subpart M - Breaded Shrimp Processing in the Contiguous States Subcategory**

#### **§ 408.130 Applicability; description of the breaded shrimp processing in the contiguous States subcategory.**

The provisions of this subpart are applicable to discharges resulting from the processing of breaded shrimp in the contiguous States by existing facilities processing more than 908 kg (2000 lbs) of raw material per day on any day during a calendar year and all new sources.

[40 FR 55781, Dec. 1, 1975]

#### **§ 408.131 Specialized definitions.**

For the purpose of this subpart:

- Except as provided below, the general definitions, abbreviations and methods of analysis set forth in 40 CFR part 401 shall apply to this subpart.
- The term *oil and grease* shall mean those components of a waste water amenable to measurement by the method described in Methods for Chemical Analysis of Water and Wastes, 1971, Environmental Protection Agency, Analytical Quality Control Laboratory, page 217.
- The term *seafood* shall mean the raw material, including freshwater and saltwater fish and shellfish, to be processed, in the form in which it is received at the processing plant.

**§ 408.132 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.**

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kg/kkg of seafood)	
TSS	280	93
Oil and grease	36	12
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (lb/1,000 lb of seafood)	
TSS	280	93
Oil and grease	36	12
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

[39 FR 23140, June 26, 1974, as amended at 60 FR 33943, June 29, 1995]

**§ 408.133 [Reserved]**

**§ 408.134 Pretreatment standards for existing sources.**

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a point source subject to the provisions of this subpart.

Pollutant or pollutant property	Pretreatment standard
pH	No limitation.
Oil and grease	Do.
TSS	Do.

[40 FR 6439, Feb. 11, 1975, as amended at 60 FR 33943, June 29, 1995]

**§ 408.135 Standards of performance for new sources.**

The following standards of performance establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a new source subject to the provisions of this subpart:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kg/kkg of seafood)	
BOD5	100	40
TSS	55	22
Oil and grease	3.8	1.5
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (lb/1,000 lb of seafood)	
BOD5	100	40
TSS	55	22
Oil and grease	3.8	1.5
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

#### **§ 408.136 Pretreatment standards for new sources.**

Any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403.

[60 FR 33943, June 29, 1995]

#### **§ 408.137 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).**

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT): The limitations shall be the same as those specified for conventional pollutants (which are defined in § 401.16) in § 408.132 of this subpart for the best practicable control technology currently available (BPT).

[51 FR 24997, July 9, 1986]

### **Subpart N - Tuna Processing Subcategory**

#### **§ 408.140 Applicability; description of the tuna processing subcategory.**

The provisions of this subpart are applicable to discharges resulting from the processing of tuna.

[40 FR 55781, Dec. 1, 1975]

#### **§ 408.141 Specialized definitions.**

For the purpose of this subpart:

- (a) Except as provided below, the general definitions, abbreviations and methods of analysis set forth in 40 CFR part 401 shall apply to this subpart.
- (b) The term *oil and grease* shall mean those components of a waste water amenable to measurement by the method described in Methods for Chemical Analysis of Water and Wastes, 1971, Environmental Protection Agency, Analytical Quality Control Laboratory, page 217.
- (c) The term *seafood* shall mean the raw material, including freshwater and saltwater fish and shellfish, to be processed, in the form in which it is received at the processing plant.

**§ 408.142 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.**

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kg/kkg of seafood)	
TSS	8.3	3.3
Oil and grease	2.1	0.84
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (lb/1,000 lb of seafood)	
TSS	8.3	3.3
Oil and grease	2.1	0.84
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

[39 FR 23140, June 26, 1974, as amended at 44 FR 45945, Aug. 9, 1979; 60 FR 33943, June 29, 1995]

**§ 408.143 [Reserved]**

**§ 408.144 Pretreatment standards for existing sources.**

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a point source subject to the provisions of this subpart.

Pollutant or pollutant property	Pretreatment standard
pH	No limitation.
BOD5	Do.

Pollutant or pollutant property	Pretreatment standard
Oil and grease	Do.

[40 FR 6439, Feb. 11, 1975, as amended at 60 FR 33943, June 29, 1995]

#### § 408.145 Standards of performance for new sources.

The following standards of performance establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a new source subject to the provisions of this subpart:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kg/kkg of seafood)	
BOD5	20	8.1
TSS	7.5	3.0
Oil and grease	1.9	0.76
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (lb/1,000 lb of seafood)	
BOD5	20	8.1
TSS	7.5	3.0
Oil and grease	1.9	0.76
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

#### § 408.146 Pretreatment standards for new sources.

Any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403.

[60 FR 33943, June 29, 1995]

#### § 408.147 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT): The limitations shall be the same as those specified for conventional pollutants (which are defined in § 401.16) in § 408.142 of this subpart for the best practicable control technology currently available (BPT).

[51 FR 24997, July 9, 1986]

### Subpart O - Fish Meal Processing Subcategory

**Source:** 40 FR 55781, Dec. 1, 1975, unless otherwise noted.

### § 408.150 Applicability; description of the fish meal processing subcategory.

The provisions of this subpart are applicable to discharges resulting from the processing of menhaden on the Gulf and Atlantic Coasts and the processing of anchovy on the West Coast into fish meal, oil and solubles.

### § 408.151 Specialized definitions.

For the purpose of this subpart:

- (a) Except as provided below, the general definitions, abbreviations and methods of analysis set forth in part 401 of this chapter shall apply to this subpart.
- (b) The term *seafood* shall mean the raw material, including freshwater and saltwater fish and shellfish, to be processed, in the form in which it is received at the processing plant.

### § 408.152 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):

- (a) Any menhaden or anchovy fish meal reduction facility which utilizes a solubles plant to process stick water or bail water shall meet the following limitations.

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kilograms per 1,000 kg of seafood)	
BOD5	7.0	3.9
TSS	3.7	1.5
Oil and grease	1.4	0.76
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (pounds per 1,000 lb of seafood)	
BOD5	7.0	3.9
TSS	3.7	1.5
Oil and grease	1.4	0.76
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

- (b) Any menhaden or anchovy fish meal reduction facility not covered under § 408.152(a) shall meet the following limitations:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kg/kkg of seafood)	
BOD5	3.5	2.8
TSS	2.6	1.7
Oil and grease	3.2	1.4
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (lb/1,000 lb of seafood)	
BOD5	3.5	2.8
TSS	2.6	1.7
Oil and grease	3.2	1.4
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

[40 FR 55781, Dec. 1, 1975, as amended at 41 FR 31821, July 30, 1976; 60 FR 33943, June 29, 1995]

#### § 408.153 [Reserved]

#### § 408.154 Pretreatment standards for existing sources.

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a point source subject to the provisions of this subpart.

Pollutant or pollutant property	Pretreatment standard
BOD5	No limitation.
TSS	Do.
pH	Do.
Oil and grease	Do.

[40 FR 55781, Dec. 1, 1975, as amended at 60 FR 33943, June 29, 1995]

#### § 408.155 Standards of performance for new sources.

The following standards of performance establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a new source subject to the provisions of this subpart:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kilograms per 1,000 kg of seafood)	
BOD5	6.7	3.8
TSS	3.7	1.5
Oil and grease	1.4	0.76
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (pounds per 1,000 lb of seafood)	
BOD5	6.7	3.8
TSS	3.7	1.5
Oil and grease	1.4	0.76
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

[40 FR 55781, Dec. 1, 1975, as amended at 41 FR 31821, July 30, 1976]

#### § 408.156 Pretreatment standards for new sources.

Any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a new source subject to the provisions of this subpart:

Pollutant or pollutant property	Pretreatment standard
BOD5	No limitation.
TSS	Do.
pH	Do.
Oil and grease	Do.

[40 FR 55781, Dec. 1, 1975, as amended at 60 FR 33944, June 29, 1995]

#### § 408.157 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT): The limitations shall be the same as those specified for conventional pollutants (which are defined in § 401.16) in § 408.152 of this subpart for the best practicable control technology currently available (BPT).

[51 FR 24997, July 9, 1986]



## Subpart P - Alaskan Hand-Butchered Salmon Processing Subcategory

**Source:** 40 FR 55782, Dec. 1, 1975, unless otherwise noted.

### § 408.160 Applicability; description of the Alaskan hand-butchered salmon processing subcategory.

The provisions of this subpart are applicable to discharges resulting from the hand-butchered of salmon in Alaska.

### § 408.161 Specialized definitions.

For the purpose of this subpart:

- (a) Except as provided below, the general definitions, abbreviations and methods of analysis set forth in part 401 of this chapter shall apply to this subpart.
- (b) The term *seafood* shall mean the raw material, including freshwater and saltwater fish and shellfish, to be processed, in the form in which it is received at the processing plant.

### § 408.162 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):

- (a) Any hand-butchered salmon processing facility located in population or processing centers including but not limited to Anchorage, Cordova, Juneau, Ketchikan, Kodiak, and Petersburg shall meet the following limitations:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kilograms per 1,000 kg of seafood)	
TSS	2.6	1.6
Oil and grease	0.31	0.19
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (pounds per 1,000 lb of seafood)	
TSS	2.6	1.6
Oil and grease	0.31	0.19
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

- (b) Any hand-butchered salmon processing facility not covered under § 408.162(a) shall meet the following limitations: No pollutants may be discharged which exceed 1.27 cm (0.5 inch) in any dimension.

[40 FR 55782, Dec. 1, 1975, as amended at 41 FR 31821, July 30, 1976; 60 FR 33944, June 29, 1995]

**§ 408.163 [Reserved]****§ 408.164 Pretreatment standards for existing sources.**

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a point source subject to the provisions of this subpart.

Pollutant or pollutant property	Pretreatment standard
BOD5	No limitation.
TSS	Do.
pH	Do.
Oil and grease	Do.

[40 FR 55781, Dec. 1, 1975, as amended at 60 FR 33944, June 29, 1995]

**§ 408.165 Standards of performance for new sources.**

- (a) The following standards of performance establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a new source subject to the provisions of this subpart:
- (1) Any hand-butchered salmon processing facility located in population or processing centers including but not limited to Anchorage, Cordova, Juneau, Ketchikan, Kodiak, and Petersburg shall meet the following limitations:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kilograms per 1,000 kg of seafood)	
TSS	2.3	1.4
Oil and grease	0.28	0.17
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (pounds per 1,000 lb of seafood)	
TSS	2.3	1.4
Oil and grease	0.28	0.17
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

- (2) Any hand-butchered salmon processing facility not covered under § 408.165(a)(1) shall meet the following limitations: No pollutants may be discharged which exceed 1.27 cm (0.5 inch) in any dimension.

- (b) [Reserved]

[40 FR 55782, Dec. 1, 1975, as amended at 41 FR 31821, July 30, 1976]

**§ 408.166 Pretreatment standards for new sources.**

Any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a new source subject to the provisions of this subpart:

Pollutant or pollutant property	Pretreatment standard
BOD5	No limitation.
TSS	Do.
pH	Do.
Oil and grease	Do.

[40 FR 55781, Dec. 1, 1975, as amended at 60 FR 33944, June 29, 1995]

**§ 408.167 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology.**

- (a) [Reserved]
- (b) Except as provided in §§ 125.30 through 125.32, any hand-butchered salmon processing facility located in population or processing centers including but not limited to Anchorage, Cordova, Juneau, Ketchikan, Kodiak, and Petersburg shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT): The limitations shall be the same as those specified for conventional pollutants (which are defined in § 401.16) in § 408.162(b)(2) of this subpart for the best practicable control technology currently available (BPT).

[51 FR 24998, July 9, 1986]

**Subpart Q - Alaskan Mechanized Salmon Processing Subcategory**

**Source:** 40 FR 55783, Dec. 1, 1975, unless otherwise noted.

**§ 408.170 Applicability; description of the Alaskan mechanized salmon processing subcategory.**

The provisions of this subpart are applicable to discharges resulting from the mechanized butchering of salmon in Alaska.

**§ 408.171 Specialized definitions.**

For the purpose of this subpart:

- (a) Except as provided below, the general definitions, abbreviations and methods of analysis set forth in part 401 of this chapter shall apply to this subpart.
- (b) The term *seafood* shall mean the raw material, including freshwater and saltwater fish and shellfish, to be processed, in the form in which it is received at the processing plant.

**§ 408.172 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.**

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):

- (a) Any mechanized salmon processing facility located in population or processing centers including but not limited to Anchorage, Cordova, Juneau, Ketchikan, Kodiak, and Petersburg shall meet the following limitations:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kilograms per 1,000 kg of seafood)	
TSS	44	26
Oil and grease	29	11
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (pounds per 1,000 lb of seafood)	
TSS	44	26
Oil and grease	29	11
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

- (b) Any mechanized salmon processing facility not covered under § 408.172(a) shall meet the following limitations: No pollutants may be discharged which exceed 1.27 cm (0.5 inch) in any dimension.

[40 FR 55783, Dec. 1, 1975, as amended at 41 FR 31821, July 30, 1976; 60 FR 33944, June 29, 1995]

#### § 408.173 [Reserved]

#### § 408.174 Pretreatment standards for existing sources.

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a point source subject to the provisions of this subpart.

Pollutant or pollutant property	Pretreatment standard
BOD5	No limitation.
TSS	Do.
pH	Do.
Oil and grease	Do.

[40 FR 55783, Dec. 1, 1975, as amended at 60 FR 33944, June 29, 1995]

#### § 408.175 Standards of performance for new sources.

- (a) The following standards of performance establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a new source subject to the provisions of this subpart:

- (1) Any mechanized salmon processing facility located in population or processing centers including but not limited to Anchorage, Cordova, Juneau, Ketchikan, Kodiak, and Petersburg shall meet the following limitations:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kilograms per 1,000 kg of seafood)	
TSS	42	25
Oil and grease	28	10
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (pounds per 1,000 lb of seafood)	
TSS	42	25
Oil and grease	28	10
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

- (2) Any mechanized salmon processing facility not covered under § 408.175(a)(1) shall meet the following limitations:  
No pollutants may be discharged which exceed 1.27 cm (0.5 inch) in any dimension.

(b) [Reserved]

[40 FR 55783, Dec. 1, 1975, as amended at 41 FR 31822, July 30, 1976]

#### § 408.176 Pretreatment standards for new sources.

Any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a new source subject to the provisions of this subpart:

Pollutant or pollutant property	Pretreatment standard
BOD5	No limitation.
TSS	Do.
pH	Do.
Oil and grease	Do.

[40 FR 55783, Dec. 1, 1975, as amended at 60 FR 33944, June 29, 1995]

#### § 408.177 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT): The limitations shall be the same as those specified for conventional pollutants (which are defined in § 401.16) in § 408.172 of this subpart for the best practicable control technology currently available (BPT).

[51 FR 24997, July 9, 1986]

## Subpart R - West Coast Hand-Butchered Salmon Processing Subcategory

**Source:** 40 FR 55784, Dec. 1, 1975, unless otherwise noted.

### § 408.180 Applicability; description of the West Coast hand-butchered salmon processing subcategory.

The provisions of this subpart are applicable to discharges resulting from the hand-butchered of salmon on the West Coast.

### § 408.181 Specialized definitions.

For the purpose of this subpart:

- (a) Except as provided below, the general definitions, abbreviations and methods of analysis set forth in part 401 of this chapter shall apply to this subpart.
- (b) The term *seafood* shall mean the raw material, including freshwater and saltwater fish and shellfish, to be processed, in the form in which it is received at the processing plant.

### § 408.182 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kilograms per 1,000 kg of seafood)	
TSS	2.6	1.6
Oil and grease	0.31	0.19
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (pounds per 1,000 lb of seafood)	
TSS	2.6	1.6
Oil and grease	0.31	0.19
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

[40 FR 55784, Dec. 1, 1975, as amended at 41 FR 31822, July 30, 1976; 60 FR 33944, June 29, 1995]

**§ 408.183 [Reserved]****§ 408.184 Pretreatment standards for existing sources.**

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a point source subject to the provisions of this subpart.

Pollutant or pollutant property	Pretreatment standard
BOD5	No limitation.
TSS	Do.
pH	Do.
Oil and grease	Do.

[40 FR 55784, Dec. 1, 1975, as amended at 60 FR 33944, June 29, 1995]

**§ 408.185 Standards of performance for new sources.**

The following standards of performance establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a new source subject to the provisions of this subpart:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kilograms per 1,000 kg of seafood)	
BOD5	2.7	1.7
TSS	0.70	0.42
Oil and grease	0.045	0.026
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (pounds per 1,000 lb of seafood)	
BOD5	2.7	1.7
TSS	0.70	0.42
Oil and grease	0.045	0.026
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

[40 FR 55784, Dec. 1, 1975, as amended at 41 FR 31822, July 30, 1976]

**§ 408.186 Pretreatment standards for new sources.**

Any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a new source subject to the provisions of this subpart:

Pollutant or pollutant property	Pretreatment standard
BOD5	No limitation.
TSS	Do.
pH	Do.
Oil and grease	Do.

[40 FR 55783, Dec. 1, 1975, as amended at 60 FR 33945, June 29, 1995]

#### **§ 408.187 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).**

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT): The limitations shall be the same as those specified for conventional pollutants (which are defined in § 401.16) in § 408.182 of this subpart for the best practicable control technology currently available (BPT).

[51 FR 24997, July 9, 1986]

### **Subpart S - West Coast Mechanized Salmon Processing Subcategory**

**Source:** 40 FR 55786, Dec. 1, 1975, unless otherwise noted.

#### **§ 408.190 Applicability; description of the West Coast mechanized salmon processing subcategory.**

The provisions of this subpart are applicable to discharges resulting from the mechanized butchering of salmon on the West Coast.

#### **§ 408.191 Specialized definitions.**

For the purpose of this subpart:

- Except as provided below, the general definitions, abbreviations and methods of analysis set forth in part 401 of this chapter shall apply to this subpart.
- The term *seafood* shall mean the raw material, including freshwater and saltwater fish and shellfish, to be processed, in the form in which it is received at the processing plant.

#### **§ 408.192 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.**

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):

Effluent characteristic	Effluent limitations



Effluent characteristic	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kilograms per 1,000 kg of seafood)	
TSS	44	26
Oil and grease	29	11
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (pounds per 1,000 lb of seafood)	
TSS	44	26
Oil and grease	29	11
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

[40 FR 55786, Dec. 1, 1975, as amended at 41 FR 31822, July 30, 1976; 60 FR 33945, June 29, 1995]

#### § 408.193 [Reserved]

#### § 408.194 Pretreatment standards for existing sources.

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a point source subject to the provisions of this subpart.

Pollutant or pollutant property	Pretreatment standard
BOD5	No limitation.
TSS	Do.
pH	Do.
Oil and grease	Do.

[40 FR 55786, Dec. 1, 1975, as amended at 60 FR 33945, June 29, 1995]

#### § 408.195 Standards of performance for new sources.

The following standards of performance establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a new source subject to the provisions of this subpart:

Effluent characteristic	Effluent limitations

Effluent characteristic	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kilograms per 1,000 kg of seafood)	
BOD5	62	38
TSS	13	7.6
Oil and grease	4.2	1.5
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (pounds per 1,000 lb of seafood)	
BOD5	62	38
TSS	13	7.6
Oil and grease	4.2	1.5
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

[40 FR 55786, Dec. 1, 1975, as amended at 41 FR 31822, July 30, 1976]

#### § 408.196 Pretreatment standards for new sources.

Any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a new source subject to the provisions of this subpart:

Pollutant or pollutant property	Pretreatment standard
BOD5	No limitation.
TSS	Do.
pH	Do.
Oil and grease	Do.

[40 FR 55786, Dec. 1, 1975, as amended at 60 FR 33945, June 29, 1995]

#### § 408.197 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT): The limitations shall be the same as those specified for conventional pollutants (which are defined in § 401.16) in § 408.192 of this subpart for the best practicable control technology currently available (BPT).

[51 FR 24997, July 9, 1986]

## Subpart T - Alaskan Bottom Fish Processing Subcategory

**Source:** 40 FR 55787, Dec. 1, 1975, unless otherwise noted.

### § 408.200 Applicability; description of the Alaskan bottom fish processing subcategory.

The provisions of this subpart are applicable to discharges resulting from the processing of bottom fish such as halibut in Alaska.

### § 408.201 Specialized definitions.

For the purpose of this subpart:

- (a) Except as provided below, the general definitions, abbreviations and methods of analysis set forth in part 401 of this chapter shall apply to this subpart.
- (b) The term *seafood* shall mean the raw material, including freshwater and saltwater fish and shellfish, to be processed, in the form in which it is received at the processing plant.

### § 408.202 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):

- (a) Any Alaskan bottom fish processing facility located in population or processing centers including but not limited to Anchorage, Cordova, Juneau, Ketchikan, Kodiak, and Petersburg shall meet the following limitations:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kg/kkg of seafood)	
TSS	3.1	1.9
Oil and grease	4.3	0.56
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (lb/1,000 lb of seafood)	
TSS	3.1	1.9
Oil and grease	4.3	0.56
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

- (b) Any Alaskan bottom-fish processing facility not covered under § 408.202(a) shall meet the following limitations: No pollutants may be discharged which exceed 1.27 cm (0.5 inch) in any dimension.

[40 FR 55787, Dec. 1, 1975, as amended at 60 FR 33945, June 29, 1995]

**§ 408.203 [Reserved]****§ 408.204 Pretreatment standards for existing sources.**

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a point source subject to the provisions of this subpart.

<b>Pollutant or pollutant property</b>	<b>Pretreatment standard</b>
BOD5	No limitation.
TSS	Do.
pH	Do.
Oil and grease	Do.

[40 FR 55787, Dec. 1, 1975, as amended at 60 FR 33945, June 29, 1995]

**§ 408.205 Standards of performance for new sources.**

- (a) The following standards of performance establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a new source subject to the provisions of this subpart:
- (1) Any Alaskan bottom fish processing facility located in population or processing centers including but not limited to Anchorage, Cordova, Juneau, Ketchikan, Kodiak, and Petersburg shall meet the following limitations:

<b>Effluent characteristic</b>	<b>Effluent limitations</b>	
	<b>Maximum for any 1 day</b>	<b>Average of daily values for 30 consecutive days shall not exceed -</b>
	Metric units (kg/kkg of seafood)	
TSS	1.9	1.1
Oil and grease	2.6	0.34
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (lb/1,000 lb of seafood)	
TSS	1.9	1.1
Oil and grease	2.6	0.34
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

- (2) Any Alaskan bottom-fish processing facility not covered under § 408.205(a)(1) shall meet the following limitations:  
No pollutants may be discharged which exceed 1.27 cm (0.5 inch) in any dimension.

- (b) [Reserved]

**§ 408.206 Pretreatment standards for new sources.**

Any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a new source subject to the provisions of this subpart:

Pollutant or pollutant property	Pretreatment standard
BOD5	No limitation.
TSS	Do.
pH	Do.
Oil and grease	Do.

[40 FR 55787, Dec. 1, 1975, as amended at 60 FR 33945, June 29, 1995]

**§ 408.207 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology.**

- (a) [Reserved]
- (b) Except as provided in §§ 125.30 through 125.32, any Alaskan bottom fish processing facility located in population or processing centers including but not limited to Anchorage, Cordova, Juneau, Ketchikan, Kodiak, and Petersburg shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT): The limitations shall be the same as those specified for conventional pollutants (which are defined in § 401.16) in § 408.202(b)(2) of this subpart for the best practicable control technology currently available (BPT).

[51 FR 24998, July 9, 1986]

**Subpart U - Non-Alaskan Conventional Bottom Fish Processing Subcategory**

**Source:** 40 FR 55788, Dec. 1, 1975, unless otherwise noted.

**§ 408.210 Applicability; description of the non-Alaskan conventional bottom fish processing subcategory.**

The provisions of this subpart are applicable to discharges resulting from the processing of bottom fish outside of Alaska in which the unit operations are carried out predominately through manual methods. However, the use of scaling machines and/or skinning machines are considered to be normal practice within this subcategory. The provisions of this subpart apply to the processing of currently, commercially processed species of bottom fish such as flounder, ocean perch, haddock, cod, sea catfish, sole, halibut, and rockfish. These provisions apply to existing facilities processing more than 1816 kg (4000 lbs) of raw material per day on any day during a calendar year and all new sources.

**§ 408.211 Specialized definitions.**

For the purpose of this subpart:

- (a) Except as provided below, the general definitions, abbreviations and methods of analysis set forth in part 401 of this chapter shall apply to this subpart.
- (b) The term *seafood* shall mean the raw material, including freshwater and saltwater fish and shellfish, to be processed, in the form in which it is received at the processing plant.

**§ 408.212 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.**

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kilograms per 1,000 kg of seafood)	
TSS	3.6	2.0
Oil and grease	1.0	0.55
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (pounds per 1,000 lb of seafood)	
TSS	3.6	2.0
Oil and grease	1.0	0.55
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

[40 FR 55788, Dec. 1, 1975, as amended at 41 FR 31822, July 30, 1976; 60 FR 33945, June 29, 1995]

**§ 408.213 [Reserved]**

**§ 408.214 Pretreatment standards for existing sources.**

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a point source subject to the provisions of this subpart.

Pollutant or pollutant property	Pretreatment standard
BOD5	No limitation.
TSS	Do.
pH	Do.
Oil and grease	Do.

[40 FR 55788, Dec. 1, 1975, as amended at 60 FR 33945, June 29, 1995]

**§ 408.215 Standards of performance for new sources.**

The following standards of performance establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a new source subject to the provisions of this subpart:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kilograms per 1,000 kg of seafood)	
BOD5	1.2	0.71
TSS	1.5	0.73
Oil and grease	0.077	0.042
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (pounds per 1,000 lb of seafood)	
BOD5	1.2	0.71
TSS	1.5	0.73
Oil and grease	0.077	0.042
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

[40 FR 55788, Dec. 1, 1975, as amended at 41 FR 31823, July 30, 1976]

#### § 408.216 Pretreatment standards for new sources.

Any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a new source subject to the provisions of this subpart:

Pollutant or pollutant property	Pretreatment standard
BOD5	No limitation.
TSS	Do.
pH	Do.
Oil and grease	Do.

[40 FR 55788, Dec. 1, 1975, as amended at 60 FR 33945, June 29, 1995]

#### § 408.217 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT): The limitations shall be the same as those specified for conventional pollutants (which are defined in § 401.16) in § 408.212 of this subpart for the best practicable control technology currently available (BPT).

[51 FR 24997, July 9, 1986]

## Subpart V - Non-Alaskan Mechanized Bottom Fish Processing Subcategory

**Source:** 40 FR 55789, Dec. 1, 1975, unless otherwise noted.

### § 408.220 Applicability; description of the non-Alaskan mechanized bottom fish processing subcategory.

The provisions of this subpart are applicable to discharges resulting from the processing of bottom fish outside of Alaska in which the unit operations (particularly the butchering and/or filleting operations) are carried out predominately through mechanized methods. The provisions of this subpart apply to the processing of bottom fish such as whiting and croaker.

### § 408.221 Specialized definitions.

For the purpose of this subpart:

- (a) Except as provided below, the general definitions, abbreviations and methods of analysis set forth in part 401 of this chapter shall apply to this subpart.
- (b) The term *seafood* shall mean the raw material, including freshwater and saltwater fish and shellfish, to be processed, in the form in which it is received at the processing plant.

### § 408.222 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kilograms per 1,000 kg of seafood)	
TSS	22	12
Oil and grease	9.9	3.9
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (pounds per 1,000 lb of seafood)	
TSS	22	12
Oil and grease	9.9	3.9
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

[40 FR 55789, Dec. 1, 1975, as amended at 41 FR 31823, July 30, 1976; 60 FR 33946, June 29, 1995]

### § 408.223 [Reserved]

### § 408.224 Pretreatment standards for existing sources.



Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a point source subject to the provisions of this subpart.

Pollutant or pollutant property	Pretreatment standard
BOD5	No limitation.
TSS	Do.
pH	Do.
Oil and grease	Do.

[40 FR 55789, Dec. 1, 1975, as amended at 60 FR 33946, June 29, 1995]

#### § 408.225 Standards of performance for new sources.

The following standards of performance establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a new source subject to the provisions of this subpart:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kilograms per 1,000 kg of seafood)	
BOD5	13	7.5
TSS	5.3	2.9
Oil and grease	1.2	0.47
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (pounds per 1,000 lb of seafood)	
BOD5	13	7.5
TSS	5.3	2.9
Oil and grease	1.2	0.47
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

[40 FR 55789, Dec. 1, 1975, as amended at 41 FR 31823, July 30, 1976]

#### § 408.226 Pretreatment standards for new sources.

Any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a new source subject to the provisions of this subpart:

Pollutant or pollutant property	Pretreatment standard
BOD5	No limitation.
TSS	Do.
pH	Do.
Oil and grease	Do.

[40 FR 55789, Dec. 1, 1975, as amended at 60 FR 33946, June 29, 1995]

#### **§ 408.227 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).**

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT): The limitations shall be the same as those specified for conventional pollutants (which are defined in § 401.16) in § 408.222 of this subpart for the best practicable control technology currently available (BPT).

[51 FR 24997, July 9, 1986]

### **Subpart W - Hand-Shucked Clam Processing Subcategory**

**Source:** 40 FR 55790, Dec. 1, 1975, unless otherwise noted.

#### **§ 408.230 Applicability; description of the hand-shucked clam processing subcategory.**

The provisions of this subpart are applicable to discharges resulting from existing hand-shucked clam processing facilities which process more than 1816 kg (4000 lbs) of raw material per day on any day during a calendar year and all new sources.

#### **§ 408.231 Specialized definitions.**

For the purpose of this subpart:

- (a) Except as provided below, the general definitions, abbreviations and methods of analysis set forth in part 401 of this chapter shall apply to this subpart.
- (b) The term *seafood* shall mean the raw material, including freshwater and saltwater fish and shellfish, to be processed, in the form in which it is received at the processing plant.

#### **§ 408.232 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.**

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kg/kkg of seafood)	

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
TSS	59	18
Oil and grease	0.60	0.23
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (lb/1,000 lb of seafood)	
TSS	59	18
Oil and grease	0.60	0.23
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

[40 FR 55790, Dec. 1, 1975, as amended at 60 FR 33946, June 29, 1995]

#### § 408.233 [Reserved]

#### § 408.234 Pretreatment standards for existing sources.

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a point source subject to the provisions of this subpart.

Pollutant or pollutant property	Pretreatment standard
BOD5	No limitation.
TSS	Do.
pH	Do.
Oil and grease	Do.

[40 FR 55790, Dec. 1, 1975, as amended at 60 FR 33946, June 29, 1995]

#### § 408.235 Standards of performance for new sources.

The following standards of performance establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a new source subject to the provisions of this subpart:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kg/kg of seafood)	

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
TSS	55	17
Oil and grease	0.56	0.21
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (lb/1,000 lb of seafood)	
TSS	55	17
Oil and grease	0.56	0.21
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

#### § 408.236 Pretreatment standards for new sources.

Any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a new source subject to the provisions of this subpart:

Pollutant or pollutant property	Pretreatment standard
BOD5	No limitation.
TSS	Do.
pH	Do.
Oil and grease	Do.

[40 FR 55790, Dec. 1, 1975, as amended at 60 FR 33946, June 29, 1995]

#### § 408.237 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT): The limitations shall be the same as those specified for conventional pollutants (which are defined in § 401.16) in § 408.232 of this subpart for the best practicable control technology currently available (BPT).

[51 FR 24997, July 9, 1986]

### Subpart X - Mechanized Clam Processing Subcategory

**Source:** 40 FR 55791, Dec. 1, 1975, unless otherwise noted.

#### § 408.240 Applicability; description of the mechanized clam processing subcategory.

The provisions of this subpart are applicable to discharges resulting from mechanized clam processing.

### § 408.241 Specialized definitions.

For the purpose of this subpart:

- (a) Except as provided below, the general definitions, abbreviations and methods of analysis set forth in part 401 of this chapter shall apply to this subpart.
- (b) The term *seafood* shall mean the raw material, including freshwater and saltwater fish and shellfish, to be processed, in the form in which it is received at the processing plant.

### § 408.242 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kg/kg of seafood)	
TSS	90	15
Oil and grease	4.2	0.97
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (lb/1,000 lb of seafood)	
TSS	90	15
Oil and grease	4.2	0.97
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

[40 FR 55791, Dec. 1, 1975, as amended at 60 FR 33946, June 29, 1995]

### § 408.243 [Reserved]

### § 408.244 Pretreatment standards for existing sources.

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a point source subject to the provisions of this subpart.

Pollutant or pollutant property	Pretreatment standard
BOD5	No limitation.

Pollutant or pollutant property	Pretreatment standard
TSS	Do.
pH	Do.
Oil and grease	Do.

[40 FR 55791, Dec. 1, 1975, as amended at 60 FR 33946, June 29, 1995]

#### § 408.245 Standards of performance for new sources.

The following standards of performance establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a new source subject to the provisions of this subpart:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kg/kkg of seafood)	
BOD5	15	5.7
TSS	26	4.4
Oil and grease	0.40	0.092
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (lb/1,000 lb of seafood)	
BOD5	15	5.7
TSS	26	4.4
Oil and grease	0.40	0.092
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

#### § 408.246 Pretreatment standards for new sources.

Any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a new source subject to the provisions of this subpart:

Pollutant or pollutant property	Pretreatment standard
BOD5	No limitation.
TSS	Do.
pH	Do.

Pollutant or pollutant property	Pretreatment standard
Oil and grease	Do.

[40 FR 55791, Dec. 1, 1975, as amended at 60 FR 33946, June 29, 1995]

**§ 408.247 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).**

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT): The limitations shall be the same as those specified for conventional pollutants (which are defined in § 401.16) in § 408.242 of this subpart for the best practicable control technology currently available (BPT).

[51 FR 24997, July 9, 1986]

**Subpart Y - Pacific Coast Hand-Shucked Oyster Processing Subcategory**

**Source:** 40 FR 55792, Dec. 1, 1975, unless otherwise noted.

**§ 408.250 Applicability; description of the Pacific Coast hand-shucked oyster processing subcategory.**

The provisions of this subpart are applicable to discharges resulting from existing Pacific Coast handshucked oyster processing facilities which process more than 454 kg (1000 lbs) of product per day on any day during a calendar year and all new sources.

**§ 408.251 Specialized definitions.**

For the purpose of this subpart:

- (a) Except as provided below, the general definitions, abbreviations and methods of analysis set forth in part 401 of this chapter shall apply to this subpart.
- (b) The term *product* shall mean the weight of the oyster meat after shucking.

**§ 408.252 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.**

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kilograms per 1,000 kg of product)	
TSS	47	38
Oil and grease	2.4	1.8
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (pounds per 1,000 lb of product)	

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
TSS	47	38
Oil and grease	2.4	1.8
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

[40 FR 55792, Dec. 1, 1975, as amended at 41 FR 31823, July 30, 1976; 60 FR 33946, June 29, 1995]

### § 408.253 [Reserved]

### § 408.254 Pretreatment standards for existing sources.

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a point source subject to the provisions of this subpart.

Pollutant or pollutant property	Pretreatment standard
BOD5	No limitation.
TSS	Do.
pH	Do.
Oil and grease	Do.

[40 FR 55792, Dec. 1, 1975, as amended at 60 FR 33947, June 29, 1995]

### § 408.255 Standards of performance for new sources.

The following standards of performance establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a new source subject to the provisions of this subpart:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kilograms per 1,000 kg of product)	
TSS	45	36
Oil and grease	2.2	1.7
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (pounds per 1,000 lb of product)	



Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
TSS	45	36
Oil and grease	2.2	1.7
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

[40 FR 55792, Dec. 1, 1975, as amended at 41 FR 31823, July 30, 1976]

#### § 408.256 Pretreatment standards for new sources.

Any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a new source subject to the provisions of this subpart:

Pollutant or pollutant property	Pretreatment standard
BOD5	No limitation.
TSS	Do.
pH	Do.
Oil and grease	Do.

[40 FR 55792, Dec. 1, 1975, as amended at 60 FR 33947, June 29, 1995]

#### § 408.257 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology.

Except as provided in §§ 125.30 through 125.32, the following limitations establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a point source subject to the provisions of this subpart after application of the best conventional pollutant control technology:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for thirty consecutive days shall not exceed -
	Metric units (kilograms per 1,000 kg of product)	
TSS	45	36
Oil and grease	2.2	1.7
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (pounds per 1,000 lb of product)	

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for thirty consecutive days shall not exceed -
TSS	45	36
Oil and grease	2.2	1.7
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

[51 FR 24998, July 9, 1986]

## Subpart Z - Atlantic and Gulf Coast Hand-Shucked Oyster Processing Subcategory

**Source:** 40 FR 55793, Dec. 1, 1975, unless otherwise noted.

### § 408.260 Applicability; description of the Atlantic and Gulf Coast hand-shucked oyster processing subcategory.

The provisions of this subpart are applicable to discharge resulting from existing hand-shucked oyster processing facilities on the Atlantic and Gulf Coasts which process more than 454 kg (1000 lbs) of product per day on any day during a calendar year and all new sources.

### § 408.261 Specialized definitions.

For the purpose of this subpart:

- (a) Except as provided below, the general definitions, abbreviations and methods of analysis set forth in part 401 of this chapter shall apply to this subpart.
- (b) The term *product* shall mean the weight of the oyster meat after shucking.

### § 408.262 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kilograms per 1,000 kg of product)	
TSS	24	16
Oil and grease	1.2	0.81
pH	( <sup>1</sup> )	( <sup>1</sup> )

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	English units (pounds per 1,000 lb of product)	
TSS	24	16
Oil and grease	1.2	0.81
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

[40 FR 55793, Dec. 1, 1975, as amended at 41 FR 31823, July 30, 1976; 60 FR 33947, June 29, 1995]

### § 408.263 [Reserved]

### § 408.264 Pretreatment standards for existing sources.

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a point source subject to the provisions of this subpart.

Pollutant or pollutant property	Pretreatment standard
BOD5	No limitation.
TSS	Do.
pH	Do.
Oil and grease	Do.

[40 FR 55793, Dec. 1, 1975, as amended at 60 FR 33947, June 29, 1995]

### § 408.265 Standards of performance for new sources.

The following standards of performance establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a new source subject to the provisions of this subpart:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kilograms per 1,000 kg of product)	
TSS	23	16
Oil and grease	1.1	0.77
pH	( <sup>1</sup> )	( <sup>1</sup> )

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	English units (pounds per 1,000 lb of product)	
TSS	23	16
Oil and grease	1.1	0.77
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

[40 FR 55793, Dec. 1, 1975, as amended at 41 FR 31824, July 30, 1976]

#### § 408.266 Pretreatment standards for new sources.

Any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a new source subject to the provisions of this subpart:

Pollutant or pollutant property	Pretreatment standard
BOD5	No limitation.
TSS	Do.
pH	Do.
Oil and grease	Do.

[40 FR 55793, Dec. 1, 1975, as amended at 60 FR 33947, June 29, 1995]

#### § 408.267 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology.

Except as provided in §§ 125.30 through 125.32, the following limitations establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a point source subject to the provisions of this subpart after application of the best conventional pollutant control technology:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for thirty consecutive days shall not exceed -
	Metric units (kilograms per 1,000 kg of product)	
TSS	23	16
Oil and grease	1.1	0.77
pH	( <sup>1</sup> )	( <sup>1</sup> )

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for thirty consecutive days shall not exceed -
	English units (pounds per 1,000 lb of product)	
TSS	23	16
Oil and grease	1.1	0.77
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

[51 FR 24998, July 9, 1986]

## Subpart AA - Steamed and Canned Oyster Processing Subcategory

**Source:** 40 FR 55794, Dec. 1, 1975, unless otherwise noted.

### § 408.270 Applicability; description of the steamed and canned oyster processing subcategory.

The provisions of this subpart are applicable to discharges resulting from oysters which are mechanically shucked.

### § 408.271 Specialized definitions.

For the purpose of this subpart:

- (a) Except as provided below, the general definitions, abbreviations and methods of analysis set forth in part 401 of this chapter shall apply to this subpart.
- (b) The term *product* shall mean the weight of the oyster meat after shucking.

### § 408.272 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kg/kg of product)	
TSS	270	190
Oil and grease	2.3	1.7
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (lb/1,000 lb of product)	

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
TSS	270	190
Oil and grease	2.3	1.7
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

[40 FR 55794, Dec. 1, 1975, as amended at 60 FR 33947, June 29, 1995]

#### § 408.273 [Reserved]

#### § 408.274 Pretreatment standards for existing sources.

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a point source subject to the provisions of this subpart.

Pollutant or pollutant property	Pretreatment standard
BOD5	No limitation.
TSS	Do.
pH	Do.
Oil and grease	Do.

[40 FR 55794, Dec. 1, 1975, as amended at 60 FR 33947, June 29, 1995]

#### § 408.275 Standards of performance for new sources.

Except for those steamed and canned oyster processing facilities which utilize air flotation treatment systems to meet the shrimp processing standards of performance for new sources under § 408.115, § 408.125, or § 408.135 and for which standards of performance should be derived on a case-by-case basis, the following standards of performance establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a new source subject to the provisions of this subpart:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kg/kg of product)	
BOD5	67	17
TSS	56	39

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
Oil and grease	0.84	0.42
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (lb/1,000 lb of product)	
BOD5	67	17
TSS	56	39
Oil and grease	0.64	0.42
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

[40 FR 55794, Dec. 1, 1975, as amended at 42 FR 6813, Feb. 4, 1977]

#### § 408.276 Pretreatment standards for new sources.

Any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a new source subject to the provisions of this subpart:

Pollutant or pollutant property	Pretreatment standard
BOD5	No limitation.
TSS	Do.
pH	Do.
Oil and grease	Do.

[40 FR 55794, Dec. 1, 1975, as amended at 60 FR 33947, June 29, 1995]

#### § 408.277 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT): The limitations shall be the same as those specified for conventional pollutants (which are defined in § 401.16) in § 408.272 of this subpart for the best practicable control technology currently available (BPT).

[51 FR 24997, July 9, 1986]

### Subpart AB - Sardine Processing Subcategory

**Source:** 40 FR 55795, Dec. 1, 1975, unless otherwise noted.

**§ 408.280 Applicability; description of the sardine processing subcategory.**

The provisions of this subpart are applicable to discharges resulting from the canning of sardines or sea herring for sardines. These provisions, however, do not cover the relatively new steaking operation in which cutting machines are used for preparing fish steaks.

**§ 408.281 Specialized definitions.**

For the purpose of this subpart:

- (a) Except as provided below, the general definitions, abbreviations and methods of analyses set forth in part 401 of this chapter shall apply to this subpart.
- (b) The term *seafood* shall mean the raw material, including freshwater and saltwater fish and shellfish, to be processed, in the form in which it is received at the processing plant.

**§ 408.282 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.**

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):

- (a) Any sardine processing facility which utilizes dry transportation systems from the fish storage area to the fish processing area shall meet the following limitations:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kg/kkg of seafood)	
TSS	36	10
Oil and grease	3.5	1.4
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (lb/1,000 lb of seafood)	
TSS	36	10
Oil and grease	3.5	1.4
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

- (b) Any sardine processing facility not covered under § 408.282(a) shall meet the following limitations:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kg/kkg of seafood)	



Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
TSS	48	16
Oil and grease	6.3	2.8
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (lb/1,000 lb of seafood)	
TSS	48	16
Oil and grease	6.3	2.8
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

[40 FR 55795, Dec. 1, 1975, as amended at 60 FR 33947, June 29, 1995]

#### § 408.283 [Reserved]

#### § 408.284 Pretreatment standards for existing sources.

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a point source subject to the provisions of this subpart.

Pollutant or pollutant property	Pretreatment standard
BOD5	No limitation.
TSS	Do.
pH	Do.
Oil and grease	Do.

[40 FR 55795, Dec. 1, 1975, as amended at 60 FR 33947, June 29, 1995]

#### § 408.285 Standards of performance for new sources.

The following standards of performance establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a new source subject to the provisions of this subpart:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kg/kg of seafood)	

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
TSS	36	10
Oil and grease	1.4	0.57
pH	( <sup>1</sup> )	( <sup>1</sup> )
English units (lb/1,000 lb of seafood)		
TSS	36	10
Oil and grease	1.4	0.57
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

#### § 408.286 Pretreatment standards for new sources.

Any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a new source subject to the provisions of this subpart:

Pollutant or pollutant property	Pretreatment standard
BOD5	No limitation.
TSS	Do.
pH	Do.
Oil and grease	Do.

[40 FR 55795, Dec. 1, 1975, as amended at 60 FR 33948, June 29, 1995]

#### § 408.287 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT): The limitations shall be the same as those specified for conventional pollutants (which are defined in § 401.16) in § 408.282 of this subpart for the best practicable control technology currently available (BPT).

[51 FR 24997, July 9, 1986]

### Subpart AC - Alaskan Scallop Processing Subcategory

**Source:** 40 FR 55796, Dec. 1, 1975, unless otherwise noted.

#### § 408.290 Applicability; description of the Alaskan scallop processing subcategory.

The provisions of this subpart are applicable to discharges resulting from the processing of scallops in Alaska.

### § 408.291 Specialized definitions.

For the purpose of this subpart:

- (a) Except as provided below, the general definitions, abbreviations and methods of analysis set forth in part 401 of this chapter shall apply to this subpart.
- (b) The term *product* shall mean the weight of the scallop meat after processing.

### § 408.292 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):

- (a) Any Alaskan scallop processing facility located in population or processing centers including but not limited to Anchorage, Cordova, Juneau, Ketchikan, Kodiak, and Petersburg shall meet the following limitations:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kg/kkg of product)	
TSS	6.6	1.4
Oil and grease	7.7	0.24
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (lb/1,000 lb of product)	
TSS	6.0	1.4
Oil and grease	7.7	0.24
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

- (b) Any Alaskan scallop processing facility not covered under § 408.292(a) shall meet the following limitations: No pollutants may be discharged which exceed 1.27 cm. (0.5 inch) in any dimension.

[40 FR 55796, Dec. 1, 1975, as amended at 60 FR 33948, June 29, 1995]

### § 408.293 [Reserved]

### § 408.294 Pretreatment standards for existing sources.

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a point source subject to the provisions of this subpart.

Pollutant or pollutant property	Pretreatment standard
BOD5	No limitation.
TSS	Do.
pH	Do.
Oil and grease	Do.

[40 FR 55796, Dec. 1, 1975, as amended at 60 FR 33948, June 29, 1995]

#### § 408.295 Standards of performance for new sources.

- (a) The following standards of performance establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a new source subject to the provisions of this subpart:
- (1) Any Alaskan scallop processing facility located in population or processing centers including but not limited to Anchorage, Cordova, Juneau, Ketchikan, Kodiak, and Petersburg shall meet the following limitations:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kg/kg of product)	
TSS	5.7	1.4
Oil and grease	7.3	0.23
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (lb/1,000 lb of product)	
TSS	5.7	1.4
Oil and grease	7.3	0.23
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

- (2) Any Alaskan scallop processing facility not covered under § 408.295(a) (1) shall meet the following limitations: No pollutants may be discharged which exceed 1.27 cm (0.5 inch) in any dimension.
- (b) [Reserved]

#### § 408.296 Pretreatment standards for new sources.

Any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a new source subject to the provisions of this subpart:

Pollutant or pollutant property	Pretreatment standard
---------------------------------	-----------------------

Pollutant or pollutant property	Pretreatment standard
BOD5	No limitation.
TSS	Do.
pH	Do.
Oil and grease	Do.

[40 FR 55796, Dec. 1, 1975, as amended at 60 FR 33948, June 29, 1995]

**§ 408.297 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology.**

- (a) [Reserved]
- (b) Except as provided in §§ 125.30 through 125.32, any Alaskan scallop processing facility located in population or processing centers including but not limited to Anchorage, Cordova, Juneau, Ketchikan, Kodiak, and Petersburg shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT): The limitations shall be the same as those specified for conventional pollutants (which are defined in § 401.16) in § 408.292(b)(2) of this subpart for the best practicable control technology currently available (BPT).

[51 FR 24998, July 9, 1986]

**Subpart AD - Non-Alaskan Scallop Processing Subcategory**

**Source:** 40 FR 55797, Dec. 1, 1975, unless otherwise noted.

**§ 408.300 Applicability; description of the non-Alaskan scallop processing subcategory.**

With the exception of land-based processing of calico scallops, the provisions of this subpart are applicable to discharges resulting from the processing of scallops outside of Alaska.

**§ 408.301 Specialized definitions.**

For the purpose of this subpart:

- (a) Except as provided below, the general definitions, abbreviations and methods of analysis set forth in part 401 of this chapter shall apply to this subpart.
- (b) The term *product* shall mean the weight of the scallop meat after processing.

**§ 408.302 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.**

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kg/kkg of product)	
TSS	6.0	1.4
Oil and grease	7.7	0.24
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (lb/1,000 lb of product)	
TSS	6.0	1.4
Oil and grease	7.7	0.24
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

[40 FR 55797, Dec. 1, 1975, as amended at 60 FR 33948, June 29, 1995]

#### § 408.303 [Reserved]

#### § 408.304 Pretreatment standards for existing sources.

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a point source subject to the provisions of this subpart.

Pollutant or pollutant property	Pretreatment standard
BOD5	No limitation.
TSS	Do.
pH	Do.
Oil and grease	Do.

[40 FR 55797, Dec. 1, 1975, as amended at 60 FR 33948, June 29, 1995]

#### § 408.305 Standards of performance for new sources.

The following standards of performance establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a new source subject to the provisions of this subpart:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kg/kg of product)	
TSS	5.7	1.4
Oil and grease	7.3	0.23
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (lb/1,000 lb of product)	
TSS	5.7	1.4
Oil and grease	7.3	0.23
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

#### § 408.306 Pretreatment standards for new sources.

Any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a new source subject to the provisions of this subpart:

Pollutant or pollutant property	Pretreatment standard
BOD5	No limitation.
TSS	Do.
pH	Do.
Oil and grease	Do.

[40 FR 55797, Dec. 1, 1975, as amended at 60 FR 33948, June 29, 1995]

#### § 408.307 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology.

Except as provided in §§ 125.30 through 125.32, the following limitations establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a point source subject to the provisions of this subpart after application of the best conventional pollutant control technology:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for thirty consecutive days shall not exceed -
	Metric units (kg/kg of product)	

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for thirty consecutive days shall not exceed -
TSS	5.7	1.4
Oil and grease	7.3	0.23
pH	( <sup>1</sup> )	( <sup>1</sup> )
English units (pounds per 1,000 lb of product)		
TSS	5.7	1.4
Oil and grease	7.3	0.23
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

[51 FR 24998, July 9, 1986]

## Subpart AE - Alaskan Herring Fillet Processing Subcategory

**Source:** 40 FR 55798, Dec. 1, 1975, unless otherwise noted.

### § 408.310 Applicability; description of the Alaskan herring fillet processing subcategory.

The provisions of this subpart are applicable to discharges resulting from the processing of herring fillets in Alaska.

### § 408.311 Specialized definitions.

For the purpose of this subpart:

- Except as provided below, the general definitions, abbreviations and methods of analysis set forth in part 401 of this chapter shall apply to this subpart.
- The term *seafood* shall mean the raw material, including freshwater and saltwater fish and shellfish, to be processed, in the form in which it is received at the processing plant.

### § 408.312 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):

- Any herring fillet processing facility located in population or processing centers including but not limited to Anchorage, Cordova, Juneau, Ketchikan, Kodiak and Petersburg shall meet the following limitations:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -



Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kg/kkg of seafood)	
TSS	32	24
Oil and grease	27	10
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (lb/1,000 lb of seafood)	
TSS	32	24
Oil and grease	27	10
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

- (b) Any Alaskan herring fillet processing facility not covered under § 408.312(a) shall meet the following limitations: No pollutants may be discharged which exceed 1.27 cm (0.5 inch) in any dimension.

[40 FR 55798, Dec. 1, 1975, as amended at 60 FR 33948, June 29, 1995]

### § 408.313 [Reserved]

### § 408.314 Pretreatment standards for existing sources.

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a point source subject to the provisions of this subpart.

Pollutant or pollutant property	Pretreatment standard
BOD5	No limitation.
TSS	Do.
pH	Do.
Oil and grease	Do.

[40 FR 55798, Dec. 1, 1975, as amended at 60 FR 33948, June 29, 1995]

### § 408.315 Standards of performance for new sources.

- (a) The following standards of performance establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a new source subject to the provisions of this subpart:
- (1) Any herring fillet processing facility located in population or processing centers including but not limited to Anchorage, Cordova, Juneau, Ketchikan, Kodiak and Petersburg shall meet the following limitations:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kg/kkg of seafood)	
TSS	23	18
Oil and grease	20	7.3
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (lb/1,000 lb of seafood)	
TSS	23	18
Oil and grease	20	7.3
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

- (2) Any Alaskan herring fillet processing facility not covered under § 408.315(a)(1) shall meet the following limitations:  
No pollutants may be discharged which exceed 1.27 cm (0.5 inch) in any dimension.

(b) [Reserved]

#### § 408.316 Pretreatment standards for new sources.

Any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a new source subject to the provisions of this subpart:

Pollutant or pollutant property	Pretreatment standard
BOD5	No limitation.
TSS	Do.
pH	Do.
Oil and grease	Do.

[40 FR 55798, Dec. 1, 1975, as amended at 60 FR 33949, June 29, 1995]

#### § 408.317 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT): The limitations shall be the same as those specified for conventional pollutants (which are defined in § 401.16) in § 408.312 of this subpart for the best practicable control technology currently available (BPT).

[51 FR 24997, July 9, 1986]

## Subpart AF - Non-Alaskan Herring Fillet Processing Subcategory

**Source:** 40 FR 55799, Dec. 1, 1975, unless otherwise noted.

### § 408.320 Applicability; description of the non-Alaskan herring fillet processing subcategory.

The provisions of this subpart are applicable to discharges resulting from the processing of herring fillets outside of Alaska.

### § 408.321 Specialized definitions.

For the purpose of this subpart:

- (a) Except as provided below, the general definitions, abbreviations and methods of analysis set forth in part 401 of this chapter shall apply to this subpart.
- (b) The term *seafood* shall mean the raw material, including freshwater and saltwater fish and shellfish, to be processed, in the form in which it is received at the processing plant.

### § 408.322 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kg/kg of seafood)	
TSS	32	24
Oil and grease	27	10
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (lb/1,000 lb of seafood)	
TSS	32	24
Oil and grease	27	10
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

[40 FR 55799, Dec. 1, 1975, as amended at 60 FR 33949, June 29, 1995]

### § 408.323 [Reserved]

### § 408.324 Pretreatment standards for existing sources.

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a point source subject to the provisions of this subpart.

Pollutant or pollutant property	Pretreatment standard
BOD5	No limitation.
TSS	Do.
pH	Do.
Oil and grease	Do.

[40 FR 55799, Dec. 1, 1975, as amended at 60 FR 33949, June 29, 1995]

#### § 408.325 Standards of performance for new sources.

The following standards of performance establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a new source subject to the provisions of this subpart:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kg/kkg of seafood)	
BOD5	16	15
TSS	7.0	5.2
Oil and grease	2.9	1.1
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (lb/1,000 lb of seafood)	
BOD5	16	15
TSS	7.0	5.2
Oil and grease	2.9	1.1
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

#### § 408.326 Pretreatment standards for new sources.

Any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a new source subject to the provisions of this subpart:

Pollutant or pollutant property	Pretreatment standard
BOD5	No limitation.
TSS	Do.
pH	Do.
Oil and grease	Do.

[40 FR 55799, Dec. 1, 1975, as amended at 60 FR 33949, June 29, 1995]

#### **§ 408.327 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).**

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT): The limitations shall be the same as those specified for conventional pollutants (which are defined in § 401.16) in § 408.322 of this subpart for the best practicable control technology currently available (BPT).

[51 FR 24997, July 9, 1986]

### **Subpart AG - Abalone Processing Subcategory**

**Source:** 40 FR 55800, Dec. 1, 1975, unless otherwise noted.

#### **§ 408.330 Applicability; description of the abalone processing subcategory.**

The provisions of this subpart are applicable to discharges resulting from the processing of abalone in the contiguous states.

#### **§ 408.331 Specialized definitions.**

For the purpose of this subpart:

- Except as provided below, the general definitions, abbreviations and methods of analysis set forth in part 401 of this chapter shall apply to this subpart.
- The term *seafood* shall mean the raw material, including freshwater and saltwater fish and shellfish, to be processed, in the form in which it is received at the processing plant.

#### **§ 408.332 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.**

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kg/kkg of seafood)	
TSS	27	15

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
Oil and grease	2.2	1.4
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (lb/1,000 lb of seafood)	
TSS	27	15
Oil and grease	2.2	1.4
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

[40 FR 55800, Dec. 1, 1975, as amended at 60 FR 33949, June 29, 1995]

### § 408.333 [Reserved]

### § 408.334 Pretreatment standards for existing sources.

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a point source subject to the provisions of this subpart.

Pollutant or pollutant property	Pretreatment standard
BOD5	No limitation.
TSS	Do.
pH	Do.
Oil and grease	Do.

[40 FR 55800, Dec. 1, 1975, as amended at 60 FR 33949, June 29, 1995]

### § 408.335 Standards of performance for new sources.

The following standards of performance establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a new source subject to the provisions of this subpart:

Pollutant or pollutant property	Pretreatment standard
BOD5	No limitation.
TSS	Do.
pH	Do.

Pollutant or pollutant property	Pretreatment standard
Oil and grease	Do.

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kg/kkg of seafood)	
TSS	26	14
Oil and grease	2.1	1.3
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (lb/1,000 lb of seafood)	
TSS	26	14
Oil and grease	2.1	1.3
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

#### § 408.336 Pretreatment standards for new sources.

Any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a new source subject to the provisions of this subpart:

Pollutant or pollutant property	Pretreatment standard
BOD5	No limitation.
TSS	Do.
pH	Do.
Oil and grease	Do.

[40 FR 55800, Dec. 1, 1975, as amended at 60 FR 33949, June 29, 1995]

#### § 408.337 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology.

Except as provided in §§ 125.30 through 125.32, the following limitations establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a point source subject to the provisions of this subpart after application of the best conventional pollutant control technology:

Effluent characteristic	Effluent limitations

Effluent characteristic	Maximum for any 1 day	Average of daily values for thirty consecutive days shall not exceed -
	Maximum for any 1 day	Average of daily values for thirty consecutive days shall not exceed -
	Metric units (kg/kkg of seafood)	
TSS	26	14
Oil and grease	21	1.3
pH	( <sup>1</sup> )	( <sup>1</sup> )
	English units (pounds per 1,000 lb of seafood)	
TSS	26	14
Oil and grease	2.1	1.3
pH	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

[51 FR 24999, July 9, 1986]