



Displaying title 40, up to date as of 10/12/2021. Title 40 was last amended 10/12/2021.

ENHANCED CONTENT - TABLE OF CONTENTS

Part 460	Hospital Point Source Category	460.10 – 460.12
Subpart A	Hospital Category	460.10 – 460.12
§ 460.10	Applicability; description of the hospital category.	
§ 460.11	Specialized definitions.	
§ 460.12	Effluent limitations and guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.	
<i>Subpart B [Reserved]</i>		

Title 40

PART 460 - HOSPITAL POINT SOURCE CATEGORY

Authority: Secs. 301, 304 (b) and (c), 360(b), 307 (b) and (c), Federal Water Pollution Control Act, as amended (33 U.S.C. 1251, 1311, 1314 (b) and (c), 1316(b) and 1317 (b) and (c), 86 Stat. 816 *et seq.*; Pub. L. 92-500) (the Act).

Source: 41 FR 18777, May 6, 1976, unless otherwise noted.

Subpart A - Hospital Category

§ 460.10 Applicability; description of the hospital category.

The provisions of this subpart are applicable to discharges resulting from the functional operations of the hospital point source category.

§ 460.11 Specialized definitions.

For the purpose of this subpart:

- (a) Except as provided below, the general definitions, abbreviations and methods of analysis set forth in part 401 of this chapter shall apply to this subpart.
- (b) The term “product” shall mean service resulting from the hospital activity in terms of 1,000 occupied beds.

§ 460.12 Effluent limitations and guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart, shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):

- (a) The following limitations establish the quantity or quality of pollutants or pollutant properties, controlled by this paragraph, which may be discharged from the hospital point source subject to the provisions of this paragraph after application of the best practicable control technology currently available:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed -
	Metric units (kg/1,000 occupied beds)	
BOD ₅	41.0	33.6
TSS	55.6	33.8
pH	(¹)	(¹)
	English units (lb/1,000 occupied beds)	
BOD ₅	90.4	74.0
TSS	122.4	74.5
pH	(¹)	(¹)

¹ Within the range 6.0 to 9.0.

[41 FR 18777, May 6, 1976, as amended at 60 FR 33972, June 29, 1995]

Subpart B [Reserved]